DOCKETED	
Docket Number:	06-AFC-09C
Project Title:	Colusa Generating Station - Compliance
TN #:	232133
Document Title:	Annual and Fourth Quarter 2019 Quarterly Operating Report
Description:	N/A
Filer:	Anwar Ali
Organization:	Pacific Gas & Electric Company
Submitter Role:	Applicant
Submission Date:	2/19/2020 3:22:38 PM
Docketed Date:	2/19/2020

Pacific Gas and Electric Company®

Mailing Address
Pacific Gas and Electric Company
Colusa Generating Station
P.O. Box 398
Maxwell, CA 95955

530.934.9061
Fax: 530.934.9024

CGS20-L-013
January 28, 2020

Mr. Anwar Ali
Compliance Project Manager
California Energy Commission
1516 Ninth Street, MS-2000
Sacramento, CA 95814

Electronically submitted to anwar.ali@energy.ca.gov

Reference: Colusa Generating Station (06-AFC-9)

Subject: Condition of Certification AQSC-9 – Quarterly Operating Reports

Dear Anwar:

Attached is the Fourth Quarter 2019 Operating Report, submitted in accordance with Condition of Certification AQSC-9.

The QOR includes the following attachments:

Attachment 1: Complaints

Attachment 2: Fuel Quality Data

Attachment 3: 40 CFR 60 Section KKKK Information

Attachment 4: Excess Emissions / Downtime Report / EDS / CMS Reports

Attachment 5: Hourly Emissions – VOC

Attachment 6: Hourly Emissions – NOx

Attachment 7: Hourly Emissions – CO

Attachment 8: Hourly Emissions – NH3

Attachment 9: Quarterly / Annual Emissions (Fuel Use, Hours of Operation, and NH3 Injection)

ATTACHMENT 1

Complaints

FCD: AQ-5

Title V: #5

During the fourth quarter of 2019, there were no complaints issued from the public for the Colusa Generating Station. The site continues to be available for inspection by representatives of the CCAPCD.

ATTACHMENT 2
Fuel Quality Data

FCD: AQ-10 & 11
Title V: #17

2019 Monthly Sulfur Content - Colusa Generating Station

All Units in Grains of Sulfur per 100 Standard Cubic Foot

Month	Jan-19	Feb-19	Mar-19	Apr-19	May-19	Jun-19	Jul-19	Aug-19	Sep-19	Oct-19	Nov-19	Dec-19	Avg
Gr/100SCF	0.238	0.189	0.182	0.194	Outage	0.286	0.192	0.209	0.067	0.250	0.286	0.181	0.207

Permit Limits:

0.75 Grains/100SCF per Month (PSD Condition X.I.4); 0.3 Grains/100SCF Annual Average (Title V # 16)

Atmospheric Analysis & Consulting, Inc.

CLIENT : PG&E
PROJECT NAME : Natural Gas Sampling
AAC PROJECT NO. : 191749
REPORT DATE : 10/16/2019

On October 10, 2019, Atmospheric Analysis & Consulting, Inc. received one (1) 1.0-Liter Silonite Canister for Total Reduced Sulfur analysis by ASTM D-5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.	Initial Pressure (mmHg)
CPP-GS-OCT-A	191749-2389	724.5

This analysis is performed in accordance with AAC's Quality Manual. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample.

The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data contained in this hardcopy report.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 5 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 10/09/2019**
PROJECT NO.	**: 191749**	**RECEIVING DATE**	**: 10/10/2019**
MATRIX	**: AIR**	**ANALYSIS DATE**	**: 10/11/2019**
UNITS	**: ppmV**	**REPORT DATE**	**: 10/16/2019**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-OCT-A**
AAC ID	**191749-2389**
Canister Dil. Fac.	**2.1**
Analyte	**Result**
Hydrogen Sulfide	**0.788**
COS / SO2	**0.723**
Methyl Mercaptan	**0.491**
Ethyl Mercaptan	**0.311**
Dimethyl Sulfide	< 0.106
Carbon Disulfide	< 0.106
Isopropyl Mercaptan	< 0.106
tert-Butyl Mercaptan	**0.856**
n-Propyl Mercaptan	< 0.106
Methylethylsulfide	< 0.106
sec-Butyl Mercaptan / Thiophene	< 0.106
iso-Butyl Mercaptan	< 0.106
Diethyl Sulfide	< 0.106
n-Butyl Mercaptan	< 0.106
Dimethyl Disulfide	< 0.106
2-Methylthiophene	< 0.106
3-Methylthiophene	< 0.106
Tetrahydrothiophene	**0.936**
Bromothiophene	< 0.106
Thiophenol	< 0.106
Diethyl Disulfide	< 0.106
Total Unidentified Sulfur	< 0.106
Total Reduced Sulfurs	**3.38**
Total Sulfurs	**4.10**

All compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 10/09/2019**
PROJECT NO.	**: 191749**	**RECEIVING DATE**	**: 10/10/2019**
MATRIX	**: AIR**	**ANALYSIS DATE**	**: 10/11/2019**
UNITS	**: grains/100 dscf**	**REPORT DATE**	**: 10/16/2019**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-OCT-A**
AAC ID	**191749-2389**
Canister Dil. Fac.	**2.1**
Analyte	**Result**
Hydrogen Sulfide	**0.04797**
COS / SO2	**0.04406**
Methyl Mercaptan	**0.02988**
Ethyl Mercaptan	**0.01892**
Dimethyl Sulfide	< 0.00646
Carbon Disulfide	< 0.00646
Isopropyl Mercaptan	< 0.00646
tert-Butyl Mercaptan	**0.05216**
n-Propyl Mercaptan	< 0.00646
Methylethylsulfide	< 0.00646
sec-Butyl Mercaptan / Thiophene	< 0.00646
iso-Butyl Mercaptan	< 0.00646
Diethyl Sulfide	< 0.00646
n-Butyl Mercaptan	< 0.00646
Dimethyl Disulfide	< 0.00646
2-Methylthiophene	< 0.00646
3-Methylthiophene	< 0.00646
Tetrahydrothiophene	**0.05704**
Bromothiophene	< 0.00646
Thiophenol	< 0.00646
Diethyl Disulfide	< 0.00646
Total Unidentified Sulfur	< 0.00646
Total Reduced Sulfurs	**0.20597**
Total Sulfurs	**0.25003**

All compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 10/11/2019
Analyst: DL
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 9/17/2019

Opening Calibration Verification Standard
525.0 ppbV H2S (SS1184)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	6083	528	100.6	1.7
Duplicate	5970	518	98.7	0.2
Triplicate	5888	511	97.4	1.5

Method Blank

Analyte	Result
H_2S	<PQL

Duplicate Analysis **Sample ID** 191755-2425

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	<PQL	<PQL	0.0	0.0

Matrix Spike & Duplicate **Sample ID** 191755-2425 x10

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	<PQL	262.5	240.9	249.9	91.8	95.2	3.7

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	525.0	517.6	98.6

** Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.*
H2S: PQL = 10.0 ppbV, MDL = 0.95 ppbV

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

191749

SAM #										Preparation and Analysis
Client: PG&E Environmental Services			Project Manager: Surinder Sidhu					Date		
Address: 3400 Crow Canyon Road			Telephone Number: 925-866-5245		Email: SKSG@pge.com			Laboratory: AAC Labs		
City: San Ramon	State: CA	Zip: 94583	Site Contacat					Laboratory Phone: 805-650-1642		
Project Number/Name: Natural Gas Sampling			Sampler: Steve North 925-785-3039					Laboratory Fax		
Contract Number, PO Number		Laboratory Contact: Marcus Hueppe - 1534 Eastman Ave. Suite A Ventura CA 93003								

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers Volume	Containers Type	Containers No.	Preservative	Condition on Receipt/Comments	Sulfur ASTM D-5504
CDP-GS-OCT-A		10/9/19	1430	Gas	1 liter	cyl	1	None	2389	X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.COM) and Evan Cavalli (EMCM@PGE.COM)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

1. Relinquished By: Steve North (via UPS)	Date: 10/9/19	Time: 1705	1. Received By	Date	Time
2. Relinquished By	Date	Time	2. Received By	Date	Time
3. Relinquished By	Date	Time	3. Received By: Rudy	Date: 10/10/19	Time: 0957

Comments

1x 60 L can

Atmospheric Analysis & Consulting, Inc.

CLIENT : PG&E
PROJECT NAME : Natural Gas Sampling
AAC PROJECT NO. : 191924
REPORT DATE : 11/18/2019

On November 7, 2019, Atmospheric Analysis & Consulting, Inc. received one (1) 1.0-Liter Silonite Canister for Total Reduced Sulfur analysis by ASTM D-5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-NOV-A	191924-3191	724.3

This analysis is performed in accordance with AAC's Quality Manual. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample.

The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 5 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 11/06/2019**
PROJECT NO.	**: 191924**	**RECEIVING DATE**	**: 11/07/2019**
MATRIX	**: AIR**	**ANALYSIS DATE**	**: 11/11/2019**
UNITS	**: ppmV**	**REPORT DATE**	**: 11/18/2019**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-NOV-A**
AAC ID	**191924-3191**
Canister Dil. Fac.	**2.2**
Analyte	**Result**
Hydrogen Sulfide	**1.12**
COS / SO2	**0.987**
Methyl Mercaptan	**0.288**
Ethyl Mercaptan	**0.129**
Dimethyl Sulfide	**0.189**
Carbon Disulfide	< 0.108
Isopropyl Mercaptan	< 0.108
tert-Butyl Mercaptan	**0.859**
n-Propyl Mercaptan	< 0.108
Methylethylsulfide	< 0.108
sec-Butyl Mercaptan / Thiophene	< 0.108
iso-Butyl Mercaptan	< 0.108
Diethyl Sulfide	< 0.108
n-Butyl Mercaptan	< 0.108
Dimethyl Disulfide	< 0.108
2-Methylthiophene	< 0.108
3-Methylthiophene	< 0.108
Tetrahydrothiophene	**1.14**
Bromothiophene	< 0.108
Thiophenol	< 0.108
Diethyl Disulfide	< 0.108
Total Unidentified Sulfur	< 0.108
Total Reduced Sulfurs	**3.72**
Total Sulfurs	**4.71**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 11/06/2019**
PROJECT NO.	**: 191924**	**RECEIVING DATE**	**: 11/07/2019**
MATRIX	**: AIR**	**ANALYSIS DATE**	**: 11/11/2019**
UNITS	**: grains/100 dscf**	**REPORT DATE**	**: 11/18/2019**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-NOV-A**
AAC ID	**191924-3191**
Canister Dil. Fac.	**2.2**
Analyte	**Result**
Hydrogen Sulfide	**0.06825**
COS / SO2	**0.06012**
Methyl Mercaptan	**0.01755**
Ethyl Mercaptan	**0.00783**
Dimethyl Sulfide	**0.01150**
Carbon Disulfide	< 0.00656
Isopropyl Mercaptan	< 0.00656
tert-Butyl Mercaptan	**0.05229**
n-Propyl Mercaptan	< 0.00656
Methylethylsulfide	< 0.00656
sec-Butyl Mercaptan / Thiophene	< 0.00656
iso-Butyl Mercaptan	< 0.00656
Diethyl Sulfide	< 0.00656
n-Butyl Mercaptan	< 0.00656
Dimethyl Disulfide	< 0.00656
2-Methylthiophene	< 0.00656
3-Methylthiophene	< 0.00656
Tetrahydrothiophene	**0.06929**
Bromothiophene	< 0.00656
Thiophenol	< 0.00656
Diethyl Disulfide	< 0.00656
Total Unidentified Sulfur	< 0.00656
Total Reduced Sulfurs	**0.22671**
Total Sulfurs	**0.28683**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 11/11/2019
Analyst: DL
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 11/11/2019

Opening Calibration Verification Standard

523.0 ppbV H2S (SS1192)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	4111	501	95.7	1.3
Duplicate	4190	510	97.6	0.6
Triplicate	4191	510	97.6	0.6

547.5 ppbV H2S (SS1192)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	4984	533	97.4	1.1
Duplicate	5028	538	98.2	0.2
Triplicate	5102	546	99.7	1.3

535.8 ppbV H2S (SS1192)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	5746	545	101.8	2.4
Duplicate	5511	523	97.6	1.8
Triplicate	5583	530	98.9	0.5

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis Sample ID 191924-3191

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	512.4	530.4	521.4	3.4
MeSH	133.2	134.4	133.8	0.9
DMS	87.9	87.5	87.7	0.4

Matrix Spike & Duplicate Sample ID 191924-3191 x10

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	52.1	261.5	305.7	317.1	97.5	101.1	3.7
MeSH	13.4	273.8	272.6	285.8	94.9	99.5	4.7
DMS	8.8	267.9	280.3	283.3	101.3	102.4	1.1

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	523.0	549.7	105.1
MeSH	547.5	544.9	99.5
DMS	535.8	514.9	96.1

**** Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.***

H2S: PQL = 10.0 ppbV, MDL = 0.95 ppbV
MeSH: PQL = 10.0 ppbV, MDL = 1.40 ppbV
DMS: PQL = 10.0 ppbV, MDL = 1.46 ppbV

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

191924

SAM #										Preparation and Analysis
Client: PG&E Environmental Services			Project Manager: Surinder Sidhu				Date: 11/6/19			
Address: 3400 Crow Canyon Road			Telephone Number: 925-866-5245	Email: SKSG@pge.com			Laboratory: AAC Labs			
City: San Ramon	State: CA	Zip: 94583	Site Contacat				Laboratory Phone: 805-650-1642			
Project Number/Name: Natural Gas Sampling			Sampler: Steve North 925-785-3039				Laboratory Fax			
Contract Number, PO Number	Laboratory Contact: Marcus Hueppe - 1534 Eastman Ave. Suite A Ventura CA 93003									

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Containers: Type	Containers: No.	Preservative	Condition on Receipt/Comments	Sulfur ASTM D-5504
CPP-GS-NOV-A	3191	11/6/19	1530	Gas	1 liter	cyl	1	None		X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.COM) and Evan Cavalli (EMCM@PGE.COM)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

1. Relinquished By: Steve North (Via UPS)	Date: 11/6/19	Time: 1745	1. Received By	Date	Time
2. Relinquished By	Date	Time	2. Received By	Date	Time
3. Relinquished By	Date	Time	3. Received By	Date: 11/7/19	Time: 11:15

Comments

~~2 X 1.0 L~~
2 X 1.0 L

Atmospheric Analysis & Consulting, Inc.

CLIENT : PG&E
PROJECT NAME : Natural Gas Sampling
AAC PROJECT NO. : 192082
REPORT DATE : 12/9/2019

On December 5, 2019, Atmospheric Analysis & Consulting, Inc. received one (1) 1.0-Liter Silonite Canister for Total Reduced Sulfur analysis by ASTM D-5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-DEC-A	192082-3971	717.9

This analysis is performed in accordance with AAC's Quality Manual. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample.

The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 5 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 12/04/2019**
PROJECT NO.	**: 192082**	**RECEIVING DATE**	**: 12/05/2019**
MATRIX	**: AIR**	**ANALYSIS DATE**	**: 12/06/2019**
UNITS	**: ppmV**	**REPORT DATE**	**: 12/09/2019**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-DEC-A**
AAC ID	**192082-3971**
Canister Dil. Fac.	**2.2**
Analyte	**Result**
Hydrogen Sulfide	**0.688**
COS / SO2	**0.710**
Methyl Mercaptan	**0.165**
Ethyl Mercaptan	< 0.110
Dimethyl Sulfide	< 0.110
Carbon Disulfide	< 0.110
Isopropyl Mercaptan	< 0.110
tert-Butyl Mercaptan	**0.644**
n-Propyl Mercaptan	< 0.110
Methylethylsulfide	< 0.110
sec-Butyl Mercaptan / Thiophene	< 0.110
iso-Butyl Mercaptan	< 0.110
Diethyl Sulfide	< 0.110
n-Butyl Mercaptan	< 0.110
Dimethyl Disulfide	< 0.110
2-Methylthiophene	< 0.110
3-Methylthiophene	< 0.110
Tetrahydrothiophene	**0.642**
Bromothiophene	< 0.110
Thiophenol	< 0.110
Diethyl Disulfide	< 0.110
Total Unidentified Sulfur	**0.130**
Total Reduced Sulfurs	**2.27**
Total Sulfurs	**2.98**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 12/04/2019**
PROJECT NO.	**: 192082**	**RECEIVING DATE**	**: 12/05/2019**
MATRIX	**: AIR**	**ANALYSIS DATE**	**: 12/06/2019**
UNITS	**: grains/100 dscf**	**REPORT DATE**	**: 12/09/2019**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-DEC-A**
AAC ID	**192082-3971**
Canister Dil. Fac.	**2.2**
Analyte	**Result**
Hydrogen Sulfide	**0.04193**
COS / SO2	**0.04327**
Methyl Mercaptan	**0.01005**
Ethyl Mercaptan	< 0.00670
Dimethyl Sulfide	< 0.00670
Carbon Disulfide	< 0.00670
Isopropyl Mercaptan	< 0.00670
tert-Butyl Mercaptan	**0.03925**
n-Propyl Mercaptan	< 0.00670
Methylethylsulfide	< 0.00670
sec-Butyl Mercaptan / Thiophene	< 0.00670
iso-Butyl Mercaptan	< 0.00670
Diethyl Sulfide	< 0.00670
n-Butyl Mercaptan	< 0.00670
Dimethyl Disulfide	< 0.00670
2-Methylthiophene	< 0.00670
3-Methylthiophene	< 0.00670
Tetrahydrothiophene	**0.03912**
Bromothiophene	< 0.00670
Thiophenol	< 0.00670
Diethyl Disulfide	< 0.00670
Total Unidentified Sulfur	**0.00790**
Total Reduced Sulfurs	**0.13826**
Total Sulfurs	**0.18153**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 12/6/2019
Analyst: ZB
Units: ppmV

Instrument ID: SCD-BTU
Calb. Date: 6/20/2019

Opening Calibration Verification Standard

0.523 ppbV H2S (SS1192)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	1459	0.534	102.2	3.0
Duplicate	1357	0.497	95.1	4.2
Triplicate	1433	0.525	100.4	1.2

0.548 ppbV H2S (SS1192)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	1461	0.557	101.7	0.3
Duplicate	1438	0.548	100.0	1.3
Triplicate	1473	0.561	102.5	1.1

0.536 ppbV H2S (SS1192)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	1638	0.534	99.6	2.0
Duplicate	1599	0.521	97.2	0.4
Triplicate	1581	0.515	96.1	1.5

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis Sample ID 192086-3988

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	0.062	0.067	0.065	7.8
MeSH	<PQL	<PQL	0.000	0.0
DMS	<PQL	<PQL	0.000	0.0

Matrix Spike & Duplicate Sample ID 192086-3988 x2

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	0.032	0.523	0.554	0.587	99.8	105.7	5.8
MeSH	<PQL	0.548	0.534	0.564	97.5	103.0	5.5
DMS	<PQL	0.536	0.498	0.524	93.0	97.8	5.1

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	0.523	0.506	96.7
MeSH	0.548	0.541	98.8
DMS	0.536	0.493	92.0

** Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.*

H2S: PQL = 20.0 ppbV, MDL = 2.40 ppbV
MeSH: PQL = 20.0 ppbV, MDL = 1.73 ppbV
DMS: PQL = 20.0 ppbV, MDL = 1.89 ppbV

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

192082

SAM #										Preparation and Analysis
Client: PG&E Environmental Services			Project Manager: Surinder Sidhu					Date: 12/4/19		
Address: 3400 Crow Canyon Road			Telephone Number: 925-866-5245		Email: SKSG@pge.com			Laboratory: AAC Labs		
City: San Ramon	State: CA	Zip: 94583	Site Contacat					Laboratory Phone: 805-650-1642		
Project Number/Name: Natural Gas Sampling			Sampler: Steve North 925-785-3039					Laboratory Fax		
Contract Number, PO Number		Laboratory Contact: Marcus Hueppe - 1534 Eastman Ave. Suite A Ventura CA 93003								

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers Volume	Containers Type	Containers No.	Preservative	Condition on Receipt/Comments	Sulfur ASTM D-5504
CPP-GS-DEC-A 3971		12/4/19	1500	Gas	1 liter	cyl	1	None		X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.COM) and Evan Cavalli (EMCM@PGE.COM)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

1. Relinquished By: Steve North (via UPS)	Date: 12/4/19	Time: 1730	1. Received By	Date	Time
2. Relinquished By	Date	Time	2. Received By	Date	Time
3. Relinquished By	Date	Time	3. Received By	Date: 12/5/19	Time: 1220

Comments

ATTACHMENT 3
40 CFR 60 Section KKKK

FCD: AQ-13
Title V: #8, 9, 25, 25, 30

40 CFR 60 KKKK Emission Limits:

Natural Gas Fired Combustion Turbine > 850 MMBtu

15 ppmvdc @ 15% O_2; 4 Hour Rolling Average

During Normal Operations

96 ppmvdc @ 15% O_2; 4 Hour Rolling Average

Turbines operating at less than 75% of Peak Load
(Startup/Shutdown)

KKKK Compliance (Colusa Generating Station)

40 CFR Part 60 Subpart KKKK applies to all stationary gas turbines rated at greater than or equal to 10 MMBtu/hr that commence construction, modification, or reconstruction after February 18, 2005. The gas turbines involved in this project have a rating of 1612 MMBtu/hr and were installed after February 18, 2005, therefore, this subpart applies.

Compliance with the applicable provisions of NSPS KKKK are summarized below. Specific data to support the compliance determinations listed below are included as attachments. The non-applicable portions of KKKK are not listed in the compliance summary:

Section	Requirement	Compliance Status
60.4305	CGS Turbines/HRSGs rated at larger than 10 MMBtu/hr and construction commenced after February 18, 2005. Subpart KKKK applies.	IN COMPLIANCE
60.4310	No exemptions apply.	No exemptions apply.
60.4315	Pollutants regulated under Subpart KKKK: NO_x and SO_2.	IN COMPLIANCE
60.4320	NOx emissions limit: 15 ppmv @15% O_2	IN COMPLIANCE
60.4330	SO_2 emissions limit: 0.90 lbs SO_2/MWh (gross output), or cannot burn any fuel which contains total potential sulfur emissions in excess of 0.060 lbs SO_2/MMBtu (heat input).	IN COMPLIANCE Based on monthly fuel sampling.
60.4333	Operate turbine/HRSG, APC systems, and monitoring equipment to minimize emissions at all times including during startup, shutdown, and malfunction.	IN COMPLIANCE
60.4340(b)(1)	For units with SCR, install a NO_x CEMS per 60.4335(b) or 60.4345. If Part 75 applies, NO_x can be monitored per Appendix E of Part 75. (CGS QAP applies here)	IN COMPLIANCE CT1 and CT2 utilize SCR and NO_x CEMS per 60.4335(b) or 60.4345. Part 75 applies and NO_x is monitored per Appendix E of Part 75.
60.4345	Meet all CEMS Performance Specs and develop a QA Plan for the CEMS. (CGS QAP applies here)	IN COMPLIANCE
60.4350	All CEMS data must be reduced to hourly averages per 60.13(h). (CGS QAP applies here)	IN COMPLIANCE

60.4355	If applicable, develop and insure all parametric monitoring and monitoring plans comply with this section. (CGS QAP applies here)	IN COMPLIANCE
60.4360	Monitor fuel sulfur content, or invoke exemption per 60.4365.	Exemption per 60.4365
60.4365	Exemption for fuel sulfur monitoring if fuel is demonstrated not to exceed potential sulfur emissions of 0.060 lb SO_2/MMBtu. Use PG&E gas quality data to show that exemption applies per 60.4365 (a) or (b).	IN COMPLIANCE Pipeline quality natural gas used with sulfur content less than 0.30 gr/100 SCF (0.0008 lb/MMBtu as SO_2). Annual compliance based on PG&E supplied fuel analysis data. See Attachment 2.
60.4375	Submit excess emissions reports per 60.7(c). Within 30 days following the end of each 6 month period (see 60.4395).	IN COMPLIANCE
60.4380(b)	Determine excess emissions and monitor downtime per (b) (1-3)	IN COMPLIANCE See Attachment 4.
60.4400	Initial and annual NO_X performance tests not required if CEMS used per 60.4340(b)(1)	IN COMPLIANCE NO_x CEMs used per 60.4340(b)(1). NO_x, CO, and VOC tested annually.
60.4415	Perform initial SO_2 performance test per 60.4415 (2) or (3). This test must be conducted even if the 60.4365 exemption is invoked.	IN COMPLIANCE Initial SO_2 source test performed in 2010; results available upon request. Ongoing compliance determined by fuel sampling (60.4415(a)(1)(ii)).

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/01/2019 00:00	2	1
10/01/2019 01:00	2	1
10/01/2019 02:00	2	1
10/01/2019 03:00	2	1
10/01/2019 04:00	3	1
10/01/2019 05:00	5	1
10/01/2019 06:00	4	1
10/01/2019 07:00	3	1
10/01/2019 08:00	2	1
10/01/2019 09:00	1	1
10/01/2019 10:00	1	1
10/01/2019 11:00	1	1
10/01/2019 12:00	1	1
10/01/2019 13:00	1	1
10/01/2019 14:00	1	1
10/01/2019 15:00	1	1
10/01/2019 16:00	1	1
10/01/2019 17:00	1	1
10/01/2019 18:00	1	1
10/01/2019 19:00	1	1
10/01/2019 20:00	1	1
10/01/2019 21:00	1	1
10/01/2019 22:00	1	1
10/01/2019 23:00	1	1
Average/Sum#:	2	1
Minimum:	1	1
Maximum:	5	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/02/2019 00:00	1	1
10/02/2019 01:00	1	1
10/02/2019 02:00	1	1
10/02/2019 03:00	1	1
10/02/2019 04:00	1	1
10/02/2019 05:00	1	1
10/02/2019 06:00	1	1
10/02/2019 07:00	1	1
10/02/2019 08:00	1	1
10/02/2019 09:00	1	1
10/02/2019 10:00	1	1
10/02/2019 11:00	0	0
10/02/2019 12:00	0	0
10/02/2019 13:00	0	0
10/02/2019 14:00	0	0
10/02/2019 15:00	1	1
10/02/2019 16:00	1	1
10/02/2019 17:00	1	1
10/02/2019 18:00	1	1
10/02/2019 19:00	1	1
10/02/2019 20:00	1	1
10/02/2019 21:00	1	1
10/02/2019 22:00	1	1
10/02/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/03/2019 00:00	1	1
10/03/2019 01:00	1	1
10/03/2019 02:00	1	1
10/03/2019 03:00	1	1
10/03/2019 04:00	1	1
10/03/2019 05:00	1	1
10/03/2019 06:00	1	1
10/03/2019 07:00	1	1
10/03/2019 08:00	1	1
10/03/2019 09:00	1	1
10/03/2019 10:00	1	1
10/03/2019 11:00	0	1
10/03/2019 12:00	0	0
10/03/2019 13:00	0	0
10/03/2019 14:00	0	1
10/03/2019 15:00	0	1
10/03/2019 16:00	1	1
10/03/2019 17:00	1	1
10/03/2019 18:00	1	1
10/03/2019 19:00	1	1
10/03/2019 20:00	1	1
10/03/2019 21:00	1	1
10/03/2019 22:00	1	1
10/03/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/04/2019 00:00	1	1
10/04/2019 01:00	1	1
10/04/2019 02:00	1	6
10/04/2019 03:00	1	10
10/04/2019 04:00	1	9
10/04/2019 05:00	1	9
10/04/2019 06:00	1	4
10/04/2019 07:00	1	1
10/04/2019 08:00	1	1
10/04/2019 09:00	1	1
10/04/2019 10:00	1	1
10/04/2019 11:00	1	1
10/04/2019 12:00	1	1
10/04/2019 13:00	13	1
10/04/2019 14:00	19	1
10/04/2019 15:00	19	1
10/04/2019 16:00	18	1
10/04/2019 17:00	6	1
10/04/2019 18:00	1	1
10/04/2019 19:00	1	1
10/04/2019 20:00	1	1
10/04/2019 21:00	1	1
10/04/2019 22:00	1	1
10/04/2019 23:00	1	1
Average/Sum#:	4	2
Minimum:	1	1
Maximum:	19	10
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/05/2019 00:00	1	1
10/05/2019 01:00	1	1
10/05/2019 02:00	1	1
10/05/2019 03:00	1	1
10/05/2019 04:00	1	1
10/05/2019 05:00	1	1
10/05/2019 06:00	1	1
10/05/2019 07:00	1	1
10/05/2019 08:00	1	1
10/05/2019 09:00	1	1
10/05/2019 10:00	1	1
10/05/2019 11:00	0	1
10/05/2019 12:00	0	0
10/05/2019 13:00	0	0
10/05/2019 14:00	0	0
10/05/2019 15:00	1	1
10/05/2019 16:00	1	1
10/05/2019 17:00	1	1
10/05/2019 18:00	1	1
10/05/2019 19:00	1	1
10/05/2019 20:00	1	1
10/05/2019 21:00	1	1
10/05/2019 22:00	1	1
10/05/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/06/2019 00:00	1	1
10/06/2019 01:00	1	1
10/06/2019 02:00	1	1
10/06/2019 03:00	1	1
10/06/2019 04:00	1	1
10/06/2019 05:00	1	1
10/06/2019 06:00	1	1
10/06/2019 07:00	1	1
10/06/2019 08:00	1	1
10/06/2019 09:00	1	1
10/06/2019 10:00	0	1
10/06/2019 11:00	0	0
10/06/2019 12:00	0	0
10/06/2019 13:00	0	0
10/06/2019 14:00	0	1
10/06/2019 15:00	1	1
10/06/2019 16:00	1	1
10/06/2019 17:00	1	1
10/06/2019 18:00	1	1
10/06/2019 19:00	1	1
10/06/2019 20:00	1	1
10/06/2019 21:00	1	1
10/06/2019 22:00	1	1
10/06/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/07/2019 00:00	1	1
10/07/2019 01:00	1	1
10/07/2019 02:00	1	1
10/07/2019 03:00	1	1
10/07/2019 04:00	1	1
10/07/2019 05:00	1	1
10/07/2019 06:00	1	1
10/07/2019 07:00	1	1
10/07/2019 08:00	1	1
10/07/2019 09:00	1	1
10/07/2019 10:00	1	1
10/07/2019 11:00	1	1
10/07/2019 12:00	1	1
10/07/2019 13:00	1	1
10/07/2019 14:00	1	1
10/07/2019 15:00	1	1
10/07/2019 16:00	1	1
10/07/2019 17:00	1	1
10/07/2019 18:00	1	1
10/07/2019 19:00	1	1
10/07/2019 20:00	1	1
10/07/2019 21:00	1	1
10/07/2019 22:00	1	1
10/07/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/08/2019 00:00	1	1
10/08/2019 01:00	1	1
10/08/2019 02:00	1	1
10/08/2019 03:00	1	1
10/08/2019 04:00	1	1
10/08/2019 05:00	1	1
10/08/2019 06:00	1	1
10/08/2019 07:00	1	1
10/08/2019 08:00	1	1
10/08/2019 09:00	1	1
10/08/2019 10:00	1	1
10/08/2019 11:00	1	1
10/08/2019 12:00	1	1
10/08/2019 13:00	1	1
10/08/2019 14:00	1	1
10/08/2019 15:00	1	1
10/08/2019 16:00	1	1
10/08/2019 17:00	1	1
10/08/2019 18:00	1	1
10/08/2019 19:00	1	1
10/08/2019 20:00	1	1
10/08/2019 21:00	1	1
10/08/2019 22:00	1	1
10/08/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/09/2019 00:00	1	1
10/09/2019 01:00	1	1
10/09/2019 02:00	1	1
10/09/2019 03:00	1	1
10/09/2019 04:00	1	1
10/09/2019 05:00	1	1
10/09/2019 06:00	1	1
10/09/2019 07:00	1	1
10/09/2019 08:00	1	1
10/09/2019 09:00	1	1
10/09/2019 10:00	1	1
10/09/2019 11:00	1	1
10/09/2019 12:00	1	1
10/09/2019 13:00	1	1
10/09/2019 14:00	1	1
10/09/2019 15:00	1	1
10/09/2019 16:00	1	1
10/09/2019 17:00	1	1
10/09/2019 18:00	1	1
10/09/2019 19:00	1	1
10/09/2019 20:00	1	1
10/09/2019 21:00	1	1
10/09/2019 22:00	1	1
10/09/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/10/2019 00:00	1	1
10/10/2019 01:00	1	1
10/10/2019 02:00	1	1
10/10/2019 03:00	1	1
10/10/2019 04:00	1	1
10/10/2019 05:00	1	1
10/10/2019 06:00	1	1
10/10/2019 07:00	1	1
10/10/2019 08:00	1	1
10/10/2019 09:00	1	1
10/10/2019 10:00	1	1
10/10/2019 11:00	0	1
10/10/2019 12:00	1	1
10/10/2019 13:00	1	1
10/10/2019 14:00	1	1
10/10/2019 15:00	1	1
10/10/2019 16:00	1	1
10/10/2019 17:00	1	1
10/10/2019 18:00	1	1
10/10/2019 19:00	1	1
10/10/2019 20:00	1	1
10/10/2019 21:00	1	1
10/10/2019 22:00	1	1
10/10/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/11/2019 00:00	1	1
10/11/2019 01:00	1	1
10/11/2019 02:00	1	1
10/11/2019 03:00	1	1
10/11/2019 04:00	1	1
10/11/2019 05:00	1	1
10/11/2019 06:00	1	1
10/11/2019 07:00	1	1
10/11/2019 08:00	0	1
10/11/2019 09:00	0	0
10/11/2019 10:00	0	0
10/11/2019 11:00	0	0
10/11/2019 12:00	0	0
10/11/2019 13:00	0	0
10/11/2019 14:00	0	1
10/11/2019 15:00	1	1
10/11/2019 16:00	1	1
10/11/2019 17:00	1	1
10/11/2019 18:00	1	1
10/11/2019 19:00	1	1
10/11/2019 20:00	1	1
10/11/2019 21:00	1	1
10/11/2019 22:00	1	1
10/11/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/12/2019 00:00	1	1
10/12/2019 01:00	1	1
10/12/2019 02:00	1	1
10/12/2019 03:00	1	1
10/12/2019 04:00	1	1
10/12/2019 05:00	1	1
10/12/2019 06:00	1	1
10/12/2019 07:00	1	2
10/12/2019 08:00	1	2
10/12/2019 09:00	1	2
10/12/2019 10:00	1	2
10/12/2019 11:00	1	6
10/12/2019 12:00	1	6
10/12/2019 13:00	1	5
10/12/2019 14:00	6	5
10/12/2019 15:00	9	1
10/12/2019 16:00	9	1
10/12/2019 17:00	9	1
10/12/2019 18:00	4	1
10/12/2019 19:00	1	1
10/12/2019 20:00	1	1
10/12/2019 21:00	1	1
10/12/2019 22:00	1	1
10/12/2019 23:00	1	1
Average/Sum#:	2	2
Minimum:	1	1
Maximum:	9	6
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/13/2019 00:00	1	1
10/13/2019 01:00	1	1
10/13/2019 02:00	1	1
10/13/2019 03:00	1	1
10/13/2019 04:00	1	1
10/13/2019 05:00	1	1
10/13/2019 06:00	1	1
10/13/2019 07:00	1	1
10/13/2019 08:00	1	1
10/13/2019 09:00	1	1
10/13/2019 10:00	1	1
10/13/2019 11:00	1	1
10/13/2019 12:00	1	1
10/13/2019 13:00	1	1
10/13/2019 14:00	1	1
10/13/2019 15:00	1	1
10/13/2019 16:00	1	1
10/13/2019 17:00	1	1
10/13/2019 18:00	1	1
10/13/2019 19:00	1	1
10/13/2019 20:00	1	1
10/13/2019 21:00	1	1
10/13/2019 22:00	1	1
10/13/2019 23:00	1	2
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/14/2019 00:00	1	2
10/14/2019 01:00	1	2
10/14/2019 02:00	1	5
10/14/2019 03:00	1	5
10/14/2019 04:00	1	5
10/14/2019 05:00	1	4
10/14/2019 06:00	2	1
10/14/2019 07:00	4	1
10/14/2019 08:00	4	1
10/14/2019 09:00	3	1
10/14/2019 10:00	3	1
10/14/2019 11:00	0	1
10/14/2019 12:00	0	0
10/14/2019 13:00	1	1
10/14/2019 14:00	1	1
10/14/2019 15:00	1	1
10/14/2019 16:00	1	1
10/14/2019 17:00	1	1
10/14/2019 18:00	1	1
10/14/2019 19:00	1	1
10/14/2019 20:00	1	1
10/14/2019 21:00	1	1
10/14/2019 22:00	1	1
10/14/2019 23:00	1	1
Average/Sum#:	1	2
Minimum:	0	0
Maximum:	4	5
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/15/2019 00:00	1	1
10/15/2019 01:00	1	1
10/15/2019 02:00	1	1
10/15/2019 03:00	1	1
10/15/2019 04:00	1	1
10/15/2019 05:00	1	1
10/15/2019 06:00	3	1
10/15/2019 07:00	4	1
10/15/2019 08:00	3	1
10/15/2019 09:00	3	1
10/15/2019 10:00	2	1
10/15/2019 11:00	0	0
10/15/2019 12:00	0	0
10/15/2019 13:00	1	1
10/15/2019 14:00	1	1
10/15/2019 15:00	1	1
10/15/2019 16:00	1	1
10/15/2019 17:00	1	1
10/15/2019 18:00	1	1
10/15/2019 19:00	1	1
10/15/2019 20:00	1	1
10/15/2019 21:00	1	1
10/15/2019 22:00	1	1
10/15/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	0
Maximum:	4	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/16/2019 00:00	1	1
10/16/2019 01:00	1	1
10/16/2019 02:00	1	1
10/16/2019 03:00	1	1
10/16/2019 04:00	1	1
10/16/2019 05:00	1	1
10/16/2019 06:00	1	1
10/16/2019 07:00	1	1
10/16/2019 08:00	1	1
10/16/2019 09:00	1	1
10/16/2019 10:00	1	1
10/16/2019 11:00	1	1
10/16/2019 12:00	1	1
10/16/2019 13:00	1	1
10/16/2019 14:00	1	1
10/16/2019 15:00	1	1
10/16/2019 16:00	1	1
10/16/2019 17:00	1	1
10/16/2019 18:00	1	1
10/16/2019 19:00	1	1
10/16/2019 20:00	13	1
10/16/2019 21:00	20	1
10/16/2019 22:00	20	1
10/16/2019 23:00	20	1
Average/Sum#:	4	1
Minimum:	1	1
Maximum:	20	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/17/2019 00:00	8	1
10/17/2019 01:00	1	1
10/17/2019 02:00	1	1
10/17/2019 03:00	1	1
10/17/2019 04:00	1	1
10/17/2019 05:00	1	1
10/17/2019 06:00	1	1
10/17/2019 07:00	1	1
10/17/2019 08:00	1	1
10/17/2019 09:00	1	1
10/17/2019 10:00	1	1
10/17/2019 11:00	1	1
10/17/2019 12:00	1	1
10/17/2019 13:00	1	1
10/17/2019 14:00	1	1
10/17/2019 15:00	1	1
10/17/2019 16:00	1	1
10/17/2019 17:00	1	1
10/17/2019 18:00	1	1
10/17/2019 19:00	1	1
10/17/2019 20:00	1	1
10/17/2019 21:00	1	1
10/17/2019 22:00	1	1
10/17/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	8	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/18/2019 00:00	1	1
10/18/2019 01:00	1	1
10/18/2019 02:00	1	1
10/18/2019 03:00	1	1
10/18/2019 04:00	1	1
10/18/2019 05:00	1	1
10/18/2019 06:00	1	1
10/18/2019 07:00	1	1
10/18/2019 08:00	1	1
10/18/2019 09:00	1	1
10/18/2019 10:00	1	1
10/18/2019 11:00	1	1
10/18/2019 12:00	1	1
10/18/2019 13:00	1	1
10/18/2019 14:00	1	1
10/18/2019 15:00	1	1
10/18/2019 16:00	1	1
10/18/2019 17:00	1	1
10/18/2019 18:00	1	1
10/18/2019 19:00	1	1
10/18/2019 20:00	1	1
10/18/2019 21:00	1	1
10/18/2019 22:00	1	1
10/18/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/19/2019 00:00	1	1
10/19/2019 01:00	1	1
10/19/2019 02:00	1	1
10/19/2019 03:00	1	1
10/19/2019 04:00	1	1
10/19/2019 05:00	1	1
10/19/2019 06:00	1	1
10/19/2019 07:00	1	2
10/19/2019 08:00	1	2
10/19/2019 09:00	1	2
10/19/2019 10:00	1	2
10/19/2019 11:00	1	2
10/19/2019 12:00	1	2
10/19/2019 13:00	1	2
10/19/2019 14:00	1	9
10/19/2019 15:00	1	12
10/19/2019 16:00	1	12
10/19/2019 17:00	1	11
10/19/2019 18:00	1	4
10/19/2019 19:00	1	1
10/19/2019 20:00	1	1
10/19/2019 21:00	1	1
10/19/2019 22:00	1	1
10/19/2019 23:00	1	1
Average/Sum#:	1	3
Minimum:	1	1
Maximum:	1	12
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/20/2019 00:00	1	1
10/20/2019 01:00	1	1
10/20/2019 02:00	1	2
10/20/2019 03:00	1	2
10/20/2019 04:00	1	2
10/20/2019 05:00	1	2
10/20/2019 06:00	1	2
10/20/2019 07:00	1	2
10/20/2019 08:00	1	2
10/20/2019 09:00	1	2
10/20/2019 10:00	1	13
10/20/2019 11:00	1	16
10/20/2019 12:00	1	16
10/20/2019 13:00	1	15
10/20/2019 14:00	14	4
10/20/2019 15:00	17	1
10/20/2019 16:00	17	1
10/20/2019 17:00	17	1
10/20/2019 18:00	4	1
10/20/2019 19:00	1	1
10/20/2019 20:00	1	1
10/20/2019 21:00	1	1
10/20/2019 22:00	1	1
10/20/2019 23:00	1	1
Average/Sum#:	4	4
Minimum:	1	1
Maximum:	17	16
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/21/2019 00:00	1	1
10/21/2019 01:00	1	1
10/21/2019 02:00	1	1
10/21/2019 03:00	1	1
10/21/2019 04:00	1	1
10/21/2019 05:00	1	1
10/21/2019 06:00	1	1
10/21/2019 07:00	1	1
10/21/2019 08:00	1	1
10/21/2019 09:00	1	1
10/21/2019 10:00	1	1
10/21/2019 11:00	0	1
10/21/2019 12:00	1	1
10/21/2019 13:00	1	1
10/21/2019 14:00	1	1
10/21/2019 15:00	1	1
10/21/2019 16:00	1	1
10/21/2019 17:00	1	1
10/21/2019 18:00	1	1
10/21/2019 19:00	1	1
10/21/2019 20:00	1	1
10/21/2019 21:00	1	1
10/21/2019 22:00	1	1
10/21/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/22/2019 00:00	1	1
10/22/2019 01:00	1	1
10/22/2019 02:00	1	1
10/22/2019 03:00	1	1
10/22/2019 04:00	1	1
10/22/2019 05:00	1	1
10/22/2019 06:00	1	1
10/22/2019 07:00	1	1
10/22/2019 08:00	1	1
10/22/2019 09:00	1	1
10/22/2019 10:00	1	1
10/22/2019 11:00	1	1
10/22/2019 12:00	1	1
10/22/2019 13:00	1	1
10/22/2019 14:00	1	1
10/22/2019 15:00	1	1
10/22/2019 16:00	1	1
10/22/2019 17:00	1	1
10/22/2019 18:00	1	1
10/22/2019 19:00	1	1
10/22/2019 20:00	1	1
10/22/2019 21:00	1	1
10/22/2019 22:00	1	1
10/22/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/23/2019 00:00	1	1
10/23/2019 01:00	1	1
10/23/2019 02:00	1	1
10/23/2019 03:00	1	1
10/23/2019 04:00	1	1
10/23/2019 05:00	1	1
10/23/2019 06:00	1	1
10/23/2019 07:00	1	1
10/23/2019 08:00	1	1
10/23/2019 09:00	1	1
10/23/2019 10:00	0	1
10/23/2019 11:00	0	1
10/23/2019 12:00	1	1
10/23/2019 13:00	1	1
10/23/2019 14:00	1	1
10/23/2019 15:00	1	1
10/23/2019 16:00	1	1
10/23/2019 17:00	1	1
10/23/2019 18:00	1	1
10/23/2019 19:00	1	1
10/23/2019 20:00	1	1
10/23/2019 21:00	1	1
10/23/2019 22:00	1	1
10/23/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/24/2019 00:00	1	1
10/24/2019 01:00	1	1
10/24/2019 02:00	1	1
10/24/2019 03:00	1	1
10/24/2019 04:00	1	1
10/24/2019 05:00	1	1
10/24/2019 06:00	1	1
10/24/2019 07:00	1	1
10/24/2019 08:00	1	1
10/24/2019 09:00	1	1
10/24/2019 10:00	1	1
10/24/2019 11:00	1	1
10/24/2019 12:00	1	1
10/24/2019 13:00	1	1
10/24/2019 14:00	1	1
10/24/2019 15:00	1	1
10/24/2019 16:00	1	1
10/24/2019 17:00	1	1
10/24/2019 18:00	1	1
10/24/2019 19:00	1	1
10/24/2019 20:00	1	1
10/24/2019 21:00	1	1
10/24/2019 22:00	1	1
10/24/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/25/2019 00:00	1	1
10/25/2019 01:00	1	1
10/25/2019 02:00	1	1
10/25/2019 03:00	1	1
10/25/2019 04:00	1	1
10/25/2019 05:00	1	1
10/25/2019 06:00	1	1
10/25/2019 07:00	1	1
10/25/2019 08:00	1	1
10/25/2019 09:00	1	1
10/25/2019 10:00	1	1
10/25/2019 11:00	1	1
10/25/2019 12:00	1	1
10/25/2019 13:00	1	1
10/25/2019 14:00	1	1
10/25/2019 15:00	1	1
10/25/2019 16:00	1	1
10/25/2019 17:00	1	1
10/25/2019 18:00	1	1
10/25/2019 19:00	1	1
10/25/2019 20:00	1	1
10/25/2019 21:00	1	1
10/25/2019 22:00	1	1
10/25/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/26/2019 00:00	1	1
10/26/2019 01:00	1	1
10/26/2019 02:00	1	1
10/26/2019 03:00	1	1
10/26/2019 04:00	1	1
10/26/2019 05:00	1	1
10/26/2019 06:00	1	1
10/26/2019 07:00	1	1
10/26/2019 08:00	1	1
10/26/2019 09:00	1	1
10/26/2019 10:00	1	1
10/26/2019 11:00	1	1
10/26/2019 12:00	1	1
10/26/2019 13:00	1	1
10/26/2019 14:00	1	1
10/26/2019 15:00	1	1
10/26/2019 16:00	1	1
10/26/2019 17:00	1	1
10/26/2019 18:00	1	1
10/26/2019 19:00	1	1
10/26/2019 20:00	1	1
10/26/2019 21:00	1	1
10/26/2019 22:00	1	2
10/26/2019 23:00	1	2
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/27/2019 00:00	1	2
10/27/2019 01:00	1	2
10/27/2019 02:00	1	2
10/27/2019 03:00	1	2
10/27/2019 04:00	1	2
10/27/2019 05:00	1	2
10/27/2019 06:00	1	2
10/27/2019 07:00	1	2
10/27/2019 08:00	1	2
10/27/2019 09:00	1	2
10/27/2019 10:00	1	2
10/27/2019 11:00	1	2
10/27/2019 12:00	1	2
10/27/2019 13:00	1	2
10/27/2019 14:00	1	2
10/27/2019 15:00	1	2
10/27/2019 16:00	1	2
10/27/2019 17:00	1	16
10/27/2019 18:00	1	26
10/27/2019 19:00	1	31
10/27/2019 20:00	1	30
10/27/2019 21:00	1	15
10/27/2019 22:00	1	6
10/27/2019 23:00	1	1
Average/Sum#:	1	7
Minimum:	1	1
Maximum:	1	31
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/28/2019 00:00	14	1
10/28/2019 01:00	25	1
10/28/2019 02:00	25	1
10/28/2019 03:00	24	1
10/28/2019 04:00	11	1
10/28/2019 05:00	1	1
10/28/2019 06:00	1	1
10/28/2019 07:00	1	1
10/28/2019 08:00	1	1
10/28/2019 09:00	1	1
10/28/2019 10:00	1	1
10/28/2019 11:00	1	1
10/28/2019 12:00	1	1
10/28/2019 13:00	1	1
10/28/2019 14:00	1	1
10/28/2019 15:00	1	1
10/28/2019 16:00	1	1
10/28/2019 17:00	1	1
10/28/2019 18:00	1	1
10/28/2019 19:00	1	1
10/28/2019 20:00	1	1
10/28/2019 21:00	1	1
10/28/2019 22:00	1	1
10/28/2019 23:00	2	3
Average/Sum#:	5	1
Minimum:	1	1
Maximum:	25	3
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/29/2019 00:00	2	3
10/29/2019 01:00	2	3
10/29/2019 02:00	2	3
10/29/2019 03:00	2	3
10/29/2019 04:00	2	3
10/29/2019 05:00	2	3
10/29/2019 06:00	2	3
10/29/2019 07:00	2	3
10/29/2019 08:00	2	3
10/29/2019 09:00	2	3
10/29/2019 10:00	2	3
10/29/2019 11:00	2	3
10/29/2019 12:00	2	3
10/29/2019 13:00	2	3
10/29/2019 14:00	2	3
10/29/2019 15:00	2	3
10/29/2019 16:00	2	3
10/29/2019 17:00	2	3
10/29/2019 18:00	2	3
10/29/2019 19:00	2	3
10/29/2019 20:00	2	3
10/29/2019 21:00	2	3
10/29/2019 22:00	2	3
10/29/2019 23:00	2	3
Average/Sum#:	2	3
Minimum:	2	3
Maximum:	2	3
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/30/2019 00:00	2	18
10/30/2019 01:00	2	26
10/30/2019 02:00	2	30
10/30/2019 03:00	2	28
10/30/2019 04:00	7	13
10/30/2019 05:00	20	5
10/30/2019 06:00	25	1
10/30/2019 07:00	24	1
10/30/2019 08:00	19	1
10/30/2019 09:00	6	1
10/30/2019 10:00	1	1
10/30/2019 11:00	1	1
10/30/2019 12:00	1	1
10/30/2019 13:00	1	1
10/30/2019 14:00	1	1
10/30/2019 15:00	1	1
10/30/2019 16:00	1	1
10/30/2019 17:00	1	1
10/30/2019 18:00	1	1
10/30/2019 19:00	1	1
10/30/2019 20:00	1	1
10/30/2019 21:00	1	1
10/30/2019 22:00	1	1
10/30/2019 23:00	1	1
Average/Sum#:	5	6
Minimum:	1	1
Maximum:	25	30
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/31/2019 00:00	1	1
10/31/2019 01:00	1	1
10/31/2019 02:00	1	1
10/31/2019 03:00	1	1
10/31/2019 04:00	1	1
10/31/2019 05:00	1	1
10/31/2019 06:00	1	1
10/31/2019 07:00	1	1
10/31/2019 08:00	1	1
10/31/2019 09:00	1	1
10/31/2019 10:00	1	1
10/31/2019 11:00	1	1
10/31/2019 12:00	1	1
10/31/2019 13:00	1	1
10/31/2019 14:00	1	1
10/31/2019 15:00	1	1
10/31/2019 16:00	1	1
10/31/2019 17:00	1	1
10/31/2019 18:00	1	1
10/31/2019 19:00	1	1
10/31/2019 20:00	1	1
10/31/2019 21:00	1	1
10/31/2019 22:00	1	1
10/31/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/01/2019 00:00	1	1
11/01/2019 01:00	1	1
11/01/2019 02:00	1	1
11/01/2019 03:00	1	1
11/01/2019 04:00	1	1
11/01/2019 05:00	1	1
11/01/2019 06:00	1	1
11/01/2019 07:00	1	1
11/01/2019 08:00	1	1
11/01/2019 09:00	1	1
11/01/2019 10:00	1	1
11/01/2019 11:00	1	1
11/01/2019 12:00	1	1
11/01/2019 13:00	1	1
11/01/2019 14:00	1	1
11/01/2019 15:00	1	1
11/01/2019 16:00	1	1
11/01/2019 17:00	1	1
11/01/2019 18:00	1	1
11/01/2019 19:00	1	1
11/01/2019 20:00	1	1
11/01/2019 21:00	1	1
11/01/2019 22:00	1	1
11/01/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/02/2019 00:00	1	1
11/02/2019 01:00	1	1
11/02/2019 02:00	1	1
11/02/2019 03:00	1	1
11/02/2019 04:00	1	1
11/02/2019 05:00	1	1
11/02/2019 06:00	1	1
11/02/2019 07:00	1	1
11/02/2019 08:00	1	1
11/02/2019 09:00	1	1
11/02/2019 10:00	1	1
11/02/2019 11:00	1	1
11/02/2019 12:00	1	1
11/02/2019 13:00	1	2
11/02/2019 14:00	1	6
11/02/2019 15:00	2	6
11/02/2019 16:00	4	6
11/02/2019 17:00	4	5
11/02/2019 18:00	4	1
11/02/2019 19:00	3	1
11/02/2019 20:00	1	1
11/02/2019 21:00	2	1
11/02/2019 22:00	2	1
11/02/2019 23:00	2	1
Average/Sum#:	2	2
Minimum:	1	1
Maximum:	4	6
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/03/2019 00:00	2	1
11/03/2019 01:00	2	1
11/03/2019 02:00	2	1
11/03/2019 03:00	2	1
11/03/2019 04:00	2	1
11/03/2019 05:00	1	1
11/03/2019 06:00	1	1
11/03/2019 07:00	1	1
11/03/2019 08:00	1	1
11/03/2019 09:00	1	1
11/03/2019 10:00	1	1
11/03/2019 11:00	1	1
11/03/2019 12:00	1	1
11/03/2019 13:00	1	1
11/03/2019 14:00	1	1
11/03/2019 15:00	1	1
11/03/2019 16:00	1	1
11/03/2019 17:00	1	1
11/03/2019 18:00	1	1
11/03/2019 19:00	1	1
11/03/2019 20:00	1	1
11/03/2019 21:00	1	1
11/03/2019 22:00	1	1
11/03/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	2	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/04/2019 00:00	1	1
11/04/2019 01:00	1	1
11/04/2019 02:00	1	1
11/04/2019 03:00	1	1
11/04/2019 04:00	1	1
11/04/2019 05:00	1	1
11/04/2019 06:00	1	1
11/04/2019 07:00	1	1
11/04/2019 08:00	1	1
11/04/2019 09:00	1	1
11/04/2019 10:00	1	1
11/04/2019 11:00	1	1
11/04/2019 12:00	1	1
11/04/2019 13:00	1	1
11/04/2019 14:00	1	1
11/04/2019 15:00	1	1
11/04/2019 16:00	1	1
11/04/2019 17:00	1	1
11/04/2019 18:00	1	1
11/04/2019 19:00	1	1
11/04/2019 20:00	1	1
11/04/2019 21:00	1	1
11/04/2019 22:00	1	1
11/04/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/05/2019 00:00	1	1
11/05/2019 01:00	1	1
11/05/2019 02:00	1	1
11/05/2019 03:00	1	1
11/05/2019 04:00	1	1
11/05/2019 05:00	1	1
11/05/2019 06:00	1	1
11/05/2019 07:00	1	1
11/05/2019 08:00	1	1
11/05/2019 09:00	1	1
11/05/2019 10:00	1	1
11/05/2019 11:00	1	1
11/05/2019 12:00	1	1
11/05/2019 13:00	1	1
11/05/2019 14:00	1	1
11/05/2019 15:00	1	1
11/05/2019 16:00	1	1
11/05/2019 17:00	1	1
11/05/2019 18:00	1	1
11/05/2019 19:00	1	1
11/05/2019 20:00	1	1
11/05/2019 21:00	1	1
11/05/2019 22:00	1	1
11/05/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/06/2019 00:00	1	1
11/06/2019 01:00	1	1
11/06/2019 02:00	1	1
11/06/2019 03:00	1	1
11/06/2019 04:00	1	1
11/06/2019 05:00	1	1
11/06/2019 06:00	1	1
11/06/2019 07:00	1	1
11/06/2019 08:00	1	1
11/06/2019 09:00	1	1
11/06/2019 10:00	1	1
11/06/2019 11:00	1	1
11/06/2019 12:00	1	1
11/06/2019 13:00	1	1
11/06/2019 14:00	1	1
11/06/2019 15:00	1	1
11/06/2019 16:00	1	1
11/06/2019 17:00	1	1
11/06/2019 18:00	1	1
11/06/2019 19:00	1	1
11/06/2019 20:00	1	1
11/06/2019 21:00	1	1
11/06/2019 22:00	1	1
11/06/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/07/2019 00:00	1	1
11/07/2019 01:00	1	1
11/07/2019 02:00	1	1
11/07/2019 03:00	1	1
11/07/2019 04:00	1	1
11/07/2019 05:00	1	1
11/07/2019 06:00	1	1
11/07/2019 07:00	1	1
11/07/2019 08:00	1	1
11/07/2019 09:00	1	1
11/07/2019 10:00	1	1
11/07/2019 11:00	1	1
11/07/2019 12:00	1	1
11/07/2019 13:00	1	1
11/07/2019 14:00	1	1
11/07/2019 15:00	1	1
11/07/2019 16:00	1	1
11/07/2019 17:00	1	1
11/07/2019 18:00	1	1
11/07/2019 19:00	1	1
11/07/2019 20:00	1	1
11/07/2019 21:00	1	1
11/07/2019 22:00	1	1
11/07/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/08/2019 00:00	1	1
11/08/2019 01:00	1	1
11/08/2019 02:00	1	1
11/08/2019 03:00	1	1
11/08/2019 04:00	1	1
11/08/2019 05:00	1	1
11/08/2019 06:00	1	1
11/08/2019 07:00	1	1
11/08/2019 08:00	1	1
11/08/2019 09:00	1	1
11/08/2019 10:00	1	1
11/08/2019 11:00	1	1
11/08/2019 12:00	1	1
11/08/2019 13:00	1	1
11/08/2019 14:00	1	1
11/08/2019 15:00	1	1
11/08/2019 16:00	1	1
11/08/2019 17:00	1	1
11/08/2019 18:00	1	1
11/08/2019 19:00	1	1
11/08/2019 20:00	1	1
11/08/2019 21:00	1	1
11/08/2019 22:00	1	1
11/08/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/09/2019 00:00	1	1
11/09/2019 01:00	1	1
11/09/2019 02:00	1	1
11/09/2019 03:00	1	1
11/09/2019 04:00	1	1
11/09/2019 05:00	1	1
11/09/2019 06:00	1	1
11/09/2019 07:00	1	1
11/09/2019 08:00	1	1
11/09/2019 09:00	1	1
11/09/2019 10:00	1	1
11/09/2019 11:00	1	0
11/09/2019 12:00	1	0
11/09/2019 13:00	1	0
11/09/2019 14:00	1	0
11/09/2019 15:00	1	1
11/09/2019 16:00	1	1
11/09/2019 17:00	1	1
11/09/2019 18:00	1	1
11/09/2019 19:00	1	1
11/09/2019 20:00	1	1
11/09/2019 21:00	1	1
11/09/2019 22:00	1	1
11/09/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/10/2019 00:00	1	1
11/10/2019 01:00	1	1
11/10/2019 02:00	1	1
11/10/2019 03:00	1	1
11/10/2019 04:00	1	1
11/10/2019 05:00	1	1
11/10/2019 06:00	1	1
11/10/2019 07:00	1	1
11/10/2019 08:00	1	1
11/10/2019 09:00	1	1
11/10/2019 10:00	1	1
11/10/2019 11:00	1	1
11/10/2019 12:00	1	1
11/10/2019 13:00	1	1
11/10/2019 14:00	1	1
11/10/2019 15:00	1	1
11/10/2019 16:00	1	1
11/10/2019 17:00	1	1
11/10/2019 18:00	1	1
11/10/2019 19:00	1	1
11/10/2019 20:00	1	1
11/10/2019 21:00	1	1
11/10/2019 22:00	1	1
11/10/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/11/2019 00:00	1	1
11/11/2019 01:00	1	1
11/11/2019 02:00	1	1
11/11/2019 03:00	1	1
11/11/2019 04:00	1	1
11/11/2019 05:00	1	1
11/11/2019 06:00	1	1
11/11/2019 07:00	1	1
11/11/2019 08:00	1	1
11/11/2019 09:00	1	1
11/11/2019 10:00	1	1
11/11/2019 11:00	1	1
11/11/2019 12:00	1	1
11/11/2019 13:00	1	1
11/11/2019 14:00	1	1
11/11/2019 15:00	1	1
11/11/2019 16:00	1	1
11/11/2019 17:00	1	1
11/11/2019 18:00	1	1
11/11/2019 19:00	1	1
11/11/2019 20:00	1	1
11/11/2019 21:00	1	1
11/11/2019 22:00	1	1
11/11/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/12/2019 00:00	1	1
11/12/2019 01:00	1	1
11/12/2019 02:00	1	1
11/12/2019 03:00	1	1
11/12/2019 04:00	1	1
11/12/2019 05:00	1	1
11/12/2019 06:00	1	1
11/12/2019 07:00	1	1
11/12/2019 08:00	1	1
11/12/2019 09:00	1	1
11/12/2019 10:00	1	1
11/12/2019 11:00	1	1
11/12/2019 12:00	1	1
11/12/2019 13:00	1	1
11/12/2019 14:00	1	1
11/12/2019 15:00	1	1
11/12/2019 16:00	1	1
11/12/2019 17:00	1	1
11/12/2019 18:00	1	1
11/12/2019 19:00	1	1
11/12/2019 20:00	1	1
11/12/2019 21:00	1	1
11/12/2019 22:00	1	1
11/12/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/13/2019 00:00	1	1
11/13/2019 01:00	1	1
11/13/2019 02:00	1	1
11/13/2019 03:00	1	1
11/13/2019 04:00	1	1
11/13/2019 05:00	1	1
11/13/2019 06:00	1	1
11/13/2019 07:00	1	1
11/13/2019 08:00	1	1
11/13/2019 09:00	1	1
11/13/2019 10:00	1	1
11/13/2019 11:00	1	1
11/13/2019 12:00	1	1
11/13/2019 13:00	1	1
11/13/2019 14:00	1	1
11/13/2019 15:00	1	1
11/13/2019 16:00	1	1
11/13/2019 17:00	1	1
11/13/2019 18:00	1	1
11/13/2019 19:00	1	1
11/13/2019 20:00	1	1
11/13/2019 21:00	1	1
11/13/2019 22:00	1	1
11/13/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/14/2019 00:00	1	1
11/14/2019 01:00	1	1
11/14/2019 02:00	1	1
11/14/2019 03:00	1	1
11/14/2019 04:00	1	1
11/14/2019 05:00	1	1
11/14/2019 06:00	1	1
11/14/2019 07:00	1	1
11/14/2019 08:00	1	1
11/14/2019 09:00	1	1
11/14/2019 10:00	1	1
11/14/2019 11:00	1	1
11/14/2019 12:00	1	1
11/14/2019 13:00	1	1
11/14/2019 14:00	1	1
11/14/2019 15:00	1	1
11/14/2019 16:00	1	1
11/14/2019 17:00	1	1
11/14/2019 18:00	1	1
11/14/2019 19:00	1	1
11/14/2019 20:00	1	1
11/14/2019 21:00	1	1
11/14/2019 22:00	1	1
11/14/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/15/2019 00:00	1	1
11/15/2019 01:00	1	1
11/15/2019 02:00	1	1
11/15/2019 03:00	1	1
11/15/2019 04:00	1	1
11/15/2019 05:00	1	1
11/15/2019 06:00	1	1
11/15/2019 07:00	1	1
11/15/2019 08:00	1	1
11/15/2019 09:00	1	1
11/15/2019 10:00	1	1
11/15/2019 11:00	1	1
11/15/2019 12:00	1	1
11/15/2019 13:00	1	1
11/15/2019 14:00	1	1
11/15/2019 15:00	1	1
11/15/2019 16:00	1	1
11/15/2019 17:00	1	1
11/15/2019 18:00	1	1
11/15/2019 19:00	1	1
11/15/2019 20:00	1	1
11/15/2019 21:00	1	1
11/15/2019 22:00	1	1
11/15/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/16/2019 00:00	1	1
11/16/2019 01:00	1	1
11/16/2019 02:00	1	1
11/16/2019 03:00	1	1
11/16/2019 04:00	1	1
11/16/2019 05:00	1	1
11/16/2019 06:00	1	1
11/16/2019 07:00	1	1
11/16/2019 08:00	1	1
11/16/2019 09:00	1	1
11/16/2019 10:00	1	1
11/16/2019 11:00	1	1
11/16/2019 12:00	1	1
11/16/2019 13:00	1	1
11/16/2019 14:00	1	1
11/16/2019 15:00	1	1
11/16/2019 16:00	1	1
11/16/2019 17:00	1	1
11/16/2019 18:00	1	1
11/16/2019 19:00	1	1
11/16/2019 20:00	1	1
11/16/2019 21:00	1	1
11/16/2019 22:00	1	1
11/16/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/17/2019 00:00	1	1
11/17/2019 01:00	1	1
11/17/2019 02:00	1	1
11/17/2019 03:00	1	1
11/17/2019 04:00	1	1
11/17/2019 05:00	1	1
11/17/2019 06:00	1	1
11/17/2019 07:00	1	1
11/17/2019 08:00	1	1
11/17/2019 09:00	1	1
11/17/2019 10:00	1	1
11/17/2019 11:00	1	1
11/17/2019 12:00	1	1
11/17/2019 13:00	1	1
11/17/2019 14:00	1	1
11/17/2019 15:00	1	1
11/17/2019 16:00	1	1
11/17/2019 17:00	1	1
11/17/2019 18:00	1	1
11/17/2019 19:00	1	1
11/17/2019 20:00	1	1
11/17/2019 21:00	1	1
11/17/2019 22:00	1	1
11/17/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/18/2019 00:00	1	1
11/18/2019 01:00	1	1
11/18/2019 02:00	1	1
11/18/2019 03:00	1	1
11/18/2019 04:00	1	1
11/18/2019 05:00	1	1
11/18/2019 06:00	1	1
11/18/2019 07:00	1	1
11/18/2019 08:00	1	1
11/18/2019 09:00	1	1
11/18/2019 10:00	1	1
11/18/2019 11:00	1	1
11/18/2019 12:00	1	1
11/18/2019 13:00	1	1
11/18/2019 14:00	1	1
11/18/2019 15:00	1	1
11/18/2019 16:00	1	1
11/18/2019 17:00	1	1
11/18/2019 18:00	1	1
11/18/2019 19:00	1	1
11/18/2019 20:00	1	1
11/18/2019 21:00	1	1
11/18/2019 22:00	1	1
11/18/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/19/2019 00:00	1	1
11/19/2019 01:00	1	1
11/19/2019 02:00	1	1
11/19/2019 03:00	1	1
11/19/2019 04:00	1	1
11/19/2019 05:00	1	1
11/19/2019 06:00	1	1
11/19/2019 07:00	1	1
11/19/2019 08:00	1	1
11/19/2019 09:00	1	1
11/19/2019 10:00	1	1
11/19/2019 11:00	1	1
11/19/2019 12:00	1	1
11/19/2019 13:00	1	0
11/19/2019 14:00	1	0
11/19/2019 15:00	1	0
11/19/2019 16:00	1	1
11/19/2019 17:00	1	1
11/19/2019 18:00	1	1
11/19/2019 19:00	1	1
11/19/2019 20:00	1	1
11/19/2019 21:00	1	1
11/19/2019 22:00	1	1
11/19/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	12.50

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/20/2019 00:00	1	1
11/20/2019 01:00	1	1
11/20/2019 02:00	1	1
11/20/2019 03:00	1	1
11/20/2019 04:00	1	1
11/20/2019 05:00	1	1
11/20/2019 06:00	1	1
11/20/2019 07:00	1	1
11/20/2019 08:00	1	1
11/20/2019 09:00	1	0
11/20/2019 10:00	1	0
11/20/2019 11:00	1	0
11/20/2019 12:00	1	0
11/20/2019 13:00	1	0
11/20/2019 14:00	1	0
11/20/2019 15:00	1	1
11/20/2019 16:00	1	1
11/20/2019 17:00	1	1
11/20/2019 18:00	1	1
11/20/2019 19:00	1	1
11/20/2019 20:00	1	1
11/20/2019 21:00	1	1
11/20/2019 22:00	1	1
11/20/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	25.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/21/2019 00:00	1	1
11/21/2019 01:00	1	1
11/21/2019 02:00	1	1
11/21/2019 03:00	1	1
11/21/2019 04:00	1	1
11/21/2019 05:00	1	1
11/21/2019 06:00	1	1
11/21/2019 07:00	1	1
11/21/2019 08:00	1	1
11/21/2019 09:00	1	1
11/21/2019 10:00	1	1
11/21/2019 11:00	1	1
11/21/2019 12:00	1	1
11/21/2019 13:00	1	1
11/21/2019 14:00	1	1
11/21/2019 15:00	1	1
11/21/2019 16:00	1	1
11/21/2019 17:00	1	1
11/21/2019 18:00	1	1
11/21/2019 19:00	1	1
11/21/2019 20:00	1	1
11/21/2019 21:00	1	1
11/21/2019 22:00	1	1
11/21/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/22/2019 00:00	1	1
11/22/2019 01:00	1	1
11/22/2019 02:00	1	1
11/22/2019 03:00	1	1
11/22/2019 04:00	1	1
11/22/2019 05:00	1	1
11/22/2019 06:00	1	1
11/22/2019 07:00	1	1
11/22/2019 08:00	1	1
11/22/2019 09:00	1	1
11/22/2019 10:00	1	1
11/22/2019 11:00	1	1
11/22/2019 12:00	1	1
11/22/2019 13:00	1	1
11/22/2019 14:00	1	1
11/22/2019 15:00	1	1
11/22/2019 16:00	1	1
11/22/2019 17:00	1	1
11/22/2019 18:00	1	1
11/22/2019 19:00	1	1
11/22/2019 20:00	1	1
11/22/2019 21:00	1	1
11/22/2019 22:00	1	1
11/22/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/23/2019 00:00	1	1
11/23/2019 01:00	1	1
11/23/2019 02:00	1	1
11/23/2019 03:00	1	1
11/23/2019 04:00	1	1
11/23/2019 05:00	1	1
11/23/2019 06:00	1	1
11/23/2019 07:00	1	1
11/23/2019 08:00	1	1
11/23/2019 09:00	1	1
11/23/2019 10:00	1	1
11/23/2019 11:00	0	0
11/23/2019 12:00	0	0
11/23/2019 13:00	0	0
11/23/2019 14:00	0	0
11/23/2019 15:00	0	0
11/23/2019 16:00	1	1
11/23/2019 17:00	1	1
11/23/2019 18:00	1	1
11/23/2019 19:00	1	1
11/23/2019 20:00	1	1
11/23/2019 21:00	1	1
11/23/2019 22:00	1	1
11/23/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/24/2019 00:00	1	1
11/24/2019 01:00	1	1
11/24/2019 02:00	1	1
11/24/2019 03:00	1	1
11/24/2019 04:00	1	1
11/24/2019 05:00	1	1
11/24/2019 06:00	1	1
11/24/2019 07:00	1	1
11/24/2019 08:00	1	1
11/24/2019 09:00	1	1
11/24/2019 10:00	0	0
11/24/2019 11:00	0	0
11/24/2019 12:00	0	0
11/24/2019 13:00	0	0
11/24/2019 14:00	0	0
11/24/2019 15:00	0	0
11/24/2019 16:00	1	0
11/24/2019 17:00	1	1
11/24/2019 18:00	1	1
11/24/2019 19:00	1	1
11/24/2019 20:00	1	1
11/24/2019 21:00	1	1
11/24/2019 22:00	1	1
11/24/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/25/2019 00:00	1	1
11/25/2019 01:00	1	1
11/25/2019 02:00	1	0
11/25/2019 03:00	1	0
11/25/2019 04:00	3	0
11/25/2019 05:00	4	0
11/25/2019 06:00	4	0
11/25/2019 07:00	3	0
11/25/2019 08:00	1	0
11/25/2019 09:00	0	0
11/25/2019 10:00	0	0
11/25/2019 11:00	0	0
11/25/2019 12:00	0	0
11/25/2019 13:00	0	0
11/25/2019 14:00	0	0
11/25/2019 15:00	0	0
11/25/2019 16:00	0	0
11/25/2019 17:00	1	1
11/25/2019 18:00	1	1
11/25/2019 19:00	1	1
11/25/2019 20:00	1	1
11/25/2019 21:00	1	1
11/25/2019 22:00	1	1
11/25/2019 23:00	1	1
Average/Sum#:	1	0
Minimum:	0	0
Maximum:	4	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/26/2019 00:00	1	1
11/26/2019 01:00	1	1
11/26/2019 02:00	1	1
11/26/2019 03:00	1	1
11/26/2019 04:00	1	1
11/26/2019 05:00	1	1
11/26/2019 06:00	1	1
11/26/2019 07:00	1	1
11/26/2019 08:00	1	1
11/26/2019 09:00	1	1
11/26/2019 10:00	0	0
11/26/2019 11:00	0	0
11/26/2019 12:00	0	0
11/26/2019 13:00	0	0
11/26/2019 14:00	0	0
11/26/2019 15:00	1	0
11/26/2019 16:00	1	1
11/26/2019 17:00	1	1
11/26/2019 18:00	1	1
11/26/2019 19:00	1	1
11/26/2019 20:00	1	1
11/26/2019 21:00	1	1
11/26/2019 22:00	1	1
11/26/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/27/2019 00:00	1	1
11/27/2019 01:00	1	1
11/27/2019 02:00	1	1
11/27/2019 03:00	1	1
11/27/2019 04:00	1	1
11/27/2019 05:00	1	1
11/27/2019 06:00	1	1
11/27/2019 07:00	1	1
11/27/2019 08:00	1	1
11/27/2019 09:00	1	1
11/27/2019 10:00	1	1
11/27/2019 11:00	1	1
11/27/2019 12:00	1	1
11/27/2019 13:00	1	1
11/27/2019 14:00	1	1
11/27/2019 15:00	1	1
11/27/2019 16:00	1	1
11/27/2019 17:00	1	1
11/27/2019 18:00	1	1
11/27/2019 19:00	1	1
11/27/2019 20:00	1	1
11/27/2019 21:00	1	1
11/27/2019 22:00	1	1
11/27/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/28/2019 00:00	1	1
11/28/2019 01:00	1	1
11/28/2019 02:00	1	1
11/28/2019 03:00	1	1
11/28/2019 04:00	1	1
11/28/2019 05:00	1	1
11/28/2019 06:00	1	1
11/28/2019 07:00	1	1
11/28/2019 08:00	1	1
11/28/2019 09:00	1	1
11/28/2019 10:00	1	1
11/28/2019 11:00	1	1
11/28/2019 12:00	1	1
11/28/2019 13:00	1	1
11/28/2019 14:00	1	1
11/28/2019 15:00	1	1
11/28/2019 16:00	1	1
11/28/2019 17:00	1	1
11/28/2019 18:00	1	1
11/28/2019 19:00	1	1
11/28/2019 20:00	1	1
11/28/2019 21:00	1	1
11/28/2019 22:00	1	1
11/28/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/29/2019 00:00	1	1
11/29/2019 01:00	1	1
11/29/2019 02:00	1	1
11/29/2019 03:00	1	1
11/29/2019 04:00	1	1
11/29/2019 05:00	1	1
11/29/2019 06:00	1	1
11/29/2019 07:00	1	1
11/29/2019 08:00	1	1
11/29/2019 09:00	1	1
11/29/2019 10:00	0	0
11/29/2019 11:00	0	0
11/29/2019 12:00	0	0
11/29/2019 13:00	0	0
11/29/2019 14:00	0	0
11/29/2019 15:00	0	0
11/29/2019 16:00	0	0
11/29/2019 17:00	1	1
11/29/2019 18:00	1	1
11/29/2019 19:00	1	1
11/29/2019 20:00	1	1
11/29/2019 21:00	1	1
11/29/2019 22:00	1	1
11/29/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/30/2019 00:00	1	1
11/30/2019 01:00	1	1
11/30/2019 02:00	1	1
11/30/2019 03:00	1	1
11/30/2019 04:00	1	1
11/30/2019 05:00	1	1
11/30/2019 06:00	1	1
11/30/2019 07:00	1	1
11/30/2019 08:00	1	1
11/30/2019 09:00	1	1
11/30/2019 10:00	1	1
11/30/2019 11:00	1	1
11/30/2019 12:00	1	1
11/30/2019 13:00	1	1
11/30/2019 14:00	1	1
11/30/2019 15:00	1	1
11/30/2019 16:00	1	1
11/30/2019 17:00	1	1
11/30/2019 18:00	1	1
11/30/2019 19:00	1	1
11/30/2019 20:00	1	1
11/30/2019 21:00	1	1
11/30/2019 22:00	1	1
11/30/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/01/2019 00:00	1	1
12/01/2019 01:00	1	1
12/01/2019 02:00	1	1
12/01/2019 03:00	1	1
12/01/2019 04:00	1	1
12/01/2019 05:00	1	1
12/01/2019 06:00	1	1
12/01/2019 07:00	1	1
12/01/2019 08:00	1	1
12/01/2019 09:00	1	1
12/01/2019 10:00	1	1
12/01/2019 11:00	1	1
12/01/2019 12:00	1	1
12/01/2019 13:00	1	1
12/01/2019 14:00	1	1
12/01/2019 15:00	1	1
12/01/2019 16:00	1	1
12/01/2019 17:00	1	1
12/01/2019 18:00	1	1
12/01/2019 19:00	1	1
12/01/2019 20:00	1	1
12/01/2019 21:00	1	1
12/01/2019 22:00	1	1
12/01/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/02/2019 00:00	1	1
12/02/2019 01:00	1	1
12/02/2019 02:00	1	1
12/02/2019 03:00	1	1
12/02/2019 04:00	1	1
12/02/2019 05:00	1	1
12/02/2019 06:00	1	1
12/02/2019 07:00	1	1
12/02/2019 08:00	1	1
12/02/2019 09:00	1	1
12/02/2019 10:00	1	1
12/02/2019 11:00	1	1
12/02/2019 12:00	1	1
12/02/2019 13:00	1	1
12/02/2019 14:00	1	1
12/02/2019 15:00	1	1
12/02/2019 16:00	1	1
12/02/2019 17:00	1	1
12/02/2019 18:00	1	1
12/02/2019 19:00	1	1
12/02/2019 20:00	1	1
12/02/2019 21:00	1	1
12/02/2019 22:00	1	1
12/02/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/03/2019 00:00	1	1
12/03/2019 01:00	1	1
12/03/2019 02:00	1	1
12/03/2019 03:00	1	1
12/03/2019 04:00	1	1
12/03/2019 05:00	1	1
12/03/2019 06:00	1	1
12/03/2019 07:00	1	1
12/03/2019 08:00	1	1
12/03/2019 09:00	1	1
12/03/2019 10:00	1	1
12/03/2019 11:00	1	1
12/03/2019 12:00	1	1
12/03/2019 13:00	1	1
12/03/2019 14:00	1	1
12/03/2019 15:00	1	1
12/03/2019 16:00	1	1
12/03/2019 17:00	1	1
12/03/2019 18:00	1	1
12/03/2019 19:00	1	1
12/03/2019 20:00	1	1
12/03/2019 21:00	1	1
12/03/2019 22:00	1	1
12/03/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/04/2019 00:00	1	1
12/04/2019 01:00	1	1
12/04/2019 02:00	1	1
12/04/2019 03:00	1	1
12/04/2019 04:00	1	1
12/04/2019 05:00	1	1
12/04/2019 06:00	1	1
12/04/2019 07:00	1	1
12/04/2019 08:00	1	1
12/04/2019 09:00	1	1
12/04/2019 10:00	1	1
12/04/2019 11:00	1	1
12/04/2019 12:00	1	1
12/04/2019 13:00	1	1
12/04/2019 14:00	1	1
12/04/2019 15:00	1	1
12/04/2019 16:00	1	1
12/04/2019 17:00	1	1
12/04/2019 18:00	1	1
12/04/2019 19:00	1	1
12/04/2019 20:00	1	1
12/04/2019 21:00	1	1
12/04/2019 22:00	1	1
12/04/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/05/2019 00:00	1	1
12/05/2019 01:00	1	1
12/05/2019 02:00	1	1
12/05/2019 03:00	1	1
12/05/2019 04:00	1	1
12/05/2019 05:00	1	1
12/05/2019 06:00	1	1
12/05/2019 07:00	1	1
12/05/2019 08:00	1	1
12/05/2019 09:00	1	1
12/05/2019 10:00	1	1
12/05/2019 11:00	1	1
12/05/2019 12:00	1	1
12/05/2019 13:00	1	1
12/05/2019 14:00	1	1
12/05/2019 15:00	1	1
12/05/2019 16:00	1	1
12/05/2019 17:00	1	1
12/05/2019 18:00	1	1
12/05/2019 19:00	1	1
12/05/2019 20:00	1	1
12/05/2019 21:00	1	1
12/05/2019 22:00	1	1
12/05/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/06/2019 00:00	1	1
12/06/2019 01:00	1	1
12/06/2019 02:00	1	1
12/06/2019 03:00	1	1
12/06/2019 04:00	1	1
12/06/2019 05:00	1	1
12/06/2019 06:00	1	1
12/06/2019 07:00	1	1
12/06/2019 08:00	1	1
12/06/2019 09:00	1	1
12/06/2019 10:00	1	1
12/06/2019 11:00	1	1
12/06/2019 12:00	1	1
12/06/2019 13:00	1	1
12/06/2019 14:00	1	1
12/06/2019 15:00	1	1
12/06/2019 16:00	1	1
12/06/2019 17:00	1	1
12/06/2019 18:00	1	1
12/06/2019 19:00	1	0
12/06/2019 20:00	1	0
12/06/2019 21:00	1	0
12/06/2019 22:00	1	0
12/06/2019 23:00	1	0
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/07/2019 00:00	1	0
12/07/2019 01:00	1	0
12/07/2019 02:00	1	1
12/07/2019 03:00	1	1
12/07/2019 04:00	1	1
12/07/2019 05:00	1	1
12/07/2019 06:00	1	1
12/07/2019 07:00	1	1
12/07/2019 08:00	1	1
12/07/2019 09:00	1	1
12/07/2019 10:00	1	1
12/07/2019 11:00	1	1
12/07/2019 12:00	1	1
12/07/2019 13:00	1	1
12/07/2019 14:00	1	1
12/07/2019 15:00	1	1
12/07/2019 16:00	1	1
12/07/2019 17:00	1	1
12/07/2019 18:00	1	1
12/07/2019 19:00	1	1
12/07/2019 20:00	1	1
12/07/2019 21:00	1	1
12/07/2019 22:00	1	1
12/07/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/08/2019 00:00	1	1
12/08/2019 01:00	1	1
12/08/2019 02:00	1	1
12/08/2019 03:00	1	1
12/08/2019 04:00	0	0
12/08/2019 05:00	0	0
12/08/2019 06:00	0	0
12/08/2019 07:00	0	0
12/08/2019 08:00	0	0
12/08/2019 09:00	0	0
12/08/2019 10:00	0	0
12/08/2019 11:00	0	0
12/08/2019 12:00	0	0
12/08/2019 13:00	0	0
12/08/2019 14:00	0	0
12/08/2019 15:00	1	0
12/08/2019 16:00	1	1
12/08/2019 17:00	1	1
12/08/2019 18:00	1	1
12/08/2019 19:00	1	1
12/08/2019 20:00	1	1
12/08/2019 21:00	1	1
12/08/2019 22:00	1	1
12/08/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/09/2019 00:00	1	1
12/09/2019 01:00	1	1
12/09/2019 02:00	1	1
12/09/2019 03:00	1	1
12/09/2019 04:00	1	1
12/09/2019 05:00	1	1
12/09/2019 06:00	1	1
12/09/2019 07:00	1	1
12/09/2019 08:00	1	1
12/09/2019 09:00	1	1
12/09/2019 10:00	1	1
12/09/2019 11:00	1	1
12/09/2019 12:00	1	1
12/09/2019 13:00	1	1
12/09/2019 14:00	1	1
12/09/2019 15:00	1	1
12/09/2019 16:00	1	1
12/09/2019 17:00	1	1
12/09/2019 18:00	1	1
12/09/2019 19:00	1	1
12/09/2019 20:00	1	1
12/09/2019 21:00	1	1
12/09/2019 22:00	1	1
12/09/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/10/2019 00:00	1	1
12/10/2019 01:00	1	1
12/10/2019 02:00	1	1
12/10/2019 03:00	1	1
12/10/2019 04:00	1	1
12/10/2019 05:00	1	1
12/10/2019 06:00	1	1
12/10/2019 07:00	1	1
12/10/2019 08:00	1	1
12/10/2019 09:00	1	1
12/10/2019 10:00	1	1
12/10/2019 11:00	1	1
12/10/2019 12:00	1	1
12/10/2019 13:00	1	1
12/10/2019 14:00	1	1
12/10/2019 15:00	1	1
12/10/2019 16:00	1	1
12/10/2019 17:00	1	1
12/10/2019 18:00	1	1
12/10/2019 19:00	1	1
12/10/2019 20:00	1	1
12/10/2019 21:00	1	1
12/10/2019 22:00	1	1
12/10/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/11/2019 00:00	1	1
12/11/2019 01:00	1	1
12/11/2019 02:00	1	1
12/11/2019 03:00	1	1
12/11/2019 04:00	1	1
12/11/2019 05:00	1	1
12/11/2019 06:00	1	1
12/11/2019 07:00	1	1
12/11/2019 08:00	1	1
12/11/2019 09:00	1	1
12/11/2019 10:00	1	1
12/11/2019 11:00	1	1
12/11/2019 12:00	1	1
12/11/2019 13:00	1	1
12/11/2019 14:00	1	1
12/11/2019 15:00	1	1
12/11/2019 16:00	1	1
12/11/2019 17:00	1	1
12/11/2019 18:00	1	1
12/11/2019 19:00	1	1
12/11/2019 20:00	1	1
12/11/2019 21:00	1	1
12/11/2019 22:00	1	1
12/11/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/12/2019 00:00	1	1
12/12/2019 01:00	1	1
12/12/2019 02:00	1	1
12/12/2019 03:00	1	1
12/12/2019 04:00	1	1
12/12/2019 05:00	1	1
12/12/2019 06:00	1	1
12/12/2019 07:00	1	1
12/12/2019 08:00	1	1
12/12/2019 09:00	1	1
12/12/2019 10:00	1	1
12/12/2019 11:00	1	1
12/12/2019 12:00	1	1
12/12/2019 13:00	1	1
12/12/2019 14:00	1	1
12/12/2019 15:00	1	1
12/12/2019 16:00	1	1
12/12/2019 17:00	1	1
12/12/2019 18:00	1	1
12/12/2019 19:00	1	1
12/12/2019 20:00	1	1
12/12/2019 21:00	1	1
12/12/2019 22:00	1	1
12/12/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/13/2019 00:00	1	1
12/13/2019 01:00	1	1
12/13/2019 02:00	1	0
12/13/2019 03:00	1	0
12/13/2019 04:00	2	0
12/13/2019 05:00	3	0
12/13/2019 06:00	3	0
12/13/2019 07:00	2	0
12/13/2019 08:00	1	0
12/13/2019 09:00	0	0
12/13/2019 10:00	0	0
12/13/2019 11:00	0	0
12/13/2019 12:00	0	0
12/13/2019 13:00	0	0
12/13/2019 14:00	0	0
12/13/2019 15:00	1	0
12/13/2019 16:00	1	1
12/13/2019 17:00	1	1
12/13/2019 18:00	1	1
12/13/2019 19:00	1	1
12/13/2019 20:00	1	1
12/13/2019 21:00	1	1
12/13/2019 22:00	1	1
12/13/2019 23:00	1	1
Average/Sum#:	1	0
Minimum:	0	0
Maximum:	3	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/14/2019 00:00	1	1
12/14/2019 01:00	1	1
12/14/2019 02:00	1	1
12/14/2019 03:00	1	1
12/14/2019 04:00	1	0
12/14/2019 05:00	0	0
12/14/2019 06:00	0	0
12/14/2019 07:00	0	0
12/14/2019 08:00	0	0
12/14/2019 09:00	0	0
12/14/2019 10:00	0	0
12/14/2019 11:00	0	0
12/14/2019 12:00	0	0
12/14/2019 13:00	0	0
12/14/2019 14:00	0	0
12/14/2019 15:00	0	0
12/14/2019 16:00	1	0
12/14/2019 17:00	1	1
12/14/2019 18:00	1	1
12/14/2019 19:00	1	1
12/14/2019 20:00	1	1
12/14/2019 21:00	1	1
12/14/2019 22:00	1	1
12/14/2019 23:00	1	1
Average/Sum#:	1	0
Minimum:	0	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/15/2019 00:00	1	1
12/15/2019 01:00	1	1
12/15/2019 02:00	1	1
12/15/2019 03:00	1	1
12/15/2019 04:00	1	1
12/15/2019 05:00	1	1
12/15/2019 06:00	1	1
12/15/2019 07:00	1	1
12/15/2019 08:00	1	1
12/15/2019 09:00	1	1
12/15/2019 10:00	0	0
12/15/2019 11:00	0	0
12/15/2019 12:00	0	0
12/15/2019 13:00	0	0
12/15/2019 14:00	0	0
12/15/2019 15:00	0	0
12/15/2019 16:00	0	0
12/15/2019 17:00	1	1
12/15/2019 18:00	1	1
12/15/2019 19:00	1	1
12/15/2019 20:00	1	1
12/15/2019 21:00	1	1
12/15/2019 22:00	1	1
12/15/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/16/2019 00:00	1	1
12/16/2019 01:00	1	1
12/16/2019 02:00	1	1
12/16/2019 03:00	1	1
12/16/2019 04:00	1	1
12/16/2019 05:00	1	1
12/16/2019 06:00	1	1
12/16/2019 07:00	1	1
12/16/2019 08:00	1	1
12/16/2019 09:00	1	1
12/16/2019 10:00	1	1
12/16/2019 11:00	1	1
12/16/2019 12:00	1	1
12/16/2019 13:00	1	1
12/16/2019 14:00	1	1
12/16/2019 15:00	1	1
12/16/2019 16:00	1	1
12/16/2019 17:00	1	1
12/16/2019 18:00	1	1
12/16/2019 19:00	1	1
12/16/2019 20:00	1	1
12/16/2019 21:00	1	1
12/16/2019 22:00	1	1
12/16/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/17/2019 00:00	1	1
12/17/2019 01:00	1	1
12/17/2019 02:00	1	1
12/17/2019 03:00	1	1
12/17/2019 04:00	1	1
12/17/2019 05:00	1	1
12/17/2019 06:00	1	1
12/17/2019 07:00	1	1
12/17/2019 08:00	1	1
12/17/2019 09:00	1	1
12/17/2019 10:00	1	1
12/17/2019 11:00	1	1
12/17/2019 12:00	1	1
12/17/2019 13:00	1	1
12/17/2019 14:00	1	1
12/17/2019 15:00	1	1
12/17/2019 16:00	1	1
12/17/2019 17:00	1	1
12/17/2019 18:00	1	1
12/17/2019 19:00	1	1
12/17/2019 20:00	1	1
12/17/2019 21:00	1	1
12/17/2019 22:00	1	1
12/17/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/18/2019 00:00	1	1
12/18/2019 01:00	1	1
12/18/2019 02:00	1	1
12/18/2019 03:00	1	1
12/18/2019 04:00	1	1
12/18/2019 05:00	1	1
12/18/2019 06:00	1	1
12/18/2019 07:00	1	1
12/18/2019 08:00	1	1
12/18/2019 09:00	1	1
12/18/2019 10:00	1	1
12/18/2019 11:00	1	1
12/18/2019 12:00	1	1
12/18/2019 13:00	1	1
12/18/2019 14:00	1	1
12/18/2019 15:00	1	1
12/18/2019 16:00	1	1
12/18/2019 17:00	1	1
12/18/2019 18:00	1	1
12/18/2019 19:00	1	1
12/18/2019 20:00	1	1
12/18/2019 21:00	1	1
12/18/2019 22:00	1	1
12/18/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/19/2019 00:00	1	1
12/19/2019 01:00	1	1
12/19/2019 02:00	1	1
12/19/2019 03:00	1	1
12/19/2019 04:00	1	1
12/19/2019 05:00	1	1
12/19/2019 06:00	1	1
12/19/2019 07:00	1	1
12/19/2019 08:00	1	1
12/19/2019 09:00	1	1
12/19/2019 10:00	1	1
12/19/2019 11:00	1	1
12/19/2019 12:00	1	1
12/19/2019 13:00	1	1
12/19/2019 14:00	1	1
12/19/2019 15:00	1	1
12/19/2019 16:00	1	1
12/19/2019 17:00	1	1
12/19/2019 18:00	1	1
12/19/2019 19:00	1	1
12/19/2019 20:00	1	1
12/19/2019 21:00	1	1
12/19/2019 22:00	1	1
12/19/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/20/2019 00:00	1	1
12/20/2019 01:00	1	1
12/20/2019 02:00	1	1
12/20/2019 03:00	1	1
12/20/2019 04:00	1	1
12/20/2019 05:00	1	1
12/20/2019 06:00	1	1
12/20/2019 07:00	1	1
12/20/2019 08:00	1	1
12/20/2019 09:00	1	1
12/20/2019 10:00	1	1
12/20/2019 11:00	1	1
12/20/2019 12:00	1	1
12/20/2019 13:00	1	0
12/20/2019 14:00	0	0
12/20/2019 15:00	1	0
12/20/2019 16:00	1	1
12/20/2019 17:00	1	1
12/20/2019 18:00	1	1
12/20/2019 19:00	1	1
12/20/2019 20:00	1	1
12/20/2019 21:00	1	1
12/20/2019 22:00	1	1
12/20/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/21/2019 00:00	1	1
12/21/2019 01:00	1	1
12/21/2019 02:00	1	1
12/21/2019 03:00	1	1
12/21/2019 04:00	1	1
12/21/2019 05:00	1	1
12/21/2019 06:00	1	1
12/21/2019 07:00	1	1
12/21/2019 08:00	1	1
12/21/2019 09:00	1	1
12/21/2019 10:00	1	1
12/21/2019 11:00	1	1
12/21/2019 12:00	1	1
12/21/2019 13:00	1	1
12/21/2019 14:00	1	1
12/21/2019 15:00	1	1
12/21/2019 16:00	1	1
12/21/2019 17:00	1	1
12/21/2019 18:00	1	1
12/21/2019 19:00	1	1
12/21/2019 20:00	1	1
12/21/2019 21:00	1	1
12/21/2019 22:00	1	1
12/21/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/22/2019 00:00	1	1
12/22/2019 01:00	1	1
12/22/2019 02:00	1	1
12/22/2019 03:00	1	1
12/22/2019 04:00	1	1
12/22/2019 05:00	1	1
12/22/2019 06:00	1	1
12/22/2019 07:00	1	1
12/22/2019 08:00	1	1
12/22/2019 09:00	1	1
12/22/2019 10:00	1	1
12/22/2019 11:00	1	1
12/22/2019 12:00	1	1
12/22/2019 13:00	1	1
12/22/2019 14:00	1	1
12/22/2019 15:00	1	1
12/22/2019 16:00	1	1
12/22/2019 17:00	1	1
12/22/2019 18:00	1	1
12/22/2019 19:00	1	1
12/22/2019 20:00	1	1
12/22/2019 21:00	1	1
12/22/2019 22:00	1	1
12/22/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/23/2019 00:00	1	1
12/23/2019 01:00	1	1
12/23/2019 02:00	1	1
12/23/2019 03:00	1	1
12/23/2019 04:00	1	1
12/23/2019 05:00	1	1
12/23/2019 06:00	1	1
12/23/2019 07:00	1	1
12/23/2019 08:00	1	1
12/23/2019 09:00	1	1
12/23/2019 10:00	1	1
12/23/2019 11:00	1	1
12/23/2019 12:00	1	1
12/23/2019 13:00	1	1
12/23/2019 14:00	1	1
12/23/2019 15:00	1	1
12/23/2019 16:00	1	1
12/23/2019 17:00	1	1
12/23/2019 18:00	1	1
12/23/2019 19:00	1	1
12/23/2019 20:00	1	1
12/23/2019 21:00	1	1
12/23/2019 22:00	1	1
12/23/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/24/2019 00:00	1	1
12/24/2019 01:00	1	1
12/24/2019 02:00	1	1
12/24/2019 03:00	1	1
12/24/2019 04:00	1	1
12/24/2019 05:00	1	1
12/24/2019 06:00	1	1
12/24/2019 07:00	1	1
12/24/2019 08:00	1	1
12/24/2019 09:00	1	1
12/24/2019 10:00	1	1
12/24/2019 11:00	1	1
12/24/2019 12:00	1	1
12/24/2019 13:00	1	1
12/24/2019 14:00	1	1
12/24/2019 15:00	1	1
12/24/2019 16:00	1	1
12/24/2019 17:00	1	1
12/24/2019 18:00	1	1
12/24/2019 19:00	1	1
12/24/2019 20:00	1	1
12/24/2019 21:00	1	1
12/24/2019 22:00	1	1
12/24/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/25/2019 00:00	1	1
12/25/2019 01:00	1	1
12/25/2019 02:00	1	1
12/25/2019 03:00	1	1
12/25/2019 04:00	1	1
12/25/2019 05:00	1	1
12/25/2019 06:00	1	1
12/25/2019 07:00	1	1
12/25/2019 08:00	1	1
12/25/2019 09:00	1	1
12/25/2019 10:00	1	1
12/25/2019 11:00	1	1
12/25/2019 12:00	1	1
12/25/2019 13:00	1	1
12/25/2019 14:00	1	1
12/25/2019 15:00	1	1
12/25/2019 16:00	1	1
12/25/2019 17:00	1	1
12/25/2019 18:00	1	1
12/25/2019 19:00	1	1
12/25/2019 20:00	1	1
12/25/2019 21:00	1	1
12/25/2019 22:00	1	1
12/25/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/26/2019 00:00	1	1
12/26/2019 01:00	1	1
12/26/2019 02:00	1	1
12/26/2019 03:00	1	1
12/26/2019 04:00	1	1
12/26/2019 05:00	1	1
12/26/2019 06:00	1	1
12/26/2019 07:00	1	1
12/26/2019 08:00	1	1
12/26/2019 09:00	1	1
12/26/2019 10:00	1	1
12/26/2019 11:00	1	1
12/26/2019 12:00	1	1
12/26/2019 13:00	1	1
12/26/2019 14:00	1	1
12/26/2019 15:00	1	1
12/26/2019 16:00	1	1
12/26/2019 17:00	1	1
12/26/2019 18:00	1	1
12/26/2019 19:00	1	1
12/26/2019 20:00	1	1
12/26/2019 21:00	1	1
12/26/2019 22:00	1	1
12/26/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/27/2019 00:00	1	1
12/27/2019 01:00	1	1
12/27/2019 02:00	1	1
12/27/2019 03:00	1	1
12/27/2019 04:00	1	1
12/27/2019 05:00	1	1
12/27/2019 06:00	1	1
12/27/2019 07:00	1	1
12/27/2019 08:00	1	1
12/27/2019 09:00	0	0
12/27/2019 10:00	0	0
12/27/2019 11:00	0	0
12/27/2019 12:00	0	0
12/27/2019 13:00	0	0
12/27/2019 14:00	0	0
12/27/2019 15:00	0	0
12/27/2019 16:00	0	0
12/27/2019 17:00	0	0
12/27/2019 18:00	0	0
12/27/2019 19:00	0	0
12/27/2019 20:00	0	0
12/27/2019 21:00	0	0
12/27/2019 22:00	0	0
12/27/2019 23:00	0	0
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	62.50	62.50

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/28/2019 00:00	0	0
12/28/2019 01:00	0	0
12/28/2019 02:00	0	0
12/28/2019 03:00	0	0
12/28/2019 04:00	0	0
12/28/2019 05:00	0	0
12/28/2019 06:00	0	0
12/28/2019 07:00	0	0
12/28/2019 08:00	0	0
12/28/2019 09:00	0	0
12/28/2019 10:00	0	0
12/28/2019 11:00	0	0
12/28/2019 12:00	0	0
12/28/2019 13:00	0	0
12/28/2019 14:00	0	0
12/28/2019 15:00	0	0
12/28/2019 16:00	0	0
12/28/2019 17:00	0	0
12/28/2019 18:00	0	0
12/28/2019 19:00	0	0
12/28/2019 20:00	0	0
12/28/2019 21:00	0	0
12/28/2019 22:00	0	0
12/28/2019 23:00	0	0
Average/Sum#:	0	0
Minimum:	0	0
Maximum:	0	0
%SI	100.00	100.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/29/2019 00:00	0	0
12/29/2019 01:00	0	0
12/29/2019 02:00	0	0
12/29/2019 03:00	0	0
12/29/2019 04:00	0	0
12/29/2019 05:00	0	0
12/29/2019 06:00	0	1
12/29/2019 07:00	0	1
12/29/2019 08:00	1	1
12/29/2019 09:00	0	1
12/29/2019 10:00	0	0
12/29/2019 11:00	0	0
12/29/2019 12:00	0	0
12/29/2019 13:00	0	0
12/29/2019 14:00	0	0
12/29/2019 15:00	0	0
12/29/2019 16:00	0	1
12/29/2019 17:00	1	1
12/29/2019 18:00	1	1
12/29/2019 19:00	1	1
12/29/2019 20:00	1	1
12/29/2019 21:00	1	1
12/29/2019 22:00	1	1
12/29/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	0
Maximum:	1	1
%SI	33.33	25.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/30/2019 00:00	1	1
12/30/2019 01:00	1	1
12/30/2019 02:00	1	1
12/30/2019 03:00	1	1
12/30/2019 04:00	1	1
12/30/2019 05:00	1	1
12/30/2019 06:00	1	1
12/30/2019 07:00	1	1
12/30/2019 08:00	1	1
12/30/2019 09:00	1	1
12/30/2019 10:00	1	1
12/30/2019 11:00	1	1
12/30/2019 12:00	1	1
12/30/2019 13:00	1	1
12/30/2019 14:00	1	1
12/30/2019 15:00	1	1
12/30/2019 16:00	1	1
12/30/2019 17:00	1	1
12/30/2019 18:00	1	1
12/30/2019 19:00	1	1
12/30/2019 20:00	1	1
12/30/2019 21:00	1	1
12/30/2019 22:00	1	1
12/30/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 09:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/31/2019 00:00	1	1
12/31/2019 01:00	1	1
12/31/2019 02:00	1	1
12/31/2019 03:00	1	1
12/31/2019 04:00	1	1
12/31/2019 05:00	1	1
12/31/2019 06:00	1	1
12/31/2019 07:00	1	1
12/31/2019 08:00	1	1
12/31/2019 09:00	1	1
12/31/2019 10:00	1	1
12/31/2019 11:00	0	0
12/31/2019 12:00	0	0
12/31/2019 13:00	0	0
12/31/2019 14:00	0	0
12/31/2019 15:00	0	0
12/31/2019 16:00	0	0
12/31/2019 17:00	1	1
12/31/2019 18:00	1	1
12/31/2019 19:00	1	1
12/31/2019 20:00	1	1
12/31/2019 21:00	1	1
12/31/2019 22:00	1	1
12/31/2019 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	0
Maximum:	1	1
%SI	0.00	0.00

Excess Emission Report

CT1 NOx 30 Day Rolling Average (KKKK)

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 09:45 **Location:** Maxwell, CA

Tag Name: CT1_NOx_30D_Ppmvdc_1D
Total Operating Time: 90.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 2.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**90.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 NOx 30 Day Rolling Average (KKKK)

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 09:44 **Location:** Maxwell, CA

Tag Name: CT2_NOx_30D_Ppmvdc_1D
Total Operating Time: 91.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 1.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**91.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 4
Excess Emission/Downtime Report

FCD: AQ-4
Title V: #29

EDS-CMS Reports

EDS/CMS Summary Report

CT1 - CO LbPerHr

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 09:50 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_CO_LbPerHr_1H
EDS Data from: CT1_CONormalOp_LbPerHr_1H
Emission Limitation: CT1_COLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 2,059.00 Hour(s)
Operating time for CMS: 2,059.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	47
e. Unknown causes	0
2. Total CMS Downtime	47
3. Total Downtime as a percentage of operating time	2.28
4. Total Availability as a percentage of operating time	97.72

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - CO Ppmvdc

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 09:58 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_CO_Ppmvdc_1H
EDS Data from: CT1_CO_3Hr_Ppmvdc_1H
Emission Limitation: CT1_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 2,059.00 Hour(s)
Operating time for CMS: 2,059.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	47
e. Unknown causes	0
2. Total CMS Downtime	47
3. Total Downtime as a percentage of operating time	2.28
4. Total Availability as a percentage of operating time	97.72

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx LbPerHr

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 10:01 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_NOx_LbPerHr_1H
EDS Data from: CT1_NOxNormalOp_LbPerHr_1H
Emission Limitation: CT1_NOxLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 2,059.00 Hour(s)
Operating time for CMS: 2,059.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	48
e. Unknown causes	0
2. Total CMS Downtime	48
3. Total Downtime as a percentage of operating time	2.33
4. Total Availability as a percentage of operating time	97.67

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx Ppmvdc

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 10:05 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Ppmvdc_1H
EDS Data from: CT1_NOx_Ppmvdc_1H
Emission Limitation: CT1_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 2,059.00 Hour(s)
Operating time for CMS: 2,059.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	47
e. Unknown causes	0
2. Total CMS Downtime	47
3. Total Downtime as a percentage of operating time	2.28
4. Total Availability as a percentage of operating time	97.72

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO LbPerHr

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 10:05 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_CO_LbPerHr_1H
EDS Data from: CT2_CONormalOp_LbPerHr_1H
Emission Limitation: CT2_COLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 2,145.00 Hour(s)
Operating time for CMS: 2,145.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	53
e. Unknown causes	0
2. Total CMS Downtime	54
3. Total Downtime as a percentage of operating time	2.52
4. Total Availability as a percentage of operating time	97.48

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO Ppmvdc

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 11:32 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_CO_Ppmvdc_1H
EDS Data from: CT2_CO_3Hr_Ppmvdc_1H
Emission Limitation: CT2_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 2,145.00 Hour(s)
Operating time for CMS: 2,145.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	53
e. Unknown causes	0
2. Total CMS Downtime	54
3. Total Downtime as a percentage of operating time	2.52
4. Total Availability as a percentage of operating time	97.48

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - NOx LbPerHr

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 11:34 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_NOx_LbPerHr_1H
EDS Data from: CT2_NOxNormalOp_LbPerHr_1H
Emission Limitation: CT2_NOxLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 2,145.00 Hour(s)
Operating time for CMS: 2,145.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	54
e. Unknown causes	0
2. Total CMS Downtime	55
3. Total Downtime as a percentage of operating time	2.56
4. Total Availability as a percentage of operating time	97.44

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - NOx Ppmvdc

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 11:34 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_NOx_Ppmvdc_1H
EDS Data from: CT2_NOx_Ppmvdc_1H
Emission Limitation: CT2_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 2,145.00 Hour(s)
Operating time for CMS: 2,145.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	53
e. Unknown causes	0
2. Total CMS Downtime	54
3. Total Downtime as a percentage of operating time	2.52
4. Total Availability as a percentage of operating time	97.48

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

Excess Emission Report

CT1 - CO LbPerHr Normal Operating 1-Hour Block Average

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 11:39 **Location:** Maxwell, CA

Tag Name: CT1_CONormalOp_LbPerHr_1H
Total Operating Time: 2,059.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 149.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,059.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - CO Ppmvdc 3-Hour Rolling Average

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 11:39 **Location:** Maxwell, CA

Tag Name: CT1_CO_3Hr_Ppmvdc_1H
Total Operating Time: 2,059.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 149.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,059.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NOx LbPerHr Normal Operating 1-Hour Block Average

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 11:40 **Location:** Maxwell, CA

Tag Name: CT1_NOxNormalOp_LbPerHr_1H
Total Operating Time: 2,059.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 149.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,059.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NOx Ppmvdc 1-Hour Block Average

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 11:42 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Ppmvdc_1H
Total Operating Time: 2,059.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 149.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,059.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO LbPerHr Normal Operating 1-Hour Block Average

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 11:47 **Location:** Maxwell, CA

Tag Name: CT2_CONormalOp_LbPerHr_1H
Total Operating Time: 2,145.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 63.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,145.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO Ppmvdc 3-Hour Rolling Average

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 11:48 **Location:** Maxwell, CA

Tag Name: CT2_CO_3Hr_Ppmvdc_1H
Total Operating Time: 2,145.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 63.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,145.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx LbPerHr Normal Operating 1-Hour Block Average

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 11:49 **Location:** Maxwell, CA

Tag Name: CT2_NOxNormalOp_LbPerHr_1H
Total Operating Time: 2,145.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 63.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,145.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx Ppmvdc 1-Hour Block Average

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 11:55 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Ppmvdc_1H
Total Operating Time: 2,145.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 63.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,145.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Invalid Data Report

CT1 - Stack CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 11:56 **Location:** Maxwell, CA

Tag Name: CT1_CO_LbPerHr_1H
Total Operating Time: 2,059.00 Hour(s)
Non-Operating Time: 149.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	11/19/2019 09:00	11/19/2019 09:59	1	13 - Maintenance	6 - Replaced malfunctioning component, performed calibration sequence
2	12/27/2019 08:00	12/29/2019 05:59	46	4 - Other known causes	7 - NEW SERVER INSTALLED- NORMAL OPERATIONS RESUMED

Total Operating Time:	**2,059.00 Hour(s)**
Total Monitor Downtime (Online only):	**47.00 Hour(s)**
Percent Monitor Availability:	**97.72 %**
Percent Monitor Downtime:	**2.28 %**

Report Code	Type	Text	Duration	Duration Percent
13	Reason	Maintenance	1	2.13
4	Reason	Other known causes	46	97.87
7	Action	NEW SERVER INSTALLED- NORMAL OPERATIONS RESUMED	46	97.87
6	Action	Replaced malfunctioning component, performed calibration sequence	1	2.13

Invalid Data Report

CT1 - Stack NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 11:57 **Location:** Maxwell, CA

Tag Name: CT1_NOx_LbPerHr_1H
Total Operating Time: 2,059.00 Hour(s)
Non-Operating Time: 149.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	11/19/2019 09:00	11/19/2019 09:59	1	13 - Maintenance	6 - Replaced malfunctioning component, performed calibration sequence
2	12/27/2019 07:00	12/29/2019 05:59	47	4 - Other known causes	7 - NEW SERVER INSTALLED- NORMAL OPERATIONS RESUMED

Total Operating Time:	**2,059.00 Hour(s)**
Total Monitor Downtime (Online only):	**48.00 Hour(s)**
Percent Monitor Availability:	**97.67 %**
Percent Monitor Downtime:	**2.33 %**

Report Code	Type	Text	Duration	Duration Percent
13	Reason	Maintenance	1	2.08
4	Reason	Other known causes	47	97.92
7	Action	NEW SERVER INSTALLED- NORMAL OPERATIONS RESUMED	47	97.92
6	Action	Replaced malfunctioning component, performed calibration sequence	1	2.08

Invalid Data Report

CT2 - Stack CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 11:57 **Location:** Maxwell, CA

Tag Name: CT2_CO_LbPerHr_1H
Total Operating Time: 2,145.00 Hour(s)
Non-Operating Time: 63.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	10/14/2019 12:00	10/14/2019 12:59	1	3 - Quality assurance calibration	8 - Quarterly Maintenance
2	11/19/2019 12:00	11/19/2019 13:59	2	13 - Maintenance	6 - Replaced malfunctioning component, performed calibration sequence
3	11/20/2019 08:00	11/20/2019 12:59	5	13 - Maintenance	6 - Replaced malfunctioning component, performed calibration sequence
4	12/27/2019 08:00	12/29/2019 05:59	46	4 - Other known causes	7 - NEW SERVER INSTALLED- NORMAL OPERATIONS RESUMED

Total Operating Time:	**2,145.00 Hour(s)**
Total Monitor Downtime (Online only):	**54.00 Hour(s)**
Percent Monitor Availability:	**97.48 %**
Percent Monitor Downtime:	**2.52 %**

Report Code	Type	Text	Duration	Duration Percent
13	Reason	Maintenance	7	12.96
4	Reason	Other known causes	46	85.19
3	Reason	Quality assurance calibration	1	1.85
7	Action	NEW SERVER INSTALLED- NORMAL OPERATIONS RESUMED	46	85.19
8	Action	Quarterly Maintenance	1	1.85
6	Action	Replaced malfunctioning component, performed calibration sequence	7	12.96

Invalid Data Report

CT2 - Stack NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 11:58 **Location:** Maxwell, CA

Tag Name: CT2_NOx_LbPerHr_1H

Total Operating Time: 2,145.00 Hour(s)

Non-Operating Time: 63.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	10/14/2019 12:00	10/14/2019 12:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga
2	11/19/2019 12:00	11/19/2019 13:59	2	13 - Maintenance	6 - Replaced malfunctioning component, performed calibration sequence
3	11/20/2019 08:00	11/20/2019 12:59	5	13 - Maintenance	6 - Replaced malfunctioning component, performed calibration sequence
4	12/27/2019 07:00	12/29/2019 05:59	47	4 - Other known causes	7 - NEW SERVER INSTALLED- NORMAL OPERATIONS RESUMED

Total Operating Time:	**2,145.00 Hour(s)**
Total Monitor Downtime (Online only):	**55.00 Hour(s)**
Percent Monitor Availability:	**97.44 %**
Percent Monitor Downtime:	**2.56 %**

Report Code	Type	Text	Duration	Duration Percent
13	Reason	Maintenance	7	12.73
4	Reason	Other known causes	47	85.45
3	Reason	Quality assurance calibration	1	1.82
7	Action	NEW SERVER INSTALLED- NORMAL OPERATIONS RESUMED	47	85.45
4	Action	Quarterly linearity/cga	1	1.82
6	Action	Replaced malfunctioning component, performed calibration sequence	7	12.73

ATTACHMENT 5
Hourly Emissions – VOC

FCD: AQ-14
Title V: #6

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/01/2019 00:00	0.0	18.2	42.3	0.0	0.0	1	0	0
10/01/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2019 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2019 04:00	0.0	17.8	412.4	0.0	0.3	1	0	0
10/01/2019 05:00	0.0	14.9	1,149.8	0.0	0.8	1	0	0
10/01/2019 06:00	0.6	14.0	1,625.3	0.6	1.1	1	1	0
10/01/2019 07:00	0.6	14.0	1,615.8	0.6	1.1	1	1	0
10/01/2019 08:00	0.6	14.1	1,628.7	0.6	1.1	1	1	0
10/01/2019 09:00	0.6	14.1	1,613.9	0.6	1.1	1	1	0
10/01/2019 10:00	0.6	14.1	1,594.1	0.6	1.1	1	1	0
10/01/2019 11:00	0.6	14.1	1,600.9	0.6	1.1	1	1	0
10/01/2019 12:00	0.6	14.1	1,584.5	0.6	1.1	1	1	0
10/01/2019 13:00	0.6	14.1	1,585.8	0.6	1.1	1	1	0
10/01/2019 14:00	0.6	14.0	1,557.4	0.6	1.1	1	1	0
10/01/2019 15:00	0.7	14.0	1,577.6	0.7	1.1	1	1	1
10/01/2019 16:00	-0.5	12.7	1,976.0	-0.2	1.4	1	1	1
10/01/2019 17:00	-0.4	12.4	2,020.5	-0.1	1.4	1	1	1
10/01/2019 18:00	-0.1	12.3	2,037.9	0.2	1.4	1	1	1
10/01/2019 19:00	0.4	12.2	2,041.4	0.5	1.4	1	1	1
10/01/2019 20:00	0.5	12.2	2,042.8	0.5	1.4	1	1	1
10/01/2019 21:00	0.5	12.3	2,029.9	0.5	1.4	1	1	1
10/01/2019 22:00	0.5	12.4	1,999.2	0.5	1.4	1	1	1
10/01/2019 23:00	0.4	12.5	2,009.0	0.5	1.4	1	1	1
Average/Sum#:	0.4	13.8	1,606.9	0.4	1.1	21 #	18 #	9 #
Minimum:	-0.5	12.2	42.3	-0.2	0.0	0	0	0
Maximum:	0.7	18.2	2,042.8	0.7	1.4	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/02/2019 00:00	0.4	12.4	2,056.0	0.5	1.4	1	1	1
10/02/2019 01:00	0.4	12.4	2,044.5	0.5	1.4	1	1	1
10/02/2019 02:00	0.4	12.4	2,031.7	0.5	1.4	1	1	1
10/02/2019 03:00	0.4	12.4	2,028.5	0.5	1.4	1	1	1
10/02/2019 04:00	0.4	12.6	1,989.4	0.5	1.4	1	1	1
10/02/2019 05:00	0.2	12.3	2,020.9	0.4	1.4	1	1	1
10/02/2019 06:00	0.4	12.5	2,017.8	0.5	1.4	1	1	1
10/02/2019 07:00	0.4	12.9	1,924.7	0.5	1.3	1	1	1
10/02/2019 08:00	0.6	14.1	1,560.2	0.6	1.1	1	1	0
10/02/2019 09:00	0.6	14.1	1,254.3	0.6	0.9	1	1	0
10/02/2019 10:00	0.6	14.1	1,263.2	0.6	0.9	1	1	0
10/02/2019 11:00	0.6	14.2	1,285.9	0.6	0.9	1	1	0
10/02/2019 12:00	0.6	14.2	1,257.9	0.6	0.9	1	1	0
10/02/2019 13:00	0.6	14.2	1,276.3	0.6	0.9	1	1	0
10/02/2019 14:00	0.7	14.0	1,537.0	0.7	1.1	1	1	1
10/02/2019 15:00	-0.4	12.7	1,966.4	-0.1	1.4	1	1	1
10/02/2019 16:00	-0.4	12.2	2,051.6	-0.1	1.4	1	1	1
10/02/2019 17:00	-0.2	12.1	2,072.2	0.1	1.5	1	1	1
10/02/2019 18:00	-0.2	12.2	2,065.4	0.1	1.4	1	1	1
10/02/2019 19:00	0.1	12.1	2,064.0	0.2	1.4	1	1	1
10/02/2019 20:00	0.4	12.1	2,060.4	0.5	1.4	1	1	1
10/02/2019 21:00	0.4	12.2	2,035.8	0.5	1.4	1	1	1
10/02/2019 22:00	0.4	12.4	2,005.7	0.5	1.4	1	1	1
10/02/2019 23:00	0.4	12.7	1,971.1	0.5	1.4	1	1	1
Average/Sum#:	0.3	12.9	1,826.7	0.4	1.3	24 #	24 #	18 #
Minimum:	-0.4	12.1	1,254.3	-0.1	0.9	1	1	0
Maximum:	0.7	14.2	2,072.2	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/03/2019 00:00	0.4	12.6	1,974.8	0.5	1.4	1	1	1
10/03/2019 01:00	0.5	12.9	1,912.3	0.5	1.3	1	1	1
10/03/2019 02:00	0.4	12.7	1,964.7	0.5	1.4	1	1	1
10/03/2019 03:00	0.4	12.5	1,997.3	0.5	1.4	1	1	1
10/03/2019 04:00	0.4	12.5	2,015.1	0.5	1.4	1	1	1
10/03/2019 05:00	0.2	12.5	2,007.9	0.4	1.4	1	1	1
10/03/2019 06:00	0.4	12.4	2,026.9	0.5	1.4	1	1	1
10/03/2019 07:00	0.4	12.7	1,928.3	0.5	1.3	1	1	1
10/03/2019 08:00	0.6	14.0	1,450.1	0.6	1.0	1	1	0
10/03/2019 09:00	0.6	14.1	1,259.2	0.6	0.9	1	1	0
10/03/2019 10:00	0.6	14.1	1,247.4	0.6	0.9	1	1	0
10/03/2019 11:00	0.6	14.1	1,248.7	0.6	0.9	1	1	0
10/03/2019 12:00	0.6	14.1	1,307.6	0.6	0.9	1	1	0
10/03/2019 13:00	0.6	14.1	1,290.2	0.6	0.9	1	1	0
10/03/2019 14:00	0.6	14.1	1,343.0	0.6	0.9	1	1	0
10/03/2019 15:00	0.6	14.1	1,353.6	0.6	0.9	1	1	0
10/03/2019 16:00	0.6	14.0	1,595.8	0.6	1.1	1	1	0
10/03/2019 17:00	0.6	14.0	1,582.6	0.6	1.1	1	1	0
10/03/2019 18:00	0.6	14.0	1,585.6	0.6	1.1	1	1	0
10/03/2019 19:00	0.6	14.0	1,613.7	0.6	1.1	1	1	0
10/03/2019 20:00	0.6	14.1	1,594.8	0.6	1.1	1	1	0
10/03/2019 21:00	0.0	14.7	1,232.4	0.0	0.9	1	0	0
10/03/2019 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2019 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.5	13.6	1,615.1	0.5	1.1	22 #	21 #	8 #
Minimum:	0.0	12.4	1,232.4	0.0	0.9	0	0	0
Maximum:	0.6	14.7	2,026.9	0.6	1.4	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/04/2019 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2019 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2019 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2019 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2019 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2019 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2019 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2019 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2019 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2019 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2019 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2019 13:00	0.0	18.0	387.9	0.0	0.3	1	0	0
10/04/2019 14:00	0.0	15.3	914.2	0.0	0.6	1	0	0
10/04/2019 15:00	0.6	14.2	1,414.6	0.6	1.0	1	1	0
10/04/2019 16:00	0.7	14.1	1,507.0	0.7	1.1	1	1	1
10/04/2019 17:00	-0.2	12.8	1,963.5	0.1	1.4	1	1	1
10/04/2019 18:00	0.1	12.2	2,093.2	0.2	1.5	1	1	1
10/04/2019 19:00	0.4	12.3	2,036.0	0.5	1.4	1	1	1
10/04/2019 20:00	0.4	12.2	2,046.2	0.5	1.4	1	1	1
10/04/2019 21:00	0.5	12.3	2,037.7	0.5	1.4	1	1	1
10/04/2019 22:00	0.5	12.4	2,015.0	0.5	1.4	1	1	1
10/04/2019 23:00	0.4	12.5	1,999.3	0.5	1.4	1	1	1
Average/Sum#:	0.3	13.5	1,674.1	0.4	1.2	11 #	9 #	8 #
Minimum:	-0.2	12.2	387.9	0.0	0.3	0	0	0
Maximum:	0.7	18.0	2,093.2	0.7	1.5	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/05/2019 00:00	0.4	12.7	1,959.8	0.5	1.4	1	1	1
10/05/2019 01:00	0.4	12.8	1,941.2	0.5	1.4	1	1	1
10/05/2019 02:00	0.5	13.0	1,904.4	0.5	1.3	1	1	1
10/05/2019 03:00	0.4	12.6	1,979.6	0.5	1.4	1	1	1
10/05/2019 04:00	0.4	12.5	2,008.3	0.5	1.4	1	1	1
10/05/2019 05:00	0.2	12.3	2,034.5	0.4	1.4	1	1	1
10/05/2019 06:00	0.4	12.7	1,981.1	0.5	1.4	1	1	1
10/05/2019 07:00	0.4	13.0	1,890.7	0.5	1.3	1	1	1
10/05/2019 08:00	0.6	14.0	1,495.3	0.6	1.0	1	1	0
10/05/2019 09:00	0.6	14.2	1,248.9	0.6	0.9	1	1	0
10/05/2019 10:00	0.6	14.2	1,243.4	0.6	0.9	1	1	0
10/05/2019 11:00	0.6	14.2	1,249.6	0.6	0.9	1	1	0
10/05/2019 12:00	0.6	14.2	1,297.4	0.6	0.9	1	1	0
10/05/2019 13:00	0.6	14.2	1,249.9	0.6	0.9	1	1	0
10/05/2019 14:00	0.6	14.2	1,429.4	0.6	1.0	1	1	0
10/05/2019 15:00	0.7	14.0	1,477.3	0.7	1.0	1	1	1
10/05/2019 16:00	-0.2	12.8	1,930.6	0.1	1.4	1	1	1
10/05/2019 17:00	-0.4	12.4	2,014.8	-0.1	1.4	1	1	1
10/05/2019 18:00	-0.4	12.4	2,021.5	-0.1	1.4	1	1	1
10/05/2019 19:00	-0.2	12.3	2,039.0	0.1	1.4	1	1	1
10/05/2019 20:00	-0.2	12.1	2,077.2	0.1	1.5	1	1	1
10/05/2019 21:00	-0.2	12.1	2,081.1	0.1	1.5	1	1	1
10/05/2019 22:00	-0.2	12.2	2,048.9	0.1	1.4	1	1	1
10/05/2019 23:00	-0.2	12.3	2,049.9	0.1	1.4	1	1	1
Average/Sum#:	0.3	13.1	1,777.2	0.4	1.2	24 #	24 #	17 #
Minimum:	-0.4	12.1	1,243.4	-0.1	0.9	1	1	0
Maximum:	0.7	14.2	2,081.1	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/06/2019 00:00	-0.2	12.3	2,028.2	0.1	1.4	1	1	1
10/06/2019 01:00	-0.2	12.6	1,974.3	0.1	1.4	1	1	1
10/06/2019 02:00	-0.4	12.6	1,977.7	-0.1	1.4	1	1	1
10/06/2019 03:00	-0.4	12.6	1,977.2	-0.1	1.4	1	1	1
10/06/2019 04:00	0.1	12.5	1,968.9	0.2	1.4	1	1	1
10/06/2019 05:00	0.2	12.4	1,976.0	0.4	1.4	1	1	1
10/06/2019 06:00	0.4	12.7	1,916.2	0.5	1.3	1	1	1
10/06/2019 07:00	0.6	14.1	1,478.5	0.6	1.0	1	1	0
10/06/2019 08:00	0.6	14.2	1,311.8	0.6	0.9	1	1	0
10/06/2019 09:00	0.6	14.2	1,235.3	0.6	0.9	1	1	0
10/06/2019 10:00	0.6	14.2	1,290.1	0.6	0.9	1	1	0
10/06/2019 11:00	0.6	14.2	1,320.5	0.6	0.9	1	1	0
10/06/2019 12:00	0.6	14.2	1,354.5	0.6	0.9	1	1	0
10/06/2019 13:00	0.6	14.2	1,326.5	0.6	0.9	1	1	0
10/06/2019 14:00	0.7	14.0	1,550.8	0.7	1.1	1	1	1
10/06/2019 15:00	-0.2	12.5	1,975.8	0.1	1.4	1	1	1
10/06/2019 16:00	-0.2	12.2	2,044.0	0.1	1.4	1	1	1
10/06/2019 17:00	-0.1	11.8	2,113.5	0.2	1.5	1	1	1
10/06/2019 18:00	-0.1	11.7	2,145.2	0.2	1.5	1	1	1
10/06/2019 19:00	-0.1	12.0	2,081.7	0.2	1.5	1	1	1
10/06/2019 20:00	-0.1	12.1	2,063.8	0.2	1.4	1	1	1
10/06/2019 21:00	-0.2	12.1	2,069.2	0.1	1.4	1	1	1
10/06/2019 22:00	-0.2	12.4	2,029.3	0.1	1.4	1	1	1
10/06/2019 23:00	0.2	12.6	1,971.4	0.4	1.4	1	1	1
Average/Sum#:	0.1	12.9	1,799.2	0.3	1.3	24 #	24 #	17 #
Minimum:	-0.4	11.7	1,235.3	-0.1	0.9	1	1	0
Maximum:	0.7	14.2	2,145.2	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/07/2019 00:00	0.4	12.6	1,953.0	0.5	1.4	1	1	1
10/07/2019 01:00	0.5	12.5	1,972.6	0.5	1.4	1	1	1
10/07/2019 02:00	0.4	12.6	1,946.1	0.5	1.4	1	1	1
10/07/2019 03:00	0.4	12.6	1,979.6	0.5	1.4	1	1	1
10/07/2019 04:00	0.4	12.3	2,020.0	0.5	1.4	1	1	1
10/07/2019 05:00	0.2	12.3	2,006.1	0.4	1.4	1	1	1
10/07/2019 06:00	0.2	12.4	2,028.9	0.4	1.4	1	1	1
10/07/2019 07:00	-0.2	12.5	2,016.6	0.1	1.4	1	1	1
10/07/2019 08:00	-0.2	12.4	2,010.8	0.1	1.4	1	1	1
10/07/2019 09:00	-0.2	12.4	2,028.9	0.1	1.4	1	1	1
10/07/2019 10:00	-0.2	12.4	2,005.9	0.1	1.4	1	1	1
10/07/2019 11:00	-0.2	12.5	1,984.6	0.1	1.4	1	1	1
10/07/2019 12:00	-0.1	12.4	1,984.8	0.2	1.4	1	1	1
10/07/2019 13:00	-0.1	12.3	2,008.6	0.2	1.4	1	1	1
10/07/2019 14:00	-0.1	12.3	2,009.2	0.2	1.4	1	1	1
10/07/2019 15:00	-0.1	12.3	2,005.4	0.2	1.4	1	1	1
10/07/2019 16:00	-0.1	12.0	2,063.4	0.2	1.4	1	1	1
10/07/2019 17:00	-0.1	11.7	2,111.3	0.2	1.5	1	1	1
10/07/2019 18:00	-0.1	11.8	2,108.8	0.2	1.5	1	1	1
10/07/2019 19:00	-0.1	12.0	2,054.5	0.2	1.4	1	1	1
10/07/2019 20:00	-0.1	12.1	2,046.3	0.2	1.4	1	1	1
10/07/2019 21:00	-0.1	12.4	2,008.2	0.2	1.4	1	1	1
10/07/2019 22:00	-0.1	12.3	2,026.2	0.2	1.4	1	1	1
10/07/2019 23:00	-0.2	12.6	1,961.2	0.1	1.4	1	1	1
Average/Sum#:	0.0	12.3	2,014.2	0.3	1.4	24 #	24 #	24 #
Minimum:	-0.2	11.7	1,946.1	0.1	1.4	1	1	1
Maximum:	0.5	12.6	2,111.3	0.5	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/08/2019 00:00	-0.1	12.8	1,913.4	0.1	1.3	1	1	1
10/08/2019 01:00	-0.1	13.1	1,852.1	0.1	1.3	1	1	1
10/08/2019 02:00	-0.1	13.2	1,856.3	0.1	1.3	1	1	1
10/08/2019 03:00	-0.2	12.9	1,910.0	0.1	1.3	1	1	1
10/08/2019 04:00	-0.2	12.8	1,925.0	0.1	1.3	1	1	1
10/08/2019 05:00	-0.4	12.3	2,012.4	-0.1	1.4	1	1	1
10/08/2019 06:00	0.2	12.3	2,007.0	0.4	1.4	1	1	1
10/08/2019 07:00	0.2	12.5	1,974.9	0.4	1.4	1	1	1
10/08/2019 08:00	0.4	12.5	1,968.7	0.5	1.4	1	1	1
10/08/2019 09:00	0.4	12.5	1,960.4	0.5	1.4	1	1	1
10/08/2019 10:00	0.5	12.4	1,961.8	0.5	1.4	1	1	1
10/08/2019 11:00	0.5	12.3	1,964.8	0.5	1.4	1	1	1
10/08/2019 12:00	0.5	12.2	1,981.7	0.5	1.4	1	1	1
10/08/2019 13:00	0.1	12.3	1,991.0	0.2	1.4	1	1	1
10/08/2019 14:00	-0.1	12.4	1,974.8	0.2	1.4	1	1	1
10/08/2019 15:00	-0.2	12.3	2,000.2	0.1	1.4	1	1	1
10/08/2019 16:00	-0.1	12.1	2,047.2	0.2	1.4	1	1	1
10/08/2019 17:00	-0.1	11.8	2,090.4	0.2	1.5	1	1	1
10/08/2019 18:00	-0.1	11.9	2,070.3	0.2	1.4	1	1	1
10/08/2019 19:00	-0.1	12.0	2,056.2	0.2	1.4	1	1	1
10/08/2019 20:00	-0.1	12.0	2,057.4	0.2	1.4	1	1	1
10/08/2019 21:00	0.2	12.2	2,023.9	0.4	1.4	1	1	1
10/08/2019 22:00	0.4	12.5	1,940.0	0.5	1.4	1	1	1
10/08/2019 23:00	0.4	12.4	1,967.7	0.5	1.4	1	1	1
Average/Sum#:	0.1	12.4	1,979.5	0.3	1.4	24 #	24 #	24 #
Minimum:	-0.4	11.8	1,852.1	-0.1	1.3	1	1	1
Maximum:	0.5	13.2	2,090.4	0.5	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/09/2019 00:00	0.4	12.4	1,975.5	0.5	1.4	1	1	1
10/09/2019 01:00	0.5	12.9	1,895.4	0.5	1.3	1	1	1
10/09/2019 02:00	0.4	12.8	1,920.1	0.5	1.3	1	1	1
10/09/2019 03:00	0.4	12.5	1,981.7	0.5	1.4	1	1	1
10/09/2019 04:00	0.4	12.4	2,006.7	0.5	1.4	1	1	1
10/09/2019 05:00	0.2	12.4	2,000.6	0.4	1.4	1	1	1
10/09/2019 06:00	0.4	12.2	2,057.8	0.5	1.4	1	1	1
10/09/2019 07:00	0.4	12.4	2,019.5	0.5	1.4	1	1	1
10/09/2019 08:00	0.4	12.5	1,982.1	0.5	1.4	1	1	1
10/09/2019 09:00	0.4	12.5	1,996.4	0.5	1.4	1	1	1
10/09/2019 10:00	0.4	12.4	2,005.0	0.5	1.4	1	1	1
10/09/2019 11:00	0.6	14.1	1,624.7	0.6	1.1	1	1	0
10/09/2019 12:00	0.6	14.2	1,608.8	0.6	1.1	1	1	0
10/09/2019 13:00	0.6	14.1	1,555.0	0.6	1.1	1	1	0
10/09/2019 14:00	0.6	14.2	1,475.5	0.6	1.0	1	1	0
10/09/2019 15:00	0.7	14.1	1,484.0	0.7	1.0	1	1	1
10/09/2019 16:00	0.4	13.0	1,828.1	0.5	1.3	1	1	1
10/09/2019 17:00	-0.1	12.6	1,987.9	0.1	1.4	1	1	1
10/09/2019 18:00	-0.1	12.7	1,973.2	0.1	1.4	1	1	1
10/09/2019 19:00	0.1	12.5	1,979.7	0.2	1.4	1	1	1
10/09/2019 20:00	0.4	12.5	1,987.3	0.5	1.4	1	1	1
10/09/2019 21:00	0.4	12.5	1,982.7	0.5	1.4	1	1	1
10/09/2019 22:00	0.4	12.5	1,990.8	0.5	1.4	1	1	1
10/09/2019 23:00	0.4	12.6	1,979.2	0.5	1.4	1	1	1
Average/Sum#:	0.4	12.9	1,887.4	0.5	1.3	24 #	24 #	20 #
Minimum:	-0.1	12.2	1,475.5	0.1	1.0	1	1	0
Maximum:	0.7	14.2	2,057.8	0.7	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/10/2019 00:00	0.4	12.6	1,978.3	0.5	1.4	1	1	1
10/10/2019 01:00	0.5	13.2	1,873.7	0.5	1.3	1	1	1
10/10/2019 02:00	0.4	13.0	1,915.8	0.5	1.3	1	1	1
10/10/2019 03:00	0.4	12.7	1,968.6	0.5	1.4	1	1	1
10/10/2019 04:00	0.4	12.7	1,969.9	0.5	1.4	1	1	1
10/10/2019 05:00	0.2	12.7	1,968.4	0.4	1.4	1	1	1
10/10/2019 06:00	0.2	12.6	2,001.8	0.4	1.4	1	1	1
10/10/2019 07:00	0.4	12.9	1,907.1	0.5	1.3	1	1	1
10/10/2019 08:00	0.6	14.1	1,446.8	0.6	1.0	1	1	0
10/10/2019 09:00	0.6	14.1	1,575.1	0.6	1.1	1	1	0
10/10/2019 10:00	0.6	14.1	1,609.9	0.6	1.1	1	1	0
10/10/2019 11:00	0.6	14.1	1,602.9	0.6	1.1	1	1	0
10/10/2019 12:00	0.6	14.2	1,613.2	0.6	1.1	1	1	0
10/10/2019 13:00	0.6	14.2	1,577.3	0.6	1.1	1	1	0
10/10/2019 14:00	0.6	14.1	1,592.7	0.6	1.1	1	1	0
10/10/2019 15:00	0.7	14.1	1,494.6	0.7	1.0	1	1	1
10/10/2019 16:00	0.4	12.4	1,979.9	0.5	1.4	1	1	1
10/10/2019 17:00	0.4	12.5	1,957.8	0.5	1.4	1	1	1
10/10/2019 18:00	-0.1	12.3	2,032.2	0.2	1.4	1	1	1
10/10/2019 19:00	-0.2	12.4	2,017.2	0.1	1.4	1	1	1
10/10/2019 20:00	-0.4	12.4	2,019.8	-0.1	1.4	1	1	1
10/10/2019 21:00	-0.2	12.4	2,024.1	0.1	1.4	1	1	1
10/10/2019 22:00	-0.1	12.4	2,017.3	0.2	1.4	1	1	1
10/10/2019 23:00	0.4	12.7	1,933.5	0.5	1.4	1	1	1
Average/Sum#:	0.3	13.1	1,836.6	0.4	1.3	24 #	24 #	17 #
Minimum:	-0.4	12.3	1,446.8	-0.1	1.0	1	1	0
Maximum:	0.7	14.2	2,032.2	0.7	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/11/2019 00:00	0.5	12.8	1,921.0	0.5	1.3	1	1	1
10/11/2019 01:00	0.5	13.2	1,849.5	0.5	1.3	1	1	1
10/11/2019 02:00	0.5	13.2	1,849.2	0.5	1.3	1	1	1
10/11/2019 03:00	0.5	13.2	1,852.3	0.5	1.3	1	1	1
10/11/2019 04:00	0.5	13.2	1,853.9	0.5	1.3	1	1	1
10/11/2019 05:00	0.7	14.1	1,636.2	0.7	1.1	1	1	1
10/11/2019 06:00	0.6	14.1	1,619.2	0.6	1.1	1	1	0
10/11/2019 07:00	0.6	14.2	1,381.8	0.6	1.0	1	1	0
10/11/2019 08:00	0.6	14.2	1,234.2	0.6	0.9	1	1	0
10/11/2019 09:00	0.6	14.2	1,232.1	0.6	0.9	1	1	0
10/11/2019 10:00	0.6	14.2	1,230.5	0.6	0.9	1	1	0
10/11/2019 11:00	0.6	14.2	1,230.6	0.6	0.9	1	1	0
10/11/2019 12:00	0.6	14.2	1,232.3	0.6	0.9	1	1	0
10/11/2019 13:00	0.6	14.2	1,264.1	0.6	0.9	1	1	0
10/11/2019 14:00	0.6	14.0	1,609.3	0.6	1.1	1	1	0
10/11/2019 15:00	0.7	14.0	1,542.3	0.7	1.1	1	1	1
10/11/2019 16:00	-0.2	12.7	1,964.1	0.1	1.4	1	1	1
10/11/2019 17:00	-0.2	11.9	2,106.6	0.1	1.5	1	1	1
10/11/2019 18:00	-0.1	11.7	2,141.4	0.2	1.5	1	1	1
10/11/2019 19:00	-0.1	12.2	2,051.6	0.2	1.4	1	1	1
10/11/2019 20:00	-0.2	12.3	2,037.1	0.1	1.4	1	1	1
10/11/2019 21:00	-0.2	12.3	2,047.1	0.1	1.4	1	1	1
10/11/2019 22:00	-0.2	12.4	2,035.8	0.1	1.4	1	1	1
10/11/2019 23:00	0.2	12.4	2,030.9	0.4	1.4	1	1	1
Average/Sum#:	0.3	13.3	1,706.4	0.4	1.2	24 #	24 #	15 #
Minimum:	-0.2	11.7	1,230.5	0.1	0.9	1	1	0
Maximum:	0.7	14.2	2,141.4	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/12/2019 00:00	0.4	12.3	2,026.7	0.5	1.4	1	1	1
10/12/2019 01:00	0.4	12.4	1,990.5	0.5	1.4	1	1	1
10/12/2019 02:00	0.4	12.4	2,002.0	0.5	1.4	1	1	1
10/12/2019 03:00	0.4	12.4	2,017.3	0.5	1.4	1	1	1
10/12/2019 04:00	0.4	12.3	2,020.6	0.5	1.4	1	1	1
10/12/2019 05:00	0.2	12.2	2,033.2	0.4	1.4	1	1	1
10/12/2019 06:00	0.2	12.3	2,037.8	0.4	1.4	1	1	1
10/12/2019 07:00	0.0	14.1	1,219.8	0.0	0.9	1	0	1
10/12/2019 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2019 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2019 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2019 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2019 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2019 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2019 14:00	0.0	17.9	390.1	0.0	0.3	1	0	0
10/12/2019 15:00	0.0	15.2	989.1	0.0	0.7	1	0	0
10/12/2019 16:00	0.6	14.1	1,604.4	0.6	1.1	1	1	0
10/12/2019 17:00	0.5	13.5	1,741.4	0.5	1.2	1	1	1
10/12/2019 18:00	-0.2	12.3	2,020.1	0.1	1.4	1	1	1
10/12/2019 19:00	-0.1	12.2	2,042.2	0.2	1.4	1	1	1
10/12/2019 20:00	-0.1	12.3	2,037.0	0.2	1.4	1	1	1
10/12/2019 21:00	-0.1	12.2	2,052.3	0.2	1.4	1	1	1
10/12/2019 22:00	-0.1	12.3	2,029.9	0.2	1.4	1	1	1
10/12/2019 23:00	0.1	12.3	2,056.3	0.2	1.4	1	1	1
Average/Sum#:	0.2	13.0	1,795.0	0.3	1.2	18 #	15 #	15 #
Minimum:	-0.2	12.2	390.1	0.0	0.3	0	0	0
Maximum:	0.6	17.9	2,056.3	0.6	1.4	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/13/2019 00:00	0.2	12.3	2,026.8	0.4	1.4	1	1	1
10/13/2019 01:00	0.4	12.3	2,027.3	0.5	1.4	1	1	1
10/13/2019 02:00	0.4	12.3	2,025.9	0.5	1.4	1	1	1
10/13/2019 03:00	0.4	12.3	2,026.9	0.5	1.4	1	1	1
10/13/2019 04:00	0.4	12.3	2,028.3	0.5	1.4	1	1	1
10/13/2019 05:00	0.2	12.3	2,029.4	0.4	1.4	1	1	1
10/13/2019 06:00	0.4	12.4	1,969.0	0.5	1.4	1	1	1
10/13/2019 07:00	0.7	14.1	1,477.2	0.7	1.0	1	1	1
10/13/2019 08:00	0.6	14.1	1,587.3	0.6	1.1	1	1	0
10/13/2019 09:00	0.6	14.1	1,612.4	0.6	1.1	1	1	0
10/13/2019 10:00	0.6	14.1	1,605.5	0.6	1.1	1	1	0
10/13/2019 11:00	0.6	14.1	1,484.2	0.6	1.0	1	1	0
10/13/2019 12:00	0.6	14.1	1,613.6	0.6	1.1	1	1	0
10/13/2019 13:00	0.6	14.1	1,505.0	0.6	1.1	1	1	0
10/13/2019 14:00	0.6	14.1	1,600.6	0.6	1.1	1	1	0
10/13/2019 15:00	0.7	14.0	1,509.0	0.7	1.1	1	1	1
10/13/2019 16:00	-0.2	12.5	1,975.9	0.1	1.4	1	1	1
10/13/2019 17:00	-0.2	12.0	2,063.5	0.1	1.4	1	1	1
10/13/2019 18:00	-0.1	12.2	2,036.2	0.2	1.4	1	1	1
10/13/2019 19:00	-0.1	12.3	2,017.4	0.2	1.4	1	1	1
10/13/2019 20:00	-0.2	12.4	2,015.0	0.1	1.4	1	1	1
10/13/2019 21:00	-0.1	12.2	2,039.3	0.2	1.4	1	1	1
10/13/2019 22:00	0.4	13.0	1,801.6	0.5	1.3	1	1	1
10/13/2019 23:00	0.0	15.0	968.5	0.0	0.7	1	0	0
Average/Sum#:	0.3	13.1	1,793.6	0.4	1.2	24 #	23 #	16 #
Minimum:	-0.2	12.0	968.5	0.0	0.7	1	0	0
Maximum:	0.7	15.0	2,063.5	0.7	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/14/2019 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2019 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2019 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2019 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2019 06:00	0.0	18.4	370.6	0.0	0.3	1	0	0
10/14/2019 07:00	0.0	14.9	1,000.6	0.0	0.7	1	0	0
10/14/2019 08:00	0.6	14.0	1,459.7	0.6	1.0	1	1	0
10/14/2019 09:00	0.6	14.1	1,251.1	0.6	0.9	1	1	0
10/14/2019 10:00	0.6	14.2	1,237.2	0.6	0.9	1	1	0
10/14/2019 11:00	0.6	14.2	1,306.3	0.6	0.9	1	1	0
10/14/2019 12:00	0.6	14.1	1,440.3	0.6	1.0	1	1	0
10/14/2019 13:00	0.5	13.9	1,556.7	0.5	1.1	1	1	1
10/14/2019 14:00	-0.2	13.1	1,937.9	-0.1	1.4	1	1	1
10/14/2019 15:00	-0.2	12.4	1,992.8	0.1	1.4	1	1	1
10/14/2019 16:00	-0.1	12.1	2,052.5	0.2	1.4	1	1	1
10/14/2019 17:00	-0.1	11.8	2,111.5	0.2	1.5	1	1	1
10/14/2019 18:00	0.1	11.7	2,145.0	0.2	1.5	1	1	1
10/14/2019 19:00	0.1	11.7	2,145.8	0.2	1.5	1	1	1
10/14/2019 20:00	-0.1	12.0	2,088.4	0.2	1.5	1	1	1
10/14/2019 21:00	-0.1	12.3	2,037.8	0.2	1.4	1	1	1
10/14/2019 22:00	-0.1	12.4	2,030.2	0.2	1.4	1	1	1
10/14/2019 23:00	-0.1	12.4	2,026.9	0.2	1.4	1	1	1
Average/Sum#:	0.2	13.3	1,677.3	0.3	1.2	18 #	16 #	11 #
Minimum:	-0.2	11.7	370.6	-0.1	0.3	0	0	0
Maximum:	0.6	18.4	2,145.8	0.6	1.5	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/15/2019 00:00	-0.2	12.4	2,031.7	0.1	1.4	1	1	1
10/15/2019 01:00	-0.2	12.4	2,022.6	0.1	1.4	1	1	1
10/15/2019 02:00	-0.2	12.4	2,030.7	0.1	1.4	1	1	1
10/15/2019 03:00	-0.2	12.5	2,021.2	0.1	1.4	1	1	1
10/15/2019 04:00	0.2	12.4	2,018.6	0.4	1.4	1	1	1
10/15/2019 05:00	0.0	14.4	1,483.8	0.0	1.0	1	0	1
10/15/2019 06:00	0.0	17.5	471.5	0.0	0.3	1	0	0
10/15/2019 07:00	0.0	13.9	1,506.9	0.0	1.1	1	0	1
10/15/2019 08:00	0.6	14.1	1,470.6	0.6	1.0	1	1	0
10/15/2019 09:00	0.6	14.1	1,304.8	0.6	0.9	1	1	0
10/15/2019 10:00	0.6	14.1	1,279.7	0.6	0.9	1	1	0
10/15/2019 11:00	0.6	14.1	1,313.0	0.6	0.9	1	1	0
10/15/2019 12:00	0.6	14.1	1,395.1	0.6	1.0	1	1	0
10/15/2019 13:00	0.6	14.1	1,611.4	0.6	1.1	1	1	0
10/15/2019 14:00	0.7	13.9	1,604.7	0.7	1.1	1	1	1
10/15/2019 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2019 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2019 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2019 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2019 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2019 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2019 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2019 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2019 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.2	13.8	1,571.1	0.3	1.1	15 #	12 #	8 #
Minimum:	-0.2	12.4	471.5	0.0	0.3	0	0	0
Maximum:	0.7	17.5	2,031.7	0.7	1.4	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/16/2019 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2019 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2019 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2019 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2019 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2019 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2019 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2019 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2019 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2019 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2019 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2019 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2019 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2019 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2019 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2019 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2019 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2019 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2019 20:00	0.0	18.1	371.0	0.0	0.3	1	0	0
10/16/2019 21:00	0.0	15.7	818.9	0.0	0.6	1	0	0
10/16/2019 22:00	0.6	14.0	1,399.1	0.6	1.0	1	1	0
10/16/2019 23:00	0.6	14.0	1,589.3	0.6	1.1	1	1	0
Average/Sum#:	0.3	15.5	1,044.6	0.3	0.8	4 #	2 #	0 #
Minimum:	0.0	14.0	371.0	0.0	0.3	0	0	0
Maximum:	0.6	18.1	1,589.3	0.6	1.1	1	1	0
%SI	83.33	83.33	83.33	83.33	83.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/17/2019 00:00	0.6	14.0	1,563.3	0.6	1.1	1	1	0
10/17/2019 01:00	0.7	14.0	1,625.3	0.7	1.1	1	1	1
10/17/2019 02:00	0.1	12.9	1,908.6	0.2	1.3	1	1	1
10/17/2019 03:00	0.2	12.8	1,936.7	0.4	1.4	1	1	1
10/17/2019 04:00	0.2	12.6	1,979.0	0.4	1.4	1	1	1
10/17/2019 05:00	0.2	12.7	1,961.4	0.4	1.4	1	1	1
10/17/2019 06:00	0.4	12.4	2,018.7	0.5	1.4	1	1	1
10/17/2019 07:00	0.5	12.6	1,979.9	0.5	1.4	1	1	1
10/17/2019 08:00	0.7	13.8	1,517.6	0.7	1.1	1	1	1
10/17/2019 09:00	0.6	14.0	1,469.0	0.6	1.0	1	1	0
10/17/2019 10:00	0.6	14.0	1,483.2	0.6	1.0	1	1	0
10/17/2019 11:00	0.6	14.1	1,527.2	0.6	1.1	1	1	0
10/17/2019 12:00	0.6	14.1	1,304.5	0.6	0.9	1	1	0
10/17/2019 13:00	0.6	14.1	1,456.5	0.6	1.0	1	1	0
10/17/2019 14:00	0.6	14.1	1,548.2	0.6	1.1	1	1	0
10/17/2019 15:00	0.7	14.1	1,486.6	0.7	1.0	1	1	1
10/17/2019 16:00	-0.1	12.8	1,937.0	0.1	1.4	1	1	1
10/17/2019 17:00	-0.1	11.9	2,133.0	0.2	1.5	1	1	1
10/17/2019 18:00	-0.1	12.1	2,078.9	0.2	1.5	1	1	1
10/17/2019 19:00	-0.1	12.3	2,049.5	0.2	1.4	1	1	1
10/17/2019 20:00	-0.1	12.2	2,064.2	0.2	1.4	1	1	1
10/17/2019 21:00	0.2	12.2	2,044.6	0.4	1.4	1	1	1
10/17/2019 22:00	0.4	12.6	1,963.0	0.5	1.4	1	1	1
10/17/2019 23:00	0.4	12.8	1,921.5	0.5	1.3	1	1	1
Average/Sum#:	0.4	13.1	1,789.9	0.5	1.3	24 #	24 #	17 #
Minimum:	-0.1	11.9	1,304.5	0.1	0.9	1	1	0
Maximum:	0.7	14.1	2,133.0	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/18/2019 00:00	0.4	12.9	1,899.3	0.5	1.3	1	1	1
10/18/2019 01:00	0.4	12.9	1,894.9	0.5	1.3	1	1	1
10/18/2019 02:00	0.4	13.2	1,843.6	0.4	1.3	1	1	1
10/18/2019 03:00	0.4	13.1	1,892.6	0.4	1.3	1	1	1
10/18/2019 04:00	0.1	12.7	1,960.8	0.2	1.4	1	1	1
10/18/2019 05:00	0.1	12.7	1,947.5	0.2	1.4	1	1	1
10/18/2019 06:00	0.1	12.5	2,010.8	0.2	1.4	1	1	1
10/18/2019 07:00	0.4	13.2	1,831.6	0.4	1.3	1	1	1
10/18/2019 08:00	0.6	14.0	1,522.1	0.6	1.1	1	1	0
10/18/2019 09:00	0.6	14.0	1,471.4	0.6	1.0	1	1	0
10/18/2019 10:00	0.6	14.0	1,480.7	0.6	1.0	1	1	0
10/18/2019 11:00	0.6	14.0	1,489.2	0.6	1.0	1	1	0
10/18/2019 12:00	0.6	14.0	1,445.2	0.6	1.0	1	1	0
10/18/2019 13:00	0.6	14.0	1,556.2	0.6	1.1	1	1	0
10/18/2019 14:00	0.6	14.0	1,553.8	0.6	1.1	1	1	0
10/18/2019 15:00	0.7	14.0	1,569.7	0.7	1.1	1	1	1
10/18/2019 16:00	-0.2	12.5	1,982.3	0.1	1.4	1	1	1
10/18/2019 17:00	-0.1	12.2	2,041.7	0.2	1.4	1	1	1
10/18/2019 18:00	-0.1	12.6	1,965.8	0.1	1.4	1	1	1
10/18/2019 19:00	-0.1	12.5	1,974.8	0.1	1.4	1	1	1
10/18/2019 20:00	-0.1	12.2	2,035.2	0.2	1.4	1	1	1
10/18/2019 21:00	-0.1	12.2	2,051.9	0.2	1.4	1	1	1
10/18/2019 22:00	-0.1	12.5	1,990.1	0.1	1.4	1	1	1
10/18/2019 23:00	-0.1	12.3	2,038.2	0.2	1.4	1	1	1
Average/Sum#:	0.3	13.1	1,810.4	0.4	1.3	24 #	24 #	17 #
Minimum:	-0.2	12.2	1,445.2	0.1	1.0	1	1	0
Maximum:	0.7	14.0	2,051.9	0.7	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/19/2019 00:00	0.1	12.5	1,983.1	0.2	1.4	1	1	1
10/19/2019 01:00	0.1	12.5	1,983.7	0.2	1.4	1	1	1
10/19/2019 02:00	0.1	12.3	2,039.7	0.2	1.4	1	1	1
10/19/2019 03:00	0.1	12.5	1,991.8	0.2	1.4	1	1	1
10/19/2019 04:00	0.2	12.7	1,957.1	0.4	1.4	1	1	1
10/19/2019 05:00	0.2	12.5	1,986.9	0.4	1.4	1	1	1
10/19/2019 06:00	0.2	12.5	1,994.6	0.4	1.4	1	1	1
10/19/2019 07:00	0.0	14.3	1,188.1	0.0	0.8	1	0	1
10/19/2019 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.1	12.7	1,890.6	0.3	1.3	8 #	7 #	8 #
Minimum:	0.0	12.3	1,188.1	0.0	0.8	0	0	0
Maximum:	0.2	14.3	2,039.7	0.4	1.4	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/20/2019 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 14:00	0.0	17.5	449.3	0.0	0.3	1	0	0
10/20/2019 15:00	0.0	15.3	991.7	0.0	0.7	1	0	0
10/20/2019 16:00	0.6	14.0	1,552.8	0.6	1.1	1	1	0
10/20/2019 17:00	0.6	14.0	1,638.6	0.6	1.1	1	1	0
10/20/2019 18:00	0.7	13.6	1,789.3	0.7	1.3	1	1	1
10/20/2019 19:00	-0.2	12.6	1,988.7	0.1	1.4	1	1	1
10/20/2019 20:00	0.2	12.5	1,999.2	0.4	1.4	1	1	1
10/20/2019 21:00	0.2	12.7	1,972.8	0.4	1.4	1	1	1
10/20/2019 22:00	0.2	12.6	1,979.2	0.4	1.4	1	1	1
10/20/2019 23:00	0.2	12.6	1,987.7	0.4	1.4	1	1	1
Average/Sum#:	0.3	13.7	1,634.9	0.4	1.2	10 #	8 #	6 #
Minimum:	-0.2	12.5	449.3	0.0	0.3	0	0	0
Maximum:	0.7	17.5	1,999.2	0.7	1.4	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/21/2019 00:00	0.4	12.8	1,929.4	0.5	1.4	1	1	1
10/21/2019 01:00	0.5	12.8	1,930.5	0.5	1.4	1	1	1
10/21/2019 02:00	0.5	12.8	1,925.9	0.5	1.3	1	1	1
10/21/2019 03:00	0.5	12.8	1,928.4	0.5	1.3	1	1	1
10/21/2019 04:00	0.4	12.6	1,995.4	0.5	1.4	1	1	1
10/21/2019 05:00	0.2	12.3	2,025.4	0.4	1.4	1	1	1
10/21/2019 06:00	0.2	12.2	2,083.3	0.4	1.5	1	1	1
10/21/2019 07:00	0.4	12.6	1,923.5	0.5	1.3	1	1	1
10/21/2019 08:00	0.6	14.1	1,251.2	0.6	0.9	1	1	0
10/21/2019 09:00	0.6	14.1	1,245.8	0.6	0.9	1	1	0
10/21/2019 10:00	0.6	14.1	1,395.1	0.6	1.0	1	1	0
10/21/2019 11:00	0.6	14.1	1,459.6	0.6	1.0	1	1	0
10/21/2019 12:00	0.6	14.0	1,554.0	0.6	1.1	1	1	0
10/21/2019 13:00	0.6	13.8	1,706.3	0.6	1.2	1	1	0
10/21/2019 14:00	0.6	13.8	1,731.6	0.6	1.2	1	1	0
10/21/2019 15:00	0.6	13.8	1,731.4	0.6	1.2	1	1	0
10/21/2019 16:00	0.6	13.8	1,731.6	0.6	1.2	1	1	0
10/21/2019 17:00	0.6	13.8	1,736.5	0.6	1.2	1	1	0
10/21/2019 18:00	0.6	13.8	1,739.6	0.6	1.2	1	1	0
10/21/2019 19:00	0.7	13.8	1,741.1	0.7	1.2	1	1	1
10/21/2019 20:00	-0.2	12.7	1,964.5	0.1	1.4	1	1	1
10/21/2019 21:00	-0.2	12.4	2,016.6	0.1	1.4	1	1	1
10/21/2019 22:00	-0.2	12.5	2,009.2	0.1	1.4	1	1	1
10/21/2019 23:00	-0.1	12.6	1,975.4	0.1	1.4	1	1	1
Average/Sum#:	0.4	13.3	1,780.5	0.5	1.2	24 #	24 #	13 #
Minimum:	-0.2	12.2	1,245.8	0.1	0.9	1	1	0
Maximum:	0.7	14.1	2,083.3	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/22/2019 00:00	-0.1	12.9	1,931.6	0.1	1.4	1	1	1
10/22/2019 01:00	0.1	12.7	1,940.1	0.2	1.4	1	1	1
10/22/2019 02:00	0.4	12.7	1,936.2	0.5	1.4	1	1	1
10/22/2019 03:00	0.4	12.6	1,947.6	0.5	1.4	1	1	1
10/22/2019 04:00	0.2	12.8	1,948.7	0.4	1.4	1	1	1
10/22/2019 05:00	0.2	12.4	2,005.3	0.4	1.4	1	1	1
10/22/2019 06:00	0.2	12.3	2,041.5	0.4	1.4	1	1	1
10/22/2019 07:00	-0.1	12.7	1,974.2	0.1	1.4	1	1	1
10/22/2019 08:00	-0.1	12.1	2,090.2	0.2	1.5	1	1	1
10/22/2019 09:00	-0.1	12.0	2,120.6	0.2	1.5	1	1	1
10/22/2019 10:00	-0.1	12.0	2,118.1	0.2	1.5	1	1	1
10/22/2019 11:00	0.1	11.9	2,114.0	0.2	1.5	1	1	1
10/22/2019 12:00	0.1	11.9	2,107.2	0.2	1.5	1	1	1
10/22/2019 13:00	0.1	11.9	2,102.3	0.2	1.5	1	1	1
10/22/2019 14:00	0.1	11.9	2,095.2	0.2	1.5	1	1	1
10/22/2019 15:00	0.1	11.9	2,091.8	0.2	1.5	1	1	1
10/22/2019 16:00	0.1	12.0	2,091.7	0.2	1.5	1	1	1
10/22/2019 17:00	0.1	11.7	2,146.0	0.2	1.5	1	1	1
10/22/2019 18:00	-0.1	12.2	2,056.5	0.2	1.4	1	1	1
10/22/2019 19:00	-0.1	12.1	2,080.8	0.2	1.5	1	1	1
10/22/2019 20:00	-0.1	12.3	2,028.7	0.2	1.4	1	1	1
10/22/2019 21:00	-0.1	12.2	2,045.9	0.2	1.4	1	1	1
10/22/2019 22:00	-0.1	12.3	2,017.3	0.2	1.4	1	1	1
10/22/2019 23:00	-0.1	12.5	1,988.7	0.1	1.4	1	1	1
Average/Sum#:	0.0	12.3	2,042.5	0.2	1.4	24 #	24 #	24 #
Minimum:	-0.1	11.7	1,931.6	0.1	1.4	1	1	1
Maximum:	0.4	12.9	2,146.0	0.5	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/23/2019 00:00	-0.1	12.5	1,983.2	0.1	1.4	1	1	1
10/23/2019 01:00	-0.1	12.5	1,981.7	0.1	1.4	1	1	1
10/23/2019 02:00	-0.1	12.6	1,967.3	0.1	1.4	1	1	1
10/23/2019 03:00	-0.2	12.6	1,974.1	0.1	1.4	1	1	1
10/23/2019 04:00	-0.1	12.7	1,950.4	0.1	1.4	1	1	1
10/23/2019 05:00	-0.2	12.1	2,044.1	0.1	1.4	1	1	1
10/23/2019 06:00	-0.1	12.3	1,996.3	0.2	1.4	1	1	1
10/23/2019 07:00	0.6	14.1	1,319.5	0.6	0.9	1	1	0
10/23/2019 08:00	0.6	14.2	1,253.2	0.6	0.9	1	1	0
10/23/2019 09:00	0.6	14.2	1,248.3	0.6	0.9	1	1	0
10/23/2019 10:00	0.6	14.1	1,369.1	0.6	1.0	1	1	0
10/23/2019 11:00	0.6	14.1	1,449.9	0.6	1.0	1	1	0
10/23/2019 12:00	0.6	14.0	1,564.5	0.6	1.1	1	1	0
10/23/2019 13:00	0.6	13.8	1,732.9	0.6	1.2	1	1	0
10/23/2019 14:00	0.6	13.8	1,730.8	0.6	1.2	1	1	0
10/23/2019 15:00	0.6	13.8	1,729.8	0.6	1.2	1	1	0
10/23/2019 16:00	0.6	13.8	1,732.1	0.6	1.2	1	1	0
10/23/2019 17:00	0.6	13.8	1,734.9	0.6	1.2	1	1	0
10/23/2019 18:00	0.6	14.0	1,695.4	0.6	1.2	1	1	0
10/23/2019 19:00	-0.1	13.1	1,865.8	0.1	1.3	1	1	1
10/23/2019 20:00	-0.2	12.3	2,056.1	0.1	1.4	1	1	1
10/23/2019 21:00	-0.2	12.1	2,092.9	0.1	1.5	1	1	1
10/23/2019 22:00	-0.1	12.1	2,085.0	0.2	1.5	1	1	1
10/23/2019 23:00	-0.2	12.4	2,029.6	0.1	1.4	1	1	1
Average/Sum#:	0.2	13.2	1,774.5	0.4	1.2	24 #	24 #	12 #
Minimum:	-0.2	12.1	1,248.3	0.1	0.9	1	1	0
Maximum:	0.6	14.2	2,092.9	0.6	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/24/2019 00:00	-0.2	12.5	2,004.2	0.1	1.4	1	1	1
10/24/2019 01:00	-0.2	12.6	1,978.6	0.1	1.4	1	1	1
10/24/2019 02:00	-0.2	13.0	1,912.0	0.1	1.3	1	1	1
10/24/2019 03:00	-0.2	12.5	2,024.2	0.1	1.4	1	1	1
10/24/2019 04:00	-0.2	12.5	2,027.4	0.1	1.4	1	1	1
10/24/2019 05:00	-0.2	12.0	2,093.4	0.1	1.5	1	1	1
10/24/2019 06:00	-0.2	12.2	2,076.2	0.1	1.5	1	1	1
10/24/2019 07:00	-0.1	12.2	2,072.3	0.2	1.5	1	1	1
10/24/2019 08:00	-0.1	12.5	2,022.3	0.1	1.4	1	1	1
10/24/2019 09:00	-0.1	12.4	2,034.5	0.2	1.4	1	1	1
10/24/2019 10:00	-0.1	12.3	2,042.6	0.2	1.4	1	1	1
10/24/2019 11:00	-0.1	12.3	2,046.6	0.2	1.4	1	1	1
10/24/2019 12:00	-0.1	12.2	2,057.0	0.2	1.4	1	1	1
10/24/2019 13:00	0.1	12.2	2,072.4	0.2	1.5	1	1	1
10/24/2019 14:00	0.1	12.1	2,084.8	0.2	1.5	1	1	1
10/24/2019 15:00	0.1	11.9	2,116.1	0.2	1.5	1	1	1
10/24/2019 16:00	0.1	11.8	2,134.3	0.2	1.5	1	1	1
10/24/2019 17:00	-0.1	12.0	2,100.2	0.2	1.5	1	1	1
10/24/2019 18:00	-0.1	12.0	2,096.5	0.2	1.5	1	1	1
10/24/2019 19:00	-0.1	11.8	2,144.7	0.2	1.5	1	1	1
10/24/2019 20:00	-0.1	11.9	2,132.1	0.2	1.5	1	1	1
10/24/2019 21:00	0.1	12.0	2,093.1	0.2	1.5	1	1	1
10/24/2019 22:00	0.4	12.0	2,081.1	0.5	1.5	1	1	1
10/24/2019 23:00	-0.1	12.0	2,104.4	0.2	1.5	1	1	1
Average/Sum#:	-0.1	12.2	2,064.6	0.2	1.5	24 #	24 #	24 #
Minimum:	-0.2	11.8	1,912.0	0.1	1.3	1	1	1
Maximum:	0.4	13.0	2,144.7	0.5	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/25/2019 00:00	-0.2	12.0	2,108.1	0.1	1.5	1	1	1
10/25/2019 01:00	-0.2	12.5	2,005.7	0.1	1.4	1	1	1
10/25/2019 02:00	0.2	12.5	1,973.9	0.4	1.4	1	1	1
10/25/2019 03:00	0.4	12.6	1,970.7	0.5	1.4	1	1	1
10/25/2019 04:00	0.4	12.5	1,999.4	0.5	1.4	1	1	1
10/25/2019 05:00	0.2	12.6	1,986.3	0.4	1.4	1	1	1
10/25/2019 06:00	0.1	12.4	2,033.6	0.2	1.4	1	1	1
10/25/2019 07:00	0.1	12.7	1,981.9	0.2	1.4	1	1	1
10/25/2019 08:00	-0.4	13.3	1,857.8	-0.1	1.3	1	1	1
10/25/2019 09:00	-0.5	13.3	1,858.6	-0.2	1.3	1	1	1
10/25/2019 10:00	-0.5	13.1	1,889.9	-0.2	1.3	1	1	1
10/25/2019 11:00	-0.4	13.1	1,886.7	-0.1	1.3	1	1	1
10/25/2019 12:00	-0.4	12.5	2,006.6	-0.1	1.4	1	1	1
10/25/2019 13:00	-0.4	12.4	2,009.5	-0.1	1.4	1	1	1
10/25/2019 14:00	-0.4	12.4	2,007.7	-0.1	1.4	1	1	1
10/25/2019 15:00	-0.4	12.4	2,010.2	-0.1	1.4	1	1	1
10/25/2019 16:00	-0.4	12.1	2,076.2	-0.1	1.5	1	1	1
10/25/2019 17:00	-0.4	12.1	2,061.9	-0.1	1.4	1	1	1
10/25/2019 18:00	-0.4	12.5	1,989.6	-0.1	1.4	1	1	1
10/25/2019 19:00	-0.4	12.5	1,989.1	-0.1	1.4	1	1	1
10/25/2019 20:00	-0.4	12.2	2,052.9	-0.1	1.4	1	1	1
10/25/2019 21:00	-0.4	12.1	2,082.8	-0.1	1.5	1	1	1
10/25/2019 22:00	-0.4	12.4	2,030.9	-0.1	1.4	1	1	1
10/25/2019 23:00	-0.2	12.4	2,024.0	0.1	1.4	1	1	1
Average/Sum#:	-0.2	12.5	1,995.6	0.0	1.4	24 #	24 #	24 #
Minimum:	-0.5	12.0	1,857.8	-0.2	1.3	1	1	1
Maximum:	0.4	13.3	2,108.1	0.5	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/26/2019 00:00	0.2	12.5	1,965.9	0.4	1.4	1	1	1
10/26/2019 01:00	0.4	12.4	1,996.6	0.5	1.4	1	1	1
10/26/2019 02:00	0.4	12.4	1,988.5	0.5	1.4	1	1	1
10/26/2019 03:00	0.4	12.5	1,983.2	0.5	1.4	1	1	1
10/26/2019 04:00	0.4	12.5	1,985.1	0.5	1.4	1	1	1
10/26/2019 05:00	0.2	13.0	1,915.2	0.4	1.3	1	1	1
10/26/2019 06:00	0.2	12.9	1,903.5	0.4	1.3	1	1	1
10/26/2019 07:00	0.6	14.0	1,476.3	0.6	1.0	1	1	0
10/26/2019 08:00	0.6	14.1	1,575.6	0.6	1.1	1	1	0
10/26/2019 09:00	0.6	14.1	1,569.9	0.6	1.1	1	1	0
10/26/2019 10:00	0.6	14.1	1,458.2	0.6	1.0	1	1	0
10/26/2019 11:00	0.6	14.0	1,419.2	0.6	1.0	1	1	0
10/26/2019 12:00	0.6	14.1	1,514.4	0.6	1.1	1	1	0
10/26/2019 13:00	0.6	14.0	1,582.0	0.6	1.1	1	1	0
10/26/2019 14:00	0.6	14.1	1,466.6	0.6	1.0	1	1	0
10/26/2019 15:00	0.7	14.0	1,480.6	0.7	1.0	1	1	1
10/26/2019 16:00	-0.4	12.8	1,923.2	-0.1	1.3	1	1	1
10/26/2019 17:00	-0.4	12.4	1,995.4	-0.1	1.4	1	1	1
10/26/2019 18:00	-0.5	12.4	1,992.8	-0.2	1.4	1	1	1
10/26/2019 19:00	-0.5	12.5	1,990.6	-0.2	1.4	1	1	1
10/26/2019 20:00	-0.5	12.4	2,001.5	-0.2	1.4	1	1	1
10/26/2019 21:00	-0.5	12.5	2,001.5	-0.2	1.4	1	1	1
10/26/2019 22:00	0.0	14.5	1,137.4	0.0	0.8	1	0	1
10/26/2019 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.2	13.2	1,753.2	0.3	1.2	23 #	22 #	15 #
Minimum:	-0.5	12.4	1,137.4	-0.2	0.8	0	0	0
Maximum:	0.7	14.5	2,001.5	0.7	1.4	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/27/2019 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/28/2019 00:00	0.0	18.6	329.6	0.0	0.2	1	0	0
10/28/2019 01:00	0.0	16.2	697.2	0.0	0.5	1	0	0
10/28/2019 02:00	0.6	14.1	1,323.7	0.6	0.9	1	1	0
10/28/2019 03:00	0.7	14.0	1,554.3	0.7	1.1	1	1	1
10/28/2019 04:00	0.2	13.1	1,907.1	0.4	1.3	1	1	1
10/28/2019 05:00	0.1	12.7	1,955.9	0.2	1.4	1	1	1
10/28/2019 06:00	0.2	12.0	2,125.2	0.4	1.5	1	1	1
10/28/2019 07:00	0.2	12.5	2,020.1	0.4	1.4	1	1	1
10/28/2019 08:00	0.2	12.7	1,975.7	0.4	1.4	1	1	1
10/28/2019 09:00	0.2	12.7	1,981.6	0.4	1.4	1	1	1
10/28/2019 10:00	0.1	12.7	1,973.6	0.2	1.4	1	1	1
10/28/2019 11:00	-0.2	13.0	1,947.0	0.1	1.4	1	1	1
10/28/2019 12:00	-0.4	12.8	1,974.1	-0.1	1.4	1	1	1
10/28/2019 13:00	-0.4	12.8	1,956.0	-0.1	1.4	1	1	1
10/28/2019 14:00	-0.4	12.8	1,976.3	-0.1	1.4	1	1	1
10/28/2019 15:00	-0.4	12.6	2,004.3	-0.1	1.4	1	1	1
10/28/2019 16:00	-0.4	12.3	2,068.2	-0.1	1.4	1	1	1
10/28/2019 17:00	-0.2	11.7	2,173.4	0.1	1.5	1	1	1
10/28/2019 18:00	-0.4	12.1	2,107.8	-0.1	1.5	1	1	1
10/28/2019 19:00	-0.2	12.2	2,092.5	0.1	1.5	1	1	1
10/28/2019 20:00	0.1	12.2	2,069.5	0.2	1.4	1	1	1
10/28/2019 21:00	0.4	12.2	2,059.4	0.5	1.4	1	1	1
10/28/2019 22:00	0.4	12.8	1,919.5	0.5	1.3	1	1	1
10/28/2019 23:00	0.0	15.8	589.0	0.0	0.4	1	0	0
Average/Sum#:	0.0	13.2	1,782.5	0.2	1.2	24 #	21 #	20 #
Minimum:	-0.4	11.7	329.6	-0.1	0.2	1	0	0
Maximum:	0.7	18.6	2,173.4	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/29/2019 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/30/2019 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2019 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2019 04:00	0.0	20.5	98.7	0.0	0.1	1	0	0
10/30/2019 05:00	0.0	17.2	500.2	0.0	0.4	1	0	0
10/30/2019 06:00	0.0	15.6	823.1	0.0	0.6	1	0	0
10/30/2019 07:00	0.7	14.0	1,699.0	0.7	1.2	1	1	1
10/30/2019 08:00	0.7	14.1	1,706.5	0.7	1.2	1	1	1
10/30/2019 09:00	0.2	13.2	1,917.2	0.4	1.3	1	1	1
10/30/2019 10:00	0.1	12.5	2,025.9	0.2	1.4	1	1	1
10/30/2019 11:00	0.2	12.3	2,071.3	0.4	1.4	1	1	1
10/30/2019 12:00	0.4	12.1	2,093.7	0.5	1.5	1	1	1
10/30/2019 13:00	0.4	12.3	2,060.7	0.5	1.4	1	1	1
10/30/2019 14:00	-0.1	12.7	2,003.9	0.1	1.4	1	1	1
10/30/2019 15:00	-0.2	12.7	2,017.3	0.1	1.4	1	1	1
10/30/2019 16:00	-0.1	12.3	2,080.1	0.2	1.5	1	1	1
10/30/2019 17:00	-0.1	13.2	1,914.6	0.1	1.3	1	1	1
10/30/2019 18:00	-0.1	13.1	1,932.1	0.1	1.4	1	1	1
10/30/2019 19:00	-0.1	13.1	1,940.6	0.1	1.4	1	1	1
10/30/2019 20:00	-0.1	13.1	1,943.6	0.1	1.4	1	1	1
10/30/2019 21:00	0.4	13.2	1,888.6	0.4	1.3	1	1	1
10/30/2019 22:00	0.4	13.2	1,902.0	0.4	1.3	1	1	1
10/30/2019 23:00	0.4	13.1	1,928.7	0.4	1.4	1	1	1
Average/Sum#:	0.2	13.7	1,727.4	0.3	1.2	20 #	17 #	17 #
Minimum:	-0.2	12.1	98.7	0.0	0.1	0	0	0
Maximum:	0.7	20.5	2,093.7	0.7	1.5	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/31/2019 00:00	0.4	13.2	1,916.2	0.4	1.3	1	1	1
10/31/2019 01:00	0.4	13.2	1,901.6	0.4	1.3	1	1	1
10/31/2019 02:00	0.4	13.2	1,899.0	0.4	1.3	1	1	1
10/31/2019 03:00	0.4	13.2	1,903.6	0.4	1.3	1	1	1
10/31/2019 04:00	0.4	13.2	1,903.4	0.4	1.3	1	1	1
10/31/2019 05:00	0.2	13.2	1,894.0	0.4	1.3	1	1	1
10/31/2019 06:00	0.4	13.2	1,903.0	0.4	1.3	1	1	1
10/31/2019 07:00	0.4	13.2	1,914.5	0.4	1.3	1	1	1
10/31/2019 08:00	0.2	13.2	1,922.1	0.4	1.3	1	1	1
10/31/2019 09:00	0.4	13.2	1,893.6	0.4	1.3	1	1	1
10/31/2019 10:00	0.1	13.2	1,897.2	0.2	1.3	1	1	1
10/31/2019 11:00	-0.2	13.2	1,910.2	-0.1	1.3	1	1	1
10/31/2019 12:00	-0.1	13.0	1,934.6	0.1	1.4	1	1	1
10/31/2019 13:00	-0.1	13.0	1,935.7	0.1	1.4	1	1	1
10/31/2019 14:00	-0.1	13.0	1,930.4	0.1	1.4	1	1	1
10/31/2019 15:00	-0.1	13.0	1,928.4	0.1	1.3	1	1	1
10/31/2019 16:00	-0.1	13.0	1,925.1	0.1	1.3	1	1	1
10/31/2019 17:00	-0.2	13.0	1,928.8	0.1	1.4	1	1	1
10/31/2019 18:00	-0.2	12.9	1,964.9	0.1	1.4	1	1	1
10/31/2019 19:00	-0.4	12.3	2,076.5	-0.1	1.5	1	1	1
10/31/2019 20:00	-0.4	12.4	2,072.5	-0.1	1.5	1	1	1
10/31/2019 21:00	-0.2	12.4	2,079.3	0.1	1.5	1	1	1
10/31/2019 22:00	0.2	12.2	2,080.8	0.4	1.5	1	1	1
10/31/2019 23:00	0.2	12.4	2,062.9	0.4	1.4	1	1	1
Average/Sum#:	0.1	13.0	1,949.1	0.2	1.4	24 #	24 #	24 #
Minimum:	-0.4	12.2	1,893.6	-0.1	1.3	1	1	1
Maximum:	0.4	13.2	2,080.8	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/01/2019 00:00	0.2	12.4	2,042.8	0.4	1.4	1	1	1
11/01/2019 01:00	0.2	12.6	2,007.6	0.4	1.4	1	1	1
11/01/2019 02:00	0.1	12.5	2,041.1	0.2	1.4	1	1	1
11/01/2019 03:00	0.1	12.5	2,042.2	0.2	1.4	1	1	1
11/01/2019 04:00	0.2	12.7	2,006.6	0.4	1.4	1	1	1
11/01/2019 05:00	-0.1	12.2	2,104.3	0.2	1.5	1	1	1
11/01/2019 06:00	0.1	12.2	2,135.2	0.2	1.5	1	1	1
11/01/2019 07:00	0.2	12.2	2,134.0	0.4	1.5	1	1	1
11/01/2019 08:00	0.2	12.2	2,118.2	0.4	1.5	1	1	1
11/01/2019 09:00	0.7	13.6	1,753.5	0.7	1.2	1	1	1
11/01/2019 10:00	0.6	14.1	1,644.8	0.6	1.2	1	1	0
11/01/2019 11:00	0.6	14.1	1,319.3	0.6	0.9	1	1	0
11/01/2019 12:00	0.6	14.1	1,505.4	0.6	1.1	1	1	0
11/01/2019 13:00	0.6	14.1	1,549.1	0.6	1.1	1	1	0
11/01/2019 14:00	0.7	14.0	1,513.1	0.7	1.1	1	1	1
11/01/2019 15:00	-0.1	12.9	1,955.6	0.1	1.4	1	1	1
11/01/2019 16:00	0.1	12.4	2,055.9	0.2	1.4	1	1	1
11/01/2019 17:00	0.1	12.0	2,130.6	0.2	1.5	1	1	1
11/01/2019 18:00	0.2	11.8	2,165.3	0.4	1.5	1	1	1
11/01/2019 19:00	0.1	12.3	2,071.2	0.2	1.4	1	1	1
11/01/2019 20:00	0.1	12.2	2,110.6	0.2	1.5	1	1	1
11/01/2019 21:00	0.1	12.5	2,038.0	0.2	1.4	1	1	1
11/01/2019 22:00	0.1	12.7	2,010.4	0.2	1.4	1	1	1
11/01/2019 23:00	-0.1	12.6	2,033.2	0.1	1.4	1	1	1
Average/Sum#:	0.2	12.8	1,937.0	0.4	1.4	24 #	24 #	20 #
Minimum:	-0.1	11.8	1,319.3	0.1	0.9	1	1	0
Maximum:	0.7	14.1	2,165.3	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/02/2019 00:00	0.4	12.4	2,050.5	0.5	1.4	1	1	1
11/02/2019 01:00	0.4	12.3	2,058.8	0.5	1.4	1	1	1
11/02/2019 02:00	0.5	12.3	2,069.6	0.5	1.4	1	1	1
11/02/2019 03:00	0.5	12.3	2,063.5	0.5	1.4	1	1	1
11/02/2019 04:00	0.5	12.3	2,069.6	0.5	1.4	1	1	1
11/02/2019 05:00	0.4	12.4	2,035.1	0.5	1.4	1	1	1
11/02/2019 06:00	0.5	12.0	2,126.4	0.5	1.5	1	1	1
11/02/2019 07:00	0.5	12.3	2,067.1	0.5	1.4	1	1	1
11/02/2019 08:00	0.5	13.1	1,887.2	0.5	1.3	1	1	1
11/02/2019 09:00	0.6	14.1	1,528.1	0.6	1.1	1	1	0
11/02/2019 10:00	0.6	14.1	1,518.3	0.6	1.1	1	1	0
11/02/2019 11:00	0.6	14.1	1,524.8	0.6	1.1	1	1	0
11/02/2019 12:00	0.6	14.1	1,539.0	0.6	1.1	1	1	0
11/02/2019 13:00	0.0	15.2	923.9	0.0	0.6	1	0	0
11/02/2019 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/02/2019 15:00	0.0	17.8	423.3	0.0	0.3	1	0	0
11/02/2019 16:00	0.0	14.5	1,124.4	0.0	0.8	1	0	0
11/02/2019 17:00	0.7	13.8	1,717.0	0.7	1.2	1	1	1
11/02/2019 18:00	-0.4	12.5	2,030.2	-0.1	1.4	1	1	1
11/02/2019 19:00	-0.1	11.8	2,166.3	0.2	1.5	1	1	1
11/02/2019 20:00	-0.1	11.9	2,141.3	0.2	1.5	1	1	1
11/02/2019 21:00	-0.2	12.3	2,073.2	0.1	1.5	1	1	1
11/02/2019 22:00	-0.2	12.4	2,044.0	0.1	1.4	1	1	1
11/02/2019 23:00	0.1	12.7	1,990.7	0.2	1.4	1	1	1
Average/Sum#:	0.3	13.2	1,790.1	0.4	1.2	23 #	20 #	16 #
Minimum:	-0.4	11.8	423.3	-0.1	0.3	0	0	0
Maximum:	0.7	17.8	2,166.3	0.7	1.5	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/03/2019 00:00	0.1	12.7	1,982.9	0.2	1.4	1	1	1
11/03/2019 01:00	0.2	12.5	2,001.1	0.4	1.4	1	1	1
11/03/2019 02:00	0.2	12.6	1,988.3	0.4	1.4	1	1	1
11/03/2019 03:00	0.2	12.5	2,009.0	0.4	1.4	1	1	1
11/03/2019 04:00	0.2	12.4	2,043.8	0.4	1.4	1	1	1
11/03/2019 05:00	0.2	11.9	2,108.2	0.4	1.5	1	1	1
11/03/2019 06:00	0.2	12.3	2,077.9	0.4	1.5	1	1	1
11/03/2019 07:00	0.4	12.6	1,991.4	0.5	1.4	1	1	1
11/03/2019 08:00	0.6	14.0	1,603.3	0.6	1.1	1	1	0
11/03/2019 09:00	0.6	14.1	1,588.7	0.6	1.1	1	1	0
11/03/2019 10:00	0.6	14.1	1,609.0	0.6	1.1	1	1	0
11/03/2019 11:00	0.6	14.1	1,598.8	0.6	1.1	1	1	0
11/03/2019 12:00	0.6	14.1	1,613.4	0.6	1.1	1	1	0
11/03/2019 13:00	0.6	14.1	1,466.9	0.6	1.0	1	1	0
11/03/2019 14:00	0.6	14.1	1,443.1	0.6	1.0	1	1	0
11/03/2019 15:00	0.4	13.4	1,764.3	0.4	1.2	1	1	1
11/03/2019 16:00	-0.4	12.2	2,071.1	-0.1	1.4	1	1	1
11/03/2019 17:00	-0.2	12.0	2,115.7	0.1	1.5	1	1	1
11/03/2019 18:00	-0.2	11.8	2,145.5	0.1	1.5	1	1	1
11/03/2019 19:00	-0.1	11.7	2,171.6	0.2	1.5	1	1	1
11/03/2019 20:00	-0.1	12.0	2,120.9	0.2	1.5	1	1	1
11/03/2019 21:00	-0.2	12.2	2,086.4	0.1	1.5	1	1	1
11/03/2019 22:00	-0.1	12.5	2,016.4	0.1	1.4	1	1	1
11/03/2019 23:00	0.1	12.3	2,054.2	0.2	1.4	1	1	1
Average/Sum#:	0.2	12.8	1,903.0	0.4	1.3	24 #	24 #	17 #
Minimum:	-0.4	11.7	1,443.1	-0.1	1.0	1	1	0
Maximum:	0.6	14.1	2,171.6	0.6	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/04/2019 00:00	0.2	12.4	2,017.2	0.4	1.4	1	1	1
11/04/2019 01:00	0.2	12.4	2,021.0	0.4	1.4	1	1	1
11/04/2019 02:00	0.2	12.7	1,956.6	0.4	1.4	1	1	1
11/04/2019 03:00	0.2	12.6	1,988.3	0.4	1.4	1	1	1
11/04/2019 04:00	0.2	12.5	2,011.8	0.4	1.4	1	1	1
11/04/2019 05:00	0.2	11.8	2,113.7	0.4	1.5	1	1	1
11/04/2019 06:00	0.2	11.8	2,167.1	0.4	1.5	1	1	1
11/04/2019 07:00	0.2	12.5	2,023.1	0.4	1.4	1	1	1
11/04/2019 08:00	0.1	12.5	2,033.8	0.2	1.4	1	1	1
11/04/2019 09:00	0.2	12.1	2,078.9	0.4	1.5	1	1	1
11/04/2019 10:00	0.2	12.2	2,046.2	0.4	1.4	1	1	1
11/04/2019 11:00	0.2	12.5	1,974.0	0.4	1.4	1	1	1
11/04/2019 12:00	0.4	12.1	2,041.9	0.5	1.4	1	1	1
11/04/2019 13:00	0.4	12.0	2,057.4	0.5	1.4	1	1	1
11/04/2019 14:00	0.4	12.1	2,029.1	0.5	1.4	1	1	1
11/04/2019 15:00	0.4	12.0	2,057.2	0.5	1.4	1	1	1
11/04/2019 16:00	0.4	11.8	2,111.5	0.5	1.5	1	1	1
11/04/2019 17:00	-0.1	11.8	2,165.5	0.2	1.5	1	1	1
11/04/2019 18:00	-0.1	11.8	2,169.5	0.2	1.5	1	1	1
11/04/2019 19:00	-0.1	11.9	2,166.6	0.2	1.5	1	1	1
11/04/2019 20:00	-0.1	12.0	2,148.6	0.2	1.5	1	1	1
11/04/2019 21:00	-0.1	11.9	2,151.7	0.2	1.5	1	1	1
11/04/2019 22:00	-0.1	11.9	2,154.1	0.2	1.5	1	1	1
11/04/2019 23:00	-0.1	12.4	2,070.8	0.2	1.4	1	1	1
Average/Sum#:	0.2	12.2	2,073.2	0.4	1.4	24 #	24 #	24 #
Minimum:	-0.1	11.8	1,956.6	0.2	1.4	1	1	1
Maximum:	0.4	12.7	2,169.5	0.5	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/05/2019 00:00	-0.2	12.3	2,088.8	0.1	1.5	1	1	1
11/05/2019 01:00	-0.2	12.3	2,089.2	0.1	1.5	1	1	1
11/05/2019 02:00	-0.2	12.3	2,085.5	0.1	1.5	1	1	1
11/05/2019 03:00	-0.2	12.3	2,084.4	0.1	1.5	1	1	1
11/05/2019 04:00	-0.2	12.3	2,074.8	0.1	1.5	1	1	1
11/05/2019 05:00	-0.2	12.0	2,120.9	0.1	1.5	1	1	1
11/05/2019 06:00	0.1	11.9	2,186.0	0.2	1.5	1	1	1
11/05/2019 07:00	0.2	12.7	2,024.9	0.4	1.4	1	1	1
11/05/2019 08:00	-0.2	12.8	2,004.9	0.1	1.4	1	1	1
11/05/2019 09:00	-0.1	12.9	1,955.4	0.1	1.4	1	1	1
11/05/2019 10:00	0.1	12.8	1,968.2	0.2	1.4	1	1	1
11/05/2019 11:00	0.1	12.8	1,967.1	0.2	1.4	1	1	1
11/05/2019 12:00	0.1	12.7	1,982.3	0.2	1.4	1	1	1
11/05/2019 13:00	0.2	12.4	2,046.5	0.4	1.4	1	1	1
11/05/2019 14:00	0.1	12.5	2,024.2	0.2	1.4	1	1	1
11/05/2019 15:00	0.1	12.4	2,041.2	0.2	1.4	1	1	1
11/05/2019 16:00	0.2	12.0	2,120.2	0.4	1.5	1	1	1
11/05/2019 17:00	0.2	12.1	2,095.3	0.4	1.5	1	1	1
11/05/2019 18:00	0.1	12.1	2,099.8	0.2	1.5	1	1	1
11/05/2019 19:00	0.2	12.1	2,112.9	0.4	1.5	1	1	1
11/05/2019 20:00	0.1	12.1	2,117.9	0.2	1.5	1	1	1
11/05/2019 21:00	0.1	12.3	2,090.1	0.2	1.5	1	1	1
11/05/2019 22:00	0.1	12.3	2,086.6	0.2	1.5	1	1	1
11/05/2019 23:00	0.1	12.3	2,086.9	0.2	1.5	1	1	1
Average/Sum#:	0.0	12.4	2,064.8	0.2	1.5	24 #	24 #	24 #
Minimum:	-0.2	11.9	1,955.4	0.1	1.4	1	1	1
Maximum:	0.2	12.9	2,186.0	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/06/2019 00:00	0.1	12.6	2,004.2	0.2	1.4	1	1	1
11/06/2019 01:00	-0.1	12.9	1,965.4	0.1	1.4	1	1	1
11/06/2019 02:00	0.1	12.5	2,046.3	0.2	1.4	1	1	1
11/06/2019 03:00	0.1	12.5	2,041.6	0.2	1.4	1	1	1
11/06/2019 04:00	0.2	12.7	1,991.3	0.4	1.4	1	1	1
11/06/2019 05:00	0.2	12.4	2,032.1	0.4	1.4	1	1	1
11/06/2019 06:00	0.1	12.1	2,120.7	0.2	1.5	1	1	1
11/06/2019 07:00	-0.2	12.4	2,059.7	0.1	1.4	1	1	1
11/06/2019 08:00	-0.4	12.6	2,014.8	-0.1	1.4	1	1	1
11/06/2019 09:00	-0.2	12.8	1,976.8	0.1	1.4	1	1	1
11/06/2019 10:00	-0.1	12.8	2,070.5	0.1	1.4	1	1	1
11/06/2019 11:00	0.1	12.7	2,095.9	0.2	1.5	1	1	1
11/06/2019 12:00	0.1	12.6	2,094.3	0.2	1.5	1	1	1
11/06/2019 13:00	0.1	12.6	2,104.3	0.2	1.5	1	1	1
11/06/2019 14:00	0.1	12.5	2,123.1	0.2	1.5	1	1	1
11/06/2019 15:00	0.2	12.4	2,134.4	0.4	1.5	1	1	1
11/06/2019 16:00	0.2	12.1	2,198.2	0.4	1.5	1	1	1
11/06/2019 17:00	0.2	11.9	2,237.1	0.4	1.6	1	1	1
11/06/2019 18:00	0.2	12.1	2,218.2	0.4	1.6	1	1	1
11/06/2019 19:00	0.2	12.0	2,223.9	0.4	1.6	1	1	1
11/06/2019 20:00	-0.1	12.0	2,231.2	0.2	1.6	1	1	1
11/06/2019 21:00	-0.1	12.0	2,248.2	0.2	1.6	1	1	1
11/06/2019 22:00	-0.2	12.1	2,220.8	0.1	1.6	1	1	1
11/06/2019 23:00	-0.2	12.4	2,170.2	0.1	1.5	1	1	1
Average/Sum#:	0.0	12.4	2,109.3	0.2	1.5	24 #	24 #	24 #
Minimum:	-0.4	11.9	1,965.4	-0.1	1.4	1	1	1
Maximum:	0.2	12.9	2,248.2	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/07/2019 00:00	-0.1	12.4	2,187.6	0.2	1.5	1	1	1
11/07/2019 01:00	0.2	12.3	2,175.9	0.4	1.5	1	1	1
11/07/2019 02:00	0.2	12.4	2,141.9	0.4	1.5	1	1	1
11/07/2019 03:00	0.2	12.8	2,080.8	0.4	1.5	1	1	1
11/07/2019 04:00	0.1	12.5	2,147.5	0.2	1.5	1	1	1
11/07/2019 05:00	0.1	12.4	2,148.9	0.2	1.5	1	1	1
11/07/2019 06:00	0.1	12.3	2,190.7	0.2	1.5	1	1	1
11/07/2019 07:00	0.1	12.5	2,150.3	0.2	1.5	1	1	1
11/07/2019 08:00	0.1	12.9	2,072.8	0.2	1.5	1	1	1
11/07/2019 09:00	0.1	12.8	2,077.3	0.2	1.5	1	1	1
11/07/2019 10:00	0.1	12.9	2,046.8	0.2	1.4	1	1	1
11/07/2019 11:00	0.1	12.7	2,093.3	0.2	1.5	1	1	1
11/07/2019 12:00	0.1	12.7	2,094.3	0.2	1.5	1	1	1
11/07/2019 13:00	0.1	12.7	2,091.8	0.2	1.5	1	1	1
11/07/2019 14:00	0.1	12.6	2,113.0	0.2	1.5	1	1	1
11/07/2019 15:00	0.1	12.5	2,140.0	0.2	1.5	1	1	1
11/07/2019 16:00	0.2	12.1	2,216.4	0.4	1.6	1	1	1
11/07/2019 17:00	0.1	12.4	2,156.1	0.2	1.5	1	1	1
11/07/2019 18:00	-0.1	11.8	2,283.2	0.2	1.6	1	1	1
11/07/2019 19:00	-0.1	11.8	2,296.1	0.2	1.6	1	1	1
11/07/2019 20:00	-0.1	12.1	2,215.0	0.2	1.6	1	1	1
11/07/2019 21:00	-0.2	12.3	2,173.0	0.1	1.5	1	1	1
11/07/2019 22:00	-0.2	12.4	2,178.2	0.1	1.5	1	1	1
11/07/2019 23:00	0.1	12.6	2,120.6	0.2	1.5	1	1	1
Average/Sum#:	0.1	12.5	2,149.6	0.2	1.5	24 #	24 #	24 #
Minimum:	-0.2	11.8	2,046.8	0.1	1.4	1	1	1
Maximum:	0.2	12.9	2,296.1	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/08/2019 00:00	0.2	12.3	2,174.6	0.4	1.5	1	1	1
11/08/2019 01:00	0.2	12.2	2,199.0	0.4	1.5	1	1	1
11/08/2019 02:00	0.2	12.4	2,155.6	0.4	1.5	1	1	1
11/08/2019 03:00	0.2	12.6	2,121.2	0.4	1.5	1	1	1
11/08/2019 04:00	0.1	12.7	2,109.9	0.2	1.5	1	1	1
11/08/2019 05:00	0.1	12.6	2,119.7	0.2	1.5	1	1	1
11/08/2019 06:00	0.1	12.6	2,121.8	0.2	1.5	1	1	1
11/08/2019 07:00	0.2	12.7	2,106.9	0.4	1.5	1	1	1
11/08/2019 08:00	0.5	13.3	1,954.7	0.5	1.4	1	1	1
11/08/2019 09:00	0.6	14.0	1,568.9	0.6	1.1	1	1	0
11/08/2019 10:00	0.6	14.1	1,391.5	0.6	1.0	1	1	0
11/08/2019 11:00	0.6	14.1	1,550.3	0.6	1.1	1	1	0
11/08/2019 12:00	0.6	14.1	1,552.1	0.6	1.1	1	1	0
11/08/2019 13:00	0.6	14.0	1,700.1	0.6	1.2	1	1	0
11/08/2019 14:00	0.7	14.0	1,711.4	0.7	1.2	1	1	1
11/08/2019 15:00	-0.2	12.9	2,042.9	0.1	1.4	1	1	1
11/08/2019 16:00	-0.2	12.6	2,098.0	0.1	1.5	1	1	1
11/08/2019 17:00	-0.2	12.5	2,118.4	0.1	1.5	1	1	1
11/08/2019 18:00	-0.2	12.2	2,175.4	0.1	1.5	1	1	1
11/08/2019 19:00	-0.2	12.4	2,133.6	0.1	1.5	1	1	1
11/08/2019 20:00	-0.2	12.3	2,168.0	0.1	1.5	1	1	1
11/08/2019 21:00	-0.2	12.3	2,174.5	0.1	1.5	1	1	1
11/08/2019 22:00	-0.2	12.4	2,170.3	0.1	1.5	1	1	1
11/08/2019 23:00	0.1	12.3	2,176.9	0.2	1.5	1	1	1
Average/Sum#:	0.2	12.9	1,991.5	0.3	1.4	24 #	24 #	19 #
Minimum:	-0.2	12.2	1,391.5	0.1	1.0	1	1	0
Maximum:	0.7	14.1	2,199.0	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/09/2019 00:00	0.2	12.2	2,182.0	0.4	1.5	1	1	1
11/09/2019 01:00	0.2	12.3	2,159.0	0.4	1.5	1	1	1
11/09/2019 02:00	0.2	12.3	2,162.3	0.4	1.5	1	1	1
11/09/2019 03:00	0.2	12.2	2,166.6	0.4	1.5	1	1	1
11/09/2019 04:00	0.2	12.2	2,177.3	0.4	1.5	1	1	1
11/09/2019 05:00	0.1	12.7	2,107.5	0.2	1.5	1	1	1
11/09/2019 06:00	0.1	12.7	2,085.2	0.2	1.5	1	1	1
11/09/2019 07:00	0.4	12.8	2,050.2	0.5	1.4	1	1	1
11/09/2019 08:00	0.7	14.0	1,569.3	0.7	1.1	1	1	1
11/09/2019 09:00	0.6	14.1	1,326.2	0.6	0.9	1	1	0
11/09/2019 10:00	0.6	14.2	1,340.4	0.6	0.9	1	1	0
11/09/2019 11:00	0.6	14.2	1,327.7	0.6	0.9	1	1	0
11/09/2019 12:00	0.6	14.2	1,332.2	0.6	0.9	1	1	0
11/09/2019 13:00	0.6	14.2	1,324.1	0.6	0.9	1	1	0
11/09/2019 14:00	0.7	14.1	1,565.1	0.7	1.1	1	1	1
11/09/2019 15:00	-0.2	12.8	2,054.2	0.1	1.4	1	1	1
11/09/2019 16:00	-0.2	12.6	2,100.8	0.1	1.5	1	1	1
11/09/2019 17:00	-0.2	12.4	2,129.6	0.1	1.5	1	1	1
11/09/2019 18:00	-0.2	12.6	2,102.2	0.1	1.5	1	1	1
11/09/2019 19:00	-0.2	12.6	2,106.5	0.1	1.5	1	1	1
11/09/2019 20:00	-0.2	12.6	2,095.8	0.1	1.5	1	1	1
11/09/2019 21:00	-0.2	12.6	2,122.8	0.1	1.5	1	1	1
11/09/2019 22:00	-0.2	12.5	2,141.9	0.1	1.5	1	1	1
11/09/2019 23:00	-0.2	12.6	2,114.0	0.1	1.5	1	1	1
Average/Sum#:	0.2	13.0	1,910.1	0.3	1.3	24 #	24 #	19 #
Minimum:	-0.2	12.2	1,324.1	0.1	0.9	1	1	0
Maximum:	0.7	14.2	2,182.0	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/10/2019 00:00	-0.2	12.6	2,129.0	0.1	1.5	1	1	1
11/10/2019 01:00	-0.1	12.9	2,062.9	0.1	1.4	1	1	1
11/10/2019 02:00	0.1	12.8	2,059.1	0.2	1.4	1	1	1
11/10/2019 03:00	0.2	12.8	2,062.4	0.4	1.4	1	1	1
11/10/2019 04:00	0.2	12.8	2,062.5	0.4	1.4	1	1	1
11/10/2019 05:00	0.1	12.8	2,059.6	0.2	1.4	1	1	1
11/10/2019 06:00	0.1	12.7	2,101.9	0.2	1.5	1	1	1
11/10/2019 07:00	0.2	12.7	2,072.8	0.4	1.5	1	1	1
11/10/2019 08:00	0.6	14.0	1,600.0	0.6	1.1	1	1	0
11/10/2019 09:00	0.6	14.1	1,562.7	0.6	1.1	1	1	0
11/10/2019 10:00	0.6	14.1	1,570.8	0.6	1.1	1	1	0
11/10/2019 11:00	0.6	14.1	1,609.2	0.6	1.1	1	1	0
11/10/2019 12:00	0.6	14.1	1,597.1	0.6	1.1	1	1	0
11/10/2019 13:00	0.6	14.1	1,684.7	0.6	1.2	1	1	0
11/10/2019 14:00	0.6	14.1	1,647.6	0.6	1.2	1	1	0
11/10/2019 15:00	0.7	14.0	1,581.4	0.7	1.1	1	1	1
11/10/2019 16:00	-0.2	12.8	2,050.6	0.1	1.4	1	1	1
11/10/2019 17:00	-0.2	12.6	2,102.6	0.1	1.5	1	1	1
11/10/2019 18:00	-0.2	12.6	2,096.3	0.1	1.5	1	1	1
11/10/2019 19:00	-0.2	12.5	2,115.4	0.1	1.5	1	1	1
11/10/2019 20:00	-0.2	12.5	2,126.8	0.1	1.5	1	1	1
11/10/2019 21:00	-0.2	12.4	2,163.0	0.1	1.5	1	1	1
11/10/2019 22:00	-0.2	12.2	2,205.1	0.1	1.5	1	1	1
11/10/2019 23:00	-0.2	12.4	2,145.5	0.1	1.5	1	1	1
Average/Sum#:	0.2	13.1	1,936.2	0.3	1.4	24 #	24 #	17 #
Minimum:	-0.2	12.2	1,562.7	0.1	1.1	1	1	0
Maximum:	0.7	14.1	2,205.1	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/11/2019 00:00	-0.2	12.5	2,134.2	0.1	1.5	1	1	1
11/11/2019 01:00	-0.1	12.6	2,092.9	0.1	1.5	1	1	1
11/11/2019 02:00	-0.2	12.6	2,117.2	0.1	1.5	1	1	1
11/11/2019 03:00	-0.2	12.6	2,096.2	0.1	1.5	1	1	1
11/11/2019 04:00	-0.2	12.6	2,097.0	0.1	1.5	1	1	1
11/11/2019 05:00	-0.2	12.7	2,088.8	0.1	1.5	1	1	1
11/11/2019 06:00	-0.2	12.7	2,093.0	0.1	1.5	1	1	1
11/11/2019 07:00	0.1	12.6	2,103.1	0.2	1.5	1	1	1
11/11/2019 08:00	0.4	13.2	1,953.2	0.4	1.4	1	1	1
11/11/2019 09:00	0.6	14.0	1,534.1	0.6	1.1	1	1	0
11/11/2019 10:00	0.6	14.1	1,549.8	0.6	1.1	1	1	0
11/11/2019 11:00	0.6	14.1	1,542.3	0.6	1.1	1	1	0
11/11/2019 12:00	0.6	14.1	1,529.6	0.6	1.1	1	1	0
11/11/2019 13:00	0.7	14.0	1,751.1	0.7	1.2	1	1	1
11/11/2019 14:00	-0.2	12.9	2,025.7	0.1	1.4	1	1	1
11/11/2019 15:00	-0.2	12.4	2,121.9	0.1	1.5	1	1	1
11/11/2019 16:00	-0.2	12.4	2,116.1	0.1	1.5	1	1	1
11/11/2019 17:00	-0.1	11.9	2,228.9	0.2	1.6	1	1	1
11/11/2019 18:00	-0.1	12.0	2,208.5	0.2	1.5	1	1	1
11/11/2019 19:00	-0.2	12.2	2,171.1	0.1	1.5	1	1	1
11/11/2019 20:00	-0.2	12.2	2,174.6	0.1	1.5	1	1	1
11/11/2019 21:00	-0.2	12.3	2,180.9	0.1	1.5	1	1	1
11/11/2019 22:00	-0.2	12.3	2,179.1	0.1	1.5	1	1	1
11/11/2019 23:00	-0.2	12.3	2,165.3	0.1	1.5	1	1	1
Average/Sum#:	0.0	12.8	2,010.6	0.2	1.4	24 #	24 #	20 #
Minimum:	-0.2	11.9	1,529.6	0.1	1.1	1	1	0
Maximum:	0.7	14.1	2,228.9	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/12/2019 00:00	-0.2	12.4	2,148.0	0.1	1.5	1	1	1
11/12/2019 01:00	-0.2	12.4	2,151.2	0.1	1.5	1	1	1
11/12/2019 02:00	-0.2	12.6	2,118.1	0.1	1.5	1	1	1
11/12/2019 03:00	0.1	12.3	2,163.2	0.2	1.5	1	1	1
11/12/2019 04:00	0.1	12.4	2,143.4	0.2	1.5	1	1	1
11/12/2019 05:00	0.1	12.5	2,123.1	0.2	1.5	1	1	1
11/12/2019 06:00	0.1	12.3	2,168.3	0.2	1.5	1	1	1
11/12/2019 07:00	0.1	12.4	2,134.0	0.2	1.5	1	1	1
11/12/2019 08:00	0.1	12.5	2,121.6	0.2	1.5	1	1	1
11/12/2019 09:00	0.1	12.5	2,109.8	0.2	1.5	1	1	1
11/12/2019 10:00	0.1	12.4	2,141.5	0.2	1.5	1	1	1
11/12/2019 11:00	0.2	12.5	2,097.7	0.4	1.5	1	1	1
11/12/2019 12:00	0.2	12.5	2,085.2	0.4	1.5	1	1	1
11/12/2019 13:00	-0.1	12.5	2,108.1	0.1	1.5	1	1	1
11/12/2019 14:00	-0.1	12.6	2,098.9	0.1	1.5	1	1	1
11/12/2019 15:00	-0.2	12.5	2,100.4	0.1	1.5	1	1	1
11/12/2019 16:00	-0.2	12.6	2,089.2	0.1	1.5	1	1	1
11/12/2019 17:00	-0.2	12.3	2,161.1	0.1	1.5	1	1	1
11/12/2019 18:00	-0.2	12.3	2,146.5	0.1	1.5	1	1	1
11/12/2019 19:00	-0.2	12.2	2,182.5	0.1	1.5	1	1	1
11/12/2019 20:00	-0.2	12.2	2,181.0	0.1	1.5	1	1	1
11/12/2019 21:00	-0.1	12.3	2,158.0	0.2	1.5	1	1	1
11/12/2019 22:00	-0.2	12.3	2,158.7	0.1	1.5	1	1	1
11/12/2019 23:00	-0.2	12.4	2,147.5	0.1	1.5	1	1	1
Average/Sum#:	-0.1	12.4	2,134.9	0.2	1.5	24 #	24 #	24 #
Minimum:	-0.2	12.2	2,085.2	0.1	1.5	1	1	1
Maximum:	0.2	12.6	2,182.5	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/13/2019 00:00	-0.1	12.5	2,133.2	0.1	1.5	1	1	1
11/13/2019 01:00	0.1	12.6	2,099.0	0.2	1.5	1	1	1
11/13/2019 02:00	0.1	12.6	2,099.4	0.2	1.5	1	1	1
11/13/2019 03:00	0.1	12.6	2,096.9	0.2	1.5	1	1	1
11/13/2019 04:00	0.1	12.5	2,124.8	0.2	1.5	1	1	1
11/13/2019 05:00	-0.1	12.4	2,129.8	0.2	1.5	1	1	1
11/13/2019 06:00	0.1	12.3	2,157.7	0.2	1.5	1	1	1
11/13/2019 07:00	0.1	12.4	2,140.0	0.2	1.5	1	1	1
11/13/2019 08:00	0.1	12.6	2,112.5	0.2	1.5	1	1	1
11/13/2019 09:00	0.1	12.6	2,098.8	0.2	1.5	1	1	1
11/13/2019 10:00	0.1	12.6	2,088.0	0.2	1.5	1	1	1
11/13/2019 11:00	0.1	12.5	2,108.8	0.2	1.5	1	1	1
11/13/2019 12:00	-0.2	12.6	2,103.8	0.1	1.5	1	1	1
11/13/2019 13:00	-0.2	12.4	2,125.1	0.1	1.5	1	1	1
11/13/2019 14:00	-0.1	12.4	2,138.2	0.2	1.5	1	1	1
11/13/2019 15:00	-0.2	12.4	2,138.0	0.1	1.5	1	1	1
11/13/2019 16:00	-0.2	12.5	2,107.1	0.1	1.5	1	1	1
11/13/2019 17:00	-0.1	11.9	2,227.9	0.2	1.6	1	1	1
11/13/2019 18:00	-0.1	12.2	2,165.9	0.2	1.5	1	1	1
11/13/2019 19:00	-0.1	12.4	2,124.9	0.2	1.5	1	1	1
11/13/2019 20:00	-0.2	12.3	2,155.1	0.1	1.5	1	1	1
11/13/2019 21:00	-0.2	12.3	2,143.4	0.1	1.5	1	1	1
11/13/2019 22:00	-0.2	12.5	2,116.7	0.1	1.5	1	1	1
11/13/2019 23:00	-0.2	12.3	2,155.7	0.1	1.5	1	1	1
Average/Sum#:	-0.1	12.4	2,128.8	0.2	1.5	24 #	24 #	24 #
Minimum:	-0.2	11.9	2,088.0	0.1	1.5	1	1	1
Maximum:	0.1	12.6	2,227.9	0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/14/2019 00:00	-0.1	12.2	2,177.1	0.2	1.5	1	1	1
11/14/2019 01:00	-0.1	12.2	2,182.2	0.2	1.5	1	1	1
11/14/2019 02:00	-0.1	12.3	2,173.9	0.2	1.5	1	1	1
11/14/2019 03:00	-0.1	12.2	2,182.4	0.2	1.5	1	1	1
11/14/2019 04:00	-0.1	12.2	2,176.3	0.2	1.5	1	1	1
11/14/2019 05:00	-0.2	12.3	2,149.8	0.1	1.5	1	1	1
11/14/2019 06:00	-0.1	12.3	2,187.6	0.2	1.5	1	1	1
11/14/2019 07:00	0.1	12.4	2,146.2	0.2	1.5	1	1	1
11/14/2019 08:00	0.1	12.6	2,089.7	0.2	1.5	1	1	1
11/14/2019 09:00	0.1	12.4	2,142.2	0.2	1.5	1	1	1
11/14/2019 10:00	0.1	12.2	2,167.8	0.2	1.5	1	1	1
11/14/2019 11:00	0.1	12.4	2,119.8	0.2	1.5	1	1	1
11/14/2019 12:00	-0.1	12.1	2,184.2	0.2	1.5	1	1	1
11/14/2019 13:00	-0.2	12.2	2,174.0	0.1	1.5	1	1	1
11/14/2019 14:00	-0.2	12.2	2,169.1	0.1	1.5	1	1	1
11/14/2019 15:00	-0.2	12.2	2,165.2	0.1	1.5	1	1	1
11/14/2019 16:00	-0.7	12.3	2,141.0	-0.2	1.5	1	1	1
11/14/2019 17:00	-0.2	12.2	2,159.5	0.1	1.5	1	1	1
11/14/2019 18:00	-0.2	12.3	2,163.1	0.1	1.5	1	1	1
11/14/2019 19:00	-0.2	12.3	2,159.5	0.1	1.5	1	1	1
11/14/2019 20:00	-0.1	12.2	2,182.2	0.2	1.5	1	1	1
11/14/2019 21:00	0.1	12.3	2,170.5	0.2	1.5	1	1	1
11/14/2019 22:00	0.1	12.4	2,142.7	0.2	1.5	1	1	1
11/14/2019 23:00	-0.1	12.4	2,163.2	0.2	1.5	1	1	1
Average/Sum#:	-0.1	12.3	2,161.2	0.2	1.5	24 #	24 #	24 #
Minimum:	-0.7	12.1	2,089.7	-0.2	1.5	1	1	1
Maximum:	0.1	12.6	2,187.6	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/15/2019 00:00	0.1	12.5	2,126.7	0.2	1.5	1	1	1
11/15/2019 01:00	0.2	12.7	2,099.1	0.4	1.5	1	1	1
11/15/2019 02:00	0.2	12.6	2,118.5	0.4	1.5	1	1	1
11/15/2019 03:00	0.2	12.8	2,077.8	0.4	1.5	1	1	1
11/15/2019 04:00	0.2	12.7	2,083.9	0.4	1.5	1	1	1
11/15/2019 05:00	0.2	12.8	2,076.5	0.4	1.5	1	1	1
11/15/2019 06:00	0.1	12.5	2,143.5	0.2	1.5	1	1	1
11/15/2019 07:00	0.2	12.4	2,159.0	0.4	1.5	1	1	1
11/15/2019 08:00	0.2	12.6	2,106.1	0.4	1.5	1	1	1
11/15/2019 09:00	0.2	12.6	2,099.3	0.4	1.5	1	1	1
11/15/2019 10:00	0.4	12.6	2,108.4	0.5	1.5	1	1	1
11/15/2019 11:00	0.4	13.1	1,996.0	0.4	1.4	1	1	1
11/15/2019 12:00	0.2	12.7	2,077.5	0.4	1.5	1	1	1
11/15/2019 13:00	0.1	12.4	2,136.6	0.2	1.5	1	1	1
11/15/2019 14:00	-0.1	12.3	2,164.4	0.2	1.5	1	1	1
11/15/2019 15:00	-0.1	12.4	2,143.2	0.2	1.5	1	1	1
11/15/2019 16:00	-0.1	12.5	2,118.8	0.1	1.5	1	1	1
11/15/2019 17:00	-0.1	12.2	2,176.0	0.2	1.5	1	1	1
11/15/2019 18:00	-0.1	12.7	2,083.8	0.1	1.5	1	1	1
11/15/2019 19:00	-0.1	12.5	2,120.1	0.1	1.5	1	1	1
11/15/2019 20:00	-0.1	12.3	2,177.8	0.2	1.5	1	1	1
11/15/2019 21:00	-0.1	12.5	2,118.1	0.1	1.5	1	1	1
11/15/2019 22:00	-0.1	12.5	2,126.7	0.1	1.5	1	1	1
11/15/2019 23:00	-0.1	12.6	2,088.2	0.1	1.5	1	1	1
Average/Sum#:	0.1	12.6	2,113.6	0.3	1.5	24 #	24 #	24 #
Minimum:	-0.1	12.2	1,996.0	0.1	1.4	1	1	1
Maximum:	0.4	13.1	2,177.8	0.5	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/16/2019 00:00	-0.1	12.7	2,078.5	0.1	1.5	1	1	1
11/16/2019 01:00	0.1	12.8	2,069.7	0.2	1.4	1	1	1
11/16/2019 02:00	0.1	12.7	2,080.8	0.2	1.5	1	1	1
11/16/2019 03:00	0.2	12.7	2,084.1	0.4	1.5	1	1	1
11/16/2019 04:00	0.1	12.7	2,078.2	0.2	1.5	1	1	1
11/16/2019 05:00	0.1	12.7	2,086.5	0.2	1.5	1	1	1
11/16/2019 06:00	0.1	12.6	2,100.0	0.2	1.5	1	1	1
11/16/2019 07:00	0.2	12.8	2,042.8	0.4	1.4	1	1	1
11/16/2019 08:00	0.6	14.0	1,650.9	0.6	1.2	1	1	0
11/16/2019 09:00	0.6	14.0	1,550.5	0.6	1.1	1	1	0
11/16/2019 10:00	0.6	14.0	1,576.9	0.6	1.1	1	1	0
11/16/2019 11:00	0.6	14.0	1,669.1	0.6	1.2	1	1	0
11/16/2019 12:00	0.6	14.0	1,625.8	0.6	1.1	1	1	0
11/16/2019 13:00	0.6	14.1	1,708.8	0.6	1.2	1	1	0
11/16/2019 14:00	0.6	14.1	1,686.5	0.6	1.2	1	1	0
11/16/2019 15:00	0.7	14.0	1,581.4	0.7	1.1	1	1	1
11/16/2019 16:00	-0.2	12.7	2,073.2	0.1	1.5	1	1	1
11/16/2019 17:00	-0.2	12.4	2,137.6	0.1	1.5	1	1	1
11/16/2019 18:00	-0.2	12.5	2,118.9	0.1	1.5	1	1	1
11/16/2019 19:00	-0.2	12.5	2,128.5	0.1	1.5	1	1	1
11/16/2019 20:00	-0.2	12.4	2,133.1	0.1	1.5	1	1	1
11/16/2019 21:00	-0.2	12.4	2,141.3	0.1	1.5	1	1	1
11/16/2019 22:00	-0.2	12.5	2,124.7	0.1	1.5	1	1	1
11/16/2019 23:00	-0.2	12.6	2,115.1	0.1	1.5	1	1	1
Average/Sum#:	0.2	13.1	1,943.5	0.3	1.4	24 #	24 #	17 #
Minimum:	-0.2	12.4	1,550.5	0.1	1.1	1	1	0
Maximum:	0.7	14.1	2,141.3	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/17/2019 00:00	-0.2	12.7	2,097.8	0.1	1.5	1	1	1
11/17/2019 01:00	-0.1	12.7	2,100.2	0.1	1.5	1	1	1
11/17/2019 02:00	0.1	13.3	1,938.3	0.2	1.4	1	1	1
11/17/2019 03:00	0.6	14.0	1,594.7	0.6	1.1	1	1	0
11/17/2019 04:00	0.6	14.0	1,701.8	0.6	1.2	1	1	0
11/17/2019 05:00	0.6	14.0	1,564.5	0.6	1.1	1	1	0
11/17/2019 06:00	0.6	14.0	1,703.8	0.6	1.2	1	1	0
11/17/2019 07:00	0.6	14.0	1,660.3	0.6	1.2	1	1	0
11/17/2019 08:00	0.6	14.0	1,663.7	0.6	1.2	1	1	0
11/17/2019 09:00	0.6	14.0	1,671.7	0.6	1.2	1	1	0
11/17/2019 10:00	0.6	14.0	1,650.1	0.6	1.2	1	1	0
11/17/2019 11:00	0.6	14.0	1,705.8	0.6	1.2	1	1	0
11/17/2019 12:00	0.6	14.1	1,632.0	0.6	1.1	1	1	0
11/17/2019 13:00	0.6	14.1	1,679.6	0.6	1.2	1	1	0
11/17/2019 14:00	0.7	14.0	1,563.0	0.7	1.1	1	1	1
11/17/2019 15:00	-0.2	12.7	2,053.9	0.1	1.4	1	1	1
11/17/2019 16:00	-0.2	12.5	2,109.5	0.1	1.5	1	1	1
11/17/2019 17:00	-0.2	12.5	2,097.8	0.1	1.5	1	1	1
11/17/2019 18:00	-0.2	12.4	2,116.5	0.1	1.5	1	1	1
11/17/2019 19:00	-0.2	12.3	2,144.0	0.1	1.5	1	1	1
11/17/2019 20:00	-0.2	12.3	2,149.2	0.1	1.5	1	1	1
11/17/2019 21:00	-0.2	12.3	2,152.5	0.1	1.5	1	1	1
11/17/2019 22:00	-0.2	12.5	2,113.2	0.1	1.5	1	1	1
11/17/2019 23:00	-0.1	12.7	2,085.7	0.1	1.5	1	1	1
Average/Sum#:	0.2	13.3	1,872.9	0.4	1.3	24 #	24 #	13 #
Minimum:	-0.2	12.3	1,563.0	0.1	1.1	1	1	0
Maximum:	0.7	14.1	2,152.5	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/18/2019 00:00	-0.1	12.5	2,099.3	0.1	1.5	1	1	1
11/18/2019 01:00	-0.1	12.6	2,101.4	0.1	1.5	1	1	1
11/18/2019 02:00	-0.1	12.6	2,099.3	0.1	1.5	1	1	1
11/18/2019 03:00	-0.1	12.6	2,099.6	0.1	1.5	1	1	1
11/18/2019 04:00	0.1	12.7	2,083.5	0.2	1.5	1	1	1
11/18/2019 05:00	-0.1	12.6	2,088.7	0.1	1.5	1	1	1
11/18/2019 06:00	-0.2	12.3	2,158.7	0.1	1.5	1	1	1
11/18/2019 07:00	0.1	12.4	2,136.0	0.2	1.5	1	1	1
11/18/2019 08:00	0.1	12.7	2,084.1	0.2	1.5	1	1	1
11/18/2019 09:00	0.1	12.9	2,026.6	0.2	1.4	1	1	1
11/18/2019 10:00	-0.2	12.5	2,120.4	0.1	1.5	1	1	1
11/18/2019 11:00	-0.2	12.1	2,188.2	0.1	1.5	1	1	1
11/18/2019 12:00	-0.2	12.3	2,143.8	0.1	1.5	1	1	1
11/18/2019 13:00	-0.1	12.2	2,164.1	0.2	1.5	1	1	1
11/18/2019 14:00	-0.1	12.2	2,149.0	0.2	1.5	1	1	1
11/18/2019 15:00	-0.1	12.2	2,147.4	0.2	1.5	1	1	1
11/18/2019 16:00	-0.1	11.9	2,201.8	0.2	1.5	1	1	1
11/18/2019 17:00	-0.1	12.1	2,181.8	0.2	1.5	1	1	1
11/18/2019 18:00	-0.1	11.8	2,238.2	0.2	1.6	1	1	1
11/18/2019 19:00	-0.1	12.0	2,203.9	0.2	1.5	1	1	1
11/18/2019 20:00	-0.1	12.0	2,198.4	0.2	1.5	1	1	1
11/18/2019 21:00	-0.1	12.2	2,157.2	0.2	1.5	1	1	1
11/18/2019 22:00	-0.1	12.2	2,152.1	0.2	1.5	1	1	1
11/18/2019 23:00	-0.1	12.3	2,144.0	0.2	1.5	1	1	1
Average/Sum#:	-0.1	12.3	2,140.3	0.2	1.5	24 #	24 #	24 #
Minimum:	-0.2	11.8	2,026.6	0.1	1.4	1	1	1
Maximum:	0.1	12.9	2,238.2	0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/19/2019 00:00	-0.2	12.3	2,139.1	0.1	1.5	1	1	1
11/19/2019 01:00	-0.2	12.5	2,096.8	0.1	1.5	1	1	1
11/19/2019 02:00	-0.2	12.5	2,092.4	0.1	1.5	1	1	1
11/19/2019 03:00	-0.1	12.5	2,088.6	0.1	1.5	1	1	1
11/19/2019 04:00	-0.1	12.5	2,094.5	0.1	1.5	1	1	1
11/19/2019 05:00	-0.1	12.4	2,105.8	0.2	1.5	1	1	1
11/19/2019 06:00	-0.1	12.5	2,087.1	0.1	1.5	1	1	1
11/19/2019 07:00	0.1	12.4	2,111.5	0.2	1.5	1	1	1
11/19/2019 08:00	-0.1	12.1	2,176.8	0.2	1.5	1	1	1
11/19/2019 09:00	0.7	0.0	2,145.5	0.7	1.5	1	1	1
11/19/2019 10:00	0.1	12.2	2,186.7	0.2	1.5	1	1	1
11/19/2019 11:00	0.1	12.4	2,153.9	0.2	1.5	1	1	1
11/19/2019 12:00	0.1	12.4	2,125.1	0.2	1.5	1	1	1
11/19/2019 13:00	0.1	12.5	2,113.5	0.2	1.5	1	1	1
11/19/2019 14:00	0.1	12.3	2,141.3	0.2	1.5	1	1	1
11/19/2019 15:00	0.1	12.5	2,106.0	0.2	1.5	1	1	1
11/19/2019 16:00	0.1	12.5	2,103.7	0.2	1.5	1	1	1
11/19/2019 17:00	0.2	12.0	2,219.9	0.4	1.6	1	1	1
11/19/2019 18:00	0.2	11.7	2,265.4	0.4	1.6	1	1	1
11/19/2019 19:00	0.1	12.3	2,145.2	0.2	1.5	1	1	1
11/19/2019 20:00	0.1	12.5	2,114.6	0.2	1.5	1	1	1
11/19/2019 21:00	0.1	12.4	2,140.3	0.2	1.5	1	1	1
11/19/2019 22:00	0.1	12.4	2,145.4	0.2	1.5	1	1	1
11/19/2019 23:00	0.1	12.3	2,154.4	0.2	1.5	1	1	1
Average/Sum#:	0.0	12.4	2,135.6	0.2	1.5	24 #	24 #	24 #
Minimum:	-0.2	11.7	2,087.1	0.1	1.5	1	1	1
Maximum:	0.2	12.5	2,265.4	0.4	1.6	1	1	1
%SI	4.17	4.17	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/20/2019 00:00	0.1	12.5	2,120.3	0.2	1.5	1	1	1
11/20/2019 01:00	0.1	12.6	2,100.2	0.2	1.5	1	1	1
11/20/2019 02:00	0.1	12.7	2,076.7	0.2	1.5	1	1	1
11/20/2019 03:00	0.1	12.7	2,083.5	0.2	1.5	1	1	1
11/20/2019 04:00	0.1	12.6	2,102.7	0.2	1.5	1	1	1
11/20/2019 05:00	-0.1	12.5	2,106.1	0.1	1.5	1	1	1
11/20/2019 06:00	0.1	12.3	2,169.8	0.2	1.5	1	1	1
11/20/2019 07:00	0.1	12.2	2,195.6	0.2	1.5	1	1	1
11/20/2019 08:00	0.1	12.2	2,180.4	0.2	1.5	1	1	1
11/20/2019 09:00	0.1	12.2	2,193.1	0.2	1.5	1	1	1
11/20/2019 10:00	0.1	12.2	2,192.6	0.2	1.5	1	1	1
11/20/2019 11:00	0.1	12.4	2,139.0	0.2	1.5	1	1	1
11/20/2019 12:00	0.1	12.4	2,142.5	0.2	1.5	1	1	1
11/20/2019 13:00	0.1	12.4	2,150.5	0.2	1.5	1	1	1
11/20/2019 14:00	0.1	12.2	2,171.7	0.2	1.5	1	1	1
11/20/2019 15:00	0.2	12.1	2,208.1	0.4	1.5	1	1	1
11/20/2019 16:00	0.1	12.3	2,163.5	0.2	1.5	1	1	1
11/20/2019 17:00	0.2	11.8	2,273.5	0.4	1.6	1	1	1
11/20/2019 18:00	0.2	11.7	2,282.2	0.4	1.6	1	1	1
11/20/2019 19:00	0.2	11.7	2,291.3	0.4	1.6	1	1	1
11/20/2019 20:00	0.2	11.9	2,247.2	0.4	1.6	1	1	1
11/20/2019 21:00	0.2	12.1	2,224.0	0.4	1.6	1	1	1
11/20/2019 22:00	0.1	12.3	2,173.9	0.2	1.5	1	1	1
11/20/2019 23:00	0.1	12.4	2,154.4	0.2	1.5	1	1	1
Average/Sum#:	0.1	12.3	2,172.6	0.2	1.5	24 #	24 #	24 #
Minimum:	-0.1	11.7	2,076.7	0.1	1.5	1	1	1
Maximum:	0.2	12.7	2,291.3	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/21/2019 00:00	0.1	12.3	2,188.1	0.2	1.5	1	1	1
11/21/2019 01:00	0.1	12.2	2,194.2	0.2	1.5	1	1	1
11/21/2019 02:00	0.1	12.3	2,179.6	0.2	1.5	1	1	1
11/21/2019 03:00	0.2	12.2	2,206.5	0.4	1.5	1	1	1
11/21/2019 04:00	0.4	12.1	2,215.0	0.5	1.6	1	1	1
11/21/2019 05:00	0.2	11.9	2,218.3	0.4	1.6	1	1	1
11/21/2019 06:00	0.4	11.8	2,280.5	0.5	1.6	1	1	1
11/21/2019 07:00	0.4	11.8	2,282.9	0.5	1.6	1	1	1
11/21/2019 08:00	0.2	12.3	2,191.2	0.4	1.5	1	1	1
11/21/2019 09:00	0.2	12.7	2,096.8	0.4	1.5	1	1	1
11/21/2019 10:00	0.1	12.5	2,131.4	0.2	1.5	1	1	1
11/21/2019 11:00	0.1	12.7	2,086.9	0.2	1.5	1	1	1
11/21/2019 12:00	0.1	12.5	2,127.9	0.2	1.5	1	1	1
11/21/2019 13:00	0.1	12.6	2,107.6	0.2	1.5	1	1	1
11/21/2019 14:00	0.1	12.6	2,096.1	0.2	1.5	1	1	1
11/21/2019 15:00	0.1	12.5	2,124.4	0.2	1.5	1	1	1
11/21/2019 16:00	0.1	12.1	2,220.6	0.2	1.6	1	1	1
11/21/2019 17:00	0.1	11.9	2,254.5	0.2	1.6	1	1	1
11/21/2019 18:00	0.1	11.8	2,278.5	0.2	1.6	1	1	1
11/21/2019 19:00	0.2	11.7	2,285.4	0.4	1.6	1	1	1
11/21/2019 20:00	0.4	11.7	2,278.3	0.5	1.6	1	1	1
11/21/2019 21:00	0.4	11.8	2,282.3	0.5	1.6	1	1	1
11/21/2019 22:00	0.2	12.0	2,249.1	0.4	1.6	1	1	1
11/21/2019 23:00	0.2	12.1	2,206.6	0.4	1.5	1	1	1
Average/Sum#:	0.2	12.2	2,199.3	0.3	1.5	24 #	24 #	24 #
Minimum:	0.1	11.7	2,086.9	0.2	1.5	1	1	1
Maximum:	0.4	12.7	2,285.4	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/22/2019 00:00	0.2	12.3	2,168.0	0.4	1.5	1	1	1
11/22/2019 01:00	0.2	12.4	2,163.6	0.4	1.5	1	1	1
11/22/2019 02:00	0.2	12.4	2,167.5	0.4	1.5	1	1	1
11/22/2019 03:00	0.2	12.4	2,166.0	0.4	1.5	1	1	1
11/22/2019 04:00	0.2	12.7	2,106.4	0.4	1.5	1	1	1
11/22/2019 05:00	0.4	12.7	2,080.5	0.5	1.5	1	1	1
11/22/2019 06:00	0.4	11.9	2,283.4	0.5	1.6	1	1	1
11/22/2019 07:00	0.5	12.0	2,262.6	0.5	1.6	1	1	1
11/22/2019 08:00	0.5	12.6	2,099.8	0.5	1.5	1	1	1
11/22/2019 09:00	0.4	12.8	2,074.5	0.5	1.5	1	1	1
11/22/2019 10:00	0.4	12.7	2,102.7	0.5	1.5	1	1	1
11/22/2019 11:00	0.4	12.8	2,076.6	0.5	1.5	1	1	1
11/22/2019 12:00	0.2	12.7	2,087.1	0.4	1.5	1	1	1
11/22/2019 13:00	0.4	12.7	2,078.5	0.5	1.5	1	1	1
11/22/2019 14:00	0.2	12.6	2,103.2	0.4	1.5	1	1	1
11/22/2019 15:00	0.2	12.5	2,107.9	0.4	1.5	1	1	1
11/22/2019 16:00	0.4	11.9	2,239.2	0.5	1.6	1	1	1
11/22/2019 17:00	0.4	12.0	2,226.1	0.5	1.6	1	1	1
11/22/2019 18:00	0.4	11.9	2,251.6	0.5	1.6	1	1	1
11/22/2019 19:00	0.4	12.0	2,222.5	0.5	1.6	1	1	1
11/22/2019 20:00	0.4	12.1	2,218.5	0.5	1.6	1	1	1
11/22/2019 21:00	0.5	12.0	2,229.1	0.5	1.6	1	1	1
11/22/2019 22:00	0.5	12.1	2,188.7	0.5	1.5	1	1	1
11/22/2019 23:00	0.5	12.4	2,146.0	0.5	1.5	1	1	1
Average/Sum#:	0.4	12.4	2,160.4	0.5	1.5	24 #	24 #	24 #
Minimum:	0.2	11.9	2,074.5	0.4	1.5	1	1	1
Maximum:	0.5	12.8	2,283.4	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/23/2019 00:00	0.5	12.4	2,135.3	0.5	1.5	1	1	1
11/23/2019 01:00	0.5	12.3	2,161.1	0.5	1.5	1	1	1
11/23/2019 02:00	0.4	12.5	2,151.6	0.5	1.5	1	1	1
11/23/2019 03:00	0.5	12.7	2,110.4	0.5	1.5	1	1	1
11/23/2019 04:00	0.5	12.4	2,162.2	0.5	1.5	1	1	1
11/23/2019 05:00	0.4	12.3	2,169.0	0.5	1.5	1	1	1
11/23/2019 06:00	0.5	12.3	2,179.1	0.5	1.5	1	1	1
11/23/2019 07:00	0.5	12.4	2,145.1	0.5	1.5	1	1	1
11/23/2019 08:00	0.5	13.2	1,952.5	0.5	1.4	1	1	1
11/23/2019 09:00	0.6	13.9	1,695.8	0.6	1.2	1	1	0
11/23/2019 10:00	0.6	14.0	1,715.5	0.6	1.2	1	1	0
11/23/2019 11:00	0.6	14.0	1,686.0	0.6	1.2	1	1	0
11/23/2019 12:00	0.6	14.0	1,703.4	0.6	1.2	1	1	0
11/23/2019 13:00	0.6	14.0	1,720.5	0.6	1.2	1	1	0
11/23/2019 14:00	0.6	14.0	1,690.7	0.6	1.2	1	1	0
11/23/2019 15:00	0.5	13.4	1,871.8	0.5	1.3	1	1	1
11/23/2019 16:00	0.4	12.3	2,154.9	0.5	1.5	1	1	1
11/23/2019 17:00	0.4	12.2	2,185.9	0.5	1.5	1	1	1
11/23/2019 18:00	0.4	12.2	2,185.5	0.5	1.5	1	1	1
11/23/2019 19:00	0.4	12.0	2,233.6	0.5	1.6	1	1	1
11/23/2019 20:00	0.4	12.1	2,218.8	0.5	1.6	1	1	1
11/23/2019 21:00	0.4	12.4	2,159.6	0.5	1.5	1	1	1
11/23/2019 22:00	0.5	12.6	2,118.5	0.5	1.5	1	1	1
11/23/2019 23:00	0.5	12.6	2,079.4	0.5	1.5	1	1	1
Average/Sum#:	0.5	12.8	2,024.4	0.5	1.4	24 #	24 #	18 #
Minimum:	0.4	12.0	1,686.0	0.5	1.2	1	1	0
Maximum:	0.6	14.0	2,233.6	0.6	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/24/2019 00:00	0.5	12.6	2,079.0	0.5	1.5	1	1	1
11/24/2019 01:00	0.5	12.7	2,078.7	0.5	1.5	1	1	1
11/24/2019 02:00	0.5	12.8	2,064.3	0.5	1.4	1	1	1
11/24/2019 03:00	0.5	12.9	2,062.7	0.5	1.4	1	1	1
11/24/2019 04:00	0.5	12.8	2,075.8	0.5	1.5	1	1	1
11/24/2019 05:00	0.4	12.8	2,072.2	0.5	1.5	1	1	1
11/24/2019 06:00	0.4	12.6	2,133.4	0.5	1.5	1	1	1
11/24/2019 07:00	0.5	12.7	2,068.8	0.5	1.4	1	1	1
11/24/2019 08:00	0.6	13.9	1,683.6	0.6	1.2	1	1	0
11/24/2019 09:00	0.6	13.9	1,672.7	0.6	1.2	1	1	0
11/24/2019 10:00	0.6	13.9	1,700.6	0.6	1.2	1	1	0
11/24/2019 11:00	0.6	13.9	1,694.9	0.6	1.2	1	1	0
11/24/2019 12:00	0.6	13.9	1,728.2	0.6	1.2	1	1	0
11/24/2019 13:00	0.6	14.0	1,711.7	0.6	1.2	1	1	0
11/24/2019 14:00	0.6	14.0	1,665.9	0.6	1.2	1	1	0
11/24/2019 15:00	0.7	13.4	1,867.6	0.7	1.3	1	1	1
11/24/2019 16:00	0.2	12.6	2,101.8	0.4	1.5	1	1	1
11/24/2019 17:00	0.2	12.3	2,155.5	0.4	1.5	1	1	1
11/24/2019 18:00	0.2	12.7	2,076.3	0.4	1.5	1	1	1
11/24/2019 19:00	0.4	12.9	2,015.8	0.5	1.4	1	1	1
11/24/2019 20:00	0.2	12.7	2,085.2	0.4	1.5	1	1	1
11/24/2019 21:00	0.4	12.4	2,134.5	0.5	1.5	1	1	1
11/24/2019 22:00	0.4	12.7	2,063.8	0.5	1.4	1	1	1
11/24/2019 23:00	0.7	13.4	1,842.0	0.7	1.3	1	1	1
Average/Sum#:	0.5	13.1	1,951.5	0.5	1.4	24 #	24 #	17 #
Minimum:	0.2	12.3	1,665.9	0.4	1.2	1	1	0
Maximum:	0.7	14.0	2,155.5	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/25/2019 00:00	0.0	14.5	1,078.5	0.0	0.8	1	0	0
11/25/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2019 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2019 04:00	0.0	17.3	516.8	0.0	0.4	1	0	0
11/25/2019 05:00	0.0	14.5	1,328.8	0.0	0.9	1	0	0
11/25/2019 06:00	0.6	14.0	1,394.5	0.6	1.0	1	1	0
11/25/2019 07:00	0.6	13.9	1,648.7	0.6	1.2	1	1	0
11/25/2019 08:00	0.6	13.9	1,697.7	0.6	1.2	1	1	0
11/25/2019 09:00	0.6	13.9	1,651.8	0.6	1.2	1	1	0
11/25/2019 10:00	0.6	14.0	1,674.1	0.6	1.2	1	1	0
11/25/2019 11:00	0.6	14.0	1,719.6	0.6	1.2	1	1	0
11/25/2019 12:00	0.6	14.0	1,712.3	0.6	1.2	1	1	0
11/25/2019 13:00	0.6	14.0	1,707.9	0.6	1.2	1	1	0
11/25/2019 14:00	0.6	14.0	1,698.8	0.6	1.2	1	1	0
11/25/2019 15:00	0.7	13.9	1,615.4	0.7	1.1	1	1	1
11/25/2019 16:00	0.2	12.8	2,087.6	0.4	1.5	1	1	1
11/25/2019 17:00	0.2	12.0	2,236.1	0.4	1.6	1	1	1
11/25/2019 18:00	0.2	12.4	2,136.2	0.4	1.5	1	1	1
11/25/2019 19:00	0.2	12.2	2,193.1	0.4	1.5	1	1	1
11/25/2019 20:00	0.2	12.2	2,199.1	0.4	1.5	1	1	1
11/25/2019 21:00	0.2	12.3	2,163.2	0.4	1.5	1	1	1
11/25/2019 22:00	0.2	12.5	2,128.3	0.4	1.5	1	1	1
11/25/2019 23:00	0.4	12.6	2,107.0	0.5	1.5	1	1	1
Average/Sum#:	0.4	13.6	1,747.4	0.4	1.2	21 #	18 #	9 #
Minimum:	0.0	12.0	516.8	0.0	0.4	0	0	0
Maximum:	0.7	17.3	2,236.1	0.7	1.6	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/26/2019 00:00	0.2	12.5	2,137.6	0.4	1.5	1	1	1
11/26/2019 01:00	0.2	12.4	2,161.7	0.4	1.5	1	1	1
11/26/2019 02:00	0.4	12.7	2,087.5	0.5	1.5	1	1	1
11/26/2019 03:00	0.4	12.7	2,083.5	0.5	1.5	1	1	1
11/26/2019 04:00	0.4	12.8	2,070.4	0.5	1.4	1	1	1
11/26/2019 05:00	0.2	13.0	2,007.1	0.4	1.4	1	1	1
11/26/2019 06:00	0.2	12.2	2,213.6	0.4	1.5	1	1	1
11/26/2019 07:00	0.5	12.7	1,981.9	0.5	1.4	1	1	1
11/26/2019 08:00	0.6	13.9	1,686.6	0.6	1.2	1	1	0
11/26/2019 09:00	0.6	13.9	1,713.5	0.6	1.2	1	1	0
11/26/2019 10:00	0.6	13.9	1,588.4	0.6	1.1	1	1	0
11/26/2019 11:00	0.6	13.9	1,644.8	0.6	1.2	1	1	0
11/26/2019 12:00	0.6	13.9	1,623.1	0.6	1.1	1	1	0
11/26/2019 13:00	0.6	13.9	1,659.4	0.6	1.2	1	1	0
11/26/2019 14:00	0.5	13.3	1,884.0	0.5	1.3	1	1	1
11/26/2019 15:00	0.1	12.6	2,088.4	0.2	1.5	1	1	1
11/26/2019 16:00	0.2	12.7	2,052.2	0.4	1.4	1	1	1
11/26/2019 17:00	0.2	12.4	2,125.3	0.4	1.5	1	1	1
11/26/2019 18:00	0.1	12.5	2,092.2	0.2	1.5	1	1	1
11/26/2019 19:00	0.1	12.5	2,117.1	0.2	1.5	1	1	1
11/26/2019 20:00	0.1	12.2	2,157.1	0.2	1.5	1	1	1
11/26/2019 21:00	0.1	12.3	2,127.0	0.2	1.5	1	1	1
11/26/2019 22:00	0.1	12.4	2,102.4	0.2	1.5	1	1	1
11/26/2019 23:00	0.1	12.3	2,115.3	0.2	1.5	1	1	1
Average/Sum#:	0.3	12.9	1,980.0	0.4	1.4	24 #	24 #	18 #
Minimum:	0.1	12.2	1,588.4	0.2	1.1	1	1	0
Maximum:	0.6	13.9	2,213.6	0.6	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/27/2019 00:00	0.1	12.3	2,131.6	0.2	1.5	1	1	1
11/27/2019 01:00	0.1	12.4	2,100.9	0.2	1.5	1	1	1
11/27/2019 02:00	0.1	12.6	2,064.8	0.2	1.4	1	1	1
11/27/2019 03:00	0.1	12.6	2,058.7	0.2	1.4	1	1	1
11/27/2019 04:00	0.1	12.6	2,071.6	0.2	1.5	1	1	1
11/27/2019 05:00	0.1	12.5	2,079.9	0.2	1.5	1	1	1
11/27/2019 06:00	0.1	12.8	2,025.5	0.2	1.4	1	1	1
11/27/2019 07:00	0.1	12.1	2,178.0	0.2	1.5	1	1	1
11/27/2019 08:00	0.2	12.2	2,174.5	0.4	1.5	1	1	1
11/27/2019 09:00	0.2	12.2	2,155.2	0.4	1.5	1	1	1
11/27/2019 10:00	0.2	12.2	2,140.8	0.4	1.5	1	1	1
11/27/2019 11:00	0.2	12.5	2,090.7	0.4	1.5	1	1	1
11/27/2019 12:00	0.2	12.3	2,124.2	0.4	1.5	1	1	1
11/27/2019 13:00	0.2	12.0	2,180.1	0.4	1.5	1	1	1
11/27/2019 14:00	0.2	12.1	2,162.8	0.4	1.5	1	1	1
11/27/2019 15:00	0.2	12.4	2,092.8	0.4	1.5	1	1	1
11/27/2019 16:00	0.2	12.6	2,059.0	0.4	1.4	1	1	1
11/27/2019 17:00	0.2	12.2	2,159.1	0.4	1.5	1	1	1
11/27/2019 18:00	0.4	13.0	1,989.8	0.5	1.4	1	1	1
11/27/2019 19:00	0.2	13.0	2,006.4	0.4	1.4	1	1	1
11/27/2019 20:00	0.1	12.1	2,207.3	0.2	1.5	1	1	1
11/27/2019 21:00	0.2	11.9	2,234.6	0.4	1.6	1	1	1
11/27/2019 22:00	0.1	12.3	2,173.1	0.2	1.5	1	1	1
11/27/2019 23:00	0.1	12.4	2,153.8	0.2	1.5	1	1	1
Average/Sum#:	0.2	12.4	2,117.3	0.3	1.5	24 #	24 #	24 #
Minimum:	0.1	11.9	1,989.8	0.2	1.4	1	1	1
Maximum:	0.4	13.0	2,234.6	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/28/2019 00:00	0.1	12.4	2,161.0	0.2	1.5	1	1	1
11/28/2019 01:00	0.1	12.5	2,137.8	0.2	1.5	1	1	1
11/28/2019 02:00	0.2	12.6	2,125.3	0.4	1.5	1	1	1
11/28/2019 03:00	0.4	12.5	2,162.9	0.5	1.5	1	1	1
11/28/2019 04:00	0.4	12.6	2,131.3	0.5	1.5	1	1	1
11/28/2019 05:00	0.2	12.7	2,102.0	0.4	1.5	1	1	1
11/28/2019 06:00	0.2	12.3	2,201.5	0.4	1.5	1	1	1
11/28/2019 07:00	0.1	12.2	2,216.2	0.2	1.6	1	1	1
11/28/2019 08:00	0.1	12.2	2,221.7	0.2	1.6	1	1	1
11/28/2019 09:00	0.1	12.2	2,198.3	0.2	1.5	1	1	1
11/28/2019 10:00	0.1	12.2	2,207.0	0.2	1.5	1	1	1
11/28/2019 11:00	0.2	12.1	2,215.4	0.4	1.6	1	1	1
11/28/2019 12:00	0.2	12.0	2,219.1	0.4	1.6	1	1	1
11/28/2019 13:00	0.2	12.1	2,200.5	0.4	1.5	1	1	1
11/28/2019 14:00	0.2	12.1	2,194.1	0.4	1.5	1	1	1
11/28/2019 15:00	0.2	12.0	2,210.6	0.4	1.5	1	1	1
11/28/2019 16:00	0.2	12.2	2,167.3	0.4	1.5	1	1	1
11/28/2019 17:00	0.2	12.2	2,167.5	0.4	1.5	1	1	1
11/28/2019 18:00	0.4	12.6	2,073.1	0.5	1.5	1	1	1
11/28/2019 19:00	0.2	12.3	2,158.8	0.4	1.5	1	1	1
11/28/2019 20:00	0.2	12.1	2,191.1	0.4	1.5	1	1	1
11/28/2019 21:00	0.2	12.1	2,190.6	0.4	1.5	1	1	1
11/28/2019 22:00	0.2	12.2	2,184.7	0.4	1.5	1	1	1
11/28/2019 23:00	0.2	12.0	2,207.5	0.4	1.5	1	1	1
Average/Sum#:	0.2	12.3	2,176.9	0.4	1.5	24 #	24 #	24 #
Minimum:	0.1	12.0	2,073.1	0.2	1.5	1	1	1
Maximum:	0.4	12.7	2,221.7	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/29/2019 00:00	0.2	12.1	2,208.9	0.4	1.5	1	1	1
11/29/2019 01:00	0.2	12.2	2,179.2	0.4	1.5	1	1	1
11/29/2019 02:00	0.2	12.2	2,185.4	0.4	1.5	1	1	1
11/29/2019 03:00	0.1	12.3	2,170.1	0.2	1.5	1	1	1
11/29/2019 04:00	0.2	12.1	2,198.9	0.4	1.5	1	1	1
11/29/2019 05:00	0.1	12.3	2,162.0	0.2	1.5	1	1	1
11/29/2019 06:00	0.1	12.1	2,217.2	0.2	1.6	1	1	1
11/29/2019 07:00	0.4	12.4	2,113.6	0.5	1.5	1	1	1
11/29/2019 08:00	0.6	13.9	1,595.4	0.6	1.1	1	1	0
11/29/2019 09:00	0.6	13.9	1,471.2	0.6	1.0	1	1	0
11/29/2019 10:00	0.6	13.9	1,632.9	0.6	1.1	1	1	0
11/29/2019 11:00	0.6	13.9	1,637.9	0.6	1.1	1	1	0
11/29/2019 12:00	0.6	13.9	1,587.7	0.6	1.1	1	1	0
11/29/2019 13:00	0.6	13.9	1,585.6	0.6	1.1	1	1	0
11/29/2019 14:00	0.6	13.9	1,495.2	0.6	1.0	1	1	0
11/29/2019 15:00	0.7	13.9	1,618.1	0.7	1.1	1	1	1
11/29/2019 16:00	0.4	12.8	2,052.1	0.5	1.4	1	1	1
11/29/2019 17:00	0.5	11.9	2,265.6	0.5	1.6	1	1	1
11/29/2019 18:00	0.5	11.8	2,286.7	0.5	1.6	1	1	1
11/29/2019 19:00	0.5	11.9	2,261.6	0.5	1.6	1	1	1
11/29/2019 20:00	0.5	11.9	2,271.4	0.5	1.6	1	1	1
11/29/2019 21:00	0.5	12.4	2,160.2	0.5	1.5	1	1	1
11/29/2019 22:00	0.4	12.5	2,173.5	0.5	1.5	1	1	1
11/29/2019 23:00	0.4	12.5	2,165.2	0.5	1.5	1	1	1
Average/Sum#:	0.4	12.8	1,987.3	0.5	1.4	24 #	24 #	17 #
Minimum:	0.1	11.8	1,471.2	0.2	1.0	1	1	0
Maximum:	0.7	13.9	2,286.7	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/30/2019 00:00	0.4	12.5	2,158.3	0.5	1.5	1	1	1
11/30/2019 01:00	0.4	12.5	2,155.6	0.5	1.5	1	1	1
11/30/2019 02:00	0.4	12.5	2,169.5	0.5	1.5	1	1	1
11/30/2019 03:00	0.4	12.4	2,170.5	0.5	1.5	1	1	1
11/30/2019 04:00	0.4	12.5	2,153.1	0.5	1.5	1	1	1
11/30/2019 05:00	0.4	12.5	2,132.3	0.5	1.5	1	1	1
11/30/2019 06:00	0.4	12.4	2,169.6	0.5	1.5	1	1	1
11/30/2019 07:00	0.4	12.5	2,138.0	0.5	1.5	1	1	1
11/30/2019 08:00	0.4	12.5	2,161.5	0.5	1.5	1	1	1
11/30/2019 09:00	0.4	12.4	2,180.5	0.5	1.5	1	1	1
11/30/2019 10:00	0.4	12.5	2,147.7	0.5	1.5	1	1	1
11/30/2019 11:00	0.4	12.7	2,092.1	0.5	1.5	1	1	1
11/30/2019 12:00	0.4	12.4	2,167.7	0.5	1.5	1	1	1
11/30/2019 13:00	0.4	12.4	2,162.5	0.5	1.5	1	1	1
11/30/2019 14:00	0.4	12.4	2,171.4	0.5	1.5	1	1	1
11/30/2019 15:00	0.4	12.5	2,151.6	0.5	1.5	1	1	1
11/30/2019 16:00	0.4	12.5	2,149.0	0.5	1.5	1	1	1
11/30/2019 17:00	0.4	12.4	2,166.5	0.5	1.5	1	1	1
11/30/2019 18:00	0.4	12.6	2,135.2	0.5	1.5	1	1	1
11/30/2019 19:00	0.4	12.2	2,213.0	0.5	1.5	1	1	1
11/30/2019 20:00	0.4	12.4	2,171.8	0.5	1.5	1	1	1
11/30/2019 21:00	0.4	12.4	2,156.3	0.5	1.5	1	1	1
11/30/2019 22:00	0.4	12.7	2,104.5	0.5	1.5	1	1	1
11/30/2019 23:00	0.4	12.8	2,091.4	0.5	1.5	1	1	1
Average/Sum#:	0.4	12.5	2,152.9	0.5	1.5	24 #	24 #	24 #
Minimum:	0.4	12.2	2,091.4	0.5	1.5	1	1	1
Maximum:	0.4	12.8	2,213.0	0.5	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/01/2019 00:00	0.4	12.6	2,140.9	0.5	1.5	1	1	1
12/01/2019 01:00	0.4	12.8	2,090.4	0.5	1.5	1	1	1
12/01/2019 02:00	0.4	12.8	2,089.1	0.5	1.5	1	1	1
12/01/2019 03:00	0.4	12.8	2,089.2	0.5	1.5	1	1	1
12/01/2019 04:00	0.4	12.8	2,084.8	0.5	1.5	1	1	1
12/01/2019 05:00	0.4	12.8	2,085.9	0.5	1.5	1	1	1
12/01/2019 06:00	0.4	12.9	2,075.5	0.5	1.5	1	1	1
12/01/2019 07:00	0.4	12.9	2,086.7	0.5	1.5	1	1	1
12/01/2019 08:00	0.4	12.5	2,176.0	0.5	1.5	1	1	1
12/01/2019 09:00	0.4	12.4	2,172.8	0.5	1.5	1	1	1
12/01/2019 10:00	0.4	12.4	2,181.5	0.5	1.5	1	1	1
12/01/2019 11:00	0.4	12.5	2,161.9	0.5	1.5	1	1	1
12/01/2019 12:00	0.4	12.8	2,086.9	0.5	1.5	1	1	1
12/01/2019 13:00	0.4	12.7	2,110.4	0.5	1.5	1	1	1
12/01/2019 14:00	0.4	12.7	2,099.5	0.5	1.5	1	1	1
12/01/2019 15:00	0.4	12.7	2,105.9	0.5	1.5	1	1	1
12/01/2019 16:00	0.4	12.6	2,107.8	0.5	1.5	1	1	1
12/01/2019 17:00	0.4	12.4	2,161.9	0.5	1.5	1	1	1
12/01/2019 18:00	0.4	12.1	2,221.6	0.5	1.6	1	1	1
12/01/2019 19:00	0.5	12.0	2,253.5	0.5	1.6	1	1	1
12/01/2019 20:00	0.5	12.2	2,209.1	0.5	1.5	1	1	1
12/01/2019 21:00	0.5	12.5	2,133.9	0.5	1.5	1	1	1
12/01/2019 22:00	0.4	12.6	2,102.8	0.5	1.5	1	1	1
12/01/2019 23:00	0.4	12.7	2,095.2	0.5	1.5	1	1	1
Average/Sum#:	0.4	12.6	2,130.1	0.5	1.5	24 #	24 #	24 #
Minimum:	0.4	12.0	2,075.5	0.5	1.5	1	1	1
Maximum:	0.5	12.9	2,253.5	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/02/2019 00:00	0.4	12.7	2,078.7	0.5	1.5	1	1	1
12/02/2019 01:00	0.4	12.7	2,082.6	0.5	1.5	1	1	1
12/02/2019 02:00	0.4	12.7	2,081.3	0.5	1.5	1	1	1
12/02/2019 03:00	0.4	12.7	2,075.0	0.5	1.5	1	1	1
12/02/2019 04:00	0.4	12.8	2,069.7	0.5	1.4	1	1	1
12/02/2019 05:00	0.4	12.7	2,075.5	0.5	1.5	1	1	1
12/02/2019 06:00	0.4	12.2	2,196.2	0.5	1.5	1	1	1
12/02/2019 07:00	0.5	11.9	2,256.7	0.5	1.6	1	1	1
12/02/2019 08:00	0.5	12.5	2,120.8	0.5	1.5	1	1	1
12/02/2019 09:00	0.5	12.7	2,077.0	0.5	1.5	1	1	1
12/02/2019 10:00	0.4	12.6	2,099.2	0.5	1.5	1	1	1
12/02/2019 11:00	0.4	12.6	2,092.7	0.5	1.5	1	1	1
12/02/2019 12:00	0.5	12.3	2,162.8	0.5	1.5	1	1	1
12/02/2019 13:00	0.5	12.5	2,118.4	0.5	1.5	1	1	1
12/02/2019 14:00	0.5	12.2	2,174.2	0.5	1.5	1	1	1
12/02/2019 15:00	0.5	12.3	2,156.8	0.5	1.5	1	1	1
12/02/2019 16:00	0.5	12.0	2,213.4	0.5	1.5	1	1	1
12/02/2019 17:00	0.5	11.8	2,268.7	0.5	1.6	1	1	1
12/02/2019 18:00	0.7	11.8	2,278.2	0.7	1.6	1	1	1
12/02/2019 19:00	0.7	11.8	2,279.3	0.7	1.6	1	1	1
12/02/2019 20:00	0.7	11.8	2,275.2	0.7	1.6	1	1	1
12/02/2019 21:00	0.7	11.9	2,248.6	0.7	1.6	1	1	1
12/02/2019 22:00	0.5	12.3	2,148.0	0.5	1.5	1	1	1
12/02/2019 23:00	0.5	12.4	2,129.3	0.5	1.5	1	1	1
Average/Sum#:	0.5	12.3	2,156.6	0.5	1.5	24 #	24 #	24 #
Minimum:	0.4	11.8	2,069.7	0.5	1.4	1	1	1
Maximum:	0.7	12.8	2,279.3	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/03/2019 00:00	0.5	12.4	2,136.3	0.5	1.5	1	1	1
12/03/2019 01:00	0.5	12.6	2,082.1	0.5	1.5	1	1	1
12/03/2019 02:00	0.5	12.6	2,078.1	0.5	1.5	1	1	1
12/03/2019 03:00	0.5	12.6	2,086.0	0.5	1.5	1	1	1
12/03/2019 04:00	0.5	12.5	2,112.1	0.5	1.5	1	1	1
12/03/2019 05:00	0.5	12.3	2,121.5	0.5	1.5	1	1	1
12/03/2019 06:00	0.5	12.3	2,153.5	0.5	1.5	1	1	1
12/03/2019 07:00	0.7	12.0	2,204.2	0.7	1.5	1	1	1
12/03/2019 08:00	0.7	12.1	2,192.7	0.7	1.5	1	1	1
12/03/2019 09:00	0.5	12.2	2,162.7	0.5	1.5	1	1	1
12/03/2019 10:00	0.5	12.4	2,107.2	0.5	1.5	1	1	1
12/03/2019 11:00	0.7	12.0	2,184.4	0.7	1.5	1	1	1
12/03/2019 12:00	0.7	11.8	2,215.8	0.7	1.6	1	1	1
12/03/2019 13:00	0.7	11.8	2,208.4	0.7	1.5	1	1	1
12/03/2019 14:00	0.7	11.8	2,205.5	0.7	1.5	1	1	1
12/03/2019 15:00	0.7	11.9	2,199.8	0.7	1.5	1	1	1
12/03/2019 16:00	0.7	11.9	2,191.5	0.7	1.5	1	1	1
12/03/2019 17:00	0.5	11.7	2,253.4	0.5	1.6	1	1	1
12/03/2019 18:00	0.5	11.7	2,252.8	0.5	1.6	1	1	1
12/03/2019 19:00	0.5	11.8	2,237.0	0.5	1.6	1	1	1
12/03/2019 20:00	0.5	11.8	2,228.0	0.5	1.6	1	1	1
12/03/2019 21:00	0.5	11.9	2,219.8	0.5	1.6	1	1	1
12/03/2019 22:00	0.5	12.2	2,159.4	0.5	1.5	1	1	1
12/03/2019 23:00	0.5	12.3	2,136.5	0.5	1.5	1	1	1
Average/Sum#:	0.6	12.1	2,172.0	0.6	1.5	24 #	24 #	24 #
Minimum:	0.5	11.7	2,078.1	0.5	1.5	1	1	1
Maximum:	0.7	12.6	2,253.4	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/04/2019 00:00	0.5	12.1	2,184.8	0.5	1.5	1	1	1
12/04/2019 01:00	0.5	12.2	2,158.5	0.5	1.5	1	1	1
12/04/2019 02:00	0.5	12.5	2,102.9	0.5	1.5	1	1	1
12/04/2019 03:00	0.5	12.5	2,114.0	0.5	1.5	1	1	1
12/04/2019 04:00	0.5	12.2	2,154.6	0.5	1.5	1	1	1
12/04/2019 05:00	0.4	12.5	2,097.2	0.5	1.5	1	1	1
12/04/2019 06:00	0.4	12.3	2,152.1	0.5	1.5	1	1	1
12/04/2019 07:00	0.5	12.0	2,205.0	0.5	1.5	1	1	1
12/04/2019 08:00	0.5	12.1	2,197.1	0.5	1.5	1	1	1
12/04/2019 09:00	0.5	12.1	2,201.4	0.5	1.5	1	1	1
12/04/2019 10:00	0.5	12.1	2,184.8	0.5	1.5	1	1	1
12/04/2019 11:00	0.5	11.9	2,229.9	0.5	1.6	1	1	1
12/04/2019 12:00	0.5	12.1	2,194.3	0.5	1.5	1	1	1
12/04/2019 13:00	0.5	12.2	2,165.2	0.5	1.5	1	1	1
12/04/2019 14:00	0.5	11.8	2,236.0	0.5	1.6	1	1	1
12/04/2019 15:00	0.5	12.0	2,197.1	0.5	1.5	1	1	1
12/04/2019 16:00	0.5	12.0	2,197.1	0.5	1.5	1	1	1
12/04/2019 17:00	0.5	12.1	2,172.7	0.5	1.5	1	1	1
12/04/2019 18:00	0.5	11.8	2,240.9	0.5	1.6	1	1	1
12/04/2019 19:00	0.5	11.8	2,242.8	0.5	1.6	1	1	1
12/04/2019 20:00	0.7	11.8	2,246.9	0.7	1.6	1	1	1
12/04/2019 21:00	0.7	11.9	2,228.4	0.7	1.6	1	1	1
12/04/2019 22:00	0.5	12.1	2,194.5	0.5	1.5	1	1	1
12/04/2019 23:00	0.5	12.3	2,147.9	0.5	1.5	1	1	1
Average/Sum#:	0.5	12.1	2,185.3	0.5	1.5	24 #	24 #	24 #
Minimum:	0.4	11.8	2,097.2	0.5	1.5	1	1	1
Maximum:	0.7	12.5	2,246.9	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/05/2019 00:00	0.5	12.2	2,160.5	0.5	1.5	1	1	1
12/05/2019 01:00	0.5	12.2	2,166.9	0.5	1.5	1	1	1
12/05/2019 02:00	0.5	12.2	2,164.3	0.5	1.5	1	1	1
12/05/2019 03:00	0.5	12.2	2,165.9	0.5	1.5	1	1	1
12/05/2019 04:00	0.5	12.4	2,132.0	0.5	1.5	1	1	1
12/05/2019 05:00	0.4	12.4	2,119.2	0.5	1.5	1	1	1
12/05/2019 06:00	0.5	12.2	2,163.7	0.5	1.5	1	1	1
12/05/2019 07:00	0.5	12.4	2,122.3	0.5	1.5	1	1	1
12/05/2019 08:00	0.5	12.7	2,069.4	0.5	1.4	1	1	1
12/05/2019 09:00	0.5	12.6	2,084.4	0.5	1.5	1	1	1
12/05/2019 10:00	0.5	12.6	2,035.3	0.5	1.4	1	1	1
12/05/2019 11:00	0.5	12.6	2,041.6	0.5	1.4	1	1	1
12/05/2019 12:00	0.5	12.5	2,049.9	0.5	1.4	1	1	1
12/05/2019 13:00	0.5	12.5	2,049.7	0.5	1.4	1	1	1
12/05/2019 14:00	0.5	12.5	2,037.5	0.5	1.4	1	1	1
12/05/2019 15:00	0.5	12.5	2,046.8	0.5	1.4	1	1	1
12/05/2019 16:00	0.5	12.1	2,140.6	0.5	1.5	1	1	1
12/05/2019 17:00	0.7	11.8	2,195.4	0.7	1.5	1	1	1
12/05/2019 18:00	0.7	11.8	2,198.0	0.7	1.5	1	1	1
12/05/2019 19:00	0.7	11.7	2,206.3	0.7	1.5	1	1	1
12/05/2019 20:00	0.7	11.8	2,203.5	0.7	1.5	1	1	1
12/05/2019 21:00	0.7	11.7	2,206.0	0.7	1.5	1	1	1
12/05/2019 22:00	0.7	12.0	2,149.6	0.7	1.5	1	1	1
12/05/2019 23:00	0.5	12.1	2,129.0	0.5	1.5	1	1	1
Average/Sum#:	0.5	12.2	2,126.6	0.6	1.5	24 #	24 #	24 #
Minimum:	0.4	11.7	2,035.3	0.5	1.4	1	1	1
Maximum:	0.7	12.7	2,206.3	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/06/2019 00:00	0.5	12.4	2,065.7	0.5	1.4	1	1	1
12/06/2019 01:00	0.5	12.4	2,061.4	0.5	1.4	1	1	1
12/06/2019 02:00	0.5	12.4	2,067.5	0.5	1.4	1	1	1
12/06/2019 03:00	0.5	12.4	2,064.0	0.5	1.4	1	1	1
12/06/2019 04:00	0.5	12.5	2,041.1	0.5	1.4	1	1	1
12/06/2019 05:00	0.4	12.5	2,034.6	0.5	1.4	1	1	1
12/06/2019 06:00	0.4	12.4	2,068.3	0.5	1.4	1	1	1
12/06/2019 07:00	0.5	12.4	2,062.6	0.5	1.4	1	1	1
12/06/2019 08:00	0.5	12.5	2,049.6	0.5	1.4	1	1	1
12/06/2019 09:00	0.4	12.6	2,023.8	0.5	1.4	1	1	1
12/06/2019 10:00	0.4	12.5	2,044.0	0.5	1.4	1	1	1
12/06/2019 11:00	0.5	12.3	2,071.0	0.5	1.4	1	1	1
12/06/2019 12:00	0.5	12.1	2,105.6	0.5	1.5	1	1	1
12/06/2019 13:00	0.5	12.0	2,114.7	0.5	1.5	1	1	1
12/06/2019 14:00	0.5	12.1	2,110.9	0.5	1.5	1	1	1
12/06/2019 15:00	0.5	12.1	2,113.4	0.5	1.5	1	1	1
12/06/2019 16:00	0.5	12.0	2,138.4	0.5	1.5	1	1	1
12/06/2019 17:00	0.5	12.0	2,126.5	0.5	1.5	1	1	1
12/06/2019 18:00	0.5	11.8	2,171.2	0.5	1.5	1	1	1
12/06/2019 19:00	0.5	11.8	2,163.3	0.5	1.5	1	1	1
12/06/2019 20:00	0.5	12.0	2,142.1	0.5	1.5	1	1	1
12/06/2019 21:00	0.5	11.8	2,187.6	0.5	1.5	1	1	1
12/06/2019 22:00	0.5	11.8	2,187.8	0.5	1.5	1	1	1
12/06/2019 23:00	0.7	11.7	2,191.1	0.7	1.5	1	1	1
Average/Sum#:	0.5	12.2	2,100.3	0.5	1.5	24 #	24 #	24 #
Minimum:	0.4	11.7	2,023.8	0.5	1.4	1	1	1
Maximum:	0.7	12.6	2,191.1	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/07/2019 00:00	0.5	11.8	2,181.2	0.5	1.5	1	1	1
12/07/2019 01:00	0.5	12.3	2,068.1	0.5	1.4	1	1	1
12/07/2019 02:00	0.4	12.5	2,037.2	0.5	1.4	1	1	1
12/07/2019 03:00	0.4	12.5	2,041.6	0.5	1.4	1	1	1
12/07/2019 04:00	0.4	12.5	2,044.2	0.5	1.4	1	1	1
12/07/2019 05:00	0.4	12.4	2,038.5	0.5	1.4	1	1	1
12/07/2019 06:00	0.4	12.4	2,038.7	0.5	1.4	1	1	1
12/07/2019 07:00	0.5	12.3	2,073.5	0.5	1.5	1	1	1
12/07/2019 08:00	0.5	12.2	2,085.4	0.5	1.5	1	1	1
12/07/2019 09:00	0.5	12.2	2,071.6	0.5	1.5	1	1	1
12/07/2019 10:00	0.5	12.3	2,053.3	0.5	1.4	1	1	1
12/07/2019 11:00	0.5	12.2	2,063.3	0.5	1.4	1	1	1
12/07/2019 12:00	0.5	12.2	2,065.0	0.5	1.4	1	1	1
12/07/2019 13:00	0.5	12.3	2,059.5	0.5	1.4	1	1	1
12/07/2019 14:00	0.5	12.3	2,058.0	0.5	1.4	1	1	1
12/07/2019 15:00	0.5	12.4	2,041.5	0.5	1.4	1	1	1
12/07/2019 16:00	0.5	12.4	2,052.6	0.5	1.4	1	1	1
12/07/2019 17:00	0.5	12.4	2,051.1	0.5	1.4	1	1	1
12/07/2019 18:00	0.5	12.1	2,107.4	0.5	1.5	1	1	1
12/07/2019 19:00	0.5	12.2	2,084.4	0.5	1.5	1	1	1
12/07/2019 20:00	0.5	12.2	2,095.9	0.5	1.5	1	1	1
12/07/2019 21:00	0.5	12.2	2,092.9	0.5	1.5	1	1	1
12/07/2019 22:00	0.5	12.3	2,068.3	0.5	1.4	1	1	1
12/07/2019 23:00	0.5	12.3	2,065.9	0.5	1.4	1	1	1
Average/Sum#:	0.5	12.3	2,068.3	0.5	1.4	24 #	24 #	24 #
Minimum:	0.4	11.8	2,037.2	0.5	1.4	1	1	1
Maximum:	0.5	12.5	2,181.2	0.5	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/08/2019 00:00	0.5	12.3	2,081.2	0.5	1.5	1	1	1
12/08/2019 01:00	0.5	12.9	1,930.7	0.5	1.4	1	1	1
12/08/2019 02:00	0.6	13.9	1,595.4	0.6	1.1	1	1	0
12/08/2019 03:00	0.6	13.9	1,458.5	0.6	1.0	1	1	0
12/08/2019 04:00	0.6	13.9	1,596.1	0.6	1.1	1	1	0
12/08/2019 05:00	0.6	13.9	1,666.5	0.6	1.2	1	1	0
12/08/2019 06:00	0.6	13.9	1,677.6	0.6	1.2	1	1	0
12/08/2019 07:00	0.6	13.9	1,657.6	0.6	1.2	1	1	0
12/08/2019 08:00	0.6	13.9	1,637.2	0.6	1.1	1	1	0
12/08/2019 09:00	0.6	13.9	1,642.1	0.6	1.1	1	1	0
12/08/2019 10:00	0.6	13.9	1,495.8	0.6	1.0	1	1	0
12/08/2019 11:00	0.6	13.9	1,581.9	0.6	1.1	1	1	0
12/08/2019 12:00	0.6	13.9	1,503.5	0.6	1.1	1	1	0
12/08/2019 13:00	0.6	13.9	1,646.3	0.6	1.2	1	1	0
12/08/2019 14:00	0.7	13.7	1,658.3	0.7	1.2	1	1	1
12/08/2019 15:00	0.2	13.1	1,877.2	0.4	1.3	1	1	1
12/08/2019 16:00	0.1	12.5	2,043.8	0.2	1.4	1	1	1
12/08/2019 17:00	0.4	12.5	2,031.1	0.5	1.4	1	1	1
12/08/2019 18:00	0.4	12.4	2,080.7	0.5	1.5	1	1	1
12/08/2019 19:00	0.4	12.3	2,096.9	0.5	1.5	1	1	1
12/08/2019 20:00	0.5	12.3	2,102.2	0.5	1.5	1	1	1
12/08/2019 21:00	0.5	12.5	2,056.3	0.5	1.4	1	1	1
12/08/2019 22:00	0.5	12.3	2,097.5	0.5	1.5	1	1	1
12/08/2019 23:00	0.5	12.2	2,112.4	0.5	1.5	1	1	1
Average/Sum#:	0.5	13.2	1,805.3	0.5	1.3	24 #	24 #	12 #
Minimum:	0.1	12.2	1,458.5	0.2	1.0	1	1	0
Maximum:	0.7	13.9	2,112.4	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/09/2019 00:00	0.5	12.4	2,082.3	0.5	1.5	1	1	1
12/09/2019 01:00	0.5	12.6	2,036.6	0.5	1.4	1	1	1
12/09/2019 02:00	0.5	12.7	2,016.3	0.5	1.4	1	1	1
12/09/2019 03:00	0.4	12.7	2,022.7	0.5	1.4	1	1	1
12/09/2019 04:00	0.5	12.5	2,071.9	0.5	1.5	1	1	1
12/09/2019 05:00	0.4	12.5	2,062.7	0.5	1.4	1	1	1
12/09/2019 06:00	0.4	12.5	2,067.6	0.5	1.4	1	1	1
12/09/2019 07:00	0.4	12.4	2,105.5	0.5	1.5	1	1	1
12/09/2019 08:00	0.4	12.4	2,097.8	0.5	1.5	1	1	1
12/09/2019 09:00	0.5	12.4	2,088.6	0.5	1.5	1	1	1
12/09/2019 10:00	0.5	12.6	2,035.9	0.5	1.4	1	1	1
12/09/2019 11:00	0.5	12.7	2,031.3	0.5	1.4	1	1	1
12/09/2019 12:00	0.5	12.6	2,026.3	0.5	1.4	1	1	1
12/09/2019 13:00	0.5	12.6	2,035.0	0.5	1.4	1	1	1
12/09/2019 14:00	0.5	12.6	2,015.9	0.5	1.4	1	1	1
12/09/2019 15:00	0.5	12.5	2,056.8	0.5	1.4	1	1	1
12/09/2019 16:00	0.5	12.5	2,047.2	0.5	1.4	1	1	1
12/09/2019 17:00	0.5	12.3	2,102.2	0.5	1.5	1	1	1
12/09/2019 18:00	0.5	12.0	2,168.2	0.5	1.5	1	1	1
12/09/2019 19:00	0.5	11.9	2,185.6	0.5	1.5	1	1	1
12/09/2019 20:00	0.5	12.0	2,184.6	0.5	1.5	1	1	1
12/09/2019 21:00	0.5	12.3	2,113.8	0.5	1.5	1	1	1
12/09/2019 22:00	0.5	12.3	2,106.2	0.5	1.5	1	1	1
12/09/2019 23:00	0.4	12.5	2,098.8	0.5	1.5	1	1	1
Average/Sum#:	0.5	12.4	2,077.5	0.5	1.5	24 #	24 #	24 #
Minimum:	0.4	11.9	2,015.9	0.5	1.4	1	1	1
Maximum:	0.5	12.7	2,185.6	0.5	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/10/2019 00:00	0.4	12.4	2,130.1	0.5	1.5	1	1	1
12/10/2019 01:00	0.4	12.4	2,122.5	0.5	1.5	1	1	1
12/10/2019 02:00	0.4	12.4	2,113.9	0.5	1.5	1	1	1
12/10/2019 03:00	0.4	12.4	2,126.8	0.5	1.5	1	1	1
12/10/2019 04:00	0.4	12.4	2,134.7	0.5	1.5	1	1	1
12/10/2019 05:00	0.4	12.4	2,118.1	0.5	1.5	1	1	1
12/10/2019 06:00	0.4	12.4	2,128.6	0.5	1.5	1	1	1
12/10/2019 07:00	0.4	12.3	2,151.0	0.5	1.5	1	1	1
12/10/2019 08:00	0.4	12.6	2,087.7	0.5	1.5	1	1	1
12/10/2019 09:00	0.4	12.4	2,119.3	0.5	1.5	1	1	1
12/10/2019 10:00	0.5	12.7	2,060.8	0.5	1.4	1	1	1
12/10/2019 11:00	0.4	12.7	2,050.2	0.5	1.4	1	1	1
12/10/2019 12:00	0.4	12.6	2,067.5	0.5	1.4	1	1	1
12/10/2019 13:00	0.4	12.6	2,064.1	0.5	1.4	1	1	1
12/10/2019 14:00	0.4	12.6	2,069.4	0.5	1.4	1	1	1
12/10/2019 15:00	0.4	12.6	2,053.7	0.5	1.4	1	1	1
12/10/2019 16:00	0.4	12.5	2,072.3	0.5	1.5	1	1	1
12/10/2019 17:00	0.5	12.2	2,149.5	0.5	1.5	1	1	1
12/10/2019 18:00	0.5	12.0	2,172.8	0.5	1.5	1	1	1
12/10/2019 19:00	0.5	12.0	2,182.4	0.5	1.5	1	1	1
12/10/2019 20:00	0.5	12.0	2,182.1	0.5	1.5	1	1	1
12/10/2019 21:00	0.5	12.2	2,136.5	0.5	1.5	1	1	1
12/10/2019 22:00	0.4	12.5	2,090.3	0.5	1.5	1	1	1
12/10/2019 23:00	0.4	12.5	2,080.4	0.5	1.5	1	1	1
Average/Sum#:	0.4	12.4	2,111.0	0.5	1.5	24 #	24 #	24 #
Minimum:	0.4	12.0	2,050.2	0.5	1.4	1	1	1
Maximum:	0.5	12.7	2,182.4	0.5	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/11/2019 00:00	0.5	12.3	2,113.6	0.5	1.5	1	1	1
12/11/2019 01:00	0.5	12.3	2,111.9	0.5	1.5	1	1	1
12/11/2019 02:00	0.4	12.5	2,080.4	0.5	1.5	1	1	1
12/11/2019 03:00	0.4	12.7	2,027.6	0.5	1.4	1	1	1
12/11/2019 04:00	0.4	12.6	2,053.1	0.5	1.4	1	1	1
12/11/2019 05:00	0.4	12.4	2,078.8	0.5	1.5	1	1	1
12/11/2019 06:00	0.4	12.3	2,119.9	0.5	1.5	1	1	1
12/11/2019 07:00	0.4	12.4	2,110.8	0.5	1.5	1	1	1
12/11/2019 08:00	0.5	12.5	2,075.9	0.5	1.5	1	1	1
12/11/2019 09:00	0.4	12.7	2,043.6	0.5	1.4	1	1	1
12/11/2019 10:00	0.4	12.6	2,057.8	0.5	1.4	1	1	1
12/11/2019 11:00	0.4	12.7	2,037.4	0.5	1.4	1	1	1
12/11/2019 12:00	0.4	12.7	2,039.8	0.5	1.4	1	1	1
12/11/2019 13:00	0.4	12.7	2,037.9	0.5	1.4	1	1	1
12/11/2019 14:00	0.4	12.5	2,069.3	0.5	1.4	1	1	1
12/11/2019 15:00	0.4	12.7	2,031.3	0.5	1.4	1	1	1
12/11/2019 16:00	0.4	12.6	2,049.9	0.5	1.4	1	1	1
12/11/2019 17:00	0.5	12.3	2,111.8	0.5	1.5	1	1	1
12/11/2019 18:00	0.4	12.4	2,084.0	0.5	1.5	1	1	1
12/11/2019 19:00	0.5	12.1	2,150.6	0.5	1.5	1	1	1
12/11/2019 20:00	0.5	12.4	2,090.0	0.5	1.5	1	1	1
12/11/2019 21:00	0.4	12.5	2,056.9	0.5	1.4	1	1	1
12/11/2019 22:00	0.4	12.6	2,043.4	0.5	1.4	1	1	1
12/11/2019 23:00	0.4	12.6	2,048.1	0.5	1.4	1	1	1
Average/Sum#:	0.4	12.5	2,071.8	0.5	1.4	24 #	24 #	24 #
Minimum:	0.4	12.1	2,027.6	0.5	1.4	1	1	1
Maximum:	0.5	12.7	2,150.6	0.5	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/12/2019 00:00	0.4	12.6	2,042.6	0.5	1.4	1	1	1
12/12/2019 01:00	0.4	12.6	2,032.2	0.5	1.4	1	1	1
12/12/2019 02:00	0.4	12.6	2,039.7	0.5	1.4	1	1	1
12/12/2019 03:00	0.4	12.6	2,039.7	0.5	1.4	1	1	1
12/12/2019 04:00	0.4	12.6	2,039.2	0.5	1.4	1	1	1
12/12/2019 05:00	0.4	12.6	2,041.5	0.5	1.4	1	1	1
12/12/2019 06:00	0.4	12.4	2,101.2	0.5	1.5	1	1	1
12/12/2019 07:00	0.5	12.2	2,127.0	0.5	1.5	1	1	1
12/12/2019 08:00	0.4	12.6	2,047.7	0.5	1.4	1	1	1
12/12/2019 09:00	0.4	12.6	2,041.3	0.5	1.4	1	1	1
12/12/2019 10:00	0.4	12.7	2,019.4	0.5	1.4	1	1	1
12/12/2019 11:00	0.4	12.7	2,015.2	0.5	1.4	1	1	1
12/12/2019 12:00	0.4	12.6	2,029.4	0.5	1.4	1	1	1
12/12/2019 13:00	0.4	12.6	2,034.4	0.5	1.4	1	1	1
12/12/2019 14:00	0.4	12.6	2,041.7	0.5	1.4	1	1	1
12/12/2019 15:00	0.4	12.6	2,040.1	0.5	1.4	1	1	1
12/12/2019 16:00	0.4	12.5	2,045.9	0.5	1.4	1	1	1
12/12/2019 17:00	0.5	12.3	2,102.5	0.5	1.5	1	1	1
12/12/2019 18:00	0.5	12.2	2,105.8	0.5	1.5	1	1	1
12/12/2019 19:00	0.5	12.3	2,097.8	0.5	1.5	1	1	1
12/12/2019 20:00	0.5	12.5	2,056.2	0.5	1.4	1	1	1
12/12/2019 21:00	0.5	12.5	2,061.2	0.5	1.4	1	1	1
12/12/2019 22:00	0.5	12.5	2,054.9	0.5	1.4	1	1	1
12/12/2019 23:00	0.7	13.3	1,815.7	0.7	1.3	1	1	1
Average/Sum#:	0.4	12.6	2,044.7	0.5	1.4	24 #	24 #	24 #
Minimum:	0.4	12.2	1,815.7	0.5	1.3	1	1	1
Maximum:	0.7	13.3	2,127.0	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/13/2019 00:00	0.0	14.3	1,253.4	0.0	0.9	1	0	0
12/13/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/13/2019 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/13/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/13/2019 04:00	0.0	17.4	488.8	0.0	0.3	1	0	0
12/13/2019 05:00	0.0	14.2	1,281.4	0.0	0.9	1	0	0
12/13/2019 06:00	0.6	13.9	1,389.3	0.6	1.0	1	1	0
12/13/2019 07:00	0.6	13.8	1,574.2	0.6	1.1	1	1	0
12/13/2019 08:00	0.6	13.8	1,672.8	0.6	1.2	1	1	0
12/13/2019 09:00	0.6	13.8	1,632.3	0.6	1.1	1	1	0
12/13/2019 10:00	0.6	13.9	1,682.6	0.6	1.2	1	1	0
12/13/2019 11:00	0.6	13.9	1,592.4	0.6	1.1	1	1	0
12/13/2019 12:00	0.6	13.9	1,489.3	0.6	1.0	1	1	0
12/13/2019 13:00	0.6	13.9	1,652.0	0.6	1.2	1	1	0
12/13/2019 14:00	0.7	13.8	1,731.7	0.7	1.2	1	1	1
12/13/2019 15:00	0.1	12.6	2,026.4	0.2	1.4	1	1	1
12/13/2019 16:00	0.1	12.3	2,079.6	0.2	1.5	1	1	1
12/13/2019 17:00	0.2	12.3	2,072.8	0.4	1.5	1	1	1
12/13/2019 18:00	0.2	12.0	2,151.0	0.4	1.5	1	1	1
12/13/2019 19:00	0.2	12.3	2,078.7	0.4	1.5	1	1	1
12/13/2019 20:00	0.2	12.2	2,110.5	0.4	1.5	1	1	1
12/13/2019 21:00	0.2	12.2	2,097.8	0.4	1.5	1	1	1
12/13/2019 22:00	0.2	12.2	2,094.1	0.4	1.5	1	1	1
12/13/2019 23:00	0.2	12.3	2,084.2	0.4	1.5	1	1	1
Average/Sum#:	0.3	13.4	1,725.5	0.4	1.2	21 #	18 #	10 #
Minimum:	0.0	12.0	488.8	0.0	0.3	0	0	0
Maximum:	0.7	17.4	2,151.0	0.7	1.5	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/14/2019 00:00	0.2	12.5	2,066.6	0.4	1.4	1	1	1
12/14/2019 01:00	0.4	12.8	1,966.5	0.5	1.4	1	1	1
12/14/2019 02:00	0.6	13.9	1,598.2	0.6	1.1	1	1	0
12/14/2019 03:00	0.6	13.9	1,553.5	0.6	1.1	1	1	0
12/14/2019 04:00	0.6	13.9	1,690.2	0.6	1.2	1	1	0
12/14/2019 05:00	0.6	13.9	1,624.9	0.6	1.1	1	1	0
12/14/2019 06:00	0.6	13.9	1,557.7	0.6	1.1	1	1	0
12/14/2019 07:00	0.6	13.9	1,482.7	0.6	1.0	1	1	0
12/14/2019 08:00	0.6	13.9	1,479.0	0.6	1.0	1	1	0
12/14/2019 09:00	0.6	13.9	1,637.4	0.6	1.1	1	1	0
12/14/2019 10:00	0.6	13.9	1,573.1	0.6	1.1	1	1	0
12/14/2019 11:00	0.6	13.9	1,601.7	0.6	1.1	1	1	0
12/14/2019 12:00	0.6	13.9	1,379.0	0.6	1.0	1	1	0
12/14/2019 13:00	0.6	13.9	1,645.5	0.6	1.2	1	1	0
12/14/2019 14:00	0.6	13.9	1,597.2	0.6	1.1	1	1	0
12/14/2019 15:00	0.7	13.8	1,604.1	0.7	1.1	1	1	1
12/14/2019 16:00	0.1	12.7	2,011.1	0.2	1.4	1	1	1
12/14/2019 17:00	0.1	12.3	2,091.2	0.2	1.5	1	1	1
12/14/2019 18:00	0.1	12.3	2,097.9	0.2	1.5	1	1	1
12/14/2019 19:00	0.2	12.5	2,063.6	0.4	1.4	1	1	1
12/14/2019 20:00	0.2	12.2	2,130.0	0.4	1.5	1	1	1
12/14/2019 21:00	0.2	12.3	2,129.7	0.4	1.5	1	1	1
12/14/2019 22:00	0.2	12.5	2,068.3	0.4	1.4	1	1	1
12/14/2019 23:00	0.2	13.1	1,936.1	0.4	1.4	1	1	1
Average/Sum#:	0.4	13.3	1,774.4	0.5	1.2	24 #	24 #	11 #
Minimum:	0.1	12.2	1,379.0	0.2	1.0	1	1	0
Maximum:	0.7	13.9	2,130.0	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/15/2019 00:00	0.2	12.7	2,039.2	0.4	1.4	1	1	1
12/15/2019 01:00	0.2	12.8	2,026.0	0.4	1.4	1	1	1
12/15/2019 02:00	0.2	12.5	2,080.0	0.4	1.5	1	1	1
12/15/2019 03:00	0.1	12.4	2,104.8	0.2	1.5	1	1	1
12/15/2019 04:00	0.1	12.4	2,114.0	0.2	1.5	1	1	1
12/15/2019 05:00	0.1	12.6	2,069.8	0.2	1.4	1	1	1
12/15/2019 06:00	0.2	12.7	2,080.6	0.4	1.5	1	1	1
12/15/2019 07:00	0.2	13.1	1,950.0	0.4	1.4	1	1	1
12/15/2019 08:00	0.6	13.9	1,584.7	0.6	1.1	1	1	0
12/15/2019 09:00	0.6	13.9	1,634.3	0.6	1.1	1	1	0
12/15/2019 10:00	0.6	13.9	1,536.0	0.6	1.1	1	1	0
12/15/2019 11:00	0.6	13.9	1,561.6	0.6	1.1	1	1	0
12/15/2019 12:00	0.6	13.9	1,545.2	0.6	1.1	1	1	0
12/15/2019 13:00	0.6	13.9	1,636.2	0.6	1.1	1	1	0
12/15/2019 14:00	0.6	13.9	1,570.8	0.6	1.1	1	1	0
12/15/2019 15:00	0.7	13.9	1,566.1	0.7	1.1	1	1	1
12/15/2019 16:00	0.1	12.9	2,007.0	0.2	1.4	1	1	1
12/15/2019 17:00	0.1	12.6	2,073.0	0.2	1.5	1	1	1
12/15/2019 18:00	0.1	12.1	2,173.9	0.2	1.5	1	1	1
12/15/2019 19:00	0.2	11.9	2,217.2	0.4	1.6	1	1	1
12/15/2019 20:00	0.2	11.9	2,209.8	0.4	1.5	1	1	1
12/15/2019 21:00	0.2	12.0	2,203.1	0.4	1.5	1	1	1
12/15/2019 22:00	0.2	12.4	2,119.6	0.4	1.5	1	1	1
12/15/2019 23:00	0.2	12.5	2,090.4	0.4	1.5	1	1	1
Average/Sum#:	0.3	12.9	1,924.7	0.4	1.4	24 #	24 #	17 #
Minimum:	0.1	11.9	1,536.0	0.2	1.1	1	1	0
Maximum:	0.7	13.9	2,217.2	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/16/2019 00:00	0.2	12.4	2,135.2	0.4	1.5	1	1	1
12/16/2019 01:00	0.2	12.4	2,136.2	0.4	1.5	1	1	1
12/16/2019 02:00	0.2	12.5	2,127.9	0.4	1.5	1	1	1
12/16/2019 03:00	0.2	12.4	2,144.8	0.4	1.5	1	1	1
12/16/2019 04:00	0.2	12.4	2,139.4	0.4	1.5	1	1	1
12/16/2019 05:00	0.1	12.4	2,115.9	0.2	1.5	1	1	1
12/16/2019 06:00	0.2	12.0	2,240.1	0.4	1.6	1	1	1
12/16/2019 07:00	0.2	12.2	2,185.3	0.4	1.5	1	1	1
12/16/2019 08:00	0.4	12.9	2,026.4	0.5	1.4	1	1	1
12/16/2019 09:00	0.4	12.9	2,023.1	0.5	1.4	1	1	1
12/16/2019 10:00	0.2	12.8	2,046.1	0.4	1.4	1	1	1
12/16/2019 11:00	0.4	12.8	2,036.8	0.5	1.4	1	1	1
12/16/2019 12:00	0.4	12.7	2,037.0	0.5	1.4	1	1	1
12/16/2019 13:00	0.4	12.7	2,041.3	0.5	1.4	1	1	1
12/16/2019 14:00	0.2	12.6	2,051.4	0.4	1.4	1	1	1
12/16/2019 15:00	0.2	12.5	2,073.5	0.4	1.5	1	1	1
12/16/2019 16:00	0.2	12.4	2,101.0	0.4	1.5	1	1	1
12/16/2019 17:00	0.2	12.1	2,175.8	0.4	1.5	1	1	1
12/16/2019 18:00	0.2	12.0	2,196.3	0.4	1.5	1	1	1
12/16/2019 19:00	0.2	11.9	2,220.4	0.4	1.6	1	1	1
12/16/2019 20:00	0.2	12.0	2,221.2	0.4	1.6	1	1	1
12/16/2019 21:00	0.2	12.0	2,214.3	0.4	1.6	1	1	1
12/16/2019 22:00	0.2	12.3	2,168.0	0.4	1.5	1	1	1
12/16/2019 23:00	0.2	12.6	2,105.4	0.4	1.5	1	1	1
Average/Sum#:	0.2	12.4	2,123.5	0.4	1.5	24 #	24 #	24 #
Minimum:	0.1	11.9	2,023.1	0.2	1.4	1	1	1
Maximum:	0.4	12.9	2,240.1	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/17/2019 00:00	0.2	12.5	2,120.4	0.4	1.5	1	1	1
12/17/2019 01:00	0.2	12.5	2,138.6	0.4	1.5	1	1	1
12/17/2019 02:00	0.2	12.5	2,135.3	0.4	1.5	1	1	1
12/17/2019 03:00	0.2	12.5	2,138.8	0.4	1.5	1	1	1
12/17/2019 04:00	0.2	12.7	2,109.4	0.4	1.5	1	1	1
12/17/2019 05:00	0.1	12.6	2,093.4	0.2	1.5	1	1	1
12/17/2019 06:00	0.1	12.4	2,170.6	0.2	1.5	1	1	1
12/17/2019 07:00	0.1	12.4	2,159.3	0.2	1.5	1	1	1
12/17/2019 08:00	0.2	12.6	2,109.3	0.4	1.5	1	1	1
12/17/2019 09:00	0.4	12.8	2,050.0	0.5	1.4	1	1	1
12/17/2019 10:00	0.4	12.9	2,031.3	0.5	1.4	1	1	1
12/17/2019 11:00	0.2	12.8	2,033.8	0.4	1.4	1	1	1
12/17/2019 12:00	0.2	12.8	2,043.2	0.4	1.4	1	1	1
12/17/2019 13:00	0.2	12.7	2,055.8	0.4	1.4	1	1	1
12/17/2019 14:00	0.2	12.5	2,085.7	0.4	1.5	1	1	1
12/17/2019 15:00	0.2	12.4	2,108.8	0.4	1.5	1	1	1
12/17/2019 16:00	0.2	12.2	2,149.3	0.4	1.5	1	1	1
12/17/2019 17:00	0.2	12.0	2,201.8	0.4	1.5	1	1	1
12/17/2019 18:00	0.2	11.8	2,256.6	0.4	1.6	1	1	1
12/17/2019 19:00	0.2	11.7	2,259.4	0.4	1.6	1	1	1
12/17/2019 20:00	0.2	11.9	2,229.3	0.4	1.6	1	1	1
12/17/2019 21:00	0.2	12.0	2,200.9	0.4	1.5	1	1	1
12/17/2019 22:00	0.2	12.0	2,195.1	0.4	1.5	1	1	1
12/17/2019 23:00	0.2	12.5	2,103.1	0.4	1.5	1	1	1
Average/Sum#:	0.2	12.4	2,132.5	0.4	1.5	24 #	24 #	24 #
Minimum:	0.1	11.7	2,031.3	0.2	1.4	1	1	1
Maximum:	0.4	12.9	2,259.4	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/18/2019 00:00	0.2	12.6	2,089.0	0.4	1.5	1	1	1
12/18/2019 01:00	0.2	12.4	2,115.3	0.4	1.5	1	1	1
12/18/2019 02:00	0.2	12.4	2,114.3	0.4	1.5	1	1	1
12/18/2019 03:00	0.2	12.4	2,122.6	0.4	1.5	1	1	1
12/18/2019 04:00	0.2	12.3	2,129.6	0.4	1.5	1	1	1
12/18/2019 05:00	0.1	12.0	2,172.0	0.2	1.5	1	1	1
12/18/2019 06:00	0.1	11.9	2,235.6	0.2	1.6	1	1	1
12/18/2019 07:00	0.2	12.1	2,195.4	0.4	1.5	1	1	1
12/18/2019 08:00	0.2	12.4	2,141.4	0.4	1.5	1	1	1
12/18/2019 09:00	0.2	12.4	2,125.4	0.4	1.5	1	1	1
12/18/2019 10:00	0.2	12.5	2,117.8	0.4	1.5	1	1	1
12/18/2019 11:00	0.2	12.4	2,135.0	0.4	1.5	1	1	1
12/18/2019 12:00	0.2	12.5	2,110.5	0.4	1.5	1	1	1
12/18/2019 13:00	0.2	12.5	2,109.7	0.4	1.5	1	1	1
12/18/2019 14:00	0.2	12.5	2,098.3	0.4	1.5	1	1	1
12/18/2019 15:00	0.2	12.7	2,072.9	0.4	1.5	1	1	1
12/18/2019 16:00	0.1	12.4	2,130.6	0.2	1.5	1	1	1
12/18/2019 17:00	0.2	12.1	2,193.1	0.4	1.5	1	1	1
12/18/2019 18:00	0.2	12.0	2,207.0	0.4	1.5	1	1	1
12/18/2019 19:00	0.2	12.1	2,204.7	0.4	1.5	1	1	1
12/18/2019 20:00	0.2	12.1	2,199.0	0.4	1.5	1	1	1
12/18/2019 21:00	0.2	12.0	2,202.2	0.4	1.5	1	1	1
12/18/2019 22:00	0.2	12.1	2,194.6	0.4	1.5	1	1	1
12/18/2019 23:00	0.2	12.5	2,101.3	0.4	1.5	1	1	1
Average/Sum#:	0.2	12.3	2,146.6	0.4	1.5	24 #	24 #	24 #
Minimum:	0.1	11.9	2,072.9	0.2	1.5	1	1	1
Maximum:	0.2	12.7	2,235.6	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/19/2019 00:00	0.2	12.4	2,116.4	0.4	1.5	1	1	1
12/19/2019 01:00	0.2	12.4	2,119.2	0.4	1.5	1	1	1
12/19/2019 02:00	0.2	12.4	2,112.3	0.4	1.5	1	1	1
12/19/2019 03:00	0.2	12.5	2,100.6	0.4	1.5	1	1	1
12/19/2019 04:00	0.2	12.4	2,115.1	0.4	1.5	1	1	1
12/19/2019 05:00	0.1	12.3	2,108.2	0.2	1.5	1	1	1
12/19/2019 06:00	0.1	12.0	2,210.4	0.2	1.5	1	1	1
12/19/2019 07:00	0.2	12.1	2,166.6	0.4	1.5	1	1	1
12/19/2019 08:00	0.4	12.7	2,040.7	0.5	1.4	1	1	1
12/19/2019 09:00	0.2	12.6	2,069.9	0.4	1.4	1	1	1
12/19/2019 10:00	0.2	12.8	2,036.9	0.4	1.4	1	1	1
12/19/2019 11:00	0.2	12.8	2,042.3	0.4	1.4	1	1	1
12/19/2019 12:00	0.2	12.7	2,037.8	0.4	1.4	1	1	1
12/19/2019 13:00	0.2	12.7	2,040.2	0.4	1.4	1	1	1
12/19/2019 14:00	0.2	12.7	2,026.1	0.4	1.4	1	1	1
12/19/2019 15:00	0.2	12.5	2,081.3	0.4	1.5	1	1	1
12/19/2019 16:00	0.2	12.4	2,101.2	0.4	1.5	1	1	1
12/19/2019 17:00	0.2	12.1	2,157.6	0.4	1.5	1	1	1
12/19/2019 18:00	0.2	11.9	2,200.2	0.4	1.5	1	1	1
12/19/2019 19:00	0.2	12.1	2,161.4	0.4	1.5	1	1	1
12/19/2019 20:00	0.2	12.1	2,167.1	0.4	1.5	1	1	1
12/19/2019 21:00	0.2	12.1	2,169.9	0.4	1.5	1	1	1
12/19/2019 22:00	0.2	12.4	2,109.8	0.4	1.5	1	1	1
12/19/2019 23:00	0.2	12.5	2,095.3	0.4	1.5	1	1	1
Average/Sum#:	0.2	12.4	2,107.8	0.4	1.5	24 #	24 #	24 #
Minimum:	0.1	11.9	2,026.1	0.2	1.4	1	1	1
Maximum:	0.4	12.8	2,210.4	0.5	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/20/2019 00:00	0.2	12.4	2,115.2	0.4	1.5	1	1	1
12/20/2019 01:00	0.2	12.5	2,098.7	0.4	1.5	1	1	1
12/20/2019 02:00	0.1	12.4	2,103.9	0.2	1.5	1	1	1
12/20/2019 03:00	0.2	12.8	2,040.2	0.4	1.4	1	1	1
12/20/2019 04:00	0.1	12.5	2,088.3	0.2	1.5	1	1	1
12/20/2019 05:00	0.1	12.4	2,097.8	0.2	1.5	1	1	1
12/20/2019 06:00	0.1	12.3	2,128.5	0.2	1.5	1	1	1
12/20/2019 07:00	0.2	12.6	2,070.4	0.4	1.4	1	1	1
12/20/2019 08:00	0.2	12.8	2,026.6	0.4	1.4	1	1	1
12/20/2019 09:00	0.2	12.7	2,046.5	0.4	1.4	1	1	1
12/20/2019 10:00	0.2	13.0	1,944.5	0.4	1.4	1	1	1
12/20/2019 11:00	0.6	13.9	1,641.5	0.6	1.1	1	1	0
12/20/2019 12:00	0.6	13.9	1,590.6	0.6	1.1	1	1	0
12/20/2019 13:00	0.6	13.9	1,650.3	0.6	1.2	1	1	0
12/20/2019 14:00	0.7	13.9	1,564.3	0.7	1.1	1	1	1
12/20/2019 15:00	-0.1	12.6	2,047.0	0.1	1.4	1	1	1
12/20/2019 16:00	0.1	12.4	2,093.1	0.2	1.5	1	1	1
12/20/2019 17:00	0.1	12.1	2,151.4	0.2	1.5	1	1	1
12/20/2019 18:00	0.1	12.0	2,184.9	0.2	1.5	1	1	1
12/20/2019 19:00	0.1	12.2	2,137.8	0.2	1.5	1	1	1
12/20/2019 20:00	0.1	12.3	2,133.7	0.2	1.5	1	1	1
12/20/2019 21:00	0.2	12.3	2,131.5	0.4	1.5	1	1	1
12/20/2019 22:00	0.1	12.2	2,136.7	0.2	1.5	1	1	1
12/20/2019 23:00	0.1	12.3	2,127.4	0.2	1.5	1	1	1
Average/Sum#:	0.2	12.7	2,014.6	0.3	1.4	24 #	24 #	21 #
Minimum:	-0.1	12.0	1,564.3	0.1	1.1	1	1	0
Maximum:	0.7	13.9	2,184.9	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/21/2019 00:00	0.2	12.5	2,087.4	0.4	1.5	1	1	1
12/21/2019 01:00	0.2	12.6	2,066.4	0.4	1.4	1	1	1
12/21/2019 02:00	0.1	12.4	2,103.2	0.2	1.5	1	1	1
12/21/2019 03:00	0.1	12.4	2,105.0	0.2	1.5	1	1	1
12/21/2019 04:00	0.1	12.3	2,113.5	0.2	1.5	1	1	1
12/21/2019 05:00	0.1	12.3	2,121.1	0.2	1.5	1	1	1
12/21/2019 06:00	0.1	12.5	2,091.9	0.2	1.5	1	1	1
12/21/2019 07:00	0.1	12.3	2,129.1	0.2	1.5	1	1	1
12/21/2019 08:00	0.1	12.3	2,117.0	0.2	1.5	1	1	1
12/21/2019 09:00	0.1	12.4	2,105.9	0.2	1.5	1	1	1
12/21/2019 10:00	0.1	12.5	2,077.8	0.2	1.5	1	1	1
12/21/2019 11:00	0.2	12.7	2,037.5	0.4	1.4	1	1	1
12/21/2019 12:00	0.2	12.7	2,036.8	0.4	1.4	1	1	1
12/21/2019 13:00	0.1	12.6	2,045.5	0.2	1.4	1	1	1
12/21/2019 14:00	0.1	12.5	2,070.8	0.2	1.4	1	1	1
12/21/2019 15:00	0.1	12.6	2,060.7	0.2	1.4	1	1	1
12/21/2019 16:00	0.1	12.6	2,045.4	0.2	1.4	1	1	1
12/21/2019 17:00	0.1	12.6	2,049.1	0.2	1.4	1	1	1
12/21/2019 18:00	0.1	12.5	2,060.8	0.2	1.4	1	1	1
12/21/2019 19:00	0.1	12.5	2,071.6	0.2	1.5	1	1	1
12/21/2019 20:00	0.1	12.4	2,090.7	0.2	1.5	1	1	1
12/21/2019 21:00	0.1	12.4	2,080.2	0.2	1.5	1	1	1
12/21/2019 22:00	0.1	12.3	2,113.6	0.2	1.5	1	1	1
12/21/2019 23:00	0.1	12.3	2,112.7	0.2	1.5	1	1	1
Average/Sum#:	0.1	12.5	2,083.1	0.2	1.5	24 #	24 #	24 #
Minimum:	0.1	12.3	2,036.8	0.2	1.4	1	1	1
Maximum:	0.2	12.7	2,129.1	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/22/2019 00:00	0.1	12.4	2,103.5	0.2	1.5	1	1	1
12/22/2019 01:00	0.1	12.5	2,067.8	0.2	1.4	1	1	1
12/22/2019 02:00	0.1	12.2	2,123.5	0.2	1.5	1	1	1
12/22/2019 03:00	0.1	12.2	2,124.1	0.2	1.5	1	1	1
12/22/2019 04:00	0.1	12.3	2,089.4	0.2	1.5	1	1	1
12/22/2019 05:00	-0.1	12.3	2,081.2	0.2	1.5	1	1	1
12/22/2019 06:00	0.1	12.2	2,119.4	0.2	1.5	1	1	1
12/22/2019 07:00	0.1	12.1	2,129.2	0.2	1.5	1	1	1
12/22/2019 08:00	0.1	12.2	2,103.1	0.2	1.5	1	1	1
12/22/2019 09:00	0.1	12.3	2,098.2	0.2	1.5	1	1	1
12/22/2019 10:00	0.1	12.3	2,090.0	0.2	1.5	1	1	1
12/22/2019 11:00	0.1	12.4	2,063.2	0.2	1.4	1	1	1
12/22/2019 12:00	0.4	12.4	2,057.0	0.5	1.4	1	1	1
12/22/2019 13:00	0.4	12.3	2,088.6	0.5	1.5	1	1	1
12/22/2019 14:00	0.4	12.3	2,065.3	0.5	1.4	1	1	1
12/22/2019 15:00	0.4	12.4	2,059.7	0.5	1.4	1	1	1
12/22/2019 16:00	0.4	12.6	2,016.6	0.5	1.4	1	1	1
12/22/2019 17:00	0.4	12.6	2,020.9	0.5	1.4	1	1	1
12/22/2019 18:00	0.4	12.5	2,035.5	0.5	1.4	1	1	1
12/22/2019 19:00	0.4	12.6	2,039.0	0.5	1.4	1	1	1
12/22/2019 20:00	0.4	12.5	2,066.6	0.5	1.4	1	1	1
12/22/2019 21:00	0.4	12.5	2,071.8	0.5	1.5	1	1	1
12/22/2019 22:00	0.4	12.7	2,039.8	0.5	1.4	1	1	1
12/22/2019 23:00	0.4	12.6	2,050.7	0.5	1.4	1	1	1
Average/Sum#:	0.2	12.4	2,075.2	0.4	1.5	24 #	24 #	24 #
Minimum:	-0.1	12.1	2,016.6	0.2	1.4	1	1	1
Maximum:	0.4	12.7	2,129.2	0.5	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/23/2019 00:00	0.4	12.6	2,056.1	0.5	1.4	1	1	1
12/23/2019 01:00	0.4	12.7	2,034.1	0.5	1.4	1	1	1
12/23/2019 02:00	0.4	12.7	2,036.2	0.5	1.4	1	1	1
12/23/2019 03:00	0.4	12.6	2,058.3	0.5	1.4	1	1	1
12/23/2019 04:00	0.4	12.6	2,048.0	0.5	1.4	1	1	1
12/23/2019 05:00	0.4	12.7	2,038.4	0.5	1.4	1	1	1
12/23/2019 06:00	0.4	12.7	2,050.3	0.5	1.4	1	1	1
12/23/2019 07:00	0.4	12.7	2,052.9	0.5	1.4	1	1	1
12/23/2019 08:00	0.5	12.0	2,196.3	0.5	1.5	1	1	1
12/23/2019 09:00	0.5	12.3	2,115.8	0.5	1.5	1	1	1
12/23/2019 10:00	0.5	12.3	2,111.4	0.5	1.5	1	1	1
12/23/2019 11:00	0.5	12.2	2,120.2	0.5	1.5	1	1	1
12/23/2019 12:00	0.5	12.2	2,121.4	0.5	1.5	1	1	1
12/23/2019 13:00	0.5	12.4	2,062.9	0.5	1.4	1	1	1
12/23/2019 14:00	0.5	12.3	2,094.8	0.5	1.5	1	1	1
12/23/2019 15:00	0.5	12.4	2,065.5	0.5	1.4	1	1	1
12/23/2019 16:00	0.5	12.5	2,052.6	0.5	1.4	1	1	1
12/23/2019 17:00	0.5	12.6	2,045.0	0.5	1.4	1	1	1
12/23/2019 18:00	0.5	12.5	2,047.0	0.5	1.4	1	1	1
12/23/2019 19:00	0.5	12.4	2,069.6	0.5	1.4	1	1	1
12/23/2019 20:00	0.5	12.2	2,125.9	0.5	1.5	1	1	1
12/23/2019 21:00	0.5	12.3	2,105.3	0.5	1.5	1	1	1
12/23/2019 22:00	0.5	12.3	2,099.8	0.5	1.5	1	1	1
12/23/2019 23:00	0.4	12.5	2,105.4	0.5	1.5	1	1	1
Average/Sum#:	0.5	12.4	2,079.7	0.5	1.4	24 #	24 #	24 #
Minimum:	0.4	12.0	2,034.1	0.5	1.4	1	1	1
Maximum:	0.5	12.7	2,196.3	0.5	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/24/2019 00:00	0.4	12.5	2,097.0	0.5	1.5	1	1	1
12/24/2019 01:00	0.4	12.7	2,050.2	0.5	1.4	1	1	1
12/24/2019 02:00	0.4	12.8	2,049.9	0.5	1.4	1	1	1
12/24/2019 03:00	0.4	12.8	2,049.2	0.5	1.4	1	1	1
12/24/2019 04:00	0.4	12.7	2,046.8	0.5	1.4	1	1	1
12/24/2019 05:00	0.4	12.7	2,047.6	0.5	1.4	1	1	1
12/24/2019 06:00	0.2	12.6	2,076.5	0.4	1.5	1	1	1
12/24/2019 07:00	0.4	12.8	2,057.9	0.5	1.4	1	1	1
12/24/2019 08:00	0.4	12.8	2,036.7	0.5	1.4	1	1	1
12/24/2019 09:00	0.4	12.8	2,035.9	0.5	1.4	1	1	1
12/24/2019 10:00	0.4	12.8	2,041.2	0.5	1.4	1	1	1
12/24/2019 11:00	0.4	12.7	2,041.8	0.5	1.4	1	1	1
12/24/2019 12:00	0.4	12.6	2,059.2	0.5	1.4	1	1	1
12/24/2019 13:00	0.4	12.7	2,038.5	0.5	1.4	1	1	1
12/24/2019 14:00	0.4	12.7	2,041.1	0.5	1.4	1	1	1
12/24/2019 15:00	0.4	12.5	2,081.4	0.5	1.5	1	1	1
12/24/2019 16:00	0.4	12.7	2,034.5	0.5	1.4	1	1	1
12/24/2019 17:00	0.4	12.6	2,058.5	0.5	1.4	1	1	1
12/24/2019 18:00	0.4	12.7	2,053.2	0.5	1.4	1	1	1
12/24/2019 19:00	0.4	12.7	2,039.5	0.5	1.4	1	1	1
12/24/2019 20:00	0.4	12.7	2,041.6	0.5	1.4	1	1	1
12/24/2019 21:00	0.4	12.7	2,040.0	0.5	1.4	1	1	1
12/24/2019 22:00	0.4	12.6	2,052.7	0.5	1.4	1	1	1
12/24/2019 23:00	0.4	12.7	2,034.4	0.5	1.4	1	1	1
Average/Sum#:	0.4	12.7	2,050.2	0.5	1.4	24 #	24 #	24 #
Minimum:	0.2	12.5	2,034.4	0.4	1.4	1	1	1
Maximum:	0.4	12.8	2,097.0	0.5	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/25/2019 00:00	0.4	12.6	2,062.4	0.5	1.4	1	1	1
12/25/2019 01:00	0.4	12.5	2,079.8	0.5	1.5	1	1	1
12/25/2019 02:00	0.4	12.4	2,122.8	0.5	1.5	1	1	1
12/25/2019 03:00	0.4	12.7	2,041.5	0.5	1.4	1	1	1
12/25/2019 04:00	0.4	12.6	2,056.3	0.5	1.4	1	1	1
12/25/2019 05:00	0.4	12.7	2,038.1	0.5	1.4	1	1	1
12/25/2019 06:00	0.2	12.7	2,050.3	0.4	1.4	1	1	1
12/25/2019 07:00	0.4	12.4	2,108.2	0.5	1.5	1	1	1
12/25/2019 08:00	0.4	12.8	2,025.0	0.5	1.4	1	1	1
12/25/2019 09:00	0.4	12.7	2,043.2	0.5	1.4	1	1	1
12/25/2019 10:00	0.4	12.7	2,041.5	0.5	1.4	1	1	1
12/25/2019 11:00	0.4	12.7	2,038.8	0.5	1.4	1	1	1
12/25/2019 12:00	0.4	12.7	2,047.3	0.5	1.4	1	1	1
12/25/2019 13:00	0.4	12.7	2,041.3	0.5	1.4	1	1	1
12/25/2019 14:00	0.4	12.6	2,068.3	0.5	1.4	1	1	1
12/25/2019 15:00	0.4	12.6	2,071.3	0.5	1.4	1	1	1
12/25/2019 16:00	0.4	12.5	2,081.3	0.5	1.5	1	1	1
12/25/2019 17:00	0.4	12.7	2,051.3	0.5	1.4	1	1	1
12/25/2019 18:00	0.4	12.6	2,067.9	0.5	1.4	1	1	1
12/25/2019 19:00	0.4	12.5	2,101.0	0.5	1.5	1	1	1
12/25/2019 20:00	0.4	12.5	2,094.6	0.5	1.5	1	1	1
12/25/2019 21:00	0.4	12.6	2,074.7	0.5	1.5	1	1	1
12/25/2019 22:00	0.4	12.6	2,061.4	0.5	1.4	1	1	1
12/25/2019 23:00	0.4	12.5	2,079.1	0.5	1.5	1	1	1
Average/Sum#:	0.4	12.6	2,064.5	0.5	1.4	24 #	24 #	24 #
Minimum:	0.2	12.4	2,025.0	0.4	1.4	1	1	1
Maximum:	0.4	12.8	2,122.8	0.5	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/26/2019 00:00	0.4	12.6	2,064.4	0.5	1.4	1	1	1
12/26/2019 01:00	0.4	12.4	2,113.7	0.5	1.5	1	1	1
12/26/2019 02:00	0.5	12.0	2,187.0	0.5	1.5	1	1	1
12/26/2019 03:00	0.5	12.0	2,188.2	0.5	1.5	1	1	1
12/26/2019 04:00	0.5	12.0	2,203.1	0.5	1.5	1	1	1
12/26/2019 05:00	0.4	12.6	2,094.2	0.5	1.5	1	1	1
12/26/2019 06:00	0.4	12.7	2,038.3	0.5	1.4	1	1	1
12/26/2019 07:00	0.4	12.5	2,092.4	0.5	1.5	1	1	1
12/26/2019 08:00	0.5	12.1	2,180.4	0.5	1.5	1	1	1
12/26/2019 09:00	0.5	12.3	2,111.9	0.5	1.5	1	1	1
12/26/2019 10:00	0.5	12.3	2,116.4	0.5	1.5	1	1	1
12/26/2019 11:00	0.5	12.5	2,070.1	0.5	1.4	1	1	1
12/26/2019 12:00	0.5	12.5	2,750.0	0.5	1.9	1	1	1
12/26/2019 13:00	0.5	12.4	2,824.5	0.5	2.0	1	1	1
12/26/2019 14:00	0.5	12.5	2,821.1	0.5	2.0	1	1	1
12/26/2019 15:00	0.5	12.4	2,825.4	0.5	2.0	1	1	1
12/26/2019 16:00	0.5	12.2	2,831.9	0.5	2.0	1	1	1
12/26/2019 17:00	0.5	12.2	2,837.3	0.5	2.0	1	1	1
12/26/2019 18:00	0.5	12.0	2,839.8	0.5	2.0	1	1	1
12/26/2019 19:00	0.5	12.0	2,839.1	0.5	2.0	1	1	1
12/26/2019 20:00	0.5	12.0	2,839.4	0.5	2.0	1	1	1
12/26/2019 21:00	0.5	12.2	2,847.7	0.5	2.0	1	1	1
12/26/2019 22:00	0.5	12.3	2,850.5	0.5	2.0	1	1	1
12/26/2019 23:00	0.5	12.3	2,852.8	0.5	2.0	1	1	1
Average/Sum#:	0.5	12.3	2,475.8	0.5	1.7	24 #	24 #	24 #
Minimum:	0.4	12.0	2,038.3	0.5	1.4	1	1	1
Maximum:	0.5	12.7	2,852.8	0.5	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/27/2019 00:00	0.5	12.3	2,848.7	0.5	2.0	1	1	1
12/27/2019 01:00	0.5	12.4	2,855.4	0.5	2.0	1	1	1
12/27/2019 02:00	0.5	12.3	2,855.8	0.5	2.0	1	1	1
12/27/2019 03:00	0.5	12.5	2,868.0	0.5	2.0	1	1	1
12/27/2019 04:00	0.5	12.7	2,879.8	0.5	2.0	1	1	1
12/27/2019 05:00	0.5	12.7	2,890.6	0.5	2.0	1	1	1
12/27/2019 06:00	0.5	12.8	2,885.3	0.5	2.0	1	1	1
12/27/2019 07:00	0.5	12.7	2,890.9	0.5	2.0	1	1	1
12/27/2019 08:00	0.5	13.1	2,775.9	0.5	1.9	1	1	1
12/27/2019 09:00	0.5	13.9	1,683.3	0.5	1.2	1	1	0
12/27/2019 10:00	0.5	13.9	1,668.1	0.5	1.2	1	1	0
12/27/2019 11:00	0.5	13.9	1,628.7	0.5	1.1	1	1	0
12/27/2019 12:00	0.5	13.9	1,624.5	0.5	1.1	1	1	0
12/27/2019 13:00	0.6	13.9	1,675.5	0.6	1.2	1	1	0
12/27/2019 14:00	0.6	13.9	1,647.4	0.6	1.2	1	1	0
12/27/2019 15:00	0.6	14.0	1,409.3	0.6	1.0	1	1	0
12/27/2019 16:00	0.6	13.9	1,616.8	0.6	1.1	1	1	0
12/27/2019 17:00	0.5	13.9	1,719.9	0.5	1.2	1	1	1
12/27/2019 18:00	0.4	12.9	2,841.1	0.5	2.0	1	1	1
12/27/2019 19:00	0.4	12.4	2,838.8	0.5	2.0	1	1	1
12/27/2019 20:00	0.4	12.2	2,841.5	0.5	2.0	1	1	1
12/27/2019 21:00	0.4	12.3	2,842.3	0.5	2.0	1	1	1
12/27/2019 22:00	0.5	12.3	2,844.9	0.5	2.0	1	1	1
12/27/2019 23:00	0.5	12.6	2,863.2	0.5	2.0	1	1	1
Average/Sum#:	0.5	12.6	2,395.7	0.5	1.7	24 #	24 #	16 #
Minimum:	0.4	12.3	1,409.3	0.5	1.0	1	1	0
Maximum:	0.6	12.8	2,890.9	0.5	2.0	1	1	1
%SI	0.00	66.67	0.00	66.67	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/28/2019 00:00	0.5	12.9	2,868.8	0.5	2.0	1	1	1
12/28/2019 01:00	0.5	12.8	2,865.2	0.5	2.0	1	1	1
12/28/2019 02:00	0.5	12.7	2,848.9	0.5	2.0	1	1	1
12/28/2019 03:00	0.5	12.8	2,850.4	0.5	2.0	1	1	1
12/28/2019 04:00	0.5	12.9	2,893.9	0.5	2.0	1	1	1
12/28/2019 05:00	0.5	12.8	2,876.3	0.5	2.0	1	1	1
12/28/2019 06:00	0.5	12.8	2,866.5	0.5	2.0	1	1	1
12/28/2019 07:00	0.5	12.6	2,871.4	0.5	2.0	1	1	1
12/28/2019 08:00	0.5	13.0	2,818.7	0.5	2.0	1	1	1
12/28/2019 09:00	0.5	13.9	1,668.5	0.5	1.2	1	1	0
12/28/2019 10:00	0.5	13.9	1,610.3	0.5	1.1	1	1	0
12/28/2019 11:00	0.5	13.9	1,650.0	0.5	1.2	1	1	0
12/28/2019 12:00	0.5	13.9	1,683.3	0.5	1.2	1	1	0
12/28/2019 13:00	0.6	13.9	1,637.1	0.6	1.1	1	1	0
12/28/2019 14:00	0.6	13.9	1,667.1	0.6	1.2	1	1	0
12/28/2019 15:00	0.7	13.9	1,632.0	0.7	1.1	1	1	1
12/28/2019 16:00	0.2	12.7	2,831.4	0.4	2.0	1	1	1
12/28/2019 17:00	0.2	12.3	2,839.1	0.4	2.0	1	1	1
12/28/2019 18:00	0.2	12.2	2,222.4	0.4	1.6	1	1	1
12/28/2019 19:00	0.2	12.2	2,128.4	0.4	1.5	1	1	1
12/28/2019 20:00	0.1	12.3	2,125.3	0.2	1.5	1	1	1
12/28/2019 21:00	0.2	12.4	2,095.7	0.4	1.5	1	1	1
12/28/2019 22:00	0.4	12.4	2,100.7	0.5	1.5	1	1	1
12/28/2019 23:00	0.4	12.4	2,108.9	0.5	1.5	1	1	1
Average/Sum#:	0.4	0.0	2,323.3	0.0	1.6	24 #	24 #	18 #
Minimum:	0.1	0.0	1,610.3	0.0	1.1	1	1	0
Maximum:	0.7	0.0	2,893.9	0.0	2.0	1	1	1
%SI	0.00	100.00	0.00	100.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/29/2019 00:00	0.4	12.5	2,095.4	0.5	1.5	1	1	1
12/29/2019 01:00	0.4	12.4	2,121.5	0.5	1.5	1	1	1
12/29/2019 02:00	0.4	12.5	2,088.4	0.5	1.5	1	1	1
12/29/2019 03:00	0.2	12.4	2,111.0	0.4	1.5	1	1	1
12/29/2019 04:00	0.4	12.5	2,092.8	0.5	1.5	1	1	1
12/29/2019 05:00	0.2	12.4	2,098.5	0.4	1.5	1	1	1
12/29/2019 06:00	0.2	12.5	2,091.3	0.4	1.5	1	1	1
12/29/2019 07:00	0.4	12.6	2,020.6	0.5	1.4	1	1	1
12/29/2019 08:00	0.6	13.8	1,672.1	0.6	1.2	1	1	0
12/29/2019 09:00	0.6	13.8	1,601.9	0.6	1.1	1	1	0
12/29/2019 10:00	0.6	13.8	1,676.5	0.6	1.2	1	1	0
12/29/2019 11:00	0.6	13.8	1,653.0	0.6	1.2	1	1	0
12/29/2019 12:00	0.6	13.8	1,688.5	0.6	1.2	1	1	0
12/29/2019 13:00	0.6	13.8	1,617.0	0.6	1.1	1	1	0
12/29/2019 14:00	0.6	13.8	1,671.1	0.6	1.2	1	1	0
12/29/2019 15:00	0.4	13.3	1,873.5	0.4	1.3	1	1	1
12/29/2019 16:00	0.2	12.6	2,055.4	0.4	1.4	1	1	1
12/29/2019 17:00	0.4	12.5	2,078.5	0.5	1.5	1	1	1
12/29/2019 18:00	0.4	12.3	2,124.3	0.5	1.5	1	1	1
12/29/2019 19:00	0.4	12.3	2,126.9	0.5	1.5	1	1	1
12/29/2019 20:00	0.4	12.3	2,126.8	0.5	1.5	1	1	1
12/29/2019 21:00	0.4	12.3	2,125.5	0.5	1.5	1	1	1
12/29/2019 22:00	0.4	12.4	2,119.0	0.5	1.5	1	1	1
12/29/2019 23:00	0.4	12.5	2,089.7	0.5	1.5	1	1	1
Average/Sum#:	0.4	13.0	1,959.1	0.5	1.4	24 #	24 #	17 #
Minimum:	0.2	12.3	1,601.9	0.4	1.1	1	1	0
Maximum:	0.6	13.8	2,126.9	0.6	1.5	1	1	1
%SI	0.00	25.00	0.00	25.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/30/2019 00:00	0.4	12.6	2,069.2	0.5	1.4	1	1	1
12/30/2019 01:00	0.4	12.6	2,060.7	0.5	1.4	1	1	1
12/30/2019 02:00	0.4	12.7	2,038.8	0.5	1.4	1	1	1
12/30/2019 03:00	0.4	12.7	2,043.5	0.5	1.4	1	1	1
12/30/2019 04:00	0.4	12.8	2,037.3	0.5	1.4	1	1	1
12/30/2019 05:00	0.4	12.7	2,048.0	0.5	1.4	1	1	1
12/30/2019 06:00	0.4	12.6	2,062.6	0.5	1.4	1	1	1
12/30/2019 07:00	0.4	12.4	2,120.4	0.5	1.5	1	1	1
12/30/2019 08:00	0.4	12.5	2,098.6	0.5	1.5	1	1	1
12/30/2019 09:00	0.5	12.5	2,057.7	0.5	1.4	1	1	1
12/30/2019 10:00	0.5	12.6	2,037.4	0.5	1.4	1	1	1
12/30/2019 11:00	0.5	12.5	2,052.2	0.5	1.4	1	1	1
12/30/2019 12:00	0.5	12.4	2,053.1	0.5	1.4	1	1	1
12/30/2019 13:00	0.5	12.3	2,076.0	0.5	1.5	1	1	1
12/30/2019 14:00	0.7	12.4	2,061.5	0.7	1.4	1	1	1
12/30/2019 15:00	0.7	12.4	2,068.2	0.7	1.4	1	1	1
12/30/2019 16:00	0.5	12.3	2,076.3	0.5	1.5	1	1	1
12/30/2019 17:00	0.5	12.3	2,093.1	0.5	1.5	1	1	1
12/30/2019 18:00	0.5	12.2	2,125.5	0.5	1.5	1	1	1
12/30/2019 19:00	0.5	12.2	2,120.6	0.5	1.5	1	1	1
12/30/2019 20:00	0.5	12.4	2,100.9	0.5	1.5	1	1	1
12/30/2019 21:00	0.5	12.5	2,072.3	0.5	1.5	1	1	1
12/30/2019 22:00	0.5	12.4	2,100.2	0.5	1.5	1	1	1
12/30/2019 23:00	0.5	12.5	2,071.5	0.5	1.5	1	1	1
Average/Sum#:	0.5	12.5	2,072.7	0.5	1.4	24 #	24 #	24 #
Minimum:	0.4	12.2	2,037.3	0.5	1.4	1	1	1
Maximum:	0.7	12.8	2,125.5	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/31/2019 00:00	0.5	12.6	2,044.4	0.5	1.4	1	1	1
12/31/2019 01:00	0.5	13.1	1,930.7	0.5	1.4	1	1	1
12/31/2019 02:00	0.5	13.1	1,927.7	0.5	1.3	1	1	1
12/31/2019 03:00	0.5	13.1	1,941.4	0.5	1.4	1	1	1
12/31/2019 04:00	0.5	12.6	2,042.1	0.5	1.4	1	1	1
12/31/2019 05:00	0.5	12.6	2,037.0	0.5	1.4	1	1	1
12/31/2019 06:00	0.5	12.7	2,030.6	0.5	1.4	1	1	1
12/31/2019 07:00	0.5	12.6	2,030.0	0.5	1.4	1	1	1
12/31/2019 08:00	0.5	13.2	1,890.6	0.5	1.3	1	1	1
12/31/2019 09:00	0.6	13.9	1,513.2	0.6	1.1	1	1	0
12/31/2019 10:00	0.6	13.9	1,612.7	0.6	1.1	1	1	0
12/31/2019 11:00	0.6	13.9	1,580.2	0.6	1.1	1	1	0
12/31/2019 12:00	0.6	13.9	1,563.3	0.6	1.1	1	1	0
12/31/2019 13:00	0.6	13.9	1,664.2	0.6	1.2	1	1	0
12/31/2019 14:00	0.6	13.9	1,566.0	0.6	1.1	1	1	0
12/31/2019 15:00	0.7	13.9	1,579.9	0.7	1.1	1	1	1
12/31/2019 16:00	0.2	12.8	1,996.1	0.4	1.4	1	1	1
12/31/2019 17:00	0.2	12.6	2,036.1	0.4	1.4	1	1	1
12/31/2019 18:00	0.2	12.7	2,032.6	0.4	1.4	1	1	1
12/31/2019 19:00	0.2	12.7	2,040.7	0.4	1.4	1	1	1
12/31/2019 20:00	0.2	12.6	2,040.9	0.4	1.4	1	1	1
12/31/2019 21:00	0.1	12.6	2,042.0	0.2	1.4	1	1	1
12/31/2019 22:00	0.1	12.6	2,043.4	0.2	1.4	1	1	1
12/31/2019 23:00	0.1	12.7	2,042.1	0.2	1.4	1	1	1
Average/Sum#:	0.4	13.1	1,884.5	0.5	1.3	24 #	24 #	18 #
Minimum:	0.1	12.6	1,513.2	0.2	1.1	1	1	0
Maximum:	0.7	13.9	2,044.4	0.7	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/01/2019 00:00	0.6	13.9	1,390.2	0.6	0.4	1	1	0
10/01/2019 01:00	0.6	13.9	1,359.0	0.6	0.4	1	1	0
10/01/2019 02:00	0.6	13.9	1,351.1	0.6	0.4	1	1	0
10/01/2019 03:00	0.6	13.9	1,395.1	0.6	0.4	1	1	0
10/01/2019 04:00	0.6	13.9	1,651.9	0.6	0.5	1	1	0
10/01/2019 05:00	0.6	13.9	1,512.6	0.6	0.5	1	1	0
10/01/2019 06:00	0.6	13.9	1,631.9	0.6	0.5	1	1	0
10/01/2019 07:00	0.6	13.9	1,627.8	0.6	0.5	1	1	0
10/01/2019 08:00	0.6	13.9	1,639.7	0.6	0.5	1	1	0
10/01/2019 09:00	0.6	13.9	1,622.6	0.6	0.5	1	1	0
10/01/2019 10:00	0.6	13.9	1,602.7	0.6	0.5	1	1	0
10/01/2019 11:00	0.6	13.9	1,608.4	0.6	0.5	1	1	0
10/01/2019 12:00	0.6	14.0	1,593.9	0.6	0.5	1	1	0
10/01/2019 13:00	0.6	14.0	1,596.7	0.6	0.5	1	1	0
10/01/2019 14:00	0.6	13.9	1,568.6	0.6	0.5	1	1	0
10/01/2019 15:00	0.7	13.9	1,583.1	0.7	0.5	1	1	1
10/01/2019 16:00	0.4	12.7	1,966.8	0.5	0.6	1	1	1
10/01/2019 17:00	0.4	12.4	2,014.1	0.5	0.6	1	1	1
10/01/2019 18:00	0.4	12.3	2,048.1	0.5	0.6	1	1	1
10/01/2019 19:00	0.5	12.2	2,077.7	0.5	0.6	1	1	1
10/01/2019 20:00	0.5	12.2	2,078.1	0.5	0.6	1	1	1
10/01/2019 21:00	0.5	12.3	2,067.4	0.5	0.6	1	1	1
10/01/2019 22:00	0.5	12.4	2,045.5	0.5	0.6	1	1	1
10/01/2019 23:00	0.4	12.4	2,044.8	0.5	0.6	1	1	1
Average/Sum#:	0.6	13.4	1,711.6	0.6	0.5	24 #	24 #	9 #
Minimum:	0.4	12.2	1,351.1	0.5	0.4	1	1	0
Maximum:	0.7	14.0	2,078.1	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/02/2019 00:00	0.7	12.4	2,058.7	0.7	0.6	1	1	1
10/02/2019 01:00	0.7	12.4	2,043.5	0.7	0.6	1	1	1
10/02/2019 02:00	0.7	12.4	2,029.4	0.7	0.6	1	1	1
10/02/2019 03:00	0.7	12.4	2,026.5	0.7	0.6	1	1	1
10/02/2019 04:00	0.7	12.6	1,987.0	0.7	0.6	1	1	1
10/02/2019 05:00	0.7	12.5	2,014.2	0.7	0.6	1	1	1
10/02/2019 06:00	0.7	12.7	2,015.5	0.7	0.6	1	1	1
10/02/2019 07:00	0.7	12.8	1,931.6	0.7	0.6	1	1	1
10/02/2019 08:00	0.6	13.9	1,569.5	0.6	0.5	1	1	0
10/02/2019 09:00	0.6	14.0	1,259.5	0.6	0.4	1	1	0
10/02/2019 10:00	0.6	14.0	1,270.2	0.6	0.4	1	1	0
10/02/2019 11:00	0.6	14.0	1,292.9	0.6	0.4	1	1	0
10/02/2019 12:00	0.6	14.0	1,269.8	0.6	0.4	1	1	0
10/02/2019 13:00	0.6	14.0	1,287.7	0.6	0.4	1	1	0
10/02/2019 14:00	0.7	13.9	1,543.8	0.7	0.5	1	1	1
10/02/2019 15:00	0.4	12.6	1,958.6	0.5	0.6	1	1	1
10/02/2019 16:00	0.4	12.2	2,036.8	0.5	0.6	1	1	1
10/02/2019 17:00	0.5	12.2	2,058.1	0.5	0.6	1	1	1
10/02/2019 18:00	0.5	12.2	2,052.5	0.5	0.6	1	1	1
10/02/2019 19:00	0.5	12.2	2,067.5	0.5	0.6	1	1	1
10/02/2019 20:00	0.5	12.1	2,080.9	0.5	0.6	1	1	1
10/02/2019 21:00	0.5	12.2	2,058.1	0.5	0.6	1	1	1
10/02/2019 22:00	0.4	12.4	2,031.3	0.5	0.6	1	1	1
10/02/2019 23:00	0.5	12.6	1,999.5	0.5	0.6	1	1	1
Average/Sum#:	0.6	12.9	1,831.0	0.6	0.6	24 #	24 #	18 #
Minimum:	0.4	12.1	1,259.5	0.5	0.4	1	1	0
Maximum:	0.7	14.0	2,080.9	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/03/2019 00:00	0.7	12.6	1,979.6	0.7	0.6	1	1	1
10/03/2019 01:00	0.7	12.8	1,922.0	0.7	0.6	1	1	1
10/03/2019 02:00	0.7	12.7	1,968.2	0.7	0.6	1	1	1
10/03/2019 03:00	0.7	12.5	1,999.6	0.7	0.6	1	1	1
10/03/2019 04:00	0.7	12.5	2,016.1	0.7	0.6	1	1	1
10/03/2019 05:00	0.7	12.5	2,008.7	0.7	0.6	1	1	1
10/03/2019 06:00	0.7	12.5	2,026.3	0.7	0.6	1	1	1
10/03/2019 07:00	0.7	12.7	1,937.3	0.7	0.6	1	1	1
10/03/2019 08:00	0.6	13.9	1,454.5	0.6	0.4	1	1	0
10/03/2019 09:00	0.6	14.0	1,262.8	0.6	0.4	1	1	0
10/03/2019 10:00	0.6	14.0	1,252.7	0.6	0.4	1	1	0
10/03/2019 11:00	0.6	14.0	1,256.7	0.6	0.4	1	1	0
10/03/2019 12:00	0.6	13.9	1,315.4	0.6	0.4	1	1	0
10/03/2019 13:00	0.6	14.0	1,300.1	0.6	0.4	1	1	0
10/03/2019 14:00	0.6	13.9	1,352.0	0.6	0.4	1	1	0
10/03/2019 15:00	0.6	13.9	1,363.7	0.6	0.4	1	1	0
10/03/2019 16:00	0.6	13.8	1,603.8	0.6	0.5	1	1	0
10/03/2019 17:00	0.6	13.8	1,591.3	0.6	0.5	1	1	0
10/03/2019 18:00	0.6	13.8	1,592.5	0.6	0.5	1	1	0
10/03/2019 19:00	0.6	13.8	1,619.0	0.6	0.5	1	1	0
10/03/2019 20:00	0.6	13.9	1,599.1	0.6	0.5	1	1	0
10/03/2019 21:00	0.0	14.4	1,273.9	0.0	0.4	1	0	0
10/03/2019 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2019 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.6	13.5	1,622.5	0.6	0.5	22 #	21 #	8 #
Minimum:	0.0	12.5	1,252.7	0.0	0.4	0	0	0
Maximum:	0.7	14.4	2,026.3	0.7	0.6	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/04/2019 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2019 02:00	0.0	18.4	360.7	0.0	0.1	1	0	0
10/04/2019 03:00	0.0	14.9	1,019.4	0.0	0.3	1	0	0
10/04/2019 04:00	0.6	14.0	1,384.4	0.6	0.4	1	1	0
10/04/2019 05:00	0.4	12.7	1,977.3	0.5	0.6	1	1	1
10/04/2019 06:00	0.4	12.5	1,978.9	0.5	0.6	1	1	1
10/04/2019 07:00	0.6	14.0	1,369.0	0.6	0.4	1	1	0
10/04/2019 08:00	0.6	14.0	1,353.8	0.6	0.4	1	1	0
10/04/2019 09:00	0.6	14.0	1,357.9	0.6	0.4	1	1	0
10/04/2019 10:00	0.6	14.0	1,360.9	0.6	0.4	1	1	0
10/04/2019 11:00	0.6	14.0	1,364.2	0.6	0.4	1	1	0
10/04/2019 12:00	0.6	14.0	1,369.6	0.6	0.4	1	1	0
10/04/2019 13:00	0.6	13.9	1,547.6	0.6	0.5	1	1	0
10/04/2019 14:00	0.6	14.0	1,445.1	0.6	0.4	1	1	0
10/04/2019 15:00	0.6	14.0	1,421.5	0.6	0.4	1	1	0
10/04/2019 16:00	0.7	13.9	1,510.6	0.7	0.5	1	1	1
10/04/2019 17:00	0.4	12.7	1,964.0	0.5	0.6	1	1	1
10/04/2019 18:00	0.5	12.1	2,096.4	0.5	0.6	1	1	1
10/04/2019 19:00	0.5	12.2	2,081.7	0.5	0.6	1	1	1
10/04/2019 20:00	0.5	12.2	2,091.6	0.5	0.6	1	1	1
10/04/2019 21:00	0.5	12.2	2,080.6	0.5	0.6	1	1	1
10/04/2019 22:00	0.5	12.3	2,059.8	0.5	0.6	1	1	1
10/04/2019 23:00	0.5	12.4	2,047.0	0.5	0.6	1	1	1
Average/Sum#:	0.5	13.6	1,601.9	0.5	0.5	22 #	20 #	10 #
Minimum:	0.0	12.1	360.7	0.0	0.1	0	0	0
Maximum:	0.7	18.4	2,096.4	0.7	0.6	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/05/2019 00:00	0.4	12.5	2,014.0	0.5	0.6	1	1	1
10/05/2019 01:00	0.4	12.6	1,994.8	0.5	0.6	1	1	1
10/05/2019 02:00	0.4	12.8	1,959.8	0.5	0.6	1	1	1
10/05/2019 03:00	0.4	12.5	2,028.9	0.5	0.6	1	1	1
10/05/2019 04:00	0.5	12.4	2,055.4	0.5	0.6	1	1	1
10/05/2019 05:00	0.5	12.3	2,077.2	0.5	0.6	1	1	1
10/05/2019 06:00	0.4	12.7	2,023.9	0.5	0.6	1	1	1
10/05/2019 07:00	0.4	12.9	1,933.7	0.5	0.6	1	1	1
10/05/2019 08:00	0.6	13.9	1,502.2	0.6	0.5	1	1	0
10/05/2019 09:00	0.6	14.0	1,256.6	0.6	0.4	1	1	0
10/05/2019 10:00	0.6	14.0	1,252.2	0.6	0.4	1	1	0
10/05/2019 11:00	0.6	14.0	1,264.7	0.6	0.4	1	1	0
10/05/2019 12:00	0.6	14.0	1,307.4	0.6	0.4	1	1	0
10/05/2019 13:00	0.6	14.0	1,259.3	0.6	0.4	1	1	0
10/05/2019 14:00	0.6	14.0	1,436.6	0.6	0.4	1	1	0
10/05/2019 15:00	0.7	13.8	1,488.5	0.7	0.4	1	1	1
10/05/2019 16:00	0.4	12.7	1,932.3	0.5	0.6	1	1	1
10/05/2019 17:00	0.4	12.4	2,004.4	0.5	0.6	1	1	1
10/05/2019 18:00	0.4	12.4	2,010.9	0.5	0.6	1	1	1
10/05/2019 19:00	0.4	12.3	2,024.8	0.5	0.6	1	1	1
10/05/2019 20:00	0.5	12.2	2,056.6	0.5	0.6	1	1	1
10/05/2019 21:00	0.5	12.1	2,060.1	0.5	0.6	1	1	1
10/05/2019 22:00	0.5	12.3	2,033.8	0.5	0.6	1	1	1
10/05/2019 23:00	0.5	12.3	2,040.2	0.5	0.6	1	1	1
Average/Sum#:	0.5	13.0	1,792.4	0.5	0.5	24 #	24 #	17 #
Minimum:	0.4	12.1	1,252.2	0.5	0.4	1	1	0
Maximum:	0.7	14.0	2,077.2	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/06/2019 00:00	0.5	12.3	2,022.8	0.5	0.6	1	1	1
10/06/2019 01:00	0.4	12.5	1,975.5	0.5	0.6	1	1	1
10/06/2019 02:00	0.4	12.6	1,977.6	0.5	0.6	1	1	1
10/06/2019 03:00	0.4	12.6	1,977.6	0.5	0.6	1	1	1
10/06/2019 04:00	0.4	12.5	2,002.9	0.5	0.6	1	1	1
10/06/2019 05:00	0.4	12.4	2,025.8	0.5	0.6	1	1	1
10/06/2019 06:00	0.5	12.8	1,951.8	0.5	0.6	1	1	1
10/06/2019 07:00	0.6	13.9	1,483.6	0.6	0.4	1	1	0
10/06/2019 08:00	0.6	14.0	1,321.9	0.6	0.4	1	1	0
10/06/2019 09:00	0.6	14.0	1,244.4	0.6	0.4	1	1	0
10/06/2019 10:00	0.6	14.0	1,300.4	0.6	0.4	1	1	0
10/06/2019 11:00	0.6	14.0	1,330.7	0.6	0.4	1	1	0
10/06/2019 12:00	0.6	14.0	1,364.0	0.6	0.4	1	1	0
10/06/2019 13:00	0.6	14.0	1,336.8	0.6	0.4	1	1	0
10/06/2019 14:00	0.7	13.8	1,557.6	0.7	0.5	1	1	1
10/06/2019 15:00	0.4	12.5	1,964.7	0.5	0.6	1	1	1
10/06/2019 16:00	0.5	12.2	2,025.1	0.5	0.6	1	1	1
10/06/2019 17:00	0.7	11.9	2,079.9	0.7	0.6	1	1	1
10/06/2019 18:00	0.7	11.9	2,101.9	0.7	0.6	1	1	1
10/06/2019 19:00	0.5	12.1	2,058.6	0.5	0.6	1	1	1
10/06/2019 20:00	0.5	12.2	2,047.0	0.5	0.6	1	1	1
10/06/2019 21:00	0.5	12.2	2,050.0	0.5	0.6	1	1	1
10/06/2019 22:00	0.5	12.4	2,020.4	0.5	0.6	1	1	1
10/06/2019 23:00	0.4	12.5	2,008.7	0.5	0.6	1	1	1
Average/Sum#:	0.5	12.9	1,801.2	0.6	0.5	24 #	24 #	17 #
Minimum:	0.4	11.9	1,244.4	0.5	0.4	1	1	0
Maximum:	0.7	14.0	2,101.9	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/07/2019 00:00	0.5	12.5	2,003.3	0.5	0.6	1	1	1
10/07/2019 01:00	0.5	12.4	2,020.7	0.5	0.6	1	1	1
10/07/2019 02:00	0.4	12.5	1,996.3	0.5	0.6	1	1	1
10/07/2019 03:00	0.4	12.5	2,017.0	0.5	0.6	1	1	1
10/07/2019 04:00	0.5	12.3	2,050.8	0.5	0.6	1	1	1
10/07/2019 05:00	0.5	12.3	2,040.1	0.5	0.6	1	1	1
10/07/2019 06:00	0.5	12.4	2,047.8	0.5	0.6	1	1	1
10/07/2019 07:00	0.5	12.4	2,029.3	0.5	0.6	1	1	1
10/07/2019 08:00	0.4	12.4	2,012.6	0.5	0.6	1	1	1
10/07/2019 09:00	0.5	12.3	2,018.7	0.5	0.6	1	1	1
10/07/2019 10:00	0.5	12.4	1,996.9	0.5	0.6	1	1	1
10/07/2019 11:00	0.5	12.4	1,980.8	0.5	0.6	1	1	1
10/07/2019 12:00	0.5	12.4	1,979.0	0.5	0.6	1	1	1
10/07/2019 13:00	0.5	12.3	1,997.0	0.5	0.6	1	1	1
10/07/2019 14:00	0.5	12.3	1,996.5	0.5	0.6	1	1	1
10/07/2019 15:00	0.5	12.2	1,991.1	0.5	0.6	1	1	1
10/07/2019 16:00	0.5	12.1	2,036.4	0.5	0.6	1	1	1
10/07/2019 17:00	0.7	11.9	2,072.5	0.7	0.6	1	1	1
10/07/2019 18:00	0.7	11.9	2,075.6	0.7	0.6	1	1	1
10/07/2019 19:00	0.5	12.1	2,039.3	0.5	0.6	1	1	1
10/07/2019 20:00	0.5	12.1	2,032.6	0.5	0.6	1	1	1
10/07/2019 21:00	0.5	12.4	2,000.8	0.5	0.6	1	1	1
10/07/2019 22:00	0.5	12.3	2,016.9	0.5	0.6	1	1	1
10/07/2019 23:00	0.5	12.6	1,964.6	0.5	0.6	1	1	1
Average/Sum#:	0.5	12.3	2,017.4	0.5	0.6	24 #	24 #	24 #
Minimum:	0.4	11.9	1,964.6	0.5	0.6	1	1	1
Maximum:	0.7	12.6	2,075.6	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/08/2019 00:00	0.4	12.8	1,916.7	0.5	0.6	1	1	1
10/08/2019 01:00	0.5	13.0	1,858.8	0.5	0.6	1	1	1
10/08/2019 02:00	0.4	13.1	1,863.2	0.4	0.6	1	1	1
10/08/2019 03:00	0.4	12.8	1,912.2	0.5	0.6	1	1	1
10/08/2019 04:00	0.4	12.7	1,926.8	0.5	0.6	1	1	1
10/08/2019 05:00	0.5	12.4	2,008.4	0.5	0.6	1	1	1
10/08/2019 06:00	0.4	12.4	2,022.8	0.5	0.6	1	1	1
10/08/2019 07:00	0.5	12.5	1,994.1	0.5	0.6	1	1	1
10/08/2019 08:00	0.5	12.5	1,993.5	0.5	0.6	1	1	1
10/08/2019 09:00	0.5	12.4	1,996.6	0.5	0.6	1	1	1
10/08/2019 10:00	0.5	12.3	2,002.3	0.5	0.6	1	1	1
10/08/2019 11:00	0.5	12.2	2,012.4	0.5	0.6	1	1	1
10/08/2019 12:00	0.5	12.1	2,033.0	0.5	0.6	1	1	1
10/08/2019 13:00	0.5	12.3	1,991.7	0.5	0.6	1	1	1
10/08/2019 14:00	0.5	12.4	1,966.3	0.5	0.6	1	1	1
10/08/2019 15:00	0.5	12.2	1,987.9	0.5	0.6	1	1	1
10/08/2019 16:00	0.5	12.1	2,024.2	0.5	0.6	1	1	1
10/08/2019 17:00	0.7	11.9	2,058.1	0.7	0.6	1	1	1
10/08/2019 18:00	0.7	12.0	2,046.4	0.7	0.6	1	1	1
10/08/2019 19:00	0.7	12.1	2,038.9	0.7	0.6	1	1	1
10/08/2019 20:00	0.7	12.1	2,038.2	0.7	0.6	1	1	1
10/08/2019 21:00	0.7	12.2	2,010.8	0.7	0.6	1	1	1
10/08/2019 22:00	0.7	12.5	1,931.7	0.7	0.6	1	1	1
10/08/2019 23:00	0.7	12.4	1,955.8	0.7	0.6	1	1	1
Average/Sum#:	0.5	12.4	1,983.0	0.6	0.6	24 #	24 #	24 #
Minimum:	0.4	11.9	1,858.8	0.4	0.6	1	1	1
Maximum:	0.7	13.1	2,058.1	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/09/2019 00:00	0.7	12.4	1,965.3	0.7	0.6	1	1	1
10/09/2019 01:00	0.7	12.8	1,892.0	0.7	0.6	1	1	1
10/09/2019 02:00	0.7	12.7	1,915.9	0.7	0.6	1	1	1
10/09/2019 03:00	0.7	12.5	1,973.2	0.7	0.6	1	1	1
10/09/2019 04:00	0.7	12.4	1,998.5	0.7	0.6	1	1	1
10/09/2019 05:00	0.7	12.4	1,991.5	0.7	0.6	1	1	1
10/09/2019 06:00	0.7	12.2	2,038.0	0.7	0.6	1	1	1
10/09/2019 07:00	0.7	12.4	2,006.4	0.7	0.6	1	1	1
10/09/2019 08:00	0.7	12.5	1,974.6	0.7	0.6	1	1	1
10/09/2019 09:00	0.7	12.4	1,993.7	0.7	0.6	1	1	1
10/09/2019 10:00	0.7	12.4	1,998.8	0.7	0.6	1	1	1
10/09/2019 11:00	0.6	13.9	1,630.0	0.6	0.5	1	1	0
10/09/2019 12:00	0.6	14.0	1,614.6	0.6	0.5	1	1	0
10/09/2019 13:00	0.6	14.0	1,558.8	0.6	0.5	1	1	0
10/09/2019 14:00	0.6	14.0	1,483.0	0.6	0.4	1	1	0
10/09/2019 15:00	0.7	13.9	1,491.3	0.7	0.4	1	1	1
10/09/2019 16:00	0.7	12.7	1,905.0	0.7	0.6	1	1	1
10/09/2019 17:00	0.5	12.6	1,990.3	0.5	0.6	1	1	1
10/09/2019 18:00	0.5	12.6	1,979.3	0.5	0.6	1	1	1
10/09/2019 19:00	0.7	12.6	1,976.6	0.7	0.6	1	1	1
10/09/2019 20:00	0.7	12.5	1,977.8	0.7	0.6	1	1	1
10/09/2019 21:00	0.7	12.6	1,969.5	0.7	0.6	1	1	1
10/09/2019 22:00	0.7	12.6	1,977.3	0.7	0.6	1	1	1
10/09/2019 23:00	0.7	12.6	1,969.1	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.8	1,886.3	0.7	0.6	24 #	24 #	20 #
Minimum:	0.5	12.2	1,483.0	0.5	0.4	1	1	0
Maximum:	0.7	14.0	2,038.0	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/10/2019 00:00	0.7	12.6	1,969.6	0.7	0.6	1	1	1
10/10/2019 01:00	0.7	13.1	1,873.4	0.7	0.6	1	1	1
10/10/2019 02:00	0.7	12.9	1,910.6	0.7	0.6	1	1	1
10/10/2019 03:00	0.7	12.7	1,961.1	0.7	0.6	1	1	1
10/10/2019 04:00	0.7	12.7	1,961.1	0.7	0.6	1	1	1
10/10/2019 05:00	0.7	12.8	1,957.5	0.7	0.6	1	1	1
10/10/2019 06:00	0.7	12.7	1,987.4	0.7	0.6	1	1	1
10/10/2019 07:00	0.7	12.9	1,898.5	0.7	0.6	1	1	1
10/10/2019 08:00	0.6	14.0	1,456.2	0.6	0.4	1	1	0
10/10/2019 09:00	0.6	14.0	1,585.4	0.6	0.5	1	1	0
10/10/2019 10:00	0.6	14.0	1,622.5	0.6	0.5	1	1	0
10/10/2019 11:00	0.6	14.0	1,610.9	0.6	0.5	1	1	0
10/10/2019 12:00	0.6	14.0	1,620.0	0.6	0.5	1	1	0
10/10/2019 13:00	0.6	14.0	1,584.7	0.6	0.5	1	1	0
10/10/2019 14:00	0.6	14.0	1,604.8	0.6	0.5	1	1	0
10/10/2019 15:00	0.6	13.9	1,496.7	0.6	0.4	1	1	0
10/10/2019 16:00	0.7	12.4	1,963.8	0.7	0.6	1	1	1
10/10/2019 17:00	0.7	12.5	1,953.8	0.7	0.6	1	1	1
10/10/2019 18:00	0.5	12.4	2,036.5	0.5	0.6	1	1	1
10/10/2019 19:00	0.5	12.4	2,025.3	0.5	0.6	1	1	1
10/10/2019 20:00	0.5	12.5	2,024.4	0.5	0.6	1	1	1
10/10/2019 21:00	0.5	12.4	2,030.6	0.5	0.6	1	1	1
10/10/2019 22:00	0.5	12.4	2,020.9	0.5	0.6	1	1	1
10/10/2019 23:00	0.7	12.7	1,933.0	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.1	1,837.0	0.6	0.6	24 #	24 #	16 #
Minimum:	0.5	12.4	1,456.2	0.5	0.4	1	1	0
Maximum:	0.7	14.0	2,036.5	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/11/2019 00:00	0.7	12.7	1,919.9	0.7	0.6	1	1	1
10/11/2019 01:00	0.7	13.1	1,853.6	0.7	0.6	1	1	1
10/11/2019 02:00	0.7	13.1	1,853.1	0.7	0.6	1	1	1
10/11/2019 03:00	0.7	13.1	1,855.3	0.7	0.6	1	1	1
10/11/2019 04:00	0.7	13.1	1,858.0	0.7	0.6	1	1	1
10/11/2019 05:00	0.7	13.9	1,649.2	0.7	0.5	1	1	1
10/11/2019 06:00	0.6	14.0	1,635.8	0.6	0.5	1	1	0
10/11/2019 07:00	0.6	14.0	1,392.5	0.6	0.4	1	1	0
10/11/2019 08:00	0.6	14.0	1,239.2	0.6	0.4	1	1	0
10/11/2019 09:00	0.6	14.0	1,237.0	0.6	0.4	1	1	0
10/11/2019 10:00	0.6	14.0	1,236.9	0.6	0.4	1	1	0
10/11/2019 11:00	0.6	14.0	1,238.9	0.6	0.4	1	1	0
10/11/2019 12:00	0.6	14.0	1,240.4	0.6	0.4	1	1	0
10/11/2019 13:00	0.6	14.0	1,272.9	0.6	0.4	1	1	0
10/11/2019 14:00	0.6	13.9	1,621.1	0.6	0.5	1	1	0
10/11/2019 15:00	0.7	13.8	1,550.6	0.7	0.5	1	1	1
10/11/2019 16:00	0.4	12.6	1,962.1	0.5	0.6	1	1	1
10/11/2019 17:00	0.7	12.0	2,105.8	0.7	0.6	1	1	1
10/11/2019 18:00	0.7	11.8	2,142.7	0.7	0.6	1	1	1
10/11/2019 19:00	0.5	12.2	2,058.2	0.5	0.6	1	1	1
10/11/2019 20:00	0.5	12.3	2,041.4	0.5	0.6	1	1	1
10/11/2019 21:00	0.5	12.3	2,054.4	0.5	0.6	1	1	1
10/11/2019 22:00	0.5	12.4	2,047.6	0.5	0.6	1	1	1
10/11/2019 23:00	0.7	12.4	2,048.4	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.2	1,713.1	0.6	0.5	24 #	24 #	15 #
Minimum:	0.4	11.8	1,236.9	0.5	0.4	1	1	0
Maximum:	0.7	14.0	2,142.7	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/12/2019 00:00	0.7	12.3	2,043.9	0.7	0.6	1	1	1
10/12/2019 01:00	0.7	12.5	2,001.9	0.7	0.6	1	1	1
10/12/2019 02:00	0.7	12.5	2,010.9	0.7	0.6	1	1	1
10/12/2019 03:00	0.7	12.4	2,027.4	0.7	0.6	1	1	1
10/12/2019 04:00	0.7	12.3	2,032.4	0.7	0.6	1	1	1
10/12/2019 05:00	0.7	12.3	2,046.4	0.7	0.6	1	1	1
10/12/2019 06:00	0.7	12.4	2,042.9	0.7	0.6	1	1	1
10/12/2019 07:00	0.0	14.1	1,233.3	0.0	0.4	1	0	1
10/12/2019 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2019 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2019 10:00	0.0	18.7	282.2	0.0	0.1	1	0	0
10/12/2019 11:00	0.0	16.1	679.8	0.0	0.2	1	0	0
10/12/2019 12:00	0.0	14.0	1,331.8	0.0	0.4	1	0	0
10/12/2019 13:00	0.6	14.0	1,293.1	0.6	0.4	1	1	0
10/12/2019 14:00	0.6	13.9	1,575.5	0.6	0.5	1	1	0
10/12/2019 15:00	0.6	14.0	1,416.1	0.6	0.4	1	1	0
10/12/2019 16:00	0.6	13.9	1,613.8	0.6	0.5	1	1	0
10/12/2019 17:00	0.7	13.4	1,744.8	0.7	0.5	1	1	1
10/12/2019 18:00	0.5	12.3	2,020.5	0.5	0.6	1	1	1
10/12/2019 19:00	0.5	12.2	2,045.4	0.5	0.6	1	1	1
10/12/2019 20:00	0.5	12.3	2,039.9	0.5	0.6	1	1	1
10/12/2019 21:00	0.5	12.2	2,055.5	0.5	0.6	1	1	1
10/12/2019 22:00	0.5	12.3	2,034.1	0.5	0.6	1	1	1
10/12/2019 23:00	0.7	12.3	2,065.9	0.7	0.6	1	1	1
Average/Sum#:	0.5	13.3	1,710.8	0.5	0.5	22 #	18 #	15 #
Minimum:	0.0	12.2	282.2	0.0	0.1	0	0	0
Maximum:	0.7	18.7	2,065.9	0.7	0.6	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/13/2019 00:00	0.7	12.3	2,037.4	0.7	0.6	1	1	1
10/13/2019 01:00	0.7	12.3	2,037.3	0.7	0.6	1	1	1
10/13/2019 02:00	0.7	12.3	2,039.5	0.7	0.6	1	1	1
10/13/2019 03:00	0.7	12.3	2,045.3	0.7	0.6	1	1	1
10/13/2019 04:00	0.7	12.3	2,044.4	0.7	0.6	1	1	1
10/13/2019 05:00	0.7	12.3	2,041.5	0.7	0.6	1	1	1
10/13/2019 06:00	0.7	12.6	1,977.0	0.7	0.6	1	1	1
10/13/2019 07:00	0.7	13.9	1,484.2	0.7	0.4	1	1	1
10/13/2019 08:00	0.6	13.9	1,595.4	0.6	0.5	1	1	0
10/13/2019 09:00	0.6	13.9	1,620.1	0.6	0.5	1	1	0
10/13/2019 10:00	0.6	13.9	1,616.1	0.6	0.5	1	1	0
10/13/2019 11:00	0.6	14.0	1,494.6	0.6	0.4	1	1	0
10/13/2019 12:00	0.6	13.9	1,624.0	0.6	0.5	1	1	0
10/13/2019 13:00	0.6	14.0	1,514.7	0.6	0.5	1	1	0
10/13/2019 14:00	0.6	13.8	1,611.1	0.6	0.5	1	1	0
10/13/2019 15:00	0.7	13.9	1,516.0	0.7	0.5	1	1	1
10/13/2019 16:00	0.4	12.5	1,957.0	0.5	0.6	1	1	1
10/13/2019 17:00	0.5	12.1	2,043.1	0.5	0.6	1	1	1
10/13/2019 18:00	0.5	12.3	2,016.4	0.5	0.6	1	1	1
10/13/2019 19:00	0.5	12.3	2,004.6	0.5	0.6	1	1	1
10/13/2019 20:00	0.5	12.4	2,005.5	0.5	0.6	1	1	1
10/13/2019 21:00	0.5	12.3	2,026.9	0.5	0.6	1	1	1
10/13/2019 22:00	0.7	13.0	1,806.1	0.7	0.5	1	1	1
10/13/2019 23:00	0.0	15.1	949.0	0.0	0.3	1	0	0
Average/Sum#:	0.6	13.1	1,796.1	0.6	0.5	24 #	23 #	16 #
Minimum:	0.0	12.1	949.0	0.0	0.3	1	0	0
Maximum:	0.7	15.1	2,045.3	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/14/2019 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2019 02:00	0.0	16.6	599.7	0.0	0.2	1	0	0
10/14/2019 03:00	0.0	13.9	1,479.8	0.0	0.4	1	0	1
10/14/2019 04:00	0.4	12.7	1,938.7	0.5	0.6	1	1	1
10/14/2019 05:00	0.4	12.3	2,034.9	0.5	0.6	1	1	1
10/14/2019 06:00	0.6	13.9	1,639.4	0.6	0.5	1	1	0
10/14/2019 07:00	0.6	13.9	1,405.1	0.6	0.4	1	1	0
10/14/2019 08:00	0.6	13.9	1,464.5	0.6	0.4	1	1	0
10/14/2019 09:00	0.6	14.0	1,259.9	0.6	0.4	1	1	0
10/14/2019 10:00	0.6	14.0	1,252.9	0.6	0.4	1	1	0
10/14/2019 11:00	0.6	14.0	1,314.5	0.6	0.4	1	1	0
10/14/2019 12:00	0.6	0.0	1,447.7	0.6	0.4	1	1	0
10/14/2019 13:00	0.7	13.7	1,561.8	0.7	0.5	1	1	1
10/14/2019 14:00	0.4	13.0	1,932.9	0.5	0.6	1	1	1
10/14/2019 15:00	0.2	12.4	1,989.6	0.4	0.6	1	1	1
10/14/2019 16:00	0.5	12.1	2,048.3	0.5	0.6	1	1	1
10/14/2019 17:00	0.7	11.9	2,110.6	0.7	0.6	1	1	1
10/14/2019 18:00	0.7	11.8	2,144.5	0.7	0.6	1	1	1
10/14/2019 19:00	0.7	11.8	2,145.1	0.7	0.6	1	1	1
10/14/2019 20:00	0.7	12.0	2,089.7	0.7	0.6	1	1	1
10/14/2019 21:00	0.5	12.3	2,040.6	0.5	0.6	1	1	1
10/14/2019 22:00	0.5	12.4	2,035.8	0.5	0.6	1	1	1
10/14/2019 23:00	0.5	12.4	2,038.8	0.5	0.6	1	1	1
Average/Sum#:	0.5	13.1	1,726.1	0.5	0.5	22 #	20 #	14 #
Minimum:	0.0	11.8	599.7	0.0	0.2	0	0	0
Maximum:	0.7	16.6	2,145.1	0.7	0.6	1	1	1
%SI	12.50	12.50	8.33	12.50	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/15/2019 00:00	0.5	12.4	2,046.8	0.5	0.6	1	1	1
10/15/2019 01:00	0.5	12.4	2,033.2	0.5	0.6	1	1	1
10/15/2019 02:00	0.5	12.4	2,043.8	0.5	0.6	1	1	1
10/15/2019 03:00	0.5	12.4	2,034.8	0.5	0.6	1	1	1
10/15/2019 04:00	0.7	12.4	2,033.5	0.7	0.6	1	1	1
10/15/2019 05:00	0.7	13.1	1,787.5	0.7	0.5	1	1	1
10/15/2019 06:00	0.6	13.9	1,676.6	0.6	0.5	1	1	0
10/15/2019 07:00	0.7	13.5	1,733.2	0.7	0.5	1	1	1
10/15/2019 08:00	0.6	13.9	1,475.9	0.6	0.4	1	1	0
10/15/2019 09:00	0.6	14.0	1,310.2	0.6	0.4	1	1	0
10/15/2019 10:00	0.6	14.0	1,287.5	0.6	0.4	1	1	0
10/15/2019 11:00	0.6	14.0	1,319.3	0.6	0.4	1	1	0
10/15/2019 12:00	0.6	14.0	1,401.6	0.6	0.4	1	1	0
10/15/2019 13:00	0.6	13.9	1,621.0	0.6	0.5	1	1	0
10/15/2019 14:00	0.7	13.8	1,623.1	0.7	0.5	1	1	1
10/15/2019 15:00	0.4	12.8	1,873.5	0.5	0.6	1	1	1
10/15/2019 16:00	0.4	11.8	2,113.6	0.5	0.6	1	1	1
10/15/2019 17:00	0.4	11.8	2,119.5	0.5	0.6	1	1	1
10/15/2019 18:00	0.4	11.8	2,123.6	0.5	0.6	1	1	1
10/15/2019 19:00	0.4	11.8	2,124.3	0.5	0.6	1	1	1
10/15/2019 20:00	0.4	11.9	2,129.5	0.5	0.6	1	1	1
10/15/2019 21:00	0.4	11.9	2,132.2	0.5	0.6	1	1	1
10/15/2019 22:00	0.4	11.9	2,129.6	0.5	0.6	1	1	1
10/15/2019 23:00	0.4	11.9	2,128.1	0.5	0.6	1	1	1
Average/Sum#:	0.5	12.8	1,845.9	0.6	0.5	24 #	24 #	17 #
Minimum:	0.4	11.8	1,287.5	0.5	0.4	1	1	0
Maximum:	0.7	14.0	2,132.2	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/16/2019 00:00	0.4	11.9	2,129.7	0.5	0.6	1	1	1
10/16/2019 01:00	0.4	11.9	2,136.0	0.5	0.6	1	1	1
10/16/2019 02:00	0.5	11.9	2,128.2	0.5	0.6	1	1	1
10/16/2019 03:00	0.5	11.9	2,115.0	0.5	0.6	1	1	1
10/16/2019 04:00	0.4	11.9	2,141.3	0.5	0.6	1	1	1
10/16/2019 05:00	0.4	11.9	2,144.1	0.5	0.6	1	1	1
10/16/2019 06:00	0.5	11.9	2,139.9	0.5	0.6	1	1	1
10/16/2019 07:00	0.5	11.9	2,129.5	0.5	0.6	1	1	1
10/16/2019 08:00	0.5	11.9	2,123.8	0.5	0.6	1	1	1
10/16/2019 09:00	0.5	11.9	2,109.3	0.5	0.6	1	1	1
10/16/2019 10:00	0.5	11.9	2,102.7	0.5	0.6	1	1	1
10/16/2019 11:00	0.4	12.0	2,095.3	0.5	0.6	1	1	1
10/16/2019 12:00	0.4	12.0	2,093.3	0.5	0.6	1	1	1
10/16/2019 13:00	0.4	11.9	2,102.4	0.5	0.6	1	1	1
10/16/2019 14:00	0.4	11.9	2,106.2	0.5	0.6	1	1	1
10/16/2019 15:00	0.4	11.8	2,107.0	0.5	0.6	1	1	1
10/16/2019 16:00	0.4	11.8	2,104.8	0.5	0.6	1	1	1
10/16/2019 17:00	0.4	11.9	2,104.4	0.5	0.6	1	1	1
10/16/2019 18:00	0.4	11.9	2,092.4	0.5	0.6	1	1	1
10/16/2019 19:00	0.4	12.0	2,084.8	0.5	0.6	1	1	1
10/16/2019 20:00	0.4	12.0	2,071.2	0.5	0.6	1	1	1
10/16/2019 21:00	0.7	13.7	1,585.8	0.7	0.5	1	1	1
10/16/2019 22:00	0.6	13.9	1,405.4	0.6	0.4	1	1	0
10/16/2019 23:00	0.6	13.9	1,601.1	0.6	0.5	1	1	0
Average/Sum#:	0.5	12.2	2,039.7	0.5	0.6	24 #	24 #	22 #
Minimum:	0.4	11.8	1,405.4	0.5	0.4	1	1	0
Maximum:	0.7	13.9	2,144.1	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/17/2019 00:00	0.6	13.9	1,577.4	0.6	0.5	1	1	0
10/17/2019 01:00	0.7	13.8	1,636.6	0.7	0.5	1	1	1
10/17/2019 02:00	0.4	12.9	1,903.6	0.5	0.6	1	1	1
10/17/2019 03:00	0.5	12.7	1,932.6	0.5	0.6	1	1	1
10/17/2019 04:00	0.5	12.5	1,974.1	0.5	0.6	1	1	1
10/17/2019 05:00	0.5	12.7	1,957.3	0.5	0.6	1	1	1
10/17/2019 06:00	0.5	12.4	2,012.2	0.5	0.6	1	1	1
10/17/2019 07:00	0.7	12.5	1,961.5	0.7	0.6	1	1	1
10/17/2019 08:00	0.7	13.7	1,521.6	0.7	0.5	1	1	1
10/17/2019 09:00	0.6	13.9	1,475.9	0.6	0.4	1	1	0
10/17/2019 10:00	0.6	13.9	1,490.2	0.6	0.4	1	1	0
10/17/2019 11:00	0.6	13.9	1,534.7	0.6	0.5	1	1	0
10/17/2019 12:00	0.6	14.0	1,313.1	0.6	0.4	1	1	0
10/17/2019 13:00	0.6	13.9	1,465.6	0.6	0.4	1	1	0
10/17/2019 14:00	0.6	13.9	1,559.5	0.6	0.5	1	1	0
10/17/2019 15:00	0.7	13.9	1,492.6	0.7	0.4	1	1	1
10/17/2019 16:00	0.5	12.7	1,931.9	0.5	0.6	1	1	1
10/17/2019 17:00	0.7	12.0	2,104.4	0.7	0.6	1	1	1
10/17/2019 18:00	0.7	12.2	2,067.5	0.7	0.6	1	1	1
10/17/2019 19:00	0.5	12.3	2,046.0	0.5	0.6	1	1	1
10/17/2019 20:00	0.5	12.3	2,062.2	0.5	0.6	1	1	1
10/17/2019 21:00	0.7	12.3	2,038.2	0.7	0.6	1	1	1
10/17/2019 22:00	0.7	12.6	1,962.2	0.7	0.6	1	1	1
10/17/2019 23:00	0.7	12.8	1,928.0	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.1	1,789.5	0.6	0.5	24 #	24 #	17 #
Minimum:	0.4	12.0	1,313.1	0.5	0.4	1	1	0
Maximum:	0.7	14.0	2,104.4	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/18/2019 00:00	0.7	12.9	1,906.9	0.7	0.6	1	1	1
10/18/2019 01:00	0.7	12.9	1,903.2	0.7	0.6	1	1	1
10/18/2019 02:00	0.7	13.1	1,860.9	0.7	0.6	1	1	1
10/18/2019 03:00	0.7	13.0	1,903.5	0.7	0.6	1	1	1
10/18/2019 04:00	0.5	12.7	1,965.6	0.5	0.6	1	1	1
10/18/2019 05:00	0.5	12.7	1,952.5	0.5	0.6	1	1	1
10/18/2019 06:00	0.7	12.5	2,006.5	0.7	0.6	1	1	1
10/18/2019 07:00	0.7	13.1	1,851.9	0.7	0.6	1	1	1
10/18/2019 08:00	0.6	13.9	1,531.1	0.6	0.5	1	1	0
10/18/2019 09:00	0.6	13.9	1,478.5	0.6	0.4	1	1	0
10/18/2019 10:00	0.6	13.9	1,486.3	0.6	0.4	1	1	0
10/18/2019 11:00	0.6	13.9	1,496.1	0.6	0.4	1	1	0
10/18/2019 12:00	0.6	13.9	1,451.2	0.6	0.4	1	1	0
10/18/2019 13:00	0.6	13.8	1,564.5	0.6	0.5	1	1	0
10/18/2019 14:00	0.6	13.8	1,563.1	0.6	0.5	1	1	0
10/18/2019 15:00	0.7	13.8	1,579.3	0.7	0.5	1	1	1
10/18/2019 16:00	0.4	12.5	1,976.9	0.5	0.6	1	1	1
10/18/2019 17:00	0.5	12.2	2,031.7	0.5	0.6	1	1	1
10/18/2019 18:00	0.5	12.5	1,964.0	0.5	0.6	1	1	1
10/18/2019 19:00	0.5	12.5	1,970.9	0.5	0.6	1	1	1
10/18/2019 20:00	0.5	12.3	2,024.7	0.5	0.6	1	1	1
10/18/2019 21:00	0.5	12.3	2,039.5	0.5	0.6	1	1	1
10/18/2019 22:00	0.5	12.5	1,987.5	0.5	0.6	1	1	1
10/18/2019 23:00	0.5	12.4	2,032.2	0.5	0.6	1	1	1
Average/Sum#:	0.6	13.0	1,813.7	0.6	0.6	24 #	24 #	17 #
Minimum:	0.4	12.2	1,451.2	0.5	0.4	1	1	0
Maximum:	0.7	13.9	2,039.5	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/19/2019 00:00	0.5	12.6	1,982.0	0.5	0.6	1	1	1
10/19/2019 01:00	0.5	12.6	1,983.7	0.5	0.6	1	1	1
10/19/2019 02:00	0.5	12.3	2,032.2	0.5	0.6	1	1	1
10/19/2019 03:00	0.5	12.5	1,991.5	0.5	0.6	1	1	1
10/19/2019 04:00	0.5	12.7	1,964.1	0.5	0.6	1	1	1
10/19/2019 05:00	0.5	12.6	1,998.3	0.5	0.6	1	1	1
10/19/2019 06:00	0.5	12.6	2,006.5	0.5	0.6	1	1	1
10/19/2019 07:00	0.0	14.6	1,161.9	0.0	0.3	1	0	1
10/19/2019 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 14:00	0.0	17.8	403.3	0.0	0.1	1	0	0
10/19/2019 15:00	0.0	15.7	801.9	0.0	0.2	1	0	0
10/19/2019 16:00	0.7	13.2	1,708.4	0.7	0.5	1	1	1
10/19/2019 17:00	0.4	12.4	1,968.5	0.5	0.6	1	1	1
10/19/2019 18:00	0.2	12.9	1,886.1	0.4	0.6	1	1	1
10/19/2019 19:00	0.2	13.0	1,868.6	0.4	0.6	1	1	1
10/19/2019 20:00	0.2	12.7	1,927.5	0.4	0.6	1	1	1
10/19/2019 21:00	0.2	12.7	1,947.7	0.4	0.6	1	1	1
10/19/2019 22:00	0.7	13.6	1,541.0	0.7	0.5	1	1	1
10/19/2019 23:00	0.6	13.9	1,364.0	0.6	0.4	1	1	0
Average/Sum#:	0.4	13.4	1,696.5	0.4	0.5	18 #	15 #	15 #
Minimum:	0.0	12.3	403.3	0.0	0.1	0	0	0
Maximum:	0.7	17.8	2,032.2	0.7	0.6	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/20/2019 00:00	0.6	13.9	1,438.8	0.6	0.4	1	1	0
10/20/2019 01:00	0.6	13.9	1,346.0	0.6	0.4	1	1	0
10/20/2019 02:00	0.0	16.2	456.0	0.0	0.1	1	0	0
10/20/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 10:00	0.0	17.5	449.3	0.0	0.1	1	0	0
10/20/2019 11:00	0.0	15.4	937.0	0.0	0.3	1	0	0
10/20/2019 12:00	0.6	14.0	1,326.2	0.6	0.4	1	1	0
10/20/2019 13:00	0.6	14.0	1,316.9	0.6	0.4	1	1	0
10/20/2019 14:00	0.6	14.0	1,565.8	0.6	0.5	1	1	0
10/20/2019 15:00	0.6	14.0	1,481.9	0.6	0.4	1	1	0
10/20/2019 16:00	0.6	13.9	1,558.3	0.6	0.5	1	1	0
10/20/2019 17:00	0.6	13.8	1,646.8	0.6	0.5	1	1	0
10/20/2019 18:00	0.7	13.3	1,788.8	0.7	0.5	1	1	1
10/20/2019 19:00	0.4	12.5	1,989.4	0.5	0.6	1	1	1
10/20/2019 20:00	0.5	12.5	2,000.9	0.5	0.6	1	1	1
10/20/2019 21:00	0.5	12.6	1,975.6	0.5	0.6	1	1	1
10/20/2019 22:00	0.5	12.6	1,979.0	0.5	0.6	1	1	1
10/20/2019 23:00	0.5	12.5	1,987.8	0.5	0.6	1	1	1
Average/Sum#:	0.5	13.9	1,485.0	0.5	0.4	17 #	14 #	6 #
Minimum:	0.0	12.5	449.3	0.0	0.1	0	0	0
Maximum:	0.7	17.5	2,000.9	0.7	0.6	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/21/2019 00:00	0.5	12.8	1,930.9	0.5	0.6	1	1	1
10/21/2019 01:00	0.7	12.7	1,928.8	0.7	0.6	1	1	1
10/21/2019 02:00	0.7	12.8	1,923.7	0.7	0.6	1	1	1
10/21/2019 03:00	0.7	12.8	1,927.2	0.7	0.6	1	1	1
10/21/2019 04:00	0.5	12.5	2,003.6	0.5	0.6	1	1	1
10/21/2019 05:00	0.5	12.4	2,036.1	0.5	0.6	1	1	1
10/21/2019 06:00	0.5	12.2	2,095.4	0.5	0.6	1	1	1
10/21/2019 07:00	0.7	12.6	1,937.3	0.7	0.6	1	1	1
10/21/2019 08:00	0.6	14.0	1,258.9	0.6	0.4	1	1	0
10/21/2019 09:00	0.6	14.0	1,254.5	0.6	0.4	1	1	0
10/21/2019 10:00	0.6	14.0	1,399.4	0.6	0.4	1	1	0
10/21/2019 11:00	0.6	14.0	1,459.5	0.6	0.4	1	1	0
10/21/2019 12:00	0.6	13.9	1,586.1	0.6	0.5	1	1	0
10/21/2019 13:00	0.6	13.7	1,733.8	0.6	0.5	1	1	0
10/21/2019 14:00	0.6	13.7	1,731.2	0.6	0.5	1	1	0
10/21/2019 15:00	0.6	13.7	1,730.0	0.6	0.5	1	1	0
10/21/2019 16:00	0.6	13.7	1,731.8	0.6	0.5	1	1	0
10/21/2019 17:00	0.6	13.7	1,736.8	0.6	0.5	1	1	0
10/21/2019 18:00	0.6	13.7	1,735.9	0.6	0.5	1	1	0
10/21/2019 19:00	0.7	13.7	1,739.4	0.7	0.5	1	1	1
10/21/2019 20:00	0.4	12.7	1,960.4	0.5	0.6	1	1	1
10/21/2019 21:00	0.5	12.4	2,008.1	0.5	0.6	1	1	1
10/21/2019 22:00	0.5	12.5	2,001.5	0.5	0.6	1	1	1
10/21/2019 23:00	0.5	12.6	1,970.1	0.5	0.6	1	1	1
Average/Sum#:	0.6	13.2	1,784.2	0.6	0.5	24 #	24 #	13 #
Minimum:	0.4	12.2	1,254.5	0.5	0.4	1	1	0
Maximum:	0.7	14.0	2,095.4	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/22/2019 00:00	0.5	12.8	1,929.4	0.5	0.6	1	1	1
10/22/2019 01:00	0.7	12.7	1,934.0	0.7	0.6	1	1	1
10/22/2019 02:00	0.7	12.7	1,923.3	0.7	0.6	1	1	1
10/22/2019 03:00	0.7	12.6	1,932.1	0.7	0.6	1	1	1
10/22/2019 04:00	0.7	12.8	1,947.6	0.7	0.6	1	1	1
10/22/2019 05:00	0.7	12.5	2,000.6	0.7	0.6	1	1	1
10/22/2019 06:00	0.7	12.4	2,031.9	0.7	0.6	1	1	1
10/22/2019 07:00	0.5	12.7	1,983.9	0.5	0.6	1	1	1
10/22/2019 08:00	0.5	12.4	2,020.9	0.5	0.6	1	1	1
10/22/2019 09:00	0.5	12.4	2,009.9	0.5	0.6	1	1	1
10/22/2019 10:00	0.5	12.4	2,016.2	0.5	0.6	1	1	1
10/22/2019 11:00	0.5	12.3	2,027.9	0.5	0.6	1	1	1
10/22/2019 12:00	0.7	12.2	2,038.6	0.7	0.6	1	1	1
10/22/2019 13:00	0.7	12.1	2,058.8	0.7	0.6	1	1	1
10/22/2019 14:00	0.7	12.0	2,064.1	0.7	0.6	1	1	1
10/22/2019 15:00	0.7	12.1	2,060.2	0.7	0.6	1	1	1
10/22/2019 16:00	0.7	12.1	2,061.5	0.7	0.6	1	1	1
10/22/2019 17:00	0.7	11.9	2,108.7	0.7	0.6	1	1	1
10/22/2019 18:00	0.5	12.2	2,035.4	0.5	0.6	1	1	1
10/22/2019 19:00	0.5	12.1	2,053.7	0.5	0.6	1	1	1
10/22/2019 20:00	0.5	12.3	2,012.1	0.5	0.6	1	1	1
10/22/2019 21:00	0.5	12.2	2,029.5	0.5	0.6	1	1	1
10/22/2019 22:00	0.5	12.3	2,006.4	0.5	0.6	1	1	1
10/22/2019 23:00	0.5	12.5	1,981.3	0.5	0.6	1	1	1
Average/Sum#:	0.6	12.4	2,011.2	0.6	0.6	24 #	24 #	24 #
Minimum:	0.5	11.9	1,923.3	0.5	0.6	1	1	1
Maximum:	0.7	12.8	2,108.7	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/23/2019 00:00	0.5	12.5	1,978.0	0.5	0.6	1	1	1
10/23/2019 01:00	0.5	12.5	1,976.9	0.5	0.6	1	1	1
10/23/2019 02:00	0.5	12.6	1,962.3	0.5	0.6	1	1	1
10/23/2019 03:00	0.5	12.6	1,970.1	0.5	0.6	1	1	1
10/23/2019 04:00	0.4	12.7	1,951.3	0.5	0.6	1	1	1
10/23/2019 05:00	0.5	12.3	2,032.6	0.5	0.6	1	1	1
10/23/2019 06:00	0.5	12.5	1,986.1	0.5	0.6	1	1	1
10/23/2019 07:00	0.6	13.9	1,333.0	0.6	0.4	1	1	0
10/23/2019 08:00	0.6	14.0	1,252.0	0.6	0.4	1	1	0
10/23/2019 09:00	0.6	14.0	1,252.4	0.6	0.4	1	1	0
10/23/2019 10:00	0.6	14.0	1,386.6	0.6	0.4	1	1	0
10/23/2019 11:00	0.6	14.0	1,473.3	0.6	0.4	1	1	0
10/23/2019 12:00	0.6	13.9	1,575.8	0.6	0.5	1	1	0
10/23/2019 13:00	0.6	13.7	1,735.3	0.6	0.5	1	1	0
10/23/2019 14:00	0.6	13.7	1,733.6	0.6	0.5	1	1	0
10/23/2019 15:00	0.6	13.7	1,731.8	0.6	0.5	1	1	0
10/23/2019 16:00	0.6	13.7	1,733.9	0.6	0.5	1	1	0
10/23/2019 17:00	0.6	13.7	1,737.2	0.6	0.5	1	1	0
10/23/2019 18:00	0.6	13.8	1,701.6	0.6	0.5	1	1	0
10/23/2019 19:00	0.4	13.0	1,869.7	0.5	0.6	1	1	1
10/23/2019 20:00	0.4	12.3	2,051.7	0.5	0.6	1	1	1
10/23/2019 21:00	0.5	12.2	2,081.6	0.5	0.6	1	1	1
10/23/2019 22:00	0.5	12.2	2,073.9	0.5	0.6	1	1	1
10/23/2019 23:00	0.4	12.4	2,027.1	0.5	0.6	1	1	1
Average/Sum#:	0.5	13.2	1,775.3	0.6	0.5	24 #	24 #	12 #
Minimum:	0.4	12.2	1,252.0	0.5	0.4	1	1	0
Maximum:	0.6	14.0	2,081.6	0.6	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/24/2019 00:00	0.4	12.5	2,004.3	0.5	0.6	1	1	1
10/24/2019 01:00	0.4	12.6	1,978.3	0.5	0.6	1	1	1
10/24/2019 02:00	0.4	12.9	1,918.4	0.5	0.6	1	1	1
10/24/2019 03:00	0.4	12.5	2,024.7	0.5	0.6	1	1	1
10/24/2019 04:00	0.4	12.5	2,028.5	0.5	0.6	1	1	1
10/24/2019 05:00	0.4	12.2	2,084.4	0.5	0.6	1	1	1
10/24/2019 06:00	0.4	12.4	2,072.1	0.5	0.6	1	1	1
10/24/2019 07:00	0.5	12.0	2,136.3	0.5	0.6	1	1	1
10/24/2019 08:00	0.5	12.0	2,131.8	0.5	0.6	1	1	1
10/24/2019 09:00	0.5	12.0	2,128.6	0.5	0.6	1	1	1
10/24/2019 10:00	0.5	11.9	2,128.7	0.5	0.6	1	1	1
10/24/2019 11:00	0.7	11.9	2,128.8	0.7	0.6	1	1	1
10/24/2019 12:00	0.7	11.9	2,119.4	0.7	0.6	1	1	1
10/24/2019 13:00	0.7	11.9	2,113.3	0.7	0.6	1	1	1
10/24/2019 14:00	0.7	11.9	2,109.4	0.7	0.6	1	1	1
10/24/2019 15:00	0.7	12.0	2,092.1	0.7	0.6	1	1	1
10/24/2019 16:00	0.5	12.0	2,102.9	0.5	0.6	1	1	1
10/24/2019 17:00	0.5	12.1	2,076.3	0.5	0.6	1	1	1
10/24/2019 18:00	0.5	12.1	2,070.7	0.5	0.6	1	1	1
10/24/2019 19:00	0.5	11.9	2,118.9	0.5	0.6	1	1	1
10/24/2019 20:00	0.5	12.0	2,109.9	0.5	0.6	1	1	1
10/24/2019 21:00	0.5	12.0	2,104.3	0.5	0.6	1	1	1
10/24/2019 22:00	0.7	12.0	2,090.1	0.7	0.6	1	1	1
10/24/2019 23:00	0.5	12.1	2,076.2	0.5	0.6	1	1	1
Average/Sum#:	0.5	12.1	2,081.2	0.6	0.6	24 #	24 #	24 #
Minimum:	0.4	11.9	1,918.4	0.5	0.6	1	1	1
Maximum:	0.7	12.9	2,136.3	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/25/2019 00:00	0.7	12.2	2,007.7	0.7	0.6	1	1	1
10/25/2019 01:00	0.7	12.5	1,958.6	0.7	0.6	1	1	1
10/25/2019 02:00	0.7	12.4	1,974.3	0.7	0.6	1	1	1
10/25/2019 03:00	0.7	12.5	1,970.3	0.7	0.6	1	1	1
10/25/2019 04:00	0.7	12.5	2,005.8	0.7	0.6	1	1	1
10/25/2019 05:00	0.7	12.6	1,993.6	0.7	0.6	1	1	1
10/25/2019 06:00	0.5	12.4	2,036.9	0.5	0.6	1	1	1
10/25/2019 07:00	0.5	12.6	1,992.3	0.5	0.6	1	1	1
10/25/2019 08:00	0.2	13.1	1,904.4	0.4	0.6	1	1	1
10/25/2019 09:00	0.2	13.1	1,903.5	0.4	0.6	1	1	1
10/25/2019 10:00	0.2	12.9	1,920.0	0.4	0.6	1	1	1
10/25/2019 11:00	0.2	12.9	1,907.8	0.4	0.6	1	1	1
10/25/2019 12:00	0.2	12.4	2,013.1	0.4	0.6	1	1	1
10/25/2019 13:00	0.2	12.4	2,013.6	0.4	0.6	1	1	1
10/25/2019 14:00	0.4	12.4	2,011.5	0.5	0.6	1	1	1
10/25/2019 15:00	0.4	12.4	2,012.4	0.5	0.6	1	1	1
10/25/2019 16:00	0.4	12.1	2,062.9	0.5	0.6	1	1	1
10/25/2019 17:00	0.4	12.1	2,057.9	0.5	0.6	1	1	1
10/25/2019 18:00	0.2	12.4	2,000.6	0.4	0.6	1	1	1
10/25/2019 19:00	0.2	12.4	2,000.0	0.4	0.6	1	1	1
10/25/2019 20:00	0.7	12.3	1,976.4	0.7	0.6	1	1	1
10/25/2019 21:00	0.7	12.2	1,999.8	0.7	0.6	1	1	1
10/25/2019 22:00	0.7	12.4	1,979.3	0.7	0.6	1	1	1
10/25/2019 23:00	0.7	12.4	1,992.8	0.7	0.6	1	1	1
Average/Sum#:	0.5	12.5	1,987.3	0.6	0.6	24 #	24 #	24 #
Minimum:	0.2	12.1	1,903.5	0.4	0.6	1	1	1
Maximum:	0.7	13.1	2,062.9	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/26/2019 00:00	0.7	12.5	1,971.3	0.7	0.6	1	1	1
10/26/2019 01:00	0.7	12.4	1,996.7	0.7	0.6	1	1	1
10/26/2019 02:00	0.7	12.4	1,995.8	0.7	0.6	1	1	1
10/26/2019 03:00	0.7	12.4	1,990.1	0.7	0.6	1	1	1
10/26/2019 04:00	0.7	12.4	1,993.0	0.7	0.6	1	1	1
10/26/2019 05:00	0.5	12.8	1,935.3	0.5	0.6	1	1	1
10/26/2019 06:00	0.5	12.8	1,921.3	0.5	0.6	1	1	1
10/26/2019 07:00	0.6	13.9	1,480.7	0.6	0.4	1	1	0
10/26/2019 08:00	0.6	13.9	1,577.9	0.6	0.5	1	1	0
10/26/2019 09:00	0.6	13.9	1,578.8	0.6	0.5	1	1	0
10/26/2019 10:00	0.6	13.9	1,467.9	0.6	0.4	1	1	0
10/26/2019 11:00	0.6	13.9	1,427.9	0.6	0.4	1	1	0
10/26/2019 12:00	0.6	14.0	1,525.7	0.6	0.5	1	1	0
10/26/2019 13:00	0.6	13.9	1,584.5	0.6	0.5	1	1	0
10/26/2019 14:00	0.6	14.0	1,472.6	0.6	0.4	1	1	0
10/26/2019 15:00	0.7	13.9	1,485.4	0.7	0.4	1	1	1
10/26/2019 16:00	0.2	12.6	1,940.8	0.4	0.6	1	1	1
10/26/2019 17:00	0.2	12.3	2,002.1	0.4	0.6	1	1	1
10/26/2019 18:00	0.2	12.4	1,998.3	0.4	0.6	1	1	1
10/26/2019 19:00	0.2	12.4	1,995.3	0.4	0.6	1	1	1
10/26/2019 20:00	0.2	12.4	2,007.7	0.4	0.6	1	1	1
10/26/2019 21:00	0.2	12.5	2,011.0	0.4	0.6	1	1	1
10/26/2019 22:00	0.0	14.4	1,147.5	0.0	0.3	1	0	1
10/26/2019 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.5	13.1	1,761.2	0.5	0.5	23 #	22 #	15 #
Minimum:	0.0	12.3	1,147.5	0.0	0.3	0	0	0
Maximum:	0.7	14.4	2,011.0	0.7	0.6	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/27/2019 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 17:00	0.0	18.0	405.9	0.0	0.1	1	0	0
10/27/2019 18:00	0.0	16.3	626.0	0.0	0.2	1	0	0
10/27/2019 19:00	0.0	15.1	901.5	0.0	0.3	1	0	0
10/27/2019 20:00	0.6	14.0	1,447.9	0.6	0.4	1	1	0
10/27/2019 21:00	0.6	14.0	1,340.3	0.6	0.4	1	1	0
10/27/2019 22:00	0.6	14.0	1,341.9	0.6	0.4	1	1	0
10/27/2019 23:00	0.6	14.0	1,343.9	0.6	0.4	1	1	0
Average/Sum#:	0.3	15.1	1,058.2	0.3	0.3	7 #	4 #	0 #
Minimum:	0.0	14.0	405.9	0.0	0.1	0	0	0
Maximum:	0.6	18.0	1,447.9	0.6	0.4	1	1	0
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/28/2019 00:00	0.6	13.9	1,544.5	0.6	0.5	1	1	0
10/28/2019 01:00	0.6	13.9	1,570.5	0.6	0.5	1	1	0
10/28/2019 02:00	0.6	14.0	1,333.4	0.6	0.4	1	1	0
10/28/2019 03:00	0.7	13.9	1,562.9	0.7	0.5	1	1	1
10/28/2019 04:00	0.5	13.0	1,919.0	0.5	0.6	1	1	1
10/28/2019 05:00	0.5	12.8	1,964.1	0.5	0.6	1	1	1
10/28/2019 06:00	0.7	12.1	2,107.7	0.7	0.6	1	1	1
10/28/2019 07:00	0.7	12.5	2,020.6	0.7	0.6	1	1	1
10/28/2019 08:00	0.5	12.7	1,979.4	0.5	0.6	1	1	1
10/28/2019 09:00	0.5	12.7	1,981.7	0.5	0.6	1	1	1
10/28/2019 10:00	0.5	12.7	1,972.7	0.5	0.6	1	1	1
10/28/2019 11:00	0.4	12.9	1,952.8	0.5	0.6	1	1	1
10/28/2019 12:00	0.2	12.7	1,978.3	0.4	0.6	1	1	1
10/28/2019 13:00	0.2	12.8	1,959.4	0.4	0.6	1	1	1
10/28/2019 14:00	0.2	12.7	1,980.2	0.4	0.6	1	1	1
10/28/2019 15:00	0.2	12.6	2,003.6	0.4	0.6	1	1	1
10/28/2019 16:00	0.4	12.4	2,057.8	0.5	0.6	1	1	1
10/28/2019 17:00	0.5	11.9	2,141.9	0.5	0.6	1	1	1
10/28/2019 18:00	0.4	12.2	2,094.9	0.5	0.6	1	1	1
10/28/2019 19:00	0.4	12.3	2,082.5	0.5	0.6	1	1	1
10/28/2019 20:00	0.5	12.3	2,067.8	0.5	0.6	1	1	1
10/28/2019 21:00	0.7	12.3	2,047.1	0.7	0.6	1	1	1
10/28/2019 22:00	0.5	12.8	1,919.9	0.5	0.6	1	1	1
10/28/2019 23:00	0.0	15.7	608.0	0.0	0.2	1	0	0
Average/Sum#:	0.5	12.9	1,868.8	0.5	0.6	24 #	23 #	20 #
Minimum:	0.0	11.9	608.0	0.0	0.2	1	0	0
Maximum:	0.7	15.7	2,141.9	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/29/2019 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/30/2019 00:00	0.0	17.7	444.4	0.0	0.1	1	0	0
10/30/2019 01:00	0.0	16.0	673.3	0.0	0.2	1	0	0
10/30/2019 02:00	0.0	15.0	990.0	0.0	0.3	1	0	0
10/30/2019 03:00	0.5	13.4	1,809.2	0.5	0.5	1	1	1
10/30/2019 04:00	0.4	12.0	2,106.0	0.5	0.6	1	1	1
10/30/2019 05:00	0.6	13.9	1,653.2	0.6	0.5	1	1	0
10/30/2019 06:00	0.6	14.0	1,485.8	0.6	0.4	1	1	0
10/30/2019 07:00	0.6	13.9	1,708.4	0.6	0.5	1	1	0
10/30/2019 08:00	0.7	13.9	1,714.6	0.7	0.5	1	1	1
10/30/2019 09:00	0.5	13.0	1,920.6	0.5	0.6	1	1	1
10/30/2019 10:00	0.5	12.6	2,017.5	0.5	0.6	1	1	1
10/30/2019 11:00	0.7	12.3	2,051.1	0.7	0.6	1	1	1
10/30/2019 12:00	0.7	12.2	2,075.4	0.7	0.6	1	1	1
10/30/2019 13:00	0.7	12.4	2,041.5	0.7	0.6	1	1	1
10/30/2019 14:00	0.4	12.7	1,998.3	0.5	0.6	1	1	1
10/30/2019 15:00	0.4	12.7	2,012.2	0.5	0.6	1	1	1
10/30/2019 16:00	0.4	12.1	2,134.2	0.5	0.6	1	1	1
10/30/2019 17:00	0.5	12.1	2,123.9	0.5	0.6	1	1	1
10/30/2019 18:00	0.4	12.3	2,096.6	0.5	0.6	1	1	1
10/30/2019 19:00	0.4	12.4	2,089.3	0.5	0.6	1	1	1
10/30/2019 20:00	0.4	12.5	2,054.6	0.5	0.6	1	1	1
10/30/2019 21:00	0.5	12.4	2,056.9	0.5	0.6	1	1	1
10/30/2019 22:00	0.5	12.8	1,959.0	0.5	0.6	1	1	1
10/30/2019 23:00	0.5	13.0	1,948.7	0.5	0.6	1	1	1
Average/Sum#:	0.5	13.2	1,798.5	0.5	0.5	24 #	21 #	18 #
Minimum:	0.0	12.0	444.4	0.0	0.1	1	0	0
Maximum:	0.7	17.7	2,134.2	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/31/2019 00:00	0.5	13.1	1,936.9	0.5	0.6	1	1	1
10/31/2019 01:00	0.5	12.9	1,965.0	0.5	0.6	1	1	1
10/31/2019 02:00	0.5	12.9	1,957.8	0.5	0.6	1	1	1
10/31/2019 03:00	0.5	12.9	1,966.3	0.5	0.6	1	1	1
10/31/2019 04:00	0.5	12.8	1,995.8	0.5	0.6	1	1	1
10/31/2019 05:00	0.5	12.6	2,009.9	0.5	0.6	1	1	1
10/31/2019 06:00	0.5	12.7	1,998.8	0.5	0.6	1	1	1
10/31/2019 07:00	0.5	12.9	1,966.9	0.5	0.6	1	1	1
10/31/2019 08:00	0.5	13.0	1,938.6	0.5	0.6	1	1	1
10/31/2019 09:00	0.5	12.8	1,961.7	0.5	0.6	1	1	1
10/31/2019 10:00	0.5	12.9	1,949.1	0.5	0.6	1	1	1
10/31/2019 11:00	0.4	13.1	1,923.3	0.4	0.6	1	1	1
10/31/2019 12:00	0.4	12.9	1,946.4	0.5	0.6	1	1	1
10/31/2019 13:00	0.4	12.9	1,946.4	0.5	0.6	1	1	1
10/31/2019 14:00	0.4	12.9	1,953.8	0.5	0.6	1	1	1
10/31/2019 15:00	0.4	12.8	1,958.8	0.5	0.6	1	1	1
10/31/2019 16:00	0.2	12.8	1,968.1	0.4	0.6	1	1	1
10/31/2019 17:00	0.2	12.9	1,946.6	0.4	0.6	1	1	1
10/31/2019 18:00	0.2	12.8	1,975.2	0.4	0.6	1	1	1
10/31/2019 19:00	0.4	12.4	2,071.2	0.5	0.6	1	1	1
10/31/2019 20:00	0.4	12.4	2,063.5	0.5	0.6	1	1	1
10/31/2019 21:00	0.4	12.4	2,072.1	0.5	0.6	1	1	1
10/31/2019 22:00	0.7	12.3	2,065.1	0.7	0.6	1	1	1
10/31/2019 23:00	0.5	12.4	2,055.0	0.5	0.6	1	1	1
Average/Sum#:	0.4	12.8	1,983.0	0.5	0.6	24 #	24 #	24 #
Minimum:	0.2	12.3	1,923.3	0.4	0.6	1	1	1
Maximum:	0.7	13.1	2,072.1	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/01/2019 00:00	0.5	12.5	2,039.3	0.5	0.6	1	1	1
11/01/2019 01:00	0.5	12.6	2,007.9	0.5	0.6	1	1	1
11/01/2019 02:00	0.5	12.5	2,037.2	0.5	0.6	1	1	1
11/01/2019 03:00	0.5	12.5	2,037.3	0.5	0.6	1	1	1
11/01/2019 04:00	0.5	12.7	2,001.1	0.5	0.6	1	1	1
11/01/2019 05:00	0.5	12.4	2,088.4	0.5	0.6	1	1	1
11/01/2019 06:00	0.5	12.3	2,111.8	0.5	0.6	1	1	1
11/01/2019 07:00	0.7	12.3	2,107.2	0.7	0.6	1	1	1
11/01/2019 08:00	0.7	12.3	2,094.9	0.7	0.6	1	1	1
11/01/2019 09:00	0.7	13.5	1,762.6	0.7	0.5	1	1	1
11/01/2019 10:00	0.6	13.9	1,657.5	0.6	0.5	1	1	0
11/01/2019 11:00	0.6	14.0	1,325.9	0.6	0.4	1	1	0
11/01/2019 12:00	0.6	13.9	1,515.9	0.6	0.5	1	1	0
11/01/2019 13:00	0.6	14.0	1,560.1	0.6	0.5	1	1	0
11/01/2019 14:00	0.7	13.9	1,520.8	0.7	0.5	1	1	1
11/01/2019 15:00	0.2	12.8	1,958.8	0.4	0.6	1	1	1
11/01/2019 16:00	0.4	12.5	1,987.6	0.5	0.6	1	1	1
11/01/2019 17:00	0.5	12.0	2,130.3	0.5	0.6	1	1	1
11/01/2019 18:00	0.5	11.9	2,165.5	0.5	0.6	1	1	1
11/01/2019 19:00	0.4	12.3	2,081.7	0.5	0.6	1	1	1
11/01/2019 20:00	0.5	12.2	2,118.3	0.5	0.6	1	1	1
11/01/2019 21:00	0.4	12.5	2,048.1	0.5	0.6	1	1	1
11/01/2019 22:00	0.4	12.7	2,021.6	0.5	0.6	1	1	1
11/01/2019 23:00	0.4	12.6	2,042.8	0.5	0.6	1	1	1
Average/Sum#:	0.5	12.8	1,934.3	0.5	0.6	24 #	24 #	20 #
Minimum:	0.2	11.9	1,325.9	0.4	0.4	1	1	0
Maximum:	0.7	14.0	2,165.5	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/02/2019 00:00	0.5	12.4	2,059.3	0.5	0.6	1	1	1
11/02/2019 01:00	0.5	12.3	2,062.5	0.5	0.6	1	1	1
11/02/2019 02:00	0.7	12.3	2,075.5	0.7	0.6	1	1	1
11/02/2019 03:00	0.5	12.3	2,071.8	0.5	0.6	1	1	1
11/02/2019 04:00	0.7	12.3	2,076.7	0.7	0.6	1	1	1
11/02/2019 05:00	0.5	12.4	2,043.3	0.5	0.6	1	1	1
11/02/2019 06:00	0.7	12.0	2,128.8	0.7	0.6	1	1	1
11/02/2019 07:00	0.7	12.3	2,071.0	0.7	0.6	1	1	1
11/02/2019 08:00	0.5	13.0	1,895.3	0.5	0.6	1	1	1
11/02/2019 09:00	0.6	13.9	1,536.5	0.6	0.5	1	1	0
11/02/2019 10:00	0.6	13.9	1,526.0	0.6	0.5	1	1	0
11/02/2019 11:00	0.6	14.0	1,536.3	0.6	0.5	1	1	0
11/02/2019 12:00	0.6	14.0	1,535.8	0.6	0.5	1	1	0
11/02/2019 13:00	0.0	15.6	733.2	0.0	0.2	1	0	0
11/02/2019 14:00	0.0	16.4	635.9	0.0	0.2	1	0	0
11/02/2019 15:00	0.0	14.0	1,533.5	0.0	0.5	1	0	0
11/02/2019 16:00	0.6	14.0	1,386.1	0.6	0.4	1	1	0
11/02/2019 17:00	0.5	13.6	1,722.6	0.5	0.5	1	1	1
11/02/2019 18:00	0.2	12.5	2,020.0	0.4	0.6	1	1	1
11/02/2019 19:00	0.5	12.0	2,132.0	0.5	0.6	1	1	1
11/02/2019 20:00	0.4	12.0	2,119.4	0.5	0.6	1	1	1
11/02/2019 21:00	0.4	12.4	2,069.6	0.5	0.6	1	1	1
11/02/2019 22:00	0.4	12.5	2,045.7	0.5	0.6	1	1	1
11/02/2019 23:00	0.4	12.7	2,001.3	0.5	0.6	1	1	1
Average/Sum#:	0.5	13.1	1,792.4	0.5	0.5	24 #	21 #	16 #
Minimum:	0.0	12.0	635.9	0.0	0.2	1	0	0
Maximum:	0.7	16.4	2,132.0	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/03/2019 00:00	0.4	12.7	1,981.8	0.5	0.6	1	1	1
11/03/2019 01:00	0.5	12.6	1,996.2	0.5	0.6	1	1	1
11/03/2019 02:00	0.4	12.7	1,986.3	0.5	0.6	1	1	1
11/03/2019 03:00	0.5	12.6	2,004.9	0.5	0.6	1	1	1
11/03/2019 04:00	0.5	12.4	2,035.2	0.5	0.6	1	1	1
11/03/2019 05:00	0.5	12.2	2,086.3	0.5	0.6	1	1	1
11/03/2019 06:00	0.5	12.4	2,066.7	0.5	0.6	1	1	1
11/03/2019 07:00	0.5	12.6	1,947.8	0.5	0.6	1	1	1
11/03/2019 08:00	0.6	13.9	1,616.8	0.6	0.5	1	1	0
11/03/2019 09:00	0.6	13.9	1,596.8	0.6	0.5	1	1	0
11/03/2019 10:00	0.6	13.9	1,616.9	0.6	0.5	1	1	0
11/03/2019 11:00	0.6	13.9	1,606.5	0.6	0.5	1	1	0
11/03/2019 12:00	0.6	14.0	1,622.4	0.6	0.5	1	1	0
11/03/2019 13:00	0.6	14.0	1,475.1	0.6	0.4	1	1	0
11/03/2019 14:00	0.6	14.0	1,450.0	0.6	0.4	1	1	0
11/03/2019 15:00	0.4	13.3	1,764.1	0.4	0.5	1	1	1
11/03/2019 16:00	0.2	12.3	2,057.5	0.4	0.6	1	1	1
11/03/2019 17:00	0.4	12.1	2,094.3	0.5	0.6	1	1	1
11/03/2019 18:00	0.4	12.0	2,112.8	0.5	0.6	1	1	1
11/03/2019 19:00	0.5	11.9	2,131.0	0.5	0.6	1	1	1
11/03/2019 20:00	0.4	12.1	2,092.6	0.5	0.6	1	1	1
11/03/2019 21:00	0.4	12.3	2,064.3	0.5	0.6	1	1	1
11/03/2019 22:00	0.4	12.5	2,016.5	0.5	0.6	1	1	1
11/03/2019 23:00	0.5	12.4	2,039.4	0.5	0.6	1	1	1
Average/Sum#:	0.5	12.9	1,894.3	0.5	0.6	24 #	24 #	17 #
Minimum:	0.2	11.9	1,450.0	0.4	0.4	1	1	0
Maximum:	0.6	14.0	2,131.0	0.6	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/04/2019 00:00	0.5	12.5	2,008.7	0.5	0.6	1	1	1
11/04/2019 01:00	0.5	12.5	2,011.6	0.5	0.6	1	1	1
11/04/2019 02:00	0.4	12.7	1,961.1	0.5	0.6	1	1	1
11/04/2019 03:00	0.4	12.6	1,987.3	0.5	0.6	1	1	1
11/04/2019 04:00	0.5	12.5	2,007.4	0.5	0.6	1	1	1
11/04/2019 05:00	0.5	12.1	2,088.0	0.5	0.6	1	1	1
11/04/2019 06:00	0.5	12.0	2,128.2	0.5	0.6	1	1	1
11/04/2019 07:00	0.4	12.5	2,016.1	0.5	0.6	1	1	1
11/04/2019 08:00	0.4	12.5	2,029.1	0.5	0.6	1	1	1
11/04/2019 09:00	0.5	12.2	2,062.6	0.5	0.6	1	1	1
11/04/2019 10:00	0.5	12.3	2,026.7	0.5	0.6	1	1	1
11/04/2019 11:00	0.5	12.5	1,959.3	0.5	0.6	1	1	1
11/04/2019 12:00	0.5	12.3	2,005.9	0.5	0.6	1	1	1
11/04/2019 13:00	0.7	12.1	2,014.3	0.7	0.6	1	1	1
11/04/2019 14:00	0.7	12.2	1,995.5	0.7	0.6	1	1	1
11/04/2019 15:00	0.7	12.1	2,019.7	0.7	0.6	1	1	1
11/04/2019 16:00	0.7	12.0	2,072.5	0.7	0.6	1	1	1
11/04/2019 17:00	0.5	11.9	2,128.1	0.5	0.6	1	1	1
11/04/2019 18:00	0.5	11.9	2,132.5	0.5	0.6	1	1	1
11/04/2019 19:00	0.5	12.0	2,132.0	0.5	0.6	1	1	1
11/04/2019 20:00	0.4	12.0	2,128.1	0.5	0.6	1	1	1
11/04/2019 21:00	0.5	12.0	2,130.5	0.5	0.6	1	1	1
11/04/2019 22:00	0.4	12.0	2,127.8	0.5	0.6	1	1	1
11/04/2019 23:00	0.4	12.3	2,059.0	0.5	0.6	1	1	1
Average/Sum#:	0.5	12.2	2,051.3	0.5	0.6	24 #	24 #	24 #
Minimum:	0.4	11.9	1,959.3	0.5	0.6	1	1	1
Maximum:	0.7	12.7	2,132.5	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/05/2019 00:00	0.4	12.3	2,077.8	0.5	0.6	1	1	1
11/05/2019 01:00	0.4	12.3	2,076.3	0.5	0.6	1	1	1
11/05/2019 02:00	0.4	12.3	2,073.7	0.5	0.6	1	1	1
11/05/2019 03:00	0.4	12.3	2,071.0	0.5	0.6	1	1	1
11/05/2019 04:00	0.4	12.3	2,068.4	0.5	0.6	1	1	1
11/05/2019 05:00	0.4	12.2	2,108.2	0.5	0.6	1	1	1
11/05/2019 06:00	0.5	12.0	2,158.8	0.5	0.6	1	1	1
11/05/2019 07:00	0.4	12.6	2,001.5	0.5	0.6	1	1	1
11/05/2019 08:00	0.2	12.6	2,016.7	0.4	0.6	1	1	1
11/05/2019 09:00	0.2	12.8	1,972.2	0.4	0.6	1	1	1
11/05/2019 10:00	0.2	12.7	1,979.7	0.4	0.6	1	1	1
11/05/2019 11:00	0.2	12.7	1,964.8	0.4	0.6	1	1	1
11/05/2019 12:00	0.2	12.6	1,974.9	0.4	0.6	1	1	1
11/05/2019 13:00	0.2	12.4	2,026.2	0.4	0.6	1	1	1
11/05/2019 14:00	0.2	12.4	2,006.2	0.4	0.6	1	1	1
11/05/2019 15:00	0.2	12.4	2,017.6	0.4	0.6	1	1	1
11/05/2019 16:00	0.4	12.1	2,078.0	0.5	0.6	1	1	1
11/05/2019 17:00	0.4	12.2	2,063.8	0.5	0.6	1	1	1
11/05/2019 18:00	0.4	12.2	2,068.5	0.5	0.6	1	1	1
11/05/2019 19:00	0.4	12.1	2,078.5	0.5	0.6	1	1	1
11/05/2019 20:00	0.4	12.2	2,085.3	0.5	0.6	1	1	1
11/05/2019 21:00	0.4	12.2	2,073.8	0.5	0.6	1	1	1
11/05/2019 22:00	0.4	12.3	2,080.1	0.5	0.6	1	1	1
11/05/2019 23:00	0.4	12.3	2,084.0	0.5	0.6	1	1	1
Average/Sum#:	0.3	12.4	2,050.3	0.5	0.6	24 #	24 #	24 #
Minimum:	0.2	12.0	1,964.8	0.4	0.6	1	1	1
Maximum:	0.5	12.8	2,158.8	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/06/2019 00:00	0.2	12.6	2,015.5	0.4	0.6	1	1	1
11/06/2019 01:00	0.2	12.8	1,981.3	0.4	0.6	1	1	1
11/06/2019 02:00	0.2	12.5	2,049.7	0.4	0.6	1	1	1
11/06/2019 03:00	0.4	12.5	2,017.1	0.5	0.6	1	1	1
11/06/2019 04:00	0.4	12.7	1,975.2	0.5	0.6	1	1	1
11/06/2019 05:00	0.4	12.5	2,023.4	0.5	0.6	1	1	1
11/06/2019 06:00	0.4	12.2	2,096.8	0.5	0.6	1	1	1
11/06/2019 07:00	0.4	12.4	2,042.3	0.5	0.6	1	1	1
11/06/2019 08:00	0.2	12.6	2,007.6	0.4	0.6	1	1	1
11/06/2019 09:00	0.2	12.7	1,976.2	0.4	0.6	1	1	1
11/06/2019 10:00	0.2	12.7	1,971.5	0.4	0.6	1	1	1
11/06/2019 11:00	0.2	12.6	1,986.6	0.4	0.6	1	1	1
11/06/2019 12:00	0.2	12.6	1,980.4	0.4	0.6	1	1	1
11/06/2019 13:00	0.2	12.5	1,987.8	0.4	0.6	1	1	1
11/06/2019 14:00	0.2	12.5	1,999.8	0.4	0.6	1	1	1
11/06/2019 15:00	0.2	12.4	2,008.2	0.4	0.6	1	1	1
11/06/2019 16:00	0.4	12.2	2,053.0	0.5	0.6	1	1	1
11/06/2019 17:00	0.4	12.1	2,085.1	0.5	0.6	1	1	1
11/06/2019 18:00	0.4	12.1	2,080.8	0.5	0.6	1	1	1
11/06/2019 19:00	0.4	12.1	2,086.5	0.5	0.6	1	1	1
11/06/2019 20:00	0.4	12.1	2,082.1	0.5	0.6	1	1	1
11/06/2019 21:00	0.4	12.1	2,096.8	0.5	0.6	1	1	1
11/06/2019 22:00	0.4	12.2	2,089.3	0.5	0.6	1	1	1
11/06/2019 23:00	0.4	12.3	2,063.7	0.5	0.6	1	1	1
Average/Sum#:	0.3	12.4	2,031.5	0.5	0.6	24 #	24 #	24 #
Minimum:	0.2	12.1	1,971.5	0.4	0.6	1	1	1
Maximum:	0.4	12.8	2,096.8	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/07/2019 00:00	0.4	12.3	2,081.6	0.5	0.6	1	1	1
11/07/2019 01:00	0.5	12.3	2,057.9	0.5	0.6	1	1	1
11/07/2019 02:00	0.5	12.4	2,032.0	0.5	0.6	1	1	1
11/07/2019 03:00	0.4	12.6	1,994.8	0.5	0.6	1	1	1
11/07/2019 04:00	0.5	12.4	2,040.5	0.5	0.6	1	1	1
11/07/2019 05:00	0.4	12.4	2,041.8	0.5	0.6	1	1	1
11/07/2019 06:00	0.5	12.3	2,066.5	0.5	0.6	1	1	1
11/07/2019 07:00	0.4	12.4	2,045.8	0.5	0.6	1	1	1
11/07/2019 08:00	0.2	12.7	2,001.6	0.4	0.6	1	1	1
11/07/2019 09:00	0.2	12.6	2,004.1	0.4	0.6	1	1	1
11/07/2019 10:00	0.2	12.7	1,976.3	0.4	0.6	1	1	1
11/07/2019 11:00	0.2	12.5	2,008.8	0.4	0.6	1	1	1
11/07/2019 12:00	0.2	12.5	2,008.1	0.4	0.6	1	1	1
11/07/2019 13:00	0.2	12.5	2,005.1	0.4	0.6	1	1	1
11/07/2019 14:00	0.2	12.4	2,020.6	0.4	0.6	1	1	1
11/07/2019 15:00	0.4	12.3	2,038.9	0.5	0.6	1	1	1
11/07/2019 16:00	0.4	12.1	2,084.0	0.5	0.6	1	1	1
11/07/2019 17:00	0.4	12.3	2,045.2	0.5	0.6	1	1	1
11/07/2019 18:00	0.4	12.1	2,104.0	0.5	0.6	1	1	1
11/07/2019 19:00	0.4	12.1	2,107.4	0.5	0.6	1	1	1
11/07/2019 20:00	0.4	12.2	2,073.1	0.5	0.6	1	1	1
11/07/2019 21:00	0.4	12.4	2,050.2	0.5	0.6	1	1	1
11/07/2019 22:00	0.4	12.4	2,056.7	0.5	0.6	1	1	1
11/07/2019 23:00	0.4	12.5	2,030.2	0.5	0.6	1	1	1
Average/Sum#:	0.4	12.4	2,040.6	0.5	0.6	24 #	24 #	24 #
Minimum:	0.2	12.1	1,976.3	0.4	0.6	1	1	1
Maximum:	0.5	12.7	2,107.4	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/08/2019 00:00	0.5	12.4	2,055.6	0.5	0.6	1	1	1
11/08/2019 01:00	0.5	12.3	2,069.5	0.5	0.6	1	1	1
11/08/2019 02:00	0.5	12.4	2,041.9	0.5	0.6	1	1	1
11/08/2019 03:00	0.4	12.5	2,013.1	0.5	0.6	1	1	1
11/08/2019 04:00	0.4	12.6	2,007.1	0.5	0.6	1	1	1
11/08/2019 05:00	0.4	12.6	2,010.1	0.5	0.6	1	1	1
11/08/2019 06:00	0.4	12.6	2,001.5	0.5	0.6	1	1	1
11/08/2019 07:00	0.4	12.7	1,992.1	0.5	0.6	1	1	1
11/08/2019 08:00	0.5	13.1	1,868.5	0.5	0.6	1	1	1
11/08/2019 09:00	0.6	13.9	1,497.5	0.6	0.4	1	1	0
11/08/2019 10:00	0.6	14.0	1,332.3	0.6	0.4	1	1	0
11/08/2019 11:00	0.6	13.9	1,483.7	0.6	0.4	1	1	0
11/08/2019 12:00	0.6	14.0	1,485.4	0.6	0.4	1	1	0
11/08/2019 13:00	0.6	13.8	1,629.9	0.6	0.5	1	1	0
11/08/2019 14:00	0.5	13.8	1,628.2	0.5	0.5	1	1	1
11/08/2019 15:00	0.2	12.8	1,938.7	0.4	0.6	1	1	1
11/08/2019 16:00	0.2	12.5	1,994.3	0.4	0.6	1	1	1
11/08/2019 17:00	0.2	12.5	2,010.5	0.4	0.6	1	1	1
11/08/2019 18:00	0.4	12.3	2,066.4	0.5	0.6	1	1	1
11/08/2019 19:00	0.2	12.4	2,028.9	0.4	0.6	1	1	1
11/08/2019 20:00	0.2	12.4	2,058.7	0.4	0.6	1	1	1
11/08/2019 21:00	0.4	12.3	2,064.8	0.5	0.6	1	1	1
11/08/2019 22:00	0.2	12.4	2,062.1	0.4	0.6	1	1	1
11/08/2019 23:00	0.4	12.3	2,077.3	0.5	0.6	1	1	1
Average/Sum#:	0.4	12.9	1,892.4	0.5	0.6	24 #	24 #	19 #
Minimum:	0.2	12.3	1,332.3	0.4	0.4	1	1	0
Maximum:	0.6	14.0	2,077.3	0.6	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/09/2019 00:00	0.5	12.2	2,078.1	0.5	0.6	1	1	1
11/09/2019 01:00	0.5	12.3	2,055.1	0.5	0.6	1	1	1
11/09/2019 02:00	0.5	12.3	2,058.6	0.5	0.6	1	1	1
11/09/2019 03:00	0.5	12.3	2,060.0	0.5	0.6	1	1	1
11/09/2019 04:00	0.5	12.3	2,069.3	0.5	0.6	1	1	1
11/09/2019 05:00	0.4	12.6	2,008.9	0.5	0.6	1	1	1
11/09/2019 06:00	0.4	12.8	1,992.1	0.5	0.6	1	1	1
11/09/2019 07:00	0.4	12.8	1,937.4	0.5	0.6	1	1	1
11/09/2019 08:00	0.6	13.9	1,495.2	0.6	0.4	1	1	0
11/09/2019 09:00	0.6	14.0	1,265.6	0.6	0.4	1	1	0
11/09/2019 10:00	0.6	14.0	1,280.9	0.6	0.4	1	1	0
11/09/2019 11:00	0.6	14.0	1,274.1	0.6	0.4	1	1	0
11/09/2019 12:00	0.6	14.0	1,282.6	0.6	0.4	1	1	0
11/09/2019 13:00	0.6	14.0	1,273.7	0.6	0.4	1	1	0
11/09/2019 14:00	0.7	13.9	1,495.9	0.7	0.4	1	1	1
11/09/2019 15:00	0.2	12.8	1,950.1	0.4	0.6	1	1	1
11/09/2019 16:00	0.2	12.5	1,996.0	0.4	0.6	1	1	1
11/09/2019 17:00	0.2	12.4	2,023.3	0.4	0.6	1	1	1
11/09/2019 18:00	0.2	12.5	1,998.6	0.4	0.6	1	1	1
11/09/2019 19:00	0.2	12.6	2,003.0	0.4	0.6	1	1	1
11/09/2019 20:00	0.2	12.6	1,991.9	0.4	0.6	1	1	1
11/09/2019 21:00	0.2	12.6	2,017.7	0.4	0.6	1	1	1
11/09/2019 22:00	0.2	12.5	2,040.6	0.4	0.6	1	1	1
11/09/2019 23:00	0.2	12.6	2,016.5	0.4	0.6	1	1	1
Average/Sum#:	0.4	12.9	1,819.4	0.5	0.5	24 #	24 #	18 #
Minimum:	0.2	12.2	1,265.6	0.4	0.4	1	1	0
Maximum:	0.7	14.0	2,078.1	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/10/2019 00:00	0.2	12.6	2,030.3	0.4	0.6	1	1	1
11/10/2019 01:00	0.4	12.8	1,969.0	0.5	0.6	1	1	1
11/10/2019 02:00	0.4	12.8	1,968.4	0.5	0.6	1	1	1
11/10/2019 03:00	0.4	12.8	1,967.9	0.5	0.6	1	1	1
11/10/2019 04:00	0.4	12.8	1,967.0	0.5	0.6	1	1	1
11/10/2019 05:00	0.4	12.8	1,964.1	0.5	0.6	1	1	1
11/10/2019 06:00	0.4	12.6	2,005.9	0.5	0.6	1	1	1
11/10/2019 07:00	0.4	12.6	1,982.3	0.5	0.6	1	1	1
11/10/2019 08:00	0.6	13.9	1,527.7	0.6	0.5	1	1	0
11/10/2019 09:00	0.6	13.9	1,493.6	0.6	0.4	1	1	0
11/10/2019 10:00	0.6	13.9	1,499.1	0.6	0.4	1	1	0
11/10/2019 11:00	0.6	13.9	1,541.4	0.6	0.5	1	1	0
11/10/2019 12:00	0.6	14.0	1,526.8	0.6	0.5	1	1	0
11/10/2019 13:00	0.6	13.9	1,610.3	0.6	0.5	1	1	0
11/10/2019 14:00	0.6	13.9	1,573.8	0.6	0.5	1	1	0
11/10/2019 15:00	0.7	13.8	1,513.5	0.7	0.5	1	1	1
11/10/2019 16:00	0.2	12.8	1,957.6	0.4	0.6	1	1	1
11/10/2019 17:00	0.2	12.5	1,995.9	0.4	0.6	1	1	1
11/10/2019 18:00	0.2	12.6	1,991.9	0.4	0.6	1	1	1
11/10/2019 19:00	0.2	12.5	2,010.5	0.4	0.6	1	1	1
11/10/2019 20:00	0.2	12.5	2,020.7	0.4	0.6	1	1	1
11/10/2019 21:00	0.2	12.4	2,058.5	0.4	0.6	1	1	1
11/10/2019 22:00	0.4	12.2	2,097.0	0.5	0.6	1	1	1
11/10/2019 23:00	0.4	12.4	2,039.4	0.5	0.6	1	1	1
Average/Sum#:	0.4	13.0	1,846.4	0.5	0.6	24 #	24 #	17 #
Minimum:	0.2	12.2	1,493.6	0.4	0.4	1	1	0
Maximum:	0.7	14.0	2,097.0	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/11/2019 00:00	0.2	12.5	2,028.0	0.4	0.6	1	1	1
11/11/2019 01:00	0.4	12.6	1,989.2	0.5	0.6	1	1	1
11/11/2019 02:00	0.2	12.6	2,012.6	0.4	0.6	1	1	1
11/11/2019 03:00	0.2	12.6	2,008.2	0.4	0.6	1	1	1
11/11/2019 04:00	0.4	12.7	1,977.9	0.5	0.6	1	1	1
11/11/2019 05:00	0.4	12.7	1,973.2	0.5	0.6	1	1	1
11/11/2019 06:00	0.2	12.7	1,998.4	0.4	0.6	1	1	1
11/11/2019 07:00	0.4	12.6	2,011.7	0.5	0.6	1	1	1
11/11/2019 08:00	0.5	13.1	1,867.2	0.5	0.6	1	1	1
11/11/2019 09:00	0.6	13.8	1,463.8	0.6	0.4	1	1	0
11/11/2019 10:00	0.6	13.9	1,483.1	0.6	0.4	1	1	0
11/11/2019 11:00	0.6	13.9	1,476.0	0.6	0.4	1	1	0
11/11/2019 12:00	0.6	13.9	1,464.3	0.6	0.4	1	1	0
11/11/2019 13:00	0.7	13.8	1,677.0	0.7	0.5	1	1	1
11/11/2019 14:00	0.2	12.8	1,901.8	0.4	0.6	1	1	1
11/11/2019 15:00	0.2	12.4	2,002.5	0.4	0.6	1	1	1
11/11/2019 16:00	0.2	12.4	1,999.4	0.4	0.6	1	1	1
11/11/2019 17:00	0.4	12.0	2,088.6	0.5	0.6	1	1	1
11/11/2019 18:00	0.4	12.1	2,075.0	0.5	0.6	1	1	1
11/11/2019 19:00	0.4	12.2	2,047.6	0.5	0.6	1	1	1
11/11/2019 20:00	0.4	12.3	2,051.4	0.5	0.6	1	1	1
11/11/2019 21:00	0.4	12.3	2,058.3	0.5	0.6	1	1	1
11/11/2019 22:00	0.4	12.3	2,056.3	0.5	0.6	1	1	1
11/11/2019 23:00	0.4	12.3	2,041.9	0.5	0.6	1	1	1
Average/Sum#:	0.4	12.8	1,906.4	0.5	0.6	24 #	24 #	20 #
Minimum:	0.2	12.0	1,463.8	0.4	0.4	1	1	0
Maximum:	0.7	13.9	2,088.6	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/12/2019 00:00	0.4	12.4	2,034.6	0.5	0.6	1	1	1
11/12/2019 01:00	0.4	12.4	2,039.0	0.5	0.6	1	1	1
11/12/2019 02:00	0.2	12.6	2,016.2	0.4	0.6	1	1	1
11/12/2019 03:00	0.4	12.4	2,056.8	0.5	0.6	1	1	1
11/12/2019 04:00	0.4	12.4	2,043.7	0.5	0.6	1	1	1
11/12/2019 05:00	0.4	12.5	2,022.9	0.5	0.6	1	1	1
11/12/2019 06:00	0.4	12.3	2,055.3	0.5	0.6	1	1	1
11/12/2019 07:00	0.4	12.5	2,024.9	0.5	0.6	1	1	1
11/12/2019 08:00	0.4	12.5	2,015.0	0.5	0.6	1	1	1
11/12/2019 09:00	0.4	12.5	2,001.4	0.5	0.6	1	1	1
11/12/2019 10:00	0.4	12.4	2,020.6	0.5	0.6	1	1	1
11/12/2019 11:00	0.4	12.5	1,981.4	0.5	0.6	1	1	1
11/12/2019 12:00	0.4	12.5	1,969.4	0.5	0.6	1	1	1
11/12/2019 13:00	0.4	12.5	1,994.7	0.5	0.6	1	1	1
11/12/2019 14:00	0.2	12.5	1,989.9	0.4	0.6	1	1	1
11/12/2019 15:00	0.2	12.5	1,992.0	0.4	0.6	1	1	1
11/12/2019 16:00	0.2	12.5	1,980.7	0.4	0.6	1	1	1
11/12/2019 17:00	0.2	12.3	2,041.0	0.4	0.6	1	1	1
11/12/2019 18:00	0.2	12.3	2,029.8	0.4	0.6	1	1	1
11/12/2019 19:00	0.4	12.2	2,062.3	0.5	0.6	1	1	1
11/12/2019 20:00	0.4	12.2	2,057.9	0.5	0.6	1	1	1
11/12/2019 21:00	0.4	12.3	2,040.2	0.5	0.6	1	1	1
11/12/2019 22:00	0.4	12.3	2,037.2	0.5	0.6	1	1	1
11/12/2019 23:00	0.4	12.4	2,020.7	0.5	0.6	1	1	1
Average/Sum#:	0.4	12.4	2,022.0	0.5	0.6	24 #	24 #	24 #
Minimum:	0.2	12.2	1,969.4	0.4	0.6	1	1	1
Maximum:	0.4	12.6	2,062.3	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/13/2019 00:00	0.4	12.5	2,026.4	0.5	0.6	1	1	1
11/13/2019 01:00	0.4	12.6	1,991.8	0.5	0.6	1	1	1
11/13/2019 02:00	0.4	12.6	1,987.6	0.5	0.6	1	1	1
11/13/2019 03:00	0.4	12.6	1,988.9	0.5	0.6	1	1	1
11/13/2019 04:00	0.4	12.5	2,009.8	0.5	0.6	1	1	1
11/13/2019 05:00	0.4	12.5	2,016.5	0.5	0.6	1	1	1
11/13/2019 06:00	0.4	12.4	2,040.0	0.5	0.6	1	1	1
11/13/2019 07:00	0.4	12.5	2,024.1	0.5	0.6	1	1	1
11/13/2019 08:00	0.4	12.6	2,004.8	0.5	0.6	1	1	1
11/13/2019 09:00	0.4	12.6	1,992.6	0.5	0.6	1	1	1
11/13/2019 10:00	0.4	12.6	1,976.3	0.5	0.6	1	1	1
11/13/2019 11:00	0.4	12.5	1,992.8	0.5	0.6	1	1	1
11/13/2019 12:00	0.2	12.5	1,992.9	0.4	0.6	1	1	1
11/13/2019 13:00	0.4	12.4	2,009.8	0.5	0.6	1	1	1
11/13/2019 14:00	0.4	12.4	2,020.0	0.5	0.6	1	1	1
11/13/2019 15:00	0.4	12.4	2,018.6	0.5	0.6	1	1	1
11/13/2019 16:00	0.2	12.5	1,991.6	0.4	0.6	1	1	1
11/13/2019 17:00	0.4	12.1	2,088.6	0.5	0.6	1	1	1
11/13/2019 18:00	0.4	12.3	2,041.8	0.5	0.6	1	1	1
11/13/2019 19:00	0.4	12.5	2,011.3	0.5	0.6	1	1	1
11/13/2019 20:00	0.4	12.3	2,037.9	0.5	0.6	1	1	1
11/13/2019 21:00	0.4	12.4	2,026.2	0.5	0.6	1	1	1
11/13/2019 22:00	0.2	12.5	2,002.5	0.4	0.6	1	1	1
11/13/2019 23:00	0.4	12.4	2,039.3	0.5	0.6	1	1	1
Average/Sum#:	0.4	12.5	2,013.8	0.5	0.6	24 #	24 #	24 #
Minimum:	0.2	12.1	1,976.3	0.4	0.6	1	1	1
Maximum:	0.4	12.6	2,088.6	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/14/2019 00:00	0.4	12.3	2,064.1	0.5	0.6	1	1	1
11/14/2019 01:00	0.4	12.3	2,075.7	0.5	0.6	1	1	1
11/14/2019 02:00	0.4	12.3	2,069.7	0.5	0.6	1	1	1
11/14/2019 03:00	0.4	12.3	2,078.8	0.5	0.6	1	1	1
11/14/2019 04:00	0.4	12.3	2,076.2	0.5	0.6	1	1	1
11/14/2019 05:00	0.4	12.4	2,052.5	0.5	0.6	1	1	1
11/14/2019 06:00	0.4	12.3	2,081.6	0.5	0.6	1	1	1
11/14/2019 07:00	0.4	12.4	2,039.1	0.5	0.6	1	1	1
11/14/2019 08:00	0.4	12.6	1,990.0	0.5	0.6	1	1	1
11/14/2019 09:00	0.4	12.4	2,032.7	0.5	0.6	1	1	1
11/14/2019 10:00	0.4	12.2	2,049.5	0.5	0.6	1	1	1
11/14/2019 11:00	0.4	12.4	2,008.2	0.5	0.6	1	1	1
11/14/2019 12:00	0.4	12.2	2,065.2	0.5	0.6	1	1	1
11/14/2019 13:00	0.4	12.2	2,061.1	0.5	0.6	1	1	1
11/14/2019 14:00	0.4	12.2	2,058.5	0.5	0.6	1	1	1
11/14/2019 15:00	0.4	12.2	2,053.1	0.5	0.6	1	1	1
11/14/2019 16:00	0.2	12.3	2,033.8	0.4	0.6	1	1	1
11/14/2019 17:00	0.4	12.3	2,055.8	0.5	0.6	1	1	1
11/14/2019 18:00	0.4	12.3	2,054.3	0.5	0.6	1	1	1
11/14/2019 19:00	0.4	12.3	2,049.6	0.5	0.6	1	1	1
11/14/2019 20:00	0.4	12.3	2,059.3	0.5	0.6	1	1	1
11/14/2019 21:00	0.4	12.4	2,050.1	0.5	0.6	1	1	1
11/14/2019 22:00	0.4	12.4	2,034.6	0.5	0.6	1	1	1
11/14/2019 23:00	0.4	12.4	2,058.2	0.5	0.6	1	1	1
Average/Sum#:	0.4	12.3	2,052.2	0.5	0.6	24 #	24 #	24 #
Minimum:	0.2	12.2	1,990.0	0.4	0.6	1	1	1
Maximum:	0.4	12.6	2,081.6	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/15/2019 00:00	0.2	12.5	2,025.4	0.4	0.6	1	1	1
11/15/2019 01:00	0.2	12.7	1,998.4	0.4	0.6	1	1	1
11/15/2019 02:00	0.2	12.6	2,013.0	0.4	0.6	1	1	1
11/15/2019 03:00	0.2	12.7	1,979.8	0.4	0.6	1	1	1
11/15/2019 04:00	0.2	12.7	1,984.6	0.4	0.6	1	1	1
11/15/2019 05:00	0.2	12.7	1,976.6	0.4	0.6	1	1	1
11/15/2019 06:00	0.2	12.4	2,037.1	0.4	0.6	1	1	1
11/15/2019 07:00	0.4	12.4	2,053.1	0.5	0.6	1	1	1
11/15/2019 08:00	0.4	12.6	2,003.6	0.5	0.6	1	1	1
11/15/2019 09:00	0.4	12.6	1,996.2	0.5	0.6	1	1	1
11/15/2019 10:00	0.4	12.5	2,005.8	0.5	0.6	1	1	1
11/15/2019 11:00	0.4	13.0	1,908.7	0.5	0.6	1	1	1
11/15/2019 12:00	0.2	12.6	1,983.9	0.4	0.6	1	1	1
11/15/2019 13:00	0.2	12.4	2,027.7	0.4	0.6	1	1	1
11/15/2019 14:00	0.4	12.3	2,046.3	0.5	0.6	1	1	1
11/15/2019 15:00	0.4	12.4	2,028.1	0.5	0.6	1	1	1
11/15/2019 16:00	0.4	12.5	2,008.2	0.5	0.6	1	1	1
11/15/2019 17:00	0.4	12.3	2,055.0	0.5	0.6	1	1	1
11/15/2019 18:00	0.4	12.6	1,978.0	0.5	0.6	1	1	1
11/15/2019 19:00	0.4	12.5	2,008.4	0.5	0.6	1	1	1
11/15/2019 20:00	0.4	12.3	2,056.7	0.5	0.6	1	1	1
11/15/2019 21:00	0.2	12.5	2,007.5	0.4	0.6	1	1	1
11/15/2019 22:00	0.4	12.4	2,014.8	0.5	0.6	1	1	1
11/15/2019 23:00	0.4	12.6	1,983.8	0.5	0.6	1	1	1
Average/Sum#:	0.3	12.5	2,007.5	0.5	0.6	24 #	24 #	24 #
Minimum:	0.2	12.3	1,908.7	0.4	0.6	1	1	1
Maximum:	0.4	13.0	2,056.7	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/16/2019 00:00	0.4	12.7	1,976.3	0.5	0.6	1	1	1
11/16/2019 01:00	0.4	12.8	1,974.9	0.5	0.6	1	1	1
11/16/2019 02:00	0.4	12.6	1,982.3	0.5	0.6	1	1	1
11/16/2019 03:00	0.4	12.6	1,979.7	0.5	0.6	1	1	1
11/16/2019 04:00	0.4	12.7	1,974.2	0.5	0.6	1	1	1
11/16/2019 05:00	0.4	12.7	1,982.6	0.5	0.6	1	1	1
11/16/2019 06:00	0.4	12.6	1,986.4	0.5	0.6	1	1	1
11/16/2019 07:00	0.4	12.7	1,939.9	0.5	0.6	1	1	1
11/16/2019 08:00	0.6	13.9	1,578.0	0.6	0.5	1	1	0
11/16/2019 09:00	0.6	13.9	1,478.3	0.6	0.4	1	1	0
11/16/2019 10:00	0.6	13.9	1,503.1	0.6	0.5	1	1	0
11/16/2019 11:00	0.6	13.9	1,592.5	0.6	0.5	1	1	0
11/16/2019 12:00	0.6	13.9	1,558.3	0.6	0.5	1	1	0
11/16/2019 13:00	0.6	13.9	1,635.9	0.6	0.5	1	1	0
11/16/2019 14:00	0.6	13.9	1,611.3	0.6	0.5	1	1	0
11/16/2019 15:00	0.7	13.8	1,512.4	0.7	0.5	1	1	1
11/16/2019 16:00	0.2	12.6	1,964.3	0.4	0.6	1	1	1
11/16/2019 17:00	0.2	12.4	2,021.7	0.4	0.6	1	1	1
11/16/2019 18:00	0.2	12.5	2,004.2	0.4	0.6	1	1	1
11/16/2019 19:00	0.2	12.5	2,013.5	0.4	0.6	1	1	1
11/16/2019 20:00	0.2	12.5	2,017.4	0.4	0.6	1	1	1
11/16/2019 21:00	0.2	12.4	2,030.3	0.4	0.6	1	1	1
11/16/2019 22:00	0.2	12.6	2,020.5	0.4	0.6	1	1	1
11/16/2019 23:00	0.2	12.6	2,011.7	0.4	0.6	1	1	1
Average/Sum#:	0.4	13.0	1,847.9	0.5	0.6	24 #	24 #	17 #
Minimum:	0.2	12.4	1,478.3	0.4	0.4	1	1	0
Maximum:	0.7	13.9	2,030.3	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/17/2019 00:00	0.2	12.7	1,997.7	0.4	0.6	1	1	1
11/17/2019 01:00	0.2	12.7	2,002.5	0.4	0.6	1	1	1
11/17/2019 02:00	0.4	13.1	1,865.3	0.4	0.6	1	1	1
11/17/2019 03:00	0.6	13.9	1,526.2	0.6	0.5	1	1	0
11/17/2019 04:00	0.6	13.8	1,634.1	0.6	0.5	1	1	0
11/17/2019 05:00	0.6	13.9	1,497.3	0.6	0.4	1	1	0
11/17/2019 06:00	0.6	13.8	1,637.4	0.6	0.5	1	1	0
11/17/2019 07:00	0.6	13.8	1,593.7	0.6	0.5	1	1	0
11/17/2019 08:00	0.6	13.8	1,597.1	0.6	0.5	1	1	0
11/17/2019 09:00	0.6	13.9	1,604.2	0.6	0.5	1	1	0
11/17/2019 10:00	0.6	13.9	1,577.2	0.6	0.5	1	1	0
11/17/2019 11:00	0.6	13.9	1,629.2	0.6	0.5	1	1	0
11/17/2019 12:00	0.6	13.9	1,566.0	0.6	0.5	1	1	0
11/17/2019 13:00	0.6	13.9	1,609.8	0.6	0.5	1	1	0
11/17/2019 14:00	0.7	13.9	1,491.5	0.7	0.4	1	1	1
11/17/2019 15:00	0.2	12.7	1,939.7	0.4	0.6	1	1	1
11/17/2019 16:00	0.2	12.5	1,993.3	0.4	0.6	1	1	1
11/17/2019 17:00	0.2	12.5	1,985.2	0.4	0.6	1	1	1
11/17/2019 18:00	0.2	12.4	2,001.4	0.4	0.6	1	1	1
11/17/2019 19:00	0.2	12.4	2,023.4	0.4	0.6	1	1	1
11/17/2019 20:00	0.2	12.4	2,028.2	0.4	0.6	1	1	1
11/17/2019 21:00	0.2	12.4	2,030.2	0.4	0.6	1	1	1
11/17/2019 22:00	0.2	12.5	1,999.3	0.4	0.6	1	1	1
11/17/2019 23:00	0.2	12.7	1,985.5	0.4	0.6	1	1	1
Average/Sum#:	0.4	13.2	1,784.0	0.5	0.5	24 #	24 #	13 #
Minimum:	0.2	12.4	1,491.5	0.4	0.4	1	1	0
Maximum:	0.7	13.9	2,030.2	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/18/2019 00:00	0.4	12.6	1,991.3	0.5	0.6	1	1	1
11/18/2019 01:00	0.2	12.6	1,995.8	0.4	0.6	1	1	1
11/18/2019 02:00	0.4	12.6	1,996.8	0.5	0.6	1	1	1
11/18/2019 03:00	0.4	12.6	1,996.3	0.5	0.6	1	1	1
11/18/2019 04:00	0.2	12.7	1,987.6	0.4	0.6	1	1	1
11/18/2019 05:00	0.2	12.6	1,990.3	0.4	0.6	1	1	1
11/18/2019 06:00	0.4	12.3	2,049.0	0.5	0.6	1	1	1
11/18/2019 07:00	0.4	12.4	2,027.8	0.5	0.6	1	1	1
11/18/2019 08:00	0.4	12.7	1,982.5	0.5	0.6	1	1	1
11/18/2019 09:00	0.4	12.9	1,928.9	0.5	0.6	1	1	1
11/18/2019 10:00	0.2	12.5	2,005.4	0.4	0.6	1	1	1
11/18/2019 11:00	0.4	12.2	2,058.8	0.5	0.6	1	1	1
11/18/2019 12:00	0.2	12.3	2,019.8	0.4	0.6	1	1	1
11/18/2019 13:00	0.4	12.2	2,036.1	0.5	0.6	1	1	1
11/18/2019 14:00	0.4	12.3	2,022.9	0.5	0.6	1	1	1
11/18/2019 15:00	0.4	12.3	2,021.2	0.5	0.6	1	1	1
11/18/2019 16:00	0.4	12.1	2,066.6	0.5	0.6	1	1	1
11/18/2019 17:00	0.4	12.1	2,053.9	0.5	0.6	1	1	1
11/18/2019 18:00	0.5	12.0	2,095.8	0.5	0.6	1	1	1
11/18/2019 19:00	0.4	12.1	2,069.3	0.5	0.6	1	1	1
11/18/2019 20:00	0.4	12.1	2,065.0	0.5	0.6	1	1	1
11/18/2019 21:00	0.4	12.2	2,032.2	0.5	0.6	1	1	1
11/18/2019 22:00	0.4	12.3	2,031.7	0.5	0.6	1	1	1
11/18/2019 23:00	0.4	12.3	2,028.6	0.5	0.6	1	1	1
Average/Sum#:	0.4	12.4	2,023.1	0.5	0.6	24 #	24 #	24 #
Minimum:	0.2	12.0	1,928.9	0.4	0.6	1	1	1
Maximum:	0.5	12.9	2,095.8	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/19/2019 00:00	0.2	12.4	2,022.4	0.4	0.6	1	1	1
11/19/2019 01:00	0.2	12.5	1,986.1	0.4	0.6	1	1	1
11/19/2019 02:00	0.2	12.5	1,982.5	0.4	0.6	1	1	1
11/19/2019 03:00	0.2	12.6	1,980.0	0.4	0.6	1	1	1
11/19/2019 04:00	0.2	12.5	1,987.7	0.4	0.6	1	1	1
11/19/2019 05:00	0.4	12.5	2,000.9	0.5	0.6	1	1	1
11/19/2019 06:00	0.2	12.5	1,984.6	0.4	0.6	1	1	1
11/19/2019 07:00	0.4	12.4	2,002.8	0.5	0.6	1	1	1
11/19/2019 08:00	0.4	12.2	2,057.5	0.5	0.6	1	1	1
11/19/2019 09:00	0.4	12.3	2,031.5	0.5	0.6	1	1	1
11/19/2019 10:00	0.4	12.2	2,061.1	0.5	0.6	1	1	1
11/19/2019 11:00	0.4	12.3	2,033.7	0.5	0.6	1	1	1
11/19/2019 12:00	0.7	0.0	2,006.3	0.7	0.6	1	1	1
11/19/2019 13:00	0.7	0.0	1,995.5	0.7	0.6	1	1	1
11/19/2019 14:00	0.4	12.4	2,018.7	0.5	0.6	1	1	1
11/19/2019 15:00	0.2	12.5	1,988.2	0.4	0.6	1	1	1
11/19/2019 16:00	0.2	12.6	1,989.9	0.4	0.6	1	1	1
11/19/2019 17:00	0.4	12.1	2,081.8	0.5	0.6	1	1	1
11/19/2019 18:00	0.5	12.0	2,115.9	0.5	0.6	1	1	1
11/19/2019 19:00	0.4	12.4	2,031.5	0.5	0.6	1	1	1
11/19/2019 20:00	0.4	12.5	2,008.6	0.5	0.6	1	1	1
11/19/2019 21:00	0.4	12.5	2,023.9	0.5	0.6	1	1	1
11/19/2019 22:00	0.4	12.4	2,031.1	0.5	0.6	1	1	1
11/19/2019 23:00	0.4	12.4	2,036.0	0.5	0.6	1	1	1
Average/Sum#:	0.3	12.4	2,019.1	0.5	0.6	24 #	24 #	24 #
Minimum:	0.2	12.0	1,980.0	0.4	0.6	1	1	1
Maximum:	0.5	12.6	2,115.9	0.5	0.6	1	1	1
%SI	8.33	8.33	0.00	8.33	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/20/2019 00:00	0.2	12.5	2,007.7	0.4	0.6	1	1	1
11/20/2019 01:00	0.2	12.6	1,990.5	0.4	0.6	1	1	1
11/20/2019 02:00	0.2	12.7	1,970.0	0.4	0.6	1	1	1
11/20/2019 03:00	0.2	12.7	1,974.5	0.4	0.6	1	1	1
11/20/2019 04:00	0.2	12.7	1,991.9	0.4	0.6	1	1	1
11/20/2019 05:00	0.2	12.7	1,997.6	0.4	0.6	1	1	1
11/20/2019 06:00	0.4	12.3	2,049.5	0.5	0.6	1	1	1
11/20/2019 07:00	0.4	12.3	2,070.6	0.5	0.6	1	1	1
11/20/2019 08:00	0.7	0.0	2,059.3	0.7	0.6	1	1	1
11/20/2019 09:00	0.7	0.0	2,067.0	0.7	0.6	1	1	1
11/20/2019 10:00	0.7	0.0	2,064.4	0.7	0.6	1	1	1
11/20/2019 11:00	0.7	0.0	2,026.1	0.7	0.6	1	1	1
11/20/2019 12:00	0.7	0.0	2,027.0	0.7	0.6	1	1	1
11/20/2019 13:00	0.7	12.2	2,033.4	0.7	0.6	1	1	1
11/20/2019 14:00	0.7	12.2	2,049.6	0.7	0.6	1	1	1
11/20/2019 15:00	0.7	12.0	2,077.1	0.7	0.6	1	1	1
11/20/2019 16:00	0.7	12.3	2,016.6	0.7	0.6	1	1	1
11/20/2019 17:00	0.7	11.9	2,081.5	0.7	0.6	1	1	1
11/20/2019 18:00	0.7	11.9	2,091.6	0.7	0.6	1	1	1
11/20/2019 19:00	0.7	11.9	2,098.5	0.7	0.6	1	1	1
11/20/2019 20:00	0.7	12.0	2,068.0	0.7	0.6	1	1	1
11/20/2019 21:00	0.7	12.1	2,048.2	0.7	0.6	1	1	1
11/20/2019 22:00	0.7	12.3	2,013.9	0.7	0.6	1	1	1
11/20/2019 23:00	0.7	12.4	2,000.4	0.7	0.6	1	1	1
Average/Sum#:	0.5	12.3	2,036.5	0.6	0.6	24 #	24 #	24 #
Minimum:	0.2	11.9	1,970.0	0.4	0.6	1	1	1
Maximum:	0.7	12.7	2,098.5	0.7	0.6	1	1	1
%SI	20.83	20.83	0.00	20.83	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/21/2019 00:00	0.7	12.2	2,026.6	0.7	0.6	1	1	1
11/21/2019 01:00	0.7	12.2	2,032.3	0.7	0.6	1	1	1
11/21/2019 02:00	0.7	12.3	2,020.5	0.7	0.6	1	1	1
11/21/2019 03:00	0.7	12.2	2,058.3	0.7	0.6	1	1	1
11/21/2019 04:00	0.7	12.1	2,076.7	0.7	0.6	1	1	1
11/21/2019 05:00	0.7	12.1	2,079.8	0.7	0.6	1	1	1
11/21/2019 06:00	0.7	11.9	2,125.4	0.7	0.6	1	1	1
11/21/2019 07:00	0.7	11.9	2,131.4	0.7	0.6	1	1	1
11/21/2019 08:00	0.7	12.2	2,067.9	0.7	0.6	1	1	1
11/21/2019 09:00	0.7	12.5	1,989.9	0.7	0.6	1	1	1
11/21/2019 10:00	0.7	12.4	2,021.5	0.7	0.6	1	1	1
11/21/2019 11:00	0.7	12.5	1,982.4	0.7	0.6	1	1	1
11/21/2019 12:00	0.7	12.3	2,016.8	0.7	0.6	1	1	1
11/21/2019 13:00	0.7	12.4	2,000.7	0.7	0.6	1	1	1
11/21/2019 14:00	0.7	12.5	1,986.6	0.7	0.6	1	1	1
11/21/2019 15:00	0.7	12.4	2,010.6	0.7	0.6	1	1	1
11/21/2019 16:00	0.7	12.0	2,089.2	0.7	0.6	1	1	1
11/21/2019 17:00	0.7	11.9	2,118.6	0.7	0.6	1	1	1
11/21/2019 18:00	0.7	11.8	2,138.0	0.7	0.6	1	1	1
11/21/2019 19:00	0.7	11.8	2,136.3	0.7	0.6	1	1	1
11/21/2019 20:00	0.7	11.8	2,131.9	0.7	0.6	1	1	1
11/21/2019 21:00	0.7	11.9	2,130.6	0.7	0.6	1	1	1
11/21/2019 22:00	0.7	12.0	2,107.5	0.7	0.6	1	1	1
11/21/2019 23:00	0.7	12.1	2,075.7	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.1	2,064.8	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	11.8	1,982.4	0.7	0.6	1	1	1
Maximum:	0.7	12.5	2,138.0	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/22/2019 00:00	0.7	12.3	2,050.2	0.7	0.6	1	1	1
11/22/2019 01:00	0.7	12.3	2,047.5	0.7	0.6	1	1	1
11/22/2019 02:00	0.7	12.3	2,048.9	0.7	0.6	1	1	1
11/22/2019 03:00	0.7	12.3	2,045.4	0.7	0.6	1	1	1
11/22/2019 04:00	0.7	12.5	2,000.2	0.7	0.6	1	1	1
11/22/2019 05:00	0.7	12.6	1,978.8	0.7	0.6	1	1	1
11/22/2019 06:00	0.7	11.8	2,159.2	0.7	0.6	1	1	1
11/22/2019 07:00	0.7	11.9	2,140.6	0.7	0.6	1	1	1
11/22/2019 08:00	0.7	12.5	1,994.4	0.7	0.6	1	1	1
11/22/2019 09:00	0.7	12.7	1,969.3	0.7	0.6	1	1	1
11/22/2019 10:00	0.7	12.6	1,991.1	0.7	0.6	1	1	1
11/22/2019 11:00	0.7	12.6	1,967.4	0.7	0.6	1	1	1
11/22/2019 12:00	0.7	12.5	1,982.7	0.7	0.6	1	1	1
11/22/2019 13:00	0.7	12.5	1,976.9	0.7	0.6	1	1	1
11/22/2019 14:00	0.7	12.4	1,999.3	0.7	0.6	1	1	1
11/22/2019 15:00	0.7	12.4	2,002.4	0.7	0.6	1	1	1
11/22/2019 16:00	0.7	11.9	2,122.3	0.7	0.6	1	1	1
11/22/2019 17:00	0.7	11.9	2,121.6	0.7	0.6	1	1	1
11/22/2019 18:00	0.7	11.8	2,152.0	0.7	0.6	1	1	1
11/22/2019 19:00	0.7	11.9	2,123.5	0.7	0.6	1	1	1
11/22/2019 20:00	0.7	12.0	2,092.1	0.7	0.6	1	1	1
11/22/2019 21:00	0.7	11.9	2,111.6	0.7	0.6	1	1	1
11/22/2019 22:00	0.7	12.1	2,079.6	0.7	0.6	1	1	1
11/22/2019 23:00	0.7	12.3	2,042.0	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.3	2,050.0	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	11.8	1,967.4	0.7	0.6	1	1	1
Maximum:	0.7	12.7	2,159.2	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/23/2019 00:00	0.7	12.3	2,034.6	0.7	0.6	1	1	1
11/23/2019 01:00	0.7	12.2	2,054.2	0.7	0.6	1	1	1
11/23/2019 02:00	0.7	12.4	2,044.4	0.7	0.6	1	1	1
11/23/2019 03:00	0.7	12.5	2,008.2	0.7	0.6	1	1	1
11/23/2019 04:00	0.7	12.3	2,054.0	0.7	0.6	1	1	1
11/23/2019 05:00	0.7	12.2	2,064.0	0.7	0.6	1	1	1
11/23/2019 06:00	0.7	12.1	2,074.8	0.7	0.6	1	1	1
11/23/2019 07:00	0.7	12.3	2,035.1	0.7	0.6	1	1	1
11/23/2019 08:00	0.7	12.9	1,872.3	0.7	0.6	1	1	1
11/23/2019 09:00	0.6	13.7	1,622.6	0.6	0.5	1	1	0
11/23/2019 10:00	0.6	13.7	1,643.2	0.6	0.5	1	1	0
11/23/2019 11:00	0.6	13.7	1,609.5	0.6	0.5	1	1	0
11/23/2019 12:00	0.6	13.7	1,625.7	0.6	0.5	1	1	0
11/23/2019 13:00	0.6	13.7	1,643.6	0.6	0.5	1	1	0
11/23/2019 14:00	0.6	13.7	1,615.4	0.6	0.5	1	1	0
11/23/2019 15:00	0.7	13.2	1,783.2	0.7	0.5	1	1	1
11/23/2019 16:00	0.7	12.2	2,049.5	0.7	0.6	1	1	1
11/23/2019 17:00	0.7	12.1	2,076.9	0.7	0.6	1	1	1
11/23/2019 18:00	0.7	12.1	2,074.6	0.7	0.6	1	1	1
11/23/2019 19:00	0.7	11.9	2,119.4	0.7	0.6	1	1	1
11/23/2019 20:00	0.7	12.0	2,112.1	0.7	0.6	1	1	1
11/23/2019 21:00	0.7	12.3	2,062.6	0.7	0.6	1	1	1
11/23/2019 22:00	0.7	12.4	2,027.2	0.7	0.6	1	1	1
11/23/2019 23:00	0.7	12.5	1,983.9	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.7	1,928.8	0.7	0.6	24 #	24 #	18 #
Minimum:	0.6	11.9	1,609.5	0.6	0.5	1	1	0
Maximum:	0.7	13.7	2,119.4	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/24/2019 00:00	0.7	12.5	1,978.6	0.7	0.6	1	1	1
11/24/2019 01:00	0.7	12.5	1,977.4	0.7	0.6	1	1	1
11/24/2019 02:00	0.7	12.7	1,962.7	0.7	0.6	1	1	1
11/24/2019 03:00	0.7	12.7	1,963.0	0.7	0.6	1	1	1
11/24/2019 04:00	0.7	12.7	1,975.2	0.7	0.6	1	1	1
11/24/2019 05:00	0.7	12.7	1,972.3	0.7	0.6	1	1	1
11/24/2019 06:00	0.7	12.4	2,031.0	0.7	0.6	1	1	1
11/24/2019 07:00	0.7	12.5	1,974.0	0.7	0.6	1	1	1
11/24/2019 08:00	0.6	13.7	1,608.6	0.6	0.5	1	1	0
11/24/2019 09:00	0.6	13.7	1,601.0	0.6	0.5	1	1	0
11/24/2019 10:00	0.6	13.7	1,629.0	0.6	0.5	1	1	0
11/24/2019 11:00	0.6	13.7	1,622.2	0.6	0.5	1	1	0
11/24/2019 12:00	0.6	13.7	1,652.1	0.6	0.5	1	1	0
11/24/2019 13:00	0.6	13.7	1,633.4	0.6	0.5	1	1	0
11/24/2019 14:00	0.6	13.7	1,589.8	0.6	0.5	1	1	0
11/24/2019 15:00	0.7	13.2	1,784.6	0.7	0.5	1	1	1
11/24/2019 16:00	0.7	12.4	2,001.2	0.7	0.6	1	1	1
11/24/2019 17:00	0.7	12.2	2,057.6	0.7	0.6	1	1	1
11/24/2019 18:00	0.7	12.5	1,975.5	0.7	0.6	1	1	1
11/24/2019 19:00	0.7	12.8	1,927.3	0.7	0.6	1	1	1
11/24/2019 20:00	0.7	12.5	1,977.5	0.7	0.6	1	1	1
11/24/2019 21:00	0.7	12.3	2,021.5	0.7	0.6	1	1	1
11/24/2019 22:00	0.7	12.6	1,963.1	0.7	0.6	1	1	1
11/24/2019 23:00	0.7	13.2	1,764.4	0.7	0.5	1	1	1
Average/Sum#:	0.7	12.9	1,860.1	0.7	0.6	24 #	24 #	17 #
Minimum:	0.6	12.2	1,589.8	0.6	0.5	1	1	0
Maximum:	0.7	13.7	2,057.6	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/25/2019 00:00	0.6	13.7	1,304.8	0.6	0.4	1	1	0
11/25/2019 01:00	0.6	13.7	1,485.0	0.6	0.4	1	1	0
11/25/2019 02:00	0.6	13.7	1,316.9	0.6	0.4	1	1	0
11/25/2019 03:00	0.6	13.7	1,357.5	0.6	0.4	1	1	0
11/25/2019 04:00	0.6	13.6	1,649.2	0.6	0.5	1	1	0
11/25/2019 05:00	0.6	13.7	1,498.7	0.6	0.4	1	1	0
11/25/2019 06:00	0.6	13.7	1,335.5	0.6	0.4	1	1	0
11/25/2019 07:00	0.6	13.7	1,573.6	0.6	0.5	1	1	0
11/25/2019 08:00	0.6	13.7	1,619.0	0.6	0.5	1	1	0
11/25/2019 09:00	0.6	13.7	1,583.5	0.6	0.5	1	1	0
11/25/2019 10:00	0.6	13.7	1,606.2	0.6	0.5	1	1	0
11/25/2019 11:00	0.6	13.7	1,648.6	0.6	0.5	1	1	0
11/25/2019 12:00	0.6	13.7	1,639.2	0.6	0.5	1	1	0
11/25/2019 13:00	0.6	13.7	1,632.2	0.6	0.5	1	1	0
11/25/2019 14:00	0.6	13.7	1,624.4	0.6	0.5	1	1	0
11/25/2019 15:00	0.7	13.7	1,542.8	0.7	0.5	1	1	1
11/25/2019 16:00	0.7	12.6	1,979.9	0.7	0.6	1	1	1
11/25/2019 17:00	0.7	12.0	2,097.6	0.7	0.6	1	1	1
11/25/2019 18:00	0.7	12.4	2,016.7	0.7	0.6	1	1	1
11/25/2019 19:00	0.7	12.2	2,065.7	0.7	0.6	1	1	1
11/25/2019 20:00	0.7	12.2	2,069.5	0.7	0.6	1	1	1
11/25/2019 21:00	0.7	12.3	2,038.6	0.7	0.6	1	1	1
11/25/2019 22:00	0.7	12.5	2,008.3	0.7	0.6	1	1	1
11/25/2019 23:00	0.7	12.6	1,990.0	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.2	1,695.1	0.6	0.5	24 #	24 #	9 #
Minimum:	0.6	12.0	1,304.8	0.6	0.4	1	1	0
Maximum:	0.7	13.7	2,097.6	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/26/2019 00:00	0.7	12.5	2,016.3	0.7	0.6	1	1	1
11/26/2019 01:00	0.7	12.4	2,036.2	0.7	0.6	1	1	1
11/26/2019 02:00	0.7	12.6	1,973.0	0.7	0.6	1	1	1
11/26/2019 03:00	0.7	12.6	1,971.7	0.7	0.6	1	1	1
11/26/2019 04:00	0.7	12.7	1,958.4	0.7	0.6	1	1	1
11/26/2019 05:00	0.7	12.9	1,909.7	0.7	0.6	1	1	1
11/26/2019 06:00	0.7	12.1	2,082.1	0.7	0.6	1	1	1
11/26/2019 07:00	0.7	12.7	1,878.7	0.7	0.6	1	1	1
11/26/2019 08:00	0.6	13.7	1,611.2	0.6	0.5	1	1	0
11/26/2019 09:00	0.6	13.7	1,636.2	0.6	0.5	1	1	0
11/26/2019 10:00	0.6	13.7	1,517.9	0.6	0.5	1	1	0
11/26/2019 11:00	0.6	13.7	1,574.2	0.6	0.5	1	1	0
11/26/2019 12:00	0.6	13.7	1,548.6	0.6	0.5	1	1	0
11/26/2019 13:00	0.6	13.6	1,583.8	0.6	0.5	1	1	0
11/26/2019 14:00	0.7	13.5	1,735.5	0.7	0.5	1	1	1
11/26/2019 15:00	0.6	13.5	1,761.0	0.6	0.5	1	1	0
11/26/2019 16:00	0.7	12.9	1,869.1	0.7	0.6	1	1	1
11/26/2019 17:00	0.7	12.3	2,024.0	0.7	0.6	1	1	1
11/26/2019 18:00	0.7	12.4	1,997.1	0.7	0.6	1	1	1
11/26/2019 19:00	0.7	12.4	2,012.3	0.7	0.6	1	1	1
11/26/2019 20:00	0.7	12.2	2,046.0	0.7	0.6	1	1	1
11/26/2019 21:00	0.7	12.2	2,018.5	0.7	0.6	1	1	1
11/26/2019 22:00	0.7	12.3	2,001.7	0.7	0.6	1	1	1
11/26/2019 23:00	0.7	12.3	2,011.4	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.9	1,865.6	0.7	0.6	24 #	24 #	17 #
Minimum:	0.6	12.1	1,517.9	0.6	0.5	1	1	0
Maximum:	0.7	13.7	2,082.1	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/27/2019 00:00	0.7	12.2	2,019.8	0.7	0.6	1	1	1
11/27/2019 01:00	0.7	12.3	1,996.2	0.7	0.6	1	1	1
11/27/2019 02:00	0.7	12.5	1,962.6	0.7	0.6	1	1	1
11/27/2019 03:00	0.7	12.5	1,960.1	0.7	0.6	1	1	1
11/27/2019 04:00	0.7	12.5	1,969.8	0.7	0.6	1	1	1
11/27/2019 05:00	0.7	12.4	1,978.9	0.7	0.6	1	1	1
11/27/2019 06:00	0.7	12.7	1,933.2	0.7	0.6	1	1	1
11/27/2019 07:00	0.7	12.1	2,066.8	0.7	0.6	1	1	1
11/27/2019 08:00	0.7	12.1	2,059.9	0.7	0.6	1	1	1
11/27/2019 09:00	0.7	12.1	2,043.2	0.7	0.6	1	1	1
11/27/2019 10:00	0.7	12.2	2,030.0	0.7	0.6	1	1	1
11/27/2019 11:00	0.7	12.4	1,986.9	0.7	0.6	1	1	1
11/27/2019 12:00	0.7	12.2	2,011.8	0.7	0.6	1	1	1
11/27/2019 13:00	0.7	12.0	2,059.1	0.7	0.6	1	1	1
11/27/2019 14:00	0.7	12.0	2,050.1	0.7	0.6	1	1	1
11/27/2019 15:00	0.7	12.3	1,992.0	0.7	0.6	1	1	1
11/27/2019 16:00	0.7	12.5	1,963.7	0.7	0.6	1	1	1
11/27/2019 17:00	0.7	12.1	2,048.8	0.7	0.6	1	1	1
11/27/2019 18:00	0.7	12.8	1,901.0	0.7	0.6	1	1	1
11/27/2019 19:00	0.7	12.8	1,914.8	0.7	0.6	1	1	1
11/27/2019 20:00	0.7	12.1	2,084.1	0.7	0.6	1	1	1
11/27/2019 21:00	0.7	12.0	2,104.0	0.7	0.6	1	1	1
11/27/2019 22:00	0.7	12.2	2,053.0	0.7	0.6	1	1	1
11/27/2019 23:00	0.7	12.3	2,036.5	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.3	2,009.4	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	12.0	1,901.0	0.7	0.6	1	1	1
Maximum:	0.7	12.8	2,104.0	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/28/2019 00:00	0.7	12.3	2,038.9	0.7	0.6	1	1	1
11/28/2019 01:00	0.7	12.4	2,022.1	0.7	0.6	1	1	1
11/28/2019 02:00	0.7	12.5	2,008.9	0.7	0.6	1	1	1
11/28/2019 03:00	0.7	12.3	2,039.7	0.7	0.6	1	1	1
11/28/2019 04:00	0.7	12.5	2,012.2	0.7	0.6	1	1	1
11/28/2019 05:00	0.7	12.7	1,937.8	0.7	0.6	1	1	1
11/28/2019 06:00	0.7	12.1	2,050.0	0.7	0.6	1	1	1
11/28/2019 07:00	0.7	12.2	2,052.7	0.7	0.6	1	1	1
11/28/2019 08:00	0.7	12.2	2,052.8	0.7	0.6	1	1	1
11/28/2019 09:00	0.7	12.2	2,039.9	0.7	0.6	1	1	1
11/28/2019 10:00	0.7	12.2	2,040.4	0.7	0.6	1	1	1
11/28/2019 11:00	0.7	12.2	2,042.1	0.7	0.6	1	1	1
11/28/2019 12:00	0.7	12.2	2,038.5	0.7	0.6	1	1	1
11/28/2019 13:00	0.7	12.2	2,027.9	0.7	0.6	1	1	1
11/28/2019 14:00	0.7	12.2	2,021.9	0.7	0.6	1	1	1
11/28/2019 15:00	0.7	12.2	2,027.9	0.7	0.6	1	1	1
11/28/2019 16:00	0.7	12.3	2,012.3	0.7	0.6	1	1	1
11/28/2019 17:00	0.7	12.3	2,012.4	0.7	0.6	1	1	1
11/28/2019 18:00	0.7	12.6	1,953.4	0.7	0.6	1	1	1
11/28/2019 19:00	0.7	12.3	2,006.6	0.7	0.6	1	1	1
11/28/2019 20:00	0.7	12.2	2,021.1	0.7	0.6	1	1	1
11/28/2019 21:00	0.7	12.3	2,021.6	0.7	0.6	1	1	1
11/28/2019 22:00	0.7	12.2	2,018.6	0.7	0.6	1	1	1
11/28/2019 23:00	0.7	12.2	2,030.4	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.3	2,022.1	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	12.1	1,937.8	0.7	0.6	1	1	1
Maximum:	0.7	12.7	2,052.8	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/29/2019 00:00	0.7	12.2	2,032.4	0.7	0.6	1	1	1
11/29/2019 01:00	0.7	12.3	2,020.3	0.7	0.6	1	1	1
11/29/2019 02:00	0.7	12.3	2,023.9	0.7	0.6	1	1	1
11/29/2019 03:00	0.7	12.3	2,019.4	0.7	0.6	1	1	1
11/29/2019 04:00	0.7	12.3	2,031.1	0.7	0.6	1	1	1
11/29/2019 05:00	0.7	12.4	2,013.8	0.7	0.6	1	1	1
11/29/2019 06:00	0.7	12.2	2,041.3	0.7	0.6	1	1	1
11/29/2019 07:00	0.7	12.4	1,963.0	0.7	0.6	1	1	1
11/29/2019 08:00	0.6	13.7	1,524.6	0.6	0.5	1	1	0
11/29/2019 09:00	0.6	13.7	1,406.3	0.6	0.4	1	1	0
11/29/2019 10:00	0.6	13.6	1,561.0	0.6	0.5	1	1	0
11/29/2019 11:00	0.6	13.6	1,564.8	0.6	0.5	1	1	0
11/29/2019 12:00	0.6	13.7	1,519.7	0.6	0.5	1	1	0
11/29/2019 13:00	0.6	13.7	1,517.4	0.6	0.5	1	1	0
11/29/2019 14:00	0.6	13.7	1,427.4	0.6	0.4	1	1	0
11/29/2019 15:00	0.7	13.6	1,546.9	0.7	0.5	1	1	1
11/29/2019 16:00	0.7	12.7	1,962.0	0.7	0.6	1	1	1
11/29/2019 17:00	0.7	12.0	2,122.2	0.7	0.6	1	1	1
11/29/2019 18:00	0.7	11.9	2,130.1	0.7	0.6	1	1	1
11/29/2019 19:00	0.7	12.0	2,114.4	0.7	0.6	1	1	1
11/29/2019 20:00	0.7	12.0	2,121.2	0.7	0.6	1	1	1
11/29/2019 21:00	0.7	12.3	2,040.7	0.7	0.6	1	1	1
11/29/2019 22:00	0.7	12.4	2,052.1	0.7	0.6	1	1	1
11/29/2019 23:00	0.7	12.4	2,046.1	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.7	1,866.8	0.7	0.6	24 #	24 #	17 #
Minimum:	0.6	11.9	1,406.3	0.6	0.4	1	1	0
Maximum:	0.7	13.7	2,130.1	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/30/2019 00:00	0.7	12.4	2,040.5	0.7	0.6	1	1	1
11/30/2019 01:00	0.7	12.5	2,036.7	0.7	0.6	1	1	1
11/30/2019 02:00	0.7	12.4	2,046.9	0.7	0.6	1	1	1
11/30/2019 03:00	0.7	12.4	2,047.2	0.7	0.6	1	1	1
11/30/2019 04:00	0.7	12.4	2,035.1	0.7	0.6	1	1	1
11/30/2019 05:00	0.7	12.5	2,017.7	0.7	0.6	1	1	1
11/30/2019 06:00	0.7	12.4	2,048.1	0.7	0.6	1	1	1
11/30/2019 07:00	0.7	12.5	2,021.9	0.7	0.6	1	1	1
11/30/2019 08:00	0.7	12.4	2,040.7	0.7	0.6	1	1	1
11/30/2019 09:00	0.7	12.3	2,058.6	0.7	0.6	1	1	1
11/30/2019 10:00	0.7	12.4	2,034.8	0.7	0.6	1	1	1
11/30/2019 11:00	0.7	12.6	1,990.1	0.7	0.6	1	1	1
11/30/2019 12:00	0.7	12.3	2,048.5	0.7	0.6	1	1	1
11/30/2019 13:00	0.7	12.3	2,045.1	0.7	0.6	1	1	1
11/30/2019 14:00	0.7	12.3	2,046.3	0.7	0.6	1	1	1
11/30/2019 15:00	0.7	12.4	2,030.8	0.7	0.6	1	1	1
11/30/2019 16:00	0.7	12.4	2,029.2	0.7	0.6	1	1	1
11/30/2019 17:00	0.7	12.4	2,041.8	0.7	0.6	1	1	1
11/30/2019 18:00	0.7	12.5	2,019.4	0.7	0.6	1	1	1
11/30/2019 19:00	0.7	12.2	2,080.7	0.7	0.6	1	1	1
11/30/2019 20:00	0.7	12.3	2,049.5	0.7	0.6	1	1	1
11/30/2019 21:00	0.7	12.4	2,031.5	0.7	0.6	1	1	1
11/30/2019 22:00	0.7	12.6	1,992.3	0.7	0.6	1	1	1
11/30/2019 23:00	0.7	12.7	1,977.5	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.4	2,033.8	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	12.2	1,977.5	0.7	0.6	1	1	1
Maximum:	0.7	12.7	2,080.7	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/01/2019 00:00	0.7	12.5	2,016.3	0.7	0.6	1	1	1
12/01/2019 01:00	0.7	12.7	1,976.4	0.7	0.6	1	1	1
12/01/2019 02:00	0.7	12.7	1,975.5	0.7	0.6	1	1	1
12/01/2019 03:00	0.7	12.7	1,975.5	0.7	0.6	1	1	1
12/01/2019 04:00	0.7	12.7	1,972.0	0.7	0.6	1	1	1
12/01/2019 05:00	0.7	12.7	1,972.7	0.7	0.6	1	1	1
12/01/2019 06:00	0.7	12.7	1,966.1	0.7	0.6	1	1	1
12/01/2019 07:00	0.7	12.7	1,972.7	0.7	0.6	1	1	1
12/01/2019 08:00	0.7	12.4	2,047.7	0.7	0.6	1	1	1
12/01/2019 09:00	0.7	12.4	2,045.3	0.7	0.6	1	1	1
12/01/2019 10:00	0.7	12.3	2,051.7	0.7	0.6	1	1	1
12/01/2019 11:00	0.7	12.4	2,035.6	0.7	0.6	1	1	1
12/01/2019 12:00	0.7	12.6	1,974.9	0.7	0.6	1	1	1
12/01/2019 13:00	0.7	12.5	1,995.0	0.7	0.6	1	1	1
12/01/2019 14:00	0.7	12.6	1,985.4	0.7	0.6	1	1	1
12/01/2019 15:00	0.7	12.5	1,993.2	0.7	0.6	1	1	1
12/01/2019 16:00	0.7	12.5	1,994.8	0.7	0.6	1	1	1
12/01/2019 17:00	0.7	12.3	2,038.8	0.7	0.6	1	1	1
12/01/2019 18:00	0.7	12.1	2,083.3	0.7	0.6	1	1	1
12/01/2019 19:00	0.7	12.0	2,107.4	0.7	0.6	1	1	1
12/01/2019 20:00	0.7	12.1	2,074.2	0.7	0.6	1	1	1
12/01/2019 21:00	0.7	12.4	2,015.4	0.7	0.6	1	1	1
12/01/2019 22:00	0.7	12.5	1,989.9	0.7	0.6	1	1	1
12/01/2019 23:00	0.7	12.5	1,983.1	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.5	2,010.1	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	12.0	1,966.1	0.7	0.6	1	1	1
Maximum:	0.7	12.7	2,107.4	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/02/2019 00:00	0.7	12.6	1,970.3	0.7	0.6	1	1	1
12/02/2019 01:00	0.7	12.6	1,972.6	0.7	0.6	1	1	1
12/02/2019 02:00	0.7	12.6	1,973.4	0.7	0.6	1	1	1
12/02/2019 03:00	0.7	12.6	1,969.1	0.7	0.6	1	1	1
12/02/2019 04:00	0.7	12.6	1,965.0	0.7	0.6	1	1	1
12/02/2019 05:00	0.7	12.6	1,968.2	0.7	0.6	1	1	1
12/02/2019 06:00	0.7	12.0	2,062.3	0.7	0.6	1	1	1
12/02/2019 07:00	0.7	11.9	2,110.4	0.7	0.6	1	1	1
12/02/2019 08:00	0.7	12.4	2,004.4	0.7	0.6	1	1	1
12/02/2019 09:00	0.7	12.6	1,968.2	0.7	0.6	1	1	1
12/02/2019 10:00	0.7	12.5	1,987.2	0.7	0.6	1	1	1
12/02/2019 11:00	0.7	12.5	1,981.7	0.7	0.6	1	1	1
12/02/2019 12:00	0.7	12.3	2,038.9	0.7	0.6	1	1	1
12/02/2019 13:00	0.7	12.4	2,003.8	0.7	0.6	1	1	1
12/02/2019 14:00	0.7	12.2	2,048.6	0.7	0.6	1	1	1
12/02/2019 15:00	0.7	12.2	2,033.3	0.7	0.6	1	1	1
12/02/2019 16:00	0.7	12.0	2,076.7	0.7	0.6	1	1	1
12/02/2019 17:00	0.7	11.9	2,116.6	0.7	0.6	1	1	1
12/02/2019 18:00	0.7	11.8	2,122.2	0.7	0.6	1	1	1
12/02/2019 19:00	0.7	11.8	2,122.9	0.7	0.6	1	1	1
12/02/2019 20:00	0.7	11.8	2,121.1	0.7	0.6	1	1	1
12/02/2019 21:00	0.7	11.9	2,104.6	0.7	0.6	1	1	1
12/02/2019 22:00	0.7	12.3	2,029.3	0.7	0.6	1	1	1
12/02/2019 23:00	0.7	12.3	2,018.3	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.3	2,032.0	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	11.8	1,965.0	0.7	0.6	1	1	1
Maximum:	0.7	12.6	2,122.9	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/03/2019 00:00	0.7	12.3	2,025.1	0.7	0.6	1	1	1
12/03/2019 01:00	0.7	12.5	1,981.0	0.7	0.6	1	1	1
12/03/2019 02:00	0.7	12.5	1,975.1	0.7	0.6	1	1	1
12/03/2019 03:00	0.7	12.4	1,980.6	0.7	0.6	1	1	1
12/03/2019 04:00	0.7	12.3	2,001.9	0.7	0.6	1	1	1
12/03/2019 05:00	0.7	12.3	2,009.2	0.7	0.6	1	1	1
12/03/2019 06:00	0.7	12.1	2,033.8	0.7	0.6	1	1	1
12/03/2019 07:00	0.7	12.0	2,076.0	0.7	0.6	1	1	1
12/03/2019 08:00	0.7	12.0	2,068.1	0.7	0.6	1	1	1
12/03/2019 09:00	0.7	12.1	2,040.2	0.7	0.6	1	1	1
12/03/2019 10:00	0.7	12.3	1,993.7	0.7	0.6	1	1	1
12/03/2019 11:00	0.7	12.0	2,042.8	0.7	0.6	1	1	1
12/03/2019 12:00	0.7	11.9	2,069.1	0.7	0.6	1	1	1
12/03/2019 13:00	0.7	11.8	2,084.2	0.7	0.6	1	1	1
12/03/2019 14:00	0.7	11.8	2,079.5	0.7	0.6	1	1	1
12/03/2019 15:00	0.7	11.8	2,071.4	0.7	0.6	1	1	1
12/03/2019 16:00	0.7	12.0	2,050.1	0.7	0.6	1	1	1
12/03/2019 17:00	0.7	11.9	2,070.8	0.7	0.6	1	1	1
12/03/2019 18:00	0.7	12.0	2,067.0	0.7	0.6	1	1	1
12/03/2019 19:00	0.7	11.8	2,100.9	0.7	0.6	1	1	1
12/03/2019 20:00	0.7	11.8	2,093.2	0.7	0.6	1	1	1
12/03/2019 21:00	0.7	11.9	2,084.5	0.7	0.6	1	1	1
12/03/2019 22:00	0.7	12.1	2,037.3	0.7	0.6	1	1	1
12/03/2019 23:00	0.7	12.2	2,021.2	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.1	2,044.0	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	11.8	1,975.1	0.7	0.6	1	1	1
Maximum:	0.7	12.5	2,100.9	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/04/2019 00:00	0.7	12.1	2,057.8	0.7	0.6	1	1	1
12/04/2019 01:00	0.7	12.2	2,039.3	0.7	0.6	1	1	1
12/04/2019 02:00	0.7	12.3	1,998.7	0.7	0.6	1	1	1
12/04/2019 03:00	0.7	12.3	2,007.1	0.7	0.6	1	1	1
12/04/2019 04:00	0.7	12.2	2,038.2	0.7	0.6	1	1	1
12/04/2019 05:00	0.7	12.4	1,991.7	0.7	0.6	1	1	1
12/04/2019 06:00	0.7	12.1	2,037.3	0.7	0.6	1	1	1
12/04/2019 07:00	0.7	12.0	2,079.0	0.7	0.6	1	1	1
12/04/2019 08:00	0.7	12.0	2,072.6	0.7	0.6	1	1	1
12/04/2019 09:00	0.7	12.0	2,075.4	0.7	0.6	1	1	1
12/04/2019 10:00	0.7	12.1	2,062.2	0.7	0.6	1	1	1
12/04/2019 11:00	0.7	11.9	2,095.5	0.7	0.6	1	1	1
12/04/2019 12:00	0.7	12.0	2,068.7	0.7	0.6	1	1	1
12/04/2019 13:00	0.7	12.1	2,043.9	0.7	0.6	1	1	1
12/04/2019 14:00	0.7	11.9	2,098.0	0.7	0.6	1	1	1
12/04/2019 15:00	0.7	12.0	2,070.8	0.7	0.6	1	1	1
12/04/2019 16:00	0.7	12.0	2,069.7	0.7	0.6	1	1	1
12/04/2019 17:00	0.7	12.1	2,049.6	0.7	0.6	1	1	1
12/04/2019 18:00	0.7	11.9	2,103.9	0.7	0.6	1	1	1
12/04/2019 19:00	0.7	11.9	2,102.3	0.7	0.6	1	1	1
12/04/2019 20:00	0.7	11.8	2,105.4	0.7	0.6	1	1	1
12/04/2019 21:00	0.7	11.9	2,096.4	0.7	0.6	1	1	1
12/04/2019 22:00	0.7	12.0	2,070.4	0.7	0.6	1	1	1
12/04/2019 23:00	0.7	12.2	2,034.4	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.1	2,061.2	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	11.8	1,991.7	0.7	0.6	1	1	1
Maximum:	0.7	12.4	2,105.4	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/05/2019 00:00	0.7	12.1	2,047.9	0.7	0.6	1	1	1
12/05/2019 01:00	0.7	12.1	2,050.8	0.7	0.6	1	1	1
12/05/2019 02:00	0.7	12.2	2,046.3	0.7	0.6	1	1	1
12/05/2019 03:00	0.7	12.2	2,046.8	0.7	0.6	1	1	1
12/05/2019 04:00	0.7	12.3	2,019.9	0.7	0.6	1	1	1
12/05/2019 05:00	0.7	12.3	2,009.1	0.7	0.6	1	1	1
12/05/2019 06:00	0.7	12.2	2,039.4	0.7	0.6	1	1	1
12/05/2019 07:00	0.7	12.3	2,014.0	0.7	0.6	1	1	1
12/05/2019 08:00	0.7	12.5	1,968.7	0.7	0.6	1	1	1
12/05/2019 09:00	0.7	12.4	1,980.4	0.7	0.6	1	1	1
12/05/2019 10:00	0.7	12.4	2,032.8	0.7	0.6	1	1	1
12/05/2019 11:00	0.7	12.4	2,037.0	0.7	0.6	1	1	1
12/05/2019 12:00	0.7	12.4	2,047.7	0.7	0.6	1	1	1
12/05/2019 13:00	0.7	12.4	2,044.3	0.7	0.6	1	1	1
12/05/2019 14:00	0.7	12.4	2,038.3	0.7	0.6	1	1	1
12/05/2019 15:00	0.7	12.4	2,040.1	0.7	0.6	1	1	1
12/05/2019 16:00	0.7	12.4	2,036.9	0.7	0.6	1	1	1
12/05/2019 17:00	0.7	12.4	2,030.5	0.7	0.6	1	1	1
12/05/2019 18:00	0.7	12.4	2,034.9	0.7	0.6	1	1	1
12/05/2019 19:00	0.7	12.4	2,038.0	0.7	0.6	1	1	1
12/05/2019 20:00	0.7	12.3	2,046.8	0.7	0.6	1	1	1
12/05/2019 21:00	0.7	12.4	2,041.3	0.7	0.6	1	1	1
12/05/2019 22:00	0.7	12.4	2,030.8	0.7	0.6	1	1	1
12/05/2019 23:00	0.7	12.5	2,022.2	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.3	2,031.0	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	12.1	1,968.7	0.7	0.6	1	1	1
Maximum:	0.7	12.5	2,050.8	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/06/2019 00:00	0.7	12.5	2,018.3	0.7	0.6	1	1	1
12/06/2019 01:00	0.7	12.5	2,009.8	0.7	0.6	1	1	1
12/06/2019 02:00	0.7	12.5	2,003.4	0.7	0.6	1	1	1
12/06/2019 03:00	0.7	12.5	2,021.2	0.7	0.6	1	1	1
12/06/2019 04:00	0.7	12.4	2,044.9	0.7	0.6	1	1	1
12/06/2019 05:00	0.7	12.4	2,041.5	0.7	0.6	1	1	1
12/06/2019 06:00	0.7	12.3	2,061.6	0.7	0.6	1	1	1
12/06/2019 07:00	0.7	12.3	2,055.8	0.7	0.6	1	1	1
12/06/2019 08:00	0.7	12.4	2,039.6	0.7	0.6	1	1	1
12/06/2019 09:00	0.7	12.4	2,032.1	0.7	0.6	1	1	1
12/06/2019 10:00	0.7	12.4	2,035.8	0.7	0.6	1	1	1
12/06/2019 11:00	0.7	12.4	2,020.2	0.7	0.6	1	1	1
12/06/2019 12:00	0.7	12.5	2,003.5	0.7	0.6	1	1	1
12/06/2019 13:00	0.7	12.5	1,987.9	0.7	0.6	1	1	1
12/06/2019 14:00	0.7	12.6	1,975.4	0.7	0.6	1	1	1
12/06/2019 15:00	0.7	12.6	1,974.0	0.7	0.6	1	1	1
12/06/2019 16:00	0.7	12.6	1,975.7	0.7	0.6	1	1	1
12/06/2019 17:00	0.7	12.6	1,974.1	0.7	0.6	1	1	1
12/06/2019 18:00	0.7	12.6	1,974.2	0.7	0.6	1	1	1
12/06/2019 19:00	0.7	12.6	1,973.5	0.7	0.6	1	1	1
12/06/2019 20:00	0.7	12.6	1,974.5	0.7	0.6	1	1	1
12/06/2019 21:00	0.7	12.7	1,949.6	0.7	0.6	1	1	1
12/06/2019 22:00	-0.4	13.1	1,867.6	-0.1	0.6	1	1	1
12/06/2019 23:00	-1.8	13.2	1,853.6	-1.2	0.6	1	1	1
Average/Sum#:	0.6	12.6	1,994.5	0.6	0.6	24 #	24 #	24 #
Minimum:	-1.8	12.3	1,853.6	-1.2	0.6	1	1	1
Maximum:	0.7	13.2	2,061.6	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/07/2019 00:00	-1.7	12.9	1,911.3	-1.1	0.6	1	1	1
12/07/2019 01:00	0.7	12.2	2,073.4	0.7	0.6	1	1	1
12/07/2019 02:00	0.7	12.3	2,048.3	0.7	0.6	1	1	1
12/07/2019 03:00	0.7	12.3	2,049.9	0.7	0.6	1	1	1
12/07/2019 04:00	0.7	12.3	2,050.6	0.7	0.6	1	1	1
12/07/2019 05:00	0.7	12.3	2,043.9	0.7	0.6	1	1	1
12/07/2019 06:00	0.7	12.3	2,047.8	0.7	0.6	1	1	1
12/07/2019 07:00	0.7	12.2	2,052.8	0.7	0.6	1	1	1
12/07/2019 08:00	0.7	12.1	2,077.9	0.7	0.6	1	1	1
12/07/2019 09:00	0.7	12.1	2,075.5	0.7	0.6	1	1	1
12/07/2019 10:00	0.7	12.2	2,056.3	0.7	0.6	1	1	1
12/07/2019 11:00	0.7	12.1	2,062.2	0.7	0.6	1	1	1
12/07/2019 12:00	0.7	12.1	2,063.2	0.7	0.6	1	1	1
12/07/2019 13:00	0.7	12.2	2,061.5	0.7	0.6	1	1	1
12/07/2019 14:00	0.7	12.2	2,062.7	0.7	0.6	1	1	1
12/07/2019 15:00	0.7	12.2	2,046.7	0.7	0.6	1	1	1
12/07/2019 16:00	0.7	12.2	2,055.2	0.7	0.6	1	1	1
12/07/2019 17:00	0.7	12.2	2,055.5	0.7	0.6	1	1	1
12/07/2019 18:00	0.7	12.0	2,103.1	0.7	0.6	1	1	1
12/07/2019 19:00	0.7	12.1	2,093.6	0.7	0.6	1	1	1
12/07/2019 20:00	0.7	12.0	2,097.4	0.7	0.6	1	1	1
12/07/2019 21:00	0.7	12.1	2,096.5	0.7	0.6	1	1	1
12/07/2019 22:00	0.7	12.2	2,074.8	0.7	0.6	1	1	1
12/07/2019 23:00	0.7	12.2	2,070.2	0.7	0.6	1	1	1
Average/Sum#:	0.6	12.2	2,059.6	0.6	0.6	24 #	24 #	24 #
Minimum:	-1.7	12.0	1,911.3	-1.1	0.6	1	1	1
Maximum:	0.7	12.9	2,103.1	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/08/2019 00:00	0.7	12.1	2,080.6	0.7	0.6	1	1	1
12/08/2019 01:00	0.7	12.6	1,938.3	0.7	0.6	1	1	1
12/08/2019 02:00	0.6	13.6	1,607.0	0.6	0.5	1	1	0
12/08/2019 03:00	0.6	13.6	1,470.4	0.6	0.4	1	1	0
12/08/2019 04:00	0.6	13.6	1,606.7	0.6	0.5	1	1	0
12/08/2019 05:00	0.6	13.6	1,674.8	0.6	0.5	1	1	0
12/08/2019 06:00	0.6	13.6	1,686.3	0.6	0.5	1	1	0
12/08/2019 07:00	0.6	13.6	1,667.1	0.6	0.5	1	1	0
12/08/2019 08:00	0.6	13.6	1,648.6	0.6	0.5	1	1	0
12/08/2019 09:00	0.6	13.6	1,651.1	0.6	0.5	1	1	0
12/08/2019 10:00	0.6	13.6	1,506.9	0.6	0.5	1	1	0
12/08/2019 11:00	0.6	13.6	1,595.1	0.6	0.5	1	1	0
12/08/2019 12:00	0.6	13.6	1,512.1	0.6	0.5	1	1	0
12/08/2019 13:00	0.6	13.6	1,659.8	0.6	0.5	1	1	0
12/08/2019 14:00	0.7	13.5	1,663.0	0.7	0.5	1	1	1
12/08/2019 15:00	0.7	12.8	1,886.7	0.7	0.6	1	1	1
12/08/2019 16:00	0.7	12.4	2,033.6	0.7	0.6	1	1	1
12/08/2019 17:00	0.7	12.4	2,028.5	0.7	0.6	1	1	1
12/08/2019 18:00	0.7	12.3	2,071.4	0.7	0.6	1	1	1
12/08/2019 19:00	0.7	12.2	2,083.6	0.7	0.6	1	1	1
12/08/2019 20:00	0.7	12.2	2,087.5	0.7	0.6	1	1	1
12/08/2019 21:00	0.7	12.4	2,048.4	0.7	0.6	1	1	1
12/08/2019 22:00	0.7	12.2	2,081.5	0.7	0.6	1	1	1
12/08/2019 23:00	0.7	12.2	2,091.9	0.7	0.6	1	1	1
Average/Sum#:	0.7	13.0	1,807.5	0.7	0.5	24 #	24 #	12 #
Minimum:	0.6	12.1	1,470.4	0.6	0.4	1	1	0
Maximum:	0.7	13.6	2,091.9	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2019 00:00	0.7	12.3	2,068.6	0.7	0.6	1	1	1
12/09/2019 01:00	0.7	12.5	2,029.9	0.7	0.6	1	1	1
12/09/2019 02:00	0.7	12.6	2,013.3	0.7	0.6	1	1	1
12/09/2019 03:00	0.7	12.5	2,019.1	0.7	0.6	1	1	1
12/09/2019 04:00	0.7	12.4	2,060.4	0.7	0.6	1	1	1
12/09/2019 05:00	0.7	12.4	2,052.2	0.7	0.6	1	1	1
12/09/2019 06:00	0.7	12.4	2,057.8	0.7	0.6	1	1	1
12/09/2019 07:00	0.7	12.3	2,088.0	0.7	0.6	1	1	1
12/09/2019 08:00	0.7	12.3	2,082.8	0.7	0.6	1	1	1
12/09/2019 09:00	0.7	12.3	2,077.4	0.7	0.6	1	1	1
12/09/2019 10:00	0.7	12.5	2,030.7	0.7	0.6	1	1	1
12/09/2019 11:00	0.7	12.5	2,025.8	0.7	0.6	1	1	1
12/09/2019 12:00	0.7	12.5	2,020.3	0.7	0.6	1	1	1
12/09/2019 13:00	0.7	12.5	2,028.2	0.7	0.6	1	1	1
12/09/2019 14:00	0.7	12.5	2,015.6	0.7	0.6	1	1	1
12/09/2019 15:00	0.7	12.3	2,048.5	0.7	0.6	1	1	1
12/09/2019 16:00	0.7	12.4	2,041.3	0.7	0.6	1	1	1
12/09/2019 17:00	0.7	12.2	2,090.0	0.7	0.6	1	1	1
12/09/2019 18:00	0.7	12.0	2,146.0	0.7	0.6	1	1	1
12/09/2019 19:00	0.7	11.9	2,159.4	0.7	0.6	1	1	1
12/09/2019 20:00	0.7	12.0	2,160.4	0.7	0.6	1	1	1
12/09/2019 21:00	0.7	12.2	2,100.0	0.7	0.6	1	1	1
12/09/2019 22:00	0.7	12.3	2,094.8	0.7	0.6	1	1	1
12/09/2019 23:00	0.7	12.4	2,086.2	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.3	2,066.5	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	11.9	2,013.3	0.7	0.6	1	1	1
Maximum:	0.7	12.6	2,160.4	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/10/2019 00:00	0.7	12.3	2,112.2	0.7	0.6	1	1	1
12/10/2019 01:00	0.7	12.3	2,109.1	0.7	0.6	1	1	1
12/10/2019 02:00	0.7	12.3	2,103.9	0.7	0.6	1	1	1
12/10/2019 03:00	0.7	12.3	2,114.9	0.7	0.6	1	1	1
12/10/2019 04:00	0.7	12.2	2,122.1	0.7	0.6	1	1	1
12/10/2019 05:00	0.7	12.4	2,103.2	0.7	0.6	1	1	1
12/10/2019 06:00	0.7	12.3	2,114.7	0.7	0.6	1	1	1
12/10/2019 07:00	0.7	12.2	2,139.7	0.7	0.6	1	1	1
12/10/2019 08:00	0.7	12.5	2,080.0	0.7	0.6	1	1	1
12/10/2019 09:00	0.7	12.3	2,107.8	0.7	0.6	1	1	1
12/10/2019 10:00	0.7	12.6	2,048.7	0.7	0.6	1	1	1
12/10/2019 11:00	0.7	12.6	2,039.8	0.7	0.6	1	1	1
12/10/2019 12:00	0.7	12.5	2,054.4	0.7	0.6	1	1	1
12/10/2019 13:00	0.7	12.5	2,051.4	0.7	0.6	1	1	1
12/10/2019 14:00	0.7	12.4	2,057.1	0.7	0.6	1	1	1
12/10/2019 15:00	0.7	12.5	2,045.6	0.7	0.6	1	1	1
12/10/2019 16:00	0.7	12.4	2,061.8	0.7	0.6	1	1	1
12/10/2019 17:00	0.7	12.1	2,128.5	0.7	0.6	1	1	1
12/10/2019 18:00	0.7	12.0	2,149.1	0.7	0.6	1	1	1
12/10/2019 19:00	0.7	12.0	2,151.7	0.7	0.6	1	1	1
12/10/2019 20:00	0.7	12.0	2,152.8	0.7	0.6	1	1	1
12/10/2019 21:00	0.7	12.2	2,117.9	0.7	0.6	1	1	1
12/10/2019 22:00	0.7	12.4	2,079.0	0.7	0.6	1	1	1
12/10/2019 23:00	0.7	12.4	2,074.2	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.3	2,096.7	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	12.0	2,039.8	0.7	0.6	1	1	1
Maximum:	0.7	12.6	2,152.8	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/11/2019 00:00	0.7	12.3	2,100.1	0.7	0.6	1	1	1
12/11/2019 01:00	0.7	12.3	2,096.8	0.7	0.6	1	1	1
12/11/2019 02:00	0.7	12.4	2,071.1	0.7	0.6	1	1	1
12/11/2019 03:00	0.7	12.6	2,022.2	0.7	0.6	1	1	1
12/11/2019 04:00	0.7	12.5	2,045.5	0.7	0.6	1	1	1
12/11/2019 05:00	0.7	12.4	2,065.7	0.7	0.6	1	1	1
12/11/2019 06:00	0.7	12.1	2,100.7	0.7	0.6	1	1	1
12/11/2019 07:00	0.7	12.3	2,093.9	0.7	0.6	1	1	1
12/11/2019 08:00	0.7	12.4	2,063.9	0.7	0.6	1	1	1
12/11/2019 09:00	0.7	12.5	2,034.7	0.7	0.6	1	1	1
12/11/2019 10:00	0.7	12.5	2,047.1	0.7	0.6	1	1	1
12/11/2019 11:00	0.7	12.5	2,029.1	0.7	0.6	1	1	1
12/11/2019 12:00	0.7	12.5	2,031.6	0.7	0.6	1	1	1
12/11/2019 13:00	0.7	12.5	2,031.7	0.7	0.6	1	1	1
12/11/2019 14:00	0.7	12.4	2,057.6	0.7	0.6	1	1	1
12/11/2019 15:00	0.7	12.5	2,027.7	0.7	0.6	1	1	1
12/11/2019 16:00	0.7	12.5	2,043.9	0.7	0.6	1	1	1
12/11/2019 17:00	0.7	12.2	2,099.3	0.7	0.6	1	1	1
12/11/2019 18:00	0.7	12.3	2,075.0	0.7	0.6	1	1	1
12/11/2019 19:00	0.7	12.1	2,134.3	0.7	0.6	1	1	1
12/11/2019 20:00	0.7	12.3	2,082.6	0.7	0.6	1	1	1
12/11/2019 21:00	0.7	12.4	2,053.6	0.7	0.6	1	1	1
12/11/2019 22:00	0.7	12.5	2,040.3	0.7	0.6	1	1	1
12/11/2019 23:00	0.7	12.4	2,042.8	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.4	2,062.1	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	12.1	2,022.2	0.7	0.6	1	1	1
Maximum:	0.7	12.6	2,134.3	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/12/2019 00:00	0.7	12.5	2,038.4	0.7	0.6	1	1	1
12/12/2019 01:00	0.7	12.5	2,026.7	0.7	0.6	1	1	1
12/12/2019 02:00	0.7	12.5	2,034.6	0.7	0.6	1	1	1
12/12/2019 03:00	0.7	12.5	2,036.3	0.7	0.6	1	1	1
12/12/2019 04:00	0.7	12.5	2,034.4	0.7	0.6	1	1	1
12/12/2019 05:00	0.7	12.5	2,032.9	0.7	0.6	1	1	1
12/12/2019 06:00	0.7	12.2	2,081.7	0.7	0.6	1	1	1
12/12/2019 07:00	0.7	12.2	2,109.2	0.7	0.6	1	1	1
12/12/2019 08:00	0.7	12.5	2,048.5	0.7	0.6	1	1	1
12/12/2019 09:00	0.7	12.5	2,041.1	0.7	0.6	1	1	1
12/12/2019 10:00	0.7	12.6	2,020.5	0.7	0.6	1	1	1
12/12/2019 11:00	0.7	12.6	2,015.7	0.7	0.6	1	1	1
12/12/2019 12:00	0.7	12.5	2,030.3	0.7	0.6	1	1	1
12/12/2019 13:00	0.7	12.5	2,032.5	0.7	0.6	1	1	1
12/12/2019 14:00	0.7	12.4	2,038.8	0.7	0.6	1	1	1
12/12/2019 15:00	0.7	12.4	2,039.5	0.7	0.6	1	1	1
12/12/2019 16:00	0.7	12.4	2,044.8	0.7	0.6	1	1	1
12/12/2019 17:00	0.7	12.2	2,092.8	0.7	0.6	1	1	1
12/12/2019 18:00	0.7	12.1	2,102.0	0.7	0.6	1	1	1
12/12/2019 19:00	0.7	12.2	2,080.7	0.7	0.6	1	1	1
12/12/2019 20:00	0.7	12.3	2,053.9	0.7	0.6	1	1	1
12/12/2019 21:00	0.7	12.4	2,058.8	0.7	0.6	1	1	1
12/12/2019 22:00	0.7	12.4	2,048.7	0.7	0.6	1	1	1
12/12/2019 23:00	0.7	13.1	1,826.5	0.7	0.5	1	1	1
Average/Sum#:	0.7	12.4	2,040.4	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	12.1	1,826.5	0.7	0.5	1	1	1
Maximum:	0.7	13.1	2,109.2	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/13/2019 00:00	0.6	13.6	1,455.3	0.6	0.4	1	1	0
12/13/2019 01:00	0.6	13.6	1,517.7	0.6	0.5	1	1	0
12/13/2019 02:00	0.6	13.6	1,391.0	0.6	0.4	1	1	0
12/13/2019 03:00	0.6	13.6	1,433.6	0.6	0.4	1	1	0
12/13/2019 04:00	0.6	13.6	1,701.2	0.6	0.5	1	1	0
12/13/2019 05:00	0.6	13.6	1,407.8	0.6	0.4	1	1	0
12/13/2019 06:00	0.6	13.6	1,398.2	0.6	0.4	1	1	0
12/13/2019 07:00	0.6	13.6	1,585.5	0.6	0.5	1	1	0
12/13/2019 08:00	0.6	13.6	1,684.7	0.6	0.5	1	1	0
12/13/2019 09:00	0.6	13.6	1,642.9	0.6	0.5	1	1	0
12/13/2019 10:00	0.6	13.6	1,696.1	0.6	0.5	1	1	0
12/13/2019 11:00	0.6	13.6	1,603.9	0.6	0.5	1	1	0
12/13/2019 12:00	0.6	13.6	1,497.2	0.6	0.4	1	1	0
12/13/2019 13:00	0.6	13.6	1,665.1	0.6	0.5	1	1	0
12/13/2019 14:00	0.7	13.5	1,746.6	0.7	0.5	1	1	1
12/13/2019 15:00	0.7	12.5	1,993.7	0.7	0.6	1	1	1
12/13/2019 16:00	0.7	12.2	2,067.1	0.7	0.6	1	1	1
12/13/2019 17:00	0.7	12.2	2,061.0	0.7	0.6	1	1	1
12/13/2019 18:00	0.7	12.0	2,113.5	0.7	0.6	1	1	1
12/13/2019 19:00	0.7	12.2	2,060.4	0.7	0.6	1	1	1
12/13/2019 20:00	0.7	12.2	2,079.0	0.7	0.6	1	1	1
12/13/2019 21:00	0.7	12.2	2,067.6	0.7	0.6	1	1	1
12/13/2019 22:00	0.7	12.2	2,069.6	0.7	0.6	1	1	1
12/13/2019 23:00	0.7	12.3	2,058.0	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.1	1,749.9	0.6	0.5	24 #	24 #	10 #
Minimum:	0.6	12.0	1,391.0	0.6	0.4	1	1	0
Maximum:	0.7	13.6	2,113.5	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/14/2019 00:00	0.7	12.4	2,045.8	0.7	0.6	1	1	1
12/14/2019 01:00	0.7	12.6	1,962.4	0.7	0.6	1	1	1
12/14/2019 02:00	0.6	13.6	1,606.6	0.6	0.5	1	1	0
12/14/2019 03:00	0.6	13.6	1,561.7	0.6	0.5	1	1	0
12/14/2019 04:00	0.6	13.6	1,695.0	0.6	0.5	1	1	0
12/14/2019 05:00	0.6	13.6	1,631.9	0.6	0.5	1	1	0
12/14/2019 06:00	0.6	13.6	1,567.2	0.6	0.5	1	1	0
12/14/2019 07:00	0.6	13.6	1,491.9	0.6	0.4	1	1	0
12/14/2019 08:00	0.6	13.6	1,487.9	0.6	0.4	1	1	0
12/14/2019 09:00	0.6	13.6	1,646.4	0.6	0.5	1	1	0
12/14/2019 10:00	0.6	13.6	1,583.8	0.6	0.5	1	1	0
12/14/2019 11:00	0.6	13.6	1,611.9	0.6	0.5	1	1	0
12/14/2019 12:00	0.6	13.7	1,386.2	0.6	0.4	1	1	0
12/14/2019 13:00	0.6	13.6	1,657.3	0.6	0.5	1	1	0
12/14/2019 14:00	0.6	13.6	1,607.0	0.6	0.5	1	1	0
12/14/2019 15:00	0.7	13.6	1,612.8	0.7	0.5	1	1	1
12/14/2019 16:00	0.7	12.5	2,014.5	0.7	0.6	1	1	1
12/14/2019 17:00	0.7	12.3	2,078.8	0.7	0.6	1	1	1
12/14/2019 18:00	0.7	12.3	2,080.7	0.7	0.6	1	1	1
12/14/2019 19:00	0.7	12.4	2,057.4	0.7	0.6	1	1	1
12/14/2019 20:00	0.7	12.2	2,104.3	0.7	0.6	1	1	1
12/14/2019 21:00	0.7	12.3	2,104.0	0.7	0.6	1	1	1
12/14/2019 22:00	0.7	12.4	2,056.1	0.7	0.6	1	1	1
12/14/2019 23:00	0.7	12.9	1,953.3	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.1	1,775.2	0.6	0.5	24 #	24 #	11 #
Minimum:	0.6	12.2	1,386.2	0.6	0.4	1	1	0
Maximum:	0.7	13.7	2,104.3	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/15/2019 00:00	0.7	12.6	2,034.8	0.7	0.6	1	1	1
12/15/2019 01:00	0.7	12.6	2,022.0	0.7	0.6	1	1	1
12/15/2019 02:00	0.7	12.4	2,068.2	0.7	0.6	1	1	1
12/15/2019 03:00	0.7	12.4	2,088.1	0.7	0.6	1	1	1
12/15/2019 04:00	0.7	12.4	2,097.5	0.7	0.6	1	1	1
12/15/2019 05:00	0.7	12.5	2,059.2	0.7	0.6	1	1	1
12/15/2019 06:00	0.7	12.5	2,068.0	0.7	0.6	1	1	1
12/15/2019 07:00	0.7	12.8	1,958.5	0.7	0.6	1	1	1
12/15/2019 08:00	0.6	13.6	1,594.2	0.6	0.5	1	1	0
12/15/2019 09:00	0.6	13.6	1,647.3	0.6	0.5	1	1	0
12/15/2019 10:00	0.6	13.6	1,546.4	0.6	0.5	1	1	0
12/15/2019 11:00	0.6	13.6	1,572.6	0.6	0.5	1	1	0
12/15/2019 12:00	0.6	13.6	1,555.2	0.6	0.5	1	1	0
12/15/2019 13:00	0.6	13.6	1,648.3	0.6	0.5	1	1	0
12/15/2019 14:00	0.6	13.6	1,578.5	0.6	0.5	1	1	0
12/15/2019 15:00	0.7	13.6	1,574.4	0.7	0.5	1	1	1
12/15/2019 16:00	0.7	12.7	2,013.2	0.7	0.6	1	1	1
12/15/2019 17:00	0.7	12.5	2,065.4	0.7	0.6	1	1	1
12/15/2019 18:00	0.7	12.2	2,140.9	0.7	0.6	1	1	1
12/15/2019 19:00	0.7	12.0	2,167.3	0.7	0.7	1	1	1
12/15/2019 20:00	0.7	12.1	2,160.8	0.7	0.6	1	1	1
12/15/2019 21:00	0.7	12.1	2,156.4	0.7	0.6	1	1	1
12/15/2019 22:00	0.7	12.3	2,096.1	0.7	0.6	1	1	1
12/15/2019 23:00	0.7	12.5	2,073.9	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.8	1,916.1	0.7	0.6	24 #	24 #	17 #
Minimum:	0.6	12.0	1,546.4	0.6	0.5	1	1	0
Maximum:	0.7	13.6	2,167.3	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/16/2019 00:00	0.7	12.3	2,105.5	0.7	0.6	1	1	1
12/16/2019 01:00	0.7	12.3	2,105.7	0.7	0.6	1	1	1
12/16/2019 02:00	0.7	12.4	2,099.3	0.7	0.6	1	1	1
12/16/2019 03:00	0.7	12.4	2,112.4	0.7	0.6	1	1	1
12/16/2019 04:00	0.7	12.4	2,110.5	0.7	0.6	1	1	1
12/16/2019 05:00	0.7	12.4	2,094.0	0.7	0.6	1	1	1
12/16/2019 06:00	0.7	12.1	2,177.6	0.7	0.7	1	1	1
12/16/2019 07:00	0.7	12.3	2,141.6	0.7	0.6	1	1	1
12/16/2019 08:00	0.7	12.8	2,024.2	0.7	0.6	1	1	1
12/16/2019 09:00	0.7	12.7	2,021.1	0.7	0.6	1	1	1
12/16/2019 10:00	0.7	12.6	2,038.9	0.7	0.6	1	1	1
12/16/2019 11:00	0.7	12.6	2,031.8	0.7	0.6	1	1	1
12/16/2019 12:00	0.7	12.6	2,033.7	0.7	0.6	1	1	1
12/16/2019 13:00	0.7	12.6	2,034.6	0.7	0.6	1	1	1
12/16/2019 14:00	0.7	12.5	2,047.6	0.7	0.6	1	1	1
12/16/2019 15:00	0.7	12.5	2,062.4	0.7	0.6	1	1	1
12/16/2019 16:00	0.7	12.4	2,085.0	0.7	0.6	1	1	1
12/16/2019 17:00	0.7	12.1	2,138.0	0.7	0.6	1	1	1
12/16/2019 18:00	0.7	12.1	2,152.8	0.7	0.6	1	1	1
12/16/2019 19:00	0.7	12.1	2,167.2	0.7	0.7	1	1	1
12/16/2019 20:00	0.7	12.1	2,167.2	0.7	0.7	1	1	1
12/16/2019 21:00	0.7	12.1	2,161.4	0.7	0.6	1	1	1
12/16/2019 22:00	0.7	12.3	2,128.4	0.7	0.6	1	1	1
12/16/2019 23:00	0.7	12.5	2,085.0	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.4	2,096.9	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	12.1	2,021.1	0.7	0.6	1	1	1
Maximum:	0.7	12.8	2,177.6	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/17/2019 00:00	0.7	12.4	2,095.6	0.7	0.6	1	1	1
12/17/2019 01:00	0.7	12.4	2,112.7	0.7	0.6	1	1	1
12/17/2019 02:00	0.7	12.4	2,111.7	0.7	0.6	1	1	1
12/17/2019 03:00	0.7	12.4	2,107.2	0.7	0.6	1	1	1
12/17/2019 04:00	0.7	12.6	2,091.3	0.7	0.6	1	1	1
12/17/2019 05:00	0.7	12.6	2,085.2	0.7	0.6	1	1	1
12/17/2019 06:00	0.7	12.2	2,143.9	0.7	0.6	1	1	1
12/17/2019 07:00	0.7	12.4	2,135.0	0.7	0.6	1	1	1
12/17/2019 08:00	0.7	12.5	2,095.6	0.7	0.6	1	1	1
12/17/2019 09:00	0.7	12.7	2,054.8	0.7	0.6	1	1	1
12/17/2019 10:00	0.7	12.7	2,041.9	0.7	0.6	1	1	1
12/17/2019 11:00	0.7	12.7	2,043.5	0.7	0.6	1	1	1
12/17/2019 12:00	0.7	12.6	2,051.0	0.7	0.6	1	1	1
12/17/2019 13:00	0.7	12.6	2,061.2	0.7	0.6	1	1	1
12/17/2019 14:00	0.7	12.4	2,086.1	0.7	0.6	1	1	1
12/17/2019 15:00	0.7	12.3	2,107.4	0.7	0.6	1	1	1
12/17/2019 16:00	0.7	12.3	2,123.4	0.7	0.6	1	1	1
12/17/2019 17:00	0.7	12.2	2,140.8	0.7	0.6	1	1	1
12/17/2019 18:00	0.7	12.2	2,127.0	0.7	0.6	1	1	1
12/17/2019 19:00	0.7	12.3	2,112.3	0.7	0.6	1	1	1
12/17/2019 20:00	0.7	12.1	2,155.6	0.7	0.6	1	1	1
12/17/2019 21:00	0.7	12.0	2,166.9	0.7	0.7	1	1	1
12/17/2019 22:00	0.7	12.1	2,160.9	0.7	0.6	1	1	1
12/17/2019 23:00	0.7	12.4	2,091.1	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.4	2,104.3	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	12.0	2,041.9	0.7	0.6	1	1	1
Maximum:	0.7	12.7	2,166.9	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/18/2019 00:00	0.7	12.5	2,083.8	0.7	0.6	1	1	1
12/18/2019 01:00	0.7	12.3	2,106.5	0.7	0.6	1	1	1
12/18/2019 02:00	0.7	12.3	2,102.9	0.7	0.6	1	1	1
12/18/2019 03:00	0.7	12.3	2,109.2	0.7	0.6	1	1	1
12/18/2019 04:00	0.7	12.3	2,115.1	0.7	0.6	1	1	1
12/18/2019 05:00	0.7	12.1	2,147.7	0.7	0.6	1	1	1
12/18/2019 06:00	0.7	12.0	2,189.5	0.7	0.7	1	1	1
12/18/2019 07:00	0.7	12.1	2,170.9	0.7	0.7	1	1	1
12/18/2019 08:00	0.7	12.3	2,125.0	0.7	0.6	1	1	1
12/18/2019 09:00	0.7	12.3	2,109.0	0.7	0.6	1	1	1
12/18/2019 10:00	0.7	12.4	2,102.2	0.7	0.6	1	1	1
12/18/2019 11:00	0.7	12.3	2,115.8	0.7	0.6	1	1	1
12/18/2019 12:00	0.7	12.3	2,099.3	0.7	0.6	1	1	1
12/18/2019 13:00	0.7	12.4	2,097.1	0.7	0.6	1	1	1
12/18/2019 14:00	0.7	12.4	2,086.5	0.7	0.6	1	1	1
12/18/2019 15:00	0.7	12.5	2,063.9	0.7	0.6	1	1	1
12/18/2019 16:00	0.7	12.4	2,100.2	0.7	0.6	1	1	1
12/18/2019 17:00	0.7	12.2	2,143.7	0.7	0.6	1	1	1
12/18/2019 18:00	0.7	12.0	2,171.8	0.7	0.7	1	1	1
12/18/2019 19:00	0.7	12.1	2,163.5	0.7	0.6	1	1	1
12/18/2019 20:00	0.7	12.0	2,173.3	0.7	0.7	1	1	1
12/18/2019 21:00	0.7	12.1	2,160.8	0.7	0.6	1	1	1
12/18/2019 22:00	0.7	12.2	2,145.7	0.7	0.6	1	1	1
12/18/2019 23:00	0.7	12.4	2,096.1	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.3	2,124.1	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	12.0	2,063.9	0.7	0.6	1	1	1
Maximum:	0.7	12.5	2,189.5	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2019 00:00	0.7	12.3	2,110.2	0.7	0.6	1	1	1
12/19/2019 01:00	0.7	12.3	2,109.6	0.7	0.6	1	1	1
12/19/2019 02:00	0.7	12.3	2,104.4	0.7	0.6	1	1	1
12/19/2019 03:00	0.7	12.4	2,093.9	0.7	0.6	1	1	1
12/19/2019 04:00	0.7	12.3	2,105.8	0.7	0.6	1	1	1
12/19/2019 05:00	0.7	12.4	2,089.4	0.7	0.6	1	1	1
12/19/2019 06:00	0.7	12.0	2,172.9	0.7	0.7	1	1	1
12/19/2019 07:00	0.7	12.1	2,151.4	0.7	0.6	1	1	1
12/19/2019 08:00	0.7	12.6	2,042.6	0.7	0.6	1	1	1
12/19/2019 09:00	0.7	12.5	2,064.5	0.7	0.6	1	1	1
12/19/2019 10:00	0.7	12.6	2,032.5	0.7	0.6	1	1	1
12/19/2019 11:00	0.7	12.6	2,033.1	0.7	0.6	1	1	1
12/19/2019 12:00	0.7	12.6	2,029.8	0.7	0.6	1	1	1
12/19/2019 13:00	0.7	12.5	2,038.5	0.7	0.6	1	1	1
12/19/2019 14:00	0.7	12.6	2,026.2	0.7	0.6	1	1	1
12/19/2019 15:00	0.7	12.4	2,075.1	0.7	0.6	1	1	1
12/19/2019 16:00	0.7	12.3	2,084.0	0.7	0.6	1	1	1
12/19/2019 17:00	0.7	12.2	2,112.7	0.7	0.6	1	1	1
12/19/2019 18:00	0.7	12.2	2,116.2	0.7	0.6	1	1	1
12/19/2019 19:00	0.7	12.1	2,140.0	0.7	0.6	1	1	1
12/19/2019 20:00	0.7	12.1	2,142.2	0.7	0.6	1	1	1
12/19/2019 21:00	0.7	12.1	2,147.2	0.7	0.6	1	1	1
12/19/2019 22:00	0.7	12.3	2,100.6	0.7	0.6	1	1	1
12/19/2019 23:00	0.7	12.4	2,087.7	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.3	2,092.1	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	12.0	2,026.2	0.7	0.6	1	1	1
Maximum:	0.7	12.6	2,172.9	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/20/2019 00:00	0.7	12.3	2,103.7	0.7	0.6	1	1	1
12/20/2019 01:00	0.7	12.3	2,089.5	0.7	0.6	1	1	1
12/20/2019 02:00	0.7	12.3	2,095.5	0.7	0.6	1	1	1
12/20/2019 03:00	0.7	12.6	2,040.0	0.7	0.6	1	1	1
12/20/2019 04:00	0.7	12.5	2,065.1	0.7	0.6	1	1	1
12/20/2019 05:00	0.7	12.4	2,092.9	0.7	0.6	1	1	1
12/20/2019 06:00	0.7	12.2	2,118.4	0.7	0.6	1	1	1
12/20/2019 07:00	0.7	12.5	2,070.4	0.7	0.6	1	1	1
12/20/2019 08:00	0.7	12.6	2,030.9	0.7	0.6	1	1	1
12/20/2019 09:00	0.7	12.6	2,044.2	0.7	0.6	1	1	1
12/20/2019 10:00	0.7	12.8	1,946.1	0.7	0.6	1	1	1
12/20/2019 11:00	0.6	13.6	1,648.3	0.6	0.5	1	1	0
12/20/2019 12:00	0.6	13.6	1,598.4	0.6	0.5	1	1	0
12/20/2019 13:00	0.6	13.6	1,659.5	0.6	0.5	1	1	0
12/20/2019 14:00	0.7	13.6	1,572.1	0.7	0.5	1	1	1
12/20/2019 15:00	0.7	12.5	2,030.2	0.7	0.6	1	1	1
12/20/2019 16:00	0.7	12.3	2,069.8	0.7	0.6	1	1	1
12/20/2019 17:00	0.7	12.1	2,112.2	0.7	0.6	1	1	1
12/20/2019 18:00	0.7	12.0	2,136.1	0.7	0.6	1	1	1
12/20/2019 19:00	0.7	12.2	2,101.3	0.7	0.6	1	1	1
12/20/2019 20:00	0.7	12.2	2,098.5	0.7	0.6	1	1	1
12/20/2019 21:00	0.7	12.2	2,097.4	0.7	0.6	1	1	1
12/20/2019 22:00	0.7	12.2	2,101.2	0.7	0.6	1	1	1
12/20/2019 23:00	0.7	12.3	2,094.2	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.6	2,000.7	0.7	0.6	24 #	24 #	21 #
Minimum:	0.6	12.0	1,572.1	0.6	0.5	1	1	0
Maximum:	0.7	13.6	2,136.1	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/21/2019 00:00	0.7	12.4	2,062.3	0.7	0.6	1	1	1
12/21/2019 01:00	0.7	12.5	2,047.9	0.7	0.6	1	1	1
12/21/2019 02:00	0.7	12.3	2,084.5	0.7	0.6	1	1	1
12/21/2019 03:00	0.7	12.3	2,086.1	0.7	0.6	1	1	1
12/21/2019 04:00	0.7	12.3	2,091.9	0.7	0.6	1	1	1
12/21/2019 05:00	0.7	12.3	2,097.3	0.7	0.6	1	1	1
12/21/2019 06:00	0.7	12.3	2,076.8	0.7	0.6	1	1	1
12/21/2019 07:00	0.7	12.3	2,106.2	0.7	0.6	1	1	1
12/21/2019 08:00	0.7	12.3	2,099.3	0.7	0.6	1	1	1
12/21/2019 09:00	0.7	12.3	2,090.7	0.7	0.6	1	1	1
12/21/2019 10:00	0.7	12.4	2,067.2	0.7	0.6	1	1	1
12/21/2019 11:00	0.7	12.6	2,036.5	0.7	0.6	1	1	1
12/21/2019 12:00	0.7	12.5	2,034.8	0.7	0.6	1	1	1
12/21/2019 13:00	0.7	12.5	2,041.3	0.7	0.6	1	1	1
12/21/2019 14:00	0.7	12.4	2,061.3	0.7	0.6	1	1	1
12/21/2019 15:00	0.7	12.5	2,051.4	0.7	0.6	1	1	1
12/21/2019 16:00	0.7	12.5	2,037.2	0.7	0.6	1	1	1
12/21/2019 17:00	0.7	12.5	2,042.2	0.7	0.6	1	1	1
12/21/2019 18:00	0.7	12.4	2,054.3	0.7	0.6	1	1	1
12/21/2019 19:00	0.7	12.4	2,062.3	0.7	0.6	1	1	1
12/21/2019 20:00	0.7	12.3	2,079.4	0.7	0.6	1	1	1
12/21/2019 21:00	0.7	12.3	2,072.6	0.7	0.6	1	1	1
12/21/2019 22:00	0.7	12.2	2,100.2	0.7	0.6	1	1	1
12/21/2019 23:00	0.7	12.3	2,098.4	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.4	2,070.1	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	12.2	2,034.8	0.7	0.6	1	1	1
Maximum:	0.7	12.6	2,106.2	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/22/2019 00:00	0.7	12.3	2,092.8	0.7	0.6	1	1	1
12/22/2019 01:00	0.7	12.4	2,061.8	0.7	0.6	1	1	1
12/22/2019 02:00	0.7	12.2	2,103.3	0.7	0.6	1	1	1
12/22/2019 03:00	0.7	12.2	2,109.5	0.7	0.6	1	1	1
12/22/2019 04:00	0.7	12.3	2,081.6	0.7	0.6	1	1	1
12/22/2019 05:00	0.7	12.3	2,073.6	0.7	0.6	1	1	1
12/22/2019 06:00	0.7	12.1	2,102.0	0.7	0.6	1	1	1
12/22/2019 07:00	0.7	12.1	2,109.7	0.7	0.6	1	1	1
12/22/2019 08:00	0.7	12.2	2,088.6	0.7	0.6	1	1	1
12/22/2019 09:00	0.7	12.3	2,085.0	0.7	0.6	1	1	1
12/22/2019 10:00	0.7	12.3	2,085.1	0.7	0.6	1	1	1
12/22/2019 11:00	0.7	12.3	2,062.4	0.7	0.6	1	1	1
12/22/2019 12:00	0.7	12.4	2,056.4	0.7	0.6	1	1	1
12/22/2019 13:00	0.7	12.2	2,083.7	0.7	0.6	1	1	1
12/22/2019 14:00	0.7	12.3	2,061.3	0.7	0.6	1	1	1
12/22/2019 15:00	0.7	12.3	2,056.8	0.7	0.6	1	1	1
12/22/2019 16:00	0.7	12.5	2,020.5	0.7	0.6	1	1	1
12/22/2019 17:00	0.7	12.5	2,023.6	0.7	0.6	1	1	1
12/22/2019 18:00	0.7	12.4	2,040.2	0.7	0.6	1	1	1
12/22/2019 19:00	0.7	12.4	2,043.9	0.7	0.6	1	1	1
12/22/2019 20:00	0.7	12.5	2,040.0	0.7	0.6	1	1	1
12/22/2019 21:00	0.7	12.5	2,028.7	0.7	0.6	1	1	1
12/22/2019 22:00	0.7	12.5	2,030.6	0.7	0.6	1	1	1
12/22/2019 23:00	0.7	12.5	2,053.2	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.3	2,066.4	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	12.1	2,020.5	0.7	0.6	1	1	1
Maximum:	0.7	12.5	2,109.7	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/23/2019 00:00	0.7	12.4	2,057.8	0.7	0.6	1	1	1
12/23/2019 01:00	0.7	12.5	2,036.7	0.7	0.6	1	1	1
12/23/2019 02:00	0.7	12.5	2,040.4	0.7	0.6	1	1	1
12/23/2019 03:00	0.7	12.5	2,059.6	0.7	0.6	1	1	1
12/23/2019 04:00	0.7	12.5	2,048.7	0.7	0.6	1	1	1
12/23/2019 05:00	0.7	12.5	2,039.1	0.7	0.6	1	1	1
12/23/2019 06:00	0.7	12.5	2,049.8	0.7	0.6	1	1	1
12/23/2019 07:00	0.7	12.5	2,055.3	0.7	0.6	1	1	1
12/23/2019 08:00	0.7	12.2	2,115.8	0.7	0.6	1	1	1
12/23/2019 09:00	0.7	12.2	2,118.1	0.7	0.6	1	1	1
12/23/2019 10:00	0.7	12.2	2,111.6	0.7	0.6	1	1	1
12/23/2019 11:00	0.7	12.1	2,115.9	0.7	0.6	1	1	1
12/23/2019 12:00	0.7	12.1	2,114.1	0.7	0.6	1	1	1
12/23/2019 13:00	0.7	12.3	2,061.2	0.7	0.6	1	1	1
12/23/2019 14:00	0.7	12.2	2,083.4	0.7	0.6	1	1	1
12/23/2019 15:00	0.7	12.3	2,059.5	0.7	0.6	1	1	1
12/23/2019 16:00	0.7	12.4	2,052.6	0.7	0.6	1	1	1
12/23/2019 17:00	0.7	12.4	2,046.0	0.7	0.6	1	1	1
12/23/2019 18:00	0.7	12.4	2,048.9	0.7	0.6	1	1	1
12/23/2019 19:00	0.7	12.4	2,071.9	0.7	0.6	1	1	1
12/23/2019 20:00	0.7	12.2	2,124.2	0.7	0.6	1	1	1
12/23/2019 21:00	0.7	12.2	2,105.7	0.7	0.6	1	1	1
12/23/2019 22:00	0.7	12.3	2,100.3	0.7	0.6	1	1	1
12/23/2019 23:00	0.7	12.4	2,102.7	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.3	2,075.8	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	12.1	2,036.7	0.7	0.6	1	1	1
Maximum:	0.7	12.5	2,124.2	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/24/2019 00:00	0.7	12.4	2,092.6	0.7	0.6	1	1	1
12/24/2019 01:00	0.7	12.6	2,047.1	0.7	0.6	1	1	1
12/24/2019 02:00	0.7	12.6	2,043.0	0.7	0.6	1	1	1
12/24/2019 03:00	0.7	12.6	2,044.0	0.7	0.6	1	1	1
12/24/2019 04:00	0.7	12.6	2,048.4	0.7	0.6	1	1	1
12/24/2019 05:00	0.7	12.6	2,049.6	0.7	0.6	1	1	1
12/24/2019 06:00	0.7	12.5	2,068.6	0.7	0.6	1	1	1
12/24/2019 07:00	0.7	12.6	2,065.7	0.7	0.6	1	1	1
12/24/2019 08:00	0.7	12.7	2,058.1	0.7	0.6	1	1	1
12/24/2019 09:00	0.7	12.6	2,046.3	0.7	0.6	1	1	1
12/24/2019 10:00	0.7	12.6	2,042.3	0.7	0.6	1	1	1
12/24/2019 11:00	0.7	12.6	2,035.5	0.7	0.6	1	1	1
12/24/2019 12:00	0.7	12.5	2,044.2	0.7	0.6	1	1	1
12/24/2019 13:00	0.7	12.6	2,032.3	0.7	0.6	1	1	1
12/24/2019 14:00	0.7	12.6	2,038.9	0.7	0.6	1	1	1
12/24/2019 15:00	0.7	12.4	2,080.9	0.7	0.6	1	1	1
12/24/2019 16:00	0.7	12.5	2,037.9	0.7	0.6	1	1	1
12/24/2019 17:00	0.7	12.5	2,057.3	0.7	0.6	1	1	1
12/24/2019 18:00	0.7	12.5	2,051.8	0.7	0.6	1	1	1
12/24/2019 19:00	0.7	12.6	2,041.0	0.7	0.6	1	1	1
12/24/2019 20:00	0.7	12.5	2,043.0	0.7	0.6	1	1	1
12/24/2019 21:00	0.7	12.6	2,042.4	0.7	0.6	1	1	1
12/24/2019 22:00	0.7	12.5	2,053.5	0.7	0.6	1	1	1
12/24/2019 23:00	0.7	12.6	2,035.2	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.6	2,050.0	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	12.4	2,032.3	0.7	0.6	1	1	1
Maximum:	0.7	12.7	2,092.6	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/25/2019 00:00	0.7	12.4	2,062.7	0.7	0.6	1	1	1
12/25/2019 01:00	0.7	12.4	2,068.2	0.7	0.6	1	1	1
12/25/2019 02:00	0.7	12.4	2,071.0	0.7	0.6	1	1	1
12/25/2019 03:00	0.7	12.6	2,045.1	0.7	0.6	1	1	1
12/25/2019 04:00	0.7	12.5	2,045.3	0.7	0.6	1	1	1
12/25/2019 05:00	0.7	12.6	2,041.9	0.7	0.6	1	1	1
12/25/2019 06:00	0.7	12.6	2,038.1	0.7	0.6	1	1	1
12/25/2019 07:00	0.7	12.5	2,056.9	0.7	0.6	1	1	1
12/25/2019 08:00	0.7	12.6	2,033.1	0.7	0.6	1	1	1
12/25/2019 09:00	0.7	12.5	2,051.2	0.7	0.6	1	1	1
12/25/2019 10:00	0.7	12.6	2,048.3	0.7	0.6	1	1	1
12/25/2019 11:00	0.7	12.5	2,044.8	0.7	0.6	1	1	1
12/25/2019 12:00	0.7	12.5	2,051.2	0.7	0.6	1	1	1
12/25/2019 13:00	0.7	12.5	2,044.4	0.7	0.6	1	1	1
12/25/2019 14:00	0.7	12.4	2,068.9	0.7	0.6	1	1	1
12/25/2019 15:00	0.7	12.4	2,069.5	0.7	0.6	1	1	1
12/25/2019 16:00	0.7	12.4	2,078.1	0.7	0.6	1	1	1
12/25/2019 17:00	0.7	12.5	2,049.5	0.7	0.6	1	1	1
12/25/2019 18:00	0.7	12.5	2,064.8	0.7	0.6	1	1	1
12/25/2019 19:00	0.7	12.3	2,095.3	0.7	0.6	1	1	1
12/25/2019 20:00	0.7	12.4	2,088.9	0.7	0.6	1	1	1
12/25/2019 21:00	0.7	12.4	2,069.7	0.7	0.6	1	1	1
12/25/2019 22:00	0.7	12.5	2,060.3	0.7	0.6	1	1	1
12/25/2019 23:00	0.7	12.4	2,067.9	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.5	2,059.0	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	12.3	2,033.1	0.7	0.6	1	1	1
Maximum:	0.7	12.6	2,095.3	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/26/2019 00:00	0.7	12.5	2,065.4	0.7	0.6	1	1	1
12/26/2019 01:00	0.7	12.4	2,073.0	0.7	0.6	1	1	1
12/26/2019 02:00	0.7	12.5	2,062.0	0.7	0.6	1	1	1
12/26/2019 03:00	0.7	12.5	2,052.8	0.7	0.6	1	1	1
12/26/2019 04:00	0.7	12.5	2,046.2	0.7	0.6	1	1	1
12/26/2019 05:00	0.7	12.6	2,040.8	0.7	0.6	1	1	1
12/26/2019 06:00	0.7	12.5	2,043.5	0.7	0.6	1	1	1
12/26/2019 07:00	0.7	12.4	2,081.9	0.7	0.6	1	1	1
12/26/2019 08:00	0.7	12.0	2,165.9	0.7	0.6	1	1	1
12/26/2019 09:00	0.7	12.2	2,108.0	0.7	0.6	1	1	1
12/26/2019 10:00	0.7	12.2	2,110.1	0.7	0.6	1	1	1
12/26/2019 11:00	0.7	12.4	2,069.7	0.7	0.6	1	1	1
12/26/2019 12:00	0.7	12.4	2,050.1	0.7	0.6	1	1	1
12/26/2019 13:00	0.7	12.3	2,072.8	0.7	0.6	1	1	1
12/26/2019 14:00	0.7	12.4	2,053.0	0.7	0.6	1	1	1
12/26/2019 15:00	0.7	12.3	2,065.9	0.7	0.6	1	1	1
12/26/2019 16:00	0.7	12.2	2,114.1	0.7	0.6	1	1	1
12/26/2019 17:00	0.7	12.1	2,126.5	0.7	0.6	1	1	1
12/26/2019 18:00	0.7	12.0	2,157.1	0.7	0.6	1	1	1
12/26/2019 19:00	0.7	12.0	2,151.5	0.7	0.6	1	1	1
12/26/2019 20:00	0.7	12.0	2,154.5	0.7	0.6	1	1	1
12/26/2019 21:00	0.7	12.2	2,121.4	0.7	0.6	1	1	1
12/26/2019 22:00	0.7	12.2	2,110.8	0.7	0.6	1	1	1
12/26/2019 23:00	0.7	12.3	2,111.1	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.3	2,092.0	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	12.0	2,040.8	0.7	0.6	1	1	1
Maximum:	0.7	12.6	2,165.9	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/27/2019 00:00	0.7	12.2	2,115.5	0.7	0.6	1	1	1
12/27/2019 01:00	0.7	12.3	2,095.3	0.7	0.6	1	1	1
12/27/2019 02:00	0.7	12.3	2,113.3	0.7	0.6	1	1	1
12/27/2019 03:00	0.7	12.4	2,082.6	0.7	0.6	1	1	1
12/27/2019 04:00	0.7	12.6	2,058.1	0.7	0.6	1	1	1
12/27/2019 05:00	0.7	12.6	2,065.8	0.7	0.6	1	1	1
12/27/2019 06:00	0.7	12.6	2,057.0	0.7	0.6	1	1	1
12/27/2019 07:00	0.7	12.6	2,071.0	0.7	0.6	1	1	1
12/27/2019 08:00	0.7	12.9	1,971.6	0.7	0.6	1	1	1
12/27/2019 09:00	0.6	13.6	1,691.3	0.6	0.5	1	1	0
12/27/2019 10:00	0.6	13.7	1,677.4	0.6	0.5	1	1	0
12/27/2019 11:00	0.6	13.7	1,637.2	0.6	0.5	1	1	0
12/27/2019 12:00	0.6	13.7	1,637.1	0.6	0.5	1	1	0
12/27/2019 13:00	0.6	13.7	1,686.6	0.6	0.5	1	1	0
12/27/2019 14:00	0.6	13.7	1,655.1	0.6	0.5	1	1	0
12/27/2019 15:00	0.6	13.7	1,417.0	0.6	0.4	1	1	0
12/27/2019 16:00	0.6	13.7	1,634.7	0.6	0.5	1	1	0
12/27/2019 17:00	0.7	13.7	1,711.5	0.7	0.5	1	1	1
12/27/2019 18:00	0.7	12.7	2,003.9	0.7	0.6	1	1	1
12/27/2019 19:00	0.7	12.3	2,086.7	0.7	0.6	1	1	1
12/27/2019 20:00	0.7	12.1	2,120.0	0.7	0.6	1	1	1
12/27/2019 21:00	0.7	12.2	2,106.8	0.7	0.6	1	1	1
12/27/2019 22:00	0.7	12.2	2,103.9	0.7	0.6	1	1	1
12/27/2019 23:00	0.7	12.4	2,070.5	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.5	1,911.2	0.7	0.6	24 #	24 #	16 #
Minimum:	0.6	12.2	1,417.0	0.7	0.4	1	1	0
Maximum:	0.7	12.6	2,120.0	0.7	0.6	1	1	1
%SI	0.00	66.67	0.00	66.67	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/28/2019 00:00	0.7	12.7	2,018.1	0.7	0.6	1	1	1
12/28/2019 01:00	0.7	12.7	2,022.8	0.7	0.6	1	1	1
12/28/2019 02:00	0.7	12.6	2,043.1	0.7	0.6	1	1	1
12/28/2019 03:00	0.7	12.6	2,024.9	0.7	0.6	1	1	1
12/28/2019 04:00	0.7	12.7	2,030.9	0.7	0.6	1	1	1
12/28/2019 05:00	0.7	12.7	2,038.8	0.7	0.6	1	1	1
12/28/2019 06:00	0.7	12.7	2,034.4	0.7	0.6	1	1	1
12/28/2019 07:00	0.7	12.5	2,072.9	0.7	0.6	1	1	1
12/28/2019 08:00	0.7	12.8	1,989.7	0.7	0.6	1	1	1
12/28/2019 09:00	0.6	13.6	1,675.3	0.6	0.5	1	1	0
12/28/2019 10:00	0.6	13.6	1,621.0	0.6	0.5	1	1	0
12/28/2019 11:00	0.6	13.6	1,660.3	0.6	0.5	1	1	0
12/28/2019 12:00	0.6	13.6	1,695.2	0.6	0.5	1	1	0
12/28/2019 13:00	0.6	13.6	1,651.6	0.6	0.5	1	1	0
12/28/2019 14:00	0.6	13.6	1,678.2	0.6	0.5	1	1	0
12/28/2019 15:00	0.7	13.7	1,609.8	0.7	0.5	1	1	1
12/28/2019 16:00	0.7	12.6	2,025.0	0.7	0.6	1	1	1
12/28/2019 17:00	0.7	12.3	2,086.2	0.7	0.6	1	1	1
12/28/2019 18:00	0.7	12.2	2,103.1	0.7	0.6	1	1	1
12/28/2019 19:00	0.7	12.2	2,102.3	0.7	0.6	1	1	1
12/28/2019 20:00	0.7	12.3	2,101.5	0.7	0.6	1	1	1
12/28/2019 21:00	0.7	12.4	2,083.1	0.7	0.6	1	1	1
12/28/2019 22:00	0.7	12.3	2,088.9	0.7	0.6	1	1	1
12/28/2019 23:00	0.7	12.3	2,094.9	0.7	0.6	1	1	1
Average/Sum#:	0.7	0.0	1,939.7	0.0	0.6	24 #	24 #	18 #
Minimum:	0.6	0.0	1,609.8	0.0	0.5	1	1	0
Maximum:	0.7	0.0	2,103.1	0.0	0.6	1	1	1
%SI	0.00	100.00	0.00	100.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/29/2019 00:00	0.7	12.4	2,084.2	0.7	0.6	1	1	1
12/29/2019 01:00	0.7	12.3	2,107.9	0.7	0.6	1	1	1
12/29/2019 02:00	0.7	12.4	2,077.9	0.7	0.6	1	1	1
12/29/2019 03:00	0.7	12.4	2,095.8	0.7	0.6	1	1	1
12/29/2019 04:00	0.7	12.4	2,083.9	0.7	0.6	1	1	1
12/29/2019 05:00	0.7	12.4	2,088.2	0.7	0.6	1	1	1
12/29/2019 06:00	0.7	12.4	2,080.9	0.7	0.6	1	1	1
12/29/2019 07:00	0.7	12.6	2,016.7	0.7	0.6	1	1	1
12/29/2019 08:00	0.6	13.6	1,678.2	0.6	0.5	1	1	0
12/29/2019 09:00	0.6	13.6	1,610.4	0.6	0.5	1	1	0
12/29/2019 10:00	0.6	13.6	1,684.2	0.6	0.5	1	1	0
12/29/2019 11:00	0.6	13.6	1,660.2	0.6	0.5	1	1	0
12/29/2019 12:00	0.6	13.6	1,695.1	0.6	0.5	1	1	0
12/29/2019 13:00	0.6	13.6	1,624.9	0.6	0.5	1	1	0
12/29/2019 14:00	0.6	13.6	1,678.3	0.6	0.5	1	1	0
12/29/2019 15:00	0.7	13.1	1,874.1	0.7	0.6	1	1	1
12/29/2019 16:00	0.7	12.5	2,054.9	0.7	0.6	1	1	1
12/29/2019 17:00	0.7	12.4	2,075.0	0.7	0.6	1	1	1
12/29/2019 18:00	0.7	12.3	2,111.6	0.7	0.6	1	1	1
12/29/2019 19:00	0.7	12.3	2,112.0	0.7	0.6	1	1	1
12/29/2019 20:00	0.7	12.3	2,110.1	0.7	0.6	1	1	1
12/29/2019 21:00	0.7	12.3	2,110.6	0.7	0.6	1	1	1
12/29/2019 22:00	0.7	12.3	2,104.5	0.7	0.6	1	1	1
12/29/2019 23:00	0.7	12.4	2,079.7	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.9	1,954.1	0.7	0.6	24 #	24 #	17 #
Minimum:	0.6	12.3	1,610.4	0.6	0.5	1	1	0
Maximum:	0.7	13.6	2,112.0	0.7	0.6	1	1	1
%SI	0.00	25.00	0.00	25.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/30/2019 00:00	0.7	12.5	2,060.5	0.7	0.6	1	1	1
12/30/2019 01:00	0.7	12.5	2,052.7	0.7	0.6	1	1	1
12/30/2019 02:00	0.7	12.6	2,033.9	0.7	0.6	1	1	1
12/30/2019 03:00	0.7	12.6	2,038.1	0.7	0.6	1	1	1
12/30/2019 04:00	0.7	12.7	2,032.3	0.7	0.6	1	1	1
12/30/2019 05:00	0.7	12.6	2,041.6	0.7	0.6	1	1	1
12/30/2019 06:00	0.7	12.5	2,054.6	0.7	0.6	1	1	1
12/30/2019 07:00	0.7	12.3	2,107.9	0.7	0.6	1	1	1
12/30/2019 08:00	0.7	12.4	2,086.6	0.7	0.6	1	1	1
12/30/2019 09:00	0.7	12.4	2,056.3	0.7	0.6	1	1	1
12/30/2019 10:00	0.7	12.5	2,035.9	0.7	0.6	1	1	1
12/30/2019 11:00	0.7	12.4	2,045.4	0.7	0.6	1	1	1
12/30/2019 12:00	0.7	12.4	2,046.0	0.7	0.6	1	1	1
12/30/2019 13:00	0.7	12.3	2,062.0	0.7	0.6	1	1	1
12/30/2019 14:00	0.7	12.3	2,055.5	0.7	0.6	1	1	1
12/30/2019 15:00	0.7	12.3	2,062.9	0.7	0.6	1	1	1
12/30/2019 16:00	0.7	12.3	2,072.2	0.7	0.6	1	1	1
12/30/2019 17:00	0.7	12.2	2,087.2	0.7	0.6	1	1	1
12/30/2019 18:00	0.7	12.2	2,114.9	0.7	0.6	1	1	1
12/30/2019 19:00	0.7	12.2	2,110.2	0.7	0.6	1	1	1
12/30/2019 20:00	0.7	12.3	2,094.3	0.7	0.6	1	1	1
12/30/2019 21:00	0.7	12.4	2,064.9	0.7	0.6	1	1	1
12/30/2019 22:00	0.7	12.4	2,066.9	0.7	0.6	1	1	1
12/30/2019 23:00	0.7	12.4	2,064.2	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.4	2,064.5	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	12.2	2,032.3	0.7	0.6	1	1	1
Maximum:	0.7	12.7	2,114.9	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/31/2019 00:00	0.7	12.5	2,046.7	0.7	0.6	1	1	1
12/31/2019 01:00	0.7	12.9	1,944.9	0.7	0.6	1	1	1
12/31/2019 02:00	0.7	12.9	1,936.4	0.7	0.6	1	1	1
12/31/2019 03:00	0.7	12.9	1,950.1	0.7	0.6	1	1	1
12/31/2019 04:00	0.7	12.5	2,044.1	0.7	0.6	1	1	1
12/31/2019 05:00	0.7	12.5	2,039.9	0.7	0.6	1	1	1
12/31/2019 06:00	0.7	12.5	2,033.5	0.7	0.6	1	1	1
12/31/2019 07:00	0.7	12.5	2,033.3	0.7	0.6	1	1	1
12/31/2019 08:00	0.7	13.0	1,901.4	0.7	0.6	1	1	1
12/31/2019 09:00	0.6	13.7	1,527.7	0.6	0.5	1	1	0
12/31/2019 10:00	0.6	13.7	1,626.9	0.6	0.5	1	1	0
12/31/2019 11:00	0.6	13.7	1,589.1	0.6	0.5	1	1	0
12/31/2019 12:00	0.6	13.7	1,570.3	0.6	0.5	1	1	0
12/31/2019 13:00	0.6	13.7	1,668.9	0.6	0.5	1	1	0
12/31/2019 14:00	0.6	13.7	1,573.5	0.6	0.5	1	1	0
12/31/2019 15:00	0.7	13.6	1,588.1	0.7	0.5	1	1	1
12/31/2019 16:00	0.7	12.6	1,992.0	0.7	0.6	1	1	1
12/31/2019 17:00	0.7	12.5	2,024.4	0.7	0.6	1	1	1
12/31/2019 18:00	0.7	12.6	2,020.8	0.7	0.6	1	1	1
12/31/2019 19:00	0.7	12.6	2,025.6	0.7	0.6	1	1	1
12/31/2019 20:00	0.7	12.6	2,029.6	0.7	0.6	1	1	1
12/31/2019 21:00	0.7	12.5	2,041.2	0.7	0.6	1	1	1
12/31/2019 22:00	0.7	12.5	2,037.7	0.7	0.6	1	1	1
12/31/2019 23:00	0.7	12.6	2,030.0	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.9	1,886.5	0.7	0.6	24 #	24 #	18 #
Minimum:	0.6	12.5	1,527.7	0.6	0.5	1	1	0
Maximum:	0.7	13.7	2,046.7	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Excess Emission Report

CT1 - VOC Lb 1-Day Block Average

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:05 **Location:** Maxwell, CA

Tag Name: CT1_VOC_Lb_1D

Total Operating Time: 90.00 Day(s) **No Exclusions Allowed**

Non-Operating Time: 2.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**90.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - VOC LbPerHr 1-Hour Block Average

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:06 **Location:** Maxwell, CA

Tag Name: CT1_VOC_LbPerHr_1H

Total Operating Time: 2,023.00 Hour(s) **No Exclusions Allowed**

Non-Operating Time: 185.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,023.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - VOC Ppmvdc 1-Hour Block Average

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 12:07 **Location:** Maxwell, CA

Tag Name: CT1_VOC_Ppmvdc_1H
Total Operating Time: 2,023.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 185.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,023.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 -VOC Lb 1-Day Block Average

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 12:07 **Location:** Maxwell, CA

Tag Name: CT2_VOC_Lb_1D
Total Operating Time: 91.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 1.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**91.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - VOC LbPerHr 1-Hour Block Average

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 12:08 **Location:** Maxwell, CA

Tag Name: CT2_VOC_LbPerHr_1H
Total Operating Time: 2,118.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 90.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,118.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - VOC Ppmvdc 1-Hour Block Average

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 12:09 **Location:** Maxwell, CA

Tag Name: CT2_VOC_Ppmvdc_1H
Total Operating Time: 2,118.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 90.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,118.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 6
Hourly Emissions – NOx

FCD: AQ-15
Title V: #6

Excess Emission Report

CT1 - NOx Lb 1-Day Block Average

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 12:13 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Lb_1D
Total Operating Time: 2,059.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 149.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,059.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx Lb 1-Day Block Average

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:14 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Lb_1D

Total Operating Time: 2,145.00 Hour(s) **No Exclusions Allowed**

Non-Operating Time: 63.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,145.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/01/2019 00:00	2.9	18.2	42.3	6.3	0.08	1	0	0
10/01/2019 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2019 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2019 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2019 04:00	1.9	17.8	412.4	3.6	2.70	1	0	0
10/01/2019 05:00	7.3	14.9	1,149.8	7.2	29.90	1	0	0
10/01/2019 06:00	0.6	14.0	1,625.3	0.5	3.30	1	1	0
10/01/2019 07:00	0.7	14.0	1,615.8	0.6	3.20	1	1	0
10/01/2019 08:00	0.7	14.1	1,628.7	0.6	3.30	1	1	0
10/01/2019 09:00	0.7	14.1	1,613.9	0.6	3.20	1	1	0
10/01/2019 10:00	0.6	14.1	1,594.1	0.5	3.20	1	1	0
10/01/2019 11:00	0.6	14.1	1,600.9	0.5	3.20	1	1	0
10/01/2019 12:00	0.6	14.1	1,584.5	0.5	3.20	1	1	0
10/01/2019 13:00	0.7	14.1	1,585.8	0.6	3.20	1	1	0
10/01/2019 14:00	0.8	14.0	1,557.4	0.7	4.70	1	1	0
10/01/2019 15:00	0.9	14.0	1,577.6	0.8	4.70	1	1	1
10/01/2019 16:00	1.3	12.7	1,976.0	0.9	5.90	1	1	1
10/01/2019 17:00	1.3	12.4	2,020.5	0.9	6.10	1	1	1
10/01/2019 18:00	1.3	12.3	2,037.9	0.9	6.10	1	1	1
10/01/2019 19:00	1.3	12.2	2,041.4	0.9	6.10	1	1	1
10/01/2019 20:00	1.3	12.2	2,042.8	0.9	6.10	1	1	1
10/01/2019 21:00	1.2	12.3	2,029.9	0.8	6.10	1	1	1
10/01/2019 22:00	1.2	12.4	1,999.2	0.8	6.00	1	1	1
10/01/2019 23:00	1.3	12.5	2,009.0	0.9	6.00	1	1	1
Average/Sum#:	1.4	13.8	1,606.9	1.4	116.28 #	21 #	18 #	9 #
Minimum:	0.6	12.2	42.3	0.5	0.08	0	0	0
Maximum:	7.3	18.2	2,042.8	7.2	29.90	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/02/2019 00:00	1.3	12.4	2,056.0	0.9	6.20	1	1	1
10/02/2019 01:00	1.3	12.4	2,044.5	0.9	6.10	1	1	1
10/02/2019 02:00	1.3	12.4	2,031.7	0.9	6.10	1	1	1
10/02/2019 03:00	1.3	12.4	2,028.5	0.9	6.10	1	1	1
10/02/2019 04:00	1.2	12.6	1,989.4	0.9	6.00	1	1	1
10/02/2019 05:00	1.2	12.3	2,020.9	0.8	6.10	1	1	1
10/02/2019 06:00	1.3	12.5	2,017.8	0.9	6.10	1	1	1
10/02/2019 07:00	1.2	12.9	1,924.7	0.9	5.80	1	1	1
10/02/2019 08:00	0.6	14.1	1,560.2	0.5	3.10	1	1	0
10/02/2019 09:00	0.4	14.1	1,254.3	0.3	1.30	1	1	0
10/02/2019 10:00	0.4	14.1	1,263.2	0.3	1.30	1	1	0
10/02/2019 11:00	0.4	14.2	1,285.9	0.4	1.30	1	1	0
10/02/2019 12:00	0.4	14.2	1,257.9	0.4	1.30	1	1	0
10/02/2019 13:00	0.4	14.2	1,276.3	0.4	1.30	1	1	0
10/02/2019 14:00	0.7	14.0	1,537.0	0.6	3.10	1	1	1
10/02/2019 15:00	1.3	12.7	1,966.4	0.9	5.90	1	1	1
10/02/2019 16:00	1.3	12.2	2,051.6	0.9	6.20	1	1	1
10/02/2019 17:00	1.4	12.1	2,072.2	0.9	6.20	1	1	1
10/02/2019 18:00	1.3	12.2	2,065.4	0.9	6.20	1	1	1
10/02/2019 19:00	1.3	12.1	2,064.0	0.9	6.20	1	1	1
10/02/2019 20:00	1.3	12.1	2,060.4	0.9	6.20	1	1	1
10/02/2019 21:00	1.3	12.2	2,035.8	0.9	6.10	1	1	1
10/02/2019 22:00	1.3	12.4	2,005.7	0.9	6.00	1	1	1
10/02/2019 23:00	1.2	12.7	1,971.1	0.9	5.90	1	1	1
Average/Sum#:	1.0	12.9	1,826.7	0.8	116.10 #	24 #	24 #	18 #
Minimum:	0.4	12.1	1,254.3	0.3	1.30	1	1	0
Maximum:	1.4	14.2	2,072.2	0.9	6.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/03/2019 00:00	1.3	12.6	1,974.8	0.9	5.90	1	1	1
10/03/2019 01:00	1.2	12.9	1,912.3	0.9	5.70	1	1	1
10/03/2019 02:00	1.3	12.7	1,964.7	0.9	5.90	1	1	1
10/03/2019 03:00	1.3	12.5	1,997.3	0.9	6.00	1	1	1
10/03/2019 04:00	1.3	12.5	2,015.1	0.9	6.00	1	1	1
10/03/2019 05:00	1.1	12.5	2,007.9	0.8	6.00	1	1	1
10/03/2019 06:00	1.3	12.4	2,026.9	0.9	6.10	1	1	1
10/03/2019 07:00	1.2	12.7	1,928.3	0.9	5.80	1	1	1
10/03/2019 08:00	0.7	14.0	1,450.1	0.6	2.90	1	1	0
10/03/2019 09:00	0.5	14.1	1,259.2	0.4	2.50	1	1	0
10/03/2019 10:00	0.5	14.1	1,247.4	0.4	2.50	1	1	0
10/03/2019 11:00	0.5	14.1	1,248.7	0.4	2.50	1	1	0
10/03/2019 12:00	0.5	14.1	1,307.6	0.4	2.60	1	1	0
10/03/2019 13:00	0.5	14.1	1,290.2	0.4	2.60	1	1	0
10/03/2019 14:00	0.6	14.1	1,343.0	0.5	2.70	1	1	0
10/03/2019 15:00	0.6	14.1	1,353.6	0.5	2.70	1	1	0
10/03/2019 16:00	0.9	14.0	1,595.8	0.8	4.80	1	1	0
10/03/2019 17:00	0.9	14.0	1,582.6	0.8	4.70	1	1	0
10/03/2019 18:00	0.9	14.0	1,585.6	0.8	4.80	1	1	0
10/03/2019 19:00	0.8	14.0	1,613.7	0.7	4.80	1	1	0
10/03/2019 20:00	0.7	14.1	1,594.8	0.6	3.20	1	1	0
10/03/2019 21:00	1.7	14.7	1,232.4	1.6	5.33	1	0	0
10/03/2019 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/03/2019 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.9	13.6	1,615.1	0.7	96.03 #	22 #	21 #	8 #
Minimum:	0.5	12.4	1,232.4	0.4	2.50	0	0	0
Maximum:	1.7	14.7	2,026.9	1.6	6.10	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2019 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2019 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2019 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2019 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2019 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2019 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2019 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2019 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2019 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2019 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2019 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2019 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2019 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2019 13:00	24.8	18.0	387.9	50.5	30.28	1	0	0
10/04/2019 14:00	21.0	15.3	914.2	22.1	75.00	1	0	0
10/04/2019 15:00	0.4	14.2	1,414.6	0.4	1.40	1	1	0
10/04/2019 16:00	0.8	14.1	1,507.0	0.7	4.50	1	1	1
10/04/2019 17:00	1.3	12.8	1,963.5	0.9	5.90	1	1	1
10/04/2019 18:00	1.3	12.2	2,093.2	0.9	6.30	1	1	1
10/04/2019 19:00	1.3	12.3	2,036.0	0.9	6.10	1	1	1
10/04/2019 20:00	1.3	12.2	2,046.2	0.9	6.10	1	1	1
10/04/2019 21:00	1.3	12.3	2,037.7	0.9	6.10	1	1	1
10/04/2019 22:00	1.2	12.4	2,015.0	0.8	6.00	1	1	1
10/04/2019 23:00	1.2	12.5	1,999.3	0.8	6.00	1	1	1
Average/Sum#:	5.1	13.5	1,674.1	7.3	153.68 #	11 #	9 #	8 #
Minimum:	0.4	12.2	387.9	0.4	1.40	0	0	0
Maximum:	24.8	18.0	2,093.2	50.5	75.00	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/05/2019 00:00	1.2	12.7	1,959.8	0.9	5.90	1	1	1
10/05/2019 01:00	1.2	12.8	1,941.2	0.9	5.80	1	1	1
10/05/2019 02:00	1.2	13.0	1,904.4	0.9	5.70	1	1	1
10/05/2019 03:00	1.2	12.6	1,979.6	0.9	5.90	1	1	1
10/05/2019 04:00	1.2	12.5	2,008.3	0.8	6.00	1	1	1
10/05/2019 05:00	1.0	12.3	2,034.5	0.7	6.10	1	1	1
10/05/2019 06:00	1.2	12.7	1,981.1	0.9	5.90	1	1	1
10/05/2019 07:00	1.2	13.0	1,890.7	0.9	5.70	1	1	1
10/05/2019 08:00	0.7	14.0	1,495.3	0.6	3.00	1	1	0
10/05/2019 09:00	0.5	14.2	1,248.9	0.4	2.50	1	1	0
10/05/2019 10:00	0.5	14.2	1,243.4	0.4	2.50	1	1	0
10/05/2019 11:00	0.4	14.2	1,249.6	0.4	1.20	1	1	0
10/05/2019 12:00	0.5	14.2	1,297.4	0.4	2.60	1	1	0
10/05/2019 13:00	0.4	14.2	1,249.9	0.4	1.20	1	1	0
10/05/2019 14:00	0.7	14.2	1,429.4	0.6	2.90	1	1	0
10/05/2019 15:00	0.7	14.0	1,477.3	0.6	3.00	1	1	1
10/05/2019 16:00	1.3	12.8	1,930.6	0.9	5.80	1	1	1
10/05/2019 17:00	1.3	12.4	2,014.8	0.9	6.00	1	1	1
10/05/2019 18:00	1.3	12.4	2,021.5	0.9	6.10	1	1	1
10/05/2019 19:00	1.3	12.3	2,039.0	0.9	6.10	1	1	1
10/05/2019 20:00	1.3	12.1	2,077.2	0.9	6.20	1	1	1
10/05/2019 21:00	1.3	12.1	2,081.1	0.9	6.20	1	1	1
10/05/2019 22:00	1.3	12.2	2,048.9	0.9	6.10	1	1	1
10/05/2019 23:00	1.3	12.3	2,049.9	0.9	6.10	1	1	1
Average/Sum#:	1.0	13.1	1,777.2	0.7	114.50 #	24 #	24 #	17 #
Minimum:	0.4	12.1	1,243.4	0.4	1.20	1	1	0
Maximum:	1.3	14.2	2,081.1	0.9	6.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/06/2019 00:00	1.3	12.3	2,028.2	0.9	6.10	1	1	1
10/06/2019 01:00	1.3	12.6	1,974.3	0.9	5.90	1	1	1
10/06/2019 02:00	1.3	12.6	1,977.7	0.9	5.90	1	1	1
10/06/2019 03:00	1.3	12.6	1,977.2	0.9	5.90	1	1	1
10/06/2019 04:00	1.3	12.5	1,968.9	0.9	5.90	1	1	1
10/06/2019 05:00	1.0	12.4	1,976.0	0.7	5.90	1	1	1
10/06/2019 06:00	1.2	12.7	1,916.2	0.9	5.70	1	1	1
10/06/2019 07:00	0.7	14.1	1,478.5	0.6	3.00	1	1	0
10/06/2019 08:00	0.5	14.2	1,311.8	0.4	2.60	1	1	0
10/06/2019 09:00	0.4	14.2	1,235.3	0.4	1.20	1	1	0
10/06/2019 10:00	0.4	14.2	1,290.1	0.4	1.30	1	1	0
10/06/2019 11:00	0.5	14.2	1,320.5	0.4	2.60	1	1	0
10/06/2019 12:00	0.5	14.2	1,354.5	0.4	2.70	1	1	0
10/06/2019 13:00	0.5	14.2	1,326.5	0.4	2.70	1	1	0
10/06/2019 14:00	0.8	14.0	1,550.8	0.7	4.70	1	1	1
10/06/2019 15:00	1.3	12.5	1,975.8	0.9	5.90	1	1	1
10/06/2019 16:00	1.3	12.2	2,044.0	0.9	6.10	1	1	1
10/06/2019 17:00	1.4	11.8	2,113.5	0.9	6.30	1	1	1
10/06/2019 18:00	1.4	11.7	2,145.2	0.9	6.40	1	1	1
10/06/2019 19:00	1.4	12.0	2,081.7	0.9	6.20	1	1	1
10/06/2019 20:00	1.3	12.1	2,063.8	0.9	6.20	1	1	1
10/06/2019 21:00	1.3	12.1	2,069.2	0.9	6.20	1	1	1
10/06/2019 22:00	1.3	12.4	2,029.3	0.9	6.10	1	1	1
10/06/2019 23:00	1.3	12.6	1,971.4	0.9	5.90	1	1	1
Average/Sum#:	1.0	12.9	1,799.2	0.7	117.40 #	24 #	24 #	17 #
Minimum:	0.4	11.7	1,235.3	0.4	1.20	1	1	0
Maximum:	1.4	14.2	2,145.2	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/07/2019 00:00	1.2	12.6	1,953.0	0.9	5.90	1	1	1
10/07/2019 01:00	1.2	12.5	1,972.6	0.8	5.90	1	1	1
10/07/2019 02:00	1.2	12.6	1,946.1	0.9	5.80	1	1	1
10/07/2019 03:00	1.3	12.6	1,979.6	0.9	5.90	1	1	1
10/07/2019 04:00	1.3	12.3	2,020.0	0.9	6.10	1	1	1
10/07/2019 05:00	1.3	12.3	2,006.1	0.9	6.00	1	1	1
10/07/2019 06:00	1.3	12.4	2,028.9	0.9	6.10	1	1	1
10/07/2019 07:00	1.3	12.5	2,016.6	0.9	6.00	1	1	1
10/07/2019 08:00	1.3	12.4	2,010.8	0.9	6.00	1	1	1
10/07/2019 09:00	1.3	12.4	2,028.9	0.9	6.10	1	1	1
10/07/2019 10:00	1.3	12.4	2,005.9	0.9	6.00	1	1	1
10/07/2019 11:00	1.2	12.5	1,984.6	0.8	6.00	1	1	1
10/07/2019 12:00	1.3	12.4	1,984.8	0.9	6.00	1	1	1
10/07/2019 13:00	1.3	12.3	2,008.6	0.9	6.00	1	1	1
10/07/2019 14:00	1.3	12.3	2,009.2	0.9	6.00	1	1	1
10/07/2019 15:00	1.3	12.3	2,005.4	0.9	6.00	1	1	1
10/07/2019 16:00	1.4	12.0	2,063.4	0.9	6.20	1	1	1
10/07/2019 17:00	1.4	11.7	2,111.3	0.9	6.30	1	1	1
10/07/2019 18:00	1.4	11.8	2,108.8	0.9	6.30	1	1	1
10/07/2019 19:00	1.3	12.0	2,054.5	0.9	6.20	1	1	1
10/07/2019 20:00	1.3	12.1	2,046.3	0.9	6.10	1	1	1
10/07/2019 21:00	1.3	12.4	2,008.2	0.9	6.00	1	1	1
10/07/2019 22:00	1.3	12.3	2,026.2	0.9	6.10	1	1	1
10/07/2019 23:00	1.3	12.6	1,961.2	0.9	5.90	1	1	1
Average/Sum#:	1.3	12.3	2,014.2	0.9	144.90 #	24 #	24 #	24 #
Minimum:	1.2	11.7	1,946.1	0.8	5.80	1	1	1
Maximum:	1.4	12.6	2,111.3	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/08/2019 00:00	1.3	12.8	1,913.4	0.9	5.70	1	1	1
10/08/2019 01:00	1.2	13.1	1,852.1	0.9	5.60	1	1	1
10/08/2019 02:00	1.2	13.2	1,856.3	0.9	5.60	1	1	1
10/08/2019 03:00	1.3	12.9	1,910.0	1.0	7.60	1	1	1
10/08/2019 04:00	1.3	12.8	1,925.0	0.9	5.80	1	1	1
10/08/2019 05:00	1.1	12.3	2,012.4	0.8	6.00	1	1	1
10/08/2019 06:00	1.3	12.3	2,007.0	0.9	6.00	1	1	1
10/08/2019 07:00	1.2	12.5	1,974.9	0.8	5.90	1	1	1
10/08/2019 08:00	1.3	12.5	1,968.7	0.9	5.90	1	1	1
10/08/2019 09:00	1.3	12.5	1,960.4	0.9	5.90	1	1	1
10/08/2019 10:00	1.2	12.4	1,961.8	0.8	5.90	1	1	1
10/08/2019 11:00	1.3	12.3	1,964.8	0.9	5.90	1	1	1
10/08/2019 12:00	1.2	12.2	1,981.7	0.8	5.90	1	1	1
10/08/2019 13:00	1.3	12.3	1,991.0	0.9	6.00	1	1	1
10/08/2019 14:00	1.3	12.4	1,974.8	0.9	5.90	1	1	1
10/08/2019 15:00	1.3	12.3	2,000.2	0.9	6.00	1	1	1
10/08/2019 16:00	1.4	12.1	2,047.2	0.9	6.10	1	1	1
10/08/2019 17:00	1.4	11.8	2,090.4	0.9	6.30	1	1	1
10/08/2019 18:00	1.4	11.9	2,070.3	0.9	6.20	1	1	1
10/08/2019 19:00	1.3	12.0	2,056.2	0.9	6.20	1	1	1
10/08/2019 20:00	1.3	12.0	2,057.4	0.9	6.20	1	1	1
10/08/2019 21:00	1.3	12.2	2,023.9	0.9	6.10	1	1	1
10/08/2019 22:00	1.2	12.5	1,940.0	0.8	5.80	1	1	1
10/08/2019 23:00	1.2	12.4	1,967.7	0.8	5.90	1	1	1
Average/Sum#:	1.3	12.4	1,979.5	0.9	144.40 #	24 #	24 #	24 #
Minimum:	1.1	11.8	1,852.1	0.8	5.60	1	1	1
Maximum:	1.4	13.2	2,090.4	1.0	7.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/09/2019 00:00	1.2	12.4	1,975.5	0.8	5.90	1	1	1
10/09/2019 01:00	1.2	12.9	1,895.4	0.9	5.70	1	1	1
10/09/2019 02:00	1.2	12.8	1,920.1	0.9	5.80	1	1	1
10/09/2019 03:00	1.2	12.5	1,981.7	0.8	5.90	1	1	1
10/09/2019 04:00	1.3	12.4	2,006.7	0.9	6.00	1	1	1
10/09/2019 05:00	1.3	12.4	2,000.6	0.9	6.00	1	1	1
10/09/2019 06:00	1.3	12.2	2,057.8	0.9	6.20	1	1	1
10/09/2019 07:00	1.2	12.4	2,019.5	0.8	6.10	1	1	1
10/09/2019 08:00	1.2	12.5	1,982.1	0.8	5.90	1	1	1
10/09/2019 09:00	1.2	12.5	1,996.4	0.8	6.00	1	1	1
10/09/2019 10:00	1.2	12.4	2,005.0	0.8	6.00	1	1	1
10/09/2019 11:00	0.6	14.1	1,624.7	0.5	3.20	1	1	0
10/09/2019 12:00	0.6	14.2	1,608.8	0.5	3.20	1	1	0
10/09/2019 13:00	0.6	14.1	1,555.0	0.5	3.10	1	1	0
10/09/2019 14:00	0.6	14.2	1,475.5	0.5	3.00	1	1	0
10/09/2019 15:00	0.7	14.1	1,484.0	0.6	3.00	1	1	1
10/09/2019 16:00	1.2	13.0	1,828.1	0.9	5.50	1	1	1
10/09/2019 17:00	1.3	12.6	1,987.9	0.9	6.00	1	1	1
10/09/2019 18:00	1.3	12.7	1,973.2	0.9	5.90	1	1	1
10/09/2019 19:00	1.3	12.5	1,979.7	0.9	5.90	1	1	1
10/09/2019 20:00	1.3	12.5	1,987.3	0.9	6.00	1	1	1
10/09/2019 21:00	1.2	12.5	1,982.7	0.8	5.90	1	1	1
10/09/2019 22:00	1.2	12.5	1,990.8	0.8	6.00	1	1	1
10/09/2019 23:00	1.3	12.6	1,979.2	0.9	5.90	1	1	1
Average/Sum#:	1.1	12.9	1,887.4	0.8	128.10 #	24 #	24 #	20 #
Minimum:	0.6	12.2	1,475.5	0.5	3.00	1	1	0
Maximum:	1.3	14.2	2,057.8	0.9	6.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/10/2019 00:00	1.2	12.6	1,978.3	0.9	5.90	1	1	1
10/10/2019 01:00	1.2	13.2	1,873.7	0.9	5.60	1	1	1
10/10/2019 02:00	1.2	13.0	1,915.8	0.9	5.70	1	1	1
10/10/2019 03:00	1.2	12.7	1,968.6	0.9	5.90	1	1	1
10/10/2019 04:00	1.2	12.7	1,969.9	0.9	5.90	1	1	1
10/10/2019 05:00	1.0	12.7	1,968.4	0.7	5.90	1	1	1
10/10/2019 06:00	1.3	12.6	2,001.8	0.9	6.00	1	1	1
10/10/2019 07:00	1.2	12.9	1,907.1	0.9	5.70	1	1	1
10/10/2019 08:00	0.5	14.1	1,446.8	0.4	2.90	1	1	0
10/10/2019 09:00	0.6	14.1	1,575.1	0.5	3.20	1	1	0
10/10/2019 10:00	0.6	14.1	1,609.9	0.5	3.20	1	1	0
10/10/2019 11:00	0.6	14.1	1,602.9	0.5	3.20	1	1	0
10/10/2019 12:00	0.7	14.2	1,613.2	0.6	3.20	1	1	0
10/10/2019 13:00	0.6	14.2	1,577.3	0.5	3.20	1	1	0
10/10/2019 14:00	0.7	14.1	1,592.7	0.6	3.20	1	1	0
10/10/2019 15:00	0.8	14.1	1,494.6	0.7	4.50	1	1	1
10/10/2019 16:00	1.3	12.4	1,979.9	0.9	5.90	1	1	1
10/10/2019 17:00	1.2	12.5	1,957.8	0.8	5.90	1	1	1
10/10/2019 18:00	1.3	12.3	2,032.2	0.9	6.10	1	1	1
10/10/2019 19:00	1.3	12.4	2,017.2	0.9	6.10	1	1	1
10/10/2019 20:00	1.3	12.4	2,019.8	0.9	6.10	1	1	1
10/10/2019 21:00	1.3	12.4	2,024.1	0.9	6.10	1	1	1
10/10/2019 22:00	1.3	12.4	2,017.3	0.9	6.10	1	1	1
10/10/2019 23:00	1.2	12.7	1,933.5	0.9	5.80	1	1	1
Average/Sum#:	1.0	13.1	1,836.6	0.8	121.30 #	24 #	24 #	17 #
Minimum:	0.5	12.3	1,446.8	0.4	2.90	1	1	0
Maximum:	1.3	14.2	2,032.2	0.9	6.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/11/2019 00:00	1.2	12.8	1,921.0	0.9	5.80	1	1	1
10/11/2019 01:00	1.2	13.2	1,849.5	0.9	5.50	1	1	1
10/11/2019 02:00	1.2	13.2	1,849.2	0.9	5.50	1	1	1
10/11/2019 03:00	1.2	13.2	1,852.3	0.9	5.60	1	1	1
10/11/2019 04:00	1.2	13.2	1,853.9	0.9	5.60	1	1	1
10/11/2019 05:00	0.4	14.1	1,636.2	0.3	1.60	1	1	1
10/11/2019 06:00	0.5	14.1	1,619.2	0.4	3.20	1	1	0
10/11/2019 07:00	0.4	14.2	1,381.8	0.4	1.40	1	1	0
10/11/2019 08:00	0.4	14.2	1,234.2	0.4	1.20	1	1	0
10/11/2019 09:00	0.4	14.2	1,232.1	0.4	1.20	1	1	0
10/11/2019 10:00	0.4	14.2	1,230.5	0.4	1.20	1	1	0
10/11/2019 11:00	0.4	14.2	1,230.6	0.4	1.20	1	1	0
10/11/2019 12:00	0.4	14.2	1,232.3	0.4	1.20	1	1	0
10/11/2019 13:00	0.4	14.2	1,264.1	0.4	1.30	1	1	0
10/11/2019 14:00	0.7	14.0	1,609.3	0.6	3.20	1	1	0
10/11/2019 15:00	0.7	14.0	1,542.3	0.6	3.10	1	1	1
10/11/2019 16:00	1.3	12.7	1,964.1	0.9	5.90	1	1	1
10/11/2019 17:00	1.4	11.9	2,106.6	0.9	6.30	1	1	1
10/11/2019 18:00	1.4	11.7	2,141.4	0.9	6.40	1	1	1
10/11/2019 19:00	1.4	12.2	2,051.6	0.9	6.20	1	1	1
10/11/2019 20:00	1.3	12.3	2,037.1	0.9	6.10	1	1	1
10/11/2019 21:00	1.3	12.3	2,047.1	0.9	6.10	1	1	1
10/11/2019 22:00	1.3	12.4	2,035.8	0.9	6.10	1	1	1
10/11/2019 23:00	1.3	12.4	2,030.9	0.9	6.10	1	1	1
Average/Sum#:	0.9	13.3	1,706.4	0.7	97.00 #	24 #	24 #	15 #
Minimum:	0.4	11.7	1,230.5	0.3	1.20	1	1	0
Maximum:	1.4	14.2	2,141.4	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/12/2019 00:00	1.3	12.3	2,026.7	0.9	6.10	1	1	1
10/12/2019 01:00	1.3	12.4	1,990.5	0.9	6.00	1	1	1
10/12/2019 02:00	1.3	12.4	2,002.0	0.9	6.00	1	1	1
10/12/2019 03:00	1.3	12.4	2,017.3	0.9	6.10	1	1	1
10/12/2019 04:00	1.3	12.3	2,020.6	0.9	6.10	1	1	1
10/12/2019 05:00	1.4	12.2	2,033.2	0.9	6.10	1	1	1
10/12/2019 06:00	1.3	12.3	2,037.8	0.9	6.10	1	1	1
10/12/2019 07:00	3.1	14.1	1,219.8	2.7	6.10	1	0	1
10/12/2019 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2019 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2019 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2019 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2019 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2019 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2019 14:00	9.1	17.9	390.1	17.9	11.57	1	0	0
10/12/2019 15:00	14.2	15.2	989.1	14.7	53.40	1	0	0
10/12/2019 16:00	0.7	14.1	1,604.4	0.6	3.20	1	1	0
10/12/2019 17:00	1.2	13.5	1,741.4	1.0	7.00	1	1	1
10/12/2019 18:00	2.1	12.3	2,020.1	1.4	10.10	1	1	1
10/12/2019 19:00	2.3	12.2	2,042.2	1.6	12.30	1	1	1
10/12/2019 20:00	1.5	12.3	2,037.0	1.0	8.10	1	1	1
10/12/2019 21:00	1.3	12.2	2,052.3	0.9	6.20	1	1	1
10/12/2019 22:00	1.3	12.3	2,029.9	0.9	6.10	1	1	1
10/12/2019 23:00	1.3	12.3	2,056.3	0.9	6.20	1	1	1
Average/Sum#:	2.6	13.0	1,795.0	2.8	172.77 #	18 #	15 #	15 #
Minimum:	0.7	12.2	390.1	0.6	3.20	0	0	0
Maximum:	14.2	17.9	2,056.3	17.9	53.40	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/13/2019 00:00	1.3	12.3	2,026.8	0.9	6.10	1	1	1
10/13/2019 01:00	1.3	12.3	2,027.3	0.9	6.10	1	1	1
10/13/2019 02:00	1.3	12.3	2,025.9	0.9	6.10	1	1	1
10/13/2019 03:00	1.3	12.3	2,026.9	0.9	6.10	1	1	1
10/13/2019 04:00	1.3	12.3	2,028.3	0.9	6.10	1	1	1
10/13/2019 05:00	1.3	12.3	2,029.4	0.9	6.10	1	1	1
10/13/2019 06:00	1.3	12.4	1,969.0	0.9	5.90	1	1	1
10/13/2019 07:00	0.6	14.1	1,477.2	0.5	3.00	1	1	1
10/13/2019 08:00	0.6	14.1	1,587.3	0.5	3.20	1	1	0
10/13/2019 09:00	0.7	14.1	1,612.4	0.6	3.20	1	1	0
10/13/2019 10:00	0.7	14.1	1,605.5	0.6	3.20	1	1	0
10/13/2019 11:00	0.6	14.1	1,484.2	0.5	3.00	1	1	0
10/13/2019 12:00	0.8	14.1	1,613.6	0.7	4.80	1	1	0
10/13/2019 13:00	0.6	14.1	1,505.0	0.5	3.00	1	1	0
10/13/2019 14:00	0.9	14.1	1,600.6	0.8	4.80	1	1	0
10/13/2019 15:00	0.7	14.0	1,509.0	0.6	3.00	1	1	1
10/13/2019 16:00	1.3	12.5	1,975.9	0.9	5.90	1	1	1
10/13/2019 17:00	1.4	12.0	2,063.5	0.9	6.20	1	1	1
10/13/2019 18:00	1.3	12.2	2,036.2	0.9	6.10	1	1	1
10/13/2019 19:00	1.3	12.3	2,017.4	0.9	6.10	1	1	1
10/13/2019 20:00	1.3	12.4	2,015.0	0.9	6.00	1	1	1
10/13/2019 21:00	1.4	12.2	2,039.3	0.9	6.10	1	1	1
10/13/2019 22:00	1.1	13.0	1,801.6	0.8	5.40	1	1	1
10/13/2019 23:00	2.5	15.0	968.5	2.5	3.65	1	0	0
Average/Sum#:	1.1	13.1	1,793.6	0.8	119.15 #	24 #	23 #	16 #
Minimum:	0.6	12.0	968.5	0.5	3.00	1	0	0
Maximum:	2.5	15.0	2,063.5	2.5	6.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/14/2019 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2019 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2019 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2019 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2019 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2019 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2019 06:00	1.3	18.4	370.6	3.1	1.11	1	0	0
10/14/2019 07:00	10.3	14.9	1,000.6	10.1	37.00	1	0	0
10/14/2019 08:00	0.4	14.0	1,459.7	0.3	1.50	1	1	0
10/14/2019 09:00	0.5	14.1	1,251.1	0.4	2.50	1	1	0
10/14/2019 10:00	0.4	14.2	1,237.2	0.4	1.20	1	1	0
10/14/2019 11:00	0.5	14.2	1,306.3	0.4	2.60	1	1	0
10/14/2019 12:00	0.6	14.1	1,440.3	0.5	2.90	1	1	0
10/14/2019 13:00	0.9	13.9	1,556.7	0.8	4.70	1	1	1
10/14/2019 14:00	1.2	13.1	1,937.9	0.9	5.80	1	1	1
10/14/2019 15:00	1.2	12.4	1,992.8	0.8	6.00	1	1	1
10/14/2019 16:00	1.4	12.1	2,052.5	0.9	6.20	1	1	1
10/14/2019 17:00	1.4	11.8	2,111.5	0.9	6.30	1	1	1
10/14/2019 18:00	1.4	11.7	2,145.0	0.9	6.40	1	1	1
10/14/2019 19:00	1.4	11.7	2,145.8	0.9	6.40	1	1	1
10/14/2019 20:00	1.4	12.0	2,088.4	0.9	6.30	1	1	1
10/14/2019 21:00	1.3	12.3	2,037.8	0.9	6.10	1	1	1
10/14/2019 22:00	1.3	12.4	2,030.2	0.9	6.10	1	1	1
10/14/2019 23:00	1.3	12.4	2,026.9	0.9	6.10	1	1	1
Average/Sum#:	1.6	13.3	1,677.3	1.4	115.21 #	18 #	16 #	11 #
Minimum:	0.4	11.7	370.6	0.3	1.11	0	0	0
Maximum:	10.3	18.4	2,145.8	10.1	37.00	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/15/2019 00:00	1.3	12.4	2,031.7	0.9	6.10	1	1	1
10/15/2019 01:00	1.3	12.4	2,022.6	0.9	6.10	1	1	1
10/15/2019 02:00	1.3	12.4	2,030.7	0.9	6.10	1	1	1
10/15/2019 03:00	1.3	12.5	2,021.2	0.9	6.10	1	1	1
10/15/2019 04:00	1.3	12.4	2,018.6	0.9	6.10	1	1	1
10/15/2019 05:00	1.9	14.4	1,483.8	1.7	6.85	1	0	1
10/15/2019 06:00	3.9	17.5	471.5	6.8	4.72	1	0	0
10/15/2019 07:00	5.6	13.9	1,506.9	4.7	25.60	1	0	1
10/15/2019 08:00	0.6	14.1	1,470.6	0.5	2.90	1	1	0
10/15/2019 09:00	0.5	14.1	1,304.8	0.4	2.60	1	1	0
10/15/2019 10:00	0.5	14.1	1,279.7	0.4	2.60	1	1	0
10/15/2019 11:00	0.5	14.1	1,313.0	0.4	2.60	1	1	0
10/15/2019 12:00	0.7	14.1	1,395.1	0.6	2.80	1	1	0
10/15/2019 13:00	1.0	14.1	1,611.4	0.9	4.80	1	1	0
10/15/2019 14:00	0.9	13.9	1,604.7	0.8	4.80	1	1	1
10/15/2019 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2019 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2019 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2019 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2019 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2019 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2019 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2019 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2019 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.5	13.8	1,571.1	1.4	90.77 #	15 #	12 #	8 #
Minimum:	0.5	12.4	471.5	0.4	2.60	0	0	0
Maximum:	5.6	17.5	2,031.7	6.8	25.60	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/16/2019 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2019 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2019 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2019 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2019 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2019 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2019 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2019 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2019 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2019 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2019 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2019 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2019 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2019 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2019 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2019 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2019 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2019 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2019 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2019 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2019 20:00	23.0	18.1	371.0	48.5	21.25	1	0	0
10/16/2019 21:00	25.6	15.7	818.9	29.0	87.60	1	0	0
10/16/2019 22:00	0.5	14.0	1,399.1	0.4	2.80	1	1	0
10/16/2019 23:00	0.8	14.0	1,589.3	0.7	4.80	1	1	0
Average/Sum#:	12.5	15.5	1,044.6	19.7	116.45 #	4 #	2 #	0 #
Minimum:	0.5	14.0	371.0	0.4	2.80	0	0	0
Maximum:	25.6	18.1	1,589.3	48.5	87.60	1	1	0
%SI	83.33	83.33	83.33	83.33	83.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/17/2019 00:00	0.8	14.0	1,563.3	0.7	4.70	1	1	0
10/17/2019 01:00	0.9	14.0	1,625.3	0.8	4.90	1	1	1
10/17/2019 02:00	1.2	12.9	1,908.6	0.9	5.70	1	1	1
10/17/2019 03:00	1.2	12.8	1,936.7	0.9	5.80	1	1	1
10/17/2019 04:00	1.2	12.6	1,979.0	0.9	5.90	1	1	1
10/17/2019 05:00	1.2	12.7	1,961.4	0.9	5.90	1	1	1
10/17/2019 06:00	1.3	12.4	2,018.7	0.9	6.10	1	1	1
10/17/2019 07:00	1.2	12.6	1,979.9	0.9	5.90	1	1	1
10/17/2019 08:00	0.9	13.8	1,517.6	0.7	4.60	1	1	1
10/17/2019 09:00	0.8	14.0	1,469.0	0.7	4.40	1	1	0
10/17/2019 10:00	0.8	14.0	1,483.2	0.7	4.40	1	1	0
10/17/2019 11:00	0.8	14.1	1,527.2	0.7	4.60	1	1	0
10/17/2019 12:00	0.6	14.1	1,304.5	0.5	2.60	1	1	0
10/17/2019 13:00	0.8	14.1	1,456.5	0.7	4.40	1	1	0
10/17/2019 14:00	0.8	14.1	1,548.2	0.7	4.60	1	1	0
10/17/2019 15:00	0.8	14.1	1,486.6	0.7	4.50	1	1	1
10/17/2019 16:00	1.2	12.8	1,937.0	0.9	5.80	1	1	1
10/17/2019 17:00	1.3	11.9	2,133.0	0.9	6.40	1	1	1
10/17/2019 18:00	1.3	12.1	2,078.9	0.9	6.20	1	1	1
10/17/2019 19:00	1.3	12.3	2,049.5	0.9	6.10	1	1	1
10/17/2019 20:00	1.3	12.2	2,064.2	0.9	6.20	1	1	1
10/17/2019 21:00	1.2	12.2	2,044.6	0.8	6.10	1	1	1
10/17/2019 22:00	1.2	12.6	1,963.0	0.9	5.90	1	1	1
10/17/2019 23:00	1.2	12.8	1,921.5	0.9	5.80	1	1	1
Average/Sum#:	1.1	13.1	1,789.9	0.8	127.50 #	24 #	24 #	17 #
Minimum:	0.6	11.9	1,304.5	0.5	2.60	1	1	0
Maximum:	1.3	14.1	2,133.0	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/18/2019 00:00	1.2	12.9	1,899.3	0.9	5.70	1	1	1
10/18/2019 01:00	1.2	12.9	1,894.9	0.9	5.70	1	1	1
10/18/2019 02:00	1.1	13.2	1,843.6	0.8	5.50	1	1	1
10/18/2019 03:00	1.2	13.1	1,892.6	0.9	5.70	1	1	1
10/18/2019 04:00	1.2	12.7	1,960.8	0.9	5.90	1	1	1
10/18/2019 05:00	1.2	12.7	1,947.5	0.9	5.80	1	1	1
10/18/2019 06:00	1.3	12.5	2,010.8	0.9	6.00	1	1	1
10/18/2019 07:00	1.1	13.2	1,831.6	0.8	5.50	1	1	1
10/18/2019 08:00	0.7	14.0	1,522.1	0.6	3.00	1	1	0
10/18/2019 09:00	0.8	14.0	1,471.4	0.7	4.40	1	1	0
10/18/2019 10:00	0.8	14.0	1,480.7	0.7	4.40	1	1	0
10/18/2019 11:00	0.8	14.0	1,489.2	0.7	4.50	1	1	0
10/18/2019 12:00	0.8	14.0	1,445.2	0.7	4.30	1	1	0
10/18/2019 13:00	0.9	14.0	1,556.2	0.8	4.70	1	1	0
10/18/2019 14:00	0.9	14.0	1,553.8	0.8	4.70	1	1	0
10/18/2019 15:00	0.9	14.0	1,569.7	0.8	4.70	1	1	1
10/18/2019 16:00	1.3	12.5	1,982.3	0.9	5.90	1	1	1
10/18/2019 17:00	1.3	12.2	2,041.7	0.9	6.10	1	1	1
10/18/2019 18:00	1.2	12.6	1,965.8	0.9	5.90	1	1	1
10/18/2019 19:00	1.3	12.5	1,974.8	0.9	5.90	1	1	1
10/18/2019 20:00	1.3	12.2	2,035.2	0.9	6.10	1	1	1
10/18/2019 21:00	1.3	12.2	2,051.9	0.9	6.20	1	1	1
10/18/2019 22:00	1.2	12.5	1,990.1	0.8	6.00	1	1	1
10/18/2019 23:00	1.3	12.3	2,038.2	0.9	6.10	1	1	1
Average/Sum#:	1.1	13.1	1,810.4	0.8	128.70 #	24 #	24 #	17 #
Minimum:	0.7	12.2	1,445.2	0.6	3.00	1	1	0
Maximum:	1.3	14.0	2,051.9	0.9	6.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/19/2019 00:00	1.2	12.5	1,983.1	0.8	5.90	1	1	1
10/19/2019 01:00	1.2	12.5	1,983.7	0.8	6.00	1	1	1
10/19/2019 02:00	1.3	12.3	2,039.7	0.9	6.10	1	1	1
10/19/2019 03:00	1.3	12.5	1,991.8	0.9	6.00	1	1	1
10/19/2019 04:00	1.2	12.7	1,957.1	0.9	5.90	1	1	1
10/19/2019 05:00	1.1	12.5	1,986.9	0.8	6.00	1	1	1
10/19/2019 06:00	1.2	12.5	1,994.6	0.8	6.00	1	1	1
10/19/2019 07:00	2.4	14.3	1,188.1	2.1	4.75	1	0	1
10/19/2019 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2019 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2019 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2019 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2019 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2019 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2019 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2019 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2019 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2019 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2019 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2019 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2019 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2019 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2019 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2019 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.4	12.7	1,890.6	1.0	46.65 #	8 #	7 #	8 #
Minimum:	1.1	12.3	1,188.1	0.8	4.75	0	0	0
Maximum:	2.4	14.3	2,039.7	2.1	6.10	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/20/2019 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2019 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2019 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2019 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2019 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2019 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2019 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2019 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2019 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2019 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2019 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2019 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2019 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2019 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2019 14:00	29.4	17.5	449.3	51.0	77.74	1	0	0
10/20/2019 15:00	13.1	15.3	991.7	13.8	50.60	1	0	0
10/20/2019 16:00	0.7	14.0	1,552.8	0.6	3.10	1	1	0
10/20/2019 17:00	0.9	14.0	1,638.6	0.8	4.90	1	1	0
10/20/2019 18:00	1.1	13.6	1,789.3	0.9	5.40	1	1	1
10/20/2019 19:00	1.2	12.6	1,988.7	0.9	6.00	1	1	1
10/20/2019 20:00	1.2	12.5	1,999.2	0.8	6.00	1	1	1
10/20/2019 21:00	1.2	12.7	1,972.8	0.9	5.90	1	1	1
10/20/2019 22:00	1.2	12.6	1,979.2	0.9	5.90	1	1	1
10/20/2019 23:00	1.2	12.6	1,987.7	0.9	6.00	1	1	1
Average/Sum#:	5.1	13.7	1,634.9	7.2	171.54 #	10 #	8 #	6 #
Minimum:	0.7	12.5	449.3	0.6	3.10	0	0	0
Maximum:	29.4	17.5	1,999.2	51.0	77.74	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/21/2019 00:00	1.2	12.8	1,929.4	0.9	5.80	1	1	1
10/21/2019 01:00	1.2	12.8	1,930.5	0.9	5.80	1	1	1
10/21/2019 02:00	1.2	12.8	1,925.9	0.9	5.80	1	1	1
10/21/2019 03:00	1.2	12.8	1,928.4	0.9	5.80	1	1	1
10/21/2019 04:00	1.2	12.6	1,995.4	0.9	6.00	1	1	1
10/21/2019 05:00	1.3	12.3	2,025.4	0.9	6.10	1	1	1
10/21/2019 06:00	1.3	12.2	2,083.3	0.9	6.20	1	1	1
10/21/2019 07:00	1.2	12.6	1,923.5	0.9	5.80	1	1	1
10/21/2019 08:00	0.5	14.1	1,251.2	0.4	2.50	1	1	0
10/21/2019 09:00	0.5	14.1	1,245.8	0.4	2.50	1	1	0
10/21/2019 10:00	0.6	14.1	1,395.1	0.5	2.80	1	1	0
10/21/2019 11:00	0.7	14.1	1,459.6	0.6	2.90	1	1	0
10/21/2019 12:00	0.9	14.0	1,554.0	0.8	4.70	1	1	0
10/21/2019 13:00	1.1	13.8	1,706.3	0.9	5.10	1	1	0
10/21/2019 14:00	1.1	13.8	1,731.6	0.9	5.20	1	1	0
10/21/2019 15:00	1.1	13.8	1,731.4	0.9	5.20	1	1	0
10/21/2019 16:00	1.1	13.8	1,731.6	0.9	5.20	1	1	0
10/21/2019 17:00	1.1	13.8	1,736.5	0.9	5.20	1	1	0
10/21/2019 18:00	1.1	13.8	1,739.6	0.9	5.20	1	1	0
10/21/2019 19:00	1.1	13.8	1,741.1	0.9	5.20	1	1	1
10/21/2019 20:00	1.3	12.7	1,964.5	0.9	5.90	1	1	1
10/21/2019 21:00	1.2	12.4	2,016.6	0.8	6.00	1	1	1
10/21/2019 22:00	1.3	12.5	2,009.2	0.9	6.00	1	1	1
10/21/2019 23:00	1.2	12.6	1,975.4	0.9	5.90	1	1	1
Average/Sum#:	1.1	13.3	1,780.5	0.8	122.80 #	24 #	24 #	13 #
Minimum:	0.5	12.2	1,245.8	0.4	2.50	1	1	0
Maximum:	1.3	14.1	2,083.3	0.9	6.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/22/2019 00:00	1.2	12.9	1,931.6	0.9	5.80	1	1	1
10/22/2019 01:00	1.2	12.7	1,940.1	0.9	5.80	1	1	1
10/22/2019 02:00	1.2	12.7	1,936.2	0.9	5.80	1	1	1
10/22/2019 03:00	1.2	12.6	1,947.6	0.9	5.80	1	1	1
10/22/2019 04:00	1.2	12.8	1,948.7	0.9	5.80	1	1	1
10/22/2019 05:00	1.3	12.4	2,005.3	0.9	6.00	1	1	1
10/22/2019 06:00	1.2	12.3	2,041.5	0.8	6.10	1	1	1
10/22/2019 07:00	1.2	12.7	1,974.2	0.9	5.90	1	1	1
10/22/2019 08:00	1.3	12.1	2,090.2	0.9	6.30	1	1	1
10/22/2019 09:00	1.3	12.0	2,120.6	0.9	6.40	1	1	1
10/22/2019 10:00	1.3	12.0	2,118.1	0.9	6.40	1	1	1
10/22/2019 11:00	1.3	11.9	2,114.0	0.9	6.30	1	1	1
10/22/2019 12:00	1.3	11.9	2,107.2	0.9	6.30	1	1	1
10/22/2019 13:00	1.3	11.9	2,102.3	0.9	6.30	1	1	1
10/22/2019 14:00	1.3	11.9	2,095.2	0.9	6.30	1	1	1
10/22/2019 15:00	1.3	11.9	2,091.8	0.9	6.30	1	1	1
10/22/2019 16:00	1.3	12.0	2,091.7	0.9	6.30	1	1	1
10/22/2019 17:00	1.3	11.7	2,146.0	0.8	6.40	1	1	1
10/22/2019 18:00	1.3	12.2	2,056.5	0.9	6.20	1	1	1
10/22/2019 19:00	1.3	12.1	2,080.8	0.9	6.20	1	1	1
10/22/2019 20:00	1.3	12.3	2,028.7	0.9	6.10	1	1	1
10/22/2019 21:00	1.3	12.2	2,045.9	0.9	6.10	1	1	1
10/22/2019 22:00	1.3	12.3	2,017.3	0.9	6.10	1	1	1
10/22/2019 23:00	1.2	12.5	1,988.7	0.8	6.00	1	1	1
Average/Sum#:	1.3	12.3	2,042.5	0.9	147.00 #	24 #	24 #	24 #
Minimum:	1.2	11.7	1,931.6	0.8	5.80	1	1	1
Maximum:	1.3	12.9	2,146.0	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/23/2019 00:00	1.3	12.5	1,983.2	0.9	5.90	1	1	1
10/23/2019 01:00	1.2	12.5	1,981.7	0.8	5.90	1	1	1
10/23/2019 02:00	1.2	12.6	1,967.3	0.9	5.90	1	1	1
10/23/2019 03:00	1.2	12.6	1,974.1	0.9	5.90	1	1	1
10/23/2019 04:00	1.2	12.7	1,950.4	0.9	5.90	1	1	1
10/23/2019 05:00	1.2	12.1	2,044.1	0.8	6.10	1	1	1
10/23/2019 06:00	1.3	12.3	1,996.3	0.9	6.00	1	1	1
10/23/2019 07:00	0.6	14.1	1,319.5	0.5	2.60	1	1	0
10/23/2019 08:00	0.5	14.2	1,253.2	0.4	2.50	1	1	0
10/23/2019 09:00	0.5	14.2	1,248.3	0.4	2.50	1	1	0
10/23/2019 10:00	0.6	14.1	1,369.1	0.5	2.70	1	1	0
10/23/2019 11:00	0.7	14.1	1,449.9	0.6	2.90	1	1	0
10/23/2019 12:00	0.8	14.0	1,564.5	0.7	4.70	1	1	0
10/23/2019 13:00	1.1	13.8	1,732.9	0.9	5.20	1	1	0
10/23/2019 14:00	1.1	13.8	1,730.8	0.9	5.20	1	1	0
10/23/2019 15:00	1.1	13.8	1,729.8	0.9	5.20	1	1	0
10/23/2019 16:00	1.1	13.8	1,732.1	0.9	5.20	1	1	0
10/23/2019 17:00	1.1	13.8	1,734.9	0.9	5.20	1	1	0
10/23/2019 18:00	0.9	14.0	1,695.4	0.8	5.10	1	1	0
10/23/2019 19:00	1.2	13.1	1,865.8	0.9	5.60	1	1	1
10/23/2019 20:00	1.3	12.3	2,056.1	0.9	6.20	1	1	1
10/23/2019 21:00	1.3	12.1	2,092.9	0.9	6.30	1	1	1
10/23/2019 22:00	1.3	12.1	2,085.0	0.9	6.30	1	1	1
10/23/2019 23:00	1.3	12.4	2,029.6	0.9	6.10	1	1	1
Average/Sum#:	1.0	13.2	1,774.5	0.8	121.10 #	24 #	24 #	12 #
Minimum:	0.5	12.1	1,248.3	0.4	2.50	1	1	0
Maximum:	1.3	14.2	2,092.9	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/24/2019 00:00	1.3	12.5	2,004.2	0.9	6.00	1	1	1
10/24/2019 01:00	1.2	12.6	1,978.6	0.9	5.90	1	1	1
10/24/2019 02:00	1.2	13.0	1,912.0	0.9	5.70	1	1	1
10/24/2019 03:00	1.3	12.5	2,024.2	0.9	6.10	1	1	1
10/24/2019 04:00	1.3	12.5	2,027.4	0.9	6.10	1	1	1
10/24/2019 05:00	1.1	12.0	2,093.4	0.7	6.30	1	1	1
10/24/2019 06:00	1.3	12.2	2,076.2	0.9	6.20	1	1	1
10/24/2019 07:00	1.3	12.2	2,072.3	0.9	6.20	1	1	1
10/24/2019 08:00	1.3	12.5	2,022.3	0.9	6.10	1	1	1
10/24/2019 09:00	1.3	12.4	2,034.5	0.9	6.10	1	1	1
10/24/2019 10:00	1.3	12.3	2,042.6	0.9	6.10	1	1	1
10/24/2019 11:00	1.3	12.3	2,046.6	0.9	6.10	1	1	1
10/24/2019 12:00	1.3	12.2	2,057.0	0.9	6.20	1	1	1
10/24/2019 13:00	1.4	12.2	2,072.4	0.9	6.20	1	1	1
10/24/2019 14:00	1.3	12.1	2,084.8	0.9	6.30	1	1	1
10/24/2019 15:00	1.4	11.9	2,116.1	0.9	6.30	1	1	1
10/24/2019 16:00	1.4	11.8	2,134.3	0.9	6.40	1	1	1
10/24/2019 17:00	1.3	12.0	2,100.2	0.9	6.30	1	1	1
10/24/2019 18:00	1.4	12.0	2,096.5	0.9	6.30	1	1	1
10/24/2019 19:00	1.4	11.8	2,144.7	0.9	6.40	1	1	1
10/24/2019 20:00	1.4	11.9	2,132.1	0.9	6.40	1	1	1
10/24/2019 21:00	1.4	12.0	2,093.1	0.9	6.30	1	1	1
10/24/2019 22:00	1.3	12.0	2,081.1	0.9	6.20	1	1	1
10/24/2019 23:00	1.4	12.0	2,104.4	0.9	6.30	1	1	1
Average/Sum#:	1.3	12.2	2,064.6	0.9	148.50 #	24 #	24 #	24 #
Minimum:	1.1	11.8	1,912.0	0.7	5.70	1	1	1
Maximum:	1.4	13.0	2,144.7	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/25/2019 00:00	1.4	12.0	2,108.1	0.9	6.30	1	1	1
10/25/2019 01:00	1.3	12.5	2,005.7	0.9	6.00	1	1	1
10/25/2019 02:00	1.3	12.5	1,973.9	0.9	5.90	1	1	1
10/25/2019 03:00	1.3	12.6	1,970.7	0.9	5.90	1	1	1
10/25/2019 04:00	1.2	12.5	1,999.4	0.8	6.00	1	1	1
10/25/2019 05:00	1.3	12.6	1,986.3	0.9	6.00	1	1	1
10/25/2019 06:00	1.3	12.4	2,033.6	0.9	6.10	1	1	1
10/25/2019 07:00	1.3	12.7	1,981.9	0.9	5.90	1	1	1
10/25/2019 08:00	1.2	13.3	1,857.8	0.9	5.60	1	1	1
10/25/2019 09:00	1.2	13.3	1,858.6	0.9	5.60	1	1	1
10/25/2019 10:00	1.2	13.1	1,889.9	0.9	5.70	1	1	1
10/25/2019 11:00	1.2	13.1	1,886.7	0.9	5.70	1	1	1
10/25/2019 12:00	1.3	12.5	2,006.6	0.9	6.00	1	1	1
10/25/2019 13:00	1.3	12.4	2,009.5	0.9	6.00	1	1	1
10/25/2019 14:00	1.3	12.4	2,007.7	0.9	6.00	1	1	1
10/25/2019 15:00	1.3	12.4	2,010.2	0.9	6.00	1	1	1
10/25/2019 16:00	1.4	12.1	2,076.2	0.9	6.20	1	1	1
10/25/2019 17:00	1.3	12.1	2,061.9	0.9	6.20	1	1	1
10/25/2019 18:00	1.3	12.5	1,989.6	0.9	6.00	1	1	1
10/25/2019 19:00	1.3	12.5	1,989.1	0.9	6.00	1	1	1
10/25/2019 20:00	1.4	12.2	2,052.9	0.9	6.20	1	1	1
10/25/2019 21:00	1.4	12.1	2,082.8	0.9	6.20	1	1	1
10/25/2019 22:00	1.3	12.4	2,030.9	0.9	6.10	1	1	1
10/25/2019 23:00	1.3	12.4	2,024.0	0.9	6.10	1	1	1
Average/Sum#:	1.3	12.5	1,995.6	0.9	143.70 #	24 #	24 #	24 #
Minimum:	1.2	12.0	1,857.8	0.8	5.60	1	1	1
Maximum:	1.4	13.3	2,108.1	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/26/2019 00:00	1.3	12.5	1,965.9	0.9	5.90	1	1	1
10/26/2019 01:00	1.2	12.4	1,996.6	0.8	6.00	1	1	1
10/26/2019 02:00	1.3	12.4	1,988.5	0.9	6.00	1	1	1
10/26/2019 03:00	1.2	12.5	1,983.2	0.8	5.90	1	1	1
10/26/2019 04:00	1.3	12.5	1,985.1	0.9	6.00	1	1	1
10/26/2019 05:00	1.1	13.0	1,915.2	0.8	5.70	1	1	1
10/26/2019 06:00	1.2	12.9	1,903.5	0.9	5.70	1	1	1
10/26/2019 07:00	0.8	14.0	1,476.3	0.7	4.40	1	1	0
10/26/2019 08:00	0.8	14.1	1,575.6	0.7	4.70	1	1	0
10/26/2019 09:00	0.7	14.1	1,569.9	0.6	3.10	1	1	0
10/26/2019 10:00	0.8	14.1	1,458.2	0.7	4.40	1	1	0
10/26/2019 11:00	0.9	14.0	1,419.2	0.8	4.30	1	1	0
10/26/2019 12:00	0.8	14.1	1,514.4	0.7	4.50	1	1	0
10/26/2019 13:00	1.0	14.0	1,582.0	0.9	4.70	1	1	0
10/26/2019 14:00	0.7	14.1	1,466.6	0.6	2.90	1	1	0
10/26/2019 15:00	0.8	14.0	1,480.6	0.7	4.40	1	1	1
10/26/2019 16:00	1.3	12.8	1,923.2	0.9	5.80	1	1	1
10/26/2019 17:00	1.3	12.4	1,995.4	0.9	6.00	1	1	1
10/26/2019 18:00	1.3	12.4	1,992.8	0.9	6.00	1	1	1
10/26/2019 19:00	1.3	12.5	1,990.6	0.9	6.00	1	1	1
10/26/2019 20:00	1.3	12.4	2,001.5	0.9	6.00	1	1	1
10/26/2019 21:00	1.3	12.5	2,001.5	0.9	6.00	1	1	1
10/26/2019 22:00	2.8	14.5	1,137.4	2.6	5.47	1	0	1
10/26/2019 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.2	13.2	1,753.2	0.9	119.87 #	23 #	22 #	15 #
Minimum:	0.7	12.4	1,137.4	0.6	2.90	0	0	0
Maximum:	2.8	14.5	2,001.5	2.6	6.00	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/27/2019 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/28/2019 00:00	20.7	18.6	329.6	53.1	16.15	1	0	0
10/28/2019 01:00	34.4	16.2	697.2	43.2	110.90	1	0	0
10/28/2019 02:00	0.4	14.1	1,323.7	0.3	1.30	1	1	0
10/28/2019 03:00	0.8	14.0	1,554.3	0.7	4.70	1	1	1
10/28/2019 04:00	1.3	13.1	1,907.1	1.0	7.60	1	1	1
10/28/2019 05:00	1.3	12.7	1,955.9	0.9	5.90	1	1	1
10/28/2019 06:00	1.3	12.0	2,125.2	0.9	6.40	1	1	1
10/28/2019 07:00	1.3	12.5	2,020.1	0.9	6.10	1	1	1
10/28/2019 08:00	1.3	12.7	1,975.7	0.9	5.90	1	1	1
10/28/2019 09:00	1.2	12.7	1,981.6	0.9	5.90	1	1	1
10/28/2019 10:00	1.2	12.7	1,973.6	0.9	5.90	1	1	1
10/28/2019 11:00	1.3	13.0	1,947.0	1.0	7.80	1	1	1
10/28/2019 12:00	1.3	12.8	1,974.1	0.9	5.90	1	1	1
10/28/2019 13:00	1.3	12.8	1,956.0	0.9	5.90	1	1	1
10/28/2019 14:00	1.3	12.8	1,976.3	0.9	5.90	1	1	1
10/28/2019 15:00	1.3	12.6	2,004.3	0.9	6.00	1	1	1
10/28/2019 16:00	1.4	12.3	2,068.2	1.0	8.30	1	1	1
10/28/2019 17:00	1.4	11.7	2,173.4	0.9	6.50	1	1	1
10/28/2019 18:00	1.4	12.1	2,107.8	0.9	6.30	1	1	1
10/28/2019 19:00	1.3	12.2	2,092.5	0.9	6.30	1	1	1
10/28/2019 20:00	1.3	12.2	2,069.5	0.9	6.20	1	1	1
10/28/2019 21:00	1.3	12.2	2,059.4	0.9	6.20	1	1	1
10/28/2019 22:00	1.2	12.8	1,919.5	0.9	5.80	1	1	1
10/28/2019 23:00	5.0	15.8	589.0	5.8	2.85	1	0	0
Average/Sum#:	3.6	13.2	1,782.5	5.0	256.70 #	24 #	21 #	20 #
Minimum:	0.4	11.7	329.6	0.3	1.30	1	0	0
Maximum:	34.4	18.6	2,173.4	53.1	110.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/29/2019 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/30/2019 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2019 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2019 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2019 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2019 04:00	1.5	20.5	98.7	22.1	0.17	1	0	0
10/30/2019 05:00	31.8	17.2	500.2	50.7	93.50	1	0	0
10/30/2019 06:00	20.5	15.6	823.1	22.8	69.10	1	0	0
10/30/2019 07:00	0.6	14.0	1,699.0	0.5	3.40	1	1	1
10/30/2019 08:00	0.8	14.1	1,706.5	0.7	5.10	1	1	1
10/30/2019 09:00	1.2	13.2	1,917.2	0.9	5.80	1	1	1
10/30/2019 10:00	1.2	12.5	2,025.9	0.8	6.10	1	1	1
10/30/2019 11:00	1.3	12.3	2,071.3	0.9	6.20	1	1	1
10/30/2019 12:00	1.3	12.1	2,093.7	0.9	6.30	1	1	1
10/30/2019 13:00	1.3	12.3	2,060.7	0.9	6.20	1	1	1
10/30/2019 14:00	1.3	12.7	2,003.9	0.9	6.00	1	1	1
10/30/2019 15:00	1.3	12.7	2,017.3	0.9	6.10	1	1	1
10/30/2019 16:00	1.3	12.3	2,080.1	0.9	6.20	1	1	1
10/30/2019 17:00	1.2	13.2	1,914.6	0.9	5.70	1	1	1
10/30/2019 18:00	1.2	13.1	1,932.1	0.9	5.80	1	1	1
10/30/2019 19:00	1.2	13.1	1,940.6	0.9	5.80	1	1	1
10/30/2019 20:00	1.2	13.1	1,943.6	0.9	5.80	1	1	1
10/30/2019 21:00	1.2	13.2	1,888.6	0.9	5.70	1	1	1
10/30/2019 22:00	1.2	13.2	1,902.0	0.9	5.70	1	1	1
10/30/2019 23:00	1.2	13.1	1,928.7	0.9	5.80	1	1	1
Average/Sum#:	3.7	13.7	1,727.4	5.5	260.47 #	20 #	17 #	17 #
Minimum:	0.6	12.1	98.7	0.5	0.17	0	0	0
Maximum:	31.8	20.5	2,093.7	50.7	93.50	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/31/2019 00:00	1.2	13.2	1,916.2	0.9	5.70	1	1	1
10/31/2019 01:00	1.2	13.2	1,901.6	0.9	5.70	1	1	1
10/31/2019 02:00	1.2	13.2	1,899.0	0.9	5.70	1	1	1
10/31/2019 03:00	1.2	13.2	1,903.6	0.9	5.70	1	1	1
10/31/2019 04:00	1.2	13.2	1,903.4	0.9	5.70	1	1	1
10/31/2019 05:00	1.1	13.2	1,894.0	0.8	5.70	1	1	1
10/31/2019 06:00	1.2	13.2	1,903.0	0.9	5.70	1	1	1
10/31/2019 07:00	1.2	13.2	1,914.5	0.9	5.70	1	1	1
10/31/2019 08:00	1.2	13.2	1,922.1	0.9	5.80	1	1	1
10/31/2019 09:00	1.2	13.2	1,893.6	0.9	5.70	1	1	1
10/31/2019 10:00	1.2	13.2	1,897.2	0.9	5.70	1	1	1
10/31/2019 11:00	1.2	13.2	1,910.2	0.9	5.70	1	1	1
10/31/2019 12:00	1.2	13.0	1,934.6	0.9	5.80	1	1	1
10/31/2019 13:00	1.2	13.0	1,935.7	0.9	5.80	1	1	1
10/31/2019 14:00	1.2	13.0	1,930.4	0.9	5.80	1	1	1
10/31/2019 15:00	1.2	13.0	1,928.4	0.9	5.80	1	1	1
10/31/2019 16:00	1.2	13.0	1,925.1	0.9	5.80	1	1	1
10/31/2019 17:00	1.3	13.0	1,928.8	1.0	7.70	1	1	1
10/31/2019 18:00	1.3	12.9	1,964.9	1.0	7.90	1	1	1
10/31/2019 19:00	1.3	12.3	2,076.5	0.9	6.20	1	1	1
10/31/2019 20:00	1.3	12.4	2,072.5	0.9	6.20	1	1	1
10/31/2019 21:00	1.3	12.4	2,079.3	0.9	6.20	1	1	1
10/31/2019 22:00	1.3	12.2	2,080.8	0.9	6.20	1	1	1
10/31/2019 23:00	1.3	12.4	2,062.9	0.9	6.20	1	1	1
Average/Sum#:	1.2	13.0	1,949.1	0.9	144.10 #	24 #	24 #	24 #
Minimum:	1.1	12.2	1,893.6	0.8	5.70	1	1	1
Maximum:	1.3	13.2	2,080.8	1.0	7.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/01/2019 00:00	1.3	12.4	2,042.8	0.9	6.10	1	1	1
11/01/2019 01:00	1.3	12.6	2,007.6	0.9	6.00	1	1	1
11/01/2019 02:00	1.3	12.5	2,041.1	0.9	6.10	1	1	1
11/01/2019 03:00	1.3	12.5	2,042.2	0.9	6.10	1	1	1
11/01/2019 04:00	1.3	12.7	2,006.6	0.9	6.00	1	1	1
11/01/2019 05:00	1.3	12.2	2,104.3	0.9	6.30	1	1	1
11/01/2019 06:00	1.3	12.2	2,135.2	0.9	6.40	1	1	1
11/01/2019 07:00	1.3	12.2	2,134.0	0.9	6.40	1	1	1
11/01/2019 08:00	1.3	12.2	2,118.2	0.9	6.40	1	1	1
11/01/2019 09:00	1.0	13.6	1,753.5	0.8	5.30	1	1	1
11/01/2019 10:00	0.7	14.1	1,644.8	0.6	3.30	1	1	0
11/01/2019 11:00	0.5	14.1	1,319.3	0.4	2.60	1	1	0
11/01/2019 12:00	0.7	14.1	1,505.4	0.6	3.00	1	1	0
11/01/2019 13:00	0.7	14.1	1,549.1	0.6	3.10	1	1	0
11/01/2019 14:00	0.8	14.0	1,513.1	0.7	4.50	1	1	1
11/01/2019 15:00	1.2	12.9	1,955.6	0.9	5.90	1	1	1
11/01/2019 16:00	1.3	12.4	2,055.9	0.9	6.20	1	1	1
11/01/2019 17:00	1.4	12.0	2,130.6	0.9	6.40	1	1	1
11/01/2019 18:00	1.4	11.8	2,165.3	0.9	6.50	1	1	1
11/01/2019 19:00	1.3	12.3	2,071.2	0.9	6.20	1	1	1
11/01/2019 20:00	1.4	12.2	2,110.6	0.9	6.30	1	1	1
11/01/2019 21:00	1.3	12.5	2,038.0	0.9	6.10	1	1	1
11/01/2019 22:00	1.3	12.7	2,010.4	0.9	6.00	1	1	1
11/01/2019 23:00	1.3	12.6	2,033.2	0.9	6.10	1	1	1
Average/Sum#:	1.2	12.8	1,937.0	0.8	133.30 #	24 #	24 #	20 #
Minimum:	0.5	11.8	1,319.3	0.4	2.60	1	1	0
Maximum:	1.4	14.1	2,165.3	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/02/2019 00:00	1.3	12.4	2,050.5	0.9	6.20	1	1	1
11/02/2019 01:00	1.3	12.3	2,058.8	0.9	6.20	1	1	1
11/02/2019 02:00	1.3	12.3	2,069.6	0.9	6.20	1	1	1
11/02/2019 03:00	1.3	12.3	2,063.5	0.9	6.20	1	1	1
11/02/2019 04:00	1.3	12.3	2,069.6	0.9	6.20	1	1	1
11/02/2019 05:00	1.4	12.4	2,035.1	1.0	8.10	1	1	1
11/02/2019 06:00	1.3	12.0	2,126.4	0.9	6.40	1	1	1
11/02/2019 07:00	1.3	12.3	2,067.1	0.9	6.20	1	1	1
11/02/2019 08:00	1.2	13.1	1,887.2	0.9	5.70	1	1	1
11/02/2019 09:00	0.7	14.1	1,528.1	0.6	3.10	1	1	0
11/02/2019 10:00	0.7	14.1	1,518.3	0.6	3.00	1	1	0
11/02/2019 11:00	0.7	14.1	1,524.8	0.6	3.00	1	1	0
11/02/2019 12:00	0.7	14.1	1,539.0	0.6	3.10	1	1	0
11/02/2019 13:00	3.4	15.2	923.9	3.5	4.44	1	0	0
11/02/2019 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/02/2019 15:00	2.5	17.8	423.3	4.8	2.43	1	0	0
11/02/2019 16:00	8.1	14.5	1,124.4	7.5	31.50	1	0	0
11/02/2019 17:00	1.0	13.8	1,717.0	0.8	5.20	1	1	1
11/02/2019 18:00	2.0	12.5	2,030.2	1.4	10.20	1	1	1
11/02/2019 19:00	2.7	11.8	2,166.3	1.8	13.00	1	1	1
11/02/2019 20:00	2.5	11.9	2,141.3	1.6	12.80	1	1	1
11/02/2019 21:00	2.3	12.3	2,073.2	1.6	12.40	1	1	1
11/02/2019 22:00	2.1	12.4	2,044.0	1.5	10.20	1	1	1
11/02/2019 23:00	2.0	12.7	1,990.7	1.4	10.00	1	1	1
Average/Sum#:	1.9	13.2	1,790.1	1.6	181.77 #	23 #	20 #	16 #
Minimum:	0.7	11.8	423.3	0.6	2.43	0	0	0
Maximum:	8.1	17.8	2,166.3	7.5	31.50	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/03/2019 00:00	2.2	12.7	1,982.9	1.6	11.90	1	1	1
11/03/2019 01:00	2.3	12.5	2,001.1	1.6	12.00	1	1	1
11/03/2019 02:00	2.3	12.6	1,988.3	1.6	11.90	1	1	1
11/03/2019 03:00	2.4	12.5	2,009.0	1.7	12.10	1	1	1
11/03/2019 04:00	2.4	12.4	2,043.8	1.7	12.30	1	1	1
11/03/2019 05:00	1.1	11.9	2,108.2	0.7	6.30	1	1	1
11/03/2019 06:00	1.3	12.3	2,077.9	0.9	6.20	1	1	1
11/03/2019 07:00	1.3	12.6	1,991.4	0.9	6.00	1	1	1
11/03/2019 08:00	0.7	14.0	1,603.3	0.6	3.20	1	1	0
11/03/2019 09:00	0.7	14.1	1,588.7	0.6	3.20	1	1	0
11/03/2019 10:00	0.7	14.1	1,609.0	0.6	3.20	1	1	0
11/03/2019 11:00	0.7	14.1	1,598.8	0.6	3.20	1	1	0
11/03/2019 12:00	0.8	14.1	1,613.4	0.7	4.80	1	1	0
11/03/2019 13:00	0.7	14.1	1,466.9	0.6	2.90	1	1	0
11/03/2019 14:00	0.8	14.1	1,443.1	0.7	4.30	1	1	0
11/03/2019 15:00	1.2	13.4	1,764.3	0.9	5.30	1	1	1
11/03/2019 16:00	1.4	12.2	2,071.1	0.9	6.20	1	1	1
11/03/2019 17:00	1.4	12.0	2,115.7	0.9	6.30	1	1	1
11/03/2019 18:00	1.4	11.8	2,145.5	0.9	6.40	1	1	1
11/03/2019 19:00	1.4	11.7	2,171.6	0.9	6.50	1	1	1
11/03/2019 20:00	1.3	12.0	2,120.9	0.9	6.40	1	1	1
11/03/2019 21:00	1.3	12.2	2,086.4	0.9	6.30	1	1	1
11/03/2019 22:00	1.3	12.5	2,016.4	0.9	6.00	1	1	1
11/03/2019 23:00	1.3	12.3	2,054.2	0.9	6.20	1	1	1
Average/Sum#:	1.4	12.8	1,903.0	1.0	159.10 #	24 #	24 #	17 #
Minimum:	0.7	11.7	1,443.1	0.6	2.90	1	1	0
Maximum:	2.4	14.1	2,171.6	1.7	12.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/04/2019 00:00	1.3	12.4	2,017.2	0.9	6.10	1	1	1
11/04/2019 01:00	1.3	12.4	2,021.0	0.9	6.10	1	1	1
11/04/2019 02:00	1.3	12.7	1,956.6	0.9	5.90	1	1	1
11/04/2019 03:00	1.2	12.6	1,988.3	0.9	6.00	1	1	1
11/04/2019 04:00	1.3	12.5	2,011.8	0.9	6.00	1	1	1
11/04/2019 05:00	1.9	11.8	2,113.7	1.2	10.60	1	1	1
11/04/2019 06:00	1.3	11.8	2,167.1	0.8	6.50	1	1	1
11/04/2019 07:00	1.3	12.5	2,023.1	0.9	6.10	1	1	1
11/04/2019 08:00	1.3	12.5	2,033.8	0.9	6.10	1	1	1
11/04/2019 09:00	1.3	12.1	2,078.9	0.9	6.20	1	1	1
11/04/2019 10:00	1.3	12.2	2,046.2	0.9	6.10	1	1	1
11/04/2019 11:00	1.2	12.5	1,974.0	0.8	5.90	1	1	1
11/04/2019 12:00	1.3	12.1	2,041.9	0.9	6.10	1	1	1
11/04/2019 13:00	1.3	12.0	2,057.4	0.9	6.20	1	1	1
11/04/2019 14:00	1.3	12.1	2,029.1	0.9	6.10	1	1	1
11/04/2019 15:00	1.3	12.0	2,057.2	0.9	6.20	1	1	1
11/04/2019 16:00	1.3	11.8	2,111.5	0.8	6.30	1	1	1
11/04/2019 17:00	1.4	11.8	2,165.5	0.9	6.50	1	1	1
11/04/2019 18:00	1.4	11.8	2,169.5	0.9	6.50	1	1	1
11/04/2019 19:00	1.4	11.9	2,166.6	0.9	6.50	1	1	1
11/04/2019 20:00	1.4	12.0	2,148.6	0.9	6.40	1	1	1
11/04/2019 21:00	1.3	11.9	2,151.7	0.9	6.50	1	1	1
11/04/2019 22:00	1.4	11.9	2,154.1	0.9	6.50	1	1	1
11/04/2019 23:00	1.3	12.4	2,070.8	0.9	6.20	1	1	1
Average/Sum#:	1.3	12.2	2,073.2	0.9	153.60 #	24 #	24 #	24 #
Minimum:	1.2	11.8	1,956.6	0.8	5.90	1	1	1
Maximum:	1.9	12.7	2,169.5	1.2	10.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/05/2019 00:00	1.3	12.3	2,088.8	0.9	6.30	1	1	1
11/05/2019 01:00	1.3	12.3	2,089.2	0.9	6.30	1	1	1
11/05/2019 02:00	1.3	12.3	2,085.5	0.9	6.30	1	1	1
11/05/2019 03:00	1.3	12.3	2,084.4	0.9	6.30	1	1	1
11/05/2019 04:00	1.3	12.3	2,074.8	0.9	6.20	1	1	1
11/05/2019 05:00	1.2	12.0	2,120.9	0.8	6.40	1	1	1
11/05/2019 06:00	1.4	11.9	2,186.0	0.9	6.60	1	1	1
11/05/2019 07:00	1.3	12.7	2,024.9	0.9	6.10	1	1	1
11/05/2019 08:00	1.3	12.8	2,004.9	0.9	6.00	1	1	1
11/05/2019 09:00	1.2	12.9	1,955.4	0.9	5.90	1	1	1
11/05/2019 10:00	1.3	12.8	1,968.2	0.9	5.90	1	1	1
11/05/2019 11:00	1.2	12.8	1,967.1	0.9	5.90	1	1	1
11/05/2019 12:00	1.3	12.7	1,982.3	0.9	5.90	1	1	1
11/05/2019 13:00	1.3	12.4	2,046.5	0.9	6.10	1	1	1
11/05/2019 14:00	1.3	12.5	2,024.2	0.9	6.10	1	1	1
11/05/2019 15:00	1.3	12.4	2,041.2	0.9	6.10	1	1	1
11/05/2019 16:00	1.4	12.0	2,120.2	0.9	6.40	1	1	1
11/05/2019 17:00	1.3	12.1	2,095.3	0.9	6.30	1	1	1
11/05/2019 18:00	1.4	12.1	2,099.8	0.9	6.30	1	1	1
11/05/2019 19:00	1.3	12.1	2,112.9	0.9	6.30	1	1	1
11/05/2019 20:00	1.3	12.1	2,117.9	0.9	6.40	1	1	1
11/05/2019 21:00	1.4	12.3	2,090.1	1.0	8.40	1	1	1
11/05/2019 22:00	1.3	12.3	2,086.6	0.9	6.30	1	1	1
11/05/2019 23:00	1.3	12.3	2,086.9	0.9	6.30	1	1	1
Average/Sum#:	1.3	12.4	2,064.8	0.9	151.10 #	24 #	24 #	24 #
Minimum:	1.2	11.9	1,955.4	0.8	5.90	1	1	1
Maximum:	1.4	12.9	2,186.0	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/06/2019 00:00	1.3	12.6	2,004.2	0.9	6.00	1	1	1
11/06/2019 01:00	1.2	12.9	1,965.4	0.9	5.90	1	1	1
11/06/2019 02:00	1.3	12.5	2,046.3	0.9	6.10	1	1	1
11/06/2019 03:00	1.3	12.5	2,041.6	0.9	6.10	1	1	1
11/06/2019 04:00	1.2	12.7	1,991.3	0.9	6.00	1	1	1
11/06/2019 05:00	1.2	12.4	2,032.1	0.8	6.10	1	1	1
11/06/2019 06:00	1.4	12.1	2,120.7	0.9	6.40	1	1	1
11/06/2019 07:00	1.3	12.4	2,059.7	0.9	6.20	1	1	1
11/06/2019 08:00	1.3	12.6	2,014.8	0.9	6.00	1	1	1
11/06/2019 09:00	1.3	12.8	1,976.8	0.9	5.90	1	1	1
11/06/2019 10:00	1.3	12.8	2,070.5	0.9	6.20	1	1	1
11/06/2019 11:00	1.3	12.7	2,095.9	0.9	6.30	1	1	1
11/06/2019 12:00	1.3	12.6	2,094.3	0.9	6.30	1	1	1
11/06/2019 13:00	1.3	12.6	2,104.3	0.9	6.30	1	1	1
11/06/2019 14:00	1.3	12.5	2,123.1	0.9	6.40	1	1	1
11/06/2019 15:00	1.3	12.4	2,134.4	0.9	6.40	1	1	1
11/06/2019 16:00	1.4	12.1	2,198.2	0.9	6.60	1	1	1
11/06/2019 17:00	1.3	11.9	2,237.1	0.9	6.70	1	1	1
11/06/2019 18:00	1.4	12.1	2,218.2	0.9	6.70	1	1	1
11/06/2019 19:00	1.4	12.0	2,223.9	0.9	6.70	1	1	1
11/06/2019 20:00	1.3	12.0	2,231.2	0.9	6.70	1	1	1
11/06/2019 21:00	1.4	12.0	2,248.2	0.9	6.70	1	1	1
11/06/2019 22:00	1.3	12.1	2,220.8	0.9	6.70	1	1	1
11/06/2019 23:00	1.3	12.4	2,170.2	0.9	6.50	1	1	1
Average/Sum#:	1.3	12.4	2,109.3	0.9	151.90 #	24 #	24 #	24 #
Minimum:	1.2	11.9	1,965.4	0.8	5.90	1	1	1
Maximum:	1.4	12.9	2,248.2	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/07/2019 00:00	1.3	12.4	2,187.6	0.9	6.60	1	1	1
11/07/2019 01:00	1.3	12.3	2,175.9	0.9	6.50	1	1	1
11/07/2019 02:00	1.3	12.4	2,141.9	0.9	6.40	1	1	1
11/07/2019 03:00	1.2	12.8	2,080.8	0.9	6.20	1	1	1
11/07/2019 04:00	1.3	12.5	2,147.5	0.9	6.40	1	1	1
11/07/2019 05:00	1.2	12.4	2,148.9	0.8	6.40	1	1	1
11/07/2019 06:00	1.3	12.3	2,190.7	0.9	6.60	1	1	1
11/07/2019 07:00	1.3	12.5	2,150.3	0.9	6.50	1	1	1
11/07/2019 08:00	1.2	12.9	2,072.8	0.9	6.20	1	1	1
11/07/2019 09:00	1.3	12.8	2,077.3	0.9	6.20	1	1	1
11/07/2019 10:00	1.3	12.9	2,046.8	1.0	8.20	1	1	1
11/07/2019 11:00	1.3	12.7	2,093.3	0.9	6.30	1	1	1
11/07/2019 12:00	1.3	12.7	2,094.3	0.9	6.30	1	1	1
11/07/2019 13:00	1.3	12.7	2,091.8	0.9	6.30	1	1	1
11/07/2019 14:00	1.3	12.6	2,113.0	0.9	6.30	1	1	1
11/07/2019 15:00	1.3	12.5	2,140.0	0.9	6.40	1	1	1
11/07/2019 16:00	1.3	12.1	2,216.4	0.9	6.60	1	1	1
11/07/2019 17:00	1.3	12.4	2,156.1	0.9	6.50	1	1	1
11/07/2019 18:00	1.4	11.8	2,283.2	0.9	6.80	1	1	1
11/07/2019 19:00	1.4	11.8	2,296.1	0.9	6.90	1	1	1
11/07/2019 20:00	1.4	12.1	2,215.0	0.9	6.60	1	1	1
11/07/2019 21:00	1.3	12.3	2,173.0	0.9	6.50	1	1	1
11/07/2019 22:00	1.3	12.4	2,178.2	0.9	6.50	1	1	1
11/07/2019 23:00	1.3	12.6	2,120.6	0.9	6.40	1	1	1
Average/Sum#:	1.3	12.5	2,149.6	0.9	156.60 #	24 #	24 #	24 #
Minimum:	1.2	11.8	2,046.8	0.8	6.20	1	1	1
Maximum:	1.4	12.9	2,296.1	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/08/2019 00:00	1.3	12.3	2,174.6	0.9	6.50	1	1	1
11/08/2019 01:00	1.3	12.2	2,199.0	0.9	6.60	1	1	1
11/08/2019 02:00	1.3	12.4	2,155.6	0.9	6.50	1	1	1
11/08/2019 03:00	1.2	12.6	2,121.2	0.9	6.40	1	1	1
11/08/2019 04:00	1.3	12.7	2,109.9	0.9	6.30	1	1	1
11/08/2019 05:00	1.2	12.6	2,119.7	0.9	6.40	1	1	1
11/08/2019 06:00	1.3	12.6	2,121.8	0.9	6.40	1	1	1
11/08/2019 07:00	1.2	12.7	2,106.9	0.9	6.30	1	1	1
11/08/2019 08:00	1.2	13.3	1,954.7	0.9	5.90	1	1	1
11/08/2019 09:00	0.8	14.0	1,568.9	0.7	4.70	1	1	0
11/08/2019 10:00	0.6	14.1	1,391.5	0.5	2.80	1	1	0
11/08/2019 11:00	0.8	14.1	1,550.3	0.7	4.70	1	1	0
11/08/2019 12:00	0.8	14.1	1,552.1	0.7	4.70	1	1	0
11/08/2019 13:00	0.9	14.0	1,700.1	0.8	5.10	1	1	0
11/08/2019 14:00	1.0	14.0	1,711.4	0.9	5.10	1	1	1
11/08/2019 15:00	1.3	12.9	2,042.9	1.0	8.20	1	1	1
11/08/2019 16:00	1.3	12.6	2,098.0	0.9	6.30	1	1	1
11/08/2019 17:00	1.3	12.5	2,118.4	0.9	6.40	1	1	1
11/08/2019 18:00	1.3	12.2	2,175.4	0.9	6.50	1	1	1
11/08/2019 19:00	1.3	12.4	2,133.6	0.9	6.40	1	1	1
11/08/2019 20:00	1.3	12.3	2,168.0	0.9	6.50	1	1	1
11/08/2019 21:00	1.3	12.3	2,174.5	0.9	6.50	1	1	1
11/08/2019 22:00	1.3	12.4	2,170.3	0.9	6.50	1	1	1
11/08/2019 23:00	1.3	12.3	2,176.9	0.9	6.50	1	1	1
Average/Sum#:	1.2	12.9	1,991.5	0.9	144.20 #	24 #	24 #	19 #
Minimum:	0.6	12.2	1,391.5	0.5	2.80	1	1	0
Maximum:	1.3	14.1	2,199.0	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/09/2019 00:00	1.3	12.2	2,182.0	0.9	6.50	1	1	1
11/09/2019 01:00	1.3	12.3	2,159.0	0.9	6.50	1	1	1
11/09/2019 02:00	1.3	12.3	2,162.3	0.9	6.50	1	1	1
11/09/2019 03:00	1.2	12.2	2,166.6	0.8	6.50	1	1	1
11/09/2019 04:00	1.3	12.2	2,177.3	0.9	6.50	1	1	1
11/09/2019 05:00	1.1	12.7	2,107.5	0.8	6.30	1	1	1
11/09/2019 06:00	1.3	12.7	2,085.2	0.9	6.30	1	1	1
11/09/2019 07:00	1.2	12.8	2,050.2	0.9	6.20	1	1	1
11/09/2019 08:00	0.8	14.0	1,569.3	0.7	4.70	1	1	1
11/09/2019 09:00	0.6	14.1	1,326.2	0.5	2.70	1	1	0
11/09/2019 10:00	0.6	14.2	1,340.4	0.5	2.70	1	1	0
11/09/2019 11:00	0.6	14.2	1,327.7	0.5	2.70	1	1	0
11/09/2019 12:00	0.6	14.2	1,332.2	0.5	2.70	1	1	0
11/09/2019 13:00	0.6	14.2	1,324.1	0.5	2.60	1	1	0
11/09/2019 14:00	0.8	14.1	1,565.1	0.7	4.70	1	1	1
11/09/2019 15:00	1.3	12.8	2,054.2	0.9	6.20	1	1	1
11/09/2019 16:00	1.3	12.6	2,100.8	0.9	6.30	1	1	1
11/09/2019 17:00	1.3	12.4	2,129.6	0.9	6.40	1	1	1
11/09/2019 18:00	1.3	12.6	2,102.2	0.9	6.30	1	1	1
11/09/2019 19:00	1.3	12.6	2,106.5	0.9	6.30	1	1	1
11/09/2019 20:00	1.3	12.6	2,095.8	0.9	6.30	1	1	1
11/09/2019 21:00	1.3	12.6	2,122.8	0.9	6.40	1	1	1
11/09/2019 22:00	1.3	12.5	2,141.9	0.9	6.40	1	1	1
11/09/2019 23:00	1.3	12.6	2,114.0	0.9	6.30	1	1	1
Average/Sum#:	1.1	13.0	1,910.1	0.8	131.00 #	24 #	24 #	19 #
Minimum:	0.6	12.2	1,324.1	0.5	2.60	1	1	0
Maximum:	1.3	14.2	2,182.0	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/10/2019 00:00	1.3	12.6	2,129.0	0.9	6.40	1	1	1
11/10/2019 01:00	1.2	12.9	2,062.9	0.9	6.20	1	1	1
11/10/2019 02:00	1.3	12.8	2,059.1	0.9	6.20	1	1	1
11/10/2019 03:00	1.2	12.8	2,062.4	0.9	6.20	1	1	1
11/10/2019 04:00	1.2	12.8	2,062.5	0.9	6.20	1	1	1
11/10/2019 05:00	1.1	12.8	2,059.6	0.8	6.20	1	1	1
11/10/2019 06:00	1.3	12.7	2,101.9	0.9	6.30	1	1	1
11/10/2019 07:00	1.2	12.7	2,072.8	0.9	6.20	1	1	1
11/10/2019 08:00	0.8	14.0	1,600.0	0.7	4.80	1	1	0
11/10/2019 09:00	0.8	14.1	1,562.7	0.7	4.70	1	1	0
11/10/2019 10:00	0.8	14.1	1,570.8	0.7	4.70	1	1	0
11/10/2019 11:00	0.8	14.1	1,609.2	0.7	4.80	1	1	0
11/10/2019 12:00	0.8	14.1	1,597.1	0.7	4.80	1	1	0
11/10/2019 13:00	0.8	14.1	1,684.7	0.7	5.10	1	1	0
11/10/2019 14:00	0.8	14.1	1,647.6	0.7	4.90	1	1	0
11/10/2019 15:00	0.8	14.0	1,581.4	0.7	4.70	1	1	1
11/10/2019 16:00	1.3	12.8	2,050.6	0.9	6.20	1	1	1
11/10/2019 17:00	1.3	12.6	2,102.6	0.9	6.30	1	1	1
11/10/2019 18:00	1.3	12.6	2,096.3	0.9	6.30	1	1	1
11/10/2019 19:00	1.3	12.5	2,115.4	0.9	6.30	1	1	1
11/10/2019 20:00	1.3	12.5	2,126.8	0.9	6.40	1	1	1
11/10/2019 21:00	1.3	12.4	2,163.0	0.9	6.50	1	1	1
11/10/2019 22:00	1.3	12.2	2,205.1	0.9	6.60	1	1	1
11/10/2019 23:00	1.3	12.4	2,145.5	0.9	6.40	1	1	1
Average/Sum#:	1.1	13.1	1,936.2	0.8	139.40 #	24 #	24 #	17 #
Minimum:	0.8	12.2	1,562.7	0.7	4.70	1	1	0
Maximum:	1.3	14.1	2,205.1	0.9	6.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/11/2019 00:00	1.3	12.5	2,134.2	0.9	6.40	1	1	1
11/11/2019 01:00	1.3	12.6	2,092.9	0.9	6.30	1	1	1
11/11/2019 02:00	1.3	12.6	2,117.2	0.9	6.40	1	1	1
11/11/2019 03:00	1.3	12.6	2,096.2	0.9	6.30	1	1	1
11/11/2019 04:00	1.3	12.6	2,097.0	0.9	6.30	1	1	1
11/11/2019 05:00	1.2	12.7	2,088.8	0.9	6.30	1	1	1
11/11/2019 06:00	1.3	12.7	2,093.0	0.9	6.30	1	1	1
11/11/2019 07:00	1.3	12.6	2,103.1	0.9	6.30	1	1	1
11/11/2019 08:00	1.2	13.2	1,953.2	0.9	5.90	1	1	1
11/11/2019 09:00	0.7	14.0	1,534.1	0.6	3.10	1	1	0
11/11/2019 10:00	0.8	14.1	1,549.8	0.7	4.60	1	1	0
11/11/2019 11:00	0.9	14.1	1,542.3	0.8	4.60	1	1	0
11/11/2019 12:00	0.8	14.1	1,529.6	0.7	4.60	1	1	0
11/11/2019 13:00	1.1	14.0	1,751.1	0.9	5.30	1	1	1
11/11/2019 14:00	1.3	12.9	2,025.7	1.0	8.10	1	1	1
11/11/2019 15:00	1.3	12.4	2,121.9	0.9	6.40	1	1	1
11/11/2019 16:00	1.3	12.4	2,116.1	0.9	6.30	1	1	1
11/11/2019 17:00	1.4	11.9	2,228.9	0.9	6.70	1	1	1
11/11/2019 18:00	1.4	12.0	2,208.5	0.9	6.60	1	1	1
11/11/2019 19:00	1.3	12.2	2,171.1	0.9	6.50	1	1	1
11/11/2019 20:00	1.3	12.2	2,174.6	0.9	6.50	1	1	1
11/11/2019 21:00	1.3	12.3	2,180.9	0.9	6.50	1	1	1
11/11/2019 22:00	1.3	12.3	2,179.1	0.9	6.50	1	1	1
11/11/2019 23:00	1.3	12.3	2,165.3	0.9	6.50	1	1	1
Average/Sum#:	1.2	12.8	2,010.6	0.9	145.30 #	24 #	24 #	20 #
Minimum:	0.7	11.9	1,529.6	0.6	3.10	1	1	0
Maximum:	1.4	14.1	2,228.9	1.0	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/12/2019 00:00	1.3	12.4	2,148.0	0.9	6.40	1	1	1
11/12/2019 01:00	1.3	12.4	2,151.2	0.9	6.50	1	1	1
11/12/2019 02:00	1.3	12.6	2,118.1	0.9	6.40	1	1	1
11/12/2019 03:00	1.3	12.3	2,163.2	0.9	6.50	1	1	1
11/12/2019 04:00	1.3	12.4	2,143.4	0.9	6.40	1	1	1
11/12/2019 05:00	1.3	12.5	2,123.1	0.9	6.40	1	1	1
11/12/2019 06:00	1.3	12.3	2,168.3	0.9	6.50	1	1	1
11/12/2019 07:00	1.3	12.4	2,134.0	0.9	6.40	1	1	1
11/12/2019 08:00	1.3	12.5	2,121.6	0.9	6.40	1	1	1
11/12/2019 09:00	1.2	12.5	2,109.8	0.8	6.30	1	1	1
11/12/2019 10:00	1.3	12.4	2,141.5	0.9	6.40	1	1	1
11/12/2019 11:00	1.2	12.5	2,097.7	0.8	6.30	1	1	1
11/12/2019 12:00	1.3	12.5	2,085.2	0.9	6.30	1	1	1
11/12/2019 13:00	1.3	12.5	2,108.1	0.9	6.30	1	1	1
11/12/2019 14:00	1.3	12.6	2,098.9	0.9	6.30	1	1	1
11/12/2019 15:00	1.3	12.5	2,100.4	0.9	6.30	1	1	1
11/12/2019 16:00	1.3	12.6	2,089.2	0.9	6.30	1	1	1
11/12/2019 17:00	1.3	12.3	2,161.1	0.9	6.50	1	1	1
11/12/2019 18:00	1.3	12.3	2,146.5	0.9	6.40	1	1	1
11/12/2019 19:00	1.4	12.2	2,182.5	0.9	6.50	1	1	1
11/12/2019 20:00	1.3	12.2	2,181.0	0.9	6.50	1	1	1
11/12/2019 21:00	1.3	12.3	2,158.0	0.9	6.50	1	1	1
11/12/2019 22:00	1.3	12.3	2,158.7	0.9	6.50	1	1	1
11/12/2019 23:00	1.3	12.4	2,147.5	0.9	6.40	1	1	1
Average/Sum#:	1.3	12.4	2,134.9	0.9	153.70 #	24 #	24 #	24 #
Minimum:	1.2	12.2	2,085.2	0.8	6.30	1	1	1
Maximum:	1.4	12.6	2,182.5	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/13/2019 00:00	1.3	12.5	2,133.2	0.9	6.40	1	1	1
11/13/2019 01:00	1.3	12.6	2,099.0	0.9	6.30	1	1	1
11/13/2019 02:00	1.3	12.6	2,099.4	0.9	6.30	1	1	1
11/13/2019 03:00	1.3	12.6	2,096.9	0.9	6.30	1	1	1
11/13/2019 04:00	1.3	12.5	2,124.8	0.9	6.40	1	1	1
11/13/2019 05:00	1.2	12.4	2,129.8	0.8	6.40	1	1	1
11/13/2019 06:00	1.3	12.3	2,157.7	0.9	6.50	1	1	1
11/13/2019 07:00	1.3	12.4	2,140.0	0.9	6.40	1	1	1
11/13/2019 08:00	1.3	12.6	2,112.5	0.9	6.30	1	1	1
11/13/2019 09:00	1.3	12.6	2,098.8	0.9	6.30	1	1	1
11/13/2019 10:00	1.3	12.6	2,088.0	0.9	6.30	1	1	1
11/13/2019 11:00	1.3	12.5	2,108.8	0.9	6.30	1	1	1
11/13/2019 12:00	1.3	12.6	2,103.8	0.9	6.30	1	1	1
11/13/2019 13:00	1.3	12.4	2,125.1	0.9	6.40	1	1	1
11/13/2019 14:00	1.3	12.4	2,138.2	0.9	6.40	1	1	1
11/13/2019 15:00	1.3	12.4	2,138.0	0.9	6.40	1	1	1
11/13/2019 16:00	1.3	12.5	2,107.1	0.9	6.30	1	1	1
11/13/2019 17:00	1.4	11.9	2,227.9	0.9	6.70	1	1	1
11/13/2019 18:00	1.3	12.2	2,165.9	0.9	6.50	1	1	1
11/13/2019 19:00	1.3	12.4	2,124.9	0.9	6.40	1	1	1
11/13/2019 20:00	1.3	12.3	2,155.1	0.9	6.50	1	1	1
11/13/2019 21:00	1.3	12.3	2,143.4	0.9	6.40	1	1	1
11/13/2019 22:00	1.3	12.5	2,116.7	0.9	6.40	1	1	1
11/13/2019 23:00	1.3	12.3	2,155.7	0.9	6.50	1	1	1
Average/Sum#:	1.3	12.4	2,128.8	0.9	153.40 #	24 #	24 #	24 #
Minimum:	1.2	11.9	2,088.0	0.8	6.30	1	1	1
Maximum:	1.4	12.6	2,227.9	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/14/2019 00:00	1.3	12.2	2,177.1	0.9	6.50	1	1	1
11/14/2019 01:00	1.3	12.2	2,182.2	0.9	6.50	1	1	1
11/14/2019 02:00	1.3	12.3	2,173.9	0.9	6.50	1	1	1
11/14/2019 03:00	1.3	12.2	2,182.4	0.9	6.50	1	1	1
11/14/2019 04:00	1.3	12.2	2,176.3	0.9	6.50	1	1	1
11/14/2019 05:00	1.4	12.3	2,149.8	1.0	8.60	1	1	1
11/14/2019 06:00	1.3	12.3	2,187.6	0.9	6.60	1	1	1
11/14/2019 07:00	1.3	12.4	2,146.2	0.9	6.40	1	1	1
11/14/2019 08:00	1.3	12.6	2,089.7	0.9	6.30	1	1	1
11/14/2019 09:00	1.3	12.4	2,142.2	0.9	6.40	1	1	1
11/14/2019 10:00	1.3	12.2	2,167.8	0.9	6.50	1	1	1
11/14/2019 11:00	1.3	12.4	2,119.8	0.9	6.40	1	1	1
11/14/2019 12:00	1.3	12.1	2,184.2	0.9	6.60	1	1	1
11/14/2019 13:00	1.4	12.2	2,174.0	0.9	6.50	1	1	1
11/14/2019 14:00	1.3	12.2	2,169.1	0.9	6.50	1	1	1
11/14/2019 15:00	1.4	12.2	2,165.2	0.9	6.50	1	1	1
11/14/2019 16:00	1.3	12.3	2,141.0	0.9	6.40	1	1	1
11/14/2019 17:00	1.3	12.2	2,159.5	0.9	6.50	1	1	1
11/14/2019 18:00	1.3	12.3	2,163.1	0.9	6.50	1	1	1
11/14/2019 19:00	1.3	12.3	2,159.5	0.9	6.50	1	1	1
11/14/2019 20:00	1.4	12.2	2,182.2	0.9	6.50	1	1	1
11/14/2019 21:00	1.3	12.3	2,170.5	0.9	6.50	1	1	1
11/14/2019 22:00	1.3	12.4	2,142.7	0.9	6.40	1	1	1
11/14/2019 23:00	1.3	12.4	2,163.2	0.9	6.50	1	1	1
Average/Sum#:	1.3	12.3	2,161.2	0.9	157.60 #	24 #	24 #	24 #
Minimum:	1.3	12.1	2,089.7	0.9	6.30	1	1	1
Maximum:	1.4	12.6	2,187.6	1.0	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/15/2019 00:00	1.3	12.5	2,126.7	0.9	6.40	1	1	1
11/15/2019 01:00	1.3	12.7	2,099.1	0.9	6.30	1	1	1
11/15/2019 02:00	1.3	12.6	2,118.5	0.9	6.40	1	1	1
11/15/2019 03:00	1.3	12.8	2,077.8	0.9	6.20	1	1	1
11/15/2019 04:00	1.3	12.7	2,083.9	0.9	6.30	1	1	1
11/15/2019 05:00	1.2	12.8	2,076.5	0.9	6.20	1	1	1
11/15/2019 06:00	1.3	12.5	2,143.5	0.9	6.40	1	1	1
11/15/2019 07:00	1.3	12.4	2,159.0	0.9	6.50	1	1	1
11/15/2019 08:00	1.3	12.6	2,106.1	0.9	6.30	1	1	1
11/15/2019 09:00	1.3	12.6	2,099.3	0.9	6.30	1	1	1
11/15/2019 10:00	1.3	12.6	2,108.4	0.9	6.30	1	1	1
11/15/2019 11:00	1.2	13.1	1,996.0	0.9	6.00	1	1	1
11/15/2019 12:00	1.3	12.7	2,077.5	0.9	6.20	1	1	1
11/15/2019 13:00	1.3	12.4	2,136.6	0.9	6.40	1	1	1
11/15/2019 14:00	1.3	12.3	2,164.4	0.9	6.50	1	1	1
11/15/2019 15:00	1.3	12.4	2,143.2	0.9	6.40	1	1	1
11/15/2019 16:00	1.3	12.5	2,118.8	0.9	6.40	1	1	1
11/15/2019 17:00	1.3	12.2	2,176.0	0.9	6.50	1	1	1
11/15/2019 18:00	1.3	12.7	2,083.8	0.9	6.30	1	1	1
11/15/2019 19:00	1.3	12.5	2,120.1	0.9	6.40	1	1	1
11/15/2019 20:00	1.3	12.3	2,177.8	0.9	6.50	1	1	1
11/15/2019 21:00	1.3	12.5	2,118.1	0.9	6.40	1	1	1
11/15/2019 22:00	1.3	12.5	2,126.7	0.9	6.40	1	1	1
11/15/2019 23:00	1.3	12.6	2,088.2	0.9	6.30	1	1	1
Average/Sum#:	1.3	12.6	2,113.6	0.9	152.30 #	24 #	24 #	24 #
Minimum:	1.2	12.2	1,996.0	0.9	6.00	1	1	1
Maximum:	1.3	13.1	2,177.8	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/16/2019 00:00	1.3	12.7	2,078.5	0.9	6.20	1	1	1
11/16/2019 01:00	1.2	12.8	2,069.7	0.9	6.20	1	1	1
11/16/2019 02:00	1.3	12.7	2,080.8	0.9	6.20	1	1	1
11/16/2019 03:00	1.3	12.7	2,084.1	0.9	6.30	1	1	1
11/16/2019 04:00	1.2	12.7	2,078.2	0.9	6.20	1	1	1
11/16/2019 05:00	1.2	12.7	2,086.5	0.9	6.30	1	1	1
11/16/2019 06:00	1.3	12.6	2,100.0	0.9	6.30	1	1	1
11/16/2019 07:00	1.2	12.8	2,042.8	0.9	6.10	1	1	1
11/16/2019 08:00	0.8	14.0	1,650.9	0.7	5.00	1	1	0
11/16/2019 09:00	0.8	14.0	1,550.5	0.7	4.70	1	1	0
11/16/2019 10:00	0.8	14.0	1,576.9	0.7	4.70	1	1	0
11/16/2019 11:00	0.8	14.0	1,669.1	0.7	5.00	1	1	0
11/16/2019 12:00	0.8	14.0	1,625.8	0.7	4.90	1	1	0
11/16/2019 13:00	0.8	14.1	1,708.8	0.7	5.10	1	1	0
11/16/2019 14:00	0.8	14.1	1,686.5	0.7	5.10	1	1	0
11/16/2019 15:00	0.8	14.0	1,581.4	0.7	4.70	1	1	1
11/16/2019 16:00	1.3	12.7	2,073.2	0.9	6.20	1	1	1
11/16/2019 17:00	1.3	12.4	2,137.6	0.9	6.40	1	1	1
11/16/2019 18:00	1.3	12.5	2,118.9	0.9	6.40	1	1	1
11/16/2019 19:00	1.3	12.5	2,128.5	0.9	6.40	1	1	1
11/16/2019 20:00	1.3	12.4	2,133.1	0.9	6.40	1	1	1
11/16/2019 21:00	1.3	12.4	2,141.3	0.9	6.40	1	1	1
11/16/2019 22:00	1.3	12.5	2,124.7	0.9	6.40	1	1	1
11/16/2019 23:00	1.3	12.6	2,115.1	0.9	6.30	1	1	1
Average/Sum#:	1.1	13.1	1,943.5	0.8	139.90 #	24 #	24 #	17 #
Minimum:	0.8	12.4	1,550.5	0.7	4.70	1	1	0
Maximum:	1.3	14.1	2,141.3	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/17/2019 00:00	1.3	12.7	2,097.8	0.9	6.30	1	1	1
11/17/2019 01:00	1.3	12.7	2,100.2	0.9	6.30	1	1	1
11/17/2019 02:00	1.1	13.3	1,938.3	0.9	5.80	1	1	1
11/17/2019 03:00	0.8	14.0	1,594.7	0.7	4.80	1	1	0
11/17/2019 04:00	0.8	14.0	1,701.8	0.7	5.10	1	1	0
11/17/2019 05:00	0.8	14.0	1,564.5	0.7	4.70	1	1	0
11/17/2019 06:00	0.9	14.0	1,703.8	0.8	5.10	1	1	0
11/17/2019 07:00	0.8	14.0	1,660.3	0.7	5.00	1	1	0
11/17/2019 08:00	0.8	14.0	1,663.7	0.7	5.00	1	1	0
11/17/2019 09:00	0.8	14.0	1,671.7	0.7	5.00	1	1	0
11/17/2019 10:00	0.8	14.0	1,650.1	0.7	5.00	1	1	0
11/17/2019 11:00	0.8	14.0	1,705.8	0.7	5.10	1	1	0
11/17/2019 12:00	0.8	14.1	1,632.0	0.7	4.90	1	1	0
11/17/2019 13:00	0.8	14.1	1,679.6	0.7	5.00	1	1	0
11/17/2019 14:00	0.8	14.0	1,563.0	0.7	4.70	1	1	1
11/17/2019 15:00	1.3	12.7	2,053.9	0.9	6.20	1	1	1
11/17/2019 16:00	1.3	12.5	2,109.5	0.9	6.30	1	1	1
11/17/2019 17:00	1.3	12.5	2,097.8	0.9	6.30	1	1	1
11/17/2019 18:00	1.3	12.4	2,116.5	0.9	6.30	1	1	1
11/17/2019 19:00	1.3	12.3	2,144.0	0.9	6.40	1	1	1
11/17/2019 20:00	1.3	12.3	2,149.2	0.9	6.40	1	1	1
11/17/2019 21:00	1.3	12.3	2,152.5	0.9	6.50	1	1	1
11/17/2019 22:00	1.3	12.5	2,113.2	0.9	6.30	1	1	1
11/17/2019 23:00	1.3	12.7	2,085.7	0.9	6.30	1	1	1
Average/Sum#:	1.0	13.3	1,872.9	0.8	134.80 #	24 #	24 #	13 #
Minimum:	0.8	12.3	1,563.0	0.7	4.70	1	1	0
Maximum:	1.3	14.1	2,152.5	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/18/2019 00:00	1.3	12.5	2,099.3	0.9	6.30	1	1	1
11/18/2019 01:00	1.3	12.6	2,101.4	0.9	6.30	1	1	1
11/18/2019 02:00	1.3	12.6	2,099.3	0.9	6.30	1	1	1
11/18/2019 03:00	1.3	12.6	2,099.6	0.9	6.30	1	1	1
11/18/2019 04:00	1.3	12.7	2,083.5	0.9	6.30	1	1	1
11/18/2019 05:00	1.3	12.6	2,088.7	0.9	6.30	1	1	1
11/18/2019 06:00	1.3	12.3	2,158.7	0.9	6.50	1	1	1
11/18/2019 07:00	1.3	12.4	2,136.0	0.9	6.40	1	1	1
11/18/2019 08:00	1.3	12.7	2,084.1	0.9	6.30	1	1	1
11/18/2019 09:00	1.2	12.9	2,026.6	0.9	6.10	1	1	1
11/18/2019 10:00	1.3	12.5	2,120.4	0.9	6.40	1	1	1
11/18/2019 11:00	1.3	12.1	2,188.2	0.9	6.60	1	1	1
11/18/2019 12:00	1.3	12.3	2,143.8	0.9	6.40	1	1	1
11/18/2019 13:00	1.4	12.2	2,164.1	0.9	6.50	1	1	1
11/18/2019 14:00	1.3	12.2	2,149.0	0.9	6.40	1	1	1
11/18/2019 15:00	1.3	12.2	2,147.4	0.9	6.40	1	1	1
11/18/2019 16:00	1.4	11.9	2,201.8	0.9	6.60	1	1	1
11/18/2019 17:00	1.4	12.1	2,181.8	0.9	6.50	1	1	1
11/18/2019 18:00	1.4	11.8	2,238.2	0.9	6.70	1	1	1
11/18/2019 19:00	1.4	12.0	2,203.9	0.9	6.60	1	1	1
11/18/2019 20:00	1.4	12.0	2,198.4	0.9	6.60	1	1	1
11/18/2019 21:00	1.3	12.2	2,157.2	0.9	6.50	1	1	1
11/18/2019 22:00	1.3	12.2	2,152.1	0.9	6.50	1	1	1
11/18/2019 23:00	1.3	12.3	2,144.0	0.9	6.40	1	1	1
Average/Sum#:	1.3	12.3	2,140.3	0.9	154.20 #	24 #	24 #	24 #
Minimum:	1.2	11.8	2,026.6	0.9	6.10	1	1	1
Maximum:	1.4	12.9	2,238.2	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/19/2019 00:00	1.3	12.3	2,139.1	0.9	6.40	1	1	1
11/19/2019 01:00	1.3	12.5	2,096.8	0.9	6.30	1	1	1
11/19/2019 02:00	1.3	12.5	2,092.4	0.9	6.30	1	1	1
11/19/2019 03:00	1.3	12.5	2,088.6	0.9	6.30	1	1	1
11/19/2019 04:00	1.3	12.5	2,094.5	0.9	6.30	1	1	1
11/19/2019 05:00	1.4	12.4	2,105.8	1.0	8.40	1	1	1
11/19/2019 06:00	1.3	12.5	2,087.1	0.9	6.30	1	1	1
11/19/2019 07:00	1.3	12.4	2,111.5	0.9	6.30	1	1	1
11/19/2019 08:00	1.3	12.1	2,176.8	0.9	6.50	1	1	1
11/19/2019 09:00	0.0	0.0	2,145.5	0.0	0.00	1	1	1
11/19/2019 10:00	1.2	12.2	2,186.7	0.8	6.60	1	1	1
11/19/2019 11:00	1.3	12.4	2,153.9	0.9	6.50	1	1	1
11/19/2019 12:00	1.3	12.4	2,125.1	0.9	6.40	1	1	1
11/19/2019 13:00	1.3	12.5	2,113.5	0.9	6.30	1	1	1
11/19/2019 14:00	1.3	12.3	2,141.3	0.9	6.40	1	1	1
11/19/2019 15:00	1.3	12.5	2,106.0	0.9	6.30	1	1	1
11/19/2019 16:00	1.3	12.5	2,103.7	0.9	6.30	1	1	1
11/19/2019 17:00	1.4	12.0	2,219.9	0.9	6.70	1	1	1
11/19/2019 18:00	1.4	11.7	2,265.4	0.9	6.80	1	1	1
11/19/2019 19:00	1.3	12.3	2,145.2	0.9	6.40	1	1	1
11/19/2019 20:00	1.3	12.5	2,114.6	0.9	6.30	1	1	1
11/19/2019 21:00	1.3	12.4	2,140.3	0.9	6.40	1	1	1
11/19/2019 22:00	1.3	12.4	2,145.4	0.9	6.40	1	1	1
11/19/2019 23:00	1.3	12.3	2,154.4	0.9	6.50	1	1	1
Average/Sum#:	1.3	12.4	2,135.6	0.9	149.40 #	24 #	24 #	24 #
Minimum:	1.2	11.7	2,087.1	0.8	6.30	1	1	1
Maximum:	1.4	12.5	2,265.4	1.0	8.40	1	1	1
%SI	4.17	4.17	0.00	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/20/2019 00:00	1.3	12.5	2,120.3	0.9	6.40	1	1	1
11/20/2019 01:00	1.3	12.6	2,100.2	0.9	6.30	1	1	1
11/20/2019 02:00	1.3	12.7	2,076.7	0.9	6.20	1	1	1
11/20/2019 03:00	1.3	12.7	2,083.5	0.9	6.30	1	1	1
11/20/2019 04:00	1.3	12.6	2,102.7	0.9	6.30	1	1	1
11/20/2019 05:00	1.2	12.5	2,106.1	0.8	6.30	1	1	1
11/20/2019 06:00	1.3	12.3	2,169.8	0.9	6.50	1	1	1
11/20/2019 07:00	1.3	12.2	2,195.6	0.9	6.60	1	1	1
11/20/2019 08:00	1.3	12.2	2,180.4	0.9	6.50	1	1	1
11/20/2019 09:00	1.3	12.2	2,193.1	0.9	6.60	1	1	1
11/20/2019 10:00	1.3	12.2	2,192.6	0.9	6.60	1	1	1
11/20/2019 11:00	1.3	12.4	2,139.0	0.9	6.40	1	1	1
11/20/2019 12:00	1.3	12.4	2,142.5	0.9	6.40	1	1	1
11/20/2019 13:00	1.3	12.4	2,150.5	0.9	6.50	1	1	1
11/20/2019 14:00	1.3	12.2	2,171.7	0.9	6.50	1	1	1
11/20/2019 15:00	1.3	12.1	2,208.1	0.9	6.60	1	1	1
11/20/2019 16:00	1.3	12.3	2,163.5	0.9	6.50	1	1	1
11/20/2019 17:00	1.3	11.8	2,273.5	0.8	6.80	1	1	1
11/20/2019 18:00	1.3	11.7	2,282.2	0.8	6.80	1	1	1
11/20/2019 19:00	1.3	11.7	2,291.3	0.8	6.90	1	1	1
11/20/2019 20:00	1.3	11.9	2,247.2	0.9	6.70	1	1	1
11/20/2019 21:00	1.3	12.1	2,224.0	0.9	6.70	1	1	1
11/20/2019 22:00	1.3	12.3	2,173.9	0.9	6.50	1	1	1
11/20/2019 23:00	1.3	12.4	2,154.4	0.9	6.50	1	1	1
Average/Sum#:	1.3	12.3	2,172.6	0.9	156.40 #	24 #	24 #	24 #
Minimum:	1.2	11.7	2,076.7	0.8	6.20	1	1	1
Maximum:	1.3	12.7	2,291.3	0.9	6.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2019 00:00	1.3	12.3	2,188.1	0.9	6.60	1	1	1
11/21/2019 01:00	1.3	12.2	2,194.2	0.9	6.60	1	1	1
11/21/2019 02:00	1.3	12.3	2,179.6	0.9	6.50	1	1	1
11/21/2019 03:00	1.3	12.2	2,206.5	0.9	6.60	1	1	1
11/21/2019 04:00	1.2	12.1	2,215.0	0.8	6.60	1	1	1
11/21/2019 05:00	1.2	11.9	2,218.3	0.8	6.70	1	1	1
11/21/2019 06:00	1.2	11.8	2,280.5	0.8	6.80	1	1	1
11/21/2019 07:00	1.3	11.8	2,282.9	0.8	6.80	1	1	1
11/21/2019 08:00	1.3	12.3	2,191.2	0.9	6.60	1	1	1
11/21/2019 09:00	1.3	12.7	2,096.8	0.9	6.30	1	1	1
11/21/2019 10:00	1.3	12.5	2,131.4	0.9	6.40	1	1	1
11/21/2019 11:00	1.3	12.7	2,086.9	0.9	6.30	1	1	1
11/21/2019 12:00	1.3	12.5	2,127.9	0.9	6.40	1	1	1
11/21/2019 13:00	1.3	12.6	2,107.6	0.9	6.30	1	1	1
11/21/2019 14:00	1.3	12.6	2,096.1	0.9	6.30	1	1	1
11/21/2019 15:00	1.3	12.5	2,124.4	0.9	6.40	1	1	1
11/21/2019 16:00	1.3	12.1	2,220.6	0.9	6.70	1	1	1
11/21/2019 17:00	1.3	11.9	2,254.5	0.9	6.80	1	1	1
11/21/2019 18:00	1.3	11.8	2,278.5	0.8	6.80	1	1	1
11/21/2019 19:00	1.3	11.7	2,285.4	0.8	6.90	1	1	1
11/21/2019 20:00	1.3	11.7	2,278.3	0.8	6.80	1	1	1
11/21/2019 21:00	1.3	11.8	2,282.3	0.8	6.80	1	1	1
11/21/2019 22:00	1.3	12.0	2,249.1	0.9	6.70	1	1	1
11/21/2019 23:00	1.3	12.1	2,206.6	0.9	6.60	1	1	1
Average/Sum#:	1.3	12.2	2,199.3	0.9	158.30 #	24 #	24 #	24 #
Minimum:	1.2	11.7	2,086.9	0.8	6.30	1	1	1
Maximum:	1.3	12.7	2,285.4	0.9	6.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/22/2019 00:00	1.2	12.3	2,168.0	0.8	6.50	1	1	1
11/22/2019 01:00	1.3	12.4	2,163.6	0.9	6.50	1	1	1
11/22/2019 02:00	1.3	12.4	2,167.5	0.9	6.50	1	1	1
11/22/2019 03:00	1.3	12.4	2,166.0	0.9	6.50	1	1	1
11/22/2019 04:00	1.3	12.7	2,106.4	0.9	6.30	1	1	1
11/22/2019 05:00	1.2	12.7	2,080.5	0.9	6.20	1	1	1
11/22/2019 06:00	1.3	11.9	2,283.4	0.9	6.90	1	1	1
11/22/2019 07:00	1.3	12.0	2,262.6	0.9	6.80	1	1	1
11/22/2019 08:00	1.3	12.6	2,099.8	0.9	6.30	1	1	1
11/22/2019 09:00	1.2	12.8	2,074.5	0.9	6.20	1	1	1
11/22/2019 10:00	1.3	12.7	2,102.7	0.9	6.30	1	1	1
11/22/2019 11:00	1.3	12.8	2,076.6	0.9	6.20	1	1	1
11/22/2019 12:00	1.3	12.7	2,087.1	0.9	6.30	1	1	1
11/22/2019 13:00	1.3	12.7	2,078.5	0.9	6.20	1	1	1
11/22/2019 14:00	1.3	12.6	2,103.2	0.9	6.30	1	1	1
11/22/2019 15:00	1.3	12.5	2,107.9	0.9	6.30	1	1	1
11/22/2019 16:00	1.3	11.9	2,239.2	0.9	6.70	1	1	1
11/22/2019 17:00	1.3	12.0	2,226.1	0.9	6.70	1	1	1
11/22/2019 18:00	1.3	11.9	2,251.6	0.9	6.80	1	1	1
11/22/2019 19:00	1.3	12.0	2,222.5	0.9	6.70	1	1	1
11/22/2019 20:00	1.3	12.1	2,218.5	0.9	6.70	1	1	1
11/22/2019 21:00	1.3	12.0	2,229.1	0.9	6.70	1	1	1
11/22/2019 22:00	1.3	12.1	2,188.7	0.9	6.60	1	1	1
11/22/2019 23:00	1.3	12.4	2,146.0	0.9	6.40	1	1	1
Average/Sum#:	1.3	12.4	2,160.4	0.9	155.60 #	24 #	24 #	24 #
Minimum:	1.2	11.9	2,074.5	0.8	6.20	1	1	1
Maximum:	1.3	12.8	2,283.4	0.9	6.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/23/2019 00:00	1.3	12.4	2,135.3	0.9	6.40	1	1	1
11/23/2019 01:00	1.3	12.3	2,161.1	0.9	6.50	1	1	1
11/23/2019 02:00	1.3	12.5	2,151.6	0.9	6.50	1	1	1
11/23/2019 03:00	1.3	12.7	2,110.4	0.9	6.30	1	1	1
11/23/2019 04:00	1.3	12.4	2,162.2	0.9	6.50	1	1	1
11/23/2019 05:00	1.1	12.3	2,169.0	0.8	6.50	1	1	1
11/23/2019 06:00	1.3	12.3	2,179.1	0.9	6.50	1	1	1
11/23/2019 07:00	1.2	12.4	2,145.1	0.8	6.40	1	1	1
11/23/2019 08:00	0.8	13.2	1,952.5	0.6	3.90	1	1	1
11/23/2019 09:00	0.4	13.9	1,695.8	0.3	1.70	1	1	0
11/23/2019 10:00	0.4	14.0	1,715.5	0.3	1.70	1	1	0
11/23/2019 11:00	0.4	14.0	1,686.0	0.3	1.70	1	1	0
11/23/2019 12:00	0.4	14.0	1,703.4	0.3	1.70	1	1	0
11/23/2019 13:00	0.4	14.0	1,720.5	0.3	1.70	1	1	0
11/23/2019 14:00	0.4	14.0	1,690.7	0.3	1.70	1	1	0
11/23/2019 15:00	0.8	13.4	1,871.8	0.6	3.70	1	1	1
11/23/2019 16:00	1.3	12.3	2,154.9	0.9	6.50	1	1	1
11/23/2019 17:00	1.3	12.2	2,185.9	0.9	6.60	1	1	1
11/23/2019 18:00	1.3	12.2	2,185.5	0.9	6.60	1	1	1
11/23/2019 19:00	1.3	12.0	2,233.6	0.9	6.70	1	1	1
11/23/2019 20:00	1.3	12.1	2,218.8	0.9	6.70	1	1	1
11/23/2019 21:00	1.3	12.4	2,159.6	0.9	6.50	1	1	1
11/23/2019 22:00	1.3	12.6	2,118.5	0.9	6.40	1	1	1
11/23/2019 23:00	1.2	12.6	2,079.4	0.9	6.20	1	1	1
Average/Sum#:	1.0	12.8	2,024.4	0.7	121.60 #	24 #	24 #	18 #
Minimum:	0.4	12.0	1,686.0	0.3	1.70	1	1	0
Maximum:	1.3	14.0	2,233.6	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/24/2019 00:00	1.2	12.6	2,079.0	0.9	6.20	1	1	1
11/24/2019 01:00	1.2	12.7	2,078.7	0.9	6.20	1	1	1
11/24/2019 02:00	1.3	12.8	2,064.3	0.9	6.20	1	1	1
11/24/2019 03:00	1.2	12.9	2,062.7	0.9	6.20	1	1	1
11/24/2019 04:00	1.2	12.8	2,075.8	0.9	6.20	1	1	1
11/24/2019 05:00	1.3	12.8	2,072.2	0.9	6.20	1	1	1
11/24/2019 06:00	1.2	12.6	2,133.4	0.9	6.40	1	1	1
11/24/2019 07:00	1.1	12.7	2,068.8	0.8	6.20	1	1	1
11/24/2019 08:00	0.4	13.9	1,683.6	0.3	1.70	1	1	0
11/24/2019 09:00	0.4	13.9	1,672.7	0.3	1.70	1	1	0
11/24/2019 10:00	0.4	13.9	1,700.6	0.3	1.70	1	1	0
11/24/2019 11:00	0.4	13.9	1,694.9	0.3	1.70	1	1	0
11/24/2019 12:00	0.4	13.9	1,728.2	0.3	1.70	1	1	0
11/24/2019 13:00	0.4	14.0	1,711.7	0.3	1.70	1	1	0
11/24/2019 14:00	0.4	14.0	1,665.9	0.3	1.70	1	1	0
11/24/2019 15:00	0.9	13.4	1,867.6	0.7	5.60	1	1	1
11/24/2019 16:00	1.3	12.6	2,101.8	0.9	6.30	1	1	1
11/24/2019 17:00	1.3	12.3	2,155.5	0.9	6.50	1	1	1
11/24/2019 18:00	1.3	12.7	2,076.3	0.9	6.20	1	1	1
11/24/2019 19:00	1.1	12.9	2,015.8	0.8	6.00	1	1	1
11/24/2019 20:00	1.3	12.7	2,085.2	0.9	6.30	1	1	1
11/24/2019 21:00	1.3	12.4	2,134.5	0.9	6.40	1	1	1
11/24/2019 22:00	1.2	12.7	2,063.8	0.9	6.20	1	1	1
11/24/2019 23:00	0.8	13.4	1,842.0	0.6	3.70	1	1	1
Average/Sum#:	1.0	13.1	1,951.5	0.7	114.90 #	24 #	24 #	17 #
Minimum:	0.4	12.3	1,665.9	0.3	1.70	1	1	0
Maximum:	1.3	14.0	2,155.5	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/25/2019 00:00	1.8	14.5	1,078.5	1.7	4.10	1	0	0
11/25/2019 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2019 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2019 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2019 04:00	4.5	17.3	516.8	7.4	6.30	1	0	0
11/25/2019 05:00	5.6	14.5	1,328.8	5.2	25.20	1	0	0
11/25/2019 06:00	0.1	14.0	1,394.5	0.1	0.00	1	1	0
11/25/2019 07:00	0.3	13.9	1,648.7	0.3	1.60	1	1	0
11/25/2019 08:00	0.4	13.9	1,697.7	0.3	1.70	1	1	0
11/25/2019 09:00	0.3	13.9	1,651.8	0.3	1.70	1	1	0
11/25/2019 10:00	0.4	14.0	1,674.1	0.3	1.70	1	1	0
11/25/2019 11:00	0.4	14.0	1,719.6	0.3	1.70	1	1	0
11/25/2019 12:00	0.4	14.0	1,712.3	0.3	1.70	1	1	0
11/25/2019 13:00	0.4	14.0	1,707.9	0.3	1.70	1	1	0
11/25/2019 14:00	0.4	14.0	1,698.8	0.3	1.70	1	1	0
11/25/2019 15:00	0.4	13.9	1,615.4	0.3	1.60	1	1	1
11/25/2019 16:00	1.2	12.8	2,087.6	0.9	6.30	1	1	1
11/25/2019 17:00	1.3	12.0	2,236.1	0.9	6.70	1	1	1
11/25/2019 18:00	1.3	12.4	2,136.2	0.9	6.40	1	1	1
11/25/2019 19:00	1.2	12.2	2,193.1	0.8	6.60	1	1	1
11/25/2019 20:00	1.3	12.2	2,199.1	0.9	6.60	1	1	1
11/25/2019 21:00	1.2	12.3	2,163.2	0.8	6.50	1	1	1
11/25/2019 22:00	1.3	12.5	2,128.3	0.9	6.40	1	1	1
11/25/2019 23:00	1.2	12.6	2,107.0	0.9	6.30	1	1	1
Average/Sum#:	1.2	13.6	1,747.4	1.1	102.50 #	21 #	18 #	9 #
Minimum:	0.1	12.0	516.8	0.1	0.00	0	0	0
Maximum:	5.6	17.3	2,236.1	7.4	25.20	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/26/2019 00:00	1.3	12.5	2,137.6	0.9	6.40	1	1	1
11/26/2019 01:00	1.3	12.4	2,161.7	0.9	6.50	1	1	1
11/26/2019 02:00	1.2	12.7	2,087.5	0.9	6.30	1	1	1
11/26/2019 03:00	1.2	12.7	2,083.5	0.9	6.30	1	1	1
11/26/2019 04:00	1.2	12.8	2,070.4	0.9	6.20	1	1	1
11/26/2019 05:00	1.2	13.0	2,007.1	0.9	6.00	1	1	1
11/26/2019 06:00	1.2	12.2	2,213.6	0.8	6.60	1	1	1
11/26/2019 07:00	1.1	12.7	1,981.9	0.8	5.90	1	1	1
11/26/2019 08:00	0.4	13.9	1,686.6	0.3	1.70	1	1	0
11/26/2019 09:00	0.4	13.9	1,713.5	0.3	1.70	1	1	0
11/26/2019 10:00	0.4	13.9	1,588.4	0.3	1.60	1	1	0
11/26/2019 11:00	0.4	13.9	1,644.8	0.3	1.60	1	1	0
11/26/2019 12:00	0.4	13.9	1,623.1	0.3	1.60	1	1	0
11/26/2019 13:00	0.4	13.9	1,659.4	0.3	1.70	1	1	0
11/26/2019 14:00	0.9	13.3	1,884.0	0.7	5.70	1	1	1
11/26/2019 15:00	1.3	12.6	2,088.4	0.9	6.30	1	1	1
11/26/2019 16:00	1.3	12.7	2,052.2	0.9	6.20	1	1	1
11/26/2019 17:00	1.3	12.4	2,125.3	0.9	6.40	1	1	1
11/26/2019 18:00	1.3	12.5	2,092.2	0.9	6.30	1	1	1
11/26/2019 19:00	1.4	12.5	2,117.1	1.0	8.50	1	1	1
11/26/2019 20:00	1.3	12.2	2,157.1	0.9	6.50	1	1	1
11/26/2019 21:00	1.3	12.3	2,127.0	0.9	6.40	1	1	1
11/26/2019 22:00	1.4	12.4	2,102.4	1.0	8.40	1	1	1
11/26/2019 23:00	1.3	12.3	2,115.3	0.9	6.30	1	1	1
Average/Sum#:	1.0	12.9	1,980.0	0.7	127.10 #	24 #	24 #	18 #
Minimum:	0.4	12.2	1,588.4	0.3	1.60	1	1	0
Maximum:	1.4	13.9	2,213.6	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/27/2019 00:00	1.4	12.3	2,131.6	1.0	8.50	1	1	1
11/27/2019 01:00	1.3	12.4	2,100.9	0.9	6.30	1	1	1
11/27/2019 02:00	1.3	12.6	2,064.8	0.9	6.20	1	1	1
11/27/2019 03:00	1.3	12.6	2,058.7	0.9	6.20	1	1	1
11/27/2019 04:00	1.3	12.6	2,071.6	0.9	6.20	1	1	1
11/27/2019 05:00	1.0	12.5	2,079.9	0.7	6.20	1	1	1
11/27/2019 06:00	1.3	12.8	2,025.5	0.9	6.10	1	1	1
11/27/2019 07:00	1.3	12.1	2,178.0	0.9	6.50	1	1	1
11/27/2019 08:00	1.3	12.2	2,174.5	0.9	6.50	1	1	1
11/27/2019 09:00	1.3	12.2	2,155.2	0.9	6.50	1	1	1
11/27/2019 10:00	1.3	12.2	2,140.8	0.9	6.40	1	1	1
11/27/2019 11:00	1.3	12.5	2,090.7	0.9	6.30	1	1	1
11/27/2019 12:00	1.3	12.3	2,124.2	0.9	6.40	1	1	1
11/27/2019 13:00	1.3	12.0	2,180.1	0.9	6.50	1	1	1
11/27/2019 14:00	1.3	12.1	2,162.8	0.9	6.50	1	1	1
11/27/2019 15:00	1.3	12.4	2,092.8	0.9	6.30	1	1	1
11/27/2019 16:00	1.3	12.6	2,059.0	0.9	6.20	1	1	1
11/27/2019 17:00	1.3	12.2	2,159.1	0.9	6.50	1	1	1
11/27/2019 18:00	1.3	13.0	1,989.8	1.0	8.00	1	1	1
11/27/2019 19:00	1.2	13.0	2,006.4	0.9	6.00	1	1	1
11/27/2019 20:00	1.3	12.1	2,207.3	0.9	6.60	1	1	1
11/27/2019 21:00	1.3	11.9	2,234.6	0.9	6.70	1	1	1
11/27/2019 22:00	1.3	12.3	2,173.1	0.9	6.50	1	1	1
11/27/2019 23:00	1.3	12.4	2,153.8	0.9	6.50	1	1	1
Average/Sum#:	1.3	12.4	2,117.3	0.9	156.60 #	24 #	24 #	24 #
Minimum:	1.0	11.9	1,989.8	0.7	6.00	1	1	1
Maximum:	1.4	13.0	2,234.6	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/28/2019 00:00	1.3	12.4	2,161.0	0.9	6.50	1	1	1
11/28/2019 01:00	1.3	12.5	2,137.8	0.9	6.40	1	1	1
11/28/2019 02:00	1.3	12.6	2,125.3	0.9	6.40	1	1	1
11/28/2019 03:00	1.3	12.5	2,162.9	0.9	6.50	1	1	1
11/28/2019 04:00	1.3	12.6	2,131.3	0.9	6.40	1	1	1
11/28/2019 05:00	1.4	12.7	2,102.0	1.0	8.40	1	1	1
11/28/2019 06:00	1.3	12.3	2,201.5	0.9	6.60	1	1	1
11/28/2019 07:00	1.3	12.2	2,216.2	0.9	6.60	1	1	1
11/28/2019 08:00	1.3	12.2	2,221.7	0.9	6.70	1	1	1
11/28/2019 09:00	1.3	12.2	2,198.3	0.9	6.60	1	1	1
11/28/2019 10:00	1.3	12.2	2,207.0	0.9	6.60	1	1	1
11/28/2019 11:00	1.3	12.1	2,215.4	0.9	6.60	1	1	1
11/28/2019 12:00	1.3	12.0	2,219.1	0.9	6.70	1	1	1
11/28/2019 13:00	1.3	12.1	2,200.5	0.9	6.60	1	1	1
11/28/2019 14:00	1.3	12.1	2,194.1	0.9	6.60	1	1	1
11/28/2019 15:00	1.3	12.0	2,210.6	0.9	6.60	1	1	1
11/28/2019 16:00	1.3	12.2	2,167.3	0.9	6.50	1	1	1
11/28/2019 17:00	1.3	12.2	2,167.5	0.9	6.50	1	1	1
11/28/2019 18:00	1.2	12.6	2,073.1	0.9	6.20	1	1	1
11/28/2019 19:00	1.3	12.3	2,158.8	0.9	6.50	1	1	1
11/28/2019 20:00	1.3	12.1	2,191.1	0.9	6.60	1	1	1
11/28/2019 21:00	1.3	12.1	2,190.6	0.9	6.60	1	1	1
11/28/2019 22:00	1.3	12.2	2,184.7	0.9	6.60	1	1	1
11/28/2019 23:00	1.3	12.0	2,207.5	0.9	6.60	1	1	1
Average/Sum#:	1.3	12.3	2,176.9	0.9	158.90 #	24 #	24 #	24 #
Minimum:	1.2	12.0	2,073.1	0.9	6.20	1	1	1
Maximum:	1.4	12.7	2,221.7	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/29/2019 00:00	1.3	12.1	2,208.9	0.9	6.60	1	1	1
11/29/2019 01:00	1.3	12.2	2,179.2	0.9	6.50	1	1	1
11/29/2019 02:00	1.3	12.2	2,185.4	0.9	6.60	1	1	1
11/29/2019 03:00	1.3	12.3	2,170.1	0.9	6.50	1	1	1
11/29/2019 04:00	1.3	12.1	2,198.9	0.9	6.60	1	1	1
11/29/2019 05:00	1.2	12.3	2,162.0	0.8	6.50	1	1	1
11/29/2019 06:00	1.3	12.1	2,217.2	0.9	6.70	1	1	1
11/29/2019 07:00	1.2	12.4	2,113.6	0.8	6.30	1	1	1
11/29/2019 08:00	0.4	13.9	1,595.4	0.3	1.60	1	1	0
11/29/2019 09:00	0.2	13.9	1,471.2	0.2	1.50	1	1	0
11/29/2019 10:00	0.4	13.9	1,632.9	0.3	1.60	1	1	0
11/29/2019 11:00	0.3	13.9	1,637.9	0.3	1.60	1	1	0
11/29/2019 12:00	0.3	13.9	1,587.7	0.3	1.60	1	1	0
11/29/2019 13:00	0.3	13.9	1,585.6	0.3	1.60	1	1	0
11/29/2019 14:00	0.3	13.9	1,495.2	0.3	1.50	1	1	0
11/29/2019 15:00	0.3	13.9	1,618.1	0.3	1.60	1	1	1
11/29/2019 16:00	1.1	12.8	2,052.1	0.8	6.20	1	1	1
11/29/2019 17:00	1.3	11.9	2,265.6	0.9	6.80	1	1	1
11/29/2019 18:00	1.3	11.8	2,286.7	0.8	6.90	1	1	1
11/29/2019 19:00	1.3	11.9	2,261.6	0.9	6.80	1	1	1
11/29/2019 20:00	1.3	11.9	2,271.4	0.9	6.80	1	1	1
11/29/2019 21:00	1.3	12.4	2,160.2	0.9	6.50	1	1	1
11/29/2019 22:00	1.3	12.5	2,173.5	0.9	6.50	1	1	1
11/29/2019 23:00	1.3	12.5	2,165.2	0.9	6.50	1	1	1
Average/Sum#:	1.0	12.8	1,987.3	0.7	117.90 #	24 #	24 #	17 #
Minimum:	0.2	11.8	1,471.2	0.2	1.50	1	1	0
Maximum:	1.3	13.9	2,286.7	0.9	6.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/30/2019 00:00	1.3	12.5	2,158.3	0.9	6.50	1	1	1
11/30/2019 01:00	1.3	12.5	2,155.6	0.9	6.50	1	1	1
11/30/2019 02:00	1.3	12.5	2,169.5	0.9	6.50	1	1	1
11/30/2019 03:00	1.3	12.4	2,170.5	0.9	6.50	1	1	1
11/30/2019 04:00	1.3	12.5	2,153.1	0.9	6.50	1	1	1
11/30/2019 05:00	1.1	12.5	2,132.3	0.8	6.40	1	1	1
11/30/2019 06:00	1.3	12.4	2,169.6	0.9	6.50	1	1	1
11/30/2019 07:00	1.3	12.5	2,138.0	0.9	6.40	1	1	1
11/30/2019 08:00	1.3	12.5	2,161.5	0.9	6.50	1	1	1
11/30/2019 09:00	1.3	12.4	2,180.5	0.9	6.50	1	1	1
11/30/2019 10:00	1.3	12.5	2,147.7	0.9	6.40	1	1	1
11/30/2019 11:00	1.2	12.7	2,092.1	0.9	6.30	1	1	1
11/30/2019 12:00	1.3	12.4	2,167.7	0.9	6.50	1	1	1
11/30/2019 13:00	1.3	12.4	2,162.5	0.9	6.50	1	1	1
11/30/2019 14:00	1.3	12.4	2,171.4	0.9	6.50	1	1	1
11/30/2019 15:00	1.3	12.5	2,151.6	0.9	6.50	1	1	1
11/30/2019 16:00	1.3	12.5	2,149.0	0.9	6.40	1	1	1
11/30/2019 17:00	1.3	12.4	2,166.5	0.9	6.50	1	1	1
11/30/2019 18:00	1.3	12.6	2,135.2	0.9	6.40	1	1	1
11/30/2019 19:00	1.3	12.2	2,213.0	0.9	6.60	1	1	1
11/30/2019 20:00	1.3	12.4	2,171.8	0.9	6.50	1	1	1
11/30/2019 21:00	1.3	12.4	2,156.3	0.9	6.50	1	1	1
11/30/2019 22:00	1.3	12.7	2,104.5	0.9	6.30	1	1	1
11/30/2019 23:00	1.3	12.8	2,091.4	0.9	6.30	1	1	1
Average/Sum#:	1.3	12.5	2,152.9	0.9	155.00 #	24 #	24 #	24 #
Minimum:	1.1	12.2	2,091.4	0.8	6.30	1	1	1
Maximum:	1.3	12.8	2,213.0	0.9	6.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2019 00:00	1.3	12.6	2,140.9	0.9	6.40	1	1	1
12/01/2019 01:00	1.3	12.8	2,090.4	0.9	6.30	1	1	1
12/01/2019 02:00	1.3	12.8	2,089.1	0.9	6.30	1	1	1
12/01/2019 03:00	1.3	12.8	2,089.2	0.9	6.30	1	1	1
12/01/2019 04:00	1.3	12.8	2,084.8	0.9	6.30	1	1	1
12/01/2019 05:00	1.3	12.8	2,085.9	0.9	6.30	1	1	1
12/01/2019 06:00	1.2	12.9	2,075.5	0.9	6.20	1	1	1
12/01/2019 07:00	1.3	12.9	2,086.7	1.0	8.30	1	1	1
12/01/2019 08:00	1.3	12.5	2,176.0	0.9	6.50	1	1	1
12/01/2019 09:00	1.3	12.4	2,172.8	0.9	6.50	1	1	1
12/01/2019 10:00	1.3	12.4	2,181.5	0.9	6.50	1	1	1
12/01/2019 11:00	1.3	12.5	2,161.9	0.9	6.50	1	1	1
12/01/2019 12:00	1.3	12.8	2,086.9	0.9	6.30	1	1	1
12/01/2019 13:00	1.3	12.7	2,110.4	0.9	6.30	1	1	1
12/01/2019 14:00	1.3	12.7	2,099.5	0.9	6.30	1	1	1
12/01/2019 15:00	1.3	12.7	2,105.9	0.9	6.30	1	1	1
12/01/2019 16:00	1.3	12.6	2,107.8	0.9	6.30	1	1	1
12/01/2019 17:00	1.3	12.4	2,161.9	0.9	6.50	1	1	1
12/01/2019 18:00	1.3	12.1	2,221.6	0.9	6.70	1	1	1
12/01/2019 19:00	1.4	12.0	2,253.5	0.9	6.80	1	1	1
12/01/2019 20:00	1.4	12.2	2,209.1	0.9	6.60	1	1	1
12/01/2019 21:00	1.3	12.5	2,133.9	0.9	6.40	1	1	1
12/01/2019 22:00	1.3	12.6	2,102.8	0.9	6.30	1	1	1
12/01/2019 23:00	1.3	12.7	2,095.2	0.9	6.30	1	1	1
Average/Sum#:	1.3	12.6	2,130.1	0.9	155.50 #	24 #	24 #	24 #
Minimum:	1.2	12.0	2,075.5	0.9	6.20	1	1	1
Maximum:	1.4	12.9	2,253.5	1.0	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/02/2019 00:00	1.3	12.7	2,078.7	0.9	6.20	1	1	1
12/02/2019 01:00	1.3	12.7	2,082.6	0.9	6.20	1	1	1
12/02/2019 02:00	1.3	12.7	2,081.3	0.9	6.20	1	1	1
12/02/2019 03:00	1.3	12.7	2,075.0	0.9	6.20	1	1	1
12/02/2019 04:00	1.3	12.8	2,069.7	0.9	6.20	1	1	1
12/02/2019 05:00	1.0	12.7	2,075.5	0.7	6.20	1	1	1
12/02/2019 06:00	1.4	12.2	2,196.2	0.9	6.60	1	1	1
12/02/2019 07:00	1.3	11.9	2,256.7	0.9	6.80	1	1	1
12/02/2019 08:00	1.3	12.5	2,120.8	0.9	6.40	1	1	1
12/02/2019 09:00	1.3	12.7	2,077.0	0.9	6.20	1	1	1
12/02/2019 10:00	1.3	12.6	2,099.2	0.9	6.30	1	1	1
12/02/2019 11:00	1.3	12.6	2,092.7	0.9	6.30	1	1	1
12/02/2019 12:00	1.3	12.3	2,162.8	0.9	6.50	1	1	1
12/02/2019 13:00	1.3	12.5	2,118.4	0.9	6.40	1	1	1
12/02/2019 14:00	1.3	12.2	2,174.2	0.9	6.50	1	1	1
12/02/2019 15:00	1.3	12.3	2,156.8	0.9	6.50	1	1	1
12/02/2019 16:00	1.4	12.0	2,213.4	0.9	6.60	1	1	1
12/02/2019 17:00	1.3	11.8	2,268.7	0.8	6.80	1	1	1
12/02/2019 18:00	1.4	11.8	2,278.2	0.9	6.80	1	1	1
12/02/2019 19:00	1.3	11.8	2,279.3	0.8	6.80	1	1	1
12/02/2019 20:00	1.3	11.8	2,275.2	0.8	6.80	1	1	1
12/02/2019 21:00	1.3	11.9	2,248.6	0.9	6.70	1	1	1
12/02/2019 22:00	1.3	12.3	2,148.0	0.9	6.40	1	1	1
12/02/2019 23:00	1.3	12.4	2,129.3	0.9	6.40	1	1	1
Average/Sum#:	1.3	12.3	2,156.6	0.9	155.00 #	24 #	24 #	24 #
Minimum:	1.0	11.8	2,069.7	0.7	6.20	1	1	1
Maximum:	1.4	12.8	2,279.3	0.9	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/03/2019 00:00	1.3	12.4	2,136.3	0.9	6.40	1	1	1
12/03/2019 01:00	1.3	12.6	2,082.1	0.9	6.20	1	1	1
12/03/2019 02:00	1.3	12.6	2,078.1	0.9	6.20	1	1	1
12/03/2019 03:00	1.3	12.6	2,086.0	0.9	6.30	1	1	1
12/03/2019 04:00	1.3	12.5	2,112.1	0.9	6.30	1	1	1
12/03/2019 05:00	1.2	12.3	2,121.5	0.8	6.40	1	1	1
12/03/2019 06:00	1.3	12.3	2,153.5	0.9	6.50	1	1	1
12/03/2019 07:00	1.3	12.0	2,204.2	0.9	6.60	1	1	1
12/03/2019 08:00	1.3	12.1	2,192.7	0.9	6.60	1	1	1
12/03/2019 09:00	1.3	12.2	2,162.7	0.9	6.50	1	1	1
12/03/2019 10:00	1.3	12.4	2,107.2	0.9	6.30	1	1	1
12/03/2019 11:00	1.3	12.0	2,184.4	0.9	6.60	1	1	1
12/03/2019 12:00	1.3	11.8	2,215.8	0.8	6.60	1	1	1
12/03/2019 13:00	1.3	11.8	2,208.4	0.8	6.60	1	1	1
12/03/2019 14:00	1.3	11.8	2,205.5	0.8	6.60	1	1	1
12/03/2019 15:00	1.3	11.9	2,199.8	0.9	6.60	1	1	1
12/03/2019 16:00	1.3	11.9	2,191.5	0.9	6.60	1	1	1
12/03/2019 17:00	1.3	11.7	2,253.4	0.8	6.80	1	1	1
12/03/2019 18:00	1.3	11.7	2,252.8	0.8	6.80	1	1	1
12/03/2019 19:00	1.3	11.8	2,237.0	0.8	6.70	1	1	1
12/03/2019 20:00	1.4	11.8	2,228.0	0.9	6.70	1	1	1
12/03/2019 21:00	1.3	11.9	2,219.8	0.9	6.70	1	1	1
12/03/2019 22:00	1.3	12.2	2,159.4	0.9	6.50	1	1	1
12/03/2019 23:00	1.3	12.3	2,136.5	0.9	6.40	1	1	1
Average/Sum#:	1.3	12.1	2,172.0	0.9	156.50 #	24 #	24 #	24 #
Minimum:	1.2	11.7	2,078.1	0.8	6.20	1	1	1
Maximum:	1.4	12.6	2,253.4	0.9	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/04/2019 00:00	1.3	12.1	2,184.8	0.9	6.60	1	1	1
12/04/2019 01:00	1.3	12.2	2,158.5	0.9	6.50	1	1	1
12/04/2019 02:00	1.3	12.5	2,102.9	0.9	6.30	1	1	1
12/04/2019 03:00	1.3	12.5	2,114.0	0.9	6.30	1	1	1
12/04/2019 04:00	1.3	12.2	2,154.6	0.9	6.50	1	1	1
12/04/2019 05:00	1.2	12.5	2,097.2	0.8	6.30	1	1	1
12/04/2019 06:00	1.3	12.3	2,152.1	0.9	6.50	1	1	1
12/04/2019 07:00	1.3	12.0	2,205.0	0.9	6.60	1	1	1
12/04/2019 08:00	1.4	12.1	2,197.1	0.9	6.60	1	1	1
12/04/2019 09:00	1.3	12.1	2,201.4	0.9	6.60	1	1	1
12/04/2019 10:00	1.4	12.1	2,184.8	0.9	6.60	1	1	1
12/04/2019 11:00	1.3	11.9	2,229.9	0.9	6.70	1	1	1
12/04/2019 12:00	1.4	12.1	2,194.3	0.9	6.60	1	1	1
12/04/2019 13:00	1.3	12.2	2,165.2	0.9	6.50	1	1	1
12/04/2019 14:00	1.3	11.8	2,236.0	0.8	6.70	1	1	1
12/04/2019 15:00	1.3	12.0	2,197.1	0.9	6.60	1	1	1
12/04/2019 16:00	1.3	12.0	2,197.1	0.9	6.60	1	1	1
12/04/2019 17:00	1.3	12.1	2,172.7	0.9	6.50	1	1	1
12/04/2019 18:00	1.3	11.8	2,240.9	0.8	6.70	1	1	1
12/04/2019 19:00	1.4	11.8	2,242.8	0.9	6.70	1	1	1
12/04/2019 20:00	1.3	11.8	2,246.9	0.8	6.70	1	1	1
12/04/2019 21:00	1.3	11.9	2,228.4	0.9	6.70	1	1	1
12/04/2019 22:00	1.3	12.1	2,194.5	0.9	6.60	1	1	1
12/04/2019 23:00	1.3	12.3	2,147.9	0.9	6.40	1	1	1
Average/Sum#:	1.3	12.1	2,185.3	0.9	157.40 #	24 #	24 #	24 #
Minimum:	1.2	11.8	2,097.2	0.8	6.30	1	1	1
Maximum:	1.4	12.5	2,246.9	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/05/2019 00:00	1.3	12.2	2,160.5	0.9	6.50	1	1	1
12/05/2019 01:00	1.3	12.2	2,166.9	0.9	6.50	1	1	1
12/05/2019 02:00	1.3	12.2	2,164.3	0.9	6.50	1	1	1
12/05/2019 03:00	1.3	12.2	2,165.9	0.9	6.50	1	1	1
12/05/2019 04:00	1.3	12.4	2,132.0	0.9	6.40	1	1	1
12/05/2019 05:00	1.3	12.4	2,119.2	0.9	6.40	1	1	1
12/05/2019 06:00	1.3	12.2	2,163.7	0.9	6.50	1	1	1
12/05/2019 07:00	1.3	12.4	2,122.3	0.9	6.40	1	1	1
12/05/2019 08:00	1.3	12.7	2,069.4	0.9	6.20	1	1	1
12/05/2019 09:00	1.3	12.6	2,084.4	0.9	6.30	1	1	1
12/05/2019 10:00	1.3	12.6	2,035.3	0.9	6.10	1	1	1
12/05/2019 11:00	1.3	12.6	2,041.6	0.9	6.10	1	1	1
12/05/2019 12:00	1.3	12.5	2,049.9	0.9	6.10	1	1	1
12/05/2019 13:00	1.3	12.5	2,049.7	0.9	6.10	1	1	1
12/05/2019 14:00	1.3	12.5	2,037.5	0.9	6.10	1	1	1
12/05/2019 15:00	1.3	12.5	2,046.8	0.9	6.10	1	1	1
12/05/2019 16:00	1.3	12.1	2,140.6	0.9	6.40	1	1	1
12/05/2019 17:00	1.3	11.8	2,195.4	0.8	6.60	1	1	1
12/05/2019 18:00	1.3	11.8	2,198.0	0.8	6.60	1	1	1
12/05/2019 19:00	1.3	11.7	2,206.3	0.8	6.60	1	1	1
12/05/2019 20:00	1.4	11.8	2,203.5	0.9	6.60	1	1	1
12/05/2019 21:00	1.3	11.7	2,206.0	0.8	6.60	1	1	1
12/05/2019 22:00	1.3	12.0	2,149.6	0.9	6.40	1	1	1
12/05/2019 23:00	1.3	12.1	2,129.0	0.9	6.40	1	1	1
Average/Sum#:	1.3	12.2	2,126.6	0.9	153.00 #	24 #	24 #	24 #
Minimum:	1.3	11.7	2,035.3	0.8	6.10	1	1	1
Maximum:	1.4	12.7	2,206.3	0.9	6.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/06/2019 00:00	1.3	12.4	2,065.7	0.9	6.20	1	1	1
12/06/2019 01:00	1.3	12.4	2,061.4	0.9	6.20	1	1	1
12/06/2019 02:00	1.3	12.4	2,067.5	0.9	6.20	1	1	1
12/06/2019 03:00	1.3	12.4	2,064.0	0.9	6.20	1	1	1
12/06/2019 04:00	1.3	12.5	2,041.1	0.9	6.10	1	1	1
12/06/2019 05:00	1.1	12.5	2,034.6	0.8	6.10	1	1	1
12/06/2019 06:00	1.3	12.4	2,068.3	0.9	6.20	1	1	1
12/06/2019 07:00	1.3	12.4	2,062.6	0.9	6.20	1	1	1
12/06/2019 08:00	1.3	12.5	2,049.6	0.9	6.10	1	1	1
12/06/2019 09:00	1.3	12.6	2,023.8	0.9	6.10	1	1	1
12/06/2019 10:00	1.3	12.5	2,044.0	0.9	6.10	1	1	1
12/06/2019 11:00	1.3	12.3	2,071.0	0.9	6.20	1	1	1
12/06/2019 12:00	1.3	12.1	2,105.6	0.9	6.30	1	1	1
12/06/2019 13:00	1.3	12.0	2,114.7	0.9	6.30	1	1	1
12/06/2019 14:00	1.3	12.1	2,110.9	0.9	6.30	1	1	1
12/06/2019 15:00	1.3	12.1	2,113.4	0.9	6.30	1	1	1
12/06/2019 16:00	1.3	12.0	2,138.4	0.9	6.40	1	1	1
12/06/2019 17:00	1.3	12.0	2,126.5	0.9	6.40	1	1	1
12/06/2019 18:00	1.4	11.8	2,171.2	0.9	6.50	1	1	1
12/06/2019 19:00	1.3	11.8	2,163.3	0.8	6.50	1	1	1
12/06/2019 20:00	1.3	12.0	2,142.1	0.9	6.40	1	1	1
12/06/2019 21:00	1.4	11.8	2,187.6	0.9	6.60	1	1	1
12/06/2019 22:00	1.4	11.8	2,187.8	0.9	6.60	1	1	1
12/06/2019 23:00	1.3	11.7	2,191.1	0.8	6.60	1	1	1
Average/Sum#:	1.3	12.2	2,100.3	0.9	151.10 #	24 #	24 #	24 #
Minimum:	1.1	11.7	2,023.8	0.8	6.10	1	1	1
Maximum:	1.4	12.6	2,191.1	0.9	6.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/07/2019 00:00	1.3	11.8	2,181.2	0.8	6.50	1	1	1
12/07/2019 01:00	1.4	12.3	2,068.1	1.0	8.30	1	1	1
12/07/2019 02:00	1.3	12.5	2,037.2	0.9	6.10	1	1	1
12/07/2019 03:00	1.3	12.5	2,041.6	0.9	6.10	1	1	1
12/07/2019 04:00	1.3	12.5	2,044.2	0.9	6.10	1	1	1
12/07/2019 05:00	1.3	12.4	2,038.5	0.9	6.10	1	1	1
12/07/2019 06:00	1.3	12.4	2,038.7	0.9	6.10	1	1	1
12/07/2019 07:00	1.3	12.3	2,073.5	0.9	6.20	1	1	1
12/07/2019 08:00	1.3	12.2	2,085.4	0.9	6.30	1	1	1
12/07/2019 09:00	1.3	12.2	2,071.6	0.9	6.20	1	1	1
12/07/2019 10:00	1.3	12.3	2,053.3	0.9	6.20	1	1	1
12/07/2019 11:00	1.3	12.2	2,063.3	0.9	6.20	1	1	1
12/07/2019 12:00	1.3	12.2	2,065.0	0.9	6.20	1	1	1
12/07/2019 13:00	1.3	12.3	2,059.5	0.9	6.20	1	1	1
12/07/2019 14:00	1.3	12.3	2,058.0	0.9	6.20	1	1	1
12/07/2019 15:00	1.3	12.4	2,041.5	0.9	6.10	1	1	1
12/07/2019 16:00	1.3	12.4	2,052.6	0.9	6.20	1	1	1
12/07/2019 17:00	1.3	12.4	2,051.1	0.9	6.20	1	1	1
12/07/2019 18:00	1.3	12.1	2,107.4	0.9	6.30	1	1	1
12/07/2019 19:00	1.3	12.2	2,084.4	0.9	6.30	1	1	1
12/07/2019 20:00	1.3	12.2	2,095.9	0.9	6.30	1	1	1
12/07/2019 21:00	1.3	12.2	2,092.9	0.9	6.30	1	1	1
12/07/2019 22:00	1.3	12.3	2,068.3	0.9	6.20	1	1	1
12/07/2019 23:00	1.3	12.3	2,065.9	0.9	6.20	1	1	1
Average/Sum#:	1.3	12.3	2,068.3	0.9	151.10 #	24 #	24 #	24 #
Minimum:	1.3	11.8	2,037.2	0.8	6.10	1	1	1
Maximum:	1.4	12.5	2,181.2	1.0	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/08/2019 00:00	1.3	12.3	2,081.2	0.9	6.20	1	1	1
12/08/2019 01:00	1.1	12.9	1,930.7	0.8	5.80	1	1	1
12/08/2019 02:00	0.5	13.9	1,595.4	0.4	3.20	1	1	0
12/08/2019 03:00	0.4	13.9	1,458.5	0.3	1.50	1	1	0
12/08/2019 04:00	0.5	13.9	1,596.1	0.4	3.20	1	1	0
12/08/2019 05:00	0.5	13.9	1,666.5	0.4	3.30	1	1	0
12/08/2019 06:00	0.5	13.9	1,677.6	0.4	3.40	1	1	0
12/08/2019 07:00	0.5	13.9	1,657.6	0.4	3.30	1	1	0
12/08/2019 08:00	0.5	13.9	1,637.2	0.4	3.30	1	1	0
12/08/2019 09:00	0.5	13.9	1,642.1	0.4	3.30	1	1	0
12/08/2019 10:00	0.5	13.9	1,495.8	0.4	3.00	1	1	0
12/08/2019 11:00	0.5	13.9	1,581.9	0.4	3.20	1	1	0
12/08/2019 12:00	0.5	13.9	1,503.5	0.4	3.00	1	1	0
12/08/2019 13:00	0.6	13.9	1,646.3	0.5	3.30	1	1	0
12/08/2019 14:00	0.6	13.7	1,658.3	0.5	3.30	1	1	1
12/08/2019 15:00	1.0	13.1	1,877.2	0.8	5.60	1	1	1
12/08/2019 16:00	1.3	12.5	2,043.8	0.9	6.10	1	1	1
12/08/2019 17:00	1.3	12.5	2,031.1	0.9	6.10	1	1	1
12/08/2019 18:00	1.3	12.4	2,080.7	0.9	6.20	1	1	1
12/08/2019 19:00	1.3	12.3	2,096.9	0.9	6.30	1	1	1
12/08/2019 20:00	1.3	12.3	2,102.2	0.9	6.30	1	1	1
12/08/2019 21:00	1.3	12.5	2,056.3	0.9	6.20	1	1	1
12/08/2019 22:00	1.3	12.3	2,097.5	0.9	6.30	1	1	1
12/08/2019 23:00	1.3	12.2	2,112.4	0.9	6.30	1	1	1
Average/Sum#:	0.9	13.2	1,805.3	0.6	107.70 #	24 #	24 #	12 #
Minimum:	0.4	12.2	1,458.5	0.3	1.50	1	1	0
Maximum:	1.3	13.9	2,112.4	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2019 00:00	1.3	12.4	2,082.3	0.9	6.20	1	1	1
12/09/2019 01:00	1.3	12.6	2,036.6	0.9	6.10	1	1	1
12/09/2019 02:00	1.3	12.7	2,016.3	0.9	6.00	1	1	1
12/09/2019 03:00	1.2	12.7	2,022.7	0.9	6.10	1	1	1
12/09/2019 04:00	1.2	12.5	2,071.9	0.8	6.20	1	1	1
12/09/2019 05:00	1.1	12.5	2,062.7	0.8	6.20	1	1	1
12/09/2019 06:00	1.3	12.5	2,067.6	0.9	6.20	1	1	1
12/09/2019 07:00	1.3	12.4	2,105.5	0.9	6.30	1	1	1
12/09/2019 08:00	1.3	12.4	2,097.8	0.9	6.30	1	1	1
12/09/2019 09:00	1.3	12.4	2,088.6	0.9	6.30	1	1	1
12/09/2019 10:00	1.2	12.6	2,035.9	0.9	6.10	1	1	1
12/09/2019 11:00	1.2	12.7	2,031.3	0.9	6.10	1	1	1
12/09/2019 12:00	1.3	12.6	2,026.3	0.9	6.10	1	1	1
12/09/2019 13:00	1.2	12.6	2,035.0	0.9	6.10	1	1	1
12/09/2019 14:00	1.2	12.6	2,015.9	0.9	6.00	1	1	1
12/09/2019 15:00	1.3	12.5	2,056.8	0.9	6.20	1	1	1
12/09/2019 16:00	1.3	12.5	2,047.2	0.9	6.10	1	1	1
12/09/2019 17:00	1.3	12.3	2,102.2	0.9	6.30	1	1	1
12/09/2019 18:00	1.3	12.0	2,168.2	0.9	6.50	1	1	1
12/09/2019 19:00	1.3	11.9	2,185.6	0.9	6.60	1	1	1
12/09/2019 20:00	1.4	12.0	2,184.6	0.9	6.60	1	1	1
12/09/2019 21:00	1.3	12.3	2,113.8	0.9	6.30	1	1	1
12/09/2019 22:00	1.3	12.3	2,106.2	0.9	6.30	1	1	1
12/09/2019 23:00	1.3	12.5	2,098.8	0.9	6.30	1	1	1
Average/Sum#:	1.3	12.4	2,077.5	0.9	149.50 #	24 #	24 #	24 #
Minimum:	1.1	11.9	2,015.9	0.8	6.00	1	1	1
Maximum:	1.4	12.7	2,185.6	0.9	6.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/10/2019 00:00	1.3	12.4	2,130.1	0.9	6.40	1	1	1
12/10/2019 01:00	1.3	12.4	2,122.5	0.9	6.40	1	1	1
12/10/2019 02:00	1.3	12.4	2,113.9	0.9	6.30	1	1	1
12/10/2019 03:00	1.3	12.4	2,126.8	0.9	6.40	1	1	1
12/10/2019 04:00	1.3	12.4	2,134.7	0.9	6.40	1	1	1
12/10/2019 05:00	1.4	12.4	2,118.1	1.0	8.50	1	1	1
12/10/2019 06:00	1.3	12.4	2,128.6	0.9	6.40	1	1	1
12/10/2019 07:00	1.3	12.3	2,151.0	0.9	6.50	1	1	1
12/10/2019 08:00	1.3	12.6	2,087.7	0.9	6.30	1	1	1
12/10/2019 09:00	1.3	12.4	2,119.3	0.9	6.40	1	1	1
12/10/2019 10:00	1.3	12.7	2,060.8	0.9	6.20	1	1	1
12/10/2019 11:00	1.3	12.7	2,050.2	0.9	6.20	1	1	1
12/10/2019 12:00	1.3	12.6	2,067.5	0.9	6.20	1	1	1
12/10/2019 13:00	1.3	12.6	2,064.1	0.9	6.20	1	1	1
12/10/2019 14:00	1.3	12.6	2,069.4	0.9	6.20	1	1	1
12/10/2019 15:00	1.3	12.6	2,053.7	0.9	6.20	1	1	1
12/10/2019 16:00	1.3	12.5	2,072.3	0.9	6.20	1	1	1
12/10/2019 17:00	1.3	12.2	2,149.5	0.9	6.40	1	1	1
12/10/2019 18:00	1.3	12.0	2,172.8	0.9	6.50	1	1	1
12/10/2019 19:00	1.3	12.0	2,182.4	0.9	6.50	1	1	1
12/10/2019 20:00	1.3	12.0	2,182.1	0.9	6.50	1	1	1
12/10/2019 21:00	1.3	12.2	2,136.5	0.9	6.40	1	1	1
12/10/2019 22:00	1.3	12.5	2,090.3	0.9	6.30	1	1	1
12/10/2019 23:00	1.3	12.5	2,080.4	0.9	6.20	1	1	1
Average/Sum#:	1.3	12.4	2,111.0	0.9	154.20 #	24 #	24 #	24 #
Minimum:	1.3	12.0	2,050.2	0.9	6.20	1	1	1
Maximum:	1.4	12.7	2,182.4	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/11/2019 00:00	1.3	12.3	2,113.6	0.9	6.30	1	1	1
12/11/2019 01:00	1.3	12.3	2,111.9	0.9	6.30	1	1	1
12/11/2019 02:00	1.3	12.5	2,080.4	0.9	6.20	1	1	1
12/11/2019 03:00	1.3	12.7	2,027.6	0.9	6.10	1	1	1
12/11/2019 04:00	1.3	12.6	2,053.1	0.9	6.20	1	1	1
12/11/2019 05:00	1.2	12.4	2,078.8	0.8	6.20	1	1	1
12/11/2019 06:00	1.2	12.3	2,119.9	0.8	6.40	1	1	1
12/11/2019 07:00	1.3	12.4	2,110.8	0.9	6.30	1	1	1
12/11/2019 08:00	1.3	12.5	2,075.9	0.9	6.20	1	1	1
12/11/2019 09:00	1.3	12.7	2,043.6	0.9	6.10	1	1	1
12/11/2019 10:00	1.3	12.6	2,057.8	0.9	6.20	1	1	1
12/11/2019 11:00	1.3	12.7	2,037.4	0.9	6.10	1	1	1
12/11/2019 12:00	1.3	12.7	2,039.8	0.9	6.10	1	1	1
12/11/2019 13:00	1.3	12.7	2,037.9	0.9	6.10	1	1	1
12/11/2019 14:00	1.3	12.5	2,069.3	0.9	6.20	1	1	1
12/11/2019 15:00	1.3	12.7	2,031.3	0.9	6.10	1	1	1
12/11/2019 16:00	1.3	12.6	2,049.9	0.9	6.10	1	1	1
12/11/2019 17:00	1.3	12.3	2,111.8	0.9	6.30	1	1	1
12/11/2019 18:00	1.3	12.4	2,084.0	0.9	6.30	1	1	1
12/11/2019 19:00	1.3	12.1	2,150.6	0.9	6.50	1	1	1
12/11/2019 20:00	1.3	12.4	2,090.0	0.9	6.30	1	1	1
12/11/2019 21:00	1.3	12.5	2,056.9	0.9	6.20	1	1	1
12/11/2019 22:00	1.3	12.6	2,043.4	0.9	6.10	1	1	1
12/11/2019 23:00	1.3	12.6	2,048.1	0.9	6.10	1	1	1
Average/Sum#:	1.3	12.5	2,071.8	0.9	149.00 #	24 #	24 #	24 #
Minimum:	1.2	12.1	2,027.6	0.8	6.10	1	1	1
Maximum:	1.3	12.7	2,150.6	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/12/2019 00:00	1.3	12.6	2,042.6	0.9	6.10	1	1	1
12/12/2019 01:00	1.3	12.6	2,032.2	0.9	6.10	1	1	1
12/12/2019 02:00	1.3	12.6	2,039.7	0.9	6.10	1	1	1
12/12/2019 03:00	1.3	12.6	2,039.7	0.9	6.10	1	1	1
12/12/2019 04:00	1.3	12.6	2,039.2	0.9	6.10	1	1	1
12/12/2019 05:00	1.2	12.6	2,041.5	0.9	6.10	1	1	1
12/12/2019 06:00	1.3	12.4	2,101.2	0.9	6.30	1	1	1
12/12/2019 07:00	1.3	12.2	2,127.0	0.9	6.40	1	1	1
12/12/2019 08:00	1.3	12.6	2,047.7	0.9	6.10	1	1	1
12/12/2019 09:00	1.3	12.6	2,041.3	0.9	6.10	1	1	1
12/12/2019 10:00	1.3	12.7	2,019.4	0.9	6.10	1	1	1
12/12/2019 11:00	1.3	12.7	2,015.2	0.9	6.00	1	1	1
12/12/2019 12:00	1.3	12.6	2,029.4	0.9	6.10	1	1	1
12/12/2019 13:00	1.3	12.6	2,034.4	0.9	6.10	1	1	1
12/12/2019 14:00	1.3	12.6	2,041.7	0.9	6.10	1	1	1
12/12/2019 15:00	1.3	12.6	2,040.1	0.9	6.10	1	1	1
12/12/2019 16:00	1.3	12.5	2,045.9	0.9	6.10	1	1	1
12/12/2019 17:00	1.3	12.3	2,102.5	0.9	6.30	1	1	1
12/12/2019 18:00	1.3	12.2	2,105.8	0.9	6.30	1	1	1
12/12/2019 19:00	1.3	12.3	2,097.8	0.9	6.30	1	1	1
12/12/2019 20:00	1.3	12.5	2,056.2	0.9	6.20	1	1	1
12/12/2019 21:00	1.3	12.5	2,061.2	0.9	6.20	1	1	1
12/12/2019 22:00	1.3	12.5	2,054.9	0.9	6.20	1	1	1
12/12/2019 23:00	1.0	13.3	1,815.7	0.8	5.40	1	1	1
Average/Sum#:	1.3	12.6	2,044.7	0.9	147.00 #	24 #	24 #	24 #
Minimum:	1.0	12.2	1,815.7	0.8	5.40	1	1	1
Maximum:	1.3	13.3	2,127.0	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/13/2019 00:00	1.4	14.3	1,253.4	1.3	5.36	1	0	0
12/13/2019 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/13/2019 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/13/2019 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/13/2019 04:00	2.7	17.4	488.8	4.6	4.57	1	0	0
12/13/2019 05:00	4.4	14.2	1,281.4	3.9	17.90	1	0	0
12/13/2019 06:00	0.2	13.9	1,389.3	0.2	1.40	1	1	0
12/13/2019 07:00	0.4	13.8	1,574.2	0.3	1.60	1	1	0
12/13/2019 08:00	0.5	13.8	1,672.8	0.4	3.30	1	1	0
12/13/2019 09:00	0.4	13.8	1,632.3	0.3	1.60	1	1	0
12/13/2019 10:00	0.5	13.9	1,682.6	0.4	3.40	1	1	0
12/13/2019 11:00	0.4	13.9	1,592.4	0.3	1.60	1	1	0
12/13/2019 12:00	0.4	13.9	1,489.3	0.3	1.50	1	1	0
12/13/2019 13:00	0.5	13.9	1,652.0	0.4	3.30	1	1	0
12/13/2019 14:00	0.5	13.8	1,731.7	0.4	3.50	1	1	1
12/13/2019 15:00	1.3	12.6	2,026.4	0.9	6.10	1	1	1
12/13/2019 16:00	1.3	12.3	2,079.6	0.9	6.20	1	1	1
12/13/2019 17:00	1.3	12.3	2,072.8	0.9	6.20	1	1	1
12/13/2019 18:00	1.3	12.0	2,151.0	0.9	6.50	1	1	1
12/13/2019 19:00	1.3	12.3	2,078.7	0.9	6.20	1	1	1
12/13/2019 20:00	1.3	12.2	2,110.5	0.9	6.30	1	1	1
12/13/2019 21:00	1.3	12.2	2,097.8	0.9	6.30	1	1	1
12/13/2019 22:00	1.3	12.2	2,094.1	0.9	6.30	1	1	1
12/13/2019 23:00	1.3	12.3	2,084.2	0.9	6.30	1	1	1
Average/Sum#:	1.1	13.4	1,725.5	1.0	105.43 #	21 #	18 #	10 #
Minimum:	0.2	12.0	488.8	0.2	1.40	0	0	0
Maximum:	4.4	17.4	2,151.0	4.6	17.90	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/14/2019 00:00	1.3	12.5	2,066.6	0.9	6.20	1	1	1
12/14/2019 01:00	1.2	12.8	1,966.5	0.9	5.90	1	1	1
12/14/2019 02:00	0.5	13.9	1,598.2	0.4	3.20	1	1	0
12/14/2019 03:00	0.4	13.9	1,553.5	0.3	1.60	1	1	0
12/14/2019 04:00	0.5	13.9	1,690.2	0.4	3.40	1	1	0
12/14/2019 05:00	0.4	13.9	1,624.9	0.3	1.60	1	1	0
12/14/2019 06:00	0.4	13.9	1,557.7	0.3	1.60	1	1	0
12/14/2019 07:00	0.3	13.9	1,482.7	0.3	1.50	1	1	0
12/14/2019 08:00	0.4	13.9	1,479.0	0.3	1.50	1	1	0
12/14/2019 09:00	0.5	13.9	1,637.4	0.4	3.30	1	1	0
12/14/2019 10:00	0.5	13.9	1,573.1	0.4	3.10	1	1	0
12/14/2019 11:00	0.5	13.9	1,601.7	0.4	3.20	1	1	0
12/14/2019 12:00	0.3	13.9	1,379.0	0.3	1.40	1	1	0
12/14/2019 13:00	0.5	13.9	1,645.5	0.4	3.30	1	1	0
12/14/2019 14:00	0.5	13.9	1,597.2	0.4	3.20	1	1	0
12/14/2019 15:00	0.4	13.8	1,604.1	0.3	1.60	1	1	1
12/14/2019 16:00	1.3	12.7	2,011.1	0.9	6.00	1	1	1
12/14/2019 17:00	1.3	12.3	2,091.2	0.9	6.30	1	1	1
12/14/2019 18:00	1.3	12.3	2,097.9	0.9	6.30	1	1	1
12/14/2019 19:00	1.3	12.5	2,063.6	0.9	6.20	1	1	1
12/14/2019 20:00	1.3	12.2	2,130.0	0.9	6.40	1	1	1
12/14/2019 21:00	1.3	12.3	2,129.7	0.9	6.40	1	1	1
12/14/2019 22:00	1.3	12.5	2,068.3	0.9	6.20	1	1	1
12/14/2019 23:00	1.0	13.1	1,936.1	0.8	5.80	1	1	1
Average/Sum#:	0.8	13.3	1,774.4	0.6	95.20 #	24 #	24 #	11 #
Minimum:	0.3	12.2	1,379.0	0.3	1.40	1	1	0
Maximum:	1.3	13.9	2,130.0	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2019 00:00	1.3	12.7	2,039.2	0.9	6.10	1	1	1
12/15/2019 01:00	1.3	12.8	2,026.0	0.9	6.10	1	1	1
12/15/2019 02:00	1.3	12.5	2,080.0	0.9	6.20	1	1	1
12/15/2019 03:00	1.3	12.4	2,104.8	0.9	6.30	1	1	1
12/15/2019 04:00	1.3	12.4	2,114.0	0.9	6.30	1	1	1
12/15/2019 05:00	1.2	12.6	2,069.8	0.9	6.20	1	1	1
12/15/2019 06:00	1.3	12.7	2,080.6	0.9	6.20	1	1	1
12/15/2019 07:00	1.0	13.1	1,950.0	0.8	5.90	1	1	1
12/15/2019 08:00	0.5	13.9	1,584.7	0.4	3.20	1	1	0
12/15/2019 09:00	0.4	13.9	1,634.3	0.3	1.60	1	1	0
12/15/2019 10:00	0.4	13.9	1,536.0	0.3	1.50	1	1	0
12/15/2019 11:00	0.4	13.9	1,561.6	0.3	1.60	1	1	0
12/15/2019 12:00	0.4	13.9	1,545.2	0.3	1.50	1	1	0
12/15/2019 13:00	0.4	13.9	1,636.2	0.3	1.60	1	1	0
12/15/2019 14:00	0.4	13.9	1,570.8	0.3	1.60	1	1	0
12/15/2019 15:00	0.4	13.9	1,566.1	0.3	1.60	1	1	1
12/15/2019 16:00	1.2	12.9	2,007.0	0.9	6.00	1	1	1
12/15/2019 17:00	1.3	12.6	2,073.0	0.9	6.20	1	1	1
12/15/2019 18:00	1.3	12.1	2,173.9	0.9	6.50	1	1	1
12/15/2019 19:00	1.3	11.9	2,217.2	0.9	6.70	1	1	1
12/15/2019 20:00	1.3	11.9	2,209.8	0.9	6.60	1	1	1
12/15/2019 21:00	1.3	12.0	2,203.1	0.9	6.60	1	1	1
12/15/2019 22:00	1.3	12.4	2,119.6	0.9	6.40	1	1	1
12/15/2019 23:00	1.3	12.5	2,090.4	0.9	6.30	1	1	1
Average/Sum#:	1.0	12.9	1,924.7	0.7	114.80 #	24 #	24 #	17 #
Minimum:	0.4	11.9	1,536.0	0.3	1.50	1	1	0
Maximum:	1.3	13.9	2,217.2	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/16/2019 00:00	1.3	12.4	2,135.2	0.9	6.40	1	1	1
12/16/2019 01:00	1.3	12.4	2,136.2	0.9	6.40	1	1	1
12/16/2019 02:00	1.3	12.5	2,127.9	0.9	6.40	1	1	1
12/16/2019 03:00	1.3	12.4	2,144.8	0.9	6.40	1	1	1
12/16/2019 04:00	1.3	12.4	2,139.4	0.9	6.40	1	1	1
12/16/2019 05:00	1.1	12.4	2,115.9	0.8	6.30	1	1	1
12/16/2019 06:00	1.3	12.0	2,240.1	0.9	6.70	1	1	1
12/16/2019 07:00	1.3	12.2	2,185.3	0.9	6.60	1	1	1
12/16/2019 08:00	1.2	12.9	2,026.4	0.9	6.10	1	1	1
12/16/2019 09:00	1.2	12.9	2,023.1	0.9	6.10	1	1	1
12/16/2019 10:00	1.2	12.8	2,046.1	0.9	6.10	1	1	1
12/16/2019 11:00	1.3	12.8	2,036.8	0.9	6.10	1	1	1
12/16/2019 12:00	1.3	12.7	2,037.0	0.9	6.10	1	1	1
12/16/2019 13:00	1.2	12.7	2,041.3	0.9	6.10	1	1	1
12/16/2019 14:00	1.2	12.6	2,051.4	0.9	6.20	1	1	1
12/16/2019 15:00	1.3	12.5	2,073.5	0.9	6.20	1	1	1
12/16/2019 16:00	1.3	12.4	2,101.0	0.9	6.30	1	1	1
12/16/2019 17:00	1.3	12.1	2,175.8	0.9	6.50	1	1	1
12/16/2019 18:00	1.3	12.0	2,196.3	0.9	6.60	1	1	1
12/16/2019 19:00	1.3	11.9	2,220.4	0.9	6.70	1	1	1
12/16/2019 20:00	1.3	12.0	2,221.2	0.9	6.70	1	1	1
12/16/2019 21:00	1.3	12.0	2,214.3	0.9	6.60	1	1	1
12/16/2019 22:00	1.3	12.3	2,168.0	0.9	6.50	1	1	1
12/16/2019 23:00	1.3	12.6	2,105.4	0.9	6.30	1	1	1
Average/Sum#:	1.3	12.4	2,123.5	0.9	152.80 #	24 #	24 #	24 #
Minimum:	1.1	11.9	2,023.1	0.8	6.10	1	1	1
Maximum:	1.3	12.9	2,240.1	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/17/2019 00:00	1.3	12.5	2,120.4	0.9	6.40	1	1	1
12/17/2019 01:00	1.3	12.5	2,138.6	0.9	6.40	1	1	1
12/17/2019 02:00	1.3	12.5	2,135.3	0.9	6.40	1	1	1
12/17/2019 03:00	1.3	12.5	2,138.8	0.9	6.40	1	1	1
12/17/2019 04:00	1.3	12.7	2,109.4	0.9	6.30	1	1	1
12/17/2019 05:00	1.2	12.6	2,093.4	0.9	6.30	1	1	1
12/17/2019 06:00	1.3	12.4	2,170.6	0.9	6.50	1	1	1
12/17/2019 07:00	1.3	12.4	2,159.3	0.9	6.50	1	1	1
12/17/2019 08:00	1.3	12.6	2,109.3	0.9	6.30	1	1	1
12/17/2019 09:00	1.3	12.8	2,050.0	0.9	6.20	1	1	1
12/17/2019 10:00	1.3	12.9	2,031.3	1.0	8.10	1	1	1
12/17/2019 11:00	1.3	12.8	2,033.8	0.9	6.10	1	1	1
12/17/2019 12:00	1.3	12.8	2,043.2	0.9	6.10	1	1	1
12/17/2019 13:00	1.3	12.7	2,055.8	0.9	6.20	1	1	1
12/17/2019 14:00	1.3	12.5	2,085.7	0.9	6.30	1	1	1
12/17/2019 15:00	1.3	12.4	2,108.8	0.9	6.30	1	1	1
12/17/2019 16:00	1.3	12.2	2,149.3	0.9	6.40	1	1	1
12/17/2019 17:00	1.3	12.0	2,201.8	0.9	6.60	1	1	1
12/17/2019 18:00	1.3	11.8	2,256.6	0.8	6.80	1	1	1
12/17/2019 19:00	1.3	11.7	2,259.4	0.8	6.80	1	1	1
12/17/2019 20:00	1.3	11.9	2,229.3	0.9	6.70	1	1	1
12/17/2019 21:00	1.3	12.0	2,200.9	0.9	6.60	1	1	1
12/17/2019 22:00	1.3	12.0	2,195.1	0.9	6.60	1	1	1
12/17/2019 23:00	1.3	12.5	2,103.1	0.9	6.30	1	1	1
Average/Sum#:	1.3	12.4	2,132.5	0.9	155.60 #	24 #	24 #	24 #
Minimum:	1.2	11.7	2,031.3	0.8	6.10	1	1	1
Maximum:	1.3	12.9	2,259.4	1.0	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/18/2019 00:00	1.3	12.6	2,089.0	0.9	6.30	1	1	1
12/18/2019 01:00	1.3	12.4	2,115.3	0.9	6.30	1	1	1
12/18/2019 02:00	1.3	12.4	2,114.3	0.9	6.30	1	1	1
12/18/2019 03:00	1.3	12.4	2,122.6	0.9	6.40	1	1	1
12/18/2019 04:00	1.3	12.3	2,129.6	0.9	6.40	1	1	1
12/18/2019 05:00	0.9	12.0	2,172.0	0.6	4.30	1	1	1
12/18/2019 06:00	1.4	11.9	2,235.6	0.9	6.70	1	1	1
12/18/2019 07:00	1.4	12.1	2,195.4	0.9	6.60	1	1	1
12/18/2019 08:00	1.3	12.4	2,141.4	0.9	6.40	1	1	1
12/18/2019 09:00	1.3	12.4	2,125.4	0.9	6.40	1	1	1
12/18/2019 10:00	1.3	12.5	2,117.8	0.9	6.40	1	1	1
12/18/2019 11:00	1.3	12.4	2,135.0	0.9	6.40	1	1	1
12/18/2019 12:00	1.3	12.5	2,110.5	0.9	6.30	1	1	1
12/18/2019 13:00	1.3	12.5	2,109.7	0.9	6.30	1	1	1
12/18/2019 14:00	1.3	12.5	2,098.3	0.9	6.30	1	1	1
12/18/2019 15:00	1.3	12.7	2,072.9	0.9	6.20	1	1	1
12/18/2019 16:00	1.3	12.4	2,130.6	0.9	6.40	1	1	1
12/18/2019 17:00	1.4	12.1	2,193.1	0.9	6.60	1	1	1
12/18/2019 18:00	1.4	12.0	2,207.0	0.9	6.60	1	1	1
12/18/2019 19:00	1.4	12.1	2,204.7	0.9	6.60	1	1	1
12/18/2019 20:00	1.4	12.1	2,199.0	0.9	6.60	1	1	1
12/18/2019 21:00	1.4	12.0	2,202.2	0.9	6.60	1	1	1
12/18/2019 22:00	1.4	12.1	2,194.6	0.9	6.60	1	1	1
12/18/2019 23:00	1.4	12.5	2,101.3	1.0	8.40	1	1	1
Average/Sum#:	1.3	12.3	2,146.6	0.9	154.40 #	24 #	24 #	24 #
Minimum:	0.9	11.9	2,072.9	0.6	4.30	1	1	1
Maximum:	1.4	12.7	2,235.6	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2019 00:00	1.3	12.4	2,116.4	0.9	6.30	1	1	1
12/19/2019 01:00	1.4	12.4	2,119.2	1.0	8.50	1	1	1
12/19/2019 02:00	1.3	12.4	2,112.3	0.9	6.30	1	1	1
12/19/2019 03:00	1.3	12.5	2,100.6	0.9	6.30	1	1	1
12/19/2019 04:00	1.3	12.4	2,115.1	0.9	6.30	1	1	1
12/19/2019 05:00	1.4	12.3	2,108.2	1.0	8.40	1	1	1
12/19/2019 06:00	1.4	12.0	2,210.4	0.9	6.60	1	1	1
12/19/2019 07:00	1.4	12.1	2,166.6	0.9	6.50	1	1	1
12/19/2019 08:00	1.3	12.7	2,040.7	0.9	6.10	1	1	1
12/19/2019 09:00	1.3	12.6	2,069.9	0.9	6.20	1	1	1
12/19/2019 10:00	1.3	12.8	2,036.9	0.9	6.10	1	1	1
12/19/2019 11:00	1.3	12.8	2,042.3	0.9	6.10	1	1	1
12/19/2019 12:00	1.3	12.7	2,037.8	0.9	6.10	1	1	1
12/19/2019 13:00	1.3	12.7	2,040.2	0.9	6.10	1	1	1
12/19/2019 14:00	1.3	12.7	2,026.1	0.9	6.10	1	1	1
12/19/2019 15:00	1.3	12.5	2,081.3	0.9	6.20	1	1	1
12/19/2019 16:00	1.3	12.4	2,101.2	0.9	6.30	1	1	1
12/19/2019 17:00	1.4	12.1	2,157.6	0.9	6.50	1	1	1
12/19/2019 18:00	1.4	11.9	2,200.2	0.9	6.60	1	1	1
12/19/2019 19:00	1.4	12.1	2,161.4	0.9	6.50	1	1	1
12/19/2019 20:00	1.4	12.1	2,167.1	0.9	6.50	1	1	1
12/19/2019 21:00	1.4	12.1	2,169.9	0.9	6.50	1	1	1
12/19/2019 22:00	1.3	12.4	2,109.8	0.9	6.30	1	1	1
12/19/2019 23:00	1.3	12.5	2,095.3	0.9	6.30	1	1	1
Average/Sum#:	1.3	12.4	2,107.8	0.9	155.70 #	24 #	24 #	24 #
Minimum:	1.3	11.9	2,026.1	0.9	6.10	1	1	1
Maximum:	1.4	12.8	2,210.4	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/20/2019 00:00	1.3	12.4	2,115.2	0.9	6.30	1	1	1
12/20/2019 01:00	1.3	12.5	2,098.7	0.9	6.30	1	1	1
12/20/2019 02:00	1.3	12.4	2,103.9	0.9	6.30	1	1	1
12/20/2019 03:00	1.3	12.8	2,040.2	0.9	6.10	1	1	1
12/20/2019 04:00	1.3	12.5	2,088.3	0.9	6.30	1	1	1
12/20/2019 05:00	1.0	12.4	2,097.8	0.7	6.30	1	1	1
12/20/2019 06:00	1.3	12.3	2,128.5	0.9	6.40	1	1	1
12/20/2019 07:00	1.3	12.6	2,070.4	0.9	6.20	1	1	1
12/20/2019 08:00	1.3	12.8	2,026.6	0.9	6.10	1	1	1
12/20/2019 09:00	1.3	12.7	2,046.5	0.9	6.10	1	1	1
12/20/2019 10:00	1.2	13.0	1,944.5	0.9	5.80	1	1	1
12/20/2019 11:00	0.5	13.9	1,641.5	0.4	3.30	1	1	0
12/20/2019 12:00	0.5	13.9	1,590.6	0.4	3.20	1	1	0
12/20/2019 13:00	0.5	13.9	1,650.3	0.4	3.30	1	1	0
12/20/2019 14:00	0.4	13.9	1,564.3	0.3	1.60	1	1	1
12/20/2019 15:00	1.3	12.6	2,047.0	0.9	6.10	1	1	1
12/20/2019 16:00	1.3	12.4	2,093.1	0.9	6.30	1	1	1
12/20/2019 17:00	1.4	12.1	2,151.4	0.9	6.50	1	1	1
12/20/2019 18:00	1.3	12.0	2,184.9	0.9	6.60	1	1	1
12/20/2019 19:00	1.3	12.2	2,137.8	0.9	6.40	1	1	1
12/20/2019 20:00	1.4	12.3	2,133.7	1.0	8.50	1	1	1
12/20/2019 21:00	1.3	12.3	2,131.5	0.9	6.40	1	1	1
12/20/2019 22:00	1.3	12.2	2,136.7	0.9	6.40	1	1	1
12/20/2019 23:00	1.4	12.3	2,127.4	1.0	8.50	1	1	1
Average/Sum#:	1.2	12.7	2,014.6	0.8	141.30 #	24 #	24 #	21 #
Minimum:	0.4	12.0	1,564.3	0.3	1.60	1	1	0
Maximum:	1.4	13.9	2,184.9	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2019 00:00	1.4	12.5	2,087.4	1.0	8.30	1	1	1
12/21/2019 01:00	1.3	12.6	2,066.4	0.9	6.20	1	1	1
12/21/2019 02:00	1.3	12.4	2,103.2	0.9	6.30	1	1	1
12/21/2019 03:00	1.4	12.4	2,105.0	1.0	8.40	1	1	1
12/21/2019 04:00	1.3	12.3	2,113.5	0.9	6.30	1	1	1
12/21/2019 05:00	1.3	12.3	2,121.1	0.9	6.40	1	1	1
12/21/2019 06:00	1.3	12.5	2,091.9	0.9	6.30	1	1	1
12/21/2019 07:00	1.4	12.3	2,129.1	1.0	8.50	1	1	1
12/21/2019 08:00	1.4	12.3	2,117.0	1.0	8.50	1	1	1
12/21/2019 09:00	1.4	12.4	2,105.9	1.0	8.40	1	1	1
12/21/2019 10:00	1.4	12.5	2,077.8	1.0	8.30	1	1	1
12/21/2019 11:00	1.3	12.7	2,037.5	0.9	6.10	1	1	1
12/21/2019 12:00	1.3	12.7	2,036.8	0.9	6.10	1	1	1
12/21/2019 13:00	1.3	12.6	2,045.5	0.9	6.10	1	1	1
12/21/2019 14:00	1.4	12.5	2,070.8	1.0	8.30	1	1	1
12/21/2019 15:00	1.3	12.6	2,060.7	0.9	6.20	1	1	1
12/21/2019 16:00	1.3	12.6	2,045.4	0.9	6.10	1	1	1
12/21/2019 17:00	1.3	12.6	2,049.1	0.9	6.10	1	1	1
12/21/2019 18:00	1.3	12.5	2,060.8	0.9	6.20	1	1	1
12/21/2019 19:00	1.4	12.5	2,071.6	1.0	8.30	1	1	1
12/21/2019 20:00	1.4	12.4	2,090.7	1.0	8.40	1	1	1
12/21/2019 21:00	1.3	12.4	2,080.2	0.9	6.20	1	1	1
12/21/2019 22:00	1.3	12.3	2,113.6	0.9	6.30	1	1	1
12/21/2019 23:00	1.4	12.3	2,112.7	1.0	8.50	1	1	1
Average/Sum#:	1.3	12.5	2,083.1	0.9	170.80 #	24 #	24 #	24 #
Minimum:	1.3	12.3	2,036.8	0.9	6.10	1	1	1
Maximum:	1.4	12.7	2,129.1	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/22/2019 00:00	1.3	12.4	2,103.5	0.9	6.30	1	1	1
12/22/2019 01:00	1.4	12.5	2,067.8	1.0	8.30	1	1	1
12/22/2019 02:00	1.4	12.2	2,123.5	0.9	6.40	1	1	1
12/22/2019 03:00	1.4	12.2	2,124.1	0.9	6.40	1	1	1
12/22/2019 04:00	1.3	12.3	2,089.4	0.9	6.30	1	1	1
12/22/2019 05:00	1.3	12.3	2,081.2	0.9	6.20	1	1	1
12/22/2019 06:00	1.3	12.2	2,119.4	0.9	6.40	1	1	1
12/22/2019 07:00	1.4	12.1	2,129.2	0.9	6.40	1	1	1
12/22/2019 08:00	1.3	12.2	2,103.1	0.9	6.30	1	1	1
12/22/2019 09:00	1.4	12.3	2,098.2	1.0	8.40	1	1	1
12/22/2019 10:00	1.4	12.3	2,090.0	1.0	8.40	1	1	1
12/22/2019 11:00	1.4	12.4	2,063.2	1.0	8.30	1	1	1
12/22/2019 12:00	1.3	12.4	2,057.0	0.9	6.20	1	1	1
12/22/2019 13:00	1.4	12.3	2,088.6	1.0	8.40	1	1	1
12/22/2019 14:00	1.4	12.3	2,065.3	1.0	8.30	1	1	1
12/22/2019 15:00	1.3	12.4	2,059.7	0.9	6.20	1	1	1
12/22/2019 16:00	1.3	12.6	2,016.6	0.9	6.00	1	1	1
12/22/2019 17:00	1.4	12.6	2,020.9	1.0	8.10	1	1	1
12/22/2019 18:00	1.3	12.5	2,035.5	0.9	6.10	1	1	1
12/22/2019 19:00	1.3	12.6	2,039.0	0.9	6.10	1	1	1
12/22/2019 20:00	1.4	12.5	2,066.6	1.0	8.30	1	1	1
12/22/2019 21:00	1.3	12.5	2,071.8	0.9	6.20	1	1	1
12/22/2019 22:00	1.3	12.7	2,039.8	0.9	6.10	1	1	1
12/22/2019 23:00	1.3	12.6	2,050.7	0.9	6.20	1	1	1
Average/Sum#:	1.3	12.4	2,075.2	0.9	166.30 #	24 #	24 #	24 #
Minimum:	1.3	12.1	2,016.6	0.9	6.00	1	1	1
Maximum:	1.4	12.7	2,129.2	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/23/2019 00:00	1.4	12.6	2,056.1	1.0	8.20	1	1	1
12/23/2019 01:00	1.3	12.7	2,034.1	0.9	6.10	1	1	1
12/23/2019 02:00	1.3	12.7	2,036.2	0.9	6.10	1	1	1
12/23/2019 03:00	1.3	12.6	2,058.3	0.9	6.20	1	1	1
12/23/2019 04:00	1.3	12.6	2,048.0	0.9	6.10	1	1	1
12/23/2019 05:00	1.2	12.7	2,038.4	0.9	6.10	1	1	1
12/23/2019 06:00	1.3	12.7	2,050.3	0.9	6.20	1	1	1
12/23/2019 07:00	1.3	12.7	2,052.9	0.9	6.20	1	1	1
12/23/2019 08:00	1.3	12.0	2,196.3	0.9	6.60	1	1	1
12/23/2019 09:00	1.3	12.3	2,115.8	0.9	6.30	1	1	1
12/23/2019 10:00	1.3	12.3	2,111.4	0.9	6.30	1	1	1
12/23/2019 11:00	1.3	12.2	2,120.2	0.9	6.40	1	1	1
12/23/2019 12:00	1.3	12.2	2,121.4	0.9	6.40	1	1	1
12/23/2019 13:00	1.3	12.4	2,062.9	0.9	6.20	1	1	1
12/23/2019 14:00	1.3	12.3	2,094.8	0.9	6.30	1	1	1
12/23/2019 15:00	1.3	12.4	2,065.5	0.9	6.20	1	1	1
12/23/2019 16:00	1.3	12.5	2,052.6	0.9	6.20	1	1	1
12/23/2019 17:00	1.3	12.6	2,045.0	0.9	6.10	1	1	1
12/23/2019 18:00	1.3	12.5	2,047.0	0.9	6.10	1	1	1
12/23/2019 19:00	1.3	12.4	2,069.6	0.9	6.20	1	1	1
12/23/2019 20:00	1.3	12.2	2,125.9	0.9	6.40	1	1	1
12/23/2019 21:00	1.3	12.3	2,105.3	0.9	6.30	1	1	1
12/23/2019 22:00	1.3	12.3	2,099.8	0.9	6.30	1	1	1
12/23/2019 23:00	1.3	12.5	2,105.4	0.9	6.30	1	1	1
Average/Sum#:	1.3	12.4	2,079.7	0.9	151.80 #	24 #	24 #	24 #
Minimum:	1.2	12.0	2,034.1	0.9	6.10	1	1	1
Maximum:	1.4	12.7	2,196.3	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/24/2019 00:00	1.3	12.5	2,097.0	0.9	6.30	1	1	1
12/24/2019 01:00	1.3	12.7	2,050.2	0.9	6.20	1	1	1
12/24/2019 02:00	1.3	12.8	2,049.9	0.9	6.10	1	1	1
12/24/2019 03:00	1.3	12.8	2,049.2	0.9	6.10	1	1	1
12/24/2019 04:00	1.3	12.7	2,046.8	0.9	6.10	1	1	1
12/24/2019 05:00	1.3	12.7	2,047.6	0.9	6.10	1	1	1
12/24/2019 06:00	1.3	12.6	2,076.5	0.9	6.20	1	1	1
12/24/2019 07:00	1.3	12.8	2,057.9	0.9	6.20	1	1	1
12/24/2019 08:00	1.3	12.8	2,036.7	0.9	6.10	1	1	1
12/24/2019 09:00	1.3	12.8	2,035.9	0.9	6.10	1	1	1
12/24/2019 10:00	1.3	12.8	2,041.2	0.9	6.10	1	1	1
12/24/2019 11:00	1.3	12.7	2,041.8	0.9	6.10	1	1	1
12/24/2019 12:00	1.3	12.6	2,059.2	0.9	6.20	1	1	1
12/24/2019 13:00	1.3	12.7	2,038.5	0.9	6.10	1	1	1
12/24/2019 14:00	1.3	12.7	2,041.1	0.9	6.10	1	1	1
12/24/2019 15:00	1.3	12.5	2,081.4	0.9	6.20	1	1	1
12/24/2019 16:00	1.3	12.7	2,034.5	0.9	6.10	1	1	1
12/24/2019 17:00	1.3	12.6	2,058.5	0.9	6.20	1	1	1
12/24/2019 18:00	1.3	12.7	2,053.2	0.9	6.20	1	1	1
12/24/2019 19:00	1.3	12.7	2,039.5	0.9	6.10	1	1	1
12/24/2019 20:00	1.3	12.7	2,041.6	0.9	6.10	1	1	1
12/24/2019 21:00	1.3	12.7	2,040.0	0.9	6.10	1	1	1
12/24/2019 22:00	1.3	12.6	2,052.7	0.9	6.20	1	1	1
12/24/2019 23:00	1.3	12.7	2,034.4	0.9	6.10	1	1	1
Average/Sum#:	1.3	12.7	2,050.2	0.9	147.40 #	24 #	24 #	24 #
Minimum:	1.3	12.5	2,034.4	0.9	6.10	1	1	1
Maximum:	1.3	12.8	2,097.0	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/25/2019 00:00	1.3	12.6	2,062.4	0.9	6.20	1	1	1
12/25/2019 01:00	1.4	12.5	2,079.8	1.0	8.30	1	1	1
12/25/2019 02:00	1.4	12.4	2,122.8	1.0	8.50	1	1	1
12/25/2019 03:00	1.3	12.7	2,041.5	0.9	6.10	1	1	1
12/25/2019 04:00	1.3	12.6	2,056.3	0.9	6.20	1	1	1
12/25/2019 05:00	1.3	12.7	2,038.1	0.9	6.10	1	1	1
12/25/2019 06:00	1.3	12.7	2,050.3	0.9	6.20	1	1	1
12/25/2019 07:00	1.4	12.4	2,108.2	1.0	8.40	1	1	1
12/25/2019 08:00	1.3	12.8	2,025.0	0.9	6.10	1	1	1
12/25/2019 09:00	1.3	12.7	2,043.2	0.9	6.10	1	1	1
12/25/2019 10:00	1.3	12.7	2,041.5	0.9	6.10	1	1	1
12/25/2019 11:00	1.3	12.7	2,038.8	0.9	6.10	1	1	1
12/25/2019 12:00	1.3	12.7	2,047.3	0.9	6.10	1	1	1
12/25/2019 13:00	1.4	12.7	2,041.3	1.0	8.20	1	1	1
12/25/2019 14:00	1.3	12.6	2,068.3	0.9	6.20	1	1	1
12/25/2019 15:00	1.4	12.6	2,071.3	1.0	8.30	1	1	1
12/25/2019 16:00	1.3	12.5	2,081.3	0.9	6.20	1	1	1
12/25/2019 17:00	1.4	12.7	2,051.3	1.0	8.20	1	1	1
12/25/2019 18:00	1.3	12.6	2,067.9	0.9	6.20	1	1	1
12/25/2019 19:00	1.3	12.5	2,101.0	0.9	6.30	1	1	1
12/25/2019 20:00	1.3	12.5	2,094.6	0.9	6.30	1	1	1
12/25/2019 21:00	1.3	12.6	2,074.7	0.9	6.20	1	1	1
12/25/2019 22:00	1.3	12.6	2,061.4	0.9	6.20	1	1	1
12/25/2019 23:00	1.3	12.5	2,079.1	0.9	6.20	1	1	1
Average/Sum#:	1.3	12.6	2,064.5	0.9	161.00 #	24 #	24 #	24 #
Minimum:	1.3	12.4	2,025.0	0.9	6.10	1	1	1
Maximum:	1.4	12.8	2,122.8	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/26/2019 00:00	1.3	12.6	2,064.4	0.9	6.20	1	1	1
12/26/2019 01:00	1.3	12.4	2,113.7	0.9	6.30	1	1	1
12/26/2019 02:00	1.4	12.0	2,187.0	0.9	6.60	1	1	1
12/26/2019 03:00	1.4	12.0	2,188.2	0.9	6.60	1	1	1
12/26/2019 04:00	1.3	12.0	2,203.1	0.9	6.60	1	1	1
12/26/2019 05:00	1.0	12.6	2,094.2	0.7	6.30	1	1	1
12/26/2019 06:00	1.2	12.7	2,038.3	0.9	6.10	1	1	1
12/26/2019 07:00	1.3	12.5	2,092.4	0.9	6.30	1	1	1
12/26/2019 08:00	1.4	12.1	2,180.4	0.9	6.50	1	1	1
12/26/2019 09:00	1.3	12.3	2,111.9	0.9	6.30	1	1	1
12/26/2019 10:00	1.3	12.3	2,116.4	0.9	6.30	1	1	1
12/26/2019 11:00	1.2	12.5	2,070.1	0.8	6.20	1	1	1
12/26/2019 12:00	0.9	12.5	2,750.0	0.6	5.50	1	1	1
12/26/2019 13:00	0.9	12.4	2,824.5	0.6	5.60	1	1	1
12/26/2019 14:00	0.9	12.5	2,821.1	0.6	5.60	1	1	1
12/26/2019 15:00	0.9	12.4	2,825.4	0.6	5.70	1	1	1
12/26/2019 16:00	0.9	12.2	2,831.9	0.6	5.70	1	1	1
12/26/2019 17:00	0.9	12.2	2,837.3	0.6	5.70	1	1	1
12/26/2019 18:00	0.9	12.0	2,839.8	0.6	5.70	1	1	1
12/26/2019 19:00	0.9	12.0	2,839.1	0.6	5.70	1	1	1
12/26/2019 20:00	0.9	12.0	2,839.4	0.6	5.70	1	1	1
12/26/2019 21:00	0.9	12.2	2,847.7	0.6	5.70	1	1	1
12/26/2019 22:00	0.9	12.3	2,850.5	0.6	5.70	1	1	1
12/26/2019 23:00	0.9	12.3	2,852.8	0.6	5.70	1	1	1
Average/Sum#:	1.1	12.3	2,475.8	0.7	144.30 #	24 #	24 #	24 #
Minimum:	0.9	12.0	2,038.3	0.6	5.50	1	1	1
Maximum:	1.4	12.7	2,852.8	0.9	6.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/27/2019 00:00	0.9	12.3	2,848.7	0.6	5.70	1	1	1
12/27/2019 01:00	0.9	12.4	2,855.4	0.6	5.70	1	1	1
12/27/2019 02:00	0.9	12.3	2,855.8	0.6	5.70	1	1	1
12/27/2019 03:00	0.9	12.5	2,868.0	0.6	5.70	1	1	1
12/27/2019 04:00	0.9	12.7	2,879.8	0.6	5.80	1	1	1
12/27/2019 05:00	0.9	12.7	2,890.6	0.6	5.80	1	1	1
12/27/2019 06:00	0.9	12.8	2,885.3	0.7	5.80	1	1	1
12/27/2019 07:00	1.0	12.7	2,890.9	0.7	8.70	1	1	1
12/27/2019 08:00	0.8	13.1	2,775.9	0.6	5.60	1	1	1
12/27/2019 09:00	0.3	13.9	1,683.3	0.3	1.70	1	1	0
12/27/2019 10:00	0.3	13.9	1,668.1	0.3	1.70	1	1	0
12/27/2019 11:00	0.3	13.9	1,628.7	0.3	1.60	1	1	0
12/27/2019 12:00	0.3	13.9	1,624.5	0.3	1.60	1	1	0
12/27/2019 13:00	0.3	13.9	1,675.5	0.3	1.70	1	1	0
12/27/2019 14:00	0.3	13.9	1,647.4	0.3	1.60	1	1	0
12/27/2019 15:00	0.3	14.0	1,409.3	0.3	1.40	1	1	0
12/27/2019 16:00	0.3	13.9	1,616.8	0.3	1.60	1	1	0
12/27/2019 17:00	0.3	13.9	1,719.9	0.3	1.70	1	1	1
12/27/2019 18:00	0.9	12.9	2,841.1	0.7	5.70	1	1	1
12/27/2019 19:00	0.9	12.4	2,838.8	0.6	5.70	1	1	1
12/27/2019 20:00	0.9	12.2	2,841.5	0.6	5.70	1	1	1
12/27/2019 21:00	0.8	12.3	2,842.3	0.5	5.70	1	1	1
12/27/2019 22:00	0.9	12.3	2,844.9	0.6	5.70	1	1	1
12/27/2019 23:00	0.9	12.6	2,863.2	0.6	5.70	1	1	1
Average/Sum#:	0.9	12.6	2,395.7	0.6	40.20 #	24 #	24 #	16 #
Minimum:	0.9	12.3	1,409.3	0.6	5.70	1	1	0
Maximum:	0.9	12.8	2,890.9	0.7	5.80	1	1	1
%SI	70.83	66.67	0.00	66.67	70.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/28/2019 00:00	0.9	12.9	2,868.8	0.7	5.70	1	1	1
12/28/2019 01:00	0.9	12.8	2,865.2	0.7	5.70	1	1	1
12/28/2019 02:00	0.9	12.7	2,848.9	0.6	5.70	1	1	1
12/28/2019 03:00	0.9	12.8	2,850.4	0.7	5.70	1	1	1
12/28/2019 04:00	1.0	12.9	2,893.9	0.7	8.70	1	1	1
12/28/2019 05:00	0.9	12.8	2,876.3	0.7	5.80	1	1	1
12/28/2019 06:00	0.9	12.8	2,866.5	0.7	5.70	1	1	1
12/28/2019 07:00	0.9	12.6	2,871.4	0.6	5.70	1	1	1
12/28/2019 08:00	0.9	13.0	2,818.7	0.7	5.60	1	1	1
12/28/2019 09:00	0.4	13.9	1,668.5	0.3	1.70	1	1	0
12/28/2019 10:00	0.3	13.9	1,610.3	0.3	1.60	1	1	0
12/28/2019 11:00	0.3	13.9	1,650.0	0.3	1.70	1	1	0
12/28/2019 12:00	0.3	13.9	1,683.3	0.3	1.70	1	1	0
12/28/2019 13:00	0.3	13.9	1,637.1	0.3	1.60	1	1	0
12/28/2019 14:00	0.3	13.9	1,667.1	0.3	1.70	1	1	0
12/28/2019 15:00	0.4	13.9	1,632.0	0.3	1.60	1	1	1
12/28/2019 16:00	0.9	12.7	2,831.4	0.6	5.70	1	1	1
12/28/2019 17:00	0.9	12.3	2,839.1	0.6	5.70	1	1	1
12/28/2019 18:00	1.6	12.2	2,222.4	1.1	8.90	1	1	1
12/28/2019 19:00	1.5	12.2	2,128.4	1.0	8.50	1	1	1
12/28/2019 20:00	1.3	12.3	2,125.3	0.9	6.40	1	1	1
12/28/2019 21:00	1.3	12.4	2,095.7	0.9	6.30	1	1	1
12/28/2019 22:00	1.3	12.4	2,100.7	0.9	6.30	1	1	1
12/28/2019 23:00	1.4	12.4	2,108.9	1.0	8.40	1	1	1
Average/Sum#:	0.0	0.0	2,323.3	0.0	0.00 #	24 #	24 #	18 #
Minimum:	0.0	0.0	1,610.3	0.0	0.00	1	1	0
Maximum:	0.0	0.0	2,893.9	0.0	0.00	1	1	1
%SI	100.00	100.00	0.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/29/2019 00:00	1.3	12.5	2,095.4	0.9	6.30	1	1	1
12/29/2019 01:00	1.3	12.4	2,121.5	0.9	6.40	1	1	1
12/29/2019 02:00	1.2	12.5	2,088.4	0.8	6.30	1	1	1
12/29/2019 03:00	1.2	12.4	2,111.0	0.8	6.30	1	1	1
12/29/2019 04:00	1.2	12.5	2,092.8	0.8	6.30	1	1	1
12/29/2019 05:00	1.3	12.4	2,098.5	0.9	6.30	1	1	1
12/29/2019 06:00	1.2	12.5	2,091.3	0.8	6.30	1	1	1
12/29/2019 07:00	1.0	12.6	2,020.6	0.7	6.10	1	1	1
12/29/2019 08:00	0.2	13.8	1,672.1	0.2	1.70	1	1	0
12/29/2019 09:00	0.2	13.8	1,601.9	0.2	1.60	1	1	0
12/29/2019 10:00	0.3	13.8	1,676.5	0.2	1.70	1	1	0
12/29/2019 11:00	0.3	13.8	1,653.0	0.2	1.70	1	1	0
12/29/2019 12:00	0.3	13.8	1,688.5	0.2	1.70	1	1	0
12/29/2019 13:00	0.3	13.8	1,617.0	0.2	1.60	1	1	0
12/29/2019 14:00	0.3	13.8	1,671.1	0.2	1.70	1	1	0
12/29/2019 15:00	0.6	13.3	1,873.5	0.5	3.70	1	1	1
12/29/2019 16:00	1.0	12.6	2,055.4	0.7	6.20	1	1	1
12/29/2019 17:00	1.1	12.5	2,078.5	0.8	6.20	1	1	1
12/29/2019 18:00	1.2	12.3	2,124.3	0.8	6.40	1	1	1
12/29/2019 19:00	1.3	12.3	2,126.9	0.9	6.40	1	1	1
12/29/2019 20:00	1.2	12.3	2,126.8	0.8	6.40	1	1	1
12/29/2019 21:00	1.2	12.3	2,125.5	0.8	6.40	1	1	1
12/29/2019 22:00	1.2	12.4	2,119.0	0.8	6.40	1	1	1
12/29/2019 23:00	1.2	12.5	2,089.7	0.8	6.30	1	1	1
Average/Sum#:	0.8	13.0	1,959.1	0.5	78.50 #	24 #	24 #	17 #
Minimum:	0.2	12.3	1,601.9	0.2	1.60	1	1	0
Maximum:	1.3	13.8	2,126.9	0.9	6.40	1	1	1
%SI	25.00	25.00	0.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/30/2019 00:00	1.2	12.6	2,069.2	0.9	6.20	1	1	1
12/30/2019 01:00	1.1	12.6	2,060.7	0.8	6.20	1	1	1
12/30/2019 02:00	1.1	12.7	2,038.8	0.8	6.10	1	1	1
12/30/2019 03:00	1.1	12.7	2,043.5	0.8	6.10	1	1	1
12/30/2019 04:00	1.1	12.8	2,037.3	0.8	6.10	1	1	1
12/30/2019 05:00	1.1	12.7	2,048.0	0.8	6.10	1	1	1
12/30/2019 06:00	1.1	12.6	2,062.6	0.8	6.20	1	1	1
12/30/2019 07:00	1.2	12.4	2,120.4	0.8	6.40	1	1	1
12/30/2019 08:00	1.2	12.5	2,098.6	0.8	6.30	1	1	1
12/30/2019 09:00	1.2	12.5	2,057.7	0.8	6.20	1	1	1
12/30/2019 10:00	1.3	12.6	2,037.4	0.9	6.10	1	1	1
12/30/2019 11:00	1.4	12.5	2,052.2	1.0	8.20	1	1	1
12/30/2019 12:00	1.2	12.4	2,053.1	0.8	6.20	1	1	1
12/30/2019 13:00	1.1	12.3	2,076.0	0.8	6.20	1	1	1
12/30/2019 14:00	1.4	12.4	2,061.5	1.0	8.20	1	1	1
12/30/2019 15:00	1.5	12.4	2,068.2	1.0	8.30	1	1	1
12/30/2019 16:00	1.5	12.3	2,076.3	1.0	8.30	1	1	1
12/30/2019 17:00	1.4	12.3	2,093.1	1.0	8.40	1	1	1
12/30/2019 18:00	1.4	12.2	2,125.5	0.9	6.40	1	1	1
12/30/2019 19:00	1.3	12.2	2,120.6	0.9	6.40	1	1	1
12/30/2019 20:00	1.3	12.4	2,100.9	0.9	6.30	1	1	1
12/30/2019 21:00	1.2	12.5	2,072.3	0.8	6.20	1	1	1
12/30/2019 22:00	1.2	12.4	2,100.2	0.8	6.30	1	1	1
12/30/2019 23:00	1.3	12.5	2,071.5	0.9	6.20	1	1	1
Average/Sum#:	1.2	12.5	2,072.7	0.9	159.60 #	24 #	24 #	24 #
Minimum:	1.1	12.2	2,037.3	0.8	6.10	1	1	1
Maximum:	1.5	12.8	2,125.5	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/31/2019 00:00	1.3	12.6	2,044.4	0.9	6.10	1	1	1
12/31/2019 01:00	1.1	13.1	1,930.7	0.8	5.80	1	1	1
12/31/2019 02:00	1.2	13.1	1,927.7	0.9	5.80	1	1	1
12/31/2019 03:00	1.1	13.1	1,941.4	0.8	5.80	1	1	1
12/31/2019 04:00	1.3	12.6	2,042.1	0.9	6.10	1	1	1
12/31/2019 05:00	0.8	12.6	2,037.0	0.6	4.10	1	1	1
12/31/2019 06:00	1.2	12.7	2,030.6	0.9	6.10	1	1	1
12/31/2019 07:00	1.3	12.6	2,030.0	0.9	6.10	1	1	1
12/31/2019 08:00	1.1	13.2	1,890.6	0.8	5.70	1	1	1
12/31/2019 09:00	0.4	13.9	1,513.2	0.3	1.50	1	1	0
12/31/2019 10:00	0.4	13.9	1,612.7	0.3	1.60	1	1	0
12/31/2019 11:00	0.4	13.9	1,580.2	0.3	1.60	1	1	0
12/31/2019 12:00	0.4	13.9	1,563.3	0.3	1.60	1	1	0
12/31/2019 13:00	0.4	13.9	1,664.2	0.3	1.70	1	1	0
12/31/2019 14:00	0.4	13.9	1,566.0	0.3	1.60	1	1	0
12/31/2019 15:00	0.4	13.9	1,579.9	0.3	1.60	1	1	1
12/31/2019 16:00	1.3	12.8	1,996.1	0.9	6.00	1	1	1
12/31/2019 17:00	1.3	12.6	2,036.1	0.9	6.10	1	1	1
12/31/2019 18:00	1.3	12.7	2,032.6	0.9	6.10	1	1	1
12/31/2019 19:00	1.3	12.7	2,040.7	0.9	6.10	1	1	1
12/31/2019 20:00	1.3	12.6	2,040.9	0.9	6.10	1	1	1
12/31/2019 21:00	1.3	12.6	2,042.0	0.9	6.10	1	1	1
12/31/2019 22:00	1.3	12.6	2,043.4	0.9	6.10	1	1	1
12/31/2019 23:00	1.3	12.7	2,042.1	0.9	6.10	1	1	1
Average/Sum#:	1.0	13.1	1,884.5	0.7	111.50 #	24 #	24 #	18 #
Minimum:	0.4	12.6	1,513.2	0.3	1.50	1	1	0
Maximum:	1.3	13.9	2,044.4	0.9	6.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/01/2019 00:00	0.7	13.9	1,390.2	0.6	2.80	1	1	0
10/01/2019 01:00	0.7	13.9	1,359.0	0.6	2.70	1	1	0
10/01/2019 02:00	0.7	13.9	1,351.1	0.6	2.70	1	1	0
10/01/2019 03:00	0.7	13.9	1,395.1	0.6	2.80	1	1	0
10/01/2019 04:00	0.9	13.9	1,651.9	0.8	5.00	1	1	0
10/01/2019 05:00	0.7	13.9	1,512.6	0.6	3.00	1	1	0
10/01/2019 06:00	0.8	13.9	1,631.9	0.7	3.30	1	1	0
10/01/2019 07:00	0.8	13.9	1,627.8	0.7	3.30	1	1	0
10/01/2019 08:00	0.8	13.9	1,639.7	0.7	3.30	1	1	0
10/01/2019 09:00	0.8	13.9	1,622.6	0.7	3.20	1	1	0
10/01/2019 10:00	0.8	13.9	1,602.7	0.7	3.20	1	1	0
10/01/2019 11:00	0.8	13.9	1,608.4	0.7	3.20	1	1	0
10/01/2019 12:00	0.8	14.0	1,593.9	0.7	4.80	1	1	0
10/01/2019 13:00	0.8	14.0	1,596.7	0.7	4.80	1	1	0
10/01/2019 14:00	0.9	13.9	1,568.6	0.8	4.70	1	1	0
10/01/2019 15:00	0.9	13.9	1,583.1	0.8	4.70	1	1	1
10/01/2019 16:00	1.5	12.7	1,966.8	1.1	7.90	1	1	1
10/01/2019 17:00	1.6	12.4	2,014.1	1.1	8.10	1	1	1
10/01/2019 18:00	1.6	12.3	2,048.1	1.1	8.20	1	1	1
10/01/2019 19:00	1.7	12.2	2,077.7	1.2	8.30	1	1	1
10/01/2019 20:00	1.6	12.2	2,078.1	1.1	8.30	1	1	1
10/01/2019 21:00	1.6	12.3	2,067.4	1.1	8.30	1	1	1
10/01/2019 22:00	1.6	12.4	2,045.5	1.1	8.20	1	1	1
10/01/2019 23:00	1.6	12.4	2,044.8	1.1	8.20	1	1	1
Average/Sum#:	1.1	13.4	1,711.6	0.8	123.00 #	24 #	24 #	9 #
Minimum:	0.7	12.2	1,351.1	0.6	2.70	1	1	0
Maximum:	1.7	14.0	2,078.1	1.2	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/02/2019 00:00	1.6	12.4	2,058.7	1.1	8.20	1	1	1
10/02/2019 01:00	1.6	12.4	2,043.5	1.1	8.20	1	1	1
10/02/2019 02:00	1.6	12.4	2,029.4	1.1	8.10	1	1	1
10/02/2019 03:00	1.6	12.4	2,026.5	1.1	8.10	1	1	1
10/02/2019 04:00	1.6	12.6	1,987.0	1.1	7.90	1	1	1
10/02/2019 05:00	1.6	12.5	2,014.2	1.1	8.10	1	1	1
10/02/2019 06:00	1.4	12.7	2,015.5	1.0	8.10	1	1	1
10/02/2019 07:00	1.5	12.8	1,931.6	1.1	7.70	1	1	1
10/02/2019 08:00	0.7	13.9	1,569.5	0.6	3.10	1	1	0
10/02/2019 09:00	0.6	14.0	1,259.5	0.5	2.50	1	1	0
10/02/2019 10:00	0.5	14.0	1,270.2	0.4	2.50	1	1	0
10/02/2019 11:00	0.5	14.0	1,292.9	0.4	2.60	1	1	0
10/02/2019 12:00	0.5	14.0	1,269.8	0.4	2.50	1	1	0
10/02/2019 13:00	0.5	14.0	1,287.7	0.4	2.60	1	1	0
10/02/2019 14:00	0.8	13.9	1,543.8	0.7	3.10	1	1	1
10/02/2019 15:00	1.5	12.6	1,958.6	1.1	7.80	1	1	1
10/02/2019 16:00	1.6	12.2	2,036.8	1.1	8.10	1	1	1
10/02/2019 17:00	1.7	12.2	2,058.1	1.2	8.20	1	1	1
10/02/2019 18:00	1.7	12.2	2,052.5	1.2	8.20	1	1	1
10/02/2019 19:00	1.7	12.2	2,067.5	1.2	8.30	1	1	1
10/02/2019 20:00	1.7	12.1	2,080.9	1.1	8.30	1	1	1
10/02/2019 21:00	1.7	12.2	2,058.1	1.2	8.20	1	1	1
10/02/2019 22:00	1.6	12.4	2,031.3	1.1	8.10	1	1	1
10/02/2019 23:00	1.6	12.6	1,999.5	1.1	8.00	1	1	1
Average/Sum#:	1.3	12.9	1,831.0	0.9	156.50 #	24 #	24 #	18 #
Minimum:	0.5	12.1	1,259.5	0.4	2.50	1	1	0
Maximum:	1.7	14.0	2,080.9	1.2	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/03/2019 00:00	1.6	12.6	1,979.6	1.1	7.90	1	1	1
10/03/2019 01:00	1.5	12.8	1,922.0	1.1	7.70	1	1	1
10/03/2019 02:00	1.6	12.7	1,968.2	1.2	7.90	1	1	1
10/03/2019 03:00	1.6	12.5	1,999.6	1.1	8.00	1	1	1
10/03/2019 04:00	1.6	12.5	2,016.1	1.1	8.10	1	1	1
10/03/2019 05:00	1.6	12.5	2,008.7	1.1	8.00	1	1	1
10/03/2019 06:00	1.3	12.5	2,026.3	0.9	6.10	1	1	1
10/03/2019 07:00	1.5	12.7	1,937.3	1.1	7.70	1	1	1
10/03/2019 08:00	0.8	13.9	1,454.5	0.7	2.90	1	1	0
10/03/2019 09:00	0.6	14.0	1,262.8	0.5	2.50	1	1	0
10/03/2019 10:00	0.6	14.0	1,252.7	0.5	2.50	1	1	0
10/03/2019 11:00	0.5	14.0	1,256.7	0.4	2.50	1	1	0
10/03/2019 12:00	0.6	13.9	1,315.4	0.5	2.60	1	1	0
10/03/2019 13:00	0.6	14.0	1,300.1	0.5	2.60	1	1	0
10/03/2019 14:00	0.7	13.9	1,352.0	0.6	2.70	1	1	0
10/03/2019 15:00	0.7	13.9	1,363.7	0.6	2.70	1	1	0
10/03/2019 16:00	1.0	13.8	1,603.8	0.8	4.80	1	1	0
10/03/2019 17:00	0.9	13.8	1,591.3	0.7	4.80	1	1	0
10/03/2019 18:00	0.9	13.8	1,592.5	0.7	4.80	1	1	0
10/03/2019 19:00	0.9	13.8	1,619.0	0.7	4.90	1	1	0
10/03/2019 20:00	0.9	13.9	1,599.1	0.8	4.80	1	1	0
10/03/2019 21:00	1.6	14.4	1,273.9	1.5	4.80	1	0	0
10/03/2019 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/03/2019 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.1	13.5	1,622.5	0.8	111.30 #	22 #	21 #	8 #
Minimum:	0.5	12.5	1,252.7	0.4	2.50	0	0	0
Maximum:	1.6	14.4	2,026.3	1.5	8.10	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2019 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2019 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2019 02:00	9.2	18.4	360.7	21.7	7.80	1	0	0
10/04/2019 03:00	14.3	14.9	1,019.4	14.1	53.00	1	0	0
10/04/2019 04:00	0.5	14.0	1,384.4	0.4	2.80	1	1	0
10/04/2019 05:00	1.5	12.7	1,977.3	1.1	7.90	1	1	1
10/04/2019 06:00	1.6	12.5	1,978.9	1.1	7.90	1	1	1
10/04/2019 07:00	0.6	14.0	1,369.0	0.5	2.70	1	1	0
10/04/2019 08:00	0.6	14.0	1,353.8	0.5	2.70	1	1	0
10/04/2019 09:00	0.7	14.0	1,357.9	0.6	2.70	1	1	0
10/04/2019 10:00	0.7	14.0	1,360.9	0.6	2.70	1	1	0
10/04/2019 11:00	0.6	14.0	1,364.2	0.5	2.70	1	1	0
10/04/2019 12:00	0.6	14.0	1,369.6	0.5	2.70	1	1	0
10/04/2019 13:00	0.9	13.9	1,547.6	0.8	4.60	1	1	0
10/04/2019 14:00	0.7	14.0	1,445.1	0.6	2.90	1	1	0
10/04/2019 15:00	0.6	14.0	1,421.5	0.5	2.80	1	1	0
10/04/2019 16:00	0.9	13.9	1,510.6	0.8	4.50	1	1	1
10/04/2019 17:00	1.5	12.7	1,964.0	1.1	7.90	1	1	1
10/04/2019 18:00	1.7	12.1	2,096.4	1.1	8.40	1	1	1
10/04/2019 19:00	1.7	12.2	2,081.7	1.2	8.30	1	1	1
10/04/2019 20:00	1.7	12.2	2,091.6	1.2	8.40	1	1	1
10/04/2019 21:00	1.7	12.2	2,080.6	1.2	8.30	1	1	1
10/04/2019 22:00	1.6	12.3	2,059.8	1.1	8.20	1	1	1
10/04/2019 23:00	1.6	12.4	2,047.0	1.1	8.20	1	1	1
Average/Sum#:	2.1	13.6	1,601.9	2.4	168.10 #	22 #	20 #	10 #
Minimum:	0.5	12.1	360.7	0.4	2.70	0	0	0
Maximum:	14.3	18.4	2,096.4	21.7	53.00	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/05/2019 00:00	1.6	12.5	2,014.0	1.1	8.10	1	1	1
10/05/2019 01:00	1.6	12.6	1,994.8	1.1	8.00	1	1	1
10/05/2019 02:00	1.5	12.8	1,959.8	1.1	7.80	1	1	1
10/05/2019 03:00	1.6	12.5	2,028.9	1.1	8.10	1	1	1
10/05/2019 04:00	1.6	12.4	2,055.4	1.1	8.20	1	1	1
10/05/2019 05:00	1.6	12.3	2,077.2	1.1	8.30	1	1	1
10/05/2019 06:00	1.5	12.7	2,023.9	1.1	8.10	1	1	1
10/05/2019 07:00	1.5	12.9	1,933.7	1.1	7.70	1	1	1
10/05/2019 08:00	0.8	13.9	1,502.2	0.7	3.00	1	1	0
10/05/2019 09:00	0.6	14.0	1,256.6	0.5	2.50	1	1	0
10/05/2019 10:00	0.5	14.0	1,252.2	0.4	2.50	1	1	0
10/05/2019 11:00	0.5	14.0	1,264.7	0.4	2.50	1	1	0
10/05/2019 12:00	0.5	14.0	1,307.4	0.4	2.60	1	1	0
10/05/2019 13:00	0.5	14.0	1,259.3	0.4	2.50	1	1	0
10/05/2019 14:00	0.7	14.0	1,436.6	0.6	2.90	1	1	0
10/05/2019 15:00	0.8	13.8	1,488.5	0.7	3.00	1	1	1
10/05/2019 16:00	1.5	12.7	1,932.3	1.1	7.70	1	1	1
10/05/2019 17:00	1.6	12.4	2,004.4	1.1	8.00	1	1	1
10/05/2019 18:00	1.6	12.4	2,010.9	1.1	8.00	1	1	1
10/05/2019 19:00	1.6	12.3	2,024.8	1.1	8.10	1	1	1
10/05/2019 20:00	1.7	12.2	2,056.6	1.2	8.20	1	1	1
10/05/2019 21:00	1.7	12.1	2,060.1	1.1	8.20	1	1	1
10/05/2019 22:00	1.6	12.3	2,033.8	1.1	8.10	1	1	1
10/05/2019 23:00	1.6	12.3	2,040.2	1.1	8.20	1	1	1
Average/Sum#:	1.3	13.0	1,792.4	0.9	150.30 #	24 #	24 #	17 #
Minimum:	0.5	12.1	1,252.2	0.4	2.50	1	1	0
Maximum:	1.7	14.0	2,077.2	1.2	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/06/2019 00:00	1.6	12.3	2,022.8	1.1	8.10	1	1	1
10/06/2019 01:00	1.6	12.5	1,975.5	1.1	7.90	1	1	1
10/06/2019 02:00	1.6	12.6	1,977.6	1.1	7.90	1	1	1
10/06/2019 03:00	1.6	12.6	1,977.6	1.1	7.90	1	1	1
10/06/2019 04:00	1.6	12.5	2,002.9	1.1	8.00	1	1	1
10/06/2019 05:00	1.6	12.4	2,025.8	1.1	8.10	1	1	1
10/06/2019 06:00	1.4	12.8	1,951.8	1.0	7.80	1	1	1
10/06/2019 07:00	0.8	13.9	1,483.6	0.7	3.00	1	1	0
10/06/2019 08:00	0.6	14.0	1,321.9	0.5	2.60	1	1	0
10/06/2019 09:00	0.5	14.0	1,244.4	0.4	2.50	1	1	0
10/06/2019 10:00	0.5	14.0	1,300.4	0.4	2.60	1	1	0
10/06/2019 11:00	0.6	14.0	1,330.7	0.5	2.70	1	1	0
10/06/2019 12:00	0.6	14.0	1,364.0	0.5	2.70	1	1	0
10/06/2019 13:00	0.6	14.0	1,336.8	0.5	2.70	1	1	0
10/06/2019 14:00	0.9	13.8	1,557.6	0.7	4.70	1	1	1
10/06/2019 15:00	1.5	12.5	1,964.7	1.1	7.90	1	1	1
10/06/2019 16:00	1.7	12.2	2,025.1	1.2	8.10	1	1	1
10/06/2019 17:00	1.7	11.9	2,079.9	1.1	8.30	1	1	1
10/06/2019 18:00	1.7	11.9	2,101.9	1.1	8.40	1	1	1
10/06/2019 19:00	1.7	12.1	2,058.6	1.1	8.20	1	1	1
10/06/2019 20:00	1.7	12.2	2,047.0	1.2	8.20	1	1	1
10/06/2019 21:00	1.6	12.2	2,050.0	1.1	8.20	1	1	1
10/06/2019 22:00	1.6	12.4	2,020.4	1.1	8.10	1	1	1
10/06/2019 23:00	1.6	12.5	2,008.7	1.1	8.00	1	1	1
Average/Sum#:	1.3	12.9	1,801.2	0.9	152.60 #	24 #	24 #	17 #
Minimum:	0.5	11.9	1,244.4	0.4	2.50	1	1	0
Maximum:	1.7	14.0	2,101.9	1.2	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/07/2019 00:00	1.6	12.5	2,003.3	1.1	8.00	1	1	1
10/07/2019 01:00	1.6	12.4	2,020.7	1.1	8.10	1	1	1
10/07/2019 02:00	1.6	12.5	1,996.3	1.1	8.00	1	1	1
10/07/2019 03:00	1.6	12.5	2,017.0	1.1	8.10	1	1	1
10/07/2019 04:00	1.7	12.3	2,050.8	1.2	8.20	1	1	1
10/07/2019 05:00	1.6	12.3	2,040.1	1.1	8.20	1	1	1
10/07/2019 06:00	1.5	12.4	2,047.8	1.0	8.20	1	1	1
10/07/2019 07:00	1.6	12.4	2,029.3	1.1	8.10	1	1	1
10/07/2019 08:00	1.6	12.4	2,012.6	1.1	8.10	1	1	1
10/07/2019 09:00	1.6	12.3	2,018.7	1.1	8.10	1	1	1
10/07/2019 10:00	1.6	12.4	1,996.9	1.1	8.00	1	1	1
10/07/2019 11:00	1.6	12.4	1,980.8	1.1	7.90	1	1	1
10/07/2019 12:00	1.6	12.4	1,979.0	1.1	7.90	1	1	1
10/07/2019 13:00	1.6	12.3	1,997.0	1.1	8.00	1	1	1
10/07/2019 14:00	1.6	12.3	1,996.5	1.1	8.00	1	1	1
10/07/2019 15:00	1.6	12.2	1,991.1	1.1	8.00	1	1	1
10/07/2019 16:00	1.7	12.1	2,036.4	1.1	8.10	1	1	1
10/07/2019 17:00	1.7	11.9	2,072.5	1.1	8.30	1	1	1
10/07/2019 18:00	1.7	11.9	2,075.6	1.1	8.30	1	1	1
10/07/2019 19:00	1.7	12.1	2,039.3	1.1	8.20	1	1	1
10/07/2019 20:00	1.7	12.1	2,032.6	1.1	8.10	1	1	1
10/07/2019 21:00	1.6	12.4	2,000.8	1.1	8.00	1	1	1
10/07/2019 22:00	1.6	12.3	2,016.9	1.1	8.10	1	1	1
10/07/2019 23:00	1.6	12.6	1,964.6	1.1	7.90	1	1	1
Average/Sum#:	1.6	12.3	2,017.4	1.1	193.90 #	24 #	24 #	24 #
Minimum:	1.5	11.9	1,964.6	1.0	7.90	1	1	1
Maximum:	1.7	12.6	2,075.6	1.2	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/08/2019 00:00	1.6	12.8	1,916.7	1.2	7.70	1	1	1
10/08/2019 01:00	1.5	13.0	1,858.8	1.1	7.40	1	1	1
10/08/2019 02:00	1.5	13.1	1,863.2	1.1	7.50	1	1	1
10/08/2019 03:00	1.5	12.8	1,912.2	1.1	7.60	1	1	1
10/08/2019 04:00	1.5	12.7	1,926.8	1.1	7.70	1	1	1
10/08/2019 05:00	1.6	12.4	2,008.4	1.1	8.00	1	1	1
10/08/2019 06:00	1.3	12.4	2,022.8	0.9	6.10	1	1	1
10/08/2019 07:00	1.5	12.5	1,994.1	1.1	8.00	1	1	1
10/08/2019 08:00	1.6	12.5	1,993.5	1.1	8.00	1	1	1
10/08/2019 09:00	1.6	12.4	1,996.6	1.1	8.00	1	1	1
10/08/2019 10:00	1.6	12.3	2,002.3	1.1	8.00	1	1	1
10/08/2019 11:00	1.7	12.2	2,012.4	1.2	8.00	1	1	1
10/08/2019 12:00	1.7	12.1	2,033.0	1.1	8.10	1	1	1
10/08/2019 13:00	1.6	12.3	1,991.7	1.1	8.00	1	1	1
10/08/2019 14:00	1.6	12.4	1,966.3	1.1	7.90	1	1	1
10/08/2019 15:00	1.6	12.2	1,987.9	1.1	8.00	1	1	1
10/08/2019 16:00	1.7	12.1	2,024.2	1.1	8.10	1	1	1
10/08/2019 17:00	1.7	11.9	2,058.1	1.1	8.20	1	1	1
10/08/2019 18:00	1.7	12.0	2,046.4	1.1	8.20	1	1	1
10/08/2019 19:00	1.7	12.1	2,038.9	1.1	8.20	1	1	1
10/08/2019 20:00	1.7	12.1	2,038.2	1.1	8.20	1	1	1
10/08/2019 21:00	1.7	12.2	2,010.8	1.2	8.00	1	1	1
10/08/2019 22:00	1.5	12.5	1,931.7	1.1	7.70	1	1	1
10/08/2019 23:00	1.5	12.4	1,955.8	1.0	7.80	1	1	1
Average/Sum#:	1.6	12.4	1,983.0	1.1	188.40 #	24 #	24 #	24 #
Minimum:	1.3	11.9	1,858.8	0.9	6.10	1	1	1
Maximum:	1.7	13.1	2,058.1	1.2	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/09/2019 00:00	1.5	12.4	1,965.3	1.0	7.90	1	1	1
10/09/2019 01:00	1.5	12.8	1,892.0	1.1	7.60	1	1	1
10/09/2019 02:00	1.4	12.7	1,915.9	1.0	7.70	1	1	1
10/09/2019 03:00	1.5	12.5	1,973.2	1.1	7.90	1	1	1
10/09/2019 04:00	1.5	12.4	1,998.5	1.0	8.00	1	1	1
10/09/2019 05:00	1.5	12.4	1,991.5	1.0	8.00	1	1	1
10/09/2019 06:00	1.1	12.2	2,038.0	0.7	6.10	1	1	1
10/09/2019 07:00	1.6	12.4	2,006.4	1.1	8.00	1	1	1
10/09/2019 08:00	1.5	12.5	1,974.6	1.1	7.90	1	1	1
10/09/2019 09:00	1.5	12.4	1,993.7	1.0	8.00	1	1	1
10/09/2019 10:00	1.5	12.4	1,998.8	1.0	8.00	1	1	1
10/09/2019 11:00	0.8	13.9	1,630.0	0.7	3.30	1	1	0
10/09/2019 12:00	0.8	14.0	1,614.6	0.7	4.80	1	1	0
10/09/2019 13:00	0.7	14.0	1,558.8	0.6	3.10	1	1	0
10/09/2019 14:00	0.7	14.0	1,483.0	0.6	3.00	1	1	0
10/09/2019 15:00	0.8	13.9	1,491.3	0.7	3.00	1	1	1
10/09/2019 16:00	1.4	12.7	1,905.0	1.0	7.60	1	1	1
10/09/2019 17:00	1.5	12.6	1,990.3	1.1	8.00	1	1	1
10/09/2019 18:00	1.6	12.6	1,979.3	1.1	7.90	1	1	1
10/09/2019 19:00	1.5	12.6	1,976.6	1.1	7.90	1	1	1
10/09/2019 20:00	1.5	12.5	1,977.8	1.1	7.90	1	1	1
10/09/2019 21:00	1.5	12.6	1,969.5	1.1	7.90	1	1	1
10/09/2019 22:00	1.5	12.6	1,977.3	1.1	7.90	1	1	1
10/09/2019 23:00	1.5	12.6	1,969.1	1.1	7.90	1	1	1
Average/Sum#:	1.3	12.8	1,886.3	1.0	165.30 #	24 #	24 #	20 #
Minimum:	0.7	12.2	1,483.0	0.6	3.00	1	1	0
Maximum:	1.6	14.0	2,038.0	1.1	8.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/10/2019 00:00	1.5	12.6	1,969.6	1.1	7.90	1	1	1
10/10/2019 01:00	1.4	13.1	1,873.4	1.1	7.50	1	1	1
10/10/2019 02:00	1.4	12.9	1,910.6	1.0	7.60	1	1	1
10/10/2019 03:00	1.5	12.7	1,961.1	1.1	7.80	1	1	1
10/10/2019 04:00	1.5	12.7	1,961.1	1.1	7.80	1	1	1
10/10/2019 05:00	1.5	12.8	1,957.5	1.1	7.80	1	1	1
10/10/2019 06:00	1.3	12.7	1,987.4	0.9	6.00	1	1	1
10/10/2019 07:00	1.5	12.9	1,898.5	1.1	7.60	1	1	1
10/10/2019 08:00	0.7	14.0	1,456.2	0.6	2.90	1	1	0
10/10/2019 09:00	0.7	14.0	1,585.4	0.6	3.20	1	1	0
10/10/2019 10:00	0.7	14.0	1,622.5	0.6	3.20	1	1	0
10/10/2019 11:00	0.7	14.0	1,610.9	0.6	3.20	1	1	0
10/10/2019 12:00	0.8	14.0	1,620.0	0.7	4.90	1	1	0
10/10/2019 13:00	0.8	14.0	1,584.7	0.7	4.80	1	1	0
10/10/2019 14:00	0.8	14.0	1,604.8	0.7	4.80	1	1	0
10/10/2019 15:00	0.9	13.9	1,496.7	0.8	4.50	1	1	0
10/10/2019 16:00	1.5	12.4	1,963.8	1.0	7.90	1	1	1
10/10/2019 17:00	1.5	12.5	1,953.8	1.1	7.80	1	1	1
10/10/2019 18:00	1.5	12.4	2,036.5	1.0	8.10	1	1	1
10/10/2019 19:00	1.6	12.4	2,025.3	1.1	8.10	1	1	1
10/10/2019 20:00	1.6	12.5	2,024.4	1.1	8.10	1	1	1
10/10/2019 21:00	1.6	12.4	2,030.6	1.1	8.10	1	1	1
10/10/2019 22:00	1.6	12.4	2,020.9	1.1	8.10	1	1	1
10/10/2019 23:00	1.5	12.7	1,933.0	1.1	7.70	1	1	1
Average/Sum#:	1.3	13.1	1,837.0	0.9	155.40 #	24 #	24 #	16 #
Minimum:	0.7	12.4	1,456.2	0.6	2.90	1	1	0
Maximum:	1.6	14.0	2,036.5	1.1	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/11/2019 00:00	1.5	12.7	1,919.9	1.1	7.70	1	1	1
10/11/2019 01:00	1.4	13.1	1,853.6	1.1	7.40	1	1	1
10/11/2019 02:00	1.4	13.1	1,853.1	1.1	7.40	1	1	1
10/11/2019 03:00	1.4	13.1	1,855.3	1.1	7.40	1	1	1
10/11/2019 04:00	1.4	13.1	1,858.0	1.1	7.40	1	1	1
10/11/2019 05:00	0.8	13.9	1,649.2	0.7	3.30	1	1	1
10/11/2019 06:00	0.7	14.0	1,635.8	0.6	3.30	1	1	0
10/11/2019 07:00	0.6	14.0	1,392.5	0.5	2.80	1	1	0
10/11/2019 08:00	0.5	14.0	1,239.2	0.4	2.50	1	1	0
10/11/2019 09:00	0.5	14.0	1,237.0	0.4	2.50	1	1	0
10/11/2019 10:00	0.6	14.0	1,236.9	0.5	2.50	1	1	0
10/11/2019 11:00	0.5	14.0	1,238.9	0.4	2.50	1	1	0
10/11/2019 12:00	0.5	14.0	1,240.4	0.4	2.50	1	1	0
10/11/2019 13:00	0.5	14.0	1,272.9	0.4	2.50	1	1	0
10/11/2019 14:00	0.9	13.9	1,621.1	0.8	4.90	1	1	0
10/11/2019 15:00	0.9	13.8	1,550.6	0.7	4.70	1	1	1
10/11/2019 16:00	1.5	12.6	1,962.1	1.1	7.80	1	1	1
10/11/2019 17:00	1.7	12.0	2,105.8	1.1	8.40	1	1	1
10/11/2019 18:00	1.7	11.8	2,142.7	1.1	8.60	1	1	1
10/11/2019 19:00	1.7	12.2	2,058.2	1.2	8.20	1	1	1
10/11/2019 20:00	1.6	12.3	2,041.4	1.1	8.20	1	1	1
10/11/2019 21:00	1.6	12.3	2,054.4	1.1	8.20	1	1	1
10/11/2019 22:00	1.6	12.4	2,047.6	1.1	8.20	1	1	1
10/11/2019 23:00	1.6	12.4	2,048.4	1.1	8.20	1	1	1
Average/Sum#:	1.1	13.2	1,713.1	0.8	137.10 #	24 #	24 #	15 #
Minimum:	0.5	11.8	1,236.9	0.4	2.50	1	1	0
Maximum:	1.7	14.0	2,142.7	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/12/2019 00:00	1.6	12.3	2,043.9	1.1	8.20	1	1	1
10/12/2019 01:00	1.6	12.5	2,001.9	1.1	8.00	1	1	1
10/12/2019 02:00	1.6	12.5	2,010.9	1.1	8.00	1	1	1
10/12/2019 03:00	1.6	12.4	2,027.4	1.1	8.10	1	1	1
10/12/2019 04:00	1.6	12.3	2,032.4	1.1	8.10	1	1	1
10/12/2019 05:00	1.6	12.3	2,046.4	1.1	8.20	1	1	1
10/12/2019 06:00	1.3	12.4	2,042.9	0.9	6.10	1	1	1
10/12/2019 07:00	4.0	14.1	1,233.3	3.5	8.00	1	0	1
10/12/2019 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2019 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2019 10:00	0.3	18.7	282.2	0.8	0.18	1	0	0
10/12/2019 11:00	14.7	16.1	679.8	18.1	45.50	1	0	0
10/12/2019 12:00	0.4	14.0	1,331.8	0.3	1.30	1	0	0
10/12/2019 13:00	0.5	14.0	1,293.1	0.4	2.60	1	1	0
10/12/2019 14:00	1.0	13.9	1,575.5	0.8	4.70	1	1	0
10/12/2019 15:00	0.7	14.0	1,416.1	0.6	2.80	1	1	0
10/12/2019 16:00	1.0	13.9	1,613.8	0.8	4.80	1	1	0
10/12/2019 17:00	1.2	13.4	1,744.8	0.9	5.20	1	1	1
10/12/2019 18:00	1.6	12.3	2,020.5	1.1	8.10	1	1	1
10/12/2019 19:00	1.7	12.2	2,045.4	1.2	8.20	1	1	1
10/12/2019 20:00	1.7	12.3	2,039.9	1.2	8.20	1	1	1
10/12/2019 21:00	1.7	12.2	2,055.5	1.2	8.20	1	1	1
10/12/2019 22:00	1.6	12.3	2,034.1	1.1	8.10	1	1	1
10/12/2019 23:00	1.7	12.3	2,065.9	1.2	8.30	1	1	1
Average/Sum#:	2.0	13.3	1,710.8	1.9	178.88 #	22 #	18 #	15 #
Minimum:	0.3	12.2	282.2	0.3	0.18	0	0	0
Maximum:	14.7	18.7	2,065.9	18.1	45.50	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/13/2019 00:00	1.6	12.3	2,037.4	1.1	8.10	1	1	1
10/13/2019 01:00	1.6	12.3	2,037.3	1.1	8.10	1	1	1
10/13/2019 02:00	1.6	12.3	2,039.5	1.1	8.20	1	1	1
10/13/2019 03:00	1.6	12.3	2,045.3	1.1	8.20	1	1	1
10/13/2019 04:00	1.6	12.3	2,044.4	1.1	8.20	1	1	1
10/13/2019 05:00	1.6	12.3	2,041.5	1.1	8.20	1	1	1
10/13/2019 06:00	1.2	12.6	1,977.0	0.9	5.90	1	1	1
10/13/2019 07:00	0.7	13.9	1,484.2	0.6	3.00	1	1	1
10/13/2019 08:00	0.8	13.9	1,595.4	0.7	3.20	1	1	0
10/13/2019 09:00	0.8	13.9	1,620.1	0.7	3.20	1	1	0
10/13/2019 10:00	0.8	13.9	1,616.1	0.7	3.20	1	1	0
10/13/2019 11:00	0.8	14.0	1,494.6	0.7	4.50	1	1	0
10/13/2019 12:00	0.9	13.9	1,624.0	0.8	4.90	1	1	0
10/13/2019 13:00	0.8	14.0	1,514.7	0.7	4.50	1	1	0
10/13/2019 14:00	1.2	13.8	1,611.1	1.0	6.40	1	1	0
10/13/2019 15:00	0.9	13.9	1,516.0	0.8	4.50	1	1	1
10/13/2019 16:00	1.5	12.5	1,957.0	1.1	7.80	1	1	1
10/13/2019 17:00	1.7	12.1	2,043.1	1.1	8.20	1	1	1
10/13/2019 18:00	1.7	12.3	2,016.4	1.2	8.10	1	1	1
10/13/2019 19:00	1.7	12.3	2,004.6	1.2	8.00	1	1	1
10/13/2019 20:00	1.6	12.4	2,005.5	1.1	8.00	1	1	1
10/13/2019 21:00	1.7	12.3	2,026.9	1.2	8.10	1	1	1
10/13/2019 22:00	1.4	13.0	1,806.1	1.0	7.20	1	1	1
10/13/2019 23:00	3.0	15.1	949.0	3.1	4.47	1	0	0
Average/Sum#:	1.4	13.1	1,796.1	1.1	152.17 #	24 #	23 #	16 #
Minimum:	0.7	12.1	949.0	0.6	3.00	1	0	0
Maximum:	3.0	15.1	2,045.3	3.1	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/14/2019 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2019 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2019 02:00	10.2	16.6	599.7	14.0	31.20	1	0	0
10/14/2019 03:00	0.5	13.9	1,479.8	0.4	3.00	1	0	1
10/14/2019 04:00	1.5	12.7	1,938.7	1.1	7.80	1	1	1
10/14/2019 05:00	1.6	12.3	2,034.9	1.1	8.10	1	1	1
10/14/2019 06:00	0.8	13.9	1,639.4	0.7	3.30	1	1	0
10/14/2019 07:00	0.7	13.9	1,405.1	0.6	2.80	1	1	0
10/14/2019 08:00	0.8	13.9	1,464.5	0.7	2.90	1	1	0
10/14/2019 09:00	0.6	14.0	1,259.9	0.5	2.50	1	1	0
10/14/2019 10:00	0.5	14.0	1,252.9	0.4	2.50	1	1	0
10/14/2019 11:00	0.5	14.0	1,314.5	0.4	2.60	1	1	0
10/14/2019 12:00	0.0	0.0	1,447.7	0.0	0.00	1	1	0
10/14/2019 13:00	1.1	13.7	1,561.8	0.9	4.70	1	1	1
10/14/2019 14:00	1.4	13.0	1,932.9	1.0	7.70	1	1	1
10/14/2019 15:00	1.5	12.4	1,989.6	1.0	8.00	1	1	1
10/14/2019 16:00	1.7	12.1	2,048.3	1.1	8.20	1	1	1
10/14/2019 17:00	1.7	11.9	2,110.6	1.1	8.40	1	1	1
10/14/2019 18:00	1.7	11.8	2,144.5	1.1	8.60	1	1	1
10/14/2019 19:00	1.7	11.8	2,145.1	1.1	8.60	1	1	1
10/14/2019 20:00	1.7	12.0	2,089.7	1.1	8.40	1	1	1
10/14/2019 21:00	1.7	12.3	2,040.6	1.2	8.20	1	1	1
10/14/2019 22:00	1.6	12.4	2,035.8	1.1	8.10	1	1	1
10/14/2019 23:00	1.6	12.4	2,038.8	1.1	8.20	1	1	1
Average/Sum#:	1.7	13.1	1,726.1	1.5	153.80 #	22 #	20 #	14 #
Minimum:	0.5	11.8	599.7	0.4	2.50	0	0	0
Maximum:	10.2	16.6	2,145.1	14.0	31.20	1	1	1
%SI	12.50	12.50	8.33	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/15/2019 00:00	1.6	12.4	2,046.8	1.1	8.20	1	1	1
10/15/2019 01:00	1.6	12.4	2,033.2	1.1	8.10	1	1	1
10/15/2019 02:00	1.6	12.4	2,043.8	1.1	8.20	1	1	1
10/15/2019 03:00	1.6	12.4	2,034.8	1.1	8.10	1	1	1
10/15/2019 04:00	1.6	12.4	2,033.5	1.1	8.10	1	1	1
10/15/2019 05:00	1.3	13.1	1,787.5	1.0	7.20	1	1	1
10/15/2019 06:00	0.9	13.9	1,676.6	0.8	5.00	1	1	0
10/15/2019 07:00	1.1	13.5	1,733.2	0.9	5.20	1	1	1
10/15/2019 08:00	0.7	13.9	1,475.9	0.6	3.00	1	1	0
10/15/2019 09:00	0.6	14.0	1,310.2	0.5	2.60	1	1	0
10/15/2019 10:00	0.5	14.0	1,287.5	0.4	2.60	1	1	0
10/15/2019 11:00	0.5	14.0	1,319.3	0.4	2.60	1	1	0
10/15/2019 12:00	0.7	14.0	1,401.6	0.6	2.80	1	1	0
10/15/2019 13:00	0.9	13.9	1,621.0	0.8	4.90	1	1	0
10/15/2019 14:00	1.1	13.8	1,623.1	0.9	4.90	1	1	1
10/15/2019 15:00	1.5	12.8	1,873.5	1.1	7.50	1	1	1
10/15/2019 16:00	1.7	11.8	2,113.6	1.1	8.50	1	1	1
10/15/2019 17:00	1.7	11.8	2,119.5	1.1	8.50	1	1	1
10/15/2019 18:00	1.7	11.8	2,123.6	1.1	8.50	1	1	1
10/15/2019 19:00	1.7	11.8	2,124.3	1.1	8.50	1	1	1
10/15/2019 20:00	1.7	11.9	2,129.5	1.1	8.50	1	1	1
10/15/2019 21:00	1.7	11.9	2,132.2	1.1	8.50	1	1	1
10/15/2019 22:00	1.7	11.9	2,129.6	1.1	8.50	1	1	1
10/15/2019 23:00	1.7	11.9	2,128.1	1.1	8.50	1	1	1
Average/Sum#:	1.3	12.8	1,845.9	0.9	157.00 #	24 #	24 #	17 #
Minimum:	0.5	11.8	1,287.5	0.4	2.60	1	1	0
Maximum:	1.7	14.0	2,132.2	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/16/2019 00:00	1.7	11.9	2,129.7	1.1	8.50	1	1	1
10/16/2019 01:00	1.7	11.9	2,136.0	1.1	8.50	1	1	1
10/16/2019 02:00	1.7	11.9	2,128.2	1.1	8.50	1	1	1
10/16/2019 03:00	1.7	11.9	2,115.0	1.1	8.50	1	1	1
10/16/2019 04:00	1.7	11.9	2,141.3	1.1	8.60	1	1	1
10/16/2019 05:00	1.7	11.9	2,144.1	1.1	8.60	1	1	1
10/16/2019 06:00	1.7	11.9	2,139.9	1.1	8.60	1	1	1
10/16/2019 07:00	1.7	11.9	2,129.5	1.1	8.50	1	1	1
10/16/2019 08:00	1.7	11.9	2,123.8	1.1	8.50	1	1	1
10/16/2019 09:00	1.7	11.9	2,109.3	1.1	8.40	1	1	1
10/16/2019 10:00	1.7	11.9	2,102.7	1.1	8.40	1	1	1
10/16/2019 11:00	1.7	12.0	2,095.3	1.1	8.40	1	1	1
10/16/2019 12:00	1.7	12.0	2,093.3	1.1	8.40	1	1	1
10/16/2019 13:00	1.7	11.9	2,102.4	1.1	8.40	1	1	1
10/16/2019 14:00	1.7	11.9	2,106.2	1.1	8.40	1	1	1
10/16/2019 15:00	1.7	11.8	2,107.0	1.1	8.40	1	1	1
10/16/2019 16:00	1.7	11.8	2,104.8	1.1	8.40	1	1	1
10/16/2019 17:00	1.7	11.9	2,104.4	1.1	8.40	1	1	1
10/16/2019 18:00	1.7	11.9	2,092.4	1.1	8.40	1	1	1
10/16/2019 19:00	1.7	12.0	2,084.8	1.1	8.30	1	1	1
10/16/2019 20:00	1.7	12.0	2,071.2	1.1	8.30	1	1	1
10/16/2019 21:00	1.0	13.7	1,585.8	0.8	4.80	1	1	1
10/16/2019 22:00	0.7	13.9	1,405.4	0.6	2.80	1	1	0
10/16/2019 23:00	0.8	13.9	1,601.1	0.7	3.20	1	1	0
Average/Sum#:	1.6	12.2	2,039.7	1.1	188.20 #	24 #	24 #	22 #
Minimum:	0.7	11.8	1,405.4	0.6	2.80	1	1	0
Maximum:	1.7	13.9	2,144.1	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/17/2019 00:00	0.8	13.9	1,577.4	0.7	3.20	1	1	0
10/17/2019 01:00	0.8	13.8	1,636.6	0.7	3.30	1	1	1
10/17/2019 02:00	1.4	12.9	1,903.6	1.0	7.60	1	1	1
10/17/2019 03:00	1.5	12.7	1,932.6	1.1	7.70	1	1	1
10/17/2019 04:00	1.6	12.5	1,974.1	1.1	7.90	1	1	1
10/17/2019 05:00	1.6	12.7	1,957.3	1.2	7.80	1	1	1
10/17/2019 06:00	1.3	12.4	2,012.2	0.9	6.00	1	1	1
10/17/2019 07:00	1.6	12.5	1,961.5	1.1	7.80	1	1	1
10/17/2019 08:00	1.0	13.7	1,521.6	0.8	4.60	1	1	1
10/17/2019 09:00	0.8	13.9	1,475.9	0.7	3.00	1	1	0
10/17/2019 10:00	0.8	13.9	1,490.2	0.7	3.00	1	1	0
10/17/2019 11:00	0.8	13.9	1,534.7	0.7	3.10	1	1	0
10/17/2019 12:00	0.6	14.0	1,313.1	0.5	2.60	1	1	0
10/17/2019 13:00	0.7	13.9	1,465.6	0.6	2.90	1	1	0
10/17/2019 14:00	0.8	13.9	1,559.5	0.7	3.10	1	1	0
10/17/2019 15:00	0.9	13.9	1,492.6	0.8	4.50	1	1	1
10/17/2019 16:00	1.5	12.7	1,931.9	1.1	7.70	1	1	1
10/17/2019 17:00	1.7	12.0	2,104.4	1.1	8.40	1	1	1
10/17/2019 18:00	1.7	12.2	2,067.5	1.2	8.30	1	1	1
10/17/2019 19:00	1.6	12.3	2,046.0	1.1	8.20	1	1	1
10/17/2019 20:00	1.7	12.3	2,062.2	1.2	8.20	1	1	1
10/17/2019 21:00	1.6	12.3	2,038.2	1.1	8.20	1	1	1
10/17/2019 22:00	1.5	12.6	1,962.2	1.1	7.80	1	1	1
10/17/2019 23:00	1.5	12.8	1,928.0	1.1	7.70	1	1	1
Average/Sum#:	1.2	13.1	1,789.5	0.9	142.60 #	24 #	24 #	17 #
Minimum:	0.6	12.0	1,313.1	0.5	2.60	1	1	0
Maximum:	1.7	14.0	2,104.4	1.2	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/18/2019 00:00	1.5	12.9	1,906.9	1.1	7.60	1	1	1
10/18/2019 01:00	1.5	12.9	1,903.2	1.1	7.60	1	1	1
10/18/2019 02:00	1.5	13.1	1,860.9	1.1	7.40	1	1	1
10/18/2019 03:00	1.5	13.0	1,903.5	1.1	7.60	1	1	1
10/18/2019 04:00	1.6	12.7	1,965.6	1.2	7.90	1	1	1
10/18/2019 05:00	1.5	12.7	1,952.5	1.1	7.80	1	1	1
10/18/2019 06:00	1.4	12.5	2,006.5	1.0	8.00	1	1	1
10/18/2019 07:00	1.4	13.1	1,851.9	1.1	7.40	1	1	1
10/18/2019 08:00	0.8	13.9	1,531.1	0.7	3.10	1	1	0
10/18/2019 09:00	0.7	13.9	1,478.5	0.6	3.00	1	1	0
10/18/2019 10:00	0.7	13.9	1,486.3	0.6	3.00	1	1	0
10/18/2019 11:00	0.8	13.9	1,496.1	0.7	3.00	1	1	0
10/18/2019 12:00	0.8	13.9	1,451.2	0.7	2.90	1	1	0
10/18/2019 13:00	0.9	13.8	1,564.5	0.7	4.70	1	1	0
10/18/2019 14:00	0.9	13.8	1,563.1	0.7	4.70	1	1	0
10/18/2019 15:00	0.9	13.8	1,579.3	0.7	4.70	1	1	1
10/18/2019 16:00	1.5	12.5	1,976.9	1.1	7.90	1	1	1
10/18/2019 17:00	1.7	12.2	2,031.7	1.2	8.10	1	1	1
10/18/2019 18:00	1.6	12.5	1,964.0	1.1	7.90	1	1	1
10/18/2019 19:00	1.6	12.5	1,970.9	1.1	7.90	1	1	1
10/18/2019 20:00	1.6	12.3	2,024.7	1.1	8.10	1	1	1
10/18/2019 21:00	1.7	12.3	2,039.5	1.2	8.20	1	1	1
10/18/2019 22:00	1.6	12.5	1,987.5	1.1	8.00	1	1	1
10/18/2019 23:00	1.6	12.4	2,032.2	1.1	8.10	1	1	1
Average/Sum#:	1.3	13.0	1,813.7	1.0	154.60 #	24 #	24 #	17 #
Minimum:	0.7	12.2	1,451.2	0.6	2.90	1	1	0
Maximum:	1.7	13.9	2,039.5	1.2	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/19/2019 00:00	1.6	12.6	1,982.0	1.1	7.90	1	1	1
10/19/2019 01:00	1.6	12.6	1,983.7	1.1	7.90	1	1	1
10/19/2019 02:00	1.7	12.3	2,032.2	1.2	8.10	1	1	1
10/19/2019 03:00	1.6	12.5	1,991.5	1.1	8.00	1	1	1
10/19/2019 04:00	1.6	12.7	1,964.1	1.2	7.90	1	1	1
10/19/2019 05:00	1.6	12.6	1,998.3	1.1	8.00	1	1	1
10/19/2019 06:00	1.5	12.6	2,006.5	1.1	8.00	1	1	1
10/19/2019 07:00	3.0	14.6	1,161.9	2.8	6.03	1	0	1
10/19/2019 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2019 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2019 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2019 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2019 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2019 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2019 14:00	16.6	17.8	403.3	31.6	20.12	1	0	0
10/19/2019 15:00	10.5	15.7	801.9	11.9	35.30	1	0	0
10/19/2019 16:00	1.0	13.2	1,708.4	0.8	5.10	1	1	1
10/19/2019 17:00	1.6	12.4	1,968.5	1.1	7.90	1	1	1
10/19/2019 18:00	1.5	12.9	1,886.1	1.1	7.50	1	1	1
10/19/2019 19:00	1.5	13.0	1,868.6	1.1	7.50	1	1	1
10/19/2019 20:00	1.6	12.7	1,927.5	1.2	7.70	1	1	1
10/19/2019 21:00	1.6	12.7	1,947.7	1.2	7.80	1	1	1
10/19/2019 22:00	1.0	13.6	1,541.0	0.8	4.60	1	1	1
10/19/2019 23:00	0.7	13.9	1,364.0	0.6	2.70	1	1	0
Average/Sum#:	2.9	13.4	1,696.5	3.5	168.05 #	18 #	15 #	15 #
Minimum:	0.7	12.3	403.3	0.6	2.70	0	0	0
Maximum:	16.6	17.8	2,032.2	31.6	35.30	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/20/2019 00:00	0.7	13.9	1,438.8	0.6	2.90	1	1	0
10/20/2019 01:00	0.6	13.9	1,346.0	0.5	2.70	1	1	0
10/20/2019 02:00	4.4	16.2	456.0	5.5	1.82	1	0	0
10/20/2019 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2019 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2019 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2019 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2019 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2019 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2019 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2019 10:00	26.9	17.5	449.3	46.7	57.98	1	0	0
10/20/2019 11:00	11.8	15.4	937.0	12.7	44.00	1	0	0
10/20/2019 12:00	0.5	14.0	1,326.2	0.4	2.70	1	1	0
10/20/2019 13:00	0.5	14.0	1,316.9	0.4	2.60	1	1	0
10/20/2019 14:00	0.8	14.0	1,565.8	0.7	4.70	1	1	0
10/20/2019 15:00	0.7	14.0	1,481.9	0.6	3.00	1	1	0
10/20/2019 16:00	0.8	13.9	1,558.3	0.7	3.10	1	1	0
10/20/2019 17:00	0.9	13.8	1,646.8	0.7	4.90	1	1	0
10/20/2019 18:00	1.2	13.3	1,788.8	0.9	5.40	1	1	1
10/20/2019 19:00	1.5	12.5	1,989.4	1.1	8.00	1	1	1
10/20/2019 20:00	1.6	12.5	2,000.9	1.1	8.00	1	1	1
10/20/2019 21:00	1.6	12.6	1,975.6	1.1	7.90	1	1	1
10/20/2019 22:00	1.6	12.6	1,979.0	1.1	7.90	1	1	1
10/20/2019 23:00	1.6	12.5	1,987.8	1.1	8.00	1	1	1
Average/Sum#:	3.4	13.9	1,485.0	4.5	175.60 #	17 #	14 #	6 #
Minimum:	0.5	12.5	449.3	0.4	1.82	0	0	0
Maximum:	26.9	17.5	2,000.9	46.7	57.98	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/21/2019 00:00	1.5	12.8	1,930.9	1.1	7.70	1	1	1
10/21/2019 01:00	1.6	12.7	1,928.8	1.2	7.70	1	1	1
10/21/2019 02:00	1.5	12.8	1,923.7	1.1	7.70	1	1	1
10/21/2019 03:00	1.5	12.8	1,927.2	1.1	7.70	1	1	1
10/21/2019 04:00	1.6	12.5	2,003.6	1.1	8.00	1	1	1
10/21/2019 05:00	1.6	12.4	2,036.1	1.1	8.10	1	1	1
10/21/2019 06:00	1.4	12.2	2,095.4	0.9	6.30	1	1	1
10/21/2019 07:00	1.6	12.6	1,937.3	1.1	7.70	1	1	1
10/21/2019 08:00	0.7	14.0	1,258.9	0.6	2.50	1	1	0
10/21/2019 09:00	0.5	14.0	1,254.5	0.4	2.50	1	1	0
10/21/2019 10:00	0.6	14.0	1,399.4	0.5	2.80	1	1	0
10/21/2019 11:00	0.7	14.0	1,459.5	0.6	2.90	1	1	0
10/21/2019 12:00	0.9	13.9	1,586.1	0.8	4.80	1	1	0
10/21/2019 13:00	1.2	13.7	1,733.8	1.0	6.90	1	1	0
10/21/2019 14:00	1.3	13.7	1,731.2	1.1	6.90	1	1	0
10/21/2019 15:00	1.2	13.7	1,730.0	1.0	6.90	1	1	0
10/21/2019 16:00	1.2	13.7	1,731.8	1.0	6.90	1	1	0
10/21/2019 17:00	1.2	13.7	1,736.8	1.0	6.90	1	1	0
10/21/2019 18:00	1.2	13.7	1,735.9	1.0	6.90	1	1	0
10/21/2019 19:00	1.2	13.7	1,739.4	1.0	7.00	1	1	1
10/21/2019 20:00	1.5	12.7	1,960.4	1.1	7.80	1	1	1
10/21/2019 21:00	1.6	12.4	2,008.1	1.1	8.00	1	1	1
10/21/2019 22:00	1.6	12.5	2,001.5	1.1	8.00	1	1	1
10/21/2019 23:00	1.6	12.6	1,970.1	1.1	7.90	1	1	1
Average/Sum#:	1.3	13.2	1,784.2	1.0	156.50 #	24 #	24 #	13 #
Minimum:	0.5	12.2	1,254.5	0.4	2.50	1	1	0
Maximum:	1.6	14.0	2,095.4	1.2	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/22/2019 00:00	1.5	12.8	1,929.4	1.1	7.70	1	1	1
10/22/2019 01:00	1.5	12.7	1,934.0	1.1	7.70	1	1	1
10/22/2019 02:00	1.5	12.7	1,923.3	1.1	7.70	1	1	1
10/22/2019 03:00	1.5	12.6	1,932.1	1.1	7.70	1	1	1
10/22/2019 04:00	1.5	12.8	1,947.6	1.1	7.80	1	1	1
10/22/2019 05:00	1.6	12.5	2,000.6	1.1	8.00	1	1	1
10/22/2019 06:00	1.3	12.4	2,031.9	0.9	6.10	1	1	1
10/22/2019 07:00	1.5	12.7	1,983.9	1.1	7.90	1	1	1
10/22/2019 08:00	1.6	12.4	2,020.9	1.1	8.10	1	1	1
10/22/2019 09:00	1.6	12.4	2,009.9	1.1	8.00	1	1	1
10/22/2019 10:00	1.6	12.4	2,016.2	1.1	8.10	1	1	1
10/22/2019 11:00	1.6	12.3	2,027.9	1.1	8.10	1	1	1
10/22/2019 12:00	1.7	12.2	2,038.6	1.2	8.20	1	1	1
10/22/2019 13:00	1.7	12.1	2,058.8	1.1	8.20	1	1	1
10/22/2019 14:00	1.7	12.0	2,064.1	1.1	8.30	1	1	1
10/22/2019 15:00	1.7	12.1	2,060.2	1.1	8.20	1	1	1
10/22/2019 16:00	1.7	12.1	2,061.5	1.1	8.20	1	1	1
10/22/2019 17:00	1.7	11.9	2,108.7	1.1	8.40	1	1	1
10/22/2019 18:00	1.6	12.2	2,035.4	1.1	8.10	1	1	1
10/22/2019 19:00	1.7	12.1	2,053.7	1.1	8.20	1	1	1
10/22/2019 20:00	1.6	12.3	2,012.1	1.1	8.00	1	1	1
10/22/2019 21:00	1.7	12.2	2,029.5	1.2	8.10	1	1	1
10/22/2019 22:00	1.6	12.3	2,006.4	1.1	8.00	1	1	1
10/22/2019 23:00	1.6	12.5	1,981.3	1.1	7.90	1	1	1
Average/Sum#:	1.6	12.4	2,011.2	1.1	190.70 #	24 #	24 #	24 #
Minimum:	1.3	11.9	1,923.3	0.9	6.10	1	1	1
Maximum:	1.7	12.8	2,108.7	1.2	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/23/2019 00:00	1.6	12.5	1,978.0	1.1	7.90	1	1	1
10/23/2019 01:00	1.6	12.5	1,976.9	1.1	7.90	1	1	1
10/23/2019 02:00	1.6	12.6	1,962.3	1.1	7.80	1	1	1
10/23/2019 03:00	1.6	12.6	1,970.1	1.1	7.90	1	1	1
10/23/2019 04:00	1.6	12.7	1,951.3	1.2	7.80	1	1	1
10/23/2019 05:00	1.6	12.3	2,032.6	1.1	8.10	1	1	1
10/23/2019 06:00	1.4	12.5	1,986.1	1.0	7.90	1	1	1
10/23/2019 07:00	0.7	13.9	1,333.0	0.6	2.70	1	1	0
10/23/2019 08:00	0.6	14.0	1,252.0	0.5	2.50	1	1	0
10/23/2019 09:00	0.5	14.0	1,252.4	0.4	2.50	1	1	0
10/23/2019 10:00	0.6	14.0	1,386.6	0.5	2.80	1	1	0
10/23/2019 11:00	0.7	14.0	1,473.3	0.6	2.90	1	1	0
10/23/2019 12:00	0.9	13.9	1,575.8	0.8	4.70	1	1	0
10/23/2019 13:00	1.3	13.7	1,735.3	1.1	6.90	1	1	0
10/23/2019 14:00	1.3	13.7	1,733.6	1.1	6.90	1	1	0
10/23/2019 15:00	1.3	13.7	1,731.8	1.1	6.90	1	1	0
10/23/2019 16:00	1.3	13.7	1,733.9	1.1	6.90	1	1	0
10/23/2019 17:00	1.2	13.7	1,737.2	1.0	6.90	1	1	0
10/23/2019 18:00	1.1	13.8	1,701.6	0.9	5.10	1	1	0
10/23/2019 19:00	1.4	13.0	1,869.7	1.0	7.50	1	1	1
10/23/2019 20:00	1.6	12.3	2,051.7	1.1	8.20	1	1	1
10/23/2019 21:00	1.7	12.2	2,081.6	1.2	8.30	1	1	1
10/23/2019 22:00	1.7	12.2	2,073.9	1.2	8.30	1	1	1
10/23/2019 23:00	1.6	12.4	2,027.1	1.1	8.10	1	1	1
Average/Sum#:	1.3	13.2	1,775.3	1.0	153.40 #	24 #	24 #	12 #
Minimum:	0.5	12.2	1,252.0	0.4	2.50	1	1	0
Maximum:	1.7	14.0	2,081.6	1.2	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/24/2019 00:00	1.6	12.5	2,004.3	1.1	8.00	1	1	1
10/24/2019 01:00	1.5	12.6	1,978.3	1.1	7.90	1	1	1
10/24/2019 02:00	1.3	12.9	1,918.4	1.0	7.70	1	1	1
10/24/2019 03:00	1.6	12.5	2,024.7	1.1	8.10	1	1	1
10/24/2019 04:00	1.7	12.5	2,028.5	1.2	8.10	1	1	1
10/24/2019 05:00	2.0	12.2	2,084.4	1.4	10.40	1	1	1
10/24/2019 06:00	1.7	12.4	2,072.1	1.2	8.30	1	1	1
10/24/2019 07:00	1.7	12.0	2,136.3	1.1	8.50	1	1	1
10/24/2019 08:00	1.7	12.0	2,131.8	1.1	8.50	1	1	1
10/24/2019 09:00	1.7	12.0	2,128.6	1.1	8.50	1	1	1
10/24/2019 10:00	1.7	11.9	2,128.7	1.1	8.50	1	1	1
10/24/2019 11:00	1.7	11.9	2,128.8	1.1	8.50	1	1	1
10/24/2019 12:00	1.7	11.9	2,119.4	1.1	8.50	1	1	1
10/24/2019 13:00	1.7	11.9	2,113.3	1.1	8.50	1	1	1
10/24/2019 14:00	1.7	11.9	2,109.4	1.1	8.40	1	1	1
10/24/2019 15:00	1.7	12.0	2,092.1	1.1	8.40	1	1	1
10/24/2019 16:00	1.7	12.0	2,102.9	1.1	8.40	1	1	1
10/24/2019 17:00	1.7	12.1	2,076.3	1.1	8.30	1	1	1
10/24/2019 18:00	1.7	12.1	2,070.7	1.1	8.30	1	1	1
10/24/2019 19:00	1.7	11.9	2,118.9	1.1	8.50	1	1	1
10/24/2019 20:00	1.7	12.0	2,109.9	1.1	8.40	1	1	1
10/24/2019 21:00	1.7	12.0	2,104.3	1.1	8.40	1	1	1
10/24/2019 22:00	1.6	12.0	2,090.1	1.1	8.40	1	1	1
10/24/2019 23:00	1.6	12.1	2,076.2	1.1	8.30	1	1	1
Average/Sum#:	1.7	12.1	2,081.2	1.1	201.80 #	24 #	24 #	24 #
Minimum:	1.3	11.9	1,918.4	1.0	7.70	1	1	1
Maximum:	2.0	12.9	2,136.3	1.4	10.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/25/2019 00:00	1.5	12.2	2,007.7	1.0	8.00	1	1	1
10/25/2019 01:00	1.5	12.5	1,958.6	1.1	7.80	1	1	1
10/25/2019 02:00	1.5	12.4	1,974.3	1.0	7.90	1	1	1
10/25/2019 03:00	1.5	12.5	1,970.3	1.1	7.90	1	1	1
10/25/2019 04:00	1.5	12.5	2,005.8	1.1	8.00	1	1	1
10/25/2019 05:00	1.6	12.6	1,993.6	1.1	8.00	1	1	1
10/25/2019 06:00	1.5	12.4	2,036.9	1.0	8.10	1	1	1
10/25/2019 07:00	1.6	12.6	1,992.3	1.1	8.00	1	1	1
10/25/2019 08:00	1.5	13.1	1,904.4	1.1	7.60	1	1	1
10/25/2019 09:00	1.5	13.1	1,903.5	1.1	7.60	1	1	1
10/25/2019 10:00	1.5	12.9	1,920.0	1.1	7.70	1	1	1
10/25/2019 11:00	1.5	12.9	1,907.8	1.1	7.60	1	1	1
10/25/2019 12:00	1.6	12.4	2,013.1	1.1	8.10	1	1	1
10/25/2019 13:00	1.7	12.4	2,013.6	1.2	8.10	1	1	1
10/25/2019 14:00	1.6	12.4	2,011.5	1.1	8.00	1	1	1
10/25/2019 15:00	1.6	12.4	2,012.4	1.1	8.00	1	1	1
10/25/2019 16:00	1.7	12.1	2,062.9	1.1	8.30	1	1	1
10/25/2019 17:00	1.7	12.1	2,057.9	1.1	8.20	1	1	1
10/25/2019 18:00	1.6	12.4	2,000.6	1.1	8.00	1	1	1
10/25/2019 19:00	1.6	12.4	2,000.0	1.1	8.00	1	1	1
10/25/2019 20:00	1.6	12.3	1,976.4	1.1	7.90	1	1	1
10/25/2019 21:00	1.6	12.2	1,999.8	1.1	8.00	1	1	1
10/25/2019 22:00	1.5	12.4	1,979.3	1.0	7.90	1	1	1
10/25/2019 23:00	1.5	12.4	1,992.8	1.0	8.00	1	1	1
Average/Sum#:	1.6	12.5	1,987.3	1.1	190.70 #	24 #	24 #	24 #
Minimum:	1.5	12.1	1,903.5	1.0	7.60	1	1	1
Maximum:	1.7	13.1	2,062.9	1.2	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/26/2019 00:00	1.5	12.5	1,971.3	1.1	7.90	1	1	1
10/26/2019 01:00	1.6	12.4	1,996.7	1.1	8.00	1	1	1
10/26/2019 02:00	1.5	12.4	1,995.8	1.0	8.00	1	1	1
10/26/2019 03:00	1.6	12.4	1,990.1	1.1	8.00	1	1	1
10/26/2019 04:00	1.6	12.4	1,993.0	1.1	8.00	1	1	1
10/26/2019 05:00	1.5	12.8	1,935.3	1.1	7.70	1	1	1
10/26/2019 06:00	1.2	12.8	1,921.3	0.9	5.80	1	1	1
10/26/2019 07:00	0.8	13.9	1,480.7	0.7	3.00	1	1	0
10/26/2019 08:00	0.8	13.9	1,577.9	0.7	3.20	1	1	0
10/26/2019 09:00	0.8	13.9	1,578.8	0.7	3.20	1	1	0
10/26/2019 10:00	0.8	13.9	1,467.9	0.7	2.90	1	1	0
10/26/2019 11:00	0.8	13.9	1,427.9	0.7	2.90	1	1	0
10/26/2019 12:00	0.8	14.0	1,525.7	0.7	4.60	1	1	0
10/26/2019 13:00	1.0	13.9	1,584.5	0.8	4.80	1	1	0
10/26/2019 14:00	0.7	14.0	1,472.6	0.6	2.90	1	1	0
10/26/2019 15:00	0.8	13.9	1,485.4	0.7	3.00	1	1	1
10/26/2019 16:00	1.5	12.6	1,940.8	1.1	7.80	1	1	1
10/26/2019 17:00	1.6	12.3	2,002.1	1.1	8.00	1	1	1
10/26/2019 18:00	1.6	12.4	1,998.3	1.1	8.00	1	1	1
10/26/2019 19:00	1.6	12.4	1,995.3	1.1	8.00	1	1	1
10/26/2019 20:00	1.6	12.4	2,007.7	1.1	8.00	1	1	1
10/26/2019 21:00	1.6	12.5	2,011.0	1.1	8.00	1	1	1
10/26/2019 22:00	3.5	14.4	1,147.5	3.2	6.62	1	0	1
10/26/2019 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.3	13.1	1,761.2	1.0	138.32 #	23 #	22 #	15 #
Minimum:	0.7	12.3	1,147.5	0.6	2.90	0	0	0
Maximum:	3.5	14.4	2,011.0	3.2	8.00	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/27/2019 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2019 17:00	29.0	18.0	405.9	59.0	37.00	1	0	0
10/27/2019 18:00	30.9	16.3	626.0	39.6	91.40	1	0	0
10/27/2019 19:00	20.5	15.1	901.5	20.9	69.40	1	0	0
10/27/2019 20:00	0.6	14.0	1,447.9	0.5	2.90	1	1	0
10/27/2019 21:00	0.6	14.0	1,340.3	0.5	2.70	1	1	0
10/27/2019 22:00	0.6	14.0	1,341.9	0.5	2.70	1	1	0
10/27/2019 23:00	0.6	14.0	1,343.9	0.5	2.70	1	1	0
Average/Sum#:	11.8	15.1	1,058.2	17.4	208.80 #	7 #	4 #	0 #
Minimum:	0.6	14.0	405.9	0.5	2.70	0	0	0
Maximum:	30.9	18.0	1,447.9	59.0	91.40	1	1	0
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/28/2019 00:00	0.8	13.9	1,544.5	0.7	3.10	1	1	0
10/28/2019 01:00	0.7	13.9	1,570.5	0.6	3.10	1	1	0
10/28/2019 02:00	0.5	14.0	1,333.4	0.4	2.70	1	1	0
10/28/2019 03:00	0.7	13.9	1,562.9	0.6	3.10	1	1	1
10/28/2019 04:00	1.5	13.0	1,919.0	1.1	7.70	1	1	1
10/28/2019 05:00	1.5	12.8	1,964.1	1.1	7.90	1	1	1
10/28/2019 06:00	1.2	12.1	2,107.7	0.8	6.30	1	1	1
10/28/2019 07:00	1.6	12.5	2,020.6	1.1	8.10	1	1	1
10/28/2019 08:00	1.5	12.7	1,979.4	1.1	7.90	1	1	1
10/28/2019 09:00	1.5	12.7	1,981.7	1.1	7.90	1	1	1
10/28/2019 10:00	1.5	12.7	1,972.7	1.1	7.90	1	1	1
10/28/2019 11:00	1.5	12.9	1,952.8	1.1	7.80	1	1	1
10/28/2019 12:00	1.6	12.7	1,978.3	1.2	7.90	1	1	1
10/28/2019 13:00	1.6	12.8	1,959.4	1.2	7.80	1	1	1
10/28/2019 14:00	1.6	12.7	1,980.2	1.2	7.90	1	1	1
10/28/2019 15:00	1.6	12.6	2,003.6	1.1	8.00	1	1	1
10/28/2019 16:00	1.6	12.4	2,057.8	1.1	8.20	1	1	1
10/28/2019 17:00	1.7	11.9	2,141.9	1.1	8.60	1	1	1
10/28/2019 18:00	1.7	12.2	2,094.9	1.2	8.40	1	1	1
10/28/2019 19:00	1.6	12.3	2,082.5	1.1	8.30	1	1	1
10/28/2019 20:00	1.6	12.3	2,067.8	1.1	8.30	1	1	1
10/28/2019 21:00	1.6	12.3	2,047.1	1.1	8.20	1	1	1
10/28/2019 22:00	1.5	12.8	1,919.9	1.1	7.70	1	1	1
10/28/2019 23:00	7.2	15.7	608.0	8.2	4.19	1	0	0
Average/Sum#:	1.6	12.9	1,868.8	1.3	166.99 #	24 #	23 #	20 #
Minimum:	0.5	11.9	608.0	0.4	2.70	1	0	0
Maximum:	7.2	15.7	2,141.9	8.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/29/2019 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2019 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/30/2019 00:00	33.2	17.7	444.4	61.2	68.27	1	0	0
10/30/2019 01:00	26.6	16.0	673.3	32.0	79.40	1	0	0
10/30/2019 02:00	16.8	15.0	990.0	16.8	61.40	1	0	0
10/30/2019 03:00	1.2	13.4	1,809.2	0.9	5.40	1	1	1
10/30/2019 04:00	1.7	12.0	2,106.0	1.1	8.40	1	1	1
10/30/2019 05:00	0.6	13.9	1,653.2	0.5	3.30	1	1	0
10/30/2019 06:00	0.5	14.0	1,485.8	0.4	3.00	1	1	0
10/30/2019 07:00	0.7	13.9	1,708.4	0.6	3.40	1	1	0
10/30/2019 08:00	0.8	13.9	1,714.6	0.7	3.40	1	1	1
10/30/2019 09:00	1.4	13.0	1,920.6	1.0	7.70	1	1	1
10/30/2019 10:00	1.5	12.6	2,017.5	1.1	8.10	1	1	1
10/30/2019 11:00	1.5	12.3	2,051.1	1.0	8.20	1	1	1
10/30/2019 12:00	1.5	12.2	2,075.4	1.0	8.30	1	1	1
10/30/2019 13:00	1.5	12.4	2,041.5	1.0	8.20	1	1	1
10/30/2019 14:00	1.6	12.7	1,998.3	1.2	8.00	1	1	1
10/30/2019 15:00	1.6	12.7	2,012.2	1.2	8.00	1	1	1
10/30/2019 16:00	1.7	12.1	2,134.2	1.1	8.50	1	1	1
10/30/2019 17:00	1.7	12.1	2,123.9	1.1	8.50	1	1	1
10/30/2019 18:00	1.6	12.3	2,096.6	1.1	8.40	1	1	1
10/30/2019 19:00	1.6	12.4	2,089.3	1.1	8.40	1	1	1
10/30/2019 20:00	1.6	12.5	2,054.6	1.1	8.20	1	1	1
10/30/2019 21:00	1.5	12.4	2,056.9	1.0	8.20	1	1	1
10/30/2019 22:00	1.4	12.8	1,959.0	1.0	7.80	1	1	1
10/30/2019 23:00	1.5	13.0	1,948.7	1.1	7.80	1	1	1
Average/Sum#:	4.4	13.2	1,798.5	5.4	358.27 #	24 #	21 #	18 #
Minimum:	0.5	12.0	444.4	0.4	3.00	1	0	0
Maximum:	33.2	17.7	2,134.2	61.2	79.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/31/2019 00:00	1.5	13.1	1,936.9	1.1	7.70	1	1	1
10/31/2019 01:00	1.5	12.9	1,965.0	1.1	7.90	1	1	1
10/31/2019 02:00	1.5	12.9	1,957.8	1.1	7.80	1	1	1
10/31/2019 03:00	1.5	12.9	1,966.3	1.1	7.90	1	1	1
10/31/2019 04:00	1.5	12.8	1,995.8	1.1	8.00	1	1	1
10/31/2019 05:00	1.5	12.6	2,009.9	1.1	8.00	1	1	1
10/31/2019 06:00	1.5	12.7	1,998.8	1.1	8.00	1	1	1
10/31/2019 07:00	1.5	12.9	1,966.9	1.1	7.90	1	1	1
10/31/2019 08:00	1.5	13.0	1,938.6	1.1	7.80	1	1	1
10/31/2019 09:00	1.5	12.8	1,961.7	1.1	7.80	1	1	1
10/31/2019 10:00	1.5	12.9	1,949.1	1.1	7.80	1	1	1
10/31/2019 11:00	1.5	13.1	1,923.3	1.1	7.70	1	1	1
10/31/2019 12:00	1.5	12.9	1,946.4	1.1	7.80	1	1	1
10/31/2019 13:00	1.5	12.9	1,946.4	1.1	7.80	1	1	1
10/31/2019 14:00	1.5	12.9	1,953.8	1.1	7.80	1	1	1
10/31/2019 15:00	1.6	12.8	1,958.8	1.2	7.80	1	1	1
10/31/2019 16:00	1.5	12.8	1,968.1	1.1	7.90	1	1	1
10/31/2019 17:00	1.5	12.9	1,946.6	1.1	7.80	1	1	1
10/31/2019 18:00	1.6	12.8	1,975.2	1.2	7.90	1	1	1
10/31/2019 19:00	1.6	12.4	2,071.2	1.1	8.30	1	1	1
10/31/2019 20:00	1.6	12.4	2,063.5	1.1	8.30	1	1	1
10/31/2019 21:00	1.6	12.4	2,072.1	1.1	8.30	1	1	1
10/31/2019 22:00	1.5	12.3	2,065.1	1.0	8.30	1	1	1
10/31/2019 23:00	1.6	12.4	2,055.0	1.1	8.20	1	1	1
Average/Sum#:	1.5	12.8	1,983.0	1.1	190.50 #	24 #	24 #	24 #
Minimum:	1.5	12.3	1,923.3	1.0	7.70	1	1	1
Maximum:	1.6	13.1	2,072.1	1.2	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2019 00:00	1.6	12.5	2,039.3	1.1	8.20	1	1	1
11/01/2019 01:00	1.5	12.6	2,007.9	1.1	8.00	1	1	1
11/01/2019 02:00	1.6	12.5	2,037.2	1.1	8.10	1	1	1
11/01/2019 03:00	1.5	12.5	2,037.3	1.1	8.10	1	1	1
11/01/2019 04:00	1.5	12.7	2,001.1	1.1	8.00	1	1	1
11/01/2019 05:00	1.6	12.4	2,088.4	1.1	8.40	1	1	1
11/01/2019 06:00	1.6	12.3	2,111.8	1.1	8.40	1	1	1
11/01/2019 07:00	1.6	12.3	2,107.2	1.1	8.40	1	1	1
11/01/2019 08:00	1.6	12.3	2,094.9	1.1	8.40	1	1	1
11/01/2019 09:00	1.1	13.5	1,762.6	0.9	5.30	1	1	1
11/01/2019 10:00	0.8	13.9	1,657.5	0.7	3.30	1	1	0
11/01/2019 11:00	0.5	14.0	1,325.9	0.4	2.70	1	1	0
11/01/2019 12:00	0.6	13.9	1,515.9	0.5	3.00	1	1	0
11/01/2019 13:00	0.7	14.0	1,560.1	0.6	3.10	1	1	0
11/01/2019 14:00	0.8	13.9	1,520.8	0.7	3.00	1	1	1
11/01/2019 15:00	1.5	12.8	1,958.8	1.1	7.80	1	1	1
11/01/2019 16:00	1.5	12.5	1,987.6	1.1	8.00	1	1	1
11/01/2019 17:00	1.7	12.0	2,130.3	1.1	8.50	1	1	1
11/01/2019 18:00	1.7	11.9	2,165.5	1.1	8.70	1	1	1
11/01/2019 19:00	1.6	12.3	2,081.7	1.1	8.30	1	1	1
11/01/2019 20:00	1.6	12.2	2,118.3	1.1	8.50	1	1	1
11/01/2019 21:00	1.6	12.5	2,048.1	1.1	8.20	1	1	1
11/01/2019 22:00	1.6	12.7	2,021.6	1.2	8.10	1	1	1
11/01/2019 23:00	1.6	12.6	2,042.8	1.1	8.20	1	1	1
Average/Sum#:	1.4	12.8	1,934.3	1.0	168.70 #	24 #	24 #	20 #
Minimum:	0.5	11.9	1,325.9	0.4	2.70	1	1	0
Maximum:	1.7	14.0	2,165.5	1.2	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/02/2019 00:00	1.6	12.4	2,059.3	1.1	8.20	1	1	1
11/02/2019 01:00	1.6	12.3	2,062.5	1.1	8.30	1	1	1
11/02/2019 02:00	1.6	12.3	2,075.5	1.1	8.30	1	1	1
11/02/2019 03:00	1.6	12.3	2,071.8	1.1	8.30	1	1	1
11/02/2019 04:00	1.6	12.3	2,076.7	1.1	8.30	1	1	1
11/02/2019 05:00	1.5	12.4	2,043.3	1.0	8.20	1	1	1
11/02/2019 06:00	1.6	12.0	2,128.8	1.1	8.50	1	1	1
11/02/2019 07:00	1.6	12.3	2,071.0	1.1	8.30	1	1	1
11/02/2019 08:00	1.4	13.0	1,895.3	1.0	7.60	1	1	1
11/02/2019 09:00	0.7	13.9	1,536.5	0.6	3.10	1	1	0
11/02/2019 10:00	0.7	13.9	1,526.0	0.6	3.10	1	1	0
11/02/2019 11:00	0.7	14.0	1,536.3	0.6	3.10	1	1	0
11/02/2019 12:00	0.7	14.0	1,535.8	0.6	3.10	1	1	0
11/02/2019 13:00	4.6	15.6	733.2	5.1	4.17	1	0	0
11/02/2019 14:00	13.8	16.4	635.9	18.1	33.23	1	0	0
11/02/2019 15:00	0.6	14.0	1,533.5	0.5	3.10	1	0	0
11/02/2019 16:00	0.6	14.0	1,386.1	0.5	2.80	1	1	0
11/02/2019 17:00	1.0	13.6	1,722.6	0.8	5.20	1	1	1
11/02/2019 18:00	1.6	12.5	2,020.0	1.1	8.10	1	1	1
11/02/2019 19:00	1.7	12.0	2,132.0	1.1	8.50	1	1	1
11/02/2019 20:00	1.7	12.0	2,119.4	1.1	8.50	1	1	1
11/02/2019 21:00	1.6	12.4	2,069.6	1.1	8.30	1	1	1
11/02/2019 22:00	1.6	12.5	2,045.7	1.1	8.20	1	1	1
11/02/2019 23:00	1.6	12.7	2,001.3	1.2	8.00	1	1	1
Average/Sum#:	2.0	13.1	1,792.4	1.8	184.50 #	24 #	21 #	16 #
Minimum:	0.6	12.0	635.9	0.5	2.80	1	0	0
Maximum:	13.8	16.4	2,132.0	18.1	33.23	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/03/2019 00:00	1.5	12.7	1,981.8	1.1	7.90	1	1	1
11/03/2019 01:00	1.5	12.6	1,996.2	1.1	8.00	1	1	1
11/03/2019 02:00	1.5	12.7	1,986.3	1.1	7.90	1	1	1
11/03/2019 03:00	1.6	12.6	2,004.9	1.1	8.00	1	1	1
11/03/2019 04:00	1.6	12.4	2,035.2	1.1	8.10	1	1	1
11/03/2019 05:00	1.6	12.2	2,086.3	1.1	8.30	1	1	1
11/03/2019 06:00	1.4	12.4	2,066.7	1.0	8.30	1	1	1
11/03/2019 07:00	1.6	12.6	1,947.8	1.1	7.80	1	1	1
11/03/2019 08:00	0.8	13.9	1,616.8	0.7	3.20	1	1	0
11/03/2019 09:00	0.8	13.9	1,596.8	0.7	3.20	1	1	0
11/03/2019 10:00	0.8	13.9	1,616.9	0.7	3.20	1	1	0
11/03/2019 11:00	0.8	13.9	1,606.5	0.7	3.20	1	1	0
11/03/2019 12:00	0.8	14.0	1,622.4	0.7	4.90	1	1	0
11/03/2019 13:00	0.7	14.0	1,475.1	0.6	3.00	1	1	0
11/03/2019 14:00	0.7	14.0	1,450.0	0.6	2.90	1	1	0
11/03/2019 15:00	1.3	13.3	1,764.1	1.0	7.10	1	1	1
11/03/2019 16:00	1.7	12.3	2,057.5	1.2	8.20	1	1	1
11/03/2019 17:00	1.7	12.1	2,094.3	1.1	8.40	1	1	1
11/03/2019 18:00	1.7	12.0	2,112.8	1.1	8.50	1	1	1
11/03/2019 19:00	1.7	11.9	2,131.0	1.1	8.50	1	1	1
11/03/2019 20:00	1.7	12.1	2,092.6	1.1	8.40	1	1	1
11/03/2019 21:00	1.6	12.3	2,064.3	1.1	8.30	1	1	1
11/03/2019 22:00	1.6	12.5	2,016.5	1.1	8.10	1	1	1
11/03/2019 23:00	1.6	12.4	2,039.4	1.1	8.20	1	1	1
Average/Sum#:	1.3	12.9	1,894.3	1.0	161.60 #	24 #	24 #	17 #
Minimum:	0.7	11.9	1,450.0	0.6	2.90	1	1	0
Maximum:	1.7	14.0	2,131.0	1.2	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/04/2019 00:00	1.6	12.5	2,008.7	1.1	8.00	1	1	1
11/04/2019 01:00	1.6	12.5	2,011.6	1.1	8.00	1	1	1
11/04/2019 02:00	1.5	12.7	1,961.1	1.1	7.80	1	1	1
11/04/2019 03:00	1.5	12.6	1,987.3	1.1	7.90	1	1	1
11/04/2019 04:00	1.6	12.5	2,007.4	1.1	8.00	1	1	1
11/04/2019 05:00	1.6	12.1	2,088.0	1.1	8.40	1	1	1
11/04/2019 06:00	1.6	12.0	2,128.2	1.1	8.50	1	1	1
11/04/2019 07:00	1.6	12.5	2,016.1	1.1	8.10	1	1	1
11/04/2019 08:00	1.6	12.5	2,029.1	1.1	8.10	1	1	1
11/04/2019 09:00	1.6	12.2	2,062.6	1.1	8.30	1	1	1
11/04/2019 10:00	1.6	12.3	2,026.7	1.1	8.10	1	1	1
11/04/2019 11:00	1.5	12.5	1,959.3	1.1	7.80	1	1	1
11/04/2019 12:00	1.5	12.3	2,005.9	1.0	8.00	1	1	1
11/04/2019 13:00	1.6	12.1	2,014.3	1.1	8.10	1	1	1
11/04/2019 14:00	1.6	12.2	1,995.5	1.1	8.00	1	1	1
11/04/2019 15:00	1.6	12.1	2,019.7	1.1	8.10	1	1	1
11/04/2019 16:00	1.6	12.0	2,072.5	1.1	8.30	1	1	1
11/04/2019 17:00	1.7	11.9	2,128.1	1.1	8.50	1	1	1
11/04/2019 18:00	1.7	11.9	2,132.5	1.1	8.50	1	1	1
11/04/2019 19:00	1.7	12.0	2,132.0	1.1	8.50	1	1	1
11/04/2019 20:00	1.7	12.0	2,128.1	1.1	8.50	1	1	1
11/04/2019 21:00	1.7	12.0	2,130.5	1.1	8.50	1	1	1
11/04/2019 22:00	1.7	12.0	2,127.8	1.1	8.50	1	1	1
11/04/2019 23:00	1.7	12.3	2,059.0	1.2	8.20	1	1	1
Average/Sum#:	1.6	12.2	2,051.3	1.1	196.70 #	24 #	24 #	24 #
Minimum:	1.5	11.9	1,959.3	1.0	7.80	1	1	1
Maximum:	1.7	12.7	2,132.5	1.2	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/05/2019 00:00	1.7	12.3	2,077.8	1.2	8.30	1	1	1
11/05/2019 01:00	1.7	12.3	2,076.3	1.2	8.30	1	1	1
11/05/2019 02:00	1.6	12.3	2,073.7	1.1	8.30	1	1	1
11/05/2019 03:00	1.7	12.3	2,071.0	1.2	8.30	1	1	1
11/05/2019 04:00	1.7	12.3	2,068.4	1.2	8.30	1	1	1
11/05/2019 05:00	1.7	12.2	2,108.2	1.2	8.40	1	1	1
11/05/2019 06:00	1.7	12.0	2,158.8	1.1	8.60	1	1	1
11/05/2019 07:00	1.6	12.6	2,001.5	1.1	8.00	1	1	1
11/05/2019 08:00	1.6	12.6	2,016.7	1.1	8.10	1	1	1
11/05/2019 09:00	1.6	12.8	1,972.2	1.2	7.90	1	1	1
11/05/2019 10:00	1.6	12.7	1,979.7	1.2	7.90	1	1	1
11/05/2019 11:00	1.6	12.7	1,964.8	1.2	7.90	1	1	1
11/05/2019 12:00	1.6	12.6	1,974.9	1.1	7.90	1	1	1
11/05/2019 13:00	1.6	12.4	2,026.2	1.1	8.10	1	1	1
11/05/2019 14:00	1.6	12.4	2,006.2	1.1	8.00	1	1	1
11/05/2019 15:00	1.6	12.4	2,017.6	1.1	8.10	1	1	1
11/05/2019 16:00	1.7	12.1	2,078.0	1.1	8.30	1	1	1
11/05/2019 17:00	1.7	12.2	2,063.8	1.2	8.30	1	1	1
11/05/2019 18:00	1.7	12.2	2,068.5	1.2	8.30	1	1	1
11/05/2019 19:00	1.7	12.1	2,078.5	1.1	8.30	1	1	1
11/05/2019 20:00	1.7	12.2	2,085.3	1.2	8.30	1	1	1
11/05/2019 21:00	1.6	12.2	2,073.8	1.1	8.30	1	1	1
11/05/2019 22:00	1.7	12.3	2,080.1	1.2	8.30	1	1	1
11/05/2019 23:00	1.7	12.3	2,084.0	1.2	8.30	1	1	1
Average/Sum#:	1.7	12.4	2,050.3	1.2	196.80 #	24 #	24 #	24 #
Minimum:	1.6	12.0	1,964.8	1.1	7.90	1	1	1
Maximum:	1.7	12.8	2,158.8	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/06/2019 00:00	1.6	12.6	2,015.5	1.1	8.10	1	1	1
11/06/2019 01:00	1.6	12.8	1,981.3	1.2	7.90	1	1	1
11/06/2019 02:00	1.6	12.5	2,049.7	1.1	8.20	1	1	1
11/06/2019 03:00	1.6	12.5	2,017.1	1.1	8.10	1	1	1
11/06/2019 04:00	1.6	12.7	1,975.2	1.2	7.90	1	1	1
11/06/2019 05:00	1.6	12.5	2,023.4	1.1	8.10	1	1	1
11/06/2019 06:00	1.4	12.2	2,096.8	0.9	6.30	1	1	1
11/06/2019 07:00	1.6	12.4	2,042.3	1.1	8.20	1	1	1
11/06/2019 08:00	1.6	12.6	2,007.6	1.1	8.00	1	1	1
11/06/2019 09:00	1.6	12.7	1,976.2	1.2	7.90	1	1	1
11/06/2019 10:00	1.6	12.7	1,971.5	1.2	7.90	1	1	1
11/06/2019 11:00	1.6	12.6	1,986.6	1.1	7.90	1	1	1
11/06/2019 12:00	1.6	12.6	1,980.4	1.1	7.90	1	1	1
11/06/2019 13:00	1.6	12.5	1,987.8	1.1	8.00	1	1	1
11/06/2019 14:00	1.6	12.5	1,999.8	1.1	8.00	1	1	1
11/06/2019 15:00	1.6	12.4	2,008.2	1.1	8.00	1	1	1
11/06/2019 16:00	1.7	12.2	2,053.0	1.2	8.20	1	1	1
11/06/2019 17:00	1.7	12.1	2,085.1	1.1	8.30	1	1	1
11/06/2019 18:00	1.7	12.1	2,080.8	1.1	8.30	1	1	1
11/06/2019 19:00	1.7	12.1	2,086.5	1.1	8.30	1	1	1
11/06/2019 20:00	1.7	12.1	2,082.1	1.1	8.30	1	1	1
11/06/2019 21:00	1.7	12.1	2,096.8	1.1	8.40	1	1	1
11/06/2019 22:00	1.7	12.2	2,089.3	1.2	8.40	1	1	1
11/06/2019 23:00	1.6	12.3	2,063.7	1.1	8.30	1	1	1
Average/Sum#:	1.6	12.4	2,031.5	1.1	192.90 #	24 #	24 #	24 #
Minimum:	1.4	12.1	1,971.5	0.9	6.30	1	1	1
Maximum:	1.7	12.8	2,096.8	1.2	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/07/2019 00:00	1.6	12.3	2,081.6	1.1	8.30	1	1	1
11/07/2019 01:00	1.6	12.3	2,057.9	1.1	8.20	1	1	1
11/07/2019 02:00	1.6	12.4	2,032.0	1.1	8.10	1	1	1
11/07/2019 03:00	1.6	12.6	1,994.8	1.1	8.00	1	1	1
11/07/2019 04:00	1.6	12.4	2,040.5	1.1	8.20	1	1	1
11/07/2019 05:00	1.6	12.4	2,041.8	1.1	8.20	1	1	1
11/07/2019 06:00	1.6	12.3	2,066.5	1.1	8.30	1	1	1
11/07/2019 07:00	1.6	12.4	2,045.8	1.1	8.20	1	1	1
11/07/2019 08:00	1.6	12.7	2,001.6	1.2	8.00	1	1	1
11/07/2019 09:00	1.6	12.6	2,004.1	1.1	8.00	1	1	1
11/07/2019 10:00	1.6	12.7	1,976.3	1.2	7.90	1	1	1
11/07/2019 11:00	1.6	12.5	2,008.8	1.1	8.00	1	1	1
11/07/2019 12:00	1.6	12.5	2,008.1	1.1	8.00	1	1	1
11/07/2019 13:00	1.6	12.5	2,005.1	1.1	8.00	1	1	1
11/07/2019 14:00	1.6	12.4	2,020.6	1.1	8.10	1	1	1
11/07/2019 15:00	1.6	12.3	2,038.9	1.1	8.20	1	1	1
11/07/2019 16:00	1.7	12.1	2,084.0	1.1	8.30	1	1	1
11/07/2019 17:00	1.6	12.3	2,045.2	1.1	8.20	1	1	1
11/07/2019 18:00	1.7	12.1	2,104.0	1.1	8.40	1	1	1
11/07/2019 19:00	1.7	12.1	2,107.4	1.1	8.40	1	1	1
11/07/2019 20:00	1.7	12.2	2,073.1	1.2	8.30	1	1	1
11/07/2019 21:00	1.6	12.4	2,050.2	1.1	8.20	1	1	1
11/07/2019 22:00	1.6	12.4	2,056.7	1.1	8.20	1	1	1
11/07/2019 23:00	1.6	12.5	2,030.2	1.1	8.10	1	1	1
Average/Sum#:	1.6	12.4	2,040.6	1.1	195.80 #	24 #	24 #	24 #
Minimum:	1.6	12.1	1,976.3	1.1	7.90	1	1	1
Maximum:	1.7	12.7	2,107.4	1.2	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/08/2019 00:00	1.6	12.4	2,055.6	1.1	8.20	1	1	1
11/08/2019 01:00	1.6	12.3	2,069.5	1.1	8.30	1	1	1
11/08/2019 02:00	1.6	12.4	2,041.9	1.1	8.20	1	1	1
11/08/2019 03:00	1.6	12.5	2,013.1	1.1	8.10	1	1	1
11/08/2019 04:00	1.6	12.6	2,007.1	1.1	8.00	1	1	1
11/08/2019 05:00	1.6	12.6	2,010.1	1.1	8.00	1	1	1
11/08/2019 06:00	1.5	12.6	2,001.5	1.1	8.00	1	1	1
11/08/2019 07:00	1.6	12.7	1,992.1	1.2	8.00	1	1	1
11/08/2019 08:00	1.3	13.1	1,868.5	1.0	7.50	1	1	1
11/08/2019 09:00	0.8	13.9	1,497.5	0.7	3.00	1	1	0
11/08/2019 10:00	0.6	14.0	1,332.3	0.5	2.70	1	1	0
11/08/2019 11:00	0.7	13.9	1,483.7	0.6	3.00	1	1	0
11/08/2019 12:00	0.7	14.0	1,485.4	0.6	3.00	1	1	0
11/08/2019 13:00	0.8	13.8	1,629.9	0.7	3.30	1	1	0
11/08/2019 14:00	1.0	13.8	1,628.2	0.8	4.90	1	1	1
11/08/2019 15:00	1.5	12.8	1,938.7	1.1	7.80	1	1	1
11/08/2019 16:00	1.6	12.5	1,994.3	1.1	8.00	1	1	1
11/08/2019 17:00	1.6	12.5	2,010.5	1.1	8.00	1	1	1
11/08/2019 18:00	1.6	12.3	2,066.4	1.1	8.30	1	1	1
11/08/2019 19:00	1.6	12.4	2,028.9	1.1	8.10	1	1	1
11/08/2019 20:00	1.6	12.4	2,058.7	1.1	8.20	1	1	1
11/08/2019 21:00	1.7	12.3	2,064.8	1.2	8.30	1	1	1
11/08/2019 22:00	1.6	12.4	2,062.1	1.1	8.20	1	1	1
11/08/2019 23:00	1.6	12.3	2,077.3	1.1	8.30	1	1	1
Average/Sum#:	1.4	12.9	1,892.4	1.0	165.40 #	24 #	24 #	19 #
Minimum:	0.6	12.3	1,332.3	0.5	2.70	1	1	0
Maximum:	1.7	14.0	2,077.3	1.2	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/09/2019 00:00	1.6	12.2	2,078.1	1.1	8.30	1	1	1
11/09/2019 01:00	1.6	12.3	2,055.1	1.1	8.20	1	1	1
11/09/2019 02:00	1.6	12.3	2,058.6	1.1	8.20	1	1	1
11/09/2019 03:00	1.6	12.3	2,060.0	1.1	8.20	1	1	1
11/09/2019 04:00	1.6	12.3	2,069.3	1.1	8.30	1	1	1
11/09/2019 05:00	1.6	12.6	2,008.9	1.1	8.00	1	1	1
11/09/2019 06:00	1.5	12.8	1,992.1	1.1	8.00	1	1	1
11/09/2019 07:00	1.5	12.8	1,937.4	1.1	7.70	1	1	1
11/09/2019 08:00	0.7	13.9	1,495.2	0.6	3.00	1	1	0
11/09/2019 09:00	0.6	14.0	1,265.6	0.5	2.50	1	1	0
11/09/2019 10:00	0.5	14.0	1,280.9	0.4	2.60	1	1	0
11/09/2019 11:00	0.5	14.0	1,274.1	0.4	2.50	1	1	0
11/09/2019 12:00	0.5	14.0	1,282.6	0.4	2.60	1	1	0
11/09/2019 13:00	0.5	14.0	1,273.7	0.4	2.50	1	1	0
11/09/2019 14:00	0.7	13.9	1,495.9	0.6	3.00	1	1	1
11/09/2019 15:00	1.4	12.8	1,950.1	1.0	7.80	1	1	1
11/09/2019 16:00	1.6	12.5	1,996.0	1.1	8.00	1	1	1
11/09/2019 17:00	1.6	12.4	2,023.3	1.1	8.10	1	1	1
11/09/2019 18:00	1.6	12.5	1,998.6	1.1	8.00	1	1	1
11/09/2019 19:00	1.6	12.6	2,003.0	1.1	8.00	1	1	1
11/09/2019 20:00	1.6	12.6	1,991.9	1.1	8.00	1	1	1
11/09/2019 21:00	1.6	12.6	2,017.7	1.1	8.10	1	1	1
11/09/2019 22:00	1.6	12.5	2,040.6	1.1	8.20	1	1	1
11/09/2019 23:00	1.6	12.6	2,016.5	1.1	8.10	1	1	1
Average/Sum#:	1.3	12.9	1,819.4	0.9	155.90 #	24 #	24 #	18 #
Minimum:	0.5	12.2	1,265.6	0.4	2.50	1	1	0
Maximum:	1.6	14.0	2,078.1	1.1	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/10/2019 00:00	1.6	12.6	2,030.3	1.1	8.10	1	1	1
11/10/2019 01:00	1.5	12.8	1,969.0	1.1	7.90	1	1	1
11/10/2019 02:00	1.5	12.8	1,968.4	1.1	7.90	1	1	1
11/10/2019 03:00	1.6	12.8	1,967.9	1.2	7.90	1	1	1
11/10/2019 04:00	1.5	12.8	1,967.0	1.1	7.90	1	1	1
11/10/2019 05:00	1.5	12.8	1,964.1	1.1	7.90	1	1	1
11/10/2019 06:00	1.5	12.6	2,005.9	1.1	8.00	1	1	1
11/10/2019 07:00	1.5	12.6	1,982.3	1.1	7.90	1	1	1
11/10/2019 08:00	0.8	13.9	1,527.7	0.7	3.10	1	1	0
11/10/2019 09:00	0.7	13.9	1,493.6	0.6	3.00	1	1	0
11/10/2019 10:00	0.7	13.9	1,499.1	0.6	3.00	1	1	0
11/10/2019 11:00	0.8	13.9	1,541.4	0.7	3.10	1	1	0
11/10/2019 12:00	0.7	14.0	1,526.8	0.6	3.10	1	1	0
11/10/2019 13:00	0.8	13.9	1,610.3	0.7	3.20	1	1	0
11/10/2019 14:00	0.9	13.9	1,573.8	0.8	4.70	1	1	0
11/10/2019 15:00	0.9	13.8	1,513.5	0.7	4.50	1	1	1
11/10/2019 16:00	1.5	12.8	1,957.6	1.1	7.80	1	1	1
11/10/2019 17:00	1.6	12.5	1,995.9	1.1	8.00	1	1	1
11/10/2019 18:00	1.6	12.6	1,991.9	1.1	8.00	1	1	1
11/10/2019 19:00	1.6	12.5	2,010.5	1.1	8.00	1	1	1
11/10/2019 20:00	1.6	12.5	2,020.7	1.1	8.10	1	1	1
11/10/2019 21:00	1.6	12.4	2,058.5	1.1	8.20	1	1	1
11/10/2019 22:00	1.6	12.2	2,097.0	1.1	8.40	1	1	1
11/10/2019 23:00	1.6	12.4	2,039.4	1.1	8.20	1	1	1
Average/Sum#:	1.3	13.0	1,846.4	1.0	155.90 #	24 #	24 #	17 #
Minimum:	0.7	12.2	1,493.6	0.6	3.00	1	1	0
Maximum:	1.6	14.0	2,097.0	1.2	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/11/2019 00:00	1.6	12.5	2,028.0	1.1	8.10	1	1	1
11/11/2019 01:00	1.6	12.6	1,989.2	1.1	8.00	1	1	1
11/11/2019 02:00	1.6	12.6	2,012.6	1.1	8.10	1	1	1
11/11/2019 03:00	1.6	12.6	2,008.2	1.1	8.00	1	1	1
11/11/2019 04:00	1.6	12.7	1,977.9	1.2	7.90	1	1	1
11/11/2019 05:00	1.5	12.7	1,973.2	1.1	7.90	1	1	1
11/11/2019 06:00	1.6	12.7	1,998.4	1.2	8.00	1	1	1
11/11/2019 07:00	1.5	12.6	2,011.7	1.1	8.00	1	1	1
11/11/2019 08:00	1.5	13.1	1,867.2	1.1	7.50	1	1	1
11/11/2019 09:00	0.9	13.8	1,463.8	0.7	4.40	1	1	0
11/11/2019 10:00	0.8	13.9	1,483.1	0.7	3.00	1	1	0
11/11/2019 11:00	0.8	13.9	1,476.0	0.7	3.00	1	1	0
11/11/2019 12:00	0.7	13.9	1,464.3	0.6	2.90	1	1	0
11/11/2019 13:00	1.1	13.8	1,677.0	0.9	5.00	1	1	1
11/11/2019 14:00	1.4	12.8	1,901.8	1.0	7.60	1	1	1
11/11/2019 15:00	1.6	12.4	2,002.5	1.1	8.00	1	1	1
11/11/2019 16:00	1.6	12.4	1,999.4	1.1	8.00	1	1	1
11/11/2019 17:00	1.7	12.0	2,088.6	1.1	8.40	1	1	1
11/11/2019 18:00	1.7	12.1	2,075.0	1.1	8.30	1	1	1
11/11/2019 19:00	1.7	12.2	2,047.6	1.2	8.20	1	1	1
11/11/2019 20:00	1.6	12.3	2,051.4	1.1	8.20	1	1	1
11/11/2019 21:00	1.6	12.3	2,058.3	1.1	8.20	1	1	1
11/11/2019 22:00	1.6	12.3	2,056.3	1.1	8.20	1	1	1
11/11/2019 23:00	1.7	12.3	2,041.9	1.2	8.20	1	1	1
Average/Sum#:	1.4	12.8	1,906.4	1.0	171.10 #	24 #	24 #	20 #
Minimum:	0.7	12.0	1,463.8	0.6	2.90	1	1	0
Maximum:	1.7	13.9	2,088.6	1.2	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/12/2019 00:00	1.6	12.4	2,034.6	1.1	8.10	1	1	1
11/12/2019 01:00	1.6	12.4	2,039.0	1.1	8.20	1	1	1
11/12/2019 02:00	1.6	12.6	2,016.2	1.1	8.10	1	1	1
11/12/2019 03:00	1.6	12.4	2,056.8	1.1	8.20	1	1	1
11/12/2019 04:00	1.6	12.4	2,043.7	1.1	8.20	1	1	1
11/12/2019 05:00	1.6	12.5	2,022.9	1.1	8.10	1	1	1
11/12/2019 06:00	1.6	12.3	2,055.3	1.1	8.20	1	1	1
11/12/2019 07:00	1.6	12.5	2,024.9	1.1	8.10	1	1	1
11/12/2019 08:00	1.6	12.5	2,015.0	1.1	8.10	1	1	1
11/12/2019 09:00	1.6	12.5	2,001.4	1.1	8.00	1	1	1
11/12/2019 10:00	1.6	12.4	2,020.6	1.1	8.10	1	1	1
11/12/2019 11:00	1.6	12.5	1,981.4	1.1	7.90	1	1	1
11/12/2019 12:00	1.6	12.5	1,969.4	1.1	7.90	1	1	1
11/12/2019 13:00	1.6	12.5	1,994.7	1.1	8.00	1	1	1
11/12/2019 14:00	1.6	12.5	1,989.9	1.1	8.00	1	1	1
11/12/2019 15:00	1.6	12.5	1,992.0	1.1	8.00	1	1	1
11/12/2019 16:00	1.6	12.5	1,980.7	1.1	7.90	1	1	1
11/12/2019 17:00	1.6	12.3	2,041.0	1.1	8.20	1	1	1
11/12/2019 18:00	1.6	12.3	2,029.8	1.1	8.10	1	1	1
11/12/2019 19:00	1.7	12.2	2,062.3	1.2	8.20	1	1	1
11/12/2019 20:00	1.6	12.2	2,057.9	1.1	8.20	1	1	1
11/12/2019 21:00	1.6	12.3	2,040.2	1.1	8.20	1	1	1
11/12/2019 22:00	1.6	12.3	2,037.2	1.1	8.10	1	1	1
11/12/2019 23:00	1.6	12.4	2,020.7	1.1	8.10	1	1	1
Average/Sum#:	1.6	12.4	2,022.0	1.1	194.20 #	24 #	24 #	24 #
Minimum:	1.6	12.2	1,969.4	1.1	7.90	1	1	1
Maximum:	1.7	12.6	2,062.3	1.2	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/13/2019 00:00	1.6	12.5	2,026.4	1.1	8.10	1	1	1
11/13/2019 01:00	1.6	12.6	1,991.8	1.1	8.00	1	1	1
11/13/2019 02:00	1.6	12.6	1,987.6	1.1	8.00	1	1	1
11/13/2019 03:00	1.6	12.6	1,988.9	1.1	8.00	1	1	1
11/13/2019 04:00	1.6	12.5	2,009.8	1.1	8.00	1	1	1
11/13/2019 05:00	1.6	12.5	2,016.5	1.1	8.10	1	1	1
11/13/2019 06:00	1.4	12.4	2,040.0	1.0	8.20	1	1	1
11/13/2019 07:00	1.6	12.5	2,024.1	1.1	8.10	1	1	1
11/13/2019 08:00	1.6	12.6	2,004.8	1.1	8.00	1	1	1
11/13/2019 09:00	1.6	12.6	1,992.6	1.1	8.00	1	1	1
11/13/2019 10:00	1.5	12.6	1,976.3	1.1	7.90	1	1	1
11/13/2019 11:00	1.6	12.5	1,992.8	1.1	8.00	1	1	1
11/13/2019 12:00	1.6	12.5	1,992.9	1.1	8.00	1	1	1
11/13/2019 13:00	1.6	12.4	2,009.8	1.1	8.00	1	1	1
11/13/2019 14:00	1.6	12.4	2,020.0	1.1	8.10	1	1	1
11/13/2019 15:00	1.6	12.4	2,018.6	1.1	8.10	1	1	1
11/13/2019 16:00	1.6	12.5	1,991.6	1.1	8.00	1	1	1
11/13/2019 17:00	1.7	12.1	2,088.6	1.1	8.40	1	1	1
11/13/2019 18:00	1.6	12.3	2,041.8	1.1	8.20	1	1	1
11/13/2019 19:00	1.6	12.5	2,011.3	1.1	8.00	1	1	1
11/13/2019 20:00	1.6	12.3	2,037.9	1.1	8.20	1	1	1
11/13/2019 21:00	1.6	12.4	2,026.2	1.1	8.10	1	1	1
11/13/2019 22:00	1.6	12.5	2,002.5	1.1	8.00	1	1	1
11/13/2019 23:00	1.6	12.4	2,039.3	1.1	8.20	1	1	1
Average/Sum#:	1.6	12.5	2,013.8	1.1	193.70 #	24 #	24 #	24 #
Minimum:	1.4	12.1	1,976.3	1.0	7.90	1	1	1
Maximum:	1.7	12.6	2,088.6	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/14/2019 00:00	1.6	12.3	2,064.1	1.1	8.30	1	1	1
11/14/2019 01:00	1.7	12.3	2,075.7	1.2	8.30	1	1	1
11/14/2019 02:00	1.6	12.3	2,069.7	1.1	8.30	1	1	1
11/14/2019 03:00	1.6	12.3	2,078.8	1.1	8.30	1	1	1
11/14/2019 04:00	1.6	12.3	2,076.2	1.1	8.30	1	1	1
11/14/2019 05:00	1.6	12.4	2,052.5	1.1	8.20	1	1	1
11/14/2019 06:00	1.6	12.3	2,081.6	1.1	8.30	1	1	1
11/14/2019 07:00	1.6	12.4	2,039.1	1.1	8.20	1	1	1
11/14/2019 08:00	1.6	12.6	1,990.0	1.1	8.00	1	1	1
11/14/2019 09:00	1.6	12.4	2,032.7	1.1	8.10	1	1	1
11/14/2019 10:00	1.6	12.2	2,049.5	1.1	8.20	1	1	1
11/14/2019 11:00	1.6	12.4	2,008.2	1.1	8.00	1	1	1
11/14/2019 12:00	1.7	12.2	2,065.2	1.2	8.30	1	1	1
11/14/2019 13:00	1.6	12.2	2,061.1	1.1	8.20	1	1	1
11/14/2019 14:00	1.7	12.2	2,058.5	1.2	8.20	1	1	1
11/14/2019 15:00	1.7	12.2	2,053.1	1.2	8.20	1	1	1
11/14/2019 16:00	1.6	12.3	2,033.8	1.1	8.10	1	1	1
11/14/2019 17:00	1.7	12.3	2,055.8	1.2	8.20	1	1	1
11/14/2019 18:00	1.7	12.3	2,054.3	1.2	8.20	1	1	1
11/14/2019 19:00	1.7	12.3	2,049.6	1.2	8.20	1	1	1
11/14/2019 20:00	1.7	12.3	2,059.3	1.2	8.20	1	1	1
11/14/2019 21:00	1.6	12.4	2,050.1	1.1	8.20	1	1	1
11/14/2019 22:00	1.6	12.4	2,034.6	1.1	8.10	1	1	1
11/14/2019 23:00	1.6	12.4	2,058.2	1.1	8.20	1	1	1
Average/Sum#:	1.6	12.3	2,052.2	1.1	196.80 #	24 #	24 #	24 #
Minimum:	1.6	12.2	1,990.0	1.1	8.00	1	1	1
Maximum:	1.7	12.6	2,081.6	1.2	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/15/2019 00:00	1.6	12.5	2,025.4	1.1	8.10	1	1	1
11/15/2019 01:00	1.6	12.7	1,998.4	1.2	8.00	1	1	1
11/15/2019 02:00	1.6	12.6	2,013.0	1.1	8.10	1	1	1
11/15/2019 03:00	1.6	12.7	1,979.8	1.2	7.90	1	1	1
11/15/2019 04:00	1.6	12.7	1,984.6	1.2	7.90	1	1	1
11/15/2019 05:00	1.6	12.7	1,976.6	1.2	7.90	1	1	1
11/15/2019 06:00	1.3	12.4	2,037.1	0.9	6.10	1	1	1
11/15/2019 07:00	1.6	12.4	2,053.1	1.1	8.20	1	1	1
11/15/2019 08:00	1.6	12.6	2,003.6	1.1	8.00	1	1	1
11/15/2019 09:00	1.6	12.6	1,996.2	1.1	8.00	1	1	1
11/15/2019 10:00	1.6	12.5	2,005.8	1.1	8.00	1	1	1
11/15/2019 11:00	1.5	13.0	1,908.7	1.1	7.60	1	1	1
11/15/2019 12:00	1.6	12.6	1,983.9	1.1	7.90	1	1	1
11/15/2019 13:00	1.6	12.4	2,027.7	1.1	8.10	1	1	1
11/15/2019 14:00	1.6	12.3	2,046.3	1.1	8.20	1	1	1
11/15/2019 15:00	1.6	12.4	2,028.1	1.1	8.10	1	1	1
11/15/2019 16:00	1.6	12.5	2,008.2	1.1	8.00	1	1	1
11/15/2019 17:00	1.6	12.3	2,055.0	1.1	8.20	1	1	1
11/15/2019 18:00	1.6	12.6	1,978.0	1.1	7.90	1	1	1
11/15/2019 19:00	1.6	12.5	2,008.4	1.1	8.00	1	1	1
11/15/2019 20:00	1.6	12.3	2,056.7	1.1	8.20	1	1	1
11/15/2019 21:00	1.6	12.5	2,007.5	1.1	8.00	1	1	1
11/15/2019 22:00	1.6	12.4	2,014.8	1.1	8.10	1	1	1
11/15/2019 23:00	1.6	12.6	1,983.8	1.1	7.90	1	1	1
Average/Sum#:	1.6	12.5	2,007.5	1.1	190.40 #	24 #	24 #	24 #
Minimum:	1.3	12.3	1,908.7	0.9	6.10	1	1	1
Maximum:	1.6	13.0	2,056.7	1.2	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/16/2019 00:00	1.6	12.7	1,976.3	1.2	7.90	1	1	1
11/16/2019 01:00	1.6	12.8	1,974.9	1.2	7.90	1	1	1
11/16/2019 02:00	1.6	12.6	1,982.3	1.1	7.90	1	1	1
11/16/2019 03:00	1.5	12.6	1,979.7	1.1	7.90	1	1	1
11/16/2019 04:00	1.6	12.7	1,974.2	1.2	7.90	1	1	1
11/16/2019 05:00	1.6	12.7	1,982.6	1.2	7.90	1	1	1
11/16/2019 06:00	1.5	12.6	1,986.4	1.1	7.90	1	1	1
11/16/2019 07:00	1.5	12.7	1,939.9	1.1	7.80	1	1	1
11/16/2019 08:00	0.8	13.9	1,578.0	0.7	3.20	1	1	0
11/16/2019 09:00	0.7	13.9	1,478.3	0.6	3.00	1	1	0
11/16/2019 10:00	0.7	13.9	1,503.1	0.6	3.00	1	1	0
11/16/2019 11:00	0.8	13.9	1,592.5	0.7	3.20	1	1	0
11/16/2019 12:00	0.7	13.9	1,558.3	0.6	3.10	1	1	0
11/16/2019 13:00	0.9	13.9	1,635.9	0.8	4.90	1	1	0
11/16/2019 14:00	0.8	13.9	1,611.3	0.7	3.20	1	1	0
11/16/2019 15:00	0.9	13.8	1,512.4	0.7	4.50	1	1	1
11/16/2019 16:00	1.5	12.6	1,964.3	1.1	7.90	1	1	1
11/16/2019 17:00	1.6	12.4	2,021.7	1.1	8.10	1	1	1
11/16/2019 18:00	1.6	12.5	2,004.2	1.1	8.00	1	1	1
11/16/2019 19:00	1.6	12.5	2,013.5	1.1	8.10	1	1	1
11/16/2019 20:00	1.6	12.5	2,017.4	1.1	8.10	1	1	1
11/16/2019 21:00	1.6	12.4	2,030.3	1.1	8.10	1	1	1
11/16/2019 22:00	1.6	12.6	2,020.5	1.1	8.10	1	1	1
11/16/2019 23:00	1.6	12.6	2,011.7	1.1	8.00	1	1	1
Average/Sum#:	1.3	13.0	1,847.9	1.0	155.60 #	24 #	24 #	17 #
Minimum:	0.7	12.4	1,478.3	0.6	3.00	1	1	0
Maximum:	1.6	13.9	2,030.3	1.2	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/17/2019 00:00	1.6	12.7	1,997.7	1.2	8.00	1	1	1
11/17/2019 01:00	1.6	12.7	2,002.5	1.2	8.00	1	1	1
11/17/2019 02:00	1.4	13.1	1,865.3	1.1	7.50	1	1	1
11/17/2019 03:00	0.8	13.9	1,526.2	0.7	3.10	1	1	0
11/17/2019 04:00	0.8	13.8	1,634.1	0.7	3.30	1	1	0
11/17/2019 05:00	0.7	13.9	1,497.3	0.6	3.00	1	1	0
11/17/2019 06:00	0.8	13.8	1,637.4	0.7	3.30	1	1	0
11/17/2019 07:00	0.8	13.8	1,593.7	0.7	3.20	1	1	0
11/17/2019 08:00	0.8	13.8	1,597.1	0.7	3.20	1	1	0
11/17/2019 09:00	0.8	13.9	1,604.2	0.7	3.20	1	1	0
11/17/2019 10:00	0.8	13.9	1,577.2	0.7	3.20	1	1	0
11/17/2019 11:00	0.9	13.9	1,629.2	0.8	4.90	1	1	0
11/17/2019 12:00	0.8	13.9	1,566.0	0.7	3.10	1	1	0
11/17/2019 13:00	0.9	13.9	1,609.8	0.8	4.80	1	1	0
11/17/2019 14:00	0.8	13.9	1,491.5	0.7	3.00	1	1	1
11/17/2019 15:00	1.5	12.7	1,939.7	1.1	7.80	1	1	1
11/17/2019 16:00	1.6	12.5	1,993.3	1.1	8.00	1	1	1
11/17/2019 17:00	1.6	12.5	1,985.2	1.1	7.90	1	1	1
11/17/2019 18:00	1.6	12.4	2,001.4	1.1	8.00	1	1	1
11/17/2019 19:00	1.7	12.4	2,023.4	1.2	8.10	1	1	1
11/17/2019 20:00	1.7	12.4	2,028.2	1.2	8.10	1	1	1
11/17/2019 21:00	1.6	12.4	2,030.2	1.1	8.10	1	1	1
11/17/2019 22:00	1.6	12.5	1,999.3	1.1	8.00	1	1	1
11/17/2019 23:00	1.6	12.7	1,985.5	1.2	7.90	1	1	1
Average/Sum#:	1.2	13.2	1,784.0	0.9	136.70 #	24 #	24 #	13 #
Minimum:	0.7	12.4	1,491.5	0.6	3.00	1	1	0
Maximum:	1.7	13.9	2,030.2	1.2	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/18/2019 00:00	1.6	12.6	1,991.3	1.1	8.00	1	1	1
11/18/2019 01:00	1.6	12.6	1,995.8	1.1	8.00	1	1	1
11/18/2019 02:00	1.6	12.6	1,996.8	1.1	8.00	1	1	1
11/18/2019 03:00	1.6	12.6	1,996.3	1.1	8.00	1	1	1
11/18/2019 04:00	1.6	12.7	1,987.6	1.2	8.00	1	1	1
11/18/2019 05:00	1.6	12.6	1,990.3	1.1	8.00	1	1	1
11/18/2019 06:00	1.5	12.3	2,049.0	1.0	8.20	1	1	1
11/18/2019 07:00	1.6	12.4	2,027.8	1.1	8.10	1	1	1
11/18/2019 08:00	1.6	12.7	1,982.5	1.2	7.90	1	1	1
11/18/2019 09:00	1.5	12.9	1,928.9	1.1	7.70	1	1	1
11/18/2019 10:00	1.6	12.5	2,005.4	1.1	8.00	1	1	1
11/18/2019 11:00	1.7	12.2	2,058.8	1.2	8.20	1	1	1
11/18/2019 12:00	1.6	12.3	2,019.8	1.1	8.10	1	1	1
11/18/2019 13:00	1.6	12.2	2,036.1	1.1	8.10	1	1	1
11/18/2019 14:00	1.6	12.3	2,022.9	1.1	8.10	1	1	1
11/18/2019 15:00	1.6	12.3	2,021.2	1.1	8.10	1	1	1
11/18/2019 16:00	1.7	12.1	2,066.6	1.1	8.30	1	1	1
11/18/2019 17:00	1.7	12.1	2,053.9	1.1	8.20	1	1	1
11/18/2019 18:00	1.7	12.0	2,095.8	1.1	8.40	1	1	1
11/18/2019 19:00	1.7	12.1	2,069.3	1.1	8.30	1	1	1
11/18/2019 20:00	1.7	12.1	2,065.0	1.1	8.30	1	1	1
11/18/2019 21:00	1.7	12.2	2,032.2	1.2	8.10	1	1	1
11/18/2019 22:00	1.6	12.3	2,031.7	1.1	8.10	1	1	1
11/18/2019 23:00	1.6	12.3	2,028.6	1.1	8.10	1	1	1
Average/Sum#:	1.6	12.4	2,023.1	1.1	194.30 #	24 #	24 #	24 #
Minimum:	1.5	12.0	1,928.9	1.0	7.70	1	1	1
Maximum:	1.7	12.9	2,095.8	1.2	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/19/2019 00:00	1.6	12.4	2,022.4	1.1	8.10	1	1	1
11/19/2019 01:00	1.6	12.5	1,986.1	1.1	7.90	1	1	1
11/19/2019 02:00	1.6	12.5	1,982.5	1.1	7.90	1	1	1
11/19/2019 03:00	1.6	12.6	1,980.0	1.1	7.90	1	1	1
11/19/2019 04:00	1.6	12.5	1,987.7	1.1	8.00	1	1	1
11/19/2019 05:00	1.6	12.5	2,000.9	1.1	8.00	1	1	1
11/19/2019 06:00	1.5	12.5	1,984.6	1.1	7.90	1	1	1
11/19/2019 07:00	1.6	12.4	2,002.8	1.1	8.00	1	1	1
11/19/2019 08:00	1.7	12.2	2,057.5	1.2	8.20	1	1	1
11/19/2019 09:00	1.7	12.3	2,031.5	1.2	8.10	1	1	1
11/19/2019 10:00	1.7	12.2	2,061.1	1.2	8.20	1	1	1
11/19/2019 11:00	1.7	12.3	2,033.7	1.2	8.10	1	1	1
11/19/2019 12:00	0.0	0.0	2,006.3	0.0	0.00	1	1	1
11/19/2019 13:00	0.0	0.0	1,995.5	0.0	0.00	1	1	1
11/19/2019 14:00	1.5	12.4	2,018.7	1.0	8.10	1	1	1
11/19/2019 15:00	1.6	12.5	1,988.2	1.1	8.00	1	1	1
11/19/2019 16:00	1.6	12.6	1,989.9	1.1	8.00	1	1	1
11/19/2019 17:00	1.6	12.1	2,081.8	1.1	8.30	1	1	1
11/19/2019 18:00	1.6	12.0	2,115.9	1.1	8.50	1	1	1
11/19/2019 19:00	1.6	12.4	2,031.5	1.1	8.10	1	1	1
11/19/2019 20:00	1.6	12.5	2,008.6	1.1	8.00	1	1	1
11/19/2019 21:00	1.6	12.5	2,023.9	1.1	8.10	1	1	1
11/19/2019 22:00	1.6	12.4	2,031.1	1.1	8.10	1	1	1
11/19/2019 23:00	1.6	12.4	2,036.0	1.1	8.10	1	1	1
Average/Sum#:	1.6	12.4	2,019.1	1.1	177.60 #	24 #	24 #	24 #
Minimum:	1.5	12.0	1,980.0	1.0	7.90	1	1	1
Maximum:	1.7	12.6	2,115.9	1.2	8.50	1	1	1
%SI	8.33	8.33	0.00	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/20/2019 00:00	1.6	12.5	2,007.7	1.1	8.00	1	1	1
11/20/2019 01:00	1.6	12.6	1,990.5	1.1	8.00	1	1	1
11/20/2019 02:00	1.5	12.7	1,970.0	1.1	7.90	1	1	1
11/20/2019 03:00	1.5	12.7	1,974.5	1.1	7.90	1	1	1
11/20/2019 04:00	1.5	12.7	1,991.9	1.1	8.00	1	1	1
11/20/2019 05:00	1.6	12.7	1,997.6	1.2	8.00	1	1	1
11/20/2019 06:00	1.5	12.3	2,049.5	1.0	8.20	1	1	1
11/20/2019 07:00	1.6	12.3	2,070.6	1.1	8.30	1	1	1
11/20/2019 08:00	0.0	0.0	2,059.3	0.0	0.00	1	1	1
11/20/2019 09:00	0.0	0.0	2,067.0	0.0	0.00	1	1	1
11/20/2019 10:00	0.0	0.0	2,064.4	0.0	0.00	1	1	1
11/20/2019 11:00	0.0	0.0	2,026.1	0.0	0.00	1	1	1
11/20/2019 12:00	0.0	0.0	2,027.0	0.0	0.00	1	1	1
11/20/2019 13:00	1.2	12.2	2,033.4	0.8	6.10	1	1	1
11/20/2019 14:00	1.3	12.2	2,049.6	0.9	6.10	1	1	1
11/20/2019 15:00	1.4	12.0	2,077.1	0.9	6.20	1	1	1
11/20/2019 16:00	1.4	12.3	2,016.6	1.0	8.10	1	1	1
11/20/2019 17:00	1.7	11.9	2,081.5	1.1	8.30	1	1	1
11/20/2019 18:00	1.6	11.9	2,091.6	1.0	8.40	1	1	1
11/20/2019 19:00	1.7	11.9	2,098.5	1.1	8.40	1	1	1
11/20/2019 20:00	1.7	12.0	2,068.0	1.1	8.30	1	1	1
11/20/2019 21:00	1.7	12.1	2,048.2	1.1	8.20	1	1	1
11/20/2019 22:00	1.6	12.3	2,013.9	1.1	8.10	1	1	1
11/20/2019 23:00	1.6	12.4	2,000.4	1.1	8.00	1	1	1
Average/Sum#:	1.5	12.3	2,036.5	1.1	148.50 #	24 #	24 #	24 #
Minimum:	1.2	11.9	1,970.0	0.8	6.10	1	1	1
Maximum:	1.7	12.7	2,098.5	1.2	8.40	1	1	1
%SI	20.83	20.83	0.00	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2019 00:00	1.6	12.2	2,026.6	1.1	8.10	1	1	1
11/21/2019 01:00	1.6	12.2	2,032.3	1.1	8.10	1	1	1
11/21/2019 02:00	1.6	12.3	2,020.5	1.1	8.10	1	1	1
11/21/2019 03:00	1.6	12.2	2,058.3	1.1	8.20	1	1	1
11/21/2019 04:00	1.6	12.1	2,076.7	1.1	8.30	1	1	1
11/21/2019 05:00	1.6	12.1	2,079.8	1.1	8.30	1	1	1
11/21/2019 06:00	1.7	11.9	2,125.4	1.1	8.50	1	1	1
11/21/2019 07:00	1.7	11.9	2,131.4	1.1	8.50	1	1	1
11/21/2019 08:00	1.5	12.2	2,067.9	1.0	8.30	1	1	1
11/21/2019 09:00	1.3	12.5	1,989.9	0.9	6.00	1	1	1
11/21/2019 10:00	1.3	12.4	2,021.5	0.9	6.10	1	1	1
11/21/2019 11:00	1.2	12.5	1,982.4	0.8	5.90	1	1	1
11/21/2019 12:00	1.3	12.3	2,016.8	0.9	6.10	1	1	1
11/21/2019 13:00	1.2	12.4	2,000.7	0.8	6.00	1	1	1
11/21/2019 14:00	1.2	12.5	1,986.6	0.8	6.00	1	1	1
11/21/2019 15:00	1.2	12.4	2,010.6	0.8	6.00	1	1	1
11/21/2019 16:00	1.4	12.0	2,089.2	0.9	6.30	1	1	1
11/21/2019 17:00	1.5	11.9	2,118.6	1.0	8.50	1	1	1
11/21/2019 18:00	1.5	11.8	2,138.0	1.0	8.60	1	1	1
11/21/2019 19:00	1.6	11.8	2,136.3	1.0	8.50	1	1	1
11/21/2019 20:00	1.7	11.8	2,131.9	1.1	8.50	1	1	1
11/21/2019 21:00	1.7	11.9	2,130.6	1.1	8.50	1	1	1
11/21/2019 22:00	1.6	12.0	2,107.5	1.1	8.40	1	1	1
11/21/2019 23:00	1.6	12.1	2,075.7	1.1	8.30	1	1	1
Average/Sum#:	1.5	12.1	2,064.8	1.0	182.10 #	24 #	24 #	24 #
Minimum:	1.2	11.8	1,982.4	0.8	5.90	1	1	1
Maximum:	1.7	12.5	2,138.0	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2019 00:00	1.5	12.3	2,050.2	1.0	8.20	1	1	1
11/22/2019 01:00	1.5	12.3	2,047.5	1.0	8.20	1	1	1
11/22/2019 02:00	1.5	12.3	2,048.9	1.0	8.20	1	1	1
11/22/2019 03:00	1.5	12.3	2,045.4	1.0	8.20	1	1	1
11/22/2019 04:00	1.4	12.5	2,000.2	1.0	8.00	1	1	1
11/22/2019 05:00	1.3	12.6	1,978.8	0.9	5.90	1	1	1
11/22/2019 06:00	1.5	11.8	2,159.2	1.0	8.60	1	1	1
11/22/2019 07:00	1.7	11.9	2,140.6	1.1	8.60	1	1	1
11/22/2019 08:00	1.4	12.5	1,994.4	1.0	8.00	1	1	1
11/22/2019 09:00	1.3	12.7	1,969.3	0.9	5.90	1	1	1
11/22/2019 10:00	1.3	12.6	1,991.1	0.9	6.00	1	1	1
11/22/2019 11:00	1.3	12.6	1,967.4	0.9	5.90	1	1	1
11/22/2019 12:00	1.3	12.5	1,982.7	0.9	5.90	1	1	1
11/22/2019 13:00	1.3	12.5	1,976.9	0.9	5.90	1	1	1
11/22/2019 14:00	1.3	12.4	1,999.3	0.9	6.00	1	1	1
11/22/2019 15:00	1.3	12.4	2,002.4	0.9	6.00	1	1	1
11/22/2019 16:00	1.5	11.9	2,122.3	1.0	8.50	1	1	1
11/22/2019 17:00	1.4	11.9	2,121.6	0.9	6.40	1	1	1
11/22/2019 18:00	1.5	11.8	2,152.0	1.0	8.60	1	1	1
11/22/2019 19:00	1.5	11.9	2,123.5	1.0	8.50	1	1	1
11/22/2019 20:00	1.4	12.0	2,092.1	0.9	6.30	1	1	1
11/22/2019 21:00	1.7	11.9	2,111.6	1.1	8.40	1	1	1
11/22/2019 22:00	1.6	12.1	2,079.6	1.1	8.30	1	1	1
11/22/2019 23:00	1.5	12.3	2,042.0	1.0	8.20	1	1	1
Average/Sum#:	1.4	12.3	2,050.0	1.0	176.70 #	24 #	24 #	24 #
Minimum:	1.3	11.8	1,967.4	0.9	5.90	1	1	1
Maximum:	1.7	12.7	2,159.2	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/23/2019 00:00	1.6	12.3	2,034.6	1.1	8.10	1	1	1
11/23/2019 01:00	1.6	12.2	2,054.2	1.1	8.20	1	1	1
11/23/2019 02:00	1.4	12.4	2,044.4	1.0	8.20	1	1	1
11/23/2019 03:00	1.4	12.5	2,008.2	1.0	8.00	1	1	1
11/23/2019 04:00	1.5	12.3	2,054.0	1.0	8.20	1	1	1
11/23/2019 05:00	1.5	12.2	2,064.0	1.0	8.30	1	1	1
11/23/2019 06:00	1.6	12.1	2,074.8	1.1	8.30	1	1	1
11/23/2019 07:00	1.5	12.3	2,035.1	1.0	8.10	1	1	1
11/23/2019 08:00	0.9	12.9	1,872.3	0.7	3.70	1	1	1
11/23/2019 09:00	0.4	13.7	1,622.6	0.3	1.60	1	1	0
11/23/2019 10:00	0.4	13.7	1,643.2	0.3	1.60	1	1	0
11/23/2019 11:00	0.4	13.7	1,609.5	0.3	1.60	1	1	0
11/23/2019 12:00	0.4	13.7	1,625.7	0.3	1.60	1	1	0
11/23/2019 13:00	0.4	13.7	1,643.6	0.3	1.60	1	1	0
11/23/2019 14:00	0.4	13.7	1,615.4	0.3	1.60	1	1	0
11/23/2019 15:00	0.7	13.2	1,783.2	0.5	3.60	1	1	1
11/23/2019 16:00	1.3	12.2	2,049.5	0.9	6.10	1	1	1
11/23/2019 17:00	1.4	12.1	2,076.9	0.9	6.20	1	1	1
11/23/2019 18:00	1.4	12.1	2,074.6	0.9	6.20	1	1	1
11/23/2019 19:00	1.5	11.9	2,119.4	1.0	8.50	1	1	1
11/23/2019 20:00	1.4	12.0	2,112.1	0.9	6.30	1	1	1
11/23/2019 21:00	1.3	12.3	2,062.6	0.9	6.20	1	1	1
11/23/2019 22:00	1.3	12.4	2,027.2	0.9	6.10	1	1	1
11/23/2019 23:00	1.5	12.5	1,983.9	1.1	7.90	1	1	1
Average/Sum#:	1.1	12.7	1,928.8	0.8	135.80 #	24 #	24 #	18 #
Minimum:	0.4	11.9	1,609.5	0.3	1.60	1	1	0
Maximum:	1.6	13.7	2,119.4	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/24/2019 00:00	1.5	12.5	1,978.6	1.1	7.90	1	1	1
11/24/2019 01:00	1.4	12.5	1,977.4	1.0	7.90	1	1	1
11/24/2019 02:00	1.4	12.7	1,962.7	1.0	7.90	1	1	1
11/24/2019 03:00	1.4	12.7	1,963.0	1.0	7.90	1	1	1
11/24/2019 04:00	1.4	12.7	1,975.2	1.0	7.90	1	1	1
11/24/2019 05:00	1.4	12.7	1,972.3	1.0	7.90	1	1	1
11/24/2019 06:00	1.3	12.4	2,031.0	0.9	6.10	1	1	1
11/24/2019 07:00	1.2	12.5	1,974.0	0.8	5.90	1	1	1
11/24/2019 08:00	0.4	13.7	1,608.6	0.3	1.60	1	1	0
11/24/2019 09:00	0.3	13.7	1,601.0	0.2	1.60	1	1	0
11/24/2019 10:00	0.3	13.7	1,629.0	0.2	1.60	1	1	0
11/24/2019 11:00	0.4	13.7	1,622.2	0.3	1.60	1	1	0
11/24/2019 12:00	0.4	13.7	1,652.1	0.3	1.70	1	1	0
11/24/2019 13:00	0.4	13.7	1,633.4	0.3	1.60	1	1	0
11/24/2019 14:00	0.4	13.7	1,589.8	0.3	1.60	1	1	0
11/24/2019 15:00	0.7	13.2	1,784.6	0.5	3.60	1	1	1
11/24/2019 16:00	1.2	12.4	2,001.2	0.8	6.00	1	1	1
11/24/2019 17:00	1.3	12.2	2,057.6	0.9	6.20	1	1	1
11/24/2019 18:00	1.2	12.5	1,975.5	0.8	5.90	1	1	1
11/24/2019 19:00	1.1	12.8	1,927.3	0.8	5.80	1	1	1
11/24/2019 20:00	1.2	12.5	1,977.5	0.8	5.90	1	1	1
11/24/2019 21:00	1.5	12.3	2,021.5	1.0	8.10	1	1	1
11/24/2019 22:00	1.4	12.6	1,963.1	1.0	7.90	1	1	1
11/24/2019 23:00	0.8	13.2	1,764.4	0.6	3.50	1	1	1
Average/Sum#:	1.0	12.9	1,860.1	0.7	123.60 #	24 #	24 #	17 #
Minimum:	0.3	12.2	1,589.8	0.2	1.60	1	1	0
Maximum:	1.5	13.7	2,057.6	1.1	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/25/2019 00:00	0.2	13.7	1,304.8	0.2	1.30	1	1	0
11/25/2019 01:00	0.3	13.7	1,485.0	0.2	1.50	1	1	0
11/25/2019 02:00	0.2	13.7	1,316.9	0.2	1.30	1	1	0
11/25/2019 03:00	0.2	13.7	1,357.5	0.2	1.40	1	1	0
11/25/2019 04:00	0.5	13.6	1,649.2	0.4	1.60	1	1	0
11/25/2019 05:00	0.3	13.7	1,498.7	0.2	1.50	1	1	0
11/25/2019 06:00	0.1	13.7	1,335.5	0.1	0.00	1	1	0
11/25/2019 07:00	0.3	13.7	1,573.6	0.2	1.60	1	1	0
11/25/2019 08:00	0.4	13.7	1,619.0	0.3	1.60	1	1	0
11/25/2019 09:00	0.3	13.7	1,583.5	0.2	1.60	1	1	0
11/25/2019 10:00	0.4	13.7	1,606.2	0.3	1.60	1	1	0
11/25/2019 11:00	0.4	13.7	1,648.6	0.3	1.60	1	1	0
11/25/2019 12:00	0.4	13.7	1,639.2	0.3	1.60	1	1	0
11/25/2019 13:00	0.4	13.7	1,632.2	0.3	1.60	1	1	0
11/25/2019 14:00	0.4	13.7	1,624.4	0.3	1.60	1	1	0
11/25/2019 15:00	0.3	13.7	1,542.8	0.2	1.50	1	1	1
11/25/2019 16:00	1.1	12.6	1,979.9	0.8	5.90	1	1	1
11/25/2019 17:00	1.6	12.0	2,097.6	1.1	8.40	1	1	1
11/25/2019 18:00	1.5	12.4	2,016.7	1.0	8.10	1	1	1
11/25/2019 19:00	1.6	12.2	2,065.7	1.1	8.30	1	1	1
11/25/2019 20:00	1.6	12.2	2,069.5	1.1	8.30	1	1	1
11/25/2019 21:00	1.6	12.3	2,038.6	1.1	8.20	1	1	1
11/25/2019 22:00	1.5	12.5	2,008.3	1.1	8.00	1	1	1
11/25/2019 23:00	1.5	12.6	1,990.0	1.1	8.00	1	1	1
Average/Sum#:	0.7	13.2	1,695.1	0.5	86.10 #	24 #	24 #	9 #
Minimum:	0.1	12.0	1,304.8	0.1	0.00	1	1	0
Maximum:	1.6	13.7	2,097.6	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/26/2019 00:00	1.5	12.5	2,016.3	1.1	8.10	1	1	1
11/26/2019 01:00	1.5	12.4	2,036.2	1.0	8.10	1	1	1
11/26/2019 02:00	1.4	12.6	1,973.0	1.0	7.90	1	1	1
11/26/2019 03:00	1.4	12.6	1,971.7	1.0	7.90	1	1	1
11/26/2019 04:00	1.4	12.7	1,958.4	1.0	7.80	1	1	1
11/26/2019 05:00	1.1	12.9	1,909.7	0.8	5.70	1	1	1
11/26/2019 06:00	1.3	12.1	2,082.1	0.9	6.20	1	1	1
11/26/2019 07:00	1.2	12.7	1,878.7	0.9	5.60	1	1	1
11/26/2019 08:00	0.3	13.7	1,611.2	0.2	1.60	1	1	0
11/26/2019 09:00	0.4	13.7	1,636.2	0.3	1.60	1	1	0
11/26/2019 10:00	0.2	13.7	1,517.9	0.2	1.50	1	1	0
11/26/2019 11:00	0.3	13.7	1,574.2	0.2	1.60	1	1	0
11/26/2019 12:00	0.3	13.7	1,548.6	0.2	1.50	1	1	0
11/26/2019 13:00	0.3	13.6	1,583.8	0.2	1.60	1	1	0
11/26/2019 14:00	0.6	13.5	1,735.5	0.5	3.50	1	1	1
11/26/2019 15:00	0.7	13.5	1,761.0	0.6	3.50	1	1	0
11/26/2019 16:00	1.0	12.9	1,869.1	0.7	5.60	1	1	1
11/26/2019 17:00	1.3	12.3	2,024.0	0.9	6.10	1	1	1
11/26/2019 18:00	1.3	12.4	1,997.1	0.9	6.00	1	1	1
11/26/2019 19:00	1.3	12.4	2,012.3	0.9	6.00	1	1	1
11/26/2019 20:00	1.3	12.2	2,046.0	0.9	6.10	1	1	1
11/26/2019 21:00	1.3	12.2	2,018.5	0.9	6.10	1	1	1
11/26/2019 22:00	1.3	12.3	2,001.7	0.9	6.00	1	1	1
11/26/2019 23:00	1.3	12.3	2,011.4	0.9	6.00	1	1	1
Average/Sum#:	1.0	12.9	1,865.6	0.7	121.60 #	24 #	24 #	17 #
Minimum:	0.2	12.1	1,517.9	0.2	1.50	1	1	0
Maximum:	1.5	13.7	2,082.1	1.1	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/27/2019 00:00	1.3	12.2	2,019.8	0.9	6.10	1	1	1
11/27/2019 01:00	1.3	12.3	1,996.2	0.9	6.00	1	1	1
11/27/2019 02:00	1.2	12.5	1,962.6	0.8	5.90	1	1	1
11/27/2019 03:00	1.2	12.5	1,960.1	0.8	5.90	1	1	1
11/27/2019 04:00	1.3	12.5	1,969.8	0.9	5.90	1	1	1
11/27/2019 05:00	1.3	12.4	1,978.9	0.9	5.90	1	1	1
11/27/2019 06:00	1.2	12.7	1,933.2	0.9	5.80	1	1	1
11/27/2019 07:00	1.5	12.1	2,066.8	1.0	8.30	1	1	1
11/27/2019 08:00	1.5	12.1	2,059.9	1.0	8.20	1	1	1
11/27/2019 09:00	1.4	12.1	2,043.2	0.9	6.10	1	1	1
11/27/2019 10:00	1.5	12.2	2,030.0	1.0	8.10	1	1	1
11/27/2019 11:00	1.3	12.4	1,986.9	0.9	6.00	1	1	1
11/27/2019 12:00	1.4	12.2	2,011.8	0.9	6.00	1	1	1
11/27/2019 13:00	1.6	12.0	2,059.1	1.1	8.20	1	1	1
11/27/2019 14:00	1.5	12.0	2,050.1	1.0	8.20	1	1	1
11/27/2019 15:00	1.4	12.3	1,992.0	1.0	8.00	1	1	1
11/27/2019 16:00	1.4	12.5	1,963.7	1.0	7.90	1	1	1
11/27/2019 17:00	1.5	12.1	2,048.8	1.0	8.20	1	1	1
11/27/2019 18:00	1.3	12.8	1,901.0	0.9	5.70	1	1	1
11/27/2019 19:00	1.2	12.8	1,914.8	0.9	5.70	1	1	1
11/27/2019 20:00	1.5	12.1	2,084.1	1.0	8.30	1	1	1
11/27/2019 21:00	1.6	12.0	2,104.0	1.1	8.40	1	1	1
11/27/2019 22:00	1.4	12.2	2,053.0	0.9	6.20	1	1	1
11/27/2019 23:00	1.3	12.3	2,036.5	0.9	6.10	1	1	1
Average/Sum#:	1.4	12.3	2,009.4	0.9	165.10 #	24 #	24 #	24 #
Minimum:	1.2	12.0	1,901.0	0.8	5.70	1	1	1
Maximum:	1.6	12.8	2,104.0	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2019 00:00	1.3	12.3	2,038.9	0.9	6.10	1	1	1
11/28/2019 01:00	1.3	12.4	2,022.1	0.9	6.10	1	1	1
11/28/2019 02:00	1.3	12.5	2,008.9	0.9	6.00	1	1	1
11/28/2019 03:00	1.3	12.3	2,039.7	0.9	6.10	1	1	1
11/28/2019 04:00	1.2	12.5	2,012.2	0.8	6.00	1	1	1
11/28/2019 05:00	1.1	12.7	1,937.8	0.8	5.80	1	1	1
11/28/2019 06:00	1.4	12.1	2,050.0	0.9	6.20	1	1	1
11/28/2019 07:00	1.3	12.2	2,052.7	0.9	6.20	1	1	1
11/28/2019 08:00	1.4	12.2	2,052.8	0.9	6.20	1	1	1
11/28/2019 09:00	1.3	12.2	2,039.9	0.9	6.10	1	1	1
11/28/2019 10:00	1.4	12.2	2,040.4	0.9	6.10	1	1	1
11/28/2019 11:00	1.4	12.2	2,042.1	0.9	6.10	1	1	1
11/28/2019 12:00	1.4	12.2	2,038.5	0.9	6.10	1	1	1
11/28/2019 13:00	1.4	12.2	2,027.9	0.9	6.10	1	1	1
11/28/2019 14:00	1.4	12.2	2,021.9	0.9	6.10	1	1	1
11/28/2019 15:00	1.4	12.2	2,027.9	0.9	6.10	1	1	1
11/28/2019 16:00	1.4	12.3	2,012.3	1.0	8.00	1	1	1
11/28/2019 17:00	1.4	12.3	2,012.4	1.0	8.00	1	1	1
11/28/2019 18:00	1.2	12.6	1,953.4	0.9	5.90	1	1	1
11/28/2019 19:00	1.4	12.3	2,006.6	1.0	8.00	1	1	1
11/28/2019 20:00	1.4	12.2	2,021.1	0.9	6.10	1	1	1
11/28/2019 21:00	1.4	12.3	2,021.6	1.0	8.10	1	1	1
11/28/2019 22:00	1.5	12.2	2,018.6	1.0	8.10	1	1	1
11/28/2019 23:00	1.5	12.2	2,030.4	1.0	8.10	1	1	1
Average/Sum#:	1.4	12.3	2,022.1	0.9	157.70 #	24 #	24 #	24 #
Minimum:	1.1	12.1	1,937.8	0.8	5.80	1	1	1
Maximum:	1.5	12.7	2,052.8	1.0	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/29/2019 00:00	1.4	12.2	2,032.4	0.9	6.10	1	1	1
11/29/2019 01:00	1.4	12.3	2,020.3	1.0	8.10	1	1	1
11/29/2019 02:00	1.4	12.3	2,023.9	1.0	8.10	1	1	1
11/29/2019 03:00	1.4	12.3	2,019.4	1.0	8.10	1	1	1
11/29/2019 04:00	1.4	12.3	2,031.1	1.0	8.10	1	1	1
11/29/2019 05:00	1.4	12.4	2,013.8	1.0	8.10	1	1	1
11/29/2019 06:00	1.4	12.2	2,041.3	0.9	6.10	1	1	1
11/29/2019 07:00	1.2	12.4	1,963.0	0.8	5.90	1	1	1
11/29/2019 08:00	0.3	13.7	1,524.6	0.2	1.50	1	1	0
11/29/2019 09:00	0.2	13.7	1,406.3	0.2	1.40	1	1	0
11/29/2019 10:00	0.2	13.6	1,561.0	0.2	1.60	1	1	0
11/29/2019 11:00	0.2	13.6	1,564.8	0.2	1.60	1	1	0
11/29/2019 12:00	0.2	13.7	1,519.7	0.2	1.50	1	1	0
11/29/2019 13:00	0.2	13.7	1,517.4	0.2	1.50	1	1	0
11/29/2019 14:00	0.2	13.7	1,427.4	0.2	1.40	1	1	0
11/29/2019 15:00	0.3	13.6	1,546.9	0.2	1.50	1	1	1
11/29/2019 16:00	1.1	12.7	1,962.0	0.8	5.90	1	1	1
11/29/2019 17:00	1.6	12.0	2,122.2	1.1	8.50	1	1	1
11/29/2019 18:00	1.6	11.9	2,130.1	1.0	8.50	1	1	1
11/29/2019 19:00	1.6	12.0	2,114.4	1.1	8.50	1	1	1
11/29/2019 20:00	1.6	12.0	2,121.2	1.1	8.50	1	1	1
11/29/2019 21:00	1.4	12.3	2,040.7	1.0	8.20	1	1	1
11/29/2019 22:00	1.4	12.4	2,052.1	1.0	8.20	1	1	1
11/29/2019 23:00	1.4	12.4	2,046.1	1.0	8.20	1	1	1
Average/Sum#:	1.0	12.7	1,866.8	0.7	135.10 #	24 #	24 #	17 #
Minimum:	0.2	11.9	1,406.3	0.2	1.40	1	1	0
Maximum:	1.6	13.7	2,130.1	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/30/2019 00:00	1.4	12.4	2,040.5	1.0	8.20	1	1	1
11/30/2019 01:00	1.4	12.5	2,036.7	1.0	8.10	1	1	1
11/30/2019 02:00	1.4	12.4	2,046.9	1.0	8.20	1	1	1
11/30/2019 03:00	1.4	12.4	2,047.2	1.0	8.20	1	1	1
11/30/2019 04:00	1.3	12.4	2,035.1	0.9	6.10	1	1	1
11/30/2019 05:00	1.3	12.5	2,017.7	0.9	6.10	1	1	1
11/30/2019 06:00	1.3	12.4	2,048.1	0.9	6.10	1	1	1
11/30/2019 07:00	1.3	12.5	2,021.9	0.9	6.10	1	1	1
11/30/2019 08:00	1.3	12.4	2,040.7	0.9	6.10	1	1	1
11/30/2019 09:00	1.4	12.3	2,058.6	1.0	8.20	1	1	1
11/30/2019 10:00	1.3	12.4	2,034.8	0.9	6.10	1	1	1
11/30/2019 11:00	1.3	12.6	1,990.1	0.9	6.00	1	1	1
11/30/2019 12:00	1.5	12.3	2,048.5	1.0	8.20	1	1	1
11/30/2019 13:00	1.4	12.3	2,045.1	1.0	8.20	1	1	1
11/30/2019 14:00	1.4	12.3	2,046.3	1.0	8.20	1	1	1
11/30/2019 15:00	1.3	12.4	2,030.8	0.9	6.10	1	1	1
11/30/2019 16:00	1.3	12.4	2,029.2	0.9	6.10	1	1	1
11/30/2019 17:00	1.3	12.4	2,041.8	0.9	6.10	1	1	1
11/30/2019 18:00	1.3	12.5	2,019.4	0.9	6.10	1	1	1
11/30/2019 19:00	1.4	12.2	2,080.7	0.9	6.20	1	1	1
11/30/2019 20:00	1.3	12.3	2,049.5	0.9	6.10	1	1	1
11/30/2019 21:00	1.3	12.4	2,031.5	0.9	6.10	1	1	1
11/30/2019 22:00	1.3	12.6	1,992.3	0.9	6.00	1	1	1
11/30/2019 23:00	1.3	12.7	1,977.5	0.9	5.90	1	1	1
Average/Sum#:	1.3	12.4	2,033.8	0.9	162.80 #	24 #	24 #	24 #
Minimum:	1.3	12.2	1,977.5	0.9	5.90	1	1	1
Maximum:	1.5	12.7	2,080.7	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/01/2019 00:00	1.3	12.5	2,016.3	0.9	6.00	1	1	1
12/01/2019 01:00	1.3	12.7	1,976.4	0.9	5.90	1	1	1
12/01/2019 02:00	1.3	12.7	1,975.5	0.9	5.90	1	1	1
12/01/2019 03:00	1.3	12.7	1,975.5	0.9	5.90	1	1	1
12/01/2019 04:00	1.3	12.7	1,972.0	0.9	5.90	1	1	1
12/01/2019 05:00	1.3	12.7	1,972.7	0.9	5.90	1	1	1
12/01/2019 06:00	1.2	12.7	1,966.1	0.9	5.90	1	1	1
12/01/2019 07:00	1.2	12.7	1,972.7	0.9	5.90	1	1	1
12/01/2019 08:00	1.3	12.4	2,047.7	0.9	6.10	1	1	1
12/01/2019 09:00	1.3	12.4	2,045.3	0.9	6.10	1	1	1
12/01/2019 10:00	1.3	12.3	2,051.7	0.9	6.20	1	1	1
12/01/2019 11:00	1.3	12.4	2,035.6	0.9	6.10	1	1	1
12/01/2019 12:00	1.2	12.6	1,974.9	0.9	5.90	1	1	1
12/01/2019 13:00	1.3	12.5	1,995.0	0.9	6.00	1	1	1
12/01/2019 14:00	1.3	12.6	1,985.4	0.9	6.00	1	1	1
12/01/2019 15:00	1.3	12.5	1,993.2	0.9	6.00	1	1	1
12/01/2019 16:00	1.3	12.5	1,994.8	0.9	6.00	1	1	1
12/01/2019 17:00	1.3	12.3	2,038.8	0.9	6.10	1	1	1
12/01/2019 18:00	1.4	12.1	2,083.3	0.9	6.20	1	1	1
12/01/2019 19:00	1.4	12.0	2,107.4	0.9	6.30	1	1	1
12/01/2019 20:00	1.4	12.1	2,074.2	0.9	6.20	1	1	1
12/01/2019 21:00	1.3	12.4	2,015.4	0.9	6.00	1	1	1
12/01/2019 22:00	1.3	12.5	1,989.9	0.9	6.00	1	1	1
12/01/2019 23:00	1.3	12.5	1,983.1	0.9	5.90	1	1	1
Average/Sum#:	1.3	12.5	2,010.1	0.9	144.40 #	24 #	24 #	24 #
Minimum:	1.2	12.0	1,966.1	0.9	5.90	1	1	1
Maximum:	1.4	12.7	2,107.4	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/02/2019 00:00	1.3	12.6	1,970.3	0.9	5.90	1	1	1
12/02/2019 01:00	1.3	12.6	1,972.6	0.9	5.90	1	1	1
12/02/2019 02:00	1.3	12.6	1,973.4	0.9	5.90	1	1	1
12/02/2019 03:00	1.3	12.6	1,969.1	0.9	5.90	1	1	1
12/02/2019 04:00	1.3	12.6	1,965.0	0.9	5.90	1	1	1
12/02/2019 05:00	1.3	12.6	1,968.2	0.9	5.90	1	1	1
12/02/2019 06:00	1.6	12.0	2,062.3	1.1	8.20	1	1	1
12/02/2019 07:00	1.4	11.9	2,110.4	0.9	6.30	1	1	1
12/02/2019 08:00	1.3	12.4	2,004.4	0.9	6.00	1	1	1
12/02/2019 09:00	1.3	12.6	1,968.2	0.9	5.90	1	1	1
12/02/2019 10:00	1.3	12.5	1,987.2	0.9	6.00	1	1	1
12/02/2019 11:00	1.2	12.5	1,981.7	0.8	5.90	1	1	1
12/02/2019 12:00	1.3	12.3	2,038.9	0.9	6.10	1	1	1
12/02/2019 13:00	1.2	12.4	2,003.8	0.8	6.00	1	1	1
12/02/2019 14:00	1.3	12.2	2,048.6	0.9	6.10	1	1	1
12/02/2019 15:00	1.3	12.2	2,033.3	0.9	6.10	1	1	1
12/02/2019 16:00	1.3	12.0	2,076.7	0.9	6.20	1	1	1
12/02/2019 17:00	1.4	11.9	2,116.6	0.9	6.30	1	1	1
12/02/2019 18:00	1.4	11.8	2,122.2	0.9	6.40	1	1	1
12/02/2019 19:00	1.4	11.8	2,122.9	0.9	6.40	1	1	1
12/02/2019 20:00	1.4	11.8	2,121.1	0.9	6.40	1	1	1
12/02/2019 21:00	1.4	11.9	2,104.6	0.9	6.30	1	1	1
12/02/2019 22:00	1.3	12.3	2,029.3	0.9	6.10	1	1	1
12/02/2019 23:00	1.3	12.3	2,018.3	0.9	6.10	1	1	1
Average/Sum#:	1.3	12.3	2,032.0	0.9	148.20 #	24 #	24 #	24 #
Minimum:	1.2	11.8	1,965.0	0.8	5.90	1	1	1
Maximum:	1.6	12.6	2,122.9	1.1	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/03/2019 00:00	1.3	12.3	2,025.1	0.9	6.10	1	1	1
12/03/2019 01:00	1.3	12.5	1,981.0	0.9	5.90	1	1	1
12/03/2019 02:00	1.3	12.5	1,975.1	0.9	5.90	1	1	1
12/03/2019 03:00	1.3	12.4	1,980.6	0.9	5.90	1	1	1
12/03/2019 04:00	1.3	12.3	2,001.9	0.9	6.00	1	1	1
12/03/2019 05:00	1.3	12.3	2,009.2	0.9	6.00	1	1	1
12/03/2019 06:00	1.4	12.1	2,033.8	0.9	6.10	1	1	1
12/03/2019 07:00	1.4	12.0	2,076.0	0.9	6.20	1	1	1
12/03/2019 08:00	1.4	12.0	2,068.1	0.9	6.20	1	1	1
12/03/2019 09:00	1.4	12.1	2,040.2	0.9	6.10	1	1	1
12/03/2019 10:00	1.3	12.3	1,993.7	0.9	6.00	1	1	1
12/03/2019 11:00	1.5	12.0	2,042.8	1.0	8.20	1	1	1
12/03/2019 12:00	1.6	11.9	2,069.1	1.0	8.30	1	1	1
12/03/2019 13:00	1.7	11.8	2,084.2	1.1	8.30	1	1	1
12/03/2019 14:00	1.7	11.8	2,079.5	1.1	8.30	1	1	1
12/03/2019 15:00	1.7	11.8	2,071.4	1.1	8.30	1	1	1
12/03/2019 16:00	1.5	12.0	2,050.1	1.0	8.20	1	1	1
12/03/2019 17:00	1.2	11.9	2,070.8	0.8	6.20	1	1	1
12/03/2019 18:00	1.2	12.0	2,067.0	0.8	6.20	1	1	1
12/03/2019 19:00	1.5	11.8	2,100.9	1.0	8.40	1	1	1
12/03/2019 20:00	1.5	11.8	2,093.2	1.0	8.40	1	1	1
12/03/2019 21:00	1.4	11.9	2,084.5	0.9	6.30	1	1	1
12/03/2019 22:00	1.3	12.1	2,037.3	0.9	6.10	1	1	1
12/03/2019 23:00	1.3	12.2	2,021.2	0.9	6.10	1	1	1
Average/Sum#:	1.4	12.1	2,044.0	0.9	163.70 #	24 #	24 #	24 #
Minimum:	1.2	11.8	1,975.1	0.8	5.90	1	1	1
Maximum:	1.7	12.5	2,100.9	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/04/2019 00:00	1.4	12.1	2,057.8	0.9	6.20	1	1	1
12/04/2019 01:00	1.4	12.2	2,039.3	0.9	6.10	1	1	1
12/04/2019 02:00	1.3	12.3	1,998.7	0.9	6.00	1	1	1
12/04/2019 03:00	1.3	12.3	2,007.1	0.9	6.00	1	1	1
12/04/2019 04:00	1.3	12.2	2,038.2	0.9	6.10	1	1	1
12/04/2019 05:00	1.2	12.4	1,991.7	0.8	6.00	1	1	1
12/04/2019 06:00	1.5	12.1	2,037.3	1.0	8.10	1	1	1
12/04/2019 07:00	1.3	12.0	2,079.0	0.9	6.20	1	1	1
12/04/2019 08:00	1.4	12.0	2,072.6	0.9	6.20	1	1	1
12/04/2019 09:00	1.3	12.0	2,075.4	0.9	6.20	1	1	1
12/04/2019 10:00	1.3	12.1	2,062.2	0.9	6.20	1	1	1
12/04/2019 11:00	1.4	11.9	2,095.5	0.9	6.30	1	1	1
12/04/2019 12:00	1.4	12.0	2,068.7	0.9	6.20	1	1	1
12/04/2019 13:00	1.3	12.1	2,043.9	0.9	6.10	1	1	1
12/04/2019 14:00	1.4	11.9	2,098.0	0.9	6.30	1	1	1
12/04/2019 15:00	1.4	12.0	2,070.8	0.9	6.20	1	1	1
12/04/2019 16:00	1.4	12.0	2,069.7	0.9	6.20	1	1	1
12/04/2019 17:00	1.3	12.1	2,049.6	0.9	6.10	1	1	1
12/04/2019 18:00	1.4	11.9	2,103.9	0.9	6.30	1	1	1
12/04/2019 19:00	1.4	11.9	2,102.3	0.9	6.30	1	1	1
12/04/2019 20:00	1.4	11.8	2,105.4	0.9	6.30	1	1	1
12/04/2019 21:00	1.4	11.9	2,096.4	0.9	6.30	1	1	1
12/04/2019 22:00	1.3	12.0	2,070.4	0.9	6.20	1	1	1
12/04/2019 23:00	1.3	12.2	2,034.4	0.9	6.10	1	1	1
Average/Sum#:	1.4	12.1	2,061.2	0.9	150.20 #	24 #	24 #	24 #
Minimum:	1.2	11.8	1,991.7	0.8	6.00	1	1	1
Maximum:	1.5	12.4	2,105.4	1.0	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/05/2019 00:00	1.3	12.1	2,047.9	0.9	6.10	1	1	1
12/05/2019 01:00	1.3	12.1	2,050.8	0.9	6.20	1	1	1
12/05/2019 02:00	1.3	12.2	2,046.3	0.9	6.10	1	1	1
12/05/2019 03:00	1.3	12.2	2,046.8	0.9	6.10	1	1	1
12/05/2019 04:00	1.3	12.3	2,019.9	0.9	6.10	1	1	1
12/05/2019 05:00	1.3	12.3	2,009.1	0.9	6.00	1	1	1
12/05/2019 06:00	1.2	12.2	2,039.4	0.8	6.10	1	1	1
12/05/2019 07:00	1.2	12.3	2,014.0	0.8	6.00	1	1	1
12/05/2019 08:00	1.2	12.5	1,968.7	0.8	5.90	1	1	1
12/05/2019 09:00	1.3	12.4	1,980.4	0.9	5.90	1	1	1
12/05/2019 10:00	1.3	12.4	2,032.8	0.9	6.10	1	1	1
12/05/2019 11:00	1.3	12.4	2,037.0	0.9	6.10	1	1	1
12/05/2019 12:00	1.3	12.4	2,047.7	0.9	6.10	1	1	1
12/05/2019 13:00	1.3	12.4	2,044.3	0.9	6.10	1	1	1
12/05/2019 14:00	1.3	12.4	2,038.3	0.9	6.10	1	1	1
12/05/2019 15:00	1.3	12.4	2,040.1	0.9	6.10	1	1	1
12/05/2019 16:00	1.0	12.4	2,036.9	0.7	6.10	1	1	1
12/05/2019 17:00	0.8	12.4	2,030.5	0.6	4.10	1	1	1
12/05/2019 18:00	0.7	12.4	2,034.9	0.5	4.10	1	1	1
12/05/2019 19:00	0.7	12.4	2,038.0	0.5	4.10	1	1	1
12/05/2019 20:00	0.8	12.3	2,046.8	0.5	4.10	1	1	1
12/05/2019 21:00	0.7	12.4	2,041.3	0.5	4.10	1	1	1
12/05/2019 22:00	0.8	12.4	2,030.8	0.6	4.10	1	1	1
12/05/2019 23:00	0.9	12.5	2,022.2	0.6	4.00	1	1	1
Average/Sum#:	1.1	12.3	2,031.0	0.8	131.80 #	24 #	24 #	24 #
Minimum:	0.7	12.1	1,968.7	0.5	4.00	1	1	1
Maximum:	1.3	12.5	2,050.8	0.9	6.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/06/2019 00:00	1.0	12.5	2,018.3	0.7	6.10	1	1	1
12/06/2019 01:00	1.1	12.5	2,009.8	0.8	6.00	1	1	1
12/06/2019 02:00	1.0	12.5	2,003.4	0.7	6.00	1	1	1
12/06/2019 03:00	1.1	12.5	2,021.2	0.8	6.10	1	1	1
12/06/2019 04:00	1.3	12.4	2,044.9	0.9	6.10	1	1	1
12/06/2019 05:00	1.3	12.4	2,041.5	0.9	6.10	1	1	1
12/06/2019 06:00	1.5	12.3	2,061.6	1.0	8.20	1	1	1
12/06/2019 07:00	1.2	12.3	2,055.8	0.8	6.20	1	1	1
12/06/2019 08:00	1.2	12.4	2,039.6	0.8	6.10	1	1	1
12/06/2019 09:00	1.3	12.4	2,032.1	0.9	6.10	1	1	1
12/06/2019 10:00	1.3	12.4	2,035.8	0.9	6.10	1	1	1
12/06/2019 11:00	1.1	12.4	2,020.2	0.8	6.10	1	1	1
12/06/2019 12:00	1.0	12.5	2,003.5	0.7	6.00	1	1	1
12/06/2019 13:00	0.8	12.5	1,987.9	0.6	4.00	1	1	1
12/06/2019 14:00	0.8	12.6	1,975.4	0.6	4.00	1	1	1
12/06/2019 15:00	0.8	12.6	1,974.0	0.6	3.90	1	1	1
12/06/2019 16:00	0.7	12.6	1,975.7	0.5	4.00	1	1	1
12/06/2019 17:00	0.7	12.6	1,974.1	0.5	3.90	1	1	1
12/06/2019 18:00	0.6	12.6	1,974.2	0.4	3.90	1	1	1
12/06/2019 19:00	0.6	12.6	1,973.5	0.4	3.90	1	1	1
12/06/2019 20:00	0.6	12.6	1,974.5	0.4	3.90	1	1	1
12/06/2019 21:00	0.5	12.7	1,949.6	0.4	1.90	1	1	1
12/06/2019 22:00	0.3	13.1	1,867.6	0.2	1.90	1	1	1
12/06/2019 23:00	0.3	13.2	1,853.6	0.2	1.90	1	1	1
Average/Sum#:	0.9	12.6	1,994.5	0.6	118.40 #	24 #	24 #	24 #
Minimum:	0.3	12.3	1,853.6	0.2	1.90	1	1	1
Maximum:	1.5	13.2	2,061.6	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/07/2019 00:00	0.4	12.9	1,911.3	0.3	1.90	1	1	1
12/07/2019 01:00	1.2	12.2	2,073.4	0.8	6.20	1	1	1
12/07/2019 02:00	1.3	12.3	2,048.3	0.9	6.10	1	1	1
12/07/2019 03:00	1.3	12.3	2,049.9	0.9	6.10	1	1	1
12/07/2019 04:00	1.3	12.3	2,050.6	0.9	6.20	1	1	1
12/07/2019 05:00	1.3	12.3	2,043.9	0.9	6.10	1	1	1
12/07/2019 06:00	1.4	12.3	2,047.8	1.0	8.20	1	1	1
12/07/2019 07:00	1.2	12.2	2,052.8	0.8	6.20	1	1	1
12/07/2019 08:00	1.3	12.1	2,077.9	0.9	6.20	1	1	1
12/07/2019 09:00	1.4	12.1	2,075.5	0.9	6.20	1	1	1
12/07/2019 10:00	1.4	12.2	2,056.3	0.9	6.20	1	1	1
12/07/2019 11:00	1.4	12.1	2,062.2	0.9	6.20	1	1	1
12/07/2019 12:00	1.4	12.1	2,063.2	0.9	6.20	1	1	1
12/07/2019 13:00	1.3	12.2	2,061.5	0.9	6.20	1	1	1
12/07/2019 14:00	1.4	12.2	2,062.7	0.9	6.20	1	1	1
12/07/2019 15:00	1.4	12.2	2,046.7	0.9	6.10	1	1	1
12/07/2019 16:00	1.4	12.2	2,055.2	0.9	6.20	1	1	1
12/07/2019 17:00	1.4	12.2	2,055.5	0.9	6.20	1	1	1
12/07/2019 18:00	1.5	12.0	2,103.1	1.0	8.40	1	1	1
12/07/2019 19:00	1.5	12.1	2,093.6	1.0	8.40	1	1	1
12/07/2019 20:00	1.5	12.0	2,097.4	1.0	8.40	1	1	1
12/07/2019 21:00	1.4	12.1	2,096.5	0.9	6.30	1	1	1
12/07/2019 22:00	1.4	12.2	2,074.8	0.9	6.20	1	1	1
12/07/2019 23:00	1.4	12.2	2,070.2	0.9	6.20	1	1	1
Average/Sum#:	1.3	12.2	2,059.6	0.9	152.80 #	24 #	24 #	24 #
Minimum:	0.4	12.0	1,911.3	0.3	1.90	1	1	1
Maximum:	1.5	12.9	2,103.1	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/08/2019 00:00	1.4	12.1	2,080.6	0.9	6.20	1	1	1
12/08/2019 01:00	1.2	12.6	1,938.3	0.9	5.80	1	1	1
12/08/2019 02:00	0.4	13.6	1,607.0	0.3	1.60	1	1	0
12/08/2019 03:00	0.2	13.6	1,470.4	0.2	1.50	1	1	0
12/08/2019 04:00	0.3	13.6	1,606.7	0.2	1.60	1	1	0
12/08/2019 05:00	0.4	13.6	1,674.8	0.3	1.70	1	1	0
12/08/2019 06:00	0.4	13.6	1,686.3	0.3	1.70	1	1	0
12/08/2019 07:00	0.4	13.6	1,667.1	0.3	1.70	1	1	0
12/08/2019 08:00	0.4	13.6	1,648.6	0.3	1.60	1	1	0
12/08/2019 09:00	0.4	13.6	1,651.1	0.3	1.70	1	1	0
12/08/2019 10:00	0.3	13.6	1,506.9	0.2	1.50	1	1	0
12/08/2019 11:00	0.3	13.6	1,595.1	0.2	1.60	1	1	0
12/08/2019 12:00	0.3	13.6	1,512.1	0.2	1.50	1	1	0
12/08/2019 13:00	0.4	13.6	1,659.8	0.3	1.70	1	1	0
12/08/2019 14:00	0.5	13.5	1,663.0	0.4	1.70	1	1	1
12/08/2019 15:00	0.9	12.8	1,886.7	0.7	3.80	1	1	1
12/08/2019 16:00	1.4	12.4	2,033.6	1.0	8.10	1	1	1
12/08/2019 17:00	1.4	12.4	2,028.5	1.0	8.10	1	1	1
12/08/2019 18:00	1.5	12.3	2,071.4	1.0	8.30	1	1	1
12/08/2019 19:00	1.5	12.2	2,083.6	1.0	8.30	1	1	1
12/08/2019 20:00	1.5	12.2	2,087.5	1.0	8.40	1	1	1
12/08/2019 21:00	1.4	12.4	2,048.4	1.0	8.20	1	1	1
12/08/2019 22:00	1.5	12.2	2,081.5	1.0	8.30	1	1	1
12/08/2019 23:00	1.5	12.2	2,091.9	1.0	8.40	1	1	1
Average/Sum#:	0.8	13.0	1,807.5	0.6	103.00 #	24 #	24 #	12 #
Minimum:	0.2	12.1	1,470.4	0.2	1.50	1	1	0
Maximum:	1.5	13.6	2,091.9	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2019 00:00	1.5	12.3	2,068.6	1.0	8.30	1	1	1
12/09/2019 01:00	1.4	12.5	2,029.9	1.0	8.10	1	1	1
12/09/2019 02:00	1.4	12.6	2,013.3	1.0	8.10	1	1	1
12/09/2019 03:00	1.4	12.5	2,019.1	1.0	8.10	1	1	1
12/09/2019 04:00	1.5	12.4	2,060.4	1.0	8.20	1	1	1
12/09/2019 05:00	1.4	12.4	2,052.2	1.0	8.20	1	1	1
12/09/2019 06:00	1.4	12.4	2,057.8	1.0	8.20	1	1	1
12/09/2019 07:00	1.4	12.3	2,088.0	1.0	8.40	1	1	1
12/09/2019 08:00	1.4	12.3	2,082.8	1.0	8.30	1	1	1
12/09/2019 09:00	1.4	12.3	2,077.4	1.0	8.30	1	1	1
12/09/2019 10:00	1.4	12.5	2,030.7	1.0	8.10	1	1	1
12/09/2019 11:00	1.4	12.5	2,025.8	1.0	8.10	1	1	1
12/09/2019 12:00	1.4	12.5	2,020.3	1.0	8.10	1	1	1
12/09/2019 13:00	1.5	12.5	2,028.2	1.1	8.10	1	1	1
12/09/2019 14:00	1.5	12.5	2,015.6	1.1	8.10	1	1	1
12/09/2019 15:00	1.5	12.3	2,048.5	1.0	8.20	1	1	1
12/09/2019 16:00	1.4	12.4	2,041.3	1.0	8.20	1	1	1
12/09/2019 17:00	1.5	12.2	2,090.0	1.0	8.40	1	1	1
12/09/2019 18:00	1.5	12.0	2,146.0	1.0	8.60	1	1	1
12/09/2019 19:00	1.5	11.9	2,159.4	1.0	8.60	1	1	1
12/09/2019 20:00	1.5	12.0	2,160.4	1.0	8.60	1	1	1
12/09/2019 21:00	1.4	12.2	2,100.0	0.9	6.30	1	1	1
12/09/2019 22:00	1.4	12.3	2,094.8	1.0	8.40	1	1	1
12/09/2019 23:00	1.4	12.4	2,086.2	1.0	8.30	1	1	1
Average/Sum#:	1.4	12.3	2,066.5	1.0	196.30 #	24 #	24 #	24 #
Minimum:	1.4	11.9	2,013.3	0.9	6.30	1	1	1
Maximum:	1.5	12.6	2,160.4	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/10/2019 00:00	1.4	12.3	2,112.2	1.0	8.40	1	1	1
12/10/2019 01:00	1.4	12.3	2,109.1	1.0	8.40	1	1	1
12/10/2019 02:00	1.4	12.3	2,103.9	1.0	8.40	1	1	1
12/10/2019 03:00	1.4	12.3	2,114.9	1.0	8.50	1	1	1
12/10/2019 04:00	1.4	12.2	2,122.1	0.9	6.40	1	1	1
12/10/2019 05:00	1.4	12.4	2,103.2	1.0	8.40	1	1	1
12/10/2019 06:00	1.4	12.3	2,114.7	1.0	8.50	1	1	1
12/10/2019 07:00	1.4	12.2	2,139.7	0.9	6.40	1	1	1
12/10/2019 08:00	1.4	12.5	2,080.0	1.0	8.30	1	1	1
12/10/2019 09:00	1.4	12.3	2,107.8	1.0	8.40	1	1	1
12/10/2019 10:00	1.3	12.6	2,048.7	0.9	6.10	1	1	1
12/10/2019 11:00	1.3	12.6	2,039.8	0.9	6.10	1	1	1
12/10/2019 12:00	1.4	12.5	2,054.4	1.0	8.20	1	1	1
12/10/2019 13:00	1.4	12.5	2,051.4	1.0	8.20	1	1	1
12/10/2019 14:00	1.4	12.4	2,057.1	1.0	8.20	1	1	1
12/10/2019 15:00	1.3	12.5	2,045.6	0.9	6.10	1	1	1
12/10/2019 16:00	1.4	12.4	2,061.8	1.0	8.20	1	1	1
12/10/2019 17:00	1.5	12.1	2,128.5	1.0	8.50	1	1	1
12/10/2019 18:00	1.5	12.0	2,149.1	1.0	8.60	1	1	1
12/10/2019 19:00	1.4	12.0	2,151.7	0.9	6.50	1	1	1
12/10/2019 20:00	1.4	12.0	2,152.8	0.9	6.50	1	1	1
12/10/2019 21:00	1.4	12.2	2,117.9	0.9	6.40	1	1	1
12/10/2019 22:00	1.3	12.4	2,079.0	0.9	6.20	1	1	1
12/10/2019 23:00	1.3	12.4	2,074.2	0.9	6.20	1	1	1
Average/Sum#:	1.4	12.3	2,096.7	1.0	180.10 #	24 #	24 #	24 #
Minimum:	1.3	12.0	2,039.8	0.9	6.10	1	1	1
Maximum:	1.5	12.6	2,152.8	1.0	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/11/2019 00:00	1.4	12.3	2,100.1	1.0	8.40	1	1	1
12/11/2019 01:00	1.3	12.3	2,096.8	0.9	6.30	1	1	1
12/11/2019 02:00	1.3	12.4	2,071.1	0.9	6.20	1	1	1
12/11/2019 03:00	1.3	12.6	2,022.2	0.9	6.10	1	1	1
12/11/2019 04:00	1.3	12.5	2,045.5	0.9	6.10	1	1	1
12/11/2019 05:00	1.3	12.4	2,065.7	0.9	6.20	1	1	1
12/11/2019 06:00	1.5	12.1	2,100.7	1.0	8.40	1	1	1
12/11/2019 07:00	1.3	12.3	2,093.9	0.9	6.30	1	1	1
12/11/2019 08:00	1.3	12.4	2,063.9	0.9	6.20	1	1	1
12/11/2019 09:00	1.3	12.5	2,034.7	0.9	6.10	1	1	1
12/11/2019 10:00	1.3	12.5	2,047.1	0.9	6.10	1	1	1
12/11/2019 11:00	1.3	12.5	2,029.1	0.9	6.10	1	1	1
12/11/2019 12:00	1.3	12.5	2,031.6	0.9	6.10	1	1	1
12/11/2019 13:00	1.3	12.5	2,031.7	0.9	6.10	1	1	1
12/11/2019 14:00	1.3	12.4	2,057.6	0.9	6.20	1	1	1
12/11/2019 15:00	1.3	12.5	2,027.7	0.9	6.10	1	1	1
12/11/2019 16:00	1.3	12.5	2,043.9	0.9	6.10	1	1	1
12/11/2019 17:00	1.4	12.2	2,099.3	0.9	6.30	1	1	1
12/11/2019 18:00	1.3	12.3	2,075.0	0.9	6.20	1	1	1
12/11/2019 19:00	1.4	12.1	2,134.3	0.9	6.40	1	1	1
12/11/2019 20:00	1.3	12.3	2,082.6	0.9	6.20	1	1	1
12/11/2019 21:00	1.3	12.4	2,053.6	0.9	6.20	1	1	1
12/11/2019 22:00	1.3	12.5	2,040.3	0.9	6.10	1	1	1
12/11/2019 23:00	1.3	12.4	2,042.8	0.9	6.10	1	1	1
Average/Sum#:	1.3	12.4	2,062.1	0.9	152.60 #	24 #	24 #	24 #
Minimum:	1.3	12.1	2,022.2	0.9	6.10	1	1	1
Maximum:	1.5	12.6	2,134.3	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/12/2019 00:00	1.3	12.5	2,038.4	0.9	6.10	1	1	1
12/12/2019 01:00	1.3	12.5	2,026.7	0.9	6.10	1	1	1
12/12/2019 02:00	1.3	12.5	2,034.6	0.9	6.10	1	1	1
12/12/2019 03:00	1.3	12.5	2,036.3	0.9	6.10	1	1	1
12/12/2019 04:00	1.3	12.5	2,034.4	0.9	6.10	1	1	1
12/12/2019 05:00	1.3	12.5	2,032.9	0.9	6.10	1	1	1
12/12/2019 06:00	1.4	12.2	2,081.7	0.9	6.20	1	1	1
12/12/2019 07:00	1.3	12.2	2,109.2	0.9	6.30	1	1	1
12/12/2019 08:00	1.3	12.5	2,048.5	0.9	6.10	1	1	1
12/12/2019 09:00	1.3	12.5	2,041.1	0.9	6.10	1	1	1
12/12/2019 10:00	1.3	12.6	2,020.5	0.9	6.10	1	1	1
12/12/2019 11:00	1.3	12.6	2,015.7	0.9	6.00	1	1	1
12/12/2019 12:00	1.3	12.5	2,030.3	0.9	6.10	1	1	1
12/12/2019 13:00	1.3	12.5	2,032.5	0.9	6.10	1	1	1
12/12/2019 14:00	1.3	12.4	2,038.8	0.9	6.10	1	1	1
12/12/2019 15:00	1.3	12.4	2,039.5	0.9	6.10	1	1	1
12/12/2019 16:00	1.3	12.4	2,044.8	0.9	6.10	1	1	1
12/12/2019 17:00	1.4	12.2	2,092.8	0.9	6.30	1	1	1
12/12/2019 18:00	1.5	12.1	2,102.0	1.0	8.40	1	1	1
12/12/2019 19:00	1.3	12.2	2,080.7	0.9	6.20	1	1	1
12/12/2019 20:00	1.3	12.3	2,053.9	0.9	6.20	1	1	1
12/12/2019 21:00	1.4	12.4	2,058.8	1.0	8.20	1	1	1
12/12/2019 22:00	1.3	12.4	2,048.7	0.9	6.10	1	1	1
12/12/2019 23:00	0.9	13.1	1,826.5	0.7	5.50	1	1	1
Average/Sum#:	1.3	12.4	2,040.4	0.9	150.80 #	24 #	24 #	24 #
Minimum:	0.9	12.1	1,826.5	0.7	5.50	1	1	1
Maximum:	1.5	13.1	2,109.2	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/13/2019 00:00	0.3	13.6	1,455.3	0.2	1.50	1	1	0
12/13/2019 01:00	0.4	13.6	1,517.7	0.3	1.50	1	1	0
12/13/2019 02:00	0.3	13.6	1,391.0	0.2	1.40	1	1	0
12/13/2019 03:00	0.3	13.6	1,433.6	0.2	1.40	1	1	0
12/13/2019 04:00	0.5	13.6	1,701.2	0.4	1.70	1	1	0
12/13/2019 05:00	0.2	13.6	1,407.8	0.2	1.40	1	1	0
12/13/2019 06:00	0.2	13.6	1,398.2	0.2	1.40	1	1	0
12/13/2019 07:00	0.3	13.6	1,585.5	0.2	1.60	1	1	0
12/13/2019 08:00	0.4	13.6	1,684.7	0.3	1.70	1	1	0
12/13/2019 09:00	0.4	13.6	1,642.9	0.3	1.60	1	1	0
12/13/2019 10:00	0.4	13.6	1,696.1	0.3	1.70	1	1	0
12/13/2019 11:00	0.4	13.6	1,603.9	0.3	1.60	1	1	0
12/13/2019 12:00	0.3	13.6	1,497.2	0.2	1.50	1	1	0
12/13/2019 13:00	0.5	13.6	1,665.1	0.4	1.70	1	1	0
12/13/2019 14:00	0.6	13.5	1,746.6	0.5	3.50	1	1	1
12/13/2019 15:00	1.2	12.5	1,993.7	0.8	6.00	1	1	1
12/13/2019 16:00	1.4	12.2	2,067.1	0.9	6.20	1	1	1
12/13/2019 17:00	1.4	12.2	2,061.0	0.9	6.20	1	1	1
12/13/2019 18:00	1.5	12.0	2,113.5	1.0	8.50	1	1	1
12/13/2019 19:00	1.4	12.2	2,060.4	0.9	6.20	1	1	1
12/13/2019 20:00	1.4	12.2	2,079.0	0.9	6.20	1	1	1
12/13/2019 21:00	1.5	12.2	2,067.6	1.0	8.30	1	1	1
12/13/2019 22:00	1.5	12.2	2,069.6	1.0	8.30	1	1	1
12/13/2019 23:00	1.5	12.3	2,058.0	1.0	8.20	1	1	1
Average/Sum#:	0.8	13.1	1,749.9	0.5	89.30 #	24 #	24 #	10 #
Minimum:	0.2	12.0	1,391.0	0.2	1.40	1	1	0
Maximum:	1.5	13.6	2,113.5	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/14/2019 00:00	1.4	12.4	2,045.8	1.0	8.20	1	1	1
12/14/2019 01:00	1.3	12.6	1,962.4	0.9	5.90	1	1	1
12/14/2019 02:00	0.4	13.6	1,606.6	0.3	1.60	1	1	0
12/14/2019 03:00	0.3	13.6	1,561.7	0.2	1.60	1	1	0
12/14/2019 04:00	0.4	13.6	1,695.0	0.3	1.70	1	1	0
12/14/2019 05:00	0.3	13.6	1,631.9	0.2	1.60	1	1	0
12/14/2019 06:00	0.3	13.6	1,567.2	0.2	1.60	1	1	0
12/14/2019 07:00	0.3	13.6	1,491.9	0.2	1.50	1	1	0
12/14/2019 08:00	0.3	13.6	1,487.9	0.2	1.50	1	1	0
12/14/2019 09:00	0.4	13.6	1,646.4	0.3	1.60	1	1	0
12/14/2019 10:00	0.3	13.6	1,583.8	0.2	1.60	1	1	0
12/14/2019 11:00	0.3	13.6	1,611.9	0.2	1.60	1	1	0
12/14/2019 12:00	0.2	13.7	1,386.2	0.2	1.40	1	1	0
12/14/2019 13:00	0.4	13.6	1,657.3	0.3	1.70	1	1	0
12/14/2019 14:00	0.3	13.6	1,607.0	0.2	1.60	1	1	0
12/14/2019 15:00	0.4	13.6	1,612.8	0.3	1.60	1	1	1
12/14/2019 16:00	1.1	12.5	2,014.5	0.8	6.00	1	1	1
12/14/2019 17:00	1.3	12.3	2,078.8	0.9	6.20	1	1	1
12/14/2019 18:00	1.4	12.3	2,080.7	1.0	8.30	1	1	1
12/14/2019 19:00	1.4	12.4	2,057.4	1.0	8.20	1	1	1
12/14/2019 20:00	1.5	12.2	2,104.3	1.0	8.40	1	1	1
12/14/2019 21:00	1.4	12.3	2,104.0	1.0	8.40	1	1	1
12/14/2019 22:00	1.3	12.4	2,056.1	0.9	6.20	1	1	1
12/14/2019 23:00	1.1	12.9	1,953.3	0.8	5.90	1	1	1
Average/Sum#:	0.7	13.1	1,775.2	0.5	93.90 #	24 #	24 #	11 #
Minimum:	0.2	12.2	1,386.2	0.2	1.40	1	1	0
Maximum:	1.5	13.7	2,104.3	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2019 00:00	1.3	12.6	2,034.8	0.9	6.10	1	1	1
12/15/2019 01:00	1.3	12.6	2,022.0	0.9	6.10	1	1	1
12/15/2019 02:00	1.4	12.4	2,068.2	1.0	8.30	1	1	1
12/15/2019 03:00	1.4	12.4	2,088.1	1.0	8.40	1	1	1
12/15/2019 04:00	1.4	12.4	2,097.5	1.0	8.40	1	1	1
12/15/2019 05:00	1.3	12.5	2,059.2	0.9	6.20	1	1	1
12/15/2019 06:00	1.4	12.5	2,068.0	1.0	8.30	1	1	1
12/15/2019 07:00	1.1	12.8	1,958.5	0.8	5.90	1	1	1
12/15/2019 08:00	0.4	13.6	1,594.2	0.3	1.60	1	1	0
12/15/2019 09:00	0.3	13.6	1,647.3	0.2	1.60	1	1	0
12/15/2019 10:00	0.2	13.6	1,546.4	0.2	1.50	1	1	0
12/15/2019 11:00	0.3	13.6	1,572.6	0.2	1.60	1	1	0
12/15/2019 12:00	0.3	13.6	1,555.2	0.2	1.60	1	1	0
12/15/2019 13:00	0.3	13.6	1,648.3	0.2	1.60	1	1	0
12/15/2019 14:00	0.3	13.6	1,578.5	0.2	1.60	1	1	0
12/15/2019 15:00	0.4	13.6	1,574.4	0.3	1.60	1	1	1
12/15/2019 16:00	1.1	12.7	2,013.2	0.8	6.00	1	1	1
12/15/2019 17:00	1.4	12.5	2,065.4	1.0	8.30	1	1	1
12/15/2019 18:00	1.5	12.2	2,140.9	1.0	8.60	1	1	1
12/15/2019 19:00	1.5	12.0	2,167.3	1.0	8.70	1	1	1
12/15/2019 20:00	1.5	12.1	2,160.8	1.0	8.60	1	1	1
12/15/2019 21:00	1.5	12.1	2,156.4	1.0	8.60	1	1	1
12/15/2019 22:00	1.5	12.3	2,096.1	1.0	8.40	1	1	1
12/15/2019 23:00	1.4	12.5	2,073.9	1.0	8.30	1	1	1
Average/Sum#:	1.0	12.8	1,916.1	0.7	135.90 #	24 #	24 #	17 #
Minimum:	0.2	12.0	1,546.4	0.2	1.50	1	1	0
Maximum:	1.5	13.6	2,167.3	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/16/2019 00:00	1.4	12.3	2,105.5	1.0	8.40	1	1	1
12/16/2019 01:00	1.4	12.3	2,105.7	1.0	8.40	1	1	1
12/16/2019 02:00	1.4	12.4	2,099.3	1.0	8.40	1	1	1
12/16/2019 03:00	1.4	12.4	2,112.4	1.0	8.40	1	1	1
12/16/2019 04:00	1.4	12.4	2,110.5	1.0	8.40	1	1	1
12/16/2019 05:00	1.4	12.4	2,094.0	1.0	8.40	1	1	1
12/16/2019 06:00	1.5	12.1	2,177.6	1.0	8.70	1	1	1
12/16/2019 07:00	1.4	12.3	2,141.6	1.0	8.60	1	1	1
12/16/2019 08:00	1.3	12.8	2,024.2	0.9	6.10	1	1	1
12/16/2019 09:00	1.4	12.7	2,021.1	1.0	8.10	1	1	1
12/16/2019 10:00	1.5	12.6	2,038.9	1.1	8.20	1	1	1
12/16/2019 11:00	1.5	12.6	2,031.8	1.1	8.10	1	1	1
12/16/2019 12:00	1.5	12.6	2,033.7	1.1	8.10	1	1	1
12/16/2019 13:00	1.5	12.6	2,034.6	1.1	8.10	1	1	1
12/16/2019 14:00	1.5	12.5	2,047.6	1.1	8.20	1	1	1
12/16/2019 15:00	1.5	12.5	2,062.4	1.1	8.20	1	1	1
12/16/2019 16:00	1.5	12.4	2,085.0	1.0	8.30	1	1	1
12/16/2019 17:00	1.6	12.1	2,138.0	1.1	8.60	1	1	1
12/16/2019 18:00	1.6	12.1	2,152.8	1.1	8.60	1	1	1
12/16/2019 19:00	1.5	12.1	2,167.2	1.0	8.70	1	1	1
12/16/2019 20:00	1.5	12.1	2,167.2	1.0	8.70	1	1	1
12/16/2019 21:00	1.4	12.1	2,161.4	0.9	6.50	1	1	1
12/16/2019 22:00	1.4	12.3	2,128.4	1.0	8.50	1	1	1
12/16/2019 23:00	1.4	12.5	2,085.0	1.0	8.30	1	1	1
Average/Sum#:	1.5	12.4	2,096.9	1.0	197.00 #	24 #	24 #	24 #
Minimum:	1.3	12.1	2,021.1	0.9	6.10	1	1	1
Maximum:	1.6	12.8	2,177.6	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/17/2019 00:00	1.4	12.4	2,095.6	1.0	8.40	1	1	1
12/17/2019 01:00	1.4	12.4	2,112.7	1.0	8.50	1	1	1
12/17/2019 02:00	1.4	12.4	2,111.7	1.0	8.40	1	1	1
12/17/2019 03:00	1.4	12.4	2,107.2	1.0	8.40	1	1	1
12/17/2019 04:00	1.4	12.6	2,091.3	1.0	8.40	1	1	1
12/17/2019 05:00	1.4	12.6	2,085.2	1.0	8.30	1	1	1
12/17/2019 06:00	1.5	12.2	2,143.9	1.0	8.60	1	1	1
12/17/2019 07:00	1.4	12.4	2,135.0	1.0	8.50	1	1	1
12/17/2019 08:00	1.4	12.5	2,095.6	1.0	8.40	1	1	1
12/17/2019 09:00	1.3	12.7	2,054.8	0.9	6.20	1	1	1
12/17/2019 10:00	1.4	12.7	2,041.9	1.0	8.20	1	1	1
12/17/2019 11:00	1.4	12.7	2,043.5	1.0	8.20	1	1	1
12/17/2019 12:00	1.4	12.6	2,051.0	1.0	8.20	1	1	1
12/17/2019 13:00	1.4	12.6	2,061.2	1.0	8.20	1	1	1
12/17/2019 14:00	1.5	12.4	2,086.1	1.0	8.30	1	1	1
12/17/2019 15:00	1.5	12.3	2,107.4	1.0	8.40	1	1	1
12/17/2019 16:00	1.4	12.3	2,123.4	1.0	8.50	1	1	1
12/17/2019 17:00	1.3	12.2	2,140.8	0.9	6.40	1	1	1
12/17/2019 18:00	1.1	12.2	2,127.0	0.7	6.40	1	1	1
12/17/2019 19:00	1.1	12.3	2,112.3	0.8	6.30	1	1	1
12/17/2019 20:00	1.3	12.1	2,155.6	0.9	6.50	1	1	1
12/17/2019 21:00	1.6	12.0	2,166.9	1.1	8.70	1	1	1
12/17/2019 22:00	1.6	12.1	2,160.9	1.1	8.60	1	1	1
12/17/2019 23:00	1.4	12.4	2,091.1	1.0	8.40	1	1	1
Average/Sum#:	1.4	12.4	2,104.3	1.0	191.40 #	24 #	24 #	24 #
Minimum:	1.1	12.0	2,041.9	0.7	6.20	1	1	1
Maximum:	1.6	12.7	2,166.9	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/18/2019 00:00	1.4	12.5	2,083.8	1.0	8.30	1	1	1
12/18/2019 01:00	1.5	12.3	2,106.5	1.0	8.40	1	1	1
12/18/2019 02:00	1.5	12.3	2,102.9	1.0	8.40	1	1	1
12/18/2019 03:00	1.4	12.3	2,109.2	1.0	8.40	1	1	1
12/18/2019 04:00	1.5	12.3	2,115.1	1.0	8.50	1	1	1
12/18/2019 05:00	1.5	12.1	2,147.7	1.0	8.60	1	1	1
12/18/2019 06:00	1.5	12.0	2,189.5	1.0	8.80	1	1	1
12/18/2019 07:00	1.5	12.1	2,170.9	1.0	8.70	1	1	1
12/18/2019 08:00	1.4	12.3	2,125.0	1.0	8.50	1	1	1
12/18/2019 09:00	1.4	12.3	2,109.0	1.0	8.40	1	1	1
12/18/2019 10:00	1.4	12.4	2,102.2	1.0	8.40	1	1	1
12/18/2019 11:00	1.4	12.3	2,115.8	1.0	8.50	1	1	1
12/18/2019 12:00	1.3	12.3	2,099.3	0.9	6.30	1	1	1
12/18/2019 13:00	1.3	12.4	2,097.1	0.9	6.30	1	1	1
12/18/2019 14:00	1.3	12.4	2,086.5	0.9	6.30	1	1	1
12/18/2019 15:00	1.3	12.5	2,063.9	0.9	6.20	1	1	1
12/18/2019 16:00	1.3	12.4	2,100.2	0.9	6.30	1	1	1
12/18/2019 17:00	1.3	12.2	2,143.7	0.9	6.40	1	1	1
12/18/2019 18:00	1.5	12.0	2,171.8	1.0	8.70	1	1	1
12/18/2019 19:00	1.4	12.1	2,163.5	0.9	6.50	1	1	1
12/18/2019 20:00	1.5	12.0	2,173.3	1.0	8.70	1	1	1
12/18/2019 21:00	1.4	12.1	2,160.8	0.9	6.50	1	1	1
12/18/2019 22:00	1.3	12.2	2,145.7	0.9	6.40	1	1	1
12/18/2019 23:00	1.4	12.4	2,096.1	1.0	8.40	1	1	1
Average/Sum#:	1.4	12.3	2,124.1	1.0	184.90 #	24 #	24 #	24 #
Minimum:	1.3	12.0	2,063.9	0.9	6.20	1	1	1
Maximum:	1.5	12.5	2,189.5	1.0	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2019 00:00	1.4	12.3	2,110.2	1.0	8.40	1	1	1
12/19/2019 01:00	1.4	12.3	2,109.6	1.0	8.40	1	1	1
12/19/2019 02:00	1.4	12.3	2,104.4	1.0	8.40	1	1	1
12/19/2019 03:00	1.4	12.4	2,093.9	1.0	8.40	1	1	1
12/19/2019 04:00	1.4	12.3	2,105.8	1.0	8.40	1	1	1
12/19/2019 05:00	1.4	12.4	2,089.4	1.0	8.40	1	1	1
12/19/2019 06:00	1.5	12.0	2,172.9	1.0	8.70	1	1	1
12/19/2019 07:00	1.4	12.1	2,151.4	0.9	6.50	1	1	1
12/19/2019 08:00	1.3	12.6	2,042.6	0.9	6.10	1	1	1
12/19/2019 09:00	1.3	12.5	2,064.5	0.9	6.20	1	1	1
12/19/2019 10:00	1.3	12.6	2,032.5	0.9	6.10	1	1	1
12/19/2019 11:00	1.3	12.6	2,033.1	0.9	6.10	1	1	1
12/19/2019 12:00	1.3	12.6	2,029.8	0.9	6.10	1	1	1
12/19/2019 13:00	1.3	12.5	2,038.5	0.9	6.10	1	1	1
12/19/2019 14:00	1.3	12.6	2,026.2	0.9	6.10	1	1	1
12/19/2019 15:00	1.3	12.4	2,075.1	0.9	6.20	1	1	1
12/19/2019 16:00	1.4	12.3	2,084.0	1.0	8.30	1	1	1
12/19/2019 17:00	1.3	12.2	2,112.7	0.9	6.30	1	1	1
12/19/2019 18:00	1.2	12.2	2,116.2	0.8	6.30	1	1	1
12/19/2019 19:00	1.4	12.1	2,140.0	0.9	6.40	1	1	1
12/19/2019 20:00	1.4	12.1	2,142.2	0.9	6.40	1	1	1
12/19/2019 21:00	1.4	12.1	2,147.2	0.9	6.40	1	1	1
12/19/2019 22:00	1.3	12.3	2,100.6	0.9	6.30	1	1	1
12/19/2019 23:00	1.3	12.4	2,087.7	0.9	6.30	1	1	1
Average/Sum#:	1.4	12.3	2,092.1	0.9	167.30 #	24 #	24 #	24 #
Minimum:	1.2	12.0	2,026.2	0.8	6.10	1	1	1
Maximum:	1.5	12.6	2,172.9	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/20/2019 00:00	1.3	12.3	2,103.7	0.9	6.30	1	1	1
12/20/2019 01:00	1.3	12.3	2,089.5	0.9	6.30	1	1	1
12/20/2019 02:00	1.3	12.3	2,095.5	0.9	6.30	1	1	1
12/20/2019 03:00	1.3	12.6	2,040.0	0.9	6.10	1	1	1
12/20/2019 04:00	1.3	12.5	2,065.1	0.9	6.20	1	1	1
12/20/2019 05:00	1.3	12.4	2,092.9	0.9	6.30	1	1	1
12/20/2019 06:00	1.4	12.2	2,118.4	0.9	6.40	1	1	1
12/20/2019 07:00	1.2	12.5	2,070.4	0.8	6.20	1	1	1
12/20/2019 08:00	1.2	12.6	2,030.9	0.9	6.10	1	1	1
12/20/2019 09:00	1.2	12.6	2,044.2	0.9	6.10	1	1	1
12/20/2019 10:00	1.1	12.8	1,946.1	0.8	5.80	1	1	1
12/20/2019 11:00	0.4	13.6	1,648.3	0.3	1.60	1	1	0
12/20/2019 12:00	0.3	13.6	1,598.4	0.2	1.60	1	1	0
12/20/2019 13:00	0.4	13.6	1,659.5	0.3	1.70	1	1	0
12/20/2019 14:00	0.4	13.6	1,572.1	0.3	1.60	1	1	1
12/20/2019 15:00	1.1	12.5	2,030.2	0.8	6.10	1	1	1
12/20/2019 16:00	1.3	12.3	2,069.8	0.9	6.20	1	1	1
12/20/2019 17:00	1.4	12.1	2,112.2	0.9	6.30	1	1	1
12/20/2019 18:00	1.4	12.0	2,136.1	0.9	6.40	1	1	1
12/20/2019 19:00	1.4	12.2	2,101.3	0.9	6.30	1	1	1
12/20/2019 20:00	1.3	12.2	2,098.5	0.9	6.30	1	1	1
12/20/2019 21:00	1.3	12.2	2,097.4	0.9	6.30	1	1	1
12/20/2019 22:00	1.3	12.2	2,101.2	0.9	6.30	1	1	1
12/20/2019 23:00	1.3	12.3	2,094.2	0.9	6.30	1	1	1
Average/Sum#:	1.1	12.6	2,000.7	0.8	131.10 #	24 #	24 #	21 #
Minimum:	0.3	12.0	1,572.1	0.2	1.60	1	1	0
Maximum:	1.4	13.6	2,136.1	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2019 00:00	1.3	12.4	2,062.3	0.9	6.20	1	1	1
12/21/2019 01:00	1.2	12.5	2,047.9	0.8	6.10	1	1	1
12/21/2019 02:00	1.3	12.3	2,084.5	0.9	6.30	1	1	1
12/21/2019 03:00	1.3	12.3	2,086.1	0.9	6.30	1	1	1
12/21/2019 04:00	1.3	12.3	2,091.9	0.9	6.30	1	1	1
12/21/2019 05:00	1.3	12.3	2,097.3	0.9	6.30	1	1	1
12/21/2019 06:00	1.3	12.3	2,076.8	0.9	6.20	1	1	1
12/21/2019 07:00	1.3	12.3	2,106.2	0.9	6.30	1	1	1
12/21/2019 08:00	1.3	12.3	2,099.3	0.9	6.30	1	1	1
12/21/2019 09:00	1.3	12.3	2,090.7	0.9	6.30	1	1	1
12/21/2019 10:00	1.2	12.4	2,067.2	0.8	6.20	1	1	1
12/21/2019 11:00	1.2	12.6	2,036.5	0.9	6.10	1	1	1
12/21/2019 12:00	1.2	12.5	2,034.8	0.8	6.10	1	1	1
12/21/2019 13:00	1.2	12.5	2,041.3	0.8	6.10	1	1	1
12/21/2019 14:00	1.3	12.4	2,061.3	0.9	6.20	1	1	1
12/21/2019 15:00	1.3	12.5	2,051.4	0.9	6.20	1	1	1
12/21/2019 16:00	1.3	12.5	2,037.2	0.9	6.10	1	1	1
12/21/2019 17:00	1.3	12.5	2,042.2	0.9	6.10	1	1	1
12/21/2019 18:00	1.3	12.4	2,054.3	0.9	6.20	1	1	1
12/21/2019 19:00	1.3	12.4	2,062.3	0.9	6.20	1	1	1
12/21/2019 20:00	1.4	12.3	2,079.4	1.0	8.30	1	1	1
12/21/2019 21:00	1.4	12.3	2,072.6	1.0	8.30	1	1	1
12/21/2019 22:00	1.4	12.2	2,100.2	0.9	6.30	1	1	1
12/21/2019 23:00	1.4	12.3	2,098.4	1.0	8.40	1	1	1
Average/Sum#:	1.3	12.4	2,070.1	0.9	155.40 #	24 #	24 #	24 #
Minimum:	1.2	12.2	2,034.8	0.8	6.10	1	1	1
Maximum:	1.4	12.6	2,106.2	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/22/2019 00:00	1.4	12.3	2,092.8	1.0	8.40	1	1	1
12/22/2019 01:00	1.3	12.4	2,061.8	0.9	6.20	1	1	1
12/22/2019 02:00	1.4	12.2	2,103.3	0.9	6.30	1	1	1
12/22/2019 03:00	1.4	12.2	2,109.5	0.9	6.30	1	1	1
12/22/2019 04:00	1.4	12.3	2,081.6	1.0	8.30	1	1	1
12/22/2019 05:00	1.4	12.3	2,073.6	1.0	8.30	1	1	1
12/22/2019 06:00	1.5	12.1	2,102.0	1.0	8.40	1	1	1
12/22/2019 07:00	1.4	12.1	2,109.7	0.9	6.30	1	1	1
12/22/2019 08:00	1.4	12.2	2,088.6	0.9	6.30	1	1	1
12/22/2019 09:00	1.4	12.3	2,085.0	1.0	8.30	1	1	1
12/22/2019 10:00	1.3	12.3	2,085.1	0.9	6.30	1	1	1
12/22/2019 11:00	1.3	12.3	2,062.4	0.9	6.20	1	1	1
12/22/2019 12:00	1.3	12.4	2,056.4	0.9	6.20	1	1	1
12/22/2019 13:00	1.3	12.2	2,083.7	0.9	6.30	1	1	1
12/22/2019 14:00	1.3	12.3	2,061.3	0.9	6.20	1	1	1
12/22/2019 15:00	1.3	12.3	2,056.8	0.9	6.20	1	1	1
12/22/2019 16:00	1.2	12.5	2,020.5	0.8	6.10	1	1	1
12/22/2019 17:00	1.2	12.5	2,023.6	0.8	6.10	1	1	1
12/22/2019 18:00	1.3	12.4	2,040.2	0.9	6.10	1	1	1
12/22/2019 19:00	1.3	12.4	2,043.9	0.9	6.10	1	1	1
12/22/2019 20:00	1.2	12.5	2,040.0	0.8	6.10	1	1	1
12/22/2019 21:00	1.1	12.5	2,028.7	0.8	6.10	1	1	1
12/22/2019 22:00	1.2	12.5	2,030.6	0.8	6.10	1	1	1
12/22/2019 23:00	1.3	12.5	2,053.2	0.9	6.20	1	1	1
Average/Sum#:	1.3	12.3	2,066.4	0.9	159.40 #	24 #	24 #	24 #
Minimum:	1.1	12.1	2,020.5	0.8	6.10	1	1	1
Maximum:	1.5	12.5	2,109.7	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/23/2019 00:00	1.3	12.4	2,057.8	0.9	6.20	1	1	1
12/23/2019 01:00	1.3	12.5	2,036.7	0.9	6.10	1	1	1
12/23/2019 02:00	1.3	12.5	2,040.4	0.9	6.10	1	1	1
12/23/2019 03:00	1.3	12.5	2,059.6	0.9	6.20	1	1	1
12/23/2019 04:00	1.3	12.5	2,048.7	0.9	6.10	1	1	1
12/23/2019 05:00	1.3	12.5	2,039.1	0.9	6.10	1	1	1
12/23/2019 06:00	1.4	12.5	2,049.8	1.0	8.20	1	1	1
12/23/2019 07:00	1.3	12.5	2,055.3	0.9	6.20	1	1	1
12/23/2019 08:00	1.2	12.2	2,115.8	0.8	6.30	1	1	1
12/23/2019 09:00	1.5	12.2	2,118.1	1.0	8.50	1	1	1
12/23/2019 10:00	1.5	12.2	2,111.6	1.0	8.40	1	1	1
12/23/2019 11:00	1.6	12.1	2,115.9	1.1	8.50	1	1	1
12/23/2019 12:00	1.6	12.1	2,114.1	1.1	8.50	1	1	1
12/23/2019 13:00	1.5	12.3	2,061.2	1.0	8.20	1	1	1
12/23/2019 14:00	1.6	12.2	2,083.4	1.1	8.30	1	1	1
12/23/2019 15:00	1.5	12.3	2,059.5	1.0	8.20	1	1	1
12/23/2019 16:00	1.4	12.4	2,052.6	1.0	8.20	1	1	1
12/23/2019 17:00	1.4	12.4	2,046.0	1.0	8.20	1	1	1
12/23/2019 18:00	1.4	12.4	2,048.9	1.0	8.20	1	1	1
12/23/2019 19:00	1.4	12.4	2,071.9	1.0	8.30	1	1	1
12/23/2019 20:00	1.5	12.2	2,124.2	1.0	8.50	1	1	1
12/23/2019 21:00	1.5	12.2	2,105.7	1.0	8.40	1	1	1
12/23/2019 22:00	1.5	12.3	2,100.3	1.0	8.40	1	1	1
12/23/2019 23:00	1.4	12.4	2,102.7	1.0	8.40	1	1	1
Average/Sum#:	1.4	12.3	2,075.8	1.0	182.70 #	24 #	24 #	24 #
Minimum:	1.2	12.1	2,036.7	0.8	6.10	1	1	1
Maximum:	1.6	12.5	2,124.2	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/24/2019 00:00	1.4	12.4	2,092.6	1.0	8.40	1	1	1
12/24/2019 01:00	1.3	12.6	2,047.1	0.9	6.10	1	1	1
12/24/2019 02:00	1.3	12.6	2,043.0	0.9	6.10	1	1	1
12/24/2019 03:00	1.3	12.6	2,044.0	0.9	6.10	1	1	1
12/24/2019 04:00	1.3	12.6	2,048.4	0.9	6.10	1	1	1
12/24/2019 05:00	1.3	12.6	2,049.6	0.9	6.10	1	1	1
12/24/2019 06:00	1.3	12.5	2,068.6	0.9	6.20	1	1	1
12/24/2019 07:00	1.2	12.6	2,065.7	0.9	6.20	1	1	1
12/24/2019 08:00	1.2	12.7	2,058.1	0.9	6.20	1	1	1
12/24/2019 09:00	1.2	12.6	2,046.3	0.9	6.10	1	1	1
12/24/2019 10:00	1.2	12.6	2,042.3	0.9	6.10	1	1	1
12/24/2019 11:00	1.3	12.6	2,035.5	0.9	6.10	1	1	1
12/24/2019 12:00	1.3	12.5	2,044.2	0.9	6.10	1	1	1
12/24/2019 13:00	1.3	12.6	2,032.3	0.9	6.10	1	1	1
12/24/2019 14:00	1.3	12.6	2,038.9	0.9	6.10	1	1	1
12/24/2019 15:00	1.4	12.4	2,080.9	1.0	8.30	1	1	1
12/24/2019 16:00	1.3	12.5	2,037.9	0.9	6.10	1	1	1
12/24/2019 17:00	1.3	12.5	2,057.3	0.9	6.20	1	1	1
12/24/2019 18:00	1.3	12.5	2,051.8	0.9	6.20	1	1	1
12/24/2019 19:00	1.3	12.6	2,041.0	0.9	6.10	1	1	1
12/24/2019 20:00	1.3	12.5	2,043.0	0.9	6.10	1	1	1
12/24/2019 21:00	1.3	12.6	2,042.4	0.9	6.10	1	1	1
12/24/2019 22:00	1.3	12.5	2,053.5	0.9	6.20	1	1	1
12/24/2019 23:00	1.3	12.6	2,035.2	0.9	6.10	1	1	1
Average/Sum#:	1.3	12.6	2,050.0	0.9	151.50 #	24 #	24 #	24 #
Minimum:	1.2	12.4	2,032.3	0.9	6.10	1	1	1
Maximum:	1.4	12.7	2,092.6	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/25/2019 00:00	1.3	12.4	2,062.7	0.9	6.20	1	1	1
12/25/2019 01:00	1.3	12.4	2,068.2	0.9	6.20	1	1	1
12/25/2019 02:00	1.1	12.4	2,071.0	0.8	6.20	1	1	1
12/25/2019 03:00	1.2	12.6	2,045.1	0.9	6.10	1	1	1
12/25/2019 04:00	1.3	12.5	2,045.3	0.9	6.10	1	1	1
12/25/2019 05:00	1.2	12.6	2,041.9	0.9	6.10	1	1	1
12/25/2019 06:00	1.2	12.6	2,038.1	0.9	6.10	1	1	1
12/25/2019 07:00	1.0	12.5	2,056.9	0.7	6.20	1	1	1
12/25/2019 08:00	1.2	12.6	2,033.1	0.9	6.10	1	1	1
12/25/2019 09:00	1.3	12.5	2,051.2	0.9	6.20	1	1	1
12/25/2019 10:00	1.3	12.6	2,048.3	0.9	6.10	1	1	1
12/25/2019 11:00	1.3	12.5	2,044.8	0.9	6.10	1	1	1
12/25/2019 12:00	1.3	12.5	2,051.2	0.9	6.20	1	1	1
12/25/2019 13:00	1.3	12.5	2,044.4	0.9	6.10	1	1	1
12/25/2019 14:00	1.3	12.4	2,068.9	0.9	6.20	1	1	1
12/25/2019 15:00	1.3	12.4	2,069.5	0.9	6.20	1	1	1
12/25/2019 16:00	1.3	12.4	2,078.1	0.9	6.20	1	1	1
12/25/2019 17:00	1.3	12.5	2,049.5	0.9	6.10	1	1	1
12/25/2019 18:00	1.3	12.5	2,064.8	0.9	6.20	1	1	1
12/25/2019 19:00	1.4	12.3	2,095.3	1.0	8.40	1	1	1
12/25/2019 20:00	1.3	12.4	2,088.9	0.9	6.30	1	1	1
12/25/2019 21:00	1.3	12.4	2,069.7	0.9	6.20	1	1	1
12/25/2019 22:00	1.3	12.5	2,060.3	0.9	6.20	1	1	1
12/25/2019 23:00	1.3	12.4	2,067.9	0.9	6.20	1	1	1
Average/Sum#:	1.3	12.5	2,059.0	0.9	150.20 #	24 #	24 #	24 #
Minimum:	1.0	12.3	2,033.1	0.7	6.10	1	1	1
Maximum:	1.4	12.6	2,095.3	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/26/2019 00:00	1.4	12.5	2,065.4	1.0	8.30	1	1	1
12/26/2019 01:00	1.3	12.4	2,073.0	0.9	6.20	1	1	1
12/26/2019 02:00	0.9	12.5	2,062.0	0.6	4.10	1	1	1
12/26/2019 03:00	0.9	12.5	2,052.8	0.6	4.10	1	1	1
12/26/2019 04:00	0.8	12.5	2,046.2	0.6	4.10	1	1	1
12/26/2019 05:00	1.0	12.6	2,040.8	0.7	6.10	1	1	1
12/26/2019 06:00	1.4	12.5	2,043.5	1.0	8.20	1	1	1
12/26/2019 07:00	1.4	12.4	2,081.9	1.0	8.30	1	1	1
12/26/2019 08:00	1.6	12.0	2,165.9	1.1	8.70	1	1	1
12/26/2019 09:00	1.5	12.2	2,108.0	1.0	8.40	1	1	1
12/26/2019 10:00	1.6	12.2	2,110.1	1.1	8.40	1	1	1
12/26/2019 11:00	1.5	12.4	2,069.7	1.0	8.30	1	1	1
12/26/2019 12:00	1.1	12.4	2,050.1	0.8	6.20	1	1	1
12/26/2019 13:00	1.1	12.3	2,072.8	0.8	6.20	1	1	1
12/26/2019 14:00	1.0	12.4	2,053.0	0.7	6.20	1	1	1
12/26/2019 15:00	1.0	12.3	2,065.9	0.7	6.20	1	1	1
12/26/2019 16:00	1.1	12.2	2,114.1	0.7	6.30	1	1	1
12/26/2019 17:00	1.1	12.1	2,126.5	0.7	6.40	1	1	1
12/26/2019 18:00	1.1	12.0	2,157.1	0.7	6.50	1	1	1
12/26/2019 19:00	1.1	12.0	2,151.5	0.7	6.50	1	1	1
12/26/2019 20:00	1.1	12.0	2,154.5	0.7	6.50	1	1	1
12/26/2019 21:00	1.0	12.2	2,121.4	0.7	4.20	1	1	1
12/26/2019 22:00	1.0	12.2	2,110.8	0.7	4.20	1	1	1
12/26/2019 23:00	1.1	12.3	2,111.1	0.8	6.30	1	1	1
Average/Sum#:	1.2	12.3	2,092.0	0.8	154.90 #	24 #	24 #	24 #
Minimum:	0.8	12.0	2,040.8	0.6	4.10	1	1	1
Maximum:	1.6	12.6	2,165.9	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/27/2019 00:00	1.0	12.2	2,115.5	0.7	4.20	1	1	1
12/27/2019 01:00	1.0	12.3	2,095.3	0.7	6.30	1	1	1
12/27/2019 02:00	1.0	12.3	2,113.3	0.7	6.30	1	1	1
12/27/2019 03:00	1.0	12.4	2,082.6	0.7	6.20	1	1	1
12/27/2019 04:00	1.0	12.6	2,058.1	0.7	6.20	1	1	1
12/27/2019 05:00	1.0	12.6	2,065.8	0.7	6.20	1	1	1
12/27/2019 06:00	1.0	12.6	2,057.0	0.7	6.20	1	1	1
12/27/2019 07:00	1.0	12.6	2,071.0	0.7	6.20	1	1	1
12/27/2019 08:00	0.9	12.9	1,971.6	0.7	3.90	1	1	1
12/27/2019 09:00	0.3	13.6	1,691.3	0.2	1.70	1	1	0
12/27/2019 10:00	0.3	13.7	1,677.4	0.2	1.70	1	1	0
12/27/2019 11:00	0.3	13.7	1,637.2	0.2	1.60	1	1	0
12/27/2019 12:00	0.2	13.7	1,637.1	0.2	1.60	1	1	0
12/27/2019 13:00	0.3	13.7	1,686.6	0.2	1.70	1	1	0
12/27/2019 14:00	0.3	13.7	1,655.1	0.2	1.70	1	1	0
12/27/2019 15:00	0.2	13.7	1,417.0	0.2	1.40	1	1	0
12/27/2019 16:00	0.2	13.7	1,634.7	0.2	1.60	1	1	0
12/27/2019 17:00	0.3	13.7	1,711.5	0.2	1.70	1	1	1
12/27/2019 18:00	0.8	12.7	2,003.9	0.6	4.00	1	1	1
12/27/2019 19:00	1.1	12.3	2,086.7	0.8	6.30	1	1	1
12/27/2019 20:00	1.1	12.1	2,120.0	0.7	6.40	1	1	1
12/27/2019 21:00	1.1	12.2	2,106.8	0.7	6.30	1	1	1
12/27/2019 22:00	1.1	12.2	2,103.9	0.7	6.30	1	1	1
12/27/2019 23:00	1.0	12.4	2,070.5	0.7	6.20	1	1	1
Average/Sum#:	1.0	12.5	1,911.2	0.7	41.60 #	24 #	24 #	16 #
Minimum:	1.0	12.2	1,417.0	0.7	4.20	1	1	0
Maximum:	1.0	12.6	2,120.0	0.7	6.30	1	1	1
%SI	66.67	66.67	0.00	66.67	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/28/2019 00:00	1.0	12.7	2,018.1	0.7	6.10	1	1	1
12/28/2019 01:00	1.0	12.7	2,022.8	0.7	6.10	1	1	1
12/28/2019 02:00	1.1	12.6	2,043.1	0.8	6.10	1	1	1
12/28/2019 03:00	1.1	12.6	2,024.9	0.8	6.10	1	1	1
12/28/2019 04:00	0.9	12.7	2,030.9	0.6	4.10	1	1	1
12/28/2019 05:00	0.9	12.7	2,038.8	0.6	4.10	1	1	1
12/28/2019 06:00	1.0	12.7	2,034.4	0.7	6.10	1	1	1
12/28/2019 07:00	1.0	12.5	2,072.9	0.7	6.20	1	1	1
12/28/2019 08:00	1.0	12.8	1,989.7	0.7	6.00	1	1	1
12/28/2019 09:00	0.4	13.6	1,675.3	0.3	1.70	1	1	0
12/28/2019 10:00	0.2	13.6	1,621.0	0.2	1.60	1	1	0
12/28/2019 11:00	0.2	13.6	1,660.3	0.2	1.70	1	1	0
12/28/2019 12:00	0.3	13.6	1,695.2	0.2	1.70	1	1	0
12/28/2019 13:00	0.3	13.6	1,651.6	0.2	1.70	1	1	0
12/28/2019 14:00	0.3	13.6	1,678.2	0.2	1.70	1	1	0
12/28/2019 15:00	0.3	13.7	1,609.8	0.2	1.60	1	1	1
12/28/2019 16:00	0.8	12.6	2,025.0	0.6	4.10	1	1	1
12/28/2019 17:00	1.0	12.3	2,086.2	0.7	6.30	1	1	1
12/28/2019 18:00	1.4	12.2	2,103.1	0.9	6.30	1	1	1
12/28/2019 19:00	1.5	12.2	2,102.3	1.0	8.40	1	1	1
12/28/2019 20:00	1.4	12.3	2,101.5	1.0	8.40	1	1	1
12/28/2019 21:00	1.4	12.4	2,083.1	1.0	8.30	1	1	1
12/28/2019 22:00	1.4	12.3	2,088.9	1.0	8.40	1	1	1
12/28/2019 23:00	1.4	12.3	2,094.9	1.0	8.40	1	1	1
Average/Sum#:	0.0	0.0	1,939.7	0.0	0.00 #	24 #	24 #	18 #
Minimum:	0.0	0.0	1,609.8	0.0	0.00	1	1	0
Maximum:	0.0	0.0	2,103.1	0.0	0.00	1	1	1
%SI	100.00	100.00	0.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/29/2019 00:00	1.3	12.4	2,084.2	0.9	6.30	1	1	1
12/29/2019 01:00	1.4	12.3	2,107.9	1.0	8.40	1	1	1
12/29/2019 02:00	1.3	12.4	2,077.9	0.9	6.20	1	1	1
12/29/2019 03:00	1.3	12.4	2,095.8	0.9	6.30	1	1	1
12/29/2019 04:00	1.3	12.4	2,083.9	0.9	6.30	1	1	1
12/29/2019 05:00	1.3	12.4	2,088.2	0.9	6.30	1	1	1
12/29/2019 06:00	1.3	12.4	2,080.9	0.9	6.20	1	1	1
12/29/2019 07:00	1.1	12.6	2,016.7	0.8	6.10	1	1	1
12/29/2019 08:00	0.4	13.6	1,678.2	0.3	1.70	1	1	0
12/29/2019 09:00	0.3	13.6	1,610.4	0.2	1.60	1	1	0
12/29/2019 10:00	0.4	13.6	1,684.2	0.3	1.70	1	1	0
12/29/2019 11:00	0.4	13.6	1,660.2	0.3	1.70	1	1	0
12/29/2019 12:00	0.4	13.6	1,695.1	0.3	1.70	1	1	0
12/29/2019 13:00	0.4	13.6	1,624.9	0.3	1.60	1	1	0
12/29/2019 14:00	0.4	13.6	1,678.3	0.3	1.70	1	1	0
12/29/2019 15:00	0.8	13.1	1,874.1	0.6	3.70	1	1	1
12/29/2019 16:00	1.3	12.5	2,054.9	0.9	6.20	1	1	1
12/29/2019 17:00	1.4	12.4	2,075.0	1.0	8.30	1	1	1
12/29/2019 18:00	1.4	12.3	2,111.6	1.0	8.40	1	1	1
12/29/2019 19:00	1.4	12.3	2,112.0	1.0	8.40	1	1	1
12/29/2019 20:00	1.4	12.3	2,110.1	1.0	8.40	1	1	1
12/29/2019 21:00	1.4	12.3	2,110.6	1.0	8.40	1	1	1
12/29/2019 22:00	1.4	12.3	2,104.5	1.0	8.40	1	1	1
12/29/2019 23:00	1.4	12.4	2,079.7	1.0	8.30	1	1	1
Average/Sum#:	0.9	12.9	1,954.1	0.7	92.50 #	24 #	24 #	17 #
Minimum:	0.3	12.3	1,610.4	0.2	1.60	1	1	0
Maximum:	1.4	13.6	2,112.0	1.0	8.40	1	1	1
%SI	25.00	25.00	0.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/30/2019 00:00	1.4	12.5	2,060.5	1.0	8.20	1	1	1
12/30/2019 01:00	1.4	12.5	2,052.7	1.0	8.20	1	1	1
12/30/2019 02:00	1.4	12.6	2,033.9	1.0	8.10	1	1	1
12/30/2019 03:00	1.4	12.6	2,038.1	1.0	8.20	1	1	1
12/30/2019 04:00	1.3	12.7	2,032.3	0.9	6.10	1	1	1
12/30/2019 05:00	1.4	12.6	2,041.6	1.0	8.20	1	1	1
12/30/2019 06:00	1.4	12.5	2,054.6	1.0	8.20	1	1	1
12/30/2019 07:00	1.4	12.3	2,107.9	1.0	8.40	1	1	1
12/30/2019 08:00	1.4	12.4	2,086.6	1.0	8.30	1	1	1
12/30/2019 09:00	1.5	12.4	2,056.3	1.0	8.20	1	1	1
12/30/2019 10:00	1.5	12.5	2,035.9	1.1	8.10	1	1	1
12/30/2019 11:00	1.5	12.4	2,045.4	1.0	8.20	1	1	1
12/30/2019 12:00	1.6	12.4	2,046.0	1.1	8.20	1	1	1
12/30/2019 13:00	1.6	12.3	2,062.0	1.1	8.20	1	1	1
12/30/2019 14:00	1.6	12.3	2,055.5	1.1	8.20	1	1	1
12/30/2019 15:00	1.7	12.3	2,062.9	1.2	8.30	1	1	1
12/30/2019 16:00	1.6	12.3	2,072.2	1.1	8.30	1	1	1
12/30/2019 17:00	1.6	12.2	2,087.2	1.1	8.30	1	1	1
12/30/2019 18:00	1.4	12.2	2,114.9	0.9	6.30	1	1	1
12/30/2019 19:00	1.4	12.2	2,110.2	0.9	6.30	1	1	1
12/30/2019 20:00	1.4	12.3	2,094.3	1.0	8.40	1	1	1
12/30/2019 21:00	1.4	12.4	2,064.9	1.0	8.30	1	1	1
12/30/2019 22:00	1.6	12.4	2,066.9	1.1	8.30	1	1	1
12/30/2019 23:00	1.6	12.4	2,064.2	1.1	8.30	1	1	1
Average/Sum#:	1.5	12.4	2,064.5	1.0	191.80 #	24 #	24 #	24 #
Minimum:	1.3	12.2	2,032.3	0.9	6.10	1	1	1
Maximum:	1.7	12.7	2,114.9	1.2	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/31/2019 00:00	1.6	12.5	2,046.7	1.1	8.20	1	1	1
12/31/2019 01:00	1.5	12.9	1,944.9	1.1	7.80	1	1	1
12/31/2019 02:00	1.5	12.9	1,936.4	1.1	7.70	1	1	1
12/31/2019 03:00	1.4	12.9	1,950.1	1.0	7.80	1	1	1
12/31/2019 04:00	1.5	12.5	2,044.1	1.1	8.20	1	1	1
12/31/2019 05:00	1.5	12.5	2,039.9	1.1	8.20	1	1	1
12/31/2019 06:00	1.5	12.5	2,033.5	1.1	8.10	1	1	1
12/31/2019 07:00	1.5	12.5	2,033.3	1.1	8.10	1	1	1
12/31/2019 08:00	1.4	13.0	1,901.4	1.0	7.60	1	1	1
12/31/2019 09:00	0.4	13.7	1,527.7	0.3	1.50	1	1	0
12/31/2019 10:00	0.4	13.7	1,626.9	0.3	1.60	1	1	0
12/31/2019 11:00	0.3	13.7	1,589.1	0.2	1.60	1	1	0
12/31/2019 12:00	0.3	13.7	1,570.3	0.2	1.60	1	1	0
12/31/2019 13:00	0.4	13.7	1,668.9	0.3	1.70	1	1	0
12/31/2019 14:00	0.4	13.7	1,573.5	0.3	1.60	1	1	0
12/31/2019 15:00	0.4	13.6	1,588.1	0.3	1.60	1	1	1
12/31/2019 16:00	1.2	12.6	1,992.0	0.9	6.00	1	1	1
12/31/2019 17:00	1.4	12.5	2,024.4	1.0	8.10	1	1	1
12/31/2019 18:00	1.4	12.6	2,020.8	1.0	8.10	1	1	1
12/31/2019 19:00	1.4	12.6	2,025.6	1.0	8.10	1	1	1
12/31/2019 20:00	1.4	12.6	2,029.6	1.0	8.10	1	1	1
12/31/2019 21:00	1.4	12.5	2,041.2	1.0	8.20	1	1	1
12/31/2019 22:00	1.3	12.5	2,037.7	0.9	6.10	1	1	1
12/31/2019 23:00	1.3	12.6	2,030.0	0.9	6.10	1	1	1
Average/Sum#:	1.1	12.9	1,886.5	0.8	141.70 #	24 #	24 #	18 #
Minimum:	0.3	12.5	1,527.7	0.2	1.50	1	1	0
Maximum:	1.6	13.7	2,046.7	1.1	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

ATTACHMENT 7
Hourly Emissions – CO

FCD: AQ-16
Title V: #6

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2019 00:00	15.3	18.2	42.3	0.0	0.3	1	1	0
10/01/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/01/2019 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/01/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/01/2019 04:00	11.9	17.8	412.4	0.0	10.5	1	1	0
10/01/2019 05:00	15.3	14.9	1,149.8	0.0	38.7	1	1	0
10/01/2019 06:00	0.0	14.0	1,625.3	0.0	0.0	1	1	0
10/01/2019 07:00	0.0	14.0	1,615.8	0.0	0.0	1	1	0
10/01/2019 08:00	0.0	14.1	1,628.7	0.0	0.0	1	1	0
10/01/2019 09:00	0.0	14.1	1,613.9	0.0	0.0	1	1	0
10/01/2019 10:00	0.0	14.1	1,594.1	0.0	0.0	1	1	0
10/01/2019 11:00	0.0	14.1	1,600.9	0.0	0.0	1	1	0
10/01/2019 12:00	0.0	14.1	1,584.5	0.0	0.0	1	1	0
10/01/2019 13:00	0.0	14.1	1,585.8	0.0	0.0	1	1	0
10/01/2019 14:00	0.0	14.0	1,557.4	0.0	0.0	1	1	0
10/01/2019 15:00	0.0	14.0	1,577.6	0.0	0.0	1	1	1
10/01/2019 16:00	0.8	12.7	1,976.0	0.2	2.5	1	1	1
10/01/2019 17:00	0.7	12.4	2,020.5	0.4	2.2	1	1	1
10/01/2019 18:00	0.5	12.3	2,037.9	0.5	1.6	1	1	1
10/01/2019 19:00	0.2	12.2	2,041.4	0.3	0.6	1	1	1
10/01/2019 20:00	0.1	12.2	2,042.8	0.2	0.3	1	1	1
10/01/2019 21:00	0.1	12.3	2,029.9	0.1	0.3	1	1	1
10/01/2019 22:00	0.1	12.4	1,999.2	0.1	0.3	1	1	1
10/01/2019 23:00	0.2	12.5	2,009.0	0.1	0.6	1	1	1
Average/Sum#:	2.2	13.8	1,606.9	0.1	57.9 #	21 #	24 #	9 #
Minimum:	0.0	12.2	42.3	0.0	0.0	0	1	0
Maximum:	15.3	18.2	2,042.8	0.5	38.7	1	1	1
%SI	12.50	12.50	12.50	33.33	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/02/2019 00:00	0.2	12.4	2,056.0	0.1	0.6	1	1	1
10/02/2019 01:00	0.2	12.4	2,044.5	0.1	0.6	1	1	1
10/02/2019 02:00	0.2	12.4	2,031.7	0.1	0.6	1	1	1
10/02/2019 03:00	0.2	12.4	2,028.5	0.1	0.6	1	1	1
10/02/2019 04:00	0.2	12.6	1,989.4	0.1	0.6	1	1	1
10/02/2019 05:00	0.3	12.3	2,020.9	0.1	0.9	1	1	1
10/02/2019 06:00	0.2	12.5	2,017.8	0.1	0.6	1	1	1
10/02/2019 07:00	0.2	12.9	1,924.7	0.1	0.6	1	1	1
10/02/2019 08:00	0.0	14.1	1,560.2	0.1	0.0	1	1	0
10/02/2019 09:00	0.0	14.1	1,254.3	0.0	0.0	1	1	0
10/02/2019 10:00	0.0	14.1	1,263.2	0.0	0.0	1	1	0
10/02/2019 11:00	0.0	14.2	1,285.9	0.0	0.0	1	1	0
10/02/2019 12:00	0.0	14.2	1,257.9	0.0	0.0	1	1	0
10/02/2019 13:00	0.0	14.2	1,276.3	0.0	0.0	1	1	0
10/02/2019 14:00	0.0	14.0	1,537.0	0.0	0.0	1	1	1
10/02/2019 15:00	0.7	12.7	1,966.4	0.2	2.2	1	1	1
10/02/2019 16:00	0.7	12.2	2,051.6	0.3	2.2	1	1	1
10/02/2019 17:00	0.6	12.1	2,072.2	0.5	1.9	1	1	1
10/02/2019 18:00	0.6	12.2	2,065.4	0.4	1.9	1	1	1
10/02/2019 19:00	0.4	12.1	2,064.0	0.4	1.2	1	1	1
10/02/2019 20:00	0.2	12.1	2,060.4	0.3	0.6	1	1	1
10/02/2019 21:00	0.2	12.2	2,035.8	0.2	0.6	1	1	1
10/02/2019 22:00	0.2	12.4	2,005.7	0.1	0.6	1	1	1
10/02/2019 23:00	0.2	12.7	1,971.1	0.1	0.6	1	1	1
Average/Sum#:	0.2	12.9	1,826.7	0.1	16.9 #	24 #	24 #	18 #
Minimum:	0.0	12.1	1,254.3	0.0	0.0	1	1	0
Maximum:	0.7	14.2	2,072.2	0.5	2.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/03/2019 00:00	0.2	12.6	1,974.8	0.1	0.6	1	1	1
10/03/2019 01:00	0.1	12.9	1,912.3	0.1	0.3	1	1	1
10/03/2019 02:00	0.2	12.7	1,964.7	0.1	0.6	1	1	1
10/03/2019 03:00	0.2	12.5	1,997.3	0.1	0.6	1	1	1
10/03/2019 04:00	0.2	12.5	2,015.1	0.1	0.6	1	1	1
10/03/2019 05:00	0.3	12.5	2,007.9	0.1	0.9	1	1	1
10/03/2019 06:00	0.2	12.4	2,026.9	0.1	0.6	1	1	1
10/03/2019 07:00	0.2	12.7	1,928.3	0.1	0.6	1	1	1
10/03/2019 08:00	0.0	14.0	1,450.1	0.1	0.0	1	1	0
10/03/2019 09:00	0.0	14.1	1,259.2	0.0	0.0	1	1	0
10/03/2019 10:00	0.0	14.1	1,247.4	0.0	0.0	1	1	0
10/03/2019 11:00	0.0	14.1	1,248.7	0.0	0.0	1	1	0
10/03/2019 12:00	0.0	14.1	1,307.6	0.0	0.0	1	1	0
10/03/2019 13:00	0.0	14.1	1,290.2	0.0	0.0	1	1	0
10/03/2019 14:00	0.0	14.1	1,343.0	0.0	0.0	1	1	0
10/03/2019 15:00	0.0	14.1	1,353.6	0.0	0.0	1	1	0
10/03/2019 16:00	0.0	14.0	1,595.8	0.0	0.0	1	1	0
10/03/2019 17:00	0.0	14.0	1,582.6	0.0	0.0	1	1	0
10/03/2019 18:00	0.0	14.0	1,585.6	0.0	0.0	1	1	0
10/03/2019 19:00	0.0	14.0	1,613.7	0.0	0.0	1	1	0
10/03/2019 20:00	0.0	14.1	1,594.8	0.0	0.0	1	1	0
10/03/2019 21:00	3.5	14.7	1,232.4	0.0	6.6	1	0	0
10/03/2019 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2019 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.2	13.6	1,615.1	0.0	11.4 #	22 #	21 #	8 #
Minimum:	0.0	12.4	1,232.4	0.0	0.0	0	0	0
Maximum:	3.5	14.7	2,026.9	0.1	6.6	1	1	1
%SI	8.33	8.33	8.33	12.50	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2019 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2019 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2019 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/04/2019 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/04/2019 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/04/2019 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/04/2019 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/04/2019 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/04/2019 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/04/2019 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/04/2019 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/04/2019 13:00	15.6	18.0	387.9	0.0	11.6	1	1	0
10/04/2019 14:00	19.6	15.3	914.2	0.0	42.3	1	1	0
10/04/2019 15:00	0.0	14.2	1,414.6	0.0	0.0	1	1	0
10/04/2019 16:00	0.0	14.1	1,507.0	0.0	0.0	1	1	1
10/04/2019 17:00	0.6	12.8	1,963.5	0.1	1.9	1	1	1
10/04/2019 18:00	0.4	12.2	2,093.2	0.2	1.3	1	1	1
10/04/2019 19:00	0.2	12.3	2,036.0	0.3	0.6	1	1	1
10/04/2019 20:00	0.2	12.2	2,046.2	0.2	0.6	1	1	1
10/04/2019 21:00	0.1	12.3	2,037.7	0.1	0.3	1	1	1
10/04/2019 22:00	0.1	12.4	2,015.0	0.1	0.3	1	1	1
10/04/2019 23:00	0.2	12.5	1,999.3	0.1	0.6	1	1	1
Average/Sum#:	3.4	13.5	1,674.1	0.2	59.5 #	11 #	20 #	8 #
Minimum:	0.0	12.2	387.9	0.1	0.0	0	0	0
Maximum:	19.6	18.0	2,093.2	0.3	42.3	1	1	1
%SI	54.17	54.17	54.17	70.83	54.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/05/2019 00:00	0.2	12.7	1,959.8	0.1	0.6	1	1	1
10/05/2019 01:00	0.2	12.8	1,941.2	0.1	0.6	1	1	1
10/05/2019 02:00	0.1	13.0	1,904.4	0.1	0.3	1	1	1
10/05/2019 03:00	0.2	12.6	1,979.6	0.1	0.6	1	1	1
10/05/2019 04:00	0.2	12.5	2,008.3	0.1	0.6	1	1	1
10/05/2019 05:00	0.3	12.3	2,034.5	0.1	0.9	1	1	1
10/05/2019 06:00	0.2	12.7	1,981.1	0.1	0.6	1	1	1
10/05/2019 07:00	0.2	13.0	1,890.7	0.1	0.6	1	1	1
10/05/2019 08:00	0.0	14.0	1,495.3	0.1	0.0	1	1	0
10/05/2019 09:00	0.0	14.2	1,248.9	0.0	0.0	1	1	0
10/05/2019 10:00	0.0	14.2	1,243.4	0.0	0.0	1	1	0
10/05/2019 11:00	0.0	14.2	1,249.6	0.0	0.0	1	1	0
10/05/2019 12:00	0.0	14.2	1,297.4	0.0	0.0	1	1	0
10/05/2019 13:00	0.0	14.2	1,249.9	0.0	0.0	1	1	0
10/05/2019 14:00	0.0	14.2	1,429.4	0.0	0.0	1	1	0
10/05/2019 15:00	0.0	14.0	1,477.3	0.0	0.0	1	1	1
10/05/2019 16:00	0.6	12.8	1,930.6	0.1	1.9	1	1	1
10/05/2019 17:00	0.7	12.4	2,014.8	0.3	2.2	1	1	1
10/05/2019 18:00	0.7	12.4	2,021.5	0.5	2.2	1	1	1
10/05/2019 19:00	0.6	12.3	2,039.0	0.5	1.9	1	1	1
10/05/2019 20:00	0.6	12.1	2,077.2	0.4	1.9	1	1	1
10/05/2019 21:00	0.6	12.1	2,081.1	0.4	1.9	1	1	1
10/05/2019 22:00	0.6	12.2	2,048.9	0.4	1.9	1	1	1
10/05/2019 23:00	0.6	12.3	2,049.9	0.4	1.9	1	1	1
Average/Sum#:	0.3	13.1	1,777.2	0.2	20.6 #	24 #	24 #	17 #
Minimum:	0.0	12.1	1,243.4	0.0	0.0	1	1	0
Maximum:	0.7	14.2	2,081.1	0.5	2.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/06/2019 00:00	0.6	12.3	2,028.2	0.4	1.9	1	1	1
10/06/2019 01:00	0.6	12.6	1,974.3	0.4	1.9	1	1	1
10/06/2019 02:00	0.7	12.6	1,977.7	0.4	2.2	1	1	1
10/06/2019 03:00	0.7	12.6	1,977.2	0.5	2.2	1	1	1
10/06/2019 04:00	0.4	12.5	1,968.9	0.4	1.2	1	1	1
10/06/2019 05:00	0.3	12.4	1,976.0	0.3	0.9	1	1	1
10/06/2019 06:00	0.2	12.7	1,916.2	0.2	0.6	1	1	1
10/06/2019 07:00	0.0	14.1	1,478.5	0.1	0.0	1	1	0
10/06/2019 08:00	0.0	14.2	1,311.8	0.0	0.0	1	1	0
10/06/2019 09:00	0.0	14.2	1,235.3	0.0	0.0	1	1	0
10/06/2019 10:00	0.0	14.2	1,290.1	0.0	0.0	1	1	0
10/06/2019 11:00	0.0	14.2	1,320.5	0.0	0.0	1	1	0
10/06/2019 12:00	0.0	14.2	1,354.5	0.0	0.0	1	1	0
10/06/2019 13:00	0.0	14.2	1,326.5	0.0	0.0	1	1	0
10/06/2019 14:00	0.0	14.0	1,550.8	0.0	0.0	1	1	1
10/06/2019 15:00	0.6	12.5	1,975.8	0.1	1.9	1	1	1
10/06/2019 16:00	0.6	12.2	2,044.0	0.3	1.9	1	1	1
10/06/2019 17:00	0.5	11.8	2,113.5	0.4	1.5	1	1	1
10/06/2019 18:00	0.5	11.7	2,145.2	0.3	1.5	1	1	1
10/06/2019 19:00	0.5	12.0	2,081.7	0.3	1.5	1	1	1
10/06/2019 20:00	0.5	12.1	2,063.8	0.3	1.5	1	1	1
10/06/2019 21:00	0.6	12.1	2,069.2	0.3	1.9	1	1	1
10/06/2019 22:00	0.6	12.4	2,029.3	0.4	1.9	1	1	1
10/06/2019 23:00	0.3	12.6	1,971.4	0.3	0.9	1	1	1
Average/Sum#:	0.3	12.9	1,799.2	0.2	25.4 #	24 #	24 #	17 #
Minimum:	0.0	11.7	1,235.3	0.0	0.0	1	1	0
Maximum:	0.7	14.2	2,145.2	0.5	2.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/07/2019 00:00	0.2	12.6	1,953.0	0.2	0.6	1	1	1
10/07/2019 01:00	0.1	12.5	1,972.6	0.1	0.3	1	1	1
10/07/2019 02:00	0.2	12.6	1,946.1	0.1	0.6	1	1	1
10/07/2019 03:00	0.2	12.6	1,979.6	0.1	0.6	1	1	1
10/07/2019 04:00	0.2	12.3	2,020.0	0.1	0.6	1	1	1
10/07/2019 05:00	0.3	12.3	2,006.1	0.1	0.9	1	1	1
10/07/2019 06:00	0.3	12.4	2,028.9	0.2	0.9	1	1	1
10/07/2019 07:00	0.6	12.5	2,016.6	0.3	1.9	1	1	1
10/07/2019 08:00	0.6	12.4	2,010.8	0.3	1.9	1	1	1
10/07/2019 09:00	0.6	12.4	2,028.9	0.4	1.9	1	1	1
10/07/2019 10:00	0.6	12.4	2,005.9	0.4	1.9	1	1	1
10/07/2019 11:00	0.6	12.5	1,984.6	0.4	1.9	1	1	1
10/07/2019 12:00	0.5	12.4	1,984.8	0.4	1.5	1	1	1
10/07/2019 13:00	0.5	12.3	2,008.6	0.3	1.5	1	1	1
10/07/2019 14:00	0.5	12.3	2,009.2	0.3	1.5	1	1	1
10/07/2019 15:00	0.5	12.3	2,005.4	0.3	1.5	1	1	1
10/07/2019 16:00	0.5	12.0	2,063.4	0.3	1.5	1	1	1
10/07/2019 17:00	0.5	11.7	2,111.3	0.3	1.5	1	1	1
10/07/2019 18:00	0.5	11.8	2,108.8	0.3	1.5	1	1	1
10/07/2019 19:00	0.5	12.0	2,054.5	0.3	1.5	1	1	1
10/07/2019 20:00	0.5	12.1	2,046.3	0.3	1.5	1	1	1
10/07/2019 21:00	0.5	12.4	2,008.2	0.3	1.6	1	1	1
10/07/2019 22:00	0.5	12.3	2,026.2	0.3	1.6	1	1	1
10/07/2019 23:00	0.6	12.6	1,961.2	0.3	1.9	1	1	1
Average/Sum#:	0.4	12.3	2,014.2	0.3	32.6 #	24 #	24 #	24 #
Minimum:	0.1	11.7	1,946.1	0.1	0.3	1	1	1
Maximum:	0.6	12.6	2,111.3	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/08/2019 00:00	0.5	12.8	1,913.4	0.4	1.6	1	1	1
10/08/2019 01:00	0.5	13.1	1,852.1	0.4	1.6	1	1	1
10/08/2019 02:00	0.5	13.2	1,856.3	0.4	1.6	1	1	1
10/08/2019 03:00	0.6	12.9	1,910.0	0.4	1.9	1	1	1
10/08/2019 04:00	0.6	12.8	1,925.0	0.4	1.9	1	1	1
10/08/2019 05:00	0.7	12.3	2,012.4	0.4	2.2	1	1	1
10/08/2019 06:00	0.3	12.3	2,007.0	0.4	0.9	1	1	1
10/08/2019 07:00	0.3	12.5	1,974.9	0.3	0.9	1	1	1
10/08/2019 08:00	0.2	12.5	1,968.7	0.2	0.6	1	1	1
10/08/2019 09:00	0.2	12.5	1,960.4	0.1	0.6	1	1	1
10/08/2019 10:00	0.1	12.4	1,961.8	0.1	0.3	1	1	1
10/08/2019 11:00	0.1	12.3	1,964.8	0.1	0.3	1	1	1
10/08/2019 12:00	0.1	12.2	1,981.7	0.1	0.3	1	1	1
10/08/2019 13:00	0.4	12.3	1,991.0	0.2	1.2	1	1	1
10/08/2019 14:00	0.5	12.4	1,974.8	0.2	1.5	1	1	1
10/08/2019 15:00	0.6	12.3	2,000.2	0.3	1.8	1	1	1
10/08/2019 16:00	0.5	12.1	2,047.2	0.3	1.5	1	1	1
10/08/2019 17:00	0.5	11.8	2,090.4	0.3	1.5	1	1	1
10/08/2019 18:00	0.5	11.9	2,070.3	0.3	1.5	1	1	1
10/08/2019 19:00	0.5	12.0	2,056.2	0.3	1.5	1	1	1
10/08/2019 20:00	0.5	12.0	2,057.4	0.3	1.5	1	1	1
10/08/2019 21:00	0.3	12.2	2,023.9	0.3	0.9	1	1	1
10/08/2019 22:00	0.2	12.5	1,940.0	0.2	0.6	1	1	1
10/08/2019 23:00	0.2	12.4	1,967.7	0.1	0.6	1	1	1
Average/Sum#:	0.4	12.4	1,979.5	0.3	28.8 #	24 #	24 #	24 #
Minimum:	0.1	11.8	1,852.1	0.1	0.3	1	1	1
Maximum:	0.7	13.2	2,090.4	0.4	2.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/09/2019 00:00	0.2	12.4	1,975.5	0.1	0.6	1	1	1
10/09/2019 01:00	0.1	12.9	1,895.4	0.1	0.3	1	1	1
10/09/2019 02:00	0.2	12.8	1,920.1	0.1	0.6	1	1	1
10/09/2019 03:00	0.2	12.5	1,981.7	0.1	0.6	1	1	1
10/09/2019 04:00	0.2	12.4	2,006.7	0.1	0.6	1	1	1
10/09/2019 05:00	0.3	12.4	2,000.6	0.1	0.9	1	1	1
10/09/2019 06:00	0.2	12.2	2,057.8	0.1	0.6	1	1	1
10/09/2019 07:00	0.2	12.4	2,019.5	0.1	0.6	1	1	1
10/09/2019 08:00	0.2	12.5	1,982.1	0.1	0.6	1	1	1
10/09/2019 09:00	0.2	12.5	1,996.4	0.1	0.6	1	1	1
10/09/2019 10:00	0.2	12.4	2,005.0	0.1	0.6	1	1	1
10/09/2019 11:00	0.0	14.1	1,624.7	0.1	0.0	1	1	0
10/09/2019 12:00	0.0	14.2	1,608.8	0.0	0.0	1	1	0
10/09/2019 13:00	0.0	14.1	1,555.0	0.0	0.0	1	1	0
10/09/2019 14:00	0.0	14.2	1,475.5	0.0	0.0	1	1	0
10/09/2019 15:00	0.0	14.1	1,484.0	0.0	0.0	1	1	1
10/09/2019 16:00	0.2	13.0	1,828.1	0.0	0.6	1	1	1
10/09/2019 17:00	0.5	12.6	1,987.9	0.2	1.6	1	1	1
10/09/2019 18:00	0.5	12.7	1,973.2	0.3	1.6	1	1	1
10/09/2019 19:00	0.4	12.5	1,979.7	0.4	1.2	1	1	1
10/09/2019 20:00	0.2	12.5	1,987.3	0.3	0.6	1	1	1
10/09/2019 21:00	0.2	12.5	1,982.7	0.2	0.6	1	1	1
10/09/2019 22:00	0.2	12.5	1,990.8	0.1	0.6	1	1	1
10/09/2019 23:00	0.2	12.6	1,979.2	0.1	0.6	1	1	1
Average/Sum#:	0.2	12.9	1,887.4	0.1	14.0 #	24 #	24 #	20 #
Minimum:	0.0	12.2	1,475.5	0.0	0.0	1	1	0
Maximum:	0.5	14.2	2,057.8	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/10/2019 00:00	0.2	12.6	1,978.3	0.1	0.6	1	1	1
10/10/2019 01:00	0.1	13.2	1,873.7	0.1	0.3	1	1	1
10/10/2019 02:00	0.2	13.0	1,915.8	0.1	0.6	1	1	1
10/10/2019 03:00	0.2	12.7	1,968.6	0.1	0.6	1	1	1
10/10/2019 04:00	0.2	12.7	1,969.9	0.1	0.6	1	1	1
10/10/2019 05:00	0.3	12.7	1,968.4	0.1	1.0	1	1	1
10/10/2019 06:00	0.3	12.6	2,001.8	0.2	1.0	1	1	1
10/10/2019 07:00	0.2	12.9	1,907.1	0.2	0.6	1	1	1
10/10/2019 08:00	0.0	14.1	1,446.8	0.1	0.0	1	1	0
10/10/2019 09:00	0.0	14.1	1,575.1	0.0	0.0	1	1	0
10/10/2019 10:00	0.0	14.1	1,609.9	0.0	0.0	1	1	0
10/10/2019 11:00	0.0	14.1	1,602.9	0.0	0.0	1	1	0
10/10/2019 12:00	0.0	14.2	1,613.2	0.0	0.0	1	1	0
10/10/2019 13:00	0.0	14.2	1,577.3	0.0	0.0	1	1	0
10/10/2019 14:00	0.0	14.1	1,592.7	0.0	0.0	1	1	0
10/10/2019 15:00	0.0	14.1	1,494.6	0.0	0.0	1	1	1
10/10/2019 16:00	0.2	12.4	1,979.9	0.0	0.6	1	1	1
10/10/2019 17:00	0.2	12.5	1,957.8	0.1	0.6	1	1	1
10/10/2019 18:00	0.5	12.3	2,032.2	0.2	1.6	1	1	1
10/10/2019 19:00	0.6	12.4	2,017.2	0.3	1.9	1	1	1
10/10/2019 20:00	0.7	12.4	2,019.8	0.4	2.2	1	1	1
10/10/2019 21:00	0.6	12.4	2,024.1	0.4	1.9	1	1	1
10/10/2019 22:00	0.5	12.4	2,017.3	0.4	1.6	1	1	1
10/10/2019 23:00	0.2	12.7	1,933.5	0.3	0.6	1	1	1
Average/Sum#:	0.2	13.1	1,836.6	0.1	16.3 #	24 #	24 #	17 #
Minimum:	0.0	12.3	1,446.8	0.0	0.0	1	1	0
Maximum:	0.7	14.2	2,032.2	0.4	2.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/11/2019 00:00	0.1	12.8	1,921.0	0.2	0.3	1	1	1
10/11/2019 01:00	0.1	13.2	1,849.5	0.1	0.3	1	1	1
10/11/2019 02:00	0.1	13.2	1,849.2	0.1	0.3	1	1	1
10/11/2019 03:00	0.1	13.2	1,852.3	0.1	0.3	1	1	1
10/11/2019 04:00	0.1	13.2	1,853.9	0.1	0.3	1	1	1
10/11/2019 05:00	0.0	14.1	1,636.2	0.1	0.0	1	1	1
10/11/2019 06:00	0.0	14.1	1,619.2	0.0	0.0	1	1	0
10/11/2019 07:00	0.0	14.2	1,381.8	0.0	0.0	1	1	0
10/11/2019 08:00	0.0	14.2	1,234.2	0.0	0.0	1	1	0
10/11/2019 09:00	0.0	14.2	1,232.1	0.0	0.0	1	1	0
10/11/2019 10:00	0.0	14.2	1,230.5	0.0	0.0	1	1	0
10/11/2019 11:00	0.0	14.2	1,230.6	0.0	0.0	1	1	0
10/11/2019 12:00	0.0	14.2	1,232.3	0.0	0.0	1	1	0
10/11/2019 13:00	0.0	14.2	1,264.1	0.0	0.0	1	1	0
10/11/2019 14:00	0.0	14.0	1,609.3	0.0	0.0	1	1	0
10/11/2019 15:00	0.0	14.0	1,542.3	0.0	0.0	1	1	1
10/11/2019 16:00	0.6	12.7	1,964.1	0.1	1.9	1	1	1
10/11/2019 17:00	0.6	11.9	2,106.6	0.3	1.9	1	1	1
10/11/2019 18:00	0.5	11.7	2,141.4	0.4	1.5	1	1	1
10/11/2019 19:00	0.5	12.2	2,051.6	0.3	1.6	1	1	1
10/11/2019 20:00	0.6	12.3	2,037.1	0.3	1.9	1	1	1
10/11/2019 21:00	0.6	12.3	2,047.1	0.4	1.9	1	1	1
10/11/2019 22:00	0.6	12.4	2,035.8	0.4	1.9	1	1	1
10/11/2019 23:00	0.3	12.4	2,030.9	0.3	0.9	1	1	1
Average/Sum#:	0.2	13.3	1,706.4	0.1	15.0 #	24 #	24 #	15 #
Minimum:	0.0	11.7	1,230.5	0.0	0.0	1	1	0
Maximum:	0.6	14.2	2,141.4	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/12/2019 00:00	0.2	12.3	2,026.7	0.2	0.6	1	1	1
10/12/2019 01:00	0.2	12.4	1,990.5	0.1	0.6	1	1	1
10/12/2019 02:00	0.2	12.4	2,002.0	0.1	0.6	1	1	1
10/12/2019 03:00	0.2	12.4	2,017.3	0.1	0.6	1	1	1
10/12/2019 04:00	0.2	12.3	2,020.6	0.1	0.6	1	1	1
10/12/2019 05:00	0.3	12.2	2,033.2	0.1	0.9	1	1	1
10/12/2019 06:00	0.3	12.3	2,037.8	0.2	0.9	1	1	1
10/12/2019 07:00	5.6	14.1	1,219.8	0.0	6.7	1	0	1
10/12/2019 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2019 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2019 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2019 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2019 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2019 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/12/2019 14:00	9.5	17.9	390.1	0.0	7.3	1	1	0
10/12/2019 15:00	11.3	15.2	989.1	0.0	25.9	1	1	0
10/12/2019 16:00	0.0	14.1	1,604.4	0.0	0.0	1	1	0
10/12/2019 17:00	0.1	13.5	1,741.4	0.0	0.3	1	1	1
10/12/2019 18:00	0.6	12.3	2,020.1	0.2	1.9	1	1	1
10/12/2019 19:00	0.5	12.2	2,042.2	0.3	1.6	1	1	1
10/12/2019 20:00	0.5	12.3	2,037.0	0.3	1.6	1	1	1
10/12/2019 21:00	0.5	12.2	2,052.3	0.3	1.6	1	1	1
10/12/2019 22:00	0.5	12.3	2,029.9	0.3	1.6	1	1	1
10/12/2019 23:00	0.4	12.3	2,056.3	0.3	1.3	1	1	1
Average/Sum#:	1.7	13.0	1,795.0	0.2	54.6 #	18 #	18 #	15 #
Minimum:	0.0	12.2	390.1	0.1	0.0	0	0	0
Maximum:	11.3	17.9	2,056.3	0.3	25.9	1	1	1
%SI	25.00	25.00	25.00	45.83	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/13/2019 00:00	0.3	12.3	2,026.8	0.3	0.9	1	1	1
10/13/2019 01:00	0.2	12.3	2,027.3	0.2	0.6	1	1	1
10/13/2019 02:00	0.2	12.3	2,025.9	0.1	0.6	1	1	1
10/13/2019 03:00	0.2	12.3	2,026.9	0.1	0.6	1	1	1
10/13/2019 04:00	0.2	12.3	2,028.3	0.1	0.6	1	1	1
10/13/2019 05:00	0.3	12.3	2,029.4	0.1	0.9	1	1	1
10/13/2019 06:00	0.2	12.4	1,969.0	0.1	0.6	1	1	1
10/13/2019 07:00	0.0	14.1	1,477.2	0.1	0.0	1	1	1
10/13/2019 08:00	0.0	14.1	1,587.3	0.0	0.0	1	1	0
10/13/2019 09:00	0.0	14.1	1,612.4	0.0	0.0	1	1	0
10/13/2019 10:00	0.0	14.1	1,605.5	0.0	0.0	1	1	0
10/13/2019 11:00	0.0	14.1	1,484.2	0.0	0.0	1	1	0
10/13/2019 12:00	0.0	14.1	1,613.6	0.0	0.0	1	1	0
10/13/2019 13:00	0.0	14.1	1,505.0	0.0	0.0	1	1	0
10/13/2019 14:00	0.0	14.1	1,600.6	0.0	0.0	1	1	0
10/13/2019 15:00	0.0	14.0	1,509.0	0.0	0.0	1	1	1
10/13/2019 16:00	0.6	12.5	1,975.9	0.1	1.9	1	1	1
10/13/2019 17:00	0.6	12.0	2,063.5	0.3	1.8	1	1	1
10/13/2019 18:00	0.5	12.2	2,036.2	0.4	1.5	1	1	1
10/13/2019 19:00	0.5	12.3	2,017.4	0.3	1.5	1	1	1
10/13/2019 20:00	0.6	12.4	2,015.0	0.3	1.9	1	1	1
10/13/2019 21:00	0.5	12.2	2,039.3	0.3	1.5	1	1	1
10/13/2019 22:00	0.2	13.0	1,801.6	0.3	0.6	1	1	1
10/13/2019 23:00	5.6	15.0	968.5	0.0	5.1	1	0	0
Average/Sum#:	0.4	13.1	1,793.6	0.1	20.6 #	24 #	23 #	16 #
Minimum:	0.0	12.0	968.5	0.0	0.0	1	0	0
Maximum:	5.6	15.0	2,063.5	0.4	5.1	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/14/2019 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2019 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2019 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/14/2019 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/14/2019 06:00	9.7	18.4	370.6	0.0	5.1	1	1	0
10/14/2019 07:00	20.6	14.9	1,000.6	0.0	45.4	1	1	0
10/14/2019 08:00	0.0	14.0	1,459.7	0.0	0.0	1	1	0
10/14/2019 09:00	0.0	14.1	1,251.1	0.0	0.0	1	1	0
10/14/2019 10:00	0.0	14.2	1,237.2	0.0	0.0	1	1	0
10/14/2019 11:00	0.0	14.2	1,306.3	0.0	0.0	1	1	0
10/14/2019 12:00	0.0	14.1	1,440.3	0.0	0.0	1	1	0
10/14/2019 13:00	0.1	13.9	1,556.7	0.0	0.3	1	1	1
10/14/2019 14:00	0.6	13.1	1,937.9	0.2	2.0	1	1	1
10/14/2019 15:00	0.6	12.4	1,992.8	0.3	1.9	1	1	1
10/14/2019 16:00	0.5	12.1	2,052.5	0.4	1.5	1	1	1
10/14/2019 17:00	0.5	11.8	2,111.5	0.3	1.5	1	1	1
10/14/2019 18:00	0.4	11.7	2,145.0	0.3	1.2	1	1	1
10/14/2019 19:00	0.4	11.7	2,145.8	0.3	1.2	1	1	1
10/14/2019 20:00	0.5	12.0	2,088.4	0.3	1.5	1	1	1
10/14/2019 21:00	0.5	12.3	2,037.8	0.3	1.6	1	1	1
10/14/2019 22:00	0.5	12.4	2,030.2	0.3	1.6	1	1	1
10/14/2019 23:00	0.5	12.4	2,026.9	0.3	1.6	1	1	1
Average/Sum#:	2.0	13.3	1,677.3	0.2	66.4 #	18 #	20 #	11 #
Minimum:	0.0	11.7	370.6	0.0	0.0	0	0	0
Maximum:	20.6	18.4	2,145.8	0.4	45.4	1	1	1
%SI	25.00	25.00	25.00	41.67	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/15/2019 00:00	0.6	12.4	2,031.7	0.3	1.9	1	1	1
10/15/2019 01:00	0.6	12.4	2,022.6	0.4	1.9	1	1	1
10/15/2019 02:00	0.6	12.4	2,030.7	0.4	1.9	1	1	1
10/15/2019 03:00	0.6	12.5	2,021.2	0.4	1.9	1	1	1
10/15/2019 04:00	0.3	12.4	2,018.6	0.3	0.9	1	1	1
10/15/2019 05:00	6.3	14.4	1,483.8	0.0	14.6	1	1	1
10/15/2019 06:00	16.1	17.5	471.5	0.0	11.8	1	1	0
10/15/2019 07:00	6.5	13.9	1,506.9	0.0	18.5	1	1	1
10/15/2019 08:00	0.0	14.1	1,470.6	0.0	0.0	1	1	0
10/15/2019 09:00	0.0	14.1	1,304.8	0.0	0.0	1	1	0
10/15/2019 10:00	0.0	14.1	1,279.7	0.0	0.0	1	1	0
10/15/2019 11:00	0.0	14.1	1,313.0	0.0	0.0	1	1	0
10/15/2019 12:00	0.0	14.1	1,395.1	0.0	0.0	1	1	0
10/15/2019 13:00	0.0	14.1	1,611.4	0.0	0.0	1	1	0
10/15/2019 14:00	0.0	13.9	1,604.7	0.0	0.0	1	1	1
10/15/2019 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/15/2019 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/15/2019 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/15/2019 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/15/2019 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/15/2019 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/15/2019 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/15/2019 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/15/2019 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	2.1	13.8	1,571.1	0.2	53.4 #	15 #	24 #	8 #
Minimum:	0.0	12.4	471.5	0.0	0.0	0	1	0
Maximum:	16.1	17.5	2,031.7	0.4	18.5	1	1	1
%SI	37.50	37.50	37.50	58.33	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/16/2019 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2019 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2019 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2019 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2019 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2019 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2019 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2019 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2019 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2019 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2019 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2019 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2019 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2019 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2019 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2019 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2019 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2019 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2019 20:00	59.1	18.1	371.0	0.0	33.1	1	1	0
10/16/2019 21:00	15.7	15.7	818.9	0.0	32.7	1	1	0
10/16/2019 22:00	0.0	14.0	1,399.1	0.0	0.0	1	1	0
10/16/2019 23:00	0.0	14.0	1,589.3	0.0	0.0	1	1	0
Average/Sum#:	18.7	15.5	1,044.6	0.0	65.8 #	4 #	24 #	0 #
Minimum:	0.0	14.0	371.0	0.0	0.0	0	1	0
Maximum:	59.1	18.1	1,589.3	0.0	33.1	1	1	0
%SI	83.33	83.33	83.33	100.00	83.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/17/2019 00:00	0.0	14.0	1,563.3	0.0	0.0	1	1	0
10/17/2019 01:00	0.0	14.0	1,625.3	0.0	0.0	1	1	1
10/17/2019 02:00	0.4	12.9	1,908.6	0.1	1.3	1	1	1
10/17/2019 03:00	0.3	12.8	1,936.7	0.2	0.9	1	1	1
10/17/2019 04:00	0.3	12.6	1,979.0	0.2	0.9	1	1	1
10/17/2019 05:00	0.3	12.7	1,961.4	0.2	0.9	1	1	1
10/17/2019 06:00	0.2	12.4	2,018.7	0.2	0.6	1	1	1
10/17/2019 07:00	0.1	12.6	1,979.9	0.1	0.3	1	1	1
10/17/2019 08:00	0.0	13.8	1,517.6	0.1	0.0	1	1	1
10/17/2019 09:00	0.0	14.0	1,469.0	0.0	0.0	1	1	0
10/17/2019 10:00	0.0	14.0	1,483.2	0.0	0.0	1	1	0
10/17/2019 11:00	0.0	14.1	1,527.2	0.0	0.0	1	1	0
10/17/2019 12:00	0.0	14.1	1,304.5	0.0	0.0	1	1	0
10/17/2019 13:00	0.0	14.1	1,456.5	0.0	0.0	1	1	0
10/17/2019 14:00	0.0	14.1	1,548.2	0.0	0.0	1	1	0
10/17/2019 15:00	0.0	14.1	1,486.6	0.0	0.0	1	1	1
10/17/2019 16:00	0.5	12.8	1,937.0	0.1	1.6	1	1	1
10/17/2019 17:00	0.5	11.9	2,133.0	0.2	1.6	1	1	1
10/17/2019 18:00	0.5	12.1	2,078.9	0.3	1.6	1	1	1
10/17/2019 19:00	0.5	12.3	2,049.5	0.3	1.6	1	1	1
10/17/2019 20:00	0.5	12.2	2,064.2	0.3	1.6	1	1	1
10/17/2019 21:00	0.3	12.2	2,044.6	0.3	0.9	1	1	1
10/17/2019 22:00	0.2	12.6	1,963.0	0.2	0.6	1	1	1
10/17/2019 23:00	0.2	12.8	1,921.5	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.1	1,789.9	0.1	15.0 #	24 #	24 #	17 #
Minimum:	0.0	11.9	1,304.5	0.0	0.0	1	1	0
Maximum:	0.5	14.1	2,133.0	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/18/2019 00:00	0.2	12.9	1,899.3	0.1	0.6	1	1	1
10/18/2019 01:00	0.2	12.9	1,894.9	0.1	0.6	1	1	1
10/18/2019 02:00	0.2	13.2	1,843.6	0.1	0.6	1	1	1
10/18/2019 03:00	0.2	13.1	1,892.6	0.2	0.6	1	1	1
10/18/2019 04:00	0.4	12.7	1,960.8	0.2	1.3	1	1	1
10/18/2019 05:00	0.4	12.7	1,947.5	0.3	1.3	1	1	1
10/18/2019 06:00	0.4	12.5	2,010.8	0.3	1.3	1	1	1
10/18/2019 07:00	0.2	13.2	1,831.6	0.3	0.6	1	1	1
10/18/2019 08:00	0.0	14.0	1,522.1	0.2	0.0	1	1	0
10/18/2019 09:00	0.0	14.0	1,471.4	0.1	0.0	1	1	0
10/18/2019 10:00	0.0	14.0	1,480.7	0.0	0.0	1	1	0
10/18/2019 11:00	0.0	14.0	1,489.2	0.0	0.0	1	1	0
10/18/2019 12:00	0.0	14.0	1,445.2	0.0	0.0	1	1	0
10/18/2019 13:00	0.0	14.0	1,556.2	0.0	0.0	1	1	0
10/18/2019 14:00	0.0	14.0	1,553.8	0.0	0.0	1	1	0
10/18/2019 15:00	0.0	14.0	1,569.7	0.0	0.0	1	1	1
10/18/2019 16:00	0.6	12.5	1,982.3	0.1	1.9	1	1	1
10/18/2019 17:00	0.5	12.2	2,041.7	0.2	1.5	1	1	1
10/18/2019 18:00	0.5	12.6	1,965.8	0.4	1.6	1	1	1
10/18/2019 19:00	0.5	12.5	1,974.8	0.4	1.6	1	1	1
10/18/2019 20:00	0.5	12.2	2,035.2	0.4	1.5	1	1	1
10/18/2019 21:00	0.5	12.2	2,051.9	0.3	1.6	1	1	1
10/18/2019 22:00	0.5	12.5	1,990.1	0.3	1.6	1	1	1
10/18/2019 23:00	0.5	12.3	2,038.2	0.3	1.6	1	1	1
Average/Sum#:	0.3	13.1	1,810.4	0.2	19.8 #	24 #	24 #	17 #
Minimum:	0.0	12.2	1,445.2	0.0	0.0	1	1	0
Maximum:	0.6	14.0	2,051.9	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/19/2019 00:00	0.4	12.5	1,983.1	0.3	1.2	1	1	1
10/19/2019 01:00	0.4	12.5	1,983.7	0.3	1.2	1	1	1
10/19/2019 02:00	0.4	12.3	2,039.7	0.3	1.3	1	1	1
10/19/2019 03:00	0.4	12.5	1,991.8	0.3	1.3	1	1	1
10/19/2019 04:00	0.3	12.7	1,957.1	0.3	0.9	1	1	1
10/19/2019 05:00	0.3	12.5	1,986.9	0.2	0.9	1	1	1
10/19/2019 06:00	0.3	12.5	1,994.6	0.2	0.9	1	1	1
10/19/2019 07:00	6.0	14.3	1,188.1	0.0	7.2	1	0	1
10/19/2019 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/19/2019 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/19/2019 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/19/2019 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/19/2019 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/19/2019 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/19/2019 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/19/2019 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	1.1	12.7	1,890.6	0.3	14.9 #	8 #	15 #	8 #
Minimum:	0.3	12.3	1,188.1	0.2	0.9	0	0	0
Maximum:	6.0	14.3	2,039.7	0.3	7.2	1	1	1
%SI	66.67	66.67	66.67	70.83	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/20/2019 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/20/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/20/2019 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/20/2019 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/20/2019 14:00	29.7	17.5	449.3	0.0	47.7	1	1	0
10/20/2019 15:00	12.3	15.3	991.7	0.0	28.8	1	1	0
10/20/2019 16:00	0.0	14.0	1,552.8	0.0	0.0	1	1	0
10/20/2019 17:00	0.0	14.0	1,638.6	0.0	0.0	1	1	0
10/20/2019 18:00	0.0	13.6	1,789.3	0.0	0.0	1	1	1
10/20/2019 19:00	0.6	12.6	1,988.7	0.1	1.9	1	1	1
10/20/2019 20:00	0.3	12.5	1,999.2	0.2	0.9	1	1	1
10/20/2019 21:00	0.3	12.7	1,972.8	0.3	1.0	1	1	1
10/20/2019 22:00	0.3	12.6	1,979.2	0.2	0.9	1	1	1
10/20/2019 23:00	0.3	12.6	1,987.7	0.2	0.9	1	1	1
Average/Sum#:	4.4	13.7	1,634.9	0.2	82.1 #	10 #	14 #	6 #
Minimum:	0.0	12.5	449.3	0.0	0.0	0	0	0
Maximum:	29.7	17.5	1,999.2	0.3	47.7	1	1	1
%SI	58.33	58.33	58.33	75.00	58.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/21/2019 00:00	0.2	12.8	1,929.4	0.2	0.6	1	1	1
10/21/2019 01:00	0.1	12.8	1,930.5	0.1	0.3	1	1	1
10/21/2019 02:00	0.1	12.8	1,925.9	0.1	0.3	1	1	1
10/21/2019 03:00	0.1	12.8	1,928.4	0.1	0.3	1	1	1
10/21/2019 04:00	0.2	12.6	1,995.4	0.1	0.6	1	1	1
10/21/2019 05:00	0.3	12.3	2,025.4	0.1	0.9	1	1	1
10/21/2019 06:00	0.3	12.2	2,083.3	0.2	0.9	1	1	1
10/21/2019 07:00	0.2	12.6	1,923.5	0.2	0.6	1	1	1
10/21/2019 08:00	0.0	14.1	1,251.2	0.1	0.0	1	1	0
10/21/2019 09:00	0.0	14.1	1,245.8	0.0	0.0	1	1	0
10/21/2019 10:00	0.0	14.1	1,395.1	0.0	0.0	1	1	0
10/21/2019 11:00	0.0	14.1	1,459.6	0.0	0.0	1	1	0
10/21/2019 12:00	0.0	14.0	1,554.0	0.0	0.0	1	1	0
10/21/2019 13:00	0.0	13.8	1,706.3	0.0	0.0	1	1	0
10/21/2019 14:00	0.0	13.8	1,731.6	0.0	0.0	1	1	0
10/21/2019 15:00	0.0	13.8	1,731.4	0.0	0.0	1	1	0
10/21/2019 16:00	0.0	13.8	1,731.6	0.0	0.0	1	1	0
10/21/2019 17:00	0.0	13.8	1,736.5	0.0	0.0	1	1	0
10/21/2019 18:00	0.0	13.8	1,739.6	0.0	0.0	1	1	0
10/21/2019 19:00	0.0	13.8	1,741.1	0.0	0.0	1	1	1
10/21/2019 20:00	0.6	12.7	1,964.5	0.1	1.9	1	1	1
10/21/2019 21:00	0.6	12.4	2,016.6	0.3	1.9	1	1	1
10/21/2019 22:00	0.6	12.5	2,009.2	0.4	1.9	1	1	1
10/21/2019 23:00	0.5	12.6	1,975.4	0.4	1.6	1	1	1
Average/Sum#:	0.2	13.3	1,780.5	0.1	11.8 #	24 #	24 #	13 #
Minimum:	0.0	12.2	1,245.8	0.0	0.0	1	1	0
Maximum:	0.6	14.1	2,083.3	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/22/2019 00:00	0.5	12.9	1,931.6	0.4	1.6	1	1	1
10/22/2019 01:00	0.4	12.7	1,940.1	0.4	1.2	1	1	1
10/22/2019 02:00	0.2	12.7	1,936.2	0.3	0.6	1	1	1
10/22/2019 03:00	0.2	12.6	1,947.6	0.2	0.6	1	1	1
10/22/2019 04:00	0.3	12.8	1,948.7	0.1	1.0	1	1	1
10/22/2019 05:00	0.3	12.4	2,005.3	0.2	0.9	1	1	1
10/22/2019 06:00	0.3	12.3	2,041.5	0.2	0.9	1	1	1
10/22/2019 07:00	0.5	12.7	1,974.2	0.3	1.6	1	1	1
10/22/2019 08:00	0.5	12.1	2,090.2	0.3	1.6	1	1	1
10/22/2019 09:00	0.5	12.0	2,120.6	0.3	1.6	1	1	1
10/22/2019 10:00	0.5	12.0	2,118.1	0.3	1.6	1	1	1
10/22/2019 11:00	0.4	11.9	2,114.0	0.3	1.2	1	1	1
10/22/2019 12:00	0.4	11.9	2,107.2	0.3	1.2	1	1	1
10/22/2019 13:00	0.4	11.9	2,102.3	0.3	1.2	1	1	1
10/22/2019 14:00	0.4	11.9	2,095.2	0.3	1.2	1	1	1
10/22/2019 15:00	0.4	11.9	2,091.8	0.3	1.2	1	1	1
10/22/2019 16:00	0.4	12.0	2,091.7	0.3	1.2	1	1	1
10/22/2019 17:00	0.4	11.7	2,146.0	0.3	1.2	1	1	1
10/22/2019 18:00	0.5	12.2	2,056.5	0.3	1.6	1	1	1
10/22/2019 19:00	0.5	12.1	2,080.8	0.3	1.6	1	1	1
10/22/2019 20:00	0.5	12.3	2,028.7	0.3	1.6	1	1	1
10/22/2019 21:00	0.5	12.2	2,045.9	0.3	1.6	1	1	1
10/22/2019 22:00	0.5	12.3	2,017.3	0.3	1.5	1	1	1
10/22/2019 23:00	0.5	12.5	1,988.7	0.3	1.6	1	1	1
Average/Sum#:	0.4	12.3	2,042.5	0.3	31.1 #	24 #	24 #	24 #
Minimum:	0.2	11.7	1,931.6	0.1	0.6	1	1	1
Maximum:	0.5	12.9	2,146.0	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/23/2019 00:00	0.5	12.5	1,983.2	0.4	1.6	1	1	1
10/23/2019 01:00	0.5	12.5	1,981.7	0.4	1.6	1	1	1
10/23/2019 02:00	0.5	12.6	1,967.3	0.4	1.6	1	1	1
10/23/2019 03:00	0.6	12.6	1,974.1	0.4	1.9	1	1	1
10/23/2019 04:00	0.5	12.7	1,950.4	0.4	1.6	1	1	1
10/23/2019 05:00	0.6	12.1	2,044.1	0.4	1.8	1	1	1
10/23/2019 06:00	0.5	12.3	1,996.3	0.4	1.5	1	1	1
10/23/2019 07:00	0.0	14.1	1,319.5	0.2	0.0	1	1	0
10/23/2019 08:00	0.0	14.2	1,253.2	0.1	0.0	1	1	0
10/23/2019 09:00	0.0	14.2	1,248.3	0.0	0.0	1	1	0
10/23/2019 10:00	0.0	14.1	1,369.1	0.0	0.0	1	1	0
10/23/2019 11:00	0.0	14.1	1,449.9	0.0	0.0	1	1	0
10/23/2019 12:00	0.0	14.0	1,564.5	0.0	0.0	1	1	0
10/23/2019 13:00	0.0	13.8	1,732.9	0.0	0.0	1	1	0
10/23/2019 14:00	0.0	13.8	1,730.8	0.0	0.0	1	1	0
10/23/2019 15:00	0.0	13.8	1,729.8	0.0	0.0	1	1	0
10/23/2019 16:00	0.0	13.8	1,732.1	0.0	0.0	1	1	0
10/23/2019 17:00	0.0	13.8	1,734.9	0.0	0.0	1	1	0
10/23/2019 18:00	0.0	14.0	1,695.4	0.0	0.0	1	1	0
10/23/2019 19:00	0.5	13.1	1,865.8	0.1	1.6	1	1	1
10/23/2019 20:00	0.6	12.3	2,056.1	0.3	1.9	1	1	1
10/23/2019 21:00	0.6	12.1	2,092.9	0.4	1.9	1	1	1
10/23/2019 22:00	0.5	12.1	2,085.0	0.4	1.6	1	1	1
10/23/2019 23:00	0.6	12.4	2,029.6	0.4	1.9	1	1	1
Average/Sum#:	0.3	13.2	1,774.5	0.2	20.5 #	24 #	24 #	12 #
Minimum:	0.0	12.1	1,248.3	0.0	0.0	1	1	0
Maximum:	0.6	14.2	2,092.9	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/24/2019 00:00	0.6	12.5	2,004.2	0.4	1.9	1	1	1
10/24/2019 01:00	0.6	12.6	1,978.6	0.4	1.9	1	1	1
10/24/2019 02:00	0.6	13.0	1,912.0	0.4	1.9	1	1	1
10/24/2019 03:00	0.6	12.5	2,024.2	0.4	1.9	1	1	1
10/24/2019 04:00	0.6	12.5	2,027.4	0.4	1.9	1	1	1
10/24/2019 05:00	0.6	12.0	2,093.4	0.4	1.9	1	1	1
10/24/2019 06:00	0.6	12.2	2,076.2	0.4	1.9	1	1	1
10/24/2019 07:00	0.5	12.2	2,072.3	0.4	1.6	1	1	1
10/24/2019 08:00	0.5	12.5	2,022.3	0.4	1.6	1	1	1
10/24/2019 09:00	0.5	12.4	2,034.5	0.3	1.6	1	1	1
10/24/2019 10:00	0.5	12.3	2,042.6	0.3	1.6	1	1	1
10/24/2019 11:00	0.5	12.3	2,046.6	0.3	1.6	1	1	1
10/24/2019 12:00	0.5	12.2	2,057.0	0.3	1.6	1	1	1
10/24/2019 13:00	0.4	12.2	2,072.4	0.3	1.3	1	1	1
10/24/2019 14:00	0.4	12.1	2,084.8	0.3	1.3	1	1	1
10/24/2019 15:00	0.4	11.9	2,116.1	0.3	1.2	1	1	1
10/24/2019 16:00	0.4	11.8	2,134.3	0.3	1.2	1	1	1
10/24/2019 17:00	0.5	12.0	2,100.2	0.3	1.6	1	1	1
10/24/2019 18:00	0.5	12.0	2,096.5	0.3	1.6	1	1	1
10/24/2019 19:00	0.5	11.8	2,144.7	0.3	1.6	1	1	1
10/24/2019 20:00	0.5	11.9	2,132.1	0.3	1.6	1	1	1
10/24/2019 21:00	0.4	12.0	2,093.1	0.3	1.2	1	1	1
10/24/2019 22:00	0.2	12.0	2,081.1	0.2	0.6	1	1	1
10/24/2019 23:00	0.5	12.0	2,104.4	0.2	1.6	1	1	1
Average/Sum#:	0.5	12.2	2,064.6	0.3	37.7 #	24 #	24 #	24 #
Minimum:	0.2	11.8	1,912.0	0.2	0.6	1	1	1
Maximum:	0.6	13.0	2,144.7	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/25/2019 00:00	0.6	12.0	2,108.1	0.3	1.9	1	1	1
10/25/2019 01:00	0.6	12.5	2,005.7	0.4	1.9	1	1	1
10/25/2019 02:00	0.3	12.5	1,973.9	0.3	0.9	1	1	1
10/25/2019 03:00	0.2	12.6	1,970.7	0.2	0.6	1	1	1
10/25/2019 04:00	0.2	12.5	1,999.4	0.1	0.6	1	1	1
10/25/2019 05:00	0.3	12.6	1,986.3	0.1	0.9	1	1	1
10/25/2019 06:00	0.4	12.4	2,033.6	0.2	1.3	1	1	1
10/25/2019 07:00	0.4	12.7	1,981.9	0.3	1.3	1	1	1
10/25/2019 08:00	0.7	13.3	1,857.8	0.4	2.3	1	1	1
10/25/2019 09:00	0.8	13.3	1,858.6	0.5	2.6	1	1	1
10/25/2019 10:00	0.8	13.1	1,889.9	0.6	2.6	1	1	1
10/25/2019 11:00	0.7	13.1	1,886.7	0.6	2.2	1	1	1
10/25/2019 12:00	0.7	12.5	2,006.6	0.5	2.2	1	1	1
10/25/2019 13:00	0.7	12.4	2,009.5	0.5	2.2	1	1	1
10/25/2019 14:00	0.7	12.4	2,007.7	0.5	2.2	1	1	1
10/25/2019 15:00	0.7	12.4	2,010.2	0.5	2.2	1	1	1
10/25/2019 16:00	0.7	12.1	2,076.2	0.5	2.2	1	1	1
10/25/2019 17:00	0.7	12.1	2,061.9	0.5	2.2	1	1	1
10/25/2019 18:00	0.7	12.5	1,989.6	0.5	2.2	1	1	1
10/25/2019 19:00	0.7	12.5	1,989.1	0.5	2.2	1	1	1
10/25/2019 20:00	0.7	12.2	2,052.9	0.5	2.2	1	1	1
10/25/2019 21:00	0.7	12.1	2,082.8	0.5	2.2	1	1	1
10/25/2019 22:00	0.7	12.4	2,030.9	0.5	2.2	1	1	1
10/25/2019 23:00	0.6	12.4	2,024.0	0.5	1.9	1	1	1
Average/Sum#:	0.6	12.5	1,995.6	0.4	45.2 #	24 #	24 #	24 #
Minimum:	0.2	12.0	1,857.8	0.1	0.6	1	1	1
Maximum:	0.8	13.3	2,108.1	0.6	2.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/26/2019 00:00	0.3	12.5	1,965.9	0.4	0.9	1	1	1
10/26/2019 01:00	0.2	12.4	1,996.6	0.2	0.6	1	1	1
10/26/2019 02:00	0.2	12.4	1,988.5	0.1	0.6	1	1	1
10/26/2019 03:00	0.2	12.5	1,983.2	0.1	0.6	1	1	1
10/26/2019 04:00	0.2	12.5	1,985.1	0.1	0.6	1	1	1
10/26/2019 05:00	0.3	13.0	1,915.2	0.1	1.0	1	1	1
10/26/2019 06:00	0.3	12.9	1,903.5	0.2	0.9	1	1	1
10/26/2019 07:00	0.0	14.0	1,476.3	0.1	0.0	1	1	0
10/26/2019 08:00	0.0	14.1	1,575.6	0.1	0.0	1	1	0
10/26/2019 09:00	0.0	14.1	1,569.9	0.0	0.0	1	1	0
10/26/2019 10:00	0.0	14.1	1,458.2	0.0	0.0	1	1	0
10/26/2019 11:00	0.0	14.0	1,419.2	0.0	0.0	1	1	0
10/26/2019 12:00	0.0	14.1	1,514.4	0.0	0.0	1	1	0
10/26/2019 13:00	0.0	14.0	1,582.0	0.0	0.0	1	1	0
10/26/2019 14:00	0.0	14.1	1,466.6	0.0	0.0	1	1	0
10/26/2019 15:00	0.0	14.0	1,480.6	0.0	0.0	1	1	1
10/26/2019 16:00	0.7	12.8	1,923.2	0.2	2.2	1	1	1
10/26/2019 17:00	0.7	12.4	1,995.4	0.3	2.2	1	1	1
10/26/2019 18:00	0.8	12.4	1,992.8	0.5	2.5	1	1	1
10/26/2019 19:00	0.8	12.5	1,990.6	0.6	2.5	1	1	1
10/26/2019 20:00	0.8	12.4	2,001.5	0.6	2.5	1	1	1
10/26/2019 21:00	0.8	12.5	2,001.5	0.6	2.5	1	1	1
10/26/2019 22:00	6.6	14.5	1,137.4	0.0	7.4	1	0	1
10/26/2019 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.6	13.2	1,753.2	0.2	27.0 #	23 #	22 #	15 #
Minimum:	0.0	12.4	1,137.4	0.0	0.0	0	0	0
Maximum:	6.6	14.5	2,001.5	0.6	7.4	1	1	1
%SI	4.17	4.17	4.17	8.33	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/27/2019 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/27/2019 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/27/2019 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/27/2019 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	4 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/28/2019 00:00	89.6	18.6	329.6	0.0	42.4	1	1	0
10/28/2019 01:00	21.9	16.2	697.2	0.0	42.9	1	1	0
10/28/2019 02:00	0.0	14.1	1,323.7	0.0	0.0	1	1	0
10/28/2019 03:00	0.0	14.0	1,554.3	0.0	0.0	1	1	1
10/28/2019 04:00	0.3	13.1	1,907.1	0.1	1.0	1	1	1
10/28/2019 05:00	0.4	12.7	1,955.9	0.2	1.3	1	1	1
10/28/2019 06:00	0.3	12.0	2,125.2	0.2	0.9	1	1	1
10/28/2019 07:00	0.3	12.5	2,020.1	0.2	1.0	1	1	1
10/28/2019 08:00	0.3	12.7	1,975.7	0.2	1.0	1	1	1
10/28/2019 09:00	0.3	12.7	1,981.6	0.2	1.0	1	1	1
10/28/2019 10:00	0.4	12.7	1,973.6	0.2	1.3	1	1	1
10/28/2019 11:00	0.6	13.0	1,947.0	0.3	2.0	1	1	1
10/28/2019 12:00	0.7	12.8	1,974.1	0.4	2.3	1	1	1
10/28/2019 13:00	0.7	12.8	1,956.0	0.5	2.2	1	1	1
10/28/2019 14:00	0.7	12.8	1,976.3	0.5	2.3	1	1	1
10/28/2019 15:00	0.7	12.6	2,004.3	0.5	2.2	1	1	1
10/28/2019 16:00	0.7	12.3	2,068.2	0.5	2.2	1	1	1
10/28/2019 17:00	0.6	11.7	2,173.4	0.5	1.9	1	1	1
10/28/2019 18:00	0.7	12.1	2,107.8	0.5	2.2	1	1	1
10/28/2019 19:00	0.6	12.2	2,092.5	0.4	1.9	1	1	1
10/28/2019 20:00	0.4	12.2	2,069.5	0.4	1.3	1	1	1
10/28/2019 21:00	0.2	12.2	2,059.4	0.3	0.6	1	1	1
10/28/2019 22:00	0.2	12.8	1,919.5	0.2	0.6	1	1	1
10/28/2019 23:00	10.1	15.8	589.0	0.0	3.5	1	0	0
Average/Sum#:	5.4	13.2	1,782.5	0.3	118.0 #	24 #	23 #	20 #
Minimum:	0.0	11.7	329.6	0.1	0.0	1	0	0
Maximum:	89.6	18.6	2,173.4	0.5	42.9	1	1	1
%SI	0.00	0.00	0.00	20.83	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/29/2019 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/30/2019 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2019 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/30/2019 04:00	84.5	20.5	98.7	0.0	27.5	1	1	0
10/30/2019 05:00	36.2	17.2	500.2	0.0	64.6	1	1	0
10/30/2019 06:00	22.9	15.6	823.1	0.0	47.0	1	1	0
10/30/2019 07:00	0.0	14.0	1,699.0	0.0	0.0	1	1	1
10/30/2019 08:00	0.0	14.1	1,706.5	0.0	0.0	1	1	1
10/30/2019 09:00	0.3	13.2	1,917.2	0.1	1.0	1	1	1
10/30/2019 10:00	0.4	12.5	2,025.9	0.2	1.3	1	1	1
10/30/2019 11:00	0.3	12.3	2,071.3	0.2	1.0	1	1	1
10/30/2019 12:00	0.2	12.1	2,093.7	0.2	0.6	1	1	1
10/30/2019 13:00	0.2	12.3	2,060.7	0.1	0.6	1	1	1
10/30/2019 14:00	0.5	12.7	2,003.9	0.2	1.6	1	1	1
10/30/2019 15:00	0.6	12.7	2,017.3	0.3	1.9	1	1	1
10/30/2019 16:00	0.5	12.3	2,080.1	0.4	1.6	1	1	1
10/30/2019 17:00	0.5	13.2	1,914.6	0.4	1.6	1	1	1
10/30/2019 18:00	0.5	13.1	1,932.1	0.4	1.6	1	1	1
10/30/2019 19:00	0.5	13.1	1,940.6	0.4	1.6	1	1	1
10/30/2019 20:00	0.5	13.1	1,943.6	0.4	1.6	1	1	1
10/30/2019 21:00	0.2	13.2	1,888.6	0.3	0.6	1	1	1
10/30/2019 22:00	0.2	13.2	1,902.0	0.3	0.7	1	1	1
10/30/2019 23:00	0.2	13.1	1,928.7	0.2	0.7	1	1	1
Average/Sum#:	7.5	13.7	1,727.4	0.3	157.1 #	20 #	21 #	17 #
Minimum:	0.0	12.1	98.7	0.1	0.0	0	0	0
Maximum:	84.5	20.5	2,093.7	0.4	64.6	1	1	1
%SI	16.67	16.67	16.67	37.50	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/31/2019 00:00	0.2	13.2	1,916.2	0.2	0.7	1	1	1
10/31/2019 01:00	0.2	13.2	1,901.6	0.2	0.7	1	1	1
10/31/2019 02:00	0.2	13.2	1,899.0	0.2	0.7	1	1	1
10/31/2019 03:00	0.2	13.2	1,903.6	0.2	0.7	1	1	1
10/31/2019 04:00	0.2	13.2	1,903.4	0.2	0.7	1	1	1
10/31/2019 05:00	0.3	13.2	1,894.0	0.2	1.0	1	1	1
10/31/2019 06:00	0.2	13.2	1,903.0	0.2	0.7	1	1	1
10/31/2019 07:00	0.2	13.2	1,914.5	0.2	0.7	1	1	1
10/31/2019 08:00	0.3	13.2	1,922.1	0.2	1.0	1	1	1
10/31/2019 09:00	0.2	13.2	1,893.6	0.2	0.6	1	1	1
10/31/2019 10:00	0.4	13.2	1,897.2	0.2	1.3	1	1	1
10/31/2019 11:00	0.6	13.2	1,910.2	0.3	2.0	1	1	1
10/31/2019 12:00	0.5	13.0	1,934.6	0.4	1.6	1	1	1
10/31/2019 13:00	0.5	13.0	1,935.7	0.4	1.6	1	1	1
10/31/2019 14:00	0.5	13.0	1,930.4	0.4	1.6	1	1	1
10/31/2019 15:00	0.5	13.0	1,928.4	0.4	1.6	1	1	1
10/31/2019 16:00	0.5	13.0	1,925.1	0.4	1.6	1	1	1
10/31/2019 17:00	0.6	13.0	1,928.8	0.4	1.9	1	1	1
10/31/2019 18:00	0.6	12.9	1,964.9	0.4	1.9	1	1	1
10/31/2019 19:00	0.7	12.3	2,076.5	0.4	2.2	1	1	1
10/31/2019 20:00	0.7	12.4	2,072.5	0.5	2.3	1	1	1
10/31/2019 21:00	0.6	12.4	2,079.3	0.5	1.9	1	1	1
10/31/2019 22:00	0.3	12.2	2,080.8	0.4	0.9	1	1	1
10/31/2019 23:00	0.3	12.4	2,062.9	0.3	1.0	1	1	1
Average/Sum#:	0.4	13.0	1,949.1	0.3	30.9 #	24 #	24 #	24 #
Minimum:	0.2	12.2	1,893.6	0.2	0.6	1	1	1
Maximum:	0.7	13.2	2,080.8	0.5	2.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2019 00:00	0.3	12.4	2,042.8	0.2	1.0	1	1	1
11/01/2019 01:00	0.3	12.6	2,007.6	0.2	1.0	1	1	1
11/01/2019 02:00	0.4	12.5	2,041.1	0.2	1.3	1	1	1
11/01/2019 03:00	0.4	12.5	2,042.2	0.3	1.3	1	1	1
11/01/2019 04:00	0.3	12.7	2,006.6	0.3	1.0	1	1	1
11/01/2019 05:00	0.5	12.2	2,104.3	0.3	1.6	1	1	1
11/01/2019 06:00	0.4	12.2	2,135.2	0.3	1.3	1	1	1
11/01/2019 07:00	0.3	12.2	2,134.0	0.3	1.0	1	1	1
11/01/2019 08:00	0.3	12.2	2,118.2	0.2	1.0	1	1	1
11/01/2019 09:00	0.0	13.6	1,753.5	0.1	0.0	1	1	1
11/01/2019 10:00	0.0	14.1	1,644.8	0.1	0.0	1	1	0
11/01/2019 11:00	0.0	14.1	1,319.3	0.0	0.0	1	1	0
11/01/2019 12:00	0.0	14.1	1,505.4	0.0	0.0	1	1	0
11/01/2019 13:00	0.0	14.1	1,549.1	0.0	0.0	1	1	0
11/01/2019 14:00	0.0	14.0	1,513.1	0.0	0.0	1	1	1
11/01/2019 15:00	0.5	12.9	1,955.6	0.1	1.6	1	1	1
11/01/2019 16:00	0.4	12.4	2,055.9	0.2	1.3	1	1	1
11/01/2019 17:00	0.4	12.0	2,130.6	0.3	1.3	1	1	1
11/01/2019 18:00	0.3	11.8	2,165.3	0.3	0.9	1	1	1
11/01/2019 19:00	0.4	12.3	2,071.2	0.3	1.3	1	1	1
11/01/2019 20:00	0.4	12.2	2,110.6	0.3	1.3	1	1	1
11/01/2019 21:00	0.4	12.5	2,038.0	0.3	1.3	1	1	1
11/01/2019 22:00	0.4	12.7	2,010.4	0.3	1.3	1	1	1
11/01/2019 23:00	0.5	12.6	2,033.2	0.3	1.6	1	1	1
Average/Sum#:	0.3	12.8	1,937.0	0.2	22.4 #	24 #	24 #	20 #
Minimum:	0.0	11.8	1,319.3	0.0	0.0	1	1	0
Maximum:	0.5	14.1	2,165.3	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/02/2019 00:00	0.2	12.4	2,050.5	0.3	0.6	1	1	1
11/02/2019 01:00	0.2	12.3	2,058.8	0.2	0.6	1	1	1
11/02/2019 02:00	0.1	12.3	2,069.6	0.1	0.3	1	1	1
11/02/2019 03:00	0.1	12.3	2,063.5	0.1	0.3	1	1	1
11/02/2019 04:00	0.1	12.3	2,069.6	0.1	0.3	1	1	1
11/02/2019 05:00	0.2	12.4	2,035.1	0.1	0.6	1	1	1
11/02/2019 06:00	0.1	12.0	2,126.4	0.1	0.3	1	1	1
11/02/2019 07:00	0.1	12.3	2,067.1	0.1	0.3	1	1	1
11/02/2019 08:00	0.1	13.1	1,887.2	0.1	0.3	1	1	1
11/02/2019 09:00	0.0	14.1	1,528.1	0.1	0.0	1	1	0
11/02/2019 10:00	0.0	14.1	1,518.3	0.0	0.0	1	1	0
11/02/2019 11:00	0.0	14.1	1,524.8	0.0	0.0	1	1	0
11/02/2019 12:00	0.0	14.1	1,539.0	0.0	0.0	1	1	0
11/02/2019 13:00	6.9	15.2	923.9	0.0	5.5	1	0	0
11/02/2019 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/02/2019 15:00	11.4	17.8	423.3	0.0	6.6	1	0	0
11/02/2019 16:00	9.1	14.5	1,124.4	0.0	21.1	1	1	0
11/02/2019 17:00	0.0	13.8	1,717.0	0.0	0.0	1	1	1
11/02/2019 18:00	0.7	12.5	2,030.2	0.0	2.2	1	1	1
11/02/2019 19:00	0.5	11.8	2,166.3	0.3	1.6	1	1	1
11/02/2019 20:00	0.5	11.9	2,141.3	0.4	1.6	1	1	1
11/02/2019 21:00	0.6	12.3	2,073.2	0.3	1.9	1	1	1
11/02/2019 22:00	0.6	12.4	2,044.0	0.4	1.9	1	1	1
11/02/2019 23:00	0.4	12.7	1,990.7	0.4	1.3	1	1	1
Average/Sum#:	1.4	13.2	1,790.1	0.2	47.3 #	23 #	21 #	16 #
Minimum:	0.0	11.8	423.3	0.0	0.0	0	0	0
Maximum:	11.4	17.8	2,166.3	0.4	21.1	1	1	1
%SI	4.17	4.17	4.17	25.00	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/03/2019 00:00	0.4	12.7	1,982.9	0.3	1.3	1	1	1
11/03/2019 01:00	0.3	12.5	2,001.1	0.3	0.9	1	1	1
11/03/2019 02:00	0.3	12.6	1,988.3	0.2	0.9	1	1	1
11/03/2019 03:00	0.3	12.5	2,009.0	0.2	0.9	1	1	1
11/03/2019 04:00	0.3	12.4	2,043.8	0.2	1.0	1	1	1
11/03/2019 05:00	0.3	11.9	2,108.2	0.2	0.9	1	1	1
11/03/2019 06:00	0.3	12.3	2,077.9	0.2	1.0	1	1	1
11/03/2019 07:00	0.2	12.6	1,991.4	0.2	0.6	1	1	1
11/03/2019 08:00	0.0	14.0	1,603.3	0.1	0.0	1	1	0
11/03/2019 09:00	0.0	14.1	1,588.7	0.0	0.0	1	1	0
11/03/2019 10:00	0.0	14.1	1,609.0	0.0	0.0	1	1	0
11/03/2019 11:00	0.0	14.1	1,598.8	0.0	0.0	1	1	0
11/03/2019 12:00	0.0	14.1	1,613.4	0.0	0.0	1	1	0
11/03/2019 13:00	0.0	14.1	1,466.9	0.0	0.0	1	1	0
11/03/2019 14:00	0.0	14.1	1,443.1	0.0	0.0	1	1	0
11/03/2019 15:00	0.2	13.4	1,764.3	0.1	0.6	1	1	1
11/03/2019 16:00	0.7	12.2	2,071.1	0.2	2.2	1	1	1
11/03/2019 17:00	0.6	12.0	2,115.7	0.4	1.9	1	1	1
11/03/2019 18:00	0.6	11.8	2,145.5	0.4	1.9	1	1	1
11/03/2019 19:00	0.5	11.7	2,171.6	0.4	1.6	1	1	1
11/03/2019 20:00	0.5	12.0	2,120.9	0.3	1.6	1	1	1
11/03/2019 21:00	0.6	12.2	2,086.4	0.3	1.9	1	1	1
11/03/2019 22:00	0.5	12.5	2,016.4	0.4	1.6	1	1	1
11/03/2019 23:00	0.4	12.3	2,054.2	0.4	1.3	1	1	1
Average/Sum#:	0.3	12.8	1,903.0	0.2	22.1 #	24 #	24 #	17 #
Minimum:	0.0	11.7	1,443.1	0.0	0.0	1	1	0
Maximum:	0.7	14.1	2,171.6	0.4	2.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/04/2019 00:00	0.3	12.4	2,017.2	0.3	0.9	1	1	1
11/04/2019 01:00	0.3	12.4	2,021.0	0.2	0.9	1	1	1
11/04/2019 02:00	0.3	12.7	1,956.6	0.2	0.9	1	1	1
11/04/2019 03:00	0.3	12.6	1,988.3	0.2	0.9	1	1	1
11/04/2019 04:00	0.3	12.5	2,011.8	0.2	0.9	1	1	1
11/04/2019 05:00	0.3	11.8	2,113.7	0.2	0.9	1	1	1
11/04/2019 06:00	0.3	11.8	2,167.1	0.2	0.9	1	1	1
11/04/2019 07:00	0.3	12.5	2,023.1	0.2	1.0	1	1	1
11/04/2019 08:00	0.4	12.5	2,033.8	0.2	1.3	1	1	1
11/04/2019 09:00	0.3	12.1	2,078.9	0.2	0.9	1	1	1
11/04/2019 10:00	0.3	12.2	2,046.2	0.2	0.9	1	1	1
11/04/2019 11:00	0.3	12.5	1,974.0	0.2	0.9	1	1	1
11/04/2019 12:00	0.2	12.1	2,041.9	0.2	0.6	1	1	1
11/04/2019 13:00	0.2	12.0	2,057.4	0.1	0.6	1	1	1
11/04/2019 14:00	0.2	12.1	2,029.1	0.1	0.6	1	1	1
11/04/2019 15:00	0.2	12.0	2,057.2	0.1	0.6	1	1	1
11/04/2019 16:00	0.2	11.8	2,111.5	0.1	0.6	1	1	1
11/04/2019 17:00	0.5	11.8	2,165.5	0.2	1.6	1	1	1
11/04/2019 18:00	0.5	11.8	2,169.5	0.2	1.6	1	1	1
11/04/2019 19:00	0.5	11.9	2,166.6	0.3	1.6	1	1	1
11/04/2019 20:00	0.5	12.0	2,148.6	0.3	1.6	1	1	1
11/04/2019 21:00	0.5	11.9	2,151.7	0.3	1.6	1	1	1
11/04/2019 22:00	0.5	11.9	2,154.1	0.3	1.6	1	1	1
11/04/2019 23:00	0.5	12.4	2,070.8	0.3	1.6	1	1	1
Average/Sum#:	0.3	12.2	2,073.2	0.2	25.5 #	24 #	24 #	24 #
Minimum:	0.2	11.8	1,956.6	0.1	0.6	1	1	1
Maximum:	0.5	12.7	2,169.5	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/05/2019 00:00	0.6	12.3	2,088.8	0.3	1.9	1	1	1
11/05/2019 01:00	0.6	12.3	2,089.2	0.4	1.9	1	1	1
11/05/2019 02:00	0.6	12.3	2,085.5	0.4	1.9	1	1	1
11/05/2019 03:00	0.6	12.3	2,084.4	0.4	1.9	1	1	1
11/05/2019 04:00	0.6	12.3	2,074.8	0.4	1.9	1	1	1
11/05/2019 05:00	0.6	12.0	2,120.9	0.4	1.9	1	1	1
11/05/2019 06:00	0.4	11.9	2,186.0	0.4	1.3	1	1	1
11/05/2019 07:00	0.3	12.7	2,024.9	0.3	1.0	1	1	1
11/05/2019 08:00	0.6	12.8	2,004.9	0.3	2.0	1	1	1
11/05/2019 09:00	0.5	12.9	1,955.4	0.3	1.6	1	1	1
11/05/2019 10:00	0.4	12.8	1,968.2	0.4	1.3	1	1	1
11/05/2019 11:00	0.4	12.8	1,967.1	0.3	1.3	1	1	1
11/05/2019 12:00	0.4	12.7	1,982.3	0.3	1.3	1	1	1
11/05/2019 13:00	0.3	12.4	2,046.5	0.3	1.0	1	1	1
11/05/2019 14:00	0.4	12.5	2,024.2	0.3	1.3	1	1	1
11/05/2019 15:00	0.4	12.4	2,041.2	0.3	1.3	1	1	1
11/05/2019 16:00	0.3	12.0	2,120.2	0.3	0.9	1	1	1
11/05/2019 17:00	0.3	12.1	2,095.3	0.2	0.9	1	1	1
11/05/2019 18:00	0.4	12.1	2,099.8	0.2	1.3	1	1	1
11/05/2019 19:00	0.3	12.1	2,112.9	0.2	1.0	1	1	1
11/05/2019 20:00	0.4	12.1	2,117.9	0.3	1.3	1	1	1
11/05/2019 21:00	0.4	12.3	2,090.1	0.3	1.3	1	1	1
11/05/2019 22:00	0.4	12.3	2,086.6	0.3	1.3	1	1	1
11/05/2019 23:00	0.4	12.3	2,086.9	0.3	1.3	1	1	1
Average/Sum#:	0.4	12.4	2,064.8	0.3	34.1 #	24 #	24 #	24 #
Minimum:	0.3	11.9	1,955.4	0.2	0.9	1	1	1
Maximum:	0.6	12.9	2,186.0	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/06/2019 00:00	0.4	12.6	2,004.2	0.3	1.3	1	1	1
11/06/2019 01:00	0.5	12.9	1,965.4	0.3	1.6	1	1	1
11/06/2019 02:00	0.4	12.5	2,046.3	0.3	1.3	1	1	1
11/06/2019 03:00	0.4	12.5	2,041.6	0.3	1.3	1	1	1
11/06/2019 04:00	0.3	12.7	1,991.3	0.3	1.0	1	1	1
11/06/2019 05:00	0.3	12.4	2,032.1	0.2	0.9	1	1	1
11/06/2019 06:00	0.4	12.1	2,120.7	0.2	1.3	1	1	1
11/06/2019 07:00	0.6	12.4	2,059.7	0.3	1.9	1	1	1
11/06/2019 08:00	0.7	12.6	2,014.8	0.4	2.2	1	1	1
11/06/2019 09:00	0.6	12.8	1,976.8	0.4	1.9	1	1	1
11/06/2019 10:00	0.5	12.8	2,070.5	0.4	1.7	1	1	1
11/06/2019 11:00	0.4	12.7	2,095.9	0.4	1.4	1	1	1
11/06/2019 12:00	0.4	12.6	2,094.3	0.3	1.3	1	1	1
11/06/2019 13:00	0.4	12.6	2,104.3	0.3	1.3	1	1	1
11/06/2019 14:00	0.4	12.5	2,123.1	0.3	1.3	1	1	1
11/06/2019 15:00	0.3	12.4	2,134.4	0.3	1.0	1	1	1
11/06/2019 16:00	0.3	12.1	2,198.2	0.2	1.0	1	1	1
11/06/2019 17:00	0.3	11.9	2,237.1	0.2	1.0	1	1	1
11/06/2019 18:00	0.3	12.1	2,218.2	0.2	1.0	1	1	1
11/06/2019 19:00	0.3	12.0	2,223.9	0.2	1.0	1	1	1
11/06/2019 20:00	0.5	12.0	2,231.2	0.2	1.7	1	1	1
11/06/2019 21:00	0.5	12.0	2,248.2	0.3	1.7	1	1	1
11/06/2019 22:00	0.6	12.1	2,220.8	0.3	2.0	1	1	1
11/06/2019 23:00	0.6	12.4	2,170.2	0.4	2.0	1	1	1
Average/Sum#:	0.4	12.4	2,109.3	0.3	34.1 #	24 #	24 #	24 #
Minimum:	0.3	11.9	1,965.4	0.2	0.9	1	1	1
Maximum:	0.7	12.9	2,248.2	0.4	2.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/07/2019 00:00	0.5	12.4	2,187.6	0.4	1.7	1	1	1
11/07/2019 01:00	0.3	12.3	2,175.9	0.3	1.0	1	1	1
11/07/2019 02:00	0.3	12.4	2,141.9	0.2	1.0	1	1	1
11/07/2019 03:00	0.3	12.8	2,080.8	0.2	1.0	1	1	1
11/07/2019 04:00	0.4	12.5	2,147.5	0.2	1.4	1	1	1
11/07/2019 05:00	0.4	12.4	2,148.9	0.3	1.3	1	1	1
11/07/2019 06:00	0.4	12.3	2,190.7	0.3	1.3	1	1	1
11/07/2019 07:00	0.4	12.5	2,150.3	0.3	1.4	1	1	1
11/07/2019 08:00	0.4	12.9	2,072.8	0.3	1.4	1	1	1
11/07/2019 09:00	0.4	12.8	2,077.3	0.3	1.4	1	1	1
11/07/2019 10:00	0.4	12.9	2,046.8	0.3	1.4	1	1	1
11/07/2019 11:00	0.4	12.7	2,093.3	0.3	1.3	1	1	1
11/07/2019 12:00	0.4	12.7	2,094.3	0.3	1.3	1	1	1
11/07/2019 13:00	0.4	12.7	2,091.8	0.3	1.3	1	1	1
11/07/2019 14:00	0.4	12.6	2,113.0	0.3	1.3	1	1	1
11/07/2019 15:00	0.4	12.5	2,140.0	0.3	1.3	1	1	1
11/07/2019 16:00	0.3	12.1	2,216.4	0.3	1.0	1	1	1
11/07/2019 17:00	0.4	12.4	2,156.1	0.3	1.3	1	1	1
11/07/2019 18:00	0.5	11.8	2,283.2	0.3	1.7	1	1	1
11/07/2019 19:00	0.5	11.8	2,296.1	0.3	1.7	1	1	1
11/07/2019 20:00	0.5	12.1	2,215.0	0.3	1.7	1	1	1
11/07/2019 21:00	0.6	12.3	2,173.0	0.3	2.0	1	1	1
11/07/2019 22:00	0.6	12.4	2,178.2	0.4	2.0	1	1	1
11/07/2019 23:00	0.4	12.6	2,120.6	0.4	1.3	1	1	1
Average/Sum#:	0.4	12.5	2,149.6	0.3	33.5 #	24 #	24 #	24 #
Minimum:	0.3	11.8	2,046.8	0.2	1.0	1	1	1
Maximum:	0.6	12.9	2,296.1	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/08/2019 00:00	0.3	12.3	2,174.6	0.3	1.0	1	1	1
11/08/2019 01:00	0.3	12.2	2,199.0	0.2	1.0	1	1	1
11/08/2019 02:00	0.3	12.4	2,155.6	0.2	1.0	1	1	1
11/08/2019 03:00	0.3	12.6	2,121.2	0.2	1.0	1	1	1
11/08/2019 04:00	0.4	12.7	2,109.9	0.2	1.4	1	1	1
11/08/2019 05:00	0.4	12.6	2,119.7	0.3	1.3	1	1	1
11/08/2019 06:00	0.4	12.6	2,121.8	0.3	1.4	1	1	1
11/08/2019 07:00	0.3	12.7	2,106.9	0.3	1.0	1	1	1
11/08/2019 08:00	0.1	13.3	1,954.7	0.2	0.3	1	1	1
11/08/2019 09:00	0.0	14.0	1,568.9	0.1	0.0	1	1	0
11/08/2019 10:00	0.0	14.1	1,391.5	0.0	0.0	1	1	0
11/08/2019 11:00	0.0	14.1	1,550.3	0.0	0.0	1	1	0
11/08/2019 12:00	0.0	14.1	1,552.1	0.0	0.0	1	1	0
11/08/2019 13:00	0.0	14.0	1,700.1	0.0	0.0	1	1	0
11/08/2019 14:00	0.0	14.0	1,711.4	0.0	0.0	1	1	1
11/08/2019 15:00	0.6	12.9	2,042.9	0.1	2.0	1	1	1
11/08/2019 16:00	0.6	12.6	2,098.0	0.3	2.0	1	1	1
11/08/2019 17:00	0.6	12.5	2,118.4	0.4	2.0	1	1	1
11/08/2019 18:00	0.6	12.2	2,175.4	0.4	2.0	1	1	1
11/08/2019 19:00	0.6	12.4	2,133.6	0.4	2.0	1	1	1
11/08/2019 20:00	0.6	12.3	2,168.0	0.4	2.0	1	1	1
11/08/2019 21:00	0.6	12.3	2,174.5	0.4	2.0	1	1	1
11/08/2019 22:00	0.6	12.4	2,170.3	0.4	2.0	1	1	1
11/08/2019 23:00	0.4	12.3	2,176.9	0.4	1.3	1	1	1
Average/Sum#:	0.3	12.9	1,991.5	0.2	26.7 #	24 #	24 #	19 #
Minimum:	0.0	12.2	1,391.5	0.0	0.0	1	1	0
Maximum:	0.6	14.1	2,199.0	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/09/2019 00:00	0.3	12.2	2,182.0	0.3	1.0	1	1	1
11/09/2019 01:00	0.3	12.3	2,159.0	0.2	1.0	1	1	1
11/09/2019 02:00	0.3	12.3	2,162.3	0.2	1.0	1	1	1
11/09/2019 03:00	0.3	12.2	2,166.6	0.2	1.0	1	1	1
11/09/2019 04:00	0.3	12.2	2,177.3	0.2	1.0	1	1	1
11/09/2019 05:00	0.4	12.7	2,107.5	0.2	1.4	1	1	1
11/09/2019 06:00	0.4	12.7	2,085.2	0.3	1.3	1	1	1
11/09/2019 07:00	0.2	12.8	2,050.2	0.2	0.7	1	1	1
11/09/2019 08:00	0.0	14.0	1,569.3	0.1	0.0	1	1	1
11/09/2019 09:00	0.0	14.1	1,326.2	0.0	0.0	1	1	0
11/09/2019 10:00	0.0	14.2	1,340.4	0.0	0.0	1	1	0
11/09/2019 11:00	0.0	14.2	1,327.7	0.0	0.0	1	1	0
11/09/2019 12:00	0.0	14.2	1,332.2	0.0	0.0	1	1	0
11/09/2019 13:00	0.0	14.2	1,324.1	0.0	0.0	1	1	0
11/09/2019 14:00	0.0	14.1	1,565.1	0.0	0.0	1	1	1
11/09/2019 15:00	0.6	12.8	2,054.2	0.1	2.0	1	1	1
11/09/2019 16:00	0.6	12.6	2,100.8	0.3	2.0	1	1	1
11/09/2019 17:00	0.6	12.4	2,129.6	0.4	2.0	1	1	1
11/09/2019 18:00	0.6	12.6	2,102.2	0.4	2.0	1	1	1
11/09/2019 19:00	0.6	12.6	2,106.5	0.4	2.0	1	1	1
11/09/2019 20:00	0.6	12.6	2,095.8	0.4	2.0	1	1	1
11/09/2019 21:00	0.6	12.6	2,122.8	0.4	2.0	1	1	1
11/09/2019 22:00	0.6	12.5	2,141.9	0.4	2.0	1	1	1
11/09/2019 23:00	0.6	12.6	2,114.0	0.4	2.0	1	1	1
Average/Sum#:	0.3	13.0	1,910.1	0.2	26.4 #	24 #	24 #	19 #
Minimum:	0.0	12.2	1,324.1	0.0	0.0	1	1	0
Maximum:	0.6	14.2	2,182.0	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/10/2019 00:00	0.6	12.6	2,129.0	0.4	2.0	1	1	1
11/10/2019 01:00	0.5	12.9	2,062.9	0.4	1.7	1	1	1
11/10/2019 02:00	0.4	12.8	2,059.1	0.4	1.3	1	1	1
11/10/2019 03:00	0.3	12.8	2,062.4	0.3	1.0	1	1	1
11/10/2019 04:00	0.3	12.8	2,062.5	0.2	1.0	1	1	1
11/10/2019 05:00	0.4	12.8	2,059.6	0.2	1.3	1	1	1
11/10/2019 06:00	0.4	12.7	2,101.9	0.3	1.4	1	1	1
11/10/2019 07:00	0.3	12.7	2,072.8	0.3	1.0	1	1	1
11/10/2019 08:00	0.0	14.0	1,600.0	0.2	0.0	1	1	0
11/10/2019 09:00	0.0	14.1	1,562.7	0.1	0.0	1	1	0
11/10/2019 10:00	0.0	14.1	1,570.8	0.0	0.0	1	1	0
11/10/2019 11:00	0.0	14.1	1,609.2	0.0	0.0	1	1	0
11/10/2019 12:00	0.0	14.1	1,597.1	0.0	0.0	1	1	0
11/10/2019 13:00	0.0	14.1	1,684.7	0.0	0.0	1	1	0
11/10/2019 14:00	0.0	14.1	1,647.6	0.0	0.0	1	1	0
11/10/2019 15:00	0.0	14.0	1,581.4	0.0	0.0	1	1	1
11/10/2019 16:00	0.6	12.8	2,050.6	0.1	2.0	1	1	1
11/10/2019 17:00	0.6	12.6	2,102.6	0.3	2.0	1	1	1
11/10/2019 18:00	0.6	12.6	2,096.3	0.4	2.0	1	1	1
11/10/2019 19:00	0.6	12.5	2,115.4	0.4	2.0	1	1	1
11/10/2019 20:00	0.6	12.5	2,126.8	0.4	2.0	1	1	1
11/10/2019 21:00	0.6	12.4	2,163.0	0.4	2.0	1	1	1
11/10/2019 22:00	0.6	12.2	2,205.1	0.4	2.0	1	1	1
11/10/2019 23:00	0.6	12.4	2,145.5	0.4	2.0	1	1	1
Average/Sum#:	0.3	13.1	1,936.2	0.2	26.7 #	24 #	24 #	17 #
Minimum:	0.0	12.2	1,562.7	0.0	0.0	1	1	0
Maximum:	0.6	14.1	2,205.1	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/11/2019 00:00	0.6	12.5	2,134.2	0.4	2.0	1	1	1
11/11/2019 01:00	0.5	12.6	2,092.9	0.4	1.7	1	1	1
11/11/2019 02:00	0.6	12.6	2,117.2	0.4	2.0	1	1	1
11/11/2019 03:00	0.6	12.6	2,096.2	0.4	2.0	1	1	1
11/11/2019 04:00	0.6	12.6	2,097.0	0.4	2.0	1	1	1
11/11/2019 05:00	0.6	12.7	2,088.8	0.4	2.0	1	1	1
11/11/2019 06:00	0.6	12.7	2,093.0	0.4	2.0	1	1	1
11/11/2019 07:00	0.4	12.6	2,103.1	0.4	1.3	1	1	1
11/11/2019 08:00	0.2	13.2	1,953.2	0.3	0.7	1	1	1
11/11/2019 09:00	0.0	14.0	1,534.1	0.2	0.0	1	1	0
11/11/2019 10:00	0.0	14.1	1,549.8	0.1	0.0	1	1	0
11/11/2019 11:00	0.0	14.1	1,542.3	0.0	0.0	1	1	0
11/11/2019 12:00	0.0	14.1	1,529.6	0.0	0.0	1	1	0
11/11/2019 13:00	0.0	14.0	1,751.1	0.0	0.0	1	1	1
11/11/2019 14:00	0.6	12.9	2,025.7	0.1	2.0	1	1	1
11/11/2019 15:00	0.6	12.4	2,121.9	0.3	2.0	1	1	1
11/11/2019 16:00	0.6	12.4	2,116.1	0.4	2.0	1	1	1
11/11/2019 17:00	0.5	11.9	2,228.9	0.4	1.6	1	1	1
11/11/2019 18:00	0.5	12.0	2,208.5	0.3	1.6	1	1	1
11/11/2019 19:00	0.6	12.2	2,171.1	0.3	2.0	1	1	1
11/11/2019 20:00	0.6	12.2	2,174.6	0.4	2.0	1	1	1
11/11/2019 21:00	0.6	12.3	2,180.9	0.4	2.0	1	1	1
11/11/2019 22:00	0.6	12.3	2,179.1	0.4	2.0	1	1	1
11/11/2019 23:00	0.6	12.3	2,165.3	0.4	2.0	1	1	1
Average/Sum#:	0.4	12.8	2,010.6	0.3	34.9 #	24 #	24 #	20 #
Minimum:	0.0	11.9	1,529.6	0.0	0.0	1	1	0
Maximum:	0.6	14.1	2,228.9	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/12/2019 00:00	0.6	12.4	2,148.0	0.4	2.0	1	1	1
11/12/2019 01:00	0.6	12.4	2,151.2	0.4	2.0	1	1	1
11/12/2019 02:00	0.6	12.6	2,118.1	0.4	2.0	1	1	1
11/12/2019 03:00	0.4	12.3	2,163.2	0.4	1.3	1	1	1
11/12/2019 04:00	0.4	12.4	2,143.4	0.3	1.3	1	1	1
11/12/2019 05:00	0.4	12.5	2,123.1	0.3	1.3	1	1	1
11/12/2019 06:00	0.4	12.3	2,168.3	0.3	1.3	1	1	1
11/12/2019 07:00	0.4	12.4	2,134.0	0.3	1.3	1	1	1
11/12/2019 08:00	0.4	12.5	2,121.6	0.3	1.3	1	1	1
11/12/2019 09:00	0.4	12.5	2,109.8	0.3	1.3	1	1	1
11/12/2019 10:00	0.4	12.4	2,141.5	0.3	1.3	1	1	1
11/12/2019 11:00	0.3	12.5	2,097.7	0.3	1.0	1	1	1
11/12/2019 12:00	0.3	12.5	2,085.2	0.2	1.0	1	1	1
11/12/2019 13:00	0.5	12.5	2,108.1	0.3	1.7	1	1	1
11/12/2019 14:00	0.5	12.6	2,098.9	0.3	1.7	1	1	1
11/12/2019 15:00	0.6	12.5	2,100.4	0.4	2.0	1	1	1
11/12/2019 16:00	0.6	12.6	2,089.2	0.4	2.0	1	1	1
11/12/2019 17:00	0.6	12.3	2,161.1	0.4	2.0	1	1	1
11/12/2019 18:00	0.6	12.3	2,146.5	0.4	2.0	1	1	1
11/12/2019 19:00	0.6	12.2	2,182.5	0.4	2.0	1	1	1
11/12/2019 20:00	0.6	12.2	2,181.0	0.4	2.0	1	1	1
11/12/2019 21:00	0.5	12.3	2,158.0	0.4	1.7	1	1	1
11/12/2019 22:00	0.6	12.3	2,158.7	0.4	2.0	1	1	1
11/12/2019 23:00	0.6	12.4	2,147.5	0.4	2.0	1	1	1
Average/Sum#:	0.5	12.4	2,134.9	0.4	39.5 #	24 #	24 #	24 #
Minimum:	0.3	12.2	2,085.2	0.2	1.0	1	1	1
Maximum:	0.6	12.6	2,182.5	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/13/2019 00:00	0.5	12.5	2,133.2	0.4	1.7	1	1	1
11/13/2019 01:00	0.4	12.6	2,099.0	0.4	1.3	1	1	1
11/13/2019 02:00	0.4	12.6	2,099.4	0.3	1.3	1	1	1
11/13/2019 03:00	0.4	12.6	2,096.9	0.3	1.3	1	1	1
11/13/2019 04:00	0.4	12.5	2,124.8	0.3	1.3	1	1	1
11/13/2019 05:00	0.5	12.4	2,129.8	0.3	1.7	1	1	1
11/13/2019 06:00	0.4	12.3	2,157.7	0.3	1.3	1	1	1
11/13/2019 07:00	0.4	12.4	2,140.0	0.3	1.3	1	1	1
11/13/2019 08:00	0.4	12.6	2,112.5	0.3	1.3	1	1	1
11/13/2019 09:00	0.4	12.6	2,098.8	0.3	1.3	1	1	1
11/13/2019 10:00	0.4	12.6	2,088.0	0.3	1.3	1	1	1
11/13/2019 11:00	0.4	12.5	2,108.8	0.3	1.3	1	1	1
11/13/2019 12:00	0.6	12.6	2,103.8	0.3	2.0	1	1	1
11/13/2019 13:00	0.6	12.4	2,125.1	0.4	2.0	1	1	1
11/13/2019 14:00	0.5	12.4	2,138.2	0.4	1.7	1	1	1
11/13/2019 15:00	0.6	12.4	2,138.0	0.4	2.0	1	1	1
11/13/2019 16:00	0.6	12.5	2,107.1	0.4	2.0	1	1	1
11/13/2019 17:00	0.5	11.9	2,227.9	0.4	1.6	1	1	1
11/13/2019 18:00	0.5	12.2	2,165.9	0.3	1.6	1	1	1
11/13/2019 19:00	0.5	12.4	2,124.9	0.3	1.7	1	1	1
11/13/2019 20:00	0.6	12.3	2,155.1	0.3	2.0	1	1	1
11/13/2019 21:00	0.6	12.3	2,143.4	0.4	2.0	1	1	1
11/13/2019 22:00	0.6	12.5	2,116.7	0.4	2.0	1	1	1
11/13/2019 23:00	0.6	12.3	2,155.7	0.4	2.0	1	1	1
Average/Sum#:	0.5	12.4	2,128.8	0.3	39.0 #	24 #	24 #	24 #
Minimum:	0.4	11.9	2,088.0	0.3	1.3	1	1	1
Maximum:	0.6	12.6	2,227.9	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/14/2019 00:00	0.5	12.2	2,177.1	0.4	1.7	1	1	1
11/14/2019 01:00	0.5	12.2	2,182.2	0.3	1.7	1	1	1
11/14/2019 02:00	0.5	12.3	2,173.9	0.3	1.7	1	1	1
11/14/2019 03:00	0.5	12.2	2,182.4	0.3	1.7	1	1	1
11/14/2019 04:00	0.5	12.2	2,176.3	0.3	1.7	1	1	1
11/14/2019 05:00	0.6	12.3	2,149.8	0.3	2.0	1	1	1
11/14/2019 06:00	0.5	12.3	2,187.6	0.3	1.7	1	1	1
11/14/2019 07:00	0.4	12.4	2,146.2	0.3	1.3	1	1	1
11/14/2019 08:00	0.4	12.6	2,089.7	0.3	1.3	1	1	1
11/14/2019 09:00	0.4	12.4	2,142.2	0.3	1.3	1	1	1
11/14/2019 10:00	0.4	12.2	2,167.8	0.3	1.3	1	1	1
11/14/2019 11:00	0.4	12.4	2,119.8	0.3	1.3	1	1	1
11/14/2019 12:00	0.5	12.1	2,184.2	0.3	1.6	1	1	1
11/14/2019 13:00	0.6	12.2	2,174.0	0.3	2.0	1	1	1
11/14/2019 14:00	0.6	12.2	2,169.1	0.4	2.0	1	1	1
11/14/2019 15:00	0.6	12.2	2,165.2	0.4	2.0	1	1	1
11/14/2019 16:00	0.9	12.3	2,141.0	0.5	3.0	1	1	1
11/14/2019 17:00	0.6	12.2	2,159.5	0.5	2.0	1	1	1
11/14/2019 18:00	0.6	12.3	2,163.1	0.5	2.0	1	1	1
11/14/2019 19:00	0.6	12.3	2,159.5	0.4	2.0	1	1	1
11/14/2019 20:00	0.5	12.2	2,182.2	0.4	1.7	1	1	1
11/14/2019 21:00	0.4	12.3	2,170.5	0.3	1.3	1	1	1
11/14/2019 22:00	0.4	12.4	2,142.7	0.3	1.3	1	1	1
11/14/2019 23:00	0.5	12.4	2,163.2	0.3	1.7	1	1	1
Average/Sum#:	0.5	12.3	2,161.2	0.3	41.3 #	24 #	24 #	24 #
Minimum:	0.4	12.1	2,089.7	0.3	1.3	1	1	1
Maximum:	0.9	12.6	2,187.6	0.5	3.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/15/2019 00:00	0.4	12.5	2,126.7	0.3	1.3	1	1	1
11/15/2019 01:00	0.3	12.7	2,099.1	0.3	1.0	1	1	1
11/15/2019 02:00	0.3	12.6	2,118.5	0.2	1.0	1	1	1
11/15/2019 03:00	0.3	12.8	2,077.8	0.2	1.0	1	1	1
11/15/2019 04:00	0.3	12.7	2,083.9	0.2	1.0	1	1	1
11/15/2019 05:00	0.3	12.8	2,076.5	0.2	1.0	1	1	1
11/15/2019 06:00	0.4	12.5	2,143.5	0.2	1.3	1	1	1
11/15/2019 07:00	0.3	12.4	2,159.0	0.2	1.0	1	1	1
11/15/2019 08:00	0.3	12.6	2,106.1	0.2	1.0	1	1	1
11/15/2019 09:00	0.3	12.6	2,099.3	0.2	1.0	1	1	1
11/15/2019 10:00	0.2	12.6	2,108.4	0.2	0.7	1	1	1
11/15/2019 11:00	0.2	13.1	1,996.0	0.2	0.7	1	1	1
11/15/2019 12:00	0.3	12.7	2,077.5	0.2	1.0	1	1	1
11/15/2019 13:00	0.4	12.4	2,136.6	0.2	1.3	1	1	1
11/15/2019 14:00	0.5	12.3	2,164.4	0.3	1.7	1	1	1
11/15/2019 15:00	0.5	12.4	2,143.2	0.3	1.7	1	1	1
11/15/2019 16:00	0.5	12.5	2,118.8	0.3	1.7	1	1	1
11/15/2019 17:00	0.5	12.2	2,176.0	0.3	1.7	1	1	1
11/15/2019 18:00	0.5	12.7	2,083.8	0.4	1.7	1	1	1
11/15/2019 19:00	0.5	12.5	2,120.1	0.4	1.7	1	1	1
11/15/2019 20:00	0.5	12.3	2,177.8	0.4	1.7	1	1	1
11/15/2019 21:00	0.5	12.5	2,118.1	0.4	1.7	1	1	1
11/15/2019 22:00	0.5	12.5	2,126.7	0.4	1.7	1	1	1
11/15/2019 23:00	0.5	12.6	2,088.2	0.4	1.7	1	1	1
Average/Sum#:	0.4	12.6	2,113.6	0.3	31.3 #	24 #	24 #	24 #
Minimum:	0.2	12.2	1,996.0	0.2	0.7	1	1	1
Maximum:	0.5	13.1	2,177.8	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/16/2019 00:00	0.5	12.7	2,078.5	0.4	1.7	1	1	1
11/16/2019 01:00	0.4	12.8	2,069.7	0.4	1.3	1	1	1
11/16/2019 02:00	0.4	12.7	2,080.8	0.3	1.3	1	1	1
11/16/2019 03:00	0.3	12.7	2,084.1	0.3	1.0	1	1	1
11/16/2019 04:00	0.4	12.7	2,078.2	0.3	1.3	1	1	1
11/16/2019 05:00	0.4	12.7	2,086.5	0.3	1.3	1	1	1
11/16/2019 06:00	0.4	12.6	2,100.0	0.3	1.3	1	1	1
11/16/2019 07:00	0.3	12.8	2,042.8	0.3	1.0	1	1	1
11/16/2019 08:00	0.0	14.0	1,650.9	0.2	0.0	1	1	0
11/16/2019 09:00	0.0	14.0	1,550.5	0.1	0.0	1	1	0
11/16/2019 10:00	0.0	14.0	1,576.9	0.0	0.0	1	1	0
11/16/2019 11:00	0.0	14.0	1,669.1	0.0	0.0	1	1	0
11/16/2019 12:00	0.0	14.0	1,625.8	0.0	0.0	1	1	0
11/16/2019 13:00	0.0	14.1	1,708.8	0.0	0.0	1	1	0
11/16/2019 14:00	0.0	14.1	1,686.5	0.0	0.0	1	1	0
11/16/2019 15:00	0.0	14.0	1,581.4	0.0	0.0	1	1	1
11/16/2019 16:00	0.6	12.7	2,073.2	0.1	2.0	1	1	1
11/16/2019 17:00	0.6	12.4	2,137.6	0.3	2.0	1	1	1
11/16/2019 18:00	0.6	12.5	2,118.9	0.4	2.0	1	1	1
11/16/2019 19:00	0.6	12.5	2,128.5	0.4	2.0	1	1	1
11/16/2019 20:00	0.6	12.4	2,133.1	0.4	2.0	1	1	1
11/16/2019 21:00	0.6	12.4	2,141.3	0.4	2.0	1	1	1
11/16/2019 22:00	0.6	12.5	2,124.7	0.4	2.0	1	1	1
11/16/2019 23:00	0.6	12.6	2,115.1	0.4	2.0	1	1	1
Average/Sum#:	0.3	13.1	1,943.5	0.2	26.2 #	24 #	24 #	17 #
Minimum:	0.0	12.4	1,550.5	0.0	0.0	1	1	0
Maximum:	0.6	14.1	2,141.3	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/17/2019 00:00	0.6	12.7	2,097.8	0.4	2.0	1	1	1
11/17/2019 01:00	0.5	12.7	2,100.2	0.4	1.7	1	1	1
11/17/2019 02:00	0.4	13.3	1,938.3	0.4	1.3	1	1	1
11/17/2019 03:00	0.0	14.0	1,594.7	0.2	0.0	1	1	0
11/17/2019 04:00	0.0	14.0	1,701.8	0.1	0.0	1	1	0
11/17/2019 05:00	0.0	14.0	1,564.5	0.0	0.0	1	1	0
11/17/2019 06:00	0.0	14.0	1,703.8	0.0	0.0	1	1	0
11/17/2019 07:00	0.0	14.0	1,660.3	0.0	0.0	1	1	0
11/17/2019 08:00	0.0	14.0	1,663.7	0.0	0.0	1	1	0
11/17/2019 09:00	0.0	14.0	1,671.7	0.0	0.0	1	1	0
11/17/2019 10:00	0.0	14.0	1,650.1	0.0	0.0	1	1	0
11/17/2019 11:00	0.0	14.0	1,705.8	0.0	0.0	1	1	0
11/17/2019 12:00	0.0	14.1	1,632.0	0.0	0.0	1	1	0
11/17/2019 13:00	0.0	14.1	1,679.6	0.0	0.0	1	1	0
11/17/2019 14:00	0.0	14.0	1,563.0	0.0	0.0	1	1	1
11/17/2019 15:00	0.6	12.7	2,053.9	0.1	2.0	1	1	1
11/17/2019 16:00	0.6	12.5	2,109.5	0.3	2.0	1	1	1
11/17/2019 17:00	0.6	12.5	2,097.8	0.4	2.0	1	1	1
11/17/2019 18:00	0.6	12.4	2,116.5	0.4	2.0	1	1	1
11/17/2019 19:00	0.6	12.3	2,144.0	0.4	2.0	1	1	1
11/17/2019 20:00	0.6	12.3	2,149.2	0.4	2.0	1	1	1
11/17/2019 21:00	0.6	12.3	2,152.5	0.4	2.0	1	1	1
11/17/2019 22:00	0.6	12.5	2,113.2	0.4	2.0	1	1	1
11/17/2019 23:00	0.5	12.7	2,085.7	0.4	1.7	1	1	1
Average/Sum#:	0.3	13.3	1,872.9	0.2	22.7 #	24 #	24 #	13 #
Minimum:	0.0	12.3	1,563.0	0.0	0.0	1	1	0
Maximum:	0.6	14.1	2,152.5	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/18/2019 00:00	0.5	12.5	2,099.3	0.4	1.7	1	1	1
11/18/2019 01:00	0.5	12.6	2,101.4	0.4	1.7	1	1	1
11/18/2019 02:00	0.5	12.6	2,099.3	0.4	1.7	1	1	1
11/18/2019 03:00	0.5	12.6	2,099.6	0.4	1.7	1	1	1
11/18/2019 04:00	0.4	12.7	2,083.5	0.4	1.3	1	1	1
11/18/2019 05:00	0.5	12.6	2,088.7	0.4	1.7	1	1	1
11/18/2019 06:00	0.6	12.3	2,158.7	0.4	2.0	1	1	1
11/18/2019 07:00	0.4	12.4	2,136.0	0.4	1.3	1	1	1
11/18/2019 08:00	0.4	12.7	2,084.1	0.3	1.3	1	1	1
11/18/2019 09:00	0.4	12.9	2,026.6	0.3	1.3	1	1	1
11/18/2019 10:00	0.6	12.5	2,120.4	0.3	2.0	1	1	1
11/18/2019 11:00	0.6	12.1	2,188.2	0.4	2.0	1	1	1
11/18/2019 12:00	0.6	12.3	2,143.8	0.4	2.0	1	1	1
11/18/2019 13:00	0.5	12.2	2,164.1	0.4	1.6	1	1	1
11/18/2019 14:00	0.5	12.2	2,149.0	0.3	1.6	1	1	1
11/18/2019 15:00	0.5	12.2	2,147.4	0.3	1.6	1	1	1
11/18/2019 16:00	0.5	11.9	2,201.8	0.3	1.6	1	1	1
11/18/2019 17:00	0.5	12.1	2,181.8	0.3	1.6	1	1	1
11/18/2019 18:00	0.5	11.8	2,238.2	0.3	1.6	1	1	1
11/18/2019 19:00	0.5	12.0	2,203.9	0.3	1.6	1	1	1
11/18/2019 20:00	0.5	12.0	2,198.4	0.3	1.6	1	1	1
11/18/2019 21:00	0.5	12.2	2,157.2	0.3	1.6	1	1	1
11/18/2019 22:00	0.5	12.2	2,152.1	0.3	1.6	1	1	1
11/18/2019 23:00	0.5	12.3	2,144.0	0.3	1.6	1	1	1
Average/Sum#:	0.5	12.3	2,140.3	0.3	39.3 #	24 #	24 #	24 #
Minimum:	0.4	11.8	2,026.6	0.3	1.3	1	1	1
Maximum:	0.6	12.9	2,238.2	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/19/2019 00:00	0.6	12.3	2,139.1	0.3	2.0	1	1	1
11/19/2019 01:00	0.6	12.5	2,096.8	0.4	2.0	1	1	1
11/19/2019 02:00	0.6	12.5	2,092.4	0.4	2.0	1	1	1
11/19/2019 03:00	0.5	12.5	2,088.6	0.4	1.6	1	1	1
11/19/2019 04:00	0.5	12.5	2,094.5	0.4	1.6	1	1	1
11/19/2019 05:00	0.5	12.4	2,105.8	0.4	1.6	1	1	1
11/19/2019 06:00	0.5	12.5	2,087.1	0.4	1.6	1	1	1
11/19/2019 07:00	0.4	12.4	2,111.5	0.3	1.3	1	1	1
11/19/2019 08:00	0.5	12.1	2,176.8	0.3	1.6	1	1	1
11/19/2019 09:00	0.0	0.0	2,145.5	0.0	0.0	1	1	1
11/19/2019 10:00	0.4	12.2	2,186.7	0.0	1.3	1	1	1
11/19/2019 11:00	0.4	12.4	2,153.9	0.0	1.3	1	1	1
11/19/2019 12:00	0.4	12.4	2,125.1	0.3	1.3	1	1	1
11/19/2019 13:00	0.4	12.5	2,113.5	0.3	1.3	1	1	1
11/19/2019 14:00	0.4	12.3	2,141.3	0.3	1.3	1	1	1
11/19/2019 15:00	0.4	12.5	2,106.0	0.3	1.3	1	1	1
11/19/2019 16:00	0.4	12.5	2,103.7	0.3	1.3	1	1	1
11/19/2019 17:00	0.3	12.0	2,219.9	0.3	1.0	1	1	1
11/19/2019 18:00	0.3	11.7	2,265.4	0.2	1.0	1	1	1
11/19/2019 19:00	0.4	12.3	2,145.2	0.2	1.3	1	1	1
11/19/2019 20:00	0.4	12.5	2,114.6	0.3	1.3	1	1	1
11/19/2019 21:00	0.4	12.4	2,140.3	0.3	1.3	1	1	1
11/19/2019 22:00	0.4	12.4	2,145.4	0.3	1.3	1	1	1
11/19/2019 23:00	0.4	12.3	2,154.4	0.3	1.3	1	1	1
Average/Sum#:	0.4	12.4	2,135.6	0.3	32.9 #	24 #	24 #	24 #
Minimum:	0.3	11.7	2,087.1	0.2	1.0	1	1	1
Maximum:	0.6	12.5	2,265.4	0.4	2.0	1	1	1
%SI	4.17	4.17	0.00	12.50	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/20/2019 00:00	0.4	12.5	2,120.3	0.3	1.3	1	1	1
11/20/2019 01:00	0.4	12.6	2,100.2	0.3	1.3	1	1	1
11/20/2019 02:00	0.4	12.7	2,076.7	0.3	1.3	1	1	1
11/20/2019 03:00	0.4	12.7	2,083.5	0.3	1.3	1	1	1
11/20/2019 04:00	0.4	12.6	2,102.7	0.3	1.3	1	1	1
11/20/2019 05:00	0.5	12.5	2,106.1	0.3	1.7	1	1	1
11/20/2019 06:00	0.4	12.3	2,169.8	0.3	1.3	1	1	1
11/20/2019 07:00	0.4	12.2	2,195.6	0.3	1.3	1	1	1
11/20/2019 08:00	0.4	12.2	2,180.4	0.3	1.3	1	1	1
11/20/2019 09:00	0.4	12.2	2,193.1	0.3	1.3	1	1	1
11/20/2019 10:00	0.4	12.2	2,192.6	0.3	1.3	1	1	1
11/20/2019 11:00	0.4	12.4	2,139.0	0.3	1.3	1	1	1
11/20/2019 12:00	0.4	12.4	2,142.5	0.3	1.3	1	1	1
11/20/2019 13:00	0.4	12.4	2,150.5	0.3	1.3	1	1	1
11/20/2019 14:00	0.4	12.2	2,171.7	0.3	1.3	1	1	1
11/20/2019 15:00	0.3	12.1	2,208.1	0.3	1.0	1	1	1
11/20/2019 16:00	0.4	12.3	2,163.5	0.3	1.3	1	1	1
11/20/2019 17:00	0.3	11.8	2,273.5	0.2	1.0	1	1	1
11/20/2019 18:00	0.3	11.7	2,282.2	0.2	1.0	1	1	1
11/20/2019 19:00	0.3	11.7	2,291.3	0.2	1.0	1	1	1
11/20/2019 20:00	0.3	11.9	2,247.2	0.2	1.0	1	1	1
11/20/2019 21:00	0.3	12.1	2,224.0	0.2	1.0	1	1	1
11/20/2019 22:00	0.4	12.3	2,173.9	0.2	1.3	1	1	1
11/20/2019 23:00	0.4	12.4	2,154.4	0.3	1.3	1	1	1
Average/Sum#:	0.4	12.3	2,172.6	0.3	29.8 #	24 #	24 #	24 #
Minimum:	0.3	11.7	2,076.7	0.2	1.0	1	1	1
Maximum:	0.5	12.7	2,291.3	0.3	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2019 00:00	0.4	12.3	2,188.1	0.3	1.3	1	1	1
11/21/2019 01:00	0.4	12.2	2,194.2	0.3	1.3	1	1	1
11/21/2019 02:00	0.4	12.3	2,179.6	0.3	1.3	1	1	1
11/21/2019 03:00	0.3	12.2	2,206.5	0.3	1.0	1	1	1
11/21/2019 04:00	0.2	12.1	2,215.0	0.2	0.7	1	1	1
11/21/2019 05:00	0.3	11.9	2,218.3	0.2	1.0	1	1	1
11/21/2019 06:00	0.2	11.8	2,280.5	0.1	0.7	1	1	1
11/21/2019 07:00	0.2	11.8	2,282.9	0.1	0.7	1	1	1
11/21/2019 08:00	0.3	12.3	2,191.2	0.1	1.0	1	1	1
11/21/2019 09:00	0.3	12.7	2,096.8	0.2	1.0	1	1	1
11/21/2019 10:00	0.4	12.5	2,131.4	0.2	1.3	1	1	1
11/21/2019 11:00	0.4	12.7	2,086.9	0.3	1.3	1	1	1
11/21/2019 12:00	0.4	12.5	2,127.9	0.3	1.3	1	1	1
11/21/2019 13:00	0.4	12.6	2,107.6	0.3	1.3	1	1	1
11/21/2019 14:00	0.4	12.6	2,096.1	0.3	1.3	1	1	1
11/21/2019 15:00	0.4	12.5	2,124.4	0.3	1.3	1	1	1
11/21/2019 16:00	0.4	12.1	2,220.6	0.3	1.3	1	1	1
11/21/2019 17:00	0.4	11.9	2,254.5	0.3	1.3	1	1	1
11/21/2019 18:00	0.4	11.8	2,278.5	0.3	1.3	1	1	1
11/21/2019 19:00	0.3	11.7	2,285.4	0.3	1.0	1	1	1
11/21/2019 20:00	0.2	11.7	2,278.3	0.2	0.7	1	1	1
11/21/2019 21:00	0.2	11.8	2,282.3	0.1	0.7	1	1	1
11/21/2019 22:00	0.3	12.0	2,249.1	0.1	1.0	1	1	1
11/21/2019 23:00	0.3	12.1	2,206.6	0.2	1.0	1	1	1
Average/Sum#:	0.3	12.2	2,199.3	0.2	26.1 #	24 #	24 #	24 #
Minimum:	0.2	11.7	2,086.9	0.1	0.7	1	1	1
Maximum:	0.4	12.7	2,285.4	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2019 00:00	0.3	12.3	2,168.0	0.2	1.0	1	1	1
11/22/2019 01:00	0.3	12.4	2,163.6	0.2	1.0	1	1	1
11/22/2019 02:00	0.3	12.4	2,167.5	0.2	1.0	1	1	1
11/22/2019 03:00	0.3	12.4	2,166.0	0.2	1.0	1	1	1
11/22/2019 04:00	0.3	12.7	2,106.4	0.2	1.0	1	1	1
11/22/2019 05:00	0.2	12.7	2,080.5	0.2	0.7	1	1	1
11/22/2019 06:00	0.2	11.9	2,283.4	0.1	0.7	1	1	1
11/22/2019 07:00	0.1	12.0	2,262.6	0.1	0.3	1	1	1
11/22/2019 08:00	0.1	12.6	2,099.8	0.1	0.3	1	1	1
11/22/2019 09:00	0.2	12.8	2,074.5	0.1	0.7	1	1	1
11/22/2019 10:00	0.2	12.7	2,102.7	0.1	0.7	1	1	1
11/22/2019 11:00	0.2	12.8	2,076.6	0.1	0.7	1	1	1
11/22/2019 12:00	0.3	12.7	2,087.1	0.1	1.0	1	1	1
11/22/2019 13:00	0.2	12.7	2,078.5	0.1	0.7	1	1	1
11/22/2019 14:00	0.3	12.6	2,103.2	0.2	1.0	1	1	1
11/22/2019 15:00	0.3	12.5	2,107.9	0.2	1.0	1	1	1
11/22/2019 16:00	0.2	11.9	2,239.2	0.2	0.7	1	1	1
11/22/2019 17:00	0.2	12.0	2,226.1	0.1	0.7	1	1	1
11/22/2019 18:00	0.2	11.9	2,251.6	0.1	0.7	1	1	1
11/22/2019 19:00	0.2	12.0	2,222.5	0.1	0.7	1	1	1
11/22/2019 20:00	0.2	12.1	2,218.5	0.1	0.7	1	1	1
11/22/2019 21:00	0.1	12.0	2,229.1	0.1	0.3	1	1	1
11/22/2019 22:00	0.1	12.1	2,188.7	0.1	0.3	1	1	1
11/22/2019 23:00	0.1	12.4	2,146.0	0.1	0.3	1	1	1
Average/Sum#:	0.2	12.4	2,160.4	0.1	17.2 #	24 #	24 #	24 #
Minimum:	0.1	11.9	2,074.5	0.1	0.3	1	1	1
Maximum:	0.3	12.8	2,283.4	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/23/2019 00:00	0.1	12.4	2,135.3	0.1	0.3	1	1	1
11/23/2019 01:00	0.1	12.3	2,161.1	0.1	0.3	1	1	1
11/23/2019 02:00	0.2	12.5	2,151.6	0.1	0.7	1	1	1
11/23/2019 03:00	0.1	12.7	2,110.4	0.1	0.3	1	1	1
11/23/2019 04:00	0.1	12.4	2,162.2	0.1	0.3	1	1	1
11/23/2019 05:00	0.2	12.3	2,169.0	0.1	0.7	1	1	1
11/23/2019 06:00	0.1	12.3	2,179.1	0.1	0.3	1	1	1
11/23/2019 07:00	0.1	12.4	2,145.1	0.1	0.3	1	1	1
11/23/2019 08:00	0.1	13.2	1,952.5	0.1	0.3	1	1	1
11/23/2019 09:00	0.0	13.9	1,695.8	0.1	0.0	1	1	0
11/23/2019 10:00	0.0	14.0	1,715.5	0.0	0.0	1	1	0
11/23/2019 11:00	0.0	14.0	1,686.0	0.0	0.0	1	1	0
11/23/2019 12:00	0.0	14.0	1,703.4	0.0	0.0	1	1	0
11/23/2019 13:00	0.0	14.0	1,720.5	0.0	0.0	1	1	0
11/23/2019 14:00	0.0	14.0	1,690.7	0.0	0.0	1	1	0
11/23/2019 15:00	0.1	13.4	1,871.8	0.0	0.3	1	1	1
11/23/2019 16:00	0.2	12.3	2,154.9	0.1	0.7	1	1	1
11/23/2019 17:00	0.2	12.2	2,185.9	0.1	0.7	1	1	1
11/23/2019 18:00	0.2	12.2	2,185.5	0.1	0.7	1	1	1
11/23/2019 19:00	0.2	12.0	2,233.6	0.1	0.7	1	1	1
11/23/2019 20:00	0.2	12.1	2,218.8	0.1	0.7	1	1	1
11/23/2019 21:00	0.2	12.4	2,159.6	0.1	0.7	1	1	1
11/23/2019 22:00	0.1	12.6	2,118.5	0.1	0.3	1	1	1
11/23/2019 23:00	0.1	12.6	2,079.4	0.1	0.3	1	1	1
Average/Sum#:	0.1	12.8	2,024.4	0.1	8.6 #	24 #	24 #	18 #
Minimum:	0.0	12.0	1,686.0	0.0	0.0	1	1	0
Maximum:	0.2	14.0	2,233.6	0.1	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/24/2019 00:00	0.1	12.6	2,079.0	0.1	0.3	1	1	1
11/24/2019 01:00	0.1	12.7	2,078.7	0.1	0.3	1	1	1
11/24/2019 02:00	0.1	12.8	2,064.3	0.1	0.3	1	1	1
11/24/2019 03:00	0.1	12.9	2,062.7	0.1	0.3	1	1	1
11/24/2019 04:00	0.1	12.8	2,075.8	0.1	0.3	1	1	1
11/24/2019 05:00	0.2	12.8	2,072.2	0.1	0.7	1	1	1
11/24/2019 06:00	0.2	12.6	2,133.4	0.1	0.7	1	1	1
11/24/2019 07:00	0.1	12.7	2,068.8	0.1	0.3	1	1	1
11/24/2019 08:00	0.0	13.9	1,683.6	0.1	0.0	1	1	0
11/24/2019 09:00	0.0	13.9	1,672.7	0.0	0.0	1	1	0
11/24/2019 10:00	0.0	13.9	1,700.6	0.0	0.0	1	1	0
11/24/2019 11:00	0.0	13.9	1,694.9	0.0	0.0	1	1	0
11/24/2019 12:00	0.0	13.9	1,728.2	0.0	0.0	1	1	0
11/24/2019 13:00	0.0	14.0	1,711.7	0.0	0.0	1	1	0
11/24/2019 14:00	0.0	14.0	1,665.9	0.0	0.0	1	1	0
11/24/2019 15:00	0.0	13.4	1,867.6	0.0	0.0	1	1	1
11/24/2019 16:00	0.3	12.6	2,101.8	0.1	1.0	1	1	1
11/24/2019 17:00	0.3	12.3	2,155.5	0.1	1.0	1	1	1
11/24/2019 18:00	0.3	12.7	2,076.3	0.2	1.0	1	1	1
11/24/2019 19:00	0.2	12.9	2,015.8	0.2	0.7	1	1	1
11/24/2019 20:00	0.3	12.7	2,085.2	0.2	1.0	1	1	1
11/24/2019 21:00	0.2	12.4	2,134.5	0.1	0.7	1	1	1
11/24/2019 22:00	0.2	12.7	2,063.8	0.1	0.7	1	1	1
11/24/2019 23:00	0.0	13.4	1,842.0	0.1	0.0	1	1	1
Average/Sum#:	0.1	13.1	1,951.5	0.1	9.3 #	24 #	24 #	17 #
Minimum:	0.0	12.3	1,665.9	0.0	0.0	1	1	0
Maximum:	0.3	14.0	2,155.5	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/25/2019 00:00	4.3	14.5	1,078.5	0.0	6.0	1	1	0
11/25/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/25/2019 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/25/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/25/2019 04:00	20.1	17.3	516.8	0.0	17.1	1	1	0
11/25/2019 05:00	14.7	14.5	1,328.8	0.0	40.3	1	1	0
11/25/2019 06:00	0.0	14.0	1,394.5	0.0	0.0	1	1	0
11/25/2019 07:00	0.0	13.9	1,648.7	0.0	0.0	1	1	0
11/25/2019 08:00	0.0	13.9	1,697.7	0.0	0.0	1	1	0
11/25/2019 09:00	0.0	13.9	1,651.8	0.0	0.0	1	1	0
11/25/2019 10:00	0.0	14.0	1,674.1	0.0	0.0	1	1	0
11/25/2019 11:00	0.0	14.0	1,719.6	0.0	0.0	1	1	0
11/25/2019 12:00	0.0	14.0	1,712.3	0.0	0.0	1	1	0
11/25/2019 13:00	0.0	14.0	1,707.9	0.0	0.0	1	1	0
11/25/2019 14:00	0.0	14.0	1,698.8	0.0	0.0	1	1	0
11/25/2019 15:00	0.0	13.9	1,615.4	0.0	0.0	1	1	1
11/25/2019 16:00	0.3	12.8	2,087.6	0.1	1.0	1	1	1
11/25/2019 17:00	0.3	12.0	2,236.1	0.1	1.0	1	1	1
11/25/2019 18:00	0.3	12.4	2,136.2	0.2	1.0	1	1	1
11/25/2019 19:00	0.3	12.2	2,193.1	0.2	1.0	1	1	1
11/25/2019 20:00	0.3	12.2	2,199.1	0.2	1.0	1	1	1
11/25/2019 21:00	0.3	12.3	2,163.2	0.2	1.0	1	1	1
11/25/2019 22:00	0.3	12.5	2,128.3	0.2	1.0	1	1	1
11/25/2019 23:00	0.2	12.6	2,107.0	0.2	0.7	1	1	1
Average/Sum#:	2.0	13.6	1,747.4	0.1	71.1 #	21 #	24 #	9 #
Minimum:	0.0	12.0	516.8	0.0	0.0	0	1	0
Maximum:	20.1	17.3	2,236.1	0.2	40.3	1	1	1
%SI	12.50	12.50	12.50	33.33	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/26/2019 00:00	0.3	12.5	2,137.6	0.2	1.0	1	1	1
11/26/2019 01:00	0.3	12.4	2,161.7	0.2	1.0	1	1	1
11/26/2019 02:00	0.2	12.7	2,087.5	0.2	0.7	1	1	1
11/26/2019 03:00	0.2	12.7	2,083.5	0.1	0.7	1	1	1
11/26/2019 04:00	0.2	12.8	2,070.4	0.1	0.7	1	1	1
11/26/2019 05:00	0.3	13.0	2,007.1	0.1	1.0	1	1	1
11/26/2019 06:00	0.3	12.2	2,213.6	0.2	1.0	1	1	1
11/26/2019 07:00	0.1	12.7	1,981.9	0.2	0.3	1	1	1
11/26/2019 08:00	0.0	13.9	1,686.6	0.1	0.0	1	1	0
11/26/2019 09:00	0.0	13.9	1,713.5	0.0	0.0	1	1	0
11/26/2019 10:00	0.0	13.9	1,588.4	0.0	0.0	1	1	0
11/26/2019 11:00	0.0	13.9	1,644.8	0.0	0.0	1	1	0
11/26/2019 12:00	0.0	13.9	1,623.1	0.0	0.0	1	1	0
11/26/2019 13:00	0.0	13.9	1,659.4	0.0	0.0	1	1	0
11/26/2019 14:00	0.1	13.3	1,884.0	0.0	0.3	1	1	1
11/26/2019 15:00	0.4	12.6	2,088.4	0.1	1.3	1	1	1
11/26/2019 16:00	0.3	12.7	2,052.2	0.2	1.0	1	1	1
11/26/2019 17:00	0.3	12.4	2,125.3	0.2	1.0	1	1	1
11/26/2019 18:00	0.4	12.5	2,092.2	0.2	1.3	1	1	1
11/26/2019 19:00	0.4	12.5	2,117.1	0.3	1.3	1	1	1
11/26/2019 20:00	0.4	12.2	2,157.1	0.3	1.3	1	1	1
11/26/2019 21:00	0.4	12.3	2,127.0	0.3	1.3	1	1	1
11/26/2019 22:00	0.4	12.4	2,102.4	0.3	1.3	1	1	1
11/26/2019 23:00	0.4	12.3	2,115.3	0.3	1.3	1	1	1
Average/Sum#:	0.2	12.9	1,980.0	0.2	17.8 #	24 #	24 #	18 #
Minimum:	0.0	12.2	1,588.4	0.0	0.0	1	1	0
Maximum:	0.4	13.9	2,213.6	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/27/2019 00:00	0.4	12.3	2,131.6	0.3	1.3	1	1	1
11/27/2019 01:00	0.4	12.4	2,100.9	0.3	1.3	1	1	1
11/27/2019 02:00	0.4	12.6	2,064.8	0.3	1.3	1	1	1
11/27/2019 03:00	0.4	12.6	2,058.7	0.3	1.3	1	1	1
11/27/2019 04:00	0.4	12.6	2,071.6	0.3	1.3	1	1	1
11/27/2019 05:00	0.4	12.5	2,079.9	0.3	1.3	1	1	1
11/27/2019 06:00	0.4	12.8	2,025.5	0.3	1.3	1	1	1
11/27/2019 07:00	0.4	12.1	2,178.0	0.3	1.3	1	1	1
11/27/2019 08:00	0.3	12.2	2,174.5	0.3	1.0	1	1	1
11/27/2019 09:00	0.3	12.2	2,155.2	0.2	1.0	1	1	1
11/27/2019 10:00	0.3	12.2	2,140.8	0.2	1.0	1	1	1
11/27/2019 11:00	0.3	12.5	2,090.7	0.2	1.0	1	1	1
11/27/2019 12:00	0.3	12.3	2,124.2	0.2	1.0	1	1	1
11/27/2019 13:00	0.3	12.0	2,180.1	0.2	1.0	1	1	1
11/27/2019 14:00	0.3	12.1	2,162.8	0.2	1.0	1	1	1
11/27/2019 15:00	0.3	12.4	2,092.8	0.2	1.0	1	1	1
11/27/2019 16:00	0.3	12.6	2,059.0	0.2	1.0	1	1	1
11/27/2019 17:00	0.3	12.2	2,159.1	0.2	1.0	1	1	1
11/27/2019 18:00	0.2	13.0	1,989.8	0.2	0.7	1	1	1
11/27/2019 19:00	0.3	13.0	2,006.4	0.2	1.0	1	1	1
11/27/2019 20:00	0.4	12.1	2,207.3	0.2	1.3	1	1	1
11/27/2019 21:00	0.3	11.9	2,234.6	0.2	1.0	1	1	1
11/27/2019 22:00	0.4	12.3	2,173.1	0.3	1.3	1	1	1
11/27/2019 23:00	0.4	12.4	2,153.8	0.3	1.3	1	1	1
Average/Sum#:	0.3	12.4	2,117.3	0.2	27.0 #	24 #	24 #	24 #
Minimum:	0.2	11.9	1,989.8	0.2	0.7	1	1	1
Maximum:	0.4	13.0	2,234.6	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2019 00:00	0.4	12.4	2,161.0	0.3	1.3	1	1	1
11/28/2019 01:00	0.4	12.5	2,137.8	0.3	1.3	1	1	1
11/28/2019 02:00	0.3	12.6	2,125.3	0.3	1.0	1	1	1
11/28/2019 03:00	0.2	12.5	2,162.9	0.2	0.7	1	1	1
11/28/2019 04:00	0.2	12.6	2,131.3	0.1	0.7	1	1	1
11/28/2019 05:00	0.3	12.7	2,102.0	0.1	1.0	1	1	1
11/28/2019 06:00	0.3	12.3	2,201.5	0.2	1.0	1	1	1
11/28/2019 07:00	0.4	12.2	2,216.2	0.2	1.3	1	1	1
11/28/2019 08:00	0.4	12.2	2,221.7	0.3	1.3	1	1	1
11/28/2019 09:00	0.4	12.2	2,198.3	0.3	1.3	1	1	1
11/28/2019 10:00	0.4	12.2	2,207.0	0.3	1.3	1	1	1
11/28/2019 11:00	0.3	12.1	2,215.4	0.3	1.0	1	1	1
11/28/2019 12:00	0.3	12.0	2,219.1	0.2	1.0	1	1	1
11/28/2019 13:00	0.3	12.1	2,200.5	0.2	1.0	1	1	1
11/28/2019 14:00	0.3	12.1	2,194.1	0.2	1.0	1	1	1
11/28/2019 15:00	0.3	12.0	2,210.6	0.2	1.0	1	1	1
11/28/2019 16:00	0.3	12.2	2,167.3	0.2	1.0	1	1	1
11/28/2019 17:00	0.3	12.2	2,167.5	0.2	1.0	1	1	1
11/28/2019 18:00	0.2	12.6	2,073.1	0.2	0.7	1	1	1
11/28/2019 19:00	0.3	12.3	2,158.8	0.2	1.0	1	1	1
11/28/2019 20:00	0.3	12.1	2,191.1	0.2	1.0	1	1	1
11/28/2019 21:00	0.3	12.1	2,190.6	0.2	1.0	1	1	1
11/28/2019 22:00	0.3	12.2	2,184.7	0.2	1.0	1	1	1
11/28/2019 23:00	0.3	12.0	2,207.5	0.2	1.0	1	1	1
Average/Sum#:	0.3	12.3	2,176.9	0.2	24.9 #	24 #	24 #	24 #
Minimum:	0.2	12.0	2,073.1	0.1	0.7	1	1	1
Maximum:	0.4	12.7	2,221.7	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/29/2019 00:00	0.3	12.1	2,208.9	0.2	1.0	1	1	1
11/29/2019 01:00	0.3	12.2	2,179.2	0.2	1.0	1	1	1
11/29/2019 02:00	0.3	12.2	2,185.4	0.2	1.0	1	1	1
11/29/2019 03:00	0.4	12.3	2,170.1	0.2	1.3	1	1	1
11/29/2019 04:00	0.3	12.1	2,198.9	0.2	1.0	1	1	1
11/29/2019 05:00	0.4	12.3	2,162.0	0.3	1.3	1	1	1
11/29/2019 06:00	0.4	12.1	2,217.2	0.3	1.3	1	1	1
11/29/2019 07:00	0.2	12.4	2,113.6	0.2	0.7	1	1	1
11/29/2019 08:00	0.0	13.9	1,595.4	0.1	0.0	1	1	0
11/29/2019 09:00	0.0	13.9	1,471.2	0.0	0.0	1	1	0
11/29/2019 10:00	0.0	13.9	1,632.9	0.0	0.0	1	1	0
11/29/2019 11:00	0.0	13.9	1,637.9	0.0	0.0	1	1	0
11/29/2019 12:00	0.0	13.9	1,587.7	0.0	0.0	1	1	0
11/29/2019 13:00	0.0	13.9	1,585.6	0.0	0.0	1	1	0
11/29/2019 14:00	0.0	13.9	1,495.2	0.0	0.0	1	1	0
11/29/2019 15:00	0.0	13.9	1,618.1	0.0	0.0	1	1	1
11/29/2019 16:00	0.2	12.8	2,052.1	0.0	0.7	1	1	1
11/29/2019 17:00	0.1	11.9	2,265.6	0.1	0.3	1	1	1
11/29/2019 18:00	0.1	11.8	2,286.7	0.1	0.3	1	1	1
11/29/2019 19:00	0.1	11.9	2,261.6	0.1	0.3	1	1	1
11/29/2019 20:00	0.1	11.9	2,271.4	0.1	0.3	1	1	1
11/29/2019 21:00	0.1	12.4	2,160.2	0.1	0.3	1	1	1
11/29/2019 22:00	0.2	12.5	2,173.5	0.1	0.7	1	1	1
11/29/2019 23:00	0.2	12.5	2,165.2	0.1	0.7	1	1	1
Average/Sum#:	0.2	12.8	1,987.3	0.1	12.2 #	24 #	24 #	17 #
Minimum:	0.0	11.8	1,471.2	0.0	0.0	1	1	0
Maximum:	0.4	13.9	2,286.7	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/30/2019 00:00	0.2	12.5	2,158.3	0.1	0.7	1	1	1
11/30/2019 01:00	0.2	12.5	2,155.6	0.1	0.7	1	1	1
11/30/2019 02:00	0.2	12.5	2,169.5	0.1	0.7	1	1	1
11/30/2019 03:00	0.2	12.4	2,170.5	0.1	0.7	1	1	1
11/30/2019 04:00	0.2	12.5	2,153.1	0.1	0.7	1	1	1
11/30/2019 05:00	0.2	12.5	2,132.3	0.1	0.7	1	1	1
11/30/2019 06:00	0.2	12.4	2,169.6	0.1	0.7	1	1	1
11/30/2019 07:00	0.2	12.5	2,138.0	0.1	0.7	1	1	1
11/30/2019 08:00	0.2	12.5	2,161.5	0.1	0.7	1	1	1
11/30/2019 09:00	0.2	12.4	2,180.5	0.1	0.7	1	1	1
11/30/2019 10:00	0.2	12.5	2,147.7	0.1	0.7	1	1	1
11/30/2019 11:00	0.2	12.7	2,092.1	0.1	0.7	1	1	1
11/30/2019 12:00	0.2	12.4	2,167.7	0.1	0.7	1	1	1
11/30/2019 13:00	0.2	12.4	2,162.5	0.1	0.7	1	1	1
11/30/2019 14:00	0.2	12.4	2,171.4	0.1	0.7	1	1	1
11/30/2019 15:00	0.2	12.5	2,151.6	0.1	0.7	1	1	1
11/30/2019 16:00	0.2	12.5	2,149.0	0.1	0.7	1	1	1
11/30/2019 17:00	0.2	12.4	2,166.5	0.1	0.7	1	1	1
11/30/2019 18:00	0.2	12.6	2,135.2	0.1	0.7	1	1	1
11/30/2019 19:00	0.2	12.2	2,213.0	0.1	0.7	1	1	1
11/30/2019 20:00	0.2	12.4	2,171.8	0.1	0.7	1	1	1
11/30/2019 21:00	0.2	12.4	2,156.3	0.1	0.7	1	1	1
11/30/2019 22:00	0.2	12.7	2,104.5	0.1	0.7	1	1	1
11/30/2019 23:00	0.2	12.8	2,091.4	0.1	0.7	1	1	1
Average/Sum#:	0.2	12.5	2,152.9	0.1	16.8 #	24 #	24 #	24 #
Minimum:	0.2	12.2	2,091.4	0.1	0.7	1	1	1
Maximum:	0.2	12.8	2,213.0	0.1	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2019 00:00	0.2	12.6	2,140.9	0.1	0.7	1	1	1
12/01/2019 01:00	0.2	12.8	2,090.4	0.1	0.7	1	1	1
12/01/2019 02:00	0.2	12.8	2,089.1	0.1	0.7	1	1	1
12/01/2019 03:00	0.2	12.8	2,089.2	0.1	0.7	1	1	1
12/01/2019 04:00	0.2	12.8	2,084.8	0.1	0.7	1	1	1
12/01/2019 05:00	0.2	12.8	2,085.9	0.1	0.7	1	1	1
12/01/2019 06:00	0.2	12.9	2,075.5	0.1	0.7	1	1	1
12/01/2019 07:00	0.2	12.9	2,086.7	0.1	0.7	1	1	1
12/01/2019 08:00	0.2	12.5	2,176.0	0.1	0.7	1	1	1
12/01/2019 09:00	0.2	12.4	2,172.8	0.1	0.7	1	1	1
12/01/2019 10:00	0.2	12.4	2,181.5	0.1	0.7	1	1	1
12/01/2019 11:00	0.2	12.5	2,161.9	0.1	0.7	1	1	1
12/01/2019 12:00	0.2	12.8	2,086.9	0.1	0.7	1	1	1
12/01/2019 13:00	0.2	12.7	2,110.4	0.1	0.7	1	1	1
12/01/2019 14:00	0.2	12.7	2,099.5	0.1	0.7	1	1	1
12/01/2019 15:00	0.2	12.7	2,105.9	0.1	0.7	1	1	1
12/01/2019 16:00	0.2	12.6	2,107.8	0.1	0.7	1	1	1
12/01/2019 17:00	0.2	12.4	2,161.9	0.1	0.7	1	1	1
12/01/2019 18:00	0.2	12.1	2,221.6	0.1	0.7	1	1	1
12/01/2019 19:00	0.1	12.0	2,253.5	0.1	0.3	1	1	1
12/01/2019 20:00	0.1	12.2	2,209.1	0.1	0.3	1	1	1
12/01/2019 21:00	0.1	12.5	2,133.9	0.1	0.3	1	1	1
12/01/2019 22:00	0.2	12.6	2,102.8	0.1	0.7	1	1	1
12/01/2019 23:00	0.2	12.7	2,095.2	0.1	0.7	1	1	1
Average/Sum#:	0.2	12.6	2,130.1	0.1	15.6 #	24 #	24 #	24 #
Minimum:	0.1	12.0	2,075.5	0.1	0.3	1	1	1
Maximum:	0.2	12.9	2,253.5	0.1	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/02/2019 00:00	0.2	12.7	2,078.7	0.1	0.7	1	1	1
12/02/2019 01:00	0.2	12.7	2,082.6	0.1	0.7	1	1	1
12/02/2019 02:00	0.2	12.7	2,081.3	0.1	0.7	1	1	1
12/02/2019 03:00	0.2	12.7	2,075.0	0.1	0.7	1	1	1
12/02/2019 04:00	0.2	12.8	2,069.7	0.1	0.7	1	1	1
12/02/2019 05:00	0.2	12.7	2,075.5	0.1	0.7	1	1	1
12/02/2019 06:00	0.2	12.2	2,196.2	0.1	0.7	1	1	1
12/02/2019 07:00	0.1	11.9	2,256.7	0.1	0.3	1	1	1
12/02/2019 08:00	0.1	12.5	2,120.8	0.1	0.3	1	1	1
12/02/2019 09:00	0.1	12.7	2,077.0	0.1	0.3	1	1	1
12/02/2019 10:00	0.2	12.6	2,099.2	0.1	0.7	1	1	1
12/02/2019 11:00	0.2	12.6	2,092.7	0.1	0.7	1	1	1
12/02/2019 12:00	0.1	12.3	2,162.8	0.1	0.3	1	1	1
12/02/2019 13:00	0.1	12.5	2,118.4	0.1	0.3	1	1	1
12/02/2019 14:00	0.1	12.2	2,174.2	0.1	0.3	1	1	1
12/02/2019 15:00	0.1	12.3	2,156.8	0.1	0.3	1	1	1
12/02/2019 16:00	0.1	12.0	2,213.4	0.1	0.3	1	1	1
12/02/2019 17:00	0.1	11.8	2,268.7	0.1	0.3	1	1	1
12/02/2019 18:00	0.0	11.8	2,278.2	0.1	0.0	1	1	1
12/02/2019 19:00	0.0	11.8	2,279.3	0.0	0.0	1	1	1
12/02/2019 20:00	0.0	11.8	2,275.2	0.0	0.0	1	1	1
12/02/2019 21:00	0.0	11.9	2,248.6	0.0	0.0	1	1	1
12/02/2019 22:00	0.1	12.3	2,148.0	0.0	0.3	1	1	1
12/02/2019 23:00	0.1	12.4	2,129.3	0.1	0.3	1	1	1
Average/Sum#:	0.1	12.3	2,156.6	0.1	9.6 #	24 #	24 #	24 #
Minimum:	0.0	11.8	2,069.7	0.0	0.0	1	1	1
Maximum:	0.2	12.8	2,279.3	0.1	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/03/2019 00:00	0.1	12.4	2,136.3	0.1	0.3	1	1	1
12/03/2019 01:00	0.1	12.6	2,082.1	0.1	0.3	1	1	1
12/03/2019 02:00	0.1	12.6	2,078.1	0.1	0.3	1	1	1
12/03/2019 03:00	0.1	12.6	2,086.0	0.1	0.3	1	1	1
12/03/2019 04:00	0.1	12.5	2,112.1	0.1	0.3	1	1	1
12/03/2019 05:00	0.1	12.3	2,121.5	0.1	0.3	1	1	1
12/03/2019 06:00	0.1	12.3	2,153.5	0.1	0.3	1	1	1
12/03/2019 07:00	0.0	12.0	2,204.2	0.1	0.0	1	1	1
12/03/2019 08:00	0.0	12.1	2,192.7	0.0	0.0	1	1	1
12/03/2019 09:00	0.1	12.2	2,162.7	0.0	0.3	1	1	1
12/03/2019 10:00	0.1	12.4	2,107.2	0.1	0.3	1	1	1
12/03/2019 11:00	0.0	12.0	2,184.4	0.1	0.0	1	1	1
12/03/2019 12:00	0.0	11.8	2,215.8	0.0	0.0	1	1	1
12/03/2019 13:00	0.0	11.8	2,208.4	0.0	0.0	1	1	1
12/03/2019 14:00	0.0	11.8	2,205.5	0.0	0.0	1	1	1
12/03/2019 15:00	0.0	11.9	2,199.8	0.0	0.0	1	1	1
12/03/2019 16:00	0.0	11.9	2,191.5	0.0	0.0	1	1	1
12/03/2019 17:00	0.1	11.7	2,253.4	0.0	0.3	1	1	1
12/03/2019 18:00	0.1	11.7	2,252.8	0.1	0.3	1	1	1
12/03/2019 19:00	0.1	11.8	2,237.0	0.1	0.3	1	1	1
12/03/2019 20:00	0.1	11.8	2,228.0	0.1	0.3	1	1	1
12/03/2019 21:00	0.1	11.9	2,219.8	0.1	0.3	1	1	1
12/03/2019 22:00	0.1	12.2	2,159.4	0.1	0.3	1	1	1
12/03/2019 23:00	0.1	12.3	2,136.5	0.1	0.3	1	1	1
Average/Sum#:	0.1	12.1	2,172.0	0.1	4.8 #	24 #	24 #	24 #
Minimum:	0.0	11.7	2,078.1	0.0	0.0	1	1	1
Maximum:	0.1	12.6	2,253.4	0.1	0.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/04/2019 00:00	0.1	12.1	2,184.8	0.1	0.3	1	1	1
12/04/2019 01:00	0.1	12.2	2,158.5	0.1	0.3	1	1	1
12/04/2019 02:00	0.1	12.5	2,102.9	0.1	0.3	1	1	1
12/04/2019 03:00	0.1	12.5	2,114.0	0.1	0.3	1	1	1
12/04/2019 04:00	0.1	12.2	2,154.6	0.1	0.3	1	1	1
12/04/2019 05:00	0.2	12.5	2,097.2	0.1	0.7	1	1	1
12/04/2019 06:00	0.2	12.3	2,152.1	0.1	0.7	1	1	1
12/04/2019 07:00	0.1	12.0	2,205.0	0.1	0.3	1	1	1
12/04/2019 08:00	0.1	12.1	2,197.1	0.1	0.3	1	1	1
12/04/2019 09:00	0.1	12.1	2,201.4	0.1	0.3	1	1	1
12/04/2019 10:00	0.1	12.1	2,184.8	0.1	0.3	1	1	1
12/04/2019 11:00	0.1	11.9	2,229.9	0.1	0.3	1	1	1
12/04/2019 12:00	0.1	12.1	2,194.3	0.1	0.3	1	1	1
12/04/2019 13:00	0.1	12.2	2,165.2	0.1	0.3	1	1	1
12/04/2019 14:00	0.1	11.8	2,236.0	0.1	0.3	1	1	1
12/04/2019 15:00	0.1	12.0	2,197.1	0.1	0.3	1	1	1
12/04/2019 16:00	0.1	12.0	2,197.1	0.1	0.3	1	1	1
12/04/2019 17:00	0.1	12.1	2,172.7	0.1	0.3	1	1	1
12/04/2019 18:00	0.1	11.8	2,240.9	0.1	0.3	1	1	1
12/04/2019 19:00	0.1	11.8	2,242.8	0.1	0.3	1	1	1
12/04/2019 20:00	0.0	11.8	2,246.9	0.1	0.0	1	1	1
12/04/2019 21:00	0.0	11.9	2,228.4	0.0	0.0	1	1	1
12/04/2019 22:00	0.1	12.1	2,194.5	0.0	0.3	1	1	1
12/04/2019 23:00	0.1	12.3	2,147.9	0.1	0.3	1	1	1
Average/Sum#:	0.1	12.1	2,185.3	0.1	7.4 #	24 #	24 #	24 #
Minimum:	0.0	11.8	2,097.2	0.0	0.0	1	1	1
Maximum:	0.2	12.5	2,246.9	0.1	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/05/2019 00:00	0.1	12.2	2,160.5	0.1	0.3	1	1	1
12/05/2019 01:00	0.1	12.2	2,166.9	0.1	0.3	1	1	1
12/05/2019 02:00	0.1	12.2	2,164.3	0.1	0.3	1	1	1
12/05/2019 03:00	0.1	12.2	2,165.9	0.1	0.3	1	1	1
12/05/2019 04:00	0.1	12.4	2,132.0	0.1	0.3	1	1	1
12/05/2019 05:00	0.2	12.4	2,119.2	0.1	0.7	1	1	1
12/05/2019 06:00	0.1	12.2	2,163.7	0.1	0.3	1	1	1
12/05/2019 07:00	0.1	12.4	2,122.3	0.1	0.3	1	1	1
12/05/2019 08:00	0.1	12.7	2,069.4	0.1	0.3	1	1	1
12/05/2019 09:00	0.1	12.6	2,084.4	0.1	0.3	1	1	1
12/05/2019 10:00	0.1	12.6	2,035.3	0.1	0.3	1	1	1
12/05/2019 11:00	0.1	12.6	2,041.6	0.1	0.3	1	1	1
12/05/2019 12:00	0.1	12.5	2,049.9	0.1	0.3	1	1	1
12/05/2019 13:00	0.1	12.5	2,049.7	0.1	0.3	1	1	1
12/05/2019 14:00	0.1	12.5	2,037.5	0.1	0.3	1	1	1
12/05/2019 15:00	0.1	12.5	2,046.8	0.1	0.3	1	1	1
12/05/2019 16:00	0.1	12.1	2,140.6	0.1	0.3	1	1	1
12/05/2019 17:00	0.0	11.8	2,195.4	0.1	0.0	1	1	1
12/05/2019 18:00	0.0	11.8	2,198.0	0.0	0.0	1	1	1
12/05/2019 19:00	0.0	11.7	2,206.3	0.0	0.0	1	1	1
12/05/2019 20:00	0.0	11.8	2,203.5	0.0	0.0	1	1	1
12/05/2019 21:00	0.0	11.7	2,206.0	0.0	0.0	1	1	1
12/05/2019 22:00	0.0	12.0	2,149.6	0.0	0.0	1	1	1
12/05/2019 23:00	0.1	12.1	2,129.0	0.0	0.3	1	1	1
Average/Sum#:	0.1	12.2	2,126.6	0.1	5.8 #	24 #	24 #	24 #
Minimum:	0.0	11.7	2,035.3	0.0	0.0	1	1	1
Maximum:	0.2	12.7	2,206.3	0.1	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/06/2019 00:00	0.1	12.4	2,065.7	0.1	0.3	1	1	1
12/06/2019 01:00	0.1	12.4	2,061.4	0.1	0.3	1	1	1
12/06/2019 02:00	0.1	12.4	2,067.5	0.1	0.3	1	1	1
12/06/2019 03:00	0.1	12.4	2,064.0	0.1	0.3	1	1	1
12/06/2019 04:00	0.1	12.5	2,041.1	0.1	0.3	1	1	1
12/06/2019 05:00	0.2	12.5	2,034.6	0.1	0.6	1	1	1
12/06/2019 06:00	0.2	12.4	2,068.3	0.1	0.6	1	1	1
12/06/2019 07:00	0.1	12.4	2,062.6	0.1	0.3	1	1	1
12/06/2019 08:00	0.1	12.5	2,049.6	0.1	0.3	1	1	1
12/06/2019 09:00	0.2	12.6	2,023.8	0.1	0.6	1	1	1
12/06/2019 10:00	0.2	12.5	2,044.0	0.1	0.6	1	1	1
12/06/2019 11:00	0.1	12.3	2,071.0	0.1	0.3	1	1	1
12/06/2019 12:00	0.1	12.1	2,105.6	0.1	0.3	1	1	1
12/06/2019 13:00	0.1	12.0	2,114.7	0.1	0.3	1	1	1
12/06/2019 14:00	0.1	12.1	2,110.9	0.1	0.3	1	1	1
12/06/2019 15:00	0.1	12.1	2,113.4	0.1	0.3	1	1	1
12/06/2019 16:00	0.1	12.0	2,138.4	0.1	0.3	1	1	1
12/06/2019 17:00	0.1	12.0	2,126.5	0.1	0.3	1	1	1
12/06/2019 18:00	0.1	11.8	2,171.2	0.1	0.3	1	1	1
12/06/2019 19:00	0.1	11.8	2,163.3	0.1	0.3	1	1	1
12/06/2019 20:00	0.1	12.0	2,142.1	0.1	0.3	1	1	1
12/06/2019 21:00	0.1	11.8	2,187.6	0.1	0.3	1	1	1
12/06/2019 22:00	0.1	11.8	2,187.8	0.1	0.3	1	1	1
12/06/2019 23:00	0.0	11.7	2,191.1	0.1	0.0	1	1	1
Average/Sum#:	0.1	12.2	2,100.3	0.1	8.1 #	24 #	24 #	24 #
Minimum:	0.0	11.7	2,023.8	0.1	0.0	1	1	1
Maximum:	0.2	12.6	2,191.1	0.1	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/07/2019 00:00	0.1	11.8	2,181.2	0.1	0.3	1	1	1
12/07/2019 01:00	0.1	12.3	2,068.1	0.1	0.3	1	1	1
12/07/2019 02:00	0.2	12.5	2,037.2	0.1	0.6	1	1	1
12/07/2019 03:00	0.2	12.5	2,041.6	0.1	0.6	1	1	1
12/07/2019 04:00	0.2	12.5	2,044.2	0.1	0.6	1	1	1
12/07/2019 05:00	0.2	12.4	2,038.5	0.1	0.6	1	1	1
12/07/2019 06:00	0.2	12.4	2,038.7	0.1	0.6	1	1	1
12/07/2019 07:00	0.1	12.3	2,073.5	0.1	0.3	1	1	1
12/07/2019 08:00	0.1	12.2	2,085.4	0.1	0.3	1	1	1
12/07/2019 09:00	0.1	12.2	2,071.6	0.1	0.3	1	1	1
12/07/2019 10:00	0.1	12.3	2,053.3	0.1	0.3	1	1	1
12/07/2019 11:00	0.1	12.2	2,063.3	0.1	0.3	1	1	1
12/07/2019 12:00	0.1	12.2	2,065.0	0.1	0.3	1	1	1
12/07/2019 13:00	0.1	12.3	2,059.5	0.1	0.3	1	1	1
12/07/2019 14:00	0.1	12.3	2,058.0	0.1	0.3	1	1	1
12/07/2019 15:00	0.1	12.4	2,041.5	0.1	0.3	1	1	1
12/07/2019 16:00	0.1	12.4	2,052.6	0.1	0.3	1	1	1
12/07/2019 17:00	0.1	12.4	2,051.1	0.1	0.3	1	1	1
12/07/2019 18:00	0.1	12.1	2,107.4	0.1	0.3	1	1	1
12/07/2019 19:00	0.1	12.2	2,084.4	0.1	0.3	1	1	1
12/07/2019 20:00	0.1	12.2	2,095.9	0.1	0.3	1	1	1
12/07/2019 21:00	0.1	12.2	2,092.9	0.1	0.3	1	1	1
12/07/2019 22:00	0.1	12.3	2,068.3	0.1	0.3	1	1	1
12/07/2019 23:00	0.1	12.3	2,065.9	0.1	0.3	1	1	1
Average/Sum#:	0.1	12.3	2,068.3	0.1	8.7 #	24 #	24 #	24 #
Minimum:	0.1	11.8	2,037.2	0.1	0.3	1	1	1
Maximum:	0.2	12.5	2,181.2	0.1	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/08/2019 00:00	0.1	12.3	2,081.2	0.1	0.3	1	1	1
12/08/2019 01:00	0.1	12.9	1,930.7	0.1	0.3	1	1	1
12/08/2019 02:00	0.0	13.9	1,595.4	0.1	0.0	1	1	0
12/08/2019 03:00	0.0	13.9	1,458.5	0.0	0.0	1	1	0
12/08/2019 04:00	0.0	13.9	1,596.1	0.0	0.0	1	1	0
12/08/2019 05:00	0.0	13.9	1,666.5	0.0	0.0	1	1	0
12/08/2019 06:00	0.0	13.9	1,677.6	0.0	0.0	1	1	0
12/08/2019 07:00	0.0	13.9	1,657.6	0.0	0.0	1	1	0
12/08/2019 08:00	0.0	13.9	1,637.2	0.0	0.0	1	1	0
12/08/2019 09:00	0.0	13.9	1,642.1	0.0	0.0	1	1	0
12/08/2019 10:00	0.0	13.9	1,495.8	0.0	0.0	1	1	0
12/08/2019 11:00	0.0	13.9	1,581.9	0.0	0.0	1	1	0
12/08/2019 12:00	0.0	13.9	1,503.5	0.0	0.0	1	1	0
12/08/2019 13:00	0.0	13.9	1,646.3	0.0	0.0	1	1	0
12/08/2019 14:00	0.0	13.7	1,658.3	0.0	0.0	1	1	1
12/08/2019 15:00	0.3	13.1	1,877.2	0.1	1.0	1	1	1
12/08/2019 16:00	0.4	12.5	2,043.8	0.2	1.3	1	1	1
12/08/2019 17:00	0.2	12.5	2,031.1	0.2	0.6	1	1	1
12/08/2019 18:00	0.2	12.4	2,080.7	0.2	0.6	1	1	1
12/08/2019 19:00	0.2	12.3	2,096.9	0.1	0.6	1	1	1
12/08/2019 20:00	0.1	12.3	2,102.2	0.1	0.3	1	1	1
12/08/2019 21:00	0.1	12.5	2,056.3	0.1	0.3	1	1	1
12/08/2019 22:00	0.1	12.3	2,097.5	0.1	0.3	1	1	1
12/08/2019 23:00	0.1	12.2	2,112.4	0.1	0.3	1	1	1
Average/Sum#:	0.1	13.2	1,805.3	0.1	5.9 #	24 #	24 #	12 #
Minimum:	0.0	12.2	1,458.5	0.0	0.0	1	1	0
Maximum:	0.4	13.9	2,112.4	0.2	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2019 00:00	0.1	12.4	2,082.3	0.1	0.3	1	1	1
12/09/2019 01:00	0.1	12.6	2,036.6	0.1	0.3	1	1	1
12/09/2019 02:00	0.1	12.7	2,016.3	0.1	0.3	1	1	1
12/09/2019 03:00	0.2	12.7	2,022.7	0.1	0.7	1	1	1
12/09/2019 04:00	0.1	12.5	2,071.9	0.1	0.3	1	1	1
12/09/2019 05:00	0.2	12.5	2,062.7	0.1	0.6	1	1	1
12/09/2019 06:00	0.2	12.5	2,067.6	0.1	0.7	1	1	1
12/09/2019 07:00	0.2	12.4	2,105.5	0.1	0.7	1	1	1
12/09/2019 08:00	0.2	12.4	2,097.8	0.1	0.7	1	1	1
12/09/2019 09:00	0.1	12.4	2,088.6	0.1	0.3	1	1	1
12/09/2019 10:00	0.1	12.6	2,035.9	0.1	0.3	1	1	1
12/09/2019 11:00	0.1	12.7	2,031.3	0.1	0.3	1	1	1
12/09/2019 12:00	0.1	12.6	2,026.3	0.1	0.3	1	1	1
12/09/2019 13:00	0.1	12.6	2,035.0	0.1	0.3	1	1	1
12/09/2019 14:00	0.1	12.6	2,015.9	0.1	0.3	1	1	1
12/09/2019 15:00	0.1	12.5	2,056.8	0.1	0.3	1	1	1
12/09/2019 16:00	0.1	12.5	2,047.2	0.1	0.3	1	1	1
12/09/2019 17:00	0.1	12.3	2,102.2	0.1	0.3	1	1	1
12/09/2019 18:00	0.1	12.0	2,168.2	0.1	0.3	1	1	1
12/09/2019 19:00	0.1	11.9	2,185.6	0.1	0.3	1	1	1
12/09/2019 20:00	0.1	12.0	2,184.6	0.1	0.3	1	1	1
12/09/2019 21:00	0.1	12.3	2,113.8	0.1	0.3	1	1	1
12/09/2019 22:00	0.1	12.3	2,106.2	0.1	0.3	1	1	1
12/09/2019 23:00	0.2	12.5	2,098.8	0.1	0.7	1	1	1
Average/Sum#:	0.1	12.4	2,077.5	0.1	9.5 #	24 #	24 #	24 #
Minimum:	0.1	11.9	2,015.9	0.1	0.3	1	1	1
Maximum:	0.2	12.7	2,185.6	0.1	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/10/2019 00:00	0.2	12.4	2,130.1	0.1	0.7	1	1	1
12/10/2019 01:00	0.2	12.4	2,122.5	0.1	0.7	1	1	1
12/10/2019 02:00	0.2	12.4	2,113.9	0.1	0.7	1	1	1
12/10/2019 03:00	0.2	12.4	2,126.8	0.1	0.7	1	1	1
12/10/2019 04:00	0.2	12.4	2,134.7	0.1	0.7	1	1	1
12/10/2019 05:00	0.2	12.4	2,118.1	0.1	0.7	1	1	1
12/10/2019 06:00	0.2	12.4	2,128.6	0.1	0.7	1	1	1
12/10/2019 07:00	0.2	12.3	2,151.0	0.1	0.7	1	1	1
12/10/2019 08:00	0.2	12.6	2,087.7	0.1	0.7	1	1	1
12/10/2019 09:00	0.2	12.4	2,119.3	0.1	0.7	1	1	1
12/10/2019 10:00	0.1	12.7	2,060.8	0.1	0.3	1	1	1
12/10/2019 11:00	0.2	12.7	2,050.2	0.1	0.7	1	1	1
12/10/2019 12:00	0.2	12.6	2,067.5	0.1	0.7	1	1	1
12/10/2019 13:00	0.2	12.6	2,064.1	0.1	0.7	1	1	1
12/10/2019 14:00	0.2	12.6	2,069.4	0.1	0.7	1	1	1
12/10/2019 15:00	0.2	12.6	2,053.7	0.1	0.7	1	1	1
12/10/2019 16:00	0.2	12.5	2,072.3	0.1	0.7	1	1	1
12/10/2019 17:00	0.1	12.2	2,149.5	0.1	0.3	1	1	1
12/10/2019 18:00	0.1	12.0	2,172.8	0.1	0.3	1	1	1
12/10/2019 19:00	0.1	12.0	2,182.4	0.1	0.3	1	1	1
12/10/2019 20:00	0.1	12.0	2,182.1	0.1	0.3	1	1	1
12/10/2019 21:00	0.1	12.2	2,136.5	0.1	0.3	1	1	1
12/10/2019 22:00	0.2	12.5	2,090.3	0.1	0.7	1	1	1
12/10/2019 23:00	0.2	12.5	2,080.4	0.1	0.7	1	1	1
Average/Sum#:	0.2	12.4	2,111.0	0.1	14.4 #	24 #	24 #	24 #
Minimum:	0.1	12.0	2,050.2	0.1	0.3	1	1	1
Maximum:	0.2	12.7	2,182.4	0.1	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/11/2019 00:00	0.1	12.3	2,113.6	0.1	0.3	1	1	1
12/11/2019 01:00	0.1	12.3	2,111.9	0.1	0.3	1	1	1
12/11/2019 02:00	0.2	12.5	2,080.4	0.1	0.7	1	1	1
12/11/2019 03:00	0.2	12.7	2,027.6	0.1	0.7	1	1	1
12/11/2019 04:00	0.2	12.6	2,053.1	0.1	0.7	1	1	1
12/11/2019 05:00	0.2	12.4	2,078.8	0.1	0.6	1	1	1
12/11/2019 06:00	0.2	12.3	2,119.9	0.1	0.7	1	1	1
12/11/2019 07:00	0.2	12.4	2,110.8	0.1	0.7	1	1	1
12/11/2019 08:00	0.1	12.5	2,075.9	0.1	0.3	1	1	1
12/11/2019 09:00	0.2	12.7	2,043.6	0.1	0.7	1	1	1
12/11/2019 10:00	0.2	12.6	2,057.8	0.1	0.7	1	1	1
12/11/2019 11:00	0.2	12.7	2,037.4	0.1	0.7	1	1	1
12/11/2019 12:00	0.2	12.7	2,039.8	0.1	0.7	1	1	1
12/11/2019 13:00	0.2	12.7	2,037.9	0.1	0.7	1	1	1
12/11/2019 14:00	0.2	12.5	2,069.3	0.1	0.7	1	1	1
12/11/2019 15:00	0.2	12.7	2,031.3	0.1	0.7	1	1	1
12/11/2019 16:00	0.2	12.6	2,049.9	0.1	0.7	1	1	1
12/11/2019 17:00	0.1	12.3	2,111.8	0.1	0.3	1	1	1
12/11/2019 18:00	0.2	12.4	2,084.0	0.1	0.6	1	1	1
12/11/2019 19:00	0.1	12.1	2,150.6	0.1	0.3	1	1	1
12/11/2019 20:00	0.1	12.4	2,090.0	0.1	0.3	1	1	1
12/11/2019 21:00	0.2	12.5	2,056.9	0.1	0.6	1	1	1
12/11/2019 22:00	0.2	12.6	2,043.4	0.1	0.7	1	1	1
12/11/2019 23:00	0.2	12.6	2,048.1	0.1	0.7	1	1	1
Average/Sum#:	0.2	12.5	2,071.8	0.1	14.1 #	24 #	24 #	24 #
Minimum:	0.1	12.1	2,027.6	0.1	0.3	1	1	1
Maximum:	0.2	12.7	2,150.6	0.1	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/12/2019 00:00	0.2	12.6	2,042.6	0.1	0.7	1	1	1
12/12/2019 01:00	0.2	12.6	2,032.2	0.1	0.6	1	1	1
12/12/2019 02:00	0.2	12.6	2,039.7	0.1	0.6	1	1	1
12/12/2019 03:00	0.2	12.6	2,039.7	0.1	0.6	1	1	1
12/12/2019 04:00	0.2	12.6	2,039.2	0.1	0.6	1	1	1
12/12/2019 05:00	0.2	12.6	2,041.5	0.1	0.6	1	1	1
12/12/2019 06:00	0.2	12.4	2,101.2	0.1	0.7	1	1	1
12/12/2019 07:00	0.1	12.2	2,127.0	0.1	0.3	1	1	1
12/12/2019 08:00	0.2	12.6	2,047.7	0.1	0.7	1	1	1
12/12/2019 09:00	0.2	12.6	2,041.3	0.1	0.6	1	1	1
12/12/2019 10:00	0.2	12.7	2,019.4	0.1	0.7	1	1	1
12/12/2019 11:00	0.2	12.7	2,015.2	0.1	0.6	1	1	1
12/12/2019 12:00	0.2	12.6	2,029.4	0.1	0.6	1	1	1
12/12/2019 13:00	0.2	12.6	2,034.4	0.1	0.6	1	1	1
12/12/2019 14:00	0.2	12.6	2,041.7	0.1	0.6	1	1	1
12/12/2019 15:00	0.2	12.6	2,040.1	0.1	0.6	1	1	1
12/12/2019 16:00	0.2	12.5	2,045.9	0.1	0.6	1	1	1
12/12/2019 17:00	0.1	12.3	2,102.5	0.1	0.3	1	1	1
12/12/2019 18:00	0.1	12.2	2,105.8	0.1	0.3	1	1	1
12/12/2019 19:00	0.1	12.3	2,097.8	0.1	0.3	1	1	1
12/12/2019 20:00	0.1	12.5	2,056.2	0.1	0.3	1	1	1
12/12/2019 21:00	0.1	12.5	2,061.2	0.1	0.3	1	1	1
12/12/2019 22:00	0.1	12.5	2,054.9	0.1	0.3	1	1	1
12/12/2019 23:00	0.0	13.3	1,815.7	0.1	0.0	1	1	1
Average/Sum#:	0.2	12.6	2,044.7	0.1	12.1 #	24 #	24 #	24 #
Minimum:	0.0	12.2	1,815.7	0.1	0.0	1	1	1
Maximum:	0.2	13.3	2,127.0	0.1	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/13/2019 00:00	3.6	14.3	1,253.4	0.0	7.7	1	1	0
12/13/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/13/2019 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/13/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/13/2019 04:00	17.1	17.4	488.8	0.0	17.3	1	1	0
12/13/2019 05:00	8.4	14.2	1,281.4	0.0	21.2	1	1	0
12/13/2019 06:00	0.0	13.9	1,389.3	0.0	0.0	1	1	0
12/13/2019 07:00	0.0	13.8	1,574.2	0.0	0.0	1	1	0
12/13/2019 08:00	0.0	13.8	1,672.8	0.0	0.0	1	1	0
12/13/2019 09:00	0.0	13.8	1,632.3	0.0	0.0	1	1	0
12/13/2019 10:00	0.0	13.9	1,682.6	0.0	0.0	1	1	0
12/13/2019 11:00	0.0	13.9	1,592.4	0.0	0.0	1	1	0
12/13/2019 12:00	0.0	13.9	1,489.3	0.0	0.0	1	1	0
12/13/2019 13:00	0.0	13.9	1,652.0	0.0	0.0	1	1	0
12/13/2019 14:00	0.0	13.8	1,731.7	0.0	0.0	1	1	1
12/13/2019 15:00	0.4	12.6	2,026.4	0.1	1.3	1	1	1
12/13/2019 16:00	0.4	12.3	2,079.6	0.2	1.3	1	1	1
12/13/2019 17:00	0.3	12.3	2,072.8	0.3	1.0	1	1	1
12/13/2019 18:00	0.3	12.0	2,151.0	0.2	1.0	1	1	1
12/13/2019 19:00	0.3	12.3	2,078.7	0.2	1.0	1	1	1
12/13/2019 20:00	0.3	12.2	2,110.5	0.2	1.0	1	1	1
12/13/2019 21:00	0.3	12.2	2,097.8	0.2	1.0	1	1	1
12/13/2019 22:00	0.3	12.2	2,094.1	0.2	1.0	1	1	1
12/13/2019 23:00	0.3	12.3	2,084.2	0.2	1.0	1	1	1
Average/Sum#:	1.5	13.4	1,725.5	0.1	55.8 #	21 #	24 #	10 #
Minimum:	0.0	12.0	488.8	0.0	0.0	0	1	0
Maximum:	17.1	17.4	2,151.0	0.3	21.2	1	1	1
%SI	12.50	12.50	12.50	33.33	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/14/2019 00:00	0.3	12.5	2,066.6	0.2	1.0	1	1	1
12/14/2019 01:00	0.2	12.8	1,966.5	0.2	0.6	1	1	1
12/14/2019 02:00	0.0	13.9	1,598.2	0.1	0.0	1	1	0
12/14/2019 03:00	0.0	13.9	1,553.5	0.0	0.0	1	1	0
12/14/2019 04:00	0.0	13.9	1,690.2	0.0	0.0	1	1	0
12/14/2019 05:00	0.0	13.9	1,624.9	0.0	0.0	1	1	0
12/14/2019 06:00	0.0	13.9	1,557.7	0.0	0.0	1	1	0
12/14/2019 07:00	0.0	13.9	1,482.7	0.0	0.0	1	1	0
12/14/2019 08:00	0.0	13.9	1,479.0	0.0	0.0	1	1	0
12/14/2019 09:00	0.0	13.9	1,637.4	0.0	0.0	1	1	0
12/14/2019 10:00	0.0	13.9	1,573.1	0.0	0.0	1	1	0
12/14/2019 11:00	0.0	13.9	1,601.7	0.0	0.0	1	1	0
12/14/2019 12:00	0.0	13.9	1,379.0	0.0	0.0	1	1	0
12/14/2019 13:00	0.0	13.9	1,645.5	0.0	0.0	1	1	0
12/14/2019 14:00	0.0	13.9	1,597.2	0.0	0.0	1	1	0
12/14/2019 15:00	0.0	13.8	1,604.1	0.0	0.0	1	1	1
12/14/2019 16:00	0.4	12.7	2,011.1	0.1	1.3	1	1	1
12/14/2019 17:00	0.4	12.3	2,091.2	0.2	1.3	1	1	1
12/14/2019 18:00	0.4	12.3	2,097.9	0.3	1.3	1	1	1
12/14/2019 19:00	0.3	12.5	2,063.6	0.3	1.0	1	1	1
12/14/2019 20:00	0.3	12.2	2,130.0	0.2	1.0	1	1	1
12/14/2019 21:00	0.3	12.3	2,129.7	0.2	1.0	1	1	1
12/14/2019 22:00	0.3	12.5	2,068.3	0.2	1.0	1	1	1
12/14/2019 23:00	0.3	13.1	1,936.1	0.2	1.0	1	1	1
Average/Sum#:	0.1	13.3	1,774.4	0.1	10.5 #	24 #	24 #	11 #
Minimum:	0.0	12.2	1,379.0	0.0	0.0	1	1	0
Maximum:	0.4	13.9	2,130.0	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2019 00:00	0.3	12.7	2,039.2	0.2	1.0	1	1	1
12/15/2019 01:00	0.3	12.8	2,026.0	0.2	1.0	1	1	1
12/15/2019 02:00	0.3	12.5	2,080.0	0.2	1.0	1	1	1
12/15/2019 03:00	0.4	12.4	2,104.8	0.2	1.3	1	1	1
12/15/2019 04:00	0.4	12.4	2,114.0	0.3	1.3	1	1	1
12/15/2019 05:00	0.4	12.6	2,069.8	0.3	1.3	1	1	1
12/15/2019 06:00	0.3	12.7	2,080.6	0.3	1.0	1	1	1
12/15/2019 07:00	0.3	13.1	1,950.0	0.2	1.0	1	1	1
12/15/2019 08:00	0.0	13.9	1,584.7	0.1	0.0	1	1	0
12/15/2019 09:00	0.0	13.9	1,634.3	0.1	0.0	1	1	0
12/15/2019 10:00	0.0	13.9	1,536.0	0.0	0.0	1	1	0
12/15/2019 11:00	0.0	13.9	1,561.6	0.0	0.0	1	1	0
12/15/2019 12:00	0.0	13.9	1,545.2	0.0	0.0	1	1	0
12/15/2019 13:00	0.0	13.9	1,636.2	0.0	0.0	1	1	0
12/15/2019 14:00	0.0	13.9	1,570.8	0.0	0.0	1	1	0
12/15/2019 15:00	0.0	13.9	1,566.1	0.0	0.0	1	1	1
12/15/2019 16:00	0.4	12.9	2,007.0	0.1	1.3	1	1	1
12/15/2019 17:00	0.4	12.6	2,073.0	0.2	1.3	1	1	1
12/15/2019 18:00	0.4	12.1	2,173.9	0.3	1.3	1	1	1
12/15/2019 19:00	0.3	11.9	2,217.2	0.3	1.0	1	1	1
12/15/2019 20:00	0.3	11.9	2,209.8	0.2	1.0	1	1	1
12/15/2019 21:00	0.3	12.0	2,203.1	0.2	1.0	1	1	1
12/15/2019 22:00	0.3	12.4	2,119.6	0.2	1.0	1	1	1
12/15/2019 23:00	0.3	12.5	2,090.4	0.2	1.0	1	1	1
Average/Sum#:	0.2	12.9	1,924.7	0.2	17.8 #	24 #	24 #	17 #
Minimum:	0.0	11.9	1,536.0	0.0	0.0	1	1	0
Maximum:	0.4	13.9	2,217.2	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/16/2019 00:00	0.3	12.4	2,135.2	0.2	1.0	1	1	1
12/16/2019 01:00	0.3	12.4	2,136.2	0.2	1.0	1	1	1
12/16/2019 02:00	0.3	12.5	2,127.9	0.2	1.0	1	1	1
12/16/2019 03:00	0.3	12.4	2,144.8	0.2	1.0	1	1	1
12/16/2019 04:00	0.3	12.4	2,139.4	0.2	1.0	1	1	1
12/16/2019 05:00	0.4	12.4	2,115.9	0.2	1.3	1	1	1
12/16/2019 06:00	0.3	12.0	2,240.1	0.2	1.0	1	1	1
12/16/2019 07:00	0.3	12.2	2,185.3	0.2	1.0	1	1	1
12/16/2019 08:00	0.2	12.9	2,026.4	0.2	0.7	1	1	1
12/16/2019 09:00	0.2	12.9	2,023.1	0.1	0.7	1	1	1
12/16/2019 10:00	0.3	12.8	2,046.1	0.1	1.0	1	1	1
12/16/2019 11:00	0.2	12.8	2,036.8	0.1	0.7	1	1	1
12/16/2019 12:00	0.2	12.7	2,037.0	0.1	0.7	1	1	1
12/16/2019 13:00	0.2	12.7	2,041.3	0.1	0.7	1	1	1
12/16/2019 14:00	0.3	12.6	2,051.4	0.1	1.0	1	1	1
12/16/2019 15:00	0.3	12.5	2,073.5	0.2	1.0	1	1	1
12/16/2019 16:00	0.3	12.4	2,101.0	0.2	1.0	1	1	1
12/16/2019 17:00	0.3	12.1	2,175.8	0.2	1.0	1	1	1
12/16/2019 18:00	0.3	12.0	2,196.3	0.2	1.0	1	1	1
12/16/2019 19:00	0.3	11.9	2,220.4	0.2	1.0	1	1	1
12/16/2019 20:00	0.3	12.0	2,221.2	0.2	1.0	1	1	1
12/16/2019 21:00	0.3	12.0	2,214.3	0.2	1.0	1	1	1
12/16/2019 22:00	0.3	12.3	2,168.0	0.2	1.0	1	1	1
12/16/2019 23:00	0.3	12.6	2,105.4	0.2	1.0	1	1	1
Average/Sum#:	0.3	12.4	2,123.5	0.2	22.8 #	24 #	24 #	24 #
Minimum:	0.2	11.9	2,023.1	0.1	0.7	1	1	1
Maximum:	0.4	12.9	2,240.1	0.2	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/17/2019 00:00	0.3	12.5	2,120.4	0.2	1.0	1	1	1
12/17/2019 01:00	0.3	12.5	2,138.6	0.2	1.0	1	1	1
12/17/2019 02:00	0.3	12.5	2,135.3	0.2	1.0	1	1	1
12/17/2019 03:00	0.3	12.5	2,138.8	0.2	1.0	1	1	1
12/17/2019 04:00	0.3	12.7	2,109.4	0.2	1.0	1	1	1
12/17/2019 05:00	0.4	12.6	2,093.4	0.2	1.3	1	1	1
12/17/2019 06:00	0.4	12.4	2,170.6	0.3	1.3	1	1	1
12/17/2019 07:00	0.4	12.4	2,159.3	0.3	1.3	1	1	1
12/17/2019 08:00	0.3	12.6	2,109.3	0.3	1.0	1	1	1
12/17/2019 09:00	0.2	12.8	2,050.0	0.2	0.7	1	1	1
12/17/2019 10:00	0.2	12.9	2,031.3	0.1	0.7	1	1	1
12/17/2019 11:00	0.3	12.8	2,033.8	0.1	1.0	1	1	1
12/17/2019 12:00	0.3	12.8	2,043.2	0.2	1.0	1	1	1
12/17/2019 13:00	0.3	12.7	2,055.8	0.2	1.0	1	1	1
12/17/2019 14:00	0.3	12.5	2,085.7	0.2	1.0	1	1	1
12/17/2019 15:00	0.3	12.4	2,108.8	0.2	1.0	1	1	1
12/17/2019 16:00	0.3	12.2	2,149.3	0.2	1.0	1	1	1
12/17/2019 17:00	0.3	12.0	2,201.8	0.2	1.0	1	1	1
12/17/2019 18:00	0.3	11.8	2,256.6	0.2	1.0	1	1	1
12/17/2019 19:00	0.3	11.7	2,259.4	0.2	1.0	1	1	1
12/17/2019 20:00	0.3	11.9	2,229.3	0.2	1.0	1	1	1
12/17/2019 21:00	0.3	12.0	2,200.9	0.2	1.0	1	1	1
12/17/2019 22:00	0.3	12.0	2,195.1	0.2	1.0	1	1	1
12/17/2019 23:00	0.3	12.5	2,103.1	0.2	1.0	1	1	1
Average/Sum#:	0.3	12.4	2,132.5	0.2	24.3 #	24 #	24 #	24 #
Minimum:	0.2	11.7	2,031.3	0.1	0.7	1	1	1
Maximum:	0.4	12.9	2,259.4	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/18/2019 00:00	0.3	12.6	2,089.0	0.2	1.0	1	1	1
12/18/2019 01:00	0.3	12.4	2,115.3	0.2	1.0	1	1	1
12/18/2019 02:00	0.3	12.4	2,114.3	0.2	1.0	1	1	1
12/18/2019 03:00	0.3	12.4	2,122.6	0.2	1.0	1	1	1
12/18/2019 04:00	0.3	12.3	2,129.6	0.2	1.0	1	1	1
12/18/2019 05:00	0.4	12.0	2,172.0	0.2	1.3	1	1	1
12/18/2019 06:00	0.4	11.9	2,235.6	0.3	1.3	1	1	1
12/18/2019 07:00	0.3	12.1	2,195.4	0.3	1.0	1	1	1
12/18/2019 08:00	0.3	12.4	2,141.4	0.2	1.0	1	1	1
12/18/2019 09:00	0.3	12.4	2,125.4	0.2	1.0	1	1	1
12/18/2019 10:00	0.3	12.5	2,117.8	0.2	1.0	1	1	1
12/18/2019 11:00	0.3	12.4	2,135.0	0.2	1.0	1	1	1
12/18/2019 12:00	0.3	12.5	2,110.5	0.2	1.0	1	1	1
12/18/2019 13:00	0.3	12.5	2,109.7	0.2	1.0	1	1	1
12/18/2019 14:00	0.3	12.5	2,098.3	0.2	1.0	1	1	1
12/18/2019 15:00	0.3	12.7	2,072.9	0.2	1.0	1	1	1
12/18/2019 16:00	0.4	12.4	2,130.6	0.2	1.3	1	1	1
12/18/2019 17:00	0.3	12.1	2,193.1	0.2	1.0	1	1	1
12/18/2019 18:00	0.3	12.0	2,207.0	0.2	1.0	1	1	1
12/18/2019 19:00	0.3	12.1	2,204.7	0.2	1.0	1	1	1
12/18/2019 20:00	0.3	12.1	2,199.0	0.2	1.0	1	1	1
12/18/2019 21:00	0.3	12.0	2,202.2	0.2	1.0	1	1	1
12/18/2019 22:00	0.3	12.1	2,194.6	0.2	1.0	1	1	1
12/18/2019 23:00	0.3	12.5	2,101.3	0.2	1.0	1	1	1
Average/Sum#:	0.3	12.3	2,146.6	0.2	24.9 #	24 #	24 #	24 #
Minimum:	0.3	11.9	2,072.9	0.2	1.0	1	1	1
Maximum:	0.4	12.7	2,235.6	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2019 00:00	0.3	12.4	2,116.4	0.2	1.0	1	1	1
12/19/2019 01:00	0.3	12.4	2,119.2	0.2	1.0	1	1	1
12/19/2019 02:00	0.3	12.4	2,112.3	0.2	1.0	1	1	1
12/19/2019 03:00	0.3	12.5	2,100.6	0.2	1.0	1	1	1
12/19/2019 04:00	0.3	12.4	2,115.1	0.2	1.0	1	1	1
12/19/2019 05:00	0.4	12.3	2,108.2	0.2	1.3	1	1	1
12/19/2019 06:00	0.4	12.0	2,210.4	0.3	1.3	1	1	1
12/19/2019 07:00	0.3	12.1	2,166.6	0.3	1.0	1	1	1
12/19/2019 08:00	0.2	12.7	2,040.7	0.2	0.7	1	1	1
12/19/2019 09:00	0.3	12.6	2,069.9	0.2	1.0	1	1	1
12/19/2019 10:00	0.3	12.8	2,036.9	0.2	1.0	1	1	1
12/19/2019 11:00	0.3	12.8	2,042.3	0.2	1.0	1	1	1
12/19/2019 12:00	0.3	12.7	2,037.8	0.2	1.0	1	1	1
12/19/2019 13:00	0.3	12.7	2,040.2	0.2	1.0	1	1	1
12/19/2019 14:00	0.3	12.7	2,026.1	0.2	1.0	1	1	1
12/19/2019 15:00	0.3	12.5	2,081.3	0.2	1.0	1	1	1
12/19/2019 16:00	0.3	12.4	2,101.2	0.2	1.0	1	1	1
12/19/2019 17:00	0.3	12.1	2,157.6	0.2	1.0	1	1	1
12/19/2019 18:00	0.3	11.9	2,200.2	0.2	1.0	1	1	1
12/19/2019 19:00	0.3	12.1	2,161.4	0.2	1.0	1	1	1
12/19/2019 20:00	0.3	12.1	2,167.1	0.2	1.0	1	1	1
12/19/2019 21:00	0.3	12.1	2,169.9	0.2	1.0	1	1	1
12/19/2019 22:00	0.3	12.4	2,109.8	0.2	1.0	1	1	1
12/19/2019 23:00	0.3	12.5	2,095.3	0.2	1.0	1	1	1
Average/Sum#:	0.3	12.4	2,107.8	0.2	24.3 #	24 #	24 #	24 #
Minimum:	0.2	11.9	2,026.1	0.2	0.7	1	1	1
Maximum:	0.4	12.8	2,210.4	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/20/2019 00:00	0.3	12.4	2,115.2	0.2	1.0	1	1	1
12/20/2019 01:00	0.3	12.5	2,098.7	0.2	1.0	1	1	1
12/20/2019 02:00	0.4	12.4	2,103.9	0.2	1.3	1	1	1
12/20/2019 03:00	0.3	12.8	2,040.2	0.2	1.0	1	1	1
12/20/2019 04:00	0.4	12.5	2,088.3	0.3	1.3	1	1	1
12/20/2019 05:00	0.4	12.4	2,097.8	0.3	1.3	1	1	1
12/20/2019 06:00	0.4	12.3	2,128.5	0.3	1.3	1	1	1
12/20/2019 07:00	0.3	12.6	2,070.4	0.3	1.0	1	1	1
12/20/2019 08:00	0.3	12.8	2,026.6	0.2	1.0	1	1	1
12/20/2019 09:00	0.3	12.7	2,046.5	0.2	1.0	1	1	1
12/20/2019 10:00	0.3	13.0	1,944.5	0.2	1.0	1	1	1
12/20/2019 11:00	0.0	13.9	1,641.5	0.1	0.0	1	1	0
12/20/2019 12:00	0.0	13.9	1,590.6	0.1	0.0	1	1	0
12/20/2019 13:00	0.0	13.9	1,650.3	0.0	0.0	1	1	0
12/20/2019 14:00	0.0	13.9	1,564.3	0.0	0.0	1	1	1
12/20/2019 15:00	0.5	12.6	2,047.0	0.1	1.6	1	1	1
12/20/2019 16:00	0.4	12.4	2,093.1	0.2	1.3	1	1	1
12/20/2019 17:00	0.4	12.1	2,151.4	0.3	1.3	1	1	1
12/20/2019 18:00	0.4	12.0	2,184.9	0.3	1.3	1	1	1
12/20/2019 19:00	0.4	12.2	2,137.8	0.3	1.3	1	1	1
12/20/2019 20:00	0.4	12.3	2,133.7	0.3	1.3	1	1	1
12/20/2019 21:00	0.3	12.3	2,131.5	0.3	1.0	1	1	1
12/20/2019 22:00	0.4	12.2	2,136.7	0.3	1.3	1	1	1
12/20/2019 23:00	0.4	12.3	2,127.4	0.3	1.3	1	1	1
Average/Sum#:	0.3	12.7	2,014.6	0.2	23.9 #	24 #	24 #	21 #
Minimum:	0.0	12.0	1,564.3	0.0	0.0	1	1	0
Maximum:	0.5	13.9	2,184.9	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2019 00:00	0.3	12.5	2,087.4	0.3	1.0	1	1	1
12/21/2019 01:00	0.3	12.6	2,066.4	0.2	1.0	1	1	1
12/21/2019 02:00	0.4	12.4	2,103.2	0.2	1.3	1	1	1
12/21/2019 03:00	0.4	12.4	2,105.0	0.3	1.3	1	1	1
12/21/2019 04:00	0.4	12.3	2,113.5	0.3	1.3	1	1	1
12/21/2019 05:00	0.4	12.3	2,121.1	0.3	1.3	1	1	1
12/21/2019 06:00	0.4	12.5	2,091.9	0.3	1.3	1	1	1
12/21/2019 07:00	0.4	12.3	2,129.1	0.3	1.3	1	1	1
12/21/2019 08:00	0.4	12.3	2,117.0	0.3	1.3	1	1	1
12/21/2019 09:00	0.4	12.4	2,105.9	0.3	1.3	1	1	1
12/21/2019 10:00	0.4	12.5	2,077.8	0.3	1.3	1	1	1
12/21/2019 11:00	0.3	12.7	2,037.5	0.3	1.0	1	1	1
12/21/2019 12:00	0.3	12.7	2,036.8	0.2	1.0	1	1	1
12/21/2019 13:00	0.4	12.6	2,045.5	0.2	1.3	1	1	1
12/21/2019 14:00	0.4	12.5	2,070.8	0.3	1.3	1	1	1
12/21/2019 15:00	0.4	12.6	2,060.7	0.3	1.3	1	1	1
12/21/2019 16:00	0.4	12.6	2,045.4	0.3	1.3	1	1	1
12/21/2019 17:00	0.4	12.6	2,049.1	0.3	1.3	1	1	1
12/21/2019 18:00	0.4	12.5	2,060.8	0.3	1.3	1	1	1
12/21/2019 19:00	0.4	12.5	2,071.6	0.3	1.3	1	1	1
12/21/2019 20:00	0.4	12.4	2,090.7	0.3	1.3	1	1	1
12/21/2019 21:00	0.4	12.4	2,080.2	0.3	1.3	1	1	1
12/21/2019 22:00	0.4	12.3	2,113.6	0.3	1.3	1	1	1
12/21/2019 23:00	0.4	12.3	2,112.7	0.3	1.3	1	1	1
Average/Sum#:	0.4	12.5	2,083.1	0.3	30.0 #	24 #	24 #	24 #
Minimum:	0.3	12.3	2,036.8	0.2	1.0	1	1	1
Maximum:	0.4	12.7	2,129.1	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/22/2019 00:00	0.4	12.4	2,103.5	0.3	1.3	1	1	1
12/22/2019 01:00	0.4	12.5	2,067.8	0.3	1.3	1	1	1
12/22/2019 02:00	0.4	12.2	2,123.5	0.3	1.3	1	1	1
12/22/2019 03:00	0.4	12.2	2,124.1	0.3	1.3	1	1	1
12/22/2019 04:00	0.4	12.3	2,089.4	0.3	1.3	1	1	1
12/22/2019 05:00	0.5	12.3	2,081.2	0.3	1.6	1	1	1
12/22/2019 06:00	0.4	12.2	2,119.4	0.3	1.3	1	1	1
12/22/2019 07:00	0.4	12.1	2,129.2	0.3	1.3	1	1	1
12/22/2019 08:00	0.4	12.2	2,103.1	0.3	1.3	1	1	1
12/22/2019 09:00	0.4	12.3	2,098.2	0.3	1.3	1	1	1
12/22/2019 10:00	0.4	12.3	2,090.0	0.3	1.3	1	1	1
12/22/2019 11:00	0.4	12.4	2,063.2	0.3	1.3	1	1	1
12/22/2019 12:00	0.2	12.4	2,057.0	0.2	0.6	1	1	1
12/22/2019 13:00	0.2	12.3	2,088.6	0.2	0.6	1	1	1
12/22/2019 14:00	0.2	12.3	2,065.3	0.1	0.6	1	1	1
12/22/2019 15:00	0.2	12.4	2,059.7	0.1	0.6	1	1	1
12/22/2019 16:00	0.2	12.6	2,016.6	0.1	0.6	1	1	1
12/22/2019 17:00	0.2	12.6	2,020.9	0.1	0.6	1	1	1
12/22/2019 18:00	0.2	12.5	2,035.5	0.1	0.6	1	1	1
12/22/2019 19:00	0.2	12.6	2,039.0	0.1	0.6	1	1	1
12/22/2019 20:00	0.2	12.5	2,066.6	0.1	0.6	1	1	1
12/22/2019 21:00	0.2	12.5	2,071.8	0.1	0.7	1	1	1
12/22/2019 22:00	0.2	12.7	2,039.8	0.1	0.7	1	1	1
12/22/2019 23:00	0.2	12.6	2,050.7	0.1	0.7	1	1	1
Average/Sum#:	0.3	12.4	2,075.2	0.2	23.4 #	24 #	24 #	24 #
Minimum:	0.2	12.1	2,016.6	0.1	0.6	1	1	1
Maximum:	0.5	12.7	2,129.2	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/23/2019 00:00	0.2	12.6	2,056.1	0.1	0.7	1	1	1
12/23/2019 01:00	0.2	12.7	2,034.1	0.1	0.7	1	1	1
12/23/2019 02:00	0.2	12.7	2,036.2	0.1	0.7	1	1	1
12/23/2019 03:00	0.2	12.6	2,058.3	0.1	0.7	1	1	1
12/23/2019 04:00	0.2	12.6	2,048.0	0.1	0.7	1	1	1
12/23/2019 05:00	0.2	12.7	2,038.4	0.1	0.7	1	1	1
12/23/2019 06:00	0.2	12.7	2,050.3	0.1	0.7	1	1	1
12/23/2019 07:00	0.2	12.7	2,052.9	0.1	0.7	1	1	1
12/23/2019 08:00	0.1	12.0	2,196.3	0.1	0.3	1	1	1
12/23/2019 09:00	0.1	12.3	2,115.8	0.1	0.3	1	1	1
12/23/2019 10:00	0.1	12.3	2,111.4	0.1	0.3	1	1	1
12/23/2019 11:00	0.1	12.2	2,120.2	0.1	0.3	1	1	1
12/23/2019 12:00	0.1	12.2	2,121.4	0.1	0.3	1	1	1
12/23/2019 13:00	0.1	12.4	2,062.9	0.1	0.3	1	1	1
12/23/2019 14:00	0.1	12.3	2,094.8	0.1	0.3	1	1	1
12/23/2019 15:00	0.1	12.4	2,065.5	0.1	0.3	1	1	1
12/23/2019 16:00	0.1	12.5	2,052.6	0.1	0.3	1	1	1
12/23/2019 17:00	0.1	12.6	2,045.0	0.1	0.3	1	1	1
12/23/2019 18:00	0.1	12.5	2,047.0	0.1	0.3	1	1	1
12/23/2019 19:00	0.1	12.4	2,069.6	0.1	0.3	1	1	1
12/23/2019 20:00	0.1	12.2	2,125.9	0.1	0.3	1	1	1
12/23/2019 21:00	0.1	12.3	2,105.3	0.1	0.3	1	1	1
12/23/2019 22:00	0.1	12.3	2,099.8	0.1	0.3	1	1	1
12/23/2019 23:00	0.2	12.5	2,105.4	0.1	0.7	1	1	1
Average/Sum#:	0.1	12.4	2,079.7	0.1	10.8 #	24 #	24 #	24 #
Minimum:	0.1	12.0	2,034.1	0.1	0.3	1	1	1
Maximum:	0.2	12.7	2,196.3	0.1	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/24/2019 00:00	0.2	12.5	2,097.0	0.1	0.7	1	1	1
12/24/2019 01:00	0.2	12.7	2,050.2	0.1	0.7	1	1	1
12/24/2019 02:00	0.2	12.8	2,049.9	0.1	0.7	1	1	1
12/24/2019 03:00	0.2	12.8	2,049.2	0.1	0.7	1	1	1
12/24/2019 04:00	0.2	12.7	2,046.8	0.1	0.7	1	1	1
12/24/2019 05:00	0.2	12.7	2,047.6	0.1	0.7	1	1	1
12/24/2019 06:00	0.3	12.6	2,076.5	0.1	1.0	1	1	1
12/24/2019 07:00	0.2	12.8	2,057.9	0.1	0.7	1	1	1
12/24/2019 08:00	0.2	12.8	2,036.7	0.1	0.7	1	1	1
12/24/2019 09:00	0.2	12.8	2,035.9	0.1	0.7	1	1	1
12/24/2019 10:00	0.2	12.8	2,041.2	0.1	0.7	1	1	1
12/24/2019 11:00	0.2	12.7	2,041.8	0.1	0.7	1	1	1
12/24/2019 12:00	0.2	12.6	2,059.2	0.1	0.7	1	1	1
12/24/2019 13:00	0.2	12.7	2,038.5	0.1	0.7	1	1	1
12/24/2019 14:00	0.2	12.7	2,041.1	0.1	0.7	1	1	1
12/24/2019 15:00	0.2	12.5	2,081.4	0.1	0.7	1	1	1
12/24/2019 16:00	0.2	12.7	2,034.5	0.1	0.7	1	1	1
12/24/2019 17:00	0.2	12.6	2,058.5	0.1	0.7	1	1	1
12/24/2019 18:00	0.2	12.7	2,053.2	0.1	0.7	1	1	1
12/24/2019 19:00	0.2	12.7	2,039.5	0.1	0.7	1	1	1
12/24/2019 20:00	0.2	12.7	2,041.6	0.1	0.7	1	1	1
12/24/2019 21:00	0.2	12.7	2,040.0	0.1	0.7	1	1	1
12/24/2019 22:00	0.2	12.6	2,052.7	0.1	0.7	1	1	1
12/24/2019 23:00	0.2	12.7	2,034.4	0.1	0.7	1	1	1
Average/Sum#:	0.2	12.7	2,050.2	0.1	17.1 #	24 #	24 #	24 #
Minimum:	0.2	12.5	2,034.4	0.1	0.7	1	1	1
Maximum:	0.3	12.8	2,097.0	0.1	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/25/2019 00:00	0.2	12.6	2,062.4	0.1	0.7	1	1	1
12/25/2019 01:00	0.2	12.5	2,079.8	0.1	0.7	1	1	1
12/25/2019 02:00	0.2	12.4	2,122.8	0.1	0.7	1	1	1
12/25/2019 03:00	0.2	12.7	2,041.5	0.1	0.7	1	1	1
12/25/2019 04:00	0.2	12.6	2,056.3	0.1	0.7	1	1	1
12/25/2019 05:00	0.2	12.7	2,038.1	0.1	0.7	1	1	1
12/25/2019 06:00	0.3	12.7	2,050.3	0.1	1.0	1	1	1
12/25/2019 07:00	0.2	12.4	2,108.2	0.1	0.7	1	1	1
12/25/2019 08:00	0.2	12.8	2,025.0	0.1	0.7	1	1	1
12/25/2019 09:00	0.2	12.7	2,043.2	0.1	0.7	1	1	1
12/25/2019 10:00	0.2	12.7	2,041.5	0.1	0.7	1	1	1
12/25/2019 11:00	0.2	12.7	2,038.8	0.1	0.7	1	1	1
12/25/2019 12:00	0.2	12.7	2,047.3	0.1	0.7	1	1	1
12/25/2019 13:00	0.2	12.7	2,041.3	0.1	0.7	1	1	1
12/25/2019 14:00	0.2	12.6	2,068.3	0.1	0.7	1	1	1
12/25/2019 15:00	0.2	12.6	2,071.3	0.1	0.7	1	1	1
12/25/2019 16:00	0.2	12.5	2,081.3	0.1	0.7	1	1	1
12/25/2019 17:00	0.2	12.7	2,051.3	0.1	0.7	1	1	1
12/25/2019 18:00	0.2	12.6	2,067.9	0.1	0.7	1	1	1
12/25/2019 19:00	0.2	12.5	2,101.0	0.1	0.7	1	1	1
12/25/2019 20:00	0.2	12.5	2,094.6	0.1	0.7	1	1	1
12/25/2019 21:00	0.2	12.6	2,074.7	0.1	0.7	1	1	1
12/25/2019 22:00	0.2	12.6	2,061.4	0.1	0.7	1	1	1
12/25/2019 23:00	0.2	12.5	2,079.1	0.1	0.7	1	1	1
Average/Sum#:	0.2	12.6	2,064.5	0.1	17.1 #	24 #	24 #	24 #
Minimum:	0.2	12.4	2,025.0	0.1	0.7	1	1	1
Maximum:	0.3	12.8	2,122.8	0.1	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/26/2019 00:00	0.2	12.6	2,064.4	0.1	0.7	1	1	1
12/26/2019 01:00	0.2	12.4	2,113.7	0.1	0.7	1	1	1
12/26/2019 02:00	0.1	12.0	2,187.0	0.1	0.3	1	1	1
12/26/2019 03:00	0.1	12.0	2,188.2	0.1	0.3	1	1	1
12/26/2019 04:00	0.1	12.0	2,203.1	0.1	0.3	1	1	1
12/26/2019 05:00	0.2	12.6	2,094.2	0.1	0.7	1	1	1
12/26/2019 06:00	0.2	12.7	2,038.3	0.1	0.7	1	1	1
12/26/2019 07:00	0.2	12.5	2,092.4	0.1	0.7	1	1	1
12/26/2019 08:00	0.1	12.1	2,180.4	0.1	0.3	1	1	1
12/26/2019 09:00	0.1	12.3	2,111.9	0.1	0.3	1	1	1
12/26/2019 10:00	0.1	12.3	2,116.4	0.1	0.3	1	1	1
12/26/2019 11:00	0.1	12.5	2,070.1	0.1	0.3	1	1	1
12/26/2019 12:00	0.1	12.5	2,750.0	0.1	0.4	1	1	1
12/26/2019 13:00	0.1	12.4	2,824.5	0.1	0.4	1	1	1
12/26/2019 14:00	0.1	12.5	2,821.1	0.1	0.4	1	1	1
12/26/2019 15:00	0.1	12.4	2,825.4	0.1	0.4	1	1	1
12/26/2019 16:00	0.1	12.2	2,831.9	0.1	0.4	1	1	1
12/26/2019 17:00	0.1	12.2	2,837.3	0.1	0.4	1	1	1
12/26/2019 18:00	0.1	12.0	2,839.8	0.1	0.4	1	1	1
12/26/2019 19:00	0.1	12.0	2,839.1	0.1	0.4	1	1	1
12/26/2019 20:00	0.1	12.0	2,839.4	0.1	0.4	1	1	1
12/26/2019 21:00	0.1	12.2	2,847.7	0.1	0.4	1	1	1
12/26/2019 22:00	0.1	12.3	2,850.5	0.1	0.4	1	1	1
12/26/2019 23:00	0.1	12.3	2,852.8	0.1	0.4	1	1	1
Average/Sum#:	0.1	12.3	2,475.8	0.1	10.4 #	24 #	24 #	24 #
Minimum:	0.1	12.0	2,038.3	0.1	0.3	1	1	1
Maximum:	0.2	12.7	2,852.8	0.1	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/27/2019 00:00	0.1	12.3	2,848.7	0.1	0.4	1	1	1
12/27/2019 01:00	0.1	12.4	2,855.4	0.1	0.4	1	1	1
12/27/2019 02:00	0.1	12.3	2,855.8	0.1	0.4	1	1	1
12/27/2019 03:00	0.1	12.5	2,868.0	0.1	0.5	1	1	1
12/27/2019 04:00	0.1	12.7	2,879.8	0.1	0.5	1	1	1
12/27/2019 05:00	0.1	12.7	2,890.6	0.1	0.5	1	1	1
12/27/2019 06:00	0.1	12.8	2,885.3	0.1	0.5	1	1	1
12/27/2019 07:00	0.1	12.7	2,890.9	0.1	0.5	1	1	1
12/27/2019 08:00	0.1	13.1	2,775.9	0.0	0.5	1	1	1
12/27/2019 09:00	0.1	13.9	1,683.3	0.0	0.3	1	1	0
12/27/2019 10:00	0.1	13.9	1,668.1	0.0	0.3	1	1	0
12/27/2019 11:00	0.1	13.9	1,628.7	0.0	0.3	1	1	0
12/27/2019 12:00	0.1	13.9	1,624.5	0.0	0.3	1	1	0
12/27/2019 13:00	0.0	13.9	1,675.5	0.0	0.0	1	1	0
12/27/2019 14:00	0.0	13.9	1,647.4	0.0	0.0	1	1	0
12/27/2019 15:00	0.0	14.0	1,409.3	0.0	0.0	1	1	0
12/27/2019 16:00	0.0	13.9	1,616.8	0.0	0.0	1	1	0
12/27/2019 17:00	0.1	13.9	1,719.9	0.0	0.3	1	1	1
12/27/2019 18:00	0.2	12.9	2,841.1	0.0	0.9	1	1	1
12/27/2019 19:00	0.2	12.4	2,838.8	0.0	0.9	1	1	1
12/27/2019 20:00	0.2	12.2	2,841.5	0.0	0.9	1	1	1
12/27/2019 21:00	0.2	12.3	2,842.3	0.0	0.9	1	1	1
12/27/2019 22:00	0.1	12.3	2,844.9	0.0	0.4	1	1	1
12/27/2019 23:00	0.1	12.6	2,863.2	0.0	0.5	1	1	1
Average/Sum#:	0.1	12.6	2,395.7	0.1	3.7 #	24 #	24 #	16 #
Minimum:	0.0	12.3	1,409.3	0.1	0.4	1	1	0
Maximum:	0.2	12.8	2,890.9	0.1	0.5	1	1	1
%SI	0.00	66.67	0.00	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/28/2019 00:00	0.1	12.9	2,868.8	0.0	0.5	1	1	1
12/28/2019 01:00	0.1	12.8	2,865.2	0.0	0.5	1	1	1
12/28/2019 02:00	0.1	12.7	2,848.9	0.0	0.5	1	1	1
12/28/2019 03:00	0.1	12.8	2,850.4	0.0	0.5	1	1	1
12/28/2019 04:00	0.1	12.9	2,893.9	0.0	0.5	1	1	1
12/28/2019 05:00	0.1	12.8	2,876.3	0.0	0.5	1	1	1
12/28/2019 06:00	0.1	12.8	2,866.5	0.0	0.5	1	1	1
12/28/2019 07:00	0.1	12.6	2,871.4	0.0	0.5	1	1	1
12/28/2019 08:00	0.1	13.0	2,818.7	0.0	0.5	1	1	1
12/28/2019 09:00	0.1	13.9	1,668.5	0.0	0.3	1	1	0
12/28/2019 10:00	0.1	13.9	1,610.3	0.0	0.3	1	1	0
12/28/2019 11:00	0.1	13.9	1,650.0	0.0	0.3	1	1	0
12/28/2019 12:00	0.1	13.9	1,683.3	0.0	0.3	1	1	0
12/28/2019 13:00	0.0	13.9	1,637.1	0.0	0.0	1	1	0
12/28/2019 14:00	0.0	13.9	1,667.1	0.0	0.0	1	1	0
12/28/2019 15:00	0.0	13.9	1,632.0	0.0	0.0	1	1	1
12/28/2019 16:00	0.3	12.7	2,831.4	0.0	1.4	1	1	1
12/28/2019 17:00	0.3	12.3	2,839.1	0.0	1.3	1	1	1
12/28/2019 18:00	0.3	12.2	2,222.4	0.0	1.0	1	1	1
12/28/2019 19:00	0.3	12.2	2,128.4	0.0	1.0	1	1	1
12/28/2019 20:00	0.4	12.3	2,125.3	0.0	1.3	1	1	1
12/28/2019 21:00	0.3	12.4	2,095.7	0.0	1.0	1	1	1
12/28/2019 22:00	0.2	12.4	2,100.7	0.0	0.7	1	1	1
12/28/2019 23:00	0.2	12.4	2,108.9	0.0	0.7	1	1	1
Average/Sum#:	0.2	0.0	2,323.3	0.0	0.0 #	24 #	24 #	18 #
Minimum:	0.0	0.0	1,610.3	0.0	0.0	1	1	0
Maximum:	0.4	0.0	2,893.9	0.0	0.0	1	1	1
%SI	0.00	100.00	0.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/29/2019 00:00	0.2	12.5	2,095.4	0.0	0.7	1	1	1
12/29/2019 01:00	0.2	12.4	2,121.5	0.0	0.7	1	1	1
12/29/2019 02:00	0.2	12.5	2,088.4	0.0	0.7	1	1	1
12/29/2019 03:00	0.3	12.4	2,111.0	0.0	1.0	1	1	1
12/29/2019 04:00	0.2	12.5	2,092.8	0.0	0.7	1	1	1
12/29/2019 05:00	0.3	12.4	2,098.5	0.0	1.0	1	1	1
12/29/2019 06:00	0.3	12.5	2,091.3	0.0	1.0	1	1	1
12/29/2019 07:00	0.2	12.6	2,020.6	0.0	0.6	1	1	1
12/29/2019 08:00	0.0	13.8	1,672.1	0.1	0.0	1	1	0
12/29/2019 09:00	0.0	13.8	1,601.9	0.0	0.0	1	1	0
12/29/2019 10:00	0.0	13.8	1,676.5	0.0	0.0	1	1	0
12/29/2019 11:00	0.0	13.8	1,653.0	0.0	0.0	1	1	0
12/29/2019 12:00	0.0	13.8	1,688.5	0.0	0.0	1	1	0
12/29/2019 13:00	0.0	13.8	1,617.0	0.0	0.0	1	1	0
12/29/2019 14:00	0.0	13.8	1,671.1	0.0	0.0	1	1	0
12/29/2019 15:00	0.2	13.3	1,873.5	0.1	0.7	1	1	1
12/29/2019 16:00	0.3	12.6	2,055.4	0.1	1.0	1	1	1
12/29/2019 17:00	0.2	12.5	2,078.5	0.2	0.7	1	1	1
12/29/2019 18:00	0.2	12.3	2,124.3	0.1	0.7	1	1	1
12/29/2019 19:00	0.2	12.3	2,126.9	0.1	0.7	1	1	1
12/29/2019 20:00	0.2	12.3	2,126.8	0.1	0.7	1	1	1
12/29/2019 21:00	0.2	12.3	2,125.5	0.1	0.7	1	1	1
12/29/2019 22:00	0.2	12.4	2,119.0	0.1	0.7	1	1	1
12/29/2019 23:00	0.2	12.5	2,089.7	0.1	0.7	1	1	1
Average/Sum#:	0.2	13.0	1,959.1	0.1	8.2 #	24 #	24 #	17 #
Minimum:	0.0	12.3	1,601.9	0.0	0.0	1	1	0
Maximum:	0.3	13.8	2,126.9	0.2	1.0	1	1	1
%SI	0.00	25.00	0.00	33.33	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/30/2019 00:00	0.2	12.6	2,069.2	0.1	0.7	1	1	1
12/30/2019 01:00	0.2	12.6	2,060.7	0.1	0.7	1	1	1
12/30/2019 02:00	0.2	12.7	2,038.8	0.1	0.7	1	1	1
12/30/2019 03:00	0.2	12.7	2,043.5	0.1	0.7	1	1	1
12/30/2019 04:00	0.2	12.8	2,037.3	0.1	0.7	1	1	1
12/30/2019 05:00	0.2	12.7	2,048.0	0.1	0.7	1	1	1
12/30/2019 06:00	0.2	12.6	2,062.6	0.1	0.7	1	1	1
12/30/2019 07:00	0.2	12.4	2,120.4	0.1	0.7	1	1	1
12/30/2019 08:00	0.2	12.5	2,098.6	0.1	0.7	1	1	1
12/30/2019 09:00	0.1	12.5	2,057.7	0.1	0.3	1	1	1
12/30/2019 10:00	0.1	12.6	2,037.4	0.1	0.3	1	1	1
12/30/2019 11:00	0.1	12.5	2,052.2	0.1	0.3	1	1	1
12/30/2019 12:00	0.1	12.4	2,053.1	0.1	0.3	1	1	1
12/30/2019 13:00	0.1	12.3	2,076.0	0.1	0.3	1	1	1
12/30/2019 14:00	0.0	12.4	2,061.5	0.1	0.0	1	1	1
12/30/2019 15:00	0.0	12.4	2,068.2	0.0	0.0	1	1	1
12/30/2019 16:00	0.1	12.3	2,076.3	0.0	0.3	1	1	1
12/30/2019 17:00	0.1	12.3	2,093.1	0.1	0.3	1	1	1
12/30/2019 18:00	0.1	12.2	2,125.5	0.1	0.3	1	1	1
12/30/2019 19:00	0.1	12.2	2,120.6	0.1	0.3	1	1	1
12/30/2019 20:00	0.1	12.4	2,100.9	0.1	0.3	1	1	1
12/30/2019 21:00	0.1	12.5	2,072.3	0.1	0.3	1	1	1
12/30/2019 22:00	0.1	12.4	2,100.2	0.1	0.3	1	1	1
12/30/2019 23:00	0.1	12.5	2,071.5	0.1	0.3	1	1	1
Average/Sum#:	0.1	12.5	2,072.7	0.1	10.2 #	24 #	24 #	24 #
Minimum:	0.0	12.2	2,037.3	0.0	0.0	1	1	1
Maximum:	0.2	12.8	2,125.5	0.1	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/31/2019 00:00	0.1	12.6	2,044.4	0.1	0.3	1	1	1
12/31/2019 01:00	0.1	13.1	1,930.7	0.1	0.3	1	1	1
12/31/2019 02:00	0.1	13.1	1,927.7	0.1	0.3	1	1	1
12/31/2019 03:00	0.1	13.1	1,941.4	0.1	0.3	1	1	1
12/31/2019 04:00	0.1	12.6	2,042.1	0.1	0.3	1	1	1
12/31/2019 05:00	0.1	12.6	2,037.0	0.1	0.3	1	1	1
12/31/2019 06:00	0.1	12.7	2,030.6	0.1	0.3	1	1	1
12/31/2019 07:00	0.1	12.6	2,030.0	0.1	0.3	1	1	1
12/31/2019 08:00	0.1	13.2	1,890.6	0.1	0.3	1	1	1
12/31/2019 09:00	0.0	13.9	1,513.2	0.1	0.0	1	1	0
12/31/2019 10:00	0.0	13.9	1,612.7	0.0	0.0	1	1	0
12/31/2019 11:00	0.0	13.9	1,580.2	0.0	0.0	1	1	0
12/31/2019 12:00	0.0	13.9	1,563.3	0.0	0.0	1	1	0
12/31/2019 13:00	0.0	13.9	1,664.2	0.0	0.0	1	1	0
12/31/2019 14:00	0.0	13.9	1,566.0	0.0	0.0	1	1	0
12/31/2019 15:00	0.0	13.9	1,579.9	0.0	0.0	1	1	1
12/31/2019 16:00	0.3	12.8	1,996.1	0.1	1.0	1	1	1
12/31/2019 17:00	0.3	12.6	2,036.1	0.1	1.0	1	1	1
12/31/2019 18:00	0.3	12.7	2,032.6	0.2	1.0	1	1	1
12/31/2019 19:00	0.3	12.7	2,040.7	0.2	1.0	1	1	1
12/31/2019 20:00	0.3	12.6	2,040.9	0.2	1.0	1	1	1
12/31/2019 21:00	0.4	12.6	2,042.0	0.2	1.3	1	1	1
12/31/2019 22:00	0.4	12.6	2,043.4	0.3	1.3	1	1	1
12/31/2019 23:00	0.4	12.7	2,042.1	0.3	1.3	1	1	1
Average/Sum#:	0.2	13.1	1,884.5	0.1	11.6 #	24 #	24 #	18 #
Minimum:	0.0	12.6	1,513.2	0.0	0.0	1	1	0
Maximum:	0.4	13.9	2,044.4	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2019 00:00	0.0	13.9	1,390.2	0.0	0.0	1	1	0
10/01/2019 01:00	0.0	13.9	1,359.0	0.0	0.0	1	1	0
10/01/2019 02:00	0.0	13.9	1,351.1	0.0	0.0	1	1	0
10/01/2019 03:00	0.0	13.9	1,395.1	0.0	0.0	1	1	0
10/01/2019 04:00	0.0	13.9	1,651.9	0.0	0.0	1	1	0
10/01/2019 05:00	0.0	13.9	1,512.6	0.0	0.0	1	1	0
10/01/2019 06:00	0.0	13.9	1,631.9	0.0	0.0	1	1	0
10/01/2019 07:00	0.0	13.9	1,627.8	0.0	0.0	1	1	0
10/01/2019 08:00	0.0	13.9	1,639.7	0.0	0.0	1	1	0
10/01/2019 09:00	0.0	13.9	1,622.6	0.0	0.0	1	1	0
10/01/2019 10:00	0.0	13.9	1,602.7	0.0	0.0	1	1	0
10/01/2019 11:00	0.0	13.9	1,608.4	0.0	0.0	1	1	0
10/01/2019 12:00	0.0	14.0	1,593.9	0.0	0.0	1	1	0
10/01/2019 13:00	0.0	14.0	1,596.7	0.0	0.0	1	1	0
10/01/2019 14:00	0.0	13.9	1,568.6	0.0	0.0	1	1	0
10/01/2019 15:00	0.0	13.9	1,583.1	0.0	0.0	1	1	1
10/01/2019 16:00	0.2	12.7	1,966.8	0.0	0.6	1	1	1
10/01/2019 17:00	0.2	12.4	2,014.1	0.1	0.6	1	1	1
10/01/2019 18:00	0.2	12.3	2,048.1	0.1	0.6	1	1	1
10/01/2019 19:00	0.1	12.2	2,077.7	0.1	0.3	1	1	1
10/01/2019 20:00	0.1	12.2	2,078.1	0.1	0.3	1	1	1
10/01/2019 21:00	0.1	12.3	2,067.4	0.1	0.3	1	1	1
10/01/2019 22:00	0.1	12.4	2,045.5	0.1	0.3	1	1	1
10/01/2019 23:00	0.2	12.4	2,044.8	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.4	1,711.6	0.0	3.6 #	24 #	24 #	9 #
Minimum:	0.0	12.2	1,351.1	0.0	0.0	1	1	0
Maximum:	0.2	14.0	2,078.1	0.1	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/02/2019 00:00	0.0	12.4	2,058.7	0.1	0.0	1	1	1
10/02/2019 01:00	0.0	12.4	2,043.5	0.0	0.0	1	1	1
10/02/2019 02:00	0.0	12.4	2,029.4	0.0	0.0	1	1	1
10/02/2019 03:00	0.0	12.4	2,026.5	0.0	0.0	1	1	1
10/02/2019 04:00	0.0	12.6	1,987.0	0.0	0.0	1	1	1
10/02/2019 05:00	0.0	12.5	2,014.2	0.0	0.0	1	1	1
10/02/2019 06:00	0.0	12.7	2,015.5	0.0	0.0	1	1	1
10/02/2019 07:00	0.0	12.8	1,931.6	0.0	0.0	1	1	1
10/02/2019 08:00	0.0	13.9	1,569.5	0.0	0.0	1	1	0
10/02/2019 09:00	0.0	14.0	1,259.5	0.0	0.0	1	1	0
10/02/2019 10:00	0.0	14.0	1,270.2	0.0	0.0	1	1	0
10/02/2019 11:00	0.0	14.0	1,292.9	0.0	0.0	1	1	0
10/02/2019 12:00	0.0	14.0	1,269.8	0.0	0.0	1	1	0
10/02/2019 13:00	0.0	14.0	1,287.7	0.0	0.0	1	1	0
10/02/2019 14:00	0.0	13.9	1,543.8	0.0	0.0	1	1	1
10/02/2019 15:00	0.2	12.6	1,958.6	0.0	0.6	1	1	1
10/02/2019 16:00	0.2	12.2	2,036.8	0.1	0.6	1	1	1
10/02/2019 17:00	0.1	12.2	2,058.1	0.1	0.3	1	1	1
10/02/2019 18:00	0.1	12.2	2,052.5	0.1	0.3	1	1	1
10/02/2019 19:00	0.1	12.2	2,067.5	0.1	0.3	1	1	1
10/02/2019 20:00	0.1	12.1	2,080.9	0.1	0.3	1	1	1
10/02/2019 21:00	0.1	12.2	2,058.1	0.1	0.3	1	1	1
10/02/2019 22:00	0.2	12.4	2,031.3	0.1	0.6	1	1	1
10/02/2019 23:00	0.1	12.6	1,999.5	0.1	0.3	1	1	1
Average/Sum#:	0.1	12.9	1,831.0	0.0	3.6 #	24 #	24 #	18 #
Minimum:	0.0	12.1	1,259.5	0.0	0.0	1	1	0
Maximum:	0.2	14.0	2,080.9	0.1	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/03/2019 00:00	0.0	12.6	1,979.6	0.1	0.0	1	1	1
10/03/2019 01:00	0.0	12.8	1,922.0	0.0	0.0	1	1	1
10/03/2019 02:00	0.0	12.7	1,968.2	0.0	0.0	1	1	1
10/03/2019 03:00	0.0	12.5	1,999.6	0.0	0.0	1	1	1
10/03/2019 04:00	0.0	12.5	2,016.1	0.0	0.0	1	1	1
10/03/2019 05:00	0.0	12.5	2,008.7	0.0	0.0	1	1	1
10/03/2019 06:00	0.0	12.5	2,026.3	0.0	0.0	1	1	1
10/03/2019 07:00	0.0	12.7	1,937.3	0.0	0.0	1	1	1
10/03/2019 08:00	0.0	13.9	1,454.5	0.0	0.0	1	1	0
10/03/2019 09:00	0.0	14.0	1,262.8	0.0	0.0	1	1	0
10/03/2019 10:00	0.0	14.0	1,252.7	0.0	0.0	1	1	0
10/03/2019 11:00	0.0	14.0	1,256.7	0.0	0.0	1	1	0
10/03/2019 12:00	0.0	13.9	1,315.4	0.0	0.0	1	1	0
10/03/2019 13:00	0.0	14.0	1,300.1	0.0	0.0	1	1	0
10/03/2019 14:00	0.0	13.9	1,352.0	0.0	0.0	1	1	0
10/03/2019 15:00	0.0	13.9	1,363.7	0.0	0.0	1	1	0
10/03/2019 16:00	0.0	13.8	1,603.8	0.0	0.0	1	1	0
10/03/2019 17:00	0.0	13.8	1,591.3	0.0	0.0	1	1	0
10/03/2019 18:00	0.0	13.8	1,592.5	0.0	0.0	1	1	0
10/03/2019 19:00	0.0	13.8	1,619.0	0.0	0.0	1	1	0
10/03/2019 20:00	0.0	13.9	1,599.1	0.0	0.0	1	1	0
10/03/2019 21:00	3.4	14.4	1,273.9	0.0	6.6	1	0	0
10/03/2019 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2019 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.2	13.5	1,622.5	0.0	6.6 #	22 #	21 #	8 #
Minimum:	0.0	12.5	1,252.7	0.0	0.0	0	0	0
Maximum:	3.4	14.4	2,026.3	0.1	6.6	1	1	1
%SI	8.33	8.33	8.33	12.50	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2019 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2019 02:00	10.8	18.4	360.7	0.0	5.6	1	0	0
10/04/2019 03:00	18.9	14.9	1,019.4	0.0	42.4	1	0	0
10/04/2019 04:00	0.0	14.0	1,384.4	0.0	0.0	1	1	0
10/04/2019 05:00	0.2	12.7	1,977.3	0.0	0.6	1	1	1
10/04/2019 06:00	0.2	12.5	1,978.9	0.1	0.6	1	1	1
10/04/2019 07:00	0.0	14.0	1,369.0	0.1	0.0	1	1	0
10/04/2019 08:00	0.0	14.0	1,353.8	0.0	0.0	1	1	0
10/04/2019 09:00	0.0	14.0	1,357.9	0.0	0.0	1	1	0
10/04/2019 10:00	0.0	14.0	1,360.9	0.0	0.0	1	1	0
10/04/2019 11:00	0.0	14.0	1,364.2	0.0	0.0	1	1	0
10/04/2019 12:00	0.0	14.0	1,369.6	0.0	0.0	1	1	0
10/04/2019 13:00	0.0	13.9	1,547.6	0.0	0.0	1	1	0
10/04/2019 14:00	0.0	14.0	1,445.1	0.0	0.0	1	1	0
10/04/2019 15:00	0.0	14.0	1,421.5	0.0	0.0	1	1	0
10/04/2019 16:00	0.0	13.9	1,510.6	0.0	0.0	1	1	1
10/04/2019 17:00	0.2	12.7	1,964.0	0.0	0.6	1	1	1
10/04/2019 18:00	0.1	12.1	2,096.4	0.1	0.3	1	1	1
10/04/2019 19:00	0.1	12.2	2,081.7	0.1	0.3	1	1	1
10/04/2019 20:00	0.1	12.2	2,091.6	0.1	0.3	1	1	1
10/04/2019 21:00	0.1	12.2	2,080.6	0.1	0.3	1	1	1
10/04/2019 22:00	0.1	12.3	2,059.8	0.1	0.3	1	1	1
10/04/2019 23:00	0.1	12.4	2,047.0	0.1	0.3	1	1	1
Average/Sum#:	1.4	13.6	1,601.9	0.0	51.6 #	22 #	20 #	10 #
Minimum:	0.0	12.1	360.7	0.0	0.0	0	0	0
Maximum:	18.9	18.4	2,096.4	0.1	42.4	1	1	1
%SI	8.33	8.33	8.33	25.00	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/05/2019 00:00	0.2	12.5	2,014.0	0.1	0.6	1	1	1
10/05/2019 01:00	0.2	12.6	1,994.8	0.1	0.6	1	1	1
10/05/2019 02:00	0.2	12.8	1,959.8	0.1	0.6	1	1	1
10/05/2019 03:00	0.2	12.5	2,028.9	0.1	0.6	1	1	1
10/05/2019 04:00	0.1	12.4	2,055.4	0.1	0.3	1	1	1
10/05/2019 05:00	0.1	12.3	2,077.2	0.1	0.3	1	1	1
10/05/2019 06:00	0.2	12.7	2,023.9	0.1	0.7	1	1	1
10/05/2019 07:00	0.2	12.9	1,933.7	0.1	0.6	1	1	1
10/05/2019 08:00	0.0	13.9	1,502.2	0.1	0.0	1	1	0
10/05/2019 09:00	0.0	14.0	1,256.6	0.0	0.0	1	1	0
10/05/2019 10:00	0.0	14.0	1,252.2	0.0	0.0	1	1	0
10/05/2019 11:00	0.0	14.0	1,264.7	0.0	0.0	1	1	0
10/05/2019 12:00	0.0	14.0	1,307.4	0.0	0.0	1	1	0
10/05/2019 13:00	0.0	14.0	1,259.3	0.0	0.0	1	1	0
10/05/2019 14:00	0.0	14.0	1,436.6	0.0	0.0	1	1	0
10/05/2019 15:00	0.0	13.8	1,488.5	0.0	0.0	1	1	1
10/05/2019 16:00	0.2	12.7	1,932.3	0.0	0.6	1	1	1
10/05/2019 17:00	0.2	12.4	2,004.4	0.1	0.6	1	1	1
10/05/2019 18:00	0.2	12.4	2,010.9	0.1	0.6	1	1	1
10/05/2019 19:00	0.2	12.3	2,024.8	0.1	0.6	1	1	1
10/05/2019 20:00	0.1	12.2	2,056.6	0.1	0.3	1	1	1
10/05/2019 21:00	0.1	12.1	2,060.1	0.1	0.3	1	1	1
10/05/2019 22:00	0.1	12.3	2,033.8	0.1	0.3	1	1	1
10/05/2019 23:00	0.1	12.3	2,040.2	0.1	0.3	1	1	1
Average/Sum#:	0.1	13.0	1,792.4	0.1	7.9 #	24 #	24 #	17 #
Minimum:	0.0	12.1	1,252.2	0.0	0.0	1	1	0
Maximum:	0.2	14.0	2,077.2	0.1	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/06/2019 00:00	0.1	12.3	2,022.8	0.1	0.3	1	1	1
10/06/2019 01:00	0.2	12.5	1,975.5	0.1	0.6	1	1	1
10/06/2019 02:00	0.2	12.6	1,977.6	0.1	0.6	1	1	1
10/06/2019 03:00	0.2	12.6	1,977.6	0.1	0.6	1	1	1
10/06/2019 04:00	0.2	12.5	2,002.9	0.1	0.6	1	1	1
10/06/2019 05:00	0.2	12.4	2,025.8	0.1	0.6	1	1	1
10/06/2019 06:00	0.1	12.8	1,951.8	0.1	0.3	1	1	1
10/06/2019 07:00	0.0	13.9	1,483.6	0.1	0.0	1	1	0
10/06/2019 08:00	0.0	14.0	1,321.9	0.0	0.0	1	1	0
10/06/2019 09:00	0.0	14.0	1,244.4	0.0	0.0	1	1	0
10/06/2019 10:00	0.0	14.0	1,300.4	0.0	0.0	1	1	0
10/06/2019 11:00	0.0	14.0	1,330.7	0.0	0.0	1	1	0
10/06/2019 12:00	0.0	14.0	1,364.0	0.0	0.0	1	1	0
10/06/2019 13:00	0.0	14.0	1,336.8	0.0	0.0	1	1	0
10/06/2019 14:00	0.0	13.8	1,557.6	0.0	0.0	1	1	1
10/06/2019 15:00	0.2	12.5	1,964.7	0.0	0.6	1	1	1
10/06/2019 16:00	0.1	12.2	2,025.1	0.1	0.3	1	1	1
10/06/2019 17:00	0.0	11.9	2,079.9	0.1	0.0	1	1	1
10/06/2019 18:00	0.0	11.9	2,101.9	0.0	0.0	1	1	1
10/06/2019 19:00	0.1	12.1	2,058.6	0.0	0.3	1	1	1
10/06/2019 20:00	0.1	12.2	2,047.0	0.1	0.3	1	1	1
10/06/2019 21:00	0.1	12.2	2,050.0	0.1	0.3	1	1	1
10/06/2019 22:00	0.1	12.4	2,020.4	0.1	0.3	1	1	1
10/06/2019 23:00	0.2	12.5	2,008.7	0.1	0.6	1	1	1
Average/Sum#:	0.1	12.9	1,801.2	0.1	6.3 #	24 #	24 #	17 #
Minimum:	0.0	11.9	1,244.4	0.0	0.0	1	1	0
Maximum:	0.2	14.0	2,101.9	0.1	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/07/2019 00:00	0.1	12.5	2,003.3	0.1	0.3	1	1	1
10/07/2019 01:00	0.1	12.4	2,020.7	0.1	0.3	1	1	1
10/07/2019 02:00	0.2	12.5	1,996.3	0.1	0.6	1	1	1
10/07/2019 03:00	0.2	12.5	2,017.0	0.1	0.6	1	1	1
10/07/2019 04:00	0.1	12.3	2,050.8	0.1	0.3	1	1	1
10/07/2019 05:00	0.1	12.3	2,040.1	0.1	0.3	1	1	1
10/07/2019 06:00	0.1	12.4	2,047.8	0.1	0.3	1	1	1
10/07/2019 07:00	0.1	12.4	2,029.3	0.1	0.3	1	1	1
10/07/2019 08:00	0.2	12.4	2,012.6	0.1	0.6	1	1	1
10/07/2019 09:00	0.1	12.3	2,018.7	0.1	0.3	1	1	1
10/07/2019 10:00	0.1	12.4	1,996.9	0.1	0.3	1	1	1
10/07/2019 11:00	0.1	12.4	1,980.8	0.1	0.3	1	1	1
10/07/2019 12:00	0.1	12.4	1,979.0	0.1	0.3	1	1	1
10/07/2019 13:00	0.1	12.3	1,997.0	0.1	0.3	1	1	1
10/07/2019 14:00	0.1	12.3	1,996.5	0.1	0.3	1	1	1
10/07/2019 15:00	0.1	12.2	1,991.1	0.1	0.3	1	1	1
10/07/2019 16:00	0.1	12.1	2,036.4	0.1	0.3	1	1	1
10/07/2019 17:00	0.0	11.9	2,072.5	0.1	0.0	1	1	1
10/07/2019 18:00	0.0	11.9	2,075.6	0.0	0.0	1	1	1
10/07/2019 19:00	0.1	12.1	2,039.3	0.0	0.3	1	1	1
10/07/2019 20:00	0.1	12.1	2,032.6	0.1	0.3	1	1	1
10/07/2019 21:00	0.1	12.4	2,000.8	0.1	0.3	1	1	1
10/07/2019 22:00	0.1	12.3	2,016.9	0.1	0.3	1	1	1
10/07/2019 23:00	0.1	12.6	1,964.6	0.1	0.3	1	1	1
Average/Sum#:	0.1	12.3	2,017.4	0.1	7.5 #	24 #	24 #	24 #
Minimum:	0.0	11.9	1,964.6	0.0	0.0	1	1	1
Maximum:	0.2	12.6	2,075.6	0.1	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/08/2019 00:00	0.2	12.8	1,916.7	0.1	0.6	1	1	1
10/08/2019 01:00	0.1	13.0	1,858.8	0.1	0.3	1	1	1
10/08/2019 02:00	0.2	13.1	1,863.2	0.1	0.6	1	1	1
10/08/2019 03:00	0.2	12.8	1,912.2	0.1	0.6	1	1	1
10/08/2019 04:00	0.2	12.7	1,926.8	0.1	0.6	1	1	1
10/08/2019 05:00	0.1	12.4	2,008.4	0.1	0.3	1	1	1
10/08/2019 06:00	0.2	12.4	2,022.8	0.1	0.6	1	1	1
10/08/2019 07:00	0.1	12.5	1,994.1	0.1	0.3	1	1	1
10/08/2019 08:00	0.1	12.5	1,993.5	0.1	0.3	1	1	1
10/08/2019 09:00	0.1	12.4	1,996.6	0.1	0.3	1	1	1
10/08/2019 10:00	0.1	12.3	2,002.3	0.1	0.3	1	1	1
10/08/2019 11:00	0.1	12.2	2,012.4	0.1	0.3	1	1	1
10/08/2019 12:00	0.1	12.1	2,033.0	0.1	0.3	1	1	1
10/08/2019 13:00	0.1	12.3	1,991.7	0.1	0.3	1	1	1
10/08/2019 14:00	0.1	12.4	1,966.3	0.1	0.3	1	1	1
10/08/2019 15:00	0.1	12.2	1,987.9	0.1	0.3	1	1	1
10/08/2019 16:00	0.1	12.1	2,024.2	0.1	0.3	1	1	1
10/08/2019 17:00	0.0	11.9	2,058.1	0.1	0.0	1	1	1
10/08/2019 18:00	0.0	12.0	2,046.4	0.0	0.0	1	1	1
10/08/2019 19:00	0.0	12.1	2,038.9	0.0	0.0	1	1	1
10/08/2019 20:00	0.0	12.1	2,038.2	0.0	0.0	1	1	1
10/08/2019 21:00	0.0	12.2	2,010.8	0.0	0.0	1	1	1
10/08/2019 22:00	0.0	12.5	1,931.7	0.0	0.0	1	1	1
10/08/2019 23:00	0.0	12.4	1,955.8	0.0	0.0	1	1	1
Average/Sum#:	0.1	12.4	1,983.0	0.1	6.6 #	24 #	24 #	24 #
Minimum:	0.0	11.9	1,858.8	0.0	0.0	1	1	1
Maximum:	0.2	13.1	2,058.1	0.1	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/09/2019 00:00	0.0	12.4	1,965.3	0.0	0.0	1	1	1
10/09/2019 01:00	0.0	12.8	1,892.0	0.0	0.0	1	1	1
10/09/2019 02:00	0.0	12.7	1,915.9	0.0	0.0	1	1	1
10/09/2019 03:00	0.0	12.5	1,973.2	0.0	0.0	1	1	1
10/09/2019 04:00	0.0	12.4	1,998.5	0.0	0.0	1	1	1
10/09/2019 05:00	0.0	12.4	1,991.5	0.0	0.0	1	1	1
10/09/2019 06:00	0.0	12.2	2,038.0	0.0	0.0	1	1	1
10/09/2019 07:00	0.0	12.4	2,006.4	0.0	0.0	1	1	1
10/09/2019 08:00	0.0	12.5	1,974.6	0.0	0.0	1	1	1
10/09/2019 09:00	0.0	12.4	1,993.7	0.0	0.0	1	1	1
10/09/2019 10:00	0.0	12.4	1,998.8	0.0	0.0	1	1	1
10/09/2019 11:00	0.0	13.9	1,630.0	0.0	0.0	1	1	0
10/09/2019 12:00	0.0	14.0	1,614.6	0.0	0.0	1	1	0
10/09/2019 13:00	0.0	14.0	1,558.8	0.0	0.0	1	1	0
10/09/2019 14:00	0.0	14.0	1,483.0	0.0	0.0	1	1	0
10/09/2019 15:00	0.0	13.9	1,491.3	0.0	0.0	1	1	1
10/09/2019 16:00	0.0	12.7	1,905.0	0.0	0.0	1	1	1
10/09/2019 17:00	0.1	12.6	1,990.3	0.0	0.3	1	1	1
10/09/2019 18:00	0.1	12.6	1,979.3	0.1	0.3	1	1	1
10/09/2019 19:00	0.0	12.6	1,976.6	0.1	0.0	1	1	1
10/09/2019 20:00	0.0	12.5	1,977.8	0.0	0.0	1	1	1
10/09/2019 21:00	0.0	12.6	1,969.5	0.0	0.0	1	1	1
10/09/2019 22:00	0.0	12.6	1,977.3	0.0	0.0	1	1	1
10/09/2019 23:00	0.0	12.6	1,969.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.8	1,886.3	0.0	0.6 #	24 #	24 #	20 #
Minimum:	0.0	12.2	1,483.0	0.0	0.0	1	1	0
Maximum:	0.1	14.0	2,038.0	0.1	0.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/10/2019 00:00	0.0	12.6	1,969.6	0.0	0.0	1	1	1
10/10/2019 01:00	0.0	13.1	1,873.4	0.0	0.0	1	1	1
10/10/2019 02:00	0.0	12.9	1,910.6	0.0	0.0	1	1	1
10/10/2019 03:00	0.0	12.7	1,961.1	0.0	0.0	1	1	1
10/10/2019 04:00	0.0	12.7	1,961.1	0.0	0.0	1	1	1
10/10/2019 05:00	0.0	12.8	1,957.5	0.0	0.0	1	1	1
10/10/2019 06:00	0.0	12.7	1,987.4	0.0	0.0	1	1	1
10/10/2019 07:00	0.0	12.9	1,898.5	0.0	0.0	1	1	1
10/10/2019 08:00	0.0	14.0	1,456.2	0.0	0.0	1	1	0
10/10/2019 09:00	0.0	14.0	1,585.4	0.0	0.0	1	1	0
10/10/2019 10:00	0.0	14.0	1,622.5	0.0	0.0	1	1	0
10/10/2019 11:00	0.0	14.0	1,610.9	0.0	0.0	1	1	0
10/10/2019 12:00	0.0	14.0	1,620.0	0.0	0.0	1	1	0
10/10/2019 13:00	0.0	14.0	1,584.7	0.0	0.0	1	1	0
10/10/2019 14:00	0.0	14.0	1,604.8	0.0	0.0	1	1	0
10/10/2019 15:00	0.0	13.9	1,496.7	0.0	0.0	1	1	0
10/10/2019 16:00	0.0	12.4	1,963.8	0.0	0.0	1	1	1
10/10/2019 17:00	0.0	12.5	1,953.8	0.0	0.0	1	1	1
10/10/2019 18:00	0.1	12.4	2,036.5	0.0	0.3	1	1	1
10/10/2019 19:00	0.1	12.4	2,025.3	0.1	0.3	1	1	1
10/10/2019 20:00	0.1	12.5	2,024.4	0.1	0.3	1	1	1
10/10/2019 21:00	0.1	12.4	2,030.6	0.1	0.3	1	1	1
10/10/2019 22:00	0.1	12.4	2,020.9	0.1	0.3	1	1	1
10/10/2019 23:00	0.0	12.7	1,933.0	0.1	0.0	1	1	1
Average/Sum#:	0.0	13.1	1,837.0	0.0	1.5 #	24 #	24 #	16 #
Minimum:	0.0	12.4	1,456.2	0.0	0.0	1	1	0
Maximum:	0.1	14.0	2,036.5	0.1	0.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/11/2019 00:00	0.0	12.7	1,919.9	0.0	0.0	1	1	1
10/11/2019 01:00	0.0	13.1	1,853.6	0.0	0.0	1	1	1
10/11/2019 02:00	0.0	13.1	1,853.1	0.0	0.0	1	1	1
10/11/2019 03:00	0.0	13.1	1,855.3	0.0	0.0	1	1	1
10/11/2019 04:00	0.0	13.1	1,858.0	0.0	0.0	1	1	1
10/11/2019 05:00	0.0	13.9	1,649.2	0.0	0.0	1	1	1
10/11/2019 06:00	0.0	14.0	1,635.8	0.0	0.0	1	1	0
10/11/2019 07:00	0.0	14.0	1,392.5	0.0	0.0	1	1	0
10/11/2019 08:00	0.0	14.0	1,239.2	0.0	0.0	1	1	0
10/11/2019 09:00	0.0	14.0	1,237.0	0.0	0.0	1	1	0
10/11/2019 10:00	0.0	14.0	1,236.9	0.0	0.0	1	1	0
10/11/2019 11:00	0.0	14.0	1,238.9	0.0	0.0	1	1	0
10/11/2019 12:00	0.0	14.0	1,240.4	0.0	0.0	1	1	0
10/11/2019 13:00	0.0	14.0	1,272.9	0.0	0.0	1	1	0
10/11/2019 14:00	0.0	13.9	1,621.1	0.0	0.0	1	1	0
10/11/2019 15:00	0.0	13.8	1,550.6	0.0	0.0	1	1	1
10/11/2019 16:00	0.2	12.6	1,962.1	0.0	0.6	1	1	1
10/11/2019 17:00	0.0	12.0	2,105.8	0.0	0.0	1	1	1
10/11/2019 18:00	0.0	11.8	2,142.7	0.0	0.0	1	1	1
10/11/2019 19:00	0.1	12.2	2,058.2	0.0	0.3	1	1	1
10/11/2019 20:00	0.1	12.3	2,041.4	0.1	0.3	1	1	1
10/11/2019 21:00	0.1	12.3	2,054.4	0.1	0.3	1	1	1
10/11/2019 22:00	0.1	12.4	2,047.6	0.1	0.3	1	1	1
10/11/2019 23:00	0.0	12.4	2,048.4	0.1	0.0	1	1	1
Average/Sum#:	0.0	13.2	1,713.1	0.0	1.8 #	24 #	24 #	15 #
Minimum:	0.0	11.8	1,236.9	0.0	0.0	1	1	0
Maximum:	0.2	14.0	2,142.7	0.1	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/12/2019 00:00	0.0	12.3	2,043.9	0.0	0.0	1	1	1
10/12/2019 01:00	0.0	12.5	2,001.9	0.0	0.0	1	1	1
10/12/2019 02:00	0.0	12.5	2,010.9	0.0	0.0	1	1	1
10/12/2019 03:00	0.0	12.4	2,027.4	0.0	0.0	1	1	1
10/12/2019 04:00	0.0	12.3	2,032.4	0.0	0.0	1	1	1
10/12/2019 05:00	0.0	12.3	2,046.4	0.0	0.0	1	1	1
10/12/2019 06:00	0.0	12.4	2,042.9	0.0	0.0	1	1	1
10/12/2019 07:00	3.8	14.1	1,233.3	0.0	4.6	1	0	1
10/12/2019 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2019 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2019 10:00	3.3	18.7	282.2	0.0	1.2	1	0	0
10/12/2019 11:00	13.1	16.1	679.8	0.0	24.5	1	0	0
10/12/2019 12:00	0.0	14.0	1,331.8	0.0	0.0	1	0	0
10/12/2019 13:00	0.0	14.0	1,293.1	0.0	0.0	1	1	0
10/12/2019 14:00	0.0	13.9	1,575.5	0.0	0.0	1	1	0
10/12/2019 15:00	0.0	14.0	1,416.1	0.0	0.0	1	1	0
10/12/2019 16:00	0.0	13.9	1,613.8	0.0	0.0	1	1	0
10/12/2019 17:00	0.0	13.4	1,744.8	0.0	0.0	1	1	1
10/12/2019 18:00	0.1	12.3	2,020.5	0.0	0.3	1	1	1
10/12/2019 19:00	0.1	12.2	2,045.4	0.1	0.3	1	1	1
10/12/2019 20:00	0.1	12.3	2,039.9	0.1	0.3	1	1	1
10/12/2019 21:00	0.1	12.2	2,055.5	0.1	0.3	1	1	1
10/12/2019 22:00	0.1	12.3	2,034.1	0.1	0.3	1	1	1
10/12/2019 23:00	0.0	12.3	2,065.9	0.1	0.0	1	1	1
Average/Sum#:	0.9	13.3	1,710.8	0.0	31.8 #	22 #	18 #	15 #
Minimum:	0.0	12.2	282.2	0.0	0.0	0	0	0
Maximum:	13.1	18.7	2,065.9	0.1	24.5	1	1	1
%SI	8.33	8.33	8.33	33.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/13/2019 00:00	0.0	12.3	2,037.4	0.0	0.0	1	1	1
10/13/2019 01:00	0.0	12.3	2,037.3	0.0	0.0	1	1	1
10/13/2019 02:00	0.0	12.3	2,039.5	0.0	0.0	1	1	1
10/13/2019 03:00	0.0	12.3	2,045.3	0.0	0.0	1	1	1
10/13/2019 04:00	0.0	12.3	2,044.4	0.0	0.0	1	1	1
10/13/2019 05:00	0.0	12.3	2,041.5	0.0	0.0	1	1	1
10/13/2019 06:00	0.0	12.6	1,977.0	0.0	0.0	1	1	1
10/13/2019 07:00	0.0	13.9	1,484.2	0.0	0.0	1	1	1
10/13/2019 08:00	0.0	13.9	1,595.4	0.0	0.0	1	1	0
10/13/2019 09:00	0.0	13.9	1,620.1	0.0	0.0	1	1	0
10/13/2019 10:00	0.0	13.9	1,616.1	0.0	0.0	1	1	0
10/13/2019 11:00	0.0	14.0	1,494.6	0.0	0.0	1	1	0
10/13/2019 12:00	0.0	13.9	1,624.0	0.0	0.0	1	1	0
10/13/2019 13:00	0.0	14.0	1,514.7	0.0	0.0	1	1	0
10/13/2019 14:00	0.0	13.8	1,611.1	0.0	0.0	1	1	0
10/13/2019 15:00	0.0	13.9	1,516.0	0.0	0.0	1	1	1
10/13/2019 16:00	0.2	12.5	1,957.0	0.0	0.6	1	1	1
10/13/2019 17:00	0.1	12.1	2,043.1	0.1	0.3	1	1	1
10/13/2019 18:00	0.1	12.3	2,016.4	0.1	0.3	1	1	1
10/13/2019 19:00	0.1	12.3	2,004.6	0.1	0.3	1	1	1
10/13/2019 20:00	0.1	12.4	2,005.5	0.1	0.3	1	1	1
10/13/2019 21:00	0.1	12.3	2,026.9	0.1	0.3	1	1	1
10/13/2019 22:00	0.0	13.0	1,806.1	0.1	0.0	1	1	1
10/13/2019 23:00	4.5	15.1	949.0	0.0	4.2	1	0	0
Average/Sum#:	0.2	13.1	1,796.1	0.0	6.3 #	24 #	23 #	16 #
Minimum:	0.0	12.1	949.0	0.0	0.0	1	0	0
Maximum:	4.5	15.1	2,045.3	0.1	4.2	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/14/2019 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2019 02:00	13.1	16.6	599.7	0.0	24.1	1	0	0
10/14/2019 03:00	0.0	13.9	1,479.8	0.0	0.0	1	0	1
10/14/2019 04:00	0.2	12.7	1,938.7	0.0	0.6	1	1	1
10/14/2019 05:00	0.2	12.3	2,034.9	0.0	0.6	1	1	1
10/14/2019 06:00	0.0	13.9	1,639.4	0.1	0.0	1	1	0
10/14/2019 07:00	0.0	13.9	1,405.1	0.0	0.0	1	1	0
10/14/2019 08:00	0.0	13.9	1,464.5	0.0	0.0	1	1	0
10/14/2019 09:00	0.0	14.0	1,259.9	0.0	0.0	1	1	0
10/14/2019 10:00	0.0	14.0	1,252.9	0.0	0.0	1	1	0
10/14/2019 11:00	0.0	14.0	1,314.5	0.0	0.0	1	1	0
10/14/2019 12:00	0.0	0.0	1,447.7	0.0	0.0	1	1	0
10/14/2019 13:00	0.0	13.7	1,561.8	0.0	0.0	1	1	1
10/14/2019 14:00	0.2	13.0	1,932.9	0.0	0.6	1	1	1
10/14/2019 15:00	0.3	12.4	1,989.6	0.1	0.9	1	1	1
10/14/2019 16:00	0.1	12.1	2,048.3	0.1	0.3	1	1	1
10/14/2019 17:00	0.0	11.9	2,110.6	0.1	0.0	1	1	1
10/14/2019 18:00	0.0	11.8	2,144.5	0.0	0.0	1	1	1
10/14/2019 19:00	0.0	11.8	2,145.1	0.0	0.0	1	1	1
10/14/2019 20:00	0.0	12.0	2,089.7	0.0	0.0	1	1	1
10/14/2019 21:00	0.1	12.3	2,040.6	0.0	0.3	1	1	1
10/14/2019 22:00	0.1	12.4	2,035.8	0.1	0.3	1	1	1
10/14/2019 23:00	0.1	12.4	2,038.8	0.1	0.3	1	1	1
Average/Sum#:	0.7	13.1	1,726.1	0.0	28.0 #	22 #	20 #	14 #
Minimum:	0.0	11.8	599.7	0.0	0.0	0	0	0
Maximum:	13.1	16.6	2,145.1	0.1	24.1	1	1	1
%SI	12.50	12.50	8.33	37.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/15/2019 00:00	0.1	12.4	2,046.8	0.1	0.3	1	1	1
10/15/2019 01:00	0.1	12.4	2,033.2	0.1	0.3	1	1	1
10/15/2019 02:00	0.1	12.4	2,043.8	0.1	0.3	1	1	1
10/15/2019 03:00	0.1	12.4	2,034.8	0.1	0.3	1	1	1
10/15/2019 04:00	0.0	12.4	2,033.5	0.1	0.0	1	1	1
10/15/2019 05:00	0.0	13.1	1,787.5	0.0	0.0	1	1	1
10/15/2019 06:00	0.0	13.9	1,676.6	0.0	0.0	1	1	0
10/15/2019 07:00	0.0	13.5	1,733.2	0.0	0.0	1	1	1
10/15/2019 08:00	0.0	13.9	1,475.9	0.0	0.0	1	1	0
10/15/2019 09:00	0.0	14.0	1,310.2	0.0	0.0	1	1	0
10/15/2019 10:00	0.0	14.0	1,287.5	0.0	0.0	1	1	0
10/15/2019 11:00	0.0	14.0	1,319.3	0.0	0.0	1	1	0
10/15/2019 12:00	0.0	14.0	1,401.6	0.0	0.0	1	1	0
10/15/2019 13:00	0.0	13.9	1,621.0	0.0	0.0	1	1	0
10/15/2019 14:00	0.0	13.8	1,623.1	0.0	0.0	1	1	1
10/15/2019 15:00	0.2	12.8	1,873.5	0.0	0.6	1	1	1
10/15/2019 16:00	0.2	11.8	2,113.6	0.1	0.6	1	1	1
10/15/2019 17:00	0.2	11.8	2,119.5	0.1	0.6	1	1	1
10/15/2019 18:00	0.2	11.8	2,123.6	0.1	0.6	1	1	1
10/15/2019 19:00	0.2	11.8	2,124.3	0.1	0.6	1	1	1
10/15/2019 20:00	0.2	11.9	2,129.5	0.1	0.6	1	1	1
10/15/2019 21:00	0.2	11.9	2,132.2	0.1	0.6	1	1	1
10/15/2019 22:00	0.2	11.9	2,129.6	0.1	0.6	1	1	1
10/15/2019 23:00	0.2	11.9	2,128.1	0.1	0.6	1	1	1
Average/Sum#:	0.1	12.8	1,845.9	0.1	6.6 #	24 #	24 #	17 #
Minimum:	0.0	11.8	1,287.5	0.0	0.0	1	1	0
Maximum:	0.2	14.0	2,132.2	0.1	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/16/2019 00:00	0.2	11.9	2,129.7	0.1	0.6	1	1	1
10/16/2019 01:00	0.2	11.9	2,136.0	0.1	0.6	1	1	1
10/16/2019 02:00	0.1	11.9	2,128.2	0.1	0.3	1	1	1
10/16/2019 03:00	0.1	11.9	2,115.0	0.1	0.3	1	1	1
10/16/2019 04:00	0.2	11.9	2,141.3	0.1	0.6	1	1	1
10/16/2019 05:00	0.2	11.9	2,144.1	0.1	0.6	1	1	1
10/16/2019 06:00	0.1	11.9	2,139.9	0.1	0.3	1	1	1
10/16/2019 07:00	0.1	11.9	2,129.5	0.1	0.3	1	1	1
10/16/2019 08:00	0.1	11.9	2,123.8	0.1	0.3	1	1	1
10/16/2019 09:00	0.1	11.9	2,109.3	0.1	0.3	1	1	1
10/16/2019 10:00	0.1	11.9	2,102.7	0.1	0.3	1	1	1
10/16/2019 11:00	0.2	12.0	2,095.3	0.1	0.6	1	1	1
10/16/2019 12:00	0.2	12.0	2,093.3	0.1	0.6	1	1	1
10/16/2019 13:00	0.2	11.9	2,102.4	0.1	0.6	1	1	1
10/16/2019 14:00	0.2	11.9	2,106.2	0.1	0.6	1	1	1
10/16/2019 15:00	0.2	11.8	2,107.0	0.1	0.6	1	1	1
10/16/2019 16:00	0.2	11.8	2,104.8	0.1	0.6	1	1	1
10/16/2019 17:00	0.2	11.9	2,104.4	0.1	0.6	1	1	1
10/16/2019 18:00	0.2	11.9	2,092.4	0.1	0.6	1	1	1
10/16/2019 19:00	0.2	12.0	2,084.8	0.1	0.6	1	1	1
10/16/2019 20:00	0.2	12.0	2,071.2	0.1	0.6	1	1	1
10/16/2019 21:00	0.0	13.7	1,585.8	0.1	0.0	1	1	1
10/16/2019 22:00	0.0	13.9	1,405.4	0.0	0.0	1	1	0
10/16/2019 23:00	0.0	13.9	1,601.1	0.0	0.0	1	1	0
Average/Sum#:	0.1	12.2	2,039.7	0.1	10.5 #	24 #	24 #	22 #
Minimum:	0.0	11.8	1,405.4	0.0	0.0	1	1	0
Maximum:	0.2	13.9	2,144.1	0.1	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/17/2019 00:00	0.0	13.9	1,577.4	0.0	0.0	1	1	0
10/17/2019 01:00	0.0	13.8	1,636.6	0.0	0.0	1	1	1
10/17/2019 02:00	0.2	12.9	1,903.6	0.0	0.6	1	1	1
10/17/2019 03:00	0.1	12.7	1,932.6	0.1	0.3	1	1	1
10/17/2019 04:00	0.1	12.5	1,974.1	0.1	0.3	1	1	1
10/17/2019 05:00	0.1	12.7	1,957.3	0.1	0.3	1	1	1
10/17/2019 06:00	0.1	12.4	2,012.2	0.1	0.3	1	1	1
10/17/2019 07:00	0.0	12.5	1,961.5	0.1	0.0	1	1	1
10/17/2019 08:00	0.0	13.7	1,521.6	0.0	0.0	1	1	1
10/17/2019 09:00	0.0	13.9	1,475.9	0.0	0.0	1	1	0
10/17/2019 10:00	0.0	13.9	1,490.2	0.0	0.0	1	1	0
10/17/2019 11:00	0.0	13.9	1,534.7	0.0	0.0	1	1	0
10/17/2019 12:00	0.0	14.0	1,313.1	0.0	0.0	1	1	0
10/17/2019 13:00	0.0	13.9	1,465.6	0.0	0.0	1	1	0
10/17/2019 14:00	0.0	13.9	1,559.5	0.0	0.0	1	1	0
10/17/2019 15:00	0.0	13.9	1,492.6	0.0	0.0	1	1	1
10/17/2019 16:00	0.1	12.7	1,931.9	0.0	0.3	1	1	1
10/17/2019 17:00	0.0	12.0	2,104.4	0.0	0.0	1	1	1
10/17/2019 18:00	0.0	12.2	2,067.5	0.0	0.0	1	1	1
10/17/2019 19:00	0.1	12.3	2,046.0	0.0	0.3	1	1	1
10/17/2019 20:00	0.1	12.3	2,062.2	0.1	0.3	1	1	1
10/17/2019 21:00	0.0	12.3	2,038.2	0.1	0.0	1	1	1
10/17/2019 22:00	0.0	12.6	1,962.2	0.0	0.0	1	1	1
10/17/2019 23:00	0.0	12.8	1,928.0	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.1	1,789.5	0.0	2.7 #	24 #	24 #	17 #
Minimum:	0.0	12.0	1,313.1	0.0	0.0	1	1	0
Maximum:	0.2	14.0	2,104.4	0.1	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/18/2019 00:00	0.0	12.9	1,906.9	0.0	0.0	1	1	1
10/18/2019 01:00	0.0	12.9	1,903.2	0.0	0.0	1	1	1
10/18/2019 02:00	0.0	13.1	1,860.9	0.0	0.0	1	1	1
10/18/2019 03:00	0.0	13.0	1,903.5	0.0	0.0	1	1	1
10/18/2019 04:00	0.1	12.7	1,965.6	0.0	0.3	1	1	1
10/18/2019 05:00	0.1	12.7	1,952.5	0.1	0.3	1	1	1
10/18/2019 06:00	0.0	12.5	2,006.5	0.1	0.0	1	1	1
10/18/2019 07:00	0.0	13.1	1,851.9	0.0	0.0	1	1	1
10/18/2019 08:00	0.0	13.9	1,531.1	0.0	0.0	1	1	0
10/18/2019 09:00	0.0	13.9	1,478.5	0.0	0.0	1	1	0
10/18/2019 10:00	0.0	13.9	1,486.3	0.0	0.0	1	1	0
10/18/2019 11:00	0.0	13.9	1,496.1	0.0	0.0	1	1	0
10/18/2019 12:00	0.0	13.9	1,451.2	0.0	0.0	1	1	0
10/18/2019 13:00	0.0	13.8	1,564.5	0.0	0.0	1	1	0
10/18/2019 14:00	0.0	13.8	1,563.1	0.0	0.0	1	1	0
10/18/2019 15:00	0.0	13.8	1,579.3	0.0	0.0	1	1	1
10/18/2019 16:00	0.2	12.5	1,976.9	0.0	0.6	1	1	1
10/18/2019 17:00	0.1	12.2	2,031.7	0.1	0.3	1	1	1
10/18/2019 18:00	0.1	12.5	1,964.0	0.1	0.3	1	1	1
10/18/2019 19:00	0.1	12.5	1,970.9	0.1	0.3	1	1	1
10/18/2019 20:00	0.1	12.3	2,024.7	0.1	0.3	1	1	1
10/18/2019 21:00	0.1	12.3	2,039.5	0.1	0.3	1	1	1
10/18/2019 22:00	0.1	12.5	1,987.5	0.1	0.3	1	1	1
10/18/2019 23:00	0.1	12.4	2,032.2	0.1	0.3	1	1	1
Average/Sum#:	0.0	13.0	1,813.7	0.0	3.3 #	24 #	24 #	17 #
Minimum:	0.0	12.2	1,451.2	0.0	0.0	1	1	0
Maximum:	0.2	13.9	2,039.5	0.1	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/19/2019 00:00	0.1	12.6	1,982.0	0.1	0.3	1	1	1
10/19/2019 01:00	0.1	12.6	1,983.7	0.1	0.3	1	1	1
10/19/2019 02:00	0.1	12.3	2,032.2	0.1	0.3	1	1	1
10/19/2019 03:00	0.1	12.5	1,991.5	0.1	0.3	1	1	1
10/19/2019 04:00	0.1	12.7	1,964.1	0.1	0.3	1	1	1
10/19/2019 05:00	0.1	12.6	1,998.3	0.1	0.3	1	1	1
10/19/2019 06:00	0.1	12.6	2,006.5	0.1	0.3	1	1	1
10/19/2019 07:00	4.6	14.6	1,161.9	0.0	5.8	1	0	1
10/19/2019 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2019 14:00	10.5	17.8	403.3	0.0	7.7	1	0	0
10/19/2019 15:00	15.4	15.7	801.9	0.0	31.4	1	0	0
10/19/2019 16:00	0.0	13.2	1,708.4	0.0	0.0	1	1	1
10/19/2019 17:00	0.2	12.4	1,968.5	0.0	0.6	1	1	1
10/19/2019 18:00	0.3	12.9	1,886.1	0.1	0.9	1	1	1
10/19/2019 19:00	0.3	13.0	1,868.6	0.2	0.9	1	1	1
10/19/2019 20:00	0.3	12.7	1,927.5	0.2	0.9	1	1	1
10/19/2019 21:00	0.3	12.7	1,947.7	0.2	0.9	1	1	1
10/19/2019 22:00	0.0	13.6	1,541.0	0.1	0.0	1	1	1
10/19/2019 23:00	0.0	13.9	1,364.0	0.1	0.0	1	1	0
Average/Sum#:	1.8	13.4	1,696.5	0.1	51.2 #	18 #	15 #	15 #
Minimum:	0.0	12.3	403.3	0.1	0.0	0	0	0
Maximum:	15.4	17.8	2,032.2	0.2	31.4	1	1	1
%SI	25.00	25.00	25.00	45.83	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/20/2019 00:00	0.0	13.9	1,438.8	0.0	0.0	1	1	0
10/20/2019 01:00	0.0	13.9	1,346.0	0.0	0.0	1	1	0
10/20/2019 02:00	12.6	16.2	456.0	0.0	3.2	1	0	0
10/20/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2019 10:00	12.9	17.5	449.3	0.0	16.9	1	0	0
10/20/2019 11:00	11.7	15.4	937.0	0.0	26.3	1	0	0
10/20/2019 12:00	0.0	14.0	1,326.2	0.0	0.0	1	1	0
10/20/2019 13:00	0.0	14.0	1,316.9	0.0	0.0	1	1	0
10/20/2019 14:00	0.0	14.0	1,565.8	0.0	0.0	1	1	0
10/20/2019 15:00	0.0	14.0	1,481.9	0.0	0.0	1	1	0
10/20/2019 16:00	0.0	13.9	1,558.3	0.0	0.0	1	1	0
10/20/2019 17:00	0.0	13.8	1,646.8	0.0	0.0	1	1	0
10/20/2019 18:00	0.0	13.3	1,788.8	0.0	0.0	1	1	1
10/20/2019 19:00	0.2	12.5	1,989.4	0.0	0.6	1	1	1
10/20/2019 20:00	0.1	12.5	2,000.9	0.1	0.3	1	1	1
10/20/2019 21:00	0.1	12.6	1,975.6	0.1	0.3	1	1	1
10/20/2019 22:00	0.1	12.6	1,979.0	0.1	0.3	1	1	1
10/20/2019 23:00	0.1	12.5	1,987.8	0.1	0.3	1	1	1
Average/Sum#:	2.2	13.9	1,485.0	0.0	48.2 #	17 #	14 #	6 #
Minimum:	0.0	12.5	449.3	0.0	0.0	0	0	0
Maximum:	12.9	17.5	2,000.9	0.1	26.3	1	1	1
%SI	29.17	29.17	29.17	50.00	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/21/2019 00:00	0.1	12.8	1,930.9	0.1	0.3	1	1	1
10/21/2019 01:00	0.0	12.7	1,928.8	0.1	0.0	1	1	1
10/21/2019 02:00	0.0	12.8	1,923.7	0.0	0.0	1	1	1
10/21/2019 03:00	0.0	12.8	1,927.2	0.0	0.0	1	1	1
10/21/2019 04:00	0.1	12.5	2,003.6	0.0	0.3	1	1	1
10/21/2019 05:00	0.1	12.4	2,036.1	0.1	0.3	1	1	1
10/21/2019 06:00	0.1	12.2	2,095.4	0.1	0.3	1	1	1
10/21/2019 07:00	0.0	12.6	1,937.3	0.1	0.0	1	1	1
10/21/2019 08:00	0.0	14.0	1,258.9	0.0	0.0	1	1	0
10/21/2019 09:00	0.0	14.0	1,254.5	0.0	0.0	1	1	0
10/21/2019 10:00	0.0	14.0	1,399.4	0.0	0.0	1	1	0
10/21/2019 11:00	0.0	14.0	1,459.5	0.0	0.0	1	1	0
10/21/2019 12:00	0.0	13.9	1,586.1	0.0	0.0	1	1	0
10/21/2019 13:00	0.0	13.7	1,733.8	0.0	0.0	1	1	0
10/21/2019 14:00	0.0	13.7	1,731.2	0.0	0.0	1	1	0
10/21/2019 15:00	0.0	13.7	1,730.0	0.0	0.0	1	1	0
10/21/2019 16:00	0.0	13.7	1,731.8	0.0	0.0	1	1	0
10/21/2019 17:00	0.0	13.7	1,736.8	0.0	0.0	1	1	0
10/21/2019 18:00	0.0	13.7	1,735.9	0.0	0.0	1	1	0
10/21/2019 19:00	0.0	13.7	1,739.4	0.0	0.0	1	1	1
10/21/2019 20:00	0.2	12.7	1,960.4	0.0	0.6	1	1	1
10/21/2019 21:00	0.1	12.4	2,008.1	0.1	0.3	1	1	1
10/21/2019 22:00	0.1	12.5	2,001.5	0.1	0.3	1	1	1
10/21/2019 23:00	0.1	12.6	1,970.1	0.1	0.3	1	1	1
Average/Sum#:	0.0	13.2	1,784.2	0.0	2.7 #	24 #	24 #	13 #
Minimum:	0.0	12.2	1,254.5	0.0	0.0	1	1	0
Maximum:	0.2	14.0	2,095.4	0.1	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/22/2019 00:00	0.1	12.8	1,929.4	0.1	0.3	1	1	1
10/22/2019 01:00	0.0	12.7	1,934.0	0.1	0.0	1	1	1
10/22/2019 02:00	0.0	12.7	1,923.3	0.0	0.0	1	1	1
10/22/2019 03:00	0.0	12.6	1,932.1	0.0	0.0	1	1	1
10/22/2019 04:00	0.0	12.8	1,947.6	0.0	0.0	1	1	1
10/22/2019 05:00	0.0	12.5	2,000.6	0.0	0.0	1	1	1
10/22/2019 06:00	0.0	12.4	2,031.9	0.0	0.0	1	1	1
10/22/2019 07:00	0.1	12.7	1,983.9	0.0	0.3	1	1	1
10/22/2019 08:00	0.1	12.4	2,020.9	0.1	0.3	1	1	1
10/22/2019 09:00	0.1	12.4	2,009.9	0.1	0.3	1	1	1
10/22/2019 10:00	0.1	12.4	2,016.2	0.1	0.3	1	1	1
10/22/2019 11:00	0.1	12.3	2,027.9	0.1	0.3	1	1	1
10/22/2019 12:00	0.0	12.2	2,038.6	0.1	0.0	1	1	1
10/22/2019 13:00	0.0	12.1	2,058.8	0.0	0.0	1	1	1
10/22/2019 14:00	0.0	12.0	2,064.1	0.0	0.0	1	1	1
10/22/2019 15:00	0.0	12.1	2,060.2	0.0	0.0	1	1	1
10/22/2019 16:00	0.0	12.1	2,061.5	0.0	0.0	1	1	1
10/22/2019 17:00	0.0	11.9	2,108.7	0.0	0.0	1	1	1
10/22/2019 18:00	0.1	12.2	2,035.4	0.0	0.3	1	1	1
10/22/2019 19:00	0.1	12.1	2,053.7	0.1	0.3	1	1	1
10/22/2019 20:00	0.1	12.3	2,012.1	0.1	0.3	1	1	1
10/22/2019 21:00	0.1	12.2	2,029.5	0.1	0.3	1	1	1
10/22/2019 22:00	0.1	12.3	2,006.4	0.1	0.3	1	1	1
10/22/2019 23:00	0.1	12.5	1,981.3	0.1	0.3	1	1	1
Average/Sum#:	0.1	12.4	2,011.2	0.1	3.6 #	24 #	24 #	24 #
Minimum:	0.0	11.9	1,923.3	0.0	0.0	1	1	1
Maximum:	0.1	12.8	2,108.7	0.1	0.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/23/2019 00:00	0.1	12.5	1,978.0	0.1	0.3	1	1	1
10/23/2019 01:00	0.1	12.5	1,976.9	0.1	0.3	1	1	1
10/23/2019 02:00	0.1	12.6	1,962.3	0.1	0.3	1	1	1
10/23/2019 03:00	0.1	12.6	1,970.1	0.1	0.3	1	1	1
10/23/2019 04:00	0.2	12.7	1,951.3	0.1	0.6	1	1	1
10/23/2019 05:00	0.1	12.3	2,032.6	0.1	0.3	1	1	1
10/23/2019 06:00	0.1	12.5	1,986.1	0.1	0.3	1	1	1
10/23/2019 07:00	0.0	13.9	1,333.0	0.1	0.0	1	1	0
10/23/2019 08:00	0.0	14.0	1,252.0	0.0	0.0	1	1	0
10/23/2019 09:00	0.0	14.0	1,252.4	0.0	0.0	1	1	0
10/23/2019 10:00	0.0	14.0	1,386.6	0.0	0.0	1	1	0
10/23/2019 11:00	0.0	14.0	1,473.3	0.0	0.0	1	1	0
10/23/2019 12:00	0.0	13.9	1,575.8	0.0	0.0	1	1	0
10/23/2019 13:00	0.0	13.7	1,735.3	0.0	0.0	1	1	0
10/23/2019 14:00	0.0	13.7	1,733.6	0.0	0.0	1	1	0
10/23/2019 15:00	0.0	13.7	1,731.8	0.0	0.0	1	1	0
10/23/2019 16:00	0.0	13.7	1,733.9	0.0	0.0	1	1	0
10/23/2019 17:00	0.0	13.7	1,737.2	0.0	0.0	1	1	0
10/23/2019 18:00	0.0	13.8	1,701.6	0.0	0.0	1	1	0
10/23/2019 19:00	0.2	13.0	1,869.7	0.0	0.6	1	1	1
10/23/2019 20:00	0.2	12.3	2,051.7	0.1	0.6	1	1	1
10/23/2019 21:00	0.1	12.2	2,081.6	0.1	0.3	1	1	1
10/23/2019 22:00	0.1	12.2	2,073.9	0.1	0.3	1	1	1
10/23/2019 23:00	0.2	12.4	2,027.1	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.2	1,775.3	0.1	4.8 #	24 #	24 #	12 #
Minimum:	0.0	12.2	1,252.0	0.0	0.0	1	1	0
Maximum:	0.2	14.0	2,081.6	0.1	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/24/2019 00:00	0.2	12.5	2,004.3	0.1	0.6	1	1	1
10/24/2019 01:00	0.2	12.6	1,978.3	0.1	0.6	1	1	1
10/24/2019 02:00	0.2	12.9	1,918.4	0.1	0.6	1	1	1
10/24/2019 03:00	0.2	12.5	2,024.7	0.1	0.6	1	1	1
10/24/2019 04:00	0.2	12.5	2,028.5	0.1	0.6	1	1	1
10/24/2019 05:00	0.2	12.2	2,084.4	0.1	0.6	1	1	1
10/24/2019 06:00	0.2	12.4	2,072.1	0.1	0.6	1	1	1
10/24/2019 07:00	0.1	12.0	2,136.3	0.1	0.3	1	1	1
10/24/2019 08:00	0.1	12.0	2,131.8	0.1	0.3	1	1	1
10/24/2019 09:00	0.1	12.0	2,128.6	0.1	0.3	1	1	1
10/24/2019 10:00	0.1	11.9	2,128.7	0.1	0.3	1	1	1
10/24/2019 11:00	0.0	11.9	2,128.8	0.1	0.0	1	1	1
10/24/2019 12:00	0.0	11.9	2,119.4	0.0	0.0	1	1	1
10/24/2019 13:00	0.0	11.9	2,113.3	0.0	0.0	1	1	1
10/24/2019 14:00	0.0	11.9	2,109.4	0.0	0.0	1	1	1
10/24/2019 15:00	0.0	12.0	2,092.1	0.0	0.0	1	1	1
10/24/2019 16:00	0.1	12.0	2,102.9	0.0	0.3	1	1	1
10/24/2019 17:00	0.1	12.1	2,076.3	0.1	0.3	1	1	1
10/24/2019 18:00	0.1	12.1	2,070.7	0.1	0.3	1	1	1
10/24/2019 19:00	0.1	11.9	2,118.9	0.1	0.3	1	1	1
10/24/2019 20:00	0.1	12.0	2,109.9	0.1	0.3	1	1	1
10/24/2019 21:00	0.1	12.0	2,104.3	0.1	0.3	1	1	1
10/24/2019 22:00	0.0	12.0	2,090.1	0.1	0.0	1	1	1
10/24/2019 23:00	0.1	12.1	2,076.2	0.1	0.3	1	1	1
Average/Sum#:	0.1	12.1	2,081.2	0.1	7.5 #	24 #	24 #	24 #
Minimum:	0.0	11.9	1,918.4	0.0	0.0	1	1	1
Maximum:	0.2	12.9	2,136.3	0.1	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/25/2019 00:00	0.0	12.2	2,007.7	0.0	0.0	1	1	1
10/25/2019 01:00	0.0	12.5	1,958.6	0.0	0.0	1	1	1
10/25/2019 02:00	0.0	12.4	1,974.3	0.0	0.0	1	1	1
10/25/2019 03:00	0.0	12.5	1,970.3	0.0	0.0	1	1	1
10/25/2019 04:00	0.0	12.5	2,005.8	0.0	0.0	1	1	1
10/25/2019 05:00	0.0	12.6	1,993.6	0.0	0.0	1	1	1
10/25/2019 06:00	0.1	12.4	2,036.9	0.0	0.3	1	1	1
10/25/2019 07:00	0.1	12.6	1,992.3	0.1	0.3	1	1	1
10/25/2019 08:00	0.3	13.1	1,904.4	0.1	1.0	1	1	1
10/25/2019 09:00	0.3	13.1	1,903.5	0.2	1.0	1	1	1
10/25/2019 10:00	0.3	12.9	1,920.0	0.2	1.0	1	1	1
10/25/2019 11:00	0.3	12.9	1,907.8	0.2	0.9	1	1	1
10/25/2019 12:00	0.3	12.4	2,013.1	0.2	0.9	1	1	1
10/25/2019 13:00	0.3	12.4	2,013.6	0.2	0.9	1	1	1
10/25/2019 14:00	0.2	12.4	2,011.5	0.2	0.6	1	1	1
10/25/2019 15:00	0.2	12.4	2,012.4	0.1	0.6	1	1	1
10/25/2019 16:00	0.2	12.1	2,062.9	0.1	0.6	1	1	1
10/25/2019 17:00	0.2	12.1	2,057.9	0.1	0.6	1	1	1
10/25/2019 18:00	0.3	12.4	2,000.6	0.1	0.9	1	1	1
10/25/2019 19:00	0.3	12.4	2,000.0	0.2	0.9	1	1	1
10/25/2019 20:00	0.0	12.3	1,976.4	0.1	0.0	1	1	1
10/25/2019 21:00	0.0	12.2	1,999.8	0.1	0.0	1	1	1
10/25/2019 22:00	0.0	12.4	1,979.3	0.0	0.0	1	1	1
10/25/2019 23:00	0.0	12.4	1,992.8	0.0	0.0	1	1	1
Average/Sum#:	0.1	12.5	1,987.3	0.1	10.5 #	24 #	24 #	24 #
Minimum:	0.0	12.1	1,903.5	0.0	0.0	1	1	1
Maximum:	0.3	13.1	2,062.9	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/26/2019 00:00	0.0	12.5	1,971.3	0.0	0.0	1	1	1
10/26/2019 01:00	0.0	12.4	1,996.7	0.0	0.0	1	1	1
10/26/2019 02:00	0.0	12.4	1,995.8	0.0	0.0	1	1	1
10/26/2019 03:00	0.0	12.4	1,990.1	0.0	0.0	1	1	1
10/26/2019 04:00	0.0	12.4	1,993.0	0.0	0.0	1	1	1
10/26/2019 05:00	0.1	12.8	1,935.3	0.0	0.3	1	1	1
10/26/2019 06:00	0.1	12.8	1,921.3	0.1	0.3	1	1	1
10/26/2019 07:00	0.0	13.9	1,480.7	0.1	0.0	1	1	0
10/26/2019 08:00	0.0	13.9	1,577.9	0.0	0.0	1	1	0
10/26/2019 09:00	0.0	13.9	1,578.8	0.0	0.0	1	1	0
10/26/2019 10:00	0.0	13.9	1,467.9	0.0	0.0	1	1	0
10/26/2019 11:00	0.0	13.9	1,427.9	0.0	0.0	1	1	0
10/26/2019 12:00	0.0	14.0	1,525.7	0.0	0.0	1	1	0
10/26/2019 13:00	0.0	13.9	1,584.5	0.0	0.0	1	1	0
10/26/2019 14:00	0.0	14.0	1,472.6	0.0	0.0	1	1	0
10/26/2019 15:00	0.0	13.9	1,485.4	0.0	0.0	1	1	1
10/26/2019 16:00	0.3	12.6	1,940.8	0.1	0.9	1	1	1
10/26/2019 17:00	0.3	12.3	2,002.1	0.1	0.9	1	1	1
10/26/2019 18:00	0.3	12.4	1,998.3	0.2	0.9	1	1	1
10/26/2019 19:00	0.3	12.4	1,995.3	0.2	0.9	1	1	1
10/26/2019 20:00	0.3	12.4	2,007.7	0.2	0.9	1	1	1
10/26/2019 21:00	0.3	12.5	2,011.0	0.2	0.9	1	1	1
10/26/2019 22:00	5.5	14.4	1,147.5	0.0	6.1	1	0	1
10/26/2019 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.3	13.1	1,761.2	0.1	12.1 #	23 #	22 #	15 #
Minimum:	0.0	12.3	1,147.5	0.0	0.0	0	0	0
Maximum:	5.5	14.4	2,011.0	0.2	6.1	1	1	1
%SI	4.17	4.17	4.17	8.33	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/27/2019 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2019 17:00	60.6	18.0	405.9	0.0	47.0	1	0	0
10/27/2019 18:00	19.8	16.3	626.0	0.0	35.6	1	0	0
10/27/2019 19:00	20.2	15.1	901.5	0.0	41.5	1	0	0
10/27/2019 20:00	0.0	14.0	1,447.9	0.0	0.0	1	1	0
10/27/2019 21:00	0.0	14.0	1,340.3	0.0	0.0	1	1	0
10/27/2019 22:00	0.0	14.0	1,341.9	0.0	0.0	1	1	0
10/27/2019 23:00	0.0	14.0	1,343.9	0.0	0.0	1	1	0
Average/Sum#:	14.4	15.1	1,058.2	0.0	124.1 #	7 #	4 #	0 #
Minimum:	0.0	14.0	405.9	0.0	0.0	0	0	0
Maximum:	60.6	18.0	1,447.9	0.0	47.0	1	1	0
%SI	70.83	70.83	70.83	91.67	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/28/2019 00:00	0.0	13.9	1,544.5	0.0	0.0	1	1	0
10/28/2019 01:00	0.0	13.9	1,570.5	0.0	0.0	1	1	0
10/28/2019 02:00	0.0	14.0	1,333.4	0.0	0.0	1	1	0
10/28/2019 03:00	0.0	13.9	1,562.9	0.0	0.0	1	1	1
10/28/2019 04:00	0.1	13.0	1,919.0	0.0	0.3	1	1	1
10/28/2019 05:00	0.1	12.8	1,964.1	0.1	0.3	1	1	1
10/28/2019 06:00	0.0	12.1	2,107.7	0.1	0.0	1	1	1
10/28/2019 07:00	0.0	12.5	2,020.6	0.0	0.0	1	1	1
10/28/2019 08:00	0.1	12.7	1,979.4	0.0	0.3	1	1	1
10/28/2019 09:00	0.1	12.7	1,981.7	0.1	0.3	1	1	1
10/28/2019 10:00	0.1	12.7	1,972.7	0.1	0.3	1	1	1
10/28/2019 11:00	0.2	12.9	1,952.8	0.1	0.6	1	1	1
10/28/2019 12:00	0.3	12.7	1,978.3	0.1	1.0	1	1	1
10/28/2019 13:00	0.3	12.8	1,959.4	0.2	1.0	1	1	1
10/28/2019 14:00	0.3	12.7	1,980.2	0.2	1.0	1	1	1
10/28/2019 15:00	0.3	12.6	2,003.6	0.2	1.0	1	1	1
10/28/2019 16:00	0.2	12.4	2,057.8	0.2	0.6	1	1	1
10/28/2019 17:00	0.1	11.9	2,141.9	0.1	0.3	1	1	1
10/28/2019 18:00	0.2	12.2	2,094.9	0.1	0.6	1	1	1
10/28/2019 19:00	0.2	12.3	2,082.5	0.1	0.6	1	1	1
10/28/2019 20:00	0.1	12.3	2,067.8	0.1	0.3	1	1	1
10/28/2019 21:00	0.0	12.3	2,047.1	0.1	0.0	1	1	1
10/28/2019 22:00	0.1	12.8	1,919.9	0.1	0.3	1	1	1
10/28/2019 23:00	8.2	15.7	608.0	0.0	2.9	1	0	0
Average/Sum#:	0.5	12.9	1,868.8	0.1	11.7 #	24 #	23 #	20 #
Minimum:	0.0	11.9	608.0	0.0	0.0	1	0	0
Maximum:	8.2	15.7	2,141.9	0.2	2.9	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/29/2019 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2019 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/30/2019 00:00	52.0	17.7	444.4	0.0	64.9	1	0	0
10/30/2019 01:00	26.3	16.0	673.3	0.0	47.7	1	0	0
10/30/2019 02:00	19.8	15.0	990.0	0.0	43.9	1	0	0
10/30/2019 03:00	0.1	13.4	1,809.2	0.0	0.3	1	1	1
10/30/2019 04:00	0.2	12.0	2,106.0	0.0	0.6	1	1	1
10/30/2019 05:00	0.0	13.9	1,653.2	0.1	0.0	1	1	0
10/30/2019 06:00	0.0	14.0	1,485.8	0.0	0.0	1	1	0
10/30/2019 07:00	0.0	13.9	1,708.4	0.0	0.0	1	1	0
10/30/2019 08:00	0.0	13.9	1,714.6	0.0	0.0	1	1	1
10/30/2019 09:00	0.1	13.0	1,920.6	0.0	0.3	1	1	1
10/30/2019 10:00	0.1	12.6	2,017.5	0.1	0.3	1	1	1
10/30/2019 11:00	0.0	12.3	2,051.1	0.1	0.0	1	1	1
10/30/2019 12:00	0.0	12.2	2,075.4	0.0	0.0	1	1	1
10/30/2019 13:00	0.0	12.4	2,041.5	0.0	0.0	1	1	1
10/30/2019 14:00	0.2	12.7	1,998.3	0.0	0.6	1	1	1
10/30/2019 15:00	0.2	12.7	2,012.2	0.1	0.6	1	1	1
10/30/2019 16:00	0.2	12.1	2,134.2	0.1	0.6	1	1	1
10/30/2019 17:00	0.1	12.1	2,123.9	0.1	0.3	1	1	1
10/30/2019 18:00	0.2	12.3	2,096.6	0.1	0.6	1	1	1
10/30/2019 19:00	0.2	12.4	2,089.3	0.1	0.6	1	1	1
10/30/2019 20:00	0.2	12.5	2,054.6	0.1	0.6	1	1	1
10/30/2019 21:00	0.1	12.4	2,056.9	0.1	0.3	1	1	1
10/30/2019 22:00	0.1	12.8	1,959.0	0.1	0.3	1	1	1
10/30/2019 23:00	0.1	13.0	1,948.7	0.1	0.3	1	1	1
Average/Sum#:	4.2	13.2	1,798.5	0.1	162.8 #	24 #	21 #	18 #
Minimum:	0.0	12.0	444.4	0.0	0.0	1	0	0
Maximum:	52.0	17.7	2,134.2	0.1	64.9	1	1	1
%SI	0.00	0.00	0.00	20.83	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/31/2019 00:00	0.1	13.1	1,936.9	0.1	0.3	1	1	1
10/31/2019 01:00	0.1	12.9	1,965.0	0.1	0.3	1	1	1
10/31/2019 02:00	0.1	12.9	1,957.8	0.1	0.3	1	1	1
10/31/2019 03:00	0.1	12.9	1,966.3	0.1	0.3	1	1	1
10/31/2019 04:00	0.1	12.8	1,995.8	0.1	0.3	1	1	1
10/31/2019 05:00	0.1	12.6	2,009.9	0.1	0.3	1	1	1
10/31/2019 06:00	0.1	12.7	1,998.8	0.1	0.3	1	1	1
10/31/2019 07:00	0.1	12.9	1,966.9	0.1	0.3	1	1	1
10/31/2019 08:00	0.1	13.0	1,938.6	0.1	0.3	1	1	1
10/31/2019 09:00	0.1	12.8	1,961.7	0.1	0.3	1	1	1
10/31/2019 10:00	0.1	12.9	1,949.1	0.1	0.3	1	1	1
10/31/2019 11:00	0.2	13.1	1,923.3	0.1	0.7	1	1	1
10/31/2019 12:00	0.2	12.9	1,946.4	0.1	0.6	1	1	1
10/31/2019 13:00	0.2	12.9	1,946.4	0.1	0.6	1	1	1
10/31/2019 14:00	0.2	12.9	1,953.8	0.1	0.6	1	1	1
10/31/2019 15:00	0.2	12.8	1,958.8	0.1	0.6	1	1	1
10/31/2019 16:00	0.3	12.8	1,968.1	0.1	1.0	1	1	1
10/31/2019 17:00	0.3	12.9	1,946.6	0.2	1.0	1	1	1
10/31/2019 18:00	0.3	12.8	1,975.2	0.2	1.0	1	1	1
10/31/2019 19:00	0.2	12.4	2,071.2	0.2	0.6	1	1	1
10/31/2019 20:00	0.2	12.4	2,063.5	0.1	0.6	1	1	1
10/31/2019 21:00	0.2	12.4	2,072.1	0.1	0.6	1	1	1
10/31/2019 22:00	0.0	12.3	2,065.1	0.1	0.0	1	1	1
10/31/2019 23:00	0.1	12.4	2,055.0	0.1	0.3	1	1	1
Average/Sum#:	0.2	12.8	1,983.0	0.1	11.5 #	24 #	24 #	24 #
Minimum:	0.0	12.3	1,923.3	0.1	0.0	1	1	1
Maximum:	0.3	13.1	2,072.1	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2019 00:00	0.1	12.5	2,039.3	0.1	0.3	1	1	1
11/01/2019 01:00	0.1	12.6	2,007.9	0.1	0.3	1	1	1
11/01/2019 02:00	0.1	12.5	2,037.2	0.1	0.3	1	1	1
11/01/2019 03:00	0.1	12.5	2,037.3	0.1	0.3	1	1	1
11/01/2019 04:00	0.1	12.7	2,001.1	0.1	0.3	1	1	1
11/01/2019 05:00	0.1	12.4	2,088.4	0.1	0.3	1	1	1
11/01/2019 06:00	0.1	12.3	2,111.8	0.1	0.3	1	1	1
11/01/2019 07:00	0.0	12.3	2,107.2	0.1	0.0	1	1	1
11/01/2019 08:00	0.0	12.3	2,094.9	0.0	0.0	1	1	1
11/01/2019 09:00	0.0	13.5	1,762.6	0.0	0.0	1	1	1
11/01/2019 10:00	0.0	13.9	1,657.5	0.0	0.0	1	1	0
11/01/2019 11:00	0.0	14.0	1,325.9	0.0	0.0	1	1	0
11/01/2019 12:00	0.0	13.9	1,515.9	0.0	0.0	1	1	0
11/01/2019 13:00	0.0	14.0	1,560.1	0.0	0.0	1	1	0
11/01/2019 14:00	0.0	13.9	1,520.8	0.0	0.0	1	1	1
11/01/2019 15:00	0.3	12.8	1,958.8	0.1	1.0	1	1	1
11/01/2019 16:00	0.2	12.5	1,987.6	0.1	0.6	1	1	1
11/01/2019 17:00	0.1	12.0	2,130.3	0.1	0.3	1	1	1
11/01/2019 18:00	0.1	11.9	2,165.5	0.1	0.3	1	1	1
11/01/2019 19:00	0.2	12.3	2,081.7	0.1	0.6	1	1	1
11/01/2019 20:00	0.1	12.2	2,118.3	0.1	0.3	1	1	1
11/01/2019 21:00	0.2	12.5	2,048.1	0.1	0.6	1	1	1
11/01/2019 22:00	0.2	12.7	2,021.6	0.1	0.7	1	1	1
11/01/2019 23:00	0.2	12.6	2,042.8	0.1	0.7	1	1	1
Average/Sum#:	0.1	12.8	1,934.3	0.1	7.2 #	24 #	24 #	20 #
Minimum:	0.0	11.9	1,325.9	0.0	0.0	1	1	0
Maximum:	0.3	14.0	2,165.5	0.1	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/02/2019 00:00	0.1	12.4	2,059.3	0.1	0.3	1	1	1
11/02/2019 01:00	0.1	12.3	2,062.5	0.1	0.3	1	1	1
11/02/2019 02:00	0.0	12.3	2,075.5	0.1	0.0	1	1	1
11/02/2019 03:00	0.1	12.3	2,071.8	0.1	0.3	1	1	1
11/02/2019 04:00	0.0	12.3	2,076.7	0.0	0.0	1	1	1
11/02/2019 05:00	0.1	12.4	2,043.3	0.1	0.3	1	1	1
11/02/2019 06:00	0.0	12.0	2,128.8	0.0	0.0	1	1	1
11/02/2019 07:00	0.0	12.3	2,071.0	0.0	0.0	1	1	1
11/02/2019 08:00	0.1	13.0	1,895.3	0.0	0.3	1	1	1
11/02/2019 09:00	0.0	13.9	1,536.5	0.0	0.0	1	1	0
11/02/2019 10:00	0.0	13.9	1,526.0	0.0	0.0	1	1	0
11/02/2019 11:00	0.0	14.0	1,536.3	0.0	0.0	1	1	0
11/02/2019 12:00	0.0	14.0	1,535.8	0.0	0.0	1	1	0
11/02/2019 13:00	7.2	15.6	733.2	0.0	4.0	1	0	0
11/02/2019 14:00	17.6	16.4	635.9	0.0	25.6	1	0	0
11/02/2019 15:00	0.0	14.0	1,533.5	0.0	0.0	1	0	0
11/02/2019 16:00	0.0	14.0	1,386.1	0.0	0.0	1	1	0
11/02/2019 17:00	0.1	13.6	1,722.6	0.0	0.3	1	1	1
11/02/2019 18:00	0.3	12.5	2,020.0	0.1	1.0	1	1	1
11/02/2019 19:00	0.1	12.0	2,132.0	0.1	0.3	1	1	1
11/02/2019 20:00	0.2	12.0	2,119.4	0.1	0.6	1	1	1
11/02/2019 21:00	0.2	12.4	2,069.6	0.1	0.6	1	1	1
11/02/2019 22:00	0.2	12.5	2,045.7	0.1	0.6	1	1	1
11/02/2019 23:00	0.2	12.7	2,001.3	0.1	0.6	1	1	1
Average/Sum#:	1.1	13.1	1,792.4	0.1	35.1 #	24 #	21 #	16 #
Minimum:	0.0	12.0	635.9	0.0	0.0	1	0	0
Maximum:	17.6	16.4	2,132.0	0.1	25.6	1	1	1
%SI	0.00	0.00	0.00	20.83	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/03/2019 00:00	0.2	12.7	1,981.8	0.1	0.6	1	1	1
11/03/2019 01:00	0.1	12.6	1,996.2	0.1	0.3	1	1	1
11/03/2019 02:00	0.2	12.7	1,986.3	0.1	0.6	1	1	1
11/03/2019 03:00	0.1	12.6	2,004.9	0.1	0.3	1	1	1
11/03/2019 04:00	0.1	12.4	2,035.2	0.1	0.3	1	1	1
11/03/2019 05:00	0.1	12.2	2,086.3	0.1	0.3	1	1	1
11/03/2019 06:00	0.1	12.4	2,066.7	0.1	0.3	1	1	1
11/03/2019 07:00	0.1	12.6	1,947.8	0.1	0.3	1	1	1
11/03/2019 08:00	0.0	13.9	1,616.8	0.1	0.0	1	1	0
11/03/2019 09:00	0.0	13.9	1,596.8	0.0	0.0	1	1	0
11/03/2019 10:00	0.0	13.9	1,616.9	0.0	0.0	1	1	0
11/03/2019 11:00	0.0	13.9	1,606.5	0.0	0.0	1	1	0
11/03/2019 12:00	0.0	14.0	1,622.4	0.0	0.0	1	1	0
11/03/2019 13:00	0.0	14.0	1,475.1	0.0	0.0	1	1	0
11/03/2019 14:00	0.0	14.0	1,450.0	0.0	0.0	1	1	0
11/03/2019 15:00	0.2	13.3	1,764.1	0.1	0.6	1	1	1
11/03/2019 16:00	0.3	12.3	2,057.5	0.1	0.9	1	1	1
11/03/2019 17:00	0.2	12.1	2,094.3	0.2	0.6	1	1	1
11/03/2019 18:00	0.2	12.0	2,112.8	0.1	0.6	1	1	1
11/03/2019 19:00	0.1	11.9	2,131.0	0.1	0.3	1	1	1
11/03/2019 20:00	0.2	12.1	2,092.6	0.1	0.6	1	1	1
11/03/2019 21:00	0.2	12.3	2,064.3	0.1	0.6	1	1	1
11/03/2019 22:00	0.2	12.5	2,016.5	0.1	0.6	1	1	1
11/03/2019 23:00	0.1	12.4	2,039.4	0.1	0.3	1	1	1
Average/Sum#:	0.1	12.9	1,894.3	0.1	8.1 #	24 #	24 #	17 #
Minimum:	0.0	11.9	1,450.0	0.0	0.0	1	1	0
Maximum:	0.3	14.0	2,131.0	0.2	0.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/04/2019 00:00	0.1	12.5	2,008.7	0.1	0.3	1	1	1
11/04/2019 01:00	0.1	12.5	2,011.6	0.1	0.3	1	1	1
11/04/2019 02:00	0.2	12.7	1,961.1	0.1	0.6	1	1	1
11/04/2019 03:00	0.2	12.6	1,987.3	0.1	0.6	1	1	1
11/04/2019 04:00	0.1	12.5	2,007.4	0.1	0.3	1	1	1
11/04/2019 05:00	0.1	12.1	2,088.0	0.1	0.3	1	1	1
11/04/2019 06:00	0.1	12.0	2,128.2	0.1	0.3	1	1	1
11/04/2019 07:00	0.2	12.5	2,016.1	0.1	0.6	1	1	1
11/04/2019 08:00	0.2	12.5	2,029.1	0.1	0.6	1	1	1
11/04/2019 09:00	0.1	12.2	2,062.6	0.1	0.3	1	1	1
11/04/2019 10:00	0.1	12.3	2,026.7	0.1	0.3	1	1	1
11/04/2019 11:00	0.1	12.5	1,959.3	0.1	0.3	1	1	1
11/04/2019 12:00	0.1	12.3	2,005.9	0.1	0.3	1	1	1
11/04/2019 13:00	0.0	12.1	2,014.3	0.1	0.0	1	1	1
11/04/2019 14:00	0.0	12.2	1,995.5	0.0	0.0	1	1	1
11/04/2019 15:00	0.0	12.1	2,019.7	0.0	0.0	1	1	1
11/04/2019 16:00	0.0	12.0	2,072.5	0.0	0.0	1	1	1
11/04/2019 17:00	0.1	11.9	2,128.1	0.0	0.3	1	1	1
11/04/2019 18:00	0.1	11.9	2,132.5	0.1	0.3	1	1	1
11/04/2019 19:00	0.1	12.0	2,132.0	0.1	0.3	1	1	1
11/04/2019 20:00	0.2	12.0	2,128.1	0.1	0.6	1	1	1
11/04/2019 21:00	0.1	12.0	2,130.5	0.1	0.3	1	1	1
11/04/2019 22:00	0.2	12.0	2,127.8	0.1	0.6	1	1	1
11/04/2019 23:00	0.2	12.3	2,059.0	0.1	0.6	1	1	1
Average/Sum#:	0.1	12.2	2,051.3	0.1	8.1 #	24 #	24 #	24 #
Minimum:	0.0	11.9	1,959.3	0.0	0.0	1	1	1
Maximum:	0.2	12.7	2,132.5	0.1	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/05/2019 00:00	0.2	12.3	2,077.8	0.1	0.6	1	1	1
11/05/2019 01:00	0.2	12.3	2,076.3	0.1	0.6	1	1	1
11/05/2019 02:00	0.2	12.3	2,073.7	0.1	0.6	1	1	1
11/05/2019 03:00	0.2	12.3	2,071.0	0.1	0.6	1	1	1
11/05/2019 04:00	0.2	12.3	2,068.4	0.1	0.6	1	1	1
11/05/2019 05:00	0.2	12.2	2,108.2	0.1	0.6	1	1	1
11/05/2019 06:00	0.1	12.0	2,158.8	0.1	0.3	1	1	1
11/05/2019 07:00	0.2	12.6	2,001.5	0.1	0.6	1	1	1
11/05/2019 08:00	0.3	12.6	2,016.7	0.1	1.0	1	1	1
11/05/2019 09:00	0.3	12.8	1,972.2	0.2	1.0	1	1	1
11/05/2019 10:00	0.3	12.7	1,979.7	0.2	1.0	1	1	1
11/05/2019 11:00	0.3	12.7	1,964.8	0.2	0.9	1	1	1
11/05/2019 12:00	0.3	12.6	1,974.9	0.2	0.9	1	1	1
11/05/2019 13:00	0.3	12.4	2,026.2	0.2	0.9	1	1	1
11/05/2019 14:00	0.3	12.4	2,006.2	0.2	0.9	1	1	1
11/05/2019 15:00	0.3	12.4	2,017.6	0.2	0.9	1	1	1
11/05/2019 16:00	0.2	12.1	2,078.0	0.2	0.6	1	1	1
11/05/2019 17:00	0.2	12.2	2,063.8	0.1	0.6	1	1	1
11/05/2019 18:00	0.2	12.2	2,068.5	0.1	0.6	1	1	1
11/05/2019 19:00	0.2	12.1	2,078.5	0.1	0.6	1	1	1
11/05/2019 20:00	0.2	12.2	2,085.3	0.1	0.6	1	1	1
11/05/2019 21:00	0.2	12.2	2,073.8	0.1	0.6	1	1	1
11/05/2019 22:00	0.2	12.3	2,080.1	0.1	0.6	1	1	1
11/05/2019 23:00	0.2	12.3	2,084.0	0.1	0.6	1	1	1
Average/Sum#:	0.2	12.4	2,050.3	0.1	16.8 #	24 #	24 #	24 #
Minimum:	0.1	12.0	1,964.8	0.1	0.3	1	1	1
Maximum:	0.3	12.8	2,158.8	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/06/2019 00:00	0.3	12.6	2,015.5	0.1	1.0	1	1	1
11/06/2019 01:00	0.3	12.8	1,981.3	0.2	1.0	1	1	1
11/06/2019 02:00	0.3	12.5	2,049.7	0.2	1.0	1	1	1
11/06/2019 03:00	0.2	12.5	2,017.1	0.2	0.6	1	1	1
11/06/2019 04:00	0.2	12.7	1,975.2	0.1	0.6	1	1	1
11/06/2019 05:00	0.2	12.5	2,023.4	0.1	0.6	1	1	1
11/06/2019 06:00	0.2	12.2	2,096.8	0.1	0.6	1	1	1
11/06/2019 07:00	0.2	12.4	2,042.3	0.1	0.6	1	1	1
11/06/2019 08:00	0.3	12.6	2,007.6	0.1	1.0	1	1	1
11/06/2019 09:00	0.3	12.7	1,976.2	0.2	1.0	1	1	1
11/06/2019 10:00	0.3	12.7	1,971.5	0.2	1.0	1	1	1
11/06/2019 11:00	0.3	12.6	1,986.6	0.2	0.9	1	1	1
11/06/2019 12:00	0.3	12.6	1,980.4	0.2	0.9	1	1	1
11/06/2019 13:00	0.3	12.5	1,987.8	0.2	0.9	1	1	1
11/06/2019 14:00	0.3	12.5	1,999.8	0.2	0.9	1	1	1
11/06/2019 15:00	0.3	12.4	2,008.2	0.2	0.9	1	1	1
11/06/2019 16:00	0.2	12.2	2,053.0	0.2	0.6	1	1	1
11/06/2019 17:00	0.2	12.1	2,085.1	0.1	0.6	1	1	1
11/06/2019 18:00	0.2	12.1	2,080.8	0.1	0.6	1	1	1
11/06/2019 19:00	0.2	12.1	2,086.5	0.1	0.6	1	1	1
11/06/2019 20:00	0.2	12.1	2,082.1	0.1	0.6	1	1	1
11/06/2019 21:00	0.2	12.1	2,096.8	0.1	0.6	1	1	1
11/06/2019 22:00	0.2	12.2	2,089.3	0.1	0.6	1	1	1
11/06/2019 23:00	0.2	12.3	2,063.7	0.1	0.6	1	1	1
Average/Sum#:	0.2	12.4	2,031.5	0.1	18.3 #	24 #	24 #	24 #
Minimum:	0.2	12.1	1,971.5	0.1	0.6	1	1	1
Maximum:	0.3	12.8	2,096.8	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/07/2019 00:00	0.2	12.3	2,081.6	0.1	0.6	1	1	1
11/07/2019 01:00	0.1	12.3	2,057.9	0.1	0.3	1	1	1
11/07/2019 02:00	0.1	12.4	2,032.0	0.1	0.3	1	1	1
11/07/2019 03:00	0.2	12.6	1,994.8	0.1	0.6	1	1	1
11/07/2019 04:00	0.1	12.4	2,040.5	0.1	0.3	1	1	1
11/07/2019 05:00	0.2	12.4	2,041.8	0.1	0.6	1	1	1
11/07/2019 06:00	0.1	12.3	2,066.5	0.1	0.3	1	1	1
11/07/2019 07:00	0.2	12.4	2,045.8	0.1	0.6	1	1	1
11/07/2019 08:00	0.3	12.7	2,001.6	0.1	1.0	1	1	1
11/07/2019 09:00	0.3	12.6	2,004.1	0.2	1.0	1	1	1
11/07/2019 10:00	0.3	12.7	1,976.3	0.2	1.0	1	1	1
11/07/2019 11:00	0.3	12.5	2,008.8	0.2	0.9	1	1	1
11/07/2019 12:00	0.3	12.5	2,008.1	0.2	0.9	1	1	1
11/07/2019 13:00	0.3	12.5	2,005.1	0.2	0.9	1	1	1
11/07/2019 14:00	0.3	12.4	2,020.6	0.2	0.9	1	1	1
11/07/2019 15:00	0.2	12.3	2,038.9	0.2	0.6	1	1	1
11/07/2019 16:00	0.2	12.1	2,084.0	0.1	0.6	1	1	1
11/07/2019 17:00	0.2	12.3	2,045.2	0.1	0.6	1	1	1
11/07/2019 18:00	0.2	12.1	2,104.0	0.1	0.6	1	1	1
11/07/2019 19:00	0.2	12.1	2,107.4	0.1	0.6	1	1	1
11/07/2019 20:00	0.2	12.2	2,073.1	0.1	0.6	1	1	1
11/07/2019 21:00	0.2	12.4	2,050.2	0.1	0.6	1	1	1
11/07/2019 22:00	0.2	12.4	2,056.7	0.1	0.6	1	1	1
11/07/2019 23:00	0.2	12.5	2,030.2	0.1	0.6	1	1	1
Average/Sum#:	0.2	12.4	2,040.6	0.1	15.6 #	24 #	24 #	24 #
Minimum:	0.1	12.1	1,976.3	0.1	0.3	1	1	1
Maximum:	0.3	12.7	2,107.4	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/08/2019 00:00	0.1	12.4	2,055.6	0.1	0.3	1	1	1
11/08/2019 01:00	0.1	12.3	2,069.5	0.1	0.3	1	1	1
11/08/2019 02:00	0.1	12.4	2,041.9	0.1	0.3	1	1	1
11/08/2019 03:00	0.2	12.5	2,013.1	0.1	0.6	1	1	1
11/08/2019 04:00	0.2	12.6	2,007.1	0.1	0.6	1	1	1
11/08/2019 05:00	0.2	12.6	2,010.1	0.1	0.6	1	1	1
11/08/2019 06:00	0.2	12.6	2,001.5	0.1	0.6	1	1	1
11/08/2019 07:00	0.2	12.7	1,992.1	0.1	0.6	1	1	1
11/08/2019 08:00	0.1	13.1	1,868.5	0.1	0.3	1	1	1
11/08/2019 09:00	0.0	13.9	1,497.5	0.1	0.0	1	1	0
11/08/2019 10:00	0.0	14.0	1,332.3	0.0	0.0	1	1	0
11/08/2019 11:00	0.0	13.9	1,483.7	0.0	0.0	1	1	0
11/08/2019 12:00	0.0	14.0	1,485.4	0.0	0.0	1	1	0
11/08/2019 13:00	0.0	13.8	1,629.9	0.0	0.0	1	1	0
11/08/2019 14:00	0.1	13.8	1,628.2	0.0	0.3	1	1	1
11/08/2019 15:00	0.3	12.8	1,938.7	0.1	0.9	1	1	1
11/08/2019 16:00	0.3	12.5	1,994.3	0.2	0.9	1	1	1
11/08/2019 17:00	0.3	12.5	2,010.5	0.2	0.9	1	1	1
11/08/2019 18:00	0.2	12.3	2,066.4	0.2	0.6	1	1	1
11/08/2019 19:00	0.3	12.4	2,028.9	0.2	0.9	1	1	1
11/08/2019 20:00	0.3	12.4	2,058.7	0.2	1.0	1	1	1
11/08/2019 21:00	0.2	12.3	2,064.8	0.2	0.6	1	1	1
11/08/2019 22:00	0.3	12.4	2,062.1	0.2	1.0	1	1	1
11/08/2019 23:00	0.2	12.3	2,077.3	0.1	0.6	1	1	1
Average/Sum#:	0.2	12.9	1,892.4	0.1	11.9 #	24 #	24 #	19 #
Minimum:	0.0	12.3	1,332.3	0.0	0.0	1	1	0
Maximum:	0.3	14.0	2,077.3	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/09/2019 00:00	0.1	12.2	2,078.1	0.1	0.3	1	1	1
11/09/2019 01:00	0.1	12.3	2,055.1	0.1	0.3	1	1	1
11/09/2019 02:00	0.1	12.3	2,058.6	0.1	0.3	1	1	1
11/09/2019 03:00	0.1	12.3	2,060.0	0.1	0.3	1	1	1
11/09/2019 04:00	0.1	12.3	2,069.3	0.1	0.3	1	1	1
11/09/2019 05:00	0.2	12.6	2,008.9	0.1	0.6	1	1	1
11/09/2019 06:00	0.2	12.8	1,992.1	0.1	0.6	1	1	1
11/09/2019 07:00	0.2	12.8	1,937.4	0.1	0.6	1	1	1
11/09/2019 08:00	0.0	13.9	1,495.2	0.1	0.0	1	1	0
11/09/2019 09:00	0.0	14.0	1,265.6	0.0	0.0	1	1	0
11/09/2019 10:00	0.0	14.0	1,280.9	0.0	0.0	1	1	0
11/09/2019 11:00	0.0	14.0	1,274.1	0.0	0.0	1	1	0
11/09/2019 12:00	0.0	14.0	1,282.6	0.0	0.0	1	1	0
11/09/2019 13:00	0.0	14.0	1,273.7	0.0	0.0	1	1	0
11/09/2019 14:00	0.0	13.9	1,495.9	0.0	0.0	1	1	1
11/09/2019 15:00	0.3	12.8	1,950.1	0.1	1.0	1	1	1
11/09/2019 16:00	0.3	12.5	1,996.0	0.1	0.9	1	1	1
11/09/2019 17:00	0.3	12.4	2,023.3	0.2	0.9	1	1	1
11/09/2019 18:00	0.3	12.5	1,998.6	0.2	0.9	1	1	1
11/09/2019 19:00	0.3	12.6	2,003.0	0.2	1.0	1	1	1
11/09/2019 20:00	0.3	12.6	1,991.9	0.2	1.0	1	1	1
11/09/2019 21:00	0.3	12.6	2,017.7	0.2	1.0	1	1	1
11/09/2019 22:00	0.3	12.5	2,040.6	0.2	1.0	1	1	1
11/09/2019 23:00	0.3	12.6	2,016.5	0.2	1.0	1	1	1
Average/Sum#:	0.2	12.9	1,819.4	0.1	12.0 #	24 #	24 #	18 #
Minimum:	0.0	12.2	1,265.6	0.0	0.0	1	1	0
Maximum:	0.3	14.0	2,078.1	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/10/2019 00:00	0.3	12.6	2,030.3	0.2	1.0	1	1	1
11/10/2019 01:00	0.2	12.8	1,969.0	0.2	0.6	1	1	1
11/10/2019 02:00	0.2	12.8	1,968.4	0.1	0.6	1	1	1
11/10/2019 03:00	0.2	12.8	1,967.9	0.1	0.6	1	1	1
11/10/2019 04:00	0.2	12.8	1,967.0	0.1	0.6	1	1	1
11/10/2019 05:00	0.2	12.8	1,964.1	0.1	0.6	1	1	1
11/10/2019 06:00	0.2	12.6	2,005.9	0.1	0.6	1	1	1
11/10/2019 07:00	0.2	12.6	1,982.3	0.1	0.6	1	1	1
11/10/2019 08:00	0.0	13.9	1,527.7	0.1	0.0	1	1	0
11/10/2019 09:00	0.0	13.9	1,493.6	0.0	0.0	1	1	0
11/10/2019 10:00	0.0	13.9	1,499.1	0.0	0.0	1	1	0
11/10/2019 11:00	0.0	13.9	1,541.4	0.0	0.0	1	1	0
11/10/2019 12:00	0.0	14.0	1,526.8	0.0	0.0	1	1	0
11/10/2019 13:00	0.0	13.9	1,610.3	0.0	0.0	1	1	0
11/10/2019 14:00	0.0	13.9	1,573.8	0.0	0.0	1	1	0
11/10/2019 15:00	0.0	13.8	1,513.5	0.0	0.0	1	1	1
11/10/2019 16:00	0.3	12.8	1,957.6	0.1	1.0	1	1	1
11/10/2019 17:00	0.3	12.5	1,995.9	0.1	0.9	1	1	1
11/10/2019 18:00	0.3	12.6	1,991.9	0.2	1.0	1	1	1
11/10/2019 19:00	0.3	12.5	2,010.5	0.2	0.9	1	1	1
11/10/2019 20:00	0.3	12.5	2,020.7	0.2	1.0	1	1	1
11/10/2019 21:00	0.3	12.4	2,058.5	0.2	1.0	1	1	1
11/10/2019 22:00	0.2	12.2	2,097.0	0.2	0.6	1	1	1
11/10/2019 23:00	0.2	12.4	2,039.4	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.0	1,846.4	0.1	12.2 #	24 #	24 #	17 #
Minimum:	0.0	12.2	1,493.6	0.0	0.0	1	1	0
Maximum:	0.3	14.0	2,097.0	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/11/2019 00:00	0.3	12.5	2,028.0	0.1	1.0	1	1	1
11/11/2019 01:00	0.2	12.6	1,989.2	0.1	0.6	1	1	1
11/11/2019 02:00	0.3	12.6	2,012.6	0.2	1.0	1	1	1
11/11/2019 03:00	0.3	12.6	2,008.2	0.2	1.0	1	1	1
11/11/2019 04:00	0.2	12.7	1,977.9	0.2	0.6	1	1	1
11/11/2019 05:00	0.2	12.7	1,973.2	0.1	0.6	1	1	1
11/11/2019 06:00	0.3	12.7	1,998.4	0.1	1.0	1	1	1
11/11/2019 07:00	0.2	12.6	2,011.7	0.1	0.6	1	1	1
11/11/2019 08:00	0.1	13.1	1,867.2	0.1	0.3	1	1	1
11/11/2019 09:00	0.0	13.8	1,463.8	0.1	0.0	1	1	0
11/11/2019 10:00	0.0	13.9	1,483.1	0.0	0.0	1	1	0
11/11/2019 11:00	0.0	13.9	1,476.0	0.0	0.0	1	1	0
11/11/2019 12:00	0.0	13.9	1,464.3	0.0	0.0	1	1	0
11/11/2019 13:00	0.0	13.8	1,677.0	0.0	0.0	1	1	1
11/11/2019 14:00	0.3	12.8	1,901.8	0.1	0.9	1	1	1
11/11/2019 15:00	0.3	12.4	2,002.5	0.1	0.9	1	1	1
11/11/2019 16:00	0.3	12.4	1,999.4	0.2	0.9	1	1	1
11/11/2019 17:00	0.2	12.0	2,088.6	0.2	0.6	1	1	1
11/11/2019 18:00	0.2	12.1	2,075.0	0.1	0.6	1	1	1
11/11/2019 19:00	0.2	12.2	2,047.6	0.1	0.6	1	1	1
11/11/2019 20:00	0.2	12.3	2,051.4	0.1	0.6	1	1	1
11/11/2019 21:00	0.2	12.3	2,058.3	0.1	0.6	1	1	1
11/11/2019 22:00	0.2	12.3	2,056.3	0.1	0.6	1	1	1
11/11/2019 23:00	0.2	12.3	2,041.9	0.1	0.6	1	1	1
Average/Sum#:	0.2	12.8	1,906.4	0.1	13.6 #	24 #	24 #	20 #
Minimum:	0.0	12.0	1,463.8	0.0	0.0	1	1	0
Maximum:	0.3	13.9	2,088.6	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/12/2019 00:00	0.2	12.4	2,034.6	0.1	0.6	1	1	1
11/12/2019 01:00	0.2	12.4	2,039.0	0.1	0.6	1	1	1
11/12/2019 02:00	0.3	12.6	2,016.2	0.1	1.0	1	1	1
11/12/2019 03:00	0.2	12.4	2,056.8	0.1	0.6	1	1	1
11/12/2019 04:00	0.2	12.4	2,043.7	0.1	0.6	1	1	1
11/12/2019 05:00	0.2	12.5	2,022.9	0.1	0.6	1	1	1
11/12/2019 06:00	0.2	12.3	2,055.3	0.1	0.6	1	1	1
11/12/2019 07:00	0.2	12.5	2,024.9	0.1	0.6	1	1	1
11/12/2019 08:00	0.2	12.5	2,015.0	0.1	0.6	1	1	1
11/12/2019 09:00	0.2	12.5	2,001.4	0.1	0.6	1	1	1
11/12/2019 10:00	0.2	12.4	2,020.6	0.1	0.6	1	1	1
11/12/2019 11:00	0.2	12.5	1,981.4	0.1	0.6	1	1	1
11/12/2019 12:00	0.2	12.5	1,969.4	0.1	0.6	1	1	1
11/12/2019 13:00	0.2	12.5	1,994.7	0.1	0.6	1	1	1
11/12/2019 14:00	0.3	12.5	1,989.9	0.1	0.9	1	1	1
11/12/2019 15:00	0.3	12.5	1,992.0	0.2	0.9	1	1	1
11/12/2019 16:00	0.3	12.5	1,980.7	0.2	0.9	1	1	1
11/12/2019 17:00	0.3	12.3	2,041.0	0.2	0.9	1	1	1
11/12/2019 18:00	0.3	12.3	2,029.8	0.2	0.9	1	1	1
11/12/2019 19:00	0.2	12.2	2,062.3	0.2	0.6	1	1	1
11/12/2019 20:00	0.2	12.2	2,057.9	0.1	0.6	1	1	1
11/12/2019 21:00	0.2	12.3	2,040.2	0.1	0.6	1	1	1
11/12/2019 22:00	0.2	12.3	2,037.2	0.1	0.6	1	1	1
11/12/2019 23:00	0.2	12.4	2,020.7	0.1	0.6	1	1	1
Average/Sum#:	0.2	12.4	2,022.0	0.1	16.3 #	24 #	24 #	24 #
Minimum:	0.2	12.2	1,969.4	0.1	0.6	1	1	1
Maximum:	0.3	12.6	2,062.3	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/13/2019 00:00	0.2	12.5	2,026.4	0.1	0.6	1	1	1
11/13/2019 01:00	0.2	12.6	1,991.8	0.1	0.6	1	1	1
11/13/2019 02:00	0.2	12.6	1,987.6	0.1	0.6	1	1	1
11/13/2019 03:00	0.2	12.6	1,988.9	0.1	0.6	1	1	1
11/13/2019 04:00	0.2	12.5	2,009.8	0.1	0.6	1	1	1
11/13/2019 05:00	0.2	12.5	2,016.5	0.1	0.6	1	1	1
11/13/2019 06:00	0.2	12.4	2,040.0	0.1	0.6	1	1	1
11/13/2019 07:00	0.2	12.5	2,024.1	0.1	0.6	1	1	1
11/13/2019 08:00	0.2	12.6	2,004.8	0.1	0.6	1	1	1
11/13/2019 09:00	0.2	12.6	1,992.6	0.1	0.6	1	1	1
11/13/2019 10:00	0.2	12.6	1,976.3	0.1	0.6	1	1	1
11/13/2019 11:00	0.2	12.5	1,992.8	0.1	0.6	1	1	1
11/13/2019 12:00	0.3	12.5	1,992.9	0.1	0.9	1	1	1
11/13/2019 13:00	0.2	12.4	2,009.8	0.1	0.6	1	1	1
11/13/2019 14:00	0.2	12.4	2,020.0	0.1	0.6	1	1	1
11/13/2019 15:00	0.2	12.4	2,018.6	0.1	0.6	1	1	1
11/13/2019 16:00	0.3	12.5	1,991.6	0.1	0.9	1	1	1
11/13/2019 17:00	0.2	12.1	2,088.6	0.1	0.6	1	1	1
11/13/2019 18:00	0.2	12.3	2,041.8	0.1	0.6	1	1	1
11/13/2019 19:00	0.2	12.5	2,011.3	0.1	0.6	1	1	1
11/13/2019 20:00	0.2	12.3	2,037.9	0.1	0.6	1	1	1
11/13/2019 21:00	0.2	12.4	2,026.2	0.1	0.6	1	1	1
11/13/2019 22:00	0.3	12.5	2,002.5	0.1	0.9	1	1	1
11/13/2019 23:00	0.2	12.4	2,039.3	0.1	0.6	1	1	1
Average/Sum#:	0.2	12.5	2,013.8	0.1	15.3 #	24 #	24 #	24 #
Minimum:	0.2	12.1	1,976.3	0.1	0.6	1	1	1
Maximum:	0.3	12.6	2,088.6	0.1	0.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/14/2019 00:00	0.2	12.3	2,064.1	0.1	0.6	1	1	1
11/14/2019 01:00	0.2	12.3	2,075.7	0.1	0.6	1	1	1
11/14/2019 02:00	0.2	12.3	2,069.7	0.1	0.6	1	1	1
11/14/2019 03:00	0.2	12.3	2,078.8	0.1	0.6	1	1	1
11/14/2019 04:00	0.2	12.3	2,076.2	0.1	0.6	1	1	1
11/14/2019 05:00	0.2	12.4	2,052.5	0.1	0.6	1	1	1
11/14/2019 06:00	0.2	12.3	2,081.6	0.1	0.6	1	1	1
11/14/2019 07:00	0.2	12.4	2,039.1	0.1	0.6	1	1	1
11/14/2019 08:00	0.2	12.6	1,990.0	0.1	0.6	1	1	1
11/14/2019 09:00	0.2	12.4	2,032.7	0.1	0.6	1	1	1
11/14/2019 10:00	0.2	12.2	2,049.5	0.1	0.6	1	1	1
11/14/2019 11:00	0.2	12.4	2,008.2	0.1	0.6	1	1	1
11/14/2019 12:00	0.2	12.2	2,065.2	0.1	0.6	1	1	1
11/14/2019 13:00	0.2	12.2	2,061.1	0.1	0.6	1	1	1
11/14/2019 14:00	0.2	12.2	2,058.5	0.1	0.6	1	1	1
11/14/2019 15:00	0.2	12.2	2,053.1	0.1	0.6	1	1	1
11/14/2019 16:00	0.3	12.3	2,033.8	0.1	0.9	1	1	1
11/14/2019 17:00	0.2	12.3	2,055.8	0.1	0.6	1	1	1
11/14/2019 18:00	0.2	12.3	2,054.3	0.1	0.6	1	1	1
11/14/2019 19:00	0.2	12.3	2,049.6	0.1	0.6	1	1	1
11/14/2019 20:00	0.2	12.3	2,059.3	0.1	0.6	1	1	1
11/14/2019 21:00	0.2	12.4	2,050.1	0.1	0.6	1	1	1
11/14/2019 22:00	0.2	12.4	2,034.6	0.1	0.6	1	1	1
11/14/2019 23:00	0.2	12.4	2,058.2	0.1	0.6	1	1	1
Average/Sum#:	0.2	12.3	2,052.2	0.1	14.7 #	24 #	24 #	24 #
Minimum:	0.2	12.2	1,990.0	0.1	0.6	1	1	1
Maximum:	0.3	12.6	2,081.6	0.1	0.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/15/2019 00:00	0.3	12.5	2,025.4	0.1	1.0	1	1	1
11/15/2019 01:00	0.3	12.7	1,998.4	0.2	1.0	1	1	1
11/15/2019 02:00	0.3	12.6	2,013.0	0.2	1.0	1	1	1
11/15/2019 03:00	0.3	12.7	1,979.8	0.2	1.0	1	1	1
11/15/2019 04:00	0.3	12.7	1,984.6	0.2	1.0	1	1	1
11/15/2019 05:00	0.3	12.7	1,976.6	0.2	1.0	1	1	1
11/15/2019 06:00	0.3	12.4	2,037.1	0.2	0.9	1	1	1
11/15/2019 07:00	0.2	12.4	2,053.1	0.2	0.6	1	1	1
11/15/2019 08:00	0.2	12.6	2,003.6	0.1	0.6	1	1	1
11/15/2019 09:00	0.2	12.6	1,996.2	0.1	0.6	1	1	1
11/15/2019 10:00	0.2	12.5	2,005.8	0.1	0.6	1	1	1
11/15/2019 11:00	0.2	13.0	1,908.7	0.1	0.6	1	1	1
11/15/2019 12:00	0.3	12.6	1,983.9	0.1	0.9	1	1	1
11/15/2019 13:00	0.3	12.4	2,027.7	0.2	0.9	1	1	1
11/15/2019 14:00	0.2	12.3	2,046.3	0.2	0.6	1	1	1
11/15/2019 15:00	0.2	12.4	2,028.1	0.1	0.6	1	1	1
11/15/2019 16:00	0.2	12.5	2,008.2	0.1	0.6	1	1	1
11/15/2019 17:00	0.2	12.3	2,055.0	0.1	0.6	1	1	1
11/15/2019 18:00	0.2	12.6	1,978.0	0.1	0.6	1	1	1
11/15/2019 19:00	0.2	12.5	2,008.4	0.1	0.6	1	1	1
11/15/2019 20:00	0.2	12.3	2,056.7	0.1	0.6	1	1	1
11/15/2019 21:00	0.3	12.5	2,007.5	0.1	0.9	1	1	1
11/15/2019 22:00	0.2	12.4	2,014.8	0.1	0.6	1	1	1
11/15/2019 23:00	0.2	12.6	1,983.8	0.1	0.6	1	1	1
Average/Sum#:	0.2	12.5	2,007.5	0.1	18.0 #	24 #	24 #	24 #
Minimum:	0.2	12.3	1,908.7	0.1	0.6	1	1	1
Maximum:	0.3	13.0	2,056.7	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/16/2019 00:00	0.2	12.7	1,976.3	0.1	0.6	1	1	1
11/16/2019 01:00	0.2	12.8	1,974.9	0.1	0.6	1	1	1
11/16/2019 02:00	0.2	12.6	1,982.3	0.1	0.6	1	1	1
11/16/2019 03:00	0.2	12.6	1,979.7	0.1	0.6	1	1	1
11/16/2019 04:00	0.2	12.7	1,974.2	0.1	0.6	1	1	1
11/16/2019 05:00	0.2	12.7	1,982.6	0.1	0.6	1	1	1
11/16/2019 06:00	0.2	12.6	1,986.4	0.1	0.6	1	1	1
11/16/2019 07:00	0.2	12.7	1,939.9	0.1	0.6	1	1	1
11/16/2019 08:00	0.0	13.9	1,578.0	0.1	0.0	1	1	0
11/16/2019 09:00	0.0	13.9	1,478.3	0.0	0.0	1	1	0
11/16/2019 10:00	0.0	13.9	1,503.1	0.0	0.0	1	1	0
11/16/2019 11:00	0.0	13.9	1,592.5	0.0	0.0	1	1	0
11/16/2019 12:00	0.0	13.9	1,558.3	0.0	0.0	1	1	0
11/16/2019 13:00	0.0	13.9	1,635.9	0.0	0.0	1	1	0
11/16/2019 14:00	0.0	13.9	1,611.3	0.0	0.0	1	1	0
11/16/2019 15:00	0.0	13.8	1,512.4	0.0	0.0	1	1	1
11/16/2019 16:00	0.3	12.6	1,964.3	0.1	0.9	1	1	1
11/16/2019 17:00	0.3	12.4	2,021.7	0.1	0.9	1	1	1
11/16/2019 18:00	0.3	12.5	2,004.2	0.2	0.9	1	1	1
11/16/2019 19:00	0.3	12.5	2,013.5	0.2	0.9	1	1	1
11/16/2019 20:00	0.3	12.5	2,017.4	0.2	1.0	1	1	1
11/16/2019 21:00	0.3	12.4	2,030.3	0.2	0.9	1	1	1
11/16/2019 22:00	0.3	12.6	2,020.5	0.2	1.0	1	1	1
11/16/2019 23:00	0.3	12.6	2,011.7	0.2	1.0	1	1	1
Average/Sum#:	0.2	13.0	1,847.9	0.1	12.3 #	24 #	24 #	17 #
Minimum:	0.0	12.4	1,478.3	0.0	0.0	1	1	0
Maximum:	0.3	13.9	2,030.3	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/17/2019 00:00	0.3	12.7	1,997.7	0.2	1.0	1	1	1
11/17/2019 01:00	0.3	12.7	2,002.5	0.2	1.0	1	1	1
11/17/2019 02:00	0.2	13.1	1,865.3	0.2	0.6	1	1	1
11/17/2019 03:00	0.0	13.9	1,526.2	0.1	0.0	1	1	0
11/17/2019 04:00	0.0	13.8	1,634.1	0.1	0.0	1	1	0
11/17/2019 05:00	0.0	13.9	1,497.3	0.0	0.0	1	1	0
11/17/2019 06:00	0.0	13.8	1,637.4	0.0	0.0	1	1	0
11/17/2019 07:00	0.0	13.8	1,593.7	0.0	0.0	1	1	0
11/17/2019 08:00	0.0	13.8	1,597.1	0.0	0.0	1	1	0
11/17/2019 09:00	0.0	13.9	1,604.2	0.0	0.0	1	1	0
11/17/2019 10:00	0.0	13.9	1,577.2	0.0	0.0	1	1	0
11/17/2019 11:00	0.0	13.9	1,629.2	0.0	0.0	1	1	0
11/17/2019 12:00	0.0	13.9	1,566.0	0.0	0.0	1	1	0
11/17/2019 13:00	0.0	13.9	1,609.8	0.0	0.0	1	1	0
11/17/2019 14:00	0.0	13.9	1,491.5	0.0	0.0	1	1	1
11/17/2019 15:00	0.3	12.7	1,939.7	0.1	0.9	1	1	1
11/17/2019 16:00	0.3	12.5	1,993.3	0.1	0.9	1	1	1
11/17/2019 17:00	0.3	12.5	1,985.2	0.2	0.9	1	1	1
11/17/2019 18:00	0.3	12.4	2,001.4	0.2	0.9	1	1	1
11/17/2019 19:00	0.3	12.4	2,023.4	0.2	0.9	1	1	1
11/17/2019 20:00	0.3	12.4	2,028.2	0.2	0.9	1	1	1
11/17/2019 21:00	0.3	12.4	2,030.2	0.2	0.9	1	1	1
11/17/2019 22:00	0.3	12.5	1,999.3	0.2	0.9	1	1	1
11/17/2019 23:00	0.3	12.7	1,985.5	0.2	1.0	1	1	1
Average/Sum#:	0.1	13.2	1,784.0	0.1	10.8 #	24 #	24 #	13 #
Minimum:	0.0	12.4	1,491.5	0.0	0.0	1	1	0
Maximum:	0.3	13.9	2,030.2	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/18/2019 00:00	0.2	12.6	1,991.3	0.2	0.6	1	1	1
11/18/2019 01:00	0.3	12.6	1,995.8	0.2	1.0	1	1	1
11/18/2019 02:00	0.2	12.6	1,996.8	0.1	0.6	1	1	1
11/18/2019 03:00	0.2	12.6	1,996.3	0.1	0.6	1	1	1
11/18/2019 04:00	0.3	12.7	1,987.6	0.1	1.0	1	1	1
11/18/2019 05:00	0.3	12.6	1,990.3	0.2	1.0	1	1	1
11/18/2019 06:00	0.2	12.3	2,049.0	0.2	0.6	1	1	1
11/18/2019 07:00	0.2	12.4	2,027.8	0.1	0.6	1	1	1
11/18/2019 08:00	0.2	12.7	1,982.5	0.1	0.6	1	1	1
11/18/2019 09:00	0.2	12.9	1,928.9	0.1	0.6	1	1	1
11/18/2019 10:00	0.3	12.5	2,005.4	0.1	0.9	1	1	1
11/18/2019 11:00	0.2	12.2	2,058.8	0.1	0.6	1	1	1
11/18/2019 12:00	0.3	12.3	2,019.8	0.2	0.9	1	1	1
11/18/2019 13:00	0.2	12.2	2,036.1	0.1	0.6	1	1	1
11/18/2019 14:00	0.2	12.3	2,022.9	0.1	0.6	1	1	1
11/18/2019 15:00	0.2	12.3	2,021.2	0.1	0.6	1	1	1
11/18/2019 16:00	0.2	12.1	2,066.6	0.1	0.6	1	1	1
11/18/2019 17:00	0.2	12.1	2,053.9	0.1	0.6	1	1	1
11/18/2019 18:00	0.1	12.0	2,095.8	0.1	0.3	1	1	1
11/18/2019 19:00	0.2	12.1	2,069.3	0.1	0.6	1	1	1
11/18/2019 20:00	0.2	12.1	2,065.0	0.1	0.6	1	1	1
11/18/2019 21:00	0.2	12.2	2,032.2	0.1	0.6	1	1	1
11/18/2019 22:00	0.2	12.3	2,031.7	0.1	0.6	1	1	1
11/18/2019 23:00	0.2	12.3	2,028.6	0.1	0.6	1	1	1
Average/Sum#:	0.2	12.4	2,023.1	0.1	15.9 #	24 #	24 #	24 #
Minimum:	0.1	12.0	1,928.9	0.1	0.3	1	1	1
Maximum:	0.3	12.9	2,095.8	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/19/2019 00:00	0.3	12.4	2,022.4	0.1	0.9	1	1	1
11/19/2019 01:00	0.3	12.5	1,986.1	0.2	0.9	1	1	1
11/19/2019 02:00	0.3	12.5	1,982.5	0.2	0.9	1	1	1
11/19/2019 03:00	0.3	12.6	1,980.0	0.2	0.9	1	1	1
11/19/2019 04:00	0.3	12.5	1,987.7	0.2	0.9	1	1	1
11/19/2019 05:00	0.2	12.5	2,000.9	0.2	0.6	1	1	1
11/19/2019 06:00	0.3	12.5	1,984.6	0.2	0.9	1	1	1
11/19/2019 07:00	0.2	12.4	2,002.8	0.1	0.6	1	1	1
11/19/2019 08:00	0.2	12.2	2,057.5	0.1	0.6	1	1	1
11/19/2019 09:00	0.2	12.3	2,031.5	0.1	0.6	1	1	1
11/19/2019 10:00	0.2	12.2	2,061.1	0.1	0.6	1	1	1
11/19/2019 11:00	0.2	12.3	2,033.7	0.1	0.6	1	1	1
11/19/2019 12:00	0.0	0.0	2,006.3	0.0	0.0	1	1	1
11/19/2019 13:00	0.0	0.0	1,995.5	0.0	0.0	1	1	1
11/19/2019 14:00	0.2	12.4	2,018.7	0.0	0.6	1	1	1
11/19/2019 15:00	0.3	12.5	1,988.2	0.0	0.9	1	1	1
11/19/2019 16:00	0.3	12.6	1,989.9	0.2	0.9	1	1	1
11/19/2019 17:00	0.2	12.1	2,081.8	0.2	0.6	1	1	1
11/19/2019 18:00	0.1	12.0	2,115.9	0.1	0.3	1	1	1
11/19/2019 19:00	0.2	12.4	2,031.5	0.1	0.6	1	1	1
11/19/2019 20:00	0.2	12.5	2,008.6	0.1	0.6	1	1	1
11/19/2019 21:00	0.2	12.5	2,023.9	0.1	0.6	1	1	1
11/19/2019 22:00	0.2	12.4	2,031.1	0.1	0.6	1	1	1
11/19/2019 23:00	0.2	12.4	2,036.0	0.1	0.6	1	1	1
Average/Sum#:	0.2	12.4	2,019.1	0.1	15.3 #	24 #	24 #	24 #
Minimum:	0.1	12.0	1,980.0	0.1	0.3	1	1	1
Maximum:	0.3	12.6	2,115.9	0.2	0.9	1	1	1
%SI	8.33	8.33	0.00	16.67	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/20/2019 00:00	0.3	12.5	2,007.7	0.1	0.9	1	1	1
11/20/2019 01:00	0.3	12.6	1,990.5	0.2	1.0	1	1	1
11/20/2019 02:00	0.3	12.7	1,970.0	0.2	1.0	1	1	1
11/20/2019 03:00	0.3	12.7	1,974.5	0.2	1.0	1	1	1
11/20/2019 04:00	0.3	12.7	1,991.9	0.2	1.0	1	1	1
11/20/2019 05:00	0.3	12.7	1,997.6	0.2	1.0	1	1	1
11/20/2019 06:00	0.2	12.3	2,049.5	0.2	0.6	1	1	1
11/20/2019 07:00	0.2	12.3	2,070.6	0.1	0.6	1	1	1
11/20/2019 08:00	0.0	0.0	2,059.3	0.0	0.0	1	1	1
11/20/2019 09:00	0.0	0.0	2,067.0	0.0	0.0	1	1	1
11/20/2019 10:00	0.0	0.0	2,064.4	0.0	0.0	1	1	1
11/20/2019 11:00	0.0	0.0	2,026.1	0.0	0.0	1	1	1
11/20/2019 12:00	0.0	0.0	2,027.0	0.0	0.0	1	1	1
11/20/2019 13:00	0.0	12.2	2,033.4	0.0	0.0	1	1	1
11/20/2019 14:00	0.0	12.2	2,049.6	0.0	0.0	1	1	1
11/20/2019 15:00	0.0	12.0	2,077.1	0.0	0.0	1	1	1
11/20/2019 16:00	0.0	12.3	2,016.6	0.0	0.0	1	1	1
11/20/2019 17:00	0.0	11.9	2,081.5	0.0	0.0	1	1	1
11/20/2019 18:00	0.0	11.9	2,091.6	0.0	0.0	1	1	1
11/20/2019 19:00	0.0	11.9	2,098.5	0.0	0.0	1	1	1
11/20/2019 20:00	0.0	12.0	2,068.0	0.0	0.0	1	1	1
11/20/2019 21:00	0.0	12.1	2,048.2	0.0	0.0	1	1	1
11/20/2019 22:00	0.0	12.3	2,013.9	0.0	0.0	1	1	1
11/20/2019 23:00	0.0	12.4	2,000.4	0.0	0.0	1	1	1
Average/Sum#:	0.1	12.3	2,036.5	0.1	7.1 #	24 #	24 #	24 #
Minimum:	0.0	11.9	1,970.0	0.0	0.0	1	1	1
Maximum:	0.3	12.7	2,098.5	0.2	1.0	1	1	1
%SI	20.83	20.83	0.00	29.17	20.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2019 00:00	0.0	12.2	2,026.6	0.0	0.0	1	1	1
11/21/2019 01:00	0.0	12.2	2,032.3	0.0	0.0	1	1	1
11/21/2019 02:00	0.0	12.3	2,020.5	0.0	0.0	1	1	1
11/21/2019 03:00	0.0	12.2	2,058.3	0.0	0.0	1	1	1
11/21/2019 04:00	0.0	12.1	2,076.7	0.0	0.0	1	1	1
11/21/2019 05:00	0.0	12.1	2,079.8	0.0	0.0	1	1	1
11/21/2019 06:00	0.0	11.9	2,125.4	0.0	0.0	1	1	1
11/21/2019 07:00	0.0	11.9	2,131.4	0.0	0.0	1	1	1
11/21/2019 08:00	0.0	12.2	2,067.9	0.0	0.0	1	1	1
11/21/2019 09:00	0.0	12.5	1,989.9	0.0	0.0	1	1	1
11/21/2019 10:00	0.0	12.4	2,021.5	0.0	0.0	1	1	1
11/21/2019 11:00	0.0	12.5	1,982.4	0.0	0.0	1	1	1
11/21/2019 12:00	0.0	12.3	2,016.8	0.0	0.0	1	1	1
11/21/2019 13:00	0.0	12.4	2,000.7	0.0	0.0	1	1	1
11/21/2019 14:00	0.0	12.5	1,986.6	0.0	0.0	1	1	1
11/21/2019 15:00	0.0	12.4	2,010.6	0.0	0.0	1	1	1
11/21/2019 16:00	0.0	12.0	2,089.2	0.0	0.0	1	1	1
11/21/2019 17:00	0.0	11.9	2,118.6	0.0	0.0	1	1	1
11/21/2019 18:00	0.0	11.8	2,138.0	0.0	0.0	1	1	1
11/21/2019 19:00	0.0	11.8	2,136.3	0.0	0.0	1	1	1
11/21/2019 20:00	0.0	11.8	2,131.9	0.0	0.0	1	1	1
11/21/2019 21:00	0.0	11.9	2,130.6	0.0	0.0	1	1	1
11/21/2019 22:00	0.0	12.0	2,107.5	0.0	0.0	1	1	1
11/21/2019 23:00	0.0	12.1	2,075.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.1	2,064.8	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.8	1,982.4	0.0	0.0	1	1	1
Maximum:	0.0	12.5	2,138.0	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2019 00:00	0.0	12.3	2,050.2	0.0	0.0	1	1	1
11/22/2019 01:00	0.0	12.3	2,047.5	0.0	0.0	1	1	1
11/22/2019 02:00	0.0	12.3	2,048.9	0.0	0.0	1	1	1
11/22/2019 03:00	0.0	12.3	2,045.4	0.0	0.0	1	1	1
11/22/2019 04:00	0.0	12.5	2,000.2	0.0	0.0	1	1	1
11/22/2019 05:00	0.0	12.6	1,978.8	0.0	0.0	1	1	1
11/22/2019 06:00	0.0	11.8	2,159.2	0.0	0.0	1	1	1
11/22/2019 07:00	0.0	11.9	2,140.6	0.0	0.0	1	1	1
11/22/2019 08:00	0.0	12.5	1,994.4	0.0	0.0	1	1	1
11/22/2019 09:00	0.0	12.7	1,969.3	0.0	0.0	1	1	1
11/22/2019 10:00	0.0	12.6	1,991.1	0.0	0.0	1	1	1
11/22/2019 11:00	0.0	12.6	1,967.4	0.0	0.0	1	1	1
11/22/2019 12:00	0.0	12.5	1,982.7	0.0	0.0	1	1	1
11/22/2019 13:00	0.0	12.5	1,976.9	0.0	0.0	1	1	1
11/22/2019 14:00	0.0	12.4	1,999.3	0.0	0.0	1	1	1
11/22/2019 15:00	0.0	12.4	2,002.4	0.0	0.0	1	1	1
11/22/2019 16:00	0.0	11.9	2,122.3	0.0	0.0	1	1	1
11/22/2019 17:00	0.0	11.9	2,121.6	0.0	0.0	1	1	1
11/22/2019 18:00	0.0	11.8	2,152.0	0.0	0.0	1	1	1
11/22/2019 19:00	0.0	11.9	2,123.5	0.0	0.0	1	1	1
11/22/2019 20:00	0.0	12.0	2,092.1	0.0	0.0	1	1	1
11/22/2019 21:00	0.0	11.9	2,111.6	0.0	0.0	1	1	1
11/22/2019 22:00	0.0	12.1	2,079.6	0.0	0.0	1	1	1
11/22/2019 23:00	0.0	12.3	2,042.0	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.3	2,050.0	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.8	1,967.4	0.0	0.0	1	1	1
Maximum:	0.0	12.7	2,159.2	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/23/2019 00:00	0.0	12.3	2,034.6	0.0	0.0	1	1	1
11/23/2019 01:00	0.0	12.2	2,054.2	0.0	0.0	1	1	1
11/23/2019 02:00	0.0	12.4	2,044.4	0.0	0.0	1	1	1
11/23/2019 03:00	0.0	12.5	2,008.2	0.0	0.0	1	1	1
11/23/2019 04:00	0.0	12.3	2,054.0	0.0	0.0	1	1	1
11/23/2019 05:00	0.0	12.2	2,064.0	0.0	0.0	1	1	1
11/23/2019 06:00	0.0	12.1	2,074.8	0.0	0.0	1	1	1
11/23/2019 07:00	0.0	12.3	2,035.1	0.0	0.0	1	1	1
11/23/2019 08:00	0.0	12.9	1,872.3	0.0	0.0	1	1	1
11/23/2019 09:00	0.0	13.7	1,622.6	0.0	0.0	1	1	0
11/23/2019 10:00	0.0	13.7	1,643.2	0.0	0.0	1	1	0
11/23/2019 11:00	0.0	13.7	1,609.5	0.0	0.0	1	1	0
11/23/2019 12:00	0.0	13.7	1,625.7	0.0	0.0	1	1	0
11/23/2019 13:00	0.0	13.7	1,643.6	0.0	0.0	1	1	0
11/23/2019 14:00	0.0	13.7	1,615.4	0.0	0.0	1	1	0
11/23/2019 15:00	0.0	13.2	1,783.2	0.0	0.0	1	1	1
11/23/2019 16:00	0.0	12.2	2,049.5	0.0	0.0	1	1	1
11/23/2019 17:00	0.0	12.1	2,076.9	0.0	0.0	1	1	1
11/23/2019 18:00	0.0	12.1	2,074.6	0.0	0.0	1	1	1
11/23/2019 19:00	0.0	11.9	2,119.4	0.0	0.0	1	1	1
11/23/2019 20:00	0.0	12.0	2,112.1	0.0	0.0	1	1	1
11/23/2019 21:00	0.0	12.3	2,062.6	0.0	0.0	1	1	1
11/23/2019 22:00	0.0	12.4	2,027.2	0.0	0.0	1	1	1
11/23/2019 23:00	0.0	12.5	1,983.9	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.7	1,928.8	0.0	0.0 #	24 #	24 #	18 #
Minimum:	0.0	11.9	1,609.5	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,119.4	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/24/2019 00:00	0.0	12.5	1,978.6	0.0	0.0	1	1	1
11/24/2019 01:00	0.0	12.5	1,977.4	0.0	0.0	1	1	1
11/24/2019 02:00	0.0	12.7	1,962.7	0.0	0.0	1	1	1
11/24/2019 03:00	0.0	12.7	1,963.0	0.0	0.0	1	1	1
11/24/2019 04:00	0.0	12.7	1,975.2	0.0	0.0	1	1	1
11/24/2019 05:00	0.0	12.7	1,972.3	0.0	0.0	1	1	1
11/24/2019 06:00	0.0	12.4	2,031.0	0.0	0.0	1	1	1
11/24/2019 07:00	0.0	12.5	1,974.0	0.0	0.0	1	1	1
11/24/2019 08:00	0.0	13.7	1,608.6	0.0	0.0	1	1	0
11/24/2019 09:00	0.0	13.7	1,601.0	0.0	0.0	1	1	0
11/24/2019 10:00	0.0	13.7	1,629.0	0.0	0.0	1	1	0
11/24/2019 11:00	0.0	13.7	1,622.2	0.0	0.0	1	1	0
11/24/2019 12:00	0.0	13.7	1,652.1	0.0	0.0	1	1	0
11/24/2019 13:00	0.0	13.7	1,633.4	0.0	0.0	1	1	0
11/24/2019 14:00	0.0	13.7	1,589.8	0.0	0.0	1	1	0
11/24/2019 15:00	0.0	13.2	1,784.6	0.0	0.0	1	1	1
11/24/2019 16:00	0.0	12.4	2,001.2	0.0	0.0	1	1	1
11/24/2019 17:00	0.0	12.2	2,057.6	0.0	0.0	1	1	1
11/24/2019 18:00	0.0	12.5	1,975.5	0.0	0.0	1	1	1
11/24/2019 19:00	0.0	12.8	1,927.3	0.0	0.0	1	1	1
11/24/2019 20:00	0.0	12.5	1,977.5	0.0	0.0	1	1	1
11/24/2019 21:00	0.0	12.3	2,021.5	0.0	0.0	1	1	1
11/24/2019 22:00	0.0	12.6	1,963.1	0.0	0.0	1	1	1
11/24/2019 23:00	0.0	13.2	1,764.4	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.9	1,860.1	0.0	0.0 #	24 #	24 #	17 #
Minimum:	0.0	12.2	1,589.8	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,057.6	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/25/2019 00:00	0.0	13.7	1,304.8	0.0	0.0	1	1	0
11/25/2019 01:00	0.0	13.7	1,485.0	0.0	0.0	1	1	0
11/25/2019 02:00	0.0	13.7	1,316.9	0.0	0.0	1	1	0
11/25/2019 03:00	0.0	13.7	1,357.5	0.0	0.0	1	1	0
11/25/2019 04:00	0.0	13.6	1,649.2	0.0	0.0	1	1	0
11/25/2019 05:00	0.0	13.7	1,498.7	0.0	0.0	1	1	0
11/25/2019 06:00	0.0	13.7	1,335.5	0.0	0.0	1	1	0
11/25/2019 07:00	0.0	13.7	1,573.6	0.0	0.0	1	1	0
11/25/2019 08:00	0.0	13.7	1,619.0	0.0	0.0	1	1	0
11/25/2019 09:00	0.0	13.7	1,583.5	0.0	0.0	1	1	0
11/25/2019 10:00	0.0	13.7	1,606.2	0.0	0.0	1	1	0
11/25/2019 11:00	0.0	13.7	1,648.6	0.0	0.0	1	1	0
11/25/2019 12:00	0.0	13.7	1,639.2	0.0	0.0	1	1	0
11/25/2019 13:00	0.0	13.7	1,632.2	0.0	0.0	1	1	0
11/25/2019 14:00	0.0	13.7	1,624.4	0.0	0.0	1	1	0
11/25/2019 15:00	0.0	13.7	1,542.8	0.0	0.0	1	1	1
11/25/2019 16:00	0.0	12.6	1,979.9	0.0	0.0	1	1	1
11/25/2019 17:00	0.0	12.0	2,097.6	0.0	0.0	1	1	1
11/25/2019 18:00	0.0	12.4	2,016.7	0.0	0.0	1	1	1
11/25/2019 19:00	0.0	12.2	2,065.7	0.0	0.0	1	1	1
11/25/2019 20:00	0.0	12.2	2,069.5	0.0	0.0	1	1	1
11/25/2019 21:00	0.0	12.3	2,038.6	0.0	0.0	1	1	1
11/25/2019 22:00	0.0	12.5	2,008.3	0.0	0.0	1	1	1
11/25/2019 23:00	0.0	12.6	1,990.0	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.2	1,695.1	0.0	0.0 #	24 #	24 #	9 #
Minimum:	0.0	12.0	1,304.8	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,097.6	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/26/2019 00:00	0.0	12.5	2,016.3	0.0	0.0	1	1	1
11/26/2019 01:00	0.0	12.4	2,036.2	0.0	0.0	1	1	1
11/26/2019 02:00	0.0	12.6	1,973.0	0.0	0.0	1	1	1
11/26/2019 03:00	0.0	12.6	1,971.7	0.0	0.0	1	1	1
11/26/2019 04:00	0.0	12.7	1,958.4	0.0	0.0	1	1	1
11/26/2019 05:00	0.0	12.9	1,909.7	0.0	0.0	1	1	1
11/26/2019 06:00	0.0	12.1	2,082.1	0.0	0.0	1	1	1
11/26/2019 07:00	0.0	12.7	1,878.7	0.0	0.0	1	1	1
11/26/2019 08:00	0.0	13.7	1,611.2	0.0	0.0	1	1	0
11/26/2019 09:00	0.0	13.7	1,636.2	0.0	0.0	1	1	0
11/26/2019 10:00	0.0	13.7	1,517.9	0.0	0.0	1	1	0
11/26/2019 11:00	0.0	13.7	1,574.2	0.0	0.0	1	1	0
11/26/2019 12:00	0.0	13.7	1,548.6	0.0	0.0	1	1	0
11/26/2019 13:00	0.0	13.6	1,583.8	0.0	0.0	1	1	0
11/26/2019 14:00	0.0	13.5	1,735.5	0.0	0.0	1	1	1
11/26/2019 15:00	0.0	13.5	1,761.0	0.0	0.0	1	1	0
11/26/2019 16:00	0.0	12.9	1,869.1	0.0	0.0	1	1	1
11/26/2019 17:00	0.0	12.3	2,024.0	0.0	0.0	1	1	1
11/26/2019 18:00	0.0	12.4	1,997.1	0.0	0.0	1	1	1
11/26/2019 19:00	0.0	12.4	2,012.3	0.0	0.0	1	1	1
11/26/2019 20:00	0.0	12.2	2,046.0	0.0	0.0	1	1	1
11/26/2019 21:00	0.0	12.2	2,018.5	0.0	0.0	1	1	1
11/26/2019 22:00	0.0	12.3	2,001.7	0.0	0.0	1	1	1
11/26/2019 23:00	0.0	12.3	2,011.4	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.9	1,865.6	0.0	0.0 #	24 #	24 #	17 #
Minimum:	0.0	12.1	1,517.9	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,082.1	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/27/2019 00:00	0.0	12.2	2,019.8	0.0	0.0	1	1	1
11/27/2019 01:00	0.0	12.3	1,996.2	0.0	0.0	1	1	1
11/27/2019 02:00	0.0	12.5	1,962.6	0.0	0.0	1	1	1
11/27/2019 03:00	0.0	12.5	1,960.1	0.0	0.0	1	1	1
11/27/2019 04:00	0.0	12.5	1,969.8	0.0	0.0	1	1	1
11/27/2019 05:00	0.0	12.4	1,978.9	0.0	0.0	1	1	1
11/27/2019 06:00	0.0	12.7	1,933.2	0.0	0.0	1	1	1
11/27/2019 07:00	0.0	12.1	2,066.8	0.0	0.0	1	1	1
11/27/2019 08:00	0.0	12.1	2,059.9	0.0	0.0	1	1	1
11/27/2019 09:00	0.0	12.1	2,043.2	0.0	0.0	1	1	1
11/27/2019 10:00	0.0	12.2	2,030.0	0.0	0.0	1	1	1
11/27/2019 11:00	0.0	12.4	1,986.9	0.0	0.0	1	1	1
11/27/2019 12:00	0.0	12.2	2,011.8	0.0	0.0	1	1	1
11/27/2019 13:00	0.0	12.0	2,059.1	0.0	0.0	1	1	1
11/27/2019 14:00	0.0	12.0	2,050.1	0.0	0.0	1	1	1
11/27/2019 15:00	0.0	12.3	1,992.0	0.0	0.0	1	1	1
11/27/2019 16:00	0.0	12.5	1,963.7	0.0	0.0	1	1	1
11/27/2019 17:00	0.0	12.1	2,048.8	0.0	0.0	1	1	1
11/27/2019 18:00	0.0	12.8	1,901.0	0.0	0.0	1	1	1
11/27/2019 19:00	0.0	12.8	1,914.8	0.0	0.0	1	1	1
11/27/2019 20:00	0.0	12.1	2,084.1	0.0	0.0	1	1	1
11/27/2019 21:00	0.0	12.0	2,104.0	0.0	0.0	1	1	1
11/27/2019 22:00	0.0	12.2	2,053.0	0.0	0.0	1	1	1
11/27/2019 23:00	0.0	12.3	2,036.5	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.3	2,009.4	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.0	1,901.0	0.0	0.0	1	1	1
Maximum:	0.0	12.8	2,104.0	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2019 00:00	0.0	12.3	2,038.9	0.0	0.0	1	1	1
11/28/2019 01:00	0.0	12.4	2,022.1	0.0	0.0	1	1	1
11/28/2019 02:00	0.0	12.5	2,008.9	0.0	0.0	1	1	1
11/28/2019 03:00	0.0	12.3	2,039.7	0.0	0.0	1	1	1
11/28/2019 04:00	0.0	12.5	2,012.2	0.0	0.0	1	1	1
11/28/2019 05:00	0.0	12.7	1,937.8	0.0	0.0	1	1	1
11/28/2019 06:00	0.0	12.1	2,050.0	0.0	0.0	1	1	1
11/28/2019 07:00	0.0	12.2	2,052.7	0.0	0.0	1	1	1
11/28/2019 08:00	0.0	12.2	2,052.8	0.0	0.0	1	1	1
11/28/2019 09:00	0.0	12.2	2,039.9	0.0	0.0	1	1	1
11/28/2019 10:00	0.0	12.2	2,040.4	0.0	0.0	1	1	1
11/28/2019 11:00	0.0	12.2	2,042.1	0.0	0.0	1	1	1
11/28/2019 12:00	0.0	12.2	2,038.5	0.0	0.0	1	1	1
11/28/2019 13:00	0.0	12.2	2,027.9	0.0	0.0	1	1	1
11/28/2019 14:00	0.0	12.2	2,021.9	0.0	0.0	1	1	1
11/28/2019 15:00	0.0	12.2	2,027.9	0.0	0.0	1	1	1
11/28/2019 16:00	0.0	12.3	2,012.3	0.0	0.0	1	1	1
11/28/2019 17:00	0.0	12.3	2,012.4	0.0	0.0	1	1	1
11/28/2019 18:00	0.0	12.6	1,953.4	0.0	0.0	1	1	1
11/28/2019 19:00	0.0	12.3	2,006.6	0.0	0.0	1	1	1
11/28/2019 20:00	0.0	12.2	2,021.1	0.0	0.0	1	1	1
11/28/2019 21:00	0.0	12.3	2,021.6	0.0	0.0	1	1	1
11/28/2019 22:00	0.0	12.2	2,018.6	0.0	0.0	1	1	1
11/28/2019 23:00	0.0	12.2	2,030.4	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.3	2,022.1	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.1	1,937.8	0.0	0.0	1	1	1
Maximum:	0.0	12.7	2,052.8	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/29/2019 00:00	0.0	12.2	2,032.4	0.0	0.0	1	1	1
11/29/2019 01:00	0.0	12.3	2,020.3	0.0	0.0	1	1	1
11/29/2019 02:00	0.0	12.3	2,023.9	0.0	0.0	1	1	1
11/29/2019 03:00	0.0	12.3	2,019.4	0.0	0.0	1	1	1
11/29/2019 04:00	0.0	12.3	2,031.1	0.0	0.0	1	1	1
11/29/2019 05:00	0.0	12.4	2,013.8	0.0	0.0	1	1	1
11/29/2019 06:00	0.0	12.2	2,041.3	0.0	0.0	1	1	1
11/29/2019 07:00	0.0	12.4	1,963.0	0.0	0.0	1	1	1
11/29/2019 08:00	0.0	13.7	1,524.6	0.0	0.0	1	1	0
11/29/2019 09:00	0.0	13.7	1,406.3	0.0	0.0	1	1	0
11/29/2019 10:00	0.0	13.6	1,561.0	0.0	0.0	1	1	0
11/29/2019 11:00	0.0	13.6	1,564.8	0.0	0.0	1	1	0
11/29/2019 12:00	0.0	13.7	1,519.7	0.0	0.0	1	1	0
11/29/2019 13:00	0.0	13.7	1,517.4	0.0	0.0	1	1	0
11/29/2019 14:00	0.0	13.7	1,427.4	0.0	0.0	1	1	0
11/29/2019 15:00	0.0	13.6	1,546.9	0.0	0.0	1	1	1
11/29/2019 16:00	0.0	12.7	1,962.0	0.0	0.0	1	1	1
11/29/2019 17:00	0.0	12.0	2,122.2	0.0	0.0	1	1	1
11/29/2019 18:00	0.0	11.9	2,130.1	0.0	0.0	1	1	1
11/29/2019 19:00	0.0	12.0	2,114.4	0.0	0.0	1	1	1
11/29/2019 20:00	0.0	12.0	2,121.2	0.0	0.0	1	1	1
11/29/2019 21:00	0.0	12.3	2,040.7	0.0	0.0	1	1	1
11/29/2019 22:00	0.0	12.4	2,052.1	0.0	0.0	1	1	1
11/29/2019 23:00	0.0	12.4	2,046.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.7	1,866.8	0.0	0.0 #	24 #	24 #	17 #
Minimum:	0.0	11.9	1,406.3	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,130.1	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/30/2019 00:00	0.0	12.4	2,040.5	0.0	0.0	1	1	1
11/30/2019 01:00	0.0	12.5	2,036.7	0.0	0.0	1	1	1
11/30/2019 02:00	0.0	12.4	2,046.9	0.0	0.0	1	1	1
11/30/2019 03:00	0.0	12.4	2,047.2	0.0	0.0	1	1	1
11/30/2019 04:00	0.0	12.4	2,035.1	0.0	0.0	1	1	1
11/30/2019 05:00	0.0	12.5	2,017.7	0.0	0.0	1	1	1
11/30/2019 06:00	0.0	12.4	2,048.1	0.0	0.0	1	1	1
11/30/2019 07:00	0.0	12.5	2,021.9	0.0	0.0	1	1	1
11/30/2019 08:00	0.0	12.4	2,040.7	0.0	0.0	1	1	1
11/30/2019 09:00	0.0	12.3	2,058.6	0.0	0.0	1	1	1
11/30/2019 10:00	0.0	12.4	2,034.8	0.0	0.0	1	1	1
11/30/2019 11:00	0.0	12.6	1,990.1	0.0	0.0	1	1	1
11/30/2019 12:00	0.0	12.3	2,048.5	0.0	0.0	1	1	1
11/30/2019 13:00	0.0	12.3	2,045.1	0.0	0.0	1	1	1
11/30/2019 14:00	0.0	12.3	2,046.3	0.0	0.0	1	1	1
11/30/2019 15:00	0.0	12.4	2,030.8	0.0	0.0	1	1	1
11/30/2019 16:00	0.0	12.4	2,029.2	0.0	0.0	1	1	1
11/30/2019 17:00	0.0	12.4	2,041.8	0.0	0.0	1	1	1
11/30/2019 18:00	0.0	12.5	2,019.4	0.0	0.0	1	1	1
11/30/2019 19:00	0.0	12.2	2,080.7	0.0	0.0	1	1	1
11/30/2019 20:00	0.0	12.3	2,049.5	0.0	0.0	1	1	1
11/30/2019 21:00	0.0	12.4	2,031.5	0.0	0.0	1	1	1
11/30/2019 22:00	0.0	12.6	1,992.3	0.0	0.0	1	1	1
11/30/2019 23:00	0.0	12.7	1,977.5	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.4	2,033.8	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.2	1,977.5	0.0	0.0	1	1	1
Maximum:	0.0	12.7	2,080.7	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2019 00:00	0.0	12.5	2,016.3	0.0	0.0	1	1	1
12/01/2019 01:00	0.0	12.7	1,976.4	0.0	0.0	1	1	1
12/01/2019 02:00	0.0	12.7	1,975.5	0.0	0.0	1	1	1
12/01/2019 03:00	0.0	12.7	1,975.5	0.0	0.0	1	1	1
12/01/2019 04:00	0.0	12.7	1,972.0	0.0	0.0	1	1	1
12/01/2019 05:00	0.0	12.7	1,972.7	0.0	0.0	1	1	1
12/01/2019 06:00	0.0	12.7	1,966.1	0.0	0.0	1	1	1
12/01/2019 07:00	0.0	12.7	1,972.7	0.0	0.0	1	1	1
12/01/2019 08:00	0.0	12.4	2,047.7	0.0	0.0	1	1	1
12/01/2019 09:00	0.0	12.4	2,045.3	0.0	0.0	1	1	1
12/01/2019 10:00	0.0	12.3	2,051.7	0.0	0.0	1	1	1
12/01/2019 11:00	0.0	12.4	2,035.6	0.0	0.0	1	1	1
12/01/2019 12:00	0.0	12.6	1,974.9	0.0	0.0	1	1	1
12/01/2019 13:00	0.0	12.5	1,995.0	0.0	0.0	1	1	1
12/01/2019 14:00	0.0	12.6	1,985.4	0.0	0.0	1	1	1
12/01/2019 15:00	0.0	12.5	1,993.2	0.0	0.0	1	1	1
12/01/2019 16:00	0.0	12.5	1,994.8	0.0	0.0	1	1	1
12/01/2019 17:00	0.0	12.3	2,038.8	0.0	0.0	1	1	1
12/01/2019 18:00	0.0	12.1	2,083.3	0.0	0.0	1	1	1
12/01/2019 19:00	0.0	12.0	2,107.4	0.0	0.0	1	1	1
12/01/2019 20:00	0.0	12.1	2,074.2	0.0	0.0	1	1	1
12/01/2019 21:00	0.0	12.4	2,015.4	0.0	0.0	1	1	1
12/01/2019 22:00	0.0	12.5	1,989.9	0.0	0.0	1	1	1
12/01/2019 23:00	0.0	12.5	1,983.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.5	2,010.1	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.0	1,966.1	0.0	0.0	1	1	1
Maximum:	0.0	12.7	2,107.4	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/02/2019 00:00	0.0	12.6	1,970.3	0.0	0.0	1	1	1
12/02/2019 01:00	0.0	12.6	1,972.6	0.0	0.0	1	1	1
12/02/2019 02:00	0.0	12.6	1,973.4	0.0	0.0	1	1	1
12/02/2019 03:00	0.0	12.6	1,969.1	0.0	0.0	1	1	1
12/02/2019 04:00	0.0	12.6	1,965.0	0.0	0.0	1	1	1
12/02/2019 05:00	0.0	12.6	1,968.2	0.0	0.0	1	1	1
12/02/2019 06:00	0.0	12.0	2,062.3	0.0	0.0	1	1	1
12/02/2019 07:00	0.0	11.9	2,110.4	0.0	0.0	1	1	1
12/02/2019 08:00	0.0	12.4	2,004.4	0.0	0.0	1	1	1
12/02/2019 09:00	0.0	12.6	1,968.2	0.0	0.0	1	1	1
12/02/2019 10:00	0.0	12.5	1,987.2	0.0	0.0	1	1	1
12/02/2019 11:00	0.0	12.5	1,981.7	0.0	0.0	1	1	1
12/02/2019 12:00	0.0	12.3	2,038.9	0.0	0.0	1	1	1
12/02/2019 13:00	0.0	12.4	2,003.8	0.0	0.0	1	1	1
12/02/2019 14:00	0.0	12.2	2,048.6	0.0	0.0	1	1	1
12/02/2019 15:00	0.0	12.2	2,033.3	0.0	0.0	1	1	1
12/02/2019 16:00	0.0	12.0	2,076.7	0.0	0.0	1	1	1
12/02/2019 17:00	0.0	11.9	2,116.6	0.0	0.0	1	1	1
12/02/2019 18:00	0.0	11.8	2,122.2	0.0	0.0	1	1	1
12/02/2019 19:00	0.0	11.8	2,122.9	0.0	0.0	1	1	1
12/02/2019 20:00	0.0	11.8	2,121.1	0.0	0.0	1	1	1
12/02/2019 21:00	0.0	11.9	2,104.6	0.0	0.0	1	1	1
12/02/2019 22:00	0.0	12.3	2,029.3	0.0	0.0	1	1	1
12/02/2019 23:00	0.0	12.3	2,018.3	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.3	2,032.0	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.8	1,965.0	0.0	0.0	1	1	1
Maximum:	0.0	12.6	2,122.9	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/03/2019 00:00	0.0	12.3	2,025.1	0.0	0.0	1	1	1
12/03/2019 01:00	0.0	12.5	1,981.0	0.0	0.0	1	1	1
12/03/2019 02:00	0.0	12.5	1,975.1	0.0	0.0	1	1	1
12/03/2019 03:00	0.0	12.4	1,980.6	0.0	0.0	1	1	1
12/03/2019 04:00	0.0	12.3	2,001.9	0.0	0.0	1	1	1
12/03/2019 05:00	0.0	12.3	2,009.2	0.0	0.0	1	1	1
12/03/2019 06:00	0.0	12.1	2,033.8	0.0	0.0	1	1	1
12/03/2019 07:00	0.0	12.0	2,076.0	0.0	0.0	1	1	1
12/03/2019 08:00	0.0	12.0	2,068.1	0.0	0.0	1	1	1
12/03/2019 09:00	0.0	12.1	2,040.2	0.0	0.0	1	1	1
12/03/2019 10:00	0.0	12.3	1,993.7	0.0	0.0	1	1	1
12/03/2019 11:00	0.0	12.0	2,042.8	0.0	0.0	1	1	1
12/03/2019 12:00	0.0	11.9	2,069.1	0.0	0.0	1	1	1
12/03/2019 13:00	0.0	11.8	2,084.2	0.0	0.0	1	1	1
12/03/2019 14:00	0.0	11.8	2,079.5	0.0	0.0	1	1	1
12/03/2019 15:00	0.0	11.8	2,071.4	0.0	0.0	1	1	1
12/03/2019 16:00	0.0	12.0	2,050.1	0.0	0.0	1	1	1
12/03/2019 17:00	0.0	11.9	2,070.8	0.0	0.0	1	1	1
12/03/2019 18:00	0.0	12.0	2,067.0	0.0	0.0	1	1	1
12/03/2019 19:00	0.0	11.8	2,100.9	0.0	0.0	1	1	1
12/03/2019 20:00	0.0	11.8	2,093.2	0.0	0.0	1	1	1
12/03/2019 21:00	0.0	11.9	2,084.5	0.0	0.0	1	1	1
12/03/2019 22:00	0.0	12.1	2,037.3	0.0	0.0	1	1	1
12/03/2019 23:00	0.0	12.2	2,021.2	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.1	2,044.0	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.8	1,975.1	0.0	0.0	1	1	1
Maximum:	0.0	12.5	2,100.9	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/04/2019 00:00	0.0	12.1	2,057.8	0.0	0.0	1	1	1
12/04/2019 01:00	0.0	12.2	2,039.3	0.0	0.0	1	1	1
12/04/2019 02:00	0.0	12.3	1,998.7	0.0	0.0	1	1	1
12/04/2019 03:00	0.0	12.3	2,007.1	0.0	0.0	1	1	1
12/04/2019 04:00	0.0	12.2	2,038.2	0.0	0.0	1	1	1
12/04/2019 05:00	0.0	12.4	1,991.7	0.0	0.0	1	1	1
12/04/2019 06:00	0.0	12.1	2,037.3	0.0	0.0	1	1	1
12/04/2019 07:00	0.0	12.0	2,079.0	0.0	0.0	1	1	1
12/04/2019 08:00	0.0	12.0	2,072.6	0.0	0.0	1	1	1
12/04/2019 09:00	0.0	12.0	2,075.4	0.0	0.0	1	1	1
12/04/2019 10:00	0.0	12.1	2,062.2	0.0	0.0	1	1	1
12/04/2019 11:00	0.0	11.9	2,095.5	0.0	0.0	1	1	1
12/04/2019 12:00	0.0	12.0	2,068.7	0.0	0.0	1	1	1
12/04/2019 13:00	0.0	12.1	2,043.9	0.0	0.0	1	1	1
12/04/2019 14:00	0.0	11.9	2,098.0	0.0	0.0	1	1	1
12/04/2019 15:00	0.0	12.0	2,070.8	0.0	0.0	1	1	1
12/04/2019 16:00	0.0	12.0	2,069.7	0.0	0.0	1	1	1
12/04/2019 17:00	0.0	12.1	2,049.6	0.0	0.0	1	1	1
12/04/2019 18:00	0.0	11.9	2,103.9	0.0	0.0	1	1	1
12/04/2019 19:00	0.0	11.9	2,102.3	0.0	0.0	1	1	1
12/04/2019 20:00	0.0	11.8	2,105.4	0.0	0.0	1	1	1
12/04/2019 21:00	0.0	11.9	2,096.4	0.0	0.0	1	1	1
12/04/2019 22:00	0.0	12.0	2,070.4	0.0	0.0	1	1	1
12/04/2019 23:00	0.0	12.2	2,034.4	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.1	2,061.2	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.8	1,991.7	0.0	0.0	1	1	1
Maximum:	0.0	12.4	2,105.4	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/05/2019 00:00	0.0	12.1	2,047.9	0.0	0.0	1	1	1
12/05/2019 01:00	0.0	12.1	2,050.8	0.0	0.0	1	1	1
12/05/2019 02:00	0.0	12.2	2,046.3	0.0	0.0	1	1	1
12/05/2019 03:00	0.0	12.2	2,046.8	0.0	0.0	1	1	1
12/05/2019 04:00	0.0	12.3	2,019.9	0.0	0.0	1	1	1
12/05/2019 05:00	0.0	12.3	2,009.1	0.0	0.0	1	1	1
12/05/2019 06:00	0.0	12.2	2,039.4	0.0	0.0	1	1	1
12/05/2019 07:00	0.0	12.3	2,014.0	0.0	0.0	1	1	1
12/05/2019 08:00	0.0	12.5	1,968.7	0.0	0.0	1	1	1
12/05/2019 09:00	0.0	12.4	1,980.4	0.0	0.0	1	1	1
12/05/2019 10:00	0.0	12.4	2,032.8	0.0	0.0	1	1	1
12/05/2019 11:00	0.0	12.4	2,037.0	0.0	0.0	1	1	1
12/05/2019 12:00	0.0	12.4	2,047.7	0.0	0.0	1	1	1
12/05/2019 13:00	0.0	12.4	2,044.3	0.0	0.0	1	1	1
12/05/2019 14:00	0.0	12.4	2,038.3	0.0	0.0	1	1	1
12/05/2019 15:00	0.0	12.4	2,040.1	0.0	0.0	1	1	1
12/05/2019 16:00	0.0	12.4	2,036.9	0.0	0.0	1	1	1
12/05/2019 17:00	0.0	12.4	2,030.5	0.0	0.0	1	1	1
12/05/2019 18:00	0.0	12.4	2,034.9	0.0	0.0	1	1	1
12/05/2019 19:00	0.0	12.4	2,038.0	0.0	0.0	1	1	1
12/05/2019 20:00	0.0	12.3	2,046.8	0.0	0.0	1	1	1
12/05/2019 21:00	0.0	12.4	2,041.3	0.0	0.0	1	1	1
12/05/2019 22:00	0.0	12.4	2,030.8	0.0	0.0	1	1	1
12/05/2019 23:00	0.0	12.5	2,022.2	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.3	2,031.0	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.1	1,968.7	0.0	0.0	1	1	1
Maximum:	0.0	12.5	2,050.8	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/06/2019 00:00	0.0	12.5	2,018.3	0.0	0.0	1	1	1
12/06/2019 01:00	0.0	12.5	2,009.8	0.0	0.0	1	1	1
12/06/2019 02:00	0.0	12.5	2,003.4	0.0	0.0	1	1	1
12/06/2019 03:00	0.0	12.5	2,021.2	0.0	0.0	1	1	1
12/06/2019 04:00	0.0	12.4	2,044.9	0.0	0.0	1	1	1
12/06/2019 05:00	0.0	12.4	2,041.5	0.0	0.0	1	1	1
12/06/2019 06:00	0.0	12.3	2,061.6	0.0	0.0	1	1	1
12/06/2019 07:00	0.0	12.3	2,055.8	0.0	0.0	1	1	1
12/06/2019 08:00	0.0	12.4	2,039.6	0.0	0.0	1	1	1
12/06/2019 09:00	0.0	12.4	2,032.1	0.0	0.0	1	1	1
12/06/2019 10:00	0.0	12.4	2,035.8	0.0	0.0	1	1	1
12/06/2019 11:00	0.0	12.4	2,020.2	0.0	0.0	1	1	1
12/06/2019 12:00	0.0	12.5	2,003.5	0.0	0.0	1	1	1
12/06/2019 13:00	0.0	12.5	1,987.9	0.0	0.0	1	1	1
12/06/2019 14:00	0.0	12.6	1,975.4	0.0	0.0	1	1	1
12/06/2019 15:00	0.0	12.6	1,974.0	0.0	0.0	1	1	1
12/06/2019 16:00	0.0	12.6	1,975.7	0.0	0.0	1	1	1
12/06/2019 17:00	0.0	12.6	1,974.1	0.0	0.0	1	1	1
12/06/2019 18:00	0.0	12.6	1,974.2	0.0	0.0	1	1	1
12/06/2019 19:00	0.0	12.6	1,973.5	0.0	0.0	1	1	1
12/06/2019 20:00	0.0	12.6	1,974.5	0.0	0.0	1	1	1
12/06/2019 21:00	0.0	12.7	1,949.6	0.0	0.0	1	1	1
12/06/2019 22:00	0.7	13.1	1,867.6	0.2	2.2	1	1	1
12/06/2019 23:00	1.7	13.2	1,853.6	0.6	5.4	1	1	1
Average/Sum#:	0.1	12.6	1,994.5	0.0	7.6 #	24 #	24 #	24 #
Minimum:	0.0	12.3	1,853.6	0.0	0.0	1	1	1
Maximum:	1.7	13.2	2,061.6	0.6	5.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/07/2019 00:00	1.6	12.9	1,911.3	1.0	5.0	1	1	1
12/07/2019 01:00	0.0	12.2	2,073.4	0.8	0.0	1	1	1
12/07/2019 02:00	0.0	12.3	2,048.3	0.4	0.0	1	1	1
12/07/2019 03:00	0.0	12.3	2,049.9	0.0	0.0	1	1	1
12/07/2019 04:00	0.0	12.3	2,050.6	0.0	0.0	1	1	1
12/07/2019 05:00	0.0	12.3	2,043.9	0.0	0.0	1	1	1
12/07/2019 06:00	0.0	12.3	2,047.8	0.0	0.0	1	1	1
12/07/2019 07:00	0.0	12.2	2,052.8	0.0	0.0	1	1	1
12/07/2019 08:00	0.0	12.1	2,077.9	0.0	0.0	1	1	1
12/07/2019 09:00	0.0	12.1	2,075.5	0.0	0.0	1	1	1
12/07/2019 10:00	0.0	12.2	2,056.3	0.0	0.0	1	1	1
12/07/2019 11:00	0.0	12.1	2,062.2	0.0	0.0	1	1	1
12/07/2019 12:00	0.0	12.1	2,063.2	0.0	0.0	1	1	1
12/07/2019 13:00	0.0	12.2	2,061.5	0.0	0.0	1	1	1
12/07/2019 14:00	0.0	12.2	2,062.7	0.0	0.0	1	1	1
12/07/2019 15:00	0.0	12.2	2,046.7	0.0	0.0	1	1	1
12/07/2019 16:00	0.0	12.2	2,055.2	0.0	0.0	1	1	1
12/07/2019 17:00	0.0	12.2	2,055.5	0.0	0.0	1	1	1
12/07/2019 18:00	0.0	12.0	2,103.1	0.0	0.0	1	1	1
12/07/2019 19:00	0.0	12.1	2,093.6	0.0	0.0	1	1	1
12/07/2019 20:00	0.0	12.0	2,097.4	0.0	0.0	1	1	1
12/07/2019 21:00	0.0	12.1	2,096.5	0.0	0.0	1	1	1
12/07/2019 22:00	0.0	12.2	2,074.8	0.0	0.0	1	1	1
12/07/2019 23:00	0.0	12.2	2,070.2	0.0	0.0	1	1	1
Average/Sum#:	0.1	12.2	2,059.6	0.1	5.0 #	24 #	24 #	24 #
Minimum:	0.0	12.0	1,911.3	0.0	0.0	1	1	1
Maximum:	1.6	12.9	2,103.1	1.0	5.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/08/2019 00:00	0.0	12.1	2,080.6	0.0	0.0	1	1	1
12/08/2019 01:00	0.0	12.6	1,938.3	0.0	0.0	1	1	1
12/08/2019 02:00	0.0	13.6	1,607.0	0.0	0.0	1	1	0
12/08/2019 03:00	0.0	13.6	1,470.4	0.0	0.0	1	1	0
12/08/2019 04:00	0.0	13.6	1,606.7	0.0	0.0	1	1	0
12/08/2019 05:00	0.0	13.6	1,674.8	0.0	0.0	1	1	0
12/08/2019 06:00	0.0	13.6	1,686.3	0.0	0.0	1	1	0
12/08/2019 07:00	0.0	13.6	1,667.1	0.0	0.0	1	1	0
12/08/2019 08:00	0.0	13.6	1,648.6	0.0	0.0	1	1	0
12/08/2019 09:00	0.0	13.6	1,651.1	0.0	0.0	1	1	0
12/08/2019 10:00	0.0	13.6	1,506.9	0.0	0.0	1	1	0
12/08/2019 11:00	0.0	13.6	1,595.1	0.0	0.0	1	1	0
12/08/2019 12:00	0.0	13.6	1,512.1	0.0	0.0	1	1	0
12/08/2019 13:00	0.0	13.6	1,659.8	0.0	0.0	1	1	0
12/08/2019 14:00	0.0	13.5	1,663.0	0.0	0.0	1	1	1
12/08/2019 15:00	0.0	12.8	1,886.7	0.0	0.0	1	1	1
12/08/2019 16:00	0.0	12.4	2,033.6	0.0	0.0	1	1	1
12/08/2019 17:00	0.0	12.4	2,028.5	0.0	0.0	1	1	1
12/08/2019 18:00	0.0	12.3	2,071.4	0.0	0.0	1	1	1
12/08/2019 19:00	0.0	12.2	2,083.6	0.0	0.0	1	1	1
12/08/2019 20:00	0.0	12.2	2,087.5	0.0	0.0	1	1	1
12/08/2019 21:00	0.0	12.4	2,048.4	0.0	0.0	1	1	1
12/08/2019 22:00	0.0	12.2	2,081.5	0.0	0.0	1	1	1
12/08/2019 23:00	0.0	12.2	2,091.9	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.0	1,807.5	0.0	0.0 #	24 #	24 #	12 #
Minimum:	0.0	12.1	1,470.4	0.0	0.0	1	1	0
Maximum:	0.0	13.6	2,091.9	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2019 00:00	0.0	12.3	2,068.6	0.0	0.0	1	1	1
12/09/2019 01:00	0.0	12.5	2,029.9	0.0	0.0	1	1	1
12/09/2019 02:00	0.0	12.6	2,013.3	0.0	0.0	1	1	1
12/09/2019 03:00	0.0	12.5	2,019.1	0.0	0.0	1	1	1
12/09/2019 04:00	0.0	12.4	2,060.4	0.0	0.0	1	1	1
12/09/2019 05:00	0.0	12.4	2,052.2	0.0	0.0	1	1	1
12/09/2019 06:00	0.0	12.4	2,057.8	0.0	0.0	1	1	1
12/09/2019 07:00	0.0	12.3	2,088.0	0.0	0.0	1	1	1
12/09/2019 08:00	0.0	12.3	2,082.8	0.0	0.0	1	1	1
12/09/2019 09:00	0.0	12.3	2,077.4	0.0	0.0	1	1	1
12/09/2019 10:00	0.0	12.5	2,030.7	0.0	0.0	1	1	1
12/09/2019 11:00	0.0	12.5	2,025.8	0.0	0.0	1	1	1
12/09/2019 12:00	0.0	12.5	2,020.3	0.0	0.0	1	1	1
12/09/2019 13:00	0.0	12.5	2,028.2	0.0	0.0	1	1	1
12/09/2019 14:00	0.0	12.5	2,015.6	0.0	0.0	1	1	1
12/09/2019 15:00	0.0	12.3	2,048.5	0.0	0.0	1	1	1
12/09/2019 16:00	0.0	12.4	2,041.3	0.0	0.0	1	1	1
12/09/2019 17:00	0.0	12.2	2,090.0	0.0	0.0	1	1	1
12/09/2019 18:00	0.0	12.0	2,146.0	0.0	0.0	1	1	1
12/09/2019 19:00	0.0	11.9	2,159.4	0.0	0.0	1	1	1
12/09/2019 20:00	0.0	12.0	2,160.4	0.0	0.0	1	1	1
12/09/2019 21:00	0.0	12.2	2,100.0	0.0	0.0	1	1	1
12/09/2019 22:00	0.0	12.3	2,094.8	0.0	0.0	1	1	1
12/09/2019 23:00	0.0	12.4	2,086.2	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.3	2,066.5	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.9	2,013.3	0.0	0.0	1	1	1
Maximum:	0.0	12.6	2,160.4	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/10/2019 00:00	0.0	12.3	2,112.2	0.0	0.0	1	1	1
12/10/2019 01:00	0.0	12.3	2,109.1	0.0	0.0	1	1	1
12/10/2019 02:00	0.0	12.3	2,103.9	0.0	0.0	1	1	1
12/10/2019 03:00	0.0	12.3	2,114.9	0.0	0.0	1	1	1
12/10/2019 04:00	0.0	12.2	2,122.1	0.0	0.0	1	1	1
12/10/2019 05:00	0.0	12.4	2,103.2	0.0	0.0	1	1	1
12/10/2019 06:00	0.0	12.3	2,114.7	0.0	0.0	1	1	1
12/10/2019 07:00	0.0	12.2	2,139.7	0.0	0.0	1	1	1
12/10/2019 08:00	0.0	12.5	2,080.0	0.0	0.0	1	1	1
12/10/2019 09:00	0.0	12.3	2,107.8	0.0	0.0	1	1	1
12/10/2019 10:00	0.0	12.6	2,048.7	0.0	0.0	1	1	1
12/10/2019 11:00	0.0	12.6	2,039.8	0.0	0.0	1	1	1
12/10/2019 12:00	0.0	12.5	2,054.4	0.0	0.0	1	1	1
12/10/2019 13:00	0.0	12.5	2,051.4	0.0	0.0	1	1	1
12/10/2019 14:00	0.0	12.4	2,057.1	0.0	0.0	1	1	1
12/10/2019 15:00	0.0	12.5	2,045.6	0.0	0.0	1	1	1
12/10/2019 16:00	0.0	12.4	2,061.8	0.0	0.0	1	1	1
12/10/2019 17:00	0.0	12.1	2,128.5	0.0	0.0	1	1	1
12/10/2019 18:00	0.0	12.0	2,149.1	0.0	0.0	1	1	1
12/10/2019 19:00	0.0	12.0	2,151.7	0.0	0.0	1	1	1
12/10/2019 20:00	0.0	12.0	2,152.8	0.0	0.0	1	1	1
12/10/2019 21:00	0.0	12.2	2,117.9	0.0	0.0	1	1	1
12/10/2019 22:00	0.0	12.4	2,079.0	0.0	0.0	1	1	1
12/10/2019 23:00	0.0	12.4	2,074.2	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.3	2,096.7	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.0	2,039.8	0.0	0.0	1	1	1
Maximum:	0.0	12.6	2,152.8	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/11/2019 00:00	0.0	12.3	2,100.1	0.0	0.0	1	1	1
12/11/2019 01:00	0.0	12.3	2,096.8	0.0	0.0	1	1	1
12/11/2019 02:00	0.0	12.4	2,071.1	0.0	0.0	1	1	1
12/11/2019 03:00	0.0	12.6	2,022.2	0.0	0.0	1	1	1
12/11/2019 04:00	0.0	12.5	2,045.5	0.0	0.0	1	1	1
12/11/2019 05:00	0.0	12.4	2,065.7	0.0	0.0	1	1	1
12/11/2019 06:00	0.0	12.1	2,100.7	0.0	0.0	1	1	1
12/11/2019 07:00	0.0	12.3	2,093.9	0.0	0.0	1	1	1
12/11/2019 08:00	0.0	12.4	2,063.9	0.0	0.0	1	1	1
12/11/2019 09:00	0.0	12.5	2,034.7	0.0	0.0	1	1	1
12/11/2019 10:00	0.0	12.5	2,047.1	0.0	0.0	1	1	1
12/11/2019 11:00	0.0	12.5	2,029.1	0.0	0.0	1	1	1
12/11/2019 12:00	0.0	12.5	2,031.6	0.0	0.0	1	1	1
12/11/2019 13:00	0.0	12.5	2,031.7	0.0	0.0	1	1	1
12/11/2019 14:00	0.0	12.4	2,057.6	0.0	0.0	1	1	1
12/11/2019 15:00	0.0	12.5	2,027.7	0.0	0.0	1	1	1
12/11/2019 16:00	0.0	12.5	2,043.9	0.0	0.0	1	1	1
12/11/2019 17:00	0.0	12.2	2,099.3	0.0	0.0	1	1	1
12/11/2019 18:00	0.0	12.3	2,075.0	0.0	0.0	1	1	1
12/11/2019 19:00	0.0	12.1	2,134.3	0.0	0.0	1	1	1
12/11/2019 20:00	0.0	12.3	2,082.6	0.0	0.0	1	1	1
12/11/2019 21:00	0.0	12.4	2,053.6	0.0	0.0	1	1	1
12/11/2019 22:00	0.0	12.5	2,040.3	0.0	0.0	1	1	1
12/11/2019 23:00	0.0	12.4	2,042.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.4	2,062.1	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.1	2,022.2	0.0	0.0	1	1	1
Maximum:	0.0	12.6	2,134.3	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/12/2019 00:00	0.0	12.5	2,038.4	0.0	0.0	1	1	1
12/12/2019 01:00	0.0	12.5	2,026.7	0.0	0.0	1	1	1
12/12/2019 02:00	0.0	12.5	2,034.6	0.0	0.0	1	1	1
12/12/2019 03:00	0.0	12.5	2,036.3	0.0	0.0	1	1	1
12/12/2019 04:00	0.0	12.5	2,034.4	0.0	0.0	1	1	1
12/12/2019 05:00	0.0	12.5	2,032.9	0.0	0.0	1	1	1
12/12/2019 06:00	0.0	12.2	2,081.7	0.0	0.0	1	1	1
12/12/2019 07:00	0.0	12.2	2,109.2	0.0	0.0	1	1	1
12/12/2019 08:00	0.0	12.5	2,048.5	0.0	0.0	1	1	1
12/12/2019 09:00	0.0	12.5	2,041.1	0.0	0.0	1	1	1
12/12/2019 10:00	0.0	12.6	2,020.5	0.0	0.0	1	1	1
12/12/2019 11:00	0.0	12.6	2,015.7	0.0	0.0	1	1	1
12/12/2019 12:00	0.0	12.5	2,030.3	0.0	0.0	1	1	1
12/12/2019 13:00	0.0	12.5	2,032.5	0.0	0.0	1	1	1
12/12/2019 14:00	0.0	12.4	2,038.8	0.0	0.0	1	1	1
12/12/2019 15:00	0.0	12.4	2,039.5	0.0	0.0	1	1	1
12/12/2019 16:00	0.0	12.4	2,044.8	0.0	0.0	1	1	1
12/12/2019 17:00	0.0	12.2	2,092.8	0.0	0.0	1	1	1
12/12/2019 18:00	0.0	12.1	2,102.0	0.0	0.0	1	1	1
12/12/2019 19:00	0.0	12.2	2,080.7	0.0	0.0	1	1	1
12/12/2019 20:00	0.0	12.3	2,053.9	0.0	0.0	1	1	1
12/12/2019 21:00	0.0	12.4	2,058.8	0.0	0.0	1	1	1
12/12/2019 22:00	0.0	12.4	2,048.7	0.0	0.0	1	1	1
12/12/2019 23:00	0.0	13.1	1,826.5	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.4	2,040.4	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.1	1,826.5	0.0	0.0	1	1	1
Maximum:	0.0	13.1	2,109.2	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/13/2019 00:00	0.0	13.6	1,455.3	0.0	0.0	1	1	0
12/13/2019 01:00	0.0	13.6	1,517.7	0.0	0.0	1	1	0
12/13/2019 02:00	0.0	13.6	1,391.0	0.0	0.0	1	1	0
12/13/2019 03:00	0.0	13.6	1,433.6	0.0	0.0	1	1	0
12/13/2019 04:00	0.0	13.6	1,701.2	0.0	0.0	1	1	0
12/13/2019 05:00	0.0	13.6	1,407.8	0.0	0.0	1	1	0
12/13/2019 06:00	0.0	13.6	1,398.2	0.0	0.0	1	1	0
12/13/2019 07:00	0.0	13.6	1,585.5	0.0	0.0	1	1	0
12/13/2019 08:00	0.0	13.6	1,684.7	0.0	0.0	1	1	0
12/13/2019 09:00	0.0	13.6	1,642.9	0.0	0.0	1	1	0
12/13/2019 10:00	0.0	13.6	1,696.1	0.0	0.0	1	1	0
12/13/2019 11:00	0.0	13.6	1,603.9	0.0	0.0	1	1	0
12/13/2019 12:00	0.0	13.6	1,497.2	0.0	0.0	1	1	0
12/13/2019 13:00	0.0	13.6	1,665.1	0.0	0.0	1	1	0
12/13/2019 14:00	0.0	13.5	1,746.6	0.0	0.0	1	1	1
12/13/2019 15:00	0.0	12.5	1,993.7	0.0	0.0	1	1	1
12/13/2019 16:00	0.0	12.2	2,067.1	0.0	0.0	1	1	1
12/13/2019 17:00	0.0	12.2	2,061.0	0.0	0.0	1	1	1
12/13/2019 18:00	0.0	12.0	2,113.5	0.0	0.0	1	1	1
12/13/2019 19:00	0.0	12.2	2,060.4	0.0	0.0	1	1	1
12/13/2019 20:00	0.0	12.2	2,079.0	0.0	0.0	1	1	1
12/13/2019 21:00	0.0	12.2	2,067.6	0.0	0.0	1	1	1
12/13/2019 22:00	0.0	12.2	2,069.6	0.0	0.0	1	1	1
12/13/2019 23:00	0.0	12.3	2,058.0	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.1	1,749.9	0.0	0.0 #	24 #	24 #	10 #
Minimum:	0.0	12.0	1,391.0	0.0	0.0	1	1	0
Maximum:	0.0	13.6	2,113.5	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/14/2019 00:00	0.0	12.4	2,045.8	0.0	0.0	1	1	1
12/14/2019 01:00	0.0	12.6	1,962.4	0.0	0.0	1	1	1
12/14/2019 02:00	0.0	13.6	1,606.6	0.0	0.0	1	1	0
12/14/2019 03:00	0.0	13.6	1,561.7	0.0	0.0	1	1	0
12/14/2019 04:00	0.0	13.6	1,695.0	0.0	0.0	1	1	0
12/14/2019 05:00	0.0	13.6	1,631.9	0.0	0.0	1	1	0
12/14/2019 06:00	0.0	13.6	1,567.2	0.0	0.0	1	1	0
12/14/2019 07:00	0.0	13.6	1,491.9	0.0	0.0	1	1	0
12/14/2019 08:00	0.0	13.6	1,487.9	0.0	0.0	1	1	0
12/14/2019 09:00	0.0	13.6	1,646.4	0.0	0.0	1	1	0
12/14/2019 10:00	0.0	13.6	1,583.8	0.0	0.0	1	1	0
12/14/2019 11:00	0.0	13.6	1,611.9	0.0	0.0	1	1	0
12/14/2019 12:00	0.0	13.7	1,386.2	0.0	0.0	1	1	0
12/14/2019 13:00	0.0	13.6	1,657.3	0.0	0.0	1	1	0
12/14/2019 14:00	0.0	13.6	1,607.0	0.0	0.0	1	1	0
12/14/2019 15:00	0.0	13.6	1,612.8	0.0	0.0	1	1	1
12/14/2019 16:00	0.0	12.5	2,014.5	0.0	0.0	1	1	1
12/14/2019 17:00	0.0	12.3	2,078.8	0.0	0.0	1	1	1
12/14/2019 18:00	0.0	12.3	2,080.7	0.0	0.0	1	1	1
12/14/2019 19:00	0.0	12.4	2,057.4	0.0	0.0	1	1	1
12/14/2019 20:00	0.0	12.2	2,104.3	0.0	0.0	1	1	1
12/14/2019 21:00	0.0	12.3	2,104.0	0.0	0.0	1	1	1
12/14/2019 22:00	0.0	12.4	2,056.1	0.0	0.0	1	1	1
12/14/2019 23:00	0.0	12.9	1,953.3	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.1	1,775.2	0.0	0.0 #	24 #	24 #	11 #
Minimum:	0.0	12.2	1,386.2	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,104.3	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2019 00:00	0.0	12.6	2,034.8	0.0	0.0	1	1	1
12/15/2019 01:00	0.0	12.6	2,022.0	0.0	0.0	1	1	1
12/15/2019 02:00	0.0	12.4	2,068.2	0.0	0.0	1	1	1
12/15/2019 03:00	0.0	12.4	2,088.1	0.0	0.0	1	1	1
12/15/2019 04:00	0.0	12.4	2,097.5	0.0	0.0	1	1	1
12/15/2019 05:00	0.0	12.5	2,059.2	0.0	0.0	1	1	1
12/15/2019 06:00	0.0	12.5	2,068.0	0.0	0.0	1	1	1
12/15/2019 07:00	0.0	12.8	1,958.5	0.0	0.0	1	1	1
12/15/2019 08:00	0.0	13.6	1,594.2	0.0	0.0	1	1	0
12/15/2019 09:00	0.0	13.6	1,647.3	0.0	0.0	1	1	0
12/15/2019 10:00	0.0	13.6	1,546.4	0.0	0.0	1	1	0
12/15/2019 11:00	0.0	13.6	1,572.6	0.0	0.0	1	1	0
12/15/2019 12:00	0.0	13.6	1,555.2	0.0	0.0	1	1	0
12/15/2019 13:00	0.0	13.6	1,648.3	0.0	0.0	1	1	0
12/15/2019 14:00	0.0	13.6	1,578.5	0.0	0.0	1	1	0
12/15/2019 15:00	0.0	13.6	1,574.4	0.0	0.0	1	1	1
12/15/2019 16:00	0.0	12.7	2,013.2	0.0	0.0	1	1	1
12/15/2019 17:00	0.0	12.5	2,065.4	0.0	0.0	1	1	1
12/15/2019 18:00	0.0	12.2	2,140.9	0.0	0.0	1	1	1
12/15/2019 19:00	0.0	12.0	2,167.3	0.0	0.0	1	1	1
12/15/2019 20:00	0.0	12.1	2,160.8	0.0	0.0	1	1	1
12/15/2019 21:00	0.0	12.1	2,156.4	0.0	0.0	1	1	1
12/15/2019 22:00	0.0	12.3	2,096.1	0.0	0.0	1	1	1
12/15/2019 23:00	0.0	12.5	2,073.9	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.8	1,916.1	0.0	0.0 #	24 #	24 #	17 #
Minimum:	0.0	12.0	1,546.4	0.0	0.0	1	1	0
Maximum:	0.0	13.6	2,167.3	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/16/2019 00:00	0.0	12.3	2,105.5	0.0	0.0	1	1	1
12/16/2019 01:00	0.0	12.3	2,105.7	0.0	0.0	1	1	1
12/16/2019 02:00	0.0	12.4	2,099.3	0.0	0.0	1	1	1
12/16/2019 03:00	0.0	12.4	2,112.4	0.0	0.0	1	1	1
12/16/2019 04:00	0.0	12.4	2,110.5	0.0	0.0	1	1	1
12/16/2019 05:00	0.0	12.4	2,094.0	0.0	0.0	1	1	1
12/16/2019 06:00	0.0	12.1	2,177.6	0.0	0.0	1	1	1
12/16/2019 07:00	0.0	12.3	2,141.6	0.0	0.0	1	1	1
12/16/2019 08:00	0.0	12.8	2,024.2	0.0	0.0	1	1	1
12/16/2019 09:00	0.0	12.7	2,021.1	0.0	0.0	1	1	1
12/16/2019 10:00	0.0	12.6	2,038.9	0.0	0.0	1	1	1
12/16/2019 11:00	0.0	12.6	2,031.8	0.0	0.0	1	1	1
12/16/2019 12:00	0.0	12.6	2,033.7	0.0	0.0	1	1	1
12/16/2019 13:00	0.0	12.6	2,034.6	0.0	0.0	1	1	1
12/16/2019 14:00	0.0	12.5	2,047.6	0.0	0.0	1	1	1
12/16/2019 15:00	0.0	12.5	2,062.4	0.0	0.0	1	1	1
12/16/2019 16:00	0.0	12.4	2,085.0	0.0	0.0	1	1	1
12/16/2019 17:00	0.0	12.1	2,138.0	0.0	0.0	1	1	1
12/16/2019 18:00	0.0	12.1	2,152.8	0.0	0.0	1	1	1
12/16/2019 19:00	0.0	12.1	2,167.2	0.0	0.0	1	1	1
12/16/2019 20:00	0.0	12.1	2,167.2	0.0	0.0	1	1	1
12/16/2019 21:00	0.0	12.1	2,161.4	0.0	0.0	1	1	1
12/16/2019 22:00	0.0	12.3	2,128.4	0.0	0.0	1	1	1
12/16/2019 23:00	0.0	12.5	2,085.0	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.4	2,096.9	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.1	2,021.1	0.0	0.0	1	1	1
Maximum:	0.0	12.8	2,177.6	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/17/2019 00:00	0.0	12.4	2,095.6	0.0	0.0	1	1	1
12/17/2019 01:00	0.0	12.4	2,112.7	0.0	0.0	1	1	1
12/17/2019 02:00	0.0	12.4	2,111.7	0.0	0.0	1	1	1
12/17/2019 03:00	0.0	12.4	2,107.2	0.0	0.0	1	1	1
12/17/2019 04:00	0.0	12.6	2,091.3	0.0	0.0	1	1	1
12/17/2019 05:00	0.0	12.6	2,085.2	0.0	0.0	1	1	1
12/17/2019 06:00	0.0	12.2	2,143.9	0.0	0.0	1	1	1
12/17/2019 07:00	0.0	12.4	2,135.0	0.0	0.0	1	1	1
12/17/2019 08:00	0.0	12.5	2,095.6	0.0	0.0	1	1	1
12/17/2019 09:00	0.0	12.7	2,054.8	0.0	0.0	1	1	1
12/17/2019 10:00	0.0	12.7	2,041.9	0.0	0.0	1	1	1
12/17/2019 11:00	0.0	12.7	2,043.5	0.0	0.0	1	1	1
12/17/2019 12:00	0.0	12.6	2,051.0	0.0	0.0	1	1	1
12/17/2019 13:00	0.0	12.6	2,061.2	0.0	0.0	1	1	1
12/17/2019 14:00	0.0	12.4	2,086.1	0.0	0.0	1	1	1
12/17/2019 15:00	0.0	12.3	2,107.4	0.0	0.0	1	1	1
12/17/2019 16:00	0.0	12.3	2,123.4	0.0	0.0	1	1	1
12/17/2019 17:00	0.0	12.2	2,140.8	0.0	0.0	1	1	1
12/17/2019 18:00	0.0	12.2	2,127.0	0.0	0.0	1	1	1
12/17/2019 19:00	0.0	12.3	2,112.3	0.0	0.0	1	1	1
12/17/2019 20:00	0.0	12.1	2,155.6	0.0	0.0	1	1	1
12/17/2019 21:00	0.0	12.0	2,166.9	0.0	0.0	1	1	1
12/17/2019 22:00	0.0	12.1	2,160.9	0.0	0.0	1	1	1
12/17/2019 23:00	0.0	12.4	2,091.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.4	2,104.3	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.0	2,041.9	0.0	0.0	1	1	1
Maximum:	0.0	12.7	2,166.9	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/18/2019 00:00	0.0	12.5	2,083.8	0.0	0.0	1	1	1
12/18/2019 01:00	0.0	12.3	2,106.5	0.0	0.0	1	1	1
12/18/2019 02:00	0.0	12.3	2,102.9	0.0	0.0	1	1	1
12/18/2019 03:00	0.0	12.3	2,109.2	0.0	0.0	1	1	1
12/18/2019 04:00	0.0	12.3	2,115.1	0.0	0.0	1	1	1
12/18/2019 05:00	0.0	12.1	2,147.7	0.0	0.0	1	1	1
12/18/2019 06:00	0.0	12.0	2,189.5	0.0	0.0	1	1	1
12/18/2019 07:00	0.0	12.1	2,170.9	0.0	0.0	1	1	1
12/18/2019 08:00	0.0	12.3	2,125.0	0.0	0.0	1	1	1
12/18/2019 09:00	0.0	12.3	2,109.0	0.0	0.0	1	1	1
12/18/2019 10:00	0.0	12.4	2,102.2	0.0	0.0	1	1	1
12/18/2019 11:00	0.0	12.3	2,115.8	0.0	0.0	1	1	1
12/18/2019 12:00	0.0	12.3	2,099.3	0.0	0.0	1	1	1
12/18/2019 13:00	0.0	12.4	2,097.1	0.0	0.0	1	1	1
12/18/2019 14:00	0.0	12.4	2,086.5	0.0	0.0	1	1	1
12/18/2019 15:00	0.0	12.5	2,063.9	0.0	0.0	1	1	1
12/18/2019 16:00	0.0	12.4	2,100.2	0.0	0.0	1	1	1
12/18/2019 17:00	0.0	12.2	2,143.7	0.0	0.0	1	1	1
12/18/2019 18:00	0.0	12.0	2,171.8	0.0	0.0	1	1	1
12/18/2019 19:00	0.0	12.1	2,163.5	0.0	0.0	1	1	1
12/18/2019 20:00	0.0	12.0	2,173.3	0.0	0.0	1	1	1
12/18/2019 21:00	0.0	12.1	2,160.8	0.0	0.0	1	1	1
12/18/2019 22:00	0.0	12.2	2,145.7	0.0	0.0	1	1	1
12/18/2019 23:00	0.0	12.4	2,096.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.3	2,124.1	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.0	2,063.9	0.0	0.0	1	1	1
Maximum:	0.0	12.5	2,189.5	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2019 00:00	0.0	12.3	2,110.2	0.0	0.0	1	1	1
12/19/2019 01:00	0.0	12.3	2,109.6	0.0	0.0	1	1	1
12/19/2019 02:00	0.0	12.3	2,104.4	0.0	0.0	1	1	1
12/19/2019 03:00	0.0	12.4	2,093.9	0.0	0.0	1	1	1
12/19/2019 04:00	0.0	12.3	2,105.8	0.0	0.0	1	1	1
12/19/2019 05:00	0.0	12.4	2,089.4	0.0	0.0	1	1	1
12/19/2019 06:00	0.0	12.0	2,172.9	0.0	0.0	1	1	1
12/19/2019 07:00	0.0	12.1	2,151.4	0.0	0.0	1	1	1
12/19/2019 08:00	0.0	12.6	2,042.6	0.0	0.0	1	1	1
12/19/2019 09:00	0.0	12.5	2,064.5	0.0	0.0	1	1	1
12/19/2019 10:00	0.0	12.6	2,032.5	0.0	0.0	1	1	1
12/19/2019 11:00	0.0	12.6	2,033.1	0.0	0.0	1	1	1
12/19/2019 12:00	0.0	12.6	2,029.8	0.0	0.0	1	1	1
12/19/2019 13:00	0.0	12.5	2,038.5	0.0	0.0	1	1	1
12/19/2019 14:00	0.0	12.6	2,026.2	0.0	0.0	1	1	1
12/19/2019 15:00	0.0	12.4	2,075.1	0.0	0.0	1	1	1
12/19/2019 16:00	0.0	12.3	2,084.0	0.0	0.0	1	1	1
12/19/2019 17:00	0.0	12.2	2,112.7	0.0	0.0	1	1	1
12/19/2019 18:00	0.0	12.2	2,116.2	0.0	0.0	1	1	1
12/19/2019 19:00	0.0	12.1	2,140.0	0.0	0.0	1	1	1
12/19/2019 20:00	0.0	12.1	2,142.2	0.0	0.0	1	1	1
12/19/2019 21:00	0.0	12.1	2,147.2	0.0	0.0	1	1	1
12/19/2019 22:00	0.0	12.3	2,100.6	0.0	0.0	1	1	1
12/19/2019 23:00	0.0	12.4	2,087.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.3	2,092.1	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.0	2,026.2	0.0	0.0	1	1	1
Maximum:	0.0	12.6	2,172.9	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/20/2019 00:00	0.0	12.3	2,103.7	0.0	0.0	1	1	1
12/20/2019 01:00	0.0	12.3	2,089.5	0.0	0.0	1	1	1
12/20/2019 02:00	0.0	12.3	2,095.5	0.0	0.0	1	1	1
12/20/2019 03:00	0.0	12.6	2,040.0	0.0	0.0	1	1	1
12/20/2019 04:00	0.0	12.5	2,065.1	0.0	0.0	1	1	1
12/20/2019 05:00	0.0	12.4	2,092.9	0.0	0.0	1	1	1
12/20/2019 06:00	0.0	12.2	2,118.4	0.0	0.0	1	1	1
12/20/2019 07:00	0.0	12.5	2,070.4	0.0	0.0	1	1	1
12/20/2019 08:00	0.0	12.6	2,030.9	0.0	0.0	1	1	1
12/20/2019 09:00	0.0	12.6	2,044.2	0.0	0.0	1	1	1
12/20/2019 10:00	0.0	12.8	1,946.1	0.0	0.0	1	1	1
12/20/2019 11:00	0.0	13.6	1,648.3	0.0	0.0	1	1	0
12/20/2019 12:00	0.0	13.6	1,598.4	0.0	0.0	1	1	0
12/20/2019 13:00	0.0	13.6	1,659.5	0.0	0.0	1	1	0
12/20/2019 14:00	0.0	13.6	1,572.1	0.0	0.0	1	1	1
12/20/2019 15:00	0.0	12.5	2,030.2	0.0	0.0	1	1	1
12/20/2019 16:00	0.0	12.3	2,069.8	0.0	0.0	1	1	1
12/20/2019 17:00	0.0	12.1	2,112.2	0.0	0.0	1	1	1
12/20/2019 18:00	0.0	12.0	2,136.1	0.0	0.0	1	1	1
12/20/2019 19:00	0.0	12.2	2,101.3	0.0	0.0	1	1	1
12/20/2019 20:00	0.0	12.2	2,098.5	0.0	0.0	1	1	1
12/20/2019 21:00	0.0	12.2	2,097.4	0.0	0.0	1	1	1
12/20/2019 22:00	0.0	12.2	2,101.2	0.0	0.0	1	1	1
12/20/2019 23:00	0.0	12.3	2,094.2	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.6	2,000.7	0.0	0.0 #	24 #	24 #	21 #
Minimum:	0.0	12.0	1,572.1	0.0	0.0	1	1	0
Maximum:	0.0	13.6	2,136.1	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2019 00:00	0.0	12.4	2,062.3	0.0	0.0	1	1	1
12/21/2019 01:00	0.0	12.5	2,047.9	0.0	0.0	1	1	1
12/21/2019 02:00	0.0	12.3	2,084.5	0.0	0.0	1	1	1
12/21/2019 03:00	0.0	12.3	2,086.1	0.0	0.0	1	1	1
12/21/2019 04:00	0.0	12.3	2,091.9	0.0	0.0	1	1	1
12/21/2019 05:00	0.0	12.3	2,097.3	0.0	0.0	1	1	1
12/21/2019 06:00	0.0	12.3	2,076.8	0.0	0.0	1	1	1
12/21/2019 07:00	0.0	12.3	2,106.2	0.0	0.0	1	1	1
12/21/2019 08:00	0.0	12.3	2,099.3	0.0	0.0	1	1	1
12/21/2019 09:00	0.0	12.3	2,090.7	0.0	0.0	1	1	1
12/21/2019 10:00	0.0	12.4	2,067.2	0.0	0.0	1	1	1
12/21/2019 11:00	0.0	12.6	2,036.5	0.0	0.0	1	1	1
12/21/2019 12:00	0.0	12.5	2,034.8	0.0	0.0	1	1	1
12/21/2019 13:00	0.0	12.5	2,041.3	0.0	0.0	1	1	1
12/21/2019 14:00	0.0	12.4	2,061.3	0.0	0.0	1	1	1
12/21/2019 15:00	0.0	12.5	2,051.4	0.0	0.0	1	1	1
12/21/2019 16:00	0.0	12.5	2,037.2	0.0	0.0	1	1	1
12/21/2019 17:00	0.0	12.5	2,042.2	0.0	0.0	1	1	1
12/21/2019 18:00	0.0	12.4	2,054.3	0.0	0.0	1	1	1
12/21/2019 19:00	0.0	12.4	2,062.3	0.0	0.0	1	1	1
12/21/2019 20:00	0.0	12.3	2,079.4	0.0	0.0	1	1	1
12/21/2019 21:00	0.0	12.3	2,072.6	0.0	0.0	1	1	1
12/21/2019 22:00	0.0	12.2	2,100.2	0.0	0.0	1	1	1
12/21/2019 23:00	0.0	12.3	2,098.4	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.4	2,070.1	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.2	2,034.8	0.0	0.0	1	1	1
Maximum:	0.0	12.6	2,106.2	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/22/2019 00:00	0.0	12.3	2,092.8	0.0	0.0	1	1	1
12/22/2019 01:00	0.0	12.4	2,061.8	0.0	0.0	1	1	1
12/22/2019 02:00	0.0	12.2	2,103.3	0.0	0.0	1	1	1
12/22/2019 03:00	0.0	12.2	2,109.5	0.0	0.0	1	1	1
12/22/2019 04:00	0.0	12.3	2,081.6	0.0	0.0	1	1	1
12/22/2019 05:00	0.0	12.3	2,073.6	0.0	0.0	1	1	1
12/22/2019 06:00	0.0	12.1	2,102.0	0.0	0.0	1	1	1
12/22/2019 07:00	0.0	12.1	2,109.7	0.0	0.0	1	1	1
12/22/2019 08:00	0.0	12.2	2,088.6	0.0	0.0	1	1	1
12/22/2019 09:00	0.0	12.3	2,085.0	0.0	0.0	1	1	1
12/22/2019 10:00	0.0	12.3	2,085.1	0.0	0.0	1	1	1
12/22/2019 11:00	0.0	12.3	2,062.4	0.0	0.0	1	1	1
12/22/2019 12:00	0.0	12.4	2,056.4	0.0	0.0	1	1	1
12/22/2019 13:00	0.0	12.2	2,083.7	0.0	0.0	1	1	1
12/22/2019 14:00	0.0	12.3	2,061.3	0.0	0.0	1	1	1
12/22/2019 15:00	0.0	12.3	2,056.8	0.0	0.0	1	1	1
12/22/2019 16:00	0.0	12.5	2,020.5	0.0	0.0	1	1	1
12/22/2019 17:00	0.0	12.5	2,023.6	0.0	0.0	1	1	1
12/22/2019 18:00	0.0	12.4	2,040.2	0.0	0.0	1	1	1
12/22/2019 19:00	0.0	12.4	2,043.9	0.0	0.0	1	1	1
12/22/2019 20:00	0.0	12.5	2,040.0	0.0	0.0	1	1	1
12/22/2019 21:00	0.0	12.5	2,028.7	0.0	0.0	1	1	1
12/22/2019 22:00	0.0	12.5	2,030.6	0.0	0.0	1	1	1
12/22/2019 23:00	0.0	12.5	2,053.2	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.3	2,066.4	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.1	2,020.5	0.0	0.0	1	1	1
Maximum:	0.0	12.5	2,109.7	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/23/2019 00:00	0.0	12.4	2,057.8	0.0	0.0	1	1	1
12/23/2019 01:00	0.0	12.5	2,036.7	0.0	0.0	1	1	1
12/23/2019 02:00	0.0	12.5	2,040.4	0.0	0.0	1	1	1
12/23/2019 03:00	0.0	12.5	2,059.6	0.0	0.0	1	1	1
12/23/2019 04:00	0.0	12.5	2,048.7	0.0	0.0	1	1	1
12/23/2019 05:00	0.0	12.5	2,039.1	0.0	0.0	1	1	1
12/23/2019 06:00	0.0	12.5	2,049.8	0.0	0.0	1	1	1
12/23/2019 07:00	0.0	12.5	2,055.3	0.0	0.0	1	1	1
12/23/2019 08:00	0.0	12.2	2,115.8	0.0	0.0	1	1	1
12/23/2019 09:00	0.0	12.2	2,118.1	0.0	0.0	1	1	1
12/23/2019 10:00	0.0	12.2	2,111.6	0.0	0.0	1	1	1
12/23/2019 11:00	0.0	12.1	2,115.9	0.0	0.0	1	1	1
12/23/2019 12:00	0.0	12.1	2,114.1	0.0	0.0	1	1	1
12/23/2019 13:00	0.0	12.3	2,061.2	0.0	0.0	1	1	1
12/23/2019 14:00	0.0	12.2	2,083.4	0.0	0.0	1	1	1
12/23/2019 15:00	0.0	12.3	2,059.5	0.0	0.0	1	1	1
12/23/2019 16:00	0.0	12.4	2,052.6	0.0	0.0	1	1	1
12/23/2019 17:00	0.0	12.4	2,046.0	0.0	0.0	1	1	1
12/23/2019 18:00	0.0	12.4	2,048.9	0.0	0.0	1	1	1
12/23/2019 19:00	0.0	12.4	2,071.9	0.0	0.0	1	1	1
12/23/2019 20:00	0.0	12.2	2,124.2	0.0	0.0	1	1	1
12/23/2019 21:00	0.0	12.2	2,105.7	0.0	0.0	1	1	1
12/23/2019 22:00	0.0	12.3	2,100.3	0.0	0.0	1	1	1
12/23/2019 23:00	0.0	12.4	2,102.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.3	2,075.8	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.1	2,036.7	0.0	0.0	1	1	1
Maximum:	0.0	12.5	2,124.2	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/24/2019 00:00	0.0	12.4	2,092.6	0.0	0.0	1	1	1
12/24/2019 01:00	0.0	12.6	2,047.1	0.0	0.0	1	1	1
12/24/2019 02:00	0.0	12.6	2,043.0	0.0	0.0	1	1	1
12/24/2019 03:00	0.0	12.6	2,044.0	0.0	0.0	1	1	1
12/24/2019 04:00	0.0	12.6	2,048.4	0.0	0.0	1	1	1
12/24/2019 05:00	0.0	12.6	2,049.6	0.0	0.0	1	1	1
12/24/2019 06:00	0.0	12.5	2,068.6	0.0	0.0	1	1	1
12/24/2019 07:00	0.0	12.6	2,065.7	0.0	0.0	1	1	1
12/24/2019 08:00	0.0	12.7	2,058.1	0.0	0.0	1	1	1
12/24/2019 09:00	0.0	12.6	2,046.3	0.0	0.0	1	1	1
12/24/2019 10:00	0.0	12.6	2,042.3	0.0	0.0	1	1	1
12/24/2019 11:00	0.0	12.6	2,035.5	0.0	0.0	1	1	1
12/24/2019 12:00	0.0	12.5	2,044.2	0.0	0.0	1	1	1
12/24/2019 13:00	0.0	12.6	2,032.3	0.0	0.0	1	1	1
12/24/2019 14:00	0.0	12.6	2,038.9	0.0	0.0	1	1	1
12/24/2019 15:00	0.0	12.4	2,080.9	0.0	0.0	1	1	1
12/24/2019 16:00	0.0	12.5	2,037.9	0.0	0.0	1	1	1
12/24/2019 17:00	0.0	12.5	2,057.3	0.0	0.0	1	1	1
12/24/2019 18:00	0.0	12.5	2,051.8	0.0	0.0	1	1	1
12/24/2019 19:00	0.0	12.6	2,041.0	0.0	0.0	1	1	1
12/24/2019 20:00	0.0	12.5	2,043.0	0.0	0.0	1	1	1
12/24/2019 21:00	0.0	12.6	2,042.4	0.0	0.0	1	1	1
12/24/2019 22:00	0.0	12.5	2,053.5	0.0	0.0	1	1	1
12/24/2019 23:00	0.0	12.6	2,035.2	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.6	2,050.0	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.4	2,032.3	0.0	0.0	1	1	1
Maximum:	0.0	12.7	2,092.6	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/25/2019 00:00	0.0	12.4	2,062.7	0.0	0.0	1	1	1
12/25/2019 01:00	0.0	12.4	2,068.2	0.0	0.0	1	1	1
12/25/2019 02:00	0.0	12.4	2,071.0	0.0	0.0	1	1	1
12/25/2019 03:00	0.0	12.6	2,045.1	0.0	0.0	1	1	1
12/25/2019 04:00	0.0	12.5	2,045.3	0.0	0.0	1	1	1
12/25/2019 05:00	0.0	12.6	2,041.9	0.0	0.0	1	1	1
12/25/2019 06:00	0.0	12.6	2,038.1	0.0	0.0	1	1	1
12/25/2019 07:00	0.0	12.5	2,056.9	0.0	0.0	1	1	1
12/25/2019 08:00	0.0	12.6	2,033.1	0.0	0.0	1	1	1
12/25/2019 09:00	0.0	12.5	2,051.2	0.0	0.0	1	1	1
12/25/2019 10:00	0.0	12.6	2,048.3	0.0	0.0	1	1	1
12/25/2019 11:00	0.0	12.5	2,044.8	0.0	0.0	1	1	1
12/25/2019 12:00	0.0	12.5	2,051.2	0.0	0.0	1	1	1
12/25/2019 13:00	0.0	12.5	2,044.4	0.0	0.0	1	1	1
12/25/2019 14:00	0.0	12.4	2,068.9	0.0	0.0	1	1	1
12/25/2019 15:00	0.0	12.4	2,069.5	0.0	0.0	1	1	1
12/25/2019 16:00	0.0	12.4	2,078.1	0.0	0.0	1	1	1
12/25/2019 17:00	0.0	12.5	2,049.5	0.0	0.0	1	1	1
12/25/2019 18:00	0.0	12.5	2,064.8	0.0	0.0	1	1	1
12/25/2019 19:00	0.0	12.3	2,095.3	0.0	0.0	1	1	1
12/25/2019 20:00	0.0	12.4	2,088.9	0.0	0.0	1	1	1
12/25/2019 21:00	0.0	12.4	2,069.7	0.0	0.0	1	1	1
12/25/2019 22:00	0.0	12.5	2,060.3	0.0	0.0	1	1	1
12/25/2019 23:00	0.0	12.4	2,067.9	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.5	2,059.0	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.3	2,033.1	0.0	0.0	1	1	1
Maximum:	0.0	12.6	2,095.3	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/26/2019 00:00	0.0	12.5	2,065.4	0.0	0.0	1	1	1
12/26/2019 01:00	0.0	12.4	2,073.0	0.0	0.0	1	1	1
12/26/2019 02:00	0.0	12.5	2,062.0	0.0	0.0	1	1	1
12/26/2019 03:00	0.0	12.5	2,052.8	0.0	0.0	1	1	1
12/26/2019 04:00	0.0	12.5	2,046.2	0.0	0.0	1	1	1
12/26/2019 05:00	0.0	12.6	2,040.8	0.0	0.0	1	1	1
12/26/2019 06:00	0.0	12.5	2,043.5	0.0	0.0	1	1	1
12/26/2019 07:00	0.0	12.4	2,081.9	0.0	0.0	1	1	1
12/26/2019 08:00	0.0	12.0	2,165.9	0.0	0.0	1	1	1
12/26/2019 09:00	0.0	12.2	2,108.0	0.0	0.0	1	1	1
12/26/2019 10:00	0.0	12.2	2,110.1	0.0	0.0	1	1	1
12/26/2019 11:00	0.0	12.4	2,069.7	0.0	0.0	1	1	1
12/26/2019 12:00	0.0	12.4	2,050.1	0.0	0.0	1	1	1
12/26/2019 13:00	0.0	12.3	2,072.8	0.0	0.0	1	1	1
12/26/2019 14:00	0.0	12.4	2,053.0	0.0	0.0	1	1	1
12/26/2019 15:00	0.0	12.3	2,065.9	0.0	0.0	1	1	1
12/26/2019 16:00	0.0	12.2	2,114.1	0.0	0.0	1	1	1
12/26/2019 17:00	0.0	12.1	2,126.5	0.0	0.0	1	1	1
12/26/2019 18:00	0.0	12.0	2,157.1	0.0	0.0	1	1	1
12/26/2019 19:00	0.0	12.0	2,151.5	0.0	0.0	1	1	1
12/26/2019 20:00	0.0	12.0	2,154.5	0.0	0.0	1	1	1
12/26/2019 21:00	0.0	12.2	2,121.4	0.0	0.0	1	1	1
12/26/2019 22:00	0.0	12.2	2,110.8	0.0	0.0	1	1	1
12/26/2019 23:00	0.0	12.3	2,111.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.3	2,092.0	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.0	2,040.8	0.0	0.0	1	1	1
Maximum:	0.0	12.6	2,165.9	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/27/2019 00:00	0.0	12.2	2,115.5	0.0	0.0	1	1	1
12/27/2019 01:00	0.0	12.3	2,095.3	0.0	0.0	1	1	1
12/27/2019 02:00	0.0	12.3	2,113.3	0.0	0.0	1	1	1
12/27/2019 03:00	0.0	12.4	2,082.6	0.0	0.0	1	1	1
12/27/2019 04:00	0.0	12.6	2,058.1	0.0	0.0	1	1	1
12/27/2019 05:00	0.0	12.6	2,065.8	0.0	0.0	1	1	1
12/27/2019 06:00	0.0	12.6	2,057.0	0.0	0.0	1	1	1
12/27/2019 07:00	0.0	12.6	2,071.0	0.0	0.0	1	1	1
12/27/2019 08:00	0.0	12.9	1,971.6	0.0	0.0	1	1	1
12/27/2019 09:00	0.0	13.6	1,691.3	0.0	0.0	1	1	0
12/27/2019 10:00	0.0	13.7	1,677.4	0.0	0.0	1	1	0
12/27/2019 11:00	0.0	13.7	1,637.2	0.0	0.0	1	1	0
12/27/2019 12:00	0.0	13.7	1,637.1	0.0	0.0	1	1	0
12/27/2019 13:00	0.0	13.7	1,686.6	0.0	0.0	1	1	0
12/27/2019 14:00	0.0	13.7	1,655.1	0.0	0.0	1	1	0
12/27/2019 15:00	0.0	13.7	1,417.0	0.0	0.0	1	1	0
12/27/2019 16:00	0.0	13.7	1,634.7	0.0	0.0	1	1	0
12/27/2019 17:00	0.0	13.7	1,711.5	0.0	0.0	1	1	1
12/27/2019 18:00	0.0	12.7	2,003.9	0.0	0.0	1	1	1
12/27/2019 19:00	0.0	12.3	2,086.7	0.0	0.0	1	1	1
12/27/2019 20:00	0.0	12.1	2,120.0	0.0	0.0	1	1	1
12/27/2019 21:00	0.0	12.2	2,106.8	0.0	0.0	1	1	1
12/27/2019 22:00	0.0	12.2	2,103.9	0.0	0.0	1	1	1
12/27/2019 23:00	0.0	12.4	2,070.5	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.5	1,911.2	0.0	0.0 #	24 #	24 #	16 #
Minimum:	0.0	12.2	1,417.0	0.0	0.0	1	1	0
Maximum:	0.0	12.6	2,120.0	0.0	0.0	1	1	1
%SI	0.00	66.67	0.00	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/28/2019 00:00	0.0	12.7	2,018.1	0.0	0.0	1	1	1
12/28/2019 01:00	0.0	12.7	2,022.8	0.0	0.0	1	1	1
12/28/2019 02:00	0.0	12.6	2,043.1	0.0	0.0	1	1	1
12/28/2019 03:00	0.0	12.6	2,024.9	0.0	0.0	1	1	1
12/28/2019 04:00	0.0	12.7	2,030.9	0.0	0.0	1	1	1
12/28/2019 05:00	0.0	12.7	2,038.8	0.0	0.0	1	1	1
12/28/2019 06:00	0.0	12.7	2,034.4	0.0	0.0	1	1	1
12/28/2019 07:00	0.0	12.5	2,072.9	0.0	0.0	1	1	1
12/28/2019 08:00	0.0	12.8	1,989.7	0.0	0.0	1	1	1
12/28/2019 09:00	0.0	13.6	1,675.3	0.0	0.0	1	1	0
12/28/2019 10:00	0.0	13.6	1,621.0	0.0	0.0	1	1	0
12/28/2019 11:00	0.0	13.6	1,660.3	0.0	0.0	1	1	0
12/28/2019 12:00	0.0	13.6	1,695.2	0.0	0.0	1	1	0
12/28/2019 13:00	0.0	13.6	1,651.6	0.0	0.0	1	1	0
12/28/2019 14:00	0.0	13.6	1,678.2	0.0	0.0	1	1	0
12/28/2019 15:00	0.0	13.7	1,609.8	0.0	0.0	1	1	1
12/28/2019 16:00	0.0	12.6	2,025.0	0.0	0.0	1	1	1
12/28/2019 17:00	0.0	12.3	2,086.2	0.0	0.0	1	1	1
12/28/2019 18:00	0.0	12.2	2,103.1	0.0	0.0	1	1	1
12/28/2019 19:00	0.0	12.2	2,102.3	0.0	0.0	1	1	1
12/28/2019 20:00	0.0	12.3	2,101.5	0.0	0.0	1	1	1
12/28/2019 21:00	0.0	12.4	2,083.1	0.0	0.0	1	1	1
12/28/2019 22:00	0.0	12.3	2,088.9	0.0	0.0	1	1	1
12/28/2019 23:00	0.0	12.3	2,094.9	0.0	0.0	1	1	1
Average/Sum#:	0.0	0.0	1,939.7	0.0	0.0 #	24 #	24 #	18 #
Minimum:	0.0	0.0	1,609.8	0.0	0.0	1	1	0
Maximum:	0.0	0.0	2,103.1	0.0	0.0	1	1	1
%SI	0.00	100.00	0.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/29/2019 00:00	0.0	12.4	2,084.2	0.0	0.0	1	1	1
12/29/2019 01:00	0.0	12.3	2,107.9	0.0	0.0	1	1	1
12/29/2019 02:00	0.0	12.4	2,077.9	0.0	0.0	1	1	1
12/29/2019 03:00	0.0	12.4	2,095.8	0.0	0.0	1	1	1
12/29/2019 04:00	0.0	12.4	2,083.9	0.0	0.0	1	1	1
12/29/2019 05:00	0.0	12.4	2,088.2	0.0	0.0	1	1	1
12/29/2019 06:00	0.0	12.4	2,080.9	0.0	0.0	1	1	1
12/29/2019 07:00	0.0	12.6	2,016.7	0.0	0.0	1	1	1
12/29/2019 08:00	0.0	13.6	1,678.2	0.0	0.0	1	1	0
12/29/2019 09:00	0.0	13.6	1,610.4	0.0	0.0	1	1	0
12/29/2019 10:00	0.0	13.6	1,684.2	0.0	0.0	1	1	0
12/29/2019 11:00	0.0	13.6	1,660.2	0.0	0.0	1	1	0
12/29/2019 12:00	0.0	13.6	1,695.1	0.0	0.0	1	1	0
12/29/2019 13:00	0.0	13.6	1,624.9	0.0	0.0	1	1	0
12/29/2019 14:00	0.0	13.6	1,678.3	0.0	0.0	1	1	0
12/29/2019 15:00	0.0	13.1	1,874.1	0.0	0.0	1	1	1
12/29/2019 16:00	0.0	12.5	2,054.9	0.0	0.0	1	1	1
12/29/2019 17:00	0.0	12.4	2,075.0	0.0	0.0	1	1	1
12/29/2019 18:00	0.0	12.3	2,111.6	0.0	0.0	1	1	1
12/29/2019 19:00	0.0	12.3	2,112.0	0.0	0.0	1	1	1
12/29/2019 20:00	0.0	12.3	2,110.1	0.0	0.0	1	1	1
12/29/2019 21:00	0.0	12.3	2,110.6	0.0	0.0	1	1	1
12/29/2019 22:00	0.0	12.3	2,104.5	0.0	0.0	1	1	1
12/29/2019 23:00	0.0	12.4	2,079.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.9	1,954.1	0.0	0.0 #	24 #	24 #	17 #
Minimum:	0.0	12.3	1,610.4	0.0	0.0	1	1	0
Maximum:	0.0	13.6	2,112.0	0.0	0.0	1	1	1
%SI	0.00	25.00	0.00	33.33	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/30/2019 00:00	0.0	12.5	2,060.5	0.0	0.0	1	1	1
12/30/2019 01:00	0.0	12.5	2,052.7	0.0	0.0	1	1	1
12/30/2019 02:00	0.0	12.6	2,033.9	0.0	0.0	1	1	1
12/30/2019 03:00	0.0	12.6	2,038.1	0.0	0.0	1	1	1
12/30/2019 04:00	0.0	12.7	2,032.3	0.0	0.0	1	1	1
12/30/2019 05:00	0.0	12.6	2,041.6	0.0	0.0	1	1	1
12/30/2019 06:00	0.0	12.5	2,054.6	0.0	0.0	1	1	1
12/30/2019 07:00	0.0	12.3	2,107.9	0.0	0.0	1	1	1
12/30/2019 08:00	0.0	12.4	2,086.6	0.0	0.0	1	1	1
12/30/2019 09:00	0.0	12.4	2,056.3	0.0	0.0	1	1	1
12/30/2019 10:00	0.0	12.5	2,035.9	0.0	0.0	1	1	1
12/30/2019 11:00	0.0	12.4	2,045.4	0.0	0.0	1	1	1
12/30/2019 12:00	0.0	12.4	2,046.0	0.0	0.0	1	1	1
12/30/2019 13:00	0.0	12.3	2,062.0	0.0	0.0	1	1	1
12/30/2019 14:00	0.0	12.3	2,055.5	0.0	0.0	1	1	1
12/30/2019 15:00	0.0	12.3	2,062.9	0.0	0.0	1	1	1
12/30/2019 16:00	0.0	12.3	2,072.2	0.0	0.0	1	1	1
12/30/2019 17:00	0.0	12.2	2,087.2	0.0	0.0	1	1	1
12/30/2019 18:00	0.0	12.2	2,114.9	0.0	0.0	1	1	1
12/30/2019 19:00	0.0	12.2	2,110.2	0.0	0.0	1	1	1
12/30/2019 20:00	0.0	12.3	2,094.3	0.0	0.0	1	1	1
12/30/2019 21:00	0.0	12.4	2,064.9	0.0	0.0	1	1	1
12/30/2019 22:00	0.0	12.4	2,066.9	0.0	0.0	1	1	1
12/30/2019 23:00	0.0	12.4	2,064.2	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.4	2,064.5	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.2	2,032.3	0.0	0.0	1	1	1
Maximum:	0.0	12.7	2,114.9	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/31/2019 00:00	0.0	12.5	2,046.7	0.0	0.0	1	1	1
12/31/2019 01:00	0.0	12.9	1,944.9	0.0	0.0	1	1	1
12/31/2019 02:00	0.0	12.9	1,936.4	0.0	0.0	1	1	1
12/31/2019 03:00	0.0	12.9	1,950.1	0.0	0.0	1	1	1
12/31/2019 04:00	0.0	12.5	2,044.1	0.0	0.0	1	1	1
12/31/2019 05:00	0.0	12.5	2,039.9	0.0	0.0	1	1	1
12/31/2019 06:00	0.0	12.5	2,033.5	0.0	0.0	1	1	1
12/31/2019 07:00	0.0	12.5	2,033.3	0.0	0.0	1	1	1
12/31/2019 08:00	0.0	13.0	1,901.4	0.0	0.0	1	1	1
12/31/2019 09:00	0.0	13.7	1,527.7	0.0	0.0	1	1	0
12/31/2019 10:00	0.0	13.7	1,626.9	0.0	0.0	1	1	0
12/31/2019 11:00	0.0	13.7	1,589.1	0.0	0.0	1	1	0
12/31/2019 12:00	0.0	13.7	1,570.3	0.0	0.0	1	1	0
12/31/2019 13:00	0.0	13.7	1,668.9	0.0	0.0	1	1	0
12/31/2019 14:00	0.0	13.7	1,573.5	0.0	0.0	1	1	0
12/31/2019 15:00	0.0	13.6	1,588.1	0.0	0.0	1	1	1
12/31/2019 16:00	0.0	12.6	1,992.0	0.0	0.0	1	1	1
12/31/2019 17:00	0.0	12.5	2,024.4	0.0	0.0	1	1	1
12/31/2019 18:00	0.0	12.6	2,020.8	0.0	0.0	1	1	1
12/31/2019 19:00	0.0	12.6	2,025.6	0.0	0.0	1	1	1
12/31/2019 20:00	0.0	12.6	2,029.6	0.0	0.0	1	1	1
12/31/2019 21:00	0.0	12.5	2,041.2	0.0	0.0	1	1	1
12/31/2019 22:00	0.0	12.5	2,037.7	0.0	0.0	1	1	1
12/31/2019 23:00	0.0	12.6	2,030.0	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.9	1,886.5	0.0	0.0 #	24 #	24 #	18 #
Minimum:	0.0	12.5	1,527.7	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,046.7	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Excess Emission Report

CT1 - CO Lb 1-Day Block Average

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 12:22 **Location:** Maxwell, CA

Tag Name: CT1_CO_Lb_1D
Total Operating Time: 2,059.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 149.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,059.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO Lb 1-Day Block Average

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:23 **Location:** Maxwell, CA

Tag Name: CT2_CO_Lb_1D

Total Operating Time: 2,145.00 Hour(s) **No Exclusions Allowed**

Non-Operating Time: 63.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,145.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 8

Hourly Emissions – NH_3

FCD: AQ-18

Title V: #6

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/01/2019 00:00	9.9	19.0	30.7	129.0	214,543.2	42.3	22.0	0.4
10/01/2019 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2019 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2019 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2019 04:00	38.8	17.6	69.4	224.4	1,821,776.2	412.4	3.2	0.5
10/01/2019 05:00	32.7	14.8	31.6	208.6	2,624,273.6	1,149.8	2.4	1.0
10/01/2019 06:00	8.6	13.9	7.2	106.7	3,225,689.1	1,625.3	1.1	0.7
10/01/2019 07:00	8.7	13.9	7.3	105.4	3,206,834.7	1,615.8	1.1	0.6
10/01/2019 08:00	8.7	14.0	7.4	105.9	3,279,972.8	1,628.7	1.1	0.7
10/01/2019 09:00	8.8	14.0	7.5	105.9	3,250,167.7	1,613.9	1.1	0.6
10/01/2019 10:00	8.8	14.0	7.5	104.5	3,210,293.3	1,594.1	1.1	0.6
10/01/2019 11:00	8.7	14.0	7.4	104.2	3,223,987.5	1,600.9	1.1	0.6
10/01/2019 12:00	8.8	14.0	7.5	103.4	3,190,960.2	1,584.5	1.1	0.6
10/01/2019 13:00	8.9	14.0	7.6	103.7	3,193,578.2	1,585.8	1.1	0.6
10/01/2019 14:00	8.9	13.9	7.5	102.5	3,090,929.8	1,557.4	1.1	0.6
10/01/2019 15:00	9.1	13.9	7.7	103.4	3,131,020.2	1,577.6	1.1	0.6
10/01/2019 16:00	11.6	13.4	9.1	152.1	3,299,978.8	1,976.0	1.5	1.2
10/01/2019 17:00	11.5	13.4	9.0	162.5	3,255,202.3	2,020.5	1.7	1.4
10/01/2019 18:00	11.6	13.4	9.1	170.4	3,245,058.1	2,037.9	1.8	1.4
10/01/2019 19:00	11.6	13.5	9.2	177.7	3,213,267.7	2,041.4	1.9	1.4
10/01/2019 20:00	11.5	13.5	9.2	179.7	3,215,471.4	2,042.8	1.9	1.4
10/01/2019 21:00	11.2	13.5	8.9	173.8	3,232,319.3	2,029.9	1.8	1.4
10/01/2019 22:00	11.3	13.5	9.0	168.6	3,220,886.2	1,999.2	1.8	1.4
10/01/2019 23:00	11.0	13.5	8.8	161.4	3,275,206.7	2,009.0	1.7	1.4
Average/Sum#:	12.4	14.2	13.3	140.7	2,981,972.2	1,606.9	2.5	0.9
Minimum:	8.6	13.4	7.2	102.5	214,543.2	42.3	1.1	0.4
Maximum:	38.8	19.0	69.4	224.4	3,299,978.8	2,042.8	22.0	1.4
%SI	12.50	12.50	12.50	12.50	12.50	12.50	12.50	12.50

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/02/2019 00:00	10.6	13.4	8.3	158.8	3,312,395.9	2,056.0	1.6	1.2
10/02/2019 01:00	10.7	13.4	8.4	159.4	3,293,868.4	2,044.5	1.7	1.4
10/02/2019 02:00	10.8	13.4	8.5	160.7	3,273,246.5	2,031.7	1.7	1.4
10/02/2019 03:00	10.8	13.4	8.5	162.5	3,268,091.0	2,028.5	1.7	1.4
10/02/2019 04:00	10.9	13.5	8.7	156.8	3,282,328.8	1,989.4	1.6	1.2
10/02/2019 05:00	11.3	13.4	8.9	179.4	3,217,988.1	2,020.9	1.9	1.4
10/02/2019 06:00	10.9	13.4	8.6	151.6	3,289,553.0	2,017.8	1.6	1.2
10/02/2019 07:00	10.6	13.5	8.5	144.0	3,294,663.9	1,924.7	1.5	1.2
10/02/2019 08:00	8.2	14.0	7.0	101.7	3,142,023.4	1,560.2	1.1	0.6
10/02/2019 09:00	9.0	14.0	7.7	86.9	2,525,983.8	1,254.3	1.1	0.5
10/02/2019 10:00	9.0	14.1	7.8	86.3	2,543,907.2	1,263.2	1.1	0.5
10/02/2019 11:00	8.9	14.1	7.7	86.5	2,628,272.9	1,285.9	1.1	0.5
10/02/2019 12:00	9.0	14.1	7.8	86.4	2,571,043.2	1,257.9	1.1	0.5
10/02/2019 13:00	8.9	14.1	7.7	86.1	2,608,651.3	1,276.3	1.1	0.5
10/02/2019 14:00	9.1	13.9	7.7	101.4	3,050,442.4	1,537.0	1.1	0.6
10/02/2019 15:00	11.4	13.4	9.0	148.2	3,283,946.5	1,966.4	1.5	1.2
10/02/2019 16:00	11.6	13.4	9.1	172.1	3,229,323.1	2,051.6	1.8	1.4
10/02/2019 17:00	11.4	13.3	8.9	177.0	3,224,683.2	2,072.2	1.9	1.5
10/02/2019 18:00	11.4	13.3	8.9	173.4	3,251,045.0	2,065.4	1.8	1.4
10/02/2019 19:00	11.3	13.4	8.9	174.2	3,211,922.6	2,064.0	1.9	1.4
10/02/2019 20:00	11.3	13.4	8.9	180.8	3,206,320.5	2,060.4	1.9	1.4
10/02/2019 21:00	11.1	13.4	8.7	171.2	3,204,453.1	2,035.8	1.8	1.4
10/02/2019 22:00	11.0	13.4	8.7	163.6	3,231,358.2	2,005.7	1.7	1.4
10/02/2019 23:00	10.8	13.4	8.5	150.7	3,291,795.6	1,971.1	1.6	1.2
Average/Sum#:	10.4	13.6	8.4	142.5	3,101,554.5	1,826.7	1.5	1.1
Minimum:	8.2	13.3	7.0	86.1	2,525,983.8	1,254.3	1.1	0.5
Maximum:	11.6	14.1	9.1	180.8	3,312,395.9	2,072.2	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/03/2019 00:00	10.7	13.4	8.4	150.0	3,258,240.1	1,974.8	1.6	1.2
10/03/2019 01:00	10.7	13.5	8.5	143.0	3,273,437.8	1,912.3	1.5	1.1
10/03/2019 02:00	10.8	13.4	8.5	149.7	3,281,107.4	1,964.7	1.5	1.2
10/03/2019 03:00	10.7	13.4	8.4	155.4	3,256,132.5	1,997.3	1.6	1.2
10/03/2019 04:00	10.6	13.4	8.3	153.6	3,285,151.3	2,015.1	1.6	1.2
10/03/2019 05:00	10.9	13.4	8.6	175.8	3,273,413.4	2,007.9	1.8	1.4
10/03/2019 06:00	10.8	13.4	8.5	153.2	3,265,513.3	2,026.9	1.6	1.2
10/03/2019 07:00	10.7	13.5	8.5	149.6	3,220,318.3	1,928.3	1.6	1.2
10/03/2019 08:00	8.9	13.9	7.5	97.1	2,877,974.3	1,450.1	1.1	0.6
10/03/2019 09:00	9.1	14.0	7.8	87.2	2,535,851.7	1,259.2	1.1	0.5
10/03/2019 10:00	9.2	14.0	7.9	86.8	2,512,088.2	1,247.4	1.1	0.5
10/03/2019 11:00	9.2	14.0	7.9	86.8	2,514,706.2	1,248.7	1.1	0.5
10/03/2019 12:00	8.8	14.0	7.5	86.4	2,633,322.5	1,307.6	1.1	0.5
10/03/2019 13:00	8.9	14.0	7.6	86.3	2,598,281.4	1,290.2	1.1	0.5
10/03/2019 14:00	8.8	14.0	7.5	87.5	2,704,613.2	1,343.0	1.1	0.5
10/03/2019 15:00	9.0	14.0	7.7	89.7	2,725,960.1	1,353.6	1.1	0.5
10/03/2019 16:00	9.0	13.9	7.6	103.6	3,167,141.2	1,595.8	1.1	0.6
10/03/2019 17:00	9.0	13.9	7.6	104.2	3,140,943.5	1,582.6	1.1	0.6
10/03/2019 18:00	9.0	13.9	7.6	104.1	3,146,897.5	1,585.6	1.1	0.6
10/03/2019 19:00	9.0	13.9	7.6	105.6	3,202,666.9	1,613.7	1.1	0.6
10/03/2019 20:00	8.7	14.0	7.4	104.0	3,211,703.0	1,594.8	1.1	0.6
10/03/2019 21:00	15.1	14.8	14.6	121.3	2,722,062.3	1,232.4	1.4	0.6
10/03/2019 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/03/2019 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	9.9	13.8	8.3	117.3	2,991,251.2	1,615.1	1.3	0.8
Minimum:	8.7	13.4	7.4	86.3	2,512,088.2	1,232.4	1.1	0.5
Maximum:	15.1	14.8	14.6	175.8	3,285,151.3	2,026.9	1.8	1.4
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/04/2019 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2019 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2019 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2019 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2019 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2019 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2019 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2019 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2019 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2019 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2019 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2019 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2019 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2019 13:00	40.8	17.7	75.2	19.5	1,831,723.2	387.9	0.0	0.0
10/04/2019 14:00	46.2	15.1	47.0	220.7	2,235,585.3	914.2	3.2	1.1
10/04/2019 15:00	8.4	14.1	7.3	95.7	2,891,325.0	1,414.6	1.1	0.6
10/04/2019 16:00	9.9	13.9	8.3	103.9	3,034,886.1	1,507.0	1.1	0.6
10/04/2019 17:00	11.2	13.5	8.9	148.8	3,319,586.1	1,963.5	1.5	1.2
10/04/2019 18:00	11.5	13.4	9.0	183.6	3,294,803.6	2,093.2	1.9	1.5
10/04/2019 19:00	11.8	13.5	9.4	185.2	3,242,032.6	2,036.0	2.0	1.6
10/04/2019 20:00	11.5	13.5	9.2	184.2	3,220,823.2	2,046.2	2.0	1.6
10/04/2019 21:00	11.3	13.5	9.0	180.0	3,244,739.6	2,037.7	1.9	1.4
10/04/2019 22:00	11.2	13.5	8.9	171.0	3,246,341.3	2,015.0	1.8	1.4
10/04/2019 23:00	11.2	13.5	8.9	169.6	3,259,393.1	1,999.3	1.8	1.4
Average/Sum#:	16.8	14.1	18.3	151.1	2,983,749.0	1,674.1	1.7	1.1
Minimum:	8.4	13.4	7.3	19.5	1,831,723.2	387.9	0.0	0.0
Maximum:	46.2	17.7	75.2	220.7	3,319,586.1	2,093.2	3.2	1.6
%SI	54.17	54.17	54.17	54.17	54.17	54.17	54.17	54.17

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/05/2019 00:00	11.2	13.5	8.9	157.8	3,272,924.3	1,959.8	1.6	1.2
10/05/2019 01:00	11.0	13.5	8.8	152.5	3,281,884.7	1,941.2	1.6	1.2
10/05/2019 02:00	11.0	13.5	8.8	146.9	3,301,179.5	1,904.4	1.5	1.1
10/05/2019 03:00	11.3	13.5	9.0	163.5	3,266,159.7	1,979.6	1.7	1.4
10/05/2019 04:00	11.1	13.5	8.9	166.5	3,274,065.5	2,008.3	1.7	1.4
10/05/2019 05:00	11.3	13.4	8.9	191.2	3,239,644.1	2,034.5	2.0	1.6
10/05/2019 06:00	11.1	13.5	8.9	155.3	3,308,495.9	1,981.1	1.6	1.2
10/05/2019 07:00	10.6	13.5	8.5	143.4	3,277,431.2	1,890.7	1.5	1.1
10/05/2019 08:00	8.5	13.9	7.2	99.0	2,967,681.6	1,495.3	1.1	0.6
10/05/2019 09:00	9.1	14.1	7.9	87.4	2,552,647.9	1,248.9	1.1	0.5
10/05/2019 10:00	9.2	14.1	8.0	87.0	2,541,406.4	1,243.4	1.1	0.5
10/05/2019 11:00	9.0	14.1	7.8	86.8	2,554,078.7	1,249.6	1.1	0.5
10/05/2019 12:00	8.6	14.1	7.5	85.7	2,651,777.9	1,297.4	1.1	0.5
10/05/2019 13:00	8.9	14.1	7.7	86.6	2,554,691.8	1,249.9	1.1	0.5
10/05/2019 14:00	8.6	14.0	7.4	93.6	2,921,574.9	1,429.4	1.1	0.6
10/05/2019 15:00	9.0	14.0	7.7	98.1	2,931,957.5	1,477.3	1.1	0.6
10/05/2019 16:00	11.2	13.4	8.8	146.8	3,263,963.8	1,930.6	1.5	1.2
10/05/2019 17:00	11.4	13.4	9.0	163.5	3,246,019.1	2,014.8	1.7	1.4
10/05/2019 18:00	11.4	13.4	9.0	167.7	3,256,813.4	2,021.5	1.8	1.4
10/05/2019 19:00	11.3	13.4	8.9	168.8	3,246,809.7	2,039.0	1.8	1.4
10/05/2019 20:00	11.3	13.3	8.8	181.3	3,232,464.0	2,077.2	1.9	1.5
10/05/2019 21:00	11.3	13.3	8.8	177.9	3,238,533.1	2,081.1	1.9	1.5
10/05/2019 22:00	11.2	13.3	8.7	171.3	3,225,073.1	2,048.9	1.8	1.4
10/05/2019 23:00	11.3	13.3	8.8	171.3	3,264,166.3	2,049.9	1.8	1.4
Average/Sum#:	10.4	13.6	8.4	139.6	3,077,976.8	1,777.2	1.5	1.1
Minimum:	8.5	13.3	7.2	85.7	2,541,406.4	1,243.4	1.1	0.5
Maximum:	11.4	14.1	9.0	191.2	3,308,495.9	2,081.1	2.0	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/06/2019 00:00	11.3	13.4	8.9	168.2	3,229,612.3	2,028.2	1.8	1.4
10/06/2019 01:00	11.2	13.4	8.8	157.1	3,257,415.1	1,974.3	1.6	1.2
10/06/2019 02:00	11.1	13.4	8.7	154.9	3,263,024.8	1,977.7	1.6	1.2
10/06/2019 03:00	11.2	13.4	8.8	157.1	3,262,199.9	1,977.2	1.6	1.2
10/06/2019 04:00	11.4	13.5	9.1	157.9	3,209,832.9	1,968.9	1.7	1.4
10/06/2019 05:00	11.6	13.5	9.2	187.8	3,183,508.9	1,976.0	2.0	1.6
10/06/2019 06:00	11.1	13.5	8.9	161.3	3,200,111.0	1,916.2	1.7	1.3
10/06/2019 07:00	8.4	14.0	7.2	98.0	2,977,491.1	1,478.5	1.1	0.6
10/06/2019 08:00	8.6	14.1	7.5	88.0	2,681,210.3	1,311.8	1.1	0.5
10/06/2019 09:00	9.1	14.1	7.9	86.8	2,524,850.7	1,235.3	1.1	0.5
10/06/2019 10:00	8.5	14.1	7.4	86.3	2,636,857.3	1,290.1	1.1	0.5
10/06/2019 11:00	8.5	14.1	7.4	87.6	2,698,992.4	1,320.5	1.1	0.5
10/06/2019 12:00	8.5	14.1	7.4	88.4	2,768,485.6	1,354.5	1.0	0.5
10/06/2019 13:00	8.4	14.1	7.3	86.9	2,711,255.9	1,326.5	1.1	0.5
10/06/2019 14:00	8.9	13.9	7.5	101.9	3,077,830.9	1,550.8	1.1	0.6
10/06/2019 15:00	11.4	13.4	9.0	153.3	3,221,081.8	1,975.8	1.6	1.2
10/06/2019 16:00	11.4	13.3	8.9	172.6	3,217,360.3	2,044.0	1.8	1.4
10/06/2019 17:00	11.4	13.3	8.9	189.9	3,180,525.8	2,113.5	2.1	1.7
10/06/2019 18:00	11.4	13.3	8.9	199.2	3,193,140.4	2,145.2	2.2	1.7
10/06/2019 19:00	11.2	13.3	8.7	180.8	3,203,068.2	2,081.7	1.9	1.5
10/06/2019 20:00	11.2	13.3	8.7	174.9	3,211,611.4	2,063.8	1.9	1.4
10/06/2019 21:00	11.1	13.3	8.6	174.2	3,220,014.7	2,069.2	1.9	1.4
10/06/2019 22:00	10.9	13.4	8.6	162.6	3,269,379.9	2,029.3	1.7	1.4
10/06/2019 23:00	11.0	13.5	8.8	156.0	3,252,630.4	1,971.4	1.6	1.2
Average/Sum#:	10.4	13.6	8.4	143.0	3,068,812.2	1,799.2	1.6	1.1
Minimum:	8.4	13.3	7.2	86.3	2,524,850.7	1,235.3	1.0	0.5
Maximum:	11.6	14.1	9.2	199.2	3,269,379.9	2,145.2	2.2	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/07/2019 00:00	11.0	13.5	8.8	160.1	3,222,272.1	1,953.0	1.7	1.4
10/07/2019 01:00	10.9	13.5	8.7	163.1	3,215,864.9	1,972.6	1.7	1.4
10/07/2019 02:00	10.9	13.5	8.7	157.2	3,210,887.7	1,946.1	1.7	1.4
10/07/2019 03:00	10.6	13.5	8.5	157.7	3,266,159.7	1,979.6	1.6	1.2
10/07/2019 04:00	10.7	13.4	8.4	169.9	3,216,554.9	2,020.0	1.8	1.4
10/07/2019 05:00	11.1	13.4	8.7	160.4	3,194,421.2	2,006.1	1.7	1.4
10/07/2019 06:00	11.0	13.4	8.7	166.6	3,268,735.5	2,028.9	1.7	1.4
10/07/2019 07:00	10.9	13.4	8.6	162.8	3,287,596.7	2,016.6	1.7	1.4
10/07/2019 08:00	11.1	13.4	8.7	164.2	3,239,574.8	2,010.8	1.7	1.4
10/07/2019 09:00	11.2	13.4	8.8	168.8	3,268,735.5	2,028.9	1.8	1.4
10/07/2019 10:00	11.1	13.4	8.7	167.0	3,231,680.4	2,005.9	1.8	1.4
10/07/2019 11:00	11.2	13.4	8.8	158.5	3,235,428.1	1,984.6	1.7	1.4
10/07/2019 12:00	11.2	13.4	8.8	159.9	3,197,686.5	1,984.8	1.7	1.4
10/07/2019 13:00	11.3	13.4	8.9	166.4	3,198,402.1	2,008.6	1.8	1.4
10/07/2019 14:00	11.3	13.4	8.9	168.2	3,199,357.5	2,009.2	1.8	1.4
10/07/2019 15:00	11.2	13.4	8.8	165.2	3,193,306.6	2,005.4	1.8	1.4
10/07/2019 16:00	11.2	13.3	8.7	179.0	3,174,910.4	2,063.4	1.9	1.4
10/07/2019 17:00	11.3	13.3	8.8	193.8	3,142,680.1	2,111.3	2.1	1.7
10/07/2019 18:00	11.3	13.3	8.8	192.4	3,173,452.9	2,108.8	2.1	1.7
10/07/2019 19:00	11.0	13.3	8.5	175.7	3,161,216.2	2,054.5	1.9	1.4
10/07/2019 20:00	11.0	13.3	8.5	173.2	3,184,378.5	2,046.3	1.9	1.4
10/07/2019 21:00	11.0	13.4	8.7	161.8	3,235,385.9	2,008.2	1.7	1.4
10/07/2019 22:00	11.1	13.4	8.7	166.5	3,226,427.5	2,026.2	1.8	1.4
10/07/2019 23:00	10.9	13.4	8.6	151.0	3,235,801.3	1,961.2	1.6	1.2
Average/Sum#:	11.1	13.4	8.7	167.1	3,215,871.5	2,014.2	1.8	1.4
Minimum:	10.6	13.3	8.4	151.0	3,142,680.1	1,946.1	1.6	1.2
Maximum:	11.3	13.5	8.9	193.8	3,287,596.7	2,111.3	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/08/2019 00:00	11.0	13.4	8.7	147.9	3,234,884.7	1,913.4	1.5	1.1
10/08/2019 01:00	11.0	13.5	8.8	138.3	3,251,680.6	1,852.1	1.4	0.9
10/08/2019 02:00	11.0	13.5	8.8	139.6	3,301,379.8	1,856.3	1.4	0.9
10/08/2019 03:00	11.0	13.4	8.7	143.9	3,269,500.7	1,910.0	1.5	1.1
10/08/2019 04:00	11.0	13.4	8.7	145.1	3,254,496.2	1,925.0	1.5	1.2
10/08/2019 05:00	10.9	13.4	8.6	173.2	3,204,453.1	2,012.4	1.9	1.4
10/08/2019 06:00	11.0	13.4	8.7	158.4	3,195,854.3	2,007.0	1.7	1.4
10/08/2019 07:00	10.9	13.4	8.6	154.8	3,219,614.5	1,974.9	1.6	1.2
10/08/2019 08:00	10.8	13.4	8.5	153.3	3,209,506.9	1,968.7	1.6	1.2
10/08/2019 09:00	10.7	13.5	8.5	155.5	3,195,975.7	1,960.4	1.7	1.4
10/08/2019 10:00	10.6	13.5	8.5	160.1	3,160,631.5	1,961.8	1.7	1.4
10/08/2019 11:00	10.6	13.5	8.5	161.0	3,128,657.0	1,964.8	1.8	1.4
10/08/2019 12:00	10.7	13.5	8.5	171.6	3,119,296.9	1,981.7	1.9	1.4
10/08/2019 13:00	10.8	13.4	8.5	163.9	3,170,376.7	1,991.0	1.8	1.4
10/08/2019 14:00	11.1	13.4	8.7	159.0	3,181,575.6	1,974.8	1.7	1.4
10/08/2019 15:00	11.2	13.3	8.7	166.7	3,185,026.3	2,000.2	1.8	1.4
10/08/2019 16:00	11.2	13.3	8.7	173.3	3,185,779.1	2,047.2	1.9	1.4
10/08/2019 17:00	11.1	13.3	8.6	186.3	3,145,763.4	2,090.4	2.1	1.7
10/08/2019 18:00	11.0	13.3	8.5	179.2	3,150,132.6	2,070.3	2.0	1.7
10/08/2019 19:00	11.1	13.3	8.6	174.1	3,163,831.9	2,056.2	1.9	1.4
10/08/2019 20:00	10.9	13.3	8.5	172.2	3,165,678.3	2,057.4	1.9	1.4
10/08/2019 21:00	11.1	13.4	8.7	170.3	3,185,721.9	2,023.9	1.8	1.4
10/08/2019 22:00	10.9	13.4	8.6	154.6	3,162,718.2	1,940.0	1.7	1.4
10/08/2019 23:00	10.9	13.4	8.6	164.3	3,170,136.9	1,967.7	1.8	1.4
Average/Sum#:	10.9	13.4	8.6	161.1	3,192,194.7	1,979.5	1.7	1.3
Minimum:	10.6	13.3	8.5	138.3	3,119,296.9	1,852.1	1.4	0.9
Maximum:	11.2	13.5	8.8	186.3	3,301,379.8	2,090.4	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/09/2019 00:00	11.0	13.5	8.8	166.1	3,182,703.4	1,975.5	1.8	1.4
10/09/2019 01:00	10.9	13.5	8.7	152.9	3,244,508.7	1,895.4	1.6	1.1
10/09/2019 02:00	11.0	13.5	8.8	156.0	3,246,212.0	1,920.1	1.6	1.2
10/09/2019 03:00	10.8	13.5	8.6	165.0	3,230,700.4	1,981.7	1.7	1.4
10/09/2019 04:00	10.8	13.4	8.5	166.3	3,232,969.3	2,006.7	1.8	1.4
10/09/2019 05:00	11.1	13.4	8.7	159.0	3,223,141.7	2,000.6	1.7	1.4
10/09/2019 06:00	11.3	13.4	8.9	181.4	3,239,082.2	2,057.8	1.9	1.4
10/09/2019 07:00	10.9	13.4	8.6	173.4	3,253,591.2	2,019.5	1.8	1.4
10/09/2019 08:00	11.0	13.5	8.8	165.5	3,231,352.5	1,982.1	1.7	1.4
10/09/2019 09:00	11.1	13.5	8.9	172.4	3,254,665.3	1,996.4	1.8	1.4
10/09/2019 10:00	11.1	13.5	8.9	177.4	3,230,230.5	2,005.0	1.9	1.4
10/09/2019 11:00	8.1	14.0	6.9	109.7	3,271,917.3	1,624.7	1.1	0.6
10/09/2019 12:00	8.2	14.0	7.0	104.7	3,288,253.7	1,608.8	1.1	0.6
10/09/2019 13:00	8.3	14.0	7.1	104.0	3,131,551.3	1,555.0	1.1	0.6
10/09/2019 14:00	8.3	14.1	7.2	96.2	3,015,799.5	1,475.5	1.0	0.6
10/09/2019 15:00	8.8	14.0	7.5	97.7	2,988,567.3	1,484.0	1.1	0.6
10/09/2019 16:00	11.4	13.6	9.2	151.0	3,168,917.4	1,828.1	1.6	1.1
10/09/2019 17:00	11.1	13.4	8.7	160.4	3,279,853.9	1,987.9	1.7	1.4
10/09/2019 18:00	11.0	13.4	8.7	155.1	3,295,302.7	1,973.2	1.6	1.2
10/09/2019 19:00	11.6	13.5	9.2	167.6	3,227,439.8	1,979.7	1.8	1.4
10/09/2019 20:00	11.4	13.5	9.1	170.9	3,239,829.9	1,987.3	1.8	1.4
10/09/2019 21:00	11.0	13.5	8.8	168.8	3,232,330.6	1,982.7	1.8	1.4
10/09/2019 22:00	11.1	13.5	8.9	167.5	3,245,535.8	1,990.8	1.8	1.4
10/09/2019 23:00	11.0	13.5	8.8	162.7	3,265,499.7	1,979.2	1.7	1.4
Average/Sum#:	10.5	13.6	8.5	152.2	3,217,498.2	1,887.4	1.6	1.2
Minimum:	8.1	13.4	6.9	96.2	2,988,567.3	1,475.5	1.0	0.6
Maximum:	11.6	14.1	9.2	181.4	3,295,302.7	2,057.8	1.9	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/10/2019 00:00	10.9	13.5	8.7	164.2	3,264,014.8	1,978.3	1.7	1.4
10/10/2019 01:00	10.8	13.6	8.7	143.5	3,332,325.3	1,873.7	1.4	0.9
10/10/2019 02:00	10.9	13.5	8.7	153.6	3,320,940.8	1,915.8	1.6	1.1
10/10/2019 03:00	10.8	13.5	8.6	155.0	3,287,620.5	1,968.6	1.6	1.2
10/10/2019 04:00	10.8	13.5	8.6	154.6	3,289,791.6	1,969.9	1.6	1.2
10/10/2019 05:00	11.1	13.5	8.9	170.0	3,287,286.5	1,968.4	1.8	1.4
10/10/2019 06:00	11.1	13.5	8.9	160.9	3,302,787.6	2,001.8	1.7	1.4
10/10/2019 07:00	10.9	13.5	8.7	154.6	3,264,536.6	1,907.1	1.6	1.1
10/10/2019 08:00	8.2	14.0	7.0	96.2	2,913,651.8	1,446.8	1.1	0.6
10/10/2019 09:00	8.1	14.0	6.9	102.0	3,172,029.9	1,575.1	1.1	0.6
10/10/2019 10:00	8.4	14.0	7.2	104.8	3,242,112.2	1,609.9	1.1	0.6
10/10/2019 11:00	8.5	14.0	7.3	104.8	3,228,015.2	1,602.9	1.1	0.6
10/10/2019 12:00	8.6	14.0	7.4	105.7	3,297,246.9	1,613.2	1.1	0.6
10/10/2019 13:00	8.7	14.0	7.4	104.2	3,223,870.3	1,577.3	1.1	0.6
10/10/2019 14:00	9.0	14.0	7.7	105.8	3,207,473.8	1,592.7	1.1	0.6
10/10/2019 15:00	9.8	14.0	8.4	106.7	3,009,914.2	1,494.6	1.2	0.7
10/10/2019 16:00	11.9	13.5	9.5	171.5	3,189,792.2	1,979.9	1.8	1.4
10/10/2019 17:00	11.4	13.5	9.1	170.5	3,191,737.0	1,957.8	1.8	1.4
10/10/2019 18:00	11.0	13.4	8.7	169.7	3,235,981.7	2,032.2	1.8	1.4
10/10/2019 19:00	11.0	13.4	8.7	162.3	3,249,885.7	2,017.2	1.7	1.4
10/10/2019 20:00	11.1	13.4	8.7	162.2	3,254,074.6	2,019.8	1.7	1.4
10/10/2019 21:00	11.1	13.4	8.7	161.6	3,261,002.2	2,024.1	1.7	1.4
10/10/2019 22:00	11.1	13.4	8.7	160.8	3,250,046.8	2,017.3	1.7	1.4
10/10/2019 23:00	11.3	13.5	9.0	158.9	3,229,002.5	1,933.5	1.7	1.4
Average/Sum#:	10.3	13.7	8.3	141.8	3,229,380.9	1,836.6	1.5	1.1
Minimum:	8.1	13.4	6.9	96.2	2,913,651.8	1,446.8	1.1	0.6
Maximum:	11.9	14.0	9.5	171.5	3,332,325.3	2,032.2	1.8	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/11/2019 00:00	11.0	13.5	8.8	158.4	3,247,733.6	1,921.0	1.7	1.3
10/11/2019 01:00	10.9	13.6	8.8	140.9	3,289,286.2	1,849.5	1.4	0.9
10/11/2019 02:00	10.9	13.6	8.8	142.6	3,288,752.7	1,849.2	1.5	1.1
10/11/2019 03:00	10.9	13.6	8.8	144.2	3,294,266.0	1,852.3	1.5	1.1
10/11/2019 04:00	10.9	13.6	8.8	142.0	3,297,111.5	1,853.9	1.4	0.9
10/11/2019 05:00	8.8	13.9	7.4	124.0	3,295,076.7	1,636.2	1.3	0.8
10/11/2019 06:00	8.3	14.0	7.1	106.0	3,260,841.1	1,619.2	1.1	0.6
10/11/2019 07:00	8.5	14.1	7.4	93.5	2,824,284.5	1,381.8	1.1	0.6
10/11/2019 08:00	9.0	14.1	7.8	87.1	2,522,602.4	1,234.2	1.1	0.5
10/11/2019 09:00	9.0	14.1	7.8	86.9	2,518,310.1	1,232.1	1.1	0.5
10/11/2019 10:00	8.9	14.1	7.7	86.7	2,515,039.9	1,230.5	1.1	0.5
10/11/2019 11:00	8.9	14.1	7.7	86.6	2,515,244.2	1,230.6	1.1	0.5
10/11/2019 12:00	8.9	14.1	7.7	86.4	2,518,718.9	1,232.3	1.1	0.5
10/11/2019 13:00	8.8	14.1	7.6	87.4	2,583,715.5	1,264.1	1.1	0.5
10/11/2019 14:00	8.6	13.9	7.2	105.1	3,193,934.3	1,609.3	1.1	0.6
10/11/2019 15:00	9.1	13.9	7.7	102.8	3,060,961.2	1,542.3	1.1	0.6
10/11/2019 16:00	11.1	13.4	8.7	143.3	3,280,105.4	1,964.1	1.5	1.2
10/11/2019 17:00	11.2	13.3	8.7	180.5	3,205,366.0	2,106.6	1.9	1.5
10/11/2019 18:00	11.1	13.3	8.6	189.7	3,187,484.1	2,141.4	2.1	1.7
10/11/2019 19:00	10.9	13.4	8.6	163.3	3,229,323.1	2,051.6	1.7	1.4
10/11/2019 20:00	10.9	13.4	8.6	162.6	3,243,784.2	2,037.1	1.7	1.4
10/11/2019 21:00	10.8	13.4	8.5	161.5	3,259,707.7	2,047.1	1.7	1.4
10/11/2019 22:00	10.9	13.4	8.6	161.0	3,279,852.0	2,035.8	1.7	1.4
10/11/2019 23:00	10.8	13.5	8.6	163.0	3,271,957.6	2,030.9	1.7	1.4
Average/Sum#:	10.0	13.7	8.2	129.4	3,049,310.8	1,706.4	1.4	1.0
Minimum:	8.3	13.3	7.1	86.4	2,515,039.9	1,230.5	1.1	0.5
Maximum:	11.2	14.1	8.8	189.7	3,297,111.5	2,141.4	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/12/2019 00:00	10.7	13.5	8.5	167.9	3,227,223.7	2,026.7	1.8	1.4
10/12/2019 01:00	10.6	13.5	8.5	160.2	3,206,869.7	1,990.5	1.7	1.4
10/12/2019 02:00	10.5	13.5	8.4	161.5	3,225,397.2	2,002.0	1.7	1.4
10/12/2019 03:00	10.5	13.4	8.3	162.6	3,250,046.8	2,017.3	1.7	1.4
10/12/2019 04:00	10.4	13.4	8.2	163.1	3,217,510.4	2,020.6	1.7	1.4
10/12/2019 05:00	10.9	13.4	8.6	160.4	3,200,360.5	2,033.2	1.7	1.4
10/12/2019 06:00	10.6	13.4	8.3	162.1	3,244,898.8	2,037.8	1.7	1.4
10/12/2019 07:00	16.8	14.8	16.2	154.7	2,456,505.7	1,219.8	2.1	1.0
10/12/2019 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2019 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2019 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2019 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2019 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2019 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2019 14:00	42.7	17.5	74.1	159.9	1,780,708.2	390.1	0.0	0.0
10/12/2019 15:00	38.9	15.1	39.6	219.9	2,376,311.7	989.1	2.9	1.1
10/12/2019 16:00	9.3	14.0	8.0	108.4	3,231,036.0	1,604.4	1.1	0.6
10/12/2019 17:00	10.7	13.6	8.6	116.3	3,222,588.7	1,741.4	1.2	0.9
10/12/2019 18:00	11.6	13.3	9.0	136.0	3,216,714.2	2,020.1	1.4	1.0
10/12/2019 19:00	11.5	13.3	8.9	139.0	3,214,527.0	2,042.2	1.5	1.2
10/12/2019 20:00	11.4	13.3	8.9	166.2	3,243,625.0	2,037.0	1.7	1.4
10/12/2019 21:00	11.3	13.3	8.8	173.4	3,230,424.9	2,052.3	1.8	1.4
10/12/2019 22:00	11.3	13.3	8.8	163.6	3,232,319.3	2,029.9	1.7	1.4
10/12/2019 23:00	11.2	13.4	8.8	166.4	3,274,357.4	2,056.3	1.7	1.4
Average/Sum#:	14.5	13.8	14.4	157.9	3,058,412.5	1,795.0	1.6	1.2
Minimum:	9.3	13.3	8.0	108.4	1,780,708.2	390.1	0.0	0.0
Maximum:	42.7	17.5	74.1	219.9	3,274,357.4	2,056.3	2.9	1.4
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/13/2019 00:00	11.3	13.4	8.9	175.3	3,227,383.0	2,026.8	1.9	1.4
10/13/2019 01:00	11.1	13.4	8.7	171.9	3,228,179.1	2,027.3	1.8	1.4
10/13/2019 02:00	11.1	13.4	8.7	170.1	3,225,949.8	2,025.9	1.8	1.4
10/13/2019 03:00	11.2	13.4	8.8	174.8	3,227,542.2	2,026.9	1.9	1.4
10/13/2019 04:00	11.1	13.4	8.7	171.2	3,229,771.5	2,028.3	1.8	1.4
10/13/2019 05:00	11.3	13.4	8.9	167.4	3,231,523.1	2,029.4	1.8	1.4
10/13/2019 06:00	11.0	13.4	8.7	160.8	3,172,231.3	1,969.0	1.7	1.4
10/13/2019 07:00	8.4	14.0	7.2	98.0	2,974,873.1	1,477.2	1.1	0.6
10/13/2019 08:00	8.5	14.0	7.3	103.0	3,196,599.0	1,587.3	1.1	0.6
10/13/2019 09:00	8.9	14.0	7.6	105.6	3,247,146.9	1,612.4	1.1	0.6
10/13/2019 10:00	8.9	14.0	7.6	105.4	3,233,251.2	1,605.5	1.1	0.6
10/13/2019 11:00	8.5	14.0	7.3	97.2	2,988,970.1	1,484.2	1.1	0.6
10/13/2019 12:00	9.3	14.0	8.0	106.6	3,249,563.5	1,613.6	1.1	0.6
10/13/2019 13:00	8.6	14.0	7.4	98.8	3,030,858.4	1,505.0	1.1	0.6
10/13/2019 14:00	9.9	13.9	8.3	107.4	3,223,383.3	1,600.6	1.1	0.6
10/13/2019 15:00	9.2	13.9	7.8	106.3	2,994,871.6	1,509.0	1.2	0.8
10/13/2019 16:00	11.8	13.4	9.3	154.5	3,221,244.8	1,975.9	1.6	1.2
10/13/2019 17:00	11.7	13.3	9.1	173.9	3,175,064.3	2,063.5	1.9	1.4
10/13/2019 18:00	11.5	13.3	8.9	168.9	3,205,082.7	2,036.2	1.8	1.4
10/13/2019 19:00	11.4	13.3	8.9	165.4	3,212,414.8	2,017.4	1.8	1.4
10/13/2019 20:00	11.1	13.3	8.6	158.9	3,246,341.3	2,015.0	1.7	1.4
10/13/2019 21:00	11.4	13.3	8.9	171.3	3,209,962.2	2,039.3	1.8	1.4
10/13/2019 22:00	10.1	13.5	8.1	137.2	3,122,981.0	1,801.6	1.5	1.1
10/13/2019 23:00	18.2	15.2	18.8	131.1	2,247,944.9	968.5	1.8	0.7
Average/Sum#:	10.6	13.7	8.8	140.9	3,138,463.9	1,793.6	1.5	1.1
Minimum:	8.4	13.3	7.2	97.2	2,247,944.9	968.5	1.1	0.6
Maximum:	18.2	15.2	18.8	175.3	3,249,563.5	2,063.5	1.9	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/14/2019 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2019 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2019 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2019 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2019 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2019 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2019 06:00	32.5	17.7	59.9	197.9	2,030,034.7	370.6	2.4	0.3
10/14/2019 07:00	36.4	14.8	35.2	214.3	2,283,743.4	1,000.6	3.0	1.2
10/14/2019 08:00	8.6	13.9	7.2	98.2	2,897,027.2	1,459.7	1.1	0.6
10/14/2019 09:00	8.8	14.1	7.6	86.5	2,519,539.5	1,251.1	1.1	0.5
10/14/2019 10:00	8.9	14.1	7.7	86.4	2,528,734.1	1,237.2	1.1	0.5
10/14/2019 11:00	8.4	14.1	7.3	88.1	2,669,968.8	1,306.3	1.1	0.5
10/14/2019 12:00	8.7	14.0	7.4	94.9	2,900,561.7	1,440.3	1.1	0.6
10/14/2019 13:00	9.3	13.9	7.8	107.2	3,045,404.2	1,556.7	1.2	0.8
10/14/2019 14:00	11.8	13.4	9.3	132.7	3,402,317.3	1,937.9	1.3	1.0
10/14/2019 15:00	11.8	13.4	9.3	157.5	3,210,575.2	1,992.8	1.7	1.4
10/14/2019 16:00	11.7	13.3	9.1	174.9	3,194,026.8	2,052.5	1.9	1.4
10/14/2019 17:00	11.6	13.3	9.0	189.6	3,177,516.0	2,111.5	2.1	1.7
10/14/2019 18:00	11.4	13.3	8.9	191.5	3,192,842.7	2,145.0	2.1	1.7
10/14/2019 19:00	11.5	13.3	8.9	197.9	3,194,033.5	2,145.8	2.1	1.7
10/14/2019 20:00	11.3	13.3	8.8	184.7	3,213,377.4	2,088.4	2.0	1.7
10/14/2019 21:00	11.1	13.3	8.6	161.6	3,244,898.8	2,037.8	1.7	1.4
10/14/2019 22:00	11.3	13.3	8.8	162.5	3,270,829.9	2,030.2	1.7	1.4
10/14/2019 23:00	11.4	13.3	8.9	167.4	3,265,513.3	2,026.9	1.7	1.4
Average/Sum#:	13.1	13.9	12.8	149.7	2,957,830.3	1,677.3	1.7	1.1
Minimum:	8.4	13.3	7.2	86.4	2,030,034.7	370.6	1.1	0.3
Maximum:	36.4	17.7	59.9	214.3	3,402,317.3	2,145.8	3.0	1.7
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/15/2019 00:00	11.4	13.3	8.9	164.9	3,273,246.5	2,031.7	1.7	1.4
10/15/2019 01:00	11.2	13.3	8.7	158.7	3,258,585.6	2,022.6	1.7	1.4
10/15/2019 02:00	11.2	13.3	8.7	161.8	3,271,635.4	2,030.7	1.7	1.4
10/15/2019 03:00	11.1	13.4	8.7	157.6	3,295,095.9	2,021.2	1.6	1.2
10/15/2019 04:00	11.2	13.4	8.8	166.5	3,252,141.2	2,018.6	1.7	1.4
10/15/2019 05:00	18.2	14.6	17.0	163.8	3,126,079.8	1,483.8	1.6	0.9
10/15/2019 06:00	42.8	17.0	64.7	212.4	1,899,069.4	471.5	2.9	0.5
10/15/2019 07:00	20.2	14.0	17.3	179.6	2,947,979.4	1,506.9	2.0	1.2
10/15/2019 08:00	8.6	13.9	7.2	97.6	2,961,581.6	1,470.6	1.1	0.6
10/15/2019 09:00	8.5	14.0	7.3	86.0	2,627,683.7	1,304.8	1.1	0.5
10/15/2019 10:00	8.8	14.0	7.5	86.0	2,577,135.9	1,279.7	1.1	0.5
10/15/2019 11:00	8.7	14.0	7.4	86.0	2,644,197.4	1,313.0	1.1	0.5
10/15/2019 12:00	8.9	14.0	7.6	91.6	2,809,535.2	1,395.1	1.1	0.6
10/15/2019 13:00	9.3	14.0	8.0	106.0	3,245,133.0	1,611.4	1.1	0.6
10/15/2019 14:00	9.3	14.0	8.0	129.7	3,139,307.6	1,604.7	1.4	0.8
10/15/2019 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2019 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2019 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2019 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2019 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2019 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2019 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2019 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2019 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	13.3	14.0	13.1	136.5	2,955,227.2	1,571.1	1.5	0.9
Minimum:	8.5	13.3	7.2	86.0	1,899,069.4	471.5	1.1	0.5
Maximum:	42.8	17.0	64.7	212.4	3,295,095.9	2,031.7	2.9	1.4
%SI	37.50	37.50	37.50	37.50	37.50	37.50	37.50	37.50

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/16/2019 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2019 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2019 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2019 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2019 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2019 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2019 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2019 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2019 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2019 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2019 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2019 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2019 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2019 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2019 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2019 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2019 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2019 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2019 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2019 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2019 20:00	35.5	17.6	63.5	0.0	1,814,487.3	371.0	0.0	0.0
10/16/2019 21:00	42.0	15.6	46.8	145.3	2,156,580.1	818.9	0.0	0.0
10/16/2019 22:00	9.2	14.0	7.9	101.5	2,776,756.0	1,399.1	1.2	0.7
10/16/2019 23:00	9.0	13.9	7.6	106.7	3,154,240.8	1,589.3	1.1	0.6
Average/Sum#:	23.9	15.3	31.5	88.4	2,475,516.1	1,044.6	0.6	0.3
Minimum:	9.0	13.9	7.6	0.0	1,814,487.3	371.0	0.0	0.0
Maximum:	42.0	17.6	63.5	145.3	3,154,240.8	1,589.3	1.2	0.7
%SI	83.33	83.33	83.33	83.33	83.33	83.33	83.33	83.33

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/17/2019 00:00	9.0	13.9	7.6	105.6	3,102,639.3	1,563.3	1.1	0.6
10/17/2019 01:00	9.2	13.9	7.8	107.1	3,225,689.1	1,625.3	1.1	0.7
10/17/2019 02:00	11.4	13.4	9.0	142.2	3,267,104.2	1,908.6	1.5	1.1
10/17/2019 03:00	11.4	13.4	9.0	147.8	3,274,276.8	1,936.7	1.5	1.2
10/17/2019 04:00	11.4	13.4	9.0	156.5	3,265,169.7	1,979.0	1.6	1.2
10/17/2019 05:00	11.3	13.4	8.9	151.9	3,275,596.3	1,961.4	1.6	1.2
10/17/2019 06:00	11.4	13.3	8.9	162.4	3,252,302.4	2,018.7	1.7	1.4
10/17/2019 07:00	11.3	13.4	8.9	162.3	3,266,654.6	1,979.9	1.7	1.4
10/17/2019 08:00	9.6	13.8	8.0	109.9	2,927,096.4	1,517.6	1.2	0.8
10/17/2019 09:00	9.1	13.9	7.7	98.8	2,915,484.7	1,469.0	1.1	0.6
10/17/2019 10:00	9.1	13.9	7.7	100.0	2,943,667.0	1,483.2	1.1	0.6
10/17/2019 11:00	9.0	14.0	7.7	102.1	3,075,566.1	1,527.2	1.1	0.6
10/17/2019 12:00	9.2	14.1	8.0	90.6	2,627,079.6	1,304.5	1.1	0.5
10/17/2019 13:00	9.1	14.0	7.8	97.6	2,933,186.2	1,456.5	1.1	0.6
10/17/2019 14:00	9.0	14.0	7.7	103.0	3,117,857.1	1,548.2	1.1	0.6
10/17/2019 15:00	10.0	14.0	8.6	107.7	2,993,803.4	1,486.6	1.2	0.7
10/17/2019 16:00	11.5	13.4	9.0	151.9	3,274,784.0	1,937.0	1.6	1.2
10/17/2019 17:00	11.4	13.3	8.9	195.1	3,245,535.8	2,133.0	2.1	1.7
10/17/2019 18:00	11.0	13.3	8.5	173.0	3,235,109.5	2,078.9	1.8	1.5
10/17/2019 19:00	11.1	13.4	8.7	169.5	3,263,529.4	2,049.5	1.8	1.4
10/17/2019 20:00	10.9	13.4	8.6	171.4	3,249,156.1	2,064.2	1.8	1.4
10/17/2019 21:00	11.1	13.4	8.7	176.4	3,218,304.7	2,044.6	1.9	1.4
10/17/2019 22:00	10.7	13.5	8.5	160.3	3,238,771.2	1,963.0	1.7	1.4
10/17/2019 23:00	10.8	13.5	8.6	150.9	3,248,579.0	1,921.5	1.6	1.2
Average/Sum#:	10.4	13.6	8.4	137.3	3,143,205.9	1,789.9	1.5	1.0
Minimum:	9.0	13.3	7.6	90.6	2,627,079.6	1,304.5	1.1	0.5
Maximum:	11.5	14.1	9.0	195.1	3,275,596.3	2,133.0	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/18/2019 00:00	10.9	13.5	8.7	148.1	3,251,184.7	1,899.3	1.5	1.1
10/18/2019 01:00	10.8	13.5	8.6	144.9	3,243,652.8	1,894.9	1.5	1.1
10/18/2019 02:00	10.5	13.5	8.4	139.6	3,278,793.2	1,843.6	1.4	0.9
10/18/2019 03:00	10.8	13.5	8.6	142.9	3,322,785.4	1,892.6	1.4	0.9
10/18/2019 04:00	10.9	13.4	8.6	153.2	3,274,594.3	1,960.8	1.6	1.2
10/18/2019 05:00	11.0	13.4	8.7	158.9	3,252,382.9	1,947.5	1.7	1.4
10/18/2019 06:00	11.2	13.4	8.8	159.8	3,278,141.1	2,010.8	1.7	1.4
10/18/2019 07:00	9.9	13.6	8.0	128.9	3,257,451.6	1,831.6	1.3	0.9
10/18/2019 08:00	8.7	13.9	7.3	102.6	3,020,870.8	1,522.1	1.1	0.6
10/18/2019 09:00	8.9	13.9	7.5	99.0	2,920,247.9	1,471.4	1.1	0.6
10/18/2019 10:00	9.1	13.9	7.7	100.3	2,938,705.3	1,480.7	1.1	0.6
10/18/2019 11:00	9.2	13.9	7.8	100.9	2,955,575.1	1,489.2	1.1	0.6
10/18/2019 12:00	9.2	13.9	7.8	97.9	2,868,249.4	1,445.2	1.1	0.6
10/18/2019 13:00	9.2	13.9	7.8	104.8	3,088,548.2	1,556.2	1.1	0.6
10/18/2019 14:00	9.3	13.9	7.8	105.1	3,083,784.9	1,553.8	1.1	0.6
10/18/2019 15:00	9.5	13.9	8.0	105.7	3,115,341.2	1,569.7	1.1	0.6
10/18/2019 16:00	11.7	13.4	9.2	160.5	3,231,678.5	1,982.3	1.7	1.4
10/18/2019 17:00	11.3	13.3	8.8	169.8	3,213,740.0	2,041.7	1.8	1.4
10/18/2019 18:00	11.3	13.4	8.9	158.1	3,243,390.9	1,965.8	1.7	1.4
10/18/2019 19:00	11.3	13.4	8.9	159.0	3,219,451.5	1,974.8	1.7	1.4
10/18/2019 20:00	11.1	13.3	8.6	170.1	3,203,508.6	2,035.2	1.8	1.4
10/18/2019 21:00	11.1	13.3	8.6	170.5	3,229,795.3	2,051.9	1.8	1.4
10/18/2019 22:00	10.9	13.4	8.6	157.5	3,244,394.6	1,990.1	1.7	1.4
10/18/2019 23:00	10.8	13.4	8.5	163.1	3,245,535.8	2,038.2	1.7	1.4
Average/Sum#:	10.4	13.6	8.3	137.6	3,165,908.5	1,810.4	1.5	1.0
Minimum:	8.7	13.3	7.3	97.9	2,868,249.4	1,445.2	1.1	0.6
Maximum:	11.7	13.9	9.2	170.5	3,322,785.4	2,051.9	1.8	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/19/2019 00:00	10.7	13.4	8.4	153.1	3,232,982.7	1,983.1	1.6	1.2
10/19/2019 01:00	10.9	13.4	8.6	159.8	3,233,960.9	1,983.7	1.7	1.4
10/19/2019 02:00	10.8	13.3	8.4	162.1	3,247,924.3	2,039.7	1.7	1.4
10/19/2019 03:00	10.7	13.4	8.4	155.9	3,247,166.1	1,991.8	1.6	1.2
10/19/2019 04:00	10.8	13.4	8.5	150.3	3,268,415.2	1,957.1	1.6	1.2
10/19/2019 05:00	11.0	13.4	8.7	155.7	3,239,177.7	1,986.9	1.6	1.2
10/19/2019 06:00	11.1	13.3	8.6	157.6	3,251,730.8	1,994.6	1.6	1.2
10/19/2019 07:00	16.9	14.7	16.1	149.8	2,465,171.4	1,188.1	2.0	1.0
10/19/2019 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2019 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2019 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2019 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2019 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2019 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2019 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2019 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2019 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2019 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2019 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2019 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2019 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2019 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2019 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2019 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	11.6	13.5	9.5	155.5	3,148,316.1	1,890.6	1.7	1.2
Minimum:	10.7	13.3	8.4	149.8	2,465,171.4	1,188.1	1.6	1.0
Maximum:	16.9	14.7	16.1	162.1	3,268,415.2	2,039.7	2.0	1.4
%SI	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/20/2019 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2019 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2019 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2019 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2019 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2019 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2019 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2019 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2019 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2019 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2019 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2019 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2019 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2019 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2019 14:00	44.4	17.4	74.8	72.4	1,809,654.0	449.3	0.0	0.0
10/20/2019 15:00	36.4	15.2	37.7	226.2	2,425,103.9	991.7	3.0	1.2
10/20/2019 16:00	8.9	13.9	7.5	105.8	3,081,800.3	1,552.8	1.1	0.6
10/20/2019 17:00	9.1	13.9	7.7	108.0	3,252,085.2	1,638.6	1.1	0.7
10/20/2019 18:00	11.3	13.5	9.0	135.6	3,356,590.5	1,789.3	1.3	0.9
10/20/2019 19:00	11.4	13.4	9.0	160.3	3,281,173.8	1,988.7	1.7	1.4
10/20/2019 20:00	11.3	13.4	8.9	158.2	3,259,230.0	1,999.2	1.6	1.2
10/20/2019 21:00	11.3	13.4	8.9	156.4	3,294,634.7	1,972.8	1.6	1.2
10/20/2019 22:00	11.4	13.4	9.0	162.2	3,265,499.7	1,979.2	1.7	1.4
10/20/2019 23:00	11.3	13.4	8.9	157.5	3,279,523.9	1,987.7	1.6	1.2
Average/Sum#:	16.7	14.1	18.1	144.3	3,030,529.6	1,634.9	1.5	1.0
Minimum:	8.9	13.4	7.5	72.4	1,809,654.0	449.3	0.0	0.0
Maximum:	44.4	17.4	74.8	226.2	3,356,590.5	1,999.2	3.0	1.4
%SI	58.33	58.33	58.33	58.33	58.33	58.33	58.33	58.33

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/21/2019 00:00	11.2	13.4	8.8	148.5	3,261,935.1	1,929.4	1.5	1.2
10/21/2019 01:00	11.4	13.5	9.1	155.5	3,263,794.8	1,930.5	1.6	1.2
10/21/2019 02:00	11.3	13.5	9.0	153.1	3,256,017.8	1,925.9	1.6	1.2
10/21/2019 03:00	11.2	13.4	8.8	151.8	3,260,244.4	1,928.4	1.6	1.2
10/21/2019 04:00	10.9	13.4	8.6	159.2	3,292,228.2	1,995.4	1.6	1.2
10/21/2019 05:00	11.3	13.4	8.9	167.3	3,225,153.7	2,025.4	1.8	1.4
10/21/2019 06:00	11.4	13.3	8.9	173.9	3,279,220.5	2,083.3	1.8	1.5
10/21/2019 07:00	11.1	13.4	8.7	160.8	3,173,599.8	1,923.5	1.7	1.3
10/21/2019 08:00	9.4	14.1	8.2	90.6	2,519,740.9	1,251.2	1.2	0.6
10/21/2019 09:00	9.4	14.1	8.2	88.7	2,508,866.0	1,245.8	1.2	0.6
10/21/2019 10:00	9.1	14.0	7.8	94.1	2,809,535.2	1,395.1	1.1	0.6
10/21/2019 11:00	8.9	14.0	7.6	97.0	2,939,429.2	1,459.6	1.1	0.6
10/21/2019 12:00	9.9	13.9	8.3	109.6	3,084,181.9	1,554.0	1.2	0.8
10/21/2019 13:00	11.1	13.7	9.1	133.9	3,291,054.7	1,706.3	1.3	0.9
10/21/2019 14:00	11.3	13.7	9.3	137.2	3,339,852.5	1,731.6	1.4	0.9
10/21/2019 15:00	11.3	13.7	9.3	139.4	3,339,466.7	1,731.4	1.4	0.9
10/21/2019 16:00	11.4	13.6	9.2	141.4	3,339,852.5	1,731.6	1.4	0.9
10/21/2019 17:00	11.4	13.6	9.2	140.2	3,349,303.4	1,736.5	1.4	0.9
10/21/2019 18:00	11.3	13.6	9.1	137.8	3,355,282.6	1,739.6	1.4	0.9
10/21/2019 19:00	11.1	13.6	9.0	137.6	3,358,175.8	1,741.1	1.4	0.9
10/21/2019 20:00	11.6	13.4	9.1	150.3	3,280,773.4	1,964.5	1.5	1.2
10/21/2019 21:00	11.5	13.4	9.0	160.8	3,248,919.1	2,016.6	1.7	1.4
10/21/2019 22:00	11.5	13.4	9.0	162.9	3,275,532.7	2,009.2	1.7	1.4
10/21/2019 23:00	11.4	13.4	9.0	159.0	3,259,230.0	1,975.4	1.7	1.4
Average/Sum#:	10.9	13.6	8.8	139.6	3,179,641.3	1,780.5	1.5	1.0
Minimum:	8.9	13.3	7.6	88.7	2,508,866.0	1,245.8	1.1	0.6
Maximum:	11.6	14.1	9.3	173.9	3,358,175.8	2,083.3	1.8	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/22/2019 00:00	11.2	13.4	8.8	148.5	3,306,475.2	1,931.6	1.5	1.2
10/22/2019 01:00	11.3	13.5	9.0	149.4	3,240,024.7	1,940.1	1.6	1.2
10/22/2019 02:00	11.3	13.5	9.0	156.9	3,233,511.6	1,936.2	1.6	1.2
10/22/2019 03:00	11.1	13.5	8.9	154.6	3,213,362.6	1,947.6	1.6	1.2
10/22/2019 04:00	10.9	13.4	8.6	150.9	3,294,564.6	1,948.7	1.5	1.2
10/22/2019 05:00	11.1	13.4	8.7	159.3	3,230,713.8	2,005.3	1.7	1.4
10/22/2019 06:00	11.1	13.4	8.7	165.5	3,250,790.6	2,041.5	1.7	1.4
10/22/2019 07:00	11.0	13.4	8.7	156.6	3,296,972.7	1,974.2	1.6	1.2
10/22/2019 08:00	11.3	13.3	8.8	176.5	3,252,694.1	2,090.2	1.9	1.5
10/22/2019 09:00	11.4	13.3	8.9	188.4	3,262,922.9	2,120.6	2.0	1.7
10/22/2019 10:00	11.4	13.3	8.9	189.3	3,259,076.2	2,118.1	2.0	1.7
10/22/2019 11:00	11.4	13.3	8.9	184.5	3,216,625.7	2,114.0	2.0	1.7
10/22/2019 12:00	11.4	13.3	8.9	187.9	3,206,279.0	2,107.2	2.0	1.7
10/22/2019 13:00	11.4	13.3	8.9	188.8	3,198,823.2	2,102.3	2.0	1.7
10/22/2019 14:00	11.5	13.3	8.9	185.6	3,188,020.0	2,095.2	2.0	1.7
10/22/2019 15:00	11.5	13.3	8.9	191.9	3,182,846.6	2,091.8	2.1	1.7
10/22/2019 16:00	11.2	13.3	8.7	180.4	3,218,455.0	2,091.7	1.9	1.5
10/22/2019 17:00	11.3	13.3	8.8	196.5	3,194,331.2	2,146.0	2.1	1.7
10/22/2019 18:00	11.2	13.3	8.7	172.9	3,237,035.9	2,056.5	1.8	1.4
10/22/2019 19:00	11.4	13.3	8.9	178.5	3,238,066.2	2,080.8	1.9	1.5
10/22/2019 20:00	11.3	13.3	8.8	169.7	3,230,408.4	2,028.7	1.8	1.4
10/22/2019 21:00	11.3	13.3	8.8	169.9	3,220,351.0	2,045.9	1.8	1.4
10/22/2019 22:00	11.4	13.3	8.9	166.4	3,212,255.6	2,017.3	1.8	1.4
10/22/2019 23:00	11.4	13.3	8.9	164.8	3,242,112.2	1,988.7	1.7	1.4
Average/Sum#:	11.3	13.3	8.8	172.2	3,234,446.6	2,042.5	1.8	1.5
Minimum:	10.9	13.3	8.6	148.5	3,182,846.6	1,931.6	1.5	1.2
Maximum:	11.5	13.5	9.0	196.5	3,306,475.2	2,146.0	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/23/2019 00:00	11.4	13.3	8.9	157.5	3,233,145.8	1,983.2	1.7	1.4
10/23/2019 01:00	11.4	13.3	8.9	158.4	3,230,700.4	1,981.7	1.7	1.4
10/23/2019 02:00	11.4	13.4	9.0	157.3	3,245,865.8	1,967.3	1.6	1.2
10/23/2019 03:00	11.4	13.4	9.0	156.4	3,257,085.2	1,974.1	1.6	1.2
10/23/2019 04:00	11.4	13.4	9.0	154.3	3,257,226.0	1,950.4	1.6	1.2
10/23/2019 05:00	11.5	13.3	8.9	180.5	3,180,955.0	2,044.1	2.0	1.6
10/23/2019 06:00	11.5	13.4	9.0	165.3	3,178,816.2	1,996.3	1.8	1.4
10/23/2019 07:00	9.2	14.0	7.9	93.6	2,657,287.5	1,319.5	1.2	0.7
10/23/2019 08:00	9.3	14.1	8.1	88.5	2,561,436.8	1,253.2	1.1	0.5
10/23/2019 09:00	9.3	14.1	8.1	88.3	2,551,421.6	1,248.3	1.1	0.5
10/23/2019 10:00	9.0	14.0	7.7	92.6	2,757,174.9	1,369.1	1.1	0.5
10/23/2019 11:00	8.9	14.0	7.6	96.3	2,919,894.7	1,449.9	1.1	0.6
10/23/2019 12:00	9.7	13.9	8.2	113.3	3,105,020.9	1,564.5	1.2	0.8
10/23/2019 13:00	11.2	13.7	9.2	138.2	3,342,359.9	1,732.9	1.4	0.9
10/23/2019 14:00	11.3	13.7	9.3	139.8	3,338,309.5	1,730.8	1.4	0.9
10/23/2019 15:00	11.3	13.7	9.3	137.4	3,336,380.7	1,729.8	1.4	0.9
10/23/2019 16:00	11.3	13.7	9.3	138.0	3,340,816.9	1,732.1	1.4	0.9
10/23/2019 17:00	11.3	13.7	9.3	141.6	3,346,217.4	1,734.9	1.4	0.9
10/23/2019 18:00	9.3	13.9	7.8	113.9	3,364,814.6	1,695.4	1.1	0.7
10/23/2019 19:00	11.2	13.5	8.9	141.6	3,275,733.4	1,865.8	1.4	0.9
10/23/2019 20:00	11.7	13.4	9.2	175.6	3,274,038.9	2,056.1	1.8	1.4
10/23/2019 21:00	11.6	13.3	9.0	185.4	3,256,895.8	2,092.9	2.0	1.7
10/23/2019 22:00	11.4	13.3	8.9	178.5	3,244,602.1	2,085.0	1.9	1.5
10/23/2019 23:00	11.3	13.4	8.9	167.5	3,269,863.2	2,029.6	1.7	1.4
Average/Sum#:	10.8	13.6	8.7	140.0	3,146,919.3	1,774.5	1.5	1.0
Minimum:	8.9	13.3	7.6	88.3	2,551,421.6	1,248.3	1.1	0.5
Maximum:	11.7	14.1	9.3	185.4	3,364,814.6	2,092.9	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/24/2019 00:00	11.3	13.4	8.9	162.6	3,267,381.4	2,004.2	1.7	1.4
10/24/2019 01:00	11.3	13.4	8.9	158.0	3,264,509.7	1,978.6	1.6	1.2
10/24/2019 02:00	11.2	13.5	8.9	148.7	3,314,353.7	1,912.0	1.5	1.1
10/24/2019 03:00	11.4	13.4	9.0	166.0	3,299,986.7	2,024.2	1.7	1.4
10/24/2019 04:00	11.4	13.4	9.0	169.4	3,305,203.6	2,027.4	1.7	1.4
10/24/2019 05:00	11.5	13.3	8.9	204.4	3,221,070.8	2,093.4	2.2	1.7
10/24/2019 06:00	11.4	13.4	9.0	174.6	3,268,044.7	2,076.2	1.8	1.5
10/24/2019 07:00	11.4	13.4	9.0	171.9	3,261,905.9	2,072.3	1.8	1.5
10/24/2019 08:00	11.3	13.4	8.9	166.0	3,296,889.2	2,022.3	1.7	1.4
10/24/2019 09:00	11.3	13.4	8.9	162.1	3,277,757.5	2,034.5	1.7	1.4
10/24/2019 10:00	11.3	13.4	8.9	164.5	3,252,542.1	2,042.6	1.7	1.4
10/24/2019 11:00	11.2	13.4	8.8	166.6	3,258,911.6	2,046.6	1.7	1.4
10/24/2019 12:00	11.3	13.4	8.9	168.9	3,237,822.9	2,057.0	1.8	1.4
10/24/2019 13:00	11.3	13.4	8.9	177.7	3,262,063.3	2,072.4	1.9	1.5
10/24/2019 14:00	11.3	13.4	8.9	177.7	3,244,290.9	2,084.8	1.9	1.5
10/24/2019 15:00	11.4	13.3	8.9	186.6	3,219,821.0	2,116.1	2.0	1.7
10/24/2019 16:00	11.3	13.3	8.8	194.4	3,211,826.9	2,134.3	2.1	1.7
10/24/2019 17:00	11.0	13.3	8.5	175.7	3,231,533.8	2,100.2	1.9	1.5
10/24/2019 18:00	11.0	13.3	8.5	177.6	3,225,840.7	2,096.5	1.9	1.5
10/24/2019 19:00	11.3	13.3	8.8	193.3	3,227,477.4	2,144.7	2.1	1.7
10/24/2019 20:00	11.4	13.3	8.9	192.5	3,244,166.4	2,132.1	2.1	1.7
10/24/2019 21:00	11.5	13.4	9.0	190.7	3,220,609.2	2,093.1	2.0	1.7
10/24/2019 22:00	11.3	13.5	9.0	191.1	3,202,145.0	2,081.1	2.1	1.7
10/24/2019 23:00	11.1	13.3	8.6	183.5	3,237,996.3	2,104.4	2.0	1.7
Average/Sum#:	11.3	13.4	8.9	176.0	3,252,256.3	2,064.6	1.9	1.5
Minimum:	11.0	13.3	8.5	148.7	3,202,145.0	1,912.0	1.5	1.1
Maximum:	11.5	13.5	9.0	204.4	3,314,353.7	2,144.7	2.2	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/25/2019 00:00	11.3	13.3	8.8	188.6	3,243,689.4	2,108.1	2.0	1.7
10/25/2019 01:00	11.3	13.4	8.9	163.3	3,269,826.8	2,005.7	1.7	1.4
10/25/2019 02:00	11.4	13.5	9.1	164.7	3,217,984.3	1,973.9	1.7	1.4
10/25/2019 03:00	11.1	13.5	8.9	164.2	3,251,475.5	1,970.7	1.7	1.4
10/25/2019 04:00	10.8	13.5	8.6	160.0	3,259,556.1	1,999.4	1.7	1.4
10/25/2019 05:00	11.0	13.5	8.8	154.9	3,277,214.0	1,986.3	1.6	1.2
10/25/2019 06:00	11.1	13.4	8.7	163.9	3,276,307.6	2,033.6	1.7	1.4
10/25/2019 07:00	11.0	13.5	8.8	160.3	3,309,831.9	1,981.9	1.6	1.2
10/25/2019 08:00	9.9	13.6	8.0	123.2	3,347,521.9	1,857.8	1.2	0.9
10/25/2019 09:00	10.6	13.6	8.6	134.5	3,348,963.4	1,858.6	1.3	0.9
10/25/2019 10:00	11.4	13.5	9.1	147.2	3,318,045.1	1,889.9	1.5	1.1
10/25/2019 11:00	11.4	13.5	9.1	148.7	3,312,426.9	1,886.7	1.5	1.1
10/25/2019 12:00	11.6	13.4	9.1	163.3	3,271,294.0	2,006.6	1.7	1.4
10/25/2019 13:00	11.5	13.4	9.0	163.1	3,237,480.4	2,009.5	1.7	1.4
10/25/2019 14:00	11.5	13.4	9.0	163.7	3,234,580.4	2,007.7	1.7	1.4
10/25/2019 15:00	11.5	13.4	9.0	166.7	3,238,608.1	2,010.2	1.8	1.4
10/25/2019 16:00	11.6	13.3	9.0	182.4	3,230,907.8	2,076.2	1.9	1.5
10/25/2019 17:00	11.5	13.3	8.9	177.2	3,208,654.7	2,061.9	1.9	1.4
10/25/2019 18:00	11.5	13.4	9.0	162.0	3,243,579.5	1,989.6	1.7	1.4
10/25/2019 19:00	11.5	13.4	9.0	161.3	3,242,764.3	1,989.1	1.7	1.4
10/25/2019 20:00	11.4	13.4	9.0	171.4	3,231,369.3	2,052.9	1.8	1.4
10/25/2019 21:00	11.4	13.3	8.9	179.8	3,241,178.5	2,082.8	1.9	1.5
10/25/2019 22:00	11.2	13.4	8.8	165.4	3,271,957.6	2,030.9	1.7	1.4
10/25/2019 23:00	11.2	13.4	8.8	161.5	3,260,841.1	2,024.0	1.7	1.4
Average/Sum#:	11.2	13.4	8.9	162.1	3,264,419.1	1,995.6	1.7	1.3
Minimum:	9.9	13.3	8.0	123.2	3,208,654.7	1,857.8	1.2	0.9
Maximum:	11.6	13.6	9.1	188.6	3,348,963.4	2,108.1	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/26/2019 00:00	11.5	13.5	9.2	166.5	3,204,942.1	1,965.9	1.8	1.4
10/26/2019 01:00	11.2	13.5	8.9	168.3	3,216,697.3	1,996.6	1.8	1.4
10/26/2019 02:00	10.9	13.5	8.7	163.7	3,203,647.5	1,988.5	1.7	1.4
10/26/2019 03:00	10.6	13.5	8.5	157.6	3,233,145.8	1,983.2	1.7	1.4
10/26/2019 04:00	10.7	13.5	8.5	157.9	3,236,243.3	1,985.1	1.7	1.4
10/26/2019 05:00	10.9	13.5	8.7	157.1	3,319,900.7	1,915.2	1.6	1.1
10/26/2019 06:00	10.9	13.5	8.7	142.6	3,258,374.1	1,903.5	1.5	1.1
10/26/2019 07:00	8.9	13.9	7.5	99.1	2,929,972.8	1,476.3	1.1	0.6
10/26/2019 08:00	8.8	14.0	7.5	102.3	3,173,036.9	1,575.6	1.1	0.6
10/26/2019 09:00	8.7	14.0	7.4	102.2	3,161,557.9	1,569.9	1.1	0.6
10/26/2019 10:00	9.0	14.0	7.7	96.0	2,936,609.8	1,458.2	1.1	0.6
10/26/2019 11:00	9.2	13.9	7.8	93.8	2,816,648.0	1,419.2	1.1	0.6
10/26/2019 12:00	9.0	14.0	7.7	99.1	3,049,788.7	1,514.4	1.1	0.6
10/26/2019 13:00	10.2	13.9	8.6	113.7	3,139,752.7	1,582.0	1.2	0.8
10/26/2019 14:00	8.9	14.0	7.6	96.1	2,953,526.2	1,466.6	1.1	0.6
10/26/2019 15:00	10.1	13.9	8.5	106.0	2,938,506.9	1,480.6	1.2	0.7
10/26/2019 16:00	11.5	13.4	9.0	148.9	3,251,453.1	1,923.2	1.5	1.2
10/26/2019 17:00	11.6	13.4	9.1	164.1	3,214,764.0	1,995.4	1.7	1.4
10/26/2019 18:00	11.3	13.4	8.9	158.4	3,210,575.2	1,992.8	1.7	1.4
10/26/2019 19:00	11.5	13.4	9.0	160.1	3,245,209.7	1,990.6	1.7	1.4
10/26/2019 20:00	11.5	13.4	9.0	163.0	3,224,591.7	2,001.5	1.7	1.4
10/26/2019 21:00	11.4	13.4	9.0	164.6	3,262,979.6	2,001.5	1.7	1.4
10/26/2019 22:00	17.2	14.9	16.9	137.4	2,433,723.9	1,137.4	1.8	0.8
10/26/2019 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	10.7	13.7	8.8	135.6	3,113,723.8	1,753.2	1.5	1.0
Minimum:	8.7	13.4	7.4	93.8	2,433,723.9	1,137.4	1.1	0.6
Maximum:	17.2	14.9	16.9	168.3	3,319,900.7	2,001.5	1.8	1.4
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/27/2019 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/28/2019 00:00	30.0	18.0	61.0	0.0	1,962,444.7	329.6	0.0	0.0
10/28/2019 01:00	50.5	16.2	63.4	132.6	2,031,410.0	697.2	0.0	0.0
10/28/2019 02:00	8.7	14.1	7.5	104.9	2,665,745.7	1,323.7	1.3	0.7
10/28/2019 03:00	9.4	14.0	8.0	102.1	3,084,777.3	1,554.3	1.1	0.6
10/28/2019 04:00	11.4	13.6	9.2	144.2	3,348,242.6	1,907.1	1.4	1.0
10/28/2019 05:00	11.6	13.6	9.4	154.9	3,266,411.2	1,955.9	1.6	1.2
10/28/2019 06:00	11.9	13.4	9.4	191.3	3,270,000.8	2,125.2	2.0	1.7
10/28/2019 07:00	11.3	13.5	9.0	164.6	3,293,302.6	2,020.1	1.7	1.4
10/28/2019 08:00	11.4	13.5	9.1	163.6	3,299,477.8	1,975.7	1.7	1.4
10/28/2019 09:00	11.4	13.5	9.1	164.6	3,309,330.9	1,981.6	1.7	1.4
10/28/2019 10:00	11.3	13.5	9.0	164.3	3,295,970.7	1,973.6	1.7	1.4
10/28/2019 11:00	11.3	13.5	9.0	152.2	3,375,024.4	1,947.0	1.5	1.2
10/28/2019 12:00	11.4	13.5	9.1	156.6	3,337,507.0	1,974.1	1.6	1.2
10/28/2019 13:00	11.4	13.5	9.1	158.1	3,306,906.3	1,956.0	1.6	1.2
10/28/2019 14:00	11.4	13.5	9.1	158.4	3,341,226.4	1,976.3	1.6	1.2
10/28/2019 15:00	11.5	13.4	9.0	159.6	3,306,912.4	2,004.3	1.6	1.2
10/28/2019 16:00	11.5	13.4	9.0	177.1	3,293,306.4	2,068.2	1.8	1.4
10/28/2019 17:00	11.4	13.3	8.9	200.2	3,235,116.3	2,173.4	2.1	1.7
10/28/2019 18:00	11.3	13.4	8.9	177.9	3,280,082.6	2,107.8	1.9	1.5
10/28/2019 19:00	11.1	13.4	8.7	173.4	3,293,701.8	2,092.5	1.8	1.5
10/28/2019 20:00	11.3	13.5	9.0	177.9	3,257,498.6	2,069.5	1.9	1.4
10/28/2019 21:00	11.1	13.5	8.9	175.2	3,241,600.7	2,059.4	1.9	1.4
10/28/2019 22:00	10.5	13.5	8.4	149.8	3,245,197.7	1,919.5	1.6	1.2
10/28/2019 23:00	25.4	16.2	31.9	160.0	1,581,550.9	589.0	3.2	0.7
Average/Sum#:	14.1	13.9	14.3	152.6	3,080,114.4	1,782.5	1.6	1.2
Minimum:	8.7	13.3	7.5	0.0	1,581,550.9	329.6	0.0	0.0
Maximum:	50.5	18.0	63.4	200.2	3,375,024.4	2,173.4	3.2	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/29/2019 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/30/2019 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2019 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2019 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2019 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2019 04:00	9.0	19.2	31.2	0.0	3,379,054.7	98.7	0.0	0.0
10/30/2019 05:00	45.6	17.3	74.7	82.6	1,851,313.7	500.2	0.0	0.0
10/30/2019 06:00	47.6	15.6	53.0	247.9	2,126,741.9	823.1	3.7	1.2
10/30/2019 07:00	8.6	14.0	7.4	120.5	3,371,959.5	1,699.0	1.2	0.8
10/30/2019 08:00	9.1	14.0	7.8	110.5	3,436,651.0	1,706.5	1.1	0.7
10/30/2019 09:00	11.7	13.6	9.5	155.3	3,409,688.9	1,917.2	1.5	1.2
10/30/2019 10:00	12.1	13.6	9.8	170.5	3,302,758.2	2,025.9	1.7	1.4
10/30/2019 11:00	11.9	13.5	9.5	191.7	3,298,242.7	2,071.3	2.0	1.7
10/30/2019 12:00	11.8	13.5	9.4	195.6	3,258,140.7	2,093.7	2.1	1.7
10/30/2019 13:00	11.6	13.5	9.2	188.7	3,281,363.8	2,060.7	2.0	1.6
10/30/2019 14:00	11.1	13.5	8.9	157.8	3,346,572.6	2,003.9	1.6	1.2
10/30/2019 15:00	11.3	13.5	9.0	163.4	3,368,951.0	2,017.3	1.6	1.2
10/30/2019 16:00	11.3	13.4	8.9	178.8	3,312,255.4	2,080.1	1.8	1.5
10/30/2019 17:00	11.1	13.5	8.9	143.2	3,405,064.8	1,914.6	1.4	1.0
10/30/2019 18:00	11.0	13.5	8.8	140.9	3,392,134.4	1,932.1	1.4	1.0
10/30/2019 19:00	11.0	13.5	8.8	144.9	3,407,057.6	1,940.6	1.4	1.0
10/30/2019 20:00	11.1	13.5	8.9	145.2	3,412,324.7	1,943.6	1.4	1.0
10/30/2019 21:00	11.3	13.6	9.1	146.4	3,358,824.5	1,888.6	1.5	1.1
10/30/2019 22:00	11.0	13.6	8.9	143.0	3,382,656.1	1,902.0	1.4	1.0
10/30/2019 23:00	10.8	13.6	8.7	143.1	3,386,165.1	1,928.7	1.4	1.0
Average/Sum#:	14.5	14.2	15.5	148.5	3,224,396.1	1,727.4	1.5	1.1
Minimum:	8.6	13.4	7.4	0.0	1,851,313.7	98.7	0.0	0.0
Maximum:	47.6	19.2	74.7	247.9	3,436,651.0	2,093.7	3.7	1.7
%SI	16.67	16.67	16.67	16.67	16.67	16.67	16.67	16.67

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/31/2019 00:00	10.6	13.6	8.6	135.5	3,407,910.4	1,916.2	1.3	1.0
10/31/2019 01:00	10.9	13.6	8.8	142.7	3,381,944.7	1,901.6	1.4	1.0
10/31/2019 02:00	10.9	13.6	8.8	140.1	3,377,320.7	1,899.0	1.4	0.9
10/31/2019 03:00	10.8	13.6	8.7	139.9	3,385,501.6	1,903.6	1.4	1.0
10/31/2019 04:00	10.8	13.6	8.7	141.2	3,385,145.9	1,903.4	1.4	1.0
10/31/2019 05:00	11.1	13.6	9.0	141.4	3,368,428.3	1,894.0	1.4	0.9
10/31/2019 06:00	11.1	13.6	9.0	140.1	3,384,434.5	1,903.0	1.4	1.0
10/31/2019 07:00	10.8	13.6	8.7	142.7	3,404,887.0	1,914.5	1.4	1.0
10/31/2019 08:00	10.9	13.6	8.8	142.2	3,418,403.4	1,922.1	1.4	1.0
10/31/2019 09:00	11.1	13.6	9.0	145.2	3,367,716.9	1,893.6	1.4	0.9
10/31/2019 10:00	11.2	13.5	8.9	149.4	3,374,119.4	1,897.2	1.5	1.1
10/31/2019 11:00	11.1	13.5	8.9	147.1	3,397,239.6	1,910.2	1.4	1.0
10/31/2019 12:00	11.2	13.5	8.9	149.1	3,353,529.6	1,934.6	1.5	1.2
10/31/2019 13:00	11.2	13.5	8.9	149.1	3,355,436.4	1,935.7	1.5	1.2
10/31/2019 14:00	11.3	13.5	9.0	148.8	3,346,249.2	1,930.4	1.5	1.2
10/31/2019 15:00	11.3	13.5	9.0	147.7	3,342,782.3	1,928.4	1.5	1.2
10/31/2019 16:00	11.3	13.5	9.0	147.8	3,337,061.9	1,925.1	1.5	1.2
10/31/2019 17:00	11.3	13.5	9.0	147.5	3,343,475.6	1,928.8	1.5	1.2
10/31/2019 18:00	11.2	13.4	8.8	150.9	3,363,477.5	1,964.9	1.5	1.2
10/31/2019 19:00	11.2	13.4	8.8	165.9	3,306,522.9	2,076.5	1.7	1.5
10/31/2019 20:00	11.3	13.4	8.9	169.8	3,338,978.9	2,072.5	1.7	1.5
10/31/2019 21:00	11.1	13.4	8.7	168.4	3,349,934.3	2,079.3	1.7	1.5
10/31/2019 22:00	11.2	13.5	8.9	179.5	3,275,285.4	2,080.8	1.9	1.5
10/31/2019 23:00	10.7	13.5	8.5	169.4	3,323,512.4	2,062.9	1.7	1.4
Average/Sum#:	11.1	13.5	8.8	150.1	3,362,054.1	1,949.1	1.5	1.2
Minimum:	10.6	13.4	8.5	135.5	3,275,285.4	1,893.6	1.3	0.9
Maximum:	11.3	13.6	9.0	179.5	3,418,403.4	2,080.8	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/01/2019 00:00	10.9	13.5	8.7	165.8	3,291,129.6	2,042.8	1.7	1.4
11/01/2019 01:00	10.6	13.5	8.5	159.0	3,312,357.1	2,007.6	1.6	1.2
11/01/2019 02:00	10.7	13.5	8.5	158.7	3,327,538.2	2,041.1	1.6	1.2
11/01/2019 03:00	10.8	13.5	8.6	163.7	3,329,331.5	2,042.2	1.7	1.4
11/01/2019 04:00	10.8	13.5	8.6	155.8	3,351,081.7	2,006.6	1.6	1.2
11/01/2019 05:00	10.8	13.4	8.5	170.3	3,312,275.6	2,104.3	1.8	1.5
11/01/2019 06:00	11.0	13.4	8.7	178.1	3,360,913.7	2,135.2	1.8	1.5
11/01/2019 07:00	10.7	13.4	8.4	175.6	3,359,024.9	2,134.0	1.8	1.5
11/01/2019 08:00	10.8	13.4	8.5	181.4	3,334,154.9	2,118.2	1.9	1.5
11/01/2019 09:00	9.3	13.7	7.6	127.5	3,289,432.4	1,753.5	1.3	0.9
11/01/2019 10:00	8.7	14.0	7.4	106.2	3,312,395.9	1,644.8	1.1	0.7
11/01/2019 11:00	8.7	14.1	7.5	87.4	2,656,884.7	1,319.3	1.1	0.5
11/01/2019 12:00	8.8	14.0	7.5	98.1	3,031,663.9	1,505.4	1.1	0.6
11/01/2019 13:00	8.8	14.0	7.5	101.2	3,119,669.6	1,549.1	1.1	0.6
11/01/2019 14:00	9.5	14.0	8.1	101.1	3,003,008.7	1,513.1	1.1	0.6
11/01/2019 15:00	11.3	13.4	8.9	153.1	3,347,557.9	1,955.6	1.5	1.2
11/01/2019 16:00	11.4	13.4	9.0	174.9	3,312,234.8	2,055.9	1.8	1.4
11/01/2019 17:00	11.4	13.3	8.9	188.8	3,278,309.7	2,130.6	2.0	1.7
11/01/2019 18:00	11.3	13.3	8.8	201.3	3,258,477.6	2,165.3	2.1	1.7
11/01/2019 19:00	11.1	13.4	8.7	168.5	3,298,083.5	2,071.2	1.7	1.4
11/01/2019 20:00	11.2	13.3	8.7	183.8	3,322,192.1	2,110.6	1.9	1.5
11/01/2019 21:00	11.2	13.4	8.8	165.0	3,322,484.4	2,038.0	1.7	1.4
11/01/2019 22:00	11.2	13.4	8.8	160.6	3,357,427.8	2,010.4	1.6	1.2
11/01/2019 23:00	11.1	13.4	8.7	162.0	3,354,594.8	2,033.2	1.6	1.2
Average/Sum#:	10.5	13.6	8.4	153.7	3,260,092.7	1,937.0	1.6	1.2
Minimum:	8.7	13.3	7.4	87.4	2,656,884.7	1,319.3	1.1	0.5
Maximum:	11.4	14.1	9.0	201.3	3,360,913.7	2,165.3	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/02/2019 00:00	11.2	13.4	8.8	168.4	3,303,534.9	2,050.5	1.7	1.4
11/02/2019 01:00	11.1	13.4	8.7	176.1	3,278,338.3	2,058.8	1.8	1.4
11/02/2019 02:00	11.0	13.4	8.7	176.5	3,295,535.7	2,069.6	1.8	1.4
11/02/2019 03:00	10.8	13.4	8.5	172.4	3,285,822.3	2,063.5	1.8	1.4
11/02/2019 04:00	10.8	13.4	8.5	177.6	3,295,535.7	2,069.6	1.9	1.4
11/02/2019 05:00	11.1	13.4	8.7	166.6	3,278,724.2	2,035.1	1.7	1.4
11/02/2019 06:00	11.4	13.4	9.0	195.5	3,271,847.2	2,126.4	2.1	1.7
11/02/2019 07:00	10.9	13.4	8.6	169.6	3,291,554.8	2,067.1	1.8	1.4
11/02/2019 08:00	10.5	13.5	8.4	146.0	3,313,304.7	1,887.2	1.5	1.1
11/02/2019 09:00	8.6	14.0	7.4	100.6	3,077,378.5	1,528.1	1.1	0.6
11/02/2019 10:00	8.8	14.0	7.5	99.1	3,057,642.7	1,518.3	1.1	0.6
11/02/2019 11:00	8.7	14.0	7.4	98.9	3,070,732.8	1,524.8	1.1	0.6
11/02/2019 12:00	8.8	14.0	7.5	100.5	3,099,329.6	1,539.0	1.1	0.6
11/02/2019 13:00	21.7	15.5	23.7	140.9	2,219,668.8	923.9	1.9	0.6
11/02/2019 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/02/2019 15:00	42.1	17.3	69.0	214.0	1,869,926.9	423.3	2.9	0.5
11/02/2019 16:00	25.7	14.5	23.7	177.4	2,405,907.5	1,124.4	2.4	1.0
11/02/2019 17:00	9.8	13.8	8.1	111.9	3,311,692.5	1,717.0	1.1	0.7
11/02/2019 18:00	11.7	13.3	9.1	134.0	3,309,768.3	2,030.2	1.4	1.0
11/02/2019 19:00	11.6	13.3	9.0	147.8	3,259,982.5	2,166.3	1.5	1.3
11/02/2019 20:00	11.3	13.3	8.8	146.2	3,258,164.9	2,141.3	1.5	1.3
11/02/2019 21:00	11.2	13.3	8.7	137.8	3,301,268.2	2,073.2	1.4	1.0
11/02/2019 22:00	11.0	13.4	8.7	134.8	3,293,062.9	2,044.0	1.4	1.0
11/02/2019 23:00	10.9	13.4	8.6	128.9	3,324,528.2	1,990.7	1.3	1.0
Average/Sum#:	13.1	13.8	12.4	148.8	3,107,532.7	1,790.1	1.6	1.1
Minimum:	8.6	13.3	7.4	98.9	1,869,926.9	423.3	1.1	0.5
Maximum:	42.1	17.3	69.0	214.0	3,324,528.2	2,166.3	2.9	1.7
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/03/2019 00:00	11.2	13.5	8.9	130.5	3,311,502.0	1,982.9	1.3	1.0
11/03/2019 01:00	11.1	13.4	8.7	132.4	3,262,327.5	2,001.1	1.4	1.0
11/03/2019 02:00	11.0	13.4	8.7	130.7	3,280,513.9	1,988.3	1.3	1.0
11/03/2019 03:00	11.1	13.4	8.7	133.0	3,275,206.7	2,009.0	1.4	1.0
11/03/2019 04:00	11.0	13.4	8.7	136.2	3,292,740.7	2,043.8	1.4	1.0
11/03/2019 05:00	11.2	13.4	8.8	179.5	3,207,800.5	2,108.2	1.9	1.5
11/03/2019 06:00	11.2	13.4	8.8	169.6	3,308,752.2	2,077.9	1.7	1.5
11/03/2019 07:00	10.6	13.5	8.5	158.5	3,285,628.6	1,991.4	1.6	1.2
11/03/2019 08:00	8.6	13.9	7.2	105.6	3,182,026.3	1,603.3	1.1	0.6
11/03/2019 09:00	8.7	13.9	7.3	103.5	3,199,418.4	1,588.7	1.1	0.6
11/03/2019 10:00	8.8	14.0	7.5	104.6	3,240,299.8	1,609.0	1.1	0.6
11/03/2019 11:00	8.8	14.0	7.5	104.1	3,219,758.4	1,598.8	1.1	0.6
11/03/2019 12:00	8.9	14.0	7.6	105.2	3,249,160.7	1,613.4	1.1	0.6
11/03/2019 13:00	9.1	14.0	7.8	97.0	2,954,130.3	1,466.9	1.1	0.6
11/03/2019 14:00	9.0	14.0	7.7	94.9	2,906,200.5	1,443.1	1.1	0.6
11/03/2019 15:00	11.3	13.6	9.1	135.9	3,221,433.9	1,764.3	1.4	0.9
11/03/2019 16:00	11.7	13.3	9.1	172.1	3,260,017.1	2,071.1	1.8	1.4
11/03/2019 17:00	11.5	13.3	8.9	187.1	3,255,383.3	2,115.7	2.0	1.7
11/03/2019 18:00	11.4	13.3	8.9	188.3	3,228,681.3	2,145.5	2.0	1.7
11/03/2019 19:00	11.2	13.3	8.7	195.8	3,232,436.9	2,171.6	2.1	1.7
11/03/2019 20:00	11.1	13.3	8.6	183.8	3,263,384.5	2,120.9	1.9	1.5
11/03/2019 21:00	11.2	13.3	8.7	173.7	3,284,100.0	2,086.4	1.8	1.5
11/03/2019 22:00	11.0	13.4	8.7	158.4	3,287,270.6	2,016.4	1.6	1.2
11/03/2019 23:00	11.1	13.4	8.7	170.7	3,271,013.5	2,054.2	1.8	1.4
Average/Sum#:	10.5	13.6	8.4	143.8	3,228,299.5	1,903.0	1.5	1.1
Minimum:	8.6	13.3	7.2	94.9	2,906,200.5	1,443.1	1.1	0.6
Maximum:	11.7	14.0	9.1	195.8	3,311,502.0	2,171.6	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/04/2019 00:00	11.1	13.4	8.7	169.6	3,249,885.7	2,017.2	1.8	1.4
11/04/2019 01:00	11.1	13.4	8.7	164.7	3,256,007.9	2,021.0	1.7	1.4
11/04/2019 02:00	11.0	13.5	8.8	155.8	3,267,580.2	1,956.6	1.6	1.2
11/04/2019 03:00	11.1	13.4	8.7	160.6	3,280,513.9	1,988.3	1.7	1.4
11/04/2019 04:00	11.0	13.4	8.7	162.0	3,279,771.4	2,011.8	1.7	1.4
11/04/2019 05:00	11.3	13.4	8.9	175.1	3,180,826.7	2,113.7	1.9	1.5
11/04/2019 06:00	11.2	13.3	8.7	191.7	3,261,186.4	2,167.1	2.0	1.7
11/04/2019 07:00	10.9	13.5	8.7	164.0	3,298,193.4	2,023.1	1.7	1.4
11/04/2019 08:00	10.9	13.4	8.6	165.1	3,315,637.3	2,033.8	1.7	1.4
11/04/2019 09:00	11.3	13.4	8.9	182.3	3,235,109.5	2,078.9	1.9	1.5
11/04/2019 10:00	11.3	13.4	8.9	182.3	3,220,823.2	2,046.2	1.9	1.4
11/04/2019 11:00	11.2	13.5	8.9	163.3	3,218,147.3	1,974.0	1.7	1.4
11/04/2019 12:00	11.2	13.4	8.8	183.8	3,177,531.4	2,041.9	2.0	1.6
11/04/2019 13:00	11.3	13.4	8.9	190.0	3,165,678.3	2,057.4	2.1	1.6
11/04/2019 14:00	11.2	13.5	8.9	180.2	3,157,612.5	2,029.1	2.0	1.6
11/04/2019 15:00	11.2	13.4	8.8	193.7	3,165,370.6	2,057.2	2.1	1.6
11/04/2019 16:00	11.2	13.4	8.8	193.9	3,177,516.0	2,111.5	2.1	1.7
11/04/2019 17:00	11.0	13.3	8.5	196.3	3,258,778.6	2,165.5	2.1	1.7
11/04/2019 18:00	11.1	13.3	8.6	197.4	3,264,798.0	2,169.5	2.1	1.7
11/04/2019 19:00	11.0	13.3	8.5	190.7	3,296,661.0	2,166.6	2.0	1.7
11/04/2019 20:00	11.1	13.3	8.6	191.9	3,306,005.9	2,148.6	2.0	1.7
11/04/2019 21:00	11.2	13.3	8.7	188.1	3,273,989.4	2,151.7	2.0	1.7
11/04/2019 22:00	11.2	13.3	8.7	192.4	3,277,641.2	2,154.1	2.0	1.7
11/04/2019 23:00	11.1	13.3	8.6	169.4	3,336,240.0	2,070.8	1.7	1.4
Average/Sum#:	11.1	13.4	8.7	179.3	3,246,729.4	2,073.2	1.9	1.5
Minimum:	10.9	13.3	8.5	155.8	3,157,612.5	1,956.6	1.6	1.2
Maximum:	11.3	13.5	8.9	197.4	3,336,240.0	2,169.5	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/05/2019 00:00	11.2	13.3	8.7	172.9	3,326,108.9	2,088.8	1.8	1.5
11/05/2019 01:00	11.2	13.3	8.7	174.9	3,326,745.8	2,089.2	1.8	1.5
11/05/2019 02:00	11.2	13.3	8.7	169.5	3,320,854.1	2,085.5	1.7	1.5
11/05/2019 03:00	11.2	13.3	8.7	175.4	3,319,102.5	2,084.4	1.8	1.5
11/05/2019 04:00	11.2	13.3	8.7	170.8	3,303,815.9	2,074.8	1.8	1.5
11/05/2019 05:00	11.2	13.3	8.7	185.6	3,263,384.5	2,120.9	2.0	1.7
11/05/2019 06:00	11.2	13.3	8.7	184.9	3,326,179.7	2,186.0	1.9	1.5
11/05/2019 07:00	10.8	13.4	8.5	153.2	3,381,643.2	2,024.9	1.5	1.2
11/05/2019 08:00	11.0	13.4	8.7	157.1	3,389,578.9	2,004.9	1.6	1.2
11/05/2019 09:00	11.0	13.4	8.7	151.5	3,347,215.6	1,955.4	1.5	1.2
11/05/2019 10:00	11.3	13.4	8.9	157.0	3,327,532.2	1,968.2	1.6	1.2
11/05/2019 11:00	11.4	13.4	9.0	155.9	3,325,672.5	1,967.1	1.6	1.2
11/05/2019 12:00	11.4	13.4	9.0	157.4	3,310,499.9	1,982.3	1.6	1.2
11/05/2019 13:00	11.5	13.3	8.9	174.6	3,297,090.6	2,046.5	1.8	1.4
11/05/2019 14:00	11.3	13.3	8.8	166.5	3,299,986.7	2,024.2	1.7	1.4
11/05/2019 15:00	11.5	13.3	8.9	170.7	3,288,551.8	2,041.2	1.8	1.4
11/05/2019 16:00	11.4	13.3	8.9	192.4	3,262,307.4	2,120.2	2.0	1.7
11/05/2019 17:00	11.4	13.3	8.9	180.8	3,260,630.6	2,095.3	1.9	1.5
11/05/2019 18:00	11.3	13.3	8.8	183.2	3,267,633.3	2,099.8	1.9	1.5
11/05/2019 19:00	11.4	13.3	8.9	192.6	3,288,019.1	2,112.9	2.0	1.7
11/05/2019 20:00	11.3	13.3	8.8	185.2	3,295,799.9	2,117.9	1.9	1.5
11/05/2019 21:00	11.3	13.3	8.8	180.8	3,328,179.0	2,090.1	1.9	1.5
11/05/2019 22:00	11.3	13.3	8.8	177.6	3,322,605.7	2,086.6	1.8	1.5
11/05/2019 23:00	11.3	13.3	8.8	176.6	3,323,083.4	2,086.9	1.8	1.5
Average/Sum#:	11.3	13.3	8.8	172.8	3,312,592.6	2,064.8	1.8	1.4
Minimum:	10.8	13.3	8.5	151.5	3,260,630.6	1,955.4	1.5	1.2
Maximum:	11.5	13.4	9.0	192.6	3,389,578.9	2,186.0	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/06/2019 00:00	11.2	13.3	8.7	166.4	3,306,747.4	2,004.2	1.7	1.4
11/06/2019 01:00	11.2	13.4	8.8	151.3	3,364,333.4	1,965.4	1.5	1.2
11/06/2019 02:00	11.2	13.3	8.7	165.6	3,336,015.6	2,046.3	1.7	1.4
11/06/2019 03:00	11.1	13.3	8.6	165.9	3,328,353.4	2,041.6	1.7	1.4
11/06/2019 04:00	11.1	13.4	8.7	152.1	3,325,530.2	1,991.3	1.5	1.2
11/06/2019 05:00	11.3	13.4	8.9	156.3	3,273,890.9	2,032.1	1.6	1.2
11/06/2019 06:00	11.5	13.3	8.9	185.5	3,300,157.1	2,120.7	1.9	1.5
11/06/2019 07:00	11.3	13.3	8.8	166.0	3,318,356.9	2,059.7	1.7	1.4
11/06/2019 08:00	11.0	13.4	8.7	156.8	3,324,236.4	2,014.8	1.6	1.2
11/06/2019 09:00	11.2	13.4	8.8	156.3	3,342,071.8	1,976.8	1.6	1.2
11/06/2019 10:00	11.3	13.4	8.9	156.7	3,500,485.4	2,070.5	1.5	1.2
11/06/2019 11:00	11.3	13.4	8.9	156.3	3,500,215.3	2,095.9	1.5	1.3
11/06/2019 12:00	11.3	13.4	8.9	158.9	3,455,404.2	2,094.3	1.5	1.3
11/06/2019 13:00	11.4	13.4	9.0	164.1	3,471,903.3	2,104.3	1.6	1.3
11/06/2019 14:00	11.2	13.3	8.7	163.4	3,461,220.1	2,123.1	1.6	1.3
11/06/2019 15:00	11.2	13.3	8.7	163.7	3,438,705.2	2,134.4	1.6	1.3
11/06/2019 16:00	11.3	13.3	8.8	181.7	3,420,759.9	2,198.2	1.8	1.5
11/06/2019 17:00	11.3	13.3	8.8	189.3	3,403,932.5	2,237.1	1.9	1.6
11/06/2019 18:00	11.3	13.3	8.8	185.9	3,451,883.1	2,218.2	1.8	1.6
11/06/2019 19:00	11.3	13.3	8.8	189.6	3,421,868.4	2,223.9	1.9	1.6
11/06/2019 20:00	11.3	13.3	8.8	181.8	3,433,100.8	2,231.2	1.8	1.6
11/06/2019 21:00	11.1	13.3	8.6	184.9	3,459,258.3	2,248.2	1.8	1.6
11/06/2019 22:00	11.2	13.3	8.7	177.0	3,455,929.2	2,220.8	1.8	1.6
11/06/2019 23:00	11.1	13.3	8.6	166.2	3,496,382.1	2,170.2	1.6	1.3
Average/Sum#:	11.2	13.3	8.8	168.4	3,399,614.2	2,109.3	1.7	1.4
Minimum:	11.0	13.3	8.6	151.3	3,273,890.9	1,965.4	1.5	1.2
Maximum:	11.5	13.4	9.0	189.6	3,500,485.4	2,248.2	1.9	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/07/2019 00:00	10.9	13.3	8.5	167.9	3,524,415.0	2,187.6	1.6	1.3
11/07/2019 01:00	11.1	13.4	8.7	170.1	3,464,802.9	2,175.9	1.7	1.5
11/07/2019 02:00	10.9	13.4	8.6	167.8	3,450,788.3	2,141.9	1.7	1.5
11/07/2019 03:00	10.7	13.4	8.4	149.5	3,517,899.1	2,080.8	1.4	1.0
11/07/2019 04:00	10.8	13.4	8.5	164.4	3,500,998.6	2,147.5	1.6	1.3
11/07/2019 05:00	10.8	13.4	8.5	154.9	3,462,066.0	2,148.9	1.5	1.3
11/07/2019 06:00	11.2	13.4	8.8	164.3	3,488,369.8	2,190.7	1.6	1.3
11/07/2019 07:00	10.9	13.4	8.6	163.4	3,505,563.4	2,150.3	1.6	1.3
11/07/2019 08:00	10.9	13.4	8.6	149.4	3,548,178.6	2,072.8	1.4	1.0
11/07/2019 09:00	11.0	13.4	8.7	151.5	3,511,981.8	2,077.3	1.4	1.0
11/07/2019 10:00	11.1	13.4	8.7	151.7	3,503,672.3	2,046.8	1.5	1.2
11/07/2019 11:00	11.3	13.4	8.9	156.1	3,495,873.2	2,093.3	1.5	1.3
11/07/2019 12:00	11.4	13.4	9.0	157.5	3,497,543.3	2,094.3	1.5	1.3
11/07/2019 13:00	11.4	13.4	9.0	157.9	3,493,368.2	2,091.8	1.5	1.3
11/07/2019 14:00	11.4	13.4	9.0	162.9	3,486,257.5	2,113.0	1.6	1.3
11/07/2019 15:00	11.4	13.3	8.9	168.8	3,488,771.6	2,140.0	1.6	1.3
11/07/2019 16:00	11.3	13.3	8.8	179.5	3,449,082.1	2,216.4	1.8	1.6
11/07/2019 17:00	11.0	13.3	8.5	166.6	3,473,665.8	2,156.1	1.6	1.3
11/07/2019 18:00	11.3	13.3	8.8	195.0	3,435,900.8	2,283.2	2.0	1.8
11/07/2019 19:00	11.2	13.3	8.7	193.5	3,455,313.5	2,296.1	1.9	1.6
11/07/2019 20:00	11.1	13.3	8.6	179.6	3,446,903.4	2,215.0	1.8	1.6
11/07/2019 21:00	11.2	13.3	8.7	166.6	3,460,185.1	2,173.0	1.6	1.3
11/07/2019 22:00	10.9	13.3	8.5	161.5	3,509,270.8	2,178.2	1.6	1.3
11/07/2019 23:00	10.6	13.4	8.3	150.7	3,498,796.8	2,120.6	1.5	1.3
Average/Sum#:	11.1	13.4	8.7	164.6	3,486,236.2	2,149.6	1.6	1.3
Minimum:	10.6	13.3	8.3	149.4	3,435,900.8	2,046.8	1.4	1.0
Maximum:	11.4	13.4	9.0	195.0	3,548,178.6	2,296.1	2.0	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/08/2019 00:00	10.8	13.4	8.5	166.9	3,462,732.9	2,174.6	1.6	1.3
11/08/2019 01:00	10.6	13.4	8.3	171.0	3,461,338.2	2,199.0	1.7	1.5
11/08/2019 02:00	10.6	13.4	8.3	164.2	3,472,860.2	2,155.6	1.6	1.3
11/08/2019 03:00	10.5	13.4	8.3	154.9	3,499,786.8	2,121.2	1.5	1.3
11/08/2019 04:00	10.7	13.4	8.4	152.5	3,523,595.7	2,109.9	1.5	1.3
11/08/2019 05:00	10.8	13.4	8.5	175.4	3,497,311.9	2,119.7	1.7	1.5
11/08/2019 06:00	11.1	13.4	8.7	157.2	3,500,776.7	2,121.8	1.5	1.3
11/08/2019 07:00	10.9	13.5	8.7	153.6	3,518,585.7	2,106.9	1.5	1.3
11/08/2019 08:00	10.1	13.6	8.2	135.6	3,522,123.5	1,954.7	1.3	1.0
11/08/2019 09:00	8.8	13.9	7.4	98.4	3,113,753.5	1,568.9	1.0	0.6
11/08/2019 10:00	8.8	14.0	7.5	86.6	2,802,285.3	1,391.5	1.0	0.6
11/08/2019 11:00	9.1	14.0	7.8	96.2	3,122,086.2	1,550.3	1.0	0.6
11/08/2019 12:00	9.1	14.0	7.8	96.5	3,125,711.2	1,552.1	1.0	0.6
11/08/2019 13:00	9.1	13.9	7.7	105.4	3,374,142.6	1,700.1	1.0	0.7
11/08/2019 14:00	10.3	13.8	8.6	120.3	3,396,569.4	1,711.4	1.2	0.9
11/08/2019 15:00	11.7	13.4	9.2	150.6	3,496,996.3	2,042.9	1.4	1.0
11/08/2019 16:00	11.5	13.4	9.0	162.1	3,461,508.9	2,098.0	1.6	1.3
11/08/2019 17:00	11.4	13.4	9.0	162.3	3,453,557.9	2,118.4	1.6	1.3
11/08/2019 18:00	11.4	13.3	8.9	171.1	3,424,190.6	2,175.4	1.7	1.5
11/08/2019 19:00	11.1	13.3	8.6	165.2	3,437,416.3	2,133.6	1.6	1.3
11/08/2019 20:00	11.1	13.3	8.6	167.3	3,452,223.3	2,168.0	1.6	1.3
11/08/2019 21:00	11.0	13.3	8.5	165.2	3,462,573.6	2,174.5	1.6	1.3
11/08/2019 22:00	10.9	13.3	8.5	164.6	3,496,543.2	2,170.3	1.6	1.3
11/08/2019 23:00	11.0	13.4	8.7	168.9	3,466,395.3	2,176.9	1.7	1.5
Average/Sum#:	10.5	13.5	8.4	146.3	3,397,711.1	1,991.5	1.4	1.2
Minimum:	8.8	13.3	7.4	86.6	2,802,285.3	1,391.5	1.0	0.6
Maximum:	11.7	14.0	9.2	175.4	3,523,595.7	2,199.0	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/09/2019 00:00	10.9	13.4	8.6	181.1	3,434,579.3	2,182.0	1.8	1.5
11/09/2019 01:00	10.9	13.4	8.6	171.2	3,437,892.1	2,159.0	1.7	1.5
11/09/2019 02:00	10.9	13.4	8.6	178.5	3,443,146.9	2,162.3	1.8	1.5
11/09/2019 03:00	10.9	13.4	8.6	177.3	3,410,338.9	2,166.6	1.8	1.5
11/09/2019 04:00	10.7	13.4	8.4	173.4	3,427,181.3	2,177.3	1.7	1.5
11/09/2019 05:00	10.5	13.4	8.3	163.0	3,519,587.7	2,107.5	1.6	1.3
11/09/2019 06:00	11.1	13.4	8.7	154.1	3,482,346.0	2,085.2	1.5	1.3
11/09/2019 07:00	10.7	13.5	8.5	153.2	3,466,165.3	2,050.2	1.5	1.2
11/09/2019 08:00	8.7	13.9	7.3	98.7	3,114,547.4	1,569.3	1.0	0.6
11/09/2019 09:00	9.1	14.0	7.8	87.3	2,670,780.3	1,326.2	1.1	0.5
11/09/2019 10:00	9.0	14.0	7.7	87.0	2,739,666.3	1,340.4	1.0	0.5
11/09/2019 11:00	9.1	14.1	7.9	86.9	2,713,708.6	1,327.7	1.0	0.5
11/09/2019 12:00	9.2	14.1	8.0	87.2	2,722,906.2	1,332.2	1.0	0.5
11/09/2019 13:00	9.2	14.1	8.0	87.1	2,706,350.5	1,324.1	1.0	0.5
11/09/2019 14:00	9.2	14.0	7.9	98.3	3,151,891.3	1,565.1	1.0	0.6
11/09/2019 15:00	11.4	13.4	9.0	148.2	3,472,927.9	2,054.2	1.4	1.0
11/09/2019 16:00	11.5	13.4	9.0	159.5	3,466,128.6	2,100.8	1.5	1.3
11/09/2019 17:00	11.4	13.3	8.9	164.3	3,430,972.0	2,129.6	1.6	1.3
11/09/2019 18:00	11.3	13.4	8.9	157.1	3,468,438.5	2,102.2	1.5	1.3
11/09/2019 19:00	11.0	13.4	8.7	155.5	3,475,533.1	2,106.5	1.5	1.3
11/09/2019 20:00	11.1	13.4	8.7	156.9	3,457,879.1	2,095.8	1.5	1.3
11/09/2019 21:00	10.9	13.4	8.6	154.8	3,502,426.6	2,122.8	1.5	1.3
11/09/2019 22:00	11.1	13.3	8.6	161.3	3,491,869.2	2,141.9	1.6	1.3
11/09/2019 23:00	10.9	13.4	8.6	157.4	3,487,907.4	2,114.0	1.5	1.3
Average/Sum#:	10.4	13.6	8.4	141.6	3,278,965.4	1,910.1	1.4	1.1
Minimum:	8.7	13.3	7.3	86.9	2,670,780.3	1,324.1	1.0	0.5
Maximum:	11.5	14.1	9.0	181.1	3,519,587.7	2,182.0	1.8	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/10/2019 00:00	11.1	13.4	8.7	161.0	3,512,656.0	2,129.0	1.5	1.3
11/10/2019 01:00	11.0	13.4	8.7	147.8	3,531,232.0	2,062.9	1.4	1.0
11/10/2019 02:00	11.0	13.4	8.7	149.3	3,481,212.0	2,059.1	1.4	1.0
11/10/2019 03:00	10.9	13.4	8.6	152.5	3,486,791.2	2,062.4	1.5	1.2
11/10/2019 04:00	10.8	13.4	8.5	149.1	3,486,960.2	2,062.5	1.4	1.0
11/10/2019 05:00	10.6	13.4	8.3	142.3	3,482,057.4	2,059.6	1.4	1.0
11/10/2019 06:00	11.2	13.4	8.8	153.0	3,510,235.5	2,101.9	1.5	1.3
11/10/2019 07:00	10.7	13.5	8.5	157.3	3,461,637.6	2,072.8	1.5	1.2
11/10/2019 08:00	8.7	13.9	7.3	100.2	3,175,476.8	1,600.0	1.0	0.6
11/10/2019 09:00	8.8	13.9	7.4	97.0	3,147,058.1	1,562.7	1.0	0.6
11/10/2019 10:00	8.9	13.9	7.5	97.6	3,163,370.3	1,570.8	1.0	0.6
11/10/2019 11:00	9.0	14.0	7.7	101.2	3,240,702.5	1,609.2	1.0	0.6
11/10/2019 12:00	8.9	14.0	7.6	99.6	3,216,334.8	1,597.1	1.0	0.6
11/10/2019 13:00	9.0	14.0	7.7	104.4	3,392,748.9	1,684.7	1.0	0.7
11/10/2019 14:00	9.1	14.0	7.8	102.6	3,318,034.7	1,647.6	1.0	0.7
11/10/2019 15:00	9.7	13.9	8.2	107.7	3,138,561.9	1,581.4	1.1	0.6
11/10/2019 16:00	11.4	13.4	9.0	145.2	3,466,841.5	2,050.6	1.4	1.0
11/10/2019 17:00	11.2	13.3	8.7	154.6	3,469,098.4	2,102.6	1.5	1.3
11/10/2019 18:00	11.3	13.3	8.8	154.6	3,458,704.0	2,096.3	1.5	1.3
11/10/2019 19:00	11.2	13.3	8.7	157.3	3,448,667.1	2,115.4	1.5	1.3
11/10/2019 20:00	11.1	13.3	8.6	160.7	3,467,252.1	2,126.8	1.6	1.3
11/10/2019 21:00	11.0	13.3	8.5	160.6	3,484,782.3	2,163.0	1.6	1.3
11/10/2019 22:00	11.0	13.3	8.5	172.5	3,470,939.9	2,205.1	1.7	1.5
11/10/2019 23:00	10.9	13.3	8.5	160.5	3,456,588.3	2,145.5	1.6	1.3
Average/Sum#:	10.4	13.6	8.3	137.0	3,394,497.6	1,936.2	1.3	1.0
Minimum:	8.7	13.3	7.3	97.0	3,138,561.9	1,562.7	1.0	0.6
Maximum:	11.4	14.0	9.0	172.5	3,531,232.0	2,205.1	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/11/2019 00:00	11.1	13.3	8.6	157.3	3,479,316.1	2,134.2	1.5	1.3
11/11/2019 01:00	11.0	13.4	8.7	155.6	3,453,094.3	2,092.9	1.5	1.3
11/11/2019 02:00	11.1	13.4	8.7	154.3	3,493,187.1	2,117.2	1.5	1.3
11/11/2019 03:00	10.9	13.4	8.6	150.8	3,458,539.0	2,096.2	1.5	1.3
11/11/2019 04:00	10.9	13.4	8.6	152.2	3,459,859.0	2,097.0	1.5	1.3
11/11/2019 05:00	11.1	13.3	8.6	152.3	3,488,358.1	2,088.8	1.5	1.3
11/11/2019 06:00	11.3	13.4	8.9	152.4	3,495,372.2	2,093.0	1.5	1.3
11/11/2019 07:00	11.1	13.4	8.7	154.5	3,469,923.4	2,103.1	1.5	1.3
11/11/2019 08:00	10.9	13.5	8.7	144.8	3,473,713.9	1,953.2	1.4	1.0
11/11/2019 09:00	9.3	13.9	7.8	103.5	3,044,686.9	1,534.1	1.1	0.6
11/11/2019 10:00	9.0	13.9	7.6	96.1	3,121,079.3	1,549.8	1.0	0.6
11/11/2019 11:00	9.1	13.9	7.7	95.8	3,105,975.3	1,542.3	1.0	0.6
11/11/2019 12:00	9.1	13.9	7.7	95.2	3,080,399.3	1,529.6	1.0	0.6
11/11/2019 13:00	10.3	13.8	8.6	115.6	3,475,360.9	1,751.1	1.1	0.7
11/11/2019 14:00	11.4	13.4	9.0	145.4	3,467,553.7	2,025.7	1.4	1.0
11/11/2019 15:00	11.4	13.3	8.9	161.9	3,418,566.6	2,121.9	1.6	1.3
11/11/2019 16:00	11.3	13.3	8.8	160.0	3,409,222.3	2,116.1	1.6	1.3
11/11/2019 17:00	11.2	13.3	8.7	179.0	3,391,455.6	2,228.9	1.8	1.6
11/11/2019 18:00	11.1	13.3	8.6	179.9	3,398,172.8	2,208.5	1.8	1.5
11/11/2019 19:00	11.1	13.3	8.6	169.1	3,417,422.2	2,171.1	1.7	1.5
11/11/2019 20:00	11.0	13.3	8.5	167.8	3,422,931.3	2,174.6	1.7	1.5
11/11/2019 21:00	10.9	13.3	8.5	167.4	3,472,764.7	2,180.9	1.6	1.3
11/11/2019 22:00	11.0	13.3	8.5	170.8	3,469,898.5	2,179.1	1.7	1.5
11/11/2019 23:00	11.1	13.3	8.6	164.2	3,447,924.0	2,165.3	1.6	1.3
Average/Sum#:	10.7	13.5	8.5	147.7	3,392,282.4	2,010.6	1.5	1.2
Minimum:	9.0	13.3	7.6	95.2	3,044,686.9	1,529.6	1.0	0.6
Maximum:	11.4	13.9	9.0	179.9	3,495,372.2	2,228.9	1.8	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/12/2019 00:00	11.0	13.3	8.5	163.5	3,460,616.0	2,148.0	1.6	1.3
11/12/2019 01:00	11.0	13.3	8.5	163.0	3,465,771.5	2,151.2	1.6	1.3
11/12/2019 02:00	10.9	13.3	8.5	153.1	3,494,672.0	2,118.1	1.5	1.3
11/12/2019 03:00	10.8	13.4	8.5	165.6	3,444,580.0	2,163.2	1.6	1.3
11/12/2019 04:00	10.8	13.4	8.5	160.3	3,453,205.0	2,143.4	1.6	1.3
11/12/2019 05:00	10.8	13.4	8.5	159.1	3,461,220.1	2,123.1	1.6	1.3
11/12/2019 06:00	11.3	13.4	8.9	167.1	3,452,701.0	2,168.3	1.6	1.3
11/12/2019 07:00	10.9	13.4	8.6	160.0	3,438,060.7	2,134.0	1.6	1.3
11/12/2019 08:00	10.9	13.4	8.6	164.2	3,458,774.7	2,121.6	1.6	1.3
11/12/2019 09:00	10.9	13.4	8.6	160.9	3,439,537.6	2,109.8	1.6	1.3
11/12/2019 10:00	10.9	13.4	8.6	168.4	3,450,143.9	2,141.5	1.7	1.5
11/12/2019 11:00	10.9	13.4	8.6	160.7	3,419,811.3	2,097.7	1.6	1.3
11/12/2019 12:00	10.8	13.4	8.5	156.5	3,399,433.0	2,085.2	1.6	1.3
11/12/2019 13:00	10.9	13.4	8.6	160.8	3,436,766.1	2,108.1	1.6	1.3
11/12/2019 14:00	11.1	13.4	8.7	159.1	3,462,993.8	2,098.9	1.6	1.3
11/12/2019 15:00	11.2	13.3	8.7	156.6	3,424,213.1	2,100.4	1.5	1.3
11/12/2019 16:00	11.2	13.4	8.8	156.5	3,446,989.7	2,089.2	1.5	1.3
11/12/2019 17:00	11.3	13.3	8.8	170.6	3,441,236.1	2,161.1	1.7	1.5
11/12/2019 18:00	11.2	13.3	8.7	163.5	3,417,987.7	2,146.5	1.6	1.3
11/12/2019 19:00	11.1	13.3	8.6	172.2	3,435,366.3	2,182.5	1.7	1.5
11/12/2019 20:00	10.9	13.3	8.5	166.4	3,433,005.3	2,181.0	1.7	1.5
11/12/2019 21:00	11.0	13.3	8.5	166.4	3,436,299.8	2,158.0	1.7	1.5
11/12/2019 22:00	10.9	13.3	8.5	162.8	3,437,414.4	2,158.7	1.6	1.3
11/12/2019 23:00	10.9	13.3	8.5	160.7	3,459,810.4	2,147.5	1.6	1.3
Average/Sum#:	11.0	13.4	8.6	162.4	3,444,608.7	2,134.9	1.6	1.3
Minimum:	10.8	13.3	8.5	153.1	3,399,433.0	2,085.2	1.5	1.3
Maximum:	11.3	13.4	8.9	172.2	3,494,672.0	2,182.5	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/13/2019 00:00	10.8	13.3	8.4	158.2	3,477,685.8	2,133.2	1.5	1.3
11/13/2019 01:00	10.7	13.4	8.4	149.0	3,463,158.8	2,099.0	1.4	1.0
11/13/2019 02:00	10.7	13.4	8.4	152.6	3,463,818.7	2,099.4	1.5	1.3
11/13/2019 03:00	10.7	13.4	8.4	152.5	3,459,694.0	2,096.9	1.5	1.3
11/13/2019 04:00	10.8	13.4	8.5	157.0	3,463,991.6	2,124.8	1.5	1.3
11/13/2019 05:00	10.8	13.4	8.5	163.1	3,431,294.2	2,129.8	1.6	1.3
11/13/2019 06:00	11.1	13.4	8.7	162.4	3,435,822.1	2,157.7	1.6	1.3
11/13/2019 07:00	10.8	13.4	8.5	163.4	3,447,727.3	2,140.0	1.6	1.3
11/13/2019 08:00	10.7	13.4	8.4	152.0	3,485,432.5	2,112.5	1.5	1.3
11/13/2019 09:00	10.8	13.4	8.5	156.0	3,462,828.8	2,098.8	1.5	1.3
11/13/2019 10:00	10.8	13.4	8.5	157.4	3,445,009.8	2,088.0	1.5	1.3
11/13/2019 11:00	10.9	13.4	8.6	156.5	3,437,907.3	2,108.8	1.5	1.3
11/13/2019 12:00	11.0	13.3	8.5	156.5	3,471,078.3	2,103.8	1.5	1.3
11/13/2019 13:00	11.1	13.3	8.6	162.3	3,423,722.1	2,125.1	1.6	1.3
11/13/2019 14:00	11.0	13.3	8.5	159.9	3,444,827.3	2,138.2	1.6	1.3
11/13/2019 15:00	11.1	13.3	8.6	161.9	3,444,505.1	2,138.0	1.6	1.3
11/13/2019 16:00	11.1	13.3	8.6	158.9	3,435,135.9	2,107.1	1.6	1.3
11/13/2019 17:00	11.2	13.3	8.7	185.0	3,389,934.0	2,227.9	1.9	1.6
11/13/2019 18:00	11.0	13.3	8.5	164.7	3,409,237.1	2,165.9	1.6	1.3
11/13/2019 19:00	10.9	13.3	8.5	159.3	3,423,399.9	2,124.9	1.6	1.3
11/13/2019 20:00	10.9	13.3	8.5	165.1	3,431,682.0	2,155.1	1.6	1.3
11/13/2019 21:00	10.8	13.3	8.4	158.6	3,413,051.4	2,143.4	1.6	1.3
11/13/2019 22:00	10.8	13.3	8.4	154.6	3,450,786.4	2,116.7	1.5	1.3
11/13/2019 23:00	11.0	13.3	8.5	166.1	3,432,637.4	2,155.7	1.6	1.3
Average/Sum#:	10.9	13.3	8.5	159.7	3,443,515.3	2,128.8	1.6	1.3
Minimum:	10.7	13.3	8.4	149.0	3,389,934.0	2,088.0	1.4	1.0
Maximum:	11.2	13.4	8.7	185.0	3,485,432.5	2,227.9	1.9	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/14/2019 00:00	11.0	13.3	8.5	166.8	3,426,866.5	2,177.1	1.7	1.5
11/14/2019 01:00	10.9	13.3	8.5	168.4	3,434,894.1	2,182.2	1.7	1.5
11/14/2019 02:00	10.9	13.3	8.5	168.6	3,461,618.2	2,173.9	1.7	1.5
11/14/2019 03:00	10.9	13.3	8.5	168.3	3,435,208.9	2,182.4	1.7	1.5
11/14/2019 04:00	10.9	13.3	8.5	166.1	3,425,607.2	2,176.3	1.7	1.5
11/14/2019 05:00	10.9	13.3	8.5	163.9	3,423,242.5	2,149.8	1.6	1.3
11/14/2019 06:00	10.9	13.3	8.5	160.5	3,483,433.5	2,187.6	1.6	1.3
11/14/2019 07:00	10.9	13.4	8.6	162.6	3,457,716.0	2,146.2	1.6	1.3
11/14/2019 08:00	10.8	13.4	8.5	154.8	3,447,814.6	2,089.7	1.5	1.3
11/14/2019 09:00	10.9	13.4	8.6	161.9	3,451,271.7	2,142.2	1.6	1.3
11/14/2019 10:00	10.8	13.4	8.5	170.3	3,412,227.8	2,167.8	1.7	1.5
11/14/2019 11:00	10.8	13.4	8.5	161.7	3,415,183.3	2,119.8	1.6	1.3
11/14/2019 12:00	10.8	13.3	8.4	169.6	3,398,973.6	2,184.2	1.7	1.5
11/14/2019 13:00	11.0	13.3	8.5	173.2	3,421,986.9	2,174.0	1.7	1.5
11/14/2019 14:00	11.1	13.3	8.6	166.8	3,414,274.1	2,169.1	1.7	1.5
11/14/2019 15:00	11.0	13.3	8.5	169.9	3,408,135.3	2,165.2	1.7	1.5
11/14/2019 16:00	11.1	13.3	8.6	162.6	3,409,229.8	2,141.0	1.6	1.3
11/14/2019 17:00	11.1	13.3	8.6	167.3	3,399,163.2	2,159.5	1.7	1.5
11/14/2019 18:00	11.1	13.3	8.6	169.0	3,444,420.8	2,163.1	1.7	1.5
11/14/2019 19:00	11.1	13.3	8.6	163.6	3,438,688.3	2,159.5	1.6	1.3
11/14/2019 20:00	11.0	13.3	8.5	167.8	3,434,894.1	2,182.2	1.7	1.5
11/14/2019 21:00	10.7	13.3	8.3	159.8	3,456,204.2	2,170.5	1.6	1.3
11/14/2019 22:00	10.6	13.3	8.2	156.7	3,452,077.2	2,142.7	1.5	1.3
11/14/2019 23:00	10.8	13.3	8.4	162.3	3,485,104.5	2,163.2	1.6	1.3
Average/Sum#:	10.9	13.3	8.5	165.1	3,434,926.5	2,161.2	1.6	1.4
Minimum:	10.6	13.3	8.2	154.8	3,398,973.6	2,089.7	1.5	1.3
Maximum:	11.1	13.4	8.6	173.2	3,485,104.5	2,187.6	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/15/2019 00:00	10.8	13.3	8.4	154.6	3,467,089.1	2,126.7	1.5	1.3
11/15/2019 01:00	10.8	13.3	8.4	152.3	3,505,559.4	2,099.1	1.5	1.3
11/15/2019 02:00	10.7	13.3	8.3	152.3	3,495,332.0	2,118.5	1.5	1.3
11/15/2019 03:00	10.7	13.4	8.4	148.6	3,512,827.1	2,077.8	1.4	1.0
11/15/2019 04:00	10.8	13.4	8.5	151.3	3,480,175.0	2,083.9	1.5	1.3
11/15/2019 05:00	10.7	13.4	8.4	146.1	3,510,629.3	2,076.5	1.4	1.0
11/15/2019 06:00	11.3	13.3	8.8	160.3	3,494,477.6	2,143.5	1.5	1.3
11/15/2019 07:00	11.0	13.3	8.5	160.4	3,478,337.9	2,159.0	1.6	1.3
11/15/2019 08:00	10.8	13.3	8.4	154.0	3,474,873.1	2,106.1	1.5	1.3
11/15/2019 09:00	11.0	13.4	8.7	158.2	3,463,653.7	2,099.3	1.5	1.3
11/15/2019 10:00	11.0	13.3	8.5	159.3	3,478,667.9	2,108.4	1.6	1.3
11/15/2019 11:00	10.5	13.4	8.3	140.8	3,504,321.9	1,996.0	1.3	1.0
11/15/2019 12:00	10.9	13.3	8.5	153.2	3,469,486.8	2,077.5	1.5	1.2
11/15/2019 13:00	11.0	13.3	8.5	159.7	3,442,249.6	2,136.6	1.6	1.3
11/15/2019 14:00	11.1	13.3	8.6	168.2	3,446,490.9	2,164.4	1.7	1.5
11/15/2019 15:00	11.0	13.3	8.5	162.6	3,452,882.8	2,143.2	1.6	1.3
11/15/2019 16:00	11.0	13.3	8.5	157.9	3,454,210.0	2,118.8	1.5	1.3
11/15/2019 17:00	11.1	13.3	8.6	170.5	3,425,135.0	2,176.0	1.7	1.5
11/15/2019 18:00	11.0	13.4	8.7	153.9	3,480,008.0	2,083.8	1.5	1.3
11/15/2019 19:00	11.1	13.3	8.6	156.4	3,456,329.3	2,120.1	1.5	1.3
11/15/2019 20:00	11.1	13.3	8.6	171.2	3,467,828.4	2,177.8	1.7	1.5
11/15/2019 21:00	11.0	13.3	8.5	155.8	3,453,068.8	2,118.1	1.5	1.3
11/15/2019 22:00	10.9	13.3	8.5	155.9	3,467,089.1	2,126.7	1.5	1.3
11/15/2019 23:00	11.0	13.3	8.5	152.5	3,445,339.8	2,088.2	1.5	1.3
Average/Sum#:	10.9	13.3	8.5	156.5	3,471,919.3	2,113.6	1.5	1.3
Minimum:	10.5	13.3	8.3	140.8	3,425,135.0	1,996.0	1.3	1.0
Maximum:	11.3	13.4	8.8	171.2	3,512,827.1	2,177.8	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/16/2019 00:00	11.0	13.4	8.7	153.5	3,471,156.8	2,078.5	1.5	1.2
11/16/2019 01:00	10.7	13.4	8.4	143.9	3,499,132.9	2,069.7	1.4	1.0
11/16/2019 02:00	10.9	13.4	8.6	151.2	3,474,997.9	2,080.8	1.5	1.2
11/16/2019 03:00	10.8	13.4	8.5	151.8	3,480,509.0	2,084.1	1.5	1.3
11/16/2019 04:00	10.5	13.4	8.3	145.2	3,470,655.8	2,078.2	1.4	1.0
11/16/2019 05:00	10.5	13.4	8.3	146.5	3,484,517.0	2,086.5	1.4	1.0
11/16/2019 06:00	11.0	13.4	8.7	149.2	3,464,808.7	2,100.0	1.4	1.1
11/16/2019 07:00	10.6	13.4	8.3	151.0	3,453,654.5	2,042.8	1.5	1.2
11/16/2019 08:00	8.7	13.9	7.3	103.3	3,276,496.7	1,650.9	1.0	0.7
11/16/2019 09:00	8.9	13.9	7.5	96.9	3,077,235.5	1,550.5	1.0	0.6
11/16/2019 10:00	9.1	13.9	7.7	98.8	3,129,630.9	1,576.9	1.0	0.6
11/16/2019 11:00	9.0	13.9	7.6	103.9	3,312,617.7	1,669.1	1.0	0.7
11/16/2019 12:00	9.1	13.9	7.7	102.0	3,226,681.4	1,625.8	1.0	0.7
11/16/2019 13:00	9.0	13.9	7.6	106.0	3,441,282.9	1,708.8	1.0	0.7
11/16/2019 14:00	9.0	13.9	7.6	104.7	3,396,373.9	1,686.5	1.0	0.7
11/16/2019 15:00	9.6	13.9	8.1	103.4	3,138,561.9	1,581.4	1.1	0.6
11/16/2019 16:00	11.4	13.4	9.0	149.8	3,462,305.6	2,073.2	1.4	1.0
11/16/2019 17:00	11.3	13.3	8.8	162.9	3,443,860.7	2,137.6	1.6	1.3
11/16/2019 18:00	11.2	13.3	8.7	160.4	3,454,373.0	2,118.9	1.6	1.3
11/16/2019 19:00	11.0	13.3	8.5	157.2	3,470,023.6	2,128.5	1.5	1.3
11/16/2019 20:00	10.9	13.3	8.5	157.5	3,436,610.8	2,133.1	1.6	1.3
11/16/2019 21:00	11.0	13.3	8.5	163.8	3,449,821.7	2,141.3	1.6	1.3
11/16/2019 22:00	10.8	13.4	8.5	156.0	3,463,828.6	2,124.7	1.5	1.3
11/16/2019 23:00	10.9	13.4	8.6	154.7	3,489,722.3	2,115.1	1.5	1.3
Average/Sum#:	10.3	13.5	8.3	136.4	3,394,535.8	1,943.5	1.3	1.0
Minimum:	8.7	13.3	7.3	96.9	3,077,235.5	1,550.5	1.0	0.6
Maximum:	11.4	13.9	9.0	163.8	3,499,132.9	2,141.3	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/17/2019 00:00	10.9	13.4	8.6	150.6	3,503,388.4	2,097.8	1.4	1.0
11/17/2019 01:00	10.8	13.4	8.5	150.1	3,507,396.5	2,100.2	1.4	1.1
11/17/2019 02:00	9.9	13.5	7.9	128.4	3,492,572.7	1,938.3	1.2	1.0
11/17/2019 03:00	8.9	13.9	7.5	100.2	3,164,958.1	1,594.7	1.0	0.6
11/17/2019 04:00	8.9	13.9	7.5	105.9	3,377,516.5	1,701.8	1.0	0.7
11/17/2019 05:00	9.1	13.9	7.7	99.2	3,105,020.9	1,564.5	1.0	0.6
11/17/2019 06:00	9.2	13.9	7.8	106.9	3,381,485.9	1,703.8	1.0	0.7
11/17/2019 07:00	9.2	13.9	7.8	104.4	3,295,152.6	1,660.3	1.0	0.7
11/17/2019 08:00	9.1	13.9	7.7	104.6	3,301,900.5	1,663.7	1.0	0.7
11/17/2019 09:00	9.1	13.9	7.7	105.4	3,317,777.9	1,671.7	1.0	0.7
11/17/2019 10:00	9.2	13.9	7.8	103.8	3,274,909.0	1,650.1	1.0	0.7
11/17/2019 11:00	9.1	13.9	7.7	106.3	3,385,455.2	1,705.8	1.0	0.7
11/17/2019 12:00	9.1	13.9	7.7	102.5	3,286,618.5	1,632.0	1.0	0.7
11/17/2019 13:00	9.0	14.0	7.7	104.6	3,382,478.2	1,679.6	1.0	0.7
11/17/2019 14:00	9.6	13.9	8.1	100.5	3,102,043.9	1,563.0	1.1	0.6
11/17/2019 15:00	11.5	13.4	9.0	152.1	3,430,074.1	2,053.9	1.5	1.2
11/17/2019 16:00	11.3	13.3	8.8	156.1	3,439,048.5	2,109.5	1.5	1.3
11/17/2019 17:00	11.2	13.3	8.7	157.3	3,419,974.4	2,097.8	1.6	1.3
11/17/2019 18:00	11.1	13.3	8.6	158.6	3,409,866.7	2,116.5	1.6	1.3
11/17/2019 19:00	11.3	13.3	8.8	169.1	3,414,006.8	2,144.0	1.7	1.5
11/17/2019 20:00	11.1	13.3	8.6	164.3	3,422,287.1	2,149.2	1.6	1.3
11/17/2019 21:00	11.1	13.3	8.6	165.2	3,427,541.8	2,152.5	1.6	1.3
11/17/2019 22:00	11.0	13.3	8.5	159.6	3,445,080.5	2,113.2	1.6	1.3
11/17/2019 23:00	10.9	13.4	8.6	149.0	3,483,181.0	2,085.7	1.4	1.0
Average/Sum#:	10.1	13.6	8.2	129.4	3,365,405.7	1,872.9	1.3	0.9
Minimum:	8.9	13.3	7.5	99.2	3,102,043.9	1,563.0	1.0	0.6
Maximum:	11.5	14.0	9.0	169.1	3,507,396.5	2,152.5	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/18/2019 00:00	10.9	13.4	8.6	158.0	3,422,419.8	2,099.3	1.6	1.3
11/18/2019 01:00	10.8	13.4	8.5	155.6	3,467,118.6	2,101.4	1.5	1.3
11/18/2019 02:00	10.7	13.4	8.4	154.8	3,463,653.7	2,099.3	1.5	1.3
11/18/2019 03:00	10.8	13.4	8.5	152.6	3,464,148.7	2,099.6	1.5	1.3
11/18/2019 04:00	10.7	13.4	8.4	152.5	3,479,507.0	2,083.5	1.5	1.3
11/18/2019 05:00	10.8	13.4	8.5	159.8	3,446,164.7	2,088.7	1.6	1.3
11/18/2019 06:00	11.2	13.3	8.7	163.2	3,437,414.4	2,158.7	1.6	1.3
11/18/2019 07:00	10.9	13.4	8.6	160.9	3,441,282.9	2,136.0	1.6	1.3
11/18/2019 08:00	10.8	13.4	8.5	151.8	3,480,509.0	2,084.1	1.5	1.3
11/18/2019 09:00	10.9	13.4	8.6	150.6	3,469,094.3	2,026.6	1.5	1.2
11/18/2019 10:00	11.2	13.3	8.7	163.6	3,456,818.4	2,120.4	1.6	1.3
11/18/2019 11:00	11.0	13.3	8.5	172.3	3,405,198.2	2,188.2	1.7	1.5
11/18/2019 12:00	10.9	13.3	8.5	160.0	3,413,688.4	2,143.8	1.6	1.3
11/18/2019 13:00	11.0	13.3	8.5	169.4	3,406,403.8	2,164.1	1.7	1.5
11/18/2019 14:00	10.9	13.3	8.5	164.0	3,382,635.6	2,149.0	1.7	1.5
11/18/2019 15:00	11.1	13.3	8.6	166.4	3,380,117.2	2,147.4	1.7	1.5
11/18/2019 16:00	11.1	13.3	8.6	178.1	3,350,220.7	2,201.8	1.8	1.5
11/18/2019 17:00	11.0	13.3	8.5	178.1	3,395,238.8	2,181.8	1.8	1.5
11/18/2019 18:00	10.9	13.2	8.4	183.3	3,368,182.0	2,238.2	1.9	1.6
11/18/2019 19:00	11.0	13.3	8.5	176.4	3,391,094.8	2,203.9	1.8	1.5
11/18/2019 20:00	11.0	13.3	8.5	176.0	3,382,632.1	2,198.4	1.8	1.5
11/18/2019 21:00	11.0	13.3	8.5	168.9	3,395,542.9	2,157.2	1.7	1.5
11/18/2019 22:00	10.9	13.3	8.5	163.7	3,387,515.2	2,152.1	1.6	1.3
11/18/2019 23:00	11.0	13.3	8.5	166.7	3,414,006.8	2,144.0	1.7	1.5
Average/Sum#:	10.9	13.3	8.5	164.4	3,420,858.7	2,140.3	1.6	1.4
Minimum:	10.7	13.2	8.4	150.6	3,350,220.7	2,026.6	1.5	1.2
Maximum:	11.2	13.4	8.7	183.3	3,480,509.0	2,238.2	1.9	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/19/2019 00:00	11.0	13.3	8.5	164.3	3,406,204.3	2,139.1	1.6	1.3
11/19/2019 01:00	11.0	13.3	8.5	155.6	3,418,344.1	2,096.8	1.5	1.3
11/19/2019 02:00	10.9	13.3	8.5	150.6	3,411,170.9	2,092.4	1.5	1.3
11/19/2019 03:00	10.9	13.4	8.6	153.1	3,404,975.9	2,088.6	1.5	1.3
11/19/2019 04:00	10.9	13.3	8.5	156.6	3,414,594.5	2,094.5	1.6	1.3
11/19/2019 05:00	10.9	13.3	8.5	160.2	3,392,628.1	2,105.8	1.6	1.3
11/19/2019 06:00	11.2	13.4	8.8	150.9	3,402,530.5	2,087.1	1.5	1.3
11/19/2019 07:00	11.1	13.3	8.6	160.6	3,401,811.3	2,111.5	1.6	1.3
11/19/2019 08:00	11.1	13.3	8.6	173.4	3,387,458.0	2,176.8	1.8	1.5
11/19/2019 09:00	0.0	0.0	0.0	181.4	1,405,789.5	2,145.5	4.8	3.9
11/19/2019 10:00	11.6	13.5	9.2	196.0	3,441,977.4	2,186.7	2.0	1.7
11/19/2019 11:00	11.5	13.4	9.0	164.4	3,470,121.4	2,153.9	1.6	1.3
11/19/2019 12:00	11.2	13.4	8.8	162.3	3,423,722.1	2,125.1	1.6	1.3
11/19/2019 13:00	11.1	13.4	8.7	160.3	3,445,569.6	2,113.5	1.6	1.3
11/19/2019 14:00	11.1	13.4	8.7	168.3	3,409,707.5	2,141.3	1.7	1.5
11/19/2019 15:00	11.0	13.4	8.7	158.4	3,433,342.6	2,106.0	1.6	1.3
11/19/2019 16:00	11.1	13.4	8.7	158.6	3,429,592.9	2,103.7	1.6	1.3
11/19/2019 17:00	11.1	13.3	8.6	188.0	3,415,713.7	2,219.9	1.9	1.6
11/19/2019 18:00	11.0	13.3	8.5	196.1	3,372,058.7	2,265.4	2.0	1.8
11/19/2019 19:00	10.8	13.4	8.5	162.2	3,415,917.7	2,145.2	1.6	1.3
11/19/2019 20:00	10.9	13.4	8.6	159.2	3,447,362.9	2,114.6	1.6	1.3
11/19/2019 21:00	11.0	13.4	8.7	163.2	3,448,210.6	2,140.3	1.6	1.3
11/19/2019 22:00	10.9	13.3	8.5	165.0	3,456,427.1	2,145.4	1.6	1.3
11/19/2019 23:00	10.9	13.3	8.5	165.1	3,430,567.3	2,154.4	1.6	1.3
Average/Sum#:	11.1	13.4	8.6	165.6	3,420,870.0	2,135.6	1.6	1.4
Minimum:	10.8	13.3	8.5	150.6	3,372,058.7	2,087.1	1.5	1.3
Maximum:	11.6	13.5	9.2	196.1	3,470,121.4	2,265.4	2.0	1.8
%SI	4.17	4.17	4.17	0.00	4.17	0.00	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/20/2019 00:00	10.9	13.4	8.6	160.4	3,456,655.4	2,120.3	1.6	1.3
11/20/2019 01:00	11.0	13.4	8.7	155.9	3,465,138.7	2,100.2	1.5	1.3
11/20/2019 02:00	11.0	13.4	8.7	152.0	3,468,150.8	2,076.7	1.5	1.2
11/20/2019 03:00	11.0	13.4	8.7	152.6	3,479,507.0	2,083.5	1.5	1.3
11/20/2019 04:00	11.0	13.4	8.7	155.1	3,469,263.4	2,102.7	1.5	1.3
11/20/2019 05:00	11.0	13.4	8.7	168.8	3,433,505.6	2,106.1	1.7	1.5
11/20/2019 06:00	11.3	13.3	8.8	167.1	3,455,089.6	2,169.8	1.6	1.3
11/20/2019 07:00	11.1	13.3	8.6	172.4	3,455,986.4	2,195.6	1.7	1.5
11/20/2019 08:00	10.8	13.3	8.4	165.7	3,432,060.8	2,180.4	1.6	1.3
11/20/2019 09:00	10.8	13.3	8.4	170.4	3,452,051.3	2,193.1	1.7	1.5
11/20/2019 10:00	10.9	13.3	8.5	172.0	3,451,264.3	2,192.6	1.7	1.5
11/20/2019 11:00	10.8	13.3	8.4	158.9	3,446,116.2	2,139.0	1.6	1.3
11/20/2019 12:00	10.9	13.4	8.6	161.8	3,451,755.0	2,142.5	1.6	1.3
11/20/2019 13:00	10.9	13.3	8.5	164.0	3,464,643.7	2,150.5	1.6	1.3
11/20/2019 14:00	10.7	13.3	8.3	151.3	3,418,366.6	2,171.7	1.5	1.3
11/20/2019 15:00	10.9	13.3	8.5	159.7	3,436,165.9	2,208.1	1.6	1.3
11/20/2019 16:00	10.9	13.3	8.5	150.9	3,445,057.7	2,163.5	1.5	1.3
11/20/2019 17:00	10.8	13.3	8.4	173.9	3,421,303.7	2,273.5	1.7	1.6
11/20/2019 18:00	10.8	13.3	8.4	177.9	3,397,065.6	2,282.2	1.8	1.6
11/20/2019 19:00	10.7	13.3	8.3	174.1	3,410,611.0	2,291.3	1.8	1.6
11/20/2019 20:00	10.8	13.3	8.4	167.2	3,419,300.5	2,247.2	1.7	1.6
11/20/2019 21:00	10.8	13.3	8.4	160.7	3,460,908.9	2,224.0	1.6	1.3
11/20/2019 22:00	10.8	13.3	8.4	149.5	3,461,618.2	2,173.9	1.5	1.3
11/20/2019 23:00	10.8	13.4	8.5	148.5	3,470,926.9	2,154.4	1.4	1.1
Average/Sum#:	10.9	13.3	8.5	162.1	3,446,771.4	2,172.6	1.6	1.4
Minimum:	10.7	13.3	8.3	148.5	3,397,065.6	2,076.7	1.4	1.1
Maximum:	11.3	13.4	8.8	177.9	3,479,507.0	2,291.3	1.8	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/21/2019 00:00	10.9	13.3	8.5	153.9	3,484,229.6	2,188.1	1.5	1.3
11/21/2019 01:00	10.9	13.3	8.5	153.4	3,453,782.7	2,194.2	1.5	1.3
11/21/2019 02:00	10.9	13.3	8.5	152.0	3,470,694.6	2,179.6	1.5	1.3
11/21/2019 03:00	10.8	13.4	8.5	162.6	3,473,143.6	2,206.5	1.6	1.3
11/21/2019 04:00	10.8	13.4	8.5	165.1	3,446,903.4	2,215.0	1.6	1.3
11/21/2019 05:00	10.7	13.4	8.4	159.3	3,375,326.8	2,218.3	1.6	1.3
11/21/2019 06:00	11.2	13.4	8.8	179.8	3,431,837.7	2,280.5	1.8	1.6
11/21/2019 07:00	10.7	13.4	8.4	179.3	3,435,449.4	2,282.9	1.8	1.6
11/21/2019 08:00	10.4	13.4	8.2	153.2	3,489,165.9	2,191.2	1.5	1.3
11/21/2019 09:00	10.5	13.4	8.3	134.2	3,501,718.4	2,096.8	1.3	1.0
11/21/2019 10:00	10.9	13.4	8.6	144.7	3,474,751.3	2,131.4	1.4	1.1
11/21/2019 11:00	10.9	13.4	8.6	137.8	3,485,185.1	2,086.9	1.3	1.0
11/21/2019 12:00	10.9	13.4	8.6	143.1	3,469,045.4	2,127.9	1.4	1.1
11/21/2019 13:00	10.9	13.4	8.6	141.5	3,477,348.0	2,107.6	1.4	1.1
11/21/2019 14:00	10.9	13.4	8.6	138.4	3,458,374.0	2,096.1	1.3	1.0
11/21/2019 15:00	11.0	13.4	8.7	144.1	3,463,339.5	2,124.4	1.4	1.1
11/21/2019 16:00	11.0	13.3	8.5	161.5	3,455,617.9	2,220.6	1.6	1.3
11/21/2019 17:00	11.0	13.3	8.5	169.9	3,430,408.1	2,254.5	1.7	1.6
11/21/2019 18:00	10.9	13.3	8.5	176.8	3,428,828.0	2,278.5	1.8	1.6
11/21/2019 19:00	10.7	13.3	8.3	179.1	3,401,828.8	2,285.4	1.8	1.6
11/21/2019 20:00	10.8	13.4	8.5	182.7	3,391,260.4	2,278.3	1.9	1.6
11/21/2019 21:00	10.8	13.3	8.4	181.1	3,434,546.5	2,282.3	1.8	1.6
11/21/2019 22:00	10.7	13.4	8.4	169.5	3,460,643.1	2,249.1	1.7	1.6
11/21/2019 23:00	10.7	13.4	8.4	161.1	3,433,831.6	2,206.6	1.6	1.3
Average/Sum#:	10.8	13.4	8.5	159.3	3,451,135.8	2,199.3	1.6	1.3
Minimum:	10.4	13.3	8.2	134.2	3,375,326.8	2,086.9	1.3	1.0
Maximum:	11.2	13.4	8.8	182.7	3,501,718.4	2,285.4	1.9	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/22/2019 00:00	10.7	13.4	8.4	153.1	3,452,223.3	2,168.0	1.5	1.3
11/22/2019 01:00	10.7	13.4	8.4	153.0	3,485,748.9	2,163.6	1.5	1.3
11/22/2019 02:00	10.7	13.4	8.4	151.3	3,492,032.2	2,167.5	1.5	1.3
11/22/2019 03:00	10.7	13.4	8.4	150.9	3,489,615.5	2,166.0	1.5	1.3
11/22/2019 04:00	10.6	13.4	8.3	140.4	3,517,750.6	2,106.4	1.3	1.1
11/22/2019 05:00	10.2	13.5	8.1	134.2	3,474,496.9	2,080.5	1.3	1.0
11/22/2019 06:00	11.2	13.3	8.7	178.0	3,474,381.8	2,283.4	1.8	1.6
11/22/2019 07:00	10.7	13.3	8.3	169.7	3,481,415.3	2,262.6	1.7	1.6
11/22/2019 08:00	10.6	13.4	8.3	141.2	3,464,478.7	2,099.8	1.4	1.0
11/22/2019 09:00	10.7	13.4	8.4	138.6	3,507,248.0	2,074.5	1.3	1.0
11/22/2019 10:00	10.9	13.4	8.6	140.1	3,511,571.5	2,102.7	1.3	1.1
11/22/2019 11:00	10.9	13.4	8.6	136.7	3,510,798.4	2,076.6	1.3	1.0
11/22/2019 12:00	11.0	13.4	8.7	140.3	3,485,519.1	2,087.1	1.3	1.0
11/22/2019 13:00	10.9	13.4	8.6	137.8	3,471,156.8	2,078.5	1.3	1.0
11/22/2019 14:00	11.0	13.4	8.7	143.1	3,470,088.4	2,103.2	1.4	1.1
11/22/2019 15:00	11.0	13.4	8.7	145.2	3,436,440.1	2,107.9	1.4	1.1
11/22/2019 16:00	11.1	13.3	8.6	170.1	3,407,127.9	2,239.2	1.7	1.6
11/22/2019 17:00	10.9	13.3	8.5	163.8	3,425,253.5	2,226.1	1.6	1.3
11/22/2019 18:00	10.9	13.3	8.5	173.6	3,425,995.5	2,251.6	1.7	1.6
11/22/2019 19:00	10.9	13.3	8.5	165.5	3,419,714.3	2,222.5	1.6	1.3
11/22/2019 20:00	10.8	13.3	8.4	162.4	3,452,350.0	2,218.5	1.6	1.3
11/22/2019 21:00	10.8	13.4	8.5	168.3	3,429,869.5	2,229.1	1.7	1.6
11/22/2019 22:00	10.8	13.4	8.5	165.5	3,405,976.3	2,188.7	1.7	1.5
11/22/2019 23:00	10.7	13.4	8.4	150.1	3,457,393.8	2,146.0	1.5	1.3
Average/Sum#:	10.8	13.4	8.5	153.0	3,464,526.9	2,160.4	1.5	1.3
Minimum:	10.2	13.3	8.1	134.2	3,405,976.3	2,074.5	1.3	1.0
Maximum:	11.2	13.5	8.7	178.0	3,517,750.6	2,283.4	1.8	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/23/2019 00:00	10.9	13.4	8.6	154.0	3,440,155.2	2,135.3	1.5	1.3
11/23/2019 01:00	10.8	13.4	8.5	159.6	3,441,236.1	2,161.1	1.6	1.3
11/23/2019 02:00	10.6	13.4	8.3	144.1	3,507,682.7	2,151.6	1.4	1.1
11/23/2019 03:00	10.6	13.4	8.3	141.5	3,524,430.8	2,110.4	1.3	1.1
11/23/2019 04:00	10.7	13.4	8.4	150.0	3,483,493.4	2,162.2	1.5	1.3
11/23/2019 05:00	10.7	13.4	8.4	160.7	3,453,815.7	2,169.0	1.6	1.3
11/23/2019 06:00	11.2	13.4	8.8	158.9	3,469,898.5	2,179.1	1.5	1.3
11/23/2019 07:00	10.9	13.4	8.6	148.6	3,455,943.8	2,145.1	1.4	1.1
11/23/2019 08:00	8.7	13.7	7.1	114.2	3,472,469.0	1,952.5	1.1	0.8
11/23/2019 09:00	8.6	13.9	7.2	104.6	3,317,528.4	1,695.8	1.0	0.7
11/23/2019 10:00	8.8	13.9	7.4	106.0	3,404,706.6	1,715.5	1.0	0.7
11/23/2019 11:00	8.8	13.9	7.4	104.2	3,346,158.7	1,686.0	1.0	0.7
11/23/2019 12:00	8.8	13.9	7.4	105.0	3,380,692.0	1,703.4	1.0	0.7
11/23/2019 13:00	8.8	14.0	7.5	106.0	3,414,629.9	1,720.5	1.0	0.7
11/23/2019 14:00	8.8	14.0	7.5	104.4	3,355,486.7	1,690.7	1.0	0.7
11/23/2019 15:00	10.1	13.6	8.2	116.1	3,417,718.1	1,871.8	1.1	0.7
11/23/2019 16:00	11.2	13.3	8.7	147.7	3,431,363.5	2,154.9	1.4	1.1
11/23/2019 17:00	11.0	13.3	8.5	156.7	3,440,718.1	2,185.9	1.5	1.3
11/23/2019 18:00	10.9	13.3	8.5	156.2	3,440,088.5	2,185.5	1.5	1.3
11/23/2019 19:00	10.8	13.3	8.4	162.9	3,436,793.6	2,233.6	1.6	1.3
11/23/2019 20:00	10.7	13.3	8.3	159.7	3,452,816.8	2,218.8	1.6	1.3
11/23/2019 21:00	10.5	13.4	8.3	142.4	3,479,304.6	2,159.6	1.4	1.1
11/23/2019 22:00	10.5	13.4	8.3	142.1	3,495,332.0	2,118.5	1.4	1.1
11/23/2019 23:00	10.8	13.4	8.5	143.4	3,430,820.6	2,079.4	1.4	1.0
Average/Sum#:	10.2	13.5	8.1	137.0	3,437,220.1	2,024.4	1.3	1.0
Minimum:	8.6	13.3	7.1	104.2	3,317,528.4	1,686.0	1.0	0.7
Maximum:	11.2	14.0	8.8	162.9	3,524,430.8	2,233.6	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/24/2019 00:00	10.8	13.4	8.5	144.3	3,430,160.6	2,079.0	1.4	1.0
11/24/2019 01:00	10.7	13.4	8.4	139.4	3,471,490.8	2,078.7	1.3	1.0
11/24/2019 02:00	10.5	13.5	8.4	134.9	3,490,003.4	2,064.3	1.3	1.0
11/24/2019 03:00	10.3	13.5	8.2	129.7	3,530,889.6	2,062.7	1.2	1.0
11/24/2019 04:00	10.6	13.5	8.5	135.2	3,509,445.8	2,075.8	1.3	1.0
11/24/2019 05:00	10.5	13.5	8.4	136.9	3,503,359.5	2,072.2	1.3	1.0
11/24/2019 06:00	11.1	13.4	8.7	144.0	3,519,915.6	2,133.4	1.4	1.1
11/24/2019 07:00	10.1	13.5	8.1	138.7	3,454,957.5	2,068.8	1.3	1.0
11/24/2019 08:00	8.5	13.9	7.2	103.6	3,293,661.3	1,683.6	1.0	0.7
11/24/2019 09:00	8.7	13.9	7.3	103.5	3,272,337.4	1,672.7	1.0	0.7
11/24/2019 10:00	8.8	13.9	7.4	105.3	3,326,918.7	1,700.6	1.0	0.7
11/24/2019 11:00	8.8	13.9	7.4	105.1	3,315,767.7	1,694.9	1.0	0.7
11/24/2019 12:00	8.8	13.9	7.4	106.3	3,380,913.2	1,728.2	1.0	0.7
11/24/2019 13:00	8.8	13.9	7.4	105.6	3,397,164.8	1,711.7	1.0	0.7
11/24/2019 14:00	8.9	14.0	7.6	103.1	3,306,266.8	1,665.9	1.0	0.7
11/24/2019 15:00	10.4	13.6	8.4	116.5	3,410,049.3	1,867.6	1.1	0.7
11/24/2019 16:00	11.2	13.4	8.8	140.3	3,467,778.5	2,101.8	1.3	1.1
11/24/2019 17:00	11.1	13.3	8.6	151.8	3,432,318.9	2,155.5	1.5	1.3
11/24/2019 18:00	10.9	13.4	8.6	138.6	3,467,482.7	2,076.3	1.3	1.0
11/24/2019 19:00	10.3	13.5	8.2	128.1	3,450,607.1	2,015.8	1.2	1.0
11/24/2019 20:00	11.0	13.4	8.7	136.9	3,482,346.0	2,085.2	1.3	1.0
11/24/2019 21:00	10.9	13.4	8.6	149.5	3,438,866.3	2,134.5	1.5	1.3
11/24/2019 22:00	10.8	13.4	8.5	138.4	3,446,607.4	2,063.8	1.3	1.0
11/24/2019 23:00	9.0	13.7	7.4	114.0	3,363,306.3	1,842.0	1.1	0.7
Average/Sum#:	10.1	13.6	8.1	127.1	3,423,442.3	1,951.5	1.2	0.9
Minimum:	8.5	13.3	7.2	103.1	3,272,337.4	1,665.9	1.0	0.7
Maximum:	11.2	14.0	8.8	151.8	3,530,889.6	2,155.5	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/25/2019 00:00	14.9	14.8	14.4	115.0	2,307,694.1	1,078.5	1.6	0.6
11/25/2019 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2019 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2019 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2019 04:00	42.3	17.0	64.0	214.6	1,965,884.8	516.8	2.9	0.6
11/25/2019 05:00	27.7	14.5	25.5	195.1	2,843,267.4	1,328.8	2.1	1.1
11/25/2019 06:00	9.0	14.0	7.7	91.1	2,767,626.5	1,394.5	1.1	0.6
11/25/2019 07:00	8.9	13.9	7.5	102.6	3,225,385.7	1,648.7	1.0	0.7
11/25/2019 08:00	9.0	13.9	7.6	105.6	3,321,245.4	1,697.7	1.0	0.7
11/25/2019 09:00	9.2	13.9	7.8	109.1	3,231,450.3	1,651.8	1.1	0.7
11/25/2019 10:00	9.1	13.9	7.7	104.9	3,322,541.1	1,674.1	1.0	0.7
11/25/2019 11:00	9.0	14.0	7.7	107.2	3,412,843.7	1,719.6	1.0	0.7
11/25/2019 12:00	8.9	14.0	7.6	106.4	3,398,355.6	1,712.3	1.0	0.7
11/25/2019 13:00	8.9	14.0	7.6	106.0	3,389,623.1	1,707.9	1.0	0.7
11/25/2019 14:00	8.9	14.0	7.6	105.6	3,371,562.5	1,698.8	1.0	0.7
11/25/2019 15:00	9.2	14.0	7.9	100.8	3,160,240.2	1,615.4	1.0	0.6
11/25/2019 16:00	11.1	13.4	8.7	131.7	3,529,395.5	2,087.6	1.2	1.0
11/25/2019 17:00	11.5	13.4	9.0	170.8	3,440,640.3	2,236.1	1.7	1.6
11/25/2019 18:00	11.3	13.4	8.9	155.9	3,441,605.1	2,136.2	1.5	1.3
11/25/2019 19:00	11.3	13.4	8.9	165.2	3,452,051.3	2,193.1	1.6	1.3
11/25/2019 20:00	11.2	13.4	8.8	166.0	3,461,495.6	2,199.1	1.6	1.3
11/25/2019 21:00	11.1	13.4	8.7	157.8	3,444,580.0	2,163.2	1.5	1.3
11/25/2019 22:00	10.9	13.4	8.6	148.8	3,469,697.5	2,128.3	1.4	1.1
11/25/2019 23:00	10.9	13.4	8.6	145.8	3,476,358.0	2,107.0	1.4	1.1
Average/Sum#:	12.6	14.0	11.9	133.6	3,211,121.1	1,747.4	1.4	0.9
Minimum:	8.9	13.4	7.5	91.1	1,965,884.8	516.8	1.0	0.6
Maximum:	42.3	17.0	64.0	214.6	3,529,395.5	2,236.1	2.9	1.6
%SI	12.50	12.50	12.50	12.50	12.50	12.50	12.50	12.50

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/26/2019 00:00	11.0	13.4	8.7	147.9	3,484,859.0	2,137.6	1.4	1.1
11/26/2019 01:00	11.0	13.4	8.7	150.8	3,482,687.9	2,161.7	1.5	1.3
11/26/2019 02:00	10.9	13.5	8.7	139.8	3,486,187.1	2,087.5	1.3	1.0
11/26/2019 03:00	10.6	13.5	8.5	139.2	3,479,507.0	2,083.5	1.3	1.0
11/26/2019 04:00	10.7	13.5	8.5	133.7	3,500,316.4	2,070.4	1.3	1.0
11/26/2019 05:00	9.7	13.6	7.8	131.7	3,479,204.7	2,007.1	1.3	1.0
11/26/2019 06:00	11.4	13.4	9.0	158.2	3,484,319.3	2,213.6	1.5	1.3
11/26/2019 07:00	10.4	13.5	8.3	140.4	3,309,831.9	1,981.9	1.4	1.0
11/26/2019 08:00	8.7	13.9	7.3	104.6	3,299,530.2	1,686.6	1.0	0.7
11/26/2019 09:00	8.8	13.9	7.4	106.0	3,352,155.3	1,713.5	1.0	0.7
11/26/2019 10:00	9.0	13.9	7.6	99.6	3,107,419.6	1,588.4	1.0	0.6
11/26/2019 11:00	9.0	13.9	7.6	102.6	3,217,756.0	1,644.8	1.0	0.7
11/26/2019 12:00	9.0	13.9	7.6	101.6	3,175,303.9	1,623.1	1.0	0.6
11/26/2019 13:00	9.0	13.9	7.6	103.6	3,246,318.3	1,659.4	1.0	0.7
11/26/2019 14:00	10.3	13.6	8.3	121.2	3,394,731.0	1,884.0	1.2	0.9
11/26/2019 15:00	11.1	13.4	8.7	137.9	3,445,669.7	2,088.4	1.3	1.0
11/26/2019 16:00	11.0	13.4	8.7	131.8	3,427,235.0	2,052.2	1.3	1.0
11/26/2019 17:00	11.0	13.3	8.5	141.9	3,424,044.3	2,125.3	1.4	1.1
11/26/2019 18:00	10.6	13.4	8.3	135.3	3,410,844.9	2,092.2	1.3	1.0
11/26/2019 19:00	10.7	13.4	8.4	135.3	3,451,438.5	2,117.1	1.3	1.1
11/26/2019 20:00	10.8	13.3	8.4	145.1	3,395,385.4	2,157.1	1.4	1.1
11/26/2019 21:00	10.7	13.3	8.3	139.6	3,386,936.8	2,127.0	1.4	1.1
11/26/2019 22:00	10.7	13.4	8.4	136.7	3,387,150.4	2,102.4	1.4	1.1
11/26/2019 23:00	10.8	13.4	8.5	139.4	3,368,306.3	2,115.3	1.4	1.1
Average/Sum#:	10.3	13.5	8.2	130.2	3,383,214.1	1,980.0	1.3	1.0
Minimum:	8.7	13.3	7.3	99.6	3,107,419.6	1,588.4	1.0	0.6
Maximum:	11.4	13.9	9.0	158.2	3,500,316.4	2,213.6	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/27/2019 00:00	10.8	13.4	8.5	142.8	3,394,261.6	2,131.6	1.4	1.1
11/27/2019 01:00	10.7	13.4	8.4	138.6	3,384,733.8	2,100.9	1.4	1.1
11/27/2019 02:00	10.7	13.4	8.4	134.2	3,406,731.9	2,064.8	1.3	1.0
11/27/2019 03:00	10.7	13.4	8.4	132.1	3,396,667.4	2,058.7	1.3	1.0
11/27/2019 04:00	10.7	13.4	8.4	133.5	3,417,951.3	2,071.6	1.3	1.0
11/27/2019 05:00	10.9	13.4	8.6	142.8	3,390,792.6	2,079.9	1.4	1.0
11/27/2019 06:00	11.1	13.5	8.9	129.7	3,424,406.3	2,025.5	1.2	1.0
11/27/2019 07:00	11.1	13.4	8.7	153.3	3,389,325.4	2,178.0	1.5	1.3
11/27/2019 08:00	10.9	13.4	8.6	153.5	3,422,773.9	2,174.5	1.5	1.3
11/27/2019 09:00	10.8	13.4	8.5	148.7	3,392,394.7	2,155.2	1.5	1.3
11/27/2019 10:00	10.8	13.4	8.5	150.7	3,369,728.4	2,140.8	1.5	1.3
11/27/2019 11:00	10.9	13.4	8.6	141.5	3,408,399.5	2,090.7	1.4	1.0
11/27/2019 12:00	10.8	13.4	8.5	149.5	3,382,478.2	2,124.2	1.5	1.3
11/27/2019 13:00	10.8	13.4	8.5	160.1	3,354,474.3	2,180.1	1.6	1.3
11/27/2019 14:00	10.8	13.4	8.5	158.2	3,365,671.7	2,162.8	1.6	1.3
11/27/2019 15:00	10.9	13.4	8.6	143.9	3,371,683.9	2,092.8	1.4	1.0
11/27/2019 16:00	10.8	13.4	8.5	142.0	3,397,162.4	2,059.0	1.4	1.0
11/27/2019 17:00	10.7	13.4	8.4	149.0	3,398,533.5	2,159.1	1.5	1.3
11/27/2019 18:00	10.4	13.5	8.3	124.6	3,449,216.0	1,989.8	1.2	1.0
11/27/2019 19:00	10.3	13.5	8.2	124.7	3,477,991.2	2,006.4	1.2	1.0
11/27/2019 20:00	10.6	13.3	8.2	155.2	3,434,921.0	2,207.3	1.5	1.3
11/27/2019 21:00	10.6	13.3	8.2	162.1	3,400,128.6	2,234.6	1.6	1.3
11/27/2019 22:00	10.5	13.4	8.3	144.8	3,460,344.3	2,173.1	1.4	1.1
11/27/2019 23:00	10.6	13.4	8.3	141.3	3,469,960.3	2,153.8	1.4	1.1
Average/Sum#:	10.7	13.4	8.5	144.0	3,406,697.2	2,117.3	1.4	1.1
Minimum:	10.3	13.3	8.2	124.6	3,354,474.3	1,989.8	1.2	1.0
Maximum:	11.1	13.5	8.9	162.1	3,477,991.2	2,234.6	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/28/2019 00:00	10.6	13.4	8.3	142.2	3,481,560.1	2,161.0	1.4	1.1
11/28/2019 01:00	10.6	13.4	8.3	138.2	3,485,185.1	2,137.8	1.3	1.1
11/28/2019 02:00	10.6	13.4	8.3	136.2	3,506,551.4	2,125.3	1.3	1.1
11/28/2019 03:00	10.5	13.3	8.2	139.8	3,526,104.8	2,162.9	1.3	1.1
11/28/2019 04:00	10.4	13.4	8.2	134.6	3,516,450.8	2,131.3	1.3	1.1
11/28/2019 05:00	10.6	13.4	8.3	137.7	3,510,402.5	2,102.0	1.3	1.1
11/28/2019 06:00	11.1	13.3	8.6	149.2	3,505,567.2	2,201.5	1.4	1.1
11/28/2019 07:00	10.8	13.3	8.4	149.3	3,488,411.9	2,216.2	1.4	1.1
11/28/2019 08:00	10.7	13.3	8.3	151.0	3,497,069.1	2,221.7	1.5	1.3
11/28/2019 09:00	10.6	13.3	8.2	148.4	3,460,236.3	2,198.3	1.4	1.1
11/28/2019 10:00	10.7	13.3	8.3	153.4	3,473,930.6	2,207.0	1.5	1.3
11/28/2019 11:00	10.8	13.3	8.4	157.5	3,447,525.9	2,215.4	1.5	1.3
11/28/2019 12:00	10.7	13.3	8.3	162.5	3,414,482.8	2,219.1	1.6	1.3
11/28/2019 13:00	10.8	13.4	8.5	161.5	3,424,339.0	2,200.5	1.6	1.3
11/28/2019 14:00	10.8	13.4	8.5	159.0	3,414,379.6	2,194.1	1.6	1.3
11/28/2019 15:00	10.8	13.3	8.4	164.1	3,401,404.0	2,210.6	1.6	1.3
11/28/2019 16:00	10.7	13.4	8.4	153.3	3,411,440.8	2,167.3	1.5	1.3
11/28/2019 17:00	10.7	13.4	8.4	152.7	3,411,755.6	2,167.5	1.5	1.3
11/28/2019 18:00	10.3	13.5	8.2	136.0	3,420,426.1	2,073.1	1.3	1.0
11/28/2019 19:00	10.9	13.4	8.6	153.6	3,437,573.7	2,158.8	1.5	1.3
11/28/2019 20:00	10.8	13.4	8.5	159.6	3,409,711.1	2,191.1	1.6	1.3
11/28/2019 21:00	10.8	13.4	8.5	159.8	3,408,933.0	2,190.6	1.6	1.3
11/28/2019 22:00	10.8	13.4	8.5	159.6	3,438,829.3	2,184.7	1.6	1.3
11/28/2019 23:00	10.8	13.4	8.5	159.9	3,396,634.1	2,207.5	1.6	1.3
Average/Sum#:	10.7	13.4	8.4	150.8	3,453,704.4	2,176.9	1.5	1.2
Minimum:	10.3	13.3	8.2	134.6	3,396,634.1	2,073.1	1.3	1.0
Maximum:	11.1	13.5	8.6	164.1	3,526,104.8	2,221.7	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/29/2019 00:00	10.8	13.4	8.5	161.3	3,437,410.8	2,208.9	1.6	1.3
11/29/2019 01:00	10.7	13.4	8.4	152.1	3,430,172.0	2,179.2	1.5	1.3
11/29/2019 02:00	10.6	13.4	8.3	153.5	3,439,931.1	2,185.4	1.5	1.3
11/29/2019 03:00	10.6	13.4	8.3	147.5	3,455,567.3	2,170.1	1.4	1.1
11/29/2019 04:00	10.6	13.4	8.3	156.8	3,421,849.2	2,198.9	1.6	1.3
11/29/2019 05:00	10.7	13.4	8.4	163.4	3,442,669.2	2,162.0	1.6	1.3
11/29/2019 06:00	11.1	13.4	8.7	156.9	3,450,327.0	2,217.2	1.5	1.3
11/29/2019 07:00	10.2	13.4	8.0	146.4	3,405,194.6	2,113.6	1.5	1.3
11/29/2019 08:00	8.8	13.9	7.4	103.0	3,121,113.8	1,595.4	1.1	0.6
11/29/2019 09:00	9.0	13.9	7.6	96.1	2,878,138.8	1,471.2	1.1	0.6
11/29/2019 10:00	9.0	13.9	7.6	104.5	3,194,475.8	1,632.9	1.1	0.7
11/29/2019 11:00	9.0	13.9	7.6	105.5	3,204,257.4	1,637.9	1.1	0.7
11/29/2019 12:00	9.1	13.9	7.7	102.7	3,106,050.1	1,587.7	1.1	0.6
11/29/2019 13:00	9.1	13.9	7.7	102.5	3,101,941.9	1,585.6	1.1	0.6
11/29/2019 14:00	9.1	13.9	7.7	97.2	2,925,090.5	1,495.2	1.1	0.6
11/29/2019 15:00	9.1	13.9	7.7	102.5	3,165,522.3	1,618.1	1.1	0.6
11/29/2019 16:00	10.9	13.5	8.7	129.1	3,469,377.5	2,052.1	1.2	1.0
11/29/2019 17:00	11.2	13.3	8.7	176.5	3,447,297.6	2,265.6	1.7	1.6
11/29/2019 18:00	10.8	13.3	8.4	178.1	3,441,167.8	2,286.7	1.8	1.6
11/29/2019 19:00	10.7	13.3	8.3	172.7	3,441,211.3	2,261.6	1.7	1.6
11/29/2019 20:00	10.7	13.3	8.3	171.5	3,456,122.8	2,271.4	1.7	1.6
11/29/2019 21:00	10.6	13.4	8.3	150.1	3,480,271.2	2,160.2	1.5	1.3
11/29/2019 22:00	10.4	13.4	8.2	143.0	3,543,385.6	2,173.5	1.4	1.1
11/29/2019 23:00	10.5	13.4	8.3	145.2	3,529,854.4	2,165.2	1.4	1.1
Average/Sum#:	10.1	13.6	8.1	138.3	3,332,850.0	1,987.3	1.4	1.1
Minimum:	8.8	13.3	7.4	96.1	2,878,138.8	1,471.2	1.1	0.6
Maximum:	11.2	13.9	8.7	178.1	3,543,385.6	2,286.7	1.8	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/30/2019 00:00	10.5	13.4	8.3	141.8	3,518,605.5	2,158.3	1.3	1.1
11/30/2019 01:00	10.5	13.4	8.3	139.0	3,514,203.8	2,155.6	1.3	1.1
11/30/2019 02:00	10.6	13.4	8.3	143.8	3,536,864.5	2,169.5	1.4	1.1
11/30/2019 03:00	10.6	13.4	8.3	145.4	3,496,865.4	2,170.5	1.4	1.1
11/30/2019 04:00	10.5	13.4	8.3	140.6	3,510,128.1	2,153.1	1.3	1.1
11/30/2019 05:00	10.6	13.4	8.3	145.6	3,476,218.6	2,132.3	1.4	1.1
11/30/2019 06:00	11.0	13.4	8.7	144.8	3,495,415.5	2,169.6	1.4	1.1
11/30/2019 07:00	10.6	13.4	8.3	139.6	3,485,511.1	2,138.0	1.3	1.1
11/30/2019 08:00	10.6	13.3	8.2	145.2	3,523,822.4	2,161.5	1.4	1.1
11/30/2019 09:00	10.5	13.3	8.2	144.5	3,512,976.3	2,180.5	1.4	1.1
11/30/2019 10:00	10.6	13.4	8.3	142.7	3,501,324.7	2,147.7	1.4	1.1
11/30/2019 11:00	10.6	13.4	8.3	136.1	3,493,869.2	2,092.1	1.3	1.0
11/30/2019 12:00	10.6	13.4	8.3	146.9	3,492,354.4	2,167.7	1.4	1.1
11/30/2019 13:00	10.5	13.4	8.3	143.7	3,483,976.7	2,162.5	1.4	1.1
11/30/2019 14:00	10.4	13.3	8.1	141.7	3,498,315.4	2,171.4	1.4	1.1
11/30/2019 15:00	10.5	13.3	8.2	139.1	3,507,682.7	2,151.6	1.3	1.1
11/30/2019 16:00	10.4	13.4	8.2	142.0	3,503,444.0	2,149.0	1.4	1.1
11/30/2019 17:00	10.6	13.3	8.2	142.5	3,490,421.1	2,166.5	1.4	1.1
11/30/2019 18:00	10.6	13.3	8.2	139.3	3,522,885.5	2,135.2	1.3	1.1
11/30/2019 19:00	10.6	13.3	8.2	149.9	3,483,374.9	2,213.0	1.5	1.3
11/30/2019 20:00	10.6	13.3	8.2	145.0	3,498,959.9	2,171.8	1.4	1.1
11/30/2019 21:00	10.6	13.3	8.2	142.9	3,473,988.0	2,156.3	1.4	1.1
11/30/2019 22:00	10.5	13.4	8.3	133.1	3,514,577.6	2,104.5	1.3	1.1
11/30/2019 23:00	10.5	13.4	8.3	131.5	3,535,819.9	2,091.4	1.2	1.0
Average/Sum#:	10.6	13.4	8.3	141.9	3,502,983.6	2,152.9	1.4	1.1
Minimum:	10.4	13.3	8.1	131.5	3,473,988.0	2,091.4	1.2	1.0
Maximum:	11.0	13.4	8.7	149.9	3,536,864.5	2,213.0	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/01/2019 00:00	10.5	13.3	8.2	136.6	3,532,290.0	2,140.9	1.3	1.1
12/01/2019 01:00	10.5	13.4	8.3	131.2	3,534,129.3	2,090.4	1.2	1.0
12/01/2019 02:00	10.6	13.4	8.3	131.1	3,531,931.5	2,089.1	1.2	1.0
12/01/2019 03:00	10.6	13.4	8.3	132.0	3,532,100.5	2,089.2	1.2	1.0
12/01/2019 04:00	10.6	13.4	8.3	131.8	3,524,661.7	2,084.8	1.2	1.0
12/01/2019 05:00	10.6	13.4	8.3	132.2	3,526,521.4	2,085.9	1.2	1.0
12/01/2019 06:00	10.7	13.4	8.4	126.4	3,552,800.4	2,075.5	1.2	1.0
12/01/2019 07:00	10.6	13.4	8.3	128.7	3,571,972.3	2,086.7	1.2	1.0
12/01/2019 08:00	10.6	13.3	8.2	140.7	3,547,461.3	2,176.0	1.3	1.1
12/01/2019 09:00	10.7	13.3	8.3	141.1	3,500,570.9	2,172.8	1.3	1.1
12/01/2019 10:00	10.7	13.3	8.3	145.0	3,514,587.4	2,181.5	1.4	1.1
12/01/2019 11:00	10.6	13.3	8.2	141.7	3,524,474.5	2,161.9	1.3	1.1
12/01/2019 12:00	10.5	13.4	8.3	131.4	3,528,212.0	2,086.9	1.2	1.0
12/01/2019 13:00	10.5	13.4	8.3	133.2	3,524,430.8	2,110.4	1.3	1.1
12/01/2019 14:00	10.6	13.4	8.3	135.1	3,506,227.4	2,099.5	1.3	1.0
12/01/2019 15:00	10.7	13.4	8.4	136.5	3,516,915.6	2,105.9	1.3	1.1
12/01/2019 16:00	10.7	13.4	8.4	136.1	3,477,678.0	2,107.8	1.3	1.1
12/01/2019 17:00	10.7	13.3	8.3	145.3	3,483,010.1	2,161.9	1.4	1.1
12/01/2019 18:00	10.7	13.3	8.3	155.3	3,457,174.1	2,221.6	1.5	1.3
12/01/2019 19:00	10.7	13.3	8.3	163.8	3,467,413.3	2,253.5	1.6	1.4
12/01/2019 20:00	10.5	13.3	8.2	152.0	3,477,236.1	2,209.1	1.5	1.3
12/01/2019 21:00	10.6	13.3	8.2	140.1	3,478,827.0	2,133.9	1.4	1.1
12/01/2019 22:00	10.6	13.4	8.3	135.8	3,469,428.4	2,102.8	1.3	1.1
12/01/2019 23:00	10.6	13.4	8.3	134.7	3,499,046.3	2,095.2	1.3	1.0
Average/Sum#:	10.6	13.4	8.3	138.2	3,511,629.2	2,130.1	1.3	1.1
Minimum:	10.5	13.3	8.2	126.4	3,457,174.1	2,075.5	1.2	1.0
Maximum:	10.7	13.4	8.4	163.8	3,571,972.3	2,253.5	1.6	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/02/2019 00:00	10.6	13.4	8.3	133.2	3,471,490.8	2,078.7	1.3	1.0
12/02/2019 01:00	10.6	13.4	8.3	132.9	3,478,003.9	2,082.6	1.3	1.0
12/02/2019 02:00	10.6	13.4	8.3	133.5	3,475,832.9	2,081.3	1.3	1.0
12/02/2019 03:00	10.7	13.4	8.4	134.4	3,465,311.7	2,075.0	1.3	1.0
12/02/2019 04:00	10.7	13.4	8.4	132.7	3,499,132.9	2,069.7	1.3	1.0
12/02/2019 05:00	10.8	13.4	8.5	138.2	3,466,146.7	2,075.5	1.3	1.0
12/02/2019 06:00	11.1	13.3	8.6	152.7	3,456,930.8	2,196.2	1.5	1.3
12/02/2019 07:00	10.9	13.3	8.5	167.9	3,433,755.6	2,256.7	1.7	1.6
12/02/2019 08:00	10.5	13.3	8.2	136.7	3,457,470.5	2,120.8	1.3	1.1
12/02/2019 09:00	10.7	13.4	8.4	134.4	3,468,651.8	2,077.0	1.3	1.0
12/02/2019 10:00	10.8	13.3	8.4	137.8	3,463,488.8	2,099.2	1.3	1.0
12/02/2019 11:00	10.8	13.3	8.4	138.1	3,452,764.3	2,092.7	1.3	1.0
12/02/2019 12:00	10.7	13.3	8.3	149.1	3,443,943.1	2,162.8	1.5	1.3
12/02/2019 13:00	10.5	13.3	8.2	138.2	3,453,557.9	2,118.4	1.3	1.1
12/02/2019 14:00	10.8	13.3	8.4	152.7	3,422,301.7	2,174.2	1.5	1.3
12/02/2019 15:00	10.8	13.3	8.4	148.5	3,434,389.0	2,156.8	1.5	1.3
12/02/2019 16:00	10.8	13.3	8.4	162.6	3,405,712.3	2,213.4	1.6	1.3
12/02/2019 17:00	10.6	13.3	8.2	167.3	3,414,080.3	2,268.7	1.7	1.6
12/02/2019 18:00	10.8	13.2	8.3	176.2	3,428,376.5	2,278.2	1.8	1.6
12/02/2019 19:00	10.8	13.2	8.3	171.6	3,430,031.9	2,279.3	1.7	1.6
12/02/2019 20:00	10.8	13.2	8.3	176.3	3,423,861.9	2,275.2	1.8	1.6
12/02/2019 21:00	10.8	13.3	8.4	169.3	3,421,430.7	2,248.6	1.7	1.6
12/02/2019 22:00	10.7	13.3	8.3	149.5	3,420,376.3	2,148.0	1.5	1.3
12/02/2019 23:00	10.8	13.3	8.4	147.1	3,430,488.6	2,129.3	1.4	1.1
Average/Sum#:	10.7	13.3	8.4	149.2	3,446,563.8	2,156.6	1.5	1.2
Minimum:	10.5	13.2	8.2	132.7	3,405,712.3	2,069.7	1.3	1.0
Maximum:	11.1	13.4	8.6	176.3	3,499,132.9	2,279.3	1.8	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/03/2019 00:00	10.7	13.3	8.3	146.3	3,441,766.2	2,136.3	1.4	1.1
12/03/2019 01:00	10.8	13.3	8.4	138.5	3,435,275.3	2,082.1	1.3	1.0
12/03/2019 02:00	11.0	13.3	8.5	140.8	3,428,675.7	2,078.1	1.4	1.0
12/03/2019 03:00	10.8	13.3	8.4	139.5	3,441,710.0	2,086.0	1.4	1.0
12/03/2019 04:00	10.8	13.3	8.4	144.9	3,443,287.2	2,112.1	1.4	1.1
12/03/2019 05:00	10.9	13.3	8.5	158.2	3,378,178.9	2,121.5	1.6	1.3
12/03/2019 06:00	11.3	13.3	8.8	151.3	3,429,134.2	2,153.5	1.5	1.3
12/03/2019 07:00	11.0	13.3	8.5	162.6	3,391,556.4	2,204.2	1.6	1.3
12/03/2019 08:00	10.9	13.3	8.5	160.4	3,412,201.0	2,192.7	1.6	1.3
12/03/2019 09:00	10.8	13.3	8.4	151.3	3,404,200.1	2,162.7	1.5	1.3
12/03/2019 10:00	10.8	13.3	8.4	144.9	3,394,883.6	2,107.2	1.4	1.1
12/03/2019 11:00	11.1	13.3	8.6	170.5	3,361,090.6	2,184.4	1.7	1.5
12/03/2019 12:00	11.1	13.3	8.6	175.0	3,334,473.1	2,215.8	1.8	1.6
12/03/2019 13:00	10.9	13.3	8.5	171.4	3,323,337.2	2,208.4	1.8	1.5
12/03/2019 14:00	11.0	13.3	8.5	177.3	3,318,973.1	2,205.5	1.8	1.5
12/03/2019 15:00	11.0	13.3	8.5	171.6	3,347,177.5	2,199.8	1.8	1.5
12/03/2019 16:00	10.9	13.3	8.5	166.8	3,334,548.4	2,191.5	1.7	1.5
12/03/2019 17:00	11.0	13.2	8.4	181.5	3,354,196.6	2,253.4	1.9	1.6
12/03/2019 18:00	11.1	13.2	8.5	179.2	3,353,303.5	2,252.8	1.8	1.6
12/03/2019 19:00	11.0	13.2	8.4	171.1	3,366,376.2	2,237.0	1.7	1.6
12/03/2019 20:00	11.0	13.2	8.4	171.7	3,352,832.4	2,228.0	1.8	1.6
12/03/2019 21:00	10.9	13.3	8.5	163.7	3,377,609.2	2,219.8	1.7	1.6
12/03/2019 22:00	10.6	13.3	8.2	151.9	3,399,005.8	2,159.4	1.5	1.3
12/03/2019 23:00	10.5	13.3	8.2	143.6	3,402,064.2	2,136.5	1.4	1.1
Average/Sum#:	10.9	13.3	8.5	159.8	3,384,410.7	2,172.0	1.6	1.3
Minimum:	10.5	13.2	8.2	138.5	3,318,973.1	2,078.1	1.3	1.0
Maximum:	11.3	13.3	8.8	181.5	3,443,287.2	2,253.4	1.9	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/04/2019 00:00	10.8	13.3	8.4	158.9	3,399,907.3	2,184.8	1.6	1.3
12/04/2019 01:00	10.6	13.3	8.2	149.1	3,397,589.1	2,158.5	1.5	1.3
12/04/2019 02:00	10.5	13.3	8.2	138.0	3,428,288.7	2,102.9	1.4	1.1
12/04/2019 03:00	10.7	13.3	8.3	143.3	3,446,384.7	2,114.0	1.4	1.1
12/04/2019 04:00	10.8	13.3	8.4	149.3	3,391,450.3	2,154.6	1.5	1.3
12/04/2019 05:00	10.7	13.3	8.3	144.1	3,418,996.2	2,097.2	1.4	1.0
12/04/2019 06:00	11.1	13.3	8.6	146.3	3,426,904.9	2,152.1	1.4	1.1
12/04/2019 07:00	10.9	13.3	8.5	158.3	3,392,787.4	2,205.0	1.6	1.3
12/04/2019 08:00	10.6	13.3	8.2	152.5	3,419,048.1	2,197.1	1.5	1.3
12/04/2019 09:00	10.7	13.3	8.3	156.9	3,425,739.6	2,201.4	1.6	1.3
12/04/2019 10:00	10.7	13.3	8.3	153.1	3,399,907.3	2,184.8	1.5	1.3
12/04/2019 11:00	10.8	13.3	8.4	164.9	3,392,977.1	2,229.9	1.7	1.6
12/04/2019 12:00	10.6	13.3	8.2	156.2	3,414,690.8	2,194.3	1.6	1.3
12/04/2019 13:00	10.7	13.3	8.3	153.3	3,408,135.3	2,165.2	1.5	1.3
12/04/2019 14:00	10.8	13.2	8.3	166.5	3,364,871.3	2,236.0	1.7	1.6
12/04/2019 15:00	10.7	13.3	8.3	160.8	3,380,631.8	2,197.1	1.6	1.3
12/04/2019 16:00	10.7	13.3	8.3	157.4	3,380,631.8	2,197.1	1.6	1.3
12/04/2019 17:00	10.7	13.3	8.3	154.0	3,381,077.7	2,172.7	1.5	1.3
12/04/2019 18:00	10.8	13.2	8.3	166.9	3,372,245.2	2,240.9	1.7	1.6
12/04/2019 19:00	10.7	13.2	8.2	169.5	3,375,104.4	2,242.8	1.7	1.6
12/04/2019 20:00	10.7	13.2	8.2	167.3	3,381,274.3	2,246.9	1.7	1.6
12/04/2019 21:00	10.6	13.3	8.2	163.4	3,390,694.8	2,228.4	1.6	1.3
12/04/2019 22:00	10.7	13.3	8.3	156.9	3,415,002.1	2,194.5	1.6	1.3
12/04/2019 23:00	10.7	13.3	8.3	148.8	3,420,217.0	2,147.9	1.5	1.3
Average/Sum#:	10.7	13.3	8.3	155.7	3,401,023.2	2,185.3	1.6	1.3
Minimum:	10.5	13.2	8.2	138.0	3,364,871.3	2,097.2	1.4	1.0
Maximum:	11.1	13.3	8.6	169.5	3,446,384.7	2,246.9	1.7	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/05/2019 00:00	10.7	13.3	8.3	148.2	3,400,737.2	2,160.5	1.5	1.3
12/05/2019 01:00	10.6	13.3	8.2	150.3	3,410,811.1	2,166.9	1.5	1.3
12/05/2019 02:00	10.6	13.3	8.2	145.7	3,406,718.6	2,164.3	1.4	1.1
12/05/2019 03:00	10.7	13.3	8.3	149.1	3,409,237.1	2,165.9	1.5	1.3
12/05/2019 04:00	10.6	13.3	8.2	143.8	3,434,838.6	2,132.0	1.4	1.1
12/05/2019 05:00	10.7	13.3	8.3	143.2	3,414,216.7	2,119.2	1.4	1.1
12/05/2019 06:00	11.1	13.3	8.6	149.9	3,405,774.2	2,163.7	1.5	1.3
12/05/2019 07:00	10.8	13.3	8.4	142.3	3,419,211.0	2,122.3	1.4	1.1
12/05/2019 08:00	10.7	13.4	8.4	135.6	3,455,959.5	2,069.4	1.3	1.0
12/05/2019 09:00	10.8	13.3	8.4	137.7	3,439,070.1	2,084.4	1.3	1.0
12/05/2019 10:00	10.7	13.3	8.3	137.1	3,358,059.6	2,035.3	1.4	1.0
12/05/2019 11:00	10.6	13.3	8.2	136.8	3,368,454.0	2,041.6	1.4	1.0
12/05/2019 12:00	10.6	13.3	8.2	137.9	3,341,884.6	2,049.9	1.4	1.0
12/05/2019 13:00	10.7	13.3	8.3	141.5	3,341,558.5	2,049.7	1.4	1.0
12/05/2019 14:00	10.7	13.3	8.3	138.5	3,321,669.3	2,037.5	1.4	1.0
12/05/2019 15:00	10.8	13.3	8.4	142.9	3,336,830.7	2,046.8	1.4	1.0
12/05/2019 16:00	10.9	13.3	8.5	163.1	3,331,124.8	2,140.6	1.7	1.5
12/05/2019 17:00	10.9	13.2	8.4	171.2	3,303,773.9	2,195.4	1.8	1.5
12/05/2019 18:00	10.8	13.2	8.3	175.7	3,307,686.6	2,198.0	1.8	1.5
12/05/2019 19:00	10.8	13.2	8.3	172.6	3,284,088.1	2,206.3	1.8	1.5
12/05/2019 20:00	10.8	13.2	8.3	175.3	3,315,963.3	2,203.5	1.8	1.5
12/05/2019 21:00	10.8	13.2	8.3	172.9	3,283,641.5	2,206.0	1.8	1.5
12/05/2019 22:00	10.8	13.3	8.4	161.2	3,307,544.6	2,149.6	1.7	1.5
12/05/2019 23:00	10.7	13.3	8.3	156.0	3,313,073.3	2,129.0	1.6	1.3
Average/Sum#:	10.7	13.3	8.3	151.2	3,362,997.0	2,126.6	1.5	1.2
Minimum:	10.6	13.2	8.2	135.6	3,283,641.5	2,035.3	1.3	1.0
Maximum:	11.1	13.4	8.6	175.7	3,455,959.5	2,206.3	1.8	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/06/2019 00:00	10.7	13.3	8.3	141.8	3,328,023.5	2,065.7	1.4	1.0
12/06/2019 01:00	10.6	13.3	8.2	140.0	3,321,095.8	2,061.4	1.4	1.0
12/06/2019 02:00	10.8	13.3	8.4	144.3	3,330,923.4	2,067.5	1.5	1.2
12/06/2019 03:00	10.8	13.3	8.4	143.0	3,325,284.6	2,064.0	1.4	1.0
12/06/2019 04:00	10.8	13.3	8.4	139.4	3,327,538.2	2,041.1	1.4	1.0
12/06/2019 05:00	10.7	13.3	8.3	142.7	3,316,941.5	2,034.6	1.4	1.0
12/06/2019 06:00	11.2	13.3	8.7	143.1	3,332,212.3	2,068.3	1.4	1.0
12/06/2019 07:00	10.9	13.3	8.5	141.0	3,323,029.1	2,062.6	1.4	1.0
12/06/2019 08:00	10.8	13.3	8.4	141.0	3,341,395.5	2,049.6	1.4	1.0
12/06/2019 09:00	10.8	13.3	8.4	136.8	3,339,085.6	2,023.8	1.4	1.0
12/06/2019 10:00	10.9	13.3	8.5	140.8	3,332,266.0	2,044.0	1.4	1.0
12/06/2019 11:00	10.9	13.3	8.5	148.1	3,297,765.0	2,071.0	1.5	1.2
12/06/2019 12:00	10.9	13.3	8.5	158.7	3,276,659.1	2,105.6	1.7	1.5
12/06/2019 13:00	10.9	13.3	8.5	156.4	3,253,844.7	2,114.7	1.6	1.3
12/06/2019 14:00	10.9	13.3	8.5	161.4	3,284,906.7	2,110.9	1.7	1.5
12/06/2019 15:00	10.9	13.3	8.5	158.9	3,288,797.2	2,113.4	1.6	1.3
12/06/2019 16:00	11.0	13.3	8.5	164.2	3,290,311.4	2,138.4	1.7	1.5
12/06/2019 17:00	10.9	13.3	8.5	160.2	3,272,001.1	2,126.5	1.7	1.5
12/06/2019 18:00	11.0	13.2	8.4	171.7	3,267,356.3	2,171.2	1.8	1.5
12/06/2019 19:00	11.0	13.2	8.4	166.2	3,255,467.9	2,163.3	1.7	1.5
12/06/2019 20:00	11.0	13.2	8.4	161.0	3,296,004.5	2,142.1	1.7	1.5
12/06/2019 21:00	10.9	13.2	8.4	170.7	3,292,036.0	2,187.6	1.8	1.5
12/06/2019 22:00	10.9	13.2	8.4	176.2	3,292,337.0	2,187.8	1.8	1.5
12/06/2019 23:00	11.0	13.2	8.4	175.4	3,261,462.8	2,191.1	1.9	1.5
Average/Sum#:	10.9	13.3	8.4	153.5	3,301,947.7	2,100.3	1.6	1.3
Minimum:	10.6	13.2	8.2	136.8	3,253,844.7	2,023.8	1.4	1.0
Maximum:	11.2	13.3	8.7	176.2	3,341,395.5	2,191.1	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/07/2019 00:00	10.9	13.2	8.4	166.9	3,282,404.9	2,181.2	1.7	1.5
12/07/2019 01:00	10.6	13.3	8.2	139.7	3,293,147.2	2,068.1	1.4	1.0
12/07/2019 02:00	10.7	13.3	8.3	136.9	3,321,180.2	2,037.2	1.4	1.0
12/07/2019 03:00	10.9	13.3	8.5	139.5	3,328,353.4	2,041.6	1.4	1.0
12/07/2019 04:00	10.9	13.3	8.5	139.6	3,332,592.1	2,044.2	1.4	1.0
12/07/2019 05:00	10.8	13.3	8.4	138.9	3,284,201.9	2,038.5	1.4	1.0
12/07/2019 06:00	11.1	13.3	8.6	140.6	3,284,524.1	2,038.7	1.4	1.0
12/07/2019 07:00	11.1	13.3	8.6	149.1	3,301,745.9	2,073.5	1.5	1.2
12/07/2019 08:00	11.0	13.3	8.5	148.9	3,282,526.0	2,085.4	1.5	1.3
12/07/2019 09:00	10.9	13.3	8.5	147.7	3,260,804.1	2,071.6	1.5	1.2
12/07/2019 10:00	11.0	13.3	8.5	148.6	3,269,580.3	2,053.3	1.5	1.2
12/07/2019 11:00	11.0	13.3	8.5	150.7	3,247,739.5	2,063.3	1.6	1.2
12/07/2019 12:00	11.0	13.3	8.5	149.6	3,250,415.3	2,065.0	1.6	1.2
12/07/2019 13:00	10.9	13.3	8.5	144.9	3,279,452.9	2,059.5	1.5	1.2
12/07/2019 14:00	10.9	13.3	8.5	145.4	3,277,064.4	2,058.0	1.5	1.2
12/07/2019 15:00	10.9	13.3	8.5	144.5	3,289,035.2	2,041.5	1.5	1.2
12/07/2019 16:00	11.0	13.3	8.5	147.7	3,306,918.2	2,052.6	1.5	1.2
12/07/2019 17:00	10.9	13.3	8.5	145.8	3,304,501.6	2,051.1	1.5	1.2
12/07/2019 18:00	10.8	13.3	8.4	155.9	3,279,460.2	2,107.4	1.6	1.3
12/07/2019 19:00	10.9	13.3	8.5	151.9	3,280,951.9	2,084.4	1.6	1.3
12/07/2019 20:00	10.9	13.3	8.5	153.8	3,299,053.5	2,095.9	1.6	1.3
12/07/2019 21:00	10.9	13.3	8.5	151.3	3,294,331.4	2,092.9	1.6	1.3
12/07/2019 22:00	10.7	13.3	8.3	144.0	3,293,465.6	2,068.3	1.5	1.2
12/07/2019 23:00	10.9	13.3	8.5	145.8	3,289,644.0	2,065.9	1.5	1.2
Average/Sum#:	10.9	13.3	8.5	147.0	3,288,878.9	2,068.3	1.5	1.2
Minimum:	10.6	13.2	8.2	136.9	3,247,739.5	2,037.2	1.4	1.0
Maximum:	11.1	13.3	8.6	166.9	3,332,592.1	2,181.2	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/08/2019 00:00	10.9	13.3	8.5	149.2	3,314,007.0	2,081.2	1.5	1.2
12/08/2019 01:00	10.1	13.4	7.9	126.9	3,304,934.6	1,930.7	1.3	1.0
12/08/2019 02:00	8.9	13.9	7.5	105.2	3,121,113.8	1,595.4	1.1	0.6
12/08/2019 03:00	9.2	13.9	7.8	96.5	2,853,293.5	1,458.5	1.1	0.6
12/08/2019 04:00	9.2	13.8	7.6	105.4	3,122,483.2	1,596.1	1.1	0.6
12/08/2019 05:00	9.1	13.8	7.6	106.2	3,260,208.2	1,666.5	1.1	0.7
12/08/2019 06:00	9.2	13.9	7.8	107.9	3,281,923.4	1,677.6	1.1	0.7
12/08/2019 07:00	9.2	13.8	7.6	106.5	3,242,796.9	1,657.6	1.1	0.7
12/08/2019 08:00	9.2	13.8	7.6	105.3	3,202,888.0	1,637.2	1.1	0.7
12/08/2019 09:00	9.2	13.8	7.6	105.6	3,212,474.0	1,642.1	1.1	0.7
12/08/2019 10:00	9.4	13.9	7.9	97.3	2,926,264.3	1,495.8	1.1	0.6
12/08/2019 11:00	9.3	13.9	7.8	101.9	3,094,703.5	1,581.9	1.1	0.6
12/08/2019 12:00	9.4	13.9	7.9	97.6	2,941,327.9	1,503.5	1.1	0.6
12/08/2019 13:00	9.3	13.8	7.7	106.2	3,220,690.5	1,646.3	1.1	0.7
12/08/2019 14:00	9.3	13.8	7.7	105.6	3,154,050.6	1,658.3	1.1	0.7
12/08/2019 15:00	10.5	13.6	8.5	121.8	3,295,748.0	1,877.2	1.2	0.9
12/08/2019 16:00	11.4	13.4	9.0	144.3	3,331,939.9	2,043.8	1.4	1.0
12/08/2019 17:00	11.2	13.4	8.8	145.1	3,311,235.6	2,031.1	1.5	1.2
12/08/2019 18:00	11.1	13.3	8.6	152.5	3,352,189.8	2,080.7	1.5	1.2
12/08/2019 19:00	10.9	13.3	8.5	150.5	3,339,007.0	2,096.9	1.5	1.3
12/08/2019 20:00	10.9	13.3	8.5	153.1	3,347,446.4	2,102.2	1.5	1.3
12/08/2019 21:00	10.9	13.3	8.5	147.0	3,352,318.3	2,056.3	1.5	1.2
12/08/2019 22:00	11.0	13.3	8.5	153.8	3,339,962.4	2,097.5	1.6	1.3
12/08/2019 23:00	11.0	13.3	8.5	161.2	3,325,025.4	2,112.4	1.7	1.5
Average/Sum#:	10.0	13.6	8.1	123.0	3,218,668.0	1,805.3	1.3	0.9
Minimum:	8.9	13.3	7.5	96.5	2,853,293.5	1,458.5	1.1	0.6
Maximum:	11.4	13.9	9.0	161.2	3,352,318.3	2,112.4	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/09/2019 00:00	10.7	13.3	8.3	148.5	3,354,767.5	2,082.3	1.5	1.2
12/09/2019 01:00	10.7	13.4	8.4	141.2	3,360,204.5	2,036.6	1.4	1.0
12/09/2019 02:00	10.8	13.4	8.5	141.6	3,367,281.0	2,016.3	1.4	1.0
12/09/2019 03:00	10.9	13.4	8.6	139.7	3,377,969.1	2,022.7	1.4	1.0
12/09/2019 04:00	10.9	13.4	8.6	149.9	3,377,750.5	2,071.9	1.5	1.2
12/09/2019 05:00	10.9	13.4	8.6	157.4	3,362,752.0	2,062.7	1.6	1.2
12/09/2019 06:00	11.1	13.4	8.7	144.7	3,370,740.3	2,067.6	1.4	1.0
12/09/2019 07:00	10.8	13.4	8.5	148.8	3,392,144.8	2,105.5	1.5	1.3
12/09/2019 08:00	10.7	13.3	8.3	144.7	3,379,739.4	2,097.8	1.4	1.0
12/09/2019 09:00	10.8	13.4	8.5	148.0	3,364,917.4	2,088.6	1.5	1.3
12/09/2019 10:00	10.8	13.4	8.5	144.7	3,359,049.5	2,035.9	1.4	1.0
12/09/2019 11:00	10.8	13.4	8.5	140.8	3,392,331.4	2,031.3	1.4	1.0
12/09/2019 12:00	10.7	13.4	8.4	140.1	3,343,210.4	2,026.3	1.4	1.0
12/09/2019 13:00	10.9	13.4	8.6	146.1	3,357,564.6	2,035.0	1.5	1.2
12/09/2019 14:00	10.8	13.4	8.5	142.3	3,326,051.3	2,015.9	1.4	1.0
12/09/2019 15:00	10.9	13.4	8.6	148.0	3,353,133.4	2,056.8	1.5	1.2
12/09/2019 16:00	10.8	13.4	8.5	145.2	3,337,482.9	2,047.2	1.5	1.2
12/09/2019 17:00	10.8	13.3	8.4	152.5	3,347,446.4	2,102.2	1.5	1.3
12/09/2019 18:00	10.8	13.3	8.4	166.3	3,336,164.0	2,168.2	1.7	1.5
12/09/2019 19:00	10.7	13.3	8.3	167.8	3,325,571.0	2,185.6	1.7	1.5
12/09/2019 20:00	10.7	13.3	8.3	166.9	3,361,398.3	2,184.6	1.7	1.5
12/09/2019 21:00	10.6	13.3	8.2	151.6	3,365,917.7	2,113.8	1.5	1.3
12/09/2019 22:00	10.6	13.3	8.2	148.0	3,353,815.9	2,106.2	1.5	1.3
12/09/2019 23:00	10.4	13.4	8.2	142.4	3,421,604.6	2,098.8	1.4	1.0
Average/Sum#:	10.8	13.4	8.4	148.6	3,362,042.0	2,077.5	1.5	1.2
Minimum:	10.4	13.3	8.2	139.7	3,325,571.0	2,015.9	1.4	1.0
Maximum:	11.1	13.4	8.7	167.8	3,421,604.6	2,185.6	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/10/2019 00:00	10.5	13.3	8.2	144.7	3,431,777.5	2,130.1	1.4	1.1
12/10/2019 01:00	10.5	13.3	8.2	146.6	3,419,533.2	2,122.5	1.4	1.1
12/10/2019 02:00	10.6	13.3	8.2	146.8	3,405,677.9	2,113.9	1.5	1.3
12/10/2019 03:00	10.6	13.3	8.2	148.4	3,426,460.9	2,126.8	1.5	1.3
12/10/2019 04:00	10.6	13.3	8.2	149.2	3,439,188.5	2,134.7	1.5	1.3
12/10/2019 05:00	10.7	13.4	8.4	150.9	3,412,444.5	2,118.1	1.5	1.3
12/10/2019 06:00	11.0	13.3	8.5	144.1	3,429,360.9	2,128.6	1.4	1.1
12/10/2019 07:00	10.7	13.3	8.3	151.3	3,425,153.3	2,151.0	1.5	1.3
12/10/2019 08:00	10.6	13.4	8.3	139.7	3,444,514.8	2,087.7	1.4	1.0
12/10/2019 09:00	10.6	13.3	8.2	147.3	3,414,377.8	2,119.3	1.5	1.3
12/10/2019 10:00	10.6	13.4	8.3	136.8	3,441,597.3	2,060.8	1.3	1.0
12/10/2019 11:00	10.6	13.4	8.3	137.2	3,423,895.0	2,050.2	1.3	1.0
12/10/2019 12:00	10.7	13.4	8.4	139.7	3,411,186.6	2,067.5	1.4	1.0
12/10/2019 13:00	10.7	13.4	8.4	141.3	3,405,577.0	2,064.1	1.4	1.0
12/10/2019 14:00	10.7	13.4	8.4	141.0	3,414,321.5	2,069.4	1.4	1.0
12/10/2019 15:00	10.5	13.4	8.3	135.6	3,388,417.9	2,053.7	1.3	1.0
12/10/2019 16:00	10.6	13.4	8.3	140.2	3,378,402.6	2,072.3	1.4	1.0
12/10/2019 17:00	10.6	13.3	8.2	153.6	3,383,422.7	2,149.5	1.5	1.3
12/10/2019 18:00	10.8	13.3	8.4	162.4	3,343,241.9	2,172.8	1.7	1.5
12/10/2019 19:00	10.7	13.3	8.3	159.6	3,358,013.2	2,182.4	1.6	1.3
12/10/2019 20:00	10.6	13.3	8.2	162.7	3,357,551.6	2,182.1	1.7	1.5
12/10/2019 21:00	10.6	13.3	8.2	150.8	3,362,960.0	2,136.5	1.5	1.3
12/10/2019 22:00	10.6	13.3	8.2	143.7	3,407,747.4	2,090.3	1.4	1.0
12/10/2019 23:00	10.6	13.3	8.2	140.4	3,391,607.7	2,080.4	1.4	1.0
Average/Sum#:	10.6	13.3	8.3	146.4	3,404,851.3	2,111.0	1.5	1.2
Minimum:	10.5	13.3	8.2	135.6	3,343,241.9	2,050.2	1.3	1.0
Maximum:	11.0	13.4	8.5	162.7	3,444,514.8	2,182.4	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/11/2019 00:00	10.7	13.3	8.3	148.5	3,365,599.3	2,113.6	1.5	1.3
12/11/2019 01:00	10.7	13.3	8.3	147.4	3,362,892.3	2,111.9	1.5	1.3
12/11/2019 02:00	10.7	13.3	8.3	142.4	3,391,607.7	2,080.4	1.4	1.0
12/11/2019 03:00	10.6	13.4	8.3	135.3	3,386,152.3	2,027.6	1.3	1.0
12/11/2019 04:00	10.7	13.4	8.4	138.0	3,387,428.0	2,053.1	1.4	1.0
12/11/2019 05:00	10.8	13.3	8.4	147.9	3,349,128.7	2,078.8	1.5	1.2
12/11/2019 06:00	11.0	13.3	8.5	145.9	3,375,631.1	2,119.9	1.5	1.3
12/11/2019 07:00	10.9	13.3	8.5	145.5	3,400,683.5	2,110.8	1.4	1.1
12/11/2019 08:00	10.7	13.3	8.3	141.6	3,384,271.5	2,075.9	1.4	1.0
12/11/2019 09:00	10.7	13.4	8.4	135.8	3,412,872.8	2,043.6	1.3	1.0
12/11/2019 10:00	10.7	13.3	8.3	137.5	3,395,182.5	2,057.8	1.4	1.0
12/11/2019 11:00	10.7	13.4	8.4	135.7	3,402,518.6	2,037.4	1.3	1.0
12/11/2019 12:00	10.6	13.4	8.3	134.8	3,406,526.7	2,039.8	1.3	1.0
12/11/2019 13:00	10.6	13.4	8.3	132.9	3,403,353.6	2,037.9	1.3	1.0
12/11/2019 14:00	10.7	13.3	8.3	139.8	3,373,511.8	2,069.3	1.4	1.0
12/11/2019 15:00	10.6	13.4	8.3	135.0	3,392,331.4	2,031.3	1.3	1.0
12/11/2019 16:00	10.6	13.4	8.3	136.2	3,382,148.2	2,049.9	1.3	1.0
12/11/2019 17:00	10.7	13.3	8.3	147.5	3,362,733.0	2,111.8	1.5	1.3
12/11/2019 18:00	10.7	13.3	8.3	144.2	3,357,506.4	2,084.0	1.4	1.0
12/11/2019 19:00	10.8	13.3	8.4	155.4	3,346,686.5	2,150.6	1.6	1.3
12/11/2019 20:00	10.7	13.3	8.3	143.7	3,367,172.9	2,090.0	1.4	1.0
12/11/2019 21:00	10.7	13.3	8.3	139.1	3,353,296.4	2,056.9	1.4	1.0
12/11/2019 22:00	10.7	13.3	8.3	140.1	3,371,423.8	2,043.4	1.4	1.0
12/11/2019 23:00	10.8	13.3	8.4	138.0	3,379,178.4	2,048.1	1.4	1.0
Average/Sum#:	10.7	13.3	8.3	141.2	3,379,576.6	2,071.8	1.4	1.1
Minimum:	10.6	13.3	8.3	132.9	3,346,686.5	2,027.6	1.3	1.0
Maximum:	11.0	13.4	8.5	155.4	3,412,872.8	2,150.6	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/12/2019 00:00	10.8	13.3	8.4	138.2	3,370,103.9	2,042.6	1.4	1.0
12/12/2019 01:00	10.8	13.3	8.4	137.4	3,352,944.9	2,032.2	1.4	1.0
12/12/2019 02:00	10.8	13.3	8.4	137.8	3,365,319.2	2,039.7	1.4	1.0
12/12/2019 03:00	10.8	13.3	8.4	138.3	3,365,319.2	2,039.7	1.4	1.0
12/12/2019 04:00	10.8	13.3	8.4	137.2	3,364,494.2	2,039.2	1.4	1.0
12/12/2019 05:00	10.8	13.3	8.4	140.0	3,368,289.0	2,041.5	1.4	1.0
12/12/2019 06:00	11.1	13.3	8.6	146.4	3,385,217.1	2,101.2	1.5	1.3
12/12/2019 07:00	10.8	13.3	8.4	148.5	3,348,006.5	2,127.0	1.5	1.3
12/12/2019 08:00	10.7	13.3	8.3	137.3	3,378,518.4	2,047.7	1.4	1.0
12/12/2019 09:00	10.8	13.4	8.5	138.2	3,367,959.0	2,041.3	1.4	1.0
12/12/2019 10:00	10.7	13.4	8.4	135.3	3,372,458.0	2,019.4	1.3	1.0
12/12/2019 11:00	10.8	13.4	8.5	134.6	3,365,443.9	2,015.2	1.3	1.0
12/12/2019 12:00	10.7	13.3	8.3	136.8	3,348,325.1	2,029.4	1.4	1.0
12/12/2019 13:00	10.7	13.3	8.3	135.8	3,356,574.7	2,034.4	1.4	1.0
12/12/2019 14:00	10.8	13.3	8.4	138.5	3,368,619.0	2,041.7	1.4	1.0
12/12/2019 15:00	10.8	13.3	8.4	139.6	3,365,979.1	2,040.1	1.4	1.0
12/12/2019 16:00	10.6	13.3	8.2	140.6	3,335,363.5	2,045.9	1.4	1.0
12/12/2019 17:00	10.8	13.3	8.4	149.5	3,347,924.1	2,102.5	1.5	1.3
12/12/2019 18:00	10.7	13.3	8.3	147.7	3,314,636.6	2,105.8	1.5	1.3
12/12/2019 19:00	10.6	13.3	8.2	148.1	3,340,440.1	2,097.8	1.5	1.3
12/12/2019 20:00	10.7	13.3	8.3	141.6	3,352,155.3	2,056.2	1.4	1.0
12/12/2019 21:00	10.8	13.3	8.4	143.0	3,360,306.6	2,061.2	1.4	1.0
12/12/2019 22:00	10.6	13.3	8.2	137.9	3,350,035.9	2,054.9	1.4	1.0
12/12/2019 23:00	9.3	13.6	7.5	114.9	3,271,663.0	1,815.7	1.2	0.9
Average/Sum#:	10.7	13.3	8.3	139.3	3,354,837.3	2,044.7	1.4	1.1
Minimum:	9.3	13.3	7.5	114.9	3,271,663.0	1,815.7	1.2	0.9
Maximum:	11.1	13.6	8.6	149.5	3,385,217.1	2,127.0	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/13/2019 00:00	13.1	14.5	12.1	113.5	2,600,661.4	1,253.4	1.4	0.6
12/13/2019 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/13/2019 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/13/2019 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/13/2019 04:00	38.3	17.2	61.1	222.3	1,912,499.0	488.8	3.1	0.6
12/13/2019 05:00	20.0	14.2	17.6	163.1	2,619,075.2	1,281.4	2.0	1.0
12/13/2019 06:00	9.1	13.9	7.7	90.1	2,717,916.1	1,389.3	1.1	0.6
12/13/2019 07:00	9.3	13.8	7.7	100.9	3,036,264.6	1,574.2	1.1	0.6
12/13/2019 08:00	9.2	13.8	7.6	106.4	3,226,441.0	1,672.8	1.1	0.7
12/13/2019 09:00	9.4	13.8	7.8	108.1	3,148,325.9	1,632.3	1.1	0.7
12/13/2019 10:00	9.2	13.8	7.6	107.6	3,291,705.0	1,682.6	1.1	0.7
12/13/2019 11:00	9.2	13.9	7.8	102.7	3,115,244.8	1,592.4	1.1	0.6
12/13/2019 12:00	9.3	13.9	7.8	95.4	2,913,548.2	1,489.3	1.1	0.6
12/13/2019 13:00	9.3	13.8	7.7	105.8	3,231,841.5	1,652.0	1.1	0.7
12/13/2019 14:00	9.4	13.8	7.8	109.5	3,340,045.4	1,731.7	1.1	0.7
12/13/2019 15:00	11.5	13.4	9.0	135.7	3,343,375.4	2,026.4	1.3	1.0
12/13/2019 16:00	11.4	13.3	8.9	146.5	3,311,459.2	2,079.6	1.5	1.2
12/13/2019 17:00	11.2	13.3	8.7	146.3	3,300,631.2	2,072.8	1.5	1.2
12/13/2019 18:00	11.1	13.3	8.6	161.9	3,309,698.7	2,151.0	1.7	1.5
12/13/2019 19:00	10.9	13.3	8.5	146.2	3,310,026.1	2,078.7	1.5	1.2
12/13/2019 20:00	10.9	13.3	8.5	152.9	3,322,034.7	2,110.5	1.6	1.3
12/13/2019 21:00	10.9	13.3	8.5	151.3	3,302,044.2	2,097.8	1.6	1.3
12/13/2019 22:00	11.0	13.4	8.7	151.4	3,296,220.2	2,094.1	1.6	1.3
12/13/2019 23:00	11.0	13.4	8.7	153.0	3,318,784.1	2,084.2	1.6	1.3
Average/Sum#:	12.1	13.8	11.4	131.9	3,093,706.8	1,725.5	1.4	0.9
Minimum:	9.1	13.3	7.6	90.1	1,912,499.0	488.8	1.1	0.6
Maximum:	38.3	17.2	61.1	222.3	3,343,375.4	2,151.0	3.1	1.5
%SI	12.50	12.50	12.50	12.50	12.50	12.50	12.50	12.50

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/14/2019 00:00	10.8	13.4	8.5	144.2	3,369,110.0	2,066.6	1.4	1.0
12/14/2019 01:00	10.2	13.5	8.1	129.7	3,324,658.1	1,966.5	1.3	1.0
12/14/2019 02:00	8.8	13.9	7.4	102.0	3,126,591.5	1,598.2	1.1	0.6
12/14/2019 03:00	9.1	13.8	7.6	99.6	3,039,144.0	1,553.5	1.1	0.6
12/14/2019 04:00	9.1	13.8	7.6	107.1	3,306,573.0	1,690.2	1.1	0.7
12/14/2019 05:00	9.1	13.8	7.6	107.8	3,178,825.3	1,624.9	1.1	0.6
12/14/2019 06:00	9.4	13.8	7.8	100.7	3,047,360.5	1,557.7	1.1	0.6
12/14/2019 07:00	9.4	13.9	7.9	96.7	2,900,636.5	1,482.7	1.1	0.6
12/14/2019 08:00	9.2	13.9	7.8	94.7	2,893,398.1	1,479.0	1.1	0.6
12/14/2019 09:00	9.2	13.9	7.8	104.6	3,203,279.3	1,637.4	1.1	0.7
12/14/2019 10:00	9.2	13.9	7.8	101.3	3,077,487.9	1,573.1	1.1	0.6
12/14/2019 11:00	9.2	13.9	7.8	102.9	3,133,438.6	1,601.7	1.1	0.6
12/14/2019 12:00	9.0	14.0	7.7	88.5	2,697,766.0	1,379.0	1.1	0.6
12/14/2019 13:00	9.2	13.9	7.8	105.1	3,219,125.5	1,645.5	1.1	0.7
12/14/2019 14:00	9.2	13.9	7.8	102.9	3,124,635.2	1,597.2	1.1	0.6
12/14/2019 15:00	9.4	13.9	7.9	102.7	3,093,934.7	1,604.1	1.1	0.6
12/14/2019 16:00	11.1	13.4	8.7	128.0	3,358,596.8	2,011.1	1.3	1.0
12/14/2019 17:00	11.1	13.3	8.6	143.4	3,329,930.5	2,091.2	1.4	1.0
12/14/2019 18:00	11.0	13.4	8.7	147.3	3,340,599.3	2,097.9	1.5	1.3
12/14/2019 19:00	11.0	13.4	8.7	144.9	3,364,219.2	2,063.6	1.4	1.0
12/14/2019 20:00	10.9	13.4	8.6	156.5	3,352,728.7	2,130.0	1.6	1.3
12/14/2019 21:00	10.7	13.4	8.4	148.4	3,391,236.2	2,129.7	1.5	1.3
12/14/2019 22:00	10.6	13.4	8.3	135.1	3,371,881.5	2,068.3	1.3	1.0
12/14/2019 23:00	9.7	13.6	7.8	117.4	3,399,157.1	1,936.1	1.1	0.8
Average/Sum#:	9.8	13.7	8.0	117.1	3,193,513.1	1,774.4	1.2	0.8
Minimum:	8.8	13.3	7.4	88.5	2,697,766.0	1,379.0	1.1	0.6
Maximum:	11.1	14.0	8.7	156.5	3,399,157.1	2,130.0	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/15/2019 00:00	10.7	13.4	8.4	133.6	3,405,524.6	2,039.2	1.3	1.0
12/15/2019 01:00	10.6	13.4	8.3	131.9	3,425,251.6	2,026.0	1.3	1.0
12/15/2019 02:00	10.7	13.4	8.4	140.1	3,390,955.6	2,080.0	1.4	1.0
12/15/2019 03:00	10.7	13.4	8.4	142.9	3,391,017.0	2,104.8	1.4	1.1
12/15/2019 04:00	10.6	13.4	8.3	142.1	3,405,839.0	2,114.0	1.4	1.1
12/15/2019 05:00	10.6	13.4	8.3	141.9	3,414,981.4	2,069.8	1.4	1.0
12/15/2019 06:00	10.8	13.4	8.5	131.7	3,474,663.9	2,080.6	1.3	1.0
12/15/2019 07:00	9.6	13.6	7.8	121.6	3,423,561.0	1,950.0	1.2	1.0
12/15/2019 08:00	8.8	13.9	7.4	101.5	3,100,181.2	1,584.7	1.1	0.6
12/15/2019 09:00	8.9	13.9	7.5	104.5	3,197,214.7	1,634.3	1.1	0.7
12/15/2019 10:00	9.0	13.9	7.6	98.6	3,004,908.4	1,536.0	1.1	0.6
12/15/2019 11:00	9.1	13.9	7.7	100.1	3,054,990.2	1,561.6	1.1	0.6
12/15/2019 12:00	9.1	13.9	7.7	99.0	3,022,906.5	1,545.2	1.1	0.6
12/15/2019 13:00	9.0	13.9	7.6	104.6	3,200,931.7	1,636.2	1.1	0.7
12/15/2019 14:00	9.1	13.9	7.7	100.7	3,072,988.3	1,570.8	1.1	0.6
12/15/2019 15:00	9.3	13.9	7.8	100.6	3,063,793.6	1,566.1	1.1	0.6
12/15/2019 16:00	10.9	13.5	8.7	128.5	3,435,543.4	2,007.0	1.2	1.0
12/15/2019 17:00	11.1	13.4	8.7	140.6	3,420,261.1	2,073.0	1.4	1.0
12/15/2019 18:00	10.9	13.3	8.5	158.5	3,382,945.1	2,173.9	1.6	1.3
12/15/2019 19:00	10.7	13.3	8.3	167.7	3,373,653.0	2,217.2	1.7	1.6
12/15/2019 20:00	10.6	13.3	8.2	162.0	3,362,393.3	2,209.8	1.6	1.3
12/15/2019 21:00	10.5	13.3	8.2	160.7	3,389,863.9	2,203.1	1.6	1.3
12/15/2019 22:00	10.5	13.4	8.3	146.4	3,414,861.1	2,119.6	1.4	1.1
12/15/2019 23:00	10.6	13.4	8.3	141.0	3,407,910.4	2,090.4	1.4	1.0
Average/Sum#:	10.1	13.6	8.1	129.2	3,301,547.5	1,924.7	1.3	1.0
Minimum:	8.8	13.3	7.4	98.6	3,004,908.4	1,536.0	1.1	0.6
Maximum:	11.1	13.9	8.7	167.7	3,474,663.9	2,217.2	1.7	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/16/2019 00:00	10.6	13.4	8.3	145.8	3,439,994.1	2,135.2	1.4	1.1
12/16/2019 01:00	10.7	13.4	8.4	148.0	3,441,605.1	2,136.2	1.4	1.1
12/16/2019 02:00	10.7	13.4	8.4	145.9	3,469,045.4	2,127.9	1.4	1.1
12/16/2019 03:00	10.6	13.4	8.3	145.8	3,455,460.5	2,144.8	1.4	1.1
12/16/2019 04:00	10.6	13.4	8.3	144.8	3,446,760.6	2,139.4	1.4	1.1
12/16/2019 05:00	10.6	13.4	8.3	152.1	3,408,900.1	2,115.9	1.5	1.3
12/16/2019 06:00	11.0	13.3	8.5	162.5	3,446,795.0	2,240.1	1.6	1.3
12/16/2019 07:00	10.7	13.3	8.3	154.0	3,439,773.7	2,185.3	1.5	1.3
12/16/2019 08:00	10.4	13.5	8.3	129.0	3,468,752.0	2,026.4	1.2	1.0
12/16/2019 09:00	10.6	13.5	8.5	132.6	3,463,103.1	2,023.1	1.3	1.0
12/16/2019 10:00	10.8	13.4	8.5	139.7	3,459,233.6	2,046.1	1.3	1.0
12/16/2019 11:00	10.7	13.5	8.5	138.3	3,443,510.6	2,036.8	1.3	1.0
12/16/2019 12:00	10.6	13.4	8.3	138.0	3,401,850.6	2,037.0	1.4	1.0
12/16/2019 13:00	10.8	13.5	8.6	145.6	3,409,031.7	2,041.3	1.4	1.0
12/16/2019 14:00	10.7	13.4	8.4	142.1	3,384,623.1	2,051.4	1.4	1.0
12/16/2019 15:00	10.8	13.4	8.5	145.8	3,380,358.9	2,073.5	1.5	1.2
12/16/2019 16:00	10.8	13.4	8.5	149.5	3,384,894.9	2,101.0	1.5	1.3
12/16/2019 17:00	10.8	13.4	8.5	163.7	3,385,901.8	2,175.8	1.6	1.3
12/16/2019 18:00	10.7	13.4	8.4	167.5	3,379,400.9	2,196.3	1.7	1.5
12/16/2019 19:00	10.6	13.4	8.3	169.9	3,378,522.1	2,220.4	1.7	1.6
12/16/2019 20:00	10.6	13.4	8.3	168.0	3,417,714.0	2,221.2	1.7	1.6
12/16/2019 21:00	10.4	13.4	8.2	160.5	3,407,097.1	2,214.3	1.6	1.3
12/16/2019 22:00	10.3	13.4	8.1	147.9	3,452,223.3	2,168.0	1.4	1.1
12/16/2019 23:00	10.3	13.4	8.1	136.6	3,473,718.2	2,105.4	1.3	1.1
Average/Sum#:	10.6	13.4	8.4	148.9	3,426,594.6	2,123.5	1.5	1.2
Minimum:	10.3	13.3	8.1	129.0	3,378,522.1	2,023.1	1.2	1.0
Maximum:	11.0	13.5	8.6	169.9	3,473,718.2	2,240.1	1.7	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/17/2019 00:00	10.4	13.4	8.2	139.8	3,456,818.4	2,120.4	1.4	1.1
12/17/2019 01:00	10.5	13.4	8.3	144.7	3,486,489.3	2,138.6	1.4	1.1
12/17/2019 02:00	10.5	13.4	8.3	143.8	3,481,109.4	2,135.3	1.4	1.1
12/17/2019 03:00	10.4	13.4	8.2	141.4	3,486,815.3	2,138.8	1.4	1.1
12/17/2019 04:00	10.3	13.4	8.1	135.7	3,522,760.7	2,109.4	1.3	1.1
12/17/2019 05:00	10.4	13.4	8.2	139.6	3,453,919.3	2,093.4	1.4	1.0
12/17/2019 06:00	10.9	13.4	8.6	147.3	3,497,026.6	2,170.6	1.4	1.1
12/17/2019 07:00	10.5	13.4	8.3	142.2	3,478,821.3	2,159.3	1.4	1.1
12/17/2019 08:00	10.4	13.4	8.2	137.2	3,480,152.8	2,109.3	1.3	1.1
12/17/2019 09:00	10.4	13.4	8.2	131.9	3,465,827.1	2,050.0	1.3	1.0
12/17/2019 10:00	10.6	13.4	8.3	132.5	3,477,139.7	2,031.3	1.3	1.0
12/17/2019 11:00	10.6	13.4	8.3	134.8	3,438,438.7	2,033.8	1.3	1.0
12/17/2019 12:00	10.6	13.4	8.3	135.8	3,454,330.7	2,043.2	1.3	1.0
12/17/2019 13:00	10.6	13.4	8.3	137.5	3,433,247.1	2,055.8	1.3	1.0
12/17/2019 14:00	10.7	13.4	8.4	145.3	3,400,248.1	2,085.7	1.4	1.0
12/17/2019 15:00	10.6	13.4	8.3	145.6	3,397,461.3	2,108.8	1.4	1.1
12/17/2019 16:00	10.7	13.4	8.4	156.0	3,383,107.8	2,149.3	1.6	1.3
12/17/2019 17:00	10.7	13.3	8.3	167.7	3,387,863.6	2,201.8	1.7	1.5
12/17/2019 18:00	10.7	13.3	8.3	175.2	3,395,871.5	2,256.6	1.8	1.6
12/17/2019 19:00	10.5	13.3	8.2	176.3	3,363,127.7	2,259.4	1.8	1.6
12/17/2019 20:00	10.6	13.3	8.2	168.8	3,392,064.2	2,229.3	1.7	1.6
12/17/2019 21:00	10.6	13.3	8.2	164.6	3,386,478.8	2,200.9	1.7	1.5
12/17/2019 22:00	10.6	13.3	8.2	161.9	3,377,554.5	2,195.1	1.6	1.3
12/17/2019 23:00	10.3	13.4	8.1	137.4	3,428,614.8	2,103.1	1.3	1.1
Average/Sum#:	10.5	13.4	8.3	147.6	3,438,553.7	2,132.5	1.5	1.2
Minimum:	10.3	13.3	8.1	131.9	3,363,127.7	2,031.3	1.3	1.0
Maximum:	10.9	13.4	8.6	176.3	3,522,760.7	2,259.4	1.8	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/18/2019 00:00	10.4	13.4	8.2	137.2	3,446,659.7	2,089.0	1.3	1.0
12/18/2019 01:00	10.5	13.4	8.3	142.3	3,407,933.4	2,115.3	1.4	1.1
12/18/2019 02:00	10.6	13.4	8.3	145.3	3,406,322.3	2,114.3	1.4	1.1
12/18/2019 03:00	10.5	13.4	8.3	142.4	3,419,694.3	2,122.6	1.4	1.1
12/18/2019 04:00	10.5	13.4	8.3	145.0	3,391,076.9	2,129.6	1.4	1.1
12/18/2019 05:00	10.6	13.4	8.3	162.5	3,342,011.0	2,172.0	1.7	1.5
12/18/2019 06:00	10.9	13.3	8.5	160.8	3,401,650.2	2,235.6	1.6	1.3
12/18/2019 07:00	10.5	13.3	8.2	149.1	3,416,402.6	2,195.4	1.5	1.3
12/18/2019 08:00	10.5	13.3	8.2	142.5	3,449,982.8	2,141.4	1.4	1.1
12/18/2019 09:00	10.5	13.4	8.3	139.4	3,424,205.4	2,125.4	1.4	1.1
12/18/2019 10:00	10.5	13.4	8.3	139.1	3,452,579.7	2,117.8	1.3	1.1
12/18/2019 11:00	10.3	13.3	8.0	140.0	3,439,671.8	2,135.0	1.4	1.1
12/18/2019 12:00	10.4	13.4	8.2	138.1	3,440,678.8	2,110.5	1.3	1.1
12/18/2019 13:00	10.5	13.4	8.3	138.3	3,439,374.6	2,109.7	1.3	1.1
12/18/2019 14:00	10.5	13.4	8.3	136.3	3,420,789.5	2,098.3	1.3	1.0
12/18/2019 15:00	10.5	13.4	8.3	133.8	3,461,804.6	2,072.9	1.3	1.0
12/18/2019 16:00	10.5	13.3	8.2	141.6	3,432,583.0	2,130.6	1.4	1.1
12/18/2019 17:00	10.5	13.3	8.2	150.3	3,412,823.4	2,193.1	1.5	1.3
12/18/2019 18:00	10.4	13.3	8.1	152.6	3,395,864.7	2,207.0	1.5	1.3
12/18/2019 19:00	10.3	13.3	8.0	151.2	3,430,874.9	2,204.7	1.5	1.3
12/18/2019 20:00	10.3	13.3	8.0	150.2	3,422,004.8	2,199.0	1.5	1.3
12/18/2019 21:00	10.4	13.3	8.1	153.8	3,388,479.1	2,202.2	1.5	1.3
12/18/2019 22:00	10.4	13.3	8.1	152.3	3,415,157.7	2,194.6	1.5	1.3
12/18/2019 23:00	10.3	13.4	8.1	135.5	3,425,680.3	2,101.3	1.3	1.1
Average/Sum#:	10.5	13.4	8.2	145.0	3,420,179.4	2,146.6	1.4	1.2
Minimum:	10.3	13.3	8.0	133.8	3,342,011.0	2,072.9	1.3	1.0
Maximum:	10.9	13.4	8.5	162.5	3,461,804.6	2,235.6	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/19/2019 00:00	10.4	13.3	8.1	140.2	3,409,705.6	2,116.4	1.4	1.1
12/19/2019 01:00	10.5	13.3	8.2	141.0	3,414,216.7	2,119.2	1.4	1.1
12/19/2019 02:00	10.4	13.4	8.2	139.5	3,403,100.1	2,112.3	1.4	1.1
12/19/2019 03:00	10.5	13.4	8.3	139.0	3,424,539.1	2,100.6	1.4	1.1
12/19/2019 04:00	10.5	13.4	8.3	140.7	3,407,611.2	2,115.1	1.4	1.1
12/19/2019 05:00	10.5	13.4	8.3	143.5	3,357,000.6	2,108.2	1.4	1.1
12/19/2019 06:00	10.8	13.3	8.4	156.8	3,401,096.2	2,210.4	1.6	1.3
12/19/2019 07:00	10.6	13.3	8.2	148.8	3,371,585.1	2,166.6	1.5	1.3
12/19/2019 08:00	10.3	13.4	8.1	129.1	3,408,029.7	2,040.7	1.3	1.0
12/19/2019 09:00	10.5	13.4	8.3	135.3	3,415,146.4	2,069.9	1.3	1.0
12/19/2019 10:00	10.5	13.4	8.3	132.1	3,443,679.7	2,036.9	1.3	1.0
12/19/2019 11:00	10.5	13.4	8.3	131.9	3,452,809.2	2,042.3	1.3	1.0
12/19/2019 12:00	10.6	13.4	8.3	131.8	3,403,186.6	2,037.8	1.3	1.0
12/19/2019 13:00	10.6	13.4	8.3	132.9	3,407,194.7	2,040.2	1.3	1.0
12/19/2019 14:00	10.6	13.4	8.3	131.9	3,383,647.2	2,026.1	1.3	1.0
12/19/2019 15:00	10.7	13.4	8.4	140.6	3,393,075.0	2,081.3	1.4	1.0
12/19/2019 16:00	10.7	13.3	8.3	144.0	3,385,217.1	2,101.2	1.4	1.1
12/19/2019 17:00	10.6	13.3	8.2	149.8	3,357,579.6	2,157.6	1.5	1.3
12/19/2019 18:00	10.7	13.3	8.3	161.1	3,347,786.1	2,200.2	1.6	1.3
12/19/2019 19:00	10.5	13.3	8.2	149.0	3,363,493.0	2,161.4	1.5	1.3
12/19/2019 20:00	10.6	13.3	8.2	151.5	3,372,363.2	2,167.1	1.5	1.3
12/19/2019 21:00	10.6	13.3	8.2	151.7	3,376,720.4	2,169.9	1.5	1.3
12/19/2019 22:00	10.5	13.3	8.2	138.5	3,399,072.4	2,109.8	1.4	1.1
12/19/2019 23:00	10.6	13.3	8.2	139.0	3,415,898.7	2,095.3	1.4	1.0
Average/Sum#:	10.6	13.4	8.3	141.7	3,396,406.4	2,107.8	1.4	1.1
Minimum:	10.3	13.3	8.1	129.1	3,347,786.1	2,026.1	1.3	1.0
Maximum:	10.8	13.4	8.4	161.1	3,452,809.2	2,210.4	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/20/2019 00:00	10.6	13.3	8.2	141.8	3,407,772.3	2,115.2	1.4	1.1
12/20/2019 01:00	10.6	13.3	8.2	140.5	3,421,441.6	2,098.7	1.4	1.0
12/20/2019 02:00	10.6	13.3	8.2	138.9	3,389,567.0	2,103.9	1.4	1.1
12/20/2019 03:00	10.4	13.4	8.2	129.5	3,449,258.8	2,040.2	1.2	1.0
12/20/2019 04:00	10.5	13.4	8.3	137.4	3,404,486.8	2,088.3	1.4	1.0
12/20/2019 05:00	10.6	13.4	8.3	154.1	3,379,739.4	2,097.8	1.5	1.3
12/20/2019 06:00	10.9	13.3	8.5	139.9	3,389,325.4	2,128.5	1.4	1.1
12/20/2019 07:00	10.6	13.4	8.3	132.7	3,415,971.4	2,070.4	1.3	1.0
12/20/2019 08:00	10.6	13.4	8.3	128.1	3,426,266.0	2,026.6	1.2	1.0
12/20/2019 09:00	10.6	13.4	8.3	130.6	3,417,715.9	2,046.5	1.3	1.0
12/20/2019 10:00	10.0	13.5	8.0	123.0	3,370,690.8	1,944.5	1.2	1.0
12/20/2019 11:00	8.8	13.9	7.4	103.5	3,211,300.2	1,641.5	1.1	0.7
12/20/2019 12:00	9.0	13.9	7.6	100.9	3,111,723.5	1,590.6	1.1	0.6
12/20/2019 13:00	9.0	13.9	7.6	104.2	3,228,515.8	1,650.3	1.1	0.7
12/20/2019 14:00	9.3	13.9	7.8	99.8	3,060,272.2	1,564.3	1.1	0.6
12/20/2019 15:00	11.1	13.4	8.7	132.8	3,377,363.5	2,047.0	1.3	1.0
12/20/2019 16:00	11.1	13.4	8.7	141.4	3,372,167.3	2,093.1	1.4	1.0
12/20/2019 17:00	10.9	13.3	8.5	152.5	3,347,931.4	2,151.4	1.5	1.3
12/20/2019 18:00	10.8	13.3	8.4	156.2	3,361,859.9	2,184.9	1.6	1.3
12/20/2019 19:00	10.7	13.3	8.3	148.8	3,365,006.3	2,137.8	1.5	1.3
12/20/2019 20:00	10.6	13.3	8.2	144.8	3,397,605.6	2,133.7	1.4	1.1
12/20/2019 21:00	10.6	13.3	8.2	145.9	3,394,102.4	2,131.5	1.5	1.3
12/20/2019 22:00	10.6	13.3	8.2	147.4	3,363,274.8	2,136.7	1.5	1.3
12/20/2019 23:00	10.5	13.3	8.2	141.2	3,387,573.8	2,127.4	1.4	1.1
Average/Sum#:	10.4	13.4	8.2	134.0	3,352,122.2	2,014.6	1.3	1.0
Minimum:	8.8	13.3	7.4	99.8	3,060,272.2	1,564.3	1.1	0.6
Maximum:	11.1	13.9	8.7	156.2	3,449,258.8	2,184.9	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/21/2019 00:00	10.5	13.3	8.2	136.7	3,403,019.6	2,087.4	1.3	1.0
12/21/2019 01:00	10.6	13.4	8.3	134.5	3,409,371.7	2,066.4	1.3	1.0
12/21/2019 02:00	10.6	13.3	8.2	140.6	3,388,439.3	2,103.2	1.4	1.1
12/21/2019 03:00	10.4	13.3	8.1	138.2	3,391,339.2	2,105.0	1.4	1.1
12/21/2019 04:00	10.6	13.3	8.2	143.3	3,365,440.0	2,113.5	1.4	1.1
12/21/2019 05:00	10.7	13.3	8.3	144.6	3,377,541.9	2,121.1	1.4	1.1
12/21/2019 06:00	10.8	13.3	8.4	134.9	3,410,355.8	2,091.9	1.3	1.0
12/21/2019 07:00	10.7	13.3	8.3	141.9	3,390,280.8	2,129.1	1.4	1.1
12/21/2019 08:00	10.6	13.3	8.2	141.4	3,371,013.3	2,117.0	1.4	1.1
12/21/2019 09:00	10.6	13.3	8.2	138.5	3,392,789.2	2,105.9	1.4	1.1
12/21/2019 10:00	10.5	13.4	8.3	135.2	3,387,369.0	2,077.8	1.3	1.0
12/21/2019 11:00	10.5	13.4	8.3	130.0	3,402,685.6	2,037.5	1.3	1.0
12/21/2019 12:00	10.6	13.4	8.3	131.2	3,401,516.6	2,036.8	1.3	1.0
12/21/2019 13:00	10.6	13.4	8.3	131.5	3,374,888.6	2,045.5	1.3	1.0
12/21/2019 14:00	10.6	13.3	8.2	135.0	3,375,957.2	2,070.8	1.3	1.0
12/21/2019 15:00	10.6	13.4	8.3	133.9	3,399,967.3	2,060.7	1.3	1.0
12/21/2019 16:00	10.6	13.4	8.3	132.6	3,374,723.7	2,045.4	1.3	1.0
12/21/2019 17:00	10.6	13.4	8.3	134.1	3,380,828.3	2,049.1	1.3	1.0
12/21/2019 18:00	10.7	13.4	8.4	136.8	3,359,654.5	2,060.8	1.4	1.0
12/21/2019 19:00	10.6	13.4	8.3	135.4	3,377,261.4	2,071.6	1.3	1.0
12/21/2019 20:00	10.5	13.3	8.2	138.5	3,368,300.7	2,090.7	1.4	1.0
12/21/2019 21:00	10.5	13.4	8.3	138.9	3,351,384.2	2,080.2	1.4	1.0
12/21/2019 22:00	10.7	13.3	8.3	146.0	3,365,599.3	2,113.6	1.5	1.3
12/21/2019 23:00	10.6	13.3	8.2	142.0	3,364,166.2	2,112.7	1.4	1.1
Average/Sum#:	10.6	13.3	8.3	137.3	3,382,662.2	2,083.1	1.4	1.0
Minimum:	10.4	13.3	8.1	130.0	3,351,384.2	2,036.8	1.3	1.0
Maximum:	10.8	13.4	8.4	146.0	3,410,355.8	2,129.1	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/22/2019 00:00	10.6	13.3	8.2	141.2	3,388,922.6	2,103.5	1.4	1.1
12/22/2019 01:00	10.5	13.4	8.3	134.0	3,371,066.4	2,067.8	1.3	1.0
12/22/2019 02:00	10.7	13.3	8.3	146.9	3,342,497.3	2,123.5	1.5	1.3
12/22/2019 03:00	10.7	13.3	8.3	145.5	3,343,441.8	2,124.1	1.5	1.3
12/22/2019 04:00	10.5	13.3	8.2	141.7	3,327,064.3	2,089.4	1.4	1.0
12/22/2019 05:00	10.7	13.4	8.4	145.4	3,314,007.0	2,081.2	1.5	1.2
12/22/2019 06:00	11.1	13.3	8.6	146.1	3,336,043.7	2,119.4	1.5	1.3
12/22/2019 07:00	10.7	13.3	8.3	146.7	3,313,384.5	2,129.2	1.5	1.3
12/22/2019 08:00	10.7	13.3	8.3	144.8	3,310,386.7	2,103.1	1.5	1.3
12/22/2019 09:00	10.7	13.3	8.3	142.8	3,341,077.0	2,098.2	1.4	1.0
12/22/2019 10:00	10.7	13.3	8.3	142.4	3,328,019.7	2,090.0	1.4	1.0
12/22/2019 11:00	10.6	13.3	8.2	134.8	3,323,995.8	2,063.2	1.4	1.0
12/22/2019 12:00	10.7	13.3	8.3	136.8	3,314,007.0	2,057.0	1.4	1.0
12/22/2019 13:00	10.7	13.3	8.3	142.4	3,325,790.4	2,088.6	1.4	1.0
12/22/2019 14:00	10.7	13.3	8.3	140.3	3,288,688.6	2,065.3	1.4	1.0
12/22/2019 15:00	10.8	13.3	8.4	140.1	3,318,356.9	2,059.7	1.4	1.0
12/22/2019 16:00	10.7	13.4	8.4	133.4	3,327,206.3	2,016.6	1.3	1.0
12/22/2019 17:00	10.5	13.4	8.3	129.5	3,334,300.9	2,020.9	1.3	1.0
12/22/2019 18:00	10.7	13.3	8.3	134.5	3,318,408.7	2,035.5	1.4	1.0
12/22/2019 19:00	10.7	13.3	8.3	133.6	3,364,164.2	2,039.0	1.3	1.0
12/22/2019 20:00	10.5	13.3	8.2	134.9	3,369,110.0	2,066.6	1.3	1.0
12/22/2019 21:00	10.7	13.3	8.3	138.9	3,377,587.4	2,071.8	1.4	1.0
12/22/2019 22:00	10.6	13.4	8.3	132.2	3,406,526.7	2,039.8	1.3	1.0
12/22/2019 23:00	10.5	13.4	8.3	132.4	3,383,468.2	2,050.7	1.3	1.0
Average/Sum#:	10.7	13.3	8.3	139.2	3,340,313.4	2,075.2	1.4	1.1
Minimum:	10.5	13.3	8.2	129.5	3,288,688.6	2,016.6	1.3	1.0
Maximum:	11.1	13.4	8.6	146.9	3,406,526.7	2,129.2	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/23/2019 00:00	10.5	13.4	8.3	132.2	3,392,377.7	2,056.1	1.3	1.0
12/23/2019 01:00	10.5	13.4	8.3	130.6	3,397,007.5	2,034.1	1.3	1.0
12/23/2019 02:00	10.6	13.4	8.3	132.4	3,400,514.5	2,036.2	1.3	1.0
12/23/2019 03:00	10.5	13.4	8.3	133.6	3,396,007.5	2,058.3	1.3	1.0
12/23/2019 04:00	10.6	13.4	8.3	134.2	3,379,013.4	2,048.0	1.3	1.0
12/23/2019 05:00	10.6	13.4	8.3	135.9	3,404,188.6	2,038.4	1.3	1.0
12/23/2019 06:00	11.0	13.4	8.7	132.4	3,424,062.0	2,050.3	1.3	1.0
12/23/2019 07:00	10.7	13.4	8.4	134.6	3,428,404.0	2,052.9	1.3	1.0
12/23/2019 08:00	10.8	13.3	8.4	163.4	3,379,400.9	2,196.3	1.6	1.3
12/23/2019 09:00	10.7	13.4	8.4	148.5	3,369,102.5	2,115.8	1.5	1.3
12/23/2019 10:00	10.8	13.4	8.5	151.9	3,362,096.1	2,111.4	1.5	1.3
12/23/2019 11:00	10.8	13.4	8.5	155.1	3,337,303.0	2,120.2	1.6	1.3
12/23/2019 12:00	10.8	13.4	8.5	159.0	3,339,191.8	2,121.4	1.6	1.3
12/23/2019 13:00	10.7	13.4	8.4	144.0	3,323,512.4	2,062.9	1.5	1.2
12/23/2019 14:00	10.8	13.4	8.5	155.0	3,335,663.0	2,094.8	1.6	1.3
12/23/2019 15:00	10.8	13.4	8.5	145.2	3,327,701.3	2,065.5	1.5	1.2
12/23/2019 16:00	10.6	13.4	8.3	140.3	3,346,286.3	2,052.6	1.4	1.0
12/23/2019 17:00	10.6	13.4	8.3	140.2	3,374,063.7	2,045.0	1.4	1.0
12/23/2019 18:00	10.6	13.4	8.3	140.1	3,337,156.8	2,047.0	1.4	1.0
12/23/2019 19:00	10.6	13.4	8.3	142.5	3,334,306.7	2,069.6	1.4	1.0
12/23/2019 20:00	10.7	13.4	8.4	154.7	3,346,275.1	2,125.9	1.6	1.3
12/23/2019 21:00	10.6	13.4	8.3	149.1	3,352,382.7	2,105.3	1.5	1.3
12/23/2019 22:00	10.6	13.4	8.3	147.8	3,343,624.8	2,099.8	1.5	1.3
12/23/2019 23:00	10.4	13.4	8.2	138.8	3,432,364.4	2,105.4	1.4	1.1
Average/Sum#:	10.7	13.4	8.4	143.4	3,369,250.3	2,079.7	1.4	1.1
Minimum:	10.4	13.3	8.2	130.6	3,323,512.4	2,034.1	1.3	1.0
Maximum:	11.0	13.4	8.7	163.4	3,432,364.4	2,196.3	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/24/2019 00:00	10.3	13.4	8.1	137.1	3,418,670.2	2,097.0	1.3	1.0
12/24/2019 01:00	10.4	13.4	8.2	131.5	3,423,895.0	2,050.2	1.3	1.0
12/24/2019 02:00	10.4	13.4	8.2	129.3	3,465,658.1	2,049.9	1.2	1.0
12/24/2019 03:00	10.4	13.4	8.2	128.1	3,464,474.6	2,049.2	1.2	1.0
12/24/2019 04:00	10.5	13.4	8.3	130.7	3,418,216.9	2,046.8	1.3	1.0
12/24/2019 05:00	10.5	13.4	8.3	131.0	3,419,552.9	2,047.6	1.3	1.0
12/24/2019 06:00	10.7	13.4	8.4	132.4	3,426,035.8	2,076.5	1.3	1.0
12/24/2019 07:00	10.4	13.4	8.2	127.4	3,479,183.3	2,057.9	1.2	1.0
12/24/2019 08:00	10.3	13.4	8.1	125.5	3,443,341.5	2,036.7	1.2	1.0
12/24/2019 09:00	10.4	13.4	8.2	128.2	3,441,989.0	2,035.9	1.2	1.0
12/24/2019 10:00	10.5	13.4	8.3	127.8	3,450,949.4	2,041.2	1.2	1.0
12/24/2019 11:00	10.6	13.4	8.3	131.6	3,409,866.7	2,041.8	1.3	1.0
12/24/2019 12:00	10.6	13.4	8.3	136.5	3,397,492.4	2,059.2	1.3	1.0
12/24/2019 13:00	10.6	13.4	8.3	131.9	3,404,355.6	2,038.5	1.3	1.0
12/24/2019 14:00	10.6	13.4	8.3	133.9	3,408,697.7	2,041.1	1.3	1.0
12/24/2019 15:00	10.5	13.4	8.3	137.4	3,393,238.0	2,081.4	1.4	1.0
12/24/2019 16:00	10.6	13.4	8.3	131.8	3,397,675.5	2,034.5	1.3	1.0
12/24/2019 17:00	10.5	13.4	8.3	134.1	3,396,337.5	2,058.5	1.3	1.0
12/24/2019 18:00	10.5	13.4	8.3	134.3	3,428,905.1	2,053.2	1.3	1.0
12/24/2019 19:00	10.6	13.4	8.3	131.4	3,406,025.6	2,039.5	1.3	1.0
12/24/2019 20:00	10.5	13.4	8.3	131.2	3,409,532.7	2,041.6	1.3	1.0
12/24/2019 21:00	10.5	13.4	8.3	130.8	3,406,860.7	2,040.0	1.3	1.0
12/24/2019 22:00	10.5	13.4	8.3	133.2	3,386,768.0	2,052.7	1.3	1.0
12/24/2019 23:00	10.4	13.4	8.2	128.9	3,397,508.5	2,034.4	1.3	1.0
Average/Sum#:	10.5	13.4	8.3	131.5	3,420,634.6	2,050.2	1.3	1.0
Minimum:	10.3	13.4	8.1	125.5	3,386,768.0	2,034.4	1.2	1.0
Maximum:	10.7	13.4	8.4	137.4	3,479,183.3	2,097.0	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/25/2019 00:00	10.4	13.4	8.2	132.0	3,402,772.1	2,062.4	1.3	1.0
12/25/2019 01:00	10.5	13.4	8.3	135.3	3,390,629.6	2,079.8	1.3	1.0
12/25/2019 02:00	10.6	13.3	8.2	142.1	3,420,016.6	2,122.8	1.4	1.1
12/25/2019 03:00	10.4	13.4	8.2	129.3	3,409,365.7	2,041.5	1.3	1.0
12/25/2019 04:00	10.5	13.4	8.3	132.5	3,392,707.7	2,056.3	1.3	1.0
12/25/2019 05:00	10.4	13.4	8.2	131.3	3,403,687.6	2,038.1	1.3	1.0
12/25/2019 06:00	10.9	13.4	8.6	131.5	3,424,062.0	2,050.3	1.3	1.0
12/25/2019 07:00	10.7	13.3	8.3	140.3	3,396,494.7	2,108.2	1.4	1.1
12/25/2019 08:00	10.5	13.4	8.3	127.4	3,423,561.0	2,025.0	1.2	1.0
12/25/2019 09:00	10.5	13.4	8.3	129.5	3,412,204.8	2,043.2	1.3	1.0
12/25/2019 10:00	10.5	13.4	8.3	130.1	3,409,365.7	2,041.5	1.3	1.0
12/25/2019 11:00	10.5	13.4	8.3	130.9	3,404,856.6	2,038.8	1.3	1.0
12/25/2019 12:00	10.6	13.4	8.3	131.7	3,419,051.9	2,047.3	1.3	1.0
12/25/2019 13:00	10.6	13.4	8.3	132.2	3,409,031.7	2,041.3	1.3	1.0
12/25/2019 14:00	10.5	13.4	8.3	135.1	3,412,506.6	2,068.3	1.3	1.0
12/25/2019 15:00	10.4	13.4	8.2	132.5	3,417,456.3	2,071.3	1.3	1.0
12/25/2019 16:00	10.6	13.3	8.2	137.9	3,393,075.0	2,081.3	1.4	1.0
12/25/2019 17:00	10.5	13.4	8.3	130.9	3,425,732.0	2,051.3	1.3	1.0
12/25/2019 18:00	10.6	13.4	8.3	134.0	3,411,846.6	2,067.9	1.3	1.0
12/25/2019 19:00	10.5	13.3	8.2	137.3	3,425,191.2	2,101.0	1.3	1.1
12/25/2019 20:00	10.6	13.3	8.2	137.4	3,414,757.5	2,094.6	1.3	1.0
12/25/2019 21:00	10.6	13.4	8.3	135.9	3,423,066.0	2,074.7	1.3	1.0
12/25/2019 22:00	10.6	13.4	8.3	134.8	3,401,122.2	2,061.4	1.3	1.0
12/25/2019 23:00	10.6	13.4	8.3	137.8	3,389,488.4	2,079.1	1.4	1.0
Average/Sum#:	10.5	13.4	8.3	133.7	3,409,668.7	2,064.5	1.3	1.0
Minimum:	10.4	13.3	8.2	127.4	3,389,488.4	2,025.0	1.2	1.0
Maximum:	10.9	13.4	8.6	142.1	3,425,732.0	2,122.8	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/26/2019 00:00	10.6	13.4	8.3	135.5	3,406,071.9	2,064.4	1.3	1.0
12/26/2019 01:00	10.7	13.4	8.4	144.8	3,405,355.7	2,113.7	1.4	1.1
12/26/2019 02:00	10.6	13.3	8.2	159.1	3,365,091.2	2,187.0	1.6	1.3
12/26/2019 03:00	10.7	13.3	8.3	163.2	3,366,937.6	2,188.2	1.7	1.5
12/26/2019 04:00	10.6	13.3	8.2	162.4	3,389,863.9	2,203.1	1.6	1.3
12/26/2019 05:00	10.6	13.4	8.3	145.6	3,455,239.2	2,094.2	1.4	1.0
12/26/2019 06:00	10.8	13.4	8.5	128.9	3,404,021.6	2,038.3	1.3	1.0
12/26/2019 07:00	10.8	13.4	8.5	140.5	3,411,170.9	2,092.4	1.4	1.0
12/26/2019 08:00	10.7	13.3	8.3	158.1	3,393,060.1	2,180.4	1.6	1.3
12/26/2019 09:00	10.7	13.4	8.4	148.9	3,362,892.3	2,111.9	1.5	1.3
12/26/2019 10:00	10.8	13.4	8.5	153.0	3,370,057.9	2,116.4	1.5	1.3
12/26/2019 11:00	10.7	13.4	8.4	147.0	3,374,816.0	2,070.1	1.5	1.2
12/26/2019 12:00	10.8	13.4	8.5	143.9	4,483,234.6	2,750.0	1.0	1.1
12/26/2019 13:00	10.9	13.4	8.6	149.6	4,550,516.7	2,824.5	1.1	1.1
12/26/2019 14:00	10.7	13.4	8.4	145.0	4,599,146.6	2,821.1	1.0	1.1
12/26/2019 15:00	10.8	13.4	8.5	149.1	4,551,966.7	2,825.4	1.1	1.1
12/26/2019 16:00	10.8	13.4	8.5	158.5	4,457,555.1	2,831.9	1.2	1.4
12/26/2019 17:00	10.7	13.4	8.4	161.6	4,466,054.9	2,837.3	1.2	1.4
12/26/2019 18:00	10.6	13.4	8.3	162.7	4,369,540.9	2,839.8	1.2	1.4
12/26/2019 19:00	10.6	13.3	8.2	157.2	4,368,463.8	2,839.1	1.2	1.4
12/26/2019 20:00	10.7	13.2	8.2	169.8	4,368,925.4	2,839.4	1.3	1.4
12/26/2019 21:00	10.6	13.4	8.3	162.2	4,482,425.1	2,847.7	1.2	1.4
12/26/2019 22:00	10.7	13.4	8.4	152.4	4,539,004.9	2,850.5	1.1	1.1
12/26/2019 23:00	10.7	13.4	8.4	156.6	4,542,667.3	2,852.8	1.1	1.1
Average/Sum#:	10.7	13.4	8.4	152.3	3,936,836.7	2,475.8	1.3	1.2
Minimum:	10.6	13.2	8.2	128.9	3,362,892.3	2,038.3	1.0	1.0
Maximum:	10.9	13.4	8.6	169.8	4,599,146.6	2,852.8	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/27/2019 00:00	10.6	13.4	8.3	152.9	4,536,138.7	2,848.7	1.1	1.1
12/27/2019 01:00	10.6	13.4	8.3	150.7	4,600,299.3	2,855.4	1.1	1.1
12/27/2019 02:00	10.6	13.4	8.3	150.4	4,547,444.4	2,855.8	1.1	1.1
12/27/2019 03:00	10.4	13.4	8.2	139.3	4,675,606.1	2,868.0	1.0	1.1
12/27/2019 04:00	10.3	13.4	8.1	132.8	4,809,351.6	2,879.8	0.9	0.9
12/27/2019 05:00	10.3	13.4	8.1	144.4	4,827,388.0	2,890.6	1.0	1.2
12/27/2019 06:00	10.7	13.4	8.4	133.9	4,878,024.9	2,885.3	0.9	0.9
12/27/2019 07:00	10.5	13.4	8.3	131.8	4,827,889.0	2,890.9	0.9	0.9
12/27/2019 08:00	9.6	13.6	7.8	122.1	4,873,570.7	2,775.9	0.8	0.8
12/27/2019 09:00	8.5	13.9	7.2	105.1	3,293,074.4	1,683.3	1.0	0.7
12/27/2019 10:00	8.7	13.9	7.3	103.6	3,263,338.3	1,668.1	1.0	0.7
12/27/2019 11:00	8.8	13.8	7.3	103.1	3,186,259.3	1,628.7	1.1	0.7
12/27/2019 12:00	8.8	13.9	7.4	103.3	3,178,042.7	1,624.5	1.1	0.6
12/27/2019 13:00	8.8	14.0	7.5	103.3	3,277,815.1	1,675.5	1.0	0.7
12/27/2019 14:00	8.8	14.0	7.5	101.8	3,222,842.5	1,647.4	1.0	0.7
12/27/2019 15:00	9.1	13.9	7.7	92.9	2,796,999.7	1,409.3	1.1	0.6
12/27/2019 16:00	8.8	13.9	7.4	102.1	3,162,979.1	1,616.8	1.1	0.6
12/27/2019 17:00	8.8	13.9	7.4	106.6	3,364,675.7	1,719.9	1.0	0.7
12/27/2019 18:00	11.2	13.5	8.9	130.2	4,863,339.5	2,841.1	0.8	0.9
12/27/2019 19:00	11.2	13.4	8.8	154.4	4,573,555.2	2,838.8	1.1	1.1
12/27/2019 20:00	11.1	13.3	8.6	157.7	4,472,666.0	2,841.5	1.1	1.1
12/27/2019 21:00	11.0	13.4	8.7	160.8	4,525,947.6	2,842.3	1.2	1.4
12/27/2019 22:00	10.8	13.4	8.5	154.6	4,530,087.7	2,844.9	1.1	1.1
12/27/2019 23:00	10.5	13.3	8.2	141.9	4,724,019.2	2,863.2	1.0	1.1
Average/Sum#:	9.9	13.6	8.0	128.3	4,712,767.8	2,395.7	1.0	1.0
Minimum:	8.5	13.3	7.2	92.9	4,536,138.7	1,409.3	0.9	0.9
Maximum:	11.2	14.0	8.9	160.8	4,878,024.9	2,890.9	1.1	1.2
%SI	0.00	0.00	0.00	0.00	66.67	0.00	66.67	66.67

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/28/2019 00:00	10.4	13.4	8.2	129.6	4,910,755.8	2,868.8	0.8	0.9
12/28/2019 01:00	10.4	13.4	8.2	129.7	4,844,042.9	2,865.2	0.8	0.9
12/28/2019 02:00	10.6	13.4	8.3	138.3	4,757,747.7	2,848.9	0.9	0.9
12/28/2019 03:00	10.7	13.5	8.5	134.4	4,819,021.3	2,850.4	0.9	0.9
12/28/2019 04:00	10.4	13.5	8.3	128.5	4,953,721.5	2,893.9	0.8	0.9
12/28/2019 05:00	10.5	13.4	8.3	136.2	4,862,809.1	2,876.3	0.9	0.9
12/28/2019 06:00	10.9	13.4	8.6	133.1	4,846,240.7	2,866.5	0.9	0.9
12/28/2019 07:00	10.7	13.4	8.4	140.4	4,737,548.4	2,871.4	0.9	0.9
12/28/2019 08:00	10.6	13.5	8.5	131.1	4,886,071.5	2,818.7	0.8	0.8
12/28/2019 09:00	8.5	13.9	7.2	104.4	3,264,120.8	1,668.5	1.0	0.7
12/28/2019 10:00	8.7	13.9	7.3	99.8	3,150,263.0	1,610.3	1.0	0.6
12/28/2019 11:00	8.8	13.9	7.4	104.8	3,227,928.9	1,650.0	1.1	0.7
12/28/2019 12:00	8.8	13.8	7.3	106.5	3,293,074.4	1,683.3	1.1	0.7
12/28/2019 13:00	8.9	13.9	7.5	103.3	3,202,692.4	1,637.1	1.1	0.7
12/28/2019 14:00	8.9	13.9	7.5	106.2	3,261,382.0	1,667.1	1.1	0.7
12/28/2019 15:00	8.9	13.9	7.5	98.9	3,192,715.1	1,632.0	1.0	0.7
12/28/2019 16:00	11.2	13.4	8.8	131.7	4,728,522.2	2,831.4	0.9	0.8
12/28/2019 17:00	11.0	13.3	8.5	150.1	4,520,852.1	2,839.1	1.1	1.1
12/28/2019 18:00	10.9	13.4	8.6	141.0	3,498,171.0	2,222.4	1.3	1.1
12/28/2019 19:00	10.8	13.4	8.5	147.2	3,350,210.2	2,128.4	1.5	1.3
12/28/2019 20:00	10.6	13.4	8.3	148.4	3,384,229.8	2,125.3	1.5	1.3
12/28/2019 21:00	10.6	13.4	8.3	143.3	3,376,356.1	2,095.7	1.4	1.0
12/28/2019 22:00	10.6	13.4	8.3	144.7	3,384,411.5	2,100.7	1.4	1.1
12/28/2019 23:00	10.6	13.4	8.3	144.0	3,397,622.5	2,108.9	1.4	1.1
Average/Sum#:	10.1	13.6	8.1	128.2	0.0	2,323.3	0.0	0.0
Minimum:	8.5	13.3	7.2	98.9	0.0	1,610.3	0.0	0.0
Maximum:	11.2	13.9	8.8	150.1	0.0	2,893.9	0.0	0.0
%SI	0.00	0.00	0.00	0.00	100.00	0.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/29/2019 00:00	10.6	13.3	8.2	141.0	3,416,061.7	2,095.4	1.4	1.0
12/29/2019 01:00	10.6	13.3	8.2	146.2	3,417,922.2	2,121.5	1.4	1.1
12/29/2019 02:00	10.4	13.3	8.1	141.8	3,404,649.9	2,088.4	1.4	1.0
12/29/2019 03:00	10.6	13.3	8.2	144.5	3,401,005.7	2,111.0	1.4	1.1
12/29/2019 04:00	10.6	13.3	8.2	142.5	3,411,823.0	2,092.8	1.4	1.0
12/29/2019 05:00	10.6	13.4	8.3	140.4	3,380,867.1	2,098.5	1.4	1.0
12/29/2019 06:00	10.9	13.3	8.5	142.8	3,409,377.6	2,091.3	1.4	1.0
12/29/2019 07:00	10.1	13.4	7.9	142.2	3,333,805.9	2,020.6	1.4	1.0
12/29/2019 08:00	8.6	13.9	7.2	116.8	3,225,090.9	1,672.1	1.2	0.8
12/29/2019 09:00	8.9	13.9	7.5	111.2	3,089,691.4	1,601.9	1.2	0.8
12/29/2019 10:00	8.9	13.9	7.5	116.2	3,233,577.4	1,676.5	1.2	0.8
12/29/2019 11:00	8.9	13.9	7.5	114.7	3,188,251.4	1,653.0	1.2	0.8
12/29/2019 12:00	8.9	13.9	7.5	117.0	3,256,722.6	1,688.5	1.2	0.8
12/29/2019 13:00	9.0	13.9	7.6	112.8	3,118,815.8	1,617.0	1.2	0.8
12/29/2019 14:00	9.0	13.9	7.6	116.0	3,223,162.1	1,671.1	1.2	0.8
12/29/2019 15:00	10.0	13.6	8.1	128.4	3,375,811.3	1,873.5	1.3	0.9
12/29/2019 16:00	10.9	13.4	8.6	139.1	3,391,222.7	2,055.4	1.4	1.0
12/29/2019 17:00	10.8	13.3	8.4	141.7	3,388,510.2	2,078.5	1.4	1.0
12/29/2019 18:00	10.7	13.3	8.3	146.6	3,382,637.5	2,124.3	1.5	1.3
12/29/2019 19:00	10.8	13.3	8.4	147.0	3,386,777.6	2,126.9	1.5	1.3
12/29/2019 20:00	10.6	13.3	8.2	146.5	3,386,618.3	2,126.8	1.5	1.3
12/29/2019 21:00	10.6	13.3	8.2	146.5	3,384,548.3	2,125.5	1.5	1.3
12/29/2019 22:00	10.5	13.3	8.2	145.8	3,413,894.4	2,119.0	1.4	1.1
12/29/2019 23:00	10.6	13.3	8.2	142.7	3,406,769.2	2,089.7	1.4	1.0
Average/Sum#:	10.1	13.5	8.0	134.6	3,310,849.1	1,959.1	1.3	1.0
Minimum:	8.6	13.3	7.2	111.2	3,089,691.4	1,601.9	1.2	0.8
Maximum:	10.9	13.9	8.6	147.0	3,413,894.4	2,126.9	1.5	1.3
%SI	0.00	0.00	0.00	0.00	25.00	0.00	25.00	25.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/30/2019 00:00	10.6	13.4	8.3	140.1	3,413,991.5	2,069.2	1.4	1.0
12/30/2019 01:00	10.5	13.4	8.3	139.0	3,399,967.3	2,060.7	1.4	1.0
12/30/2019 02:00	10.5	13.4	8.3	136.9	3,404,856.6	2,038.8	1.3	1.0
12/30/2019 03:00	10.4	13.4	8.2	137.1	3,412,705.8	2,043.5	1.3	1.0
12/30/2019 04:00	10.4	13.4	8.2	135.7	3,444,355.9	2,037.3	1.3	1.0
12/30/2019 05:00	10.5	13.4	8.3	139.5	3,420,220.9	2,048.0	1.4	1.0
12/30/2019 06:00	10.9	13.4	8.6	140.7	3,403,102.1	2,062.6	1.4	1.0
12/30/2019 07:00	10.8	13.4	8.5	146.9	3,416,150.0	2,120.4	1.4	1.1
12/30/2019 08:00	10.5	13.4	8.3	143.3	3,421,278.6	2,098.6	1.4	1.0
12/30/2019 09:00	10.7	13.4	8.4	141.3	3,354,600.7	2,057.7	1.4	1.0
12/30/2019 10:00	10.8	13.4	8.5	139.8	3,361,524.4	2,037.4	1.4	1.0
12/30/2019 11:00	10.8	13.4	8.5	141.8	3,345,634.2	2,052.2	1.4	1.0
12/30/2019 12:00	10.9	13.4	8.6	150.9	3,307,723.8	2,053.1	1.5	1.2
12/30/2019 13:00	10.8	13.4	8.5	152.8	3,305,726.8	2,076.0	1.6	1.2
12/30/2019 14:00	10.7	13.4	8.4	143.2	3,321,256.9	2,061.5	1.5	1.2
12/30/2019 15:00	10.9	13.4	8.6	144.5	3,332,051.2	2,068.2	1.5	1.2
12/30/2019 16:00	10.8	13.4	8.5	145.1	3,306,204.5	2,076.3	1.5	1.2
12/30/2019 17:00	10.8	13.4	8.5	148.5	3,332,956.0	2,093.1	1.5	1.3
12/30/2019 18:00	10.6	13.3	8.2	147.7	3,345,645.4	2,125.5	1.5	1.3
12/30/2019 19:00	10.6	13.3	8.2	147.7	3,337,932.6	2,120.6	1.5	1.3
12/30/2019 20:00	10.5	13.3	8.2	145.1	3,384,733.8	2,100.9	1.4	1.1
12/30/2019 21:00	10.6	13.4	8.3	141.5	3,378,402.6	2,072.3	1.4	1.0
12/30/2019 22:00	10.5	13.3	8.2	144.4	3,383,606.0	2,100.2	1.4	1.1
12/30/2019 23:00	10.7	13.4	8.4	143.1	3,377,098.3	2,071.5	1.4	1.0
Average/Sum#:	10.7	13.4	8.4	143.2	3,371,321.9	2,072.7	1.4	1.1
Minimum:	10.4	13.3	8.2	135.7	3,305,726.8	2,037.3	1.3	1.0
Maximum:	10.9	13.4	8.6	152.8	3,444,355.9	2,125.5	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/31/2019 00:00	10.6	13.4	8.3	140.2	3,373,073.7	2,044.4	1.4	1.0
12/31/2019 01:00	10.3	13.5	8.2	127.5	3,389,676.5	1,930.7	1.2	1.0
12/31/2019 02:00	10.7	13.5	8.5	127.7	3,384,409.5	1,927.7	1.2	1.0
12/31/2019 03:00	10.4	13.5	8.3	128.1	3,408,462.2	1,941.4	1.2	1.0
12/31/2019 04:00	10.7	13.4	8.4	139.3	3,369,279.0	2,042.1	1.4	1.0
12/31/2019 05:00	10.8	13.4	8.5	156.9	3,360,864.4	2,037.0	1.6	1.2
12/31/2019 06:00	11.1	13.4	8.7	137.4	3,391,162.4	2,030.6	1.3	1.0
12/31/2019 07:00	10.9	13.4	8.6	139.8	3,349,315.1	2,030.0	1.4	1.0
12/31/2019 08:00	10.4	13.6	8.4	126.3	3,362,381.5	1,890.6	1.2	0.9
12/31/2019 09:00	8.7	13.9	7.3	96.8	2,960,304.3	1,513.2	1.1	0.6
12/31/2019 10:00	8.8	13.9	7.4	102.3	3,154,958.1	1,612.7	1.1	0.6
12/31/2019 11:00	8.9	13.9	7.5	100.6	3,091,377.7	1,580.2	1.1	0.6
12/31/2019 12:00	8.9	13.9	7.5	99.3	3,058,315.9	1,563.3	1.1	0.6
12/31/2019 13:00	8.8	13.9	7.4	104.5	3,255,708.7	1,664.2	1.0	0.7
12/31/2019 14:00	8.9	13.9	7.5	99.6	3,063,598.0	1,566.0	1.1	0.6
12/31/2019 15:00	9.2	13.9	7.8	100.2	3,090,790.8	1,579.9	1.1	0.6
12/31/2019 16:00	11.2	13.4	8.8	128.0	3,374,701.3	1,996.1	1.2	1.0
12/31/2019 17:00	10.9	13.4	8.6	135.4	3,359,379.5	2,036.1	1.3	1.0
12/31/2019 18:00	10.7	13.4	8.4	132.4	3,394,502.4	2,032.6	1.3	1.0
12/31/2019 19:00	10.6	13.4	8.3	134.8	3,408,029.7	2,040.7	1.3	1.0
12/31/2019 20:00	10.7	13.4	8.4	134.4	3,367,299.1	2,040.9	1.3	1.0
12/31/2019 21:00	10.6	13.4	8.3	135.9	3,369,114.0	2,042.0	1.4	1.0
12/31/2019 22:00	10.5	13.4	8.3	132.9	3,371,423.8	2,043.4	1.3	1.0
12/31/2019 23:00	10.6	13.4	8.3	134.2	3,410,367.7	2,042.1	1.3	1.0
Average/Sum#:	10.2	13.6	8.2	124.8	3,296,604.0	1,884.5	1.2	0.9
Minimum:	8.7	13.4	7.3	96.8	2,960,304.3	1,513.2	1.0	0.6
Maximum:	11.2	13.9	8.8	156.9	3,410,367.7	2,044.4	1.6	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/01/2019 00:00	7.7	13.9	6.5	83.7	2,719,676.8	1,390.2	1.0	0.6
10/01/2019 01:00	8.0	13.9	6.7	82.7	2,658,639.6	1,359.0	1.0	0.5
10/01/2019 02:00	8.0	13.9	6.7	82.2	2,643,184.7	1,351.1	1.0	0.5
10/01/2019 03:00	8.0	13.9	6.7	84.3	2,729,262.8	1,395.1	1.0	0.6
10/01/2019 04:00	7.8	13.9	6.6	99.5	3,231,645.9	1,651.9	1.0	0.7
10/01/2019 05:00	7.6	13.9	6.4	91.1	2,959,130.5	1,512.6	1.0	0.6
10/01/2019 06:00	7.8	13.9	6.6	97.0	3,192,519.5	1,631.9	0.9	0.5
10/01/2019 07:00	8.1	13.9	6.8	99.5	3,184,498.6	1,627.8	1.0	0.7
10/01/2019 08:00	7.9	13.9	6.7	99.4	3,207,778.8	1,639.7	1.0	0.7
10/01/2019 09:00	7.8	13.9	6.6	98.4	3,174,325.7	1,622.6	1.0	0.6
10/01/2019 10:00	7.8	13.9	6.6	97.5	3,135,394.9	1,602.7	1.0	0.6
10/01/2019 11:00	7.8	13.9	6.6	97.1	3,146,546.0	1,608.4	1.0	0.6
10/01/2019 12:00	7.7	13.9	6.5	95.9	3,163,370.3	1,593.9	0.9	0.5
10/01/2019 13:00	7.7	13.9	6.5	96.0	3,168,927.4	1,596.7	0.9	0.5
10/01/2019 14:00	8.0	13.8	6.6	95.9	3,068,684.4	1,568.6	1.0	0.6
10/01/2019 15:00	8.3	13.8	6.9	96.7	3,097,051.1	1,583.1	1.0	0.6
10/01/2019 16:00	9.2	13.3	7.1	117.0	3,284,614.5	1,966.8	1.1	0.8
10/01/2019 17:00	9.1	13.3	7.1	123.5	3,244,891.4	2,014.1	1.2	1.0
10/01/2019 18:00	9.1	13.2	7.0	129.4	3,261,300.1	2,048.1	1.3	1.0
10/01/2019 19:00	9.0	13.2	6.9	133.9	3,270,405.8	2,077.7	1.3	1.0
10/01/2019 20:00	9.0	13.2	6.9	134.3	3,271,035.4	2,078.1	1.3	1.0
10/01/2019 21:00	8.9	13.2	6.8	131.2	3,292,032.5	2,067.4	1.3	1.0
10/01/2019 22:00	8.9	13.3	6.9	126.5	3,295,479.5	2,045.5	1.2	1.0
10/01/2019 23:00	8.9	13.3	6.9	126.4	3,294,351.7	2,044.8	1.2	1.0
Average/Sum#:	8.3	13.7	6.7	105.0	3,112,281.2	1,711.6	1.1	0.7
Minimum:	7.6	13.2	6.4	82.2	2,643,184.7	1,351.1	0.9	0.5
Maximum:	9.2	13.9	7.1	134.3	3,295,479.5	2,078.1	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/02/2019 00:00	8.5	13.3	6.6	125.7	3,316,745.9	2,058.7	1.2	1.0
10/02/2019 01:00	8.3	13.3	6.4	125.7	3,292,257.3	2,043.5	1.2	1.0
10/02/2019 02:00	8.3	13.3	6.4	125.8	3,269,541.0	2,029.4	1.2	1.0
10/02/2019 03:00	8.3	13.3	6.4	127.8	3,264,868.8	2,026.5	1.3	1.0
10/02/2019 04:00	8.4	13.4	6.6	125.0	3,278,369.0	1,987.0	1.2	1.0
10/02/2019 05:00	8.4	13.3	6.5	129.3	3,283,684.0	2,014.2	1.3	1.0
10/02/2019 06:00	8.5	13.3	6.6	123.9	3,365,944.9	2,015.5	1.2	1.0
10/02/2019 07:00	8.5	13.4	6.7	117.0	3,265,654.5	1,931.6	1.1	0.8
10/02/2019 08:00	7.1	13.9	6.0	93.1	3,070,445.1	1,569.5	1.0	0.6
10/02/2019 09:00	8.0	13.9	6.7	83.0	2,499,695.7	1,259.5	1.0	0.5
10/02/2019 10:00	8.0	13.9	6.7	84.5	2,520,931.7	1,270.2	1.0	0.5
10/02/2019 11:00	8.0	13.9	6.7	85.4	2,565,983.7	1,292.9	1.0	0.5
10/02/2019 12:00	8.1	13.9	6.8	86.8	2,520,137.8	1,269.8	1.1	0.5
10/02/2019 13:00	8.1	13.9	6.8	85.8	2,555,663.4	1,287.7	1.0	0.5
10/02/2019 14:00	8.3	13.8	6.9	94.6	3,020,167.7	1,543.8	1.0	0.6
10/02/2019 15:00	9.3	13.3	7.2	117.7	3,231,511.6	1,958.6	1.2	1.0
10/02/2019 16:00	9.3	13.2	7.1	129.3	3,206,027.1	2,036.8	1.3	1.0
10/02/2019 17:00	9.2	13.2	7.0	131.2	3,239,554.4	2,058.1	1.3	1.0
10/02/2019 18:00	9.0	13.2	6.9	128.9	3,230,739.7	2,052.5	1.3	1.0
10/02/2019 19:00	9.0	13.2	6.9	132.4	3,254,350.5	2,067.5	1.3	1.0
10/02/2019 20:00	9.0	13.2	6.9	134.5	3,238,221.8	2,080.9	1.3	1.0
10/02/2019 21:00	8.9	13.2	6.8	129.4	3,239,554.4	2,058.1	1.3	1.0
10/02/2019 22:00	8.9	13.2	6.8	126.4	3,272,602.1	2,031.3	1.2	1.0
10/02/2019 23:00	8.6	13.3	6.7	117.9	3,298,992.8	1,999.5	1.1	0.8
Average/Sum#:	8.5	13.5	6.7	115.0	3,095,901.9	1,831.0	1.2	0.8
Minimum:	7.1	13.2	6.0	83.0	2,499,695.7	1,259.5	1.0	0.5
Maximum:	9.3	13.9	7.2	134.5	3,365,944.9	2,080.9	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/03/2019 00:00	8.4	13.3	6.5	119.8	3,266,159.7	1,979.6	1.2	1.0
10/03/2019 01:00	8.2	13.4	6.5	112.1	3,249,424.3	1,922.0	1.1	0.8
10/03/2019 02:00	8.3	13.3	6.4	117.7	3,286,952.5	1,968.2	1.2	1.0
10/03/2019 03:00	8.2	13.3	6.4	120.3	3,259,882.1	1,999.6	1.2	1.0
10/03/2019 04:00	8.2	13.3	6.4	122.6	3,286,781.5	2,016.1	1.2	1.0
10/03/2019 05:00	8.1	13.3	6.3	119.9	3,274,717.6	2,008.7	1.2	1.0
10/03/2019 06:00	8.5	13.3	6.6	128.5	3,303,410.3	2,026.3	1.2	1.0
10/03/2019 07:00	8.5	13.4	6.7	116.9	3,235,348.6	1,937.3	1.2	1.0
10/03/2019 08:00	7.6	13.9	6.4	88.2	2,845,468.2	1,454.5	1.0	0.6
10/03/2019 09:00	8.1	13.9	6.8	83.2	2,506,245.1	1,262.8	1.0	0.5
10/03/2019 10:00	8.2	13.9	6.9	83.7	2,486,199.9	1,252.7	1.1	0.5
10/03/2019 11:00	8.3	13.9	7.0	85.4	2,494,138.6	1,256.7	1.1	0.5
10/03/2019 12:00	8.1	13.9	6.8	84.3	2,573,344.0	1,315.4	1.0	0.5
10/03/2019 13:00	8.2	13.9	6.9	84.6	2,580,273.4	1,300.1	1.0	0.5
10/03/2019 14:00	8.3	13.9	7.0	83.5	2,644,945.4	1,352.0	1.0	0.5
10/03/2019 15:00	8.2	13.9	6.9	84.2	2,667,834.3	1,363.7	1.0	0.5
10/03/2019 16:00	8.3	13.8	6.9	97.1	3,093,356.1	1,603.8	1.0	0.6
10/03/2019 17:00	8.2	13.8	6.8	97.5	3,069,246.5	1,591.3	1.0	0.6
10/03/2019 18:00	8.1	13.8	6.7	97.3	3,071,561.0	1,592.5	1.0	0.6
10/03/2019 19:00	8.1	13.8	6.7	98.7	3,122,673.3	1,619.0	1.0	0.6
10/03/2019 20:00	8.0	13.8	6.6	97.7	3,128,352.2	1,599.1	1.0	0.6
10/03/2019 21:00	13.0	14.5	12.0	119.9	2,683,861.1	1,273.9	1.4	0.6
10/03/2019 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/03/2019 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	8.4	13.7	6.9	102.0	2,960,462.5	1,622.5	1.1	0.7
Minimum:	7.6	13.3	6.3	83.2	2,486,199.9	1,252.7	1.0	0.5
Maximum:	13.0	14.5	12.0	128.5	3,303,410.3	2,026.3	1.4	1.0
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/04/2019 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2019 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2019 02:00	28.1	17.9	55.3	57.4	1,975,805.5	360.7	0.3	0.0
10/04/2019 03:00	37.3	14.9	36.7	207.3	2,326,652.0	1,019.4	2.7	1.0
10/04/2019 04:00	7.8	13.9	6.6	84.7	2,747,581.3	1,384.4	1.0	0.6
10/04/2019 05:00	9.3	13.4	7.3	127.9	3,302,149.8	1,977.3	1.2	1.0
10/04/2019 06:00	9.5	13.4	7.5	134.6	3,226,135.6	1,978.9	1.3	1.0
10/04/2019 07:00	8.1	13.9	6.8	85.7	2,717,017.4	1,369.0	1.0	0.5
10/04/2019 08:00	8.2	13.9	6.9	82.7	2,686,850.3	1,353.8	0.9	0.4
10/04/2019 09:00	8.2	13.9	6.9	83.0	2,694,987.5	1,357.9	1.0	0.5
10/04/2019 10:00	8.2	13.9	6.9	83.6	2,700,941.5	1,360.9	1.0	0.5
10/04/2019 11:00	8.2	13.9	6.9	85.3	2,707,490.9	1,364.2	1.0	0.5
10/04/2019 12:00	8.1	13.9	6.8	85.8	2,718,208.2	1,369.6	1.0	0.5
10/04/2019 13:00	8.4	13.9	7.1	94.2	3,027,601.7	1,547.6	1.0	0.6
10/04/2019 14:00	8.0	13.9	6.7	88.5	2,868,051.0	1,445.1	1.0	0.6
10/04/2019 15:00	8.0	13.9	6.7	86.1	2,821,212.7	1,421.5	0.9	0.4
10/04/2019 16:00	8.7	13.9	7.3	93.5	2,955,217.8	1,510.6	1.0	0.6
10/04/2019 17:00	9.2	13.3	7.1	116.3	3,279,938.4	1,964.0	1.1	0.8
10/04/2019 18:00	9.3	13.2	7.1	135.7	3,262,342.4	2,096.4	1.3	1.0
10/04/2019 19:00	9.1	13.2	7.0	133.2	3,276,702.0	2,081.7	1.3	1.0
10/04/2019 20:00	9.2	13.2	7.0	134.8	3,292,285.1	2,091.6	1.3	1.0
10/04/2019 21:00	9.1	13.2	7.0	132.9	3,274,970.5	2,080.6	1.3	1.0
10/04/2019 22:00	9.0	13.2	6.9	129.2	3,279,930.6	2,059.8	1.3	1.0
10/04/2019 23:00	9.0	13.2	6.9	126.6	3,297,896.1	2,047.0	1.2	1.0
Average/Sum#:	10.8	13.9	10.5	108.6	2,929,089.5	1,601.9	1.1	0.7
Minimum:	7.8	13.2	6.6	57.4	1,975,805.5	360.7	0.3	0.0
Maximum:	37.3	17.9	55.3	207.3	3,302,149.8	2,096.4	2.7	1.0
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/05/2019 00:00	8.9	13.3	6.9	121.9	3,283,358.0	2,014.0	1.2	1.0
10/05/2019 01:00	8.9	13.3	6.9	119.5	3,291,238.3	1,994.8	1.2	1.0
10/05/2019 02:00	8.8	13.3	6.8	115.9	3,313,330.8	1,959.8	1.1	0.8
10/05/2019 03:00	9.0	13.3	7.0	124.5	3,307,649.0	2,028.9	1.2	1.0
10/05/2019 04:00	9.0	13.2	6.9	126.4	3,311,429.3	2,055.4	1.2	1.0
10/05/2019 05:00	9.0	13.2	6.9	130.2	3,307,637.6	2,077.2	1.3	1.0
10/05/2019 06:00	9.0	13.2	6.9	125.9	3,379,973.2	2,023.9	1.2	1.0
10/05/2019 07:00	8.9	13.4	7.0	115.1	3,310,069.9	1,933.7	1.1	0.8
10/05/2019 08:00	7.7	13.8	6.4	92.0	2,938,784.7	1,502.2	1.0	0.6
10/05/2019 09:00	8.2	13.9	6.9	84.4	2,493,940.1	1,256.6	1.1	0.5
10/05/2019 10:00	8.1	14.0	6.9	85.7	2,485,207.6	1,252.2	1.1	0.5
10/05/2019 11:00	8.0	14.0	6.8	86.4	2,510,016.0	1,264.7	1.1	0.5
10/05/2019 12:00	8.0	13.9	6.7	87.0	2,594,761.5	1,307.4	1.0	0.5
10/05/2019 13:00	8.0	14.0	6.8	86.6	2,499,298.7	1,259.3	1.1	0.5
10/05/2019 14:00	8.0	13.9	6.7	87.9	2,851,181.3	1,436.6	1.0	0.6
10/05/2019 15:00	8.3	13.9	7.0	92.9	2,870,969.3	1,488.5	1.0	0.6
10/05/2019 16:00	9.4	13.3	7.3	117.0	3,226,998.5	1,932.3	1.1	0.8
10/05/2019 17:00	9.4	13.2	7.2	126.7	3,229,263.8	2,004.4	1.3	1.0
10/05/2019 18:00	9.2	13.2	7.0	128.9	3,239,735.9	2,010.9	1.3	1.0
10/05/2019 19:00	9.2	13.2	7.0	131.7	3,224,198.2	2,024.8	1.3	1.0
10/05/2019 20:00	9.3	13.2	7.1	135.9	3,237,193.3	2,056.6	1.4	1.0
10/05/2019 21:00	9.3	13.1	7.0	135.9	3,205,853.6	2,060.1	1.4	1.0
10/05/2019 22:00	9.2	13.2	7.0	130.8	3,238,529.4	2,033.8	1.3	1.0
10/05/2019 23:00	9.2	13.2	7.0	133.2	3,248,720.5	2,040.2	1.3	1.0
Average/Sum#:	8.8	13.5	6.9	113.4	3,066,639.1	1,792.4	1.2	0.8
Minimum:	7.7	13.1	6.4	84.4	2,485,207.6	1,252.2	1.0	0.5
Maximum:	9.4	14.0	7.3	135.9	3,379,973.2	2,077.2	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/06/2019 00:00	9.2	13.2	7.0	129.7	3,221,013.5	2,022.8	1.3	1.0
10/06/2019 01:00	9.1	13.3	7.1	122.0	3,220,592.7	1,975.5	1.2	1.0
10/06/2019 02:00	9.1	13.3	7.1	122.9	3,262,859.8	1,977.6	1.2	1.0
10/06/2019 03:00	9.1	13.3	7.1	122.2	3,262,859.8	1,977.6	1.2	1.0
10/06/2019 04:00	9.1	13.2	7.0	125.1	3,265,262.0	2,002.9	1.2	1.0
10/06/2019 05:00	9.2	13.2	7.0	129.1	3,263,741.1	2,025.8	1.3	1.0
10/06/2019 06:00	9.1	13.3	7.1	128.0	3,299,805.6	1,951.8	1.2	1.0
10/06/2019 07:00	8.1	13.9	6.8	92.8	2,902,397.2	1,483.6	1.0	0.6
10/06/2019 08:00	8.0	14.0	6.8	83.1	2,623,539.3	1,321.9	1.0	0.5
10/06/2019 09:00	8.1	14.0	6.9	84.7	2,469,727.1	1,244.4	1.1	0.5
10/06/2019 10:00	7.8	14.0	6.7	84.2	2,580,868.8	1,300.4	1.0	0.5
10/06/2019 11:00	7.8	14.0	6.7	86.0	2,641,004.4	1,330.7	1.0	0.5
10/06/2019 12:00	7.8	14.0	6.7	86.6	2,707,094.0	1,364.0	1.0	0.5
10/06/2019 13:00	7.8	14.0	6.7	86.0	2,653,110.9	1,336.8	1.0	0.5
10/06/2019 14:00	8.3	13.8	6.9	96.6	3,004,247.1	1,557.6	1.0	0.6
10/06/2019 15:00	9.6	13.2	7.4	122.0	3,202,985.8	1,964.7	1.2	1.0
10/06/2019 16:00	9.4	13.2	7.2	133.2	3,187,610.7	2,025.1	1.3	1.0
10/06/2019 17:00	9.4	13.1	7.1	140.7	3,164,739.8	2,079.9	1.4	1.0
10/06/2019 18:00	9.3	13.1	7.0	146.3	3,198,214.6	2,101.9	1.5	1.3
10/06/2019 19:00	9.2	13.1	7.0	135.5	3,203,519.4	2,058.6	1.4	1.0
10/06/2019 20:00	9.1	13.2	7.0	133.6	3,222,082.4	2,047.0	1.3	1.0
10/06/2019 21:00	9.1	13.2	7.0	133.3	3,226,804.6	2,050.0	1.3	1.0
10/06/2019 22:00	9.0	13.2	6.9	127.1	3,255,041.2	2,020.4	1.3	1.0
10/06/2019 23:00	8.9	13.3	6.9	124.2	3,274,717.6	2,008.7	1.2	1.0
Average/Sum#:	8.8	13.5	7.0	115.6	3,054,743.3	1,801.2	1.2	0.9
Minimum:	7.8	13.1	6.7	83.1	2,469,727.1	1,244.4	1.0	0.5
Maximum:	9.6	14.0	7.4	146.3	3,299,805.6	2,101.9	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/07/2019 00:00	9.0	13.3	7.0	124.3	3,265,914.1	2,003.3	1.2	1.0
10/07/2019 01:00	9.0	13.2	6.9	127.6	3,255,524.5	2,020.7	1.3	1.0
10/07/2019 02:00	9.0	13.2	6.9	123.4	3,254,502.3	1,996.3	1.2	1.0
10/07/2019 03:00	9.0	13.2	6.9	125.5	3,288,248.8	2,017.0	1.2	1.0
10/07/2019 04:00	9.0	13.2	6.9	130.4	3,265,599.4	2,050.8	1.3	1.0
10/07/2019 05:00	9.0	13.2	6.9	130.1	3,248,561.3	2,040.1	1.3	1.0
10/07/2019 06:00	9.1	13.2	7.0	133.7	3,299,185.0	2,047.8	1.3	1.0
10/07/2019 07:00	9.2	13.2	7.0	126.5	3,269,379.9	2,029.3	1.2	1.0
10/07/2019 08:00	9.1	13.2	7.0	127.6	3,242,474.7	2,012.6	1.3	1.0
10/07/2019 09:00	9.1	13.2	7.0	128.8	3,214,484.9	2,018.7	1.3	1.0
10/07/2019 10:00	9.1	13.2	7.0	127.5	3,217,180.6	1,996.9	1.3	1.0
10/07/2019 11:00	9.1	13.2	7.0	125.5	3,191,242.1	1,980.8	1.3	1.0
10/07/2019 12:00	9.2	13.2	7.0	126.5	3,188,342.2	1,979.0	1.3	1.0
10/07/2019 13:00	9.3	13.2	7.1	131.1	3,179,930.8	1,997.0	1.3	1.0
10/07/2019 14:00	9.3	13.2	7.1	131.0	3,179,134.6	1,996.5	1.3	1.0
10/07/2019 15:00	9.4	13.1	7.1	130.9	3,134,093.0	1,991.1	1.3	1.0
10/07/2019 16:00	9.4	13.1	7.1	137.7	3,168,972.5	2,036.4	1.4	1.0
10/07/2019 17:00	9.5	13.0	7.1	143.0	3,153,480.0	2,072.5	1.5	1.2
10/07/2019 18:00	9.3	13.1	7.0	141.8	3,158,196.9	2,075.6	1.5	1.2
10/07/2019 19:00	9.1	13.1	6.9	134.6	3,173,485.4	2,039.3	1.4	1.0
10/07/2019 20:00	9.0	13.1	6.8	130.8	3,163,059.1	2,032.6	1.3	1.0
10/07/2019 21:00	8.9	13.2	6.8	124.4	3,223,463.9	2,000.8	1.2	1.0
10/07/2019 22:00	8.9	13.2	6.8	127.1	3,211,618.7	2,016.9	1.3	1.0
10/07/2019 23:00	8.7	13.3	6.8	117.7	3,241,411.0	1,964.6	1.2	1.0
Average/Sum#:	9.1	13.2	7.0	129.5	3,216,145.2	2,017.4	1.3	1.0
Minimum:	8.7	13.0	6.8	117.7	3,134,093.0	1,964.6	1.2	1.0
Maximum:	9.5	13.3	7.1	143.0	3,299,185.0	2,075.6	1.5	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/08/2019 00:00	8.7	13.3	6.8	113.6	3,240,463.8	1,916.7	1.1	0.8
10/08/2019 01:00	8.7	13.4	6.8	109.0	3,222,134.2	1,858.8	1.1	0.7
10/08/2019 02:00	8.7	13.4	6.8	108.3	3,271,168.6	1,863.2	1.0	0.7
10/08/2019 03:00	8.8	13.3	6.8	113.3	3,232,855.9	1,912.2	1.1	0.8
10/08/2019 04:00	8.7	13.3	6.8	114.1	3,217,813.3	1,926.8	1.1	0.8
10/08/2019 05:00	8.7	13.2	6.7	121.9	3,235,708.2	2,008.4	1.2	1.0
10/08/2019 06:00	9.0	13.2	6.9	134.6	3,258,907.8	2,022.8	1.3	1.0
10/08/2019 07:00	8.9	13.2	6.8	121.1	3,250,915.7	1,994.1	1.2	1.0
10/08/2019 08:00	8.8	13.2	6.7	120.8	3,249,937.5	1,993.5	1.2	1.0
10/08/2019 09:00	8.8	13.2	6.7	122.7	3,216,697.3	1,996.6	1.2	1.0
10/08/2019 10:00	8.9	13.2	6.8	125.9	3,188,370.3	2,002.3	1.3	1.0
10/08/2019 11:00	9.0	13.1	6.8	129.7	3,167,620.3	2,012.4	1.3	1.0
10/08/2019 12:00	9.1	13.1	6.9	132.8	3,163,681.6	2,033.0	1.4	1.0
10/08/2019 13:00	9.1	13.1	6.9	129.3	3,171,491.3	1,991.7	1.3	1.0
10/08/2019 14:00	9.1	13.2	7.0	124.9	3,167,881.4	1,966.3	1.3	1.0
10/08/2019 15:00	9.2	13.1	7.0	128.2	3,129,056.0	1,987.9	1.3	1.0
10/08/2019 16:00	9.2	13.1	7.0	133.7	3,149,987.3	2,024.2	1.4	1.0
10/08/2019 17:00	9.2	13.0	6.9	138.6	3,131,569.2	2,058.1	1.4	1.0
10/08/2019 18:00	9.0	13.1	6.8	134.0	3,148,752.9	2,046.4	1.4	1.0
10/08/2019 19:00	9.0	13.1	6.8	132.4	3,172,862.9	2,038.9	1.3	1.0
10/08/2019 20:00	8.9	13.1	6.7	131.9	3,171,773.6	2,038.2	1.3	1.0
10/08/2019 21:00	8.7	13.2	6.7	130.3	3,165,101.8	2,010.8	1.3	1.0
10/08/2019 22:00	8.6	13.3	6.7	127.7	3,149,187.0	1,931.7	1.3	1.0
10/08/2019 23:00	8.8	13.3	6.8	131.5	3,150,965.0	1,955.8	1.3	1.0
Average/Sum#:	8.9	13.2	6.8	125.4	3,192,704.3	1,983.0	1.3	1.0
Minimum:	8.6	13.0	6.7	108.3	3,129,056.0	1,858.8	1.0	0.7
Maximum:	9.2	13.4	7.0	138.6	3,271,168.6	2,058.1	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/09/2019 00:00	8.8	13.3	6.8	136.8	3,166,270.3	1,965.3	1.4	1.0
10/09/2019 01:00	8.7	13.4	6.8	128.9	3,198,704.9	1,892.0	1.3	0.9
10/09/2019 02:00	8.9	13.4	7.0	131.7	3,199,610.0	1,915.9	1.3	1.0
10/09/2019 03:00	8.9	13.3	6.9	136.7	3,216,843.1	1,973.2	1.4	1.0
10/09/2019 04:00	8.8	13.3	6.8	135.3	3,219,758.4	1,998.5	1.4	1.0
10/09/2019 05:00	8.7	13.3	6.8	131.0	3,208,480.8	1,991.5	1.3	1.0
10/09/2019 06:00	9.1	13.2	7.0	146.6	3,207,916.0	2,038.0	1.5	1.2
10/09/2019 07:00	9.1	13.3	7.1	137.9	3,232,486.0	2,006.4	1.4	1.0
10/09/2019 08:00	9.0	13.3	7.0	138.5	3,219,125.5	1,974.6	1.4	1.0
10/09/2019 09:00	9.1	13.3	7.1	145.7	3,212,025.2	1,993.7	1.5	1.2
10/09/2019 10:00	9.2	13.3	7.1	147.1	3,220,241.7	1,998.8	1.5	1.2
10/09/2019 11:00	7.1	13.9	6.0	97.8	3,188,802.5	1,630.0	1.0	0.7
10/09/2019 12:00	7.4	13.9	6.2	96.4	3,204,453.1	1,614.6	0.9	0.5
10/09/2019 13:00	7.6	13.9	6.4	94.3	3,093,708.3	1,558.8	1.0	0.6
10/09/2019 14:00	7.7	14.0	6.6	90.3	2,943,270.1	1,483.0	1.0	0.6
10/09/2019 15:00	8.2	13.9	6.9	91.8	2,917,460.8	1,491.3	1.0	0.6
10/09/2019 16:00	9.7	13.4	7.6	137.1	3,181,406.6	1,905.0	1.4	1.0
10/09/2019 17:00	9.0	13.3	7.0	126.0	3,283,813.7	1,990.3	1.2	1.0
10/09/2019 18:00	8.9	13.3	6.9	122.2	3,265,664.7	1,979.3	1.2	1.0
10/09/2019 19:00	9.4	13.3	7.3	138.2	3,261,209.9	1,976.6	1.4	1.0
10/09/2019 20:00	9.3	13.3	7.2	143.2	3,224,342.3	1,977.8	1.4	1.0
10/09/2019 21:00	9.1	13.3	7.1	141.7	3,249,495.6	1,969.5	1.4	1.0
10/09/2019 22:00	9.0	13.3	7.0	139.7	3,262,364.9	1,977.3	1.4	1.0
10/09/2019 23:00	8.9	13.4	7.0	137.0	3,248,835.6	1,969.1	1.4	1.0
Average/Sum#:	8.7	13.4	6.9	128.0	3,192,762.1	1,886.3	1.3	0.9
Minimum:	7.1	13.2	6.0	90.3	2,917,460.8	1,483.0	0.9	0.5
Maximum:	9.7	14.0	7.6	147.1	3,283,813.7	2,038.0	1.5	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/10/2019 00:00	8.8	13.4	6.9	136.1	3,249,660.6	1,969.6	1.4	1.0
10/10/2019 01:00	8.6	13.5	6.9	122.0	3,289,076.5	1,873.4	1.2	0.9
10/10/2019 02:00	8.8	13.4	6.9	125.3	3,270,527.8	1,910.6	1.2	1.0
10/10/2019 03:00	8.8	13.4	6.9	129.3	3,275,095.3	1,961.1	1.3	1.0
10/10/2019 04:00	8.8	13.4	6.9	130.1	3,275,095.3	1,961.1	1.3	1.0
10/10/2019 05:00	8.7	13.4	6.8	127.8	3,309,442.3	1,957.5	1.2	1.0
10/10/2019 06:00	9.1	13.3	7.1	133.4	3,319,017.1	1,987.4	1.3	1.0
10/10/2019 07:00	9.1	13.4	7.2	129.0	3,249,815.2	1,898.5	1.3	0.9
10/10/2019 08:00	7.5	13.9	6.3	90.0	2,890,080.9	1,456.2	1.0	0.6
10/10/2019 09:00	7.7	13.9	6.5	96.4	3,146,500.6	1,585.4	1.0	0.6
10/10/2019 10:00	7.7	13.9	6.5	98.4	3,220,132.0	1,622.5	1.0	0.6
10/10/2019 11:00	7.7	13.9	6.5	98.1	3,197,109.8	1,610.9	1.0	0.6
10/10/2019 12:00	7.8	14.0	6.7	98.5	3,215,170.3	1,620.0	1.0	0.6
10/10/2019 13:00	7.8	13.9	6.6	97.0	3,145,111.3	1,584.7	1.0	0.6
10/10/2019 14:00	7.9	13.9	6.7	97.9	3,185,003.3	1,604.8	1.0	0.6
10/10/2019 15:00	8.6	13.9	7.2	93.8	2,928,025.0	1,496.7	1.0	0.6
10/10/2019 16:00	9.8	13.4	7.7	145.0	3,163,853.7	1,963.8	1.5	1.2
10/10/2019 17:00	9.3	13.4	7.3	140.2	3,185,215.9	1,953.8	1.4	1.0
10/10/2019 18:00	9.1	13.2	7.0	134.5	3,280,979.7	2,036.5	1.3	1.0
10/10/2019 19:00	9.1	13.2	7.0	126.8	3,262,935.5	2,025.3	1.2	1.0
10/10/2019 20:00	9.1	13.2	7.0	126.1	3,300,312.8	2,024.4	1.2	1.0
10/10/2019 21:00	9.2	13.2	7.0	127.4	3,271,474.3	2,030.6	1.2	1.0
10/10/2019 22:00	9.2	13.2	7.0	132.6	3,255,846.7	2,020.9	1.3	1.0
10/10/2019 23:00	9.2	13.4	7.2	134.6	3,228,167.5	1,933.0	1.3	1.0
Average/Sum#:	8.6	13.5	6.9	119.6	3,213,068.7	1,837.0	1.2	0.9
Minimum:	7.5	13.2	6.3	90.0	2,890,080.9	1,456.2	1.0	0.6
Maximum:	9.8	14.0	7.7	145.0	3,319,017.1	2,036.5	1.5	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/11/2019 00:00	9.0	13.4	7.1	134.0	3,206,290.1	1,919.9	1.3	1.0
10/11/2019 01:00	8.8	13.5	7.0	123.0	3,254,314.2	1,853.6	1.2	0.9
10/11/2019 02:00	8.8	13.5	7.0	121.2	3,253,436.3	1,853.1	1.2	0.9
10/11/2019 03:00	8.9	13.5	7.1	122.7	3,257,298.8	1,855.3	1.2	0.9
10/11/2019 04:00	8.9	13.5	7.1	121.3	3,262,039.1	1,858.0	1.2	0.9
10/11/2019 05:00	7.4	13.8	6.1	102.1	3,226,363.8	1,649.2	1.0	0.7
10/11/2019 06:00	7.6	13.9	6.4	98.4	3,246,528.1	1,635.8	0.9	0.5
10/11/2019 07:00	8.0	14.0	6.8	88.7	2,763,657.2	1,392.5	1.0	0.6
10/11/2019 08:00	8.2	14.0	7.0	81.5	2,459,406.8	1,239.2	1.0	0.5
10/11/2019 09:00	8.1	14.0	6.9	81.5	2,455,040.5	1,237.0	1.0	0.5
10/11/2019 10:00	8.1	14.0	6.9	81.2	2,454,842.1	1,236.9	1.0	0.5
10/11/2019 11:00	8.1	14.0	6.9	84.2	2,458,811.4	1,238.9	1.1	0.5
10/11/2019 12:00	8.1	14.0	6.9	83.6	2,461,788.4	1,240.4	1.1	0.5
10/11/2019 13:00	8.1	14.0	6.9	84.0	2,526,290.3	1,272.9	1.0	0.5
10/11/2019 14:00	8.5	13.8	7.1	100.5	3,171,391.2	1,621.1	1.0	0.6
10/11/2019 15:00	8.6	13.8	7.1	97.4	2,990,745.7	1,550.6	1.0	0.6
10/11/2019 16:00	9.4	13.3	7.3	117.9	3,237,286.2	1,962.1	1.2	1.0
10/11/2019 17:00	9.3	13.1	7.0	138.4	3,240,150.4	2,105.8	1.4	1.1
10/11/2019 18:00	9.1	13.1	6.9	143.8	3,224,467.7	2,142.7	1.4	1.1
10/11/2019 19:00	8.9	13.2	6.8	128.6	3,239,711.8	2,058.2	1.3	1.0
10/11/2019 20:00	8.8	13.3	6.8	125.3	3,250,631.3	2,041.4	1.2	1.0
10/11/2019 21:00	8.8	13.3	6.8	126.6	3,271,331.9	2,054.4	1.2	1.0
10/11/2019 22:00	8.9	13.3	6.9	127.2	3,298,862.8	2,047.6	1.2	1.0
10/11/2019 23:00	8.7	13.3	6.8	130.2	3,300,151.7	2,048.4	1.3	1.0
Average/Sum#:	8.5	13.6	6.9	110.1	3,021,284.9	1,713.1	1.1	0.8
Minimum:	7.4	13.1	6.1	81.2	2,454,842.1	1,236.9	0.9	0.5
Maximum:	9.4	14.0	7.3	143.8	3,300,151.7	2,142.7	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/12/2019 00:00	8.6	13.3	6.7	136.0	3,254,612.2	2,043.9	1.4	1.0
10/12/2019 01:00	8.6	13.4	6.8	130.6	3,263,631.8	2,001.9	1.3	1.0
10/12/2019 02:00	8.6	13.3	6.7	130.8	3,278,304.2	2,010.9	1.3	1.0
10/12/2019 03:00	8.6	13.3	6.7	129.6	3,266,318.8	2,027.4	1.3	1.0
10/12/2019 04:00	8.6	13.3	6.7	131.3	3,236,300.1	2,032.4	1.3	1.0
10/12/2019 05:00	8.6	13.3	6.7	132.3	3,258,593.1	2,046.4	1.3	1.0
10/12/2019 06:00	8.8	13.3	6.8	135.1	3,291,290.7	2,042.9	1.3	1.0
10/12/2019 07:00	15.6	14.6	14.6	143.7	2,483,692.8	1,233.3	1.8	0.9
10/12/2019 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2019 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2019 10:00	24.5	18.2	53.5	161.8	1,756,598.0	282.2	2.2	0.2
10/12/2019 11:00	46.8	16.0	56.4	277.8	1,939,447.3	679.8	4.2	1.1
10/12/2019 12:00	7.3	13.9	6.2	91.9	2,643,187.5	1,331.8	1.1	0.5
10/12/2019 13:00	7.8	14.0	6.7	82.7	2,566,380.7	1,293.1	1.0	0.5
10/12/2019 14:00	8.6	13.9	7.2	97.3	3,082,183.0	1,575.5	1.0	0.6
10/12/2019 15:00	8.2	13.9	6.9	89.0	2,810,495.5	1,416.1	1.0	0.6
10/12/2019 16:00	8.5	13.8	7.1	99.5	3,157,110.1	1,613.8	1.0	0.6
10/12/2019 17:00	8.8	13.6	7.1	106.5	3,185,828.9	1,744.8	1.0	0.7
10/12/2019 18:00	9.2	13.2	7.0	124.5	3,217,351.1	2,020.5	1.2	1.0
10/12/2019 19:00	8.9	13.2	6.8	127.5	3,219,563.9	2,045.4	1.3	1.0
10/12/2019 20:00	8.9	13.2	6.8	125.6	3,248,242.8	2,039.9	1.2	1.0
10/12/2019 21:00	8.8	13.2	6.7	128.3	3,235,461.9	2,055.5	1.3	1.0
10/12/2019 22:00	8.7	13.3	6.8	124.2	3,239,007.1	2,034.1	1.2	1.0
10/12/2019 23:00	8.6	13.3	6.7	128.3	3,289,644.0	2,065.9	1.3	1.0
Average/Sum#:	11.3	13.8	11.5	128.8	2,996,511.2	1,710.8	1.4	0.9
Minimum:	7.3	13.2	6.2	82.7	1,756,598.0	282.2	1.0	0.2
Maximum:	46.8	18.2	56.4	277.8	3,291,290.7	2,065.9	4.2	1.1
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/13/2019 00:00	8.8	13.3	6.8	134.3	3,244,261.9	2,037.4	1.3	1.0
10/13/2019 01:00	8.7	13.3	6.8	136.5	3,244,102.7	2,037.3	1.4	1.0
10/13/2019 02:00	8.7	13.3	6.8	133.8	3,247,605.8	2,039.5	1.3	1.0
10/13/2019 03:00	8.7	13.3	6.8	136.3	3,256,841.5	2,045.3	1.4	1.0
10/13/2019 04:00	8.7	13.3	6.8	134.7	3,255,408.4	2,044.4	1.3	1.0
10/13/2019 05:00	8.6	13.3	6.7	132.3	3,250,790.6	2,041.5	1.3	1.0
10/13/2019 06:00	8.7	13.4	6.8	134.7	3,261,869.9	1,977.0	1.3	1.0
10/13/2019 07:00	7.7	13.9	6.5	91.1	2,903,571.0	1,484.2	1.0	0.6
10/13/2019 08:00	7.8	13.9	6.6	96.5	3,121,113.8	1,595.4	1.0	0.6
10/13/2019 09:00	7.8	13.9	6.6	98.3	3,169,434.9	1,620.1	1.0	0.6
10/13/2019 10:00	7.9	13.9	6.7	98.0	3,161,609.6	1,616.1	1.0	0.6
10/13/2019 11:00	8.1	13.9	6.8	92.0	2,966,292.3	1,494.6	1.0	0.6
10/13/2019 12:00	8.2	13.8	6.8	99.0	3,177,064.6	1,624.0	1.0	0.6
10/13/2019 13:00	8.1	13.9	6.8	93.3	3,006,184.2	1,514.7	1.0	0.6
10/13/2019 14:00	9.0	13.8	7.5	100.7	3,107,436.1	1,611.1	1.0	0.6
10/13/2019 15:00	8.4	13.8	7.0	93.7	2,965,782.0	1,516.0	1.0	0.6
10/13/2019 16:00	9.5	13.2	7.3	120.5	3,190,432.8	1,957.0	1.2	1.0
10/13/2019 17:00	9.4	13.1	7.1	133.5	3,179,398.8	2,043.1	1.4	1.0
10/13/2019 18:00	9.0	13.2	6.9	127.8	3,210,822.5	2,016.4	1.3	1.0
10/13/2019 19:00	8.9	13.2	6.8	125.4	3,192,032.7	2,004.6	1.3	1.0
10/13/2019 20:00	8.9	13.2	6.8	123.7	3,231,036.0	2,005.5	1.2	1.0
10/13/2019 21:00	8.9	13.2	6.8	127.6	3,227,542.2	2,026.9	1.3	1.0
10/13/2019 22:00	8.3	13.4	6.5	112.9	3,130,781.5	1,806.1	1.2	0.9
10/13/2019 23:00	16.5	15.2	17.1	134.3	2,240,661.6	949.0	1.8	0.7
Average/Sum#:	8.9	13.6	7.3	117.1	3,122,586.6	1,796.1	1.2	0.8
Minimum:	7.7	13.1	6.5	91.1	2,240,661.6	949.0	1.0	0.6
Maximum:	16.5	15.2	17.1	136.5	3,261,869.9	2,045.3	1.8	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/14/2019 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2019 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2019 02:00	42.0	16.4	55.1	259.8	1,909,869.3	599.7	3.9	0.9
10/14/2019 03:00	7.4	13.9	6.2	101.5	2,894,963.1	1,479.8	1.1	0.6
10/14/2019 04:00	9.4	13.4	7.4	127.3	3,237,686.7	1,938.7	1.3	1.0
10/14/2019 05:00	9.2	13.3	7.1	140.1	3,240,281.0	2,034.9	1.4	1.0
10/14/2019 06:00	7.9	13.8	6.6	100.0	3,207,191.9	1,639.4	1.0	0.7
10/14/2019 07:00	8.1	13.9	6.8	89.0	2,748,826.0	1,405.1	1.0	0.6
10/14/2019 08:00	7.9	13.9	6.7	90.6	2,865,031.4	1,464.5	1.0	0.6
10/14/2019 09:00	8.1	13.9	6.8	84.5	2,500,489.5	1,259.9	1.1	0.5
10/14/2019 10:00	8.1	14.0	6.9	85.8	2,486,596.8	1,252.9	1.1	0.5
10/14/2019 11:00	8.1	13.9	6.8	86.2	2,608,852.7	1,314.5	1.0	0.5
10/14/2019 12:00	8.2	13.9	6.9	88.9	948,572.1	1,447.7	3.2	1.7
10/14/2019 13:00	8.3	13.8	6.9	95.6	2,970,509.7	1,561.8	1.0	0.6
10/14/2019 14:00	9.3	13.3	7.2	115.4	3,350,582.8	1,932.9	1.1	0.8
10/14/2019 15:00	9.2	13.3	7.1	129.0	3,205,419.7	1,989.6	1.3	1.0
10/14/2019 16:00	9.2	13.2	7.0	131.6	3,187,490.9	2,048.3	1.3	1.0
10/14/2019 17:00	9.1	13.1	6.9	140.7	3,211,452.3	2,110.6	1.4	1.1
10/14/2019 18:00	9.0	13.1	6.8	144.3	3,227,176.5	2,144.5	1.5	1.3
10/14/2019 19:00	8.9	13.1	6.7	144.4	3,228,079.4	2,145.1	1.5	1.3
10/14/2019 20:00	8.8	13.2	6.7	133.3	3,215,377.7	2,089.7	1.3	1.0
10/14/2019 21:00	8.7	13.2	6.7	124.8	3,249,357.4	2,040.6	1.2	1.0
10/14/2019 22:00	8.7	13.3	6.8	123.9	3,279,852.0	2,035.8	1.2	1.0
10/14/2019 23:00	8.7	13.2	6.7	123.6	3,284,685.2	2,038.8	1.2	1.0
Average/Sum#:	10.1	13.6	9.0	120.9	3,005,227.2	1,726.1	1.3	0.9
Minimum:	7.4	13.1	6.2	84.5	1,909,869.3	599.7	1.0	0.5
Maximum:	42.0	16.4	55.1	259.8	3,350,582.8	2,145.1	3.9	1.3
%SI	8.33	8.33	8.33	8.33	12.50	8.33	12.50	12.50

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/15/2019 00:00	8.7	13.3	6.8	123.9	3,297,573.9	2,046.8	1.2	1.0
10/15/2019 01:00	8.7	13.3	6.8	123.2	3,275,663.1	2,033.2	1.2	1.0
10/15/2019 02:00	8.6	13.3	6.7	122.9	3,292,740.7	2,043.8	1.2	1.0
10/15/2019 03:00	8.7	13.3	6.8	122.8	3,278,240.9	2,034.8	1.2	1.0
10/15/2019 04:00	8.7	13.3	6.8	129.3	3,276,146.5	2,033.5	1.3	1.0
10/15/2019 05:00	7.9	13.6	6.4	114.9	3,138,264.2	1,787.5	1.2	0.9
10/15/2019 06:00	7.7	13.9	6.5	99.8	3,279,967.0	1,676.6	1.0	0.7
10/15/2019 07:00	8.7	13.7	7.1	105.8	3,207,414.0	1,733.2	1.0	0.7
10/15/2019 08:00	7.7	13.9	6.5	90.6	2,887,333.5	1,475.9	1.0	0.6
10/15/2019 09:00	7.9	13.9	6.7	84.7	2,600,318.6	1,310.2	1.0	0.5
10/15/2019 10:00	7.9	13.9	6.7	86.0	2,555,266.5	1,287.5	1.1	0.5
10/15/2019 11:00	8.7	13.9	7.3	86.1	2,618,379.1	1,319.3	1.0	0.5
10/15/2019 12:00	8.4	13.9	7.1	86.8	2,781,717.7	1,401.6	1.0	0.6
10/15/2019 13:00	8.9	13.9	7.5	100.6	3,171,195.6	1,621.0	1.0	0.6
10/15/2019 14:00	9.0	13.8	7.5	101.4	3,130,581.3	1,623.1	1.0	0.6
10/15/2019 15:00	9.7	13.4	7.6	130.5	3,167,427.9	1,873.5	1.3	0.9
10/15/2019 16:00	10.1	13.1	7.6	155.1	3,180,676.2	2,113.6	1.6	1.3
10/15/2019 17:00	9.9	13.1	7.5	157.5	3,189,554.9	2,119.5	1.6	1.3
10/15/2019 18:00	9.9	13.1	7.5	156.7	3,195,724.9	2,123.6	1.6	1.3
10/15/2019 19:00	9.8	13.1	7.4	155.8	3,196,778.3	2,124.3	1.6	1.3
10/15/2019 20:00	9.8	13.1	7.4	157.2	3,240,210.3	2,129.5	1.6	1.3
10/15/2019 21:00	9.7	13.1	7.3	156.7	3,244,318.5	2,132.2	1.6	1.3
10/15/2019 22:00	9.7	13.1	7.3	153.7	3,240,362.4	2,129.6	1.5	1.3
10/15/2019 23:00	9.6	13.1	7.3	156.0	3,238,080.0	2,128.1	1.6	1.3
Average/Sum#:	8.9	13.5	7.1	123.3	3,111,830.7	1,845.9	1.3	0.9
Minimum:	7.7	13.1	6.4	84.7	2,555,266.5	1,287.5	1.0	0.5
Maximum:	10.1	13.9	7.6	157.5	3,297,573.9	2,132.2	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/16/2019 00:00	9.6	13.1	7.3	155.7	3,240,514.6	2,129.7	1.6	1.3
10/16/2019 01:00	9.5	13.1	7.2	152.0	3,250,100.5	2,136.0	1.5	1.3
10/16/2019 02:00	9.4	13.1	7.1	152.9	3,238,232.2	2,128.2	1.5	1.3
10/16/2019 03:00	9.6	13.2	7.4	159.4	3,218,147.3	2,115.0	1.6	1.3
10/16/2019 04:00	9.5	13.1	7.2	157.3	3,258,164.9	2,141.3	1.6	1.3
10/16/2019 05:00	9.5	13.1	7.2	153.4	3,262,425.4	2,144.1	1.5	1.3
10/16/2019 06:00	9.6	13.1	7.3	159.7	3,256,034.7	2,139.9	1.6	1.3
10/16/2019 07:00	9.7	13.1	7.3	157.7	3,240,210.3	2,129.5	1.6	1.3
10/16/2019 08:00	9.6	13.1	7.3	160.5	3,231,537.2	2,123.8	1.6	1.3
10/16/2019 09:00	9.7	13.1	7.3	160.3	3,209,474.3	2,109.3	1.6	1.3
10/16/2019 10:00	9.7	13.1	7.3	161.7	3,199,431.8	2,102.7	1.6	1.3
10/16/2019 11:00	9.6	13.1	7.3	150.2	3,223,994.3	2,095.3	1.5	1.3
10/16/2019 12:00	9.7	13.1	7.3	151.1	3,220,916.9	2,093.3	1.5	1.3
10/16/2019 13:00	9.8	13.1	7.4	153.9	3,198,975.4	2,102.4	1.6	1.3
10/16/2019 14:00	9.8	13.1	7.4	152.2	3,204,757.4	2,106.2	1.5	1.3
10/16/2019 15:00	9.8	13.0	7.3	153.3	3,170,744.2	2,107.0	1.6	1.3
10/16/2019 16:00	9.8	13.0	7.3	153.9	3,167,433.5	2,104.8	1.6	1.3
10/16/2019 17:00	9.8	13.0	7.3	153.3	3,202,018.5	2,104.4	1.6	1.3
10/16/2019 18:00	9.7	13.1	7.3	146.7	3,183,759.5	2,092.4	1.5	1.3
10/16/2019 19:00	9.7	13.1	7.3	148.3	3,207,838.2	2,084.8	1.5	1.3
10/16/2019 20:00	9.6	13.1	7.3	145.0	3,186,912.1	2,071.2	1.5	1.2
10/16/2019 21:00	8.5	13.7	7.0	100.9	3,016,157.2	1,585.8	1.0	0.6
10/16/2019 22:00	8.1	13.9	6.8	88.1	2,749,412.9	1,405.4	1.0	0.6
10/16/2019 23:00	8.1	13.8	6.7	98.4	3,132,264.8	1,601.1	1.0	0.6
Average/Sum#:	9.5	13.2	7.2	146.9	3,186,227.4	2,039.7	1.5	1.2
Minimum:	8.1	13.0	6.7	88.1	2,749,412.9	1,405.4	1.0	0.6
Maximum:	9.8	13.9	7.4	161.7	3,262,425.4	2,144.1	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/17/2019 00:00	7.9	13.8	6.6	96.8	3,085,900.0	1,577.4	1.0	0.6
10/17/2019 01:00	8.2	13.8	6.8	100.2	3,156,619.6	1,636.6	1.0	0.7
10/17/2019 02:00	9.1	13.3	7.1	111.5	3,258,545.3	1,903.6	1.1	0.8
10/17/2019 03:00	8.9	13.3	6.9	113.8	3,227,499.5	1,932.6	1.1	0.8
10/17/2019 04:00	8.8	13.3	6.8	118.2	3,218,310.3	1,974.1	1.2	1.0
10/17/2019 05:00	8.6	13.3	6.7	115.0	3,268,749.2	1,957.3	1.1	0.8
10/17/2019 06:00	9.0	13.2	6.9	129.4	3,241,830.3	2,012.2	1.3	1.0
10/17/2019 07:00	9.0	13.3	7.0	121.0	3,197,769.0	1,961.5	1.2	1.0
10/17/2019 08:00	8.0	13.7	6.6	94.0	2,894,050.2	1,521.6	1.0	0.6
10/17/2019 09:00	7.9	13.8	6.6	90.0	2,887,333.5	1,475.9	1.0	0.6
10/17/2019 10:00	7.9	13.9	6.7	91.3	2,915,308.9	1,490.2	1.0	0.6
10/17/2019 11:00	8.0	13.9	6.7	94.0	3,002,365.1	1,534.7	1.0	0.6
10/17/2019 12:00	8.0	13.9	6.7	83.3	2,606,074.1	1,313.1	1.0	0.5
10/17/2019 13:00	7.9	13.9	6.7	89.2	2,867,183.4	1,465.6	1.0	0.6
10/17/2019 14:00	8.0	13.9	6.7	94.6	3,050,881.9	1,559.5	1.0	0.6
10/17/2019 15:00	8.6	13.8	7.1	93.4	2,920,004.1	1,492.6	1.0	0.6
10/17/2019 16:00	9.2	13.3	7.1	115.4	3,226,330.4	1,931.9	1.1	0.8
10/17/2019 17:00	9.1	13.1	6.9	137.4	3,237,996.3	2,104.4	1.4	1.1
10/17/2019 18:00	8.8	13.2	6.7	130.3	3,254,350.5	2,067.5	1.3	1.0
10/17/2019 19:00	8.8	13.2	6.7	126.4	3,257,956.2	2,046.0	1.2	1.0
10/17/2019 20:00	8.7	13.2	6.7	126.6	3,283,752.3	2,062.2	1.2	1.0
10/17/2019 21:00	8.8	13.2	6.7	134.3	3,245,535.8	2,038.2	1.3	1.0
10/17/2019 22:00	8.5	13.3	6.6	124.0	3,237,451.2	1,962.2	1.2	1.0
10/17/2019 23:00	8.5	13.4	6.7	117.9	3,259,568.2	1,928.0	1.2	1.0
Average/Sum#:	8.5	13.5	6.8	110.3	3,116,723.6	1,789.5	1.1	0.8
Minimum:	7.9	13.1	6.6	83.3	2,606,074.1	1,313.1	1.0	0.5
Maximum:	9.2	13.9	7.1	137.4	3,283,752.3	2,104.4	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/18/2019 00:00	8.5	13.4	6.7	116.2	3,264,194.2	1,906.9	1.1	0.8
10/18/2019 01:00	8.6	13.4	6.8	116.0	3,257,860.6	1,903.2	1.1	0.8
10/18/2019 02:00	8.5	13.5	6.8	110.3	3,267,130.6	1,860.9	1.1	0.7
10/18/2019 03:00	8.5	13.4	6.7	112.9	3,299,619.4	1,903.5	1.1	0.8
10/18/2019 04:00	8.6	13.3	6.7	119.2	3,282,610.5	1,965.6	1.2	1.0
10/18/2019 05:00	8.6	13.3	6.7	119.1	3,260,733.1	1,952.5	1.2	1.0
10/18/2019 06:00	8.9	13.3	6.9	128.8	3,271,131.0	2,006.5	1.3	1.0
10/18/2019 07:00	8.6	13.5	6.9	110.2	3,251,329.5	1,851.9	1.1	0.7
10/18/2019 08:00	7.6	13.8	6.3	93.2	2,995,322.4	1,531.1	1.0	0.6
10/18/2019 09:00	7.7	13.9	6.5	90.0	2,892,419.9	1,478.5	1.0	0.6
10/18/2019 10:00	8.0	13.8	6.6	91.6	2,907,679.2	1,486.3	1.0	0.6
10/18/2019 11:00	8.0	13.8	6.6	92.1	2,926,851.2	1,496.1	1.0	0.6
10/18/2019 12:00	8.1	13.9	6.8	89.7	2,839,012.4	1,451.2	1.0	0.6
10/18/2019 13:00	8.2	13.8	6.8	96.5	3,017,555.6	1,564.5	1.0	0.6
10/18/2019 14:00	8.4	13.8	7.0	96.9	3,014,855.3	1,563.1	1.0	0.6
10/18/2019 15:00	8.6	13.8	7.1	97.6	3,046,101.3	1,579.3	1.0	0.6
10/18/2019 16:00	9.5	13.2	7.3	120.3	3,222,875.1	1,976.9	1.2	1.0
10/18/2019 17:00	9.1	13.2	7.0	127.6	3,197,999.4	2,031.7	1.3	1.0
10/18/2019 18:00	8.8	13.2	6.7	118.7	3,201,844.6	1,964.0	1.2	1.0
10/18/2019 19:00	8.8	13.2	6.7	119.2	3,213,093.5	1,970.9	1.2	1.0
10/18/2019 20:00	8.9	13.2	6.8	126.6	3,224,039.0	2,024.7	1.3	1.0
10/18/2019 21:00	8.7	13.2	6.7	125.9	3,247,605.8	2,039.5	1.2	1.0
10/18/2019 22:00	8.6	13.3	6.7	118.9	3,240,155.9	1,987.5	1.2	1.0
10/18/2019 23:00	8.5	13.2	6.5	122.8	3,274,052.0	2,032.2	1.2	1.0
Average/Sum#:	8.5	13.5	6.8	110.8	3,150,669.6	1,813.7	1.1	0.8
Minimum:	7.6	13.2	6.3	89.7	2,839,012.4	1,451.2	1.0	0.6
Maximum:	9.5	13.9	7.3	128.8	3,299,619.4	2,039.5	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/19/2019 00:00	8.5	13.3	6.6	120.4	3,270,119.4	1,982.0	1.2	1.0
10/19/2019 01:00	8.7	13.3	6.8	121.0	3,272,924.3	1,983.7	1.2	1.0
10/19/2019 02:00	8.8	13.2	6.7	126.8	3,235,981.7	2,032.2	1.3	1.0
10/19/2019 03:00	8.7	13.2	6.7	120.7	3,246,677.0	1,991.5	1.2	1.0
10/19/2019 04:00	8.7	13.3	6.8	117.3	3,280,105.4	1,964.1	1.1	0.8
10/19/2019 05:00	8.8	13.3	6.8	120.6	3,297,012.9	1,998.3	1.2	1.0
10/19/2019 06:00	9.0	13.2	6.9	125.5	3,310,542.2	2,006.5	1.2	1.0
10/19/2019 07:00	15.1	14.7	14.4	134.7	2,525,609.8	1,161.9	1.6	0.7
10/19/2019 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2019 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2019 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2019 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2019 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2019 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2019 14:00	35.1	17.5	60.9	77.0	1,781,576.9	403.3	0.9	0.1
10/19/2019 15:00	38.1	15.6	42.4	258.7	2,111,810.4	801.9	3.7	1.1
10/19/2019 16:00	8.7	13.5	6.9	114.7	3,038,343.7	1,708.4	1.2	0.9
10/19/2019 17:00	9.7	13.1	7.3	131.9	3,171,425.8	1,968.5	1.3	1.0
10/19/2019 18:00	9.3	13.3	7.2	116.3	3,228,589.2	1,886.1	1.1	0.8
10/19/2019 19:00	9.3	13.3	7.2	113.0	3,239,122.0	1,868.6	1.1	0.7
10/19/2019 20:00	9.4	13.2	7.2	123.0	3,218,982.3	1,927.5	1.2	1.0
10/19/2019 21:00	9.4	13.2	7.2	124.0	3,252,716.9	1,947.7	1.2	1.0
10/19/2019 22:00	8.2	13.7	6.7	96.3	2,890,798.6	1,541.0	1.0	0.6
10/19/2019 23:00	8.1	13.8	6.7	84.0	2,668,421.2	1,364.0	1.0	0.5
Average/Sum#:	12.3	13.8	12.3	123.7	3,002,264.4	1,696.5	1.3	0.8
Minimum:	8.1	13.1	6.6	77.0	1,781,576.9	403.3	0.9	0.1
Maximum:	38.1	17.5	60.9	258.7	3,310,542.2	2,032.2	3.7	1.1
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/20/2019 00:00	8.0	13.8	6.6	87.4	2,814,754.0	1,438.8	1.0	0.6
10/20/2019 01:00	8.0	13.9	6.7	82.4	2,633,207.5	1,346.0	1.0	0.5
10/20/2019 02:00	26.4	16.6	36.2	192.4	1,328,633.0	456.0	4.5	0.8
10/20/2019 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2019 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2019 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2019 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2019 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2019 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2019 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2019 10:00	41.3	17.4	69.6	65.5	1,809,654.0	449.3	0.8	0.1
10/20/2019 11:00	34.3	15.3	36.1	228.9	2,333,001.2	937.0	3.0	1.1
10/20/2019 12:00	7.6	13.9	6.4	84.3	2,632,073.4	1,326.2	1.0	0.5
10/20/2019 13:00	8.0	13.9	6.7	83.5	2,613,615.9	1,316.9	1.0	0.5
10/20/2019 14:00	8.2	13.9	6.9	94.7	3,107,601.0	1,565.8	0.9	0.5
10/20/2019 15:00	8.1	13.9	6.8	90.3	2,941,086.9	1,481.9	1.0	0.6
10/20/2019 16:00	8.1	13.8	6.7	94.9	3,048,534.3	1,558.3	1.0	0.6
10/20/2019 17:00	8.2	13.8	6.8	99.5	3,176,293.1	1,646.8	1.0	0.7
10/20/2019 18:00	9.1	13.5	7.3	108.1	3,223,192.5	1,788.8	1.0	0.7
10/20/2019 19:00	9.1	13.3	7.1	118.1	3,243,253.4	1,989.4	1.2	1.0
10/20/2019 20:00	8.9	13.3	6.9	119.4	3,262,001.5	2,000.9	1.2	1.0
10/20/2019 21:00	8.8	13.3	6.8	116.9	3,259,560.0	1,975.6	1.1	0.8
10/20/2019 22:00	8.8	13.3	6.8	117.6	3,265,169.7	1,979.0	1.1	0.8
10/20/2019 23:00	8.9	13.3	6.9	119.2	3,240,645.0	1,987.8	1.2	1.0
Average/Sum#:	12.9	14.1	14.0	111.9	2,819,545.7	1,485.0	1.4	0.7
Minimum:	7.6	13.3	6.4	65.5	1,328,633.0	449.3	0.8	0.1
Maximum:	41.3	17.4	69.6	228.9	3,265,169.7	2,000.9	4.5	1.1
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/21/2019 00:00	8.7	13.3	6.8	115.9	3,264,471.0	1,930.9	1.1	0.8
10/21/2019 01:00	8.8	13.4	6.9	120.3	3,221,153.4	1,928.8	1.2	1.0
10/21/2019 02:00	8.7	13.4	6.8	119.2	3,252,298.4	1,923.7	1.2	1.0
10/21/2019 03:00	8.7	13.4	6.8	120.6	3,258,215.6	1,927.2	1.2	1.0
10/21/2019 04:00	8.7	13.3	6.8	121.2	3,266,403.2	2,003.6	1.2	1.0
10/21/2019 05:00	8.8	13.2	6.7	122.9	3,280,335.3	2,036.1	1.2	1.0
10/21/2019 06:00	8.8	13.1	6.7	136.6	3,298,266.5	2,095.4	1.3	1.0
10/21/2019 07:00	9.0	13.3	7.0	120.9	3,196,368.5	1,937.3	1.2	1.0
10/21/2019 08:00	8.3	13.9	7.0	84.2	2,498,504.9	1,258.9	1.1	0.5
10/21/2019 09:00	8.2	14.0	7.0	86.1	2,489,772.3	1,254.5	1.1	0.5
10/21/2019 10:00	7.9	13.9	6.7	87.1	2,777,351.4	1,399.4	1.0	0.6
10/21/2019 11:00	7.8	13.9	6.6	88.0	2,896,630.3	1,459.5	0.9	0.4
10/21/2019 12:00	8.4	13.8	7.0	95.8	3,102,920.0	1,586.1	1.0	0.6
10/21/2019 13:00	9.0	13.6	7.3	106.5	3,297,650.0	1,733.8	1.0	0.7
10/21/2019 14:00	9.1	13.6	7.4	106.6	3,292,704.9	1,731.2	1.0	0.7
10/21/2019 15:00	9.1	13.6	7.4	106.7	3,290,422.5	1,730.0	1.0	0.7
10/21/2019 16:00	9.0	13.6	7.3	106.7	3,293,846.0	1,731.8	1.0	0.7
10/21/2019 17:00	9.0	13.6	7.3	106.8	3,303,355.9	1,736.8	1.0	0.7
10/21/2019 18:00	9.0	13.6	7.3	106.9	3,301,644.2	1,735.9	1.0	0.7
10/21/2019 19:00	8.9	13.6	7.2	106.8	3,308,301.1	1,739.4	1.0	0.7
10/21/2019 20:00	9.3	13.3	7.2	116.1	3,273,926.3	1,960.4	1.1	0.8
10/21/2019 21:00	9.1	13.2	7.0	122.0	3,235,224.8	2,008.1	1.2	1.0
10/21/2019 22:00	9.1	13.2	7.0	121.3	3,262,979.6	2,001.5	1.2	1.0
10/21/2019 23:00	8.9	13.3	6.9	117.5	3,250,485.5	1,970.1	1.2	1.0
Average/Sum#:	8.8	13.5	7.0	110.1	3,163,051.3	1,784.2	1.1	0.8
Minimum:	7.8	13.1	6.6	84.2	2,489,772.3	1,254.5	0.9	0.4
Maximum:	9.3	14.0	7.4	136.6	3,308,301.1	2,095.4	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/22/2019 00:00	8.8	13.3	6.8	112.8	3,261,935.1	1,929.4	1.1	0.8
10/22/2019 01:00	8.9	13.3	6.9	117.7	3,229,837.5	1,934.0	1.2	1.0
10/22/2019 02:00	8.7	13.4	6.8	121.2	3,211,968.2	1,923.3	1.2	1.0
10/22/2019 03:00	8.6	13.4	6.8	122.0	3,187,789.0	1,932.1	1.2	1.0
10/22/2019 04:00	8.6	13.3	6.7	117.9	3,292,704.9	1,947.6	1.1	0.8
10/22/2019 05:00	8.8	13.3	6.8	127.2	3,261,512.4	2,000.6	1.3	1.0
10/22/2019 06:00	9.0	13.2	6.9	135.2	3,273,568.7	2,031.9	1.3	1.0
10/22/2019 07:00	9.0	13.3	7.0	118.0	3,313,172.0	1,983.9	1.1	0.8
10/22/2019 08:00	9.0	13.2	6.9	123.5	3,255,846.7	2,020.9	1.2	1.0
10/22/2019 09:00	9.0	13.2	6.9	121.6	3,238,124.8	2,009.9	1.2	1.0
10/22/2019 10:00	9.0	13.2	6.9	123.3	3,248,274.6	2,016.2	1.2	1.0
10/22/2019 11:00	9.0	13.2	6.9	125.5	3,229,134.5	2,027.9	1.2	1.0
10/22/2019 12:00	9.1	13.1	6.9	129.1	3,208,860.4	2,038.6	1.3	1.0
10/22/2019 13:00	9.2	13.1	7.0	132.5	3,203,830.6	2,058.8	1.3	1.0
10/22/2019 14:00	9.2	13.1	7.0	134.3	3,175,987.5	2,064.1	1.4	1.0
10/22/2019 15:00	9.2	13.1	7.0	134.7	3,206,009.2	2,060.2	1.4	1.0
10/22/2019 16:00	9.2	13.1	7.0	133.8	3,208,032.2	2,061.5	1.3	1.0
10/22/2019 17:00	9.2	13.1	7.0	141.6	3,208,561.3	2,108.7	1.4	1.1
10/22/2019 18:00	9.0	13.2	6.9	127.7	3,203,823.4	2,035.4	1.3	1.0
10/22/2019 19:00	9.1	13.1	6.9	130.6	3,195,894.2	2,053.7	1.3	1.0
10/22/2019 20:00	9.0	13.2	6.9	123.8	3,203,975.4	2,012.1	1.2	1.0
10/22/2019 21:00	9.0	13.1	6.8	126.0	3,194,536.5	2,029.5	1.3	1.0
10/22/2019 22:00	9.0	13.2	6.9	122.8	3,194,898.9	2,006.4	1.2	1.0
10/22/2019 23:00	8.9	13.2	6.8	119.1	3,230,048.3	1,981.3	1.2	1.0
Average/Sum#:	9.0	13.2	6.9	125.9	3,226,596.9	2,011.2	1.2	1.0
Minimum:	8.6	13.1	6.7	112.8	3,175,987.5	1,923.3	1.1	0.8
Maximum:	9.2	13.4	7.0	141.6	3,313,172.0	2,108.7	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/23/2019 00:00	8.9	13.2	6.8	119.1	3,224,668.4	1,978.0	1.2	1.0
10/23/2019 01:00	8.9	13.2	6.8	118.3	3,222,875.1	1,976.9	1.2	1.0
10/23/2019 02:00	8.9	13.2	6.8	116.9	3,237,616.2	1,962.3	1.2	1.0
10/23/2019 03:00	8.9	13.2	6.8	117.5	3,250,485.5	1,970.1	1.2	1.0
10/23/2019 04:00	8.8	13.3	6.8	115.6	3,258,729.0	1,951.3	1.1	0.8
10/23/2019 05:00	9.0	13.2	6.9	125.8	3,236,618.6	2,032.6	1.2	1.0
10/23/2019 06:00	9.0	13.2	6.9	128.9	3,237,873.5	1,986.1	1.3	1.0
10/23/2019 07:00	8.3	13.9	7.0	86.7	2,607,775.3	1,333.0	1.0	0.5
10/23/2019 08:00	8.2	14.0	7.0	84.0	2,484,810.6	1,252.0	1.1	0.5
10/23/2019 09:00	8.1	14.0	6.9	84.9	2,485,604.5	1,252.4	1.1	0.5
10/23/2019 10:00	7.9	13.9	6.7	87.2	2,751,947.6	1,386.6	1.0	0.6
10/23/2019 11:00	7.9	13.9	6.7	89.1	2,924,018.8	1,473.3	0.9	0.4
10/23/2019 12:00	8.3	13.8	6.9	95.4	3,082,769.9	1,575.8	1.0	0.6
10/23/2019 13:00	9.0	13.6	7.3	106.8	3,300,503.0	1,735.3	1.0	0.7
10/23/2019 14:00	9.1	13.6	7.4	106.9	3,297,269.6	1,733.6	1.0	0.7
10/23/2019 15:00	9.1	13.6	7.4	107.0	3,293,846.0	1,731.8	1.0	0.7
10/23/2019 16:00	9.1	13.6	7.4	107.0	3,297,840.2	1,733.9	1.0	0.7
10/23/2019 17:00	9.1	13.6	7.4	107.2	3,304,116.7	1,737.2	1.0	0.7
10/23/2019 18:00	8.5	13.8	7.1	104.3	3,281,989.5	1,701.6	1.0	0.7
10/23/2019 19:00	9.2	13.4	7.2	112.5	3,241,028.8	1,869.7	1.1	0.7
10/23/2019 20:00	9.3	13.2	7.1	128.8	3,267,032.6	2,051.7	1.3	1.0
10/23/2019 21:00	9.3	13.1	7.0	134.0	3,276,544.6	2,081.6	1.3	1.0
10/23/2019 22:00	9.1	13.1	6.9	133.4	3,264,424.4	2,073.9	1.3	1.0
10/23/2019 23:00	9.0	13.2	6.9	125.4	3,265,835.5	2,027.1	1.2	1.0
Average/Sum#:	8.8	13.5	7.0	110.1	3,129,009.3	1,775.3	1.1	0.8
Minimum:	7.9	13.1	6.7	84.0	2,484,810.6	1,252.0	0.9	0.4
Maximum:	9.3	14.0	7.4	134.0	3,304,116.7	2,081.6	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/24/2019 00:00	9.0	13.3	7.0	122.2	3,267,544.4	2,004.3	1.2	1.0
10/24/2019 01:00	9.0	13.3	7.0	122.9	3,264,014.8	1,978.3	1.2	1.0
10/24/2019 02:00	8.9	13.4	7.0	122.3	3,283,879.7	1,918.4	1.2	1.0
10/24/2019 03:00	9.1	13.2	7.0	122.2	3,300,801.8	2,024.7	1.2	1.0
10/24/2019 04:00	9.0	13.2	6.9	122.4	3,306,996.9	2,028.5	1.2	1.0
10/24/2019 05:00	9.1	13.2	7.0	122.1	3,280,951.9	2,084.4	1.2	1.0
10/24/2019 06:00	9.2	13.2	7.0	127.8	3,338,334.4	2,072.1	1.2	1.0
10/24/2019 07:00	9.5	13.1	7.2	144.0	3,287,080.1	2,136.3	1.4	1.1
10/24/2019 08:00	9.3	13.1	7.0	145.0	3,280,156.1	2,131.8	1.4	1.1
10/24/2019 09:00	9.3	13.1	7.0	143.4	3,275,232.3	2,128.6	1.4	1.1
10/24/2019 10:00	9.3	13.1	7.0	143.6	3,238,993.0	2,128.7	1.4	1.1
10/24/2019 11:00	9.2	13.1	7.0	145.4	3,239,145.1	2,128.8	1.5	1.3
10/24/2019 12:00	9.2	13.1	7.0	145.1	3,224,842.3	2,119.4	1.5	1.3
10/24/2019 13:00	9.3	13.1	7.0	144.5	3,215,560.6	2,113.3	1.5	1.3
10/24/2019 14:00	9.3	13.1	7.0	142.9	3,209,626.4	2,109.4	1.4	1.1
10/24/2019 15:00	9.2	13.1	7.0	139.6	3,219,070.5	2,092.1	1.4	1.0
10/24/2019 16:00	9.2	13.1	7.0	139.9	3,235,688.2	2,102.9	1.4	1.1
10/24/2019 17:00	9.1	13.1	6.9	133.9	3,231,063.5	2,076.3	1.3	1.0
10/24/2019 18:00	9.1	13.1	6.9	133.7	3,222,348.9	2,070.7	1.3	1.0
10/24/2019 19:00	9.3	13.1	7.0	144.5	3,224,081.5	2,118.9	1.5	1.3
10/24/2019 20:00	9.4	13.1	7.1	144.3	3,246,459.0	2,109.9	1.4	1.1
10/24/2019 21:00	9.4	13.1	7.1	142.0	3,237,842.4	2,104.3	1.4	1.1
10/24/2019 22:00	9.3	13.2	7.1	151.0	3,215,993.2	2,090.1	1.5	1.3
10/24/2019 23:00	9.3	13.2	7.1	143.5	3,230,907.8	2,076.2	1.4	1.0
Average/Sum#:	9.2	13.2	7.0	137.0	3,253,192.3	2,081.2	1.4	1.1
Minimum:	8.9	13.1	6.9	122.1	3,209,626.4	1,918.4	1.2	1.0
Maximum:	9.5	13.4	7.2	151.0	3,338,334.4	2,136.3	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/25/2019 00:00	9.1	13.3	7.1	146.7	3,160,222.2	2,007.7	1.5	1.2
10/25/2019 01:00	8.8	13.3	6.8	133.4	3,193,041.2	1,958.6	1.4	1.0
10/25/2019 02:00	8.9	13.3	6.9	138.3	3,180,770.1	1,974.3	1.4	1.0
10/25/2019 03:00	8.8	13.3	6.8	134.9	3,212,115.3	1,970.3	1.4	1.0
10/25/2019 04:00	8.7	13.3	6.8	132.1	3,269,989.8	2,005.8	1.3	1.0
10/25/2019 05:00	8.6	13.3	6.7	127.7	3,289,258.4	1,993.6	1.2	1.0
10/25/2019 06:00	9.0	13.2	6.9	140.2	3,281,624.2	2,036.9	1.4	1.0
10/25/2019 07:00	9.1	13.3	7.1	127.3	3,287,113.5	1,992.3	1.2	1.0
10/25/2019 08:00	8.6	13.5	6.9	109.1	3,343,502.3	1,904.4	1.0	0.8
10/25/2019 09:00	8.8	13.4	6.9	110.7	3,341,922.2	1,903.5	1.0	0.8
10/25/2019 10:00	9.0	13.4	7.1	113.8	3,286,618.5	1,920.0	1.1	0.8
10/25/2019 11:00	9.0	13.4	7.1	114.3	3,265,734.8	1,907.8	1.1	0.8
10/25/2019 12:00	9.3	13.2	7.1	125.6	3,243,280.3	2,013.1	1.2	1.0
10/25/2019 13:00	9.3	13.2	7.1	127.1	3,244,085.8	2,013.6	1.3	1.0
10/25/2019 14:00	9.3	13.2	7.1	126.7	3,240,702.5	2,011.5	1.3	1.0
10/25/2019 15:00	9.3	13.2	7.1	127.0	3,242,152.5	2,012.4	1.3	1.0
10/25/2019 16:00	9.4	13.1	7.1	136.4	3,210,210.9	2,062.9	1.4	1.0
10/25/2019 17:00	9.3	13.1	7.0	133.5	3,202,430.0	2,057.9	1.3	1.0
10/25/2019 18:00	9.1	13.2	7.0	124.1	3,223,141.7	2,000.6	1.2	1.0
10/25/2019 19:00	9.1	13.2	7.0	122.9	3,222,175.0	2,000.0	1.2	1.0
10/25/2019 20:00	9.1	13.3	7.1	137.6	3,147,128.3	1,976.4	1.4	1.0
10/25/2019 21:00	8.8	13.3	6.8	140.5	3,147,787.2	1,999.8	1.5	1.2
10/25/2019 22:00	8.6	13.3	6.7	133.4	3,188,825.5	1,979.3	1.4	1.0
10/25/2019 23:00	8.7	13.3	6.8	134.3	3,210,575.2	1,992.8	1.4	1.0
Average/Sum#:	9.0	13.3	7.0	129.1	3,234,767.0	1,987.3	1.3	1.0
Minimum:	8.6	13.1	6.7	109.1	3,147,128.3	1,903.5	1.0	0.8
Maximum:	9.4	13.5	7.1	146.7	3,343,502.3	2,062.9	1.5	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/26/2019 00:00	8.7	13.3	6.8	132.2	3,213,745.6	1,971.3	1.3	1.0
10/26/2019 01:00	8.8	13.3	6.8	137.3	3,216,858.4	1,996.7	1.4	1.0
10/26/2019 02:00	8.8	13.3	6.8	134.1	3,215,408.5	1,995.8	1.3	1.0
10/26/2019 03:00	8.7	13.3	6.8	132.2	3,206,225.3	1,990.1	1.3	1.0
10/26/2019 04:00	8.7	13.3	6.8	133.6	3,210,897.4	1,993.0	1.3	1.0
10/26/2019 05:00	8.4	13.4	6.6	117.2	3,271,909.9	1,935.3	1.1	0.8
10/26/2019 06:00	8.6	13.4	6.8	121.4	3,248,240.8	1,921.3	1.2	1.0
10/26/2019 07:00	7.9	13.8	6.6	92.4	2,896,723.8	1,480.7	1.0	0.6
10/26/2019 08:00	7.9	13.9	6.7	96.6	3,086,878.2	1,577.9	1.0	0.6
10/26/2019 09:00	7.8	13.9	6.6	96.7	3,088,638.9	1,578.8	1.0	0.6
10/26/2019 10:00	7.8	13.9	6.6	90.0	2,871,682.9	1,467.9	1.0	0.6
10/26/2019 11:00	8.1	13.8	6.7	89.3	2,793,430.1	1,427.9	1.0	0.6
10/26/2019 12:00	8.1	13.9	6.8	93.9	3,028,015.6	1,525.7	1.0	0.6
10/26/2019 13:00	8.3	13.8	6.9	98.3	3,099,789.9	1,584.5	1.0	0.6
10/26/2019 14:00	7.7	13.9	6.5	89.9	2,922,629.5	1,472.6	1.0	0.6
10/26/2019 15:00	8.2	13.9	6.9	93.1	2,905,918.5	1,485.4	1.0	0.6
10/26/2019 16:00	9.2	13.3	7.1	115.3	3,202,143.2	1,940.8	1.1	0.8
10/26/2019 17:00	9.3	13.2	7.1	126.6	3,188,051.8	2,002.1	1.3	1.0
10/26/2019 18:00	9.1	13.2	7.0	124.3	3,219,436.2	1,998.3	1.2	1.0
10/26/2019 19:00	9.0	13.2	6.9	123.5	3,214,602.9	1,995.3	1.2	1.0
10/26/2019 20:00	9.1	13.2	7.0	124.9	3,234,580.4	2,007.7	1.2	1.0
10/26/2019 21:00	9.1	13.2	7.0	125.2	3,278,467.2	2,011.0	1.2	1.0
10/26/2019 22:00	15.3	14.8	14.8	138.4	2,417,560.7	1,147.5	1.8	0.8
10/26/2019 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	8.8	13.6	7.2	114.2	3,088,340.7	1,761.2	1.2	0.8
Minimum:	7.7	13.2	6.5	89.3	2,417,560.7	1,147.5	1.0	0.6
Maximum:	15.3	14.8	14.8	138.4	3,278,467.2	2,011.0	1.8	1.0
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/27/2019 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2019 17:00	37.3	17.7	68.8	0.0	1,916,721.9	405.9	-0.2	0.0
10/27/2019 18:00	50.1	16.2	62.9	171.0	1,863,608.0	626.0	2.7	0.6
10/27/2019 19:00	42.1	15.1	42.8	243.9	2,128,510.5	901.5	3.6	1.3
10/27/2019 20:00	7.5	13.9	6.3	90.8	2,873,608.1	1,447.9	1.0	0.6
10/27/2019 21:00	7.8	13.9	6.6	81.6	2,660,057.2	1,340.3	1.0	0.5
10/27/2019 22:00	7.9	13.9	6.7	81.8	2,663,232.7	1,341.9	1.0	0.5
10/27/2019 23:00	7.8	13.9	6.6	81.9	2,667,202.1	1,343.9	1.0	0.5
Average/Sum#:	22.9	14.9	28.7	107.3	2,396,134.4	1,058.2	1.4	0.6
Minimum:	7.5	13.9	6.3	0.0	1,863,608.0	405.9	-0.2	0.0
Maximum:	50.1	17.7	68.8	243.9	2,873,608.1	1,447.9	3.6	1.3
%SI	70.83	70.83	70.83	70.83	70.83	70.83	70.83	70.83

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/28/2019 00:00	7.9	13.9	6.7	93.4	3,021,537.1	1,544.5	1.0	0.6
10/28/2019 01:00	7.8	13.9	6.6	96.7	3,072,401.4	1,570.5	1.0	0.6
10/28/2019 02:00	7.9	13.9	6.7	82.5	2,646,363.0	1,333.4	1.0	0.5
10/28/2019 03:00	8.1	13.9	6.8	95.0	3,057,533.4	1,562.9	1.0	0.6
10/28/2019 04:00	9.3	13.5	7.4	116.2	3,326,487.8	1,919.0	1.1	0.8
10/28/2019 05:00	9.1	13.4	7.2	125.0	3,320,600.5	1,964.1	1.2	1.0
10/28/2019 06:00	9.6	13.2	7.4	155.5	3,279,927.0	2,107.7	1.5	1.3
10/28/2019 07:00	9.4	13.3	7.3	133.1	3,294,117.8	2,020.6	1.3	1.0
10/28/2019 08:00	9.2	13.4	7.2	131.3	3,305,656.9	1,979.4	1.3	1.0
10/28/2019 09:00	9.3	13.4	7.3	135.3	3,309,497.9	1,981.7	1.3	1.0
10/28/2019 10:00	9.1	13.3	7.1	127.4	3,294,467.7	1,972.7	1.2	1.0
10/28/2019 11:00	9.1	13.3	7.1	118.5	3,342,764.9	1,952.8	1.1	0.8
10/28/2019 12:00	9.2	13.3	7.1	122.1	3,303,819.8	1,978.3	1.2	1.0
10/28/2019 13:00	9.2	13.3	7.1	122.2	3,312,654.5	1,959.4	1.2	1.0
10/28/2019 14:00	9.2	13.3	7.1	122.7	3,306,992.9	1,980.2	1.2	1.0
10/28/2019 15:00	9.3	13.3	7.2	126.0	3,305,757.5	2,003.6	1.2	1.0
10/28/2019 16:00	9.3	13.2	7.1	133.3	3,315,295.9	2,057.8	1.3	1.0
10/28/2019 17:00	9.4	13.1	7.1	145.9	3,259,077.9	2,141.9	1.4	1.1
10/28/2019 18:00	9.2	13.2	7.0	136.3	3,297,479.5	2,094.9	1.3	1.0
10/28/2019 19:00	9.1	13.2	7.0	133.7	3,316,077.1	2,082.5	1.3	1.0
10/28/2019 20:00	9.1	13.2	7.0	138.9	3,292,669.5	2,067.8	1.4	1.0
10/28/2019 21:00	8.9	13.3	6.9	139.7	3,259,707.7	2,047.1	1.4	1.0
10/28/2019 22:00	8.3	13.4	6.5	119.4	3,245,873.9	1,919.9	1.2	1.0
10/28/2019 23:00	24.1	16.0	29.0	178.1	1,601,173.1	608.0	3.5	0.8
Average/Sum#:	9.6	13.5	8.0	126.2	3,170,330.6	1,868.8	1.3	0.9
Minimum:	7.8	13.1	6.5	82.5	1,601,173.1	608.0	1.0	0.5
Maximum:	24.1	16.0	29.0	178.1	3,342,764.9	2,141.9	3.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/29/2019 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2019 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/30/2019 00:00	38.2	17.6	68.3	0.0	1,901,788.1	444.4	-0.1	0.0
10/30/2019 01:00	50.6	16.0	60.9	222.2	1,881,700.9	673.3	3.6	0.9
10/30/2019 02:00	37.4	15.0	37.4	228.7	2,297,847.7	990.0	3.1	1.2
10/30/2019 03:00	8.5	13.7	7.0	117.1	3,303,416.8	1,809.2	1.1	0.7
10/30/2019 04:00	9.8	13.2	7.5	170.5	3,240,458.1	2,106.0	1.7	1.5
10/30/2019 05:00	7.5	13.9	6.3	117.7	3,234,189.1	1,653.2	1.2	0.8
10/30/2019 06:00	7.6	13.9	6.4	93.5	2,948,827.2	1,485.8	1.0	0.6
10/30/2019 07:00	7.8	13.9	6.6	101.5	3,342,178.0	1,708.4	0.9	0.5
10/30/2019 08:00	7.8	13.9	6.6	101.7	3,354,307.2	1,714.6	0.9	0.5
10/30/2019 09:00	9.5	13.5	7.6	122.8	3,329,261.4	1,920.6	1.2	1.0
10/30/2019 10:00	9.7	13.4	7.6	146.3	3,328,691.2	2,017.5	1.4	1.0
10/30/2019 11:00	9.8	13.3	7.6	160.0	3,266,077.2	2,051.1	1.6	1.2
10/30/2019 12:00	9.8	13.3	7.6	166.5	3,266,785.5	2,075.4	1.7	1.5
10/30/2019 13:00	9.6	13.3	7.5	157.9	3,289,035.2	2,041.5	1.6	1.2
10/30/2019 14:00	9.0	13.3	7.0	123.9	3,337,220.4	1,998.3	1.2	1.0
10/30/2019 15:00	9.2	13.3	7.1	127.0	3,360,433.8	2,012.2	1.2	1.0
10/30/2019 16:00	9.4	13.1	7.1	147.7	3,321,165.4	2,134.2	1.4	1.1
10/30/2019 17:00	9.4	13.2	7.2	144.7	3,305,136.9	2,123.9	1.4	1.1
10/30/2019 18:00	9.3	13.2	7.1	138.6	3,338,529.3	2,096.6	1.3	1.0
10/30/2019 19:00	9.3	13.2	7.1	137.6	3,366,045.1	2,089.3	1.3	1.0
10/30/2019 20:00	9.1	13.3	7.1	130.0	3,349,546.8	2,054.6	1.2	1.0
10/30/2019 21:00	9.5	13.3	7.4	155.5	3,313,845.9	2,056.9	1.5	1.2
10/30/2019 22:00	9.0	13.4	7.1	132.9	3,311,978.2	1,959.0	1.3	1.0
10/30/2019 23:00	8.5	13.5	6.8	119.6	3,377,971.3	1,948.7	1.1	0.8
Average/Sum#:	13.1	13.8	13.2	136.0	3,140,268.2	1,798.5	1.4	1.0
Minimum:	7.5	13.1	6.3	0.0	1,881,700.9	444.4	-0.1	0.0
Maximum:	50.6	17.6	68.3	228.7	3,377,971.3	2,134.2	3.6	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/31/2019 00:00	8.6	13.5	6.9	118.0	3,400,561.7	1,936.9	1.1	0.8
10/31/2019 01:00	8.7	13.4	6.8	123.7	3,363,648.6	1,965.0	1.2	1.0
10/31/2019 02:00	8.7	13.4	6.8	124.2	3,351,323.8	1,957.8	1.2	1.0
10/31/2019 03:00	8.7	13.4	6.8	123.6	3,365,874.0	1,966.3	1.2	1.0
10/31/2019 04:00	8.8	13.4	6.9	130.2	3,374,194.1	1,995.8	1.2	1.0
10/31/2019 05:00	8.9	13.4	7.0	133.0	3,316,151.9	2,009.9	1.3	1.0
10/31/2019 06:00	9.1	13.4	7.2	135.0	3,338,055.4	1,998.8	1.3	1.0
10/31/2019 07:00	9.0	13.4	7.1	122.2	3,366,901.0	1,966.9	1.2	1.0
10/31/2019 08:00	8.7	13.5	6.9	119.6	3,360,463.4	1,938.6	1.1	0.8
10/31/2019 09:00	9.0	13.4	7.1	133.1	3,316,543.0	1,961.7	1.3	1.0
10/31/2019 10:00	9.0	13.4	7.1	126.9	3,336,431.3	1,949.1	1.2	1.0
10/31/2019 11:00	8.9	13.4	7.0	116.4	3,376,684.5	1,923.3	1.1	0.8
10/31/2019 12:00	9.0	13.4	7.1	119.4	3,331,809.5	1,946.4	1.1	0.8
10/31/2019 13:00	9.1	13.4	7.2	118.6	3,331,809.5	1,946.4	1.1	0.8
10/31/2019 14:00	9.1	13.4	7.2	119.8	3,344,476.7	1,953.8	1.1	0.8
10/31/2019 15:00	9.1	13.3	7.1	119.8	3,311,640.1	1,958.8	1.1	0.8
10/31/2019 16:00	9.1	13.3	7.1	122.3	3,327,363.1	1,968.1	1.2	1.0
10/31/2019 17:00	9.0	13.4	7.1	117.6	3,332,151.9	1,946.6	1.1	0.8
10/31/2019 18:00	9.0	13.3	7.0	120.4	3,339,366.7	1,975.2	1.1	0.8
10/31/2019 19:00	9.1	13.2	7.0	131.4	3,336,884.5	2,071.2	1.3	1.0
10/31/2019 20:00	9.1	13.2	7.0	129.6	3,324,479.1	2,063.5	1.2	1.0
10/31/2019 21:00	8.9	13.2	6.8	131.3	3,338,334.4	2,072.1	1.3	1.0
10/31/2019 22:00	9.3	13.3	7.2	153.2	3,288,370.1	2,065.1	1.5	1.2
10/31/2019 23:00	8.7	13.3	6.8	133.5	3,310,784.8	2,055.0	1.3	1.0
Average/Sum#:	8.9	13.4	7.0	126.0	3,341,012.6	1,983.0	1.2	0.9
Minimum:	8.6	13.2	6.8	116.4	3,288,370.1	1,923.3	1.1	0.8
Maximum:	9.3	13.5	7.2	153.2	3,400,561.7	2,072.1	1.5	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/01/2019 00:00	8.8	13.3	6.8	138.1	3,324,603.7	2,039.3	1.3	1.0
11/01/2019 01:00	8.6	13.3	6.7	128.5	3,312,852.1	2,007.9	1.2	1.0
11/01/2019 02:00	8.7	13.3	6.8	131.9	3,321,180.2	2,037.2	1.3	1.0
11/01/2019 03:00	8.7	13.3	6.8	132.0	3,321,343.2	2,037.3	1.3	1.0
11/01/2019 04:00	8.6	13.4	6.8	127.1	3,341,896.5	2,001.1	1.2	1.0
11/01/2019 05:00	8.6	13.2	6.6	135.6	3,364,595.2	2,088.4	1.3	1.0
11/01/2019 06:00	9.0	13.2	6.9	140.3	3,362,733.0	2,111.8	1.3	1.1
11/01/2019 07:00	9.1	13.2	7.0	141.4	3,355,408.2	2,107.2	1.4	1.1
11/01/2019 08:00	8.9	13.2	6.8	140.0	3,335,822.3	2,094.9	1.4	1.0
11/01/2019 09:00	7.7	13.7	6.3	108.9	3,261,820.8	1,762.6	1.1	0.7
11/01/2019 10:00	7.3	13.9	6.2	97.4	3,242,601.3	1,657.5	0.9	0.5
11/01/2019 11:00	7.5	13.9	6.3	81.9	2,631,478.0	1,325.9	1.0	0.5
11/01/2019 12:00	7.5	13.9	6.3	90.0	2,965,586.3	1,515.9	0.9	0.5
11/01/2019 13:00	7.6	13.9	6.4	93.2	3,096,288.4	1,560.1	0.9	0.5
11/01/2019 14:00	8.2	13.9	6.9	93.1	2,975,172.3	1,520.8	1.0	0.6
11/01/2019 15:00	9.2	13.3	7.1	118.3	3,311,640.1	1,958.8	1.1	0.8
11/01/2019 16:00	9.1	13.3	7.1	128.5	3,240,318.9	1,987.6	1.3	1.0
11/01/2019 17:00	9.4	13.1	7.1	146.1	3,277,848.1	2,130.3	1.4	1.1
11/01/2019 18:00	9.3	13.1	7.0	151.4	3,294,987.2	2,165.5	1.5	1.3
11/01/2019 19:00	9.0	13.2	6.9	132.0	3,314,803.2	2,081.7	1.3	1.0
11/01/2019 20:00	9.1	13.1	6.9	138.1	3,334,312.3	2,118.3	1.3	1.1
11/01/2019 21:00	8.9	13.2	6.8	126.9	3,338,950.1	2,048.1	1.2	1.0
11/01/2019 22:00	8.9	13.3	6.9	124.1	3,376,132.1	2,021.6	1.2	1.0
11/01/2019 23:00	8.9	13.3	6.9	124.1	3,370,433.9	2,042.8	1.2	1.0
Average/Sum#:	8.6	13.4	6.8	123.7	3,253,033.6	1,934.3	1.2	0.9
Minimum:	7.3	13.1	6.2	81.9	2,631,478.0	1,325.9	0.9	0.5
Maximum:	9.4	13.9	7.1	151.4	3,376,132.1	2,165.5	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/02/2019 00:00	9.0	13.3	7.0	136.5	3,317,712.5	2,059.3	1.3	1.0
11/02/2019 01:00	8.9	13.2	6.8	140.8	3,284,230.0	2,062.5	1.4	1.0
11/02/2019 02:00	8.9	13.2	6.8	142.0	3,304,930.6	2,075.5	1.4	1.0
11/02/2019 03:00	8.9	13.2	6.8	140.8	3,299,038.9	2,071.8	1.4	1.0
11/02/2019 04:00	8.9	13.2	6.8	144.2	3,306,841.4	2,076.7	1.4	1.0
11/02/2019 05:00	8.9	13.3	6.9	137.1	3,291,935.1	2,043.3	1.3	1.0
11/02/2019 06:00	9.4	13.2	7.2	163.0	3,275,540.0	2,128.8	1.6	1.3
11/02/2019 07:00	9.2	13.2	7.0	139.4	3,297,765.0	2,071.0	1.4	1.0
11/02/2019 08:00	8.6	13.4	6.8	119.7	3,285,405.1	1,895.3	1.2	0.9
11/02/2019 09:00	7.2	13.9	6.1	90.9	3,005,886.5	1,536.5	0.9	0.5
11/02/2019 10:00	7.5	13.9	6.3	90.9	2,985,345.2	1,526.0	1.0	0.6
11/02/2019 11:00	7.6	13.9	6.4	91.2	3,049,053.2	1,536.3	0.9	0.5
11/02/2019 12:00	7.7	13.9	6.5	92.0	3,048,060.8	1,535.8	0.9	0.5
11/02/2019 13:00	21.7	15.8	25.1	157.6	1,894,456.5	733.2	2.5	0.7
11/02/2019 14:00	46.8	16.1	57.5	250.0	1,935,148.8	635.9	3.7	0.9
11/02/2019 15:00	7.6	13.9	6.4	108.8	3,043,496.1	1,533.5	1.1	0.6
11/02/2019 16:00	7.9	13.9	6.7	86.5	2,750,955.3	1,386.1	1.0	0.6
11/02/2019 17:00	8.5	13.7	7.0	102.9	3,231,466.4	1,722.6	1.0	0.7
11/02/2019 18:00	9.4	13.2	7.2	124.8	3,293,139.6	2,020.0	1.2	1.0
11/02/2019 19:00	9.4	13.1	7.1	143.9	3,280,463.8	2,132.0	1.4	1.1
11/02/2019 20:00	9.2	13.1	7.0	140.6	3,261,076.4	2,119.4	1.4	1.1
11/02/2019 21:00	9.0	13.2	6.9	129.6	3,334,306.7	2,069.6	1.2	1.0
11/02/2019 22:00	8.9	13.2	6.8	125.8	3,335,037.5	2,045.7	1.2	1.0
11/02/2019 23:00	8.7	13.3	6.8	120.7	3,342,230.5	2,001.3	1.2	1.0
Average/Sum#:	10.7	13.6	9.7	130.0	3,102,230.1	1,792.4	1.4	0.9
Minimum:	7.2	13.1	6.1	86.5	1,894,456.5	635.9	0.9	0.5
Maximum:	46.8	16.1	57.5	250.0	3,342,230.5	2,132.0	3.7	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/03/2019 00:00	8.9	13.3	6.9	128.8	3,309,664.9	1,981.8	1.2	1.0
11/03/2019 01:00	8.9	13.3	6.9	131.6	3,293,548.1	1,996.2	1.3	1.0
11/03/2019 02:00	8.8	13.3	6.8	127.9	3,317,180.1	1,986.3	1.2	1.0
11/03/2019 03:00	8.8	13.3	6.8	129.9	3,307,902.3	2,004.9	1.3	1.0
11/03/2019 04:00	8.9	13.2	6.8	136.0	3,278,885.3	2,035.2	1.3	1.0
11/03/2019 05:00	9.0	13.2	6.9	145.9	3,283,942.6	2,086.3	1.4	1.0
11/03/2019 06:00	9.1	13.2	7.0	144.2	3,329,634.6	2,066.7	1.4	1.0
11/03/2019 07:00	8.9	13.3	6.9	127.9	3,213,692.5	1,947.8	1.3	1.0
11/03/2019 08:00	7.3	13.9	6.2	96.1	3,162,979.1	1,616.8	1.0	0.6
11/03/2019 09:00	7.6	13.9	6.4	95.4	3,123,852.7	1,596.8	1.0	0.6
11/03/2019 10:00	7.7	13.9	6.5	96.8	3,163,174.7	1,616.9	1.0	0.6
11/03/2019 11:00	7.7	13.9	6.5	96.4	3,142,829.0	1,606.5	1.0	0.6
11/03/2019 12:00	7.6	13.9	6.4	96.6	3,219,933.5	1,622.4	0.9	0.5
11/03/2019 13:00	7.7	13.9	6.5	89.1	2,927,591.2	1,475.1	0.9	0.4
11/03/2019 14:00	7.8	13.9	6.6	87.4	2,877,775.9	1,450.0	0.9	0.4
11/03/2019 15:00	9.1	13.5	7.3	106.2	3,178,686.3	1,764.1	1.0	0.7
11/03/2019 16:00	9.3	13.1	7.0	129.8	3,276,268.2	2,057.5	1.3	1.0
11/03/2019 17:00	9.2	13.1	7.0	135.6	3,259,074.4	2,094.3	1.3	1.0
11/03/2019 18:00	9.0	13.1	6.8	138.6	3,250,921.2	2,112.8	1.4	1.1
11/03/2019 19:00	9.1	13.1	6.9	143.0	3,242,492.6	2,131.0	1.4	1.1
11/03/2019 20:00	8.9	13.1	6.7	133.8	3,256,428.9	2,092.6	1.3	1.0
11/03/2019 21:00	8.8	13.2	6.7	129.9	3,287,096.2	2,064.3	1.3	1.0
11/03/2019 22:00	8.7	13.3	6.8	122.3	3,287,433.7	2,016.5	1.2	1.0
11/03/2019 23:00	8.8	13.3	6.8	134.0	3,285,651.9	2,039.4	1.3	1.0
Average/Sum#:	8.6	13.4	6.8	121.0	3,219,860.0	1,894.3	1.2	0.9
Minimum:	7.3	13.1	6.2	87.4	2,877,775.9	1,450.0	0.9	0.4
Maximum:	9.3	13.9	7.3	145.9	3,329,634.6	2,131.0	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/04/2019 00:00	8.7	13.3	6.8	130.5	3,274,717.6	2,008.7	1.3	1.0
11/04/2019 01:00	8.7	13.3	6.8	130.5	3,279,445.3	2,011.6	1.3	1.0
11/04/2019 02:00	8.6	13.3	6.7	122.9	3,275,095.3	1,961.1	1.2	1.0
11/04/2019 03:00	8.8	13.3	6.8	127.1	3,278,863.9	1,987.3	1.2	1.0
11/04/2019 04:00	8.8	13.3	6.8	130.5	3,272,598.2	2,007.4	1.3	1.0
11/04/2019 05:00	8.9	13.2	6.8	144.8	3,249,270.6	2,088.0	1.4	1.0
11/04/2019 06:00	9.1	13.1	6.9	155.6	3,274,616.8	2,128.2	1.6	1.3
11/04/2019 07:00	9.0	13.3	7.0	127.8	3,286,781.5	2,016.1	1.2	1.0
11/04/2019 08:00	8.8	13.3	6.8	131.7	3,307,975.0	2,029.1	1.3	1.0
11/04/2019 09:00	9.1	13.2	7.0	142.9	3,246,637.6	2,062.6	1.4	1.0
11/04/2019 10:00	9.1	13.2	7.0	143.2	3,227,223.7	2,026.7	1.4	1.0
11/04/2019 11:00	9.0	13.3	7.0	132.3	3,194,182.4	1,959.3	1.3	1.0
11/04/2019 12:00	9.1	13.3	7.1	144.7	3,194,102.8	2,005.9	1.5	1.2
11/04/2019 13:00	9.1	13.2	7.0	144.2	3,134,581.3	2,014.3	1.5	1.2
11/04/2019 14:00	9.0	13.2	6.9	140.9	3,141,018.8	1,995.5	1.5	1.2
11/04/2019 15:00	9.1	13.2	7.0	146.5	3,142,984.6	2,019.7	1.5	1.2
11/04/2019 16:00	9.0	13.2	6.9	148.0	3,188,912.4	2,072.5	1.5	1.2
11/04/2019 17:00	9.0	13.0	6.7	142.0	3,238,080.0	2,128.1	1.4	1.1
11/04/2019 18:00	9.0	13.0	6.7	142.9	3,244,775.0	2,132.5	1.4	1.1
11/04/2019 19:00	8.9	13.1	6.7	138.9	3,280,463.8	2,132.0	1.4	1.1
11/04/2019 20:00	8.9	13.1	6.7	137.7	3,274,463.0	2,128.1	1.4	1.1
11/04/2019 21:00	8.9	13.1	6.7	138.9	3,278,155.8	2,130.5	1.4	1.1
11/04/2019 22:00	8.9	13.1	6.7	138.6	3,274,001.4	2,127.8	1.4	1.1
11/04/2019 23:00	8.6	13.2	6.6	125.7	3,278,656.8	2,059.0	1.2	1.0
Average/Sum#:	8.9	13.2	6.8	137.9	3,243,233.5	2,051.3	1.4	1.1
Minimum:	8.6	13.0	6.6	122.9	3,134,581.3	1,959.3	1.2	1.0
Maximum:	9.1	13.3	7.1	155.6	3,307,975.0	2,132.5	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/05/2019 00:00	8.8	13.2	6.7	129.0	3,308,593.0	2,077.8	1.3	1.0
11/05/2019 01:00	8.7	13.2	6.7	128.0	3,306,204.5	2,076.3	1.2	1.0
11/05/2019 02:00	8.8	13.2	6.7	127.4	3,302,064.4	2,073.7	1.2	1.0
11/05/2019 03:00	8.7	13.2	6.7	127.1	3,297,765.0	2,071.0	1.2	1.0
11/05/2019 04:00	8.8	13.2	6.7	126.7	3,293,624.9	2,068.4	1.2	1.0
11/05/2019 05:00	8.8	13.2	6.7	132.4	3,318,414.4	2,108.2	1.3	1.1
11/05/2019 06:00	9.0	13.1	6.8	139.9	3,321,700.4	2,158.8	1.4	1.1
11/05/2019 07:00	8.8	13.3	6.8	121.8	3,302,292.7	2,001.5	1.2	1.0
11/05/2019 08:00	8.7	13.2	6.7	121.1	3,327,371.3	2,016.7	1.2	1.0
11/05/2019 09:00	8.7	13.3	6.8	116.5	3,334,294.8	1,972.2	1.1	0.8
11/05/2019 10:00	8.8	13.3	6.8	117.6	3,306,157.9	1,979.7	1.1	0.8
11/05/2019 11:00	8.9	13.2	6.8	119.2	3,281,274.4	1,964.8	1.2	1.0
11/05/2019 12:00	8.9	13.2	6.8	119.9	3,258,405.1	1,974.9	1.2	1.0
11/05/2019 13:00	9.1	13.1	6.9	128.2	3,264,385.5	2,026.2	1.3	1.0
11/05/2019 14:00	9.0	13.2	6.9	124.6	3,232,163.8	2,006.2	1.2	1.0
11/05/2019 15:00	9.0	13.1	6.8	127.3	3,250,530.2	2,017.6	1.3	1.0
11/05/2019 16:00	9.1	13.0	6.8	136.0	3,233,708.9	2,078.0	1.4	1.0
11/05/2019 17:00	8.9	13.1	6.7	133.1	3,248,526.5	2,063.8	1.3	1.0
11/05/2019 18:00	9.0	13.1	6.8	133.6	3,255,924.5	2,068.5	1.3	1.0
11/05/2019 19:00	9.0	13.1	6.8	135.3	3,234,487.0	2,078.5	1.4	1.0
11/05/2019 20:00	9.0	13.1	6.8	135.4	3,282,368.6	2,085.3	1.3	1.0
11/05/2019 21:00	8.9	13.1	6.7	131.9	3,264,267.0	2,073.8	1.3	1.0
11/05/2019 22:00	9.1	13.1	6.9	133.4	3,312,255.4	2,080.1	1.3	1.0
11/05/2019 23:00	9.0	13.1	6.8	132.7	3,318,465.6	2,084.0	1.3	1.0
Average/Sum#:	8.9	13.2	6.8	128.3	3,285,635.2	2,050.3	1.3	1.0
Minimum:	8.7	13.0	6.7	116.5	3,232,163.8	1,964.8	1.1	0.8
Maximum:	9.1	13.3	6.9	139.9	3,334,294.8	2,158.8	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/06/2019 00:00	8.9	13.2	6.8	123.5	3,325,391.4	2,015.5	1.2	1.0
11/06/2019 01:00	8.7	13.3	6.8	117.0	3,349,679.7	1,981.3	1.1	0.8
11/06/2019 02:00	9.0	13.2	6.9	126.9	3,341,558.5	2,049.7	1.2	1.0
11/06/2019 03:00	8.8	13.2	6.7	127.3	3,288,411.8	2,017.1	1.2	1.0
11/06/2019 04:00	8.7	13.3	6.8	122.8	3,298,642.7	1,975.2	1.2	1.0
11/06/2019 05:00	8.8	13.2	6.7	129.6	3,298,682.5	2,023.4	1.3	1.0
11/06/2019 06:00	9.1	13.1	6.9	142.1	3,300,470.2	2,096.8	1.4	1.0
11/06/2019 07:00	9.1	13.1	6.9	125.4	3,290,324.0	2,042.3	1.2	1.0
11/06/2019 08:00	8.8	13.2	6.7	120.4	3,312,357.1	2,007.6	1.2	1.0
11/06/2019 09:00	8.7	13.2	6.7	117.4	3,300,312.8	1,976.2	1.1	0.8
11/06/2019 10:00	8.7	13.3	6.8	116.9	3,292,463.6	1,971.5	1.1	0.8
11/06/2019 11:00	8.8	13.2	6.7	120.0	3,277,709.0	1,986.6	1.2	1.0
11/06/2019 12:00	8.9	13.2	6.8	119.9	3,267,479.6	1,980.4	1.2	1.0
11/06/2019 13:00	8.9	13.2	6.8	121.8	3,240,645.0	1,987.8	1.2	1.0
11/06/2019 14:00	8.9	13.2	6.8	123.4	3,260,208.2	1,999.8	1.2	1.0
11/06/2019 15:00	8.9	13.1	6.7	124.2	3,235,385.9	2,008.2	1.2	1.0
11/06/2019 16:00	9.0	13.1	6.8	131.8	3,231,526.7	2,053.0	1.3	1.0
11/06/2019 17:00	9.0	13.0	6.7	136.0	3,244,757.7	2,085.1	1.4	1.0
11/06/2019 18:00	8.9	13.0	6.6	134.1	3,238,066.2	2,080.8	1.3	1.0
11/06/2019 19:00	9.1	13.0	6.8	136.4	3,246,936.3	2,086.5	1.4	1.0
11/06/2019 20:00	8.9	13.1	6.7	134.2	3,240,089.2	2,082.1	1.3	1.0
11/06/2019 21:00	8.8	13.1	6.7	133.7	3,262,964.8	2,096.8	1.3	1.0
11/06/2019 22:00	8.9	13.1	6.7	134.3	3,288,664.8	2,089.3	1.3	1.0
11/06/2019 23:00	8.7	13.1	6.6	128.0	3,286,140.8	2,063.7	1.3	1.0
Average/Sum#:	8.9	13.2	6.8	127.0	3,279,952.9	2,031.5	1.2	1.0
Minimum:	8.7	13.0	6.6	116.9	3,231,526.7	1,971.5	1.1	0.8
Maximum:	9.1	13.3	6.9	142.1	3,349,679.7	2,096.8	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/07/2019 00:00	8.6	13.1	6.5	130.8	3,314,644.0	2,081.6	1.3	1.0
11/07/2019 01:00	8.8	13.1	6.7	136.3	3,276,905.2	2,057.9	1.3	1.0
11/07/2019 02:00	8.7	13.2	6.7	131.4	3,273,729.8	2,032.0	1.3	1.0
11/07/2019 03:00	8.5	13.2	6.5	124.6	3,291,238.3	1,994.8	1.2	1.0
11/07/2019 04:00	8.8	13.2	6.7	131.5	3,287,424.1	2,040.5	1.3	1.0
11/07/2019 05:00	8.7	13.2	6.7	130.8	3,289,518.5	2,041.8	1.3	1.0
11/07/2019 06:00	9.0	13.2	6.9	135.3	3,290,599.4	2,066.5	1.3	1.0
11/07/2019 07:00	9.0	13.2	6.9	128.1	3,295,962.8	2,045.8	1.2	1.0
11/07/2019 08:00	8.9	13.2	6.8	121.0	3,342,731.5	2,001.6	1.2	1.0
11/07/2019 09:00	8.8	13.2	6.7	120.7	3,306,582.4	2,004.1	1.2	1.0
11/07/2019 10:00	8.8	13.2	6.7	119.3	3,300,479.8	1,976.3	1.2	1.0
11/07/2019 11:00	8.9	13.2	6.8	123.5	3,274,880.6	2,008.8	1.2	1.0
11/07/2019 12:00	8.9	13.2	6.8	123.0	3,273,739.4	2,008.1	1.2	1.0
11/07/2019 13:00	8.9	13.2	6.8	123.8	3,268,848.6	2,005.1	1.2	1.0
11/07/2019 14:00	9.0	13.1	6.8	126.2	3,255,363.4	2,020.6	1.2	1.0
11/07/2019 15:00	9.0	13.1	6.8	128.9	3,246,650.4	2,038.9	1.3	1.0
11/07/2019 16:00	9.0	13.0	6.7	134.4	3,243,045.9	2,084.0	1.3	1.0
11/07/2019 17:00	8.8	13.1	6.7	126.8	3,256,682.3	2,045.2	1.3	1.0
11/07/2019 18:00	9.0	13.0	6.7	137.1	3,274,169.2	2,104.0	1.4	1.1
11/07/2019 19:00	8.9	13.0	6.6	137.4	3,279,460.2	2,107.4	1.4	1.1
11/07/2019 20:00	8.8	13.1	6.7	130.3	3,263,165.2	2,073.1	1.3	1.0
11/07/2019 21:00	8.8	13.1	6.7	128.6	3,303,051.6	2,050.2	1.3	1.0
11/07/2019 22:00	8.8	13.1	6.7	126.5	3,313,523.7	2,056.7	1.2	1.0
11/07/2019 23:00	8.6	13.2	6.6	123.1	3,309,768.3	2,030.2	1.2	1.0
Average/Sum#:	8.8	13.1	6.7	128.3	3,284,673.5	2,040.6	1.3	1.0
Minimum:	8.5	13.0	6.5	119.3	3,243,045.9	1,976.3	1.2	1.0
Maximum:	9.0	13.2	6.9	137.4	3,342,731.5	2,107.4	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/08/2019 00:00	8.7	13.2	6.7	134.2	3,311,751.5	2,055.6	1.3	1.0
11/08/2019 01:00	8.7	13.2	6.7	136.7	3,295,376.5	2,069.5	1.3	1.0
11/08/2019 02:00	8.7	13.2	6.7	133.8	3,289,679.6	2,041.9	1.3	1.0
11/08/2019 03:00	8.5	13.2	6.5	127.0	3,281,890.7	2,013.1	1.2	1.0
11/08/2019 04:00	8.7	13.3	6.8	124.8	3,311,532.1	2,007.1	1.2	1.0
11/08/2019 05:00	8.7	13.2	6.7	127.1	3,316,481.9	2,010.1	1.2	1.0
11/08/2019 06:00	8.8	13.3	6.8	128.6	3,302,292.7	2,001.5	1.3	1.0
11/08/2019 07:00	8.9	13.3	6.9	122.4	3,326,866.2	1,992.1	1.2	1.0
11/08/2019 08:00	8.1	13.5	6.5	110.7	3,280,473.7	1,868.5	1.1	0.7
11/08/2019 09:00	7.4	13.8	6.1	89.4	2,929,590.0	1,497.5	1.0	0.6
11/08/2019 10:00	7.7	13.9	6.5	83.2	2,644,179.9	1,332.3	1.0	0.5
11/08/2019 11:00	7.6	13.9	6.4	87.9	2,902,592.8	1,483.7	0.9	0.4
11/08/2019 12:00	7.6	13.9	6.4	88.0	2,948,033.3	1,485.4	0.9	0.4
11/08/2019 13:00	7.8	13.8	6.5	96.8	3,143,696.9	1,629.9	1.0	0.7
11/08/2019 14:00	8.5	13.8	7.1	98.5	3,140,418.0	1,628.2	1.0	0.7
11/08/2019 15:00	9.0	13.3	7.0	112.4	3,277,658.1	1,938.7	1.1	0.8
11/08/2019 16:00	8.8	13.3	6.8	118.7	3,251,241.7	1,994.3	1.2	1.0
11/08/2019 17:00	8.7	13.3	6.8	120.2	3,277,652.1	2,010.5	1.2	1.0
11/08/2019 18:00	8.7	13.2	6.7	126.9	3,290,440.2	2,066.4	1.2	1.0
11/08/2019 19:00	8.6	13.3	6.7	122.6	3,268,735.5	2,028.9	1.2	1.0
11/08/2019 20:00	8.6	13.2	6.6	124.6	3,316,745.9	2,058.7	1.2	1.0
11/08/2019 21:00	8.5	13.2	6.5	124.4	3,287,892.4	2,064.8	1.2	1.0
11/08/2019 22:00	8.5	13.3	6.6	123.4	3,322,223.6	2,062.1	1.2	1.0
11/08/2019 23:00	8.5	13.3	6.6	130.8	3,307,796.8	2,077.3	1.3	1.0
Average/Sum#:	8.4	13.4	6.7	116.4	3,209,385.1	1,892.4	1.2	0.9
Minimum:	7.4	13.2	6.1	83.2	2,644,179.9	1,332.3	0.9	0.4
Maximum:	9.0	13.9	7.1	136.7	3,326,866.2	2,077.3	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/09/2019 00:00	8.7	13.3	6.8	138.9	3,271,035.4	2,078.1	1.4	1.0
11/09/2019 01:00	8.5	13.3	6.6	132.1	3,272,446.6	2,055.1	1.3	1.0
11/09/2019 02:00	8.6	13.3	6.7	137.7	3,278,019.8	2,058.6	1.4	1.0
11/09/2019 03:00	8.6	13.3	6.7	136.5	3,280,249.1	2,060.0	1.3	1.0
11/09/2019 04:00	8.6	13.3	6.7	138.1	3,295,058.0	2,069.3	1.4	1.0
11/09/2019 05:00	8.3	13.4	6.5	121.5	3,314,502.0	2,008.9	1.2	1.0
11/09/2019 06:00	8.7	13.4	6.8	124.1	3,367,938.7	1,992.1	1.2	1.0
11/09/2019 07:00	8.7	13.4	6.8	121.4	3,275,460.2	1,937.4	1.2	1.0
11/09/2019 08:00	7.1	13.9	6.0	88.6	2,925,090.5	1,495.2	1.0	0.6
11/09/2019 09:00	7.7	13.9	6.5	81.1	2,511,802.2	1,265.6	1.0	0.5
11/09/2019 10:00	7.8	13.9	6.6	84.1	2,542,167.7	1,280.9	1.0	0.5
11/09/2019 11:00	7.8	14.0	6.7	85.4	2,528,671.9	1,274.1	1.1	0.5
11/09/2019 12:00	7.7	14.0	6.6	85.2	2,545,541.6	1,282.6	1.0	0.5
11/09/2019 13:00	7.7	14.0	6.6	84.6	2,527,878.0	1,273.7	1.0	0.5
11/09/2019 14:00	8.0	13.9	6.7	93.3	2,926,459.9	1,495.9	1.0	0.6
11/09/2019 15:00	9.1	13.3	7.1	113.5	3,296,931.5	1,950.1	1.1	0.8
11/09/2019 16:00	8.9	13.3	6.9	118.9	3,254,013.2	1,996.0	1.2	1.0
11/09/2019 17:00	8.7	13.3	6.8	121.8	3,259,713.4	2,023.3	1.2	1.0
11/09/2019 18:00	8.6	13.3	6.7	118.4	3,258,251.9	1,998.6	1.2	1.0
11/09/2019 19:00	8.6	13.3	6.7	119.4	3,304,767.5	2,003.0	1.2	1.0
11/09/2019 20:00	8.5	13.3	6.6	117.1	3,286,453.5	1,991.9	1.1	0.8
11/09/2019 21:00	8.5	13.3	6.6	119.4	3,329,021.2	2,017.7	1.1	0.8
11/09/2019 22:00	8.5	13.3	6.6	120.8	3,326,723.1	2,040.6	1.2	1.0
11/09/2019 23:00	8.5	13.3	6.6	118.8	3,327,041.3	2,016.5	1.1	0.8
Average/Sum#:	8.4	13.5	6.7	113.4	3,104,384.9	1,819.4	1.2	0.8
Minimum:	7.1	13.3	6.0	81.1	2,511,802.2	1,265.6	1.0	0.5
Maximum:	9.1	14.0	7.1	138.9	3,367,938.7	2,078.1	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/10/2019 00:00	8.5	13.3	6.6	119.7	3,349,810.0	2,030.3	1.1	0.8
11/10/2019 01:00	8.4	13.4	6.6	113.9	3,328,884.7	1,969.0	1.1	0.8
11/10/2019 02:00	8.4	13.4	6.6	117.4	3,327,870.3	1,968.4	1.1	0.8
11/10/2019 03:00	8.4	13.4	6.6	119.1	3,327,025.0	1,967.9	1.1	0.8
11/10/2019 04:00	8.4	13.4	6.6	117.7	3,325,503.4	1,967.0	1.1	0.8
11/10/2019 05:00	8.3	13.4	6.5	117.7	3,320,600.5	1,964.1	1.1	0.8
11/10/2019 06:00	8.7	13.3	6.8	122.7	3,309,552.3	2,005.9	1.2	1.0
11/10/2019 07:00	8.7	13.4	6.8	122.8	3,270,614.4	1,982.3	1.2	1.0
11/10/2019 08:00	7.2	13.8	6.0	90.9	2,988,670.9	1,527.7	1.0	0.6
11/10/2019 09:00	7.4	13.9	6.2	88.5	2,921,960.4	1,493.6	0.9	0.4
11/10/2019 10:00	7.5	13.9	6.3	89.4	2,932,720.1	1,499.1	1.0	0.6
11/10/2019 11:00	7.6	13.9	6.4	92.3	3,015,472.5	1,541.4	1.0	0.6
11/10/2019 12:00	7.6	13.9	6.4	91.3	3,030,198.8	1,526.8	0.9	0.5
11/10/2019 13:00	7.6	13.9	6.4	95.7	3,150,263.0	1,610.3	1.0	0.6
11/10/2019 14:00	7.8	13.9	6.6	94.5	3,078,857.3	1,573.8	1.0	0.6
11/10/2019 15:00	8.2	13.8	6.8	92.5	2,919,188.5	1,513.5	1.0	0.6
11/10/2019 16:00	8.9	13.3	6.9	112.7	3,309,611.3	1,957.6	1.1	0.8
11/10/2019 17:00	8.7	13.3	6.8	117.7	3,253,850.2	1,995.9	1.2	1.0
11/10/2019 18:00	8.6	13.3	6.7	117.0	3,286,453.5	1,991.9	1.1	0.8
11/10/2019 19:00	8.5	13.3	6.6	118.4	3,277,652.1	2,010.5	1.2	1.0
11/10/2019 20:00	8.5	13.3	6.6	118.8	3,294,280.8	2,020.7	1.2	1.0
11/10/2019 21:00	8.5	13.2	6.5	122.2	3,316,423.6	2,058.5	1.2	1.0
11/10/2019 22:00	8.6	13.2	6.6	128.6	3,300,785.0	2,097.0	1.3	1.0
11/10/2019 23:00	8.4	13.2	6.4	120.7	3,285,651.9	2,039.4	1.2	1.0
Average/Sum#:	8.2	13.5	6.6	110.1	3,205,079.2	1,846.4	1.1	0.8
Minimum:	7.2	13.2	6.0	88.5	2,919,188.5	1,493.6	0.9	0.4
Maximum:	8.9	13.9	6.9	128.6	3,349,810.0	2,097.0	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/11/2019 00:00	8.5	13.2	6.5	120.4	3,306,181.7	2,028.0	1.2	1.0
11/11/2019 01:00	8.4	13.3	6.5	115.6	3,281,998.8	1,989.2	1.1	0.8
11/11/2019 02:00	8.5	13.3	6.6	118.0	3,320,606.6	2,012.6	1.1	0.8
11/11/2019 03:00	8.3	13.3	6.4	115.8	3,313,347.0	2,008.2	1.1	0.8
11/11/2019 04:00	8.6	13.3	6.7	122.1	3,303,151.8	1,977.9	1.2	1.0
11/11/2019 05:00	8.5	13.3	6.6	119.7	3,295,302.7	1,973.2	1.2	1.0
11/11/2019 06:00	8.7	13.3	6.8	117.3	3,337,387.4	1,998.4	1.1	0.8
11/11/2019 07:00	8.8	13.3	6.8	121.5	3,319,121.7	2,011.7	1.2	1.0
11/11/2019 08:00	8.4	13.5	6.7	114.1	3,278,191.3	1,867.2	1.1	0.7
11/11/2019 09:00	7.7	13.8	6.4	88.9	2,823,328.8	1,463.8	1.0	0.6
11/11/2019 10:00	7.5	13.9	6.3	87.6	2,901,419.0	1,483.1	0.9	0.4
11/11/2019 11:00	7.7	13.9	6.5	87.7	2,887,529.1	1,476.0	0.9	0.4
11/11/2019 12:00	7.7	13.9	6.5	87.1	2,864,640.2	1,464.3	0.9	0.4
11/11/2019 13:00	8.6	13.7	7.0	100.7	3,234,541.8	1,677.0	1.0	0.7
11/11/2019 14:00	8.9	13.3	6.9	110.5	3,215,273.2	1,901.8	1.1	0.8
11/11/2019 15:00	8.8	13.2	6.7	120.4	3,226,202.7	2,002.5	1.2	1.0
11/11/2019 16:00	8.7	13.2	6.7	120.2	3,221,208.4	1,999.4	1.2	1.0
11/11/2019 17:00	8.8	13.1	6.7	132.8	3,213,685.1	2,088.6	1.3	1.0
11/11/2019 18:00	8.6	13.1	6.5	130.2	3,229,040.5	2,075.0	1.3	1.0
11/11/2019 19:00	8.6	13.1	6.5	126.2	3,223,026.9	2,047.6	1.3	1.0
11/11/2019 20:00	8.6	13.1	6.5	126.7	3,266,554.9	2,051.4	1.3	1.0
11/11/2019 21:00	8.5	13.2	6.5	124.9	3,277,542.1	2,058.3	1.2	1.0
11/11/2019 22:00	8.5	13.2	6.5	123.8	3,274,357.4	2,056.3	1.2	1.0
11/11/2019 23:00	8.6	13.2	6.6	123.4	3,251,427.5	2,041.9	1.2	1.0
Average/Sum#:	8.4	13.4	6.6	114.8	3,202,711.1	1,906.4	1.1	0.8
Minimum:	7.5	13.1	6.3	87.1	2,823,328.8	1,463.8	0.9	0.4
Maximum:	8.9	13.9	7.0	132.8	3,337,387.4	2,088.6	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/12/2019 00:00	8.5	13.2	6.5	121.6	3,277,918.6	2,034.6	1.2	1.0
11/12/2019 01:00	8.5	13.2	6.5	121.7	3,285,007.4	2,039.0	1.2	1.0
11/12/2019 02:00	8.4	13.2	6.4	117.9	3,326,546.3	2,016.2	1.1	0.8
11/12/2019 03:00	8.6	13.2	6.6	126.9	3,313,684.8	2,056.8	1.2	1.0
11/12/2019 04:00	8.6	13.2	6.6	130.5	3,292,579.5	2,043.7	1.3	1.0
11/12/2019 05:00	8.6	13.3	6.7	127.2	3,297,867.4	2,022.9	1.2	1.0
11/12/2019 06:00	9.0	13.2	6.9	132.0	3,272,765.0	2,055.3	1.3	1.0
11/12/2019 07:00	8.9	13.2	6.8	128.4	3,301,127.9	2,024.9	1.2	1.0
11/12/2019 08:00	8.8	13.3	6.8	129.9	3,284,988.3	2,015.0	1.3	1.0
11/12/2019 09:00	8.8	13.3	6.8	128.2	3,262,816.6	2,001.4	1.3	1.0
11/12/2019 10:00	8.8	13.2	6.7	134.2	3,255,363.4	2,020.6	1.3	1.0
11/12/2019 11:00	8.7	13.3	6.8	126.8	3,230,211.3	1,981.4	1.3	1.0
11/12/2019 12:00	8.7	13.3	6.8	129.1	3,210,648.1	1,969.4	1.3	1.0
11/12/2019 13:00	8.6	13.2	6.6	121.9	3,251,893.8	1,994.7	1.2	1.0
11/12/2019 14:00	8.7	13.2	6.7	120.4	3,244,068.5	1,989.9	1.2	1.0
11/12/2019 15:00	8.7	13.2	6.7	122.4	3,247,492.1	1,992.0	1.2	1.0
11/12/2019 16:00	8.7	13.2	6.7	120.4	3,229,070.1	1,980.7	1.2	1.0
11/12/2019 17:00	8.9	13.1	6.7	127.1	3,249,994.4	2,041.0	1.3	1.0
11/12/2019 18:00	8.8	13.2	6.7	125.5	3,232,160.0	2,029.8	1.2	1.0
11/12/2019 19:00	8.8	13.1	6.7	128.6	3,246,165.4	2,062.3	1.3	1.0
11/12/2019 20:00	8.7	13.1	6.6	129.3	3,239,239.6	2,057.9	1.3	1.0
11/12/2019 21:00	8.6	13.2	6.6	125.5	3,248,720.5	2,040.2	1.2	1.0
11/12/2019 22:00	8.7	13.2	6.7	126.0	3,243,943.4	2,037.2	1.2	1.0
11/12/2019 23:00	8.5	13.2	6.5	121.8	3,255,524.5	2,020.7	1.2	1.0
Average/Sum#:	8.7	13.2	6.7	126.0	3,262,491.5	2,022.0	1.2	1.0
Minimum:	8.4	13.1	6.4	117.9	3,210,648.1	1,969.4	1.1	0.8
Maximum:	9.0	13.3	6.9	134.2	3,326,546.3	2,062.3	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/13/2019 00:00	8.5	13.2	6.5	120.3	3,303,573.3	2,026.4	1.2	1.0
11/13/2019 01:00	8.5	13.3	6.6	119.6	3,286,288.5	1,991.8	1.2	1.0
11/13/2019 02:00	8.6	13.3	6.7	122.6	3,279,358.9	1,987.6	1.2	1.0
11/13/2019 03:00	8.7	13.3	6.8	123.9	3,281,503.8	1,988.9	1.2	1.0
11/13/2019 04:00	8.6	13.3	6.7	124.0	3,276,510.9	2,009.8	1.2	1.0
11/13/2019 05:00	8.7	13.3	6.8	126.6	3,287,433.7	2,016.5	1.2	1.0
11/13/2019 06:00	8.9	13.2	6.8	133.3	3,286,618.5	2,040.0	1.3	1.0
11/13/2019 07:00	8.9	13.2	6.8	126.4	3,299,823.7	2,024.1	1.2	1.0
11/13/2019 08:00	8.6	13.3	6.7	122.9	3,307,737.4	2,004.8	1.2	1.0
11/13/2019 09:00	8.7	13.3	6.8	123.4	3,287,608.5	1,992.6	1.2	1.0
11/13/2019 10:00	8.7	13.3	6.8	125.3	3,260,715.0	1,976.3	1.2	1.0
11/13/2019 11:00	8.7	13.2	6.7	125.9	3,248,796.3	1,992.8	1.2	1.0
11/13/2019 12:00	8.6	13.2	6.6	119.6	3,248,959.4	1,992.9	1.2	1.0
11/13/2019 13:00	8.7	13.2	6.7	122.9	3,237,963.7	2,009.8	1.2	1.0
11/13/2019 14:00	8.6	13.2	6.6	122.2	3,254,396.8	2,020.0	1.2	1.0
11/13/2019 15:00	8.7	13.2	6.7	122.9	3,252,141.2	2,018.6	1.2	1.0
11/13/2019 16:00	8.7	13.2	6.7	120.3	3,246,840.0	1,991.6	1.2	1.0
11/13/2019 17:00	8.8	13.1	6.7	134.2	3,250,204.3	2,088.6	1.3	1.0
11/13/2019 18:00	8.7	13.2	6.7	126.9	3,251,268.3	2,041.8	1.3	1.0
11/13/2019 19:00	8.5	13.2	6.5	120.5	3,278,956.3	2,011.3	1.2	1.0
11/13/2019 20:00	8.6	13.2	6.6	124.6	3,245,058.1	2,037.9	1.2	1.0
11/13/2019 21:00	8.5	13.2	6.5	123.2	3,264,385.5	2,026.2	1.2	1.0
11/13/2019 22:00	8.5	13.2	6.5	119.3	3,264,609.9	2,002.5	1.2	1.0
11/13/2019 23:00	8.6	13.2	6.6	123.0	3,285,490.8	2,039.3	1.2	1.0
Average/Sum#:	8.7	13.2	6.7	123.9	3,270,260.1	2,013.8	1.2	1.0
Minimum:	8.5	13.1	6.5	119.3	3,237,963.7	1,976.3	1.2	1.0
Maximum:	8.9	13.3	6.8	134.2	3,307,737.4	2,088.6	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/14/2019 00:00	8.6	13.2	6.6	127.0	3,286,777.8	2,064.1	1.2	1.0
11/14/2019 01:00	8.5	13.2	6.5	126.7	3,305,249.1	2,075.7	1.2	1.0
11/14/2019 02:00	8.6	13.2	6.6	126.7	3,295,694.9	2,069.7	1.2	1.0
11/14/2019 03:00	8.5	13.2	6.5	128.1	3,310,185.4	2,078.8	1.2	1.0
11/14/2019 04:00	8.6	13.2	6.6	128.2	3,306,045.2	2,076.2	1.2	1.0
11/14/2019 05:00	8.5	13.2	6.5	123.1	3,306,757.1	2,052.5	1.2	1.0
11/14/2019 06:00	8.8	13.2	6.7	131.6	3,314,644.0	2,081.6	1.3	1.0
11/14/2019 07:00	8.9	13.2	6.8	129.1	3,285,168.5	2,039.1	1.3	1.0
11/14/2019 08:00	8.6	13.3	6.7	122.9	3,283,318.7	1,990.0	1.2	1.0
11/14/2019 09:00	8.8	13.2	6.7	129.6	3,274,857.6	2,032.7	1.3	1.0
11/14/2019 10:00	8.9	13.2	6.8	135.9	3,226,017.6	2,049.5	1.4	1.0
11/14/2019 11:00	8.8	13.2	6.7	129.5	3,235,385.9	2,008.2	1.3	1.0
11/14/2019 12:00	8.8	13.1	6.7	132.0	3,250,730.2	2,065.2	1.3	1.0
11/14/2019 13:00	8.8	13.1	6.7	128.3	3,244,276.5	2,061.1	1.3	1.0
11/14/2019 14:00	8.8	13.1	6.7	128.8	3,240,184.0	2,058.5	1.3	1.0
11/14/2019 15:00	8.8	13.1	6.7	127.4	3,231,684.1	2,053.1	1.3	1.0
11/14/2019 16:00	8.7	13.1	6.6	125.8	3,238,529.4	2,033.8	1.3	1.0
11/14/2019 17:00	8.7	13.1	6.6	126.3	3,273,561.2	2,055.8	1.2	1.0
11/14/2019 18:00	8.7	13.1	6.6	126.4	3,271,172.7	2,054.3	1.2	1.0
11/14/2019 19:00	8.7	13.2	6.7	125.5	3,263,688.6	2,049.6	1.2	1.0
11/14/2019 20:00	8.7	13.1	6.6	127.1	3,279,134.5	2,059.3	1.3	1.0
11/14/2019 21:00	8.7	13.2	6.7	128.0	3,302,890.5	2,050.1	1.2	1.0
11/14/2019 22:00	8.7	13.2	6.7	125.2	3,277,918.6	2,034.6	1.2	1.0
11/14/2019 23:00	8.7	13.2	6.7	127.3	3,315,940.3	2,058.2	1.2	1.0
Average/Sum#:	8.7	13.2	6.7	127.8	3,275,825.5	2,052.2	1.3	1.0
Minimum:	8.5	13.1	6.5	122.9	3,226,017.6	1,990.0	1.2	1.0
Maximum:	8.9	13.3	6.8	135.9	3,315,940.3	2,081.6	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/15/2019 00:00	8.6	13.2	6.6	123.8	3,301,943.0	2,025.4	1.2	1.0
11/15/2019 01:00	8.6	13.3	6.7	119.1	3,337,387.4	1,998.4	1.1	0.8
11/15/2019 02:00	8.7	13.2	6.7	121.6	3,321,266.6	2,013.0	1.2	1.0
11/15/2019 03:00	8.6	13.3	6.7	117.7	3,306,324.9	1,979.8	1.1	0.8
11/15/2019 04:00	8.6	13.3	6.7	118.4	3,314,341.0	1,984.6	1.1	0.8
11/15/2019 05:00	8.6	13.3	6.7	118.0	3,300,980.8	1,976.6	1.1	0.8
11/15/2019 06:00	9.0	13.2	6.9	131.7	3,281,946.4	2,037.1	1.3	1.0
11/15/2019 07:00	9.0	13.2	6.9	125.8	3,307,723.8	2,053.1	1.2	1.0
11/15/2019 08:00	8.7	13.3	6.8	120.8	3,305,757.5	2,003.6	1.2	1.0
11/15/2019 09:00	8.8	13.3	6.8	122.6	3,293,548.1	1,996.2	1.2	1.0
11/15/2019 10:00	8.7	13.2	6.7	124.1	3,269,989.8	2,005.8	1.2	1.0
11/15/2019 11:00	8.4	13.4	6.6	112.2	3,308,633.3	1,908.7	1.1	0.8
11/15/2019 12:00	8.7	13.2	6.7	118.0	3,273,254.3	1,983.9	1.2	1.0
11/15/2019 13:00	8.8	13.2	6.7	124.3	3,266,802.1	2,027.7	1.2	1.0
11/15/2019 14:00	8.7	13.1	6.6	126.1	3,258,433.9	2,046.3	1.2	1.0
11/15/2019 15:00	8.7	13.1	6.6	123.2	3,267,446.6	2,028.1	1.2	1.0
11/15/2019 16:00	8.6	13.2	6.6	120.2	3,273,902.4	2,008.2	1.2	1.0
11/15/2019 17:00	8.7	13.1	6.6	126.2	3,272,287.3	2,055.0	1.2	1.0
11/15/2019 18:00	8.5	13.2	6.5	116.4	3,263,519.8	1,978.0	1.1	0.8
11/15/2019 19:00	8.6	13.2	6.6	120.2	3,274,228.5	2,008.4	1.2	1.0
11/15/2019 20:00	8.7	13.1	6.6	126.9	3,274,994.3	2,056.7	1.2	1.0
11/15/2019 21:00	8.6	13.2	6.6	120.2	3,272,761.3	2,007.5	1.2	1.0
11/15/2019 22:00	8.6	13.2	6.6	121.3	3,246,019.1	2,014.8	1.2	1.0
11/15/2019 23:00	8.7	13.2	6.7	117.9	3,273,089.3	1,983.8	1.2	1.0
Average/Sum#:	8.7	13.2	6.7	121.5	3,286,107.6	2,007.5	1.2	1.0
Minimum:	8.4	13.1	6.5	112.2	3,246,019.1	1,908.7	1.1	0.8
Maximum:	9.0	13.4	6.9	131.7	3,337,387.4	2,056.7	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/16/2019 00:00	8.6	13.3	6.7	116.9	3,300,479.8	1,976.3	1.1	0.8
11/16/2019 01:00	8.5	13.3	6.6	114.6	3,338,859.5	1,974.9	1.1	0.8
11/16/2019 02:00	8.6	13.3	6.7	121.7	3,270,614.4	1,982.3	1.2	1.0
11/16/2019 03:00	8.6	13.3	6.7	121.4	3,266,324.6	1,979.7	1.2	1.0
11/16/2019 04:00	8.5	13.3	6.6	117.5	3,296,972.7	1,974.2	1.1	0.8
11/16/2019 05:00	8.6	13.3	6.7	120.4	3,311,001.0	1,982.6	1.2	1.0
11/16/2019 06:00	8.8	13.3	6.8	123.1	3,277,379.0	1,986.4	1.2	1.0
11/16/2019 07:00	8.7	13.3	6.8	120.5	3,239,690.7	1,939.9	1.2	1.0
11/16/2019 08:00	7.3	13.8	6.1	93.6	3,087,073.8	1,578.0	1.0	0.6
11/16/2019 09:00	7.5	13.8	6.2	88.2	2,892,028.7	1,478.3	1.0	0.6
11/16/2019 10:00	7.6	13.8	6.3	90.0	2,940,545.4	1,503.1	1.0	0.6
11/16/2019 11:00	7.8	13.8	6.5	95.6	3,115,440.5	1,592.5	1.0	0.6
11/16/2019 12:00	7.7	13.8	6.4	93.4	3,048,534.3	1,558.3	1.0	0.6
11/16/2019 13:00	7.9	13.9	6.7	98.0	3,200,344.8	1,635.9	1.0	0.7
11/16/2019 14:00	7.8	13.9	6.6	96.7	3,152,219.3	1,611.3	1.0	0.6
11/16/2019 15:00	8.4	13.8	7.0	93.0	2,917,066.8	1,512.4	1.0	0.6
11/16/2019 16:00	9.0	13.2	6.9	115.7	3,240,916.0	1,964.3	1.1	0.8
11/16/2019 17:00	8.9	13.2	6.8	124.0	3,257,135.6	2,021.7	1.2	1.0
11/16/2019 18:00	8.7	13.2	6.7	122.4	3,267,381.4	2,004.2	1.2	1.0
11/16/2019 19:00	8.7	13.2	6.7	122.6	3,282,542.9	2,013.5	1.2	1.0
11/16/2019 20:00	8.7	13.2	6.7	123.1	3,288,900.9	2,017.4	1.2	1.0
11/16/2019 21:00	8.8	13.2	6.7	124.9	3,270,991.0	2,030.3	1.2	1.0
11/16/2019 22:00	8.7	13.2	6.7	121.7	3,333,640.9	2,020.5	1.2	1.0
11/16/2019 23:00	8.7	13.3	6.8	120.8	3,319,121.7	2,011.7	1.2	1.0
Average/Sum#:	8.4	13.4	6.6	111.7	3,204,800.2	1,847.9	1.1	0.8
Minimum:	7.3	13.2	6.1	88.2	2,892,028.7	1,478.3	1.0	0.6
Maximum:	9.0	13.9	7.0	124.9	3,338,859.5	2,030.3	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/17/2019 00:00	8.6	13.3	6.7	118.4	3,336,218.4	1,997.7	1.1	0.8
11/17/2019 01:00	8.5	13.3	6.6	118.5	3,344,234.5	2,002.5	1.1	0.8
11/17/2019 02:00	8.1	13.4	6.4	108.2	3,274,855.5	1,865.3	1.1	0.7
11/17/2019 03:00	7.4	13.8	6.1	91.0	2,985,736.4	1,526.2	1.0	0.6
11/17/2019 04:00	7.5	13.8	6.2	96.8	3,151,797.7	1,634.1	1.0	0.7
11/17/2019 05:00	7.6	13.8	6.3	89.7	2,929,198.8	1,497.3	1.0	0.6
11/17/2019 06:00	7.8	13.8	6.5	95.9	3,158,162.7	1,637.4	0.9	0.5
11/17/2019 07:00	7.8	13.8	6.5	96.0	3,073,875.6	1,593.7	1.0	0.6
11/17/2019 08:00	7.8	13.8	6.5	96.0	3,080,433.4	1,597.1	1.0	0.6
11/17/2019 09:00	7.7	13.8	6.4	96.7	3,138,329.4	1,604.2	1.0	0.6
11/17/2019 10:00	7.8	13.8	6.5	95.2	3,085,508.8	1,577.2	1.0	0.6
11/17/2019 11:00	8.0	13.8	6.6	98.7	3,187,237.4	1,629.2	1.0	0.7
11/17/2019 12:00	7.9	13.9	6.7	94.9	3,063,598.0	1,566.0	1.0	0.6
11/17/2019 13:00	7.9	13.9	6.7	97.1	3,149,284.8	1,609.8	1.0	0.6
11/17/2019 14:00	8.2	13.8	6.8	91.8	2,917,852.1	1,491.5	1.0	0.6
11/17/2019 15:00	9.2	13.3	7.1	114.7	3,239,356.7	1,939.7	1.1	0.8
11/17/2019 16:00	8.9	13.2	6.8	121.5	3,249,611.5	1,993.3	1.2	1.0
11/17/2019 17:00	8.7	13.2	6.7	119.5	3,236,406.3	1,985.2	1.2	1.0
11/17/2019 18:00	8.7	13.2	6.7	120.8	3,224,430.5	2,001.4	1.2	1.0
11/17/2019 19:00	8.8	13.2	6.7	123.9	3,259,874.5	2,023.4	1.2	1.0
11/17/2019 20:00	8.7	13.2	6.7	124.3	3,267,607.7	2,028.2	1.2	1.0
11/17/2019 21:00	8.7	13.2	6.7	124.2	3,270,829.9	2,030.2	1.2	1.0
11/17/2019 22:00	8.6	13.2	6.6	120.1	3,259,393.1	1,999.3	1.2	1.0
11/17/2019 23:00	8.5	13.3	6.6	116.7	3,315,844.0	1,985.5	1.1	0.8
Average/Sum#:	8.2	13.5	6.6	107.1	3,174,986.6	1,784.0	1.1	0.8
Minimum:	7.4	13.2	6.1	89.7	2,917,852.1	1,491.5	0.9	0.5
Maximum:	9.2	13.9	7.1	124.3	3,344,234.5	2,030.2	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/18/2019 00:00	8.7	13.3	6.8	124.3	3,285,463.6	1,991.3	1.2	1.0
11/18/2019 01:00	8.6	13.3	6.7	122.3	3,292,888.2	1,995.8	1.2	1.0
11/18/2019 02:00	8.6	13.3	6.7	122.5	3,294,538.1	1,996.8	1.2	1.0
11/18/2019 03:00	8.6	13.3	6.7	122.9	3,293,713.1	1,996.3	1.2	1.0
11/18/2019 04:00	8.6	13.3	6.7	120.8	3,319,351.1	1,987.6	1.2	1.0
11/18/2019 05:00	8.6	13.3	6.7	121.0	3,283,813.7	1,990.3	1.2	1.0
11/18/2019 06:00	9.0	13.2	6.9	134.1	3,262,733.2	2,049.0	1.3	1.0
11/18/2019 07:00	9.0	13.2	6.9	127.2	3,266,963.3	2,027.8	1.2	1.0
11/18/2019 08:00	8.6	13.3	6.7	120.0	3,310,834.0	1,982.5	1.2	1.0
11/18/2019 09:00	8.6	13.3	6.7	114.9	3,301,853.4	1,928.9	1.1	0.8
11/18/2019 10:00	8.7	13.2	6.7	121.4	3,269,337.7	2,005.4	1.2	1.0
11/18/2019 11:00	8.8	13.1	6.7	128.7	3,240,656.2	2,058.8	1.3	1.0
11/18/2019 12:00	8.7	13.1	6.6	123.2	3,216,236.5	2,019.8	1.2	1.0
11/18/2019 13:00	8.7	13.1	6.6	126.5	3,204,925.3	2,036.1	1.3	1.0
11/18/2019 14:00	8.6	13.1	6.5	124.3	3,221,172.8	2,022.9	1.2	1.0
11/18/2019 15:00	8.7	13.1	6.6	124.4	3,218,465.8	2,021.2	1.2	1.0
11/18/2019 16:00	8.7	13.1	6.6	130.5	3,215,968.7	2,066.6	1.3	1.0
11/18/2019 17:00	8.7	13.1	6.6	128.0	3,196,205.4	2,053.9	1.3	1.0
11/18/2019 18:00	8.8	13.0	6.6	134.8	3,224,763.6	2,095.8	1.4	1.0
11/18/2019 19:00	8.7	13.1	6.6	131.2	3,220,170.3	2,069.3	1.3	1.0
11/18/2019 20:00	8.6	13.1	6.5	128.6	3,213,478.8	2,065.0	1.3	1.0
11/18/2019 21:00	8.6	13.1	6.5	124.8	3,198,786.5	2,032.2	1.3	1.0
11/18/2019 22:00	8.7	13.1	6.6	125.1	3,235,185.5	2,031.7	1.2	1.0
11/18/2019 23:00	8.6	13.1	6.5	123.9	3,230,249.2	2,028.6	1.2	1.0
Average/Sum#:	8.7	13.2	6.7	125.2	3,250,739.8	2,023.1	1.2	1.0
Minimum:	8.6	13.0	6.5	114.9	3,196,205.4	1,928.9	1.1	0.8
Maximum:	9.0	13.3	6.9	134.8	3,319,351.1	2,095.8	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/19/2019 00:00	8.6	13.2	6.6	122.0	3,258,263.4	2,022.4	1.2	1.0
11/19/2019 01:00	8.6	13.2	6.6	117.9	3,237,873.5	1,986.1	1.2	1.0
11/19/2019 02:00	8.6	13.2	6.6	117.3	3,232,004.6	1,982.5	1.2	1.0
11/19/2019 03:00	8.6	13.3	6.7	118.5	3,266,819.6	1,980.0	1.2	1.0
11/19/2019 04:00	8.7	13.2	6.7	120.8	3,240,482.0	1,987.7	1.2	1.0
11/19/2019 05:00	8.7	13.2	6.7	124.1	3,262,001.5	2,000.9	1.2	1.0
11/19/2019 06:00	8.9	13.2	6.8	126.0	3,235,428.1	1,984.6	1.3	1.0
11/19/2019 07:00	9.1	13.2	7.0	124.8	3,226,686.1	2,002.8	1.2	1.0
11/19/2019 08:00	8.9	13.1	6.7	133.0	3,238,610.0	2,057.5	1.3	1.0
11/19/2019 09:00	8.7	13.2	6.7	124.2	3,234,867.0	2,031.5	1.2	1.0
11/19/2019 10:00	8.7	13.1	6.6	129.8	3,244,276.5	2,061.1	1.3	1.0
11/19/2019 11:00	8.6	13.1	6.5	126.5	3,238,370.2	2,033.7	1.3	1.0
11/19/2019 12:00	0.0	0.0	0.0	136.1	1,314,581.9	2,006.3	3.6	2.8
11/19/2019 13:00	0.0	0.0	0.0	136.4	1,307,505.4	1,995.5	3.7	2.8
11/19/2019 14:00	9.0	13.2	6.9	133.2	3,252,302.4	2,018.7	1.3	1.0
11/19/2019 15:00	8.6	13.3	6.7	119.5	3,241,297.1	1,988.2	1.2	1.0
11/19/2019 16:00	8.3	13.3	6.4	119.4	3,283,153.7	1,989.9	1.2	1.0
11/19/2019 17:00	8.3	13.1	6.3	135.9	3,239,622.4	2,081.8	1.4	1.0
11/19/2019 18:00	8.2	13.1	6.2	142.3	3,255,691.1	2,115.9	1.4	1.1
11/19/2019 19:00	7.9	13.2	6.1	124.1	3,272,924.3	2,031.5	1.2	1.0
11/19/2019 20:00	8.0	13.2	6.1	122.3	3,274,554.5	2,008.6	1.2	1.0
11/19/2019 21:00	8.0	13.2	6.1	125.7	3,299,497.6	2,023.9	1.2	1.0
11/19/2019 22:00	8.0	13.2	6.1	127.1	3,272,279.8	2,031.1	1.3	1.0
11/19/2019 23:00	8.0	13.2	6.1	127.1	3,280,174.2	2,036.0	1.3	1.0
Average/Sum#:	8.5	13.2	6.5	126.4	3,253,962.7	2,019.1	1.3	1.0
Minimum:	7.9	13.1	6.1	117.3	3,226,686.1	1,980.0	1.2	1.0
Maximum:	9.1	13.3	7.0	142.3	3,299,497.6	2,115.9	1.4	1.1
%SI	8.33	8.33	8.33	0.00	8.33	0.00	8.33	8.33

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/20/2019 00:00	8.0	13.2	6.1	122.7	3,273,087.3	2,007.7	1.2	1.0
11/20/2019 01:00	7.9	13.2	6.1	121.2	3,284,143.7	1,990.5	1.2	1.0
11/20/2019 02:00	8.0	13.3	6.2	119.1	3,289,958.6	1,970.0	1.2	1.0
11/20/2019 03:00	7.9	13.3	6.1	118.9	3,297,473.7	1,974.5	1.2	1.0
11/20/2019 04:00	8.0	13.2	6.1	122.3	3,326,532.2	1,991.9	1.2	1.0
11/20/2019 05:00	8.0	13.2	6.1	122.6	3,336,051.4	1,997.6	1.2	1.0
11/20/2019 06:00	8.2	13.2	6.3	141.4	3,263,529.4	2,049.5	1.4	1.0
11/20/2019 07:00	8.3	13.1	6.3	133.0	3,297,128.1	2,070.6	1.3	1.0
11/20/2019 08:00	0.0	0.0	0.0	150.2	1,349,308.9	2,059.3	3.9	3.1
11/20/2019 09:00	9.4	13.1	7.1	138.3	1,354,354.2	2,067.0	3.4	2.7
11/20/2019 10:00	9.0	13.1	6.8	147.0	1,352,650.6	2,064.4	3.7	2.9
11/20/2019 11:00	8.8	13.2	6.7	140.7	1,327,555.4	2,026.1	3.6	2.8
11/20/2019 12:00	8.8	13.2	6.7	133.6	1,328,145.1	2,027.0	3.4	2.6
11/20/2019 13:00	8.8	13.2	6.7	130.2	3,200,675.3	2,033.4	1.3	1.0
11/20/2019 14:00	8.8	13.1	6.7	125.2	3,226,175.0	2,049.6	1.2	1.0
11/20/2019 15:00	8.8	13.1	6.7	128.7	3,195,990.3	2,077.1	1.3	1.0
11/20/2019 16:00	8.9	13.2	6.8	124.7	3,211,140.9	2,016.6	1.2	1.0
11/20/2019 17:00	9.3	13.1	7.0	140.8	3,167,174.3	2,081.5	1.4	1.0
11/20/2019 18:00	9.1	13.1	6.9	139.4	3,182,542.3	2,091.6	1.4	1.0
11/20/2019 19:00	9.1	13.1	6.9	137.5	3,193,041.2	2,098.5	1.4	1.0
11/20/2019 20:00	8.9	13.2	6.8	131.0	3,181,988.3	2,068.0	1.3	1.0
11/20/2019 21:00	8.9	13.2	6.8	127.8	3,187,335.3	2,048.2	1.3	1.0
11/20/2019 22:00	8.8	13.2	6.7	122.8	3,206,841.6	2,013.9	1.2	1.0
11/20/2019 23:00	8.8	13.3	6.8	120.7	3,222,819.5	2,000.4	1.2	1.0
Average/Sum#:	8.6	13.2	6.6	130.8	3,239,138.3	2,036.5	1.3	1.0
Minimum:	7.9	13.1	6.1	118.9	3,167,174.3	1,970.0	1.2	1.0
Maximum:	9.4	13.3	7.1	150.2	3,336,051.4	2,098.5	1.4	1.0
%SI	4.17	4.17	4.17	0.00	20.83	0.00	20.83	20.83

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/21/2019 00:00	8.9	13.2	6.8	123.8	3,189,971.8	2,026.6	1.2	1.0
11/21/2019 01:00	8.9	13.2	6.8	124.6	3,198,943.9	2,032.3	1.3	1.0
11/21/2019 02:00	8.8	13.2	6.7	122.9	3,217,351.1	2,020.5	1.2	1.0
11/21/2019 03:00	8.9	13.2	6.8	127.0	3,239,869.2	2,058.3	1.3	1.0
11/21/2019 04:00	8.8	13.2	6.7	128.9	3,231,685.9	2,076.7	1.3	1.0
11/21/2019 05:00	8.9	13.2	6.8	129.8	3,236,510.0	2,079.8	1.3	1.0
11/21/2019 06:00	9.2	13.1	7.0	136.5	3,233,971.8	2,125.4	1.4	1.1
11/21/2019 07:00	9.2	13.1	7.0	135.7	3,243,101.3	2,131.4	1.3	1.1
11/21/2019 08:00	8.8	13.2	6.7	127.0	3,254,980.1	2,067.9	1.3	1.0
11/21/2019 09:00	8.7	13.3	6.8	117.3	3,244,068.5	1,989.9	1.1	0.8
11/21/2019 10:00	8.7	13.2	6.7	120.4	3,256,813.4	2,021.5	1.2	1.0
11/21/2019 11:00	8.6	13.3	6.7	116.2	3,231,841.5	1,982.4	1.1	0.8
11/21/2019 12:00	8.7	13.2	6.7	120.2	3,211,459.4	2,016.8	1.2	1.0
11/21/2019 13:00	8.6	13.2	6.6	118.1	3,223,302.8	2,000.7	1.2	1.0
11/21/2019 14:00	8.6	13.2	6.6	117.1	3,238,688.7	1,986.6	1.2	1.0
11/21/2019 15:00	8.6	13.2	6.6	119.3	3,239,252.5	2,010.6	1.2	1.0
11/21/2019 16:00	8.9	13.1	6.7	128.3	3,214,608.3	2,089.2	1.3	1.0
11/21/2019 17:00	9.0	13.1	6.8	132.6	3,223,625.0	2,118.6	1.3	1.1
11/21/2019 18:00	8.9	13.1	6.7	133.7	3,217,394.9	2,138.0	1.3	1.1
11/21/2019 19:00	8.9	13.1	6.7	134.5	3,214,836.6	2,136.3	1.4	1.1
11/21/2019 20:00	9.0	13.1	6.8	135.1	3,208,215.2	2,131.9	1.4	1.1
11/21/2019 21:00	8.9	13.1	6.7	134.0	3,241,884.0	2,130.6	1.3	1.1
11/21/2019 22:00	8.9	13.1	6.7	131.2	3,242,766.2	2,107.5	1.3	1.1
11/21/2019 23:00	8.9	13.2	6.8	127.5	3,230,129.8	2,075.7	1.3	1.0
Average/Sum#:	8.8	13.2	6.7	126.7	3,228,553.0	2,064.8	1.3	1.0
Minimum:	8.6	13.1	6.6	116.2	3,189,971.8	1,982.4	1.1	0.8
Maximum:	9.2	13.3	7.0	136.5	3,256,813.4	2,138.0	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/22/2019 00:00	8.8	13.2	6.7	123.5	3,264,644.0	2,050.2	1.2	1.0
11/22/2019 01:00	8.8	13.2	6.7	123.2	3,260,344.7	2,047.5	1.2	1.0
11/22/2019 02:00	8.8	13.2	6.7	123.6	3,262,574.0	2,048.9	1.2	1.0
11/22/2019 03:00	8.7	13.2	6.7	122.7	3,257,000.7	2,045.4	1.2	1.0
11/22/2019 04:00	8.6	13.3	6.7	117.6	3,260,860.3	2,000.2	1.1	0.8
11/22/2019 05:00	8.4	13.3	6.5	115.0	3,264,839.7	1,978.8	1.1	0.8
11/22/2019 06:00	9.3	13.1	7.0	138.3	3,249,297.9	2,159.2	1.4	1.1
11/22/2019 07:00	9.2	13.1	7.0	135.3	3,257,099.8	2,140.6	1.3	1.1
11/22/2019 08:00	8.7	13.3	6.8	118.0	3,251,404.8	1,994.4	1.2	1.0
11/22/2019 09:00	8.5	13.3	6.6	114.0	3,288,789.6	1,969.3	1.1	0.8
11/22/2019 10:00	8.6	13.3	6.7	116.3	3,285,133.6	1,991.1	1.1	0.8
11/22/2019 11:00	8.6	13.3	6.7	114.1	3,246,030.8	1,967.4	1.1	0.8
11/22/2019 12:00	8.7	13.3	6.8	115.8	3,232,330.6	1,982.7	1.1	0.8
11/22/2019 13:00	8.6	13.3	6.7	115.1	3,222,875.1	1,976.9	1.1	0.8
11/22/2019 14:00	8.7	13.2	6.7	117.7	3,221,047.3	1,999.3	1.2	1.0
11/22/2019 15:00	8.7	13.3	6.8	118.2	3,226,041.6	2,002.4	1.2	1.0
11/22/2019 16:00	8.9	13.1	6.7	131.9	3,229,254.9	2,122.3	1.3	1.1
11/22/2019 17:00	8.8	13.1	6.7	131.3	3,228,189.7	2,121.6	1.3	1.1
11/22/2019 18:00	8.9	13.1	6.7	134.0	3,238,462.9	2,152.0	1.3	1.1
11/22/2019 19:00	8.8	13.1	6.7	130.8	3,231,080.8	2,123.5	1.3	1.1
11/22/2019 20:00	8.7	13.2	6.7	128.9	3,219,070.5	2,092.1	1.3	1.0
11/22/2019 21:00	8.9	13.1	6.7	132.0	3,212,973.9	2,111.6	1.3	1.1
11/22/2019 22:00	8.8	13.2	6.7	128.2	3,236,198.8	2,079.6	1.3	1.0
11/22/2019 23:00	8.7	13.2	6.7	122.3	3,251,586.7	2,042.0	1.2	1.0
Average/Sum#:	8.8	13.2	6.7	123.7	3,245,713.9	2,050.0	1.2	1.0
Minimum:	8.4	13.1	6.5	114.0	3,212,973.9	1,967.4	1.1	0.8
Maximum:	9.3	13.3	7.0	138.3	3,288,789.6	2,159.2	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/23/2019 00:00	8.9	13.2	6.8	122.7	3,239,803.3	2,034.6	1.2	1.0
11/23/2019 01:00	8.9	13.2	6.8	125.1	3,233,415.6	2,054.2	1.2	1.0
11/23/2019 02:00	8.6	13.3	6.7	121.1	3,293,707.3	2,044.4	1.2	1.0
11/23/2019 03:00	8.6	13.3	6.7	117.8	3,273,902.4	2,008.2	1.1	0.8
11/23/2019 04:00	8.7	13.3	6.8	123.0	3,270,695.0	2,054.0	1.2	1.0
11/23/2019 05:00	8.7	13.2	6.7	124.0	3,248,841.3	2,064.0	1.2	1.0
11/23/2019 06:00	9.1	13.2	7.0	126.5	3,228,729.2	2,074.8	1.3	1.0
11/23/2019 07:00	9.0	13.3	7.0	122.4	3,240,599.5	2,035.1	1.2	1.0
11/23/2019 08:00	7.6	13.5	6.1	105.1	3,204,966.6	1,872.3	1.0	0.7
11/23/2019 09:00	7.3	13.8	6.1	95.4	3,086,150.0	1,622.6	1.0	0.6
11/23/2019 10:00	7.6	13.8	6.3	97.7	3,125,330.8	1,643.2	1.0	0.7
11/23/2019 11:00	7.6	13.9	6.4	96.1	3,061,234.1	1,609.5	1.0	0.6
11/23/2019 12:00	7.7	13.9	6.5	96.7	3,092,046.1	1,625.7	1.0	0.7
11/23/2019 13:00	7.6	13.9	6.4	97.8	3,126,091.6	1,643.6	1.0	0.7
11/23/2019 14:00	7.6	13.9	6.4	95.9	3,072,455.8	1,615.4	1.0	0.6
11/23/2019 15:00	8.5	13.6	6.9	106.4	3,171,373.5	1,783.2	1.0	0.7
11/23/2019 16:00	9.0	13.2	6.9	122.3	3,226,017.6	2,049.5	1.2	1.0
11/23/2019 17:00	8.7	13.2	6.7	124.7	3,231,997.2	2,076.9	1.2	1.0
11/23/2019 18:00	8.7	13.2	6.7	124.6	3,228,418.0	2,074.6	1.2	1.0
11/23/2019 19:00	8.7	13.1	6.6	129.6	3,224,842.3	2,119.4	1.3	1.1
11/23/2019 20:00	8.6	13.1	6.5	127.3	3,249,844.1	2,112.1	1.3	1.1
11/23/2019 21:00	8.5	13.2	6.5	121.1	3,284,389.2	2,062.6	1.2	1.0
11/23/2019 22:00	8.4	13.3	6.5	117.8	3,265,996.6	2,027.2	1.2	1.0
11/23/2019 23:00	8.6	13.3	6.7	115.7	3,234,286.9	1,983.9	1.1	0.8
Average/Sum#:	8.4	13.4	6.6	114.9	3,204,797.3	1,928.8	1.1	0.9
Minimum:	7.3	13.1	6.1	95.4	3,061,234.1	1,609.5	1.0	0.6
Maximum:	9.1	13.9	7.0	129.6	3,293,707.3	2,119.4	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/24/2019 00:00	8.6	13.3	6.7	115.4	3,225,646.5	1,978.6	1.1	0.8
11/24/2019 01:00	8.6	13.3	6.7	114.9	3,223,690.2	1,977.4	1.1	0.8
11/24/2019 02:00	8.4	13.4	6.6	112.7	3,277,767.4	1,962.7	1.1	0.8
11/24/2019 03:00	8.5	13.4	6.7	112.5	3,278,268.4	1,963.0	1.1	0.8
11/24/2019 04:00	8.5	13.4	6.7	113.3	3,298,642.7	1,975.2	1.1	0.8
11/24/2019 05:00	8.5	13.4	6.7	113.3	3,293,799.6	1,972.3	1.1	0.8
11/24/2019 06:00	8.8	13.3	6.8	122.2	3,272,118.7	2,031.0	1.2	1.0
11/24/2019 07:00	8.5	13.4	6.7	117.8	3,218,147.3	1,974.0	1.2	1.0
11/24/2019 08:00	7.2	13.8	6.0	94.2	3,059,522.3	1,608.6	1.0	0.6
11/24/2019 09:00	7.4	13.8	6.1	94.7	3,045,067.3	1,601.0	1.0	0.6
11/24/2019 10:00	7.5	13.8	6.2	96.6	3,098,322.7	1,629.0	1.0	0.7
11/24/2019 11:00	7.7	13.8	6.4	97.0	3,085,389.2	1,622.2	1.0	0.6
11/24/2019 12:00	7.7	13.9	6.5	98.3	3,142,258.4	1,652.1	1.0	0.7
11/24/2019 13:00	7.7	13.9	6.5	97.6	3,106,691.4	1,633.4	1.0	0.7
11/24/2019 14:00	7.6	13.9	6.4	94.7	3,023,765.1	1,589.8	1.0	0.6
11/24/2019 15:00	8.4	13.6	6.8	105.7	3,173,863.3	1,784.6	1.0	0.7
11/24/2019 16:00	8.9	13.3	6.9	117.3	3,224,108.3	2,001.2	1.2	1.0
11/24/2019 17:00	8.8	13.2	6.7	122.7	3,238,767.4	2,057.6	1.2	1.0
11/24/2019 18:00	8.5	13.3	6.6	114.3	3,220,592.7	1,975.5	1.1	0.8
11/24/2019 19:00	8.3	13.4	6.5	109.4	3,258,384.7	1,927.3	1.1	0.8
11/24/2019 20:00	8.6	13.3	6.7	114.7	3,223,853.2	1,977.5	1.1	0.8
11/24/2019 21:00	8.7	13.3	6.8	120.5	3,218,943.5	2,021.5	1.2	1.0
11/24/2019 22:00	8.5	13.4	6.7	113.8	3,238,936.2	1,963.1	1.1	0.8
11/24/2019 23:00	7.4	13.6	6.0	101.3	3,137,938.2	1,764.4	1.0	0.7
Average/Sum#:	8.2	13.5	6.6	109.0	3,191,020.2	1,860.1	1.1	0.8
Minimum:	7.2	13.2	6.0	94.2	3,023,765.1	1,589.8	1.0	0.6
Maximum:	8.9	13.9	6.9	122.7	3,298,642.7	2,057.6	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/25/2019 00:00	7.5	13.9	6.3	80.5	2,481,701.3	1,304.8	1.0	0.5
11/25/2019 01:00	7.5	13.9	6.3	88.4	2,824,437.8	1,485.0	1.0	0.6
11/25/2019 02:00	7.6	13.9	6.4	79.9	2,504,715.2	1,316.9	1.0	0.5
11/25/2019 03:00	7.6	13.9	6.4	81.5	2,581,935.6	1,357.5	1.0	0.5
11/25/2019 04:00	7.8	13.8	6.5	98.8	3,093,773.6	1,649.2	1.0	0.7
11/25/2019 05:00	7.7	13.9	6.5	90.6	2,850,494.9	1,498.7	1.0	0.6
11/25/2019 06:00	7.9	13.9	6.7	87.3	2,540,092.0	1,335.5	1.1	0.5
11/25/2019 07:00	7.8	13.9	6.6	95.1	2,992,953.1	1,573.6	1.0	0.6
11/25/2019 08:00	7.9	13.9	6.7	97.7	3,079,302.9	1,619.0	1.0	0.6
11/25/2019 09:00	7.7	13.9	6.5	94.9	3,011,782.7	1,583.5	1.0	0.6
11/25/2019 10:00	7.7	13.9	6.5	96.4	3,054,957.6	1,606.2	1.0	0.6
11/25/2019 11:00	7.8	13.9	6.6	98.8	3,135,601.4	1,648.6	1.0	0.7
11/25/2019 12:00	7.8	13.9	6.6	98.2	3,117,722.8	1,639.2	1.0	0.7
11/25/2019 13:00	7.7	13.9	6.5	97.6	3,104,409.0	1,632.2	1.0	0.7
11/25/2019 14:00	7.7	13.9	6.5	97.4	3,089,573.6	1,624.4	1.0	0.6
11/25/2019 15:00	7.9	13.8	6.6	92.8	2,934,372.1	1,542.8	1.0	0.6
11/25/2019 16:00	9.1	13.3	7.1	115.1	3,266,654.6	1,979.9	1.1	0.8
11/25/2019 17:00	9.3	13.2	7.1	130.3	3,227,533.2	2,097.6	1.3	1.0
11/25/2019 18:00	8.8	13.3	6.8	121.6	3,249,080.2	2,016.7	1.2	1.0
11/25/2019 19:00	8.9	13.2	6.8	125.2	3,251,517.2	2,065.7	1.2	1.0
11/25/2019 20:00	8.9	13.2	6.8	125.7	3,257,498.6	2,069.5	1.2	1.0
11/25/2019 21:00	8.8	13.2	6.7	121.9	3,246,172.7	2,038.6	1.2	1.0
11/25/2019 22:00	8.6	13.3	6.7	117.8	3,274,065.5	2,008.3	1.1	0.8
11/25/2019 23:00	8.6	13.3	6.7	116.2	3,283,318.7	1,990.0	1.1	0.8
Average/Sum#:	8.1	13.7	6.6	102.1	3,018,902.8	1,695.1	1.1	0.7
Minimum:	7.5	13.2	6.3	79.9	2,481,701.3	1,304.8	1.0	0.5
Maximum:	9.3	13.9	7.1	130.3	3,283,318.7	2,097.6	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/26/2019 00:00	8.7	13.3	6.8	118.6	3,287,107.6	2,016.3	1.2	1.0
11/26/2019 01:00	8.8	13.3	6.8	121.1	3,280,496.4	2,036.2	1.2	1.0
11/26/2019 02:00	8.6	13.4	6.8	114.3	3,255,270.3	1,973.0	1.1	0.8
11/26/2019 03:00	8.4	13.4	6.6	114.2	3,253,125.4	1,971.7	1.1	0.8
11/26/2019 04:00	8.6	13.4	6.8	112.8	3,270,586.2	1,958.4	1.1	0.8
11/26/2019 05:00	8.0	13.5	6.4	106.9	3,268,987.2	1,909.7	1.0	0.8
11/26/2019 06:00	9.2	13.2	7.0	131.7	3,240,089.2	2,082.1	1.3	1.0
11/26/2019 07:00	8.5	13.4	6.7	116.7	3,137,484.9	1,878.7	1.2	0.9
11/26/2019 08:00	7.3	13.8	6.1	94.9	3,064,467.5	1,611.2	1.0	0.6
11/26/2019 09:00	7.5	13.8	6.2	97.3	3,112,016.9	1,636.2	1.0	0.7
11/26/2019 10:00	7.4	13.9	6.2	90.7	2,887,012.9	1,517.9	1.0	0.6
11/26/2019 11:00	7.6	13.8	6.3	93.6	2,994,094.3	1,574.2	1.0	0.6
11/26/2019 12:00	7.5	13.8	6.2	92.9	2,945,403.6	1,548.6	1.0	0.6
11/26/2019 13:00	7.7	13.8	6.4	95.1	2,971,088.1	1,583.8	1.0	0.6
11/26/2019 14:00	8.4	13.7	6.9	104.4	3,211,670.3	1,735.5	1.0	0.7
11/26/2019 15:00	8.5	13.6	6.9	106.7	3,258,859.9	1,761.0	1.0	0.7
11/26/2019 16:00	8.7	13.4	6.8	110.9	3,199,488.9	1,869.1	1.1	0.7
11/26/2019 17:00	8.9	13.2	6.8	120.4	3,222,924.4	2,024.0	1.2	1.0
11/26/2019 18:00	8.6	13.2	6.6	117.8	3,217,502.9	1,997.1	1.2	1.0
11/26/2019 19:00	8.7	13.2	6.7	118.8	3,241,991.4	2,012.3	1.2	1.0
11/26/2019 20:00	8.7	13.2	6.7	123.2	3,220,508.4	2,046.0	1.2	1.0
11/26/2019 21:00	8.7	13.2	6.7	120.6	3,177,222.0	2,018.5	1.2	1.0
11/26/2019 22:00	8.6	13.2	6.6	118.7	3,187,414.9	2,001.7	1.2	1.0
11/26/2019 23:00	8.7	13.2	6.7	120.4	3,202,860.7	2,011.4	1.2	1.0
Average/Sum#:	8.3	13.5	6.6	110.9	3,171,153.1	1,865.6	1.1	0.8
Minimum:	7.3	13.2	6.1	90.7	2,887,012.9	1,517.9	1.0	0.6
Maximum:	9.2	13.9	7.0	131.7	3,287,107.6	2,082.1	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/27/2019 00:00	8.7	13.2	6.7	121.8	3,179,268.2	2,019.8	1.2	1.0
11/27/2019 01:00	8.7	13.2	6.7	119.4	3,178,656.9	1,996.2	1.2	1.0
11/27/2019 02:00	8.6	13.3	6.7	115.6	3,199,562.3	1,962.6	1.1	0.8
11/27/2019 03:00	8.5	13.3	6.6	115.0	3,195,486.6	1,960.1	1.1	0.8
11/27/2019 04:00	8.7	13.3	6.8	116.3	3,211,300.2	1,969.8	1.2	1.0
11/27/2019 05:00	8.6	13.3	6.7	117.1	3,188,181.1	1,978.9	1.2	1.0
11/27/2019 06:00	8.7	13.3	6.8	113.7	3,228,501.5	1,933.2	1.1	0.8
11/27/2019 07:00	9.1	13.2	7.0	127.2	3,216,279.9	2,066.8	1.3	1.0
11/27/2019 08:00	8.8	13.2	6.7	125.4	3,205,542.4	2,059.9	1.3	1.0
11/27/2019 09:00	8.7	13.2	6.7	123.7	3,179,554.4	2,043.2	1.2	1.0
11/27/2019 10:00	8.7	13.2	6.7	123.0	3,195,323.6	2,030.0	1.2	1.0
11/27/2019 11:00	8.6	13.3	6.7	118.0	3,201,069.8	1,986.9	1.2	1.0
11/27/2019 12:00	8.7	13.2	6.7	121.6	3,166,675.8	2,011.8	1.2	1.0
11/27/2019 13:00	8.9	13.2	6.8	127.4	3,168,294.1	2,059.1	1.3	1.0
11/27/2019 14:00	8.8	13.2	6.7	125.7	3,154,446.0	2,050.1	1.3	1.0
11/27/2019 15:00	8.6	13.2	6.6	118.6	3,171,969.0	1,992.0	1.2	1.0
11/27/2019 16:00	8.6	13.3	6.7	115.4	3,201,355.6	1,963.7	1.1	0.8
11/27/2019 17:00	8.8	13.2	6.7	124.7	3,188,269.0	2,048.8	1.3	1.0
11/27/2019 18:00	8.4	13.4	6.6	108.5	3,213,920.7	1,901.0	1.1	0.8
11/27/2019 19:00	8.4	13.4	6.6	109.1	3,237,251.6	1,914.8	1.1	0.8
11/27/2019 20:00	8.8	13.2	6.7	127.4	3,243,201.5	2,084.1	1.3	1.0
11/27/2019 21:00	8.7	13.1	6.6	129.8	3,237,380.8	2,104.0	1.3	1.1
11/27/2019 22:00	8.5	13.2	6.5	122.7	3,231,526.7	2,053.0	1.2	1.0
11/27/2019 23:00	8.5	13.2	6.5	120.2	3,242,828.8	2,036.5	1.2	1.0
Average/Sum#:	8.7	13.2	6.7	120.3	3,201,493.6	2,009.4	1.2	1.0
Minimum:	8.4	13.1	6.5	108.5	3,154,446.0	1,901.0	1.1	0.8
Maximum:	9.1	13.4	7.0	129.8	3,243,201.5	2,104.0	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/28/2019 00:00	8.5	13.2	6.5	120.7	3,246,650.4	2,038.9	1.2	1.0
11/28/2019 01:00	8.5	13.2	6.5	118.8	3,257,780.1	2,022.1	1.2	1.0
11/28/2019 02:00	8.4	13.3	6.5	117.2	3,275,043.6	2,008.9	1.1	0.8
11/28/2019 03:00	8.4	13.2	6.4	120.4	3,247,924.3	2,039.7	1.2	1.0
11/28/2019 04:00	8.4	13.3	6.5	117.2	3,280,423.5	2,012.2	1.1	0.8
11/28/2019 05:00	8.3	13.3	6.4	113.5	3,236,183.6	1,937.8	1.1	0.8
11/28/2019 06:00	9.0	13.1	6.8	125.0	3,190,136.3	2,050.0	1.3	1.0
11/28/2019 07:00	9.0	13.1	6.8	127.1	3,231,054.5	2,052.7	1.3	1.0
11/28/2019 08:00	8.8	13.1	6.7	126.5	3,231,211.9	2,052.8	1.3	1.0
11/28/2019 09:00	8.7	13.1	6.6	124.8	3,210,906.7	2,039.9	1.2	1.0
11/28/2019 10:00	8.7	13.1	6.6	126.2	3,211,693.7	2,040.4	1.3	1.0
11/28/2019 11:00	8.8	13.1	6.7	127.8	3,214,369.6	2,042.1	1.3	1.0
11/28/2019 12:00	8.8	13.1	6.7	129.3	3,208,703.0	2,038.5	1.3	1.0
11/28/2019 13:00	8.8	13.1	6.7	127.8	3,192,018.1	2,027.9	1.3	1.0
11/28/2019 14:00	8.9	13.1	6.7	127.4	3,182,573.7	2,021.9	1.3	1.0
11/28/2019 15:00	8.9	13.1	6.7	129.3	3,192,018.1	2,027.9	1.3	1.0
11/28/2019 16:00	8.8	13.1	6.7	124.5	3,204,293.8	2,012.3	1.2	1.0
11/28/2019 17:00	8.8	13.1	6.7	124.0	3,204,453.1	2,012.4	1.2	1.0
11/28/2019 18:00	8.5	13.2	6.5	115.8	3,222,932.0	1,953.4	1.1	0.8
11/28/2019 19:00	8.9	13.1	6.7	123.6	3,195,217.4	2,006.6	1.2	1.0
11/28/2019 20:00	8.9	13.1	6.7	126.8	3,181,314.5	2,021.1	1.3	1.0
11/28/2019 21:00	8.9	13.1	6.7	126.8	3,219,102.7	2,021.6	1.3	1.0
11/28/2019 22:00	8.9	13.1	6.7	126.1	3,177,379.4	2,018.6	1.3	1.0
11/28/2019 23:00	8.9	13.1	6.7	128.1	3,195,953.2	2,030.4	1.3	1.0
Average/Sum#:	8.7	13.1	6.6	123.9	3,217,055.7	2,022.1	1.2	1.0
Minimum:	8.3	13.1	6.4	113.5	3,177,379.4	1,937.8	1.1	0.8
Maximum:	9.0	13.3	6.8	129.3	3,280,423.5	2,052.8	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/29/2019 00:00	8.9	13.1	6.7	128.0	3,199,101.3	2,032.4	1.3	1.0
11/29/2019 01:00	8.8	13.1	6.7	124.6	3,217,032.7	2,020.3	1.2	1.0
11/29/2019 02:00	8.9	13.1	6.7	125.2	3,222,765.1	2,023.9	1.2	1.0
11/29/2019 03:00	8.8	13.1	6.7	123.4	3,215,599.5	2,019.4	1.2	1.0
11/29/2019 04:00	8.9	13.1	6.7	126.7	3,234,230.1	2,031.1	1.3	1.0
11/29/2019 05:00	8.7	13.1	6.6	122.9	3,244,408.0	2,013.8	1.2	1.0
11/29/2019 06:00	9.0	13.1	6.8	127.6	3,213,110.3	2,041.3	1.3	1.0
11/29/2019 07:00	8.7	13.2	6.7	123.0	3,162,564.8	1,963.0	1.2	1.0
11/29/2019 08:00	7.1	13.8	5.9	92.5	2,899,756.1	1,524.6	1.0	0.6
11/29/2019 09:00	7.4	13.8	6.1	86.9	2,674,752.1	1,406.3	1.0	0.6
11/29/2019 10:00	7.4	13.8	6.1	94.8	2,928,317.1	1,561.0	1.0	0.6
11/29/2019 11:00	7.4	13.8	6.1	96.0	2,935,445.6	1,564.8	1.0	0.6
11/29/2019 12:00	7.4	13.8	6.1	93.1	2,890,436.4	1,519.7	1.0	0.6
11/29/2019 13:00	7.5	13.8	6.2	92.9	2,886,061.9	1,517.4	1.0	0.6
11/29/2019 14:00	7.6	13.8	6.3	88.4	2,714,883.8	1,427.4	1.0	0.6
11/29/2019 15:00	7.9	13.8	6.6	94.3	2,901,866.5	1,546.9	1.0	0.6
11/29/2019 16:00	9.0	13.3	7.0	114.4	3,276,598.3	1,962.0	1.1	0.8
11/29/2019 17:00	9.2	13.1	7.0	134.6	3,265,384.8	2,122.2	1.3	1.1
11/29/2019 18:00	8.9	13.1	6.7	135.3	3,241,123.2	2,130.1	1.3	1.1
11/29/2019 19:00	8.8	13.1	6.7	133.0	3,253,383.1	2,114.4	1.3	1.1
11/29/2019 20:00	8.8	13.1	6.7	133.8	3,263,846.1	2,121.2	1.3	1.1
11/29/2019 21:00	8.6	13.2	6.6	122.2	3,249,516.7	2,040.7	1.2	1.0
11/29/2019 22:00	8.5	13.2	6.5	121.3	3,306,112.7	2,052.1	1.2	1.0
11/29/2019 23:00	8.5	13.2	6.5	121.5	3,296,446.2	2,046.1	1.2	1.0
Average/Sum#:	8.4	13.4	6.5	114.9	3,112,197.6	1,866.8	1.2	0.9
Minimum:	7.1	13.1	5.9	86.9	2,674,752.1	1,406.3	1.0	0.6
Maximum:	9.2	13.8	7.0	135.3	3,306,112.7	2,130.1	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/30/2019 00:00	8.5	13.2	6.5	119.4	3,287,424.1	2,040.5	1.2	1.0
11/30/2019 01:00	8.5	13.2	6.5	119.4	3,320,365.1	2,036.7	1.2	1.0
11/30/2019 02:00	8.6	13.2	6.6	121.3	3,297,735.0	2,046.9	1.2	1.0
11/30/2019 03:00	8.6	13.2	6.6	121.9	3,298,218.4	2,047.2	1.2	1.0
11/30/2019 04:00	8.5	13.2	6.5	119.8	3,278,724.2	2,035.1	1.2	1.0
11/30/2019 05:00	8.5	13.2	6.5	117.7	3,289,390.0	2,017.7	1.1	0.8
11/30/2019 06:00	8.8	13.2	6.7	122.0	3,299,668.3	2,048.1	1.2	1.0
11/30/2019 07:00	8.7	13.2	6.7	120.2	3,296,237.1	2,021.9	1.2	1.0
11/30/2019 08:00	8.6	13.2	6.6	121.1	3,287,746.3	2,040.7	1.2	1.0
11/30/2019 09:00	8.6	13.2	6.6	123.3	3,278,019.8	2,058.6	1.2	1.0
11/30/2019 10:00	8.5	13.2	6.5	120.1	3,278,240.9	2,034.8	1.2	1.0
11/30/2019 11:00	8.5	13.3	6.6	115.1	3,283,483.7	1,990.1	1.1	0.8
11/30/2019 12:00	8.7	13.2	6.7	122.8	3,261,937.0	2,048.5	1.2	1.0
11/30/2019 13:00	8.6	13.2	6.6	122.0	3,256,523.0	2,045.1	1.2	1.0
11/30/2019 14:00	8.5	13.2	6.5	121.6	3,258,433.9	2,046.3	1.2	1.0
11/30/2019 15:00	8.5	13.2	6.5	119.7	3,271,796.5	2,030.8	1.2	1.0
11/30/2019 16:00	8.5	13.2	6.5	120.1	3,269,218.8	2,029.2	1.2	1.0
11/30/2019 17:00	8.5	13.2	6.5	121.5	3,289,518.5	2,041.8	1.2	1.0
11/30/2019 18:00	8.5	13.2	6.5	118.2	3,292,161.4	2,019.4	1.1	0.8
11/30/2019 19:00	8.7	13.1	6.6	126.3	3,275,127.9	2,080.7	1.2	1.0
11/30/2019 20:00	8.6	13.2	6.6	122.3	3,263,529.4	2,049.5	1.2	1.0
11/30/2019 21:00	8.5	13.2	6.5	120.5	3,272,924.3	2,031.5	1.2	1.0
11/30/2019 22:00	8.4	13.3	6.5	115.4	3,287,113.5	1,992.3	1.1	0.8
11/30/2019 23:00	8.4	13.3	6.5	113.3	3,302,483.8	1,977.5	1.1	0.8
Average/Sum#:	8.6	13.2	6.6	120.2	3,283,167.5	2,033.8	1.2	1.0
Minimum:	8.4	13.1	6.5	113.3	3,256,523.0	1,977.5	1.1	0.8
Maximum:	8.8	13.3	6.7	126.3	3,320,365.1	2,080.7	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/01/2019 00:00	8.5	13.2	6.5	117.9	3,287,107.6	2,016.3	1.1	0.8
12/01/2019 01:00	8.4	13.3	6.5	113.1	3,300,646.8	1,976.4	1.1	0.8
12/01/2019 02:00	8.4	13.3	6.5	113.1	3,299,143.7	1,975.5	1.1	0.8
12/01/2019 03:00	8.5	13.3	6.6	113.1	3,299,143.7	1,975.5	1.1	0.8
12/01/2019 04:00	8.4	13.3	6.5	112.7	3,293,298.6	1,972.0	1.1	0.8
12/01/2019 05:00	8.4	13.3	6.5	112.5	3,294,467.7	1,972.7	1.1	0.8
12/01/2019 06:00	8.5	13.3	6.6	113.6	3,283,445.5	1,966.1	1.1	0.8
12/01/2019 07:00	8.7	13.3	6.8	113.3	3,294,467.7	1,972.7	1.1	0.8
12/01/2019 08:00	8.7	13.2	6.7	121.4	3,299,023.9	2,047.7	1.2	1.0
12/01/2019 09:00	8.6	13.2	6.6	121.3	3,295,157.3	2,045.3	1.2	1.0
12/01/2019 10:00	8.6	13.2	6.6	121.9	3,267,032.6	2,051.7	1.2	1.0
12/01/2019 11:00	8.5	13.2	6.5	120.3	3,279,529.7	2,035.6	1.2	1.0
12/01/2019 12:00	8.4	13.3	6.5	113.3	3,258,405.1	1,974.9	1.1	0.8
12/01/2019 13:00	8.5	13.2	6.5	116.2	3,252,382.9	1,995.0	1.1	0.8
12/01/2019 14:00	8.4	13.2	6.4	115.1	3,275,729.1	1,985.4	1.1	0.8
12/01/2019 15:00	8.5	13.3	6.6	115.8	3,249,448.4	1,993.2	1.1	0.8
12/01/2019 16:00	8.5	13.2	6.5	116.1	3,252,056.9	1,994.8	1.1	0.8
12/01/2019 17:00	8.6	13.2	6.6	121.5	3,246,491.2	2,038.8	1.2	1.0
12/01/2019 18:00	8.6	13.1	6.5	127.8	3,241,956.6	2,083.3	1.3	1.0
12/01/2019 19:00	8.6	13.1	6.5	132.4	3,242,612.3	2,107.4	1.3	1.1
12/01/2019 20:00	8.5	13.1	6.4	127.2	3,227,795.5	2,074.2	1.3	1.0
12/01/2019 21:00	8.4	13.2	6.4	118.8	3,246,985.8	2,015.4	1.2	1.0
12/01/2019 22:00	8.4	13.2	6.4	115.6	3,244,068.5	1,989.9	1.1	0.8
12/01/2019 23:00	8.4	13.3	6.5	115.1	3,232,982.7	1,983.1	1.1	0.8
Average/Sum#:	8.5	13.2	6.5	117.9	3,269,307.5	2,010.1	1.2	0.9
Minimum:	8.4	13.1	6.4	112.5	3,227,795.5	1,966.1	1.1	0.8
Maximum:	8.7	13.3	6.8	132.4	3,300,646.8	2,107.4	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/02/2019 00:00	8.4	13.3	6.5	113.3	3,250,815.5	1,970.3	1.1	0.8
12/02/2019 01:00	8.4	13.3	6.5	113.8	3,254,610.3	1,972.6	1.1	0.8
12/02/2019 02:00	8.4	13.3	6.5	114.0	3,255,930.2	1,973.4	1.1	0.8
12/02/2019 03:00	8.5	13.3	6.6	113.5	3,248,835.6	1,969.1	1.1	0.8
12/02/2019 04:00	8.5	13.3	6.6	113.1	3,242,071.0	1,965.0	1.1	0.8
12/02/2019 05:00	8.5	13.2	6.5	113.5	3,247,350.7	1,968.2	1.1	0.8
12/02/2019 06:00	8.9	13.1	6.7	123.3	3,173,217.9	2,062.3	1.3	1.0
12/02/2019 07:00	9.0	13.0	6.7	133.4	3,211,148.0	2,110.4	1.3	1.1
12/02/2019 08:00	8.5	13.2	6.5	118.2	3,229,263.8	2,004.4	1.2	1.0
12/02/2019 09:00	8.4	13.3	6.5	113.3	3,247,350.7	1,968.2	1.1	0.8
12/02/2019 10:00	8.5	13.2	6.5	115.7	3,239,666.8	1,987.2	1.1	0.8
12/02/2019 11:00	8.4	13.2	6.4	115.4	3,230,700.4	1,981.7	1.1	0.8
12/02/2019 12:00	8.6	13.1	6.5	122.5	3,246,650.4	2,038.9	1.2	1.0
12/02/2019 13:00	8.5	13.2	6.5	118.2	3,228,297.2	2,003.8	1.2	1.0
12/02/2019 14:00	8.6	13.1	6.5	124.0	3,224,600.9	2,048.6	1.2	1.0
12/02/2019 15:00	8.5	13.1	6.4	122.1	3,200,517.9	2,033.3	1.2	1.0
12/02/2019 16:00	8.6	13.1	6.5	128.2	3,195,374.9	2,076.7	1.3	1.0
12/02/2019 17:00	8.6	13.0	6.4	133.5	3,220,581.8	2,116.6	1.3	1.1
12/02/2019 18:00	8.6	13.0	6.4	134.7	3,193,618.1	2,122.2	1.4	1.1
12/02/2019 19:00	8.6	13.0	6.4	134.8	3,194,671.5	2,122.9	1.4	1.1
12/02/2019 20:00	8.7	13.0	6.5	134.7	3,191,962.7	2,121.1	1.4	1.1
12/02/2019 21:00	8.6	13.0	6.4	132.2	3,202,322.8	2,104.6	1.3	1.1
12/02/2019 22:00	8.4	13.1	6.4	121.3	3,231,363.8	2,029.3	1.2	1.0
12/02/2019 23:00	8.5	13.2	6.5	119.1	3,213,847.9	2,018.3	1.2	1.0
Average/Sum#:	8.6	13.2	6.5	121.9	3,223,948.8	2,032.0	1.2	1.0
Minimum:	8.4	13.0	6.4	113.1	3,173,217.9	1,965.0	1.1	0.8
Maximum:	9.0	13.3	6.7	134.8	3,255,930.2	2,122.9	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/03/2019 00:00	8.5	13.1	6.4	120.0	3,224,676.0	2,025.1	1.2	1.0
12/03/2019 01:00	8.4	13.2	6.4	114.8	3,229,559.2	1,981.0	1.1	0.8
12/03/2019 02:00	8.5	13.2	6.5	114.6	3,219,940.6	1,975.1	1.1	0.8
12/03/2019 03:00	8.5	13.2	6.5	115.6	3,190,919.9	1,980.6	1.2	1.0
12/03/2019 04:00	8.6	13.2	6.6	118.4	3,187,733.3	2,001.9	1.2	1.0
12/03/2019 05:00	8.6	13.2	6.6	119.6	3,199,357.5	2,009.2	1.2	1.0
12/03/2019 06:00	8.9	13.1	6.7	124.4	3,164,926.5	2,033.8	1.3	1.0
12/03/2019 07:00	9.0	13.1	6.8	129.7	3,194,297.8	2,076.0	1.3	1.0
12/03/2019 08:00	8.8	13.1	6.7	127.9	3,182,142.2	2,068.1	1.3	1.0
12/03/2019 09:00	8.6	13.1	6.5	123.5	3,174,885.9	2,040.2	1.3	1.0
12/03/2019 10:00	8.6	13.1	6.5	118.5	3,174,676.0	1,993.7	1.2	1.0
12/03/2019 11:00	8.9	13.1	6.7	128.6	3,143,213.6	2,042.8	1.3	1.0
12/03/2019 12:00	8.9	13.0	6.6	131.7	3,148,306.7	2,069.1	1.4	1.0
12/03/2019 13:00	8.9	13.0	6.6	132.0	3,136,433.3	2,084.2	1.4	1.0
12/03/2019 14:00	8.9	13.0	6.6	131.9	3,129,360.4	2,079.5	1.4	1.0
12/03/2019 15:00	8.9	13.0	6.6	130.5	3,117,171.1	2,071.4	1.4	1.0
12/03/2019 16:00	8.8	13.0	6.6	128.8	3,154,446.0	2,050.1	1.3	1.0
12/03/2019 17:00	8.6	13.0	6.4	132.9	3,150,893.3	2,070.8	1.4	1.0
12/03/2019 18:00	8.6	13.0	6.4	132.8	3,180,449.7	2,067.0	1.4	1.0
12/03/2019 19:00	8.7	13.0	6.5	131.7	3,161,564.5	2,100.9	1.4	1.1
12/03/2019 20:00	8.7	13.0	6.5	131.0	3,149,977.1	2,093.2	1.3	1.0
12/03/2019 21:00	8.5	13.0	6.3	129.3	3,171,739.0	2,084.5	1.3	1.0
12/03/2019 22:00	8.4	13.1	6.4	122.1	3,170,373.1	2,037.3	1.2	1.0
12/03/2019 23:00	8.5	13.1	6.4	120.0	3,181,471.9	2,021.2	1.2	1.0
Average/Sum#:	8.7	13.1	6.5	125.4	3,172,438.1	2,044.0	1.3	1.0
Minimum:	8.4	13.0	6.3	114.6	3,117,171.1	1,975.1	1.1	0.8
Maximum:	9.0	13.2	6.8	132.9	3,229,559.2	2,100.9	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/04/2019 00:00	8.7	13.1	6.6	125.5	3,202,274.4	2,057.8	1.3	1.0
12/04/2019 01:00	8.5	13.1	6.4	122.3	3,209,962.2	2,039.3	1.2	1.0
12/04/2019 02:00	8.4	13.2	6.4	116.7	3,182,637.8	1,998.7	1.2	1.0
12/04/2019 03:00	8.5	13.2	6.5	117.9	3,196,013.6	2,007.1	1.2	1.0
12/04/2019 04:00	8.6	13.1	6.5	121.8	3,208,230.8	2,038.2	1.2	1.0
12/04/2019 05:00	8.4	13.2	6.4	116.0	3,208,803.0	1,991.7	1.2	1.0
12/04/2019 06:00	8.8	13.1	6.7	119.7	3,170,373.1	2,037.3	1.2	1.0
12/04/2019 07:00	8.9	13.1	6.7	128.3	3,198,913.8	2,079.0	1.3	1.0
12/04/2019 08:00	8.6	13.1	6.5	126.4	3,189,066.3	2,072.6	1.3	1.0
12/04/2019 09:00	8.6	13.1	6.5	126.6	3,193,374.6	2,075.4	1.3	1.0
12/04/2019 10:00	8.5	13.1	6.4	125.1	3,209,121.6	2,062.2	1.3	1.0
12/04/2019 11:00	8.6	13.0	6.4	130.1	3,188,476.4	2,095.5	1.3	1.0
12/04/2019 12:00	8.6	13.0	6.4	126.7	3,183,065.4	2,068.7	1.3	1.0
12/04/2019 13:00	8.5	13.1	6.4	123.5	3,180,643.7	2,043.9	1.3	1.0
12/04/2019 14:00	8.7	13.0	6.5	131.6	3,192,280.4	2,098.0	1.3	1.0
12/04/2019 15:00	8.6	13.0	6.4	127.7	3,186,296.6	2,070.8	1.3	1.0
12/04/2019 16:00	8.6	13.0	6.4	127.6	3,184,604.1	2,069.7	1.3	1.0
12/04/2019 17:00	8.5	13.1	6.4	124.5	3,189,513.9	2,049.6	1.3	1.0
12/04/2019 18:00	8.7	13.0	6.5	131.9	3,201,257.7	2,103.9	1.3	1.1
12/04/2019 19:00	8.6	13.0	6.4	131.8	3,198,823.2	2,102.3	1.3	1.1
12/04/2019 20:00	8.7	13.0	6.5	132.3	3,168,336.4	2,105.4	1.4	1.1
12/04/2019 21:00	8.6	13.0	6.4	131.2	3,189,845.9	2,096.4	1.3	1.0
12/04/2019 22:00	8.6	13.0	6.4	126.9	3,185,681.2	2,070.4	1.3	1.0
12/04/2019 23:00	8.5	13.1	6.4	121.2	3,202,249.4	2,034.4	1.2	1.0
Average/Sum#:	8.6	13.1	6.5	125.6	3,192,493.6	2,061.2	1.3	1.0
Minimum:	8.4	13.0	6.4	116.0	3,168,336.4	1,991.7	1.2	1.0
Maximum:	8.9	13.2	6.7	132.3	3,209,962.2	2,105.4	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/05/2019 00:00	8.6	13.1	6.5	122.0	3,186,868.4	2,047.9	1.2	1.0
12/05/2019 01:00	8.6	13.1	6.5	122.5	3,191,381.3	2,050.8	1.2	1.0
12/05/2019 02:00	8.5	13.1	6.4	121.9	3,220,980.6	2,046.3	1.2	1.0
12/05/2019 03:00	8.5	13.1	6.4	122.0	3,221,767.6	2,046.8	1.2	1.0
12/05/2019 04:00	8.4	13.1	6.4	118.7	3,216,395.7	2,019.9	1.2	1.0
12/05/2019 05:00	8.4	13.2	6.4	117.4	3,199,198.3	2,009.1	1.2	1.0
12/05/2019 06:00	8.7	13.1	6.6	123.8	3,210,119.6	2,039.4	1.2	1.0
12/05/2019 07:00	8.7	13.1	6.6	119.3	3,207,000.8	2,014.0	1.2	1.0
12/05/2019 08:00	8.4	13.2	6.4	113.3	3,209,506.9	1,968.7	1.1	0.8
12/05/2019 09:00	8.4	13.2	6.4	114.3	3,190,597.7	1,980.4	1.1	0.8
12/05/2019 10:00	8.4	13.2	6.4	114.4	3,275,018.7	2,032.8	1.1	0.8
12/05/2019 11:00	8.4	13.2	6.4	115.1	3,281,785.3	2,037.0	1.1	0.8
12/05/2019 12:00	8.5	13.2	6.5	116.1	3,299,023.9	2,047.7	1.1	0.8
12/05/2019 13:00	8.4	13.2	6.4	116.2	3,293,546.2	2,044.3	1.1	0.8
12/05/2019 14:00	8.5	13.2	6.5	115.6	3,283,879.7	2,038.3	1.1	0.8
12/05/2019 15:00	8.5	13.2	6.5	116.6	3,286,779.6	2,040.1	1.1	0.8
12/05/2019 16:00	8.4	13.2	6.4	125.7	3,281,624.2	2,036.9	1.2	1.0
12/05/2019 17:00	8.3	13.2	6.4	130.9	3,271,313.2	2,030.5	1.3	1.0
12/05/2019 18:00	8.3	13.2	6.4	131.3	3,278,402.0	2,034.9	1.3	1.0
12/05/2019 19:00	8.3	13.2	6.4	132.2	3,283,396.3	2,038.0	1.3	1.0
12/05/2019 20:00	8.3	13.2	6.4	131.8	3,259,230.0	2,046.8	1.3	1.0
12/05/2019 21:00	8.3	13.2	6.4	132.2	3,288,712.9	2,041.3	1.3	1.0
12/05/2019 22:00	8.3	13.2	6.4	126.5	3,271,796.5	2,030.8	1.2	1.0
12/05/2019 23:00	8.3	13.2	6.4	124.0	3,296,726.2	2,022.2	1.2	1.0
Average/Sum#:	8.4	13.2	6.4	121.8	3,250,210.5	2,031.0	1.2	0.9
Minimum:	8.3	13.1	6.4	113.3	3,186,868.4	1,968.7	1.1	0.8
Maximum:	8.7	13.2	6.6	132.2	3,299,023.9	2,050.8	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/06/2019 00:00	8.3	13.2	6.4	117.0	3,290,368.1	2,018.3	1.1	0.8
12/06/2019 01:00	8.3	13.2	6.4	116.6	3,276,510.9	2,009.8	1.1	0.8
12/06/2019 02:00	8.3	13.3	6.4	117.1	3,266,077.2	2,003.4	1.1	0.8
12/06/2019 03:00	8.4	13.2	6.4	117.5	3,295,095.9	2,021.2	1.1	0.8
12/06/2019 04:00	8.5	13.2	6.5	115.7	3,294,512.9	2,044.9	1.1	0.8
12/06/2019 05:00	8.5	13.2	6.5	115.0	3,289,035.2	2,041.5	1.1	0.8
12/06/2019 06:00	8.7	13.2	6.7	114.9	3,282,796.9	2,061.6	1.1	0.8
12/06/2019 07:00	8.7	13.2	6.7	119.0	3,273,561.2	2,055.8	1.2	1.0
12/06/2019 08:00	8.5	13.2	6.5	116.7	3,285,974.1	2,039.6	1.1	0.8
12/06/2019 09:00	8.5	13.2	6.5	114.6	3,273,890.9	2,032.1	1.1	0.8
12/06/2019 10:00	8.6	13.2	6.6	116.7	3,279,852.0	2,035.8	1.1	0.8
12/06/2019 11:00	8.5	13.2	6.5	119.9	3,254,719.0	2,020.2	1.2	1.0
12/06/2019 12:00	8.5	13.2	6.5	123.8	3,266,240.2	2,003.5	1.2	1.0
12/06/2019 13:00	8.5	13.2	6.5	125.5	3,240,808.0	1,987.9	1.2	1.0
12/06/2019 14:00	8.5	13.3	6.6	125.0	3,259,230.0	1,975.4	1.2	1.0
12/06/2019 15:00	8.5	13.3	6.6	124.6	3,256,920.2	1,974.0	1.2	1.0
12/06/2019 16:00	8.4	13.3	6.5	126.8	3,259,725.0	1,975.7	1.2	1.0
12/06/2019 17:00	8.4	13.3	6.5	125.5	3,257,085.2	1,974.1	1.2	1.0
12/06/2019 18:00	8.3	13.3	6.4	129.5	3,257,250.1	1,974.2	1.3	1.0
12/06/2019 19:00	8.3	13.3	6.4	129.1	3,256,095.2	1,973.5	1.3	1.0
12/06/2019 20:00	8.4	13.3	6.5	126.5	3,257,745.1	1,974.5	1.2	1.0
12/06/2019 21:00	8.3	13.3	6.4	130.6	3,255,890.0	1,949.6	1.3	1.0
12/06/2019 22:00	8.1	13.5	6.5	130.4	3,278,893.6	1,867.6	1.3	0.9
12/06/2019 23:00	8.1	13.5	6.5	130.7	3,296,578.0	1,853.6	1.3	0.9
Average/Sum#:	8.4	13.3	6.5	122.0	3,271,035.6	1,994.5	1.2	0.9
Minimum:	8.1	13.2	6.4	114.6	3,240,808.0	1,853.6	1.1	0.8
Maximum:	8.7	13.5	6.7	130.7	3,296,578.0	2,061.6	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/07/2019 00:00	8.3	13.4	6.5	126.6	3,271,726.0	1,911.3	1.2	1.0
12/07/2019 01:00	8.7	13.1	6.6	120.2	3,263,637.4	2,073.4	1.2	1.0
12/07/2019 02:00	8.6	13.2	6.6	116.5	3,261,618.6	2,048.3	1.1	0.8
12/07/2019 03:00	8.6	13.1	6.5	116.9	3,264,166.3	2,049.9	1.1	0.8
12/07/2019 04:00	8.7	13.1	6.6	117.4	3,265,281.0	2,050.6	1.1	0.8
12/07/2019 05:00	8.7	13.1	6.6	116.9	3,254,612.2	2,043.9	1.1	0.8
12/07/2019 06:00	8.9	13.1	6.7	117.0	3,260,822.4	2,047.8	1.1	0.8
12/07/2019 07:00	9.0	13.1	6.8	121.9	3,231,211.9	2,052.8	1.2	1.0
12/07/2019 08:00	8.8	13.1	6.7	122.9	3,233,553.3	2,077.9	1.2	1.0
12/07/2019 09:00	8.8	13.1	6.7	121.9	3,229,818.5	2,075.5	1.2	1.0
12/07/2019 10:00	8.8	13.1	6.7	120.3	3,236,721.1	2,056.3	1.2	1.0
12/07/2019 11:00	8.8	13.1	6.7	121.5	3,209,121.6	2,062.2	1.2	1.0
12/07/2019 12:00	8.8	13.1	6.7	121.4	3,210,677.7	2,063.2	1.2	1.0
12/07/2019 13:00	8.7	13.1	6.6	120.3	3,244,906.2	2,061.5	1.2	1.0
12/07/2019 14:00	8.8	13.1	6.7	120.5	3,246,795.0	2,062.7	1.2	1.0
12/07/2019 15:00	8.7	13.1	6.6	118.6	3,221,610.2	2,046.7	1.2	1.0
12/07/2019 16:00	8.8	13.1	6.7	120.1	3,234,989.6	2,055.2	1.2	1.0
12/07/2019 17:00	8.8	13.1	6.7	119.7	3,235,461.9	2,055.5	1.2	1.0
12/07/2019 18:00	8.9	13.1	6.7	125.9	3,235,996.0	2,103.1	1.2	1.1
12/07/2019 19:00	8.8	13.1	6.7	123.1	3,257,985.1	2,093.6	1.2	1.0
12/07/2019 20:00	8.8	13.1	6.7	124.1	3,227,225.5	2,097.4	1.2	1.0
12/07/2019 21:00	8.7	13.1	6.6	123.0	3,262,498.0	2,096.5	1.2	1.0
12/07/2019 22:00	8.7	13.1	6.6	120.2	3,265,841.0	2,074.8	1.2	1.0
12/07/2019 23:00	8.7	13.1	6.6	120.1	3,258,600.4	2,070.2	1.2	1.0
Average/Sum#:	8.7	13.1	6.7	120.7	3,245,203.2	2,059.6	1.2	1.0
Minimum:	8.3	13.1	6.5	116.5	3,209,121.6	1,911.3	1.1	0.8
Maximum:	9.0	13.4	6.8	126.6	3,271,726.0	2,103.1	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/08/2019 00:00	8.8	13.1	6.7	121.6	3,237,755.0	2,080.6	1.2	1.0
12/08/2019 01:00	8.2	13.3	6.4	110.6	3,198,018.4	1,938.3	1.1	0.8
12/08/2019 02:00	7.4	13.8	6.1	95.5	3,014,609.6	1,607.0	1.0	0.6
12/08/2019 03:00	7.7	13.8	6.4	87.9	2,758,358.4	1,470.4	1.0	0.6
12/08/2019 04:00	7.7	13.8	6.4	95.9	3,014,046.8	1,606.7	1.0	0.6
12/08/2019 05:00	7.7	13.8	6.4	98.8	3,141,797.2	1,674.8	1.0	0.7
12/08/2019 06:00	7.8	13.8	6.5	98.0	3,163,370.3	1,686.3	1.0	0.7
12/08/2019 07:00	7.8	13.8	6.5	97.8	3,127,352.6	1,667.1	1.0	0.7
12/08/2019 08:00	7.7	13.8	6.4	96.1	3,092,648.0	1,648.6	1.0	0.7
12/08/2019 09:00	7.7	13.8	6.4	96.4	3,097,337.8	1,651.1	1.0	0.7
12/08/2019 10:00	7.7	13.8	6.4	88.6	2,826,829.6	1,506.9	1.0	0.6
12/08/2019 11:00	7.7	13.8	6.4	93.0	2,992,286.1	1,595.1	1.0	0.6
12/08/2019 12:00	7.8	13.8	6.5	89.1	2,836,584.4	1,512.1	1.0	0.6
12/08/2019 13:00	7.8	13.8	6.5	97.1	3,113,658.3	1,659.8	1.0	0.7
12/08/2019 14:00	8.0	13.7	6.6	97.3	3,077,503.7	1,663.0	1.0	0.7
12/08/2019 15:00	8.6	13.4	6.8	105.0	3,189,744.4	1,886.7	1.0	0.8
12/08/2019 16:00	9.0	13.2	6.9	117.6	3,276,307.6	2,033.6	1.1	0.8
12/08/2019 17:00	8.8	13.2	6.7	116.3	3,268,091.0	2,028.5	1.1	0.8
12/08/2019 18:00	8.8	13.2	6.7	120.5	3,298,401.9	2,071.4	1.2	1.0
12/08/2019 19:00	8.7	13.1	6.6	121.7	3,279,692.7	2,083.6	1.2	1.0
12/08/2019 20:00	8.7	13.1	6.6	122.2	3,285,831.5	2,087.5	1.2	1.0
12/08/2019 21:00	8.6	13.2	6.6	117.9	3,300,151.7	2,048.4	1.1	0.8
12/08/2019 22:00	8.8	13.1	6.7	122.0	3,276,387.2	2,081.5	1.2	1.0
12/08/2019 23:00	8.8	13.1	6.7	123.6	3,292,757.3	2,091.9	1.2	1.0
Average/Sum#:	8.2	13.5	6.5	105.4	3,131,646.7	1,807.5	1.1	0.8
Minimum:	7.4	13.1	6.1	87.9	2,758,358.4	1,470.4	1.0	0.6
Maximum:	9.0	13.8	6.9	123.6	3,300,151.7	2,091.9	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/09/2019 00:00	8.7	13.2	6.7	120.5	3,293,943.3	2,068.6	1.2	1.0
12/09/2019 01:00	8.6	13.3	6.7	115.6	3,309,279.2	2,029.9	1.1	0.8
12/09/2019 02:00	8.6	13.3	6.7	114.1	3,321,761.6	2,013.3	1.1	0.8
12/09/2019 03:00	8.6	13.3	6.7	114.6	3,291,672.3	2,019.1	1.1	0.8
12/09/2019 04:00	8.8	13.2	6.7	119.6	3,319,484.7	2,060.4	1.1	0.8
12/09/2019 05:00	8.7	13.2	6.7	118.6	3,306,273.8	2,052.2	1.1	0.8
12/09/2019 06:00	8.9	13.2	6.8	122.2	3,315,295.9	2,057.8	1.2	1.0
12/09/2019 07:00	8.9	13.2	6.8	122.8	3,324,835.0	2,088.0	1.2	1.0
12/09/2019 08:00	8.6	13.2	6.6	120.8	3,316,554.8	2,082.8	1.2	1.0
12/09/2019 09:00	8.7	13.2	6.7	121.0	3,307,956.1	2,077.4	1.2	1.0
12/09/2019 10:00	8.6	13.3	6.7	116.1	3,310,583.4	2,030.7	1.1	0.8
12/09/2019 11:00	8.6	13.3	6.7	115.4	3,302,595.1	2,025.8	1.1	0.8
12/09/2019 12:00	8.6	13.3	6.7	115.4	3,293,628.7	2,020.3	1.1	0.8
12/09/2019 13:00	8.7	13.2	6.7	116.6	3,306,507.8	2,028.2	1.1	0.8
12/09/2019 14:00	8.7	13.3	6.8	115.0	3,285,966.4	2,015.6	1.1	0.8
12/09/2019 15:00	8.7	13.2	6.7	118.9	3,261,937.0	2,048.5	1.2	1.0
12/09/2019 16:00	8.6	13.2	6.6	116.8	3,288,712.9	2,041.3	1.1	0.8
12/09/2019 17:00	8.7	13.2	6.7	122.9	3,289,766.6	2,090.0	1.2	1.0
12/09/2019 18:00	8.8	13.1	6.7	130.2	3,302,005.3	2,146.0	1.3	1.1
12/09/2019 19:00	8.7	13.1	6.6	131.5	3,285,705.6	2,159.4	1.3	1.1
12/09/2019 20:00	8.7	13.1	6.6	131.2	3,324,162.3	2,160.4	1.3	1.1
12/09/2019 21:00	8.5	13.2	6.5	122.5	3,305,507.1	2,100.0	1.2	1.1
12/09/2019 22:00	8.6	13.2	6.6	121.6	3,335,663.0	2,094.8	1.2	1.0
12/09/2019 23:00	8.5	13.2	6.5	119.7	3,361,050.8	2,086.2	1.1	0.8
Average/Sum#:	8.7	13.2	6.7	120.2	3,306,702.0	2,066.5	1.2	0.9
Minimum:	8.5	13.1	6.5	114.1	3,261,937.0	2,013.3	1.1	0.8
Maximum:	8.9	13.3	6.8	131.5	3,361,050.8	2,160.4	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/10/2019 00:00	8.5	13.2	6.5	122.0	3,363,370.0	2,112.2	1.2	1.1
12/10/2019 01:00	8.5	13.2	6.5	121.5	3,358,433.7	2,109.1	1.2	1.1
12/10/2019 02:00	8.6	13.2	6.6	121.5	3,350,153.4	2,103.9	1.2	1.1
12/10/2019 03:00	8.6	13.2	6.6	122.5	3,367,669.3	2,114.9	1.2	1.1
12/10/2019 04:00	8.6	13.2	6.6	123.2	3,340,293.7	2,122.1	1.2	1.1
12/10/2019 05:00	8.5	13.2	6.5	120.9	3,388,439.3	2,103.2	1.1	0.8
12/10/2019 06:00	8.7	13.2	6.7	121.9	3,367,350.9	2,114.7	1.2	1.1
12/10/2019 07:00	8.9	13.1	6.7	125.5	3,367,997.0	2,139.7	1.2	1.1
12/10/2019 08:00	8.5	13.2	6.5	117.6	3,390,955.6	2,080.0	1.1	0.8
12/10/2019 09:00	8.6	13.2	6.6	120.6	3,356,363.6	2,107.8	1.1	0.8
12/10/2019 10:00	8.4	13.3	6.5	114.4	3,380,168.4	2,048.7	1.1	0.8
12/10/2019 11:00	8.5	13.3	6.6	114.1	3,365,484.2	2,039.8	1.1	0.8
12/10/2019 12:00	8.5	13.2	6.5	115.9	3,349,220.8	2,054.4	1.1	0.8
12/10/2019 13:00	8.5	13.2	6.5	115.8	3,344,330.0	2,051.4	1.1	0.8
12/10/2019 14:00	8.5	13.2	6.5	116.5	3,314,168.1	2,057.1	1.1	0.8
12/10/2019 15:00	8.5	13.2	6.5	115.1	3,334,874.4	2,045.6	1.1	0.8
12/10/2019 16:00	8.5	13.2	6.5	117.2	3,321,740.2	2,061.8	1.1	0.8
12/10/2019 17:00	8.7	13.1	6.6	125.4	3,312,295.2	2,128.5	1.2	1.1
12/10/2019 18:00	8.7	13.1	6.6	128.3	3,306,775.2	2,149.1	1.2	1.1
12/10/2019 19:00	8.6	13.1	6.5	129.6	3,310,775.8	2,151.7	1.3	1.1
12/10/2019 20:00	8.6	13.1	6.5	129.5	3,312,468.3	2,152.8	1.3	1.1
12/10/2019 21:00	8.5	13.1	6.4	124.4	3,333,682.6	2,117.9	1.2	1.1
12/10/2019 22:00	8.5	13.2	6.5	118.9	3,349,450.9	2,079.0	1.1	0.8
12/10/2019 23:00	8.5	13.2	6.5	118.5	3,341,717.7	2,074.2	1.1	0.8
Average/Sum#:	8.6	13.2	6.5	120.9	3,347,007.4	2,096.7	1.2	1.0
Minimum:	8.4	13.1	6.4	114.1	3,306,775.2	2,039.8	1.1	0.8
Maximum:	8.9	13.3	6.7	129.6	3,390,955.6	2,152.8	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/11/2019 00:00	8.6	13.1	6.5	121.4	3,344,102.5	2,100.1	1.2	1.1
12/11/2019 01:00	8.6	13.1	6.5	121.3	3,338,847.7	2,096.8	1.2	1.0
12/11/2019 02:00	8.5	13.2	6.5	118.1	3,336,723.3	2,071.1	1.1	0.8
12/11/2019 03:00	8.4	13.3	6.5	112.5	3,336,445.8	2,022.2	1.1	0.8
12/11/2019 04:00	8.5	13.2	6.5	114.9	3,334,711.4	2,045.5	1.1	0.8
12/11/2019 05:00	8.5	13.2	6.5	117.4	3,328,023.5	2,065.7	1.1	0.8
12/11/2019 06:00	8.8	13.2	6.7	120.5	3,269,033.9	2,100.7	1.2	1.1
12/11/2019 07:00	8.8	13.1	6.7	121.8	3,334,229.9	2,093.9	1.2	1.0
12/11/2019 08:00	8.5	13.2	6.5	117.9	3,325,123.5	2,063.9	1.1	0.8
12/11/2019 09:00	8.4	13.2	6.4	113.8	3,317,104.5	2,034.7	1.1	0.8
12/11/2019 10:00	8.5	13.2	6.5	115.2	3,337,319.8	2,047.1	1.1	0.8
12/11/2019 11:00	8.4	13.2	6.4	113.3	3,307,975.0	2,029.1	1.1	0.8
12/11/2019 12:00	8.5	13.2	6.5	114.0	3,312,050.7	2,031.6	1.1	0.8
12/11/2019 13:00	8.5	13.2	6.5	113.9	3,312,213.7	2,031.7	1.1	0.8
12/11/2019 14:00	8.5	13.2	6.5	117.1	3,314,973.7	2,057.6	1.1	0.8
12/11/2019 15:00	8.5	13.2	6.5	113.9	3,305,692.6	2,027.7	1.1	0.8
12/11/2019 16:00	8.5	13.2	6.5	115.5	3,332,103.0	2,043.9	1.1	0.8
12/11/2019 17:00	8.6	13.1	6.5	122.2	3,304,405.3	2,099.3	1.2	1.0
12/11/2019 18:00	8.5	13.2	6.5	119.1	3,304,134.4	2,075.0	1.2	1.0
12/11/2019 19:00	8.7	13.1	6.6	126.2	3,321,321.0	2,134.3	1.2	1.1
12/11/2019 20:00	8.5	13.1	6.4	120.3	3,316,236.3	2,082.6	1.2	1.0
12/11/2019 21:00	8.5	13.2	6.5	116.8	3,308,529.3	2,053.6	1.1	0.8
12/11/2019 22:00	8.5	13.2	6.5	115.5	3,326,234.0	2,040.3	1.1	0.8
12/11/2019 23:00	8.5	13.2	6.5	115.9	3,291,129.6	2,042.8	1.1	0.8
Average/Sum#:	8.5	13.2	6.5	117.4	3,319,111.0	2,062.1	1.1	0.9
Minimum:	8.4	13.1	6.4	112.5	3,269,033.9	2,022.2	1.1	0.8
Maximum:	8.8	13.3	6.7	126.2	3,344,102.5	2,134.3	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/12/2019 00:00	8.5	13.2	6.5	115.7	3,323,136.5	2,038.4	1.1	0.8
12/12/2019 01:00	8.5	13.2	6.5	114.6	3,304,062.4	2,026.7	1.1	0.8
12/12/2019 02:00	8.6	13.2	6.6	115.3	3,316,941.5	2,034.6	1.1	0.8
12/12/2019 03:00	8.6	13.2	6.6	115.6	3,319,712.9	2,036.3	1.1	0.8
12/12/2019 04:00	8.6	13.2	6.6	115.2	3,316,615.4	2,034.4	1.1	0.8
12/12/2019 05:00	8.5	13.2	6.5	114.7	3,314,170.0	2,032.9	1.1	0.8
12/12/2019 06:00	8.8	13.2	6.7	119.4	3,276,702.0	2,081.7	1.2	1.0
12/12/2019 07:00	8.9	13.1	6.7	125.2	3,319,988.4	2,109.2	1.2	1.1
12/12/2019 08:00	8.5	13.2	6.5	115.2	3,339,602.2	2,048.5	1.1	0.8
12/12/2019 09:00	8.5	13.2	6.5	114.5	3,327,538.2	2,041.1	1.1	0.8
12/12/2019 10:00	8.4	13.2	6.4	112.3	3,333,640.9	2,020.5	1.1	0.8
12/12/2019 11:00	8.4	13.2	6.4	111.9	3,325,721.4	2,015.7	1.1	0.8
12/12/2019 12:00	8.4	13.2	6.4	113.5	3,309,931.3	2,030.3	1.1	0.8
12/12/2019 13:00	8.5	13.2	6.5	113.8	3,313,517.9	2,032.5	1.1	0.8
12/12/2019 14:00	8.5	13.2	6.5	114.8	3,284,685.2	2,038.8	1.1	0.8
12/12/2019 15:00	8.5	13.2	6.5	115.0	3,285,813.0	2,039.5	1.1	0.8
12/12/2019 16:00	8.5	13.2	6.5	115.4	3,294,351.7	2,044.8	1.1	0.8
12/12/2019 17:00	8.6	13.1	6.5	121.3	3,294,174.0	2,092.8	1.2	1.0
12/12/2019 18:00	8.6	13.1	6.5	121.6	3,271,056.9	2,102.0	1.2	1.1
12/12/2019 19:00	8.5	13.1	6.4	120.6	3,275,127.9	2,080.7	1.2	1.0
12/12/2019 20:00	8.4	13.2	6.4	116.3	3,270,535.7	2,053.9	1.1	0.8
12/12/2019 21:00	8.5	13.2	6.5	116.7	3,316,907.0	2,058.8	1.1	0.8
12/12/2019 22:00	8.4	13.2	6.4	115.7	3,300,635.0	2,048.7	1.1	0.8
12/12/2019 23:00	7.7	13.5	6.1	102.4	3,206,735.4	1,826.5	1.0	0.7
Average/Sum#:	8.5	13.2	6.5	115.7	3,301,721.0	2,040.4	1.1	0.8
Minimum:	7.7	13.1	6.1	102.4	3,206,735.4	1,826.5	1.0	0.7
Maximum:	8.9	13.5	6.7	125.2	3,339,602.2	2,109.2	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/13/2019 00:00	7.4	13.8	6.1	85.2	2,730,031.9	1,455.3	1.0	0.6
12/13/2019 01:00	7.5	13.8	6.2	87.6	2,847,089.6	1,517.7	1.0	0.6
12/13/2019 02:00	7.7	13.8	6.4	80.7	2,609,410.0	1,391.0	1.0	0.6
12/13/2019 03:00	7.7	13.8	6.4	82.7	2,689,324.4	1,433.6	1.0	0.6
12/13/2019 04:00	7.8	13.8	6.5	98.4	3,191,321.6	1,701.2	1.0	0.7
12/13/2019 05:00	7.8	13.8	6.5	83.6	2,640,925.5	1,407.8	1.0	0.6
12/13/2019 06:00	7.9	13.8	6.6	84.8	2,622,916.7	1,398.2	1.0	0.6
12/13/2019 07:00	7.8	13.8	6.5	92.5	2,974,277.2	1,585.5	1.0	0.6
12/13/2019 08:00	7.7	13.8	6.4	97.4	3,160,368.8	1,684.7	1.0	0.7
12/13/2019 09:00	7.6	13.8	6.3	95.2	3,081,955.2	1,642.9	1.0	0.7
12/13/2019 10:00	7.7	13.8	6.4	98.3	3,181,754.4	1,696.1	1.0	0.7
12/13/2019 11:00	7.7	13.8	6.4	93.8	3,008,794.2	1,603.9	1.0	0.6
12/13/2019 12:00	7.7	13.8	6.4	86.9	2,808,633.1	1,497.2	1.0	0.6
12/13/2019 13:00	7.9	13.8	6.6	97.3	3,123,600.7	1,665.1	1.0	0.7
12/13/2019 14:00	8.1	13.8	6.7	101.1	3,232,211.7	1,746.6	1.0	0.7
12/13/2019 15:00	9.2	13.2	7.0	115.1	3,250,263.6	1,993.7	1.1	0.8
12/13/2019 16:00	9.0	13.1	6.8	120.5	3,253,720.9	2,067.1	1.2	1.0
12/13/2019 17:00	8.8	13.1	6.7	119.5	3,244,119.1	2,061.0	1.2	1.0
12/13/2019 18:00	8.9	13.1	6.7	126.3	3,251,998.2	2,113.5	1.2	1.1
12/13/2019 19:00	8.7	13.2	6.7	119.9	3,243,174.7	2,060.4	1.2	1.0
12/13/2019 20:00	8.8	13.1	6.7	122.0	3,272,452.1	2,079.0	1.2	1.0
12/13/2019 21:00	8.8	13.1	6.7	121.4	3,254,507.9	2,067.6	1.2	1.0
12/13/2019 22:00	8.8	13.2	6.7	121.6	3,257,656.0	2,069.6	1.2	1.0
12/13/2019 23:00	8.8	13.2	6.7	120.5	3,277,064.4	2,058.0	1.2	1.0
Average/Sum#:	8.2	13.6	6.5	102.2	3,050,315.5	1,749.9	1.1	0.8
Minimum:	7.4	13.1	6.1	80.7	2,609,410.0	1,391.0	1.0	0.6
Maximum:	9.2	13.8	7.0	126.3	3,277,064.4	2,113.5	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/14/2019 00:00	8.7	13.2	6.7	118.1	3,295,962.8	2,045.8	1.1	0.8
12/14/2019 01:00	8.2	13.3	6.4	111.5	3,237,781.2	1,962.4	1.1	0.8
12/14/2019 02:00	7.1	13.8	5.9	91.6	3,013,859.2	1,606.6	1.0	0.6
12/14/2019 03:00	7.3	13.8	6.1	89.6	2,929,630.2	1,561.7	1.0	0.6
12/14/2019 04:00	7.4	13.8	6.1	97.2	3,179,690.9	1,695.0	1.0	0.7
12/14/2019 05:00	7.4	13.8	6.1	94.2	3,061,320.1	1,631.9	1.0	0.7
12/14/2019 06:00	7.6	13.8	6.3	91.7	2,939,947.8	1,567.2	1.0	0.6
12/14/2019 07:00	7.8	13.8	6.5	88.2	2,798,690.7	1,491.9	1.0	0.6
12/14/2019 08:00	7.7	13.8	6.4	86.5	2,791,187.0	1,487.9	1.0	0.6
12/14/2019 09:00	7.6	13.8	6.3	95.4	3,088,521.0	1,646.4	1.0	0.7
12/14/2019 10:00	7.6	13.8	6.3	92.1	2,971,088.1	1,583.8	1.0	0.6
12/14/2019 11:00	7.6	13.8	6.3	93.5	3,023,801.6	1,611.9	1.0	0.6
12/14/2019 12:00	7.7	13.9	6.5	81.4	2,636,522.3	1,386.2	1.0	0.6
12/14/2019 13:00	7.7	13.8	6.4	95.7	3,108,968.5	1,657.3	1.0	0.7
12/14/2019 14:00	7.6	13.8	6.3	93.6	3,014,609.6	1,607.0	1.0	0.6
12/14/2019 15:00	8.0	13.8	6.6	94.5	3,025,489.9	1,612.8	1.0	0.6
12/14/2019 16:00	9.1	13.3	7.1	114.5	3,284,173.1	2,014.5	1.1	0.8
12/14/2019 17:00	8.9	13.2	6.8	120.6	3,310,185.4	2,078.8	1.2	1.0
12/14/2019 18:00	8.8	13.2	6.7	120.9	3,313,210.8	2,080.7	1.2	1.0
12/14/2019 19:00	8.7	13.2	6.7	118.0	3,314,651.4	2,057.4	1.1	0.8
12/14/2019 20:00	8.9	13.2	6.8	124.3	3,312,275.6	2,104.3	1.2	1.1
12/14/2019 21:00	8.7	13.2	6.7	122.6	3,350,312.7	2,104.0	1.2	1.1
12/14/2019 22:00	8.4	13.2	6.4	116.6	3,312,557.0	2,056.1	1.1	0.8
12/14/2019 23:00	7.9	13.4	6.2	105.1	3,343,620.8	1,953.3	1.0	0.8
Average/Sum#:	8.0	13.6	6.4	102.4	3,110,752.4	1,775.2	1.1	0.7
Minimum:	7.1	13.2	5.9	81.4	2,636,522.3	1,386.2	1.0	0.6
Maximum:	9.1	13.9	7.1	124.3	3,350,312.7	2,104.3	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/15/2019 00:00	8.5	13.3	6.6	114.4	3,357,234.6	2,034.8	1.1	0.8
12/15/2019 01:00	8.5	13.3	6.6	113.2	3,336,115.8	2,022.0	1.1	0.8
12/15/2019 02:00	8.6	13.2	6.6	118.3	3,332,051.2	2,068.2	1.1	0.8
12/15/2019 03:00	8.6	13.2	6.6	120.3	3,364,111.8	2,088.1	1.1	0.8
12/15/2019 04:00	8.5	13.2	6.5	120.6	3,379,256.1	2,097.5	1.1	0.8
12/15/2019 05:00	8.4	13.3	6.5	116.2	3,357,046.1	2,059.2	1.1	0.8
12/15/2019 06:00	8.6	13.3	6.7	115.5	3,371,392.4	2,068.0	1.1	0.8
12/15/2019 07:00	8.1	13.4	6.4	109.0	3,311,132.9	1,958.5	1.0	0.8
12/15/2019 08:00	7.3	13.8	6.1	91.9	2,990,597.7	1,594.2	1.0	0.6
12/15/2019 09:00	7.3	13.8	6.1	94.6	3,090,209.3	1,647.3	1.0	0.7
12/15/2019 10:00	7.4	13.8	6.1	89.2	2,900,928.6	1,546.4	1.0	0.6
12/15/2019 11:00	7.4	13.8	6.1	90.7	2,950,077.8	1,572.6	1.0	0.6
12/15/2019 12:00	7.4	13.8	6.1	89.7	2,917,436.7	1,555.2	1.0	0.6
12/15/2019 13:00	7.5	13.8	6.2	95.0	3,092,085.2	1,648.3	1.0	0.7
12/15/2019 14:00	7.4	13.8	6.1	91.4	2,961,145.7	1,578.5	1.0	0.6
12/15/2019 15:00	7.9	13.8	6.6	92.3	2,953,454.5	1,574.4	1.0	0.6
12/15/2019 16:00	8.9	13.3	6.9	112.6	3,362,103.9	2,013.2	1.1	0.8
12/15/2019 17:00	8.8	13.3	6.8	117.9	3,367,153.7	2,065.4	1.1	0.8
12/15/2019 18:00	8.8	13.1	6.7	126.4	3,369,885.8	2,140.9	1.2	1.1
12/15/2019 19:00	8.7	13.1	6.6	130.7	3,334,779.2	2,167.3	1.3	1.1
12/15/2019 20:00	8.7	13.1	6.6	129.7	3,362,559.3	2,160.8	1.2	1.1
12/15/2019 21:00	8.6	13.1	6.5	128.1	3,355,712.2	2,156.4	1.2	1.1
12/15/2019 22:00	8.5	13.2	6.5	120.9	3,337,733.1	2,096.1	1.2	1.0
12/15/2019 23:00	8.5	13.2	6.5	117.7	3,381,011.0	2,073.9	1.1	0.8
Average/Sum#:	8.2	13.4	6.5	110.3	3,230,633.9	1,916.1	1.1	0.8
Minimum:	7.3	13.1	6.1	89.2	2,900,928.6	1,546.4	1.0	0.6
Maximum:	8.9	13.8	6.9	130.7	3,381,011.0	2,167.3	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/16/2019 00:00	8.6	13.2	6.6	121.4	3,352,701.2	2,105.5	1.2	1.1
12/16/2019 01:00	8.6	13.2	6.6	121.5	3,353,019.7	2,105.7	1.2	1.1
12/16/2019 02:00	8.5	13.2	6.5	120.6	3,382,156.0	2,099.3	1.1	0.8
12/16/2019 03:00	8.5	13.2	6.5	122.0	3,403,261.3	2,112.4	1.1	0.8
12/16/2019 04:00	8.6	13.2	6.6	122.0	3,400,200.2	2,110.5	1.1	0.8
12/16/2019 05:00	8.6	13.2	6.6	120.3	3,373,617.2	2,094.0	1.1	0.8
12/16/2019 06:00	9.0	13.1	6.8	131.3	3,388,702.9	2,177.6	1.2	1.1
12/16/2019 07:00	8.8	13.1	6.7	126.8	3,410,185.2	2,141.6	1.2	1.1
12/16/2019 08:00	8.4	13.3	6.5	111.7	3,422,208.4	2,024.2	1.0	0.8
12/16/2019 09:00	8.5	13.3	6.6	112.1	3,375,297.1	2,021.1	1.1	0.8
12/16/2019 10:00	8.6	13.3	6.7	115.0	3,363,999.2	2,038.9	1.1	0.8
12/16/2019 11:00	8.6	13.3	6.7	114.7	3,352,284.9	2,031.8	1.1	0.8
12/16/2019 12:00	8.7	13.3	6.8	115.7	3,355,419.7	2,033.7	1.1	0.8
12/16/2019 13:00	8.7	13.3	6.8	115.8	3,356,904.6	2,034.6	1.1	0.8
12/16/2019 14:00	8.7	13.3	6.8	116.6	3,338,135.0	2,047.6	1.1	0.8
12/16/2019 15:00	8.7	13.3	6.8	118.2	3,362,262.9	2,062.4	1.1	0.8
12/16/2019 16:00	8.6	13.2	6.6	120.4	3,359,117.5	2,085.0	1.1	0.8
12/16/2019 17:00	8.6	13.2	6.6	126.9	3,327,078.8	2,138.0	1.2	1.1
12/16/2019 18:00	8.6	13.2	6.6	129.2	3,350,110.0	2,152.8	1.2	1.1
12/16/2019 19:00	8.6	13.1	6.5	131.5	3,372,518.8	2,167.2	1.3	1.1
12/16/2019 20:00	8.5	13.1	6.4	130.3	3,372,518.8	2,167.2	1.2	1.1
12/16/2019 21:00	8.4	13.2	6.4	128.3	3,363,493.0	2,161.4	1.2	1.1
12/16/2019 22:00	8.3	13.2	6.4	123.4	3,389,166.1	2,128.4	1.2	1.1
12/16/2019 23:00	8.4	13.3	6.5	117.3	3,399,107.0	2,085.0	1.1	0.8
Average/Sum#:	8.6	13.2	6.6	121.4	3,371,811.1	2,096.9	1.1	0.9
Minimum:	8.3	13.1	6.4	111.7	3,327,078.8	2,021.1	1.0	0.8
Maximum:	9.0	13.3	6.8	131.5	3,422,208.4	2,177.6	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/17/2019 00:00	8.5	13.2	6.5	119.5	3,376,195.0	2,095.6	1.1	0.8
12/17/2019 01:00	8.5	13.2	6.5	121.0	3,403,744.6	2,112.7	1.1	0.8
12/17/2019 02:00	8.5	13.2	6.5	120.7	3,402,133.5	2,111.7	1.1	0.8
12/17/2019 03:00	8.4	13.2	6.4	120.3	3,394,883.6	2,107.2	1.1	0.8
12/17/2019 04:00	8.3	13.3	6.4	115.6	3,450,454.5	2,091.3	1.1	0.8
12/17/2019 05:00	8.4	13.3	6.5	115.6	3,440,390.0	2,085.2	1.1	0.8
12/17/2019 06:00	8.7	13.2	6.7	124.4	3,374,608.0	2,143.9	1.2	1.1
12/17/2019 07:00	8.7	13.2	6.7	121.4	3,439,671.8	2,135.0	1.1	0.9
12/17/2019 08:00	8.5	13.3	6.6	117.3	3,416,387.8	2,095.6	1.1	0.8
12/17/2019 09:00	8.3	13.3	6.4	112.8	3,431,577.1	2,054.8	1.0	0.8
12/17/2019 10:00	8.4	13.3	6.5	112.1	3,410,033.7	2,041.9	1.0	0.8
12/17/2019 11:00	8.4	13.3	6.5	112.8	3,412,705.8	2,043.5	1.0	0.8
12/17/2019 12:00	8.4	13.3	6.5	113.5	3,383,963.1	2,051.0	1.1	0.8
12/17/2019 13:00	8.5	13.3	6.6	115.2	3,400,792.2	2,061.2	1.1	0.8
12/17/2019 14:00	8.6	13.2	6.6	118.3	3,360,889.7	2,086.1	1.1	0.8
12/17/2019 15:00	8.6	13.2	6.6	120.9	3,355,726.7	2,107.4	1.2	1.1
12/17/2019 16:00	8.6	13.2	6.6	124.0	3,381,204.3	2,123.4	1.2	1.1
12/17/2019 17:00	8.6	13.2	6.6	129.0	3,369,728.4	2,140.8	1.2	1.1
12/17/2019 18:00	8.5	13.2	6.5	132.6	3,348,006.5	2,127.0	1.3	1.1
12/17/2019 19:00	8.4	13.2	6.4	132.9	3,363,529.2	2,112.3	1.3	1.1
12/17/2019 20:00	8.6	13.1	6.5	131.3	3,354,467.3	2,155.6	1.3	1.1
12/17/2019 21:00	8.7	13.1	6.6	129.5	3,334,163.7	2,166.9	1.3	1.1
12/17/2019 22:00	8.7	13.1	6.6	129.3	3,362,714.9	2,160.9	1.2	1.1
12/17/2019 23:00	8.4	13.2	6.4	118.4	3,368,945.1	2,091.1	1.1	0.8
Average/Sum#:	8.5	13.2	6.5	121.2	3,389,038.2	2,104.3	1.1	0.9
Minimum:	8.3	13.1	6.4	112.1	3,334,163.7	2,041.9	1.0	0.8
Maximum:	8.7	13.3	6.7	132.9	3,450,454.5	2,166.9	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/18/2019 00:00	8.4	13.2	6.4	117.6	3,397,150.6	2,083.8	1.1	0.8
12/18/2019 01:00	8.6	13.2	6.6	120.7	3,354,293.6	2,106.5	1.1	0.8
12/18/2019 02:00	8.6	13.2	6.6	120.8	3,348,561.1	2,102.9	1.2	1.1
12/18/2019 03:00	8.5	13.2	6.5	121.0	3,358,592.9	2,109.2	1.2	1.1
12/18/2019 04:00	8.5	13.2	6.5	121.7	3,367,987.8	2,115.1	1.2	1.1
12/18/2019 05:00	8.6	13.1	6.5	125.5	3,342,173.6	2,147.7	1.2	1.1
12/18/2019 06:00	8.9	13.1	6.7	132.7	3,368,937.9	2,189.5	1.3	1.1
12/18/2019 07:00	8.8	13.1	6.7	128.3	3,378,276.6	2,170.9	1.2	1.1
12/18/2019 08:00	8.5	13.1	6.4	122.0	3,383,752.1	2,125.0	1.2	1.1
12/18/2019 09:00	8.4	13.2	6.4	119.9	3,358,274.4	2,109.0	1.1	0.8
12/18/2019 10:00	8.4	13.2	6.4	119.4	3,386,828.2	2,102.2	1.1	0.8
12/18/2019 11:00	8.5	13.1	6.4	121.5	3,369,102.5	2,115.8	1.2	1.1
12/18/2019 12:00	8.4	13.2	6.4	119.3	3,342,828.6	2,099.3	1.1	0.8
12/18/2019 13:00	8.4	13.2	6.4	119.0	3,378,611.6	2,097.1	1.1	0.8
12/18/2019 14:00	8.4	13.2	6.4	117.8	3,361,534.1	2,086.5	1.1	0.8
12/18/2019 15:00	8.4	13.2	6.4	115.2	3,364,708.3	2,063.9	1.1	0.8
12/18/2019 16:00	8.5	13.2	6.5	120.4	3,383,606.0	2,100.2	1.1	0.8
12/18/2019 17:00	8.5	13.1	6.4	126.4	3,374,293.2	2,143.7	1.2	1.1
12/18/2019 18:00	8.6	13.1	6.5	128.1	3,341,703.2	2,171.8	1.2	1.1
12/18/2019 19:00	8.5	13.1	6.4	127.4	3,366,761.0	2,163.5	1.2	1.1
12/18/2019 20:00	8.5	13.1	6.4	127.3	3,344,011.3	2,173.3	1.2	1.1
12/18/2019 21:00	8.5	13.1	6.4	127.7	3,362,559.3	2,160.8	1.2	1.1
12/18/2019 22:00	8.5	13.1	6.4	127.0	3,377,441.3	2,145.7	1.2	1.1
12/18/2019 23:00	8.4	13.2	6.4	118.4	3,377,000.5	2,096.1	1.1	0.8
Average/Sum#:	8.5	13.2	6.5	122.7	3,366,207.9	2,124.1	1.2	1.0
Minimum:	8.4	13.1	6.4	115.2	3,341,703.2	2,063.9	1.1	0.8
Maximum:	8.9	13.2	6.7	132.7	3,397,150.6	2,189.5	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/19/2019 00:00	8.5	13.1	6.4	120.2	3,360,185.3	2,110.2	1.1	0.8
12/19/2019 01:00	8.5	13.1	6.4	120.6	3,359,229.9	2,109.6	1.2	1.1
12/19/2019 02:00	8.4	13.2	6.4	120.1	3,350,949.6	2,104.4	1.1	0.8
12/19/2019 03:00	8.4	13.2	6.4	118.8	3,373,456.1	2,093.9	1.1	0.8
12/19/2019 04:00	8.4	13.2	6.4	120.2	3,353,178.9	2,105.8	1.1	0.8
12/19/2019 05:00	8.4	13.2	6.4	118.9	3,366,206.2	2,089.4	1.1	0.8
12/19/2019 06:00	8.8	13.1	6.7	127.1	3,343,395.8	2,172.9	1.2	1.1
12/19/2019 07:00	8.7	13.1	6.6	126.1	3,347,931.4	2,151.4	1.2	1.1
12/19/2019 08:00	8.3	13.3	6.4	113.1	3,370,103.9	2,042.6	1.1	0.8
12/19/2019 09:00	8.4	13.3	6.5	115.6	3,365,686.5	2,064.5	1.1	0.8
12/19/2019 10:00	8.3	13.3	6.4	112.4	3,353,439.8	2,032.5	1.1	0.8
12/19/2019 11:00	8.4	13.3	6.5	112.7	3,354,429.8	2,033.1	1.1	0.8
12/19/2019 12:00	8.4	13.3	6.5	112.7	3,348,985.1	2,029.8	1.1	0.8
12/19/2019 13:00	8.4	13.3	6.5	114.0	3,323,299.5	2,038.5	1.1	0.8
12/19/2019 14:00	8.4	13.3	6.5	112.9	3,343,045.4	2,026.2	1.1	0.8
12/19/2019 15:00	8.5	13.2	6.5	118.2	3,343,167.7	2,075.1	1.1	0.8
12/19/2019 16:00	8.5	13.2	6.5	119.6	3,318,465.6	2,084.0	1.2	1.0
12/19/2019 17:00	8.5	13.1	6.4	124.6	3,325,497.6	2,112.7	1.2	1.1
12/19/2019 18:00	8.4	13.1	6.4	126.7	3,331,006.8	2,116.2	1.2	1.1
12/19/2019 19:00	8.5	13.1	6.4	124.9	3,330,191.1	2,140.0	1.2	1.1
12/19/2019 20:00	8.5	13.1	6.4	124.7	3,333,614.7	2,142.2	1.2	1.1
12/19/2019 21:00	8.5	13.1	6.4	124.9	3,341,395.5	2,147.2	1.2	1.1
12/19/2019 22:00	8.4	13.1	6.4	119.7	3,344,898.7	2,100.6	1.1	0.8
12/19/2019 23:00	8.4	13.2	6.4	118.3	3,363,467.4	2,087.7	1.1	0.8
Average/Sum#:	8.5	13.2	6.5	119.5	3,347,717.8	2,092.1	1.1	0.9
Minimum:	8.3	13.1	6.4	112.4	3,318,465.6	2,026.2	1.1	0.8
Maximum:	8.8	13.3	6.7	127.1	3,373,456.1	2,172.9	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/20/2019 00:00	8.5	13.2	6.5	120.1	3,349,835.0	2,103.7	1.1	0.8
12/20/2019 01:00	8.4	13.2	6.4	118.6	3,327,223.5	2,089.5	1.1	0.8
12/20/2019 02:00	8.5	13.2	6.5	119.1	3,336,777.7	2,095.5	1.1	0.8
12/20/2019 03:00	8.3	13.3	6.4	113.0	3,365,814.1	2,040.0	1.1	0.8
12/20/2019 04:00	8.5	13.2	6.5	117.6	3,366,664.6	2,065.1	1.1	0.8
12/20/2019 05:00	8.5	13.2	6.5	118.9	3,371,845.1	2,092.9	1.1	0.8
12/20/2019 06:00	8.8	13.1	6.7	121.9	3,334,469.7	2,118.4	1.2	1.1
12/20/2019 07:00	8.6	13.2	6.6	117.0	3,375,305.1	2,070.4	1.1	0.8
12/20/2019 08:00	8.4	13.3	6.5	111.9	3,350,800.0	2,030.9	1.1	0.8
12/20/2019 09:00	8.4	13.3	6.5	113.4	3,372,743.8	2,044.2	1.1	0.8
12/20/2019 10:00	8.1	13.4	6.4	107.5	3,290,168.9	1,946.1	1.0	0.8
12/20/2019 11:00	7.1	13.8	5.9	93.2	3,092,085.2	1,648.3	0.9	0.5
12/20/2019 12:00	7.3	13.8	6.1	91.0	2,998,476.6	1,598.4	0.9	0.5
12/20/2019 13:00	7.5	13.8	6.2	95.1	3,113,095.6	1,659.5	1.0	0.7
12/20/2019 14:00	7.9	13.8	6.6	91.5	2,949,139.8	1,572.1	1.0	0.6
12/20/2019 15:00	9.0	13.2	6.9	115.3	3,309,768.3	2,030.2	1.1	0.8
12/20/2019 16:00	8.8	13.2	6.7	118.9	3,295,854.2	2,069.8	1.1	0.8
12/20/2019 17:00	8.7	13.1	6.6	123.5	3,286,929.8	2,112.2	1.2	1.1
12/20/2019 18:00	8.7	13.1	6.6	126.4	3,286,772.4	2,136.1	1.2	1.1
12/20/2019 19:00	8.5	13.1	6.4	121.8	3,307,553.4	2,101.3	1.2	1.1
12/20/2019 20:00	8.5	13.1	6.4	121.2	3,303,146.1	2,098.5	1.2	1.0
12/20/2019 21:00	8.5	13.1	6.4	121.2	3,301,414.6	2,097.4	1.2	1.0
12/20/2019 22:00	8.5	13.1	6.4	121.8	3,307,396.0	2,101.2	1.2	1.1
12/20/2019 23:00	8.4	13.1	6.4	120.7	3,334,707.6	2,094.2	1.2	1.0
Average/Sum#:	8.4	13.3	6.5	114.2	3,280,332.8	2,000.7	1.1	0.9
Minimum:	7.1	13.1	5.9	91.0	2,949,139.8	1,572.1	0.9	0.5
Maximum:	9.0	13.8	6.9	126.4	3,375,305.1	2,136.1	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/21/2019 00:00	8.4	13.2	6.4	116.9	3,322,545.8	2,062.3	1.1	0.8
12/21/2019 01:00	8.4	13.2	6.4	115.2	3,338,624.0	2,047.9	1.1	0.8
12/21/2019 02:00	8.4	13.2	6.4	119.1	3,319,261.8	2,084.5	1.1	0.8
12/21/2019 03:00	8.4	13.2	6.4	119.4	3,321,809.5	2,086.1	1.1	0.8
12/21/2019 04:00	8.4	13.2	6.4	120.6	3,331,045.2	2,091.9	1.2	1.0
12/21/2019 05:00	8.4	13.2	6.4	121.2	3,339,643.9	2,097.3	1.2	1.0
12/21/2019 06:00	8.6	13.2	6.6	119.6	3,307,000.7	2,076.8	1.2	1.0
12/21/2019 07:00	8.7	13.1	6.6	123.0	3,353,815.9	2,106.2	1.2	1.1
12/21/2019 08:00	8.5	13.2	6.5	121.1	3,342,828.6	2,099.3	1.2	1.0
12/21/2019 09:00	8.4	13.2	6.4	119.9	3,329,134.4	2,090.7	1.2	1.0
12/21/2019 10:00	8.4	13.2	6.4	117.0	3,330,440.1	2,067.2	1.1	0.8
12/21/2019 11:00	8.3	13.3	6.4	113.3	3,360,039.5	2,036.5	1.1	0.8
12/21/2019 12:00	8.4	13.2	6.4	113.6	3,317,267.5	2,034.8	1.1	0.8
12/21/2019 13:00	8.4	13.2	6.4	114.4	3,327,864.3	2,041.3	1.1	0.8
12/21/2019 14:00	8.5	13.2	6.5	117.0	3,320,934.7	2,061.3	1.1	0.8
12/21/2019 15:00	8.5	13.2	6.5	116.1	3,344,330.0	2,051.4	1.1	0.8
12/21/2019 16:00	8.5	13.2	6.5	114.9	3,321,180.2	2,037.2	1.1	0.8
12/21/2019 17:00	8.5	13.2	6.5	115.5	3,329,331.5	2,042.2	1.1	0.8
12/21/2019 18:00	8.6	13.2	6.6	117.0	3,309,657.1	2,054.3	1.1	0.8
12/21/2019 19:00	8.5	13.2	6.5	117.8	3,322,545.8	2,062.3	1.1	0.8
12/21/2019 20:00	8.7	13.2	6.7	120.4	3,311,140.8	2,079.4	1.2	1.0
12/21/2019 21:00	8.6	13.2	6.6	119.8	3,300,312.8	2,072.6	1.2	1.0
12/21/2019 22:00	8.7	13.1	6.6	122.4	3,305,821.9	2,100.2	1.2	1.1
12/21/2019 23:00	8.6	13.1	6.5	121.5	3,341,395.5	2,098.4	1.2	1.0
Average/Sum#:	8.5	13.2	6.5	118.2	3,326,998.8	2,070.1	1.1	0.9
Minimum:	8.3	13.1	6.4	113.3	3,300,312.8	2,034.8	1.1	0.8
Maximum:	8.7	13.3	6.7	123.0	3,360,039.5	2,106.2	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/22/2019 00:00	8.5	13.1	6.4	120.4	3,332,478.3	2,092.8	1.2	1.0
12/22/2019 01:00	8.5	13.2	6.5	117.0	3,321,740.2	2,061.8	1.1	0.8
12/22/2019 02:00	8.6	13.1	6.5	122.1	3,310,701.5	2,103.3	1.2	1.1
12/22/2019 03:00	8.6	13.1	6.5	122.7	3,320,460.6	2,109.5	1.2	1.1
12/22/2019 04:00	8.6	13.1	6.5	120.1	3,314,644.0	2,081.6	1.2	1.0
12/22/2019 05:00	8.6	13.1	6.5	119.2	3,301,905.1	2,073.6	1.2	1.0
12/22/2019 06:00	8.8	13.1	6.7	122.8	3,271,056.9	2,102.0	1.2	1.1
12/22/2019 07:00	8.9	13.1	6.7	124.9	3,283,039.3	2,109.7	1.2	1.1
12/22/2019 08:00	8.6	13.1	6.5	122.0	3,287,563.0	2,088.6	1.2	1.0
12/22/2019 09:00	8.6	13.1	6.5	120.9	3,320,058.0	2,085.0	1.2	1.0
12/22/2019 10:00	8.6	13.1	6.5	121.0	3,320,217.2	2,085.1	1.2	1.0
12/22/2019 11:00	8.6	13.2	6.6	118.2	3,284,070.8	2,062.4	1.1	0.8
12/22/2019 12:00	8.6	13.2	6.6	117.8	3,313,040.4	2,056.4	1.1	0.8
12/22/2019 13:00	8.7	13.1	6.6	121.5	3,279,850.1	2,083.7	1.2	1.0
12/22/2019 14:00	8.6	13.1	6.5	119.3	3,282,319.2	2,061.3	1.2	1.0
12/22/2019 15:00	8.6	13.1	6.5	118.6	3,275,153.6	2,056.8	1.2	1.0
12/22/2019 16:00	8.5	13.2	6.5	114.2	3,293,954.7	2,020.5	1.1	0.8
12/22/2019 17:00	8.5	13.2	6.5	113.8	3,299,008.6	2,023.6	1.1	0.8
12/22/2019 18:00	8.5	13.2	6.5	115.3	3,286,940.7	2,040.2	1.1	0.8
12/22/2019 19:00	8.5	13.2	6.5	115.4	3,292,901.8	2,043.9	1.1	0.8
12/22/2019 20:00	8.5	13.2	6.5	117.1	3,325,744.9	2,040.0	1.1	0.8
12/22/2019 21:00	8.4	13.2	6.4	117.5	3,307,322.9	2,028.7	1.1	0.8
12/22/2019 22:00	8.4	13.3	6.5	114.2	3,310,420.4	2,030.6	1.1	0.8
12/22/2019 23:00	8.5	13.2	6.5	115.3	3,347,264.5	2,053.2	1.1	0.8
Average/Sum#:	8.6	13.2	6.5	118.8	3,303,410.7	2,066.4	1.2	0.9
Minimum:	8.4	13.1	6.4	113.8	3,271,056.9	2,020.5	1.1	0.8
Maximum:	8.9	13.3	6.7	124.9	3,347,264.5	2,109.7	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/23/2019 00:00	8.5	13.2	6.5	116.1	3,315,295.9	2,057.8	1.1	0.8
12/23/2019 01:00	8.4	13.2	6.4	113.8	3,320,365.1	2,036.7	1.1	0.8
12/23/2019 02:00	8.5	13.2	6.5	114.3	3,326,397.0	2,040.4	1.1	0.8
12/23/2019 03:00	8.5	13.2	6.5	116.2	3,357,698.2	2,059.6	1.1	0.8
12/23/2019 04:00	8.4	13.2	6.4	115.1	3,339,928.3	2,048.7	1.1	0.8
12/23/2019 05:00	8.4	13.3	6.5	114.0	3,324,277.7	2,039.1	1.1	0.8
12/23/2019 06:00	8.6	13.3	6.7	114.9	3,341,721.6	2,049.8	1.1	0.8
12/23/2019 07:00	8.8	13.3	6.8	116.7	3,350,688.0	2,055.3	1.1	0.8
12/23/2019 08:00	8.8	13.1	6.7	131.1	3,330,377.1	2,115.8	1.3	1.1
12/23/2019 09:00	8.8	13.1	6.7	124.3	3,333,997.5	2,118.1	1.2	1.1
12/23/2019 10:00	8.8	13.1	6.7	124.0	3,323,766.1	2,111.6	1.2	1.1
12/23/2019 11:00	8.8	13.1	6.7	125.4	3,292,687.6	2,115.9	1.2	1.1
12/23/2019 12:00	8.8	13.1	6.7	126.0	3,289,886.5	2,114.1	1.2	1.1
12/23/2019 13:00	8.7	13.2	6.7	119.6	3,282,159.9	2,061.2	1.2	1.0
12/23/2019 14:00	8.8	13.2	6.7	122.3	3,279,377.9	2,083.4	1.2	1.0
12/23/2019 15:00	8.7	13.2	6.7	119.5	3,279,452.9	2,059.5	1.2	1.0
12/23/2019 16:00	8.6	13.2	6.6	117.8	3,306,918.2	2,052.6	1.1	0.8
12/23/2019 17:00	8.6	13.2	6.6	116.7	3,296,285.0	2,046.0	1.1	0.8
12/23/2019 18:00	8.6	13.2	6.6	117.0	3,300,957.2	2,048.9	1.1	0.8
12/23/2019 19:00	8.6	13.2	6.6	119.3	3,338,012.2	2,071.9	1.1	0.8
12/23/2019 20:00	8.7	13.1	6.6	125.5	3,343,599.2	2,124.2	1.2	1.1
12/23/2019 21:00	8.6	13.1	6.5	122.9	3,314,479.2	2,105.7	1.2	1.1
12/23/2019 22:00	8.6	13.2	6.6	121.4	3,344,421.0	2,100.3	1.2	1.1
12/23/2019 23:00	8.5	13.2	6.5	119.6	3,387,633.7	2,102.7	1.1	0.8
Average/Sum#:	8.6	13.2	6.6	119.7	3,321,682.6	2,075.8	1.2	0.9
Minimum:	8.4	13.1	6.4	113.8	3,279,377.9	2,036.7	1.1	0.8
Maximum:	8.8	13.3	6.8	131.1	3,387,633.7	2,124.2	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/24/2019 00:00	8.5	13.2	6.5	118.9	3,371,361.7	2,092.6	1.1	0.8
12/24/2019 01:00	8.4	13.3	6.5	114.2	3,377,528.5	2,047.1	1.1	0.8
12/24/2019 02:00	8.3	13.3	6.4	113.1	3,370,763.9	2,043.0	1.1	0.8
12/24/2019 03:00	8.4	13.3	6.5	112.9	3,372,413.8	2,044.0	1.1	0.8
12/24/2019 04:00	8.4	13.3	6.5	113.9	3,379,673.4	2,048.4	1.1	0.8
12/24/2019 05:00	8.4	13.3	6.5	114.2	3,381,653.3	2,049.6	1.1	0.8
12/24/2019 06:00	8.6	13.3	6.7	116.7	3,372,370.6	2,068.6	1.1	0.8
12/24/2019 07:00	8.5	13.3	6.6	114.4	3,408,216.8	2,065.7	1.1	0.8
12/24/2019 08:00	8.4	13.3	6.5	112.4	3,437,088.2	2,058.1	1.0	0.8
12/24/2019 09:00	8.4	13.3	6.5	112.4	3,376,208.6	2,046.3	1.1	0.8
12/24/2019 10:00	8.4	13.3	6.5	112.7	3,369,608.9	2,042.3	1.1	0.8
12/24/2019 11:00	8.4	13.3	6.5	113.4	3,358,389.6	2,035.5	1.1	0.8
12/24/2019 12:00	8.5	13.3	6.6	115.6	3,332,592.1	2,044.2	1.1	0.8
12/24/2019 13:00	8.4	13.3	6.5	113.4	3,353,109.8	2,032.3	1.1	0.8
12/24/2019 14:00	8.4	13.3	6.5	113.8	3,363,999.2	2,038.9	1.1	0.8
12/24/2019 15:00	8.6	13.2	6.6	118.5	3,352,512.0	2,080.9	1.1	0.8
12/24/2019 16:00	8.4	13.3	6.5	113.6	3,322,321.4	2,037.9	1.1	0.8
12/24/2019 17:00	8.4	13.2	6.4	115.3	3,353,948.6	2,057.3	1.1	0.8
12/24/2019 18:00	8.4	13.3	6.5	114.7	3,344,982.1	2,051.8	1.1	0.8
12/24/2019 19:00	8.4	13.3	6.5	113.6	3,367,464.1	2,041.0	1.1	0.8
12/24/2019 20:00	8.4	13.3	6.5	113.8	3,330,635.7	2,043.0	1.1	0.8
12/24/2019 21:00	8.4	13.3	6.5	113.6	3,369,773.9	2,042.4	1.1	0.8
12/24/2019 22:00	8.4	13.3	6.5	114.9	3,347,753.5	2,053.5	1.1	0.8
12/24/2019 23:00	8.4	13.3	6.5	113.2	3,357,894.6	2,035.2	1.1	0.8
Average/Sum#:	8.4	13.3	6.5	114.3	3,365,511.0	2,050.0	1.1	0.8
Minimum:	8.3	13.2	6.4	112.4	3,322,321.4	2,032.3	1.0	0.8
Maximum:	8.6	13.3	6.7	118.9	3,437,088.2	2,092.6	1.1	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/25/2019 00:00	8.4	13.2	6.4	116.1	3,323,190.2	2,062.7	1.1	0.8
12/25/2019 01:00	8.4	13.2	6.4	117.5	3,332,051.2	2,068.2	1.1	0.8
12/25/2019 02:00	8.4	13.2	6.4	121.1	3,336,562.2	2,071.0	1.2	1.0
12/25/2019 03:00	8.3	13.3	6.4	113.4	3,374,228.7	2,045.1	1.1	0.8
12/25/2019 04:00	8.4	13.3	6.5	114.8	3,334,385.3	2,045.3	1.1	0.8
12/25/2019 05:00	8.4	13.3	6.5	113.4	3,368,949.0	2,041.9	1.1	0.8
12/25/2019 06:00	8.6	13.3	6.7	113.7	3,362,679.3	2,038.1	1.1	0.8
12/25/2019 07:00	8.6	13.3	6.7	121.0	3,353,296.4	2,056.9	1.1	0.8
12/25/2019 08:00	8.4	13.3	6.5	112.2	3,354,429.8	2,033.1	1.1	0.8
12/25/2019 09:00	8.4	13.3	6.5	113.7	3,344,003.9	2,051.2	1.1	0.8
12/25/2019 10:00	8.4	13.3	6.5	113.5	3,379,508.4	2,048.3	1.1	0.8
12/25/2019 11:00	8.4	13.3	6.5	113.3	3,333,570.2	2,044.8	1.1	0.8
12/25/2019 12:00	8.4	13.2	6.4	114.2	3,344,003.9	2,051.2	1.1	0.8
12/25/2019 13:00	8.4	13.2	6.4	113.8	3,332,918.1	2,044.4	1.1	0.8
12/25/2019 14:00	8.4	13.2	6.4	116.6	3,333,179.0	2,068.9	1.1	0.8
12/25/2019 15:00	8.4	13.2	6.4	116.5	3,334,145.6	2,069.5	1.1	0.8
12/25/2019 16:00	8.4	13.2	6.4	117.4	3,348,001.0	2,078.1	1.1	0.8
12/25/2019 17:00	8.3	13.2	6.4	114.3	3,341,232.5	2,049.5	1.1	0.8
12/25/2019 18:00	8.4	13.2	6.4	115.9	3,366,175.6	2,064.8	1.1	0.8
12/25/2019 19:00	8.5	13.2	6.5	119.6	3,336,459.2	2,095.3	1.1	0.8
12/25/2019 20:00	8.5	13.2	6.5	118.9	3,365,400.7	2,088.9	1.1	0.8
12/25/2019 21:00	8.5	13.2	6.5	117.0	3,334,467.8	2,069.7	1.1	0.8
12/25/2019 22:00	8.6	13.2	6.6	116.4	3,358,839.4	2,060.3	1.1	0.8
12/25/2019 23:00	8.5	13.2	6.5	118.4	3,331,567.9	2,067.9	1.1	0.8
Average/Sum#:	8.4	13.2	6.5	115.9	3,346,801.9	2,059.0	1.1	0.8
Minimum:	8.3	13.2	6.4	112.2	3,323,190.2	2,033.1	1.1	0.8
Maximum:	8.6	13.3	6.7	121.1	3,379,508.4	2,095.3	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/26/2019 00:00	8.5	13.2	6.5	116.5	3,367,153.7	2,065.4	1.1	0.8
12/26/2019 01:00	8.5	13.2	6.5	120.9	3,339,784.4	2,073.0	1.2	1.0
12/26/2019 02:00	8.4	13.3	6.5	129.3	3,361,610.8	2,062.0	1.2	1.0
12/26/2019 03:00	8.4	13.3	6.5	129.8	3,346,612.4	2,052.8	1.2	1.0
12/26/2019 04:00	8.4	13.3	6.5	131.2	3,335,852.6	2,046.2	1.3	1.0
12/26/2019 05:00	8.4	13.3	6.5	120.1	3,367,134.1	2,040.8	1.1	0.8
12/26/2019 06:00	8.7	13.3	6.8	115.2	3,331,450.9	2,043.5	1.1	0.8
12/26/2019 07:00	8.8	13.2	6.7	119.5	3,354,123.1	2,081.9	1.1	0.8
12/26/2019 08:00	8.9	13.1	6.7	130.1	3,332,625.0	2,165.9	1.3	1.1
12/26/2019 09:00	8.7	13.2	6.7	122.7	3,318,099.5	2,108.0	1.2	1.1
12/26/2019 10:00	8.8	13.2	6.7	123.6	3,321,405.0	2,110.1	1.2	1.1
12/26/2019 11:00	8.7	13.2	6.7	119.5	3,334,467.8	2,069.7	1.1	0.8
12/26/2019 12:00	8.6	13.2	6.6	117.7	3,302,890.5	2,050.1	1.1	0.8
12/26/2019 13:00	8.8	13.2	6.7	120.5	3,300,631.2	2,072.8	1.2	1.0
12/26/2019 14:00	8.7	13.2	6.7	118.4	3,307,562.7	2,053.0	1.1	0.8
12/26/2019 15:00	8.7	13.2	6.7	120.5	3,289,644.0	2,065.9	1.2	1.0
12/26/2019 16:00	8.7	13.1	6.6	125.5	3,327,701.3	2,114.1	1.2	1.1
12/26/2019 17:00	8.7	13.1	6.6	126.1	3,309,182.9	2,126.5	1.2	1.1
12/26/2019 18:00	8.8	13.1	6.7	130.4	3,319,084.7	2,157.1	1.3	1.1
12/26/2019 19:00	8.7	13.1	6.6	130.3	3,310,468.0	2,151.5	1.3	1.1
12/26/2019 20:00	8.8	13.1	6.7	130.3	3,315,084.1	2,154.5	1.3	1.1
12/26/2019 21:00	8.6	13.1	6.5	124.8	3,339,191.8	2,121.4	1.2	1.1
12/26/2019 22:00	8.6	13.1	6.5	123.3	3,322,506.9	2,110.8	1.2	1.1
12/26/2019 23:00	8.6	13.1	6.5	123.0	3,361,618.4	2,111.1	1.2	1.1
Average/Sum#:	8.6	13.2	6.6	123.7	3,329,828.6	2,092.0	1.2	1.0
Minimum:	8.4	13.1	6.5	115.2	3,289,644.0	2,040.8	1.1	0.8
Maximum:	8.9	13.3	6.8	131.2	3,367,153.7	2,165.9	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/27/2019 00:00	8.6	13.1	6.5	124.1	3,329,904.9	2,115.5	1.2	1.1
12/27/2019 01:00	8.5	13.2	6.5	120.6	3,336,459.2	2,095.3	1.2	1.0
12/27/2019 02:00	8.6	13.2	6.6	123.3	3,365,121.6	2,113.3	1.2	1.1
12/27/2019 03:00	8.4	13.2	6.4	118.3	3,355,250.8	2,082.6	1.1	0.8
12/27/2019 04:00	8.3	13.3	6.4	115.2	3,395,677.5	2,058.1	1.1	0.8
12/27/2019 05:00	8.3	13.3	6.4	114.8	3,408,381.8	2,065.8	1.1	0.8
12/27/2019 06:00	8.4	13.3	6.5	115.4	3,393,862.6	2,057.0	1.1	0.8
12/27/2019 07:00	8.6	13.2	6.6	115.7	3,416,961.3	2,071.0	1.1	0.8
12/27/2019 08:00	7.8	13.4	6.1	107.7	3,374,946.4	1,971.6	1.0	0.8
12/27/2019 09:00	6.9	13.8	5.7	95.1	3,172,749.9	1,691.3	0.9	0.5
12/27/2019 10:00	7.3	13.8	6.1	95.2	3,190,378.4	1,677.4	0.9	0.5
12/27/2019 11:00	7.3	13.8	6.1	94.0	3,113,918.9	1,637.2	0.9	0.5
12/27/2019 12:00	7.4	13.8	6.1	93.8	3,113,728.7	1,637.1	0.9	0.5
12/27/2019 13:00	7.5	13.8	6.2	96.8	3,207,876.6	1,686.6	0.9	0.5
12/27/2019 14:00	7.4	13.8	6.1	95.4	3,147,964.3	1,655.1	0.9	0.5
12/27/2019 15:00	7.6	13.9	6.4	83.6	2,695,103.3	1,417.0	1.0	0.6
12/27/2019 16:00	7.3	13.8	6.1	93.5	3,109,163.9	1,634.7	0.9	0.5
12/27/2019 17:00	7.5	13.8	6.2	97.8	3,255,235.9	1,711.5	0.9	0.5
12/27/2019 18:00	8.9	13.3	6.9	112.9	3,346,572.6	2,003.9	1.1	0.8
12/27/2019 19:00	9.0	13.2	6.9	122.4	3,322,765.0	2,086.7	1.2	1.0
12/27/2019 20:00	8.8	13.1	6.7	125.6	3,299,067.8	2,120.0	1.2	1.1
12/27/2019 21:00	8.7	13.2	6.7	123.6	3,316,210.7	2,106.8	1.2	1.1
12/27/2019 22:00	8.7	13.2	6.7	122.9	3,311,645.9	2,103.9	1.2	1.1
12/27/2019 23:00	8.4	13.2	6.4	117.1	3,335,756.7	2,070.5	1.1	0.8
Average/Sum#:	8.1	13.4	6.4	109.4	3,375,202.5	1,911.2	1.1	0.9
Minimum:	6.9	13.1	5.7	83.6	3,329,904.9	1,417.0	1.1	0.8
Maximum:	9.0	13.9	6.9	125.6	3,416,961.3	2,120.0	1.2	1.1
%SI	0.00	0.00	0.00	0.00	66.67	0.00	66.67	66.67

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/28/2019 00:00	8.2	13.3	6.4	110.9	3,370,287.0	2,018.1	1.0	0.8
12/28/2019 01:00	8.4	13.3	6.5	112.0	3,378,136.2	2,022.8	1.0	0.8
12/28/2019 02:00	8.5	13.3	6.6	114.7	3,370,928.9	2,043.1	1.1	0.8
12/28/2019 03:00	8.4	13.3	6.5	113.0	3,340,900.5	2,024.9	1.1	0.8
12/28/2019 04:00	8.2	13.3	6.4	110.5	3,391,663.4	2,030.9	1.0	0.8
12/28/2019 05:00	8.3	13.3	6.4	113.0	3,404,856.6	2,038.8	1.0	0.8
12/28/2019 06:00	8.5	13.3	6.6	114.3	3,397,508.5	2,034.4	1.1	0.8
12/28/2019 07:00	8.7	13.2	6.7	118.4	3,379,380.7	2,072.9	1.1	0.8
12/28/2019 08:00	8.4	13.4	6.6	110.6	3,363,881.1	1,989.7	1.0	0.8
12/28/2019 09:00	6.9	13.8	5.7	95.1	3,142,735.2	1,675.3	1.0	0.7
12/28/2019 10:00	7.0	13.8	5.8	92.1	3,040,872.5	1,621.0	0.9	0.5
12/28/2019 11:00	7.2	13.8	6.0	94.1	3,114,596.3	1,660.3	0.9	0.5
12/28/2019 12:00	7.4	13.8	6.1	97.4	3,180,066.0	1,695.2	1.0	0.7
12/28/2019 13:00	7.4	13.8	6.1	95.1	3,098,275.8	1,651.6	1.0	0.7
12/28/2019 14:00	7.5	13.8	6.2	96.7	3,148,175.3	1,678.2	1.0	0.7
12/28/2019 15:00	7.4	13.8	6.1	92.2	3,061,804.7	1,609.8	0.9	0.5
12/28/2019 16:00	8.9	13.3	6.9	115.2	3,341,065.5	2,025.0	1.1	0.8
12/28/2019 17:00	8.7	13.2	6.7	120.7	3,321,968.8	2,086.2	1.2	1.0
12/28/2019 18:00	8.7	13.2	6.7	122.7	3,310,386.7	2,103.1	1.2	1.1
12/28/2019 19:00	8.6	13.2	6.6	122.4	3,309,127.5	2,102.3	1.2	1.1
12/28/2019 20:00	8.5	13.2	6.5	121.1	3,346,331.8	2,101.5	1.2	1.1
12/28/2019 21:00	8.5	13.2	6.5	118.7	3,356,056.4	2,083.1	1.1	0.8
12/28/2019 22:00	8.5	13.2	6.5	120.1	3,326,268.1	2,088.9	1.2	1.0
12/28/2019 23:00	8.6	13.2	6.6	120.8	3,335,822.3	2,094.9	1.2	1.0
Average/Sum#:	8.1	13.4	6.4	110.1	0.0	1,939.7	0.0	0.0
Minimum:	6.9	13.2	5.7	92.1	0.0	1,609.8	0.0	0.0
Maximum:	8.9	13.8	6.9	122.7	0.0	2,103.1	0.0	0.0
%SI	0.00	0.00	0.00	0.00	100.00	0.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/29/2019 00:00	8.5	13.2	6.5	118.7	3,357,828.6	2,084.2	1.1	0.8
12/29/2019 01:00	8.6	13.2	6.6	121.3	3,356,522.9	2,107.9	1.2	1.1
12/29/2019 02:00	8.5	13.2	6.5	117.9	3,347,678.7	2,077.9	1.1	0.8
12/29/2019 03:00	8.5	13.2	6.5	119.7	3,376,517.2	2,095.8	1.1	0.8
12/29/2019 04:00	8.5	13.2	6.5	118.3	3,357,345.3	2,083.9	1.1	0.8
12/29/2019 05:00	8.5	13.2	6.5	118.4	3,364,272.9	2,088.2	1.1	0.8
12/29/2019 06:00	8.6	13.2	6.6	119.7	3,352,512.0	2,080.9	1.1	0.8
12/29/2019 07:00	8.4	13.3	6.5	118.7	3,327,371.3	2,016.7	1.1	0.8
12/29/2019 08:00	7.0	13.8	5.8	95.2	3,148,175.3	1,678.2	0.9	0.5
12/29/2019 09:00	7.3	13.8	6.1	90.2	3,020,987.7	1,610.4	0.9	0.5
12/29/2019 10:00	7.3	13.8	6.1	94.6	3,159,430.9	1,684.2	0.9	0.5
12/29/2019 11:00	7.3	13.8	6.1	93.5	3,114,408.7	1,660.2	0.9	0.5
12/29/2019 12:00	7.4	13.8	6.1	95.4	3,179,878.5	1,695.1	0.9	0.5
12/29/2019 13:00	7.4	13.8	6.1	91.9	3,048,188.6	1,624.9	0.9	0.5
12/29/2019 14:00	7.4	13.8	6.1	94.5	3,148,362.9	1,678.3	0.9	0.5
12/29/2019 15:00	8.4	13.5	6.7	106.2	3,290,305.4	1,874.1	1.0	0.7
12/29/2019 16:00	8.7	13.3	6.8	114.0	3,350,035.9	2,054.9	1.1	0.8
12/29/2019 17:00	8.6	13.2	6.6	115.7	3,343,006.6	2,075.0	1.1	0.8
12/29/2019 18:00	8.6	13.1	6.5	119.6	3,362,414.6	2,111.6	1.1	0.8
12/29/2019 19:00	8.5	13.1	6.4	119.7	3,363,051.5	2,112.0	1.1	0.8
12/29/2019 20:00	8.4	13.1	6.4	119.3	3,360,026.0	2,110.1	1.1	0.8
12/29/2019 21:00	8.4	13.2	6.4	119.5	3,360,822.2	2,110.6	1.1	0.8
12/29/2019 22:00	8.5	13.2	6.5	119.1	3,351,108.9	2,104.5	1.1	0.8
12/29/2019 23:00	8.4	13.2	6.4	116.5	3,350,578.7	2,079.7	1.1	0.8
Average/Sum#:	8.2	13.4	6.4	110.7	3,257,259.2	1,954.1	1.0	0.7
Minimum:	7.0	13.1	5.8	90.2	3,020,987.7	1,610.4	0.9	0.5
Maximum:	8.7	13.8	6.8	121.3	3,363,051.5	2,112.0	1.1	0.8
%SI	0.00	0.00	0.00	0.00	25.00	0.00	25.00	25.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/30/2019 00:00	8.4	13.3	6.5	114.2	3,359,165.4	2,060.5	1.1	0.8
12/30/2019 01:00	8.4	13.3	6.5	113.4	3,346,449.3	2,052.7	1.1	0.8
12/30/2019 02:00	8.4	13.3	6.5	111.6	3,355,749.7	2,033.9	1.1	0.8
12/30/2019 03:00	8.4	13.3	6.5	112.0	3,362,679.3	2,038.1	1.1	0.8
12/30/2019 04:00	8.3	13.3	6.4	110.6	3,394,001.4	2,032.3	1.0	0.8
12/30/2019 05:00	8.4	13.3	6.5	112.2	3,368,454.0	2,041.6	1.1	0.8
12/30/2019 06:00	8.6	13.3	6.7	114.9	3,349,546.8	2,054.6	1.1	0.8
12/30/2019 07:00	8.8	13.2	6.7	120.9	3,356,522.9	2,107.9	1.1	0.8
12/30/2019 08:00	8.5	13.2	6.5	117.4	3,361,695.2	2,086.6	1.1	0.8
12/30/2019 09:00	8.5	13.3	6.6	115.6	3,312,879.2	2,056.3	1.1	0.8
12/30/2019 10:00	8.6	13.3	6.7	114.1	3,319,060.8	2,035.9	1.1	0.8
12/30/2019 11:00	8.6	13.2	6.6	116.1	3,295,318.4	2,045.4	1.1	0.8
12/30/2019 12:00	8.7	13.2	6.7	116.7	3,296,285.0	2,046.0	1.1	0.8
12/30/2019 13:00	8.7	13.2	6.7	118.9	3,283,433.8	2,062.0	1.2	1.0
12/30/2019 14:00	8.7	13.2	6.7	117.1	3,273,083.5	2,055.5	1.1	0.8
12/30/2019 15:00	8.7	13.2	6.7	118.0	3,284,866.9	2,062.9	1.1	0.8
12/30/2019 16:00	8.7	13.2	6.7	119.4	3,299,675.8	2,072.2	1.2	1.0
12/30/2019 17:00	8.6	13.2	6.6	120.4	3,285,359.3	2,087.2	1.2	1.0
12/30/2019 18:00	8.5	13.1	6.4	121.2	3,328,960.5	2,114.9	1.2	1.1
12/30/2019 19:00	8.5	13.1	6.4	120.4	3,321,562.5	2,110.2	1.2	1.1
12/30/2019 20:00	8.4	13.1	6.4	118.2	3,334,866.8	2,094.3	1.1	0.8
12/30/2019 21:00	8.4	13.2	6.4	114.9	3,326,734.6	2,064.9	1.1	0.8
12/30/2019 22:00	8.7	13.2	6.7	117.3	3,329,956.8	2,066.9	1.1	0.8
12/30/2019 23:00	8.6	13.2	6.6	116.9	3,325,606.8	2,064.2	1.1	0.8
Average/Sum#:	8.5	13.2	6.6	116.4	3,327,996.4	2,064.5	1.1	0.9
Minimum:	8.3	13.1	6.4	110.6	3,273,083.5	2,032.3	1.0	0.8
Maximum:	8.8	13.3	6.7	121.2	3,394,001.4	2,114.9	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/31/2019 00:00	8.6	13.3	6.7	114.7	3,336,667.7	2,046.7	1.1	0.8
12/31/2019 01:00	8.3	13.4	6.5	104.3	3,329,241.9	1,944.9	1.0	0.8
12/31/2019 02:00	8.4	13.4	6.6	104.4	3,314,691.7	1,936.4	1.0	0.8
12/31/2019 03:00	8.3	13.4	6.5	104.8	3,338,143.1	1,950.1	1.0	0.8
12/31/2019 04:00	8.6	13.3	6.7	114.2	3,332,429.0	2,044.1	1.1	0.8
12/31/2019 05:00	8.5	13.3	6.6	113.6	3,325,581.9	2,039.9	1.1	0.8
12/31/2019 06:00	8.8	13.3	6.8	114.0	3,315,148.2	2,033.5	1.1	0.8
12/31/2019 07:00	8.8	13.3	6.8	114.1	3,314,822.1	2,033.3	1.1	0.8
12/31/2019 08:00	8.3	13.5	6.6	103.7	3,295,979.1	1,901.4	1.0	0.8
12/31/2019 09:00	7.1	13.9	6.0	85.4	2,905,652.3	1,527.7	0.9	0.5
12/31/2019 10:00	7.3	13.9	6.2	91.2	3,094,328.5	1,626.9	0.9	0.5
12/31/2019 11:00	7.3	13.9	6.2	89.7	3,022,433.7	1,589.1	0.9	0.5
12/31/2019 12:00	7.4	13.9	6.2	89.0	2,986,676.5	1,570.3	0.9	0.5
12/31/2019 13:00	7.6	13.9	6.4	94.3	3,174,211.6	1,668.9	0.9	0.5
12/31/2019 14:00	7.4	13.9	6.2	89.4	2,992,762.9	1,573.5	0.9	0.5
12/31/2019 15:00	7.8	13.8	6.5	90.3	2,979,154.6	1,588.1	0.9	0.5
12/31/2019 16:00	9.0	13.3	7.0	110.4	3,286,618.5	1,992.0	1.1	0.8
12/31/2019 17:00	8.6	13.3	6.7	112.1	3,300,312.8	2,024.4	1.1	0.8
12/31/2019 18:00	8.5	13.3	6.6	111.1	3,334,135.9	2,020.8	1.1	0.8
12/31/2019 19:00	8.5	13.3	6.6	111.7	3,342,055.5	2,025.6	1.1	0.8
12/31/2019 20:00	8.5	13.3	6.6	111.8	3,348,655.1	2,029.6	1.1	0.8
12/31/2019 21:00	8.4	13.3	6.5	113.0	3,327,701.3	2,041.2	1.1	0.8
12/31/2019 22:00	8.4	13.3	6.5	112.5	3,321,995.3	2,037.7	1.1	0.8
12/31/2019 23:00	8.4	13.3	6.5	111.6	3,349,315.1	2,030.0	1.1	0.8
Average/Sum#:	8.2	13.5	6.5	104.6	3,236,196.4	1,886.5	1.0	0.7
Minimum:	7.1	13.3	6.0	85.4	2,905,652.3	1,527.7	0.9	0.5
Maximum:	9.0	13.9	7.0	114.7	3,349,315.1	2,046.7	1.1	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Excess Emission Report

CT1 - NH3 LbPerHr 1-Hour Block Average

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 12:28 **Location:** Maxwell, CA

Tag Name: CT1_NH3slip_LbPerHr_1H
Total Operating Time: 2,059.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 149.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,059.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NOx Ppmvdc 1-Hour Block Average

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 12:29 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Ppmvdc_1H
Total Operating Time: 2,059.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 149.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,059.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NH3 LbPerHr 1-Hour Block Average

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 12:30 **Location:** Maxwell, CA

Tag Name: CT1_NH3slip_LbPerHr_1H
Total Operating Time: 2,059.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 149.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,059.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NH3 Ppmvdc 1-Hour Block Average

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 12:31 **Location:** Maxwell, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H
Total Operating Time: 2,145.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 63.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,145.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 9

Quarterly/Annual Emissions
(Fuel Use, Hours of Operation, and NH_3 Injection)

FCD: AQ-23, 26
Title V: #6, 14

Emissions Limits per AQ-26

Quarterly and Annual Combustion Emissions from CGS Facility					
Pollutant	1st Quarter Emissions (tons)	2nd Quarter Emissions (tons)	3rd Quarter Emissions (tons)	4th Quarter Emissions (tons)	Annual Emissions (tons)
NO_x	45.56	43.58	51.30	44.27	184.7
CO	54.29	52.49	107.15	53.95	267.9
VOC's	12.30	11.63	11.84	11.76	47.5
PM10	25.54	25.78	26.02	26.02	103.4
SO_2	4.07	3.85	3.89	3.89	15.7

Notes

1. Emissions based on CT1 and CT2.
2. VOC Mass Emissions based on Average Source Test Results (lb/MMBtu). CT1 EF = 0.0009 prior to 10/30/2013 and 0.0007 after 10/30/2013. CT2 EF = 0.0007 prior to 11/01/2014 and 0.0003 after 11/01/2014.
3. PM10 based on 2010 lb/MMBtu Source Test Results. CT1 EF = 0.0025; CT2 EF = 0.003

Quarterly Emissions

Cumulative Emissions Report

From: 01/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/29/2020 12:46 **Location:** Maxwell, CA

Month	PlantWide NOx, Tons 1 Day(s)	PlantWide CO, Tons 1 Day(s)	PlantWide VOC, Tons 1 Day(s)	PlantWide PM10, Tons 1 Day(s)	PlantWide SO2, Tons 1 Day(s)
January	4.6	0.5	0.6	3.7	0.8
February	4.3	0.6	0.6	3.2	0.7
March	3.3	0.9	0.4	2.2	0.5
April	2.8	1.6	0.2	1.0	0.2
May	0.0	0.0	0.0	0.0	0.0
June	1.6	1.0	0.1	0.6	0.0
July	4.0	2.0	0.4	2.5	0.0
August	4.4	1.8	0.5	3.0	0.0
September	3.4	1.0	0.4	2.1	0.0
October	4.5	0.9	0.6	3.2	0.0
November	4.7	0.6	0.7	3.9	0.0
December	4.3	0.2	0.8	4.2	0.1
Quarter 1	12.2	2.0	1.6	9.1	2.0
Quarter 2	4.4	2.6	0.3	1.6	0.2
Quarter 3	11.8	4.8	1.3	7.6	0.0
Quarter 4	13.5	1.7	2.1	11.3	0.1
YTD	41.9	11.1	5.3	29.6	2.3

Cumulative Emissions Report

CT1

From: 01/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/29/2020 12:47 **Location:** Maxwell, CA

Month	Unit CT1 GasFlowCT, 100scf 1 Day(s)	Unit CT1 GasFlowDB, 100scf 1 Day(s)	Unit CT1 GasFlow, Total, 100scf 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)
January	10,611,447	1,117,094	11,728,540.8	635	148.1
February	10,208,376	1,072,163	11,280,535.0	617	144.0
March	6,461,790	551,583	7,013,371.4	412	135.1
April	2,565,342	109,206	2,674,549.1	188	124.9
May	0	0	0.0	0	0.0
June	1,652,869	151,803	1,804,671.0	122	154.5
July	7,281,659	1,098,330	8,379,983.3	460	171.7
August	8,940,869	1,427,462	10,368,330.7	563	168.6
September	6,233,665	1,016,292	7,249,955.8	390	159.3
October	9,695,626	1,149,258	10,844,881.3	602	147.5
November	12,257,241	1,728,824	13,986,062.1	716	150.8
December	12,951,645	1,990,861	14,942,504.5	741	140.2
Quarter 1	27,281,613	2,740,840	30,022,447.2	1,664	142.4
Quarter 2	4,218,211	261,009	4,479,220.1	310	139.7
Quarter 3	22,456,193	3,542,084	25,998,269.8	1,413	166.5
Quarter 4	34,904,512	4,868,943	39,773,447.9	2,059	146.2
YTD	88,860,529	11,412,876	100,273,385.0	5,446	149.5

Cumulative Emissions Report

CT2

From: 01/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/29/2020 12:49 **Location:** Maxwell, CA

Month	Unit CT2 GasFlowCT, 100scf 1 Day(s)	Unit CT2 GasFlowDB, 100scf 1 Day(s)	Unit CT2 GasFlow, Total, 100scf 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)
January	12,425,212	1,281,398	13,706,609.0	739	89,239.8
February	10,511,348	1,164,287	11,675,633.6	637	75,257.5
March	7,797,197	693,437	8,490,630.9	503	58,008.5
April	4,365,705	189,285	4,554,986.4	330	35,790.5
May	0	0	0.0	0	0.0
June	2,513,194	193,307	2,706,500.4	188	22,417.7
July	7,940,625	1,109,518	9,050,142.8	512	62,929.2
August	9,831,411	1,408,559	11,239,969.8	620	77,437.6
September	6,679,445	999,724	7,679,166.9	426	52,809.0
October	11,030,214	1,288,645	12,318,858.1	681	81,725.0
November	12,357,938	1,652,341	14,010,278.7	720	86,823.7
December	13,013,227	1,596,141	14,609,363.6	744	86,652.7
Quarter 1	30,733,757	3,139,122	33,872,873.5	1,879	222,505.8
Quarter 2	6,878,899	382,592	7,261,486.8	518	58,208.2
Quarter 3	24,451,481	3,517,801	27,969,279.5	1,558	193,175.8
Quarter 4	36,401,379	4,537,127	40,938,500.4	2,145	255,201.4
YTD	98,465,516	11,576,642	110,042,140.2	6,100	729,091.2

Monthly Summary By Day Report

VOC PM10

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:36 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
10/01/2019	23.2	83.8	12.4	123.1
10/02/2019	30.5	109.6	13.2	131.9
10/03/2019	24.4	87.9	10.8	106.3
10/04/2019	12.7	45.4	10.3	104.9
10/05/2019	29.9	106.5	12.9	129.2
10/06/2019	30.1	107.9	12.9	129.8
10/07/2019	33.8	120.9	14.4	145.3
10/08/2019	33.2	118.6	14.4	142.9
10/09/2019	31.6	113.2	13.7	135.6
10/10/2019	30.7	109.8	13.4	132.6
10/11/2019	28.7	102.5	12.6	123.4
10/12/2019	21.8	78.9	10.9	110.2
10/13/2019	29.5	106.3	12.7	127.4
10/14/2019	21.0	74.8	11.2	113.7
10/15/2019	15.9	57.5	12.9	133.0
10/16/2019	2.8	9.8	14.0	146.8
10/17/2019	30.0	107.2	12.9	128.8
10/18/2019	30.3	108.5	13.2	130.7
10/19/2019	10.2	36.5	9.0	89.2
10/20/2019	11.5	40.8	7.4	74.3
10/21/2019	29.9	106.5	12.8	128.6
10/22/2019	34.7	122.5	14.4	144.8
10/23/2019	29.9	106.2	12.7	127.9
10/24/2019	34.9	123.9	14.4	149.9
10/25/2019	33.5	119.7	14.4	142.9
10/26/2019	27.7	99.4	11.9	119.7
10/27/2019	0.0	0.0	2.1	21.4
10/28/2019	29.5	105.1	13.3	133.0
10/29/2019	0.0	0.0	0.0	0.0
10/30/2019	24.2	86.3	12.6	129.2
10/31/2019	32.6	116.9	14.4	142.7
Monthly Avg/Sum*:	758.7 *	2,712.9 *	368.2 *	3,699.2 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	34.9	123.9	14.4	149.9
Oct 2019 - Oct 2019	758.7	2,712.9	368.2	3,699.2
QTD:	758.7 *	2,712.9 *	368.2 *	3,699.2 *
YTD 2019:	5,083.1 *	18,151.3 *	2,461.7 *	24,863.9 *

Monthly Summary By Day Report

VOC PM10

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:36 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
11/01/2019	32.5	116.2	13.7	139.3
11/02/2019	28.0	100.9	12.7	127.2
11/03/2019	31.8	114.2	13.4	136.5
11/04/2019	34.6	124.4	14.4	147.8
11/05/2019	35.1	123.8	14.4	147.5
11/06/2019	35.6	126.4	14.4	146.2
11/07/2019	36.3	128.9	14.4	146.8
11/08/2019	33.5	119.4	13.4	136.3
11/09/2019	32.0	114.6	13.0	131.0
11/10/2019	32.4	116.2	13.4	132.9
11/11/2019	34.0	120.5	13.5	137.1
11/12/2019	36.0	128.3	14.4	145.6
11/13/2019	36.1	127.6	14.4	145.1
11/14/2019	36.0	129.8	14.4	147.8
11/15/2019	35.9	126.7	14.4	144.5
11/16/2019	33.0	116.7	13.5	132.8
11/17/2019	31.8	112.6	13.0	128.6
11/18/2019	36.0	128.5	14.4	145.9
11/19/2019	36.2	128.3	14.4	145.5
11/20/2019	36.5	130.5	14.4	146.4
11/21/2019	37.1	131.7	14.4	148.8
11/22/2019	36.8	129.8	14.4	147.5
11/23/2019	34.1	121.5	13.7	138.7
11/24/2019	33.0	117.3	13.5	134.0
11/25/2019	25.4	89.9	12.2	122.1
11/26/2019	33.4	118.7	13.6	134.1
11/27/2019	35.5	127.0	14.4	144.8
11/28/2019	36.4	130.5	14.4	145.7
11/29/2019	33.0	119.2	13.4	134.6
11/30/2019	36.0	129.0	14.4	146.2
Monthly Avg/Sum*:	1,024.0 *	3,649.1 *	416.4 *	4,207.3 *
Daily Min:	25.4	89.9	12.2	122.1
Daily Max:	37.1	131.7	14.4	148.8
Oct 2019 - Nov 2019	1,782.7	6,362.0	784.6	7,906.5
QTD:	1,782.7 *	6,362.0 *	784.6 *	7,906.5 *
YTD 2019:	6,107.1 *	21,800.4 *	2,878.1 *	29,071.2 *

Monthly Summary By Day Report

VOC PM10

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:36 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
12/01/2019	36.2	127.7	14.4	144.4
12/02/2019	36.5	129.3	14.4	146.2
12/03/2019	36.6	130.2	14.4	147.1
12/04/2019	36.6	131.3	14.4	148.2
12/05/2019	35.3	127.5	14.4	145.9
12/06/2019	34.8	126.4	14.4	143.5
12/07/2019	34.4	124.1	14.4	148.2
12/08/2019	30.5	108.2	13.0	130.1
12/09/2019	34.8	124.8	14.4	148.9
12/10/2019	35.4	126.7	14.4	150.8
12/11/2019	34.7	124.3	14.4	148.4
12/12/2019	34.0	122.6	14.3	146.7
12/13/2019	25.4	89.5	12.3	126.1
12/14/2019	29.7	106.3	12.7	127.8
12/15/2019	32.4	115.5	13.7	137.9
12/16/2019	35.7	127.5	14.7	151.0
12/17/2019	35.8	127.8	14.5	151.6
12/18/2019	36.1	128.8	14.8	152.8
12/19/2019	35.3	126.6	14.5	150.5
12/20/2019	33.9	120.7	14.0	144.0
12/21/2019	35.1	125.2	14.4	149.1
12/22/2019	34.8	124.5	14.4	149.0
12/23/2019	34.6	124.7	14.4	149.3
12/24/2019	33.9	122.7	14.4	147.3
12/25/2019	34.4	124.0	14.4	148.1
12/26/2019	41.6	148.8	14.4	150.6
12/27/2019	40.2	143.6	13.4	137.6
12/28/2019	39.2	139.5	13.7	139.8
12/29/2019	33.3	117.3	13.7	140.6
12/30/2019	34.7	124.5	14.4	148.7
12/31/2019	31.4	113.1	13.7	135.9
Monthly Avg/Sum*:	1,077.3 *	3,853.7 *	437.8 *	4,486.1 *
Daily Min:	25.4	89.5	12.3	126.1
Daily Max:	41.6	148.8	14.8	152.8
Oct 2019 - Dec 2019	2,860.0	10,215.7	1,222.4	12,392.6
QTD:	2,860.0 *	10,215.7 *	1,222.4 *	12,392.6 *
YTD 2019:	7,184.4 *	25,654.1 *	3,315.9 *	33,557.3 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:37 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
10/01/2019	57.9	116.28	20.2	3.6	123.00	24.5
10/02/2019	16.9	116.10	26.2	3.6	156.50	26.2
10/03/2019	11.4	96.03	21.2	6.6	111.30	21.7
10/04/2019	59.5	153.68	10.8	51.6	168.10	20.9
10/05/2019	20.6	114.50	25.3	7.9	150.30	25.9
10/06/2019	25.4	117.40	25.8	6.3	152.60	25.8
10/07/2019	32.6	144.90	29.0	7.5	193.90	28.8
10/08/2019	28.8	144.40	28.5	6.6	188.40	28.5
10/09/2019	14.0	128.10	27.3	0.6	165.30	27.2
10/10/2019	16.3	121.30	26.5	1.5	155.40	26.7
10/11/2019	15.0	97.00	24.4	1.8	137.10	24.4
10/12/2019	54.6	172.77	18.7	31.8	178.88	21.7
10/13/2019	20.6	119.15	25.5	6.3	152.17	25.5
10/14/2019	66.4	115.21	18.1	28.0	153.80	23.0
10/15/2019	53.4	90.77	13.8	6.6	157.00	26.7
10/16/2019	65.8	116.45	2.4	10.5	188.20	30.0
10/17/2019	15.0	127.50	25.8	2.7	142.60	25.8
10/18/2019	19.8	128.70	25.9	3.3	154.60	25.9
10/19/2019	14.9	46.65	8.8	51.2	168.05	17.9
10/20/2019	82.1	171.54	9.8	48.2	175.60	15.0
10/21/2019	11.8	122.80	25.6	2.7	156.50	25.8
10/22/2019	31.1	147.00	29.8	3.6	190.70	28.9
10/23/2019	20.5	121.10	25.4	4.8	153.40	25.3
10/24/2019	37.7	148.50	29.7	7.5	201.80	30.3
10/25/2019	45.2	143.70	28.5	10.5	190.70	28.5
10/26/2019	27.0	119.87	23.8	12.1	138.32	24.1
10/27/2019	0.0	0.00	0.0	124.1	208.80	4.3
10/28/2019	118.0	256.70	25.3	11.7	166.99	26.7
10/29/2019	0.0	0.00	0.0	0.0	0.00	0.0
10/30/2019	157.1	260.47	20.6	162.8	358.27	25.9
10/31/2019	30.9	144.10	27.7	11.5	190.50	28.8
Monthly Avg/Sum*:	1,170.3 *	3,902.67 *	650.4 *	637.5 *	5,128.78 *	740.7 *
Daily Min:	11.4	46.65	2.4	0.6	111.30	4.3
Daily Max:	157.1	260.47	29.8	162.8	358.27	30.3
Oct 2019 - Oct 2019	1,170.3	3,902.67	650.4	637.5	5,128.78	740.7
QTD:	1,170.3 *	3,902.67 *	650.4 *	637.5 *	5,128.78 *	740.7 *
YTD 2019:	10,446.3 *	27,861.72 *	4,351.1 *	10,298.3 *	38,015.93 *	4,967.0 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:37 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
11/01/2019	22.4	133.30	27.9	7.2	168.70	27.9
11/02/2019	47.3	181.77	23.8	35.1	184.50	24.9
11/03/2019	22.1	159.10	27.7	8.1	161.60	27.6
11/04/2019	25.5	153.60	29.7	8.1	196.70	29.6
11/05/2019	34.1	151.10	30.2	16.8	196.80	29.2
11/06/2019	34.1	151.90	30.2	18.3	192.90	29.3
11/07/2019	33.5	156.60	31.0	15.6	195.80	29.1
11/08/2019	26.7	144.20	28.7	11.9	165.40	27.0
11/09/2019	26.4	131.00	27.7	12.0	155.90	26.2
11/10/2019	26.7	139.40	27.8	12.2	155.90	26.6
11/11/2019	34.9	145.30	29.2	13.6	171.10	27.3
11/12/2019	39.5	153.70	31.2	16.3	194.20	28.8
11/13/2019	39.0	153.40	31.2	15.3	193.70	28.9
11/14/2019	41.3	157.60	31.2	14.7	196.80	28.8
11/15/2019	31.3	152.30	30.8	18.0	190.40	28.7
11/16/2019	26.2	139.90	27.9	12.3	155.60	26.7
11/17/2019	22.7	134.80	27.2	10.8	136.70	25.8
11/18/2019	39.3	154.20	31.1	15.9	194.30	28.9
11/19/2019	32.9	149.40	31.3	15.3	177.60	28.9
11/20/2019	29.8	156.40	31.4	7.1	148.50	29.0
11/21/2019	26.1	158.30	31.9	0.0	182.10	29.7
11/22/2019	17.2	155.60	31.1	0.0	176.70	29.6
11/23/2019	8.6	121.60	29.0	0.0	135.80	27.6
11/24/2019	9.3	114.90	27.7	0.0	123.60	27.2
11/25/2019	71.1	102.50	21.5	0.0	86.10	24.5
11/26/2019	17.8	127.10	28.8	0.0	121.60	26.7
11/27/2019	27.0	156.60	30.4	0.0	165.10	28.8
11/28/2019	24.9	158.90	31.1	0.0	157.70	28.8
11/29/2019	12.2	117.90	28.9	0.0	135.10	26.7
11/30/2019	16.8	155.00	31.2	0.0	162.80	28.8
Monthly Avg/Sum*:	866.7 *	4,367.37 *	878.8 *	284.6 *	4,979.70 *	837.6 *
Daily Min:	8.6	102.50	21.5	0.0	86.10	24.5
Daily Max:	71.1	181.77	31.9	35.1	196.80	29.7
Oct 2019 - Nov 2019	2,037.0	8,270.04	1,529.2	922.1	10,108.48	1,578.3
QTD:	2,037.0 *	8,270.04 *	1,529.2 *	922.1 *	10,108.48 *	1,578.3 *
YTD 2019:	11,313.0 *	32,229.09 *	5,229.9 *	10,582.9 *	42,995.63 *	5,804.6 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:37 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
12/01/2019	15.6	155.50	31.2	0.0	144.40	29.0
12/02/2019	9.6	155.00	31.0	0.0	148.20	29.4
12/03/2019	4.8	156.50	31.2	0.0	163.70	29.2
12/04/2019	7.4	157.40	31.2	0.0	150.20	29.4
12/05/2019	5.8	153.00	30.5	0.0	131.80	28.8
12/06/2019	8.1	151.10	30.0	7.6	118.40	28.6
12/07/2019	8.7	151.10	29.4	5.0	152.80	29.1
12/08/2019	5.9	107.70	26.1	0.0	103.00	26.1
12/09/2019	9.5	149.50	29.8	0.0	196.30	29.6
12/10/2019	14.4	154.20	30.4	0.0	180.10	30.2
12/11/2019	14.1	149.00	29.6	0.0	152.60	29.4
12/12/2019	12.1	147.00	29.2	0.0	150.80	29.0
12/13/2019	55.8	105.43	21.5	0.0	89.30	24.9
12/14/2019	10.5	95.20	25.7	0.0	93.90	25.6
12/15/2019	17.8	114.80	27.5	0.0	135.90	27.4
12/16/2019	22.8	152.80	30.4	0.0	197.00	30.4
12/17/2019	24.3	155.60	30.9	0.0	191.40	30.7
12/18/2019	24.9	154.40	31.1	0.0	184.90	31.1
12/19/2019	24.3	155.70	30.4	0.0	167.30	30.4
12/20/2019	23.9	141.30	29.3	0.0	131.10	29.1
12/21/2019	30.0	170.80	30.0	0.0	155.40	29.7
12/22/2019	23.4	166.30	29.8	0.0	159.40	29.7
12/23/2019	10.8	151.80	29.8	0.0	182.70	29.8
12/24/2019	17.1	147.40	28.9	0.0	151.50	28.9
12/25/2019	17.1	161.00	29.2	0.0	150.20	29.0
12/26/2019	10.4	144.30	35.7	0.0	154.90	29.9
12/27/2019	3.7	40.20	34.3	0.0	41.60	27.6
12/28/2019	0.0	0.00	33.5	0.0	0.00	28.0
12/29/2019	8.2	78.50	28.6	0.0	92.50	28.3
12/30/2019	10.2	159.60	29.5	0.0	191.80	29.4
12/31/2019	11.6	111.50	26.8	0.0	141.70	27.0
Monthly Avg/Sum*:	462.8 *	4,193.63 *	922.5 *	12.6 *	4,404.80 *	894.7 *
Daily Min:	0.0	0.00	21.5	0.0	0.00	24.9
Daily Max:	55.8	170.80	35.7	7.6	197.00	31.1
Oct 2019 - Dec 2019	2,499.8	12,463.67	2,451.7	934.7	14,513.28	2,473.0
QTD:	2,499.8 *	12,463.67 *	2,451.7 *	934.7 *	14,513.28 *	2,473.0 *
YTD 2019:	11,775.8 *	36,422.72 *	6,152.4 *	10,595.5 *	47,400.43 *	6,699.3 *

Monthly Summary By Day Report

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 12:38 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2019	19.58	310,409.7	8.07	24,257.6	334,667.3	2,953.8	33,500.084
10/02/2019	24.00	387,906.4	17.05	50,065.4	437,971.8	3,419.7	43,840.900
10/03/2019	21.72	331,737.2	7.92	19,780.1	351,517.3	2,580.9	35,186.928
10/04/2019	10.42	159,727.4	7.10	21,986.3	181,713.7	1,662.2	18,189.618
10/05/2019	24.00	382,097.2	16.07	44,013.7	426,110.9	3,349.9	42,653.800
10/06/2019	24.00	383,109.5	16.02	48,263.1	431,372.6	3,431.7	43,180.400
10/07/2019	24.00	409,996.9	24.00	72,929.2	482,926.1	4,009.4	48,341.000
10/08/2019	24.00	406,782.7	24.00	67,819.5	474,602.2	3,866.6	47,507.600
10/09/2019	24.00	400,684.7	18.77	51,837.9	452,522.6	3,651.7	45,297.700
10/10/2019	24.00	399,940.4	15.96	40,397.3	440,337.7	3,404.1	44,077.900
10/11/2019	24.00	375,110.5	13.21	34,013.6	409,124.1	3,105.5	40,953.100
10/12/2019	16.95	273,216.5	13.75	41,331.1	314,547.6	2,841.6	31,486.245
10/13/2019	23.42	382,786.7	13.80	41,629.8	424,416.5	3,381.0	42,484.070
10/14/2019	17.27	265,644.6	10.17	33,262.5	298,907.1	2,693.8	29,920.762
10/15/2019	14.17	213,781.4	6.10	15,412.4	229,193.8	2,048.2	22,942.126
10/16/2019	3.32	39,220.1	0.00	0.0	39,220.1	353.5	3,926.020
10/17/2019	24.00	391,794.0	14.29	37,353.8	429,147.8	3,294.0	42,957.400
10/18/2019	24.00	396,811.4	15.99	37,250.5	434,061.9	3,301.2	43,449.400
10/19/2019	7.50	127,258.9	7.18	17,904.3	145,163.2	1,244.3	14,530.950
10/20/2019	9.92	150,496.8	5.55	12,474.0	162,970.8	1,442.6	16,313.356
10/21/2019	24.00	398,102.3	11.92	28,784.5	426,886.8	3,350.6	42,731.300
10/22/2019	24.00	414,771.3	24.00	74,941.9	489,713.2	4,133.7	49,020.200
10/23/2019	24.00	393,465.5	11.75	31,977.8	425,443.3	3,359.8	42,586.900
10/24/2019	24.00	417,145.1	24.00	77,869.8	495,014.9	4,224.5	49,551.000
10/25/2019	24.00	415,394.2	24.00	63,068.6	478,462.8	3,891.3	47,894.000
10/26/2019	22.48	363,238.2	13.24	33,684.9	396,923.1	3,118.5	39,731.752
10/27/2019	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/28/2019	22.48	369,806.4	19.10	50,574.2	420,380.6	3,663.5	42,080.270
10/29/2019	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/30/2019	19.10	311,522.3	15.10	32,722.5	344,244.8	2,970.0	34,458.970
10/31/2019	24.00	423,668.0	24.00	43,648.7	467,316.7	3,601.4	46,778.300
Monthly Avg/Sum*:	592.33 *	9,695,626.3 *	422.11 *	1,149,255.0 *	10,844,881.3 *	88,349.0 *	1,085,572.051 *
Daily Min:	3.32	39,220.1	0.00	0.0	39,220.1	353.5	3,926.020
Daily Max:	24.00	423,668.0	24.00	77,869.8	495,014.9	4,224.5	49,551.000
Oct 2019 - Oct 2019	592.33	9,695,626.3	422.11	1,149,255.0	10,844,881.3	88,349.0	1,085,572.051
QTD:	592.33 *	9,695,626.3 *	422.11 *	1,149,255.0 *	10,844,881.3 *	88,349.0 *	1,085,572.051 *
YTD 2019:	3,918.71 *	63,651,635.9 *	2,654.45 *	7,693,182.5 *	71,344,818.4 *	601,159.4 *	7,259,746.552 *

Monthly Summary By Day Report

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 12:38 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2019	24.00	410,348.7	18.50	54,068.1	464,416.8	3,687.9	46,488.000
11/02/2019	21.69	356,599.9	15.25	46,021.1	402,621.0	3,421.5	40,302.399
11/03/2019	24.00	404,941.1	16.46	51,322.0	456,263.1	3,451.1	45,671.900
11/04/2019	24.00	413,724.8	24.00	83,334.8	497,059.6	4,304.3	49,755.600
11/05/2019	24.00	421,175.6	24.00	73,867.9	495,043.5	4,147.1	49,554.000
11/06/2019	24.00	420,348.7	24.00	70,397.9	490,746.6	4,041.7	50,623.200
11/07/2019	24.00	421,148.5	24.00	68,799.2	489,947.7	3,951.1	51,591.500
11/08/2019	24.00	404,922.5	18.00	48,976.9	453,899.4	3,512.0	47,795.700
11/09/2019	24.00	389,142.6	17.20	46,211.2	435,353.8	3,399.3	45,842.900
11/10/2019	24.00	402,354.3	16.03	38,944.6	441,298.9	3,288.6	46,469.000
11/11/2019	24.00	407,007.4	18.98	51,253.2	458,260.6	3,545.9	48,254.600
11/12/2019	24.00	418,013.4	24.00	68,569.9	486,583.3	3,898.0	51,237.000
11/13/2019	24.00	418,510.0	24.00	66,680.6	485,190.6	3,833.0	51,090.700
11/14/2019	24.00	419,341.2	24.00	73,242.6	492,583.8	3,962.5	51,869.200
11/15/2019	24.00	421,685.6	24.00	60,045.7	481,731.3	3,756.0	50,726.000
11/16/2019	24.00	404,223.3	15.95	38,727.1	442,950.4	3,273.6	46,642.900
11/17/2019	24.00	397,452.7	12.01	29,417.9	426,870.6	3,104.7	44,949.600
11/18/2019	24.00	417,120.4	24.00	70,700.7	487,821.1	3,946.7	51,367.500
11/19/2019	24.00	415,791.4	24.00	70,947.6	486,739.0	3,973.8	51,253.500
11/20/2019	24.00	418,779.8	24.00	76,404.4	495,184.2	3,890.8	52,142.800
11/21/2019	24.00	420,524.1	24.00	80,736.2	501,260.3	3,824.1	52,782.700
11/22/2019	24.00	423,434.1	24.00	68,966.4	492,400.5	3,672.9	51,850.000
11/23/2019	24.00	414,039.6	17.48	47,369.8	461,409.4	3,289.0	48,586.200
11/24/2019	24.00	411,313.4	16.15	33,465.8	444,779.2	3,049.7	46,835.000
11/25/2019	20.08	318,969.0	8.07	23,027.9	341,996.9	2,806.0	36,012.215
11/26/2019	24.00	409,939.5	17.27	41,341.2	451,280.7	3,123.9	47,520.100
11/27/2019	24.00	417,346.8	24.00	65,229.8	482,576.6	3,456.8	50,815.200
11/28/2019	24.00	424,219.9	24.00	71,935.6	496,155.5	3,619.1	52,245.300
11/29/2019	24.00	403,188.2	16.05	49,759.9	452,948.1	3,318.1	47,695.600
11/30/2019	24.00	431,633.2	24.00	59,056.4	490,689.6	3,406.7	51,669.600
Monthly Avg/Sum*:	713.77 *	12,257,239.7 *	607.40 *	1,728,822.4 *	13,986,062.1 *	107,955.9 *	1,459,639.914 *
Daily Min:	20.08	318,969.0	8.07	23,027.9	341,996.9	2,806.0	36,012.215
Daily Max:	24.00	431,633.2	24.00	83,334.8	501,260.3	4,304.3	52,782.700
Oct 2019 - Nov 2019	1,306.10	21,952,866.0	1,029.51	2,878,077.4	24,830,943.4	196,304.9	2,545,211.965
QTD:	1,306.10 *	21,952,866.0 *	1,029.51 *	2,878,077.4 *	24,830,943.4 *	196,304.9 *	2,545,211.965 *
YTD 2019:	4,632.48 *	75,908,875.6 *	3,261.85 *	9,422,004.9 *	85,330,880.5 *	709,115.3 *	8,719,386.466 *

Monthly Summary By Day Report

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 12:38 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr 1 Hour(s)	Unit CT1 GasFlowCT, 100scf 1 Hour(s)	Unit CT1 DBOn, Hr 1 Hour(s)	Unit CT1 GasFlowDB, 100scf 1 Hour(s)	Unit CT1 GasFlow, Total, 100scf 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtu 1 Hour(s)
12/01/2019	24.00	431,674.3	24.00	53,824.2	485,498.5	3,317.8	51,123.200
12/02/2019	24.00	425,510.1	24.00	66,024.0	491,534.1	3,580.9	51,758.300
12/03/2019	24.00	418,571.5	24.00	76,478.2	495,049.7	3,834.0	52,128.700
12/04/2019	24.00	421,365.8	24.00	76,696.0	498,061.8	3,735.7	52,446.100
12/05/2019	24.00	422,065.3	24.00	69,481.4	491,546.7	3,628.5	51,037.800
12/06/2019	24.00	418,930.8	24.00	71,402.8	490,333.6	3,683.0	50,406.200
12/07/2019	24.00	415,663.8	24.00	67,207.0	482,870.8	3,527.7	49,639.100
12/08/2019	24.00	393,579.7	11.22	27,886.5	421,466.2	2,952.6	43,326.800
12/09/2019	24.00	422,381.5	24.00	62,639.8	485,021.3	3,567.2	49,859.800
12/10/2019	24.00	429,805.6	24.00	63,043.9	492,849.5	3,514.0	50,664.700
12/11/2019	24.00	426,794.8	24.00	56,898.9	483,693.7	3,388.2	49,723.800
12/12/2019	24.00	423,982.6	23.65	53,377.1	477,359.7	3,343.2	49,072.300
12/13/2019	20.40	322,219.1	9.10	26,291.5	348,510.6	2,770.6	35,827.330
12/14/2019	24.00	390,137.5	10.02	24,116.4	414,253.9	2,811.5	42,585.200
12/15/2019	24.00	408,657.7	15.92	40,696.4	449,354.1	3,100.8	46,193.300
12/16/2019	24.00	430,553.5	24.00	65,195.3	495,748.8	3,573.6	50,962.800
12/17/2019	24.00	432,581.8	24.00	65,271.9	497,853.7	3,543.0	51,179.200
12/18/2019	24.00	432,786.3	24.00	68,354.6	501,140.9	3,479.6	51,517.300
12/19/2019	24.00	429,632.8	24.00	62,454.7	492,087.5	3,399.7	50,586.500
12/20/2019	24.00	420,522.4	19.98	49,815.8	470,338.2	3,215.9	48,350.800
12/21/2019	24.00	427,565.0	24.00	58,756.3	486,321.3	3,295.7	49,993.700
12/22/2019	24.00	423,101.4	24.00	61,374.3	484,475.7	3,341.3	49,804.100
12/23/2019	24.00	423,814.1	24.00	61,721.3	485,535.4	3,441.5	49,913.200
12/24/2019	24.00	430,534.9	24.00	48,114.3	478,649.2	3,156.0	49,205.300
12/25/2019	24.00	429,787.8	24.00	52,188.9	481,976.7	3,209.7	49,547.400
12/26/2019	24.00	424,562.2	24.00	153,448.4	578,010.6	3,655.6	59,419.600
12/27/2019	24.00	409,806.1	14.94	149,490.3	559,296.4	3,079.7	57,495.700
12/28/2019	24.00	414,567.0	16.98	127,847.5	542,414.5	3,075.6	55,760.300
12/29/2019	24.00	417,491.7	16.53	39,894.2	457,385.9	3,230.4	47,019.200
12/30/2019	24.00	425,242.2	24.00	58,662.8	483,905.0	3,436.6	49,745.600
12/31/2019	24.00	407,753.4	17.00	32,207.1	439,960.5	2,994.5	45,227.900
Monthly Avg/Sum*:	740.40 *	12,951,642.7 *	659.34 *	1,990,861.8 *	14,942,504.5 *	103,884.1 *	1,541,521.230 *
Daily Min:	20.40	322,219.1	9.10	24,116.4	348,510.6	2,770.6	35,827.330
Daily Max:	24.00	432,786.3	24.00	153,448.4	578,010.6	3,834.0	59,419.600
Oct 2019 - Dec 2019	2,046.50	34,904,508.7	1,688.85	4,868,939.2	39,773,447.9	300,189.0	4,086,733.195
QTD:	2,046.50 *	34,904,508.7 *	1,688.85 *	4,868,939.2 *	39,773,447.9 *	300,189.0 *	4,086,733.195 *
YTD 2019:	5,372.88 *	88,860,518.3 *	3,921.19 *	11,412,866.7 *	100,273,385.0 *	812,999.4 *	10,260,907.696 *

Monthly Summary By Day Report

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 12:39 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2019	24.00	386,948.2	8.07	23,418.9	410,367.1	2,519.1	41,077.800
10/02/2019	24.00	390,188.6	17.03	48,802.5	438,991.1	2,761.1	43,943.100
10/03/2019	21.75	333,583.6	7.93	19,831.3	353,414.9	2,243.1	35,376.825
10/04/2019	21.27	323,404.1	9.01	26,035.1	349,439.2	2,389.0	34,978.689
10/05/2019	24.00	386,691.9	16.07	43,060.7	429,752.6	2,722.4	43,018.300
10/06/2019	24.00	385,479.4	16.00	46,384.1	431,863.5	2,774.9	43,229.700
10/07/2019	24.00	412,872.7	24.00	70,810.3	483,683.0	3,107.5	48,416.600
10/08/2019	24.00	409,549.0	24.00	65,883.0	475,432.0	3,010.3	47,590.800
10/09/2019	24.00	400,931.4	19.02	51,320.2	452,251.6	3,071.9	45,270.500
10/10/2019	24.00	400,693.3	15.93	39,754.6	440,447.9	2,870.3	44,088.700
10/11/2019	24.00	376,292.3	13.21	34,443.0	410,735.3	2,643.3	41,115.000
10/12/2019	20.72	325,937.0	13.75	41,700.3	367,637.3	2,834.3	36,800.734
10/13/2019	23.43	383,907.3	13.78	41,330.8	425,238.1	2,810.9	42,566.270
10/14/2019	22.00	340,599.3	12.15	38,770.1	379,369.4	2,660.3	37,974.800
10/15/2019	24.00	393,530.4	15.09	49,047.2	442,577.6	2,958.0	44,301.900
10/16/2019	24.00	408,658.5	21.02	80,388.4	489,046.9	3,525.9	48,953.600
10/17/2019	24.00	392,671.8	14.29	36,386.4	429,058.2	2,648.0	42,948.900
10/18/2019	24.00	398,036.7	15.99	36,814.5	434,851.2	2,660.3	43,528.500
10/19/2019	16.95	269,510.1	12.72	27,690.5	297,200.6	2,225.9	29,749.607
10/20/2019	15.95	234,893.0	5.55	12,531.6	247,424.6	1,903.1	24,767.375
10/21/2019	24.00	399,032.6	11.88	28,744.0	427,776.6	2,642.7	42,820.400
10/22/2019	24.00	414,424.5	24.00	67,774.8	482,199.3	3,021.9	48,268.000
10/23/2019	24.00	394,635.8	11.75	31,019.2	425,655.0	2,642.7	42,607.800
10/24/2019	24.00	418,441.8	24.00	80,539.8	498,981.6	3,288.2	49,948.400
10/25/2019	24.00	411,522.4	24.00	64,957.0	476,479.4	3,097.6	47,695.500
10/26/2019	22.48	363,637.0	13.21	35,073.7	398,710.7	2,626.4	39,910.900
10/27/2019	6.42	71,648.4	0.00	0.0	71,648.4	751.0	7,171.978
10/28/2019	23.23	394,166.6	19.08	49,216.1	443,382.7	3,028.2	44,382.540
10/29/2019	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/30/2019	23.68	384,396.9	16.50	45,397.2	429,794.1	3,263.9	43,022.492
10/31/2019	24.00	423,928.8	24.00	51,519.4	475,448.2	3,022.8	47,592.300
Monthly Avg/Sum*:	673.88 *	11,030,213.4 *	463.03 *	1,288,644.7 *	12,318,858.1 *	81,725.0 *	1,233,118.010 *
Daily Min:	6.42	71,648.4	0.00	0.0	71,648.4	751.0	7,171.978
Daily Max:	24.00	423,928.8	24.00	80,539.8	498,981.6	3,525.9	49,948.400
Oct 2019 - Oct 2019	673.88	11,030,213.4	463.03	1,288,644.7	12,318,858.1	81,725.0	1,233,118.010
QTD:	673.88 *	11,030,213.4 *	463.03 *	1,288,644.7 *	12,318,858.1 *	81,725.0 *	1,233,118.010 *
YTD 2019:	4,560.83 *	73,094,339.5 *	2,898.94 *	8,328,159.0 *	81,422,497.9 *	555,614.8 *	8,287,557.444 *

Monthly Summary By Day Report

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 12:39 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2019	24.00	411,373.2	18.43	52,389.5	463,762.7	2,968.9	46,422.600
11/02/2019	23.08	377,856.6	15.25	45,368.8	423,225.4	3,119.7	42,364.962
11/03/2019	24.00	405,798.9	16.38	48,369.3	454,168.2	2,903.2	45,462.200
11/04/2019	24.00	413,531.1	24.00	78,297.3	491,828.4	3,308.8	49,232.000
11/05/2019	24.00	422,299.3	23.95	69,268.8	491,568.1	3,078.1	49,206.000
11/06/2019	24.00	420,762.9	24.00	66,317.0	487,079.9	3,047.1	48,756.700
11/07/2019	24.00	421,551.1	24.00	67,712.4	489,263.5	3,079.4	48,975.200
11/08/2019	24.00	405,537.1	18.01	48,191.5	453,728.6	2,793.1	45,418.100
11/09/2019	24.00	390,067.9	16.98	46,147.9	436,215.8	2,720.7	43,665.200
11/10/2019	24.00	403,531.8	16.03	39,152.4	442,684.2	2,642.2	44,312.600
11/11/2019	24.00	407,157.2	18.97	49,919.4	457,076.6	2,755.6	45,753.400
11/12/2019	24.00	418,181.2	24.00	66,610.8	484,792.0	3,023.3	48,527.600
11/13/2019	24.00	418,561.7	24.00	64,274.9	482,836.6	2,973.8	48,332.100
11/14/2019	24.00	420,825.4	24.00	71,199.8	492,025.2	3,066.5	49,251.700
11/15/2019	24.00	421,934.6	24.00	59,390.9	481,325.5	2,916.7	48,180.700
11/16/2019	24.00	404,977.9	15.95	38,074.3	443,052.2	2,679.8	44,349.700
11/17/2019	24.00	399,187.8	12.01	28,537.4	427,725.2	2,570.6	42,815.400
11/18/2019	24.00	417,103.3	24.00	67,947.6	485,050.9	3,005.4	48,553.600
11/19/2019	24.00	416,054.9	24.00	68,044.1	484,099.0	3,034.0	48,458.200
11/20/2019	24.00	416,107.8	24.00	72,153.1	488,260.9	3,139.8	48,874.900
11/21/2019	24.00	419,768.1	24.00	75,290.4	495,058.5	3,041.7	49,555.200
11/22/2019	24.00	423,886.4	24.00	67,612.7	491,499.1	2,967.8	49,199.000
11/23/2019	24.00	415,277.3	17.48	47,170.3	462,447.6	2,756.8	46,291.000
11/24/2019	24.00	412,403.1	16.17	33,581.6	445,984.7	2,614.9	44,643.000
11/25/2019	24.00	385,119.5	8.07	21,307.5	406,427.0	2,449.7	40,683.400
11/26/2019	24.00	411,445.6	15.57	35,854.4	447,300.0	2,662.7	44,774.600
11/27/2019	24.00	418,764.3	24.00	63,016.9	481,781.2	2,887.3	48,226.300
11/28/2019	24.00	423,925.7	23.88	60,891.0	484,816.7	2,974.7	48,530.100
11/29/2019	24.00	404,241.3	16.04	43,334.2	447,575.5	2,756.4	44,802.100
11/30/2019	24.00	430,704.9	24.00	56,914.6	487,619.5	2,885.0	48,810.900
Monthly Avg/Sum*:	719.08 *	12,357,937.9 *	605.17 *	1,652,340.8 *	14,010,278.7 *	86,823.7 *	1,402,428.462 *
Daily Min:	23.08	377,856.6	8.07	21,307.5	406,427.0	2,449.7	40,683.400
Daily Max:	24.00	430,704.9	24.00	78,297.3	495,058.5	3,308.8	49,555.200
Oct 2019 - Nov 2019	1,392.96	23,388,151.3	1,068.20	2,940,985.5	26,329,136.8	168,548.7	2,635,546.472
QTD:	1,392.96 *	23,388,151.3 *	1,068.20 *	2,940,985.5 *	26,329,136.8 *	168,548.7 *	2,635,546.472 *
YTD 2019:	5,279.91 *	85,452,277.4 *	3,504.11 *	9,980,499.8 *	95,432,776.6 *	642,438.5 *	9,689,985.906 *

Monthly Summary By Day Report

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 12:39 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr 1 Hour(s)	Unit CT2 GasFlowCT, 100scf 1 Hour(s)	Unit CT2 DBOn, Hr 1 Hour(s)	Unit CT2 GasFlowDB, 100scf 1 Hour(s)	Unit CT2 GasFlow, Total, 100scf 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtu 1 Hour(s)
12/01/2019	24.00	429,661.1	24.00	52,282.8	481,943.9	2,829.1	48,242.900
12/02/2019	24.00	425,158.3	24.00	62,047.0	487,205.3	2,925.8	48,769.100
12/03/2019	24.00	418,420.4	24.00	71,655.6	490,076.0	3,010.3	49,056.700
12/04/2019	24.00	421,923.5	24.00	72,264.6	494,188.1	3,013.3	49,468.300
12/05/2019	24.00	421,752.9	24.00	57,725.6	479,478.5	2,923.8	48,744.900
12/06/2019	24.00	419,624.6	24.00	46,017.1	465,641.7	2,928.7	47,867.800
12/07/2019	24.00	417,024.6	24.00	63,813.7	480,838.3	2,897.0	49,430.300
12/08/2019	24.00	395,081.0	11.15	26,912.2	421,993.2	2,530.5	43,380.900
12/09/2019	24.00	422,575.8	24.00	59,880.4	482,456.2	2,883.6	49,596.700
12/10/2019	24.00	429,161.3	24.00	60,329.3	489,490.6	2,900.8	50,319.600
12/11/2019	24.00	426,406.6	24.00	55,026.6	481,433.2	2,818.5	49,491.200
12/12/2019	24.00	423,873.9	23.65	52,481.9	476,355.8	2,776.7	48,969.300
12/13/2019	24.00	384,461.6	9.10	24,067.3	408,528.9	2,452.3	41,996.700
12/14/2019	24.00	391,695.6	10.02	22,752.2	414,447.8	2,457.4	42,604.900
12/15/2019	24.00	409,386.5	15.92	37,958.7	447,345.2	2,646.3	45,987.200
12/16/2019	24.00	429,534.7	24.00	60,017.9	489,552.6	2,913.0	50,325.900
12/17/2019	24.00	432,785.3	24.00	58,481.0	491,266.3	2,908.4	50,502.100
12/18/2019	24.00	431,001.5	24.00	64,907.2	495,908.7	2,945.1	50,979.500
12/19/2019	24.00	428,719.0	24.00	59,710.3	488,429.3	2,867.0	50,210.500
12/20/2019	24.00	419,442.7	19.98	47,634.2	467,076.9	2,740.6	48,015.900
12/21/2019	24.00	427,020.1	24.00	56,270.3	483,290.4	2,836.7	49,682.100
12/22/2019	24.00	423,722.7	24.00	58,710.9	482,433.6	2,851.3	49,594.300
12/23/2019	24.00	424,266.0	24.00	60,354.8	484,620.8	2,873.5	49,819.300
12/24/2019	24.00	430,262.8	24.00	48,331.9	478,594.7	2,743.2	49,199.600
12/25/2019	24.00	428,985.6	24.00	51,707.9	480,693.5	2,782.7	49,415.100
12/26/2019	24.00	424,589.3	24.00	63,815.4	488,404.7	2,969.2	50,208.100
12/27/2019	24.00	410,506.1	14.92	35,699.6	446,205.7	2,624.8	45,869.900
12/28/2019	24.00	415,478.6	16.98	37,361.0	452,839.6	2,641.8	46,552.000
12/29/2019	24.00	417,545.8	16.50	38,673.8	456,219.6	2,657.6	46,899.300
12/30/2019	24.00	424,632.9	24.00	57,342.2	481,975.1	2,792.4	49,547.000
12/31/2019	24.00	408,522.1	17.00	31,907.3	440,429.4	2,511.3	45,276.100
Monthly Avg/Sum*:	744.00 *	13,013,222.9 *	659.22 *	1,596,140.7 *	14,609,363.6 *	86,652.7 *	1,496,023.200 *
Daily Min:	24.00	384,461.6	9.10	22,752.2	408,528.9	2,452.3	41,996.700
Daily Max:	24.00	432,785.3	24.00	72,264.6	495,908.7	3,013.3	50,979.500
Oct 2019 - Dec 2019	2,136.96	36,401,374.2	1,727.42	4,537,126.2	40,938,500.4	255,201.4	4,131,569.672
QTD:	2,136.96 *	36,401,374.2 *	1,727.42 *	4,537,126.2 *	40,938,500.4 *	255,201.4 *	4,131,569.672 *
YTD 2019:	6,023.91 *	98,465,500.3 *	4,163.33 *	11,576,640.5 *	110,042,140.2 *	729,091.2 *	11,186,009.106 *

ATTACHMENT 10
Maximum Emissions

FCD: AQ-25

AQ-25 Emission Limits

Maximum Emissions Both Turbines (lbs)		
Pollutant	1-Hour Emissions	24-Hour Emissions
NO_x	666.60	2,994.60
CO	967.00	7,659.00
VOC	55.40	630.60
PM10	27.00	648.00
SO_2	14.80	355.20

Monthly Summary By Day Report

AQ-25

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:40 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
10/01/2019	239.3	61.5	35.6	206.9	24.5
10/02/2019	272.6	20.5	43.7	241.5	26.2
10/03/2019	207.3	18.0	35.2	194.2	21.7
10/04/2019	321.8	111.1	23.0	150.3	20.9
10/05/2019	264.8	28.5	42.8	235.7	25.9
10/06/2019	270.0	31.7	43.0	237.7	25.8
10/07/2019	338.8	40.1	48.2	266.2	28.8
10/08/2019	332.8	35.4	47.6	261.5	28.5
10/09/2019	293.4	14.6	45.3	248.8	27.2
10/10/2019	276.7	17.8	44.1	242.4	26.7
10/11/2019	234.1	16.8	41.3	225.9	24.4
10/12/2019	351.7	86.4	32.7	189.1	21.7
10/13/2019	271.4	26.9	42.2	233.7	25.5
10/14/2019	269.0	94.4	32.2	188.5	23.0
10/15/2019	247.8	60.0	28.8	190.5	26.7
10/16/2019	304.7	76.3	16.8	156.6	30.0
10/17/2019	270.1	17.7	42.9	236.0	25.8
10/18/2019	283.3	23.1	43.5	239.2	25.9
10/19/2019	214.8	66.1	19.2	125.7	17.9
10/20/2019	347.1	130.3	18.9	115.1	15.0
10/21/2019	279.3	14.5	42.7	235.1	25.8
10/22/2019	337.7	34.7	49.1	267.3	28.9
10/23/2019	274.5	25.3	42.6	234.1	25.3
10/24/2019	350.3	45.2	49.3	273.8	30.3
10/25/2019	334.4	55.7	47.9	262.6	28.5
10/26/2019	258.2	39.1	39.6	219.1	24.1
10/27/2019	208.8	124.1	2.1	21.4	4.3
10/28/2019	423.7	129.7	42.8	238.1	26.7
10/29/2019	0.0	0.0	0.0	0.0	0.0
10/30/2019	618.8	319.9	36.8	215.5	25.9
10/31/2019	334.6	42.4	47.0	259.6	28.8
Monthly Avg/Sum*:	9,031.8 *	1,807.8 *	1,126.9 *	6,412.1 *	- *
Daily Min:	0.0	0.0	0.0	0.0	-
Daily Max:	618.8	319.9	49.3	273.8	-
Oct 2019 - Oct 2019	9,031.8	1,807.8	1,126.9	6,412.1	-
QTD:	9,031.8 *	1,807.8 *	1,126.9 *	6,412.1 *	0.0 *
YTD 2019:	65,878.9 *	20,744.6 *	7,544.8 *	43,015.2 *	4,393.1 *

Monthly Summary By Day Report

AQ-25

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:40 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
11/01/2019	302.0	29.6	46.2	255.5	27.9
11/02/2019	366.3	82.4	40.7	228.1	24.9
11/03/2019	320.7	30.2	45.2	250.7	27.6
11/04/2019	350.3	33.6	49.0	272.2	29.6
11/05/2019	347.9	50.9	49.5	271.3	29.2
11/06/2019	344.8	52.4	50.0	272.6	29.3
11/07/2019	352.4	49.1	50.7	275.7	29.1
11/08/2019	309.6	38.6	46.9	255.7	27.0
11/09/2019	286.9	38.4	45.0	245.6	26.2
11/10/2019	295.3	38.9	45.8	249.1	26.6
11/11/2019	316.4	48.5	47.5	257.6	27.3
11/12/2019	347.9	55.8	50.4	273.9	28.8
11/13/2019	347.1	54.3	50.5	272.7	28.9
11/14/2019	354.4	56.0	50.4	277.6	28.8
11/15/2019	342.7	49.3	50.3	271.2	28.7
11/16/2019	295.5	38.5	46.5	249.5	26.7
11/17/2019	271.5	33.5	44.8	241.2	25.8
11/18/2019	348.5	55.2	50.4	274.4	28.9
11/19/2019	327.0	48.2	50.6	273.8	28.9
11/20/2019	304.9	36.9	50.9	276.9	29.0
11/21/2019	340.4	26.1	51.5	280.5	29.7
11/22/2019	332.3	17.2	51.2	277.3	29.6
11/23/2019	257.4	8.6	47.8	260.2	27.6
11/24/2019	238.5	9.3	46.5	251.3	27.2
11/25/2019	188.6	71.1	37.6	212.0	24.5
11/26/2019	248.7	17.8	47.0	252.8	26.7
11/27/2019	321.7	27.0	49.9	271.8	28.8
11/28/2019	316.6	24.9	50.8	276.2	28.8
11/29/2019	253.0	12.2	46.4	253.8	26.7
11/30/2019	317.8	16.8	50.4	275.2	28.8
Monthly Avg/Sum*:	9,347.1 *	1,151.3 *	1,440.4 *	7,856.4 *	- *
Daily Min:	188.6	8.6	37.6	212.0	-
Daily Max:	366.3	82.4	51.5	280.5	-
Oct 2019 - Nov 2019	18,378.9	2,959.1	2,567.3	14,268.5	-
QTD:	18,378.9 *	2,959.1 *	2,567.3 *	14,268.5 *	0.0 *
YTD 2019:	75,226.0 *	21,895.9 *	8,985.2 *	50,871.6 *	4,393.1 *

Monthly Summary By Day Report

AQ-25

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:40 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
12/01/2019	299.9	15.6	50.6	272.1	29.0
12/02/2019	303.2	9.6	50.9	275.5	29.4
12/03/2019	320.2	4.8	51.0	277.3	29.2
12/04/2019	307.6	7.4	51.0	279.5	29.4
12/05/2019	284.8	5.8	49.7	273.4	28.8
12/06/2019	269.5	15.7	49.2	269.9	28.6
12/07/2019	303.9	13.7	48.8	272.3	29.1
12/08/2019	210.7	5.9	43.5	238.3	26.1
12/09/2019	345.8	9.5	49.2	273.7	29.6
12/10/2019	334.3	14.4	49.8	277.5	30.2
12/11/2019	301.6	14.1	49.1	272.7	29.4
12/12/2019	297.8	12.1	48.3	269.3	29.0
12/13/2019	194.7	55.8	37.7	215.6	24.9
12/14/2019	189.1	10.5	42.4	234.1	25.6
12/15/2019	250.7	17.8	46.1	253.4	27.4
12/16/2019	349.8	22.8	50.4	278.5	30.4
12/17/2019	347.0	24.3	50.3	279.4	30.7
12/18/2019	339.3	24.9	50.9	281.6	31.1
12/19/2019	323.0	24.3	49.8	277.1	30.4
12/20/2019	272.4	23.9	47.9	264.7	29.1
12/21/2019	326.2	30.0	49.5	274.3	29.7
12/22/2019	325.7	23.4	49.2	273.5	29.7
12/23/2019	334.5	10.8	49.0	274.0	29.8
12/24/2019	298.9	17.1	48.3	270.0	28.9
12/25/2019	311.2	17.1	48.8	272.1	29.0
12/26/2019	299.2	10.4	56.0	299.4	45.2
12/27/2019	81.8	3.7	53.6	281.2	27.6
12/28/2019	0.0	0.0	52.9	279.3	35.7
12/29/2019	171.0	8.2	47.0	257.9	56.9
12/30/2019	351.4	10.2	49.1	273.2	58.9
12/31/2019	253.2	11.6	45.1	249.0	53.8
Monthly Avg/Sum*:	8,598.4 *	475.4 *	1,515.1 *	8,339.8 *	278.1 *
Daily Min:	0.0	0.0	37.7	215.6	27.6
Daily Max:	351.4	55.8	56.0	299.4	58.9
Oct 2019 - Dec 2019	26,977.3	3,434.5	4,082.4	22,608.3	278.1
QTD:	26,977.3 *	3,434.5 *	4,082.4 *	22,608.3 *	278.1 *
YTD 2019:	83,824.4 *	22,371.3 *	10,500.3 *	59,211.4 *	4,671.2 *

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/01/2019 00:00	2.9	0.3	0.4	4.2	0.8
10/01/2019 01:00	2.7	0.0	0.4	4.1	0.8
10/01/2019 02:00	2.7	0.0	0.4	4.1	0.8
10/01/2019 03:00	2.8	0.0	0.4	4.2	0.8
10/01/2019 04:00	7.7	10.5	0.7	5.5	1.1
10/01/2019 05:00	32.9	38.7	1.3	7.4	1.6
10/01/2019 06:00	6.6	0.0	1.6	9.0	2.0
10/01/2019 07:00	6.5	0.0	1.6	8.9	2.0
10/01/2019 08:00	6.6	0.0	1.6	9.0	2.0
10/01/2019 09:00	6.4	0.0	1.6	8.9	2.0
10/01/2019 10:00	6.4	0.0	1.6	8.8	2.0
10/01/2019 11:00	6.4	0.0	1.6	8.8	2.0
10/01/2019 12:00	8.0	0.0	1.6	8.8	2.0
10/01/2019 13:00	8.0	0.0	1.6	8.8	2.0
10/01/2019 14:00	9.4	0.0	1.6	8.6	1.8
10/01/2019 15:00	9.4	0.0	1.6	8.6	1.8
10/01/2019 16:00	13.8	3.1	2.0	10.8	2.4
10/01/2019 17:00	14.2	2.8	2.0	11.1	2.4
10/01/2019 18:00	14.3	2.2	2.0	11.2	2.4
10/01/2019 19:00	14.4	0.9	2.0	11.3	2.4
10/01/2019 20:00	14.4	0.6	2.0	11.3	2.4
10/01/2019 21:00	14.4	0.6	2.0	11.3	2.4
10/01/2019 22:00	14.2	0.6	2.0	11.1	2.4
10/01/2019 23:00	14.2	1.2	2.0	11.1	2.4
Average/Sum#:	239.3 #	61.5 #	35.6 #	206.9 #	44.7 #
Minimum:	2.7	0.0	0.4	4.1	0.8
Maximum:	32.9	38.7	2.0	11.3	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/02/2019 00:00	14.4	0.6	2.0	11.3	2.4
10/02/2019 01:00	14.3	0.6	2.0	11.2	2.4
10/02/2019 02:00	14.2	0.6	2.0	11.2	2.4
10/02/2019 03:00	14.2	0.6	2.0	11.2	2.4
10/02/2019 04:00	13.9	0.6	2.0	11.0	2.4
10/02/2019 05:00	14.2	0.9	2.0	11.1	2.4
10/02/2019 06:00	14.2	0.6	2.0	11.0	2.4
10/02/2019 07:00	13.5	0.6	1.9	10.6	2.4
10/02/2019 08:00	6.2	0.0	1.6	8.6	1.8
10/02/2019 09:00	3.8	0.0	1.3	6.9	1.6
10/02/2019 10:00	3.8	0.0	1.3	7.0	1.6
10/02/2019 11:00	3.9	0.0	1.3	7.1	1.6
10/02/2019 12:00	3.8	0.0	1.3	6.9	1.6
10/02/2019 13:00	3.9	0.0	1.3	7.1	1.6
10/02/2019 14:00	6.2	0.0	1.6	8.4	1.8
10/02/2019 15:00	13.7	2.8	2.0	10.8	2.4
10/02/2019 16:00	14.3	2.8	2.0	11.2	2.4
10/02/2019 17:00	14.4	2.2	2.1	11.4	2.4
10/02/2019 18:00	14.4	2.2	2.0	11.4	2.4
10/02/2019 19:00	14.5	1.5	2.0	11.4	2.4
10/02/2019 20:00	14.5	0.9	2.0	11.4	2.4
10/02/2019 21:00	14.3	0.9	2.0	11.3	2.4
10/02/2019 22:00	14.1	1.2	2.0	11.1	2.4
10/02/2019 23:00	13.9	0.9	2.0	10.9	2.4
Average/Sum#:	272.6 #	20.5 #	43.7 #	241.5 #	52.4 #
Minimum:	3.8	0.0	1.3	6.9	1.6
Maximum:	14.5	2.8	2.1	11.4	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/03/2019 00:00	13.8	0.6	2.0	10.8	2.4
10/03/2019 01:00	13.4	0.3	1.9	10.6	2.3
10/03/2019 02:00	13.8	0.6	2.0	10.8	2.4
10/03/2019 03:00	14.0	0.6	2.0	11.0	2.4
10/03/2019 04:00	14.1	0.6	2.0	11.0	2.4
10/03/2019 05:00	14.0	0.9	2.0	11.0	2.4
10/03/2019 06:00	12.2	0.6	2.0	11.2	2.4
10/03/2019 07:00	13.5	0.6	1.9	10.6	2.4
10/03/2019 08:00	5.8	0.0	1.4	8.0	1.8
10/03/2019 09:00	5.0	0.0	1.3	6.9	1.6
10/03/2019 10:00	5.0	0.0	1.3	6.9	1.5
10/03/2019 11:00	5.0	0.0	1.3	6.9	1.5
10/03/2019 12:00	5.2	0.0	1.3	7.2	1.6
10/03/2019 13:00	5.2	0.0	1.3	7.1	1.6
10/03/2019 14:00	5.4	0.0	1.3	7.5	1.6
10/03/2019 15:00	5.4	0.0	1.3	7.5	1.6
10/03/2019 16:00	9.6	0.0	1.6	8.8	2.0
10/03/2019 17:00	9.5	0.0	1.6	8.8	1.9
10/03/2019 18:00	9.6	0.0	1.6	8.8	2.0
10/03/2019 19:00	9.7	0.0	1.6	8.9	2.0
10/03/2019 20:00	8.0	0.0	1.6	8.8	2.0
10/03/2019 21:00	10.1	13.2	0.9	5.1	1.1
10/03/2019 22:00	0.0	0.0	0.0	0.0	0.0
10/03/2019 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	207.3 #	18.0 #	35.2 #	194.2 #	42.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	14.1	13.2	2.0	11.2	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/04/2019 00:00	0.0	0.0	0.0	0.0	0.0
10/04/2019 01:00	0.0	0.0	0.0	0.0	0.0
10/04/2019 02:00	7.8	5.6	0.0	0.3	0.1
10/04/2019 03:00	53.0	42.4	0.3	3.1	0.6
10/04/2019 04:00	2.8	0.0	0.4	4.2	0.8
10/04/2019 05:00	7.9	0.6	0.6	5.9	1.2
10/04/2019 06:00	7.9	0.6	0.6	5.9	1.2
10/04/2019 07:00	2.7	0.0	0.4	4.1	0.8
10/04/2019 08:00	2.7	0.0	0.4	4.1	0.8
10/04/2019 09:00	2.7	0.0	0.4	4.1	0.8
10/04/2019 10:00	2.7	0.0	0.4	4.1	0.8
10/04/2019 11:00	2.7	0.0	0.4	4.1	0.8
10/04/2019 12:00	2.7	0.0	0.4	4.1	0.8
10/04/2019 13:00	34.9	11.6	0.6	5.0	1.0
10/04/2019 14:00	77.9	42.3	1.0	6.6	1.4
10/04/2019 15:00	4.2	0.0	1.4	7.8	1.7
10/04/2019 16:00	9.0	0.0	1.6	8.3	1.8
10/04/2019 17:00	13.8	2.5	2.0	10.8	2.4
10/04/2019 18:00	14.7	1.6	2.1	11.5	2.6
10/04/2019 19:00	14.4	0.9	2.0	11.3	2.4
10/04/2019 20:00	14.5	0.9	2.0	11.4	2.5
10/04/2019 21:00	14.4	0.6	2.0	11.3	2.4
10/04/2019 22:00	14.2	0.6	2.0	11.2	2.4
10/04/2019 23:00	14.2	0.9	2.0	11.1	2.4
Average/Sum#:	321.8 #	111.1 #	23.0 #	150.3 #	31.7 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	77.9	42.4	2.1	11.5	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/05/2019 00:00	14.0	1.2	2.0	10.9	2.4
10/05/2019 01:00	13.8	1.2	2.0	10.9	2.4
10/05/2019 02:00	13.5	0.9	1.9	10.7	2.3
10/05/2019 03:00	14.0	1.2	2.0	11.0	2.4
10/05/2019 04:00	14.2	0.9	2.0	11.2	2.4
10/05/2019 05:00	14.4	1.2	2.0	11.3	2.4
10/05/2019 06:00	14.0	1.3	2.0	11.1	2.4
10/05/2019 07:00	13.4	1.2	1.9	10.5	2.3
10/05/2019 08:00	6.0	0.0	1.5	8.2	1.8
10/05/2019 09:00	5.0	0.0	1.3	6.9	1.5
10/05/2019 10:00	5.0	0.0	1.3	6.9	1.5
10/05/2019 11:00	3.7	0.0	1.3	6.9	1.5
10/05/2019 12:00	5.2	0.0	1.3	7.1	1.6
10/05/2019 13:00	3.7	0.0	1.3	6.9	1.5
10/05/2019 14:00	5.8	0.0	1.4	7.9	1.8
10/05/2019 15:00	6.0	0.0	1.4	8.2	1.8
10/05/2019 16:00	13.5	2.5	2.0	10.6	2.4
10/05/2019 17:00	14.0	2.8	2.0	11.0	2.4
10/05/2019 18:00	14.1	2.8	2.0	11.1	2.4
10/05/2019 19:00	14.2	2.5	2.0	11.2	2.4
10/05/2019 20:00	14.4	2.2	2.1	11.4	2.4
10/05/2019 21:00	14.4	2.2	2.1	11.4	2.4
10/05/2019 22:00	14.2	2.2	2.0	11.2	2.4
10/05/2019 23:00	14.3	2.2	2.0	11.2	2.4
Average/Sum#:	264.8 #	28.5 #	42.8 #	235.7 #	51.2 #
Minimum:	3.7	0.0	1.3	6.9	1.5
Maximum:	14.4	2.8	2.1	11.4	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/06/2019 00:00	14.2	2.2	2.0	11.2	2.4
10/06/2019 01:00	13.8	2.5	2.0	10.8	2.4
10/06/2019 02:00	13.8	2.8	2.0	10.8	2.4
10/06/2019 03:00	13.8	2.8	2.0	10.8	2.4
10/06/2019 04:00	13.9	1.8	2.0	10.9	2.4
10/06/2019 05:00	14.0	1.5	2.0	11.0	2.4
10/06/2019 06:00	13.5	0.9	1.9	10.7	2.3
10/06/2019 07:00	6.0	0.0	1.4	8.2	1.8
10/06/2019 08:00	5.2	0.0	1.3	7.3	1.6
10/06/2019 09:00	3.7	0.0	1.3	6.8	1.4
10/06/2019 10:00	3.9	0.0	1.3	7.1	1.6
10/06/2019 11:00	5.3	0.0	1.3	7.3	1.6
10/06/2019 12:00	5.4	0.0	1.3	7.5	1.6
10/06/2019 13:00	5.4	0.0	1.3	7.3	1.6
10/06/2019 14:00	9.4	0.0	1.6	8.6	1.8
10/06/2019 15:00	13.8	2.5	2.0	10.8	2.4
10/06/2019 16:00	14.2	2.2	2.0	11.2	2.4
10/06/2019 17:00	14.6	1.5	2.1	11.5	2.5
10/06/2019 18:00	14.8	1.5	2.1	11.7	2.6
10/06/2019 19:00	14.4	1.8	2.1	11.4	2.4
10/06/2019 20:00	14.4	1.8	2.0	11.3	2.4
10/06/2019 21:00	14.4	2.2	2.0	11.4	2.4
10/06/2019 22:00	14.2	2.2	2.0	11.2	2.4
10/06/2019 23:00	13.9	1.5	2.0	10.9	2.4
Average/Sum#:	270.0 #	31.7 #	43.0 #	237.7 #	51.6 #
Minimum:	3.7	0.0	1.3	6.8	1.4
Maximum:	14.8	2.8	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/07/2019 00:00	13.9	0.9	2.0	10.9	2.4
10/07/2019 01:00	14.0	0.6	2.0	11.0	2.4
10/07/2019 02:00	13.8	1.2	2.0	10.9	2.4
10/07/2019 03:00	14.0	1.2	2.0	11.0	2.4
10/07/2019 04:00	14.3	0.9	2.0	11.3	2.4
10/07/2019 05:00	14.2	1.2	2.0	11.1	2.4
10/07/2019 06:00	14.3	1.2	2.0	11.2	2.4
10/07/2019 07:00	14.1	2.2	2.0	11.1	2.4
10/07/2019 08:00	14.1	2.5	2.0	11.0	2.4
10/07/2019 09:00	14.2	2.2	2.0	11.2	2.4
10/07/2019 10:00	14.0	2.2	2.0	11.0	2.4
10/07/2019 11:00	13.9	2.2	2.0	10.9	2.4
10/07/2019 12:00	13.9	1.8	2.0	10.9	2.4
10/07/2019 13:00	14.0	1.8	2.0	11.0	2.4
10/07/2019 14:00	14.0	1.8	2.0	11.0	2.4
10/07/2019 15:00	14.0	1.8	2.0	11.0	2.4
10/07/2019 16:00	14.3	1.8	2.0	11.3	2.4
10/07/2019 17:00	14.6	1.5	2.1	11.5	2.5
10/07/2019 18:00	14.6	1.5	2.1	11.5	2.5
10/07/2019 19:00	14.4	1.8	2.0	11.2	2.4
10/07/2019 20:00	14.2	1.8	2.0	11.2	2.4
10/07/2019 21:00	14.0	1.9	2.0	11.0	2.4
10/07/2019 22:00	14.2	1.9	2.0	11.2	2.4
10/07/2019 23:00	13.8	2.2	2.0	10.8	2.4
Average/Sum#:	338.8 #	40.1 #	48.2 #	266.2 #	57.8 #
Minimum:	13.8	0.6	2.0	10.8	2.4
Maximum:	14.6	2.5	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/08/2019 00:00	13.4	2.2	1.9	10.6	2.3
10/08/2019 01:00	13.0	1.9	1.9	10.2	2.2
10/08/2019 02:00	13.1	2.2	1.9	10.2	2.2
10/08/2019 03:00	15.2	2.5	1.9	10.5	2.2
10/08/2019 04:00	13.5	2.5	1.9	10.6	2.4
10/08/2019 05:00	14.0	2.5	2.0	11.0	2.4
10/08/2019 06:00	12.1	1.5	2.0	11.1	2.4
10/08/2019 07:00	13.9	1.2	2.0	10.9	2.4
10/08/2019 08:00	13.9	0.9	2.0	10.9	2.4
10/08/2019 09:00	13.9	0.9	2.0	10.9	2.4
10/08/2019 10:00	13.9	0.6	2.0	10.9	2.4
10/08/2019 11:00	13.9	0.6	2.0	10.9	2.4
10/08/2019 12:00	14.0	0.6	2.0	11.1	2.4
10/08/2019 13:00	14.0	1.5	2.0	11.0	2.4
10/08/2019 14:00	13.8	1.8	2.0	10.8	2.4
10/08/2019 15:00	14.0	2.1	2.0	11.0	2.4
10/08/2019 16:00	14.2	1.8	2.0	11.2	2.4
10/08/2019 17:00	14.5	1.5	2.1	11.4	2.5
10/08/2019 18:00	14.4	1.5	2.0	11.3	2.4
10/08/2019 19:00	14.4	1.5	2.0	11.2	2.4
10/08/2019 20:00	14.4	1.5	2.0	11.2	2.4
10/08/2019 21:00	14.1	0.9	2.0	11.1	2.4
10/08/2019 22:00	13.5	0.6	2.0	10.7	2.4
10/08/2019 23:00	13.7	0.6	2.0	10.8	2.4
Average/Sum#:	332.8 #	35.4 #	47.6 #	261.5 #	57.0 #
Minimum:	12.1	0.6	1.9	10.2	2.2
Maximum:	15.2	2.5	2.1	11.4	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/09/2019 00:00	13.8	0.6	2.0	10.8	2.4
10/09/2019 01:00	13.3	0.3	1.9	10.4	2.2
10/09/2019 02:00	13.5	0.6	1.9	10.5	2.3
10/09/2019 03:00	13.8	0.6	2.0	10.9	2.4
10/09/2019 04:00	14.0	0.6	2.0	11.0	2.4
10/09/2019 05:00	14.0	0.9	2.0	11.0	2.4
10/09/2019 06:00	12.3	0.6	2.0	11.2	2.4
10/09/2019 07:00	14.1	0.6	2.0	11.0	2.4
10/09/2019 08:00	13.8	0.6	2.0	10.9	2.4
10/09/2019 09:00	14.0	0.6	2.0	11.0	2.4
10/09/2019 10:00	14.0	0.6	2.0	11.0	2.4
10/09/2019 11:00	6.5	0.0	1.6	9.0	2.0
10/09/2019 12:00	8.0	0.0	1.6	8.8	2.0
10/09/2019 13:00	6.2	0.0	1.6	8.6	1.8
10/09/2019 14:00	6.0	0.0	1.4	8.1	1.8
10/09/2019 15:00	6.0	0.0	1.4	8.2	1.8
10/09/2019 16:00	13.1	0.6	1.9	10.3	2.2
10/09/2019 17:00	14.0	1.9	2.0	11.0	2.4
10/09/2019 18:00	13.8	1.9	2.0	10.8	2.4
10/09/2019 19:00	13.8	1.2	2.0	10.8	2.4
10/09/2019 20:00	13.9	0.6	2.0	10.9	2.4
10/09/2019 21:00	13.8	0.6	2.0	10.9	2.4
10/09/2019 22:00	13.9	0.6	2.0	10.9	2.4
10/09/2019 23:00	13.8	0.6	2.0	10.8	2.4
Average/Sum#:	293.4 #	14.6 #	45.3 #	248.8 #	54.5 #
Minimum:	6.0	0.0	1.4	8.1	1.8
Maximum:	14.1	1.9	2.0	11.2	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/10/2019 00:00	13.8	0.6	2.0	10.8	2.4
10/10/2019 01:00	13.1	0.3	1.9	10.3	2.2
10/10/2019 02:00	13.3	0.6	1.9	10.5	2.2
10/10/2019 03:00	13.7	0.6	2.0	10.8	2.4
10/10/2019 04:00	13.7	0.6	2.0	10.8	2.4
10/10/2019 05:00	13.7	1.0	2.0	10.8	2.4
10/10/2019 06:00	12.0	1.0	2.0	11.0	2.4
10/10/2019 07:00	13.3	0.6	1.9	10.5	2.2
10/10/2019 08:00	5.8	0.0	1.4	8.0	1.8
10/10/2019 09:00	6.4	0.0	1.6	8.7	1.9
10/10/2019 10:00	6.4	0.0	1.6	8.9	2.0
10/10/2019 11:00	6.4	0.0	1.6	8.8	2.0
10/10/2019 12:00	8.1	0.0	1.6	8.9	2.0
10/10/2019 13:00	8.0	0.0	1.6	8.7	1.9
10/10/2019 14:00	8.0	0.0	1.6	8.8	2.0
10/10/2019 15:00	9.0	0.0	1.4	8.2	1.8
10/10/2019 16:00	13.8	0.6	2.0	10.8	2.4
10/10/2019 17:00	13.7	0.6	2.0	10.8	2.4
10/10/2019 18:00	14.2	1.9	2.0	11.2	2.4
10/10/2019 19:00	14.2	2.2	2.0	11.1	2.4
10/10/2019 20:00	14.2	2.5	2.0	11.1	2.4
10/10/2019 21:00	14.2	2.2	2.0	11.2	2.4
10/10/2019 22:00	14.2	1.9	2.0	11.1	2.4
10/10/2019 23:00	13.5	0.6	2.0	10.6	2.4
Average/Sum#:	276.7 #	17.8 #	44.1 #	242.4 #	53.2 #
Minimum:	5.8	0.0	1.4	8.0	1.8
Maximum:	14.2	2.5	2.0	11.2	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/11/2019 00:00	13.5	0.3	1.9	10.6	2.4
10/11/2019 01:00	12.9	0.3	1.9	10.2	2.2
10/11/2019 02:00	12.9	0.3	1.9	10.2	2.2
10/11/2019 03:00	13.0	0.3	1.9	10.2	2.2
10/11/2019 04:00	13.0	0.3	1.9	10.2	2.2
10/11/2019 05:00	4.9	0.0	1.6	9.0	2.0
10/11/2019 06:00	6.5	0.0	1.6	8.9	2.0
10/11/2019 07:00	4.2	0.0	1.4	7.7	1.6
10/11/2019 08:00	3.7	0.0	1.3	6.8	1.4
10/11/2019 09:00	3.7	0.0	1.3	6.8	1.4
10/11/2019 10:00	3.7	0.0	1.3	6.8	1.4
10/11/2019 11:00	3.7	0.0	1.3	6.8	1.4
10/11/2019 12:00	3.7	0.0	1.3	6.8	1.4
10/11/2019 13:00	3.8	0.0	1.3	7.0	1.6
10/11/2019 14:00	8.1	0.0	1.6	8.9	2.0
10/11/2019 15:00	7.8	0.0	1.6	8.6	1.8
10/11/2019 16:00	13.7	2.5	2.0	10.8	2.4
10/11/2019 17:00	14.7	1.9	2.1	11.6	2.6
10/11/2019 18:00	15.0	1.5	2.1	11.8	2.6
10/11/2019 19:00	14.4	1.9	2.0	11.3	2.4
10/11/2019 20:00	14.3	2.2	2.0	11.2	2.4
10/11/2019 21:00	14.3	2.2	2.0	11.3	2.4
10/11/2019 22:00	14.3	2.2	2.0	11.2	2.4
10/11/2019 23:00	14.3	0.9	2.0	11.2	2.4
Average/Sum#:	234.1 #	16.8 #	41.3 #	225.9 #	48.8 #
Minimum:	3.7	0.0	1.3	6.8	1.4
Maximum:	15.0	2.5	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/12/2019 00:00	14.3	0.6	2.0	11.2	2.4
10/12/2019 01:00	14.0	0.6	2.0	11.0	2.4
10/12/2019 02:00	14.0	0.6	2.0	11.0	2.4
10/12/2019 03:00	14.2	0.6	2.0	11.1	2.4
10/12/2019 04:00	14.2	0.6	2.0	11.2	2.4
10/12/2019 05:00	14.3	0.9	2.0	11.2	2.4
10/12/2019 06:00	12.2	0.9	2.0	11.2	2.4
10/12/2019 07:00	14.1	11.3	0.7	3.4	0.8
10/12/2019 08:00	0.0	0.0	0.0	0.0	0.0
10/12/2019 09:00	0.0	0.0	0.0	0.0	0.0
10/12/2019 10:00	0.2	1.2	0.0	0.2	0.0
10/12/2019 11:00	45.5	24.5	0.2	2.0	0.4
10/12/2019 12:00	1.3	0.0	0.4	4.0	0.8
10/12/2019 13:00	2.6	0.0	0.4	3.9	0.8
10/12/2019 14:00	16.3	7.3	0.6	5.2	1.0
10/12/2019 15:00	56.2	25.9	1.1	6.7	1.4
10/12/2019 16:00	8.0	0.0	1.6	8.8	2.0
10/12/2019 17:00	12.2	0.3	1.7	9.6	2.0
10/12/2019 18:00	18.2	2.2	2.0	11.2	2.4
10/12/2019 19:00	20.5	1.9	2.0	11.2	2.4
10/12/2019 20:00	16.3	1.9	2.0	11.2	2.4
10/12/2019 21:00	14.4	1.9	2.0	11.3	2.4
10/12/2019 22:00	14.2	1.9	2.0	11.2	2.4
10/12/2019 23:00	14.5	1.3	2.0	11.3	2.4
Average/Sum#:	351.7 #	86.4 #	32.7 #	189.1 #	40.4 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	56.2	25.9	2.0	11.3	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/13/2019 00:00	14.2	0.9	2.0	11.2	2.4
10/13/2019 01:00	14.2	0.6	2.0	11.2	2.4
10/13/2019 02:00	14.3	0.6	2.0	11.2	2.4
10/13/2019 03:00	14.3	0.6	2.0	11.2	2.4
10/13/2019 04:00	14.3	0.6	2.0	11.2	2.4
10/13/2019 05:00	14.3	0.9	2.0	11.2	2.4
10/13/2019 06:00	11.8	0.6	2.0	10.8	2.4
10/13/2019 07:00	6.0	0.0	1.4	8.2	1.8
10/13/2019 08:00	6.4	0.0	1.6	8.8	2.0
10/13/2019 09:00	6.4	0.0	1.6	8.9	2.0
10/13/2019 10:00	6.4	0.0	1.6	8.8	2.0
10/13/2019 11:00	7.5	0.0	1.4	8.2	1.8
10/13/2019 12:00	9.7	0.0	1.6	8.9	2.0
10/13/2019 13:00	7.5	0.0	1.6	8.3	1.8
10/13/2019 14:00	11.2	0.0	1.6	8.8	2.0
10/13/2019 15:00	7.5	0.0	1.6	8.3	1.8
10/13/2019 16:00	13.7	2.5	2.0	10.8	2.4
10/13/2019 17:00	14.4	2.1	2.0	11.3	2.4
10/13/2019 18:00	14.2	1.8	2.0	11.1	2.4
10/13/2019 19:00	14.1	1.8	2.0	11.0	2.4
10/13/2019 20:00	14.0	2.2	2.0	11.0	2.4
10/13/2019 21:00	14.2	1.8	2.0	11.2	2.4
10/13/2019 22:00	12.6	0.6	1.8	9.9	2.2
10/13/2019 23:00	8.1	9.3	0.4	2.2	0.4
Average/Sum#:	271.3 #	26.9 #	42.2 #	233.7 #	51.0 #
Minimum:	6.0	0.0	0.4	2.2	0.4
Maximum:	14.4	9.3	2.0	11.3	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/14/2019 00:00	0.0	0.0	0.0	0.0	0.0
10/14/2019 01:00	0.0	0.0	0.0	0.0	0.0
10/14/2019 02:00	31.2	24.1	0.2	1.8	0.4
10/14/2019 03:00	3.0	0.0	0.4	4.4	0.9
10/14/2019 04:00	7.8	0.6	0.6	5.8	1.2
10/14/2019 05:00	8.1	0.6	0.6	6.1	1.2
10/14/2019 06:00	4.4	5.1	0.6	5.1	1.1
10/14/2019 07:00	39.8	45.4	1.1	6.7	1.4
10/14/2019 08:00	4.4	0.0	1.4	8.0	1.8
10/14/2019 09:00	5.0	0.0	1.3	6.9	1.6
10/14/2019 10:00	3.7	0.0	1.3	6.9	1.5
10/14/2019 11:00	5.2	0.0	1.3	7.2	1.6
10/14/2019 12:00	2.9	0.0	1.4	7.9	1.8
10/14/2019 13:00	9.4	0.3	1.6	8.6	1.8
10/14/2019 14:00	13.5	2.6	2.0	10.6	2.4
10/14/2019 15:00	14.0	2.8	2.0	11.0	2.4
10/14/2019 16:00	14.4	1.8	2.0	11.2	2.4
10/14/2019 17:00	14.7	1.5	2.1	11.6	2.6
10/14/2019 18:00	15.0	1.2	2.1	11.8	2.6
10/14/2019 19:00	15.0	1.2	2.1	11.8	2.6
10/14/2019 20:00	14.7	1.5	2.1	11.5	2.6
10/14/2019 21:00	14.3	1.9	2.0	11.2	2.4
10/14/2019 22:00	14.2	1.9	2.0	11.2	2.4
10/14/2019 23:00	14.3	1.9	2.0	11.2	2.4
Average/Sum#:	266.1 #	94.4 #	32.2 #	188.5 #	41.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	39.8	45.4	2.1	11.8	2.6
%SI	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/15/2019 00:00	14.3	2.2	2.0	11.2	2.4
10/15/2019 01:00	14.2	2.2	2.0	11.2	2.4
10/15/2019 02:00	14.3	2.2	2.0	11.2	2.4
10/15/2019 03:00	14.2	2.2	2.0	11.2	2.4
10/15/2019 04:00	14.2	0.9	2.0	11.1	2.4
10/15/2019 05:00	14.1	14.6	1.3	8.2	1.8
10/15/2019 06:00	9.7	11.8	0.6	5.5	1.1
10/15/2019 07:00	30.8	18.5	1.6	9.0	1.9
10/15/2019 08:00	5.9	0.0	1.4	8.1	1.8
10/15/2019 09:00	5.2	0.0	1.3	7.2	1.6
10/15/2019 10:00	5.2	0.0	1.3	7.1	1.6
10/15/2019 11:00	5.2	0.0	1.3	7.3	1.6
10/15/2019 12:00	5.6	0.0	1.4	7.7	1.6
10/15/2019 13:00	9.7	0.0	1.6	8.9	2.0
10/15/2019 14:00	9.7	0.0	1.6	8.9	2.0
10/15/2019 15:00	7.5	0.6	0.6	5.6	1.1
10/15/2019 16:00	8.5	0.6	0.6	6.3	1.3
10/15/2019 17:00	8.5	0.6	0.6	6.4	1.3
10/15/2019 18:00	8.5	0.6	0.6	6.4	1.3
10/15/2019 19:00	8.5	0.6	0.6	6.4	1.3
10/15/2019 20:00	8.5	0.6	0.6	6.4	1.3
10/15/2019 21:00	8.5	0.6	0.6	6.4	1.3
10/15/2019 22:00	8.5	0.6	0.6	6.4	1.3
10/15/2019 23:00	8.5	0.6	0.6	6.4	1.3
Average/Sum#:	247.8 #	60.0 #	28.8 #	190.5 #	40.5 #
Minimum:	5.2	0.0	0.6	5.5	1.1
Maximum:	30.8	18.5	2.0	11.2	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/16/2019 00:00	8.5	0.6	0.6	6.4	1.3
10/16/2019 01:00	8.5	0.6	0.6	6.4	1.3
10/16/2019 02:00	8.5	0.3	0.6	6.4	1.3
10/16/2019 03:00	8.5	0.3	0.6	6.3	1.3
10/16/2019 04:00	8.6	0.6	0.6	6.4	1.3
10/16/2019 05:00	8.6	0.6	0.6	6.4	1.3
10/16/2019 06:00	8.6	0.3	0.6	6.4	1.3
10/16/2019 07:00	8.5	0.3	0.6	6.4	1.3
10/16/2019 08:00	8.5	0.3	0.6	6.4	1.3
10/16/2019 09:00	8.4	0.3	0.6	6.3	1.3
10/16/2019 10:00	8.4	0.3	0.6	6.3	1.3
10/16/2019 11:00	8.4	0.6	0.6	6.3	1.3
10/16/2019 12:00	8.4	0.6	0.6	6.3	1.3
10/16/2019 13:00	8.4	0.6	0.6	6.3	1.3
10/16/2019 14:00	8.4	0.6	0.6	6.3	1.3
10/16/2019 15:00	8.4	0.6	0.6	6.3	1.3
10/16/2019 16:00	8.4	0.6	0.6	6.3	1.3
10/16/2019 17:00	8.4	0.6	0.6	6.3	1.3
10/16/2019 18:00	8.4	0.6	0.6	6.3	1.3
10/16/2019 19:00	8.3	0.6	0.6	6.3	1.3
10/16/2019 20:00	29.6	33.7	0.7	6.5	1.3
10/16/2019 21:00	92.4	32.7	1.1	6.8	1.5
10/16/2019 22:00	5.6	0.0	1.4	7.7	1.6
10/16/2019 23:00	8.0	0.0	1.6	8.8	2.0
Average/Sum#:	304.7 #	76.3 #	16.8 #	156.6 #	32.4 #
Minimum:	5.6	0.0	0.6	6.3	1.3
Maximum:	92.4	33.7	1.6	8.8	2.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/17/2019 00:00	7.9	0.0	1.6	8.6	1.8
10/17/2019 01:00	8.2	0.0	1.6	9.0	2.0
10/17/2019 02:00	13.3	1.9	1.9	10.5	2.2
10/17/2019 03:00	13.5	1.2	2.0	10.6	2.4
10/17/2019 04:00	13.8	1.2	2.0	10.8	2.4
10/17/2019 05:00	13.7	1.2	2.0	10.8	2.4
10/17/2019 06:00	12.1	0.9	2.0	11.0	2.4
10/17/2019 07:00	13.7	0.3	2.0	10.8	2.4
10/17/2019 08:00	9.2	0.0	1.6	8.4	1.8
10/17/2019 09:00	7.4	0.0	1.4	8.1	1.8
10/17/2019 10:00	7.4	0.0	1.4	8.2	1.8
10/17/2019 11:00	7.7	0.0	1.6	8.4	1.8
10/17/2019 12:00	5.2	0.0	1.3	7.2	1.6
10/17/2019 13:00	7.3	0.0	1.4	8.0	1.8
10/17/2019 14:00	7.7	0.0	1.6	8.6	1.8
10/17/2019 15:00	9.0	0.0	1.4	8.2	1.8
10/17/2019 16:00	13.5	1.9	2.0	10.6	2.4
10/17/2019 17:00	14.8	1.6	2.1	11.6	2.6
10/17/2019 18:00	14.5	1.6	2.1	11.4	2.4
10/17/2019 19:00	14.3	1.9	2.0	11.2	2.4
10/17/2019 20:00	14.4	1.9	2.0	11.4	2.4
10/17/2019 21:00	14.3	0.9	2.0	11.2	2.4
10/17/2019 22:00	13.7	0.6	2.0	10.8	2.4
10/17/2019 23:00	13.5	0.6	1.9	10.6	2.4
Average/Sum#:	270.1 #	17.7 #	42.9 #	236.0 #	51.6 #
Minimum:	5.2	0.0	1.3	7.2	1.6
Maximum:	14.8	1.9	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/18/2019 00:00	13.3	0.6	1.9	10.4	2.2
10/18/2019 01:00	13.3	0.6	1.9	10.4	2.2
10/18/2019 02:00	12.9	0.6	1.9	10.2	2.2
10/18/2019 03:00	13.3	0.6	1.9	10.4	2.2
10/18/2019 04:00	13.8	1.6	2.0	10.8	2.4
10/18/2019 05:00	13.6	1.6	2.0	10.8	2.4
10/18/2019 06:00	14.0	1.3	2.0	11.0	2.4
10/18/2019 07:00	12.9	0.6	1.9	10.2	2.2
10/18/2019 08:00	6.1	0.0	1.6	8.4	1.8
10/18/2019 09:00	7.4	0.0	1.4	8.1	1.8
10/18/2019 10:00	7.4	0.0	1.4	8.2	1.8
10/18/2019 11:00	7.5	0.0	1.4	8.2	1.8
10/18/2019 12:00	7.2	0.0	1.4	8.0	1.8
10/18/2019 13:00	9.4	0.0	1.6	8.6	1.8
10/18/2019 14:00	9.4	0.0	1.6	8.6	1.8
10/18/2019 15:00	9.4	0.0	1.6	8.6	1.8
10/18/2019 16:00	13.8	2.5	2.0	10.9	2.4
10/18/2019 17:00	14.2	1.8	2.0	11.2	2.4
10/18/2019 18:00	13.8	1.9	2.0	10.8	2.4
10/18/2019 19:00	13.8	1.9	2.0	10.8	2.4
10/18/2019 20:00	14.2	1.8	2.0	11.2	2.4
10/18/2019 21:00	14.4	1.9	2.0	11.2	2.4
10/18/2019 22:00	14.0	1.9	2.0	11.0	2.4
10/18/2019 23:00	14.2	1.9	2.0	11.2	2.4
Average/Sum#:	283.3 #	23.1 #	43.5 #	239.2 #	51.8 #
Minimum:	6.1	0.0	1.4	8.0	1.8
Maximum:	14.4	2.5	2.0	11.2	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/19/2019 00:00	13.8	1.5	2.0	10.9	2.4
10/19/2019 01:00	13.9	1.5	2.0	11.0	2.4
10/19/2019 02:00	14.2	1.6	2.0	11.2	2.4
10/19/2019 03:00	14.0	1.6	2.0	11.0	2.4
10/19/2019 04:00	13.8	1.2	2.0	10.8	2.4
10/19/2019 05:00	14.0	1.2	2.0	11.0	2.4
10/19/2019 06:00	14.0	1.2	2.0	11.0	2.4
10/19/2019 07:00	10.8	13.0	0.6	3.3	0.8
10/19/2019 08:00	0.0	0.0	0.0	0.0	0.0
10/19/2019 09:00	0.0	0.0	0.0	0.0	0.0
10/19/2019 10:00	0.0	0.0	0.0	0.0	0.0
10/19/2019 11:00	0.0	0.0	0.0	0.0	0.0
10/19/2019 12:00	0.0	0.0	0.0	0.0	0.0
10/19/2019 13:00	0.0	0.0	0.0	0.0	0.0
10/19/2019 14:00	20.1	7.7	0.0	0.5	0.1
10/19/2019 15:00	35.3	31.4	0.2	2.4	0.5
10/19/2019 16:00	5.1	0.0	0.5	5.1	1.0
10/19/2019 17:00	7.9	0.6	0.6	5.9	1.2
10/19/2019 18:00	7.5	0.9	0.6	5.7	1.1
10/19/2019 19:00	7.5	0.9	0.6	5.6	1.1
10/19/2019 20:00	7.7	0.9	0.6	5.8	1.2
10/19/2019 21:00	7.8	0.9	0.6	5.8	1.2
10/19/2019 22:00	4.6	0.0	0.5	4.6	0.9
10/19/2019 23:00	2.7	0.0	0.4	4.1	0.8
Average/Sum#:	214.7 #	66.1 #	19.2 #	125.7 #	26.7 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	35.3	31.4	2.0	11.2	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/20/2019 00:00	2.9	0.0	0.4	4.3	0.9
10/20/2019 01:00	2.7	0.0	0.4	4.0	0.8
10/20/2019 02:00	1.8	3.2	0.0	0.3	0.1
10/20/2019 03:00	0.0	0.0	0.0	0.0	0.0
10/20/2019 04:00	0.0	0.0	0.0	0.0	0.0
10/20/2019 05:00	0.0	0.0	0.0	0.0	0.0
10/20/2019 06:00	0.0	0.0	0.0	0.0	0.0
10/20/2019 07:00	0.0	0.0	0.0	0.0	0.0
10/20/2019 08:00	0.0	0.0	0.0	0.0	0.0
10/20/2019 09:00	0.0	0.0	0.0	0.0	0.0
10/20/2019 10:00	58.0	16.9	0.1	1.0	0.2
10/20/2019 11:00	44.0	26.3	0.3	2.8	0.6
10/20/2019 12:00	2.7	0.0	0.4	4.0	0.8
10/20/2019 13:00	2.6	0.0	0.4	4.0	0.8
10/20/2019 14:00	82.4	47.7	0.8	5.7	1.1
10/20/2019 15:00	53.6	28.8	1.1	6.9	1.5
10/20/2019 16:00	6.2	0.0	1.6	8.6	1.8
10/20/2019 17:00	9.8	0.0	1.6	9.0	2.0
10/20/2019 18:00	10.8	0.0	1.8	9.9	2.2
10/20/2019 19:00	14.0	2.5	2.0	11.0	2.4
10/20/2019 20:00	14.0	1.2	2.0	11.0	2.4
10/20/2019 21:00	13.8	1.3	2.0	10.8	2.4
10/20/2019 22:00	13.8	1.2	2.0	10.8	2.4
10/20/2019 23:00	14.0	1.2	2.0	11.0	2.4
Average/Sum#:	347.1 #	130.3 #	18.9 #	115.1 #	24.8 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	82.4	47.7	2.0	11.0	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/21/2019 00:00	13.5	0.9	2.0	10.6	2.4
10/21/2019 01:00	13.5	0.3	2.0	10.6	2.4
10/21/2019 02:00	13.5	0.3	1.9	10.6	2.4
10/21/2019 03:00	13.5	0.3	1.9	10.6	2.4
10/21/2019 04:00	14.0	0.9	2.0	11.0	2.4
10/21/2019 05:00	14.2	1.2	2.0	11.2	2.4
10/21/2019 06:00	12.5	1.2	2.1	11.5	2.6
10/21/2019 07:00	13.5	0.6	1.9	10.6	2.4
10/21/2019 08:00	5.0	0.0	1.3	6.9	1.6
10/21/2019 09:00	5.0	0.0	1.3	6.9	1.5
10/21/2019 10:00	5.6	0.0	1.4	7.7	1.6
10/21/2019 11:00	5.8	0.0	1.4	8.0	1.8
10/21/2019 12:00	9.5	0.0	1.6	8.7	1.9
10/21/2019 13:00	12.0	0.0	1.7	9.5	2.0
10/21/2019 14:00	12.1	0.0	1.7	9.5	2.0
10/21/2019 15:00	12.1	0.0	1.7	9.5	2.0
10/21/2019 16:00	12.1	0.0	1.7	9.5	2.0
10/21/2019 17:00	12.1	0.0	1.7	9.5	2.0
10/21/2019 18:00	12.1	0.0	1.7	9.5	2.0
10/21/2019 19:00	12.2	0.0	1.7	9.6	2.0
10/21/2019 20:00	13.7	2.5	2.0	10.8	2.4
10/21/2019 21:00	14.0	2.2	2.0	11.0	2.4
10/21/2019 22:00	14.0	2.2	2.0	11.0	2.4
10/21/2019 23:00	13.8	1.9	2.0	10.8	2.4
Average/Sum#:	279.3 #	14.5 #	42.7 #	235.1 #	51.4 #
Minimum:	5.0	0.0	1.3	6.9	1.5
Maximum:	14.2	2.5	2.1	11.5	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/22/2019 00:00	13.5	1.9	2.0	10.6	2.4
10/22/2019 01:00	13.5	1.2	2.0	10.7	2.4
10/22/2019 02:00	13.5	0.6	2.0	10.6	2.4
10/22/2019 03:00	13.5	0.6	2.0	10.7	2.4
10/22/2019 04:00	13.6	1.0	2.0	10.7	2.4
10/22/2019 05:00	14.0	0.9	2.0	11.0	2.4
10/22/2019 06:00	12.2	0.9	2.0	11.2	2.4
10/22/2019 07:00	13.8	1.9	2.0	10.9	2.4
10/22/2019 08:00	14.4	1.9	2.1	11.3	2.5
10/22/2019 09:00	14.4	1.9	2.1	11.3	2.5
10/22/2019 10:00	14.5	1.9	2.1	11.3	2.5
10/22/2019 11:00	14.4	1.5	2.1	11.4	2.5
10/22/2019 12:00	14.5	1.2	2.1	11.4	2.5
10/22/2019 13:00	14.5	1.2	2.1	11.5	2.5
10/22/2019 14:00	14.6	1.2	2.1	11.4	2.5
10/22/2019 15:00	14.5	1.2	2.1	11.4	2.5
10/22/2019 16:00	14.5	1.2	2.1	11.4	2.5
10/22/2019 17:00	14.8	1.2	2.1	11.7	2.6
10/22/2019 18:00	14.3	1.9	2.0	11.2	2.4
10/22/2019 19:00	14.4	1.9	2.1	11.4	2.4
10/22/2019 20:00	14.1	1.9	2.0	11.1	2.4
10/22/2019 21:00	14.2	1.9	2.0	11.2	2.4
10/22/2019 22:00	14.1	1.8	2.0	11.0	2.4
10/22/2019 23:00	13.9	1.9	2.0	10.9	2.4
Average/Sum#:	337.7 #	34.7 #	49.1 #	267.3 #	58.7 #
Minimum:	12.2	0.6	2.0	10.6	2.4
Maximum:	14.8	1.9	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/23/2019 00:00	13.8	1.9	2.0	10.9	2.4
10/23/2019 01:00	13.8	1.9	2.0	10.9	2.4
10/23/2019 02:00	13.7	1.9	2.0	10.8	2.4
10/23/2019 03:00	13.8	2.2	2.0	10.8	2.4
10/23/2019 04:00	13.7	2.2	2.0	10.8	2.4
10/23/2019 05:00	14.2	2.1	2.0	11.2	2.4
10/23/2019 06:00	13.9	1.8	2.0	11.0	2.4
10/23/2019 07:00	5.3	0.0	1.3	7.3	1.6
10/23/2019 08:00	5.0	0.0	1.3	6.9	1.6
10/23/2019 09:00	5.0	0.0	1.3	6.9	1.5
10/23/2019 10:00	5.5	0.0	1.4	7.6	1.6
10/23/2019 11:00	5.8	0.0	1.4	8.0	1.8
10/23/2019 12:00	9.4	0.0	1.6	8.6	1.8
10/23/2019 13:00	12.1	0.0	1.7	9.5	2.0
10/23/2019 14:00	12.1	0.0	1.7	9.5	2.0
10/23/2019 15:00	12.1	0.0	1.7	9.5	2.0
10/23/2019 16:00	12.1	0.0	1.7	9.5	2.0
10/23/2019 17:00	12.1	0.0	1.7	9.5	2.0
10/23/2019 18:00	10.2	0.0	1.7	9.3	2.0
10/23/2019 19:00	13.1	2.2	1.9	10.3	2.2
10/23/2019 20:00	14.4	2.5	2.0	11.3	2.4
10/23/2019 21:00	14.6	2.2	2.1	11.4	2.5
10/23/2019 22:00	14.6	1.9	2.1	11.4	2.5
10/23/2019 23:00	14.2	2.5	2.0	11.2	2.4
Average/Sum#:	274.5 #	25.3 #	42.6 #	234.1 #	50.7 #
Minimum:	5.0	0.0	1.3	6.9	1.5
Maximum:	14.6	2.5	2.1	11.4	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/24/2019 00:00	14.0	2.5	2.0	11.0	2.4
10/24/2019 01:00	13.8	2.5	2.0	10.8	2.4
10/24/2019 02:00	13.4	2.5	1.9	10.6	2.3
10/24/2019 03:00	14.2	2.5	2.0	11.2	2.4
10/24/2019 04:00	14.2	2.5	2.0	11.2	2.4
10/24/2019 05:00	16.7	2.5	2.1	11.5	2.6
10/24/2019 06:00	14.5	2.5	2.1	11.4	2.4
10/24/2019 07:00	14.7	1.9	2.1	11.6	2.5
10/24/2019 08:00	14.6	1.9	2.0	11.5	2.5
10/24/2019 09:00	14.6	1.9	2.0	11.5	2.5
10/24/2019 10:00	14.6	1.9	2.0	11.5	2.5
10/24/2019 11:00	14.6	1.6	2.0	11.5	2.5
10/24/2019 12:00	14.7	1.6	2.0	11.5	2.5
10/24/2019 13:00	14.7	1.3	2.1	11.5	2.5
10/24/2019 14:00	14.7	1.3	2.1	11.5	2.6
10/24/2019 15:00	14.7	1.2	2.1	11.6	2.6
10/24/2019 16:00	14.8	1.5	2.1	11.6	2.6
10/24/2019 17:00	14.6	1.9	2.1	11.5	2.5
10/24/2019 18:00	14.6	1.9	2.1	11.4	2.5
10/24/2019 19:00	14.9	1.9	2.1	11.8	2.6
10/24/2019 20:00	14.8	1.9	2.1	11.6	2.6
10/24/2019 21:00	14.7	1.5	2.1	11.5	2.6
10/24/2019 22:00	14.6	0.6	2.1	11.5	2.5
10/24/2019 23:00	14.6	1.9	2.1	11.5	2.5
Average/Sum#:	350.3 #	45.2 #	49.3 #	273.8 #	60.0 #
Minimum:	13.4	0.6	1.9	10.6	2.3
Maximum:	16.7	2.5	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/25/2019 00:00	14.3	1.9	2.1	11.3	2.5
10/25/2019 01:00	13.8	1.9	2.0	10.9	2.4
10/25/2019 02:00	13.8	0.9	2.0	10.8	2.4
10/25/2019 03:00	13.8	0.6	2.0	10.8	2.4
10/25/2019 04:00	14.0	0.6	2.0	11.0	2.4
10/25/2019 05:00	14.0	0.9	2.0	11.0	2.4
10/25/2019 06:00	14.2	1.6	2.0	11.2	2.4
10/25/2019 07:00	13.9	1.6	2.0	11.0	2.4
10/25/2019 08:00	13.2	3.3	1.9	10.3	2.2
10/25/2019 09:00	13.2	3.6	1.9	10.3	2.2
10/25/2019 10:00	13.4	3.6	1.9	10.5	2.3
10/25/2019 11:00	13.3	3.1	1.9	10.4	2.2
10/25/2019 12:00	14.1	3.1	2.0	11.0	2.4
10/25/2019 13:00	14.1	3.1	2.0	11.0	2.4
10/25/2019 14:00	14.0	2.8	2.0	11.0	2.4
10/25/2019 15:00	14.0	2.8	2.0	11.0	2.4
10/25/2019 16:00	14.5	2.8	2.1	11.4	2.4
10/25/2019 17:00	14.4	2.8	2.0	11.4	2.4
10/25/2019 18:00	14.0	3.1	2.0	11.0	2.4
10/25/2019 19:00	14.0	3.1	2.0	11.0	2.4
10/25/2019 20:00	14.1	2.2	2.0	11.0	2.4
10/25/2019 21:00	14.2	2.2	2.1	11.2	2.4
10/25/2019 22:00	14.0	2.2	2.0	11.0	2.4
10/25/2019 23:00	14.1	1.9	2.0	11.1	2.4
Average/Sum#:	334.4 #	55.7 #	47.9 #	262.6 #	57.0 #
Minimum:	13.2	0.6	1.9	10.3	2.2
Maximum:	14.5	3.6	2.1	11.4	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/26/2019 00:00	13.8	0.9	2.0	10.8	2.4
10/26/2019 01:00	14.0	0.6	2.0	11.0	2.4
10/26/2019 02:00	14.0	0.6	2.0	11.0	2.4
10/26/2019 03:00	13.9	0.6	2.0	11.0	2.4
10/26/2019 04:00	14.0	0.6	2.0	11.0	2.4
10/26/2019 05:00	13.4	1.3	1.9	10.6	2.3
10/26/2019 06:00	11.5	1.2	1.9	10.6	2.3
10/26/2019 07:00	7.4	0.0	1.4	8.1	1.8
10/26/2019 08:00	7.9	0.0	1.6	8.6	1.8
10/26/2019 09:00	6.3	0.0	1.6	8.6	1.8
10/26/2019 10:00	7.3	0.0	1.4	8.0	1.8
10/26/2019 11:00	7.2	0.0	1.4	7.8	1.8
10/26/2019 12:00	9.1	0.0	1.6	8.4	1.8
10/26/2019 13:00	9.5	0.0	1.6	8.8	1.9
10/26/2019 14:00	5.8	0.0	1.4	8.1	1.8
10/26/2019 15:00	7.4	0.0	1.4	8.2	1.8
10/26/2019 16:00	13.6	3.1	1.9	10.6	2.4
10/26/2019 17:00	14.0	3.1	2.0	11.0	2.4
10/26/2019 18:00	14.0	3.4	2.0	11.0	2.4
10/26/2019 19:00	14.0	3.4	2.0	11.0	2.4
10/26/2019 20:00	14.0	3.4	2.0	11.0	2.4
10/26/2019 21:00	14.0	3.4	2.0	11.0	2.4
10/26/2019 22:00	12.1	13.5	0.5	2.9	0.6
10/26/2019 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	258.2 #	39.1 #	39.6 #	219.1 #	47.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	14.0	13.5	2.0	11.0	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/27/2019 00:00	0.0	0.0	0.0	0.0	0.0
10/27/2019 01:00	0.0	0.0	0.0	0.0	0.0
10/27/2019 02:00	0.0	0.0	0.0	0.0	0.0
10/27/2019 03:00	0.0	0.0	0.0	0.0	0.0
10/27/2019 04:00	0.0	0.0	0.0	0.0	0.0
10/27/2019 05:00	0.0	0.0	0.0	0.0	0.0
10/27/2019 06:00	0.0	0.0	0.0	0.0	0.0
10/27/2019 07:00	0.0	0.0	0.0	0.0	0.0
10/27/2019 08:00	0.0	0.0	0.0	0.0	0.0
10/27/2019 09:00	0.0	0.0	0.0	0.0	0.0
10/27/2019 10:00	0.0	0.0	0.0	0.0	0.0
10/27/2019 11:00	0.0	0.0	0.0	0.0	0.0
10/27/2019 12:00	0.0	0.0	0.0	0.0	0.0
10/27/2019 13:00	0.0	0.0	0.0	0.0	0.0
10/27/2019 14:00	0.0	0.0	0.0	0.0	0.0
10/27/2019 15:00	0.0	0.0	0.0	0.0	0.0
10/27/2019 16:00	0.0	0.0	0.0	0.0	0.0
10/27/2019 17:00	37.0	47.0	0.0	0.5	0.1
10/27/2019 18:00	91.4	35.6	0.2	1.9	0.4
10/27/2019 19:00	69.4	41.5	0.3	2.7	0.5
10/27/2019 20:00	2.9	0.0	0.4	4.3	0.9
10/27/2019 21:00	2.7	0.0	0.4	4.0	0.8
10/27/2019 22:00	2.7	0.0	0.4	4.0	0.8
10/27/2019 23:00	2.7	0.0	0.4	4.0	0.8
Average/Sum#:	208.8 #	124.1 #	2.1 #	21.4 #	4.3 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	91.4	47.0	0.4	4.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/28/2019 00:00	19.3	42.4	0.6	4.8	0.9
10/28/2019 01:00	114.0	42.9	1.0	6.4	1.3
10/28/2019 02:00	4.0	0.0	1.3	7.3	1.6
10/28/2019 03:00	7.8	0.0	1.6	8.6	1.8
10/28/2019 04:00	15.3	1.3	1.9	10.6	2.3
10/28/2019 05:00	13.8	1.6	2.0	10.8	2.4
10/28/2019 06:00	12.7	0.9	2.1	11.6	2.6
10/28/2019 07:00	14.2	1.0	2.0	11.2	2.4
10/28/2019 08:00	13.8	1.3	2.0	10.8	2.4
10/28/2019 09:00	13.8	1.3	2.0	10.9	2.4
10/28/2019 10:00	13.8	1.6	2.0	10.8	2.4
10/28/2019 11:00	15.6	2.6	2.0	10.8	2.4
10/28/2019 12:00	13.8	3.3	2.0	10.8	2.4
10/28/2019 13:00	13.7	3.2	2.0	10.8	2.4
10/28/2019 14:00	13.8	3.3	2.0	10.8	2.4
10/28/2019 15:00	14.0	3.2	2.0	11.0	2.4
10/28/2019 16:00	16.5	2.8	2.0	11.4	2.4
10/28/2019 17:00	15.1	2.2	2.1	11.8	2.6
10/28/2019 18:00	14.7	2.8	2.1	11.6	2.6
10/28/2019 19:00	14.6	2.5	2.1	11.4	2.5
10/28/2019 20:00	14.5	1.6	2.0	11.4	2.4
10/28/2019 21:00	14.4	0.6	2.0	11.2	2.4
10/28/2019 22:00	13.5	0.9	1.9	10.6	2.4
10/28/2019 23:00	7.0	6.4	0.1	0.7	0.2
Average/Sum#:	423.7 #	129.7 #	42.8 #	238.1 #	52.0 #
Minimum:	4.0	0.0	0.1	0.7	0.2
Maximum:	114.0	42.9	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/29/2019 00:00	0.0	0.0	0.0	0.0	0.0
10/29/2019 01:00	0.0	0.0	0.0	0.0	0.0
10/29/2019 02:00	0.0	0.0	0.0	0.0	0.0
10/29/2019 03:00	0.0	0.0	0.0	0.0	0.0
10/29/2019 04:00	0.0	0.0	0.0	0.0	0.0
10/29/2019 05:00	0.0	0.0	0.0	0.0	0.0
10/29/2019 06:00	0.0	0.0	0.0	0.0	0.0
10/29/2019 07:00	0.0	0.0	0.0	0.0	0.0
10/29/2019 08:00	0.0	0.0	0.0	0.0	0.0
10/29/2019 09:00	0.0	0.0	0.0	0.0	0.0
10/29/2019 10:00	0.0	0.0	0.0	0.0	0.0
10/29/2019 11:00	0.0	0.0	0.0	0.0	0.0
10/29/2019 12:00	0.0	0.0	0.0	0.0	0.0
10/29/2019 13:00	0.0	0.0	0.0	0.0	0.0
10/29/2019 14:00	0.0	0.0	0.0	0.0	0.0
10/29/2019 15:00	0.0	0.0	0.0	0.0	0.0
10/29/2019 16:00	0.0	0.0	0.0	0.0	0.0
10/29/2019 17:00	0.0	0.0	0.0	0.0	0.0
10/29/2019 18:00	0.0	0.0	0.0	0.0	0.0
10/29/2019 19:00	0.0	0.0	0.0	0.0	0.0
10/29/2019 20:00	0.0	0.0	0.0	0.0	0.0
10/29/2019 21:00	0.0	0.0	0.0	0.0	0.0
10/29/2019 22:00	0.0	0.0	0.0	0.0	0.0
10/29/2019 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/30/2019 00:00	68.3	64.9	0.1	0.9	0.2
10/30/2019 01:00	79.4	47.7	0.2	2.0	0.4
10/30/2019 02:00	61.4	43.9	0.3	3.0	0.6
10/30/2019 03:00	5.4	0.3	0.5	5.4	1.1
10/30/2019 04:00	8.6	28.1	0.6	6.3	1.3
10/30/2019 05:00	96.8	64.6	0.9	6.3	1.3
10/30/2019 06:00	72.1	47.0	1.0	6.6	1.4
10/30/2019 07:00	6.8	0.0	1.7	9.3	2.0
10/30/2019 08:00	8.5	0.0	1.7	9.4	2.0
10/30/2019 09:00	13.5	1.3	1.9	10.6	2.4
10/30/2019 10:00	14.2	1.6	2.0	11.2	2.4
10/30/2019 11:00	14.4	1.0	2.0	11.4	2.4
10/30/2019 12:00	14.6	0.6	2.1	11.4	2.5
10/30/2019 13:00	14.4	0.6	2.0	11.3	2.4
10/30/2019 14:00	14.0	2.2	2.0	11.0	2.4
10/30/2019 15:00	14.1	2.5	2.0	11.0	2.4
10/30/2019 16:00	14.7	2.2	2.1	11.6	2.5
10/30/2019 17:00	14.2	1.9	1.9	11.2	2.4
10/30/2019 18:00	14.2	2.2	2.0	11.1	2.5
10/30/2019 19:00	14.2	2.2	2.0	11.2	2.5
10/30/2019 20:00	14.0	2.2	2.0	11.1	2.4
10/30/2019 21:00	13.9	0.9	1.9	10.9	2.3
10/30/2019 22:00	13.5	1.0	1.9	10.7	2.3
10/30/2019 23:00	13.6	1.0	2.0	10.6	2.4
Average/Sum#:	618.8 #	319.9 #	36.8 #	215.5 #	46.5 #
Minimum:	5.4	0.0	0.1	0.9	0.2
Maximum:	96.8	64.9	2.1	11.6	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/31/2019 00:00	13.4	1.0	1.9	10.6	2.3
10/31/2019 01:00	13.6	1.0	1.9	10.7	2.3
10/31/2019 02:00	13.5	1.0	1.9	10.6	2.3
10/31/2019 03:00	13.6	1.0	1.9	10.7	2.3
10/31/2019 04:00	13.7	1.0	1.9	10.8	2.3
10/31/2019 05:00	13.7	1.3	1.9	10.7	2.3
10/31/2019 06:00	13.7	1.0	1.9	10.8	2.3
10/31/2019 07:00	13.6	1.0	1.9	10.7	2.3
10/31/2019 08:00	13.6	1.3	1.9	10.6	2.4
10/31/2019 09:00	13.5	0.9	1.9	10.6	2.3
10/31/2019 10:00	13.5	1.6	1.9	10.5	2.3
10/31/2019 11:00	13.4	2.7	1.9	10.6	2.3
10/31/2019 12:00	13.6	2.2	2.0	10.6	2.4
10/31/2019 13:00	13.6	2.2	2.0	10.6	2.4
10/31/2019 14:00	13.6	2.2	2.0	10.7	2.4
10/31/2019 15:00	13.6	2.2	1.9	10.7	2.4
10/31/2019 16:00	13.7	2.6	1.9	10.7	2.4
10/31/2019 17:00	15.5	2.9	2.0	10.6	2.4
10/31/2019 18:00	15.8	2.9	2.0	10.8	2.4
10/31/2019 19:00	14.5	2.8	2.1	11.4	2.4
10/31/2019 20:00	14.5	2.9	2.1	11.4	2.4
10/31/2019 21:00	14.5	2.5	2.1	11.4	2.4
10/31/2019 22:00	14.5	0.9	2.1	11.4	2.4
10/31/2019 23:00	14.4	1.3	2.0	11.4	2.4
Average/Sum#:	334.6 #	42.4 #	47.0 #	259.6 #	56.5 #
Minimum:	13.4	0.9	1.9	10.5	2.3
Maximum:	15.8	2.9	2.1	11.4	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/01/2019 00:00	14.3	1.3	2.0	11.2	2.4
11/01/2019 01:00	14.0	1.3	2.0	11.0	2.4
11/01/2019 02:00	14.2	1.6	2.0	11.2	2.4
11/01/2019 03:00	14.2	1.6	2.0	11.2	2.4
11/01/2019 04:00	14.0	1.3	2.0	11.0	2.4
11/01/2019 05:00	14.7	1.9	2.1	11.6	2.6
11/01/2019 06:00	14.8	1.6	2.1	11.6	2.6
11/01/2019 07:00	14.8	1.0	2.1	11.6	2.6
11/01/2019 08:00	14.8	1.0	2.1	11.6	2.6
11/01/2019 09:00	10.6	0.0	1.7	9.7	2.2
11/01/2019 10:00	6.6	0.0	1.7	9.1	2.0
11/01/2019 11:00	5.3	0.0	1.3	7.3	1.6
11/01/2019 12:00	6.0	0.0	1.6	8.3	1.8
11/01/2019 13:00	6.2	0.0	1.6	8.6	1.8
11/01/2019 14:00	7.5	0.0	1.6	8.4	1.8
11/01/2019 15:00	13.7	2.6	2.0	10.8	2.4
11/01/2019 16:00	14.2	1.9	2.0	11.1	2.4
11/01/2019 17:00	14.9	1.6	2.1	11.7	2.6
11/01/2019 18:00	15.2	1.2	2.1	11.9	2.6
11/01/2019 19:00	14.5	1.9	2.0	11.4	2.4
11/01/2019 20:00	14.8	1.6	2.1	11.7	2.6
11/01/2019 21:00	14.3	1.9	2.0	11.2	2.4
11/01/2019 22:00	14.1	2.0	2.0	11.1	2.4
11/01/2019 23:00	14.3	2.3	2.0	11.2	2.4
Average/Sum#:	302.0 #	29.6 #	46.2 #	255.5 #	55.8 #
Minimum:	5.3	0.0	1.3	7.3	1.6
Maximum:	15.2	2.6	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/02/2019 00:00	14.4	0.9	2.0	11.3	2.4
11/02/2019 01:00	14.5	0.9	2.0	11.3	2.4
11/02/2019 02:00	14.5	0.3	2.0	11.4	2.4
11/02/2019 03:00	14.5	0.6	2.0	11.4	2.4
11/02/2019 04:00	14.5	0.3	2.0	11.4	2.4
11/02/2019 05:00	16.3	0.9	2.0	11.2	2.4
11/02/2019 06:00	14.9	0.3	2.1	11.7	2.6
11/02/2019 07:00	14.5	0.3	2.0	11.4	2.4
11/02/2019 08:00	13.3	0.6	1.9	10.4	2.2
11/02/2019 09:00	6.2	0.0	1.6	8.4	1.8
11/02/2019 10:00	6.1	0.0	1.6	8.4	1.8
11/02/2019 11:00	6.1	0.0	1.6	8.4	1.8
11/02/2019 12:00	6.2	0.0	1.6	8.4	1.8
11/02/2019 13:00	8.6	9.5	0.3	1.6	0.3
11/02/2019 14:00	33.2	25.6	0.2	1.5	0.3
11/02/2019 15:00	5.5	6.6	0.6	5.0	1.0
11/02/2019 16:00	34.3	21.1	1.2	7.0	1.5
11/02/2019 17:00	10.4	0.3	1.7	9.5	2.0
11/02/2019 18:00	18.3	3.2	2.0	11.2	2.4
11/02/2019 19:00	21.5	1.9	2.1	11.8	2.6
11/02/2019 20:00	21.3	2.2	2.1	11.8	2.6
11/02/2019 21:00	20.7	2.5	2.1	11.4	2.4
11/02/2019 22:00	18.4	2.5	2.0	11.2	2.4
11/02/2019 23:00	18.0	1.9	2.0	11.0	2.4
Average/Sum#:	366.2 #	82.4 #	40.7 #	228.1 #	48.7 #
Minimum:	5.5	0.0	0.2	1.5	0.3
Maximum:	34.3	25.6	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/03/2019 00:00	19.8	1.9	2.0	10.9	2.4
11/03/2019 01:00	20.0	1.2	2.0	11.0	2.4
11/03/2019 02:00	19.8	1.5	2.0	11.0	2.4
11/03/2019 03:00	20.1	1.2	2.0	11.0	2.4
11/03/2019 04:00	20.4	1.3	2.0	11.2	2.4
11/03/2019 05:00	14.6	1.2	2.1	11.6	2.6
11/03/2019 06:00	14.5	1.3	2.1	11.4	2.4
11/03/2019 07:00	13.8	0.9	2.0	10.8	2.4
11/03/2019 08:00	6.4	0.0	1.6	8.9	2.0
11/03/2019 09:00	6.4	0.0	1.6	8.8	2.0
11/03/2019 10:00	6.4	0.0	1.6	8.9	2.0
11/03/2019 11:00	6.4	0.0	1.6	8.8	2.0
11/03/2019 12:00	9.7	0.0	1.6	8.9	2.0
11/03/2019 13:00	5.9	0.0	1.4	8.1	1.8
11/03/2019 14:00	7.2	0.0	1.4	8.0	1.8
11/03/2019 15:00	12.4	1.2	1.7	9.7	2.2
11/03/2019 16:00	14.4	3.1	2.0	11.4	2.4
11/03/2019 17:00	14.7	2.5	2.1	11.6	2.6
11/03/2019 18:00	14.9	2.5	2.1	11.7	2.6
11/03/2019 19:00	15.0	1.9	2.1	11.8	2.6
11/03/2019 20:00	14.8	2.2	2.1	11.6	2.6
11/03/2019 21:00	14.6	2.5	2.1	11.4	2.5
11/03/2019 22:00	14.1	2.2	2.0	11.0	2.4
11/03/2019 23:00	14.4	1.6	2.0	11.2	2.4
Average/Sum#:	320.7 #	30.2 #	45.2 #	250.7 #	55.3 #
Minimum:	5.9	0.0	1.4	8.0	1.8
Maximum:	20.4	3.1	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/04/2019 00:00	14.1	1.2	2.0	11.0	2.4
11/04/2019 01:00	14.1	1.2	2.0	11.1	2.4
11/04/2019 02:00	13.7	1.5	2.0	10.8	2.4
11/04/2019 03:00	13.9	1.5	2.0	11.0	2.4
11/04/2019 04:00	14.0	1.2	2.0	11.0	2.4
11/04/2019 05:00	19.0	1.2	2.1	11.6	2.6
11/04/2019 06:00	15.0	1.2	2.1	11.8	2.6
11/04/2019 07:00	14.2	1.6	2.0	11.1	2.4
11/04/2019 08:00	14.2	1.9	2.0	11.2	2.4
11/04/2019 09:00	14.5	1.2	2.1	11.4	2.4
11/04/2019 10:00	14.2	1.2	2.0	11.2	2.4
11/04/2019 11:00	13.7	1.2	2.0	10.8	2.4
11/04/2019 12:00	14.1	0.9	2.0	11.1	2.4
11/04/2019 13:00	14.3	0.6	2.0	11.1	2.4
11/04/2019 14:00	14.1	0.6	2.0	11.1	2.4
11/04/2019 15:00	14.3	0.6	2.0	11.2	2.4
11/04/2019 16:00	14.6	0.6	2.1	11.5	2.5
11/04/2019 17:00	15.0	1.9	2.1	11.8	2.6
11/04/2019 18:00	15.0	1.9	2.1	11.8	2.6
11/04/2019 19:00	15.0	1.9	2.1	11.8	2.6
11/04/2019 20:00	14.9	2.2	2.1	11.8	2.6
11/04/2019 21:00	15.0	1.9	2.1	11.8	2.6
11/04/2019 22:00	15.0	2.2	2.1	11.8	2.6
11/04/2019 23:00	14.4	2.2	2.0	11.4	2.4
Average/Sum#:	350.3 #	33.6 #	49.0 #	272.2 #	59.3 #
Minimum:	13.7	0.6	2.0	10.8	2.4
Maximum:	19.0	2.2	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/05/2019 00:00	14.6	2.5	2.1	11.4	2.5
11/05/2019 01:00	14.6	2.5	2.1	11.4	2.5
11/05/2019 02:00	14.6	2.5	2.1	11.4	2.5
11/05/2019 03:00	14.6	2.5	2.1	11.4	2.5
11/05/2019 04:00	14.5	2.5	2.1	11.4	2.4
11/05/2019 05:00	14.8	2.5	2.1	11.6	2.6
11/05/2019 06:00	15.2	1.6	2.1	12.0	2.6
11/05/2019 07:00	14.1	1.6	2.0	11.1	2.4
11/05/2019 08:00	14.1	3.0	2.0	11.1	2.4
11/05/2019 09:00	13.8	2.6	2.0	10.8	2.4
11/05/2019 10:00	13.8	2.3	2.0	10.8	2.4
11/05/2019 11:00	13.8	2.2	2.0	10.8	2.4
11/05/2019 12:00	13.8	2.2	2.0	10.9	2.4
11/05/2019 13:00	14.2	1.9	2.0	11.2	2.4
11/05/2019 14:00	14.1	2.2	2.0	11.1	2.4
11/05/2019 15:00	14.2	2.2	2.0	11.2	2.4
11/05/2019 16:00	14.7	1.5	2.1	11.5	2.5
11/05/2019 17:00	14.6	1.5	2.1	11.4	2.5
11/05/2019 18:00	14.6	1.9	2.1	11.4	2.5
11/05/2019 19:00	14.6	1.6	2.1	11.5	2.5
11/05/2019 20:00	14.7	1.9	2.1	11.6	2.6
11/05/2019 21:00	16.7	1.9	2.1	11.4	2.5
11/05/2019 22:00	14.6	1.9	2.1	11.4	2.5
11/05/2019 23:00	14.6	1.9	2.1	11.5	2.6
Average/Sum#:	347.9 #	50.9 #	49.5 #	271.3 #	59.4 #
Minimum:	13.8	1.5	2.0	10.8	2.4
Maximum:	16.7	3.0	2.1	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/06/2019 00:00	14.1	2.3	2.0	11.0	2.4
11/06/2019 01:00	13.8	2.6	2.0	10.8	2.4
11/06/2019 02:00	14.3	2.3	2.0	11.2	2.4
11/06/2019 03:00	14.2	1.9	2.0	11.2	2.4
11/06/2019 04:00	13.9	1.6	2.0	10.9	2.4
11/06/2019 05:00	14.2	1.5	2.0	11.2	2.4
11/06/2019 06:00	12.7	1.9	2.1	11.6	2.6
11/06/2019 07:00	14.4	2.5	2.0	11.2	2.4
11/06/2019 08:00	14.0	3.2	2.0	11.0	2.4
11/06/2019 09:00	13.8	2.9	2.0	10.8	2.4
11/06/2019 10:00	14.1	2.7	2.0	11.1	2.4
11/06/2019 11:00	14.2	2.3	2.1	11.2	2.5
11/06/2019 12:00	14.2	2.2	2.1	11.1	2.5
11/06/2019 13:00	14.3	2.2	2.1	11.3	2.5
11/06/2019 14:00	14.4	2.2	2.1	11.3	2.5
11/06/2019 15:00	14.4	1.9	2.1	11.3	2.5
11/06/2019 16:00	14.8	1.6	2.1	11.7	2.5
11/06/2019 17:00	15.0	1.6	2.2	11.9	2.6
11/06/2019 18:00	15.0	1.6	2.2	11.7	2.5
11/06/2019 19:00	15.0	1.6	2.2	11.9	2.6
11/06/2019 20:00	15.0	2.3	2.2	11.8	2.5
11/06/2019 21:00	15.1	2.3	2.2	11.9	2.6
11/06/2019 22:00	15.1	2.6	2.2	11.9	2.6
11/06/2019 23:00	14.8	2.6	2.1	11.6	2.5
Average/Sum#:	344.8 #	52.4 #	50.0 #	272.6 #	59.5 #
Minimum:	12.7	1.5	2.0	10.8	2.4
Maximum:	15.1	3.2	2.2	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/07/2019 00:00	14.9	2.3	2.1	11.7	2.5
11/07/2019 01:00	14.7	1.3	2.1	11.6	2.5
11/07/2019 02:00	14.5	1.3	2.1	11.5	2.5
11/07/2019 03:00	14.2	1.6	2.1	11.2	2.4
11/07/2019 04:00	14.6	1.7	2.1	11.5	2.5
11/07/2019 05:00	14.6	1.9	2.1	11.5	2.5
11/07/2019 06:00	14.9	1.6	2.1	11.7	2.5
11/07/2019 07:00	14.7	2.0	2.1	11.5	2.5
11/07/2019 08:00	14.2	2.4	2.1	11.2	2.4
11/07/2019 09:00	14.2	2.4	2.1	11.2	2.4
11/07/2019 10:00	16.1	2.4	2.0	11.0	2.4
11/07/2019 11:00	14.3	2.2	2.1	11.2	2.5
11/07/2019 12:00	14.3	2.2	2.1	11.2	2.5
11/07/2019 13:00	14.3	2.2	2.1	11.2	2.5
11/07/2019 14:00	14.4	2.2	2.1	11.4	2.5
11/07/2019 15:00	14.6	1.9	2.1	11.5	2.5
11/07/2019 16:00	14.9	1.6	2.2	11.8	2.6
11/07/2019 17:00	14.7	1.9	2.1	11.5	2.5
11/07/2019 18:00	15.2	2.3	2.2	12.0	2.7
11/07/2019 19:00	15.3	2.3	2.2	12.0	2.7
11/07/2019 20:00	14.9	2.3	2.2	11.7	2.5
11/07/2019 21:00	14.7	2.6	2.1	11.6	2.5
11/07/2019 22:00	14.7	2.6	2.1	11.6	2.5
11/07/2019 23:00	14.5	1.9	2.1	11.4	2.5
Average/Sum#:	352.4 #	49.1 #	50.7 #	275.7 #	60.1 #
Minimum:	14.2	1.3	2.0	11.0	2.4
Maximum:	16.1	2.6	2.2	12.0	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/08/2019 00:00	14.7	1.3	2.1	11.6	2.5
11/08/2019 01:00	14.9	1.3	2.1	11.7	2.5
11/08/2019 02:00	14.7	1.3	2.1	11.5	2.5
11/08/2019 03:00	14.5	1.6	2.1	11.3	2.5
11/08/2019 04:00	14.3	2.0	2.1	11.3	2.5
11/08/2019 05:00	14.4	1.9	2.1	11.3	2.5
11/08/2019 06:00	14.4	2.0	2.1	11.3	2.5
11/08/2019 07:00	14.3	1.6	2.1	11.3	2.5
11/08/2019 08:00	13.4	0.6	2.0	10.5	2.3
11/08/2019 09:00	7.7	0.0	1.5	8.4	1.8
11/08/2019 10:00	5.5	0.0	1.4	7.5	1.6
11/08/2019 11:00	7.7	0.0	1.5	8.4	1.8
11/08/2019 12:00	7.7	0.0	1.5	8.4	1.8
11/08/2019 13:00	8.4	0.0	1.7	9.2	2.0
11/08/2019 14:00	10.0	0.3	1.7	9.2	2.0
11/08/2019 15:00	16.0	2.9	2.0	10.9	2.4
11/08/2019 16:00	14.3	2.9	2.1	11.2	2.5
11/08/2019 17:00	14.4	2.9	2.1	11.3	2.5
11/08/2019 18:00	14.8	2.6	2.1	11.6	2.5
11/08/2019 19:00	14.5	2.9	2.1	11.4	2.5
11/08/2019 20:00	14.7	3.0	2.1	11.6	2.5
11/08/2019 21:00	14.8	2.6	2.1	11.6	2.5
11/08/2019 22:00	14.7	3.0	2.1	11.6	2.5
11/08/2019 23:00	14.8	1.9	2.1	11.6	2.5
Average/Sum#:	309.6 #	38.6 #	46.9 #	255.7 #	55.7 #
Minimum:	5.5	0.0	1.4	7.5	1.6
Maximum:	16.0	3.0	2.1	11.7	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/09/2019 00:00	14.8	1.3	2.1	11.7	2.5
11/09/2019 01:00	14.7	1.3	2.1	11.6	2.5
11/09/2019 02:00	14.7	1.3	2.1	11.6	2.5
11/09/2019 03:00	14.7	1.3	2.1	11.6	2.5
11/09/2019 04:00	14.8	1.3	2.1	11.6	2.5
11/09/2019 05:00	14.3	2.0	2.1	11.3	2.5
11/09/2019 06:00	14.3	1.9	2.1	11.2	2.5
11/09/2019 07:00	13.9	1.3	2.0	10.9	2.4
11/09/2019 08:00	7.7	0.0	1.5	8.4	1.8
11/09/2019 09:00	5.2	0.0	1.3	7.1	1.6
11/09/2019 10:00	5.3	0.0	1.3	7.2	1.6
11/09/2019 11:00	5.2	0.0	1.3	7.1	1.6
11/09/2019 12:00	5.3	0.0	1.3	7.1	1.6
11/09/2019 13:00	5.1	0.0	1.3	7.1	1.6
11/09/2019 14:00	7.7	0.0	1.5	8.4	1.8
11/09/2019 15:00	14.0	3.0	2.0	11.0	2.4
11/09/2019 16:00	14.3	2.9	2.1	11.3	2.5
11/09/2019 17:00	14.5	2.9	2.1	11.4	2.5
11/09/2019 18:00	14.3	2.9	2.1	11.3	2.5
11/09/2019 19:00	14.3	3.0	2.1	11.3	2.5
11/09/2019 20:00	14.3	3.0	2.1	11.2	2.5
11/09/2019 21:00	14.5	3.0	2.1	11.4	2.5
11/09/2019 22:00	14.6	3.0	2.1	11.5	2.5
11/09/2019 23:00	14.4	3.0	2.1	11.3	2.5
Average/Sum#:	286.9 #	38.4 #	45.0 #	245.6 #	53.9 #
Minimum:	5.1	0.0	1.3	7.1	1.6
Maximum:	14.8	3.0	2.1	11.7	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/10/2019 00:00	14.5	3.0	2.1	11.4	2.5
11/10/2019 01:00	14.1	2.3	2.0	11.1	2.4
11/10/2019 02:00	14.1	1.9	2.0	11.0	2.4
11/10/2019 03:00	14.1	1.6	2.0	11.1	2.4
11/10/2019 04:00	14.1	1.6	2.0	11.1	2.4
11/10/2019 05:00	14.1	1.9	2.0	11.0	2.4
11/10/2019 06:00	14.3	2.0	2.1	11.3	2.5
11/10/2019 07:00	14.1	1.6	2.1	11.1	2.4
11/10/2019 08:00	7.9	0.0	1.6	8.6	1.9
11/10/2019 09:00	7.7	0.0	1.5	8.4	1.8
11/10/2019 10:00	7.7	0.0	1.5	8.4	1.8
11/10/2019 11:00	7.9	0.0	1.6	8.6	1.9
11/10/2019 12:00	7.9	0.0	1.6	8.6	1.9
11/10/2019 13:00	8.3	0.0	1.7	9.0	2.0
11/10/2019 14:00	9.6	0.0	1.7	8.8	1.9
11/10/2019 15:00	9.2	0.0	1.6	8.5	1.8
11/10/2019 16:00	14.0	3.0	2.0	11.0	2.4
11/10/2019 17:00	14.3	2.9	2.1	11.3	2.5
11/10/2019 18:00	14.3	3.0	2.1	11.2	2.5
11/10/2019 19:00	14.3	2.9	2.1	11.3	2.5
11/10/2019 20:00	14.5	3.0	2.1	11.4	2.5
11/10/2019 21:00	14.7	3.0	2.1	11.6	2.5
11/10/2019 22:00	15.0	2.6	2.1	11.8	2.6
11/10/2019 23:00	14.6	2.6	2.1	11.5	2.5
Average/Sum#:	295.3 #	38.9 #	45.8 #	249.1 #	54.4 #
Minimum:	7.7	0.0	1.5	8.4	1.8
Maximum:	15.0	3.0	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/11/2019 00:00	14.5	3.0	2.1	11.4	2.5
11/11/2019 01:00	14.3	2.3	2.1	11.2	2.5
11/11/2019 02:00	14.5	3.0	2.1	11.3	2.5
11/11/2019 03:00	14.3	3.0	2.1	11.2	2.5
11/11/2019 04:00	14.2	2.6	2.1	11.1	2.5
11/11/2019 05:00	14.2	2.6	2.1	11.1	2.5
11/11/2019 06:00	14.3	3.0	2.1	11.2	2.5
11/11/2019 07:00	14.3	1.9	2.1	11.3	2.5
11/11/2019 08:00	13.4	1.0	2.0	10.5	2.3
11/11/2019 09:00	7.5	0.0	1.5	8.2	1.8
11/11/2019 10:00	7.6	0.0	1.5	8.3	1.8
11/11/2019 11:00	7.6	0.0	1.5	8.3	1.8
11/11/2019 12:00	7.5	0.0	1.5	8.2	1.8
11/11/2019 13:00	10.3	0.0	1.7	9.4	2.1
11/11/2019 14:00	15.7	2.9	2.0	10.8	2.3
11/11/2019 15:00	14.4	2.9	2.1	11.3	2.5
11/11/2019 16:00	14.3	2.9	2.1	11.3	2.5
11/11/2019 17:00	15.1	2.2	2.2	11.9	2.6
11/11/2019 18:00	14.9	2.2	2.1	11.7	2.5
11/11/2019 19:00	14.7	2.6	2.1	11.5	2.5
11/11/2019 20:00	14.7	2.6	2.1	11.6	2.5
11/11/2019 21:00	14.7	2.6	2.1	11.7	2.5
11/11/2019 22:00	14.7	2.6	2.1	11.6	2.5
11/11/2019 23:00	14.7	2.6	2.1	11.5	2.5
Average/Sum#:	316.4 #	48.5 #	47.5 #	257.6 #	56.5 #
Minimum:	7.5	0.0	1.5	8.2	1.8
Maximum:	15.7	3.0	2.2	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/12/2019 00:00	14.5	2.6	2.1	11.5	2.5
11/12/2019 01:00	14.7	2.6	2.1	11.5	2.5
11/12/2019 02:00	14.5	3.0	2.1	11.3	2.5
11/12/2019 03:00	14.7	1.9	2.1	11.6	2.5
11/12/2019 04:00	14.6	1.9	2.1	11.5	2.5
11/12/2019 05:00	14.5	1.9	2.1	11.4	2.5
11/12/2019 06:00	14.7	1.9	2.1	11.6	2.5
11/12/2019 07:00	14.5	1.9	2.1	11.4	2.5
11/12/2019 08:00	14.5	1.9	2.1	11.3	2.5
11/12/2019 09:00	14.3	1.9	2.1	11.3	2.5
11/12/2019 10:00	14.5	1.9	2.1	11.5	2.5
11/12/2019 11:00	14.2	1.6	2.1	11.1	2.5
11/12/2019 12:00	14.2	1.6	2.1	11.1	2.5
11/12/2019 13:00	14.3	2.3	2.1	11.3	2.5
11/12/2019 14:00	14.3	2.6	2.1	11.2	2.5
11/12/2019 15:00	14.3	2.9	2.1	11.3	2.5
11/12/2019 16:00	14.2	2.9	2.1	11.1	2.5
11/12/2019 17:00	14.7	2.9	2.1	11.5	2.5
11/12/2019 18:00	14.5	2.9	2.1	11.5	2.5
11/12/2019 19:00	14.7	2.6	2.1	11.7	2.5
11/12/2019 20:00	14.7	2.6	2.1	11.7	2.5
11/12/2019 21:00	14.7	2.3	2.1	11.5	2.5
11/12/2019 22:00	14.6	2.6	2.1	11.5	2.5
11/12/2019 23:00	14.5	2.6	2.1	11.5	2.5
Average/Sum#:	347.9 #	55.8 #	50.4 #	273.9 #	60.0 #
Minimum:	14.2	1.6	2.1	11.1	2.5
Maximum:	14.7	3.0	2.1	11.7	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/13/2019 00:00	14.5	2.3	2.1	11.4	2.5
11/13/2019 01:00	14.3	1.9	2.1	11.2	2.5
11/13/2019 02:00	14.3	1.9	2.1	11.2	2.5
11/13/2019 03:00	14.3	1.9	2.1	11.2	2.5
11/13/2019 04:00	14.4	1.9	2.1	11.3	2.5
11/13/2019 05:00	14.5	2.3	2.1	11.3	2.5
11/13/2019 06:00	14.7	1.9	2.1	11.5	2.5
11/13/2019 07:00	14.5	1.9	2.1	11.5	2.5
11/13/2019 08:00	14.3	1.9	2.1	11.3	2.5
11/13/2019 09:00	14.3	1.9	2.1	11.2	2.5
11/13/2019 10:00	14.2	1.9	2.1	11.1	2.5
11/13/2019 11:00	14.3	1.9	2.1	11.3	2.5
11/13/2019 12:00	14.3	2.9	2.1	11.3	2.5
11/13/2019 13:00	14.4	2.6	2.1	11.3	2.5
11/13/2019 14:00	14.5	2.3	2.1	11.4	2.5
11/13/2019 15:00	14.5	2.6	2.1	11.4	2.5
11/13/2019 16:00	14.3	2.9	2.1	11.3	2.5
11/13/2019 17:00	15.1	2.2	2.2	11.9	2.6
11/13/2019 18:00	14.7	2.2	2.1	11.5	2.5
11/13/2019 19:00	14.4	2.3	2.1	11.3	2.5
11/13/2019 20:00	14.7	2.6	2.1	11.5	2.5
11/13/2019 21:00	14.5	2.6	2.1	11.5	2.5
11/13/2019 22:00	14.4	2.9	2.1	11.3	2.5
11/13/2019 23:00	14.7	2.6	2.1	11.5	2.5
Average/Sum#:	347.1 #	54.3 #	50.5 #	272.7 #	60.1 #
Minimum:	14.2	1.9	2.1	11.1	2.5
Maximum:	15.1	2.9	2.2	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/14/2019 00:00	14.8	2.3	2.1	11.6	2.5
11/14/2019 01:00	14.8	2.3	2.1	11.7	2.5
11/14/2019 02:00	14.8	2.3	2.1	11.6	2.5
11/14/2019 03:00	14.8	2.3	2.1	11.7	2.5
11/14/2019 04:00	14.8	2.3	2.1	11.6	2.5
11/14/2019 05:00	16.8	2.6	2.1	11.6	2.5
11/14/2019 06:00	14.9	2.3	2.1	11.7	2.5
11/14/2019 07:00	14.6	1.9	2.1	11.5	2.5
11/14/2019 08:00	14.3	1.9	2.1	11.2	2.5
11/14/2019 09:00	14.5	1.9	2.1	11.5	2.5
11/14/2019 10:00	14.7	1.9	2.1	11.5	2.5
11/14/2019 11:00	14.4	1.9	2.1	11.3	2.5
11/14/2019 12:00	14.9	2.2	2.1	11.7	2.5
11/14/2019 13:00	14.7	2.6	2.1	11.6	2.5
11/14/2019 14:00	14.7	2.6	2.1	11.6	2.5
11/14/2019 15:00	14.7	2.6	2.1	11.6	2.5
11/14/2019 16:00	14.5	3.9	2.1	11.5	2.5
11/14/2019 17:00	14.7	2.6	2.1	11.6	2.5
11/14/2019 18:00	14.7	2.6	2.1	11.6	2.5
11/14/2019 19:00	14.7	2.6	2.1	11.5	2.5
11/14/2019 20:00	14.7	2.3	2.1	11.7	2.5
11/14/2019 21:00	14.7	1.9	2.1	11.6	2.5
11/14/2019 22:00	14.5	1.9	2.1	11.5	2.5
11/14/2019 23:00	14.7	2.3	2.1	11.6	2.5
Average/Sum#:	354.4 #	56.0 #	50.4 #	277.6 #	60.0 #
Minimum:	14.3	1.9	2.1	11.2	2.5
Maximum:	16.8	3.9	2.1	11.7	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/15/2019 00:00	14.5	2.3	2.1	11.4	2.5
11/15/2019 01:00	14.3	2.0	2.1	11.2	2.5
11/15/2019 02:00	14.5	2.0	2.1	11.3	2.5
11/15/2019 03:00	14.1	2.0	2.1	11.1	2.4
11/15/2019 04:00	14.2	2.0	2.1	11.2	2.5
11/15/2019 05:00	14.1	2.0	2.1	11.1	2.4
11/15/2019 06:00	12.5	2.2	2.1	11.5	2.5
11/15/2019 07:00	14.7	1.6	2.1	11.6	2.5
11/15/2019 08:00	14.3	1.6	2.1	11.3	2.5
11/15/2019 09:00	14.3	1.6	2.1	11.2	2.5
11/15/2019 10:00	14.3	1.3	2.1	11.3	2.5
11/15/2019 11:00	13.6	1.3	2.0	10.7	2.3
11/15/2019 12:00	14.1	1.9	2.1	11.2	2.4
11/15/2019 13:00	14.5	2.2	2.1	11.4	2.5
11/15/2019 14:00	14.7	2.3	2.1	11.5	2.5
11/15/2019 15:00	14.5	2.3	2.1	11.5	2.5
11/15/2019 16:00	14.4	2.3	2.1	11.3	2.5
11/15/2019 17:00	14.7	2.3	2.1	11.6	2.5
11/15/2019 18:00	14.2	2.3	2.1	11.1	2.5
11/15/2019 19:00	14.4	2.3	2.1	11.3	2.5
11/15/2019 20:00	14.7	2.3	2.1	11.6	2.5
11/15/2019 21:00	14.4	2.6	2.1	11.3	2.5
11/15/2019 22:00	14.5	2.3	2.1	11.3	2.5
11/15/2019 23:00	14.2	2.3	2.1	11.2	2.5
Average/Sum#:	342.7 #	49.3 #	50.3 #	271.2 #	59.5 #
Minimum:	12.5	1.3	2.0	10.7	2.3
Maximum:	14.7	2.6	2.1	11.6	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/16/2019 00:00	14.1	2.3	2.1	11.1	2.4
11/16/2019 01:00	14.1	1.9	2.0	11.1	2.4
11/16/2019 02:00	14.1	1.9	2.1	11.1	2.4
11/16/2019 03:00	14.2	1.6	2.1	11.1	2.5
11/16/2019 04:00	14.1	1.9	2.1	11.1	2.4
11/16/2019 05:00	14.2	1.9	2.1	11.1	2.5
11/16/2019 06:00	14.2	1.9	2.1	11.3	2.5
11/16/2019 07:00	13.9	1.6	2.0	10.9	2.4
11/16/2019 08:00	8.2	0.0	1.7	8.8	1.9
11/16/2019 09:00	7.7	0.0	1.5	8.3	1.8
11/16/2019 10:00	7.7	0.0	1.6	8.4	1.8
11/16/2019 11:00	8.2	0.0	1.7	9.0	2.0
11/16/2019 12:00	8.0	0.0	1.6	8.8	1.9
11/16/2019 13:00	10.0	0.0	1.7	9.2	2.0
11/16/2019 14:00	8.3	0.0	1.7	9.0	2.0
11/16/2019 15:00	9.2	0.0	1.6	8.5	1.8
11/16/2019 16:00	14.1	2.9	2.1	11.1	2.4
11/16/2019 17:00	14.5	2.9	2.1	11.4	2.5
11/16/2019 18:00	14.4	2.9	2.1	11.3	2.5
11/16/2019 19:00	14.5	2.9	2.1	11.3	2.5
11/16/2019 20:00	14.5	3.0	2.1	11.4	2.5
11/16/2019 21:00	14.5	2.9	2.1	11.5	2.5
11/16/2019 22:00	14.5	3.0	2.1	11.4	2.5
11/16/2019 23:00	14.3	3.0	2.1	11.3	2.5
Average/Sum#:	295.5 #	38.5 #	46.5 #	249.5 #	54.6 #
Minimum:	7.7	0.0	1.5	8.3	1.8
Maximum:	14.5	3.0	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/17/2019 00:00	14.3	3.0	2.1	11.2	2.5
11/17/2019 01:00	14.3	2.7	2.1	11.3	2.5
11/17/2019 02:00	13.3	1.9	2.0	10.4	2.3
11/17/2019 03:00	7.9	0.0	1.6	8.6	1.9
11/17/2019 04:00	8.4	0.0	1.7	9.2	2.0
11/17/2019 05:00	7.7	0.0	1.5	8.4	1.8
11/17/2019 06:00	8.4	0.0	1.7	9.2	2.0
11/17/2019 07:00	8.2	0.0	1.7	9.0	2.0
11/17/2019 08:00	8.2	0.0	1.7	9.0	2.0
11/17/2019 09:00	8.2	0.0	1.7	9.0	2.0
11/17/2019 10:00	8.2	0.0	1.7	8.8	1.9
11/17/2019 11:00	10.0	0.0	1.7	9.2	2.0
11/17/2019 12:00	8.0	0.0	1.6	8.8	1.9
11/17/2019 13:00	9.8	0.0	1.7	9.0	2.0
11/17/2019 14:00	7.7	0.0	1.5	8.4	1.8
11/17/2019 15:00	14.0	2.9	2.0	10.9	2.4
11/17/2019 16:00	14.3	2.9	2.1	11.3	2.5
11/17/2019 17:00	14.2	2.9	2.1	11.2	2.5
11/17/2019 18:00	14.3	2.9	2.1	11.3	2.5
11/17/2019 19:00	14.5	2.9	2.1	11.5	2.5
11/17/2019 20:00	14.5	2.9	2.1	11.5	2.5
11/17/2019 21:00	14.6	2.9	2.1	11.5	2.5
11/17/2019 22:00	14.3	2.9	2.1	11.3	2.5
11/17/2019 23:00	14.2	2.7	2.1	11.2	2.5
Average/Sum#:	271.5 #	33.5 #	44.8 #	241.2 #	53.0 #
Minimum:	7.7	0.0	1.5	8.4	1.8
Maximum:	14.6	3.0	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/18/2019 00:00	14.3	2.3	2.1	11.2	2.5
11/18/2019 01:00	14.3	2.7	2.1	11.3	2.5
11/18/2019 02:00	14.3	2.3	2.1	11.2	2.5
11/18/2019 03:00	14.3	2.3	2.1	11.2	2.5
11/18/2019 04:00	14.3	2.3	2.1	11.2	2.5
11/18/2019 05:00	14.3	2.7	2.1	11.2	2.5
11/18/2019 06:00	14.7	2.6	2.1	11.5	2.5
11/18/2019 07:00	14.5	1.9	2.1	11.4	2.5
11/18/2019 08:00	14.2	1.9	2.1	11.1	2.5
11/18/2019 09:00	13.8	1.9	2.0	10.9	2.4
11/18/2019 10:00	14.4	2.9	2.1	11.3	2.5
11/18/2019 11:00	14.8	2.6	2.1	11.7	2.5
11/18/2019 12:00	14.5	2.9	2.1	11.5	2.5
11/18/2019 13:00	14.6	2.2	2.1	11.5	2.5
11/18/2019 14:00	14.5	2.2	2.1	11.5	2.5
11/18/2019 15:00	14.5	2.2	2.1	11.5	2.5
11/18/2019 16:00	14.9	2.2	2.1	11.7	2.5
11/18/2019 17:00	14.7	2.2	2.1	11.7	2.5
11/18/2019 18:00	15.1	1.9	2.2	11.9	2.6
11/18/2019 19:00	14.9	2.2	2.1	11.7	2.5
11/18/2019 20:00	14.9	2.2	2.1	11.7	2.5
11/18/2019 21:00	14.6	2.2	2.1	11.5	2.5
11/18/2019 22:00	14.6	2.2	2.1	11.5	2.5
11/18/2019 23:00	14.5	2.2	2.1	11.5	2.5
Average/Sum#:	348.5 #	55.2 #	50.4 #	274.4 #	60.0 #
Minimum:	13.8	1.9	2.0	10.9	2.4
Maximum:	15.1	2.9	2.2	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/19/2019 00:00	14.5	2.9	2.1	11.4	2.5
11/19/2019 01:00	14.2	2.9	2.1	11.2	2.5
11/19/2019 02:00	14.2	2.9	2.1	11.1	2.5
11/19/2019 03:00	14.2	2.5	2.1	11.1	2.5
11/19/2019 04:00	14.3	2.5	2.1	11.2	2.5
11/19/2019 05:00	16.4	2.2	2.1	11.3	2.5
11/19/2019 06:00	14.2	2.5	2.1	11.2	2.5
11/19/2019 07:00	14.3	1.9	2.1	11.3	2.5
11/19/2019 08:00	14.7	2.2	2.1	11.6	2.5
11/19/2019 09:00	8.1	0.6	2.1	11.5	2.5
11/19/2019 10:00	14.8	1.9	2.1	11.7	2.5
11/19/2019 11:00	14.6	1.9	2.1	11.5	2.5
11/19/2019 12:00	6.4	1.3	2.1	11.3	2.5
11/19/2019 13:00	6.3	1.3	2.1	11.3	2.5
11/19/2019 14:00	14.5	1.9	2.1	11.5	2.5
11/19/2019 15:00	14.3	2.2	2.1	11.3	2.5
11/19/2019 16:00	14.3	2.2	2.1	11.3	2.5
11/19/2019 17:00	15.0	1.6	2.2	11.7	2.5
11/19/2019 18:00	15.3	1.3	2.2	12.0	2.7
11/19/2019 19:00	14.5	1.9	2.1	11.5	2.5
11/19/2019 20:00	14.3	1.9	2.1	11.3	2.5
11/19/2019 21:00	14.5	1.9	2.1	11.5	2.5
11/19/2019 22:00	14.5	1.9	2.1	11.5	2.5
11/19/2019 23:00	14.6	1.9	2.1	11.5	2.5
Average/Sum#:	306.2 #	45.0 #	50.6 #	273.8 #	60.2 #
Minimum:	14.2	1.3	2.1	11.1	2.5
Maximum:	16.4	2.9	2.2	12.0	2.7
%SI	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/20/2019 00:00	14.4	2.2	2.1	11.3	2.5
11/20/2019 01:00	14.3	2.3	2.1	11.3	2.5
11/20/2019 02:00	14.1	2.3	2.1	11.1	2.4
11/20/2019 03:00	14.2	2.3	2.1	11.1	2.5
11/20/2019 04:00	14.3	2.3	2.1	11.3	2.5
11/20/2019 05:00	14.3	2.7	2.1	11.3	2.5
11/20/2019 06:00	14.7	1.9	2.1	11.5	2.5
11/20/2019 07:00	14.9	1.9	2.1	11.7	2.5
11/20/2019 08:00	6.5	1.3	2.1	11.7	2.5
11/20/2019 09:00	6.6	1.3	2.1	11.7	2.5
11/20/2019 10:00	6.6	1.3	2.1	11.7	2.5
11/20/2019 11:00	6.4	1.3	2.1	11.4	2.5
11/20/2019 12:00	6.4	1.3	2.1	11.5	2.5
11/20/2019 13:00	12.6	1.3	2.1	11.5	2.5
11/20/2019 14:00	12.6	1.3	2.1	11.5	2.5
11/20/2019 15:00	12.8	1.0	2.1	11.7	2.5
11/20/2019 16:00	14.6	1.3	2.1	11.4	2.5
11/20/2019 17:00	15.1	1.0	2.2	11.9	2.6
11/20/2019 18:00	15.2	1.0	2.2	12.0	2.7
11/20/2019 19:00	15.3	1.0	2.2	12.0	2.7
11/20/2019 20:00	15.0	1.0	2.2	11.8	2.5
11/20/2019 21:00	14.9	1.0	2.2	11.7	2.5
11/20/2019 22:00	14.6	1.3	2.1	11.4	2.5
11/20/2019 23:00	14.5	1.3	2.1	11.4	2.5
Average/Sum#:	272.4 #	30.4 #	50.9 #	276.9 #	60.4 #
Minimum:	12.6	1.0	2.1	11.1	2.4
Maximum:	15.3	2.7	2.2	12.0	2.7
%SI	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/21/2019 00:00	14.7	1.3	2.1	11.6	2.5
11/21/2019 01:00	14.7	1.3	2.1	11.6	2.5
11/21/2019 02:00	14.6	1.3	2.1	11.5	2.5
11/21/2019 03:00	14.8	1.0	2.1	11.7	2.5
11/21/2019 04:00	14.9	0.7	2.2	11.7	2.5
11/21/2019 05:00	15.0	1.0	2.2	11.7	2.5
11/21/2019 06:00	15.3	0.7	2.2	12.1	2.7
11/21/2019 07:00	15.3	0.7	2.2	12.1	2.7
11/21/2019 08:00	14.9	1.0	2.1	11.7	2.5
11/21/2019 09:00	12.3	1.0	2.1	11.2	2.5
11/21/2019 10:00	12.5	1.3	2.1	11.4	2.5
11/21/2019 11:00	12.2	1.3	2.1	11.1	2.5
11/21/2019 12:00	12.5	1.3	2.1	11.4	2.5
11/21/2019 13:00	12.3	1.3	2.1	11.3	2.5
11/21/2019 14:00	12.3	1.3	2.1	11.2	2.5
11/21/2019 15:00	12.4	1.3	2.1	11.3	2.5
11/21/2019 16:00	13.0	1.3	2.2	11.9	2.6
11/21/2019 17:00	15.3	1.3	2.2	12.0	2.7
11/21/2019 18:00	15.4	1.3	2.2	12.1	2.7
11/21/2019 19:00	15.4	1.0	2.2	12.1	2.7
11/21/2019 20:00	15.3	0.7	2.2	12.1	2.7
11/21/2019 21:00	15.3	0.7	2.2	12.1	2.7
11/21/2019 22:00	15.1	1.0	2.2	11.9	2.6
11/21/2019 23:00	14.9	1.0	2.1	11.7	2.5
Average/Sum#:	340.4 #	26.1 #	51.5 #	280.5 #	61.6 #
Minimum:	12.2	0.7	2.1	11.1	2.5
Maximum:	15.4	1.3	2.2	12.1	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/22/2019 00:00	14.7	1.0	2.1	11.6	2.5
11/22/2019 01:00	14.7	1.0	2.1	11.5	2.5
11/22/2019 02:00	14.7	1.0	2.1	11.5	2.5
11/22/2019 03:00	14.7	1.0	2.1	11.5	2.5
11/22/2019 04:00	14.3	1.0	2.1	11.3	2.5
11/22/2019 05:00	12.1	0.7	2.1	11.1	2.4
11/22/2019 06:00	15.5	0.7	2.2	12.2	2.7
11/22/2019 07:00	15.4	0.3	2.2	12.1	2.7
11/22/2019 08:00	14.3	0.3	2.1	11.2	2.5
11/22/2019 09:00	12.1	0.7	2.1	11.1	2.4
11/22/2019 10:00	12.3	0.7	2.1	11.3	2.5
11/22/2019 11:00	12.1	0.7	2.1	11.1	2.4
11/22/2019 12:00	12.2	1.0	2.1	11.1	2.5
11/22/2019 13:00	12.1	0.7	2.1	11.1	2.4
11/22/2019 14:00	12.3	1.0	2.1	11.3	2.5
11/22/2019 15:00	12.3	1.0	2.1	11.3	2.5
11/22/2019 16:00	15.2	0.7	2.2	12.0	2.6
11/22/2019 17:00	13.1	0.7	2.2	12.0	2.6
11/22/2019 18:00	15.4	0.7	2.2	12.1	2.7
11/22/2019 19:00	15.2	0.7	2.2	12.0	2.6
11/22/2019 20:00	13.0	0.7	2.2	11.8	2.6
11/22/2019 21:00	15.1	0.3	2.2	11.9	2.6
11/22/2019 22:00	14.9	0.3	2.1	11.7	2.5
11/22/2019 23:00	14.6	0.3	2.1	11.5	2.5
Average/Sum#:	332.3 #	17.2 #	51.2 #	277.3 #	60.7 #
Minimum:	12.1	0.3	2.1	11.1	2.4
Maximum:	15.5	1.0	2.2	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/23/2019 00:00	14.5	0.3	2.1	11.4	2.5
11/23/2019 01:00	14.7	0.3	2.1	11.6	2.5
11/23/2019 02:00	14.7	0.7	2.1	11.5	2.5
11/23/2019 03:00	14.3	0.3	2.1	11.3	2.5
11/23/2019 04:00	14.7	0.3	2.1	11.6	2.5
11/23/2019 05:00	14.8	0.7	2.1	11.6	2.5
11/23/2019 06:00	14.8	0.3	2.1	11.6	2.5
11/23/2019 07:00	14.5	0.3	2.1	11.5	2.5
11/23/2019 08:00	7.6	0.3	2.0	10.5	2.3
11/23/2019 09:00	3.3	0.0	1.7	9.1	2.0
11/23/2019 10:00	3.3	0.0	1.7	9.2	2.0
11/23/2019 11:00	3.3	0.0	1.7	9.0	2.0
11/23/2019 12:00	3.3	0.0	1.7	9.2	2.0
11/23/2019 13:00	3.3	0.0	1.7	9.2	2.0
11/23/2019 14:00	3.3	0.0	1.7	9.0	2.0
11/23/2019 15:00	7.3	0.3	1.8	10.0	2.2
11/23/2019 16:00	12.6	0.7	2.1	11.5	2.5
11/23/2019 17:00	12.8	0.7	2.1	11.7	2.5
11/23/2019 18:00	12.8	0.7	2.1	11.7	2.5
11/23/2019 19:00	15.2	0.7	2.2	12.0	2.6
11/23/2019 20:00	13.0	0.7	2.2	11.8	2.6
11/23/2019 21:00	12.7	0.7	2.1	11.6	2.5
11/23/2019 22:00	12.5	0.3	2.1	11.4	2.5
11/23/2019 23:00	14.1	0.3	2.1	11.2	2.4
Average/Sum#:	257.4 #	8.6 #	47.8 #	260.2 #	56.6 #
Minimum:	3.3	0.0	1.7	9.0	2.0
Maximum:	15.2	0.7	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/24/2019 00:00	14.1	0.3	2.1	11.1	2.4
11/24/2019 01:00	14.1	0.3	2.1	11.1	2.4
11/24/2019 02:00	14.1	0.3	2.0	11.1	2.4
11/24/2019 03:00	14.1	0.3	2.0	11.1	2.4
11/24/2019 04:00	14.1	0.3	2.1	11.1	2.4
11/24/2019 05:00	14.1	0.7	2.1	11.1	2.4
11/24/2019 06:00	12.5	0.7	2.1	11.4	2.5
11/24/2019 07:00	12.1	0.3	2.0	11.1	2.4
11/24/2019 08:00	3.3	0.0	1.7	9.0	2.0
11/24/2019 09:00	3.3	0.0	1.7	9.0	2.0
11/24/2019 10:00	3.3	0.0	1.7	9.2	2.0
11/24/2019 11:00	3.3	0.0	1.7	9.1	2.0
11/24/2019 12:00	3.4	0.0	1.7	9.3	2.0
11/24/2019 13:00	3.3	0.0	1.7	9.2	2.0
11/24/2019 14:00	3.3	0.0	1.7	9.0	2.0
11/24/2019 15:00	9.2	0.0	1.8	10.1	2.2
11/24/2019 16:00	12.3	1.0	2.1	11.3	2.5
11/24/2019 17:00	12.7	1.0	2.1	11.6	2.5
11/24/2019 18:00	12.1	1.0	2.1	11.1	2.4
11/24/2019 19:00	11.8	0.7	2.0	10.8	2.4
11/24/2019 20:00	12.2	1.0	2.1	11.1	2.5
11/24/2019 21:00	14.5	0.7	2.1	11.4	2.5
11/24/2019 22:00	14.1	0.7	2.0	11.1	2.4
11/24/2019 23:00	7.2	0.0	1.8	9.9	2.2
Average/Sum#:	238.5 #	9.3 #	46.5 #	251.3 #	54.9 #
Minimum:	3.3	0.0	1.7	9.0	2.0
Maximum:	14.5	1.0	2.1	11.6	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/25/2019 00:00	5.4	6.0	0.9	5.6	1.2
11/25/2019 01:00	1.5	0.0	0.4	4.5	0.9
11/25/2019 02:00	1.3	0.0	0.4	4.0	0.8
11/25/2019 03:00	1.4	0.0	0.4	4.1	0.8
11/25/2019 04:00	7.9	17.1	0.7	5.5	1.1
11/25/2019 05:00	26.7	40.3	1.3	7.8	1.7
11/25/2019 06:00	0.0	0.0	1.4	7.5	1.6
11/25/2019 07:00	3.2	0.0	1.7	8.8	1.9
11/25/2019 08:00	3.3	0.0	1.7	9.1	2.0
11/25/2019 09:00	3.3	0.0	1.7	8.9	2.0
11/25/2019 10:00	3.3	0.0	1.7	9.0	2.0
11/25/2019 11:00	3.3	0.0	1.7	9.2	2.0
11/25/2019 12:00	3.3	0.0	1.7	9.2	2.0
11/25/2019 13:00	3.3	0.0	1.7	9.2	2.0
11/25/2019 14:00	3.3	0.0	1.7	9.1	2.0
11/25/2019 15:00	3.1	0.0	1.6	8.6	1.9
11/25/2019 16:00	12.2	1.0	2.1	11.1	2.5
11/25/2019 17:00	15.1	1.0	2.2	11.9	2.6
11/25/2019 18:00	14.5	1.0	2.1	11.4	2.5
11/25/2019 19:00	14.9	1.0	2.1	11.7	2.5
11/25/2019 20:00	14.9	1.0	2.1	11.7	2.5
11/25/2019 21:00	14.7	1.0	2.1	11.5	2.5
11/25/2019 22:00	14.4	1.0	2.1	11.3	2.5
11/25/2019 23:00	14.3	0.7	2.1	11.3	2.5
Average/Sum#:	188.6 #	71.1 #	37.6 #	212.0 #	46.0 #
Minimum:	0.0	0.0	0.4	4.0	0.8
Maximum:	26.7	40.3	2.2	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/26/2019 00:00	14.5	1.0	2.1	11.3	2.5
11/26/2019 01:00	14.6	1.0	2.1	11.5	2.5
11/26/2019 02:00	14.2	0.7	2.1	11.1	2.5
11/26/2019 03:00	14.2	0.7	2.1	11.1	2.5
11/26/2019 04:00	14.0	0.7	2.0	11.1	2.4
11/26/2019 05:00	11.7	1.0	2.0	10.7	2.3
11/26/2019 06:00	12.8	1.0	2.1	11.7	2.5
11/26/2019 07:00	11.5	0.3	2.0	10.6	2.3
11/26/2019 08:00	3.3	0.0	1.7	9.0	2.0
11/26/2019 09:00	3.3	0.0	1.7	9.2	2.0
11/26/2019 10:00	3.1	0.0	1.6	8.6	1.9
11/26/2019 11:00	3.2	0.0	1.7	8.8	1.9
11/26/2019 12:00	3.1	0.0	1.6	8.7	1.9
11/26/2019 13:00	3.3	0.0	1.7	8.9	2.0
11/26/2019 14:00	9.2	0.3	1.8	9.9	2.1
11/26/2019 15:00	9.8	1.3	2.0	10.5	2.4
11/26/2019 16:00	11.8	1.0	2.0	10.7	2.3
11/26/2019 17:00	12.5	1.0	2.1	11.4	2.5
11/26/2019 18:00	12.3	1.3	2.1	11.2	2.5
11/26/2019 19:00	14.5	1.3	2.1	11.3	2.5
11/26/2019 20:00	12.6	1.3	2.1	11.5	2.5
11/26/2019 21:00	12.5	1.3	2.1	11.4	2.5
11/26/2019 22:00	14.4	1.3	2.1	11.3	2.5
11/26/2019 23:00	12.3	1.3	2.1	11.3	2.5
Average/Sum#:	248.7 #	17.8 #	47.0 #	252.8 #	55.5 #
Minimum:	3.1	0.0	1.6	8.6	1.9
Maximum:	14.6	1.3	2.1	11.7	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/27/2019 00:00	14.6	1.3	2.1	11.4	2.5
11/27/2019 01:00	12.3	1.3	2.1	11.3	2.5
11/27/2019 02:00	12.1	1.3	2.0	11.1	2.4
11/27/2019 03:00	12.1	1.3	2.0	11.0	2.4
11/27/2019 04:00	12.1	1.3	2.1	11.1	2.4
11/27/2019 05:00	12.1	1.3	2.1	11.1	2.4
11/27/2019 06:00	11.9	1.3	2.0	10.9	2.4
11/27/2019 07:00	14.8	1.3	2.1	11.6	2.5
11/27/2019 08:00	14.7	1.0	2.1	11.6	2.5
11/27/2019 09:00	12.6	1.0	2.1	11.5	2.5
11/27/2019 10:00	14.5	1.0	2.1	11.5	2.5
11/27/2019 11:00	12.3	1.0	2.1	11.2	2.5
11/27/2019 12:00	12.4	1.0	2.1	11.3	2.5
11/27/2019 13:00	14.7	1.0	2.1	11.7	2.5
11/27/2019 14:00	14.7	1.0	2.1	11.6	2.5
11/27/2019 15:00	14.3	1.0	2.1	11.2	2.5
11/27/2019 16:00	14.1	1.0	2.0	11.0	2.4
11/27/2019 17:00	14.7	1.0	2.1	11.5	2.5
11/27/2019 18:00	13.7	0.7	2.0	10.7	2.3
11/27/2019 19:00	11.7	1.0	2.0	10.7	2.3
11/27/2019 20:00	14.9	1.3	2.1	11.8	2.6
11/27/2019 21:00	15.1	1.0	2.2	11.9	2.6
11/27/2019 22:00	12.7	1.3	2.1	11.6	2.5
11/27/2019 23:00	12.6	1.3	2.1	11.5	2.5
Average/Sum#:	321.7 #	27.0 #	49.9 #	271.8 #	59.2 #
Minimum:	11.7	0.7	2.0	10.7	2.3
Maximum:	15.1	1.3	2.2	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/28/2019 00:00	12.6	1.3	2.1	11.5	2.5
11/28/2019 01:00	12.5	1.3	2.1	11.4	2.5
11/28/2019 02:00	12.4	1.0	2.1	11.3	2.5
11/28/2019 03:00	12.6	0.7	2.1	11.5	2.5
11/28/2019 04:00	12.4	0.7	2.1	11.3	2.5
11/28/2019 05:00	14.2	1.0	2.1	11.1	2.5
11/28/2019 06:00	12.8	1.0	2.1	11.7	2.5
11/28/2019 07:00	12.8	1.3	2.2	11.7	2.5
11/28/2019 08:00	12.9	1.3	2.2	11.8	2.5
11/28/2019 09:00	12.7	1.3	2.1	11.6	2.5
11/28/2019 10:00	12.7	1.3	2.1	11.6	2.5
11/28/2019 11:00	12.7	1.0	2.2	11.6	2.5
11/28/2019 12:00	12.8	1.0	2.2	11.6	2.5
11/28/2019 13:00	12.7	1.0	2.1	11.6	2.5
11/28/2019 14:00	12.7	1.0	2.1	11.6	2.5
11/28/2019 15:00	12.7	1.0	2.1	11.6	2.5
11/28/2019 16:00	14.5	1.0	2.1	11.4	2.5
11/28/2019 17:00	14.5	1.0	2.1	11.4	2.5
11/28/2019 18:00	12.1	0.7	2.1	11.1	2.4
11/28/2019 19:00	14.5	1.0	2.1	11.4	2.5
11/28/2019 20:00	12.7	1.0	2.1	11.6	2.5
11/28/2019 21:00	14.7	1.0	2.1	11.6	2.5
11/28/2019 22:00	14.7	1.0	2.1	11.6	2.5
11/28/2019 23:00	14.7	1.0	2.1	11.6	2.5
Average/Sum#:	316.6 #	24.9 #	50.8 #	276.2 #	59.9 #
Minimum:	12.1	0.7	2.1	11.1	2.4
Maximum:	14.7	1.3	2.2	11.8	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/29/2019 00:00	12.7	1.0	2.1	11.6	2.5
11/29/2019 01:00	14.6	1.0	2.1	11.5	2.5
11/29/2019 02:00	14.7	1.0	2.1	11.6	2.5
11/29/2019 03:00	14.6	1.3	2.1	11.5	2.5
11/29/2019 04:00	14.7	1.0	2.1	11.6	2.5
11/29/2019 05:00	14.6	1.3	2.1	11.4	2.5
11/29/2019 06:00	12.8	1.3	2.2	11.6	2.5
11/29/2019 07:00	12.2	0.7	2.1	11.2	2.5
11/29/2019 08:00	3.1	0.0	1.6	8.6	1.9
11/29/2019 09:00	2.9	0.0	1.4	7.9	1.7
11/29/2019 10:00	3.2	0.0	1.6	8.8	1.9
11/29/2019 11:00	3.2	0.0	1.6	8.8	1.9
11/29/2019 12:00	3.1	0.0	1.6	8.6	1.9
11/29/2019 13:00	3.1	0.0	1.6	8.6	1.9
11/29/2019 14:00	2.9	0.0	1.4	8.0	1.8
11/29/2019 15:00	3.1	0.0	1.6	8.6	1.9
11/29/2019 16:00	12.1	0.7	2.0	11.0	2.4
11/29/2019 17:00	15.3	0.3	2.2	12.1	2.7
11/29/2019 18:00	15.4	0.3	2.2	12.1	2.7
11/29/2019 19:00	15.3	0.3	2.2	12.0	2.7
11/29/2019 20:00	15.3	0.3	2.2	12.1	2.7
11/29/2019 21:00	14.7	0.3	2.1	11.5	2.5
11/29/2019 22:00	14.7	0.7	2.1	11.6	2.5
11/29/2019 23:00	14.7	0.7	2.1	11.5	2.5
Average/Sum#:	253.0 #	12.2 #	46.4 #	253.8 #	55.6 #
Minimum:	2.9	0.0	1.4	7.9	1.7
Maximum:	15.4	1.3	2.2	12.1	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/30/2019 00:00	14.7	0.7	2.1	11.5	2.5
11/30/2019 01:00	14.6	0.7	2.1	11.5	2.5
11/30/2019 02:00	14.7	0.7	2.1	11.5	2.5
11/30/2019 03:00	14.7	0.7	2.1	11.5	2.5
11/30/2019 04:00	12.6	0.7	2.1	11.5	2.5
11/30/2019 05:00	12.5	0.7	2.1	11.4	2.5
11/30/2019 06:00	12.6	0.7	2.1	11.5	2.5
11/30/2019 07:00	12.5	0.7	2.1	11.4	2.5
11/30/2019 08:00	12.6	0.7	2.1	11.5	2.5
11/30/2019 09:00	14.7	0.7	2.1	11.7	2.5
11/30/2019 10:00	12.5	0.7	2.1	11.5	2.5
11/30/2019 11:00	12.3	0.7	2.1	11.2	2.5
11/30/2019 12:00	14.7	0.7	2.1	11.5	2.5
11/30/2019 13:00	14.7	0.7	2.1	11.5	2.5
11/30/2019 14:00	14.7	0.7	2.1	11.5	2.5
11/30/2019 15:00	12.6	0.7	2.1	11.5	2.5
11/30/2019 16:00	12.5	0.7	2.1	11.5	2.5
11/30/2019 17:00	12.6	0.7	2.1	11.5	2.5
11/30/2019 18:00	12.5	0.7	2.1	11.4	2.5
11/30/2019 19:00	12.8	0.7	2.1	11.7	2.5
11/30/2019 20:00	12.6	0.7	2.1	11.5	2.5
11/30/2019 21:00	12.6	0.7	2.1	11.5	2.5
11/30/2019 22:00	12.3	0.7	2.1	11.3	2.5
11/30/2019 23:00	12.2	0.7	2.1	11.1	2.5
Average/Sum#:	317.8 #	16.8 #	50.4 #	275.2 #	60.0 #
Minimum:	12.2	0.7	2.1	11.1	2.5
Maximum:	14.7	0.7	2.1	11.7	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/01/2019 00:00	12.4	0.7	2.1	11.4	2.5
12/01/2019 01:00	12.2	0.7	2.1	11.1	2.5
12/01/2019 02:00	12.2	0.7	2.1	11.1	2.5
12/01/2019 03:00	12.2	0.7	2.1	11.1	2.5
12/01/2019 04:00	12.2	0.7	2.1	11.1	2.5
12/01/2019 05:00	12.2	0.7	2.1	11.1	2.5
12/01/2019 06:00	12.1	0.7	2.1	11.1	2.4
12/01/2019 07:00	14.2	0.7	2.1	11.1	2.5
12/01/2019 08:00	12.6	0.7	2.1	11.5	2.5
12/01/2019 09:00	12.6	0.7	2.1	11.5	2.5
12/01/2019 10:00	12.7	0.7	2.1	11.7	2.5
12/01/2019 11:00	12.6	0.7	2.1	11.5	2.5
12/01/2019 12:00	12.2	0.7	2.1	11.1	2.5
12/01/2019 13:00	12.3	0.7	2.1	11.3	2.5
12/01/2019 14:00	12.3	0.7	2.1	11.2	2.5
12/01/2019 15:00	12.3	0.7	2.1	11.3	2.5
12/01/2019 16:00	12.3	0.7	2.1	11.3	2.5
12/01/2019 17:00	12.6	0.7	2.1	11.5	2.5
12/01/2019 18:00	12.9	0.7	2.2	11.8	2.6
12/01/2019 19:00	13.1	0.3	2.2	11.9	2.7
12/01/2019 20:00	12.8	0.3	2.1	11.7	2.5
12/01/2019 21:00	12.4	0.3	2.1	11.3	2.5
12/01/2019 22:00	12.3	0.7	2.1	11.3	2.5
12/01/2019 23:00	12.2	0.7	2.1	11.1	2.5
Average/Sum#:	299.9 #	15.6 #	50.6 #	272.1 #	60.2 #
Minimum:	12.1	0.3	2.1	11.1	2.4
Maximum:	14.2	0.7	2.2	11.9	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/02/2019 00:00	12.1	0.7	2.1	11.1	2.4
12/02/2019 01:00	12.1	0.7	2.1	11.1	2.4
12/02/2019 02:00	12.1	0.7	2.1	11.1	2.4
12/02/2019 03:00	12.1	0.7	2.1	11.1	2.4
12/02/2019 04:00	12.1	0.7	2.0	11.1	2.4
12/02/2019 05:00	12.1	0.7	2.1	11.1	2.4
12/02/2019 06:00	14.8	0.7	2.1	11.7	2.5
12/02/2019 07:00	13.1	0.3	2.2	11.9	2.7
12/02/2019 08:00	12.4	0.3	2.1	11.3	2.5
12/02/2019 09:00	12.1	0.3	2.1	11.1	2.4
12/02/2019 10:00	12.3	0.7	2.1	11.2	2.5
12/02/2019 11:00	12.2	0.7	2.1	11.1	2.5
12/02/2019 12:00	12.6	0.3	2.1	11.5	2.5
12/02/2019 13:00	12.4	0.3	2.1	11.3	2.5
12/02/2019 14:00	12.6	0.3	2.1	11.5	2.5
12/02/2019 15:00	12.6	0.3	2.1	11.5	2.5
12/02/2019 16:00	12.8	0.3	2.1	11.7	2.5
12/02/2019 17:00	13.1	0.3	2.2	12.0	2.7
12/02/2019 18:00	13.2	0.0	2.2	12.1	2.7
12/02/2019 19:00	13.2	0.0	2.2	12.1	2.7
12/02/2019 20:00	13.2	0.0	2.2	12.1	2.7
12/02/2019 21:00	13.0	0.0	2.2	11.9	2.6
12/02/2019 22:00	12.5	0.3	2.1	11.5	2.5
12/02/2019 23:00	12.5	0.3	2.1	11.4	2.5
Average/Sum#:	303.2 #	9.6 #	50.9 #	275.5 #	60.4 #
Minimum:	12.1	0.0	2.0	11.1	2.4
Maximum:	14.8	0.7	2.2	12.1	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/03/2019 00:00	12.5	0.3	2.1	11.4	2.5
12/03/2019 01:00	12.1	0.3	2.1	11.1	2.4
12/03/2019 02:00	12.1	0.3	2.1	11.1	2.4
12/03/2019 03:00	12.2	0.3	2.1	11.1	2.5
12/03/2019 04:00	12.3	0.3	2.1	11.3	2.5
12/03/2019 05:00	12.4	0.3	2.1	11.3	2.5
12/03/2019 06:00	12.6	0.3	2.1	11.5	2.5
12/03/2019 07:00	12.8	0.0	2.1	11.7	2.5
12/03/2019 08:00	12.8	0.0	2.1	11.7	2.5
12/03/2019 09:00	12.6	0.3	2.1	11.5	2.5
12/03/2019 10:00	12.3	0.3	2.1	11.3	2.5
12/03/2019 11:00	14.8	0.0	2.1	11.6	2.5
12/03/2019 12:00	14.9	0.0	2.2	11.7	2.5
12/03/2019 13:00	14.9	0.0	2.1	11.8	2.6
12/03/2019 14:00	14.9	0.0	2.1	11.7	2.5
12/03/2019 15:00	14.9	0.0	2.1	11.7	2.5
12/03/2019 16:00	14.8	0.0	2.1	11.7	2.5
12/03/2019 17:00	13.0	0.3	2.2	11.8	2.6
12/03/2019 18:00	13.0	0.3	2.2	11.8	2.6
12/03/2019 19:00	15.1	0.3	2.2	11.9	2.6
12/03/2019 20:00	15.1	0.3	2.2	11.9	2.6
12/03/2019 21:00	13.0	0.3	2.2	11.8	2.6
12/03/2019 22:00	12.6	0.3	2.1	11.5	2.5
12/03/2019 23:00	12.5	0.3	2.1	11.4	2.5
Average/Sum#:	320.2 #	4.8 #	51.0 #	277.3 #	60.4 #
Minimum:	12.1	0.0	2.1	11.1	2.4
Maximum:	15.1	0.3	2.2	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/04/2019 00:00	12.8	0.3	2.1	11.7	2.5
12/04/2019 01:00	12.6	0.3	2.1	11.5	2.5
12/04/2019 02:00	12.3	0.3	2.1	11.3	2.5
12/04/2019 03:00	12.3	0.3	2.1	11.3	2.5
12/04/2019 04:00	12.6	0.3	2.1	11.5	2.5
12/04/2019 05:00	12.3	0.7	2.1	11.2	2.5
12/04/2019 06:00	14.6	0.7	2.1	11.5	2.5
12/04/2019 07:00	12.8	0.3	2.1	11.7	2.5
12/04/2019 08:00	12.8	0.3	2.1	11.7	2.5
12/04/2019 09:00	12.8	0.3	2.1	11.7	2.5
12/04/2019 10:00	12.8	0.3	2.1	11.7	2.5
12/04/2019 11:00	13.0	0.3	2.2	11.9	2.6
12/04/2019 12:00	12.8	0.3	2.1	11.7	2.5
12/04/2019 13:00	12.6	0.3	2.1	11.5	2.5
12/04/2019 14:00	13.0	0.3	2.2	11.9	2.6
12/04/2019 15:00	12.8	0.3	2.1	11.7	2.5
12/04/2019 16:00	12.8	0.3	2.1	11.7	2.5
12/04/2019 17:00	12.6	0.3	2.1	11.5	2.5
12/04/2019 18:00	13.0	0.3	2.2	11.9	2.6
12/04/2019 19:00	13.0	0.3	2.2	11.9	2.6
12/04/2019 20:00	13.0	0.0	2.2	11.9	2.6
12/04/2019 21:00	13.0	0.0	2.2	11.9	2.6
12/04/2019 22:00	12.8	0.3	2.1	11.7	2.5
12/04/2019 23:00	12.5	0.3	2.1	11.5	2.5
Average/Sum#:	307.6 #	7.4 #	51.0 #	279.5 #	60.6 #
Minimum:	12.3	0.0	2.1	11.2	2.5
Maximum:	14.6	0.7	2.2	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/05/2019 00:00	12.6	0.3	2.1	11.5	2.5
12/05/2019 01:00	12.7	0.3	2.1	11.6	2.5
12/05/2019 02:00	12.6	0.3	2.1	11.5	2.5
12/05/2019 03:00	12.6	0.3	2.1	11.5	2.5
12/05/2019 04:00	12.5	0.3	2.1	11.4	2.5
12/05/2019 05:00	12.4	0.7	2.1	11.3	2.5
12/05/2019 06:00	12.6	0.3	2.1	11.5	2.5
12/05/2019 07:00	12.4	0.3	2.1	11.3	2.5
12/05/2019 08:00	12.1	0.3	2.0	11.1	2.4
12/05/2019 09:00	12.2	0.3	2.1	11.1	2.5
12/05/2019 10:00	12.2	0.3	2.0	11.2	2.4
12/05/2019 11:00	12.2	0.3	2.0	11.2	2.4
12/05/2019 12:00	12.2	0.3	2.0	11.2	2.4
12/05/2019 13:00	12.2	0.3	2.0	11.2	2.4
12/05/2019 14:00	12.2	0.3	2.0	11.2	2.4
12/05/2019 15:00	12.2	0.3	2.0	11.2	2.4
12/05/2019 16:00	12.5	0.3	2.1	11.5	2.5
12/05/2019 17:00	10.7	0.0	2.1	11.6	2.5
12/05/2019 18:00	10.7	0.0	2.1	11.6	2.5
12/05/2019 19:00	10.7	0.0	2.1	11.6	2.5
12/05/2019 20:00	10.7	0.0	2.1	11.6	2.5
12/05/2019 21:00	10.7	0.0	2.1	11.6	2.5
12/05/2019 22:00	10.5	0.0	2.1	11.5	2.5
12/05/2019 23:00	10.4	0.3	2.1	11.4	2.5
Average/Sum#:	284.8 #	5.8 #	49.7 #	273.4 #	59.3 #
Minimum:	10.4	0.0	2.0	11.1	2.4
Maximum:	12.7	0.7	2.1	11.6	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/06/2019 00:00	12.3	0.3	2.0	11.3	2.4
12/06/2019 01:00	12.2	0.3	2.0	11.2	2.4
12/06/2019 02:00	12.2	0.3	2.0	11.2	2.4
12/06/2019 03:00	12.3	0.3	2.0	11.3	2.4
12/06/2019 04:00	12.2	0.3	2.0	11.2	2.4
12/06/2019 05:00	12.2	0.6	2.0	11.2	2.4
12/06/2019 06:00	14.4	0.6	2.0	11.4	2.4
12/06/2019 07:00	12.4	0.3	2.0	11.4	2.4
12/06/2019 08:00	12.2	0.3	2.0	11.2	2.4
12/06/2019 09:00	12.2	0.6	2.0	11.2	2.4
12/06/2019 10:00	12.2	0.6	2.0	11.2	2.4
12/06/2019 11:00	12.3	0.3	2.0	11.3	2.4
12/06/2019 12:00	12.3	0.3	2.1	11.3	2.5
12/06/2019 13:00	10.3	0.3	2.1	11.3	2.5
12/06/2019 14:00	10.3	0.3	2.1	11.2	2.5
12/06/2019 15:00	10.2	0.3	2.1	11.2	2.5
12/06/2019 16:00	10.4	0.3	2.1	11.2	2.5
12/06/2019 17:00	10.3	0.3	2.1	11.2	2.5
12/06/2019 18:00	10.4	0.3	2.1	11.3	2.5
12/06/2019 19:00	10.4	0.3	2.1	11.3	2.5
12/06/2019 20:00	10.3	0.3	2.1	11.3	2.5
12/06/2019 21:00	8.5	0.3	2.1	11.3	2.5
12/06/2019 22:00	8.5	2.5	2.1	11.1	2.4
12/06/2019 23:00	8.5	5.4	2.1	11.1	2.4
Average/Sum#:	269.5 #	15.7 #	49.2 #	269.9 #	58.6 #
Minimum:	8.5	0.3	2.0	11.1	2.4
Maximum:	14.4	5.4	2.1	11.4	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/07/2019 00:00	8.4	5.3	2.1	11.2	2.4
12/07/2019 01:00	14.5	0.3	2.0	11.4	2.4
12/07/2019 02:00	12.2	0.6	2.0	11.2	2.4
12/07/2019 03:00	12.2	0.6	2.0	11.2	2.4
12/07/2019 04:00	12.3	0.6	2.0	11.3	2.4
12/07/2019 05:00	12.2	0.6	2.0	11.2	2.4
12/07/2019 06:00	14.3	0.6	2.0	11.2	2.4
12/07/2019 07:00	12.4	0.3	2.1	11.4	2.4
12/07/2019 08:00	12.5	0.3	2.1	11.4	2.5
12/07/2019 09:00	12.4	0.3	2.1	11.4	2.4
12/07/2019 10:00	12.4	0.3	2.0	11.3	2.4
12/07/2019 11:00	12.4	0.3	2.0	11.4	2.4
12/07/2019 12:00	12.4	0.3	2.0	11.4	2.4
12/07/2019 13:00	12.4	0.3	2.0	11.3	2.4
12/07/2019 14:00	12.4	0.3	2.0	11.3	2.4
12/07/2019 15:00	12.2	0.3	2.0	11.2	2.4
12/07/2019 16:00	12.4	0.3	2.0	11.3	2.4
12/07/2019 17:00	12.4	0.3	2.0	11.3	2.4
12/07/2019 18:00	14.7	0.3	2.1	11.6	2.6
12/07/2019 19:00	14.7	0.3	2.1	11.5	2.6
12/07/2019 20:00	14.7	0.3	2.1	11.5	2.6
12/07/2019 21:00	12.6	0.3	2.1	11.5	2.6
12/07/2019 22:00	12.4	0.3	2.0	11.4	2.4
12/07/2019 23:00	12.4	0.3	2.0	11.4	2.4
Average/Sum#:	303.9 #	13.7 #	48.8 #	272.3 #	58.5 #
Minimum:	8.4	0.3	2.0	11.2	2.4
Maximum:	14.7	5.3	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/08/2019 00:00	12.4	0.3	2.1	11.4	2.4
12/08/2019 01:00	11.6	0.3	2.0	10.6	2.4
12/08/2019 02:00	4.8	0.0	1.6	8.8	2.0
12/08/2019 03:00	3.0	0.0	1.4	8.0	1.8
12/08/2019 04:00	4.8	0.0	1.6	8.8	2.0
12/08/2019 05:00	5.0	0.0	1.7	9.2	2.0
12/08/2019 06:00	5.1	0.0	1.7	9.3	2.0
12/08/2019 07:00	5.0	0.0	1.7	9.1	2.0
12/08/2019 08:00	4.9	0.0	1.6	9.0	2.0
12/08/2019 09:00	5.0	0.0	1.6	9.1	2.0
12/08/2019 10:00	4.5	0.0	1.5	8.2	1.8
12/08/2019 11:00	4.8	0.0	1.6	8.8	1.9
12/08/2019 12:00	4.5	0.0	1.6	8.3	1.8
12/08/2019 13:00	5.0	0.0	1.7	9.1	2.0
12/08/2019 14:00	5.0	0.0	1.7	9.1	2.0
12/08/2019 15:00	9.4	1.0	1.9	10.4	2.2
12/08/2019 16:00	14.2	1.3	2.0	11.2	2.4
12/08/2019 17:00	14.2	0.6	2.0	11.2	2.4
12/08/2019 18:00	14.5	0.6	2.1	11.4	2.4
12/08/2019 19:00	14.6	0.6	2.1	11.5	2.6
12/08/2019 20:00	14.7	0.3	2.1	11.6	2.6
12/08/2019 21:00	14.4	0.3	2.0	11.2	2.4
12/08/2019 22:00	14.6	0.3	2.1	11.4	2.5
12/08/2019 23:00	14.7	0.3	2.1	11.6	2.6
Average/Sum#:	210.7 #	5.9 #	43.5 #	238.3 #	52.2 #
Minimum:	3.0	0.0	1.4	8.0	1.8
Maximum:	14.7	1.3	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/09/2019 00:00	14.5	0.3	2.1	11.4	2.4
12/09/2019 01:00	14.2	0.3	2.0	11.2	2.4
12/09/2019 02:00	14.1	0.3	2.0	11.0	2.4
12/09/2019 03:00	14.2	0.7	2.0	11.2	2.4
12/09/2019 04:00	14.4	0.3	2.1	11.4	2.4
12/09/2019 05:00	14.4	0.6	2.0	11.4	2.4
12/09/2019 06:00	14.4	0.7	2.0	11.4	2.4
12/09/2019 07:00	14.7	0.7	2.1	11.6	2.6
12/09/2019 08:00	14.6	0.7	2.1	11.4	2.5
12/09/2019 09:00	14.6	0.3	2.1	11.4	2.5
12/09/2019 10:00	14.2	0.3	2.0	11.2	2.4
12/09/2019 11:00	14.2	0.3	2.0	11.2	2.4
12/09/2019 12:00	14.2	0.3	2.0	11.2	2.4
12/09/2019 13:00	14.2	0.3	2.0	11.2	2.4
12/09/2019 14:00	14.1	0.3	2.0	11.0	2.4
12/09/2019 15:00	14.4	0.3	2.0	11.2	2.4
12/09/2019 16:00	14.3	0.3	2.0	11.2	2.4
12/09/2019 17:00	14.7	0.3	2.1	11.6	2.6
12/09/2019 18:00	15.1	0.3	2.1	11.8	2.6
12/09/2019 19:00	15.2	0.3	2.1	12.0	2.6
12/09/2019 20:00	15.2	0.3	2.1	12.0	2.6
12/09/2019 21:00	12.6	0.3	2.1	11.6	2.6
12/09/2019 22:00	14.7	0.3	2.1	11.6	2.6
12/09/2019 23:00	14.6	0.7	2.1	11.5	2.6
Average/Sum#:	345.8 #	9.5 #	49.2 #	273.7 #	59.4 #
Minimum:	12.6	0.3	2.0	11.0	2.4
Maximum:	15.2	0.7	2.1	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/10/2019 00:00	14.8	0.7	2.1	11.6	2.6
12/10/2019 01:00	14.8	0.7	2.1	11.6	2.6
12/10/2019 02:00	14.7	0.7	2.1	11.6	2.6
12/10/2019 03:00	14.9	0.7	2.1	11.6	2.6
12/10/2019 04:00	12.8	0.7	2.1	11.7	2.6
12/10/2019 05:00	16.9	0.7	2.1	11.6	2.6
12/10/2019 06:00	14.9	0.7	2.1	11.6	2.6
12/10/2019 07:00	12.9	0.7	2.1	11.8	2.6
12/10/2019 08:00	14.6	0.7	2.1	11.4	2.5
12/10/2019 09:00	14.8	0.7	2.1	11.6	2.6
12/10/2019 10:00	12.3	0.3	2.0	11.3	2.4
12/10/2019 11:00	12.3	0.7	2.0	11.2	2.4
12/10/2019 12:00	14.4	0.7	2.0	11.4	2.4
12/10/2019 13:00	14.4	0.7	2.0	11.4	2.4
12/10/2019 14:00	14.4	0.7	2.0	11.4	2.4
12/10/2019 15:00	12.3	0.7	2.0	11.2	2.4
12/10/2019 16:00	14.4	0.7	2.1	11.4	2.4
12/10/2019 17:00	14.9	0.3	2.1	11.8	2.6
12/10/2019 18:00	15.1	0.3	2.1	11.8	2.6
12/10/2019 19:00	13.0	0.3	2.1	12.0	2.6
12/10/2019 20:00	13.0	0.3	2.1	12.0	2.6
12/10/2019 21:00	12.8	0.3	2.1	11.7	2.6
12/10/2019 22:00	12.5	0.7	2.1	11.4	2.5
12/10/2019 23:00	12.4	0.7	2.1	11.4	2.4
Average/Sum#:	334.3 #	14.4 #	49.8 #	277.5 #	60.6 #
Minimum:	12.3	0.3	2.0	11.2	2.4
Maximum:	16.9	0.7	2.1	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/11/2019 00:00	14.7	0.3	2.1	11.6	2.6
12/11/2019 01:00	12.6	0.3	2.1	11.6	2.6
12/11/2019 02:00	12.4	0.7	2.1	11.4	2.4
12/11/2019 03:00	12.2	0.7	2.0	11.2	2.4
12/11/2019 04:00	12.3	0.7	2.0	11.2	2.4
12/11/2019 05:00	12.4	0.6	2.1	11.4	2.4
12/11/2019 06:00	14.8	0.7	2.1	11.6	2.6
12/11/2019 07:00	12.6	0.7	2.1	11.6	2.6
12/11/2019 08:00	12.4	0.3	2.1	11.4	2.4
12/11/2019 09:00	12.2	0.7	2.0	11.2	2.4
12/11/2019 10:00	12.3	0.7	2.0	11.2	2.4
12/11/2019 11:00	12.2	0.7	2.0	11.2	2.4
12/11/2019 12:00	12.2	0.7	2.0	11.2	2.4
12/11/2019 13:00	12.2	0.7	2.0	11.2	2.4
12/11/2019 14:00	12.4	0.7	2.0	11.4	2.4
12/11/2019 15:00	12.2	0.7	2.0	11.2	2.4
12/11/2019 16:00	12.2	0.7	2.0	11.2	2.4
12/11/2019 17:00	12.6	0.3	2.1	11.6	2.6
12/11/2019 18:00	12.5	0.6	2.1	11.4	2.5
12/11/2019 19:00	12.9	0.3	2.1	11.8	2.6
12/11/2019 20:00	12.5	0.3	2.1	11.4	2.5
12/11/2019 21:00	12.4	0.6	2.0	11.3	2.4
12/11/2019 22:00	12.2	0.7	2.0	11.2	2.4
12/11/2019 23:00	12.2	0.7	2.0	11.2	2.4
Average/Sum#:	301.6 #	14.1 #	49.1 #	272.7 #	59.0 #
Minimum:	12.2	0.3	2.0	11.2	2.4
Maximum:	14.8	0.7	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/12/2019 00:00	12.2	0.7	2.0	11.2	2.4
12/12/2019 01:00	12.2	0.6	2.0	11.2	2.4
12/12/2019 02:00	12.2	0.6	2.0	11.2	2.4
12/12/2019 03:00	12.2	0.6	2.0	11.2	2.4
12/12/2019 04:00	12.2	0.6	2.0	11.2	2.4
12/12/2019 05:00	12.2	0.6	2.0	11.2	2.4
12/12/2019 06:00	12.5	0.7	2.1	11.5	2.5
12/12/2019 07:00	12.7	0.3	2.1	11.6	2.6
12/12/2019 08:00	12.2	0.7	2.0	11.2	2.4
12/12/2019 09:00	12.2	0.6	2.0	11.2	2.4
12/12/2019 10:00	12.2	0.7	2.0	11.1	2.4
12/12/2019 11:00	12.0	0.6	2.0	11.0	2.4
12/12/2019 12:00	12.2	0.6	2.0	11.2	2.4
12/12/2019 13:00	12.2	0.6	2.0	11.2	2.4
12/12/2019 14:00	12.2	0.6	2.0	11.2	2.4
12/12/2019 15:00	12.2	0.6	2.0	11.2	2.4
12/12/2019 16:00	12.2	0.6	2.0	11.2	2.4
12/12/2019 17:00	12.6	0.3	2.1	11.6	2.6
12/12/2019 18:00	14.7	0.3	2.1	11.6	2.6
12/12/2019 19:00	12.5	0.3	2.1	11.4	2.5
12/12/2019 20:00	12.4	0.3	2.0	11.3	2.4
12/12/2019 21:00	14.4	0.3	2.0	11.4	2.4
12/12/2019 22:00	12.3	0.3	2.0	11.2	2.4
12/12/2019 23:00	10.9	0.0	1.8	10.0	2.2
Average/Sum#:	297.8 #	12.1 #	48.3 #	269.3 #	58.2 #
Minimum:	10.9	0.0	1.8	10.0	2.2
Maximum:	14.7	0.7	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/13/2019 00:00	6.9	7.7	1.2	7.0	1.5
12/13/2019 01:00	1.5	0.0	0.5	4.6	0.9
12/13/2019 02:00	1.4	0.0	0.4	4.2	0.8
12/13/2019 03:00	1.4	0.0	0.4	4.3	0.9
12/13/2019 04:00	6.3	17.3	0.7	5.8	1.2
12/13/2019 05:00	19.3	21.2	1.3	7.4	1.6
12/13/2019 06:00	2.8	0.0	1.4	7.7	1.6
12/13/2019 07:00	3.2	0.0	1.6	8.7	1.9
12/13/2019 08:00	5.0	0.0	1.7	9.3	2.0
12/13/2019 09:00	3.2	0.0	1.6	9.0	2.0
12/13/2019 10:00	5.1	0.0	1.7	9.3	2.0
12/13/2019 11:00	3.2	0.0	1.6	8.8	2.0
12/13/2019 12:00	3.0	0.0	1.4	8.2	1.8
12/13/2019 13:00	5.0	0.0	1.7	9.1	2.0
12/13/2019 14:00	7.0	0.0	1.7	9.5	2.0
12/13/2019 15:00	12.1	1.3	2.0	11.1	2.4
12/13/2019 16:00	12.4	1.3	2.1	11.4	2.4
12/13/2019 17:00	12.4	1.0	2.1	11.4	2.4
12/13/2019 18:00	15.0	1.0	2.1	11.7	2.6
12/13/2019 19:00	12.4	1.0	2.1	11.4	2.4
12/13/2019 20:00	12.5	1.0	2.1	11.5	2.5
12/13/2019 21:00	14.6	1.0	2.1	11.4	2.5
12/13/2019 22:00	14.6	1.0	2.1	11.4	2.5
12/13/2019 23:00	14.5	1.0	2.1	11.4	2.5
Average/Sum#:	194.8 #	55.8 #	37.7 #	215.6 #	46.4 #
Minimum:	1.4	0.0	0.4	4.2	0.8
Maximum:	19.3	21.2	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/14/2019 00:00	14.4	1.0	2.0	11.3	2.4
12/14/2019 01:00	11.8	0.6	2.0	10.8	2.4
12/14/2019 02:00	4.8	0.0	1.6	8.8	2.0
12/14/2019 03:00	3.2	0.0	1.6	8.6	1.8
12/14/2019 04:00	5.1	0.0	1.7	9.3	2.0
12/14/2019 05:00	3.2	0.0	1.6	9.0	2.0
12/14/2019 06:00	3.2	0.0	1.6	8.6	1.8
12/14/2019 07:00	3.0	0.0	1.4	8.2	1.8
12/14/2019 08:00	3.0	0.0	1.4	8.2	1.8
12/14/2019 09:00	4.9	0.0	1.6	9.0	2.0
12/14/2019 10:00	4.7	0.0	1.6	8.7	1.9
12/14/2019 11:00	4.8	0.0	1.6	8.8	2.0
12/14/2019 12:00	2.8	0.0	1.4	7.6	1.6
12/14/2019 13:00	5.0	0.0	1.7	9.1	2.0
12/14/2019 14:00	4.8	0.0	1.6	8.8	2.0
12/14/2019 15:00	3.2	0.0	1.6	8.8	2.0
12/14/2019 16:00	12.0	1.3	2.0	11.0	2.4
12/14/2019 17:00	12.5	1.3	2.1	11.4	2.5
12/14/2019 18:00	14.6	1.3	2.1	11.4	2.5
12/14/2019 19:00	14.4	1.0	2.0	11.4	2.4
12/14/2019 20:00	14.8	1.0	2.1	11.6	2.6
12/14/2019 21:00	14.8	1.0	2.1	11.6	2.6
12/14/2019 22:00	12.4	1.0	2.0	11.4	2.4
12/14/2019 23:00	11.7	1.0	2.0	10.7	2.4
Average/Sum#:	189.1 #	10.5 #	42.4 #	234.1 #	51.3 #
Minimum:	2.8	0.0	1.4	7.6	1.6
Maximum:	14.8	1.3	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/15/2019 00:00	12.2	1.0	2.0	11.2	2.4
12/15/2019 01:00	12.2	1.0	2.0	11.2	2.4
12/15/2019 02:00	14.5	1.0	2.1	11.4	2.4
12/15/2019 03:00	14.7	1.3	2.1	11.6	2.6
12/15/2019 04:00	14.7	1.3	2.1	11.6	2.6
12/15/2019 05:00	12.4	1.3	2.0	11.4	2.4
12/15/2019 06:00	14.5	1.0	2.1	11.4	2.4
12/15/2019 07:00	11.8	1.0	2.0	10.8	2.4
12/15/2019 08:00	4.8	0.0	1.6	8.8	2.0
12/15/2019 09:00	3.2	0.0	1.6	9.0	2.0
12/15/2019 10:00	3.0	0.0	1.6	8.4	1.8
12/15/2019 11:00	3.2	0.0	1.6	8.6	1.8
12/15/2019 12:00	3.1	0.0	1.6	8.6	1.8
12/15/2019 13:00	3.2	0.0	1.6	9.0	2.0
12/15/2019 14:00	3.2	0.0	1.6	8.6	1.8
12/15/2019 15:00	3.2	0.0	1.6	8.6	1.8
12/15/2019 16:00	12.0	1.3	2.0	11.0	2.4
12/15/2019 17:00	14.5	1.3	2.1	11.4	2.4
12/15/2019 18:00	15.1	1.3	2.1	11.8	2.6
12/15/2019 19:00	15.4	1.0	2.3	12.0	2.6
12/15/2019 20:00	15.2	1.0	2.1	12.0	2.6
12/15/2019 21:00	15.2	1.0	2.1	12.0	2.6
12/15/2019 22:00	14.8	1.0	2.1	11.6	2.6
12/15/2019 23:00	14.6	1.0	2.1	11.4	2.5
Average/Sum#:	250.7 #	17.8 #	46.1 #	253.4 #	54.9 #
Minimum:	3.0	0.0	1.6	8.4	1.8
Maximum:	15.4	1.3	2.3	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/16/2019 00:00	14.8	1.0	2.1	11.6	2.6
12/16/2019 01:00	14.8	1.0	2.1	11.6	2.6
12/16/2019 02:00	14.8	1.0	2.1	11.6	2.6
12/16/2019 03:00	14.8	1.0	2.1	11.7	2.6
12/16/2019 04:00	14.8	1.0	2.1	11.6	2.6
12/16/2019 05:00	14.7	1.3	2.1	11.6	2.6
12/16/2019 06:00	15.4	1.0	2.3	12.1	2.6
12/16/2019 07:00	15.2	1.0	2.1	11.9	2.6
12/16/2019 08:00	12.2	0.7	2.0	11.2	2.4
12/16/2019 09:00	14.2	0.7	2.0	11.2	2.4
12/16/2019 10:00	14.3	1.0	2.0	11.2	2.4
12/16/2019 11:00	14.2	0.7	2.0	11.2	2.4
12/16/2019 12:00	14.2	0.7	2.0	11.2	2.4
12/16/2019 13:00	14.2	0.7	2.0	11.2	2.4
12/16/2019 14:00	14.4	1.0	2.0	11.2	2.4
12/16/2019 15:00	14.4	1.0	2.1	11.4	2.4
12/16/2019 16:00	14.6	1.0	2.1	11.6	2.6
12/16/2019 17:00	15.1	1.0	2.1	11.8	2.6
12/16/2019 18:00	15.2	1.0	2.1	12.0	2.6
12/16/2019 19:00	15.4	1.0	2.3	12.1	2.6
12/16/2019 20:00	15.4	1.0	2.3	12.1	2.6
12/16/2019 21:00	13.1	1.0	2.2	12.0	2.6
12/16/2019 22:00	15.0	1.0	2.1	11.8	2.6
12/16/2019 23:00	14.6	1.0	2.1	11.6	2.6
Average/Sum#:	349.8 #	22.8 #	50.4 #	278.5 #	60.8 #
Minimum:	12.2	0.7	2.0	11.2	2.4
Maximum:	15.4	1.3	2.3	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/17/2019 00:00	14.8	1.0	2.1	11.6	2.6
12/17/2019 01:00	14.9	1.0	2.1	11.6	2.6
12/17/2019 02:00	14.8	1.0	2.1	11.6	2.6
12/17/2019 03:00	14.8	1.0	2.1	11.6	2.6
12/17/2019 04:00	14.7	1.0	2.1	11.6	2.6
12/17/2019 05:00	14.6	1.3	2.1	11.5	2.6
12/17/2019 06:00	15.1	1.3	2.1	11.8	2.6
12/17/2019 07:00	15.0	1.3	2.1	11.8	2.6
12/17/2019 08:00	14.7	1.0	2.1	11.6	2.6
12/17/2019 09:00	12.4	0.7	2.0	11.3	2.4
12/17/2019 10:00	16.3	0.7	2.0	11.2	2.4
12/17/2019 11:00	14.3	1.0	2.0	11.2	2.4
12/17/2019 12:00	14.3	1.0	2.0	11.3	2.4
12/17/2019 13:00	14.4	1.0	2.0	11.3	2.4
12/17/2019 14:00	14.6	1.0	2.1	11.5	2.6
12/17/2019 15:00	14.7	1.0	2.1	11.6	2.6
12/17/2019 16:00	14.9	1.0	2.1	11.8	2.6
12/17/2019 17:00	13.0	1.0	2.1	11.9	2.6
12/17/2019 18:00	13.2	1.0	2.2	12.0	2.7
12/17/2019 19:00	13.1	1.0	2.2	11.9	2.7
12/17/2019 20:00	13.2	1.0	2.2	12.1	2.6
12/17/2019 21:00	15.3	1.0	2.2	12.0	2.6
12/17/2019 22:00	15.2	1.0	2.1	12.0	2.6
12/17/2019 23:00	14.7	1.0	2.1	11.6	2.6
Average/Sum#:	347.0 #	24.3 #	50.3 #	279.4 #	61.6 #
Minimum:	12.4	0.7	2.0	11.2	2.4
Maximum:	16.3	1.3	2.2	12.1	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/18/2019 00:00	14.6	1.0	2.1	11.5	2.6
12/18/2019 01:00	14.7	1.0	2.1	11.6	2.6
12/18/2019 02:00	14.7	1.0	2.1	11.6	2.6
12/18/2019 03:00	14.8	1.0	2.1	11.6	2.6
12/18/2019 04:00	14.9	1.0	2.1	11.6	2.6
12/18/2019 05:00	12.9	1.3	2.1	11.8	2.6
12/18/2019 06:00	15.5	1.3	2.3	12.2	2.6
12/18/2019 07:00	15.3	1.0	2.2	12.0	2.6
12/18/2019 08:00	14.9	1.0	2.1	11.8	2.6
12/18/2019 09:00	14.8	1.0	2.1	11.6	2.6
12/18/2019 10:00	14.8	1.0	2.1	11.6	2.6
12/18/2019 11:00	14.9	1.0	2.1	11.6	2.6
12/18/2019 12:00	12.6	1.0	2.1	11.6	2.6
12/18/2019 13:00	12.6	1.0	2.1	11.6	2.6
12/18/2019 14:00	12.6	1.0	2.1	11.5	2.6
12/18/2019 15:00	12.4	1.0	2.1	11.4	2.4
12/18/2019 16:00	12.7	1.3	2.1	11.6	2.6
12/18/2019 17:00	13.0	1.0	2.1	11.9	2.6
12/18/2019 18:00	15.3	1.0	2.2	12.0	2.6
12/18/2019 19:00	13.1	1.0	2.1	12.0	2.6
12/18/2019 20:00	15.3	1.0	2.2	12.0	2.6
12/18/2019 21:00	13.1	1.0	2.1	12.0	2.6
12/18/2019 22:00	13.0	1.0	2.1	11.9	2.6
12/18/2019 23:00	16.8	1.0	2.1	11.6	2.6
Average/Sum#:	339.3 #	24.9 #	50.9 #	281.6 #	62.2 #
Minimum:	12.4	1.0	2.1	11.4	2.4
Maximum:	16.8	1.3	2.3	12.2	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/19/2019 00:00	14.7	1.0	2.1	11.6	2.6
12/19/2019 01:00	16.9	1.0	2.1	11.6	2.6
12/19/2019 02:00	14.7	1.0	2.1	11.6	2.6
12/19/2019 03:00	14.7	1.0	2.1	11.6	2.6
12/19/2019 04:00	14.7	1.0	2.1	11.6	2.6
12/19/2019 05:00	16.8	1.3	2.1	11.6	2.6
12/19/2019 06:00	15.3	1.3	2.2	12.0	2.6
12/19/2019 07:00	13.0	1.0	2.1	11.9	2.6
12/19/2019 08:00	12.2	0.7	2.0	11.2	2.4
12/19/2019 09:00	12.4	1.0	2.0	11.4	2.4
12/19/2019 10:00	12.2	1.0	2.0	11.2	2.4
12/19/2019 11:00	12.2	1.0	2.0	11.2	2.4
12/19/2019 12:00	12.2	1.0	2.0	11.2	2.4
12/19/2019 13:00	12.2	1.0	2.0	11.2	2.4
12/19/2019 14:00	12.2	1.0	2.0	11.2	2.4
12/19/2019 15:00	12.4	1.0	2.1	11.4	2.4
12/19/2019 16:00	14.6	1.0	2.1	11.6	2.6
12/19/2019 17:00	12.8	1.0	2.1	11.7	2.6
12/19/2019 18:00	12.9	1.0	2.1	11.8	2.6
12/19/2019 19:00	12.9	1.0	2.1	11.8	2.6
12/19/2019 20:00	12.9	1.0	2.1	11.8	2.6
12/19/2019 21:00	12.9	1.0	2.1	11.8	2.6
12/19/2019 22:00	12.6	1.0	2.1	11.6	2.6
12/19/2019 23:00	12.6	1.0	2.1	11.5	2.6
Average/Sum#:	323.0 #	24.3 #	49.8 #	277.1 #	60.8 #
Minimum:	12.2	0.7	2.0	11.2	2.4
Maximum:	16.9	1.3	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/20/2019 00:00	12.6	1.0	2.1	11.6	2.6
12/20/2019 01:00	12.6	1.0	2.1	11.5	2.6
12/20/2019 02:00	12.6	1.3	2.1	11.6	2.6
12/20/2019 03:00	12.2	1.0	2.0	11.2	2.4
12/20/2019 04:00	12.5	1.3	2.1	11.4	2.5
12/20/2019 05:00	12.6	1.3	2.1	11.5	2.6
12/20/2019 06:00	12.8	1.3	2.1	11.7	2.6
12/20/2019 07:00	12.4	1.0	2.0	11.4	2.4
12/20/2019 08:00	12.2	1.0	2.0	11.2	2.4
12/20/2019 09:00	12.2	1.0	2.0	11.2	2.4
12/20/2019 10:00	11.6	1.0	2.0	10.7	2.4
12/20/2019 11:00	4.9	0.0	1.6	9.0	2.0
12/20/2019 12:00	4.8	0.0	1.6	8.8	2.0
12/20/2019 13:00	5.0	0.0	1.7	9.1	2.0
12/20/2019 14:00	3.2	0.0	1.6	8.6	1.8
12/20/2019 15:00	12.2	1.6	2.0	11.2	2.4
12/20/2019 16:00	12.5	1.3	2.1	11.4	2.5
12/20/2019 17:00	12.8	1.3	2.1	11.7	2.6
12/20/2019 18:00	13.0	1.3	2.1	11.9	2.6
12/20/2019 19:00	12.7	1.3	2.1	11.6	2.6
12/20/2019 20:00	14.8	1.3	2.1	11.6	2.6
12/20/2019 21:00	12.7	1.0	2.1	11.6	2.6
12/20/2019 22:00	12.7	1.3	2.1	11.6	2.6
12/20/2019 23:00	14.8	1.3	2.1	11.6	2.6
Average/Sum#:	272.4 #	23.9 #	47.9 #	264.7 #	58.4 #
Minimum:	3.2	0.0	1.6	8.6	1.8
Maximum:	14.8	1.6	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/21/2019 00:00	14.5	1.0	2.1	11.4	2.5
12/21/2019 01:00	12.3	1.0	2.0	11.3	2.4
12/21/2019 02:00	12.6	1.3	2.1	11.6	2.6
12/21/2019 03:00	14.7	1.3	2.1	11.6	2.6
12/21/2019 04:00	12.6	1.3	2.1	11.6	2.6
12/21/2019 05:00	12.7	1.3	2.1	11.6	2.6
12/21/2019 06:00	12.5	1.3	2.1	11.4	2.5
12/21/2019 07:00	14.8	1.3	2.1	11.6	2.6
12/21/2019 08:00	14.8	1.3	2.1	11.6	2.6
12/21/2019 09:00	14.7	1.3	2.1	11.6	2.6
12/21/2019 10:00	14.5	1.3	2.1	11.4	2.4
12/21/2019 11:00	12.2	1.0	2.0	11.2	2.4
12/21/2019 12:00	12.2	1.0	2.0	11.2	2.4
12/21/2019 13:00	12.2	1.3	2.0	11.2	2.4
12/21/2019 14:00	14.5	1.3	2.0	11.4	2.4
12/21/2019 15:00	12.4	1.3	2.0	11.4	2.4
12/21/2019 16:00	12.2	1.3	2.0	11.2	2.4
12/21/2019 17:00	12.2	1.3	2.0	11.2	2.4
12/21/2019 18:00	12.4	1.3	2.0	11.4	2.4
12/21/2019 19:00	14.5	1.3	2.1	11.4	2.4
12/21/2019 20:00	16.7	1.3	2.1	11.4	2.5
12/21/2019 21:00	14.5	1.3	2.1	11.4	2.4
12/21/2019 22:00	12.6	1.3	2.1	11.6	2.6
12/21/2019 23:00	16.9	1.3	2.1	11.6	2.6
Average/Sum#:	326.2 #	30.0 #	49.5 #	274.3 #	59.7 #
Minimum:	12.2	1.0	2.0	11.2	2.4
Maximum:	16.9	1.3	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/22/2019 00:00	14.7	1.3	2.1	11.6	2.6
12/22/2019 01:00	14.5	1.3	2.0	11.4	2.4
12/22/2019 02:00	12.7	1.3	2.1	11.6	2.6
12/22/2019 03:00	12.7	1.3	2.1	11.6	2.6
12/22/2019 04:00	14.6	1.3	2.1	11.4	2.5
12/22/2019 05:00	14.5	1.6	2.1	11.4	2.4
12/22/2019 06:00	14.8	1.3	2.1	11.6	2.6
12/22/2019 07:00	12.7	1.3	2.1	11.6	2.6
12/22/2019 08:00	12.6	1.3	2.1	11.6	2.6
12/22/2019 09:00	16.7	1.3	2.1	11.5	2.6
12/22/2019 10:00	14.7	1.3	2.1	11.5	2.6
12/22/2019 11:00	14.5	1.3	2.0	11.4	2.4
12/22/2019 12:00	12.4	0.6	2.0	11.3	2.4
12/22/2019 13:00	14.7	0.6	2.1	11.5	2.6
12/22/2019 14:00	14.5	0.6	2.0	11.4	2.4
12/22/2019 15:00	12.4	0.6	2.0	11.3	2.4
12/22/2019 16:00	12.1	0.6	2.0	11.1	2.4
12/22/2019 17:00	14.2	0.6	2.0	11.2	2.4
12/22/2019 18:00	12.2	0.6	2.0	11.2	2.4
12/22/2019 19:00	12.2	0.6	2.0	11.2	2.4
12/22/2019 20:00	14.4	0.6	2.0	11.3	2.4
12/22/2019 21:00	12.3	0.7	2.1	11.3	2.4
12/22/2019 22:00	12.2	0.7	2.0	11.2	2.4
12/22/2019 23:00	12.4	0.7	2.0	11.3	2.4
Average/Sum#:	325.7 #	23.4 #	49.2 #	273.5 #	59.5 #
Minimum:	12.1	0.6	2.0	11.1	2.4
Maximum:	16.7	1.6	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/23/2019 00:00	14.4	0.7	2.0	11.3	2.4
12/23/2019 01:00	12.2	0.7	2.0	11.2	2.4
12/23/2019 02:00	12.2	0.7	2.0	11.2	2.4
12/23/2019 03:00	12.4	0.7	2.0	11.3	2.4
12/23/2019 04:00	12.2	0.7	2.0	11.2	2.4
12/23/2019 05:00	12.2	0.7	2.0	11.2	2.4
12/23/2019 06:00	14.4	0.7	2.0	11.2	2.4
12/23/2019 07:00	12.4	0.7	2.0	11.3	2.4
12/23/2019 08:00	12.9	0.3	2.1	11.8	2.6
12/23/2019 09:00	14.8	0.3	2.1	11.7	2.6
12/23/2019 10:00	14.7	0.3	2.1	11.6	2.6
12/23/2019 11:00	14.9	0.3	2.1	11.6	2.6
12/23/2019 12:00	14.9	0.3	2.1	11.6	2.6
12/23/2019 13:00	14.4	0.3	2.0	11.4	2.4
12/23/2019 14:00	14.6	0.3	2.1	11.5	2.6
12/23/2019 15:00	14.4	0.3	2.0	11.4	2.4
12/23/2019 16:00	14.4	0.3	2.0	11.3	2.4
12/23/2019 17:00	14.3	0.3	2.0	11.2	2.4
12/23/2019 18:00	14.3	0.3	2.0	11.2	2.4
12/23/2019 19:00	14.5	0.3	2.0	11.4	2.4
12/23/2019 20:00	14.9	0.3	2.1	11.7	2.6
12/23/2019 21:00	14.7	0.3	2.1	11.6	2.6
12/23/2019 22:00	14.7	0.3	2.1	11.5	2.6
12/23/2019 23:00	14.7	0.7	2.1	11.6	2.6
Average/Sum#:	334.5 #	10.8 #	49.0 #	274.0 #	59.6 #
Minimum:	12.2	0.3	2.0	11.2	2.4
Maximum:	14.9	0.7	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/24/2019 00:00	14.7	0.7	2.1	11.5	2.6
12/24/2019 01:00	12.3	0.7	2.0	11.2	2.4
12/24/2019 02:00	12.2	0.7	2.0	11.2	2.4
12/24/2019 03:00	12.2	0.7	2.0	11.2	2.4
12/24/2019 04:00	12.2	0.7	2.0	11.2	2.4
12/24/2019 05:00	12.2	0.7	2.0	11.2	2.4
12/24/2019 06:00	12.4	1.0	2.1	11.4	2.4
12/24/2019 07:00	12.4	0.7	2.0	11.3	2.4
12/24/2019 08:00	12.3	0.7	2.0	11.3	2.4
12/24/2019 09:00	12.2	0.7	2.0	11.2	2.4
12/24/2019 10:00	12.2	0.7	2.0	11.2	2.4
12/24/2019 11:00	12.2	0.7	2.0	11.2	2.4
12/24/2019 12:00	12.3	0.7	2.0	11.2	2.4
12/24/2019 13:00	12.2	0.7	2.0	11.2	2.4
12/24/2019 14:00	12.2	0.7	2.0	11.2	2.4
12/24/2019 15:00	14.5	0.7	2.1	11.4	2.4
12/24/2019 16:00	12.2	0.7	2.0	11.2	2.4
12/24/2019 17:00	12.4	0.7	2.0	11.3	2.4
12/24/2019 18:00	12.4	0.7	2.0	11.3	2.4
12/24/2019 19:00	12.2	0.7	2.0	11.2	2.4
12/24/2019 20:00	12.2	0.7	2.0	11.2	2.4
12/24/2019 21:00	12.2	0.7	2.0	11.2	2.4
12/24/2019 22:00	12.4	0.7	2.0	11.3	2.4
12/24/2019 23:00	12.2	0.7	2.0	11.2	2.4
Average/Sum#:	298.9 #	17.1 #	48.3 #	270.0 #	57.8 #
Minimum:	12.2	0.7	2.0	11.2	2.4
Maximum:	14.7	1.0	2.1	11.5	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/25/2019 00:00	12.4	0.7	2.0	11.4	2.4
12/25/2019 01:00	14.5	0.7	2.1	11.4	2.4
12/25/2019 02:00	14.7	0.7	2.1	11.5	2.5
12/25/2019 03:00	12.2	0.7	2.0	11.2	2.4
12/25/2019 04:00	12.3	0.7	2.0	11.2	2.4
12/25/2019 05:00	12.2	0.7	2.0	11.2	2.4
12/25/2019 06:00	12.3	1.0	2.0	11.2	2.4
12/25/2019 07:00	14.6	0.7	2.1	11.5	2.5
12/25/2019 08:00	12.2	0.7	2.0	11.2	2.4
12/25/2019 09:00	12.3	0.7	2.0	11.3	2.4
12/25/2019 10:00	12.2	0.7	2.0	11.2	2.4
12/25/2019 11:00	12.2	0.7	2.0	11.2	2.4
12/25/2019 12:00	12.3	0.7	2.0	11.3	2.4
12/25/2019 13:00	14.3	0.7	2.0	11.2	2.4
12/25/2019 14:00	12.4	0.7	2.0	11.4	2.4
12/25/2019 15:00	14.5	0.7	2.0	11.4	2.4
12/25/2019 16:00	12.4	0.7	2.1	11.4	2.4
12/25/2019 17:00	14.3	0.7	2.0	11.2	2.4
12/25/2019 18:00	12.4	0.7	2.0	11.4	2.4
12/25/2019 19:00	14.7	0.7	2.1	11.6	2.6
12/25/2019 20:00	12.6	0.7	2.1	11.5	2.6
12/25/2019 21:00	12.4	0.7	2.1	11.4	2.4
12/25/2019 22:00	12.4	0.7	2.0	11.4	2.4
12/25/2019 23:00	12.4	0.7	2.1	11.4	2.4
Average/Sum#:	311.2 #	17.1 #	48.8 #	272.1 #	58.2 #
Minimum:	12.2	0.7	2.0	11.2	2.4
Maximum:	14.7	1.0	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/26/2019 00:00	14.5	0.7	2.0	11.4	2.4
12/26/2019 01:00	12.5	0.7	2.1	11.5	2.5
12/26/2019 02:00	10.7	0.3	2.1	11.7	2.5
12/26/2019 03:00	10.7	0.3	2.1	11.7	2.5
12/26/2019 04:00	10.7	0.3	2.1	11.6	2.5
12/26/2019 05:00	12.4	0.7	2.1	11.3	2.5
12/26/2019 06:00	14.3	0.7	2.0	11.2	2.4
12/26/2019 07:00	14.6	0.7	2.1	11.4	2.5
12/26/2019 08:00	15.2	0.3	2.1	12.0	2.6
12/26/2019 09:00	14.7	0.3	2.1	11.6	2.6
12/26/2019 10:00	14.7	0.3	2.1	11.6	2.6
12/26/2019 11:00	14.5	0.3	2.0	11.4	2.4
12/26/2019 12:00	11.7	0.4	2.5	13.1	2.9
12/26/2019 13:00	11.8	0.4	2.6	13.3	2.9
12/26/2019 14:00	11.8	0.4	2.6	13.3	2.9
12/26/2019 15:00	11.9	0.4	2.6	13.3	2.9
12/26/2019 16:00	12.0	0.4	2.6	13.4	3.0
12/26/2019 17:00	12.1	0.4	2.6	13.5	3.0
12/26/2019 18:00	12.2	0.4	2.6	13.6	3.0
12/26/2019 19:00	12.2	0.4	2.6	13.6	3.0
12/26/2019 20:00	12.2	0.4	2.6	13.6	3.0
12/26/2019 21:00	9.9	0.4	2.6	13.5	3.0
12/26/2019 22:00	9.9	0.4	2.6	13.4	3.0
12/26/2019 23:00	12.0	0.4	2.6	13.4	3.0
Average/Sum#:	299.2 #	10.4 #	56.0 #	299.4 #	65.6 #
Minimum:	9.9	0.3	2.0	11.2	2.4
Maximum:	15.2	0.7	2.6	13.6	3.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/27/2019 00:00	9.9	0.4	2.6	13.4	3.0
12/27/2019 01:00	12.0	0.4	2.6	13.4	3.0
12/27/2019 02:00	12.0	0.4	2.6	13.4	3.0
12/27/2019 03:00	11.9	0.5	2.6	13.4	2.9
12/27/2019 04:00	12.0	0.5	2.6	13.4	2.9
12/27/2019 05:00	12.0	0.5	2.6	13.4	2.9
12/27/2019 06:00	12.0	0.5	2.6	13.4	2.9
12/27/2019 07:00	14.9	0.5	2.6	13.4	2.9
12/27/2019 08:00	9.5	0.5	2.5	12.8	2.9
12/27/2019 09:00	3.4	0.3	1.7	9.3	2.0
12/27/2019 10:00	3.4	0.3	1.7	9.2	2.0
12/27/2019 11:00	3.2	0.3	1.6	9.0	2.0
12/27/2019 12:00	3.2	0.3	1.6	9.0	2.0
12/27/2019 13:00	3.4	0.0	1.7	9.3	2.0
12/27/2019 14:00	3.3	0.0	1.7	9.1	2.0
12/27/2019 15:00	2.8	0.0	1.4	7.8	1.7
12/27/2019 16:00	3.2	0.0	1.6	8.9	2.0
12/27/2019 17:00	3.4	0.3	1.7	9.4	2.0
12/27/2019 18:00	9.7	0.9	2.6	13.1	2.9
12/27/2019 19:00	12.0	0.9	2.6	13.4	3.0
12/27/2019 20:00	12.1	0.9	2.6	13.5	3.0
12/27/2019 21:00	12.0	0.9	2.6	13.4	3.0
12/27/2019 22:00	12.0	0.4	2.6	13.4	3.0
12/27/2019 23:00	11.9	0.5	2.6	13.4	2.9
Average/Sum#:	81.8 #	3.7 #	53.6 #	281.2 #	61.9 #
Minimum:	9.9	0.4	1.4	7.8	1.7
Maximum:	12.0	0.5	2.6	13.5	3.0
%SI	70.83	66.67	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/28/2019 00:00	11.8	0.5	2.6	13.3	2.9
12/28/2019 01:00	11.8	0.5	2.6	13.3	2.9
12/28/2019 02:00	11.8	0.5	2.6	13.2	2.9
12/28/2019 03:00	11.8	0.5	2.6	13.2	2.9
12/28/2019 04:00	12.8	0.5	2.6	13.3	2.9
12/28/2019 05:00	9.9	0.5	2.6	13.3	2.9
12/28/2019 06:00	11.8	0.5	2.6	13.3	2.9
12/28/2019 07:00	11.9	0.5	2.6	13.4	2.9
12/28/2019 08:00	11.6	0.5	2.6	13.0	2.9
12/28/2019 09:00	3.4	0.3	1.7	9.2	2.0
12/28/2019 10:00	3.2	0.3	1.6	8.9	2.0
12/28/2019 11:00	3.4	0.3	1.7	9.1	2.0
12/28/2019 12:00	3.4	0.3	1.7	9.3	2.0
12/28/2019 13:00	3.3	0.0	1.6	9.1	2.0
12/28/2019 14:00	3.4	0.0	1.7	9.2	2.0
12/28/2019 15:00	3.2	0.0	1.6	8.9	2.0
12/28/2019 16:00	9.8	1.4	2.6	13.2	2.9
12/28/2019 17:00	12.0	1.3	2.6	13.4	3.0
12/28/2019 18:00	15.2	1.0	2.2	11.9	2.6
12/28/2019 19:00	16.9	1.0	2.1	11.6	2.6
12/28/2019 20:00	14.8	1.3	2.1	11.6	2.6
12/28/2019 21:00	14.6	1.0	2.1	11.4	2.5
12/28/2019 22:00	14.7	0.7	2.1	11.6	2.6
12/28/2019 23:00	16.8	0.7	2.1	11.6	2.6
Average/Sum#:	0.0 #	0.0 #	52.9 #	279.3 #	61.5 #
Minimum:	0.0	0.0	1.6	8.9	2.0
Maximum:	0.0	0.0	2.6	13.4	3.0
%SI	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/29/2019 00:00	12.6	0.7	2.1	11.5	2.6
12/29/2019 01:00	14.8	0.7	2.1	11.6	2.6
12/29/2019 02:00	12.5	0.7	2.1	11.4	2.5
12/29/2019 03:00	12.6	1.0	2.1	11.6	2.6
12/29/2019 04:00	12.6	0.7	2.1	11.5	2.6
12/29/2019 05:00	12.6	1.0	2.1	11.5	2.6
12/29/2019 06:00	12.5	1.0	2.1	11.4	2.5
12/29/2019 07:00	12.2	0.6	2.0	11.2	2.4
12/29/2019 08:00	3.4	0.0	1.7	9.2	2.0
12/29/2019 09:00	3.2	0.0	1.6	8.8	2.0
12/29/2019 10:00	3.4	0.0	1.7	9.3	2.0
12/29/2019 11:00	3.4	0.0	1.7	9.1	2.0
12/29/2019 12:00	3.4	0.0	1.7	9.3	2.0
12/29/2019 13:00	3.2	0.0	1.6	8.9	2.0
12/29/2019 14:00	3.4	0.0	1.7	9.2	2.0
12/29/2019 15:00	7.4	0.7	1.9	10.3	2.2
12/29/2019 16:00	12.4	1.0	2.0	11.3	2.4
12/29/2019 17:00	14.5	0.7	2.1	11.4	2.4
12/29/2019 18:00	14.8	0.7	2.1	11.6	2.6
12/29/2019 19:00	14.8	0.7	2.1	11.6	2.6
12/29/2019 20:00	14.8	0.7	2.1	11.6	2.6
12/29/2019 21:00	14.8	0.7	2.1	11.6	2.6
12/29/2019 22:00	14.8	0.7	2.1	11.6	2.6
12/29/2019 23:00	14.6	0.7	2.1	11.4	2.5
Average/Sum#:	171.0 #	8.2 #	47.0 #	257.9 #	56.9 #
Minimum:	3.2	0.0	1.6	8.8	2.0
Maximum:	14.8	1.0	2.1	11.6	2.6
%SI	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/30/2019 00:00	14.4	0.7	2.0	11.4	2.4
12/30/2019 01:00	14.4	0.7	2.0	11.4	2.4
12/30/2019 02:00	14.2	0.7	2.0	11.2	2.4
12/30/2019 03:00	14.3	0.7	2.0	11.2	2.4
12/30/2019 04:00	12.2	0.7	2.0	11.2	2.4
12/30/2019 05:00	14.3	0.7	2.0	11.2	2.4
12/30/2019 06:00	14.4	0.7	2.0	11.4	2.4
12/30/2019 07:00	14.8	0.7	2.1	11.6	2.6
12/30/2019 08:00	14.6	0.7	2.1	11.5	2.6
12/30/2019 09:00	14.4	0.3	2.0	11.3	2.4
12/30/2019 10:00	14.2	0.3	2.0	11.2	2.4
12/30/2019 11:00	16.4	0.3	2.0	11.2	2.4
12/30/2019 12:00	14.4	0.3	2.0	11.2	2.4
12/30/2019 13:00	14.4	0.3	2.1	11.4	2.4
12/30/2019 14:00	16.4	0.0	2.0	11.4	2.4
12/30/2019 15:00	16.6	0.0	2.0	11.4	2.4
12/30/2019 16:00	16.6	0.3	2.1	11.4	2.4
12/30/2019 17:00	16.7	0.3	2.1	11.5	2.6
12/30/2019 18:00	12.7	0.3	2.1	11.6	2.6
12/30/2019 19:00	12.7	0.3	2.1	11.6	2.6
12/30/2019 20:00	14.7	0.3	2.1	11.6	2.6
12/30/2019 21:00	14.5	0.3	2.1	11.4	2.4
12/30/2019 22:00	14.6	0.3	2.1	11.5	2.5
12/30/2019 23:00	14.5	0.3	2.1	11.4	2.4
Average/Sum#:	351.4 #	10.2 #	49.1 #	273.2 #	58.9 #
Minimum:	12.2	0.0	2.0	11.2	2.4
Maximum:	16.7	0.7	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/31/2019 00:00	14.3	0.3	2.0	11.2	2.4
12/31/2019 01:00	13.6	0.3	2.0	10.6	2.4
12/31/2019 02:00	13.5	0.3	1.9	10.6	2.4
12/31/2019 03:00	13.6	0.3	2.0	10.8	2.4
12/31/2019 04:00	14.3	0.3	2.0	11.2	2.4
12/31/2019 05:00	12.3	0.3	2.0	11.2	2.4
12/31/2019 06:00	14.2	0.3	2.0	11.2	2.4
12/31/2019 07:00	14.2	0.3	2.0	11.2	2.4
12/31/2019 08:00	13.3	0.3	1.9	10.4	2.2
12/31/2019 09:00	3.0	0.0	1.6	8.4	1.8
12/31/2019 10:00	3.2	0.0	1.6	8.9	2.0
12/31/2019 11:00	3.2	0.0	1.6	8.8	1.9
12/31/2019 12:00	3.2	0.0	1.6	8.6	1.8
12/31/2019 13:00	3.4	0.0	1.7	9.2	2.0
12/31/2019 14:00	3.2	0.0	1.6	8.6	1.8
12/31/2019 15:00	3.2	0.0	1.6	8.7	1.9
12/31/2019 16:00	12.0	1.0	2.0	11.0	2.4
12/31/2019 17:00	14.2	1.0	2.0	11.2	2.4
12/31/2019 18:00	14.2	1.0	2.0	11.2	2.4
12/31/2019 19:00	14.2	1.0	2.0	11.2	2.4
12/31/2019 20:00	14.2	1.0	2.0	11.2	2.4
12/31/2019 21:00	14.3	1.3	2.0	11.2	2.4
12/31/2019 22:00	12.2	1.3	2.0	11.2	2.4
12/31/2019 23:00	12.2	1.3	2.0	11.2	2.4
Average/Sum#:	253.2 #	11.6 #	45.1 #	249.0 #	53.8 #
Minimum:	3.0	0.0	1.6	8.4	1.8
Maximum:	14.3	1.3	2.0	11.2	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Excess Emission Report

CT1 and CT2 CO Lb/Day

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 12:43 **Location:** Maxwell, CA

Tag Name: ALL_CO_Lb_1D
Total Operating Time: 91.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 1.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**91.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 CO Lb/Hr

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 12:43 **Location:** Maxwell, CA

Tag Name: ALL_CO_Lb_1H
Total Operating Time: 2,145.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 63.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,145.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 NOx Lb/Day

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 12:44 **Location:** Maxwell, CA

Tag Name: ALL_NOx_Lb_1D
Total Operating Time: 91.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 1.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**91.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 NOx Lb/Hr

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:45 **Location:** Maxwell, CA

Tag Name: ALL_NOx_Lb_1H

Total Operating Time: 2,145.00 Hour(s) **No Exclusions Allowed**

Non-Operating Time: 63.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,145.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 PM10 Lb/Day

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 12:46 **Location:** Maxwell, CA

Tag Name: ALL_PM10_Lb_1D
Total Operating Time: 91.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 1.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**91.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 PM10 Lb/Hr

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 12:46 **Location:** Maxwell, CA

Tag Name: ALL_PM10_Lb_1H
Total Operating Time: 2,145.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 63.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,145.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 SO2 Lb/Day

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 12:47 **Location:** Maxwell, CA

Tag Name: ALL_SO2_Lb_1D
Total Operating Time: 91.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 1.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**91.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 SO2 Lb/Hr

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 12:47 **Location:** Maxwell, CA

Tag Name: ALL_SO2_Lb_1H
Total Operating Time: 2,145.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 63.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,145.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 VOC Lb/Day

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 12:48 **Location:** Maxwell, CA

Tag Name: ALL_VOC_Lb_1D
Total Operating Time: 91.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 1.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**91.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 VOC Lb/Hr

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:49 **Location:** Maxwell, CA

Tag Name: ALL_VOC_Lb_1H

Total Operating Time: 2,145.00 Hour(s) **No Exclusions Allowed**

Non-Operating Time: 63.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,145.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 11
CGA/Linearity

FCD: AQ-19
Title V: #13

Cylinder Gas Audit

Facility:	COLUSA GENERATION			Instrument Name:	CT1_CODualRg_P_Instrum
Unit/Stack:	CT1	Test Date:	10/16/2019	Performance Spec:	15 Pct
Parameter/Scale:	CO / Low	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
10/16/2019	11:49	L	20	4.700	4.400	23.5 %
10/16/2019	11:55	M	20	10.900	10.900	54.5 %
10/16/2019	12:04	L	20	4.700	4.300	23.5 %
10/16/2019	12:10	M	20	10.900	10.800	54.5 %
10/16/2019	12:18	L	20	4.700	4.300	23.5 %
10/16/2019	12:24	M	20	10.900	10.800	54.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	4.700	4.333	Std	**7.8**
M	10.900	10.833	Std	**0.6**

Cylinder Gas Audit

Facility:	COLUSA GENERATION			Instrument Name:	CT2_CODualRg_P_Instrum
Unit/Stack:	CT2	Test Date:	10/14/2019	Performance Spec:	15 Pct
Parameter/Scale:	CO / Low	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
10/14/2019	11:50	L	20	4.700	4.300	23.5 %
10/14/2019	11:56	M	20	10.800	10.700	54.0 %
10/14/2019	12:05	L	20	4.700	4.300	23.5 %
10/14/2019	12:11	M	20	10.800	10.700	54.0 %
10/14/2019	12:19	L	20	4.700	4.200	23.5 %
10/14/2019	12:25	M	20	10.800	10.700	54.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	4.700	4.267	Std	**9.2**
M	10.800	10.700	Std	**0.9**

Cylinder Gas Audit

Facility:	COLUSA GENERATION			Instrument Name:	CT1_CODualRg_P_Instrum
Unit/Stack:	CT1	Test Date:	10/16/2019	Performance Spec:	15 Pct
Parameter/Scale:	CO / High	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
10/16/2019	13:23	L	2000	505.500	481.700	25.3 %
10/16/2019	13:29	M	2000	1135.000	1149.400	56.8 %
10/16/2019	13:38	L	2000	505.500	481.700	25.3 %
10/16/2019	13:44	M	2000	1135.000	1148.900	56.8 %
10/16/2019	13:52	L	2000	505.500	482.200	25.3 %
10/16/2019	13:58	M	2000	1135.000	1150.000	56.8 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	505.500	481.867	Std	**4.7**
M	1135.000	1149.433	Std	**1.3**

Cylinder Gas Audit

Facility:	COLUSA GENERATION			Instrument Name:	CT2_CODualRg_P_Instrum
Unit/Stack:	CT2	Test Date:	10/14/2019	Performance Spec:	15 Pct
Parameter/Scale:	CO / High	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
10/14/2019	14:26	L	2000	500.500	492.200	25.0 %
10/14/2019	14:32	M	2000	1148.000	1156.900	57.4 %
10/14/2019	14:41	L	2000	500.500	492.500	25.0 %
10/14/2019	14:47	M	2000	1148.000	1156.100	57.4 %
10/14/2019	14:55	L	2000	500.500	492.500	25.0 %
10/14/2019	15:01	M	2000	1148.000	1156.100	57.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	500.500	492.400	Std	**1.6**
M	1148.000	1156.367	Std	**0.7**

Cylinder Gas Audit

Facility:	COLUSA GENERATION			Instrument Name:	CT1_NOXDualRg_P_Instru
Unit/Stack:	CT1	Test Date:	10/16/2019	Performance Spec:	15 Pct
Parameter/Scale:	NOX / Low	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
10/16/2019	10:23	L	10	2.400	1.800	24.0 %
10/16/2019	10:29	M	10	5.500	5.100	55.0 %
10/16/2019	10:38	L	10	2.400	1.900	24.0 %
10/16/2019	10:44	M	10	5.500	5.100	55.0 %
10/16/2019	10:52	L	10	2.400	1.900	24.0 %
10/16/2019	10:58	M	10	5.500	5.200	55.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.400	1.867	Alt	**0.5**
M	5.500	5.133	Std	**6.7**

Cylinder Gas Audit

Facility:	COLUSA GENERATION			Instrument Name:	CT2_NOXDualRg_P_Instru
Unit/Stack:	CT2	Test Date:	10/14/2019	Performance Spec:	15 Pct
Parameter/Scale:	NOX / Low	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
10/14/2019	12:51	L	10	2.600	2.200	26.0 %
10/14/2019	12:57	M	10	5.200	4.900	52.0 %
10/14/2019	13:06	L	10	2.600	2.200	26.0 %
10/14/2019	13:12	M	10	5.200	5.000	52.0 %
10/14/2019	13:20	L	10	2.600	2.200	26.0 %
10/14/2019	13:26	M	10	5.200	5.000	52.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.600	2.200	Alt	**0.4**
M	5.200	4.967	Std	**4.5**

Cylinder Gas Audit

10/16/2019

Facility:	COLUSA GENERATION			Instrument Name:	CT1_NOXInlet_P_Instrum
Unit/Stack:	CT1	Test Date:	10/15/2019	Performance Spec:	15 Pct
Parameter/Scale:	NOX / High	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
10/15/2019	14:22	L	200	50.700	50.500	25.4 %
10/15/2019	14:28	M	200	110.900	112.000	55.5 %
10/15/2019	14:37	L	200	50.700	50.600	25.4 %
10/15/2019	14:43	M	200	110.900	112.000	55.5 %
10/15/2019	14:51	L	200	50.700	50.800	25.4 %
10/15/2019	14:57	M	200	110.900	111.600	55.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.700	50.633	Std	**0.1**
M	110.900	111.867	Std	**0.9**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: NOX / High

Test Date: 10/15/2019
Test Result: **Pass**

Instrument Name: CT2_NOXInlet_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
10/15/2019	10:44	L	200	51.200	50.800	25.6 %
10/15/2019	10:50	M	200	109.900	110.500	55.0 %
10/15/2019	10:59	L	200	51.200	51.200	25.6 %
10/15/2019	11:05	M	200	109.900	110.500	55.0 %
10/15/2019	11:13	L	200	51.200	51.400	25.6 %
10/15/2019	11:19	M	200	109.900	110.400	55.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	51.200	51.133	Std	**0.1**
M	109.900	110.467	Std	**0.5**

Cylinder Gas Audit

Facility:	COLUSA GENERATION			Instrument Name:	CT1_O2DInlet_P_Instrum
Unit/Stack:	CT1	Test Date:	10/16/2019	Performance Spec:	15 Pct
Parameter/Scale:	O2D / High	Test Result:	**Pass**	Alternate Spec:	0 Pct

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
10/16/2019	09:23	L	25	5.700	5.800	22.8 %
10/16/2019	09:29	M	25	13.100	13.100	52.4 %
10/16/2019	09:38	L	25	5.700	5.800	22.8 %
10/16/2019	09:44	M	25	13.100	13.100	52.4 %
10/16/2019	09:52	L	25	5.700	5.800	22.8 %
10/16/2019	09:58	M	25	13.100	13.100	52.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	5.700	5.800	Std	**1.8**
M	13.100	13.100	Std	**0.0**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: O2D / High

Test Date: 10/15/2019
Test Result: **Pass**

Instrument Name: CT2_O2DInlet_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 0 Pct

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
10/15/2019	12:23	L	25	5.700	5.700	22.8 %
10/15/2019	12:29	M	25	13.000	13.000	52.0 %
10/15/2019	12:38	L	25	5.700	5.700	22.8 %
10/15/2019	12:44	M	25	13.000	13.000	52.0 %
10/15/2019	12:52	L	25	5.700	5.700	22.8 %
10/15/2019	12:58	M	25	13.000	13.000	52.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	5.700	5.700	Std	**0.0**
M	13.000	13.000	Std	**0.0**

Linearity Report

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT1	Component ID:	A11	ReasonForTest:	QA
		Component Type:	NOXA	Grace Period:	0
Instrument Name:	CT1_NOXDualRg_P_Instrume	Test End Date/Time:	10/15/2019	Scale:	High
Performance Spec:	5 %	Test No.:	91	Highest Error:	2.0
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/15/2019	1231	L	200.0	50.7	49.3		25.4 %
10/15/2019	1237	M	200.0	110.9	110.3		55.5 %
10/15/2019	1243	H	200.0	180.0	179.7		90.0 %
10/15/2019	1252	L	200.0	50.7	49.9		25.4 %
10/15/2019	1258	M	200.0	110.9	110.5		55.5 %
10/15/2019	1304	H	200.0	180.0	179.3		90.0 %
10/15/2019	1312	L	200.0	50.7	49.9		25.4 %
10/15/2019	1318	M	200.0	110.9	110.4		55.5 %
10/15/2019	1324	H	200.0	180.0	179.1		90.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	50.700	49.700	No	**2.0**
M	110.900	110.400	No	**0.5**
H	180.000	179.367	No	**0.4**

Linearity Report

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT1	Component ID:	A12	ReasonForTest:	QA
		Component Type:	O2D	Grace Period:	0
Instrument Name:	CT1_O2D_P_Instrument	Test End Date/Time:	10/14/2019	Scale:	High
Performance Spec:	5 %	Test No.:	90	Highest Error:	3.6
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/14/2019	1423	L	25.0	5.5	5.7		22.0 %
10/14/2019	1429	M	25.0	13.1	13.2		52.4 %
10/14/2019	1435	H	25.0	21.2	21.3		84.8 %
10/14/2019	1444	L	25.0	5.5	5.7		22.0 %
10/14/2019	1450	M	25.0	13.1	13.1		52.4 %
10/14/2019	1456	H	25.0	21.2	21.3		84.8 %
10/14/2019	1504	L	25.0	5.5	5.7		22.0 %
10/14/2019	1510	M	25.0	13.1	13.1		52.4 %
10/14/2019	1516	H	25.0	21.2	21.3		84.8 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.700	No	**3.6**
M	13.100	13.133	No	**0.3**
H	21.200	21.300	No	**0.5**

Linearity Report

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT2	Component ID:	A21	ReasonForTest:	QA
		Component Type:	NOXA	Grace Period:	0
Instrument Name:	CT2_NOXDualRg_P_Instrume	Test End Date/Time:	10/14/2019	Scale:	High
Performance Spec:	5 %	Test No.:	90	Highest Error:	1.2
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/14/2019	0730	L	200.0	51.2	50.5		25.6 %
10/14/2019	0736	M	200.0	109.9	109.0		55.0 %
10/14/2019	0742	H	200.0	182.1	180.6		91.1 %
10/14/2019	0751	L	200.0	51.2	50.7		25.6 %
10/14/2019	0757	M	200.0	109.9	109.0		55.0 %
10/14/2019	0803	H	200.0	182.1	180.7		91.1 %
10/14/2019	0811	L	200.0	51.2	50.6		25.6 %
10/14/2019	0817	M	200.0	109.9	108.9		55.0 %
10/14/2019	0823	H	200.0	182.1	180.8		91.1 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.200	50.600	No	**1.2**
M	109.900	108.967	No	**0.8**
H	182.100	180.700	No	**0.8**

Linearity Report

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT2	Component ID:	A22	ReasonForTest:	QA
		Component Type:	O2D	Grace Period:	0
Instrument Name:	CT2_O2D_P_Instrument	Test End Date/Time:	10/14/2019	Scale:	High
Performance Spec:	5 %	Test No.:	91	Highest Error:	0.0
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/14/2019	0931	L	25.0	5.7	5.7		22.8 %
10/14/2019	0937	M	25.0	13.0	13.0		52.0 %
10/14/2019	0943	H	25.0	21.4	21.4		85.6 %
10/14/2019	0952	L	25.0	5.7	5.7		22.8 %
10/14/2019	0958	M	25.0	13.0	13.0		52.0 %
10/14/2019	1004	H	25.0	21.4	21.4		85.6 %
10/14/2019	1012	L	25.0	5.7	5.7		22.8 %
10/14/2019	1018	M	25.0	13.0	13.0		52.0 %
10/14/2019	1024	H	25.0	21.4	21.4		85.6 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.700	5.700	No	**0.0**
M	13.000	13.000	No	**0.0**
H	21.400	21.400	No	**0.0**

ATTACHMENT 12
Startup/Shutdown Emissions

FCD: AQ-22
Title V: #13

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:50 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,046.47 Hours

Non-Operating Time: 161.53 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
10/01/2019 00:00 10/01/2019 00:04 Shut Down - Gas	5	0.6		
10/01/2019 04:30 10/01/2019 05:33 Hot Start - Gas	64	112.3		
10/03/2019 21:36 10/03/2019 21:42 Shut Down - Gas	7	2.3		
10/04/2019 13:35 10/04/2019 14:46 Warm Start - Gas	72	132.0		
10/12/2019 07:24 10/12/2019 07:29 Shut Down - Gas	6	1.8		
10/12/2019 14:33 10/12/2019 15:40 Hot Start - Gas	68	117.9		
10/13/2019 23:19 10/13/2019 23:24 Shut Down - Gas	6	1.7		
10/14/2019 06:44 10/14/2019 07:37 Hot Start - Gas	54	102.9		
10/15/2019 05:40 10/15/2019 05:45 Shut Down - Gas	6	1.7		
10/15/2019 06:36 10/15/2019 07:18 Hot Start - Gas	43	83.8		
10/16/2019 20:41 10/16/2019 21:47 Warm Start - Gas	67	112.9		
10/19/2019 07:25 10/19/2019 07:29 Shut Down - Gas	5	0.8		
10/20/2019 14:05 10/20/2019 15:42 Warm Start - Gas	98	161.8		

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:50 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,046.47 Hours

Non-Operating Time: 161.53 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
10/26/2019 22:23 10/26/2019 22:28 Shut Down - Gas	6	1.3		
10/28/2019 00:45 10/28/2019 01:58 Warm Start - Gas	74	126.2		
10/28/2019 23:08 10/28/2019 23:13 Shut Down - Gas	6	1.7		
10/30/2019 04:54 10/30/2019 06:55 Warm Start - Gas	122	204.7		
11/02/2019 13:16 11/02/2019 13:21 Shut Down - Gas	6	1.7		
11/02/2019 15:41 11/02/2019 16:23 Hot Start - Gas	43	82.1		
11/25/2019 00:33 11/25/2019 00:37 Shut Down - Gas	5	1.1		
11/25/2019 04:33 11/25/2019 05:28 Hot Start - Gas	56	109.1		
12/13/2019 00:46 12/13/2019 00:50 Shut Down - Gas	5	1.1		
12/13/2019 04:27 12/13/2019 05:18 Hot Start - Gas	52	94.2		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:50 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,046.47 Hours

Non-Operating Time: 161.53 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:50 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,046.47 Hours

Non-Operating Time: 161.53 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/01/2019 00:00	0.3	0	0	0	1	0
10/01/2019 01:00	0.0	0	0	0	0	0
10/01/2019 02:00	0.0	0	0	0	0	0
10/01/2019 03:00	0.0	0	0	0	0	0
10/01/2019 04:00	10.5	0	0	1	0	0
10/01/2019 05:00	22.1	0	0	1	0	0
10/01/2019 06:00	0.0	0	0	0	0	1
10/01/2019 07:00	0.0	0	0	0	0	1
10/01/2019 08:00	0.0	0	0	0	0	1
10/01/2019 09:00	0.0	0	0	0	0	1
10/01/2019 10:00	0.0	0	0	0	0	1
10/01/2019 11:00	0.0	0	0	0	0	1
10/01/2019 12:00	0.0	0	0	0	0	1
10/01/2019 13:00	0.0	0	0	0	0	1
10/01/2019 14:00	0.0	0	0	0	0	1
10/01/2019 15:00	0.0	0	0	0	0	1
10/01/2019 16:00	0.0	0	0	0	0	1
10/01/2019 17:00	0.0	0	0	0	0	1
10/01/2019 18:00	0.0	0	0	0	0	1
10/01/2019 19:00	0.0	0	0	0	0	1
10/01/2019 20:00	0.0	0	0	0	0	1
10/01/2019 21:00	0.0	0	0	0	0	1
10/01/2019 22:00	0.0	0	0	0	0	1
10/01/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	32.9 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	22.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/02/2019 00:00	0.0	0	0	0	0	1
10/02/2019 01:00	0.0	0	0	0	0	1
10/02/2019 02:00	0.0	0	0	0	0	1
10/02/2019 03:00	0.0	0	0	0	0	1
10/02/2019 04:00	0.0	0	0	0	0	1
10/02/2019 05:00	0.0	0	0	0	0	1
10/02/2019 06:00	0.0	0	0	0	0	1
10/02/2019 07:00	0.0	0	0	0	0	1
10/02/2019 08:00	0.0	0	0	0	0	1
10/02/2019 09:00	0.0	0	0	0	0	1
10/02/2019 10:00	0.0	0	0	0	0	1
10/02/2019 11:00	0.0	0	0	0	0	1
10/02/2019 12:00	0.0	0	0	0	0	1
10/02/2019 13:00	0.0	0	0	0	0	1
10/02/2019 14:00	0.0	0	0	0	0	1
10/02/2019 15:00	0.0	0	0	0	0	1
10/02/2019 16:00	0.0	0	0	0	0	1
10/02/2019 17:00	0.0	0	0	0	0	1
10/02/2019 18:00	0.0	0	0	0	0	1
10/02/2019 19:00	0.0	0	0	0	0	1
10/02/2019 20:00	0.0	0	0	0	0	1
10/02/2019 21:00	0.0	0	0	0	0	1
10/02/2019 22:00	0.0	0	0	0	0	1
10/02/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/03/2019 00:00	0.0	0	0	0	0	1
10/03/2019 01:00	0.0	0	0	0	0	1
10/03/2019 02:00	0.0	0	0	0	0	1
10/03/2019 03:00	0.0	0	0	0	0	1
10/03/2019 04:00	0.0	0	0	0	0	1
10/03/2019 05:00	0.0	0	0	0	0	1
10/03/2019 06:00	0.0	0	0	0	0	1
10/03/2019 07:00	0.0	0	0	0	0	1
10/03/2019 08:00	0.0	0	0	0	0	1
10/03/2019 09:00	0.0	0	0	0	0	1
10/03/2019 10:00	0.0	0	0	0	0	1
10/03/2019 11:00	0.0	0	0	0	0	1
10/03/2019 12:00	0.0	0	0	0	0	1
10/03/2019 13:00	0.0	0	0	0	0	1
10/03/2019 14:00	0.0	0	0	0	0	1
10/03/2019 15:00	0.0	0	0	0	0	1
10/03/2019 16:00	0.0	0	0	0	0	1
10/03/2019 17:00	0.0	0	0	0	0	1
10/03/2019 18:00	0.0	0	0	0	0	1
10/03/2019 19:00	0.0	0	0	0	0	1
10/03/2019 20:00	0.0	0	0	0	0	1
10/03/2019 21:00	1.1	0	0	0	1	0
10/03/2019 22:00	0.0	0	0	0	0	0
10/03/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.1 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/04/2019 00:00	0.0	0	0	0	0	0
10/04/2019 01:00	0.0	0	0	0	0	0
10/04/2019 02:00	0.0	0	0	0	0	0
10/04/2019 03:00	0.0	0	0	0	0	0
10/04/2019 04:00	0.0	0	0	0	0	0
10/04/2019 05:00	0.0	0	0	0	0	0
10/04/2019 06:00	0.0	0	0	0	0	0
10/04/2019 07:00	0.0	0	0	0	0	0
10/04/2019 08:00	0.0	0	0	0	0	0
10/04/2019 09:00	0.0	0	0	0	0	0
10/04/2019 10:00	0.0	0	0	0	0	0
10/04/2019 11:00	0.0	0	0	0	0	0
10/04/2019 12:00	0.0	0	0	0	0	0
10/04/2019 13:00	11.6	0	1	0	0	0
10/04/2019 14:00	33.0	0	1	0	0	0
10/04/2019 15:00	0.0	0	0	0	0	1
10/04/2019 16:00	0.0	0	0	0	0	1
10/04/2019 17:00	0.0	0	0	0	0	1
10/04/2019 18:00	0.0	0	0	0	0	1
10/04/2019 19:00	0.0	0	0	0	0	1
10/04/2019 20:00	0.0	0	0	0	0	1
10/04/2019 21:00	0.0	0	0	0	0	1
10/04/2019 22:00	0.0	0	0	0	0	1
10/04/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	44.6 #	0 #	2 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	33.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/05/2019 00:00	0.0	0	0	0	0	1
10/05/2019 01:00	0.0	0	0	0	0	1
10/05/2019 02:00	0.0	0	0	0	0	1
10/05/2019 03:00	0.0	0	0	0	0	1
10/05/2019 04:00	0.0	0	0	0	0	1
10/05/2019 05:00	0.0	0	0	0	0	1
10/05/2019 06:00	0.0	0	0	0	0	1
10/05/2019 07:00	0.0	0	0	0	0	1
10/05/2019 08:00	0.0	0	0	0	0	1
10/05/2019 09:00	0.0	0	0	0	0	1
10/05/2019 10:00	0.0	0	0	0	0	1
10/05/2019 11:00	0.0	0	0	0	0	1
10/05/2019 12:00	0.0	0	0	0	0	1
10/05/2019 13:00	0.0	0	0	0	0	1
10/05/2019 14:00	0.0	0	0	0	0	1
10/05/2019 15:00	0.0	0	0	0	0	1
10/05/2019 16:00	0.0	0	0	0	0	1
10/05/2019 17:00	0.0	0	0	0	0	1
10/05/2019 18:00	0.0	0	0	0	0	1
10/05/2019 19:00	0.0	0	0	0	0	1
10/05/2019 20:00	0.0	0	0	0	0	1
10/05/2019 21:00	0.0	0	0	0	0	1
10/05/2019 22:00	0.0	0	0	0	0	1
10/05/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/06/2019 00:00	0.0	0	0	0	0	1
10/06/2019 01:00	0.0	0	0	0	0	1
10/06/2019 02:00	0.0	0	0	0	0	1
10/06/2019 03:00	0.0	0	0	0	0	1
10/06/2019 04:00	0.0	0	0	0	0	1
10/06/2019 05:00	0.0	0	0	0	0	1
10/06/2019 06:00	0.0	0	0	0	0	1
10/06/2019 07:00	0.0	0	0	0	0	1
10/06/2019 08:00	0.0	0	0	0	0	1
10/06/2019 09:00	0.0	0	0	0	0	1
10/06/2019 10:00	0.0	0	0	0	0	1
10/06/2019 11:00	0.0	0	0	0	0	1
10/06/2019 12:00	0.0	0	0	0	0	1
10/06/2019 13:00	0.0	0	0	0	0	1
10/06/2019 14:00	0.0	0	0	0	0	1
10/06/2019 15:00	0.0	0	0	0	0	1
10/06/2019 16:00	0.0	0	0	0	0	1
10/06/2019 17:00	0.0	0	0	0	0	1
10/06/2019 18:00	0.0	0	0	0	0	1
10/06/2019 19:00	0.0	0	0	0	0	1
10/06/2019 20:00	0.0	0	0	0	0	1
10/06/2019 21:00	0.0	0	0	0	0	1
10/06/2019 22:00	0.0	0	0	0	0	1
10/06/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/07/2019 00:00	0.0	0	0	0	0	1
10/07/2019 01:00	0.0	0	0	0	0	1
10/07/2019 02:00	0.0	0	0	0	0	1
10/07/2019 03:00	0.0	0	0	0	0	1
10/07/2019 04:00	0.0	0	0	0	0	1
10/07/2019 05:00	0.0	0	0	0	0	1
10/07/2019 06:00	0.0	0	0	0	0	1
10/07/2019 07:00	0.0	0	0	0	0	1
10/07/2019 08:00	0.0	0	0	0	0	1
10/07/2019 09:00	0.0	0	0	0	0	1
10/07/2019 10:00	0.0	0	0	0	0	1
10/07/2019 11:00	0.0	0	0	0	0	1
10/07/2019 12:00	0.0	0	0	0	0	1
10/07/2019 13:00	0.0	0	0	0	0	1
10/07/2019 14:00	0.0	0	0	0	0	1
10/07/2019 15:00	0.0	0	0	0	0	1
10/07/2019 16:00	0.0	0	0	0	0	1
10/07/2019 17:00	0.0	0	0	0	0	1
10/07/2019 18:00	0.0	0	0	0	0	1
10/07/2019 19:00	0.0	0	0	0	0	1
10/07/2019 20:00	0.0	0	0	0	0	1
10/07/2019 21:00	0.0	0	0	0	0	1
10/07/2019 22:00	0.0	0	0	0	0	1
10/07/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/08/2019 00:00	0.0	0	0	0	0	1
10/08/2019 01:00	0.0	0	0	0	0	1
10/08/2019 02:00	0.0	0	0	0	0	1
10/08/2019 03:00	0.0	0	0	0	0	1
10/08/2019 04:00	0.0	0	0	0	0	1
10/08/2019 05:00	0.0	0	0	0	0	1
10/08/2019 06:00	0.0	0	0	0	0	1
10/08/2019 07:00	0.0	0	0	0	0	1
10/08/2019 08:00	0.0	0	0	0	0	1
10/08/2019 09:00	0.0	0	0	0	0	1
10/08/2019 10:00	0.0	0	0	0	0	1
10/08/2019 11:00	0.0	0	0	0	0	1
10/08/2019 12:00	0.0	0	0	0	0	1
10/08/2019 13:00	0.0	0	0	0	0	1
10/08/2019 14:00	0.0	0	0	0	0	1
10/08/2019 15:00	0.0	0	0	0	0	1
10/08/2019 16:00	0.0	0	0	0	0	1
10/08/2019 17:00	0.0	0	0	0	0	1
10/08/2019 18:00	0.0	0	0	0	0	1
10/08/2019 19:00	0.0	0	0	0	0	1
10/08/2019 20:00	0.0	0	0	0	0	1
10/08/2019 21:00	0.0	0	0	0	0	1
10/08/2019 22:00	0.0	0	0	0	0	1
10/08/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/09/2019 00:00	0.0	0	0	0	0	1
10/09/2019 01:00	0.0	0	0	0	0	1
10/09/2019 02:00	0.0	0	0	0	0	1
10/09/2019 03:00	0.0	0	0	0	0	1
10/09/2019 04:00	0.0	0	0	0	0	1
10/09/2019 05:00	0.0	0	0	0	0	1
10/09/2019 06:00	0.0	0	0	0	0	1
10/09/2019 07:00	0.0	0	0	0	0	1
10/09/2019 08:00	0.0	0	0	0	0	1
10/09/2019 09:00	0.0	0	0	0	0	1
10/09/2019 10:00	0.0	0	0	0	0	1
10/09/2019 11:00	0.0	0	0	0	0	1
10/09/2019 12:00	0.0	0	0	0	0	1
10/09/2019 13:00	0.0	0	0	0	0	1
10/09/2019 14:00	0.0	0	0	0	0	1
10/09/2019 15:00	0.0	0	0	0	0	1
10/09/2019 16:00	0.0	0	0	0	0	1
10/09/2019 17:00	0.0	0	0	0	0	1
10/09/2019 18:00	0.0	0	0	0	0	1
10/09/2019 19:00	0.0	0	0	0	0	1
10/09/2019 20:00	0.0	0	0	0	0	1
10/09/2019 21:00	0.0	0	0	0	0	1
10/09/2019 22:00	0.0	0	0	0	0	1
10/09/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/10/2019 00:00	0.0	0	0	0	0	1
10/10/2019 01:00	0.0	0	0	0	0	1
10/10/2019 02:00	0.0	0	0	0	0	1
10/10/2019 03:00	0.0	0	0	0	0	1
10/10/2019 04:00	0.0	0	0	0	0	1
10/10/2019 05:00	0.0	0	0	0	0	1
10/10/2019 06:00	0.0	0	0	0	0	1
10/10/2019 07:00	0.0	0	0	0	0	1
10/10/2019 08:00	0.0	0	0	0	0	1
10/10/2019 09:00	0.0	0	0	0	0	1
10/10/2019 10:00	0.0	0	0	0	0	1
10/10/2019 11:00	0.0	0	0	0	0	1
10/10/2019 12:00	0.0	0	0	0	0	1
10/10/2019 13:00	0.0	0	0	0	0	1
10/10/2019 14:00	0.0	0	0	0	0	1
10/10/2019 15:00	0.0	0	0	0	0	1
10/10/2019 16:00	0.0	0	0	0	0	1
10/10/2019 17:00	0.0	0	0	0	0	1
10/10/2019 18:00	0.0	0	0	0	0	1
10/10/2019 19:00	0.0	0	0	0	0	1
10/10/2019 20:00	0.0	0	0	0	0	1
10/10/2019 21:00	0.0	0	0	0	0	1
10/10/2019 22:00	0.0	0	0	0	0	1
10/10/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/11/2019 00:00	0.0	0	0	0	0	1
10/11/2019 01:00	0.0	0	0	0	0	1
10/11/2019 02:00	0.0	0	0	0	0	1
10/11/2019 03:00	0.0	0	0	0	0	1
10/11/2019 04:00	0.0	0	0	0	0	1
10/11/2019 05:00	0.0	0	0	0	0	1
10/11/2019 06:00	0.0	0	0	0	0	1
10/11/2019 07:00	0.0	0	0	0	0	1
10/11/2019 08:00	0.0	0	0	0	0	1
10/11/2019 09:00	0.0	0	0	0	0	1
10/11/2019 10:00	0.0	0	0	0	0	1
10/11/2019 11:00	0.0	0	0	0	0	1
10/11/2019 12:00	0.0	0	0	0	0	1
10/11/2019 13:00	0.0	0	0	0	0	1
10/11/2019 14:00	0.0	0	0	0	0	1
10/11/2019 15:00	0.0	0	0	0	0	1
10/11/2019 16:00	0.0	0	0	0	0	1
10/11/2019 17:00	0.0	0	0	0	0	1
10/11/2019 18:00	0.0	0	0	0	0	1
10/11/2019 19:00	0.0	0	0	0	0	1
10/11/2019 20:00	0.0	0	0	0	0	1
10/11/2019 21:00	0.0	0	0	0	0	1
10/11/2019 22:00	0.0	0	0	0	0	1
10/11/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/12/2019 00:00	0.0	0	0	0	0	1
10/12/2019 01:00	0.0	0	0	0	0	1
10/12/2019 02:00	0.0	0	0	0	0	1
10/12/2019 03:00	0.0	0	0	0	0	1
10/12/2019 04:00	0.0	0	0	0	0	1
10/12/2019 05:00	0.0	0	0	0	0	1
10/12/2019 06:00	0.0	0	0	0	0	1
10/12/2019 07:00	1.3	0	0	0	1	0
10/12/2019 08:00	0.0	0	0	0	0	0
10/12/2019 09:00	0.0	0	0	0	0	0
10/12/2019 10:00	0.0	0	0	0	0	0
10/12/2019 11:00	0.0	0	0	0	0	0
10/12/2019 12:00	0.0	0	0	0	0	0
10/12/2019 13:00	0.0	0	0	0	0	0
10/12/2019 14:00	7.3	0	0	1	0	0
10/12/2019 15:00	17.6	0	0	1	0	0
10/12/2019 16:00	0.0	0	0	0	0	1
10/12/2019 17:00	0.0	0	0	0	0	1
10/12/2019 18:00	0.0	0	0	0	0	1
10/12/2019 19:00	0.0	0	0	0	0	1
10/12/2019 20:00	0.0	0	0	0	0	1
10/12/2019 21:00	0.0	0	0	0	0	1
10/12/2019 22:00	0.0	0	0	0	0	1
10/12/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	26.2 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	17.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/13/2019 00:00	0.0	0	0	0	0	1
10/13/2019 01:00	0.0	0	0	0	0	1
10/13/2019 02:00	0.0	0	0	0	0	1
10/13/2019 03:00	0.0	0	0	0	0	1
10/13/2019 04:00	0.0	0	0	0	0	1
10/13/2019 05:00	0.0	0	0	0	0	1
10/13/2019 06:00	0.0	0	0	0	0	1
10/13/2019 07:00	0.0	0	0	0	0	1
10/13/2019 08:00	0.0	0	0	0	0	1
10/13/2019 09:00	0.0	0	0	0	0	1
10/13/2019 10:00	0.0	0	0	0	0	1
10/13/2019 11:00	0.0	0	0	0	0	1
10/13/2019 12:00	0.0	0	0	0	0	1
10/13/2019 13:00	0.0	0	0	0	0	1
10/13/2019 14:00	0.0	0	0	0	0	1
10/13/2019 15:00	0.0	0	0	0	0	1
10/13/2019 16:00	0.0	0	0	0	0	1
10/13/2019 17:00	0.0	0	0	0	0	1
10/13/2019 18:00	0.0	0	0	0	0	1
10/13/2019 19:00	0.0	0	0	0	0	1
10/13/2019 20:00	0.0	0	0	0	0	1
10/13/2019 21:00	0.0	0	0	0	0	1
10/13/2019 22:00	0.0	0	0	0	0	1
10/13/2019 23:00	1.2	0	0	0	1	0
Average/Sum#:	1.2 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/14/2019 00:00	0.0	0	0	0	0	0
10/14/2019 01:00	0.0	0	0	0	0	0
10/14/2019 02:00	0.0	0	0	0	0	0
10/14/2019 03:00	0.0	0	0	0	0	0
10/14/2019 04:00	0.0	0	0	0	0	0
10/14/2019 05:00	0.0	0	0	0	0	0
10/14/2019 06:00	5.1	0	0	1	0	0
10/14/2019 07:00	28.6	0	0	1	0	0
10/14/2019 08:00	0.0	0	0	0	0	1
10/14/2019 09:00	0.0	0	0	0	0	1
10/14/2019 10:00	0.0	0	0	0	0	1
10/14/2019 11:00	0.0	0	0	0	0	1
10/14/2019 12:00	0.0	0	0	0	0	1
10/14/2019 13:00	0.0	0	0	0	0	1
10/14/2019 14:00	0.0	0	0	0	0	1
10/14/2019 15:00	0.0	0	0	0	0	1
10/14/2019 16:00	0.0	0	0	0	0	1
10/14/2019 17:00	0.0	0	0	0	0	1
10/14/2019 18:00	0.0	0	0	0	0	1
10/14/2019 19:00	0.0	0	0	0	0	1
10/14/2019 20:00	0.0	0	0	0	0	1
10/14/2019 21:00	0.0	0	0	0	0	1
10/14/2019 22:00	0.0	0	0	0	0	1
10/14/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	33.7 #	0 #	0 #	2 #	0 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	28.6	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/15/2019 00:00	0.0	0	0	0	0	1
10/15/2019 01:00	0.0	0	0	0	0	1
10/15/2019 02:00	0.0	0	0	0	0	1
10/15/2019 03:00	0.0	0	0	0	0	1
10/15/2019 04:00	0.0	0	0	0	0	1
10/15/2019 05:00	1.9	0	0	0	1	0
10/15/2019 06:00	11.8	0	0	1	0	0
10/15/2019 07:00	5.9	0	0	1	0	0
10/15/2019 08:00	0.0	0	0	0	0	1
10/15/2019 09:00	0.0	0	0	0	0	1
10/15/2019 10:00	0.0	0	0	0	0	1
10/15/2019 11:00	0.0	0	0	0	0	1
10/15/2019 12:00	0.0	0	0	0	0	1
10/15/2019 13:00	0.0	0	0	0	0	1
10/15/2019 14:00	0.0	0	0	0	0	1
10/15/2019 15:00	0.0	0	0	0	0	0
10/15/2019 16:00	0.0	0	0	0	0	0
10/15/2019 17:00	0.0	0	0	0	0	0
10/15/2019 18:00	0.0	0	0	0	0	0
10/15/2019 19:00	0.0	0	0	0	0	0
10/15/2019 20:00	0.0	0	0	0	0	0
10/15/2019 21:00	0.0	0	0	0	0	0
10/15/2019 22:00	0.0	0	0	0	0	0
10/15/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	19.6 #	0 #	0 #	2 #	1 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	11.8	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/16/2019 00:00	0.0	0	0	0	0	0
10/16/2019 01:00	0.0	0	0	0	0	0
10/16/2019 02:00	0.0	0	0	0	0	0
10/16/2019 03:00	0.0	0	0	0	0	0
10/16/2019 04:00	0.0	0	0	0	0	0
10/16/2019 05:00	0.0	0	0	0	0	0
10/16/2019 06:00	0.0	0	0	0	0	0
10/16/2019 07:00	0.0	0	0	0	0	0
10/16/2019 08:00	0.0	0	0	0	0	0
10/16/2019 09:00	0.0	0	0	0	0	0
10/16/2019 10:00	0.0	0	0	0	0	0
10/16/2019 11:00	0.0	0	0	0	0	0
10/16/2019 12:00	0.0	0	0	0	0	0
10/16/2019 13:00	0.0	0	0	0	0	0
10/16/2019 14:00	0.0	0	0	0	0	0
10/16/2019 15:00	0.0	0	0	0	0	0
10/16/2019 16:00	0.0	0	0	0	0	0
10/16/2019 17:00	0.0	0	0	0	0	0
10/16/2019 18:00	0.0	0	0	0	0	0
10/16/2019 19:00	0.0	0	0	0	0	0
10/16/2019 20:00	33.1	0	1	0	0	0
10/16/2019 21:00	26.2	0	1	0	0	0
10/16/2019 22:00	0.0	0	0	0	0	1
10/16/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	59.3 #	0 #	2 #	0 #	0 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	33.1	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/17/2019 00:00	0.0	0	0	0	0	1
10/17/2019 01:00	0.0	0	0	0	0	1
10/17/2019 02:00	0.0	0	0	0	0	1
10/17/2019 03:00	0.0	0	0	0	0	1
10/17/2019 04:00	0.0	0	0	0	0	1
10/17/2019 05:00	0.0	0	0	0	0	1
10/17/2019 06:00	0.0	0	0	0	0	1
10/17/2019 07:00	0.0	0	0	0	0	1
10/17/2019 08:00	0.0	0	0	0	0	1
10/17/2019 09:00	0.0	0	0	0	0	1
10/17/2019 10:00	0.0	0	0	0	0	1
10/17/2019 11:00	0.0	0	0	0	0	1
10/17/2019 12:00	0.0	0	0	0	0	1
10/17/2019 13:00	0.0	0	0	0	0	1
10/17/2019 14:00	0.0	0	0	0	0	1
10/17/2019 15:00	0.0	0	0	0	0	1
10/17/2019 16:00	0.0	0	0	0	0	1
10/17/2019 17:00	0.0	0	0	0	0	1
10/17/2019 18:00	0.0	0	0	0	0	1
10/17/2019 19:00	0.0	0	0	0	0	1
10/17/2019 20:00	0.0	0	0	0	0	1
10/17/2019 21:00	0.0	0	0	0	0	1
10/17/2019 22:00	0.0	0	0	0	0	1
10/17/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/18/2019 00:00	0.0	0	0	0	0	1
10/18/2019 01:00	0.0	0	0	0	0	1
10/18/2019 02:00	0.0	0	0	0	0	1
10/18/2019 03:00	0.0	0	0	0	0	1
10/18/2019 04:00	0.0	0	0	0	0	1
10/18/2019 05:00	0.0	0	0	0	0	1
10/18/2019 06:00	0.0	0	0	0	0	1
10/18/2019 07:00	0.0	0	0	0	0	1
10/18/2019 08:00	0.0	0	0	0	0	1
10/18/2019 09:00	0.0	0	0	0	0	1
10/18/2019 10:00	0.0	0	0	0	0	1
10/18/2019 11:00	0.0	0	0	0	0	1
10/18/2019 12:00	0.0	0	0	0	0	1
10/18/2019 13:00	0.0	0	0	0	0	1
10/18/2019 14:00	0.0	0	0	0	0	1
10/18/2019 15:00	0.0	0	0	0	0	1
10/18/2019 16:00	0.0	0	0	0	0	1
10/18/2019 17:00	0.0	0	0	0	0	1
10/18/2019 18:00	0.0	0	0	0	0	1
10/18/2019 19:00	0.0	0	0	0	0	1
10/18/2019 20:00	0.0	0	0	0	0	1
10/18/2019 21:00	0.0	0	0	0	0	1
10/18/2019 22:00	0.0	0	0	0	0	1
10/18/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/19/2019 00:00	0.0	0	0	0	0	1
10/19/2019 01:00	0.0	0	0	0	0	1
10/19/2019 02:00	0.0	0	0	0	0	1
10/19/2019 03:00	0.0	0	0	0	0	1
10/19/2019 04:00	0.0	0	0	0	0	1
10/19/2019 05:00	0.0	0	0	0	0	1
10/19/2019 06:00	0.0	0	0	0	0	1
10/19/2019 07:00	1.1	0	0	0	1	0
10/19/2019 08:00	0.0	0	0	0	0	0
10/19/2019 09:00	0.0	0	0	0	0	0
10/19/2019 10:00	0.0	0	0	0	0	0
10/19/2019 11:00	0.0	0	0	0	0	0
10/19/2019 12:00	0.0	0	0	0	0	0
10/19/2019 13:00	0.0	0	0	0	0	0
10/19/2019 14:00	0.0	0	0	0	0	0
10/19/2019 15:00	0.0	0	0	0	0	0
10/19/2019 16:00	0.0	0	0	0	0	0
10/19/2019 17:00	0.0	0	0	0	0	0
10/19/2019 18:00	0.0	0	0	0	0	0
10/19/2019 19:00	0.0	0	0	0	0	0
10/19/2019 20:00	0.0	0	0	0	0	0
10/19/2019 21:00	0.0	0	0	0	0	0
10/19/2019 22:00	0.0	0	0	0	0	0
10/19/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.1 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/20/2019 00:00	0.0	0	0	0	0	0
10/20/2019 01:00	0.0	0	0	0	0	0
10/20/2019 02:00	0.0	0	0	0	0	0
10/20/2019 03:00	0.0	0	0	0	0	0
10/20/2019 04:00	0.0	0	0	0	0	0
10/20/2019 05:00	0.0	0	0	0	0	0
10/20/2019 06:00	0.0	0	0	0	0	0
10/20/2019 07:00	0.0	0	0	0	0	0
10/20/2019 08:00	0.0	0	0	0	0	0
10/20/2019 09:00	0.0	0	0	0	0	0
10/20/2019 10:00	0.0	0	0	0	0	0
10/20/2019 11:00	0.0	0	0	0	0	0
10/20/2019 12:00	0.0	0	0	0	0	0
10/20/2019 13:00	0.0	0	0	0	0	0
10/20/2019 14:00	47.7	0	1	0	0	0
10/20/2019 15:00	20.7	0	1	0	0	0
10/20/2019 16:00	0.0	0	0	0	0	1
10/20/2019 17:00	0.0	0	0	0	0	1
10/20/2019 18:00	0.0	0	0	0	0	1
10/20/2019 19:00	0.0	0	0	0	0	1
10/20/2019 20:00	0.0	0	0	0	0	1
10/20/2019 21:00	0.0	0	0	0	0	1
10/20/2019 22:00	0.0	0	0	0	0	1
10/20/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	68.4 #	0 #	2 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	47.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/21/2019 00:00	0.0	0	0	0	0	1
10/21/2019 01:00	0.0	0	0	0	0	1
10/21/2019 02:00	0.0	0	0	0	0	1
10/21/2019 03:00	0.0	0	0	0	0	1
10/21/2019 04:00	0.0	0	0	0	0	1
10/21/2019 05:00	0.0	0	0	0	0	1
10/21/2019 06:00	0.0	0	0	0	0	1
10/21/2019 07:00	0.0	0	0	0	0	1
10/21/2019 08:00	0.0	0	0	0	0	1
10/21/2019 09:00	0.0	0	0	0	0	1
10/21/2019 10:00	0.0	0	0	0	0	1
10/21/2019 11:00	0.0	0	0	0	0	1
10/21/2019 12:00	0.0	0	0	0	0	1
10/21/2019 13:00	0.0	0	0	0	0	1
10/21/2019 14:00	0.0	0	0	0	0	1
10/21/2019 15:00	0.0	0	0	0	0	1
10/21/2019 16:00	0.0	0	0	0	0	1
10/21/2019 17:00	0.0	0	0	0	0	1
10/21/2019 18:00	0.0	0	0	0	0	1
10/21/2019 19:00	0.0	0	0	0	0	1
10/21/2019 20:00	0.0	0	0	0	0	1
10/21/2019 21:00	0.0	0	0	0	0	1
10/21/2019 22:00	0.0	0	0	0	0	1
10/21/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/22/2019 00:00	0.0	0	0	0	0	1
10/22/2019 01:00	0.0	0	0	0	0	1
10/22/2019 02:00	0.0	0	0	0	0	1
10/22/2019 03:00	0.0	0	0	0	0	1
10/22/2019 04:00	0.0	0	0	0	0	1
10/22/2019 05:00	0.0	0	0	0	0	1
10/22/2019 06:00	0.0	0	0	0	0	1
10/22/2019 07:00	0.0	0	0	0	0	1
10/22/2019 08:00	0.0	0	0	0	0	1
10/22/2019 09:00	0.0	0	0	0	0	1
10/22/2019 10:00	0.0	0	0	0	0	1
10/22/2019 11:00	0.0	0	0	0	0	1
10/22/2019 12:00	0.0	0	0	0	0	1
10/22/2019 13:00	0.0	0	0	0	0	1
10/22/2019 14:00	0.0	0	0	0	0	1
10/22/2019 15:00	0.0	0	0	0	0	1
10/22/2019 16:00	0.0	0	0	0	0	1
10/22/2019 17:00	0.0	0	0	0	0	1
10/22/2019 18:00	0.0	0	0	0	0	1
10/22/2019 19:00	0.0	0	0	0	0	1
10/22/2019 20:00	0.0	0	0	0	0	1
10/22/2019 21:00	0.0	0	0	0	0	1
10/22/2019 22:00	0.0	0	0	0	0	1
10/22/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/23/2019 00:00	0.0	0	0	0	0	1
10/23/2019 01:00	0.0	0	0	0	0	1
10/23/2019 02:00	0.0	0	0	0	0	1
10/23/2019 03:00	0.0	0	0	0	0	1
10/23/2019 04:00	0.0	0	0	0	0	1
10/23/2019 05:00	0.0	0	0	0	0	1
10/23/2019 06:00	0.0	0	0	0	0	1
10/23/2019 07:00	0.0	0	0	0	0	1
10/23/2019 08:00	0.0	0	0	0	0	1
10/23/2019 09:00	0.0	0	0	0	0	1
10/23/2019 10:00	0.0	0	0	0	0	1
10/23/2019 11:00	0.0	0	0	0	0	1
10/23/2019 12:00	0.0	0	0	0	0	1
10/23/2019 13:00	0.0	0	0	0	0	1
10/23/2019 14:00	0.0	0	0	0	0	1
10/23/2019 15:00	0.0	0	0	0	0	1
10/23/2019 16:00	0.0	0	0	0	0	1
10/23/2019 17:00	0.0	0	0	0	0	1
10/23/2019 18:00	0.0	0	0	0	0	1
10/23/2019 19:00	0.0	0	0	0	0	1
10/23/2019 20:00	0.0	0	0	0	0	1
10/23/2019 21:00	0.0	0	0	0	0	1
10/23/2019 22:00	0.0	0	0	0	0	1
10/23/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/24/2019 00:00	0.0	0	0	0	0	1
10/24/2019 01:00	0.0	0	0	0	0	1
10/24/2019 02:00	0.0	0	0	0	0	1
10/24/2019 03:00	0.0	0	0	0	0	1
10/24/2019 04:00	0.0	0	0	0	0	1
10/24/2019 05:00	0.0	0	0	0	0	1
10/24/2019 06:00	0.0	0	0	0	0	1
10/24/2019 07:00	0.0	0	0	0	0	1
10/24/2019 08:00	0.0	0	0	0	0	1
10/24/2019 09:00	0.0	0	0	0	0	1
10/24/2019 10:00	0.0	0	0	0	0	1
10/24/2019 11:00	0.0	0	0	0	0	1
10/24/2019 12:00	0.0	0	0	0	0	1
10/24/2019 13:00	0.0	0	0	0	0	1
10/24/2019 14:00	0.0	0	0	0	0	1
10/24/2019 15:00	0.0	0	0	0	0	1
10/24/2019 16:00	0.0	0	0	0	0	1
10/24/2019 17:00	0.0	0	0	0	0	1
10/24/2019 18:00	0.0	0	0	0	0	1
10/24/2019 19:00	0.0	0	0	0	0	1
10/24/2019 20:00	0.0	0	0	0	0	1
10/24/2019 21:00	0.0	0	0	0	0	1
10/24/2019 22:00	0.0	0	0	0	0	1
10/24/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/25/2019 00:00	0.0	0	0	0	0	1
10/25/2019 01:00	0.0	0	0	0	0	1
10/25/2019 02:00	0.0	0	0	0	0	1
10/25/2019 03:00	0.0	0	0	0	0	1
10/25/2019 04:00	0.0	0	0	0	0	1
10/25/2019 05:00	0.0	0	0	0	0	1
10/25/2019 06:00	0.0	0	0	0	0	1
10/25/2019 07:00	0.0	0	0	0	0	1
10/25/2019 08:00	0.0	0	0	0	0	1
10/25/2019 09:00	0.0	0	0	0	0	1
10/25/2019 10:00	0.0	0	0	0	0	1
10/25/2019 11:00	0.0	0	0	0	0	1
10/25/2019 12:00	0.0	0	0	0	0	1
10/25/2019 13:00	0.0	0	0	0	0	1
10/25/2019 14:00	0.0	0	0	0	0	1
10/25/2019 15:00	0.0	0	0	0	0	1
10/25/2019 16:00	0.0	0	0	0	0	1
10/25/2019 17:00	0.0	0	0	0	0	1
10/25/2019 18:00	0.0	0	0	0	0	1
10/25/2019 19:00	0.0	0	0	0	0	1
10/25/2019 20:00	0.0	0	0	0	0	1
10/25/2019 21:00	0.0	0	0	0	0	1
10/25/2019 22:00	0.0	0	0	0	0	1
10/25/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/26/2019 00:00	0.0	0	0	0	0	1
10/26/2019 01:00	0.0	0	0	0	0	1
10/26/2019 02:00	0.0	0	0	0	0	1
10/26/2019 03:00	0.0	0	0	0	0	1
10/26/2019 04:00	0.0	0	0	0	0	1
10/26/2019 05:00	0.0	0	0	0	0	1
10/26/2019 06:00	0.0	0	0	0	0	1
10/26/2019 07:00	0.0	0	0	0	0	1
10/26/2019 08:00	0.0	0	0	0	0	1
10/26/2019 09:00	0.0	0	0	0	0	1
10/26/2019 10:00	0.0	0	0	0	0	1
10/26/2019 11:00	0.0	0	0	0	0	1
10/26/2019 12:00	0.0	0	0	0	0	1
10/26/2019 13:00	0.0	0	0	0	0	1
10/26/2019 14:00	0.0	0	0	0	0	1
10/26/2019 15:00	0.0	0	0	0	0	1
10/26/2019 16:00	0.0	0	0	0	0	1
10/26/2019 17:00	0.0	0	0	0	0	1
10/26/2019 18:00	0.0	0	0	0	0	1
10/26/2019 19:00	0.0	0	0	0	0	1
10/26/2019 20:00	0.0	0	0	0	0	1
10/26/2019 21:00	0.0	0	0	0	0	1
10/26/2019 22:00	1.6	0	0	0	1	0
10/26/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.6 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/27/2019 00:00	0.0	0	0	0	0	0
10/27/2019 01:00	0.0	0	0	0	0	0
10/27/2019 02:00	0.0	0	0	0	0	0
10/27/2019 03:00	0.0	0	0	0	0	0
10/27/2019 04:00	0.0	0	0	0	0	0
10/27/2019 05:00	0.0	0	0	0	0	0
10/27/2019 06:00	0.0	0	0	0	0	0
10/27/2019 07:00	0.0	0	0	0	0	0
10/27/2019 08:00	0.0	0	0	0	0	0
10/27/2019 09:00	0.0	0	0	0	0	0
10/27/2019 10:00	0.0	0	0	0	0	0
10/27/2019 11:00	0.0	0	0	0	0	0
10/27/2019 12:00	0.0	0	0	0	0	0
10/27/2019 13:00	0.0	0	0	0	0	0
10/27/2019 14:00	0.0	0	0	0	0	0
10/27/2019 15:00	0.0	0	0	0	0	0
10/27/2019 16:00	0.0	0	0	0	0	0
10/27/2019 17:00	0.0	0	0	0	0	0
10/27/2019 18:00	0.0	0	0	0	0	0
10/27/2019 19:00	0.0	0	0	0	0	0
10/27/2019 20:00	0.0	0	0	0	0	0
10/27/2019 21:00	0.0	0	0	0	0	0
10/27/2019 22:00	0.0	0	0	0	0	0
10/27/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/28/2019 00:00	42.4	0	1	0	0	0
10/28/2019 01:00	42.9	0	1	0	0	0
10/28/2019 02:00	0.0	0	0	0	0	1
10/28/2019 03:00	0.0	0	0	0	0	1
10/28/2019 04:00	0.0	0	0	0	0	1
10/28/2019 05:00	0.0	0	0	0	0	1
10/28/2019 06:00	0.0	0	0	0	0	1
10/28/2019 07:00	0.0	0	0	0	0	1
10/28/2019 08:00	0.0	0	0	0	0	1
10/28/2019 09:00	0.0	0	0	0	0	1
10/28/2019 10:00	0.0	0	0	0	0	1
10/28/2019 11:00	0.0	0	0	0	0	1
10/28/2019 12:00	0.0	0	0	0	0	1
10/28/2019 13:00	0.0	0	0	0	0	1
10/28/2019 14:00	0.0	0	0	0	0	1
10/28/2019 15:00	0.0	0	0	0	0	1
10/28/2019 16:00	0.0	0	0	0	0	1
10/28/2019 17:00	0.0	0	0	0	0	1
10/28/2019 18:00	0.0	0	0	0	0	1
10/28/2019 19:00	0.0	0	0	0	0	1
10/28/2019 20:00	0.0	0	0	0	0	1
10/28/2019 21:00	0.0	0	0	0	0	1
10/28/2019 22:00	0.0	0	0	0	0	1
10/28/2019 23:00	1.5	0	0	0	1	0
Average/Sum#:	86.8 #	0 #	2 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	42.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/29/2019 00:00	0.0	0	0	0	0	0
10/29/2019 01:00	0.0	0	0	0	0	0
10/29/2019 02:00	0.0	0	0	0	0	0
10/29/2019 03:00	0.0	0	0	0	0	0
10/29/2019 04:00	0.0	0	0	0	0	0
10/29/2019 05:00	0.0	0	0	0	0	0
10/29/2019 06:00	0.0	0	0	0	0	0
10/29/2019 07:00	0.0	0	0	0	0	0
10/29/2019 08:00	0.0	0	0	0	0	0
10/29/2019 09:00	0.0	0	0	0	0	0
10/29/2019 10:00	0.0	0	0	0	0	0
10/29/2019 11:00	0.0	0	0	0	0	0
10/29/2019 12:00	0.0	0	0	0	0	0
10/29/2019 13:00	0.0	0	0	0	0	0
10/29/2019 14:00	0.0	0	0	0	0	0
10/29/2019 15:00	0.0	0	0	0	0	0
10/29/2019 16:00	0.0	0	0	0	0	0
10/29/2019 17:00	0.0	0	0	0	0	0
10/29/2019 18:00	0.0	0	0	0	0	0
10/29/2019 19:00	0.0	0	0	0	0	0
10/29/2019 20:00	0.0	0	0	0	0	0
10/29/2019 21:00	0.0	0	0	0	0	0
10/29/2019 22:00	0.0	0	0	0	0	0
10/29/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/30/2019 00:00	0.0	0	0	0	0	0
10/30/2019 01:00	0.0	0	0	0	0	0
10/30/2019 02:00	0.0	0	0	0	0	0
10/30/2019 03:00	0.0	0	0	0	0	0
10/30/2019 04:00	27.5	0	1	0	0	0
10/30/2019 05:00	64.6	0	1	0	0	0
10/30/2019 06:00	43.7	0	1	0	0	0
10/30/2019 07:00	0.0	0	0	0	0	1
10/30/2019 08:00	0.0	0	0	0	0	1
10/30/2019 09:00	0.0	0	0	0	0	1
10/30/2019 10:00	0.0	0	0	0	0	1
10/30/2019 11:00	0.0	0	0	0	0	1
10/30/2019 12:00	0.0	0	0	0	0	1
10/30/2019 13:00	0.0	0	0	0	0	1
10/30/2019 14:00	0.0	0	0	0	0	1
10/30/2019 15:00	0.0	0	0	0	0	1
10/30/2019 16:00	0.0	0	0	0	0	1
10/30/2019 17:00	0.0	0	0	0	0	1
10/30/2019 18:00	0.0	0	0	0	0	1
10/30/2019 19:00	0.0	0	0	0	0	1
10/30/2019 20:00	0.0	0	0	0	0	1
10/30/2019 21:00	0.0	0	0	0	0	1
10/30/2019 22:00	0.0	0	0	0	0	1
10/30/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	135.8 #	0 #	3 #	0 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	64.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/31/2019 00:00	0.0	0	0	0	0	1
10/31/2019 01:00	0.0	0	0	0	0	1
10/31/2019 02:00	0.0	0	0	0	0	1
10/31/2019 03:00	0.0	0	0	0	0	1
10/31/2019 04:00	0.0	0	0	0	0	1
10/31/2019 05:00	0.0	0	0	0	0	1
10/31/2019 06:00	0.0	0	0	0	0	1
10/31/2019 07:00	0.0	0	0	0	0	1
10/31/2019 08:00	0.0	0	0	0	0	1
10/31/2019 09:00	0.0	0	0	0	0	1
10/31/2019 10:00	0.0	0	0	0	0	1
10/31/2019 11:00	0.0	0	0	0	0	1
10/31/2019 12:00	0.0	0	0	0	0	1
10/31/2019 13:00	0.0	0	0	0	0	1
10/31/2019 14:00	0.0	0	0	0	0	1
10/31/2019 15:00	0.0	0	0	0	0	1
10/31/2019 16:00	0.0	0	0	0	0	1
10/31/2019 17:00	0.0	0	0	0	0	1
10/31/2019 18:00	0.0	0	0	0	0	1
10/31/2019 19:00	0.0	0	0	0	0	1
10/31/2019 20:00	0.0	0	0	0	0	1
10/31/2019 21:00	0.0	0	0	0	0	1
10/31/2019 22:00	0.0	0	0	0	0	1
10/31/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/01/2019 00:00	0.0	0	0	0	0	1
11/01/2019 01:00	0.0	0	0	0	0	1
11/01/2019 02:00	0.0	0	0	0	0	1
11/01/2019 03:00	0.0	0	0	0	0	1
11/01/2019 04:00	0.0	0	0	0	0	1
11/01/2019 05:00	0.0	0	0	0	0	1
11/01/2019 06:00	0.0	0	0	0	0	1
11/01/2019 07:00	0.0	0	0	0	0	1
11/01/2019 08:00	0.0	0	0	0	0	1
11/01/2019 09:00	0.0	0	0	0	0	1
11/01/2019 10:00	0.0	0	0	0	0	1
11/01/2019 11:00	0.0	0	0	0	0	1
11/01/2019 12:00	0.0	0	0	0	0	1
11/01/2019 13:00	0.0	0	0	0	0	1
11/01/2019 14:00	0.0	0	0	0	0	1
11/01/2019 15:00	0.0	0	0	0	0	1
11/01/2019 16:00	0.0	0	0	0	0	1
11/01/2019 17:00	0.0	0	0	0	0	1
11/01/2019 18:00	0.0	0	0	0	0	1
11/01/2019 19:00	0.0	0	0	0	0	1
11/01/2019 20:00	0.0	0	0	0	0	1
11/01/2019 21:00	0.0	0	0	0	0	1
11/01/2019 22:00	0.0	0	0	0	0	1
11/01/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/02/2019 00:00	0.0	0	0	0	0	1
11/02/2019 01:00	0.0	0	0	0	0	1
11/02/2019 02:00	0.0	0	0	0	0	1
11/02/2019 03:00	0.0	0	0	0	0	1
11/02/2019 04:00	0.0	0	0	0	0	1
11/02/2019 05:00	0.0	0	0	0	0	1
11/02/2019 06:00	0.0	0	0	0	0	1
11/02/2019 07:00	0.0	0	0	0	0	1
11/02/2019 08:00	0.0	0	0	0	0	1
11/02/2019 09:00	0.0	0	0	0	0	1
11/02/2019 10:00	0.0	0	0	0	0	1
11/02/2019 11:00	0.0	0	0	0	0	1
11/02/2019 12:00	0.0	0	0	0	0	1
11/02/2019 13:00	1.5	0	0	0	1	0
11/02/2019 14:00	0.0	0	0	0	0	0
11/02/2019 15:00	6.6	0	0	1	0	0
11/02/2019 16:00	8.4	0	0	1	0	0
11/02/2019 17:00	0.0	0	0	0	0	1
11/02/2019 18:00	0.0	0	0	0	0	1
11/02/2019 19:00	0.0	0	0	0	0	1
11/02/2019 20:00	0.0	0	0	0	0	1
11/02/2019 21:00	0.0	0	0	0	0	1
11/02/2019 22:00	0.0	0	0	0	0	1
11/02/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	16.5 #	0 #	0 #	2 #	1 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	8.4	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/03/2019 00:00	0.0	0	0	0	0	1
11/03/2019 01:00	0.0	0	0	0	0	1
11/03/2019 02:00	0.0	0	0	0	0	1
11/03/2019 03:00	0.0	0	0	0	0	1
11/03/2019 04:00	0.0	0	0	0	0	1
11/03/2019 05:00	0.0	0	0	0	0	1
11/03/2019 06:00	0.0	0	0	0	0	1
11/03/2019 07:00	0.0	0	0	0	0	1
11/03/2019 08:00	0.0	0	0	0	0	1
11/03/2019 09:00	0.0	0	0	0	0	1
11/03/2019 10:00	0.0	0	0	0	0	1
11/03/2019 11:00	0.0	0	0	0	0	1
11/03/2019 12:00	0.0	0	0	0	0	1
11/03/2019 13:00	0.0	0	0	0	0	1
11/03/2019 14:00	0.0	0	0	0	0	1
11/03/2019 15:00	0.0	0	0	0	0	1
11/03/2019 16:00	0.0	0	0	0	0	1
11/03/2019 17:00	0.0	0	0	0	0	1
11/03/2019 18:00	0.0	0	0	0	0	1
11/03/2019 19:00	0.0	0	0	0	0	1
11/03/2019 20:00	0.0	0	0	0	0	1
11/03/2019 21:00	0.0	0	0	0	0	1
11/03/2019 22:00	0.0	0	0	0	0	1
11/03/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/04/2019 00:00	0.0	0	0	0	0	1
11/04/2019 01:00	0.0	0	0	0	0	1
11/04/2019 02:00	0.0	0	0	0	0	1
11/04/2019 03:00	0.0	0	0	0	0	1
11/04/2019 04:00	0.0	0	0	0	0	1
11/04/2019 05:00	0.0	0	0	0	0	1
11/04/2019 06:00	0.0	0	0	0	0	1
11/04/2019 07:00	0.0	0	0	0	0	1
11/04/2019 08:00	0.0	0	0	0	0	1
11/04/2019 09:00	0.0	0	0	0	0	1
11/04/2019 10:00	0.0	0	0	0	0	1
11/04/2019 11:00	0.0	0	0	0	0	1
11/04/2019 12:00	0.0	0	0	0	0	1
11/04/2019 13:00	0.0	0	0	0	0	1
11/04/2019 14:00	0.0	0	0	0	0	1
11/04/2019 15:00	0.0	0	0	0	0	1
11/04/2019 16:00	0.0	0	0	0	0	1
11/04/2019 17:00	0.0	0	0	0	0	1
11/04/2019 18:00	0.0	0	0	0	0	1
11/04/2019 19:00	0.0	0	0	0	0	1
11/04/2019 20:00	0.0	0	0	0	0	1
11/04/2019 21:00	0.0	0	0	0	0	1
11/04/2019 22:00	0.0	0	0	0	0	1
11/04/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/05/2019 00:00	0.0	0	0	0	0	1
11/05/2019 01:00	0.0	0	0	0	0	1
11/05/2019 02:00	0.0	0	0	0	0	1
11/05/2019 03:00	0.0	0	0	0	0	1
11/05/2019 04:00	0.0	0	0	0	0	1
11/05/2019 05:00	0.0	0	0	0	0	1
11/05/2019 06:00	0.0	0	0	0	0	1
11/05/2019 07:00	0.0	0	0	0	0	1
11/05/2019 08:00	0.0	0	0	0	0	1
11/05/2019 09:00	0.0	0	0	0	0	1
11/05/2019 10:00	0.0	0	0	0	0	1
11/05/2019 11:00	0.0	0	0	0	0	1
11/05/2019 12:00	0.0	0	0	0	0	1
11/05/2019 13:00	0.0	0	0	0	0	1
11/05/2019 14:00	0.0	0	0	0	0	1
11/05/2019 15:00	0.0	0	0	0	0	1
11/05/2019 16:00	0.0	0	0	0	0	1
11/05/2019 17:00	0.0	0	0	0	0	1
11/05/2019 18:00	0.0	0	0	0	0	1
11/05/2019 19:00	0.0	0	0	0	0	1
11/05/2019 20:00	0.0	0	0	0	0	1
11/05/2019 21:00	0.0	0	0	0	0	1
11/05/2019 22:00	0.0	0	0	0	0	1
11/05/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/06/2019 00:00	0.0	0	0	0	0	1
11/06/2019 01:00	0.0	0	0	0	0	1
11/06/2019 02:00	0.0	0	0	0	0	1
11/06/2019 03:00	0.0	0	0	0	0	1
11/06/2019 04:00	0.0	0	0	0	0	1
11/06/2019 05:00	0.0	0	0	0	0	1
11/06/2019 06:00	0.0	0	0	0	0	1
11/06/2019 07:00	0.0	0	0	0	0	1
11/06/2019 08:00	0.0	0	0	0	0	1
11/06/2019 09:00	0.0	0	0	0	0	1
11/06/2019 10:00	0.0	0	0	0	0	1
11/06/2019 11:00	0.0	0	0	0	0	1
11/06/2019 12:00	0.0	0	0	0	0	1
11/06/2019 13:00	0.0	0	0	0	0	1
11/06/2019 14:00	0.0	0	0	0	0	1
11/06/2019 15:00	0.0	0	0	0	0	1
11/06/2019 16:00	0.0	0	0	0	0	1
11/06/2019 17:00	0.0	0	0	0	0	1
11/06/2019 18:00	0.0	0	0	0	0	1
11/06/2019 19:00	0.0	0	0	0	0	1
11/06/2019 20:00	0.0	0	0	0	0	1
11/06/2019 21:00	0.0	0	0	0	0	1
11/06/2019 22:00	0.0	0	0	0	0	1
11/06/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/07/2019 00:00	0.0	0	0	0	0	1
11/07/2019 01:00	0.0	0	0	0	0	1
11/07/2019 02:00	0.0	0	0	0	0	1
11/07/2019 03:00	0.0	0	0	0	0	1
11/07/2019 04:00	0.0	0	0	0	0	1
11/07/2019 05:00	0.0	0	0	0	0	1
11/07/2019 06:00	0.0	0	0	0	0	1
11/07/2019 07:00	0.0	0	0	0	0	1
11/07/2019 08:00	0.0	0	0	0	0	1
11/07/2019 09:00	0.0	0	0	0	0	1
11/07/2019 10:00	0.0	0	0	0	0	1
11/07/2019 11:00	0.0	0	0	0	0	1
11/07/2019 12:00	0.0	0	0	0	0	1
11/07/2019 13:00	0.0	0	0	0	0	1
11/07/2019 14:00	0.0	0	0	0	0	1
11/07/2019 15:00	0.0	0	0	0	0	1
11/07/2019 16:00	0.0	0	0	0	0	1
11/07/2019 17:00	0.0	0	0	0	0	1
11/07/2019 18:00	0.0	0	0	0	0	1
11/07/2019 19:00	0.0	0	0	0	0	1
11/07/2019 20:00	0.0	0	0	0	0	1
11/07/2019 21:00	0.0	0	0	0	0	1
11/07/2019 22:00	0.0	0	0	0	0	1
11/07/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/08/2019 00:00	0.0	0	0	0	0	1
11/08/2019 01:00	0.0	0	0	0	0	1
11/08/2019 02:00	0.0	0	0	0	0	1
11/08/2019 03:00	0.0	0	0	0	0	1
11/08/2019 04:00	0.0	0	0	0	0	1
11/08/2019 05:00	0.0	0	0	0	0	1
11/08/2019 06:00	0.0	0	0	0	0	1
11/08/2019 07:00	0.0	0	0	0	0	1
11/08/2019 08:00	0.0	0	0	0	0	1
11/08/2019 09:00	0.0	0	0	0	0	1
11/08/2019 10:00	0.0	0	0	0	0	1
11/08/2019 11:00	0.0	0	0	0	0	1
11/08/2019 12:00	0.0	0	0	0	0	1
11/08/2019 13:00	0.0	0	0	0	0	1
11/08/2019 14:00	0.0	0	0	0	0	1
11/08/2019 15:00	0.0	0	0	0	0	1
11/08/2019 16:00	0.0	0	0	0	0	1
11/08/2019 17:00	0.0	0	0	0	0	1
11/08/2019 18:00	0.0	0	0	0	0	1
11/08/2019 19:00	0.0	0	0	0	0	1
11/08/2019 20:00	0.0	0	0	0	0	1
11/08/2019 21:00	0.0	0	0	0	0	1
11/08/2019 22:00	0.0	0	0	0	0	1
11/08/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/09/2019 00:00	0.0	0	0	0	0	1
11/09/2019 01:00	0.0	0	0	0	0	1
11/09/2019 02:00	0.0	0	0	0	0	1
11/09/2019 03:00	0.0	0	0	0	0	1
11/09/2019 04:00	0.0	0	0	0	0	1
11/09/2019 05:00	0.0	0	0	0	0	1
11/09/2019 06:00	0.0	0	0	0	0	1
11/09/2019 07:00	0.0	0	0	0	0	1
11/09/2019 08:00	0.0	0	0	0	0	1
11/09/2019 09:00	0.0	0	0	0	0	1
11/09/2019 10:00	0.0	0	0	0	0	1
11/09/2019 11:00	0.0	0	0	0	0	1
11/09/2019 12:00	0.0	0	0	0	0	1
11/09/2019 13:00	0.0	0	0	0	0	1
11/09/2019 14:00	0.0	0	0	0	0	1
11/09/2019 15:00	0.0	0	0	0	0	1
11/09/2019 16:00	0.0	0	0	0	0	1
11/09/2019 17:00	0.0	0	0	0	0	1
11/09/2019 18:00	0.0	0	0	0	0	1
11/09/2019 19:00	0.0	0	0	0	0	1
11/09/2019 20:00	0.0	0	0	0	0	1
11/09/2019 21:00	0.0	0	0	0	0	1
11/09/2019 22:00	0.0	0	0	0	0	1
11/09/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/10/2019 00:00	0.0	0	0	0	0	1
11/10/2019 01:00	0.0	0	0	0	0	1
11/10/2019 02:00	0.0	0	0	0	0	1
11/10/2019 03:00	0.0	0	0	0	0	1
11/10/2019 04:00	0.0	0	0	0	0	1
11/10/2019 05:00	0.0	0	0	0	0	1
11/10/2019 06:00	0.0	0	0	0	0	1
11/10/2019 07:00	0.0	0	0	0	0	1
11/10/2019 08:00	0.0	0	0	0	0	1
11/10/2019 09:00	0.0	0	0	0	0	1
11/10/2019 10:00	0.0	0	0	0	0	1
11/10/2019 11:00	0.0	0	0	0	0	1
11/10/2019 12:00	0.0	0	0	0	0	1
11/10/2019 13:00	0.0	0	0	0	0	1
11/10/2019 14:00	0.0	0	0	0	0	1
11/10/2019 15:00	0.0	0	0	0	0	1
11/10/2019 16:00	0.0	0	0	0	0	1
11/10/2019 17:00	0.0	0	0	0	0	1
11/10/2019 18:00	0.0	0	0	0	0	1
11/10/2019 19:00	0.0	0	0	0	0	1
11/10/2019 20:00	0.0	0	0	0	0	1
11/10/2019 21:00	0.0	0	0	0	0	1
11/10/2019 22:00	0.0	0	0	0	0	1
11/10/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/11/2019 00:00	0.0	0	0	0	0	1
11/11/2019 01:00	0.0	0	0	0	0	1
11/11/2019 02:00	0.0	0	0	0	0	1
11/11/2019 03:00	0.0	0	0	0	0	1
11/11/2019 04:00	0.0	0	0	0	0	1
11/11/2019 05:00	0.0	0	0	0	0	1
11/11/2019 06:00	0.0	0	0	0	0	1
11/11/2019 07:00	0.0	0	0	0	0	1
11/11/2019 08:00	0.0	0	0	0	0	1
11/11/2019 09:00	0.0	0	0	0	0	1
11/11/2019 10:00	0.0	0	0	0	0	1
11/11/2019 11:00	0.0	0	0	0	0	1
11/11/2019 12:00	0.0	0	0	0	0	1
11/11/2019 13:00	0.0	0	0	0	0	1
11/11/2019 14:00	0.0	0	0	0	0	1
11/11/2019 15:00	0.0	0	0	0	0	1
11/11/2019 16:00	0.0	0	0	0	0	1
11/11/2019 17:00	0.0	0	0	0	0	1
11/11/2019 18:00	0.0	0	0	0	0	1
11/11/2019 19:00	0.0	0	0	0	0	1
11/11/2019 20:00	0.0	0	0	0	0	1
11/11/2019 21:00	0.0	0	0	0	0	1
11/11/2019 22:00	0.0	0	0	0	0	1
11/11/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/12/2019 00:00	0.0	0	0	0	0	1
11/12/2019 01:00	0.0	0	0	0	0	1
11/12/2019 02:00	0.0	0	0	0	0	1
11/12/2019 03:00	0.0	0	0	0	0	1
11/12/2019 04:00	0.0	0	0	0	0	1
11/12/2019 05:00	0.0	0	0	0	0	1
11/12/2019 06:00	0.0	0	0	0	0	1
11/12/2019 07:00	0.0	0	0	0	0	1
11/12/2019 08:00	0.0	0	0	0	0	1
11/12/2019 09:00	0.0	0	0	0	0	1
11/12/2019 10:00	0.0	0	0	0	0	1
11/12/2019 11:00	0.0	0	0	0	0	1
11/12/2019 12:00	0.0	0	0	0	0	1
11/12/2019 13:00	0.0	0	0	0	0	1
11/12/2019 14:00	0.0	0	0	0	0	1
11/12/2019 15:00	0.0	0	0	0	0	1
11/12/2019 16:00	0.0	0	0	0	0	1
11/12/2019 17:00	0.0	0	0	0	0	1
11/12/2019 18:00	0.0	0	0	0	0	1
11/12/2019 19:00	0.0	0	0	0	0	1
11/12/2019 20:00	0.0	0	0	0	0	1
11/12/2019 21:00	0.0	0	0	0	0	1
11/12/2019 22:00	0.0	0	0	0	0	1
11/12/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/13/2019 00:00	0.0	0	0	0	0	1
11/13/2019 01:00	0.0	0	0	0	0	1
11/13/2019 02:00	0.0	0	0	0	0	1
11/13/2019 03:00	0.0	0	0	0	0	1
11/13/2019 04:00	0.0	0	0	0	0	1
11/13/2019 05:00	0.0	0	0	0	0	1
11/13/2019 06:00	0.0	0	0	0	0	1
11/13/2019 07:00	0.0	0	0	0	0	1
11/13/2019 08:00	0.0	0	0	0	0	1
11/13/2019 09:00	0.0	0	0	0	0	1
11/13/2019 10:00	0.0	0	0	0	0	1
11/13/2019 11:00	0.0	0	0	0	0	1
11/13/2019 12:00	0.0	0	0	0	0	1
11/13/2019 13:00	0.0	0	0	0	0	1
11/13/2019 14:00	0.0	0	0	0	0	1
11/13/2019 15:00	0.0	0	0	0	0	1
11/13/2019 16:00	0.0	0	0	0	0	1
11/13/2019 17:00	0.0	0	0	0	0	1
11/13/2019 18:00	0.0	0	0	0	0	1
11/13/2019 19:00	0.0	0	0	0	0	1
11/13/2019 20:00	0.0	0	0	0	0	1
11/13/2019 21:00	0.0	0	0	0	0	1
11/13/2019 22:00	0.0	0	0	0	0	1
11/13/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/14/2019 00:00	0.0	0	0	0	0	1
11/14/2019 01:00	0.0	0	0	0	0	1
11/14/2019 02:00	0.0	0	0	0	0	1
11/14/2019 03:00	0.0	0	0	0	0	1
11/14/2019 04:00	0.0	0	0	0	0	1
11/14/2019 05:00	0.0	0	0	0	0	1
11/14/2019 06:00	0.0	0	0	0	0	1
11/14/2019 07:00	0.0	0	0	0	0	1
11/14/2019 08:00	0.0	0	0	0	0	1
11/14/2019 09:00	0.0	0	0	0	0	1
11/14/2019 10:00	0.0	0	0	0	0	1
11/14/2019 11:00	0.0	0	0	0	0	1
11/14/2019 12:00	0.0	0	0	0	0	1
11/14/2019 13:00	0.0	0	0	0	0	1
11/14/2019 14:00	0.0	0	0	0	0	1
11/14/2019 15:00	0.0	0	0	0	0	1
11/14/2019 16:00	0.0	0	0	0	0	1
11/14/2019 17:00	0.0	0	0	0	0	1
11/14/2019 18:00	0.0	0	0	0	0	1
11/14/2019 19:00	0.0	0	0	0	0	1
11/14/2019 20:00	0.0	0	0	0	0	1
11/14/2019 21:00	0.0	0	0	0	0	1
11/14/2019 22:00	0.0	0	0	0	0	1
11/14/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/15/2019 00:00	0.0	0	0	0	0	1
11/15/2019 01:00	0.0	0	0	0	0	1
11/15/2019 02:00	0.0	0	0	0	0	1
11/15/2019 03:00	0.0	0	0	0	0	1
11/15/2019 04:00	0.0	0	0	0	0	1
11/15/2019 05:00	0.0	0	0	0	0	1
11/15/2019 06:00	0.0	0	0	0	0	1
11/15/2019 07:00	0.0	0	0	0	0	1
11/15/2019 08:00	0.0	0	0	0	0	1
11/15/2019 09:00	0.0	0	0	0	0	1
11/15/2019 10:00	0.0	0	0	0	0	1
11/15/2019 11:00	0.0	0	0	0	0	1
11/15/2019 12:00	0.0	0	0	0	0	1
11/15/2019 13:00	0.0	0	0	0	0	1
11/15/2019 14:00	0.0	0	0	0	0	1
11/15/2019 15:00	0.0	0	0	0	0	1
11/15/2019 16:00	0.0	0	0	0	0	1
11/15/2019 17:00	0.0	0	0	0	0	1
11/15/2019 18:00	0.0	0	0	0	0	1
11/15/2019 19:00	0.0	0	0	0	0	1
11/15/2019 20:00	0.0	0	0	0	0	1
11/15/2019 21:00	0.0	0	0	0	0	1
11/15/2019 22:00	0.0	0	0	0	0	1
11/15/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/16/2019 00:00	0.0	0	0	0	0	1
11/16/2019 01:00	0.0	0	0	0	0	1
11/16/2019 02:00	0.0	0	0	0	0	1
11/16/2019 03:00	0.0	0	0	0	0	1
11/16/2019 04:00	0.0	0	0	0	0	1
11/16/2019 05:00	0.0	0	0	0	0	1
11/16/2019 06:00	0.0	0	0	0	0	1
11/16/2019 07:00	0.0	0	0	0	0	1
11/16/2019 08:00	0.0	0	0	0	0	1
11/16/2019 09:00	0.0	0	0	0	0	1
11/16/2019 10:00	0.0	0	0	0	0	1
11/16/2019 11:00	0.0	0	0	0	0	1
11/16/2019 12:00	0.0	0	0	0	0	1
11/16/2019 13:00	0.0	0	0	0	0	1
11/16/2019 14:00	0.0	0	0	0	0	1
11/16/2019 15:00	0.0	0	0	0	0	1
11/16/2019 16:00	0.0	0	0	0	0	1
11/16/2019 17:00	0.0	0	0	0	0	1
11/16/2019 18:00	0.0	0	0	0	0	1
11/16/2019 19:00	0.0	0	0	0	0	1
11/16/2019 20:00	0.0	0	0	0	0	1
11/16/2019 21:00	0.0	0	0	0	0	1
11/16/2019 22:00	0.0	0	0	0	0	1
11/16/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/17/2019 00:00	0.0	0	0	0	0	1
11/17/2019 01:00	0.0	0	0	0	0	1
11/17/2019 02:00	0.0	0	0	0	0	1
11/17/2019 03:00	0.0	0	0	0	0	1
11/17/2019 04:00	0.0	0	0	0	0	1
11/17/2019 05:00	0.0	0	0	0	0	1
11/17/2019 06:00	0.0	0	0	0	0	1
11/17/2019 07:00	0.0	0	0	0	0	1
11/17/2019 08:00	0.0	0	0	0	0	1
11/17/2019 09:00	0.0	0	0	0	0	1
11/17/2019 10:00	0.0	0	0	0	0	1
11/17/2019 11:00	0.0	0	0	0	0	1
11/17/2019 12:00	0.0	0	0	0	0	1
11/17/2019 13:00	0.0	0	0	0	0	1
11/17/2019 14:00	0.0	0	0	0	0	1
11/17/2019 15:00	0.0	0	0	0	0	1
11/17/2019 16:00	0.0	0	0	0	0	1
11/17/2019 17:00	0.0	0	0	0	0	1
11/17/2019 18:00	0.0	0	0	0	0	1
11/17/2019 19:00	0.0	0	0	0	0	1
11/17/2019 20:00	0.0	0	0	0	0	1
11/17/2019 21:00	0.0	0	0	0	0	1
11/17/2019 22:00	0.0	0	0	0	0	1
11/17/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/18/2019 00:00	0.0	0	0	0	0	1
11/18/2019 01:00	0.0	0	0	0	0	1
11/18/2019 02:00	0.0	0	0	0	0	1
11/18/2019 03:00	0.0	0	0	0	0	1
11/18/2019 04:00	0.0	0	0	0	0	1
11/18/2019 05:00	0.0	0	0	0	0	1
11/18/2019 06:00	0.0	0	0	0	0	1
11/18/2019 07:00	0.0	0	0	0	0	1
11/18/2019 08:00	0.0	0	0	0	0	1
11/18/2019 09:00	0.0	0	0	0	0	1
11/18/2019 10:00	0.0	0	0	0	0	1
11/18/2019 11:00	0.0	0	0	0	0	1
11/18/2019 12:00	0.0	0	0	0	0	1
11/18/2019 13:00	0.0	0	0	0	0	1
11/18/2019 14:00	0.0	0	0	0	0	1
11/18/2019 15:00	0.0	0	0	0	0	1
11/18/2019 16:00	0.0	0	0	0	0	1
11/18/2019 17:00	0.0	0	0	0	0	1
11/18/2019 18:00	0.0	0	0	0	0	1
11/18/2019 19:00	0.0	0	0	0	0	1
11/18/2019 20:00	0.0	0	0	0	0	1
11/18/2019 21:00	0.0	0	0	0	0	1
11/18/2019 22:00	0.0	0	0	0	0	1
11/18/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/19/2019 00:00	0.0	0	0	0	0	1
11/19/2019 01:00	0.0	0	0	0	0	1
11/19/2019 02:00	0.0	0	0	0	0	1
11/19/2019 03:00	0.0	0	0	0	0	1
11/19/2019 04:00	0.0	0	0	0	0	1
11/19/2019 05:00	0.0	0	0	0	0	1
11/19/2019 06:00	0.0	0	0	0	0	1
11/19/2019 07:00	0.0	0	0	0	0	1
11/19/2019 08:00	0.0	0	0	0	0	1
11/19/2019 09:00	0.0	0	0	0	0	1
11/19/2019 10:00	0.0	0	0	0	0	1
11/19/2019 11:00	0.0	0	0	0	0	1
11/19/2019 12:00	0.0	0	0	0	0	1
11/19/2019 13:00	0.0	0	0	0	0	1
11/19/2019 14:00	0.0	0	0	0	0	1
11/19/2019 15:00	0.0	0	0	0	0	1
11/19/2019 16:00	0.0	0	0	0	0	1
11/19/2019 17:00	0.0	0	0	0	0	1
11/19/2019 18:00	0.0	0	0	0	0	1
11/19/2019 19:00	0.0	0	0	0	0	1
11/19/2019 20:00	0.0	0	0	0	0	1
11/19/2019 21:00	0.0	0	0	0	0	1
11/19/2019 22:00	0.0	0	0	0	0	1
11/19/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/20/2019 00:00	0.0	0	0	0	0	1
11/20/2019 01:00	0.0	0	0	0	0	1
11/20/2019 02:00	0.0	0	0	0	0	1
11/20/2019 03:00	0.0	0	0	0	0	1
11/20/2019 04:00	0.0	0	0	0	0	1
11/20/2019 05:00	0.0	0	0	0	0	1
11/20/2019 06:00	0.0	0	0	0	0	1
11/20/2019 07:00	0.0	0	0	0	0	1
11/20/2019 08:00	0.0	0	0	0	0	1
11/20/2019 09:00	0.0	0	0	0	0	1
11/20/2019 10:00	0.0	0	0	0	0	1
11/20/2019 11:00	0.0	0	0	0	0	1
11/20/2019 12:00	0.0	0	0	0	0	1
11/20/2019 13:00	0.0	0	0	0	0	1
11/20/2019 14:00	0.0	0	0	0	0	1
11/20/2019 15:00	0.0	0	0	0	0	1
11/20/2019 16:00	0.0	0	0	0	0	1
11/20/2019 17:00	0.0	0	0	0	0	1
11/20/2019 18:00	0.0	0	0	0	0	1
11/20/2019 19:00	0.0	0	0	0	0	1
11/20/2019 20:00	0.0	0	0	0	0	1
11/20/2019 21:00	0.0	0	0	0	0	1
11/20/2019 22:00	0.0	0	0	0	0	1
11/20/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/21/2019 00:00	0.0	0	0	0	0	1
11/21/2019 01:00	0.0	0	0	0	0	1
11/21/2019 02:00	0.0	0	0	0	0	1
11/21/2019 03:00	0.0	0	0	0	0	1
11/21/2019 04:00	0.0	0	0	0	0	1
11/21/2019 05:00	0.0	0	0	0	0	1
11/21/2019 06:00	0.0	0	0	0	0	1
11/21/2019 07:00	0.0	0	0	0	0	1
11/21/2019 08:00	0.0	0	0	0	0	1
11/21/2019 09:00	0.0	0	0	0	0	1
11/21/2019 10:00	0.0	0	0	0	0	1
11/21/2019 11:00	0.0	0	0	0	0	1
11/21/2019 12:00	0.0	0	0	0	0	1
11/21/2019 13:00	0.0	0	0	0	0	1
11/21/2019 14:00	0.0	0	0	0	0	1
11/21/2019 15:00	0.0	0	0	0	0	1
11/21/2019 16:00	0.0	0	0	0	0	1
11/21/2019 17:00	0.0	0	0	0	0	1
11/21/2019 18:00	0.0	0	0	0	0	1
11/21/2019 19:00	0.0	0	0	0	0	1
11/21/2019 20:00	0.0	0	0	0	0	1
11/21/2019 21:00	0.0	0	0	0	0	1
11/21/2019 22:00	0.0	0	0	0	0	1
11/21/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/22/2019 00:00	0.0	0	0	0	0	1
11/22/2019 01:00	0.0	0	0	0	0	1
11/22/2019 02:00	0.0	0	0	0	0	1
11/22/2019 03:00	0.0	0	0	0	0	1
11/22/2019 04:00	0.0	0	0	0	0	1
11/22/2019 05:00	0.0	0	0	0	0	1
11/22/2019 06:00	0.0	0	0	0	0	1
11/22/2019 07:00	0.0	0	0	0	0	1
11/22/2019 08:00	0.0	0	0	0	0	1
11/22/2019 09:00	0.0	0	0	0	0	1
11/22/2019 10:00	0.0	0	0	0	0	1
11/22/2019 11:00	0.0	0	0	0	0	1
11/22/2019 12:00	0.0	0	0	0	0	1
11/22/2019 13:00	0.0	0	0	0	0	1
11/22/2019 14:00	0.0	0	0	0	0	1
11/22/2019 15:00	0.0	0	0	0	0	1
11/22/2019 16:00	0.0	0	0	0	0	1
11/22/2019 17:00	0.0	0	0	0	0	1
11/22/2019 18:00	0.0	0	0	0	0	1
11/22/2019 19:00	0.0	0	0	0	0	1
11/22/2019 20:00	0.0	0	0	0	0	1
11/22/2019 21:00	0.0	0	0	0	0	1
11/22/2019 22:00	0.0	0	0	0	0	1
11/22/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/23/2019 00:00	0.0	0	0	0	0	1
11/23/2019 01:00	0.0	0	0	0	0	1
11/23/2019 02:00	0.0	0	0	0	0	1
11/23/2019 03:00	0.0	0	0	0	0	1
11/23/2019 04:00	0.0	0	0	0	0	1
11/23/2019 05:00	0.0	0	0	0	0	1
11/23/2019 06:00	0.0	0	0	0	0	1
11/23/2019 07:00	0.0	0	0	0	0	1
11/23/2019 08:00	0.0	0	0	0	0	1
11/23/2019 09:00	0.0	0	0	0	0	1
11/23/2019 10:00	0.0	0	0	0	0	1
11/23/2019 11:00	0.0	0	0	0	0	1
11/23/2019 12:00	0.0	0	0	0	0	1
11/23/2019 13:00	0.0	0	0	0	0	1
11/23/2019 14:00	0.0	0	0	0	0	1
11/23/2019 15:00	0.0	0	0	0	0	1
11/23/2019 16:00	0.0	0	0	0	0	1
11/23/2019 17:00	0.0	0	0	0	0	1
11/23/2019 18:00	0.0	0	0	0	0	1
11/23/2019 19:00	0.0	0	0	0	0	1
11/23/2019 20:00	0.0	0	0	0	0	1
11/23/2019 21:00	0.0	0	0	0	0	1
11/23/2019 22:00	0.0	0	0	0	0	1
11/23/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/24/2019 00:00	0.0	0	0	0	0	1
11/24/2019 01:00	0.0	0	0	0	0	1
11/24/2019 02:00	0.0	0	0	0	0	1
11/24/2019 03:00	0.0	0	0	0	0	1
11/24/2019 04:00	0.0	0	0	0	0	1
11/24/2019 05:00	0.0	0	0	0	0	1
11/24/2019 06:00	0.0	0	0	0	0	1
11/24/2019 07:00	0.0	0	0	0	0	1
11/24/2019 08:00	0.0	0	0	0	0	1
11/24/2019 09:00	0.0	0	0	0	0	1
11/24/2019 10:00	0.0	0	0	0	0	1
11/24/2019 11:00	0.0	0	0	0	0	1
11/24/2019 12:00	0.0	0	0	0	0	1
11/24/2019 13:00	0.0	0	0	0	0	1
11/24/2019 14:00	0.0	0	0	0	0	1
11/24/2019 15:00	0.0	0	0	0	0	1
11/24/2019 16:00	0.0	0	0	0	0	1
11/24/2019 17:00	0.0	0	0	0	0	1
11/24/2019 18:00	0.0	0	0	0	0	1
11/24/2019 19:00	0.0	0	0	0	0	1
11/24/2019 20:00	0.0	0	0	0	0	1
11/24/2019 21:00	0.0	0	0	0	0	1
11/24/2019 22:00	0.0	0	0	0	0	1
11/24/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/25/2019 00:00	0.8	0	0	0	1	0
11/25/2019 01:00	0.0	0	0	0	0	0
11/25/2019 02:00	0.0	0	0	0	0	0
11/25/2019 03:00	0.0	0	0	0	0	0
11/25/2019 04:00	17.1	0	0	1	0	0
11/25/2019 05:00	19.3	0	0	1	0	0
11/25/2019 06:00	0.0	0	0	0	0	1
11/25/2019 07:00	0.0	0	0	0	0	1
11/25/2019 08:00	0.0	0	0	0	0	1
11/25/2019 09:00	0.0	0	0	0	0	1
11/25/2019 10:00	0.0	0	0	0	0	1
11/25/2019 11:00	0.0	0	0	0	0	1
11/25/2019 12:00	0.0	0	0	0	0	1
11/25/2019 13:00	0.0	0	0	0	0	1
11/25/2019 14:00	0.0	0	0	0	0	1
11/25/2019 15:00	0.0	0	0	0	0	1
11/25/2019 16:00	0.0	0	0	0	0	1
11/25/2019 17:00	0.0	0	0	0	0	1
11/25/2019 18:00	0.0	0	0	0	0	1
11/25/2019 19:00	0.0	0	0	0	0	1
11/25/2019 20:00	0.0	0	0	0	0	1
11/25/2019 21:00	0.0	0	0	0	0	1
11/25/2019 22:00	0.0	0	0	0	0	1
11/25/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	37.2 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	19.3	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/26/2019 00:00	0.0	0	0	0	0	1
11/26/2019 01:00	0.0	0	0	0	0	1
11/26/2019 02:00	0.0	0	0	0	0	1
11/26/2019 03:00	0.0	0	0	0	0	1
11/26/2019 04:00	0.0	0	0	0	0	1
11/26/2019 05:00	0.0	0	0	0	0	1
11/26/2019 06:00	0.0	0	0	0	0	1
11/26/2019 07:00	0.0	0	0	0	0	1
11/26/2019 08:00	0.0	0	0	0	0	1
11/26/2019 09:00	0.0	0	0	0	0	1
11/26/2019 10:00	0.0	0	0	0	0	1
11/26/2019 11:00	0.0	0	0	0	0	1
11/26/2019 12:00	0.0	0	0	0	0	1
11/26/2019 13:00	0.0	0	0	0	0	1
11/26/2019 14:00	0.0	0	0	0	0	1
11/26/2019 15:00	0.0	0	0	0	0	1
11/26/2019 16:00	0.0	0	0	0	0	1
11/26/2019 17:00	0.0	0	0	0	0	1
11/26/2019 18:00	0.0	0	0	0	0	1
11/26/2019 19:00	0.0	0	0	0	0	1
11/26/2019 20:00	0.0	0	0	0	0	1
11/26/2019 21:00	0.0	0	0	0	0	1
11/26/2019 22:00	0.0	0	0	0	0	1
11/26/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/27/2019 00:00	0.0	0	0	0	0	1
11/27/2019 01:00	0.0	0	0	0	0	1
11/27/2019 02:00	0.0	0	0	0	0	1
11/27/2019 03:00	0.0	0	0	0	0	1
11/27/2019 04:00	0.0	0	0	0	0	1
11/27/2019 05:00	0.0	0	0	0	0	1
11/27/2019 06:00	0.0	0	0	0	0	1
11/27/2019 07:00	0.0	0	0	0	0	1
11/27/2019 08:00	0.0	0	0	0	0	1
11/27/2019 09:00	0.0	0	0	0	0	1
11/27/2019 10:00	0.0	0	0	0	0	1
11/27/2019 11:00	0.0	0	0	0	0	1
11/27/2019 12:00	0.0	0	0	0	0	1
11/27/2019 13:00	0.0	0	0	0	0	1
11/27/2019 14:00	0.0	0	0	0	0	1
11/27/2019 15:00	0.0	0	0	0	0	1
11/27/2019 16:00	0.0	0	0	0	0	1
11/27/2019 17:00	0.0	0	0	0	0	1
11/27/2019 18:00	0.0	0	0	0	0	1
11/27/2019 19:00	0.0	0	0	0	0	1
11/27/2019 20:00	0.0	0	0	0	0	1
11/27/2019 21:00	0.0	0	0	0	0	1
11/27/2019 22:00	0.0	0	0	0	0	1
11/27/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/28/2019 00:00	0.0	0	0	0	0	1
11/28/2019 01:00	0.0	0	0	0	0	1
11/28/2019 02:00	0.0	0	0	0	0	1
11/28/2019 03:00	0.0	0	0	0	0	1
11/28/2019 04:00	0.0	0	0	0	0	1
11/28/2019 05:00	0.0	0	0	0	0	1
11/28/2019 06:00	0.0	0	0	0	0	1
11/28/2019 07:00	0.0	0	0	0	0	1
11/28/2019 08:00	0.0	0	0	0	0	1
11/28/2019 09:00	0.0	0	0	0	0	1
11/28/2019 10:00	0.0	0	0	0	0	1
11/28/2019 11:00	0.0	0	0	0	0	1
11/28/2019 12:00	0.0	0	0	0	0	1
11/28/2019 13:00	0.0	0	0	0	0	1
11/28/2019 14:00	0.0	0	0	0	0	1
11/28/2019 15:00	0.0	0	0	0	0	1
11/28/2019 16:00	0.0	0	0	0	0	1
11/28/2019 17:00	0.0	0	0	0	0	1
11/28/2019 18:00	0.0	0	0	0	0	1
11/28/2019 19:00	0.0	0	0	0	0	1
11/28/2019 20:00	0.0	0	0	0	0	1
11/28/2019 21:00	0.0	0	0	0	0	1
11/28/2019 22:00	0.0	0	0	0	0	1
11/28/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/29/2019 00:00	0.0	0	0	0	0	1
11/29/2019 01:00	0.0	0	0	0	0	1
11/29/2019 02:00	0.0	0	0	0	0	1
11/29/2019 03:00	0.0	0	0	0	0	1
11/29/2019 04:00	0.0	0	0	0	0	1
11/29/2019 05:00	0.0	0	0	0	0	1
11/29/2019 06:00	0.0	0	0	0	0	1
11/29/2019 07:00	0.0	0	0	0	0	1
11/29/2019 08:00	0.0	0	0	0	0	1
11/29/2019 09:00	0.0	0	0	0	0	1
11/29/2019 10:00	0.0	0	0	0	0	1
11/29/2019 11:00	0.0	0	0	0	0	1
11/29/2019 12:00	0.0	0	0	0	0	1
11/29/2019 13:00	0.0	0	0	0	0	1
11/29/2019 14:00	0.0	0	0	0	0	1
11/29/2019 15:00	0.0	0	0	0	0	1
11/29/2019 16:00	0.0	0	0	0	0	1
11/29/2019 17:00	0.0	0	0	0	0	1
11/29/2019 18:00	0.0	0	0	0	0	1
11/29/2019 19:00	0.0	0	0	0	0	1
11/29/2019 20:00	0.0	0	0	0	0	1
11/29/2019 21:00	0.0	0	0	0	0	1
11/29/2019 22:00	0.0	0	0	0	0	1
11/29/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/30/2019 00:00	0.0	0	0	0	0	1
11/30/2019 01:00	0.0	0	0	0	0	1
11/30/2019 02:00	0.0	0	0	0	0	1
11/30/2019 03:00	0.0	0	0	0	0	1
11/30/2019 04:00	0.0	0	0	0	0	1
11/30/2019 05:00	0.0	0	0	0	0	1
11/30/2019 06:00	0.0	0	0	0	0	1
11/30/2019 07:00	0.0	0	0	0	0	1
11/30/2019 08:00	0.0	0	0	0	0	1
11/30/2019 09:00	0.0	0	0	0	0	1
11/30/2019 10:00	0.0	0	0	0	0	1
11/30/2019 11:00	0.0	0	0	0	0	1
11/30/2019 12:00	0.0	0	0	0	0	1
11/30/2019 13:00	0.0	0	0	0	0	1
11/30/2019 14:00	0.0	0	0	0	0	1
11/30/2019 15:00	0.0	0	0	0	0	1
11/30/2019 16:00	0.0	0	0	0	0	1
11/30/2019 17:00	0.0	0	0	0	0	1
11/30/2019 18:00	0.0	0	0	0	0	1
11/30/2019 19:00	0.0	0	0	0	0	1
11/30/2019 20:00	0.0	0	0	0	0	1
11/30/2019 21:00	0.0	0	0	0	0	1
11/30/2019 22:00	0.0	0	0	0	0	1
11/30/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/01/2019 00:00	0.0	0	0	0	0	1
12/01/2019 01:00	0.0	0	0	0	0	1
12/01/2019 02:00	0.0	0	0	0	0	1
12/01/2019 03:00	0.0	0	0	0	0	1
12/01/2019 04:00	0.0	0	0	0	0	1
12/01/2019 05:00	0.0	0	0	0	0	1
12/01/2019 06:00	0.0	0	0	0	0	1
12/01/2019 07:00	0.0	0	0	0	0	1
12/01/2019 08:00	0.0	0	0	0	0	1
12/01/2019 09:00	0.0	0	0	0	0	1
12/01/2019 10:00	0.0	0	0	0	0	1
12/01/2019 11:00	0.0	0	0	0	0	1
12/01/2019 12:00	0.0	0	0	0	0	1
12/01/2019 13:00	0.0	0	0	0	0	1
12/01/2019 14:00	0.0	0	0	0	0	1
12/01/2019 15:00	0.0	0	0	0	0	1
12/01/2019 16:00	0.0	0	0	0	0	1
12/01/2019 17:00	0.0	0	0	0	0	1
12/01/2019 18:00	0.0	0	0	0	0	1
12/01/2019 19:00	0.0	0	0	0	0	1
12/01/2019 20:00	0.0	0	0	0	0	1
12/01/2019 21:00	0.0	0	0	0	0	1
12/01/2019 22:00	0.0	0	0	0	0	1
12/01/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/02/2019 00:00	0.0	0	0	0	0	1
12/02/2019 01:00	0.0	0	0	0	0	1
12/02/2019 02:00	0.0	0	0	0	0	1
12/02/2019 03:00	0.0	0	0	0	0	1
12/02/2019 04:00	0.0	0	0	0	0	1
12/02/2019 05:00	0.0	0	0	0	0	1
12/02/2019 06:00	0.0	0	0	0	0	1
12/02/2019 07:00	0.0	0	0	0	0	1
12/02/2019 08:00	0.0	0	0	0	0	1
12/02/2019 09:00	0.0	0	0	0	0	1
12/02/2019 10:00	0.0	0	0	0	0	1
12/02/2019 11:00	0.0	0	0	0	0	1
12/02/2019 12:00	0.0	0	0	0	0	1
12/02/2019 13:00	0.0	0	0	0	0	1
12/02/2019 14:00	0.0	0	0	0	0	1
12/02/2019 15:00	0.0	0	0	0	0	1
12/02/2019 16:00	0.0	0	0	0	0	1
12/02/2019 17:00	0.0	0	0	0	0	1
12/02/2019 18:00	0.0	0	0	0	0	1
12/02/2019 19:00	0.0	0	0	0	0	1
12/02/2019 20:00	0.0	0	0	0	0	1
12/02/2019 21:00	0.0	0	0	0	0	1
12/02/2019 22:00	0.0	0	0	0	0	1
12/02/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/03/2019 00:00	0.0	0	0	0	0	1
12/03/2019 01:00	0.0	0	0	0	0	1
12/03/2019 02:00	0.0	0	0	0	0	1
12/03/2019 03:00	0.0	0	0	0	0	1
12/03/2019 04:00	0.0	0	0	0	0	1
12/03/2019 05:00	0.0	0	0	0	0	1
12/03/2019 06:00	0.0	0	0	0	0	1
12/03/2019 07:00	0.0	0	0	0	0	1
12/03/2019 08:00	0.0	0	0	0	0	1
12/03/2019 09:00	0.0	0	0	0	0	1
12/03/2019 10:00	0.0	0	0	0	0	1
12/03/2019 11:00	0.0	0	0	0	0	1
12/03/2019 12:00	0.0	0	0	0	0	1
12/03/2019 13:00	0.0	0	0	0	0	1
12/03/2019 14:00	0.0	0	0	0	0	1
12/03/2019 15:00	0.0	0	0	0	0	1
12/03/2019 16:00	0.0	0	0	0	0	1
12/03/2019 17:00	0.0	0	0	0	0	1
12/03/2019 18:00	0.0	0	0	0	0	1
12/03/2019 19:00	0.0	0	0	0	0	1
12/03/2019 20:00	0.0	0	0	0	0	1
12/03/2019 21:00	0.0	0	0	0	0	1
12/03/2019 22:00	0.0	0	0	0	0	1
12/03/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/04/2019 00:00	0.0	0	0	0	0	1
12/04/2019 01:00	0.0	0	0	0	0	1
12/04/2019 02:00	0.0	0	0	0	0	1
12/04/2019 03:00	0.0	0	0	0	0	1
12/04/2019 04:00	0.0	0	0	0	0	1
12/04/2019 05:00	0.0	0	0	0	0	1
12/04/2019 06:00	0.0	0	0	0	0	1
12/04/2019 07:00	0.0	0	0	0	0	1
12/04/2019 08:00	0.0	0	0	0	0	1
12/04/2019 09:00	0.0	0	0	0	0	1
12/04/2019 10:00	0.0	0	0	0	0	1
12/04/2019 11:00	0.0	0	0	0	0	1
12/04/2019 12:00	0.0	0	0	0	0	1
12/04/2019 13:00	0.0	0	0	0	0	1
12/04/2019 14:00	0.0	0	0	0	0	1
12/04/2019 15:00	0.0	0	0	0	0	1
12/04/2019 16:00	0.0	0	0	0	0	1
12/04/2019 17:00	0.0	0	0	0	0	1
12/04/2019 18:00	0.0	0	0	0	0	1
12/04/2019 19:00	0.0	0	0	0	0	1
12/04/2019 20:00	0.0	0	0	0	0	1
12/04/2019 21:00	0.0	0	0	0	0	1
12/04/2019 22:00	0.0	0	0	0	0	1
12/04/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/05/2019 00:00	0.0	0	0	0	0	1
12/05/2019 01:00	0.0	0	0	0	0	1
12/05/2019 02:00	0.0	0	0	0	0	1
12/05/2019 03:00	0.0	0	0	0	0	1
12/05/2019 04:00	0.0	0	0	0	0	1
12/05/2019 05:00	0.0	0	0	0	0	1
12/05/2019 06:00	0.0	0	0	0	0	1
12/05/2019 07:00	0.0	0	0	0	0	1
12/05/2019 08:00	0.0	0	0	0	0	1
12/05/2019 09:00	0.0	0	0	0	0	1
12/05/2019 10:00	0.0	0	0	0	0	1
12/05/2019 11:00	0.0	0	0	0	0	1
12/05/2019 12:00	0.0	0	0	0	0	1
12/05/2019 13:00	0.0	0	0	0	0	1
12/05/2019 14:00	0.0	0	0	0	0	1
12/05/2019 15:00	0.0	0	0	0	0	1
12/05/2019 16:00	0.0	0	0	0	0	1
12/05/2019 17:00	0.0	0	0	0	0	1
12/05/2019 18:00	0.0	0	0	0	0	1
12/05/2019 19:00	0.0	0	0	0	0	1
12/05/2019 20:00	0.0	0	0	0	0	1
12/05/2019 21:00	0.0	0	0	0	0	1
12/05/2019 22:00	0.0	0	0	0	0	1
12/05/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/06/2019 00:00	0.0	0	0	0	0	1
12/06/2019 01:00	0.0	0	0	0	0	1
12/06/2019 02:00	0.0	0	0	0	0	1
12/06/2019 03:00	0.0	0	0	0	0	1
12/06/2019 04:00	0.0	0	0	0	0	1
12/06/2019 05:00	0.0	0	0	0	0	1
12/06/2019 06:00	0.0	0	0	0	0	1
12/06/2019 07:00	0.0	0	0	0	0	1
12/06/2019 08:00	0.0	0	0	0	0	1
12/06/2019 09:00	0.0	0	0	0	0	1
12/06/2019 10:00	0.0	0	0	0	0	1
12/06/2019 11:00	0.0	0	0	0	0	1
12/06/2019 12:00	0.0	0	0	0	0	1
12/06/2019 13:00	0.0	0	0	0	0	1
12/06/2019 14:00	0.0	0	0	0	0	1
12/06/2019 15:00	0.0	0	0	0	0	1
12/06/2019 16:00	0.0	0	0	0	0	1
12/06/2019 17:00	0.0	0	0	0	0	1
12/06/2019 18:00	0.0	0	0	0	0	1
12/06/2019 19:00	0.0	0	0	0	0	1
12/06/2019 20:00	0.0	0	0	0	0	1
12/06/2019 21:00	0.0	0	0	0	0	1
12/06/2019 22:00	0.0	0	0	0	0	1
12/06/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/07/2019 00:00	0.0	0	0	0	0	1
12/07/2019 01:00	0.0	0	0	0	0	1
12/07/2019 02:00	0.0	0	0	0	0	1
12/07/2019 03:00	0.0	0	0	0	0	1
12/07/2019 04:00	0.0	0	0	0	0	1
12/07/2019 05:00	0.0	0	0	0	0	1
12/07/2019 06:00	0.0	0	0	0	0	1
12/07/2019 07:00	0.0	0	0	0	0	1
12/07/2019 08:00	0.0	0	0	0	0	1
12/07/2019 09:00	0.0	0	0	0	0	1
12/07/2019 10:00	0.0	0	0	0	0	1
12/07/2019 11:00	0.0	0	0	0	0	1
12/07/2019 12:00	0.0	0	0	0	0	1
12/07/2019 13:00	0.0	0	0	0	0	1
12/07/2019 14:00	0.0	0	0	0	0	1
12/07/2019 15:00	0.0	0	0	0	0	1
12/07/2019 16:00	0.0	0	0	0	0	1
12/07/2019 17:00	0.0	0	0	0	0	1
12/07/2019 18:00	0.0	0	0	0	0	1
12/07/2019 19:00	0.0	0	0	0	0	1
12/07/2019 20:00	0.0	0	0	0	0	1
12/07/2019 21:00	0.0	0	0	0	0	1
12/07/2019 22:00	0.0	0	0	0	0	1
12/07/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/08/2019 00:00	0.0	0	0	0	0	1
12/08/2019 01:00	0.0	0	0	0	0	1
12/08/2019 02:00	0.0	0	0	0	0	1
12/08/2019 03:00	0.0	0	0	0	0	1
12/08/2019 04:00	0.0	0	0	0	0	1
12/08/2019 05:00	0.0	0	0	0	0	1
12/08/2019 06:00	0.0	0	0	0	0	1
12/08/2019 07:00	0.0	0	0	0	0	1
12/08/2019 08:00	0.0	0	0	0	0	1
12/08/2019 09:00	0.0	0	0	0	0	1
12/08/2019 10:00	0.0	0	0	0	0	1
12/08/2019 11:00	0.0	0	0	0	0	1
12/08/2019 12:00	0.0	0	0	0	0	1
12/08/2019 13:00	0.0	0	0	0	0	1
12/08/2019 14:00	0.0	0	0	0	0	1
12/08/2019 15:00	0.0	0	0	0	0	1
12/08/2019 16:00	0.0	0	0	0	0	1
12/08/2019 17:00	0.0	0	0	0	0	1
12/08/2019 18:00	0.0	0	0	0	0	1
12/08/2019 19:00	0.0	0	0	0	0	1
12/08/2019 20:00	0.0	0	0	0	0	1
12/08/2019 21:00	0.0	0	0	0	0	1
12/08/2019 22:00	0.0	0	0	0	0	1
12/08/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/09/2019 00:00	0.0	0	0	0	0	1
12/09/2019 01:00	0.0	0	0	0	0	1
12/09/2019 02:00	0.0	0	0	0	0	1
12/09/2019 03:00	0.0	0	0	0	0	1
12/09/2019 04:00	0.0	0	0	0	0	1
12/09/2019 05:00	0.0	0	0	0	0	1
12/09/2019 06:00	0.0	0	0	0	0	1
12/09/2019 07:00	0.0	0	0	0	0	1
12/09/2019 08:00	0.0	0	0	0	0	1
12/09/2019 09:00	0.0	0	0	0	0	1
12/09/2019 10:00	0.0	0	0	0	0	1
12/09/2019 11:00	0.0	0	0	0	0	1
12/09/2019 12:00	0.0	0	0	0	0	1
12/09/2019 13:00	0.0	0	0	0	0	1
12/09/2019 14:00	0.0	0	0	0	0	1
12/09/2019 15:00	0.0	0	0	0	0	1
12/09/2019 16:00	0.0	0	0	0	0	1
12/09/2019 17:00	0.0	0	0	0	0	1
12/09/2019 18:00	0.0	0	0	0	0	1
12/09/2019 19:00	0.0	0	0	0	0	1
12/09/2019 20:00	0.0	0	0	0	0	1
12/09/2019 21:00	0.0	0	0	0	0	1
12/09/2019 22:00	0.0	0	0	0	0	1
12/09/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/10/2019 00:00	0.0	0	0	0	0	1
12/10/2019 01:00	0.0	0	0	0	0	1
12/10/2019 02:00	0.0	0	0	0	0	1
12/10/2019 03:00	0.0	0	0	0	0	1
12/10/2019 04:00	0.0	0	0	0	0	1
12/10/2019 05:00	0.0	0	0	0	0	1
12/10/2019 06:00	0.0	0	0	0	0	1
12/10/2019 07:00	0.0	0	0	0	0	1
12/10/2019 08:00	0.0	0	0	0	0	1
12/10/2019 09:00	0.0	0	0	0	0	1
12/10/2019 10:00	0.0	0	0	0	0	1
12/10/2019 11:00	0.0	0	0	0	0	1
12/10/2019 12:00	0.0	0	0	0	0	1
12/10/2019 13:00	0.0	0	0	0	0	1
12/10/2019 14:00	0.0	0	0	0	0	1
12/10/2019 15:00	0.0	0	0	0	0	1
12/10/2019 16:00	0.0	0	0	0	0	1
12/10/2019 17:00	0.0	0	0	0	0	1
12/10/2019 18:00	0.0	0	0	0	0	1
12/10/2019 19:00	0.0	0	0	0	0	1
12/10/2019 20:00	0.0	0	0	0	0	1
12/10/2019 21:00	0.0	0	0	0	0	1
12/10/2019 22:00	0.0	0	0	0	0	1
12/10/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/11/2019 00:00	0.0	0	0	0	0	1
12/11/2019 01:00	0.0	0	0	0	0	1
12/11/2019 02:00	0.0	0	0	0	0	1
12/11/2019 03:00	0.0	0	0	0	0	1
12/11/2019 04:00	0.0	0	0	0	0	1
12/11/2019 05:00	0.0	0	0	0	0	1
12/11/2019 06:00	0.0	0	0	0	0	1
12/11/2019 07:00	0.0	0	0	0	0	1
12/11/2019 08:00	0.0	0	0	0	0	1
12/11/2019 09:00	0.0	0	0	0	0	1
12/11/2019 10:00	0.0	0	0	0	0	1
12/11/2019 11:00	0.0	0	0	0	0	1
12/11/2019 12:00	0.0	0	0	0	0	1
12/11/2019 13:00	0.0	0	0	0	0	1
12/11/2019 14:00	0.0	0	0	0	0	1
12/11/2019 15:00	0.0	0	0	0	0	1
12/11/2019 16:00	0.0	0	0	0	0	1
12/11/2019 17:00	0.0	0	0	0	0	1
12/11/2019 18:00	0.0	0	0	0	0	1
12/11/2019 19:00	0.0	0	0	0	0	1
12/11/2019 20:00	0.0	0	0	0	0	1
12/11/2019 21:00	0.0	0	0	0	0	1
12/11/2019 22:00	0.0	0	0	0	0	1
12/11/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/12/2019 00:00	0.0	0	0	0	0	1
12/12/2019 01:00	0.0	0	0	0	0	1
12/12/2019 02:00	0.0	0	0	0	0	1
12/12/2019 03:00	0.0	0	0	0	0	1
12/12/2019 04:00	0.0	0	0	0	0	1
12/12/2019 05:00	0.0	0	0	0	0	1
12/12/2019 06:00	0.0	0	0	0	0	1
12/12/2019 07:00	0.0	0	0	0	0	1
12/12/2019 08:00	0.0	0	0	0	0	1
12/12/2019 09:00	0.0	0	0	0	0	1
12/12/2019 10:00	0.0	0	0	0	0	1
12/12/2019 11:00	0.0	0	0	0	0	1
12/12/2019 12:00	0.0	0	0	0	0	1
12/12/2019 13:00	0.0	0	0	0	0	1
12/12/2019 14:00	0.0	0	0	0	0	1
12/12/2019 15:00	0.0	0	0	0	0	1
12/12/2019 16:00	0.0	0	0	0	0	1
12/12/2019 17:00	0.0	0	0	0	0	1
12/12/2019 18:00	0.0	0	0	0	0	1
12/12/2019 19:00	0.0	0	0	0	0	1
12/12/2019 20:00	0.0	0	0	0	0	1
12/12/2019 21:00	0.0	0	0	0	0	1
12/12/2019 22:00	0.0	0	0	0	0	1
12/12/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/13/2019 00:00	0.7	0	0	0	1	0
12/13/2019 01:00	0.0	0	0	0	0	0
12/13/2019 02:00	0.0	0	0	0	0	0
12/13/2019 03:00	0.0	0	0	0	0	0
12/13/2019 04:00	17.3	0	0	1	0	0
12/13/2019 05:00	6.8	0	0	1	0	0
12/13/2019 06:00	0.0	0	0	0	0	1
12/13/2019 07:00	0.0	0	0	0	0	1
12/13/2019 08:00	0.0	0	0	0	0	1
12/13/2019 09:00	0.0	0	0	0	0	1
12/13/2019 10:00	0.0	0	0	0	0	1
12/13/2019 11:00	0.0	0	0	0	0	1
12/13/2019 12:00	0.0	0	0	0	0	1
12/13/2019 13:00	0.0	0	0	0	0	1
12/13/2019 14:00	0.0	0	0	0	0	1
12/13/2019 15:00	0.0	0	0	0	0	1
12/13/2019 16:00	0.0	0	0	0	0	1
12/13/2019 17:00	0.0	0	0	0	0	1
12/13/2019 18:00	0.0	0	0	0	0	1
12/13/2019 19:00	0.0	0	0	0	0	1
12/13/2019 20:00	0.0	0	0	0	0	1
12/13/2019 21:00	0.0	0	0	0	0	1
12/13/2019 22:00	0.0	0	0	0	0	1
12/13/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	24.8 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	17.3	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/14/2019 00:00	0.0	0	0	0	0	1
12/14/2019 01:00	0.0	0	0	0	0	1
12/14/2019 02:00	0.0	0	0	0	0	1
12/14/2019 03:00	0.0	0	0	0	0	1
12/14/2019 04:00	0.0	0	0	0	0	1
12/14/2019 05:00	0.0	0	0	0	0	1
12/14/2019 06:00	0.0	0	0	0	0	1
12/14/2019 07:00	0.0	0	0	0	0	1
12/14/2019 08:00	0.0	0	0	0	0	1
12/14/2019 09:00	0.0	0	0	0	0	1
12/14/2019 10:00	0.0	0	0	0	0	1
12/14/2019 11:00	0.0	0	0	0	0	1
12/14/2019 12:00	0.0	0	0	0	0	1
12/14/2019 13:00	0.0	0	0	0	0	1
12/14/2019 14:00	0.0	0	0	0	0	1
12/14/2019 15:00	0.0	0	0	0	0	1
12/14/2019 16:00	0.0	0	0	0	0	1
12/14/2019 17:00	0.0	0	0	0	0	1
12/14/2019 18:00	0.0	0	0	0	0	1
12/14/2019 19:00	0.0	0	0	0	0	1
12/14/2019 20:00	0.0	0	0	0	0	1
12/14/2019 21:00	0.0	0	0	0	0	1
12/14/2019 22:00	0.0	0	0	0	0	1
12/14/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/15/2019 00:00	0.0	0	0	0	0	1
12/15/2019 01:00	0.0	0	0	0	0	1
12/15/2019 02:00	0.0	0	0	0	0	1
12/15/2019 03:00	0.0	0	0	0	0	1
12/15/2019 04:00	0.0	0	0	0	0	1
12/15/2019 05:00	0.0	0	0	0	0	1
12/15/2019 06:00	0.0	0	0	0	0	1
12/15/2019 07:00	0.0	0	0	0	0	1
12/15/2019 08:00	0.0	0	0	0	0	1
12/15/2019 09:00	0.0	0	0	0	0	1
12/15/2019 10:00	0.0	0	0	0	0	1
12/15/2019 11:00	0.0	0	0	0	0	1
12/15/2019 12:00	0.0	0	0	0	0	1
12/15/2019 13:00	0.0	0	0	0	0	1
12/15/2019 14:00	0.0	0	0	0	0	1
12/15/2019 15:00	0.0	0	0	0	0	1
12/15/2019 16:00	0.0	0	0	0	0	1
12/15/2019 17:00	0.0	0	0	0	0	1
12/15/2019 18:00	0.0	0	0	0	0	1
12/15/2019 19:00	0.0	0	0	0	0	1
12/15/2019 20:00	0.0	0	0	0	0	1
12/15/2019 21:00	0.0	0	0	0	0	1
12/15/2019 22:00	0.0	0	0	0	0	1
12/15/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/16/2019 00:00	0.0	0	0	0	0	1
12/16/2019 01:00	0.0	0	0	0	0	1
12/16/2019 02:00	0.0	0	0	0	0	1
12/16/2019 03:00	0.0	0	0	0	0	1
12/16/2019 04:00	0.0	0	0	0	0	1
12/16/2019 05:00	0.0	0	0	0	0	1
12/16/2019 06:00	0.0	0	0	0	0	1
12/16/2019 07:00	0.0	0	0	0	0	1
12/16/2019 08:00	0.0	0	0	0	0	1
12/16/2019 09:00	0.0	0	0	0	0	1
12/16/2019 10:00	0.0	0	0	0	0	1
12/16/2019 11:00	0.0	0	0	0	0	1
12/16/2019 12:00	0.0	0	0	0	0	1
12/16/2019 13:00	0.0	0	0	0	0	1
12/16/2019 14:00	0.0	0	0	0	0	1
12/16/2019 15:00	0.0	0	0	0	0	1
12/16/2019 16:00	0.0	0	0	0	0	1
12/16/2019 17:00	0.0	0	0	0	0	1
12/16/2019 18:00	0.0	0	0	0	0	1
12/16/2019 19:00	0.0	0	0	0	0	1
12/16/2019 20:00	0.0	0	0	0	0	1
12/16/2019 21:00	0.0	0	0	0	0	1
12/16/2019 22:00	0.0	0	0	0	0	1
12/16/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/17/2019 00:00	0.0	0	0	0	0	1
12/17/2019 01:00	0.0	0	0	0	0	1
12/17/2019 02:00	0.0	0	0	0	0	1
12/17/2019 03:00	0.0	0	0	0	0	1
12/17/2019 04:00	0.0	0	0	0	0	1
12/17/2019 05:00	0.0	0	0	0	0	1
12/17/2019 06:00	0.0	0	0	0	0	1
12/17/2019 07:00	0.0	0	0	0	0	1
12/17/2019 08:00	0.0	0	0	0	0	1
12/17/2019 09:00	0.0	0	0	0	0	1
12/17/2019 10:00	0.0	0	0	0	0	1
12/17/2019 11:00	0.0	0	0	0	0	1
12/17/2019 12:00	0.0	0	0	0	0	1
12/17/2019 13:00	0.0	0	0	0	0	1
12/17/2019 14:00	0.0	0	0	0	0	1
12/17/2019 15:00	0.0	0	0	0	0	1
12/17/2019 16:00	0.0	0	0	0	0	1
12/17/2019 17:00	0.0	0	0	0	0	1
12/17/2019 18:00	0.0	0	0	0	0	1
12/17/2019 19:00	0.0	0	0	0	0	1
12/17/2019 20:00	0.0	0	0	0	0	1
12/17/2019 21:00	0.0	0	0	0	0	1
12/17/2019 22:00	0.0	0	0	0	0	1
12/17/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/18/2019 00:00	0.0	0	0	0	0	1
12/18/2019 01:00	0.0	0	0	0	0	1
12/18/2019 02:00	0.0	0	0	0	0	1
12/18/2019 03:00	0.0	0	0	0	0	1
12/18/2019 04:00	0.0	0	0	0	0	1
12/18/2019 05:00	0.0	0	0	0	0	1
12/18/2019 06:00	0.0	0	0	0	0	1
12/18/2019 07:00	0.0	0	0	0	0	1
12/18/2019 08:00	0.0	0	0	0	0	1
12/18/2019 09:00	0.0	0	0	0	0	1
12/18/2019 10:00	0.0	0	0	0	0	1
12/18/2019 11:00	0.0	0	0	0	0	1
12/18/2019 12:00	0.0	0	0	0	0	1
12/18/2019 13:00	0.0	0	0	0	0	1
12/18/2019 14:00	0.0	0	0	0	0	1
12/18/2019 15:00	0.0	0	0	0	0	1
12/18/2019 16:00	0.0	0	0	0	0	1
12/18/2019 17:00	0.0	0	0	0	0	1
12/18/2019 18:00	0.0	0	0	0	0	1
12/18/2019 19:00	0.0	0	0	0	0	1
12/18/2019 20:00	0.0	0	0	0	0	1
12/18/2019 21:00	0.0	0	0	0	0	1
12/18/2019 22:00	0.0	0	0	0	0	1
12/18/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/19/2019 00:00	0.0	0	0	0	0	1
12/19/2019 01:00	0.0	0	0	0	0	1
12/19/2019 02:00	0.0	0	0	0	0	1
12/19/2019 03:00	0.0	0	0	0	0	1
12/19/2019 04:00	0.0	0	0	0	0	1
12/19/2019 05:00	0.0	0	0	0	0	1
12/19/2019 06:00	0.0	0	0	0	0	1
12/19/2019 07:00	0.0	0	0	0	0	1
12/19/2019 08:00	0.0	0	0	0	0	1
12/19/2019 09:00	0.0	0	0	0	0	1
12/19/2019 10:00	0.0	0	0	0	0	1
12/19/2019 11:00	0.0	0	0	0	0	1
12/19/2019 12:00	0.0	0	0	0	0	1
12/19/2019 13:00	0.0	0	0	0	0	1
12/19/2019 14:00	0.0	0	0	0	0	1
12/19/2019 15:00	0.0	0	0	0	0	1
12/19/2019 16:00	0.0	0	0	0	0	1
12/19/2019 17:00	0.0	0	0	0	0	1
12/19/2019 18:00	0.0	0	0	0	0	1
12/19/2019 19:00	0.0	0	0	0	0	1
12/19/2019 20:00	0.0	0	0	0	0	1
12/19/2019 21:00	0.0	0	0	0	0	1
12/19/2019 22:00	0.0	0	0	0	0	1
12/19/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/20/2019 00:00	0.0	0	0	0	0	1
12/20/2019 01:00	0.0	0	0	0	0	1
12/20/2019 02:00	0.0	0	0	0	0	1
12/20/2019 03:00	0.0	0	0	0	0	1
12/20/2019 04:00	0.0	0	0	0	0	1
12/20/2019 05:00	0.0	0	0	0	0	1
12/20/2019 06:00	0.0	0	0	0	0	1
12/20/2019 07:00	0.0	0	0	0	0	1
12/20/2019 08:00	0.0	0	0	0	0	1
12/20/2019 09:00	0.0	0	0	0	0	1
12/20/2019 10:00	0.0	0	0	0	0	1
12/20/2019 11:00	0.0	0	0	0	0	1
12/20/2019 12:00	0.0	0	0	0	0	1
12/20/2019 13:00	0.0	0	0	0	0	1
12/20/2019 14:00	0.0	0	0	0	0	1
12/20/2019 15:00	0.0	0	0	0	0	1
12/20/2019 16:00	0.0	0	0	0	0	1
12/20/2019 17:00	0.0	0	0	0	0	1
12/20/2019 18:00	0.0	0	0	0	0	1
12/20/2019 19:00	0.0	0	0	0	0	1
12/20/2019 20:00	0.0	0	0	0	0	1
12/20/2019 21:00	0.0	0	0	0	0	1
12/20/2019 22:00	0.0	0	0	0	0	1
12/20/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/21/2019 00:00	0.0	0	0	0	0	1
12/21/2019 01:00	0.0	0	0	0	0	1
12/21/2019 02:00	0.0	0	0	0	0	1
12/21/2019 03:00	0.0	0	0	0	0	1
12/21/2019 04:00	0.0	0	0	0	0	1
12/21/2019 05:00	0.0	0	0	0	0	1
12/21/2019 06:00	0.0	0	0	0	0	1
12/21/2019 07:00	0.0	0	0	0	0	1
12/21/2019 08:00	0.0	0	0	0	0	1
12/21/2019 09:00	0.0	0	0	0	0	1
12/21/2019 10:00	0.0	0	0	0	0	1
12/21/2019 11:00	0.0	0	0	0	0	1
12/21/2019 12:00	0.0	0	0	0	0	1
12/21/2019 13:00	0.0	0	0	0	0	1
12/21/2019 14:00	0.0	0	0	0	0	1
12/21/2019 15:00	0.0	0	0	0	0	1
12/21/2019 16:00	0.0	0	0	0	0	1
12/21/2019 17:00	0.0	0	0	0	0	1
12/21/2019 18:00	0.0	0	0	0	0	1
12/21/2019 19:00	0.0	0	0	0	0	1
12/21/2019 20:00	0.0	0	0	0	0	1
12/21/2019 21:00	0.0	0	0	0	0	1
12/21/2019 22:00	0.0	0	0	0	0	1
12/21/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/22/2019 00:00	0.0	0	0	0	0	1
12/22/2019 01:00	0.0	0	0	0	0	1
12/22/2019 02:00	0.0	0	0	0	0	1
12/22/2019 03:00	0.0	0	0	0	0	1
12/22/2019 04:00	0.0	0	0	0	0	1
12/22/2019 05:00	0.0	0	0	0	0	1
12/22/2019 06:00	0.0	0	0	0	0	1
12/22/2019 07:00	0.0	0	0	0	0	1
12/22/2019 08:00	0.0	0	0	0	0	1
12/22/2019 09:00	0.0	0	0	0	0	1
12/22/2019 10:00	0.0	0	0	0	0	1
12/22/2019 11:00	0.0	0	0	0	0	1
12/22/2019 12:00	0.0	0	0	0	0	1
12/22/2019 13:00	0.0	0	0	0	0	1
12/22/2019 14:00	0.0	0	0	0	0	1
12/22/2019 15:00	0.0	0	0	0	0	1
12/22/2019 16:00	0.0	0	0	0	0	1
12/22/2019 17:00	0.0	0	0	0	0	1
12/22/2019 18:00	0.0	0	0	0	0	1
12/22/2019 19:00	0.0	0	0	0	0	1
12/22/2019 20:00	0.0	0	0	0	0	1
12/22/2019 21:00	0.0	0	0	0	0	1
12/22/2019 22:00	0.0	0	0	0	0	1
12/22/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/23/2019 00:00	0.0	0	0	0	0	1
12/23/2019 01:00	0.0	0	0	0	0	1
12/23/2019 02:00	0.0	0	0	0	0	1
12/23/2019 03:00	0.0	0	0	0	0	1
12/23/2019 04:00	0.0	0	0	0	0	1
12/23/2019 05:00	0.0	0	0	0	0	1
12/23/2019 06:00	0.0	0	0	0	0	1
12/23/2019 07:00	0.0	0	0	0	0	1
12/23/2019 08:00	0.0	0	0	0	0	1
12/23/2019 09:00	0.0	0	0	0	0	1
12/23/2019 10:00	0.0	0	0	0	0	1
12/23/2019 11:00	0.0	0	0	0	0	1
12/23/2019 12:00	0.0	0	0	0	0	1
12/23/2019 13:00	0.0	0	0	0	0	1
12/23/2019 14:00	0.0	0	0	0	0	1
12/23/2019 15:00	0.0	0	0	0	0	1
12/23/2019 16:00	0.0	0	0	0	0	1
12/23/2019 17:00	0.0	0	0	0	0	1
12/23/2019 18:00	0.0	0	0	0	0	1
12/23/2019 19:00	0.0	0	0	0	0	1
12/23/2019 20:00	0.0	0	0	0	0	1
12/23/2019 21:00	0.0	0	0	0	0	1
12/23/2019 22:00	0.0	0	0	0	0	1
12/23/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/24/2019 00:00	0.0	0	0	0	0	1
12/24/2019 01:00	0.0	0	0	0	0	1
12/24/2019 02:00	0.0	0	0	0	0	1
12/24/2019 03:00	0.0	0	0	0	0	1
12/24/2019 04:00	0.0	0	0	0	0	1
12/24/2019 05:00	0.0	0	0	0	0	1
12/24/2019 06:00	0.0	0	0	0	0	1
12/24/2019 07:00	0.0	0	0	0	0	1
12/24/2019 08:00	0.0	0	0	0	0	1
12/24/2019 09:00	0.0	0	0	0	0	1
12/24/2019 10:00	0.0	0	0	0	0	1
12/24/2019 11:00	0.0	0	0	0	0	1
12/24/2019 12:00	0.0	0	0	0	0	1
12/24/2019 13:00	0.0	0	0	0	0	1
12/24/2019 14:00	0.0	0	0	0	0	1
12/24/2019 15:00	0.0	0	0	0	0	1
12/24/2019 16:00	0.0	0	0	0	0	1
12/24/2019 17:00	0.0	0	0	0	0	1
12/24/2019 18:00	0.0	0	0	0	0	1
12/24/2019 19:00	0.0	0	0	0	0	1
12/24/2019 20:00	0.0	0	0	0	0	1
12/24/2019 21:00	0.0	0	0	0	0	1
12/24/2019 22:00	0.0	0	0	0	0	1
12/24/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/25/2019 00:00	0.0	0	0	0	0	1
12/25/2019 01:00	0.0	0	0	0	0	1
12/25/2019 02:00	0.0	0	0	0	0	1
12/25/2019 03:00	0.0	0	0	0	0	1
12/25/2019 04:00	0.0	0	0	0	0	1
12/25/2019 05:00	0.0	0	0	0	0	1
12/25/2019 06:00	0.0	0	0	0	0	1
12/25/2019 07:00	0.0	0	0	0	0	1
12/25/2019 08:00	0.0	0	0	0	0	1
12/25/2019 09:00	0.0	0	0	0	0	1
12/25/2019 10:00	0.0	0	0	0	0	1
12/25/2019 11:00	0.0	0	0	0	0	1
12/25/2019 12:00	0.0	0	0	0	0	1
12/25/2019 13:00	0.0	0	0	0	0	1
12/25/2019 14:00	0.0	0	0	0	0	1
12/25/2019 15:00	0.0	0	0	0	0	1
12/25/2019 16:00	0.0	0	0	0	0	1
12/25/2019 17:00	0.0	0	0	0	0	1
12/25/2019 18:00	0.0	0	0	0	0	1
12/25/2019 19:00	0.0	0	0	0	0	1
12/25/2019 20:00	0.0	0	0	0	0	1
12/25/2019 21:00	0.0	0	0	0	0	1
12/25/2019 22:00	0.0	0	0	0	0	1
12/25/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/26/2019 00:00	0.0	0	0	0	0	1
12/26/2019 01:00	0.0	0	0	0	0	1
12/26/2019 02:00	0.0	0	0	0	0	1
12/26/2019 03:00	0.0	0	0	0	0	1
12/26/2019 04:00	0.0	0	0	0	0	1
12/26/2019 05:00	0.0	0	0	0	0	1
12/26/2019 06:00	0.0	0	0	0	0	1
12/26/2019 07:00	0.0	0	0	0	0	1
12/26/2019 08:00	0.0	0	0	0	0	1
12/26/2019 09:00	0.0	0	0	0	0	1
12/26/2019 10:00	0.0	0	0	0	0	1
12/26/2019 11:00	0.0	0	0	0	0	1
12/26/2019 12:00	0.0	0	0	0	0	1
12/26/2019 13:00	0.0	0	0	0	0	1
12/26/2019 14:00	0.0	0	0	0	0	1
12/26/2019 15:00	0.0	0	0	0	0	1
12/26/2019 16:00	0.0	0	0	0	0	1
12/26/2019 17:00	0.0	0	0	0	0	1
12/26/2019 18:00	0.0	0	0	0	0	1
12/26/2019 19:00	0.0	0	0	0	0	1
12/26/2019 20:00	0.0	0	0	0	0	1
12/26/2019 21:00	0.0	0	0	0	0	1
12/26/2019 22:00	0.0	0	0	0	0	1
12/26/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/27/2019 00:00	0.0	0	0	0	0	1
12/27/2019 01:00	0.0	0	0	0	0	1
12/27/2019 02:00	0.0	0	0	0	0	1
12/27/2019 03:00	0.0	0	0	0	0	1
12/27/2019 04:00	0.0	0	0	0	0	1
12/27/2019 05:00	0.0	0	0	0	0	1
12/27/2019 06:00	0.0	0	0	0	0	1
12/27/2019 07:00	0.0	0	0	0	0	1
12/27/2019 08:00	0.0	0	0	0	0	1
12/27/2019 09:00	0.0	0	0	0	0	1
12/27/2019 10:00	0.0	0	0	0	0	1
12/27/2019 11:00	0.0	0	0	0	0	1
12/27/2019 12:00	0.0	0	0	0	0	1
12/27/2019 13:00	0.0	0	0	0	0	1
12/27/2019 14:00	0.0	0	0	0	0	1
12/27/2019 15:00	0.0	0	0	0	0	1
12/27/2019 16:00	0.0	0	0	0	0	1
12/27/2019 17:00	0.0	0	0	0	0	1
12/27/2019 18:00	0.0	0	0	0	0	1
12/27/2019 19:00	0.0	0	0	0	0	1
12/27/2019 20:00	0.0	0	0	0	0	1
12/27/2019 21:00	0.0	0	0	0	0	1
12/27/2019 22:00	0.0	0	0	0	0	1
12/27/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/28/2019 00:00	0.0	0	0	0	0	1
12/28/2019 01:00	0.0	0	0	0	0	1
12/28/2019 02:00	0.0	0	0	0	0	1
12/28/2019 03:00	0.0	0	0	0	0	1
12/28/2019 04:00	0.0	0	0	0	0	1
12/28/2019 05:00	0.0	0	0	0	0	1
12/28/2019 06:00	0.0	0	0	0	0	1
12/28/2019 07:00	0.0	0	0	0	0	1
12/28/2019 08:00	0.0	0	0	0	0	1
12/28/2019 09:00	0.0	0	0	0	0	1
12/28/2019 10:00	0.0	0	0	0	0	1
12/28/2019 11:00	0.0	0	0	0	0	1
12/28/2019 12:00	0.0	0	0	0	0	1
12/28/2019 13:00	0.0	0	0	0	0	1
12/28/2019 14:00	0.0	0	0	0	0	1
12/28/2019 15:00	0.0	0	0	0	0	1
12/28/2019 16:00	0.0	0	0	0	0	1
12/28/2019 17:00	0.0	0	0	0	0	1
12/28/2019 18:00	0.0	0	0	0	0	1
12/28/2019 19:00	0.0	0	0	0	0	1
12/28/2019 20:00	0.0	0	0	0	0	1
12/28/2019 21:00	0.0	0	0	0	0	1
12/28/2019 22:00	0.0	0	0	0	0	1
12/28/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/29/2019 00:00	0.0	0	0	0	0	1
12/29/2019 01:00	0.0	0	0	0	0	1
12/29/2019 02:00	0.0	0	0	0	0	1
12/29/2019 03:00	0.0	0	0	0	0	1
12/29/2019 04:00	0.0	0	0	0	0	1
12/29/2019 05:00	0.0	0	0	0	0	1
12/29/2019 06:00	0.0	0	0	0	0	1
12/29/2019 07:00	0.0	0	0	0	0	1
12/29/2019 08:00	0.0	0	0	0	0	1
12/29/2019 09:00	0.0	0	0	0	0	1
12/29/2019 10:00	0.0	0	0	0	0	1
12/29/2019 11:00	0.0	0	0	0	0	1
12/29/2019 12:00	0.0	0	0	0	0	1
12/29/2019 13:00	0.0	0	0	0	0	1
12/29/2019 14:00	0.0	0	0	0	0	1
12/29/2019 15:00	0.0	0	0	0	0	1
12/29/2019 16:00	0.0	0	0	0	0	1
12/29/2019 17:00	0.0	0	0	0	0	1
12/29/2019 18:00	0.0	0	0	0	0	1
12/29/2019 19:00	0.0	0	0	0	0	1
12/29/2019 20:00	0.0	0	0	0	0	1
12/29/2019 21:00	0.0	0	0	0	0	1
12/29/2019 22:00	0.0	0	0	0	0	1
12/29/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/30/2019 00:00	0.0	0	0	0	0	1
12/30/2019 01:00	0.0	0	0	0	0	1
12/30/2019 02:00	0.0	0	0	0	0	1
12/30/2019 03:00	0.0	0	0	0	0	1
12/30/2019 04:00	0.0	0	0	0	0	1
12/30/2019 05:00	0.0	0	0	0	0	1
12/30/2019 06:00	0.0	0	0	0	0	1
12/30/2019 07:00	0.0	0	0	0	0	1
12/30/2019 08:00	0.0	0	0	0	0	1
12/30/2019 09:00	0.0	0	0	0	0	1
12/30/2019 10:00	0.0	0	0	0	0	1
12/30/2019 11:00	0.0	0	0	0	0	1
12/30/2019 12:00	0.0	0	0	0	0	1
12/30/2019 13:00	0.0	0	0	0	0	1
12/30/2019 14:00	0.0	0	0	0	0	1
12/30/2019 15:00	0.0	0	0	0	0	1
12/30/2019 16:00	0.0	0	0	0	0	1
12/30/2019 17:00	0.0	0	0	0	0	1
12/30/2019 18:00	0.0	0	0	0	0	1
12/30/2019 19:00	0.0	0	0	0	0	1
12/30/2019 20:00	0.0	0	0	0	0	1
12/30/2019 21:00	0.0	0	0	0	0	1
12/30/2019 22:00	0.0	0	0	0	0	1
12/30/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/31/2019 00:00	0.0	0	0	0	0	1
12/31/2019 01:00	0.0	0	0	0	0	1
12/31/2019 02:00	0.0	0	0	0	0	1
12/31/2019 03:00	0.0	0	0	0	0	1
12/31/2019 04:00	0.0	0	0	0	0	1
12/31/2019 05:00	0.0	0	0	0	0	1
12/31/2019 06:00	0.0	0	0	0	0	1
12/31/2019 07:00	0.0	0	0	0	0	1
12/31/2019 08:00	0.0	0	0	0	0	1
12/31/2019 09:00	0.0	0	0	0	0	1
12/31/2019 10:00	0.0	0	0	0	0	1
12/31/2019 11:00	0.0	0	0	0	0	1
12/31/2019 12:00	0.0	0	0	0	0	1
12/31/2019 13:00	0.0	0	0	0	0	1
12/31/2019 14:00	0.0	0	0	0	0	1
12/31/2019 15:00	0.0	0	0	0	0	1
12/31/2019 16:00	0.0	0	0	0	0	1
12/31/2019 17:00	0.0	0	0	0	0	1
12/31/2019 18:00	0.0	0	0	0	0	1
12/31/2019 19:00	0.0	0	0	0	0	1
12/31/2019 20:00	0.0	0	0	0	0	1
12/31/2019 21:00	0.0	0	0	0	0	1
12/31/2019 22:00	0.0	0	0	0	0	1
12/31/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/01/2019 00:00	35.2	0	0	0	1	0
10/01/2019 01:00	0.0	0	0	0	0	0
10/01/2019 02:00	0.0	0	0	0	0	0
10/01/2019 03:00	0.0	0	0	0	0	0
10/01/2019 04:00	2,060.3	0	0	1	0	0
10/01/2019 05:00	4,675.8	0	0	1	0	0
10/01/2019 06:00	0.0	0	0	0	0	1
10/01/2019 07:00	0.0	0	0	0	0	1
10/01/2019 08:00	0.0	0	0	0	0	1
10/01/2019 09:00	0.0	0	0	0	0	1
10/01/2019 10:00	0.0	0	0	0	0	1
10/01/2019 11:00	0.0	0	0	0	0	1
10/01/2019 12:00	0.0	0	0	0	0	1
10/01/2019 13:00	0.0	0	0	0	0	1
10/01/2019 14:00	0.0	0	0	0	0	1
10/01/2019 15:00	0.0	0	0	0	0	1
10/01/2019 16:00	0.0	0	0	0	0	1
10/01/2019 17:00	0.0	0	0	0	0	1
10/01/2019 18:00	0.0	0	0	0	0	1
10/01/2019 19:00	0.0	0	0	0	0	1
10/01/2019 20:00	0.0	0	0	0	0	1
10/01/2019 21:00	0.0	0	0	0	0	1
10/01/2019 22:00	0.0	0	0	0	0	1
10/01/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,771.3 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,675.8	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/02/2019 00:00	0.0	0	0	0	0	1
10/02/2019 01:00	0.0	0	0	0	0	1
10/02/2019 02:00	0.0	0	0	0	0	1
10/02/2019 03:00	0.0	0	0	0	0	1
10/02/2019 04:00	0.0	0	0	0	0	1
10/02/2019 05:00	0.0	0	0	0	0	1
10/02/2019 06:00	0.0	0	0	0	0	1
10/02/2019 07:00	0.0	0	0	0	0	1
10/02/2019 08:00	0.0	0	0	0	0	1
10/02/2019 09:00	0.0	0	0	0	0	1
10/02/2019 10:00	0.0	0	0	0	0	1
10/02/2019 11:00	0.0	0	0	0	0	1
10/02/2019 12:00	0.0	0	0	0	0	1
10/02/2019 13:00	0.0	0	0	0	0	1
10/02/2019 14:00	0.0	0	0	0	0	1
10/02/2019 15:00	0.0	0	0	0	0	1
10/02/2019 16:00	0.0	0	0	0	0	1
10/02/2019 17:00	0.0	0	0	0	0	1
10/02/2019 18:00	0.0	0	0	0	0	1
10/02/2019 19:00	0.0	0	0	0	0	1
10/02/2019 20:00	0.0	0	0	0	0	1
10/02/2019 21:00	0.0	0	0	0	0	1
10/02/2019 22:00	0.0	0	0	0	0	1
10/02/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/03/2019 00:00	0.0	0	0	0	0	1
10/03/2019 01:00	0.0	0	0	0	0	1
10/03/2019 02:00	0.0	0	0	0	0	1
10/03/2019 03:00	0.0	0	0	0	0	1
10/03/2019 04:00	0.0	0	0	0	0	1
10/03/2019 05:00	0.0	0	0	0	0	1
10/03/2019 06:00	0.0	0	0	0	0	1
10/03/2019 07:00	0.0	0	0	0	0	1
10/03/2019 08:00	0.0	0	0	0	0	1
10/03/2019 09:00	0.0	0	0	0	0	1
10/03/2019 10:00	0.0	0	0	0	0	1
10/03/2019 11:00	0.0	0	0	0	0	1
10/03/2019 12:00	0.0	0	0	0	0	1
10/03/2019 13:00	0.0	0	0	0	0	1
10/03/2019 14:00	0.0	0	0	0	0	1
10/03/2019 15:00	0.0	0	0	0	0	1
10/03/2019 16:00	0.0	0	0	0	0	1
10/03/2019 17:00	0.0	0	0	0	0	1
10/03/2019 18:00	0.0	0	0	0	0	1
10/03/2019 19:00	0.0	0	0	0	0	1
10/03/2019 20:00	0.0	0	0	0	0	1
10/03/2019 21:00	135.5	0	0	0	1	0
10/03/2019 22:00	0.0	0	0	0	0	0
10/03/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	135.5 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	135.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/04/2019 00:00	0.0	0	0	0	0	0
10/04/2019 01:00	0.0	0	0	0	0	0
10/04/2019 02:00	0.0	0	0	0	0	0
10/04/2019 03:00	0.0	0	0	0	0	0
10/04/2019 04:00	0.0	0	0	0	0	0
10/04/2019 05:00	0.0	0	0	0	0	0
10/04/2019 06:00	0.0	0	0	0	0	0
10/04/2019 07:00	0.0	0	0	0	0	0
10/04/2019 08:00	0.0	0	0	0	0	0
10/04/2019 09:00	0.0	0	0	0	0	0
10/04/2019 10:00	0.0	0	0	0	0	0
10/04/2019 11:00	0.0	0	0	0	0	0
10/04/2019 12:00	0.0	0	0	0	0	0
10/04/2019 13:00	1,614.7	0	1	0	0	0
10/04/2019 14:00	6,305.3	0	1	0	0	0
10/04/2019 15:00	0.0	0	0	0	0	1
10/04/2019 16:00	0.0	0	0	0	0	1
10/04/2019 17:00	0.0	0	0	0	0	1
10/04/2019 18:00	0.0	0	0	0	0	1
10/04/2019 19:00	0.0	0	0	0	0	1
10/04/2019 20:00	0.0	0	0	0	0	1
10/04/2019 21:00	0.0	0	0	0	0	1
10/04/2019 22:00	0.0	0	0	0	0	1
10/04/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,920.0 #	0 #	2 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,305.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/05/2019 00:00	0.0	0	0	0	0	1
10/05/2019 01:00	0.0	0	0	0	0	1
10/05/2019 02:00	0.0	0	0	0	0	1
10/05/2019 03:00	0.0	0	0	0	0	1
10/05/2019 04:00	0.0	0	0	0	0	1
10/05/2019 05:00	0.0	0	0	0	0	1
10/05/2019 06:00	0.0	0	0	0	0	1
10/05/2019 07:00	0.0	0	0	0	0	1
10/05/2019 08:00	0.0	0	0	0	0	1
10/05/2019 09:00	0.0	0	0	0	0	1
10/05/2019 10:00	0.0	0	0	0	0	1
10/05/2019 11:00	0.0	0	0	0	0	1
10/05/2019 12:00	0.0	0	0	0	0	1
10/05/2019 13:00	0.0	0	0	0	0	1
10/05/2019 14:00	0.0	0	0	0	0	1
10/05/2019 15:00	0.0	0	0	0	0	1
10/05/2019 16:00	0.0	0	0	0	0	1
10/05/2019 17:00	0.0	0	0	0	0	1
10/05/2019 18:00	0.0	0	0	0	0	1
10/05/2019 19:00	0.0	0	0	0	0	1
10/05/2019 20:00	0.0	0	0	0	0	1
10/05/2019 21:00	0.0	0	0	0	0	1
10/05/2019 22:00	0.0	0	0	0	0	1
10/05/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/06/2019 00:00	0.0	0	0	0	0	1
10/06/2019 01:00	0.0	0	0	0	0	1
10/06/2019 02:00	0.0	0	0	0	0	1
10/06/2019 03:00	0.0	0	0	0	0	1
10/06/2019 04:00	0.0	0	0	0	0	1
10/06/2019 05:00	0.0	0	0	0	0	1
10/06/2019 06:00	0.0	0	0	0	0	1
10/06/2019 07:00	0.0	0	0	0	0	1
10/06/2019 08:00	0.0	0	0	0	0	1
10/06/2019 09:00	0.0	0	0	0	0	1
10/06/2019 10:00	0.0	0	0	0	0	1
10/06/2019 11:00	0.0	0	0	0	0	1
10/06/2019 12:00	0.0	0	0	0	0	1
10/06/2019 13:00	0.0	0	0	0	0	1
10/06/2019 14:00	0.0	0	0	0	0	1
10/06/2019 15:00	0.0	0	0	0	0	1
10/06/2019 16:00	0.0	0	0	0	0	1
10/06/2019 17:00	0.0	0	0	0	0	1
10/06/2019 18:00	0.0	0	0	0	0	1
10/06/2019 19:00	0.0	0	0	0	0	1
10/06/2019 20:00	0.0	0	0	0	0	1
10/06/2019 21:00	0.0	0	0	0	0	1
10/06/2019 22:00	0.0	0	0	0	0	1
10/06/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/07/2019 00:00	0.0	0	0	0	0	1
10/07/2019 01:00	0.0	0	0	0	0	1
10/07/2019 02:00	0.0	0	0	0	0	1
10/07/2019 03:00	0.0	0	0	0	0	1
10/07/2019 04:00	0.0	0	0	0	0	1
10/07/2019 05:00	0.0	0	0	0	0	1
10/07/2019 06:00	0.0	0	0	0	0	1
10/07/2019 07:00	0.0	0	0	0	0	1
10/07/2019 08:00	0.0	0	0	0	0	1
10/07/2019 09:00	0.0	0	0	0	0	1
10/07/2019 10:00	0.0	0	0	0	0	1
10/07/2019 11:00	0.0	0	0	0	0	1
10/07/2019 12:00	0.0	0	0	0	0	1
10/07/2019 13:00	0.0	0	0	0	0	1
10/07/2019 14:00	0.0	0	0	0	0	1
10/07/2019 15:00	0.0	0	0	0	0	1
10/07/2019 16:00	0.0	0	0	0	0	1
10/07/2019 17:00	0.0	0	0	0	0	1
10/07/2019 18:00	0.0	0	0	0	0	1
10/07/2019 19:00	0.0	0	0	0	0	1
10/07/2019 20:00	0.0	0	0	0	0	1
10/07/2019 21:00	0.0	0	0	0	0	1
10/07/2019 22:00	0.0	0	0	0	0	1
10/07/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/08/2019 00:00	0.0	0	0	0	0	1
10/08/2019 01:00	0.0	0	0	0	0	1
10/08/2019 02:00	0.0	0	0	0	0	1
10/08/2019 03:00	0.0	0	0	0	0	1
10/08/2019 04:00	0.0	0	0	0	0	1
10/08/2019 05:00	0.0	0	0	0	0	1
10/08/2019 06:00	0.0	0	0	0	0	1
10/08/2019 07:00	0.0	0	0	0	0	1
10/08/2019 08:00	0.0	0	0	0	0	1
10/08/2019 09:00	0.0	0	0	0	0	1
10/08/2019 10:00	0.0	0	0	0	0	1
10/08/2019 11:00	0.0	0	0	0	0	1
10/08/2019 12:00	0.0	0	0	0	0	1
10/08/2019 13:00	0.0	0	0	0	0	1
10/08/2019 14:00	0.0	0	0	0	0	1
10/08/2019 15:00	0.0	0	0	0	0	1
10/08/2019 16:00	0.0	0	0	0	0	1
10/08/2019 17:00	0.0	0	0	0	0	1
10/08/2019 18:00	0.0	0	0	0	0	1
10/08/2019 19:00	0.0	0	0	0	0	1
10/08/2019 20:00	0.0	0	0	0	0	1
10/08/2019 21:00	0.0	0	0	0	0	1
10/08/2019 22:00	0.0	0	0	0	0	1
10/08/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/09/2019 00:00	0.0	0	0	0	0	1
10/09/2019 01:00	0.0	0	0	0	0	1
10/09/2019 02:00	0.0	0	0	0	0	1
10/09/2019 03:00	0.0	0	0	0	0	1
10/09/2019 04:00	0.0	0	0	0	0	1
10/09/2019 05:00	0.0	0	0	0	0	1
10/09/2019 06:00	0.0	0	0	0	0	1
10/09/2019 07:00	0.0	0	0	0	0	1
10/09/2019 08:00	0.0	0	0	0	0	1
10/09/2019 09:00	0.0	0	0	0	0	1
10/09/2019 10:00	0.0	0	0	0	0	1
10/09/2019 11:00	0.0	0	0	0	0	1
10/09/2019 12:00	0.0	0	0	0	0	1
10/09/2019 13:00	0.0	0	0	0	0	1
10/09/2019 14:00	0.0	0	0	0	0	1
10/09/2019 15:00	0.0	0	0	0	0	1
10/09/2019 16:00	0.0	0	0	0	0	1
10/09/2019 17:00	0.0	0	0	0	0	1
10/09/2019 18:00	0.0	0	0	0	0	1
10/09/2019 19:00	0.0	0	0	0	0	1
10/09/2019 20:00	0.0	0	0	0	0	1
10/09/2019 21:00	0.0	0	0	0	0	1
10/09/2019 22:00	0.0	0	0	0	0	1
10/09/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/10/2019 00:00	0.0	0	0	0	0	1
10/10/2019 01:00	0.0	0	0	0	0	1
10/10/2019 02:00	0.0	0	0	0	0	1
10/10/2019 03:00	0.0	0	0	0	0	1
10/10/2019 04:00	0.0	0	0	0	0	1
10/10/2019 05:00	0.0	0	0	0	0	1
10/10/2019 06:00	0.0	0	0	0	0	1
10/10/2019 07:00	0.0	0	0	0	0	1
10/10/2019 08:00	0.0	0	0	0	0	1
10/10/2019 09:00	0.0	0	0	0	0	1
10/10/2019 10:00	0.0	0	0	0	0	1
10/10/2019 11:00	0.0	0	0	0	0	1
10/10/2019 12:00	0.0	0	0	0	0	1
10/10/2019 13:00	0.0	0	0	0	0	1
10/10/2019 14:00	0.0	0	0	0	0	1
10/10/2019 15:00	0.0	0	0	0	0	1
10/10/2019 16:00	0.0	0	0	0	0	1
10/10/2019 17:00	0.0	0	0	0	0	1
10/10/2019 18:00	0.0	0	0	0	0	1
10/10/2019 19:00	0.0	0	0	0	0	1
10/10/2019 20:00	0.0	0	0	0	0	1
10/10/2019 21:00	0.0	0	0	0	0	1
10/10/2019 22:00	0.0	0	0	0	0	1
10/10/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/11/2019 00:00	0.0	0	0	0	0	1
10/11/2019 01:00	0.0	0	0	0	0	1
10/11/2019 02:00	0.0	0	0	0	0	1
10/11/2019 03:00	0.0	0	0	0	0	1
10/11/2019 04:00	0.0	0	0	0	0	1
10/11/2019 05:00	0.0	0	0	0	0	1
10/11/2019 06:00	0.0	0	0	0	0	1
10/11/2019 07:00	0.0	0	0	0	0	1
10/11/2019 08:00	0.0	0	0	0	0	1
10/11/2019 09:00	0.0	0	0	0	0	1
10/11/2019 10:00	0.0	0	0	0	0	1
10/11/2019 11:00	0.0	0	0	0	0	1
10/11/2019 12:00	0.0	0	0	0	0	1
10/11/2019 13:00	0.0	0	0	0	0	1
10/11/2019 14:00	0.0	0	0	0	0	1
10/11/2019 15:00	0.0	0	0	0	0	1
10/11/2019 16:00	0.0	0	0	0	0	1
10/11/2019 17:00	0.0	0	0	0	0	1
10/11/2019 18:00	0.0	0	0	0	0	1
10/11/2019 19:00	0.0	0	0	0	0	1
10/11/2019 20:00	0.0	0	0	0	0	1
10/11/2019 21:00	0.0	0	0	0	0	1
10/11/2019 22:00	0.0	0	0	0	0	1
10/11/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/12/2019 00:00	0.0	0	0	0	0	1
10/12/2019 01:00	0.0	0	0	0	0	1
10/12/2019 02:00	0.0	0	0	0	0	1
10/12/2019 03:00	0.0	0	0	0	0	1
10/12/2019 04:00	0.0	0	0	0	0	1
10/12/2019 05:00	0.0	0	0	0	0	1
10/12/2019 06:00	0.0	0	0	0	0	1
10/12/2019 07:00	109.8	0	0	0	1	0
10/12/2019 08:00	0.0	0	0	0	0	0
10/12/2019 09:00	0.0	0	0	0	0	0
10/12/2019 10:00	0.0	0	0	0	0	0
10/12/2019 11:00	0.0	0	0	0	0	0
10/12/2019 12:00	0.0	0	0	0	0	0
10/12/2019 13:00	0.0	0	0	0	0	0
10/12/2019 14:00	1,753.9	0	0	1	0	0
10/12/2019 15:00	5,320.3	0	0	1	0	0
10/12/2019 16:00	0.0	0	0	0	0	1
10/12/2019 17:00	0.0	0	0	0	0	1
10/12/2019 18:00	0.0	0	0	0	0	1
10/12/2019 19:00	0.0	0	0	0	0	1
10/12/2019 20:00	0.0	0	0	0	0	1
10/12/2019 21:00	0.0	0	0	0	0	1
10/12/2019 22:00	0.0	0	0	0	0	1
10/12/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,184.0 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,320.3	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/13/2019 00:00	0.0	0	0	0	0	1
10/13/2019 01:00	0.0	0	0	0	0	1
10/13/2019 02:00	0.0	0	0	0	0	1
10/13/2019 03:00	0.0	0	0	0	0	1
10/13/2019 04:00	0.0	0	0	0	0	1
10/13/2019 05:00	0.0	0	0	0	0	1
10/13/2019 06:00	0.0	0	0	0	0	1
10/13/2019 07:00	0.0	0	0	0	0	1
10/13/2019 08:00	0.0	0	0	0	0	1
10/13/2019 09:00	0.0	0	0	0	0	1
10/13/2019 10:00	0.0	0	0	0	0	1
10/13/2019 11:00	0.0	0	0	0	0	1
10/13/2019 12:00	0.0	0	0	0	0	1
10/13/2019 13:00	0.0	0	0	0	0	1
10/13/2019 14:00	0.0	0	0	0	0	1
10/13/2019 15:00	0.0	0	0	0	0	1
10/13/2019 16:00	0.0	0	0	0	0	1
10/13/2019 17:00	0.0	0	0	0	0	1
10/13/2019 18:00	0.0	0	0	0	0	1
10/13/2019 19:00	0.0	0	0	0	0	1
10/13/2019 20:00	0.0	0	0	0	0	1
10/13/2019 21:00	0.0	0	0	0	0	1
10/13/2019 22:00	0.0	0	0	0	0	1
10/13/2019 23:00	101.6	0	0	0	1	0
Average/Sum#:	101.6 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	101.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/14/2019 00:00	0.0	0	0	0	0	0
10/14/2019 01:00	0.0	0	0	0	0	0
10/14/2019 02:00	0.0	0	0	0	0	0
10/14/2019 03:00	0.0	0	0	0	0	0
10/14/2019 04:00	0.0	0	0	0	0	0
10/14/2019 05:00	0.0	0	0	0	0	0
10/14/2019 06:00	987.3	0	0	1	0	0
10/14/2019 07:00	5,184.8	0	0	1	0	0
10/14/2019 08:00	0.0	0	0	0	0	1
10/14/2019 09:00	0.0	0	0	0	0	1
10/14/2019 10:00	0.0	0	0	0	0	1
10/14/2019 11:00	0.0	0	0	0	0	1
10/14/2019 12:00	0.0	0	0	0	0	1
10/14/2019 13:00	0.0	0	0	0	0	1
10/14/2019 14:00	0.0	0	0	0	0	1
10/14/2019 15:00	0.0	0	0	0	0	1
10/14/2019 16:00	0.0	0	0	0	0	1
10/14/2019 17:00	0.0	0	0	0	0	1
10/14/2019 18:00	0.0	0	0	0	0	1
10/14/2019 19:00	0.0	0	0	0	0	1
10/14/2019 20:00	0.0	0	0	0	0	1
10/14/2019 21:00	0.0	0	0	0	0	1
10/14/2019 22:00	0.0	0	0	0	0	1
10/14/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,172.1 #	0 #	0 #	2 #	0 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,184.8	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/15/2019 00:00	0.0	0	0	0	0	1
10/15/2019 01:00	0.0	0	0	0	0	1
10/15/2019 02:00	0.0	0	0	0	0	1
10/15/2019 03:00	0.0	0	0	0	0	1
10/15/2019 04:00	0.0	0	0	0	0	1
10/15/2019 05:00	103.4	0	0	0	1	0
10/15/2019 06:00	1,883.9	0	0	1	0	0
10/15/2019 07:00	3,143.0	0	0	1	0	0
10/15/2019 08:00	0.0	0	0	0	0	1
10/15/2019 09:00	0.0	0	0	0	0	1
10/15/2019 10:00	0.0	0	0	0	0	1
10/15/2019 11:00	0.0	0	0	0	0	1
10/15/2019 12:00	0.0	0	0	0	0	1
10/15/2019 13:00	0.0	0	0	0	0	1
10/15/2019 14:00	0.0	0	0	0	0	1
10/15/2019 15:00	0.0	0	0	0	0	0
10/15/2019 16:00	0.0	0	0	0	0	0
10/15/2019 17:00	0.0	0	0	0	0	0
10/15/2019 18:00	0.0	0	0	0	0	0
10/15/2019 19:00	0.0	0	0	0	0	0
10/15/2019 20:00	0.0	0	0	0	0	0
10/15/2019 21:00	0.0	0	0	0	0	0
10/15/2019 22:00	0.0	0	0	0	0	0
10/15/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	5,130.3 #	0 #	0 #	2 #	1 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,143.0	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/16/2019 00:00	0.0	0	0	0	0	0
10/16/2019 01:00	0.0	0	0	0	0	0
10/16/2019 02:00	0.0	0	0	0	0	0
10/16/2019 03:00	0.0	0	0	0	0	0
10/16/2019 04:00	0.0	0	0	0	0	0
10/16/2019 05:00	0.0	0	0	0	0	0
10/16/2019 06:00	0.0	0	0	0	0	0
10/16/2019 07:00	0.0	0	0	0	0	0
10/16/2019 08:00	0.0	0	0	0	0	0
10/16/2019 09:00	0.0	0	0	0	0	0
10/16/2019 10:00	0.0	0	0	0	0	0
10/16/2019 11:00	0.0	0	0	0	0	0
10/16/2019 12:00	0.0	0	0	0	0	0
10/16/2019 13:00	0.0	0	0	0	0	0
10/16/2019 14:00	0.0	0	0	0	0	0
10/16/2019 15:00	0.0	0	0	0	0	0
10/16/2019 16:00	0.0	0	0	0	0	0
10/16/2019 17:00	0.0	0	0	0	0	0
10/16/2019 18:00	0.0	0	0	0	0	0
10/16/2019 19:00	0.0	0	0	0	0	0
10/16/2019 20:00	1,173.4	0	1	0	0	0
10/16/2019 21:00	5,602.2	0	1	0	0	0
10/16/2019 22:00	0.0	0	0	0	0	1
10/16/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,775.6 #	0 #	2 #	0 #	0 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,602.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/17/2019 00:00	0.0	0	0	0	0	1
10/17/2019 01:00	0.0	0	0	0	0	1
10/17/2019 02:00	0.0	0	0	0	0	1
10/17/2019 03:00	0.0	0	0	0	0	1
10/17/2019 04:00	0.0	0	0	0	0	1
10/17/2019 05:00	0.0	0	0	0	0	1
10/17/2019 06:00	0.0	0	0	0	0	1
10/17/2019 07:00	0.0	0	0	0	0	1
10/17/2019 08:00	0.0	0	0	0	0	1
10/17/2019 09:00	0.0	0	0	0	0	1
10/17/2019 10:00	0.0	0	0	0	0	1
10/17/2019 11:00	0.0	0	0	0	0	1
10/17/2019 12:00	0.0	0	0	0	0	1
10/17/2019 13:00	0.0	0	0	0	0	1
10/17/2019 14:00	0.0	0	0	0	0	1
10/17/2019 15:00	0.0	0	0	0	0	1
10/17/2019 16:00	0.0	0	0	0	0	1
10/17/2019 17:00	0.0	0	0	0	0	1
10/17/2019 18:00	0.0	0	0	0	0	1
10/17/2019 19:00	0.0	0	0	0	0	1
10/17/2019 20:00	0.0	0	0	0	0	1
10/17/2019 21:00	0.0	0	0	0	0	1
10/17/2019 22:00	0.0	0	0	0	0	1
10/17/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/18/2019 00:00	0.0	0	0	0	0	1
10/18/2019 01:00	0.0	0	0	0	0	1
10/18/2019 02:00	0.0	0	0	0	0	1
10/18/2019 03:00	0.0	0	0	0	0	1
10/18/2019 04:00	0.0	0	0	0	0	1
10/18/2019 05:00	0.0	0	0	0	0	1
10/18/2019 06:00	0.0	0	0	0	0	1
10/18/2019 07:00	0.0	0	0	0	0	1
10/18/2019 08:00	0.0	0	0	0	0	1
10/18/2019 09:00	0.0	0	0	0	0	1
10/18/2019 10:00	0.0	0	0	0	0	1
10/18/2019 11:00	0.0	0	0	0	0	1
10/18/2019 12:00	0.0	0	0	0	0	1
10/18/2019 13:00	0.0	0	0	0	0	1
10/18/2019 14:00	0.0	0	0	0	0	1
10/18/2019 15:00	0.0	0	0	0	0	1
10/18/2019 16:00	0.0	0	0	0	0	1
10/18/2019 17:00	0.0	0	0	0	0	1
10/18/2019 18:00	0.0	0	0	0	0	1
10/18/2019 19:00	0.0	0	0	0	0	1
10/18/2019 20:00	0.0	0	0	0	0	1
10/18/2019 21:00	0.0	0	0	0	0	1
10/18/2019 22:00	0.0	0	0	0	0	1
10/18/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/19/2019 00:00	0.0	0	0	0	0	1
10/19/2019 01:00	0.0	0	0	0	0	1
10/19/2019 02:00	0.0	0	0	0	0	1
10/19/2019 03:00	0.0	0	0	0	0	1
10/19/2019 04:00	0.0	0	0	0	0	1
10/19/2019 05:00	0.0	0	0	0	0	1
10/19/2019 06:00	0.0	0	0	0	0	1
10/19/2019 07:00	50.7	0	0	0	1	0
10/19/2019 08:00	0.0	0	0	0	0	0
10/19/2019 09:00	0.0	0	0	0	0	0
10/19/2019 10:00	0.0	0	0	0	0	0
10/19/2019 11:00	0.0	0	0	0	0	0
10/19/2019 12:00	0.0	0	0	0	0	0
10/19/2019 13:00	0.0	0	0	0	0	0
10/19/2019 14:00	0.0	0	0	0	0	0
10/19/2019 15:00	0.0	0	0	0	0	0
10/19/2019 16:00	0.0	0	0	0	0	0
10/19/2019 17:00	0.0	0	0	0	0	0
10/19/2019 18:00	0.0	0	0	0	0	0
10/19/2019 19:00	0.0	0	0	0	0	0
10/19/2019 20:00	0.0	0	0	0	0	0
10/19/2019 21:00	0.0	0	0	0	0	0
10/19/2019 22:00	0.0	0	0	0	0	0
10/19/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	50.7 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	50.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/20/2019 00:00	0.0	0	0	0	0	0
10/20/2019 01:00	0.0	0	0	0	0	0
10/20/2019 02:00	0.0	0	0	0	0	0
10/20/2019 03:00	0.0	0	0	0	0	0
10/20/2019 04:00	0.0	0	0	0	0	0
10/20/2019 05:00	0.0	0	0	0	0	0
10/20/2019 06:00	0.0	0	0	0	0	0
10/20/2019 07:00	0.0	0	0	0	0	0
10/20/2019 08:00	0.0	0	0	0	0	0
10/20/2019 09:00	0.0	0	0	0	0	0
10/20/2019 10:00	0.0	0	0	0	0	0
10/20/2019 11:00	0.0	0	0	0	0	0
10/20/2019 12:00	0.0	0	0	0	0	0
10/20/2019 13:00	0.0	0	0	0	0	0
10/20/2019 14:00	4,114.7	0	1	0	0	0
10/20/2019 15:00	5,591.3	0	1	0	0	0
10/20/2019 16:00	0.0	0	0	0	0	1
10/20/2019 17:00	0.0	0	0	0	0	1
10/20/2019 18:00	0.0	0	0	0	0	1
10/20/2019 19:00	0.0	0	0	0	0	1
10/20/2019 20:00	0.0	0	0	0	0	1
10/20/2019 21:00	0.0	0	0	0	0	1
10/20/2019 22:00	0.0	0	0	0	0	1
10/20/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,706.0 #	0 #	2 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,591.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/21/2019 00:00	0.0	0	0	0	0	1
10/21/2019 01:00	0.0	0	0	0	0	1
10/21/2019 02:00	0.0	0	0	0	0	1
10/21/2019 03:00	0.0	0	0	0	0	1
10/21/2019 04:00	0.0	0	0	0	0	1
10/21/2019 05:00	0.0	0	0	0	0	1
10/21/2019 06:00	0.0	0	0	0	0	1
10/21/2019 07:00	0.0	0	0	0	0	1
10/21/2019 08:00	0.0	0	0	0	0	1
10/21/2019 09:00	0.0	0	0	0	0	1
10/21/2019 10:00	0.0	0	0	0	0	1
10/21/2019 11:00	0.0	0	0	0	0	1
10/21/2019 12:00	0.0	0	0	0	0	1
10/21/2019 13:00	0.0	0	0	0	0	1
10/21/2019 14:00	0.0	0	0	0	0	1
10/21/2019 15:00	0.0	0	0	0	0	1
10/21/2019 16:00	0.0	0	0	0	0	1
10/21/2019 17:00	0.0	0	0	0	0	1
10/21/2019 18:00	0.0	0	0	0	0	1
10/21/2019 19:00	0.0	0	0	0	0	1
10/21/2019 20:00	0.0	0	0	0	0	1
10/21/2019 21:00	0.0	0	0	0	0	1
10/21/2019 22:00	0.0	0	0	0	0	1
10/21/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/22/2019 00:00	0.0	0	0	0	0	1
10/22/2019 01:00	0.0	0	0	0	0	1
10/22/2019 02:00	0.0	0	0	0	0	1
10/22/2019 03:00	0.0	0	0	0	0	1
10/22/2019 04:00	0.0	0	0	0	0	1
10/22/2019 05:00	0.0	0	0	0	0	1
10/22/2019 06:00	0.0	0	0	0	0	1
10/22/2019 07:00	0.0	0	0	0	0	1
10/22/2019 08:00	0.0	0	0	0	0	1
10/22/2019 09:00	0.0	0	0	0	0	1
10/22/2019 10:00	0.0	0	0	0	0	1
10/22/2019 11:00	0.0	0	0	0	0	1
10/22/2019 12:00	0.0	0	0	0	0	1
10/22/2019 13:00	0.0	0	0	0	0	1
10/22/2019 14:00	0.0	0	0	0	0	1
10/22/2019 15:00	0.0	0	0	0	0	1
10/22/2019 16:00	0.0	0	0	0	0	1
10/22/2019 17:00	0.0	0	0	0	0	1
10/22/2019 18:00	0.0	0	0	0	0	1
10/22/2019 19:00	0.0	0	0	0	0	1
10/22/2019 20:00	0.0	0	0	0	0	1
10/22/2019 21:00	0.0	0	0	0	0	1
10/22/2019 22:00	0.0	0	0	0	0	1
10/22/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/23/2019 00:00	0.0	0	0	0	0	1
10/23/2019 01:00	0.0	0	0	0	0	1
10/23/2019 02:00	0.0	0	0	0	0	1
10/23/2019 03:00	0.0	0	0	0	0	1
10/23/2019 04:00	0.0	0	0	0	0	1
10/23/2019 05:00	0.0	0	0	0	0	1
10/23/2019 06:00	0.0	0	0	0	0	1
10/23/2019 07:00	0.0	0	0	0	0	1
10/23/2019 08:00	0.0	0	0	0	0	1
10/23/2019 09:00	0.0	0	0	0	0	1
10/23/2019 10:00	0.0	0	0	0	0	1
10/23/2019 11:00	0.0	0	0	0	0	1
10/23/2019 12:00	0.0	0	0	0	0	1
10/23/2019 13:00	0.0	0	0	0	0	1
10/23/2019 14:00	0.0	0	0	0	0	1
10/23/2019 15:00	0.0	0	0	0	0	1
10/23/2019 16:00	0.0	0	0	0	0	1
10/23/2019 17:00	0.0	0	0	0	0	1
10/23/2019 18:00	0.0	0	0	0	0	1
10/23/2019 19:00	0.0	0	0	0	0	1
10/23/2019 20:00	0.0	0	0	0	0	1
10/23/2019 21:00	0.0	0	0	0	0	1
10/23/2019 22:00	0.0	0	0	0	0	1
10/23/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/24/2019 00:00	0.0	0	0	0	0	1
10/24/2019 01:00	0.0	0	0	0	0	1
10/24/2019 02:00	0.0	0	0	0	0	1
10/24/2019 03:00	0.0	0	0	0	0	1
10/24/2019 04:00	0.0	0	0	0	0	1
10/24/2019 05:00	0.0	0	0	0	0	1
10/24/2019 06:00	0.0	0	0	0	0	1
10/24/2019 07:00	0.0	0	0	0	0	1
10/24/2019 08:00	0.0	0	0	0	0	1
10/24/2019 09:00	0.0	0	0	0	0	1
10/24/2019 10:00	0.0	0	0	0	0	1
10/24/2019 11:00	0.0	0	0	0	0	1
10/24/2019 12:00	0.0	0	0	0	0	1
10/24/2019 13:00	0.0	0	0	0	0	1
10/24/2019 14:00	0.0	0	0	0	0	1
10/24/2019 15:00	0.0	0	0	0	0	1
10/24/2019 16:00	0.0	0	0	0	0	1
10/24/2019 17:00	0.0	0	0	0	0	1
10/24/2019 18:00	0.0	0	0	0	0	1
10/24/2019 19:00	0.0	0	0	0	0	1
10/24/2019 20:00	0.0	0	0	0	0	1
10/24/2019 21:00	0.0	0	0	0	0	1
10/24/2019 22:00	0.0	0	0	0	0	1
10/24/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/25/2019 00:00	0.0	0	0	0	0	1
10/25/2019 01:00	0.0	0	0	0	0	1
10/25/2019 02:00	0.0	0	0	0	0	1
10/25/2019 03:00	0.0	0	0	0	0	1
10/25/2019 04:00	0.0	0	0	0	0	1
10/25/2019 05:00	0.0	0	0	0	0	1
10/25/2019 06:00	0.0	0	0	0	0	1
10/25/2019 07:00	0.0	0	0	0	0	1
10/25/2019 08:00	0.0	0	0	0	0	1
10/25/2019 09:00	0.0	0	0	0	0	1
10/25/2019 10:00	0.0	0	0	0	0	1
10/25/2019 11:00	0.0	0	0	0	0	1
10/25/2019 12:00	0.0	0	0	0	0	1
10/25/2019 13:00	0.0	0	0	0	0	1
10/25/2019 14:00	0.0	0	0	0	0	1
10/25/2019 15:00	0.0	0	0	0	0	1
10/25/2019 16:00	0.0	0	0	0	0	1
10/25/2019 17:00	0.0	0	0	0	0	1
10/25/2019 18:00	0.0	0	0	0	0	1
10/25/2019 19:00	0.0	0	0	0	0	1
10/25/2019 20:00	0.0	0	0	0	0	1
10/25/2019 21:00	0.0	0	0	0	0	1
10/25/2019 22:00	0.0	0	0	0	0	1
10/25/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/26/2019 00:00	0.0	0	0	0	0	1
10/26/2019 01:00	0.0	0	0	0	0	1
10/26/2019 02:00	0.0	0	0	0	0	1
10/26/2019 03:00	0.0	0	0	0	0	1
10/26/2019 04:00	0.0	0	0	0	0	1
10/26/2019 05:00	0.0	0	0	0	0	1
10/26/2019 06:00	0.0	0	0	0	0	1
10/26/2019 07:00	0.0	0	0	0	0	1
10/26/2019 08:00	0.0	0	0	0	0	1
10/26/2019 09:00	0.0	0	0	0	0	1
10/26/2019 10:00	0.0	0	0	0	0	1
10/26/2019 11:00	0.0	0	0	0	0	1
10/26/2019 12:00	0.0	0	0	0	0	1
10/26/2019 13:00	0.0	0	0	0	0	1
10/26/2019 14:00	0.0	0	0	0	0	1
10/26/2019 15:00	0.0	0	0	0	0	1
10/26/2019 16:00	0.0	0	0	0	0	1
10/26/2019 17:00	0.0	0	0	0	0	1
10/26/2019 18:00	0.0	0	0	0	0	1
10/26/2019 19:00	0.0	0	0	0	0	1
10/26/2019 20:00	0.0	0	0	0	0	1
10/26/2019 21:00	0.0	0	0	0	0	1
10/26/2019 22:00	80.2	0	0	0	1	0
10/26/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	80.2 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	80.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/27/2019 00:00	0.0	0	0	0	0	0
10/27/2019 01:00	0.0	0	0	0	0	0
10/27/2019 02:00	0.0	0	0	0	0	0
10/27/2019 03:00	0.0	0	0	0	0	0
10/27/2019 04:00	0.0	0	0	0	0	0
10/27/2019 05:00	0.0	0	0	0	0	0
10/27/2019 06:00	0.0	0	0	0	0	0
10/27/2019 07:00	0.0	0	0	0	0	0
10/27/2019 08:00	0.0	0	0	0	0	0
10/27/2019 09:00	0.0	0	0	0	0	0
10/27/2019 10:00	0.0	0	0	0	0	0
10/27/2019 11:00	0.0	0	0	0	0	0
10/27/2019 12:00	0.0	0	0	0	0	0
10/27/2019 13:00	0.0	0	0	0	0	0
10/27/2019 14:00	0.0	0	0	0	0	0
10/27/2019 15:00	0.0	0	0	0	0	0
10/27/2019 16:00	0.0	0	0	0	0	0
10/27/2019 17:00	0.0	0	0	0	0	0
10/27/2019 18:00	0.0	0	0	0	0	0
10/27/2019 19:00	0.0	0	0	0	0	0
10/27/2019 20:00	0.0	0	0	0	0	0
10/27/2019 21:00	0.0	0	0	0	0	0
10/27/2019 22:00	0.0	0	0	0	0	0
10/27/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/28/2019 00:00	823.3	0	1	0	0	0
10/28/2019 01:00	6,751.0	0	1	0	0	0
10/28/2019 02:00	0.0	0	0	0	0	1
10/28/2019 03:00	0.0	0	0	0	0	1
10/28/2019 04:00	0.0	0	0	0	0	1
10/28/2019 05:00	0.0	0	0	0	0	1
10/28/2019 06:00	0.0	0	0	0	0	1
10/28/2019 07:00	0.0	0	0	0	0	1
10/28/2019 08:00	0.0	0	0	0	0	1
10/28/2019 09:00	0.0	0	0	0	0	1
10/28/2019 10:00	0.0	0	0	0	0	1
10/28/2019 11:00	0.0	0	0	0	0	1
10/28/2019 12:00	0.0	0	0	0	0	1
10/28/2019 13:00	0.0	0	0	0	0	1
10/28/2019 14:00	0.0	0	0	0	0	1
10/28/2019 15:00	0.0	0	0	0	0	1
10/28/2019 16:00	0.0	0	0	0	0	1
10/28/2019 17:00	0.0	0	0	0	0	1
10/28/2019 18:00	0.0	0	0	0	0	1
10/28/2019 19:00	0.0	0	0	0	0	1
10/28/2019 20:00	0.0	0	0	0	0	1
10/28/2019 21:00	0.0	0	0	0	0	1
10/28/2019 22:00	0.0	0	0	0	0	1
10/28/2019 23:00	100.4	0	0	0	1	0
Average/Sum#:	7,674.7 #	0 #	2 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,751.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/29/2019 00:00	0.0	0	0	0	0	0
10/29/2019 01:00	0.0	0	0	0	0	0
10/29/2019 02:00	0.0	0	0	0	0	0
10/29/2019 03:00	0.0	0	0	0	0	0
10/29/2019 04:00	0.0	0	0	0	0	0
10/29/2019 05:00	0.0	0	0	0	0	0
10/29/2019 06:00	0.0	0	0	0	0	0
10/29/2019 07:00	0.0	0	0	0	0	0
10/29/2019 08:00	0.0	0	0	0	0	0
10/29/2019 09:00	0.0	0	0	0	0	0
10/29/2019 10:00	0.0	0	0	0	0	0
10/29/2019 11:00	0.0	0	0	0	0	0
10/29/2019 12:00	0.0	0	0	0	0	0
10/29/2019 13:00	0.0	0	0	0	0	0
10/29/2019 14:00	0.0	0	0	0	0	0
10/29/2019 15:00	0.0	0	0	0	0	0
10/29/2019 16:00	0.0	0	0	0	0	0
10/29/2019 17:00	0.0	0	0	0	0	0
10/29/2019 18:00	0.0	0	0	0	0	0
10/29/2019 19:00	0.0	0	0	0	0	0
10/29/2019 20:00	0.0	0	0	0	0	0
10/29/2019 21:00	0.0	0	0	0	0	0
10/29/2019 22:00	0.0	0	0	0	0	0
10/29/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/30/2019 00:00	0.0	0	0	0	0	0
10/30/2019 01:00	0.0	0	0	0	0	0
10/30/2019 02:00	0.0	0	0	0	0	0
10/30/2019 03:00	0.0	0	0	0	0	0
10/30/2019 04:00	98.7	0	1	0	0	0
10/30/2019 05:00	4,996.6	0	1	0	0	0
10/30/2019 06:00	7,188.3	0	1	0	0	0
10/30/2019 07:00	0.0	0	0	0	0	1
10/30/2019 08:00	0.0	0	0	0	0	1
10/30/2019 09:00	0.0	0	0	0	0	1
10/30/2019 10:00	0.0	0	0	0	0	1
10/30/2019 11:00	0.0	0	0	0	0	1
10/30/2019 12:00	0.0	0	0	0	0	1
10/30/2019 13:00	0.0	0	0	0	0	1
10/30/2019 14:00	0.0	0	0	0	0	1
10/30/2019 15:00	0.0	0	0	0	0	1
10/30/2019 16:00	0.0	0	0	0	0	1
10/30/2019 17:00	0.0	0	0	0	0	1
10/30/2019 18:00	0.0	0	0	0	0	1
10/30/2019 19:00	0.0	0	0	0	0	1
10/30/2019 20:00	0.0	0	0	0	0	1
10/30/2019 21:00	0.0	0	0	0	0	1
10/30/2019 22:00	0.0	0	0	0	0	1
10/30/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	12,283.6 #	0 #	3 #	0 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,188.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/31/2019 00:00	0.0	0	0	0	0	1
10/31/2019 01:00	0.0	0	0	0	0	1
10/31/2019 02:00	0.0	0	0	0	0	1
10/31/2019 03:00	0.0	0	0	0	0	1
10/31/2019 04:00	0.0	0	0	0	0	1
10/31/2019 05:00	0.0	0	0	0	0	1
10/31/2019 06:00	0.0	0	0	0	0	1
10/31/2019 07:00	0.0	0	0	0	0	1
10/31/2019 08:00	0.0	0	0	0	0	1
10/31/2019 09:00	0.0	0	0	0	0	1
10/31/2019 10:00	0.0	0	0	0	0	1
10/31/2019 11:00	0.0	0	0	0	0	1
10/31/2019 12:00	0.0	0	0	0	0	1
10/31/2019 13:00	0.0	0	0	0	0	1
10/31/2019 14:00	0.0	0	0	0	0	1
10/31/2019 15:00	0.0	0	0	0	0	1
10/31/2019 16:00	0.0	0	0	0	0	1
10/31/2019 17:00	0.0	0	0	0	0	1
10/31/2019 18:00	0.0	0	0	0	0	1
10/31/2019 19:00	0.0	0	0	0	0	1
10/31/2019 20:00	0.0	0	0	0	0	1
10/31/2019 21:00	0.0	0	0	0	0	1
10/31/2019 22:00	0.0	0	0	0	0	1
10/31/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/01/2019 00:00	0.0	0	0	0	0	1
11/01/2019 01:00	0.0	0	0	0	0	1
11/01/2019 02:00	0.0	0	0	0	0	1
11/01/2019 03:00	0.0	0	0	0	0	1
11/01/2019 04:00	0.0	0	0	0	0	1
11/01/2019 05:00	0.0	0	0	0	0	1
11/01/2019 06:00	0.0	0	0	0	0	1
11/01/2019 07:00	0.0	0	0	0	0	1
11/01/2019 08:00	0.0	0	0	0	0	1
11/01/2019 09:00	0.0	0	0	0	0	1
11/01/2019 10:00	0.0	0	0	0	0	1
11/01/2019 11:00	0.0	0	0	0	0	1
11/01/2019 12:00	0.0	0	0	0	0	1
11/01/2019 13:00	0.0	0	0	0	0	1
11/01/2019 14:00	0.0	0	0	0	0	1
11/01/2019 15:00	0.0	0	0	0	0	1
11/01/2019 16:00	0.0	0	0	0	0	1
11/01/2019 17:00	0.0	0	0	0	0	1
11/01/2019 18:00	0.0	0	0	0	0	1
11/01/2019 19:00	0.0	0	0	0	0	1
11/01/2019 20:00	0.0	0	0	0	0	1
11/01/2019 21:00	0.0	0	0	0	0	1
11/01/2019 22:00	0.0	0	0	0	0	1
11/01/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/02/2019 00:00	0.0	0	0	0	0	1
11/02/2019 01:00	0.0	0	0	0	0	1
11/02/2019 02:00	0.0	0	0	0	0	1
11/02/2019 03:00	0.0	0	0	0	0	1
11/02/2019 04:00	0.0	0	0	0	0	1
11/02/2019 05:00	0.0	0	0	0	0	1
11/02/2019 06:00	0.0	0	0	0	0	1
11/02/2019 07:00	0.0	0	0	0	0	1
11/02/2019 08:00	0.0	0	0	0	0	1
11/02/2019 09:00	0.0	0	0	0	0	1
11/02/2019 10:00	0.0	0	0	0	0	1
11/02/2019 11:00	0.0	0	0	0	0	1
11/02/2019 12:00	0.0	0	0	0	0	1
11/02/2019 13:00	100.8	0	0	0	1	0
11/02/2019 14:00	0.0	0	0	0	0	0
11/02/2019 15:00	1,339.0	0	0	1	0	0
11/02/2019 16:00	3,587.6	0	0	1	0	0
11/02/2019 17:00	0.0	0	0	0	0	1
11/02/2019 18:00	0.0	0	0	0	0	1
11/02/2019 19:00	0.0	0	0	0	0	1
11/02/2019 20:00	0.0	0	0	0	0	1
11/02/2019 21:00	0.0	0	0	0	0	1
11/02/2019 22:00	0.0	0	0	0	0	1
11/02/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	5,027.4 #	0 #	0 #	2 #	1 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,587.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/03/2019 00:00	0.0	0	0	0	0	1
11/03/2019 01:00	0.0	0	0	0	0	1
11/03/2019 02:00	0.0	0	0	0	0	1
11/03/2019 03:00	0.0	0	0	0	0	1
11/03/2019 04:00	0.0	0	0	0	0	1
11/03/2019 05:00	0.0	0	0	0	0	1
11/03/2019 06:00	0.0	0	0	0	0	1
11/03/2019 07:00	0.0	0	0	0	0	1
11/03/2019 08:00	0.0	0	0	0	0	1
11/03/2019 09:00	0.0	0	0	0	0	1
11/03/2019 10:00	0.0	0	0	0	0	1
11/03/2019 11:00	0.0	0	0	0	0	1
11/03/2019 12:00	0.0	0	0	0	0	1
11/03/2019 13:00	0.0	0	0	0	0	1
11/03/2019 14:00	0.0	0	0	0	0	1
11/03/2019 15:00	0.0	0	0	0	0	1
11/03/2019 16:00	0.0	0	0	0	0	1
11/03/2019 17:00	0.0	0	0	0	0	1
11/03/2019 18:00	0.0	0	0	0	0	1
11/03/2019 19:00	0.0	0	0	0	0	1
11/03/2019 20:00	0.0	0	0	0	0	1
11/03/2019 21:00	0.0	0	0	0	0	1
11/03/2019 22:00	0.0	0	0	0	0	1
11/03/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/04/2019 00:00	0.0	0	0	0	0	1
11/04/2019 01:00	0.0	0	0	0	0	1
11/04/2019 02:00	0.0	0	0	0	0	1
11/04/2019 03:00	0.0	0	0	0	0	1
11/04/2019 04:00	0.0	0	0	0	0	1
11/04/2019 05:00	0.0	0	0	0	0	1
11/04/2019 06:00	0.0	0	0	0	0	1
11/04/2019 07:00	0.0	0	0	0	0	1
11/04/2019 08:00	0.0	0	0	0	0	1
11/04/2019 09:00	0.0	0	0	0	0	1
11/04/2019 10:00	0.0	0	0	0	0	1
11/04/2019 11:00	0.0	0	0	0	0	1
11/04/2019 12:00	0.0	0	0	0	0	1
11/04/2019 13:00	0.0	0	0	0	0	1
11/04/2019 14:00	0.0	0	0	0	0	1
11/04/2019 15:00	0.0	0	0	0	0	1
11/04/2019 16:00	0.0	0	0	0	0	1
11/04/2019 17:00	0.0	0	0	0	0	1
11/04/2019 18:00	0.0	0	0	0	0	1
11/04/2019 19:00	0.0	0	0	0	0	1
11/04/2019 20:00	0.0	0	0	0	0	1
11/04/2019 21:00	0.0	0	0	0	0	1
11/04/2019 22:00	0.0	0	0	0	0	1
11/04/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/05/2019 00:00	0.0	0	0	0	0	1
11/05/2019 01:00	0.0	0	0	0	0	1
11/05/2019 02:00	0.0	0	0	0	0	1
11/05/2019 03:00	0.0	0	0	0	0	1
11/05/2019 04:00	0.0	0	0	0	0	1
11/05/2019 05:00	0.0	0	0	0	0	1
11/05/2019 06:00	0.0	0	0	0	0	1
11/05/2019 07:00	0.0	0	0	0	0	1
11/05/2019 08:00	0.0	0	0	0	0	1
11/05/2019 09:00	0.0	0	0	0	0	1
11/05/2019 10:00	0.0	0	0	0	0	1
11/05/2019 11:00	0.0	0	0	0	0	1
11/05/2019 12:00	0.0	0	0	0	0	1
11/05/2019 13:00	0.0	0	0	0	0	1
11/05/2019 14:00	0.0	0	0	0	0	1
11/05/2019 15:00	0.0	0	0	0	0	1
11/05/2019 16:00	0.0	0	0	0	0	1
11/05/2019 17:00	0.0	0	0	0	0	1
11/05/2019 18:00	0.0	0	0	0	0	1
11/05/2019 19:00	0.0	0	0	0	0	1
11/05/2019 20:00	0.0	0	0	0	0	1
11/05/2019 21:00	0.0	0	0	0	0	1
11/05/2019 22:00	0.0	0	0	0	0	1
11/05/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/06/2019 00:00	0.0	0	0	0	0	1
11/06/2019 01:00	0.0	0	0	0	0	1
11/06/2019 02:00	0.0	0	0	0	0	1
11/06/2019 03:00	0.0	0	0	0	0	1
11/06/2019 04:00	0.0	0	0	0	0	1
11/06/2019 05:00	0.0	0	0	0	0	1
11/06/2019 06:00	0.0	0	0	0	0	1
11/06/2019 07:00	0.0	0	0	0	0	1
11/06/2019 08:00	0.0	0	0	0	0	1
11/06/2019 09:00	0.0	0	0	0	0	1
11/06/2019 10:00	0.0	0	0	0	0	1
11/06/2019 11:00	0.0	0	0	0	0	1
11/06/2019 12:00	0.0	0	0	0	0	1
11/06/2019 13:00	0.0	0	0	0	0	1
11/06/2019 14:00	0.0	0	0	0	0	1
11/06/2019 15:00	0.0	0	0	0	0	1
11/06/2019 16:00	0.0	0	0	0	0	1
11/06/2019 17:00	0.0	0	0	0	0	1
11/06/2019 18:00	0.0	0	0	0	0	1
11/06/2019 19:00	0.0	0	0	0	0	1
11/06/2019 20:00	0.0	0	0	0	0	1
11/06/2019 21:00	0.0	0	0	0	0	1
11/06/2019 22:00	0.0	0	0	0	0	1
11/06/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/07/2019 00:00	0.0	0	0	0	0	1
11/07/2019 01:00	0.0	0	0	0	0	1
11/07/2019 02:00	0.0	0	0	0	0	1
11/07/2019 03:00	0.0	0	0	0	0	1
11/07/2019 04:00	0.0	0	0	0	0	1
11/07/2019 05:00	0.0	0	0	0	0	1
11/07/2019 06:00	0.0	0	0	0	0	1
11/07/2019 07:00	0.0	0	0	0	0	1
11/07/2019 08:00	0.0	0	0	0	0	1
11/07/2019 09:00	0.0	0	0	0	0	1
11/07/2019 10:00	0.0	0	0	0	0	1
11/07/2019 11:00	0.0	0	0	0	0	1
11/07/2019 12:00	0.0	0	0	0	0	1
11/07/2019 13:00	0.0	0	0	0	0	1
11/07/2019 14:00	0.0	0	0	0	0	1
11/07/2019 15:00	0.0	0	0	0	0	1
11/07/2019 16:00	0.0	0	0	0	0	1
11/07/2019 17:00	0.0	0	0	0	0	1
11/07/2019 18:00	0.0	0	0	0	0	1
11/07/2019 19:00	0.0	0	0	0	0	1
11/07/2019 20:00	0.0	0	0	0	0	1
11/07/2019 21:00	0.0	0	0	0	0	1
11/07/2019 22:00	0.0	0	0	0	0	1
11/07/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/08/2019 00:00	0.0	0	0	0	0	1
11/08/2019 01:00	0.0	0	0	0	0	1
11/08/2019 02:00	0.0	0	0	0	0	1
11/08/2019 03:00	0.0	0	0	0	0	1
11/08/2019 04:00	0.0	0	0	0	0	1
11/08/2019 05:00	0.0	0	0	0	0	1
11/08/2019 06:00	0.0	0	0	0	0	1
11/08/2019 07:00	0.0	0	0	0	0	1
11/08/2019 08:00	0.0	0	0	0	0	1
11/08/2019 09:00	0.0	0	0	0	0	1
11/08/2019 10:00	0.0	0	0	0	0	1
11/08/2019 11:00	0.0	0	0	0	0	1
11/08/2019 12:00	0.0	0	0	0	0	1
11/08/2019 13:00	0.0	0	0	0	0	1
11/08/2019 14:00	0.0	0	0	0	0	1
11/08/2019 15:00	0.0	0	0	0	0	1
11/08/2019 16:00	0.0	0	0	0	0	1
11/08/2019 17:00	0.0	0	0	0	0	1
11/08/2019 18:00	0.0	0	0	0	0	1
11/08/2019 19:00	0.0	0	0	0	0	1
11/08/2019 20:00	0.0	0	0	0	0	1
11/08/2019 21:00	0.0	0	0	0	0	1
11/08/2019 22:00	0.0	0	0	0	0	1
11/08/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/09/2019 00:00	0.0	0	0	0	0	1
11/09/2019 01:00	0.0	0	0	0	0	1
11/09/2019 02:00	0.0	0	0	0	0	1
11/09/2019 03:00	0.0	0	0	0	0	1
11/09/2019 04:00	0.0	0	0	0	0	1
11/09/2019 05:00	0.0	0	0	0	0	1
11/09/2019 06:00	0.0	0	0	0	0	1
11/09/2019 07:00	0.0	0	0	0	0	1
11/09/2019 08:00	0.0	0	0	0	0	1
11/09/2019 09:00	0.0	0	0	0	0	1
11/09/2019 10:00	0.0	0	0	0	0	1
11/09/2019 11:00	0.0	0	0	0	0	1
11/09/2019 12:00	0.0	0	0	0	0	1
11/09/2019 13:00	0.0	0	0	0	0	1
11/09/2019 14:00	0.0	0	0	0	0	1
11/09/2019 15:00	0.0	0	0	0	0	1
11/09/2019 16:00	0.0	0	0	0	0	1
11/09/2019 17:00	0.0	0	0	0	0	1
11/09/2019 18:00	0.0	0	0	0	0	1
11/09/2019 19:00	0.0	0	0	0	0	1
11/09/2019 20:00	0.0	0	0	0	0	1
11/09/2019 21:00	0.0	0	0	0	0	1
11/09/2019 22:00	0.0	0	0	0	0	1
11/09/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/10/2019 00:00	0.0	0	0	0	0	1
11/10/2019 01:00	0.0	0	0	0	0	1
11/10/2019 02:00	0.0	0	0	0	0	1
11/10/2019 03:00	0.0	0	0	0	0	1
11/10/2019 04:00	0.0	0	0	0	0	1
11/10/2019 05:00	0.0	0	0	0	0	1
11/10/2019 06:00	0.0	0	0	0	0	1
11/10/2019 07:00	0.0	0	0	0	0	1
11/10/2019 08:00	0.0	0	0	0	0	1
11/10/2019 09:00	0.0	0	0	0	0	1
11/10/2019 10:00	0.0	0	0	0	0	1
11/10/2019 11:00	0.0	0	0	0	0	1
11/10/2019 12:00	0.0	0	0	0	0	1
11/10/2019 13:00	0.0	0	0	0	0	1
11/10/2019 14:00	0.0	0	0	0	0	1
11/10/2019 15:00	0.0	0	0	0	0	1
11/10/2019 16:00	0.0	0	0	0	0	1
11/10/2019 17:00	0.0	0	0	0	0	1
11/10/2019 18:00	0.0	0	0	0	0	1
11/10/2019 19:00	0.0	0	0	0	0	1
11/10/2019 20:00	0.0	0	0	0	0	1
11/10/2019 21:00	0.0	0	0	0	0	1
11/10/2019 22:00	0.0	0	0	0	0	1
11/10/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/11/2019 00:00	0.0	0	0	0	0	1
11/11/2019 01:00	0.0	0	0	0	0	1
11/11/2019 02:00	0.0	0	0	0	0	1
11/11/2019 03:00	0.0	0	0	0	0	1
11/11/2019 04:00	0.0	0	0	0	0	1
11/11/2019 05:00	0.0	0	0	0	0	1
11/11/2019 06:00	0.0	0	0	0	0	1
11/11/2019 07:00	0.0	0	0	0	0	1
11/11/2019 08:00	0.0	0	0	0	0	1
11/11/2019 09:00	0.0	0	0	0	0	1
11/11/2019 10:00	0.0	0	0	0	0	1
11/11/2019 11:00	0.0	0	0	0	0	1
11/11/2019 12:00	0.0	0	0	0	0	1
11/11/2019 13:00	0.0	0	0	0	0	1
11/11/2019 14:00	0.0	0	0	0	0	1
11/11/2019 15:00	0.0	0	0	0	0	1
11/11/2019 16:00	0.0	0	0	0	0	1
11/11/2019 17:00	0.0	0	0	0	0	1
11/11/2019 18:00	0.0	0	0	0	0	1
11/11/2019 19:00	0.0	0	0	0	0	1
11/11/2019 20:00	0.0	0	0	0	0	1
11/11/2019 21:00	0.0	0	0	0	0	1
11/11/2019 22:00	0.0	0	0	0	0	1
11/11/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/12/2019 00:00	0.0	0	0	0	0	1
11/12/2019 01:00	0.0	0	0	0	0	1
11/12/2019 02:00	0.0	0	0	0	0	1
11/12/2019 03:00	0.0	0	0	0	0	1
11/12/2019 04:00	0.0	0	0	0	0	1
11/12/2019 05:00	0.0	0	0	0	0	1
11/12/2019 06:00	0.0	0	0	0	0	1
11/12/2019 07:00	0.0	0	0	0	0	1
11/12/2019 08:00	0.0	0	0	0	0	1
11/12/2019 09:00	0.0	0	0	0	0	1
11/12/2019 10:00	0.0	0	0	0	0	1
11/12/2019 11:00	0.0	0	0	0	0	1
11/12/2019 12:00	0.0	0	0	0	0	1
11/12/2019 13:00	0.0	0	0	0	0	1
11/12/2019 14:00	0.0	0	0	0	0	1
11/12/2019 15:00	0.0	0	0	0	0	1
11/12/2019 16:00	0.0	0	0	0	0	1
11/12/2019 17:00	0.0	0	0	0	0	1
11/12/2019 18:00	0.0	0	0	0	0	1
11/12/2019 19:00	0.0	0	0	0	0	1
11/12/2019 20:00	0.0	0	0	0	0	1
11/12/2019 21:00	0.0	0	0	0	0	1
11/12/2019 22:00	0.0	0	0	0	0	1
11/12/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/13/2019 00:00	0.0	0	0	0	0	1
11/13/2019 01:00	0.0	0	0	0	0	1
11/13/2019 02:00	0.0	0	0	0	0	1
11/13/2019 03:00	0.0	0	0	0	0	1
11/13/2019 04:00	0.0	0	0	0	0	1
11/13/2019 05:00	0.0	0	0	0	0	1
11/13/2019 06:00	0.0	0	0	0	0	1
11/13/2019 07:00	0.0	0	0	0	0	1
11/13/2019 08:00	0.0	0	0	0	0	1
11/13/2019 09:00	0.0	0	0	0	0	1
11/13/2019 10:00	0.0	0	0	0	0	1
11/13/2019 11:00	0.0	0	0	0	0	1
11/13/2019 12:00	0.0	0	0	0	0	1
11/13/2019 13:00	0.0	0	0	0	0	1
11/13/2019 14:00	0.0	0	0	0	0	1
11/13/2019 15:00	0.0	0	0	0	0	1
11/13/2019 16:00	0.0	0	0	0	0	1
11/13/2019 17:00	0.0	0	0	0	0	1
11/13/2019 18:00	0.0	0	0	0	0	1
11/13/2019 19:00	0.0	0	0	0	0	1
11/13/2019 20:00	0.0	0	0	0	0	1
11/13/2019 21:00	0.0	0	0	0	0	1
11/13/2019 22:00	0.0	0	0	0	0	1
11/13/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/14/2019 00:00	0.0	0	0	0	0	1
11/14/2019 01:00	0.0	0	0	0	0	1
11/14/2019 02:00	0.0	0	0	0	0	1
11/14/2019 03:00	0.0	0	0	0	0	1
11/14/2019 04:00	0.0	0	0	0	0	1
11/14/2019 05:00	0.0	0	0	0	0	1
11/14/2019 06:00	0.0	0	0	0	0	1
11/14/2019 07:00	0.0	0	0	0	0	1
11/14/2019 08:00	0.0	0	0	0	0	1
11/14/2019 09:00	0.0	0	0	0	0	1
11/14/2019 10:00	0.0	0	0	0	0	1
11/14/2019 11:00	0.0	0	0	0	0	1
11/14/2019 12:00	0.0	0	0	0	0	1
11/14/2019 13:00	0.0	0	0	0	0	1
11/14/2019 14:00	0.0	0	0	0	0	1
11/14/2019 15:00	0.0	0	0	0	0	1
11/14/2019 16:00	0.0	0	0	0	0	1
11/14/2019 17:00	0.0	0	0	0	0	1
11/14/2019 18:00	0.0	0	0	0	0	1
11/14/2019 19:00	0.0	0	0	0	0	1
11/14/2019 20:00	0.0	0	0	0	0	1
11/14/2019 21:00	0.0	0	0	0	0	1
11/14/2019 22:00	0.0	0	0	0	0	1
11/14/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/15/2019 00:00	0.0	0	0	0	0	1
11/15/2019 01:00	0.0	0	0	0	0	1
11/15/2019 02:00	0.0	0	0	0	0	1
11/15/2019 03:00	0.0	0	0	0	0	1
11/15/2019 04:00	0.0	0	0	0	0	1
11/15/2019 05:00	0.0	0	0	0	0	1
11/15/2019 06:00	0.0	0	0	0	0	1
11/15/2019 07:00	0.0	0	0	0	0	1
11/15/2019 08:00	0.0	0	0	0	0	1
11/15/2019 09:00	0.0	0	0	0	0	1
11/15/2019 10:00	0.0	0	0	0	0	1
11/15/2019 11:00	0.0	0	0	0	0	1
11/15/2019 12:00	0.0	0	0	0	0	1
11/15/2019 13:00	0.0	0	0	0	0	1
11/15/2019 14:00	0.0	0	0	0	0	1
11/15/2019 15:00	0.0	0	0	0	0	1
11/15/2019 16:00	0.0	0	0	0	0	1
11/15/2019 17:00	0.0	0	0	0	0	1
11/15/2019 18:00	0.0	0	0	0	0	1
11/15/2019 19:00	0.0	0	0	0	0	1
11/15/2019 20:00	0.0	0	0	0	0	1
11/15/2019 21:00	0.0	0	0	0	0	1
11/15/2019 22:00	0.0	0	0	0	0	1
11/15/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/16/2019 00:00	0.0	0	0	0	0	1
11/16/2019 01:00	0.0	0	0	0	0	1
11/16/2019 02:00	0.0	0	0	0	0	1
11/16/2019 03:00	0.0	0	0	0	0	1
11/16/2019 04:00	0.0	0	0	0	0	1
11/16/2019 05:00	0.0	0	0	0	0	1
11/16/2019 06:00	0.0	0	0	0	0	1
11/16/2019 07:00	0.0	0	0	0	0	1
11/16/2019 08:00	0.0	0	0	0	0	1
11/16/2019 09:00	0.0	0	0	0	0	1
11/16/2019 10:00	0.0	0	0	0	0	1
11/16/2019 11:00	0.0	0	0	0	0	1
11/16/2019 12:00	0.0	0	0	0	0	1
11/16/2019 13:00	0.0	0	0	0	0	1
11/16/2019 14:00	0.0	0	0	0	0	1
11/16/2019 15:00	0.0	0	0	0	0	1
11/16/2019 16:00	0.0	0	0	0	0	1
11/16/2019 17:00	0.0	0	0	0	0	1
11/16/2019 18:00	0.0	0	0	0	0	1
11/16/2019 19:00	0.0	0	0	0	0	1
11/16/2019 20:00	0.0	0	0	0	0	1
11/16/2019 21:00	0.0	0	0	0	0	1
11/16/2019 22:00	0.0	0	0	0	0	1
11/16/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/17/2019 00:00	0.0	0	0	0	0	1
11/17/2019 01:00	0.0	0	0	0	0	1
11/17/2019 02:00	0.0	0	0	0	0	1
11/17/2019 03:00	0.0	0	0	0	0	1
11/17/2019 04:00	0.0	0	0	0	0	1
11/17/2019 05:00	0.0	0	0	0	0	1
11/17/2019 06:00	0.0	0	0	0	0	1
11/17/2019 07:00	0.0	0	0	0	0	1
11/17/2019 08:00	0.0	0	0	0	0	1
11/17/2019 09:00	0.0	0	0	0	0	1
11/17/2019 10:00	0.0	0	0	0	0	1
11/17/2019 11:00	0.0	0	0	0	0	1
11/17/2019 12:00	0.0	0	0	0	0	1
11/17/2019 13:00	0.0	0	0	0	0	1
11/17/2019 14:00	0.0	0	0	0	0	1
11/17/2019 15:00	0.0	0	0	0	0	1
11/17/2019 16:00	0.0	0	0	0	0	1
11/17/2019 17:00	0.0	0	0	0	0	1
11/17/2019 18:00	0.0	0	0	0	0	1
11/17/2019 19:00	0.0	0	0	0	0	1
11/17/2019 20:00	0.0	0	0	0	0	1
11/17/2019 21:00	0.0	0	0	0	0	1
11/17/2019 22:00	0.0	0	0	0	0	1
11/17/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/18/2019 00:00	0.0	0	0	0	0	1
11/18/2019 01:00	0.0	0	0	0	0	1
11/18/2019 02:00	0.0	0	0	0	0	1
11/18/2019 03:00	0.0	0	0	0	0	1
11/18/2019 04:00	0.0	0	0	0	0	1
11/18/2019 05:00	0.0	0	0	0	0	1
11/18/2019 06:00	0.0	0	0	0	0	1
11/18/2019 07:00	0.0	0	0	0	0	1
11/18/2019 08:00	0.0	0	0	0	0	1
11/18/2019 09:00	0.0	0	0	0	0	1
11/18/2019 10:00	0.0	0	0	0	0	1
11/18/2019 11:00	0.0	0	0	0	0	1
11/18/2019 12:00	0.0	0	0	0	0	1
11/18/2019 13:00	0.0	0	0	0	0	1
11/18/2019 14:00	0.0	0	0	0	0	1
11/18/2019 15:00	0.0	0	0	0	0	1
11/18/2019 16:00	0.0	0	0	0	0	1
11/18/2019 17:00	0.0	0	0	0	0	1
11/18/2019 18:00	0.0	0	0	0	0	1
11/18/2019 19:00	0.0	0	0	0	0	1
11/18/2019 20:00	0.0	0	0	0	0	1
11/18/2019 21:00	0.0	0	0	0	0	1
11/18/2019 22:00	0.0	0	0	0	0	1
11/18/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/19/2019 00:00	0.0	0	0	0	0	1
11/19/2019 01:00	0.0	0	0	0	0	1
11/19/2019 02:00	0.0	0	0	0	0	1
11/19/2019 03:00	0.0	0	0	0	0	1
11/19/2019 04:00	0.0	0	0	0	0	1
11/19/2019 05:00	0.0	0	0	0	0	1
11/19/2019 06:00	0.0	0	0	0	0	1
11/19/2019 07:00	0.0	0	0	0	0	1
11/19/2019 08:00	0.0	0	0	0	0	1
11/19/2019 09:00	0.0	0	0	0	0	1
11/19/2019 10:00	0.0	0	0	0	0	1
11/19/2019 11:00	0.0	0	0	0	0	1
11/19/2019 12:00	0.0	0	0	0	0	1
11/19/2019 13:00	0.0	0	0	0	0	1
11/19/2019 14:00	0.0	0	0	0	0	1
11/19/2019 15:00	0.0	0	0	0	0	1
11/19/2019 16:00	0.0	0	0	0	0	1
11/19/2019 17:00	0.0	0	0	0	0	1
11/19/2019 18:00	0.0	0	0	0	0	1
11/19/2019 19:00	0.0	0	0	0	0	1
11/19/2019 20:00	0.0	0	0	0	0	1
11/19/2019 21:00	0.0	0	0	0	0	1
11/19/2019 22:00	0.0	0	0	0	0	1
11/19/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/20/2019 00:00	0.0	0	0	0	0	1
11/20/2019 01:00	0.0	0	0	0	0	1
11/20/2019 02:00	0.0	0	0	0	0	1
11/20/2019 03:00	0.0	0	0	0	0	1
11/20/2019 04:00	0.0	0	0	0	0	1
11/20/2019 05:00	0.0	0	0	0	0	1
11/20/2019 06:00	0.0	0	0	0	0	1
11/20/2019 07:00	0.0	0	0	0	0	1
11/20/2019 08:00	0.0	0	0	0	0	1
11/20/2019 09:00	0.0	0	0	0	0	1
11/20/2019 10:00	0.0	0	0	0	0	1
11/20/2019 11:00	0.0	0	0	0	0	1
11/20/2019 12:00	0.0	0	0	0	0	1
11/20/2019 13:00	0.0	0	0	0	0	1
11/20/2019 14:00	0.0	0	0	0	0	1
11/20/2019 15:00	0.0	0	0	0	0	1
11/20/2019 16:00	0.0	0	0	0	0	1
11/20/2019 17:00	0.0	0	0	0	0	1
11/20/2019 18:00	0.0	0	0	0	0	1
11/20/2019 19:00	0.0	0	0	0	0	1
11/20/2019 20:00	0.0	0	0	0	0	1
11/20/2019 21:00	0.0	0	0	0	0	1
11/20/2019 22:00	0.0	0	0	0	0	1
11/20/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/21/2019 00:00	0.0	0	0	0	0	1
11/21/2019 01:00	0.0	0	0	0	0	1
11/21/2019 02:00	0.0	0	0	0	0	1
11/21/2019 03:00	0.0	0	0	0	0	1
11/21/2019 04:00	0.0	0	0	0	0	1
11/21/2019 05:00	0.0	0	0	0	0	1
11/21/2019 06:00	0.0	0	0	0	0	1
11/21/2019 07:00	0.0	0	0	0	0	1
11/21/2019 08:00	0.0	0	0	0	0	1
11/21/2019 09:00	0.0	0	0	0	0	1
11/21/2019 10:00	0.0	0	0	0	0	1
11/21/2019 11:00	0.0	0	0	0	0	1
11/21/2019 12:00	0.0	0	0	0	0	1
11/21/2019 13:00	0.0	0	0	0	0	1
11/21/2019 14:00	0.0	0	0	0	0	1
11/21/2019 15:00	0.0	0	0	0	0	1
11/21/2019 16:00	0.0	0	0	0	0	1
11/21/2019 17:00	0.0	0	0	0	0	1
11/21/2019 18:00	0.0	0	0	0	0	1
11/21/2019 19:00	0.0	0	0	0	0	1
11/21/2019 20:00	0.0	0	0	0	0	1
11/21/2019 21:00	0.0	0	0	0	0	1
11/21/2019 22:00	0.0	0	0	0	0	1
11/21/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/22/2019 00:00	0.0	0	0	0	0	1
11/22/2019 01:00	0.0	0	0	0	0	1
11/22/2019 02:00	0.0	0	0	0	0	1
11/22/2019 03:00	0.0	0	0	0	0	1
11/22/2019 04:00	0.0	0	0	0	0	1
11/22/2019 05:00	0.0	0	0	0	0	1
11/22/2019 06:00	0.0	0	0	0	0	1
11/22/2019 07:00	0.0	0	0	0	0	1
11/22/2019 08:00	0.0	0	0	0	0	1
11/22/2019 09:00	0.0	0	0	0	0	1
11/22/2019 10:00	0.0	0	0	0	0	1
11/22/2019 11:00	0.0	0	0	0	0	1
11/22/2019 12:00	0.0	0	0	0	0	1
11/22/2019 13:00	0.0	0	0	0	0	1
11/22/2019 14:00	0.0	0	0	0	0	1
11/22/2019 15:00	0.0	0	0	0	0	1
11/22/2019 16:00	0.0	0	0	0	0	1
11/22/2019 17:00	0.0	0	0	0	0	1
11/22/2019 18:00	0.0	0	0	0	0	1
11/22/2019 19:00	0.0	0	0	0	0	1
11/22/2019 20:00	0.0	0	0	0	0	1
11/22/2019 21:00	0.0	0	0	0	0	1
11/22/2019 22:00	0.0	0	0	0	0	1
11/22/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/23/2019 00:00	0.0	0	0	0	0	1
11/23/2019 01:00	0.0	0	0	0	0	1
11/23/2019 02:00	0.0	0	0	0	0	1
11/23/2019 03:00	0.0	0	0	0	0	1
11/23/2019 04:00	0.0	0	0	0	0	1
11/23/2019 05:00	0.0	0	0	0	0	1
11/23/2019 06:00	0.0	0	0	0	0	1
11/23/2019 07:00	0.0	0	0	0	0	1
11/23/2019 08:00	0.0	0	0	0	0	1
11/23/2019 09:00	0.0	0	0	0	0	1
11/23/2019 10:00	0.0	0	0	0	0	1
11/23/2019 11:00	0.0	0	0	0	0	1
11/23/2019 12:00	0.0	0	0	0	0	1
11/23/2019 13:00	0.0	0	0	0	0	1
11/23/2019 14:00	0.0	0	0	0	0	1
11/23/2019 15:00	0.0	0	0	0	0	1
11/23/2019 16:00	0.0	0	0	0	0	1
11/23/2019 17:00	0.0	0	0	0	0	1
11/23/2019 18:00	0.0	0	0	0	0	1
11/23/2019 19:00	0.0	0	0	0	0	1
11/23/2019 20:00	0.0	0	0	0	0	1
11/23/2019 21:00	0.0	0	0	0	0	1
11/23/2019 22:00	0.0	0	0	0	0	1
11/23/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/24/2019 00:00	0.0	0	0	0	0	1
11/24/2019 01:00	0.0	0	0	0	0	1
11/24/2019 02:00	0.0	0	0	0	0	1
11/24/2019 03:00	0.0	0	0	0	0	1
11/24/2019 04:00	0.0	0	0	0	0	1
11/24/2019 05:00	0.0	0	0	0	0	1
11/24/2019 06:00	0.0	0	0	0	0	1
11/24/2019 07:00	0.0	0	0	0	0	1
11/24/2019 08:00	0.0	0	0	0	0	1
11/24/2019 09:00	0.0	0	0	0	0	1
11/24/2019 10:00	0.0	0	0	0	0	1
11/24/2019 11:00	0.0	0	0	0	0	1
11/24/2019 12:00	0.0	0	0	0	0	1
11/24/2019 13:00	0.0	0	0	0	0	1
11/24/2019 14:00	0.0	0	0	0	0	1
11/24/2019 15:00	0.0	0	0	0	0	1
11/24/2019 16:00	0.0	0	0	0	0	1
11/24/2019 17:00	0.0	0	0	0	0	1
11/24/2019 18:00	0.0	0	0	0	0	1
11/24/2019 19:00	0.0	0	0	0	0	1
11/24/2019 20:00	0.0	0	0	0	0	1
11/24/2019 21:00	0.0	0	0	0	0	1
11/24/2019 22:00	0.0	0	0	0	0	1
11/24/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/25/2019 00:00	64.3	0	0	0	1	0
11/25/2019 01:00	0.0	0	0	0	0	0
11/25/2019 02:00	0.0	0	0	0	0	0
11/25/2019 03:00	0.0	0	0	0	0	0
11/25/2019 04:00	2,208.5	0	0	1	0	0
11/25/2019 05:00	4,334.6	0	0	1	0	0
11/25/2019 06:00	0.0	0	0	0	0	1
11/25/2019 07:00	0.0	0	0	0	0	1
11/25/2019 08:00	0.0	0	0	0	0	1
11/25/2019 09:00	0.0	0	0	0	0	1
11/25/2019 10:00	0.0	0	0	0	0	1
11/25/2019 11:00	0.0	0	0	0	0	1
11/25/2019 12:00	0.0	0	0	0	0	1
11/25/2019 13:00	0.0	0	0	0	0	1
11/25/2019 14:00	0.0	0	0	0	0	1
11/25/2019 15:00	0.0	0	0	0	0	1
11/25/2019 16:00	0.0	0	0	0	0	1
11/25/2019 17:00	0.0	0	0	0	0	1
11/25/2019 18:00	0.0	0	0	0	0	1
11/25/2019 19:00	0.0	0	0	0	0	1
11/25/2019 20:00	0.0	0	0	0	0	1
11/25/2019 21:00	0.0	0	0	0	0	1
11/25/2019 22:00	0.0	0	0	0	0	1
11/25/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,607.4 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,334.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/26/2019 00:00	0.0	0	0	0	0	1
11/26/2019 01:00	0.0	0	0	0	0	1
11/26/2019 02:00	0.0	0	0	0	0	1
11/26/2019 03:00	0.0	0	0	0	0	1
11/26/2019 04:00	0.0	0	0	0	0	1
11/26/2019 05:00	0.0	0	0	0	0	1
11/26/2019 06:00	0.0	0	0	0	0	1
11/26/2019 07:00	0.0	0	0	0	0	1
11/26/2019 08:00	0.0	0	0	0	0	1
11/26/2019 09:00	0.0	0	0	0	0	1
11/26/2019 10:00	0.0	0	0	0	0	1
11/26/2019 11:00	0.0	0	0	0	0	1
11/26/2019 12:00	0.0	0	0	0	0	1
11/26/2019 13:00	0.0	0	0	0	0	1
11/26/2019 14:00	0.0	0	0	0	0	1
11/26/2019 15:00	0.0	0	0	0	0	1
11/26/2019 16:00	0.0	0	0	0	0	1
11/26/2019 17:00	0.0	0	0	0	0	1
11/26/2019 18:00	0.0	0	0	0	0	1
11/26/2019 19:00	0.0	0	0	0	0	1
11/26/2019 20:00	0.0	0	0	0	0	1
11/26/2019 21:00	0.0	0	0	0	0	1
11/26/2019 22:00	0.0	0	0	0	0	1
11/26/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/27/2019 00:00	0.0	0	0	0	0	1
11/27/2019 01:00	0.0	0	0	0	0	1
11/27/2019 02:00	0.0	0	0	0	0	1
11/27/2019 03:00	0.0	0	0	0	0	1
11/27/2019 04:00	0.0	0	0	0	0	1
11/27/2019 05:00	0.0	0	0	0	0	1
11/27/2019 06:00	0.0	0	0	0	0	1
11/27/2019 07:00	0.0	0	0	0	0	1
11/27/2019 08:00	0.0	0	0	0	0	1
11/27/2019 09:00	0.0	0	0	0	0	1
11/27/2019 10:00	0.0	0	0	0	0	1
11/27/2019 11:00	0.0	0	0	0	0	1
11/27/2019 12:00	0.0	0	0	0	0	1
11/27/2019 13:00	0.0	0	0	0	0	1
11/27/2019 14:00	0.0	0	0	0	0	1
11/27/2019 15:00	0.0	0	0	0	0	1
11/27/2019 16:00	0.0	0	0	0	0	1
11/27/2019 17:00	0.0	0	0	0	0	1
11/27/2019 18:00	0.0	0	0	0	0	1
11/27/2019 19:00	0.0	0	0	0	0	1
11/27/2019 20:00	0.0	0	0	0	0	1
11/27/2019 21:00	0.0	0	0	0	0	1
11/27/2019 22:00	0.0	0	0	0	0	1
11/27/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/28/2019 00:00	0.0	0	0	0	0	1
11/28/2019 01:00	0.0	0	0	0	0	1
11/28/2019 02:00	0.0	0	0	0	0	1
11/28/2019 03:00	0.0	0	0	0	0	1
11/28/2019 04:00	0.0	0	0	0	0	1
11/28/2019 05:00	0.0	0	0	0	0	1
11/28/2019 06:00	0.0	0	0	0	0	1
11/28/2019 07:00	0.0	0	0	0	0	1
11/28/2019 08:00	0.0	0	0	0	0	1
11/28/2019 09:00	0.0	0	0	0	0	1
11/28/2019 10:00	0.0	0	0	0	0	1
11/28/2019 11:00	0.0	0	0	0	0	1
11/28/2019 12:00	0.0	0	0	0	0	1
11/28/2019 13:00	0.0	0	0	0	0	1
11/28/2019 14:00	0.0	0	0	0	0	1
11/28/2019 15:00	0.0	0	0	0	0	1
11/28/2019 16:00	0.0	0	0	0	0	1
11/28/2019 17:00	0.0	0	0	0	0	1
11/28/2019 18:00	0.0	0	0	0	0	1
11/28/2019 19:00	0.0	0	0	0	0	1
11/28/2019 20:00	0.0	0	0	0	0	1
11/28/2019 21:00	0.0	0	0	0	0	1
11/28/2019 22:00	0.0	0	0	0	0	1
11/28/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/29/2019 00:00	0.0	0	0	0	0	1
11/29/2019 01:00	0.0	0	0	0	0	1
11/29/2019 02:00	0.0	0	0	0	0	1
11/29/2019 03:00	0.0	0	0	0	0	1
11/29/2019 04:00	0.0	0	0	0	0	1
11/29/2019 05:00	0.0	0	0	0	0	1
11/29/2019 06:00	0.0	0	0	0	0	1
11/29/2019 07:00	0.0	0	0	0	0	1
11/29/2019 08:00	0.0	0	0	0	0	1
11/29/2019 09:00	0.0	0	0	0	0	1
11/29/2019 10:00	0.0	0	0	0	0	1
11/29/2019 11:00	0.0	0	0	0	0	1
11/29/2019 12:00	0.0	0	0	0	0	1
11/29/2019 13:00	0.0	0	0	0	0	1
11/29/2019 14:00	0.0	0	0	0	0	1
11/29/2019 15:00	0.0	0	0	0	0	1
11/29/2019 16:00	0.0	0	0	0	0	1
11/29/2019 17:00	0.0	0	0	0	0	1
11/29/2019 18:00	0.0	0	0	0	0	1
11/29/2019 19:00	0.0	0	0	0	0	1
11/29/2019 20:00	0.0	0	0	0	0	1
11/29/2019 21:00	0.0	0	0	0	0	1
11/29/2019 22:00	0.0	0	0	0	0	1
11/29/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/30/2019 00:00	0.0	0	0	0	0	1
11/30/2019 01:00	0.0	0	0	0	0	1
11/30/2019 02:00	0.0	0	0	0	0	1
11/30/2019 03:00	0.0	0	0	0	0	1
11/30/2019 04:00	0.0	0	0	0	0	1
11/30/2019 05:00	0.0	0	0	0	0	1
11/30/2019 06:00	0.0	0	0	0	0	1
11/30/2019 07:00	0.0	0	0	0	0	1
11/30/2019 08:00	0.0	0	0	0	0	1
11/30/2019 09:00	0.0	0	0	0	0	1
11/30/2019 10:00	0.0	0	0	0	0	1
11/30/2019 11:00	0.0	0	0	0	0	1
11/30/2019 12:00	0.0	0	0	0	0	1
11/30/2019 13:00	0.0	0	0	0	0	1
11/30/2019 14:00	0.0	0	0	0	0	1
11/30/2019 15:00	0.0	0	0	0	0	1
11/30/2019 16:00	0.0	0	0	0	0	1
11/30/2019 17:00	0.0	0	0	0	0	1
11/30/2019 18:00	0.0	0	0	0	0	1
11/30/2019 19:00	0.0	0	0	0	0	1
11/30/2019 20:00	0.0	0	0	0	0	1
11/30/2019 21:00	0.0	0	0	0	0	1
11/30/2019 22:00	0.0	0	0	0	0	1
11/30/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/01/2019 00:00	0.0	0	0	0	0	1
12/01/2019 01:00	0.0	0	0	0	0	1
12/01/2019 02:00	0.0	0	0	0	0	1
12/01/2019 03:00	0.0	0	0	0	0	1
12/01/2019 04:00	0.0	0	0	0	0	1
12/01/2019 05:00	0.0	0	0	0	0	1
12/01/2019 06:00	0.0	0	0	0	0	1
12/01/2019 07:00	0.0	0	0	0	0	1
12/01/2019 08:00	0.0	0	0	0	0	1
12/01/2019 09:00	0.0	0	0	0	0	1
12/01/2019 10:00	0.0	0	0	0	0	1
12/01/2019 11:00	0.0	0	0	0	0	1
12/01/2019 12:00	0.0	0	0	0	0	1
12/01/2019 13:00	0.0	0	0	0	0	1
12/01/2019 14:00	0.0	0	0	0	0	1
12/01/2019 15:00	0.0	0	0	0	0	1
12/01/2019 16:00	0.0	0	0	0	0	1
12/01/2019 17:00	0.0	0	0	0	0	1
12/01/2019 18:00	0.0	0	0	0	0	1
12/01/2019 19:00	0.0	0	0	0	0	1
12/01/2019 20:00	0.0	0	0	0	0	1
12/01/2019 21:00	0.0	0	0	0	0	1
12/01/2019 22:00	0.0	0	0	0	0	1
12/01/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/02/2019 00:00	0.0	0	0	0	0	1
12/02/2019 01:00	0.0	0	0	0	0	1
12/02/2019 02:00	0.0	0	0	0	0	1
12/02/2019 03:00	0.0	0	0	0	0	1
12/02/2019 04:00	0.0	0	0	0	0	1
12/02/2019 05:00	0.0	0	0	0	0	1
12/02/2019 06:00	0.0	0	0	0	0	1
12/02/2019 07:00	0.0	0	0	0	0	1
12/02/2019 08:00	0.0	0	0	0	0	1
12/02/2019 09:00	0.0	0	0	0	0	1
12/02/2019 10:00	0.0	0	0	0	0	1
12/02/2019 11:00	0.0	0	0	0	0	1
12/02/2019 12:00	0.0	0	0	0	0	1
12/02/2019 13:00	0.0	0	0	0	0	1
12/02/2019 14:00	0.0	0	0	0	0	1
12/02/2019 15:00	0.0	0	0	0	0	1
12/02/2019 16:00	0.0	0	0	0	0	1
12/02/2019 17:00	0.0	0	0	0	0	1
12/02/2019 18:00	0.0	0	0	0	0	1
12/02/2019 19:00	0.0	0	0	0	0	1
12/02/2019 20:00	0.0	0	0	0	0	1
12/02/2019 21:00	0.0	0	0	0	0	1
12/02/2019 22:00	0.0	0	0	0	0	1
12/02/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/03/2019 00:00	0.0	0	0	0	0	1
12/03/2019 01:00	0.0	0	0	0	0	1
12/03/2019 02:00	0.0	0	0	0	0	1
12/03/2019 03:00	0.0	0	0	0	0	1
12/03/2019 04:00	0.0	0	0	0	0	1
12/03/2019 05:00	0.0	0	0	0	0	1
12/03/2019 06:00	0.0	0	0	0	0	1
12/03/2019 07:00	0.0	0	0	0	0	1
12/03/2019 08:00	0.0	0	0	0	0	1
12/03/2019 09:00	0.0	0	0	0	0	1
12/03/2019 10:00	0.0	0	0	0	0	1
12/03/2019 11:00	0.0	0	0	0	0	1
12/03/2019 12:00	0.0	0	0	0	0	1
12/03/2019 13:00	0.0	0	0	0	0	1
12/03/2019 14:00	0.0	0	0	0	0	1
12/03/2019 15:00	0.0	0	0	0	0	1
12/03/2019 16:00	0.0	0	0	0	0	1
12/03/2019 17:00	0.0	0	0	0	0	1
12/03/2019 18:00	0.0	0	0	0	0	1
12/03/2019 19:00	0.0	0	0	0	0	1
12/03/2019 20:00	0.0	0	0	0	0	1
12/03/2019 21:00	0.0	0	0	0	0	1
12/03/2019 22:00	0.0	0	0	0	0	1
12/03/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/04/2019 00:00	0.0	0	0	0	0	1
12/04/2019 01:00	0.0	0	0	0	0	1
12/04/2019 02:00	0.0	0	0	0	0	1
12/04/2019 03:00	0.0	0	0	0	0	1
12/04/2019 04:00	0.0	0	0	0	0	1
12/04/2019 05:00	0.0	0	0	0	0	1
12/04/2019 06:00	0.0	0	0	0	0	1
12/04/2019 07:00	0.0	0	0	0	0	1
12/04/2019 08:00	0.0	0	0	0	0	1
12/04/2019 09:00	0.0	0	0	0	0	1
12/04/2019 10:00	0.0	0	0	0	0	1
12/04/2019 11:00	0.0	0	0	0	0	1
12/04/2019 12:00	0.0	0	0	0	0	1
12/04/2019 13:00	0.0	0	0	0	0	1
12/04/2019 14:00	0.0	0	0	0	0	1
12/04/2019 15:00	0.0	0	0	0	0	1
12/04/2019 16:00	0.0	0	0	0	0	1
12/04/2019 17:00	0.0	0	0	0	0	1
12/04/2019 18:00	0.0	0	0	0	0	1
12/04/2019 19:00	0.0	0	0	0	0	1
12/04/2019 20:00	0.0	0	0	0	0	1
12/04/2019 21:00	0.0	0	0	0	0	1
12/04/2019 22:00	0.0	0	0	0	0	1
12/04/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/05/2019 00:00	0.0	0	0	0	0	1
12/05/2019 01:00	0.0	0	0	0	0	1
12/05/2019 02:00	0.0	0	0	0	0	1
12/05/2019 03:00	0.0	0	0	0	0	1
12/05/2019 04:00	0.0	0	0	0	0	1
12/05/2019 05:00	0.0	0	0	0	0	1
12/05/2019 06:00	0.0	0	0	0	0	1
12/05/2019 07:00	0.0	0	0	0	0	1
12/05/2019 08:00	0.0	0	0	0	0	1
12/05/2019 09:00	0.0	0	0	0	0	1
12/05/2019 10:00	0.0	0	0	0	0	1
12/05/2019 11:00	0.0	0	0	0	0	1
12/05/2019 12:00	0.0	0	0	0	0	1
12/05/2019 13:00	0.0	0	0	0	0	1
12/05/2019 14:00	0.0	0	0	0	0	1
12/05/2019 15:00	0.0	0	0	0	0	1
12/05/2019 16:00	0.0	0	0	0	0	1
12/05/2019 17:00	0.0	0	0	0	0	1
12/05/2019 18:00	0.0	0	0	0	0	1
12/05/2019 19:00	0.0	0	0	0	0	1
12/05/2019 20:00	0.0	0	0	0	0	1
12/05/2019 21:00	0.0	0	0	0	0	1
12/05/2019 22:00	0.0	0	0	0	0	1
12/05/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/06/2019 00:00	0.0	0	0	0	0	1
12/06/2019 01:00	0.0	0	0	0	0	1
12/06/2019 02:00	0.0	0	0	0	0	1
12/06/2019 03:00	0.0	0	0	0	0	1
12/06/2019 04:00	0.0	0	0	0	0	1
12/06/2019 05:00	0.0	0	0	0	0	1
12/06/2019 06:00	0.0	0	0	0	0	1
12/06/2019 07:00	0.0	0	0	0	0	1
12/06/2019 08:00	0.0	0	0	0	0	1
12/06/2019 09:00	0.0	0	0	0	0	1
12/06/2019 10:00	0.0	0	0	0	0	1
12/06/2019 11:00	0.0	0	0	0	0	1
12/06/2019 12:00	0.0	0	0	0	0	1
12/06/2019 13:00	0.0	0	0	0	0	1
12/06/2019 14:00	0.0	0	0	0	0	1
12/06/2019 15:00	0.0	0	0	0	0	1
12/06/2019 16:00	0.0	0	0	0	0	1
12/06/2019 17:00	0.0	0	0	0	0	1
12/06/2019 18:00	0.0	0	0	0	0	1
12/06/2019 19:00	0.0	0	0	0	0	1
12/06/2019 20:00	0.0	0	0	0	0	1
12/06/2019 21:00	0.0	0	0	0	0	1
12/06/2019 22:00	0.0	0	0	0	0	1
12/06/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/07/2019 00:00	0.0	0	0	0	0	1
12/07/2019 01:00	0.0	0	0	0	0	1
12/07/2019 02:00	0.0	0	0	0	0	1
12/07/2019 03:00	0.0	0	0	0	0	1
12/07/2019 04:00	0.0	0	0	0	0	1
12/07/2019 05:00	0.0	0	0	0	0	1
12/07/2019 06:00	0.0	0	0	0	0	1
12/07/2019 07:00	0.0	0	0	0	0	1
12/07/2019 08:00	0.0	0	0	0	0	1
12/07/2019 09:00	0.0	0	0	0	0	1
12/07/2019 10:00	0.0	0	0	0	0	1
12/07/2019 11:00	0.0	0	0	0	0	1
12/07/2019 12:00	0.0	0	0	0	0	1
12/07/2019 13:00	0.0	0	0	0	0	1
12/07/2019 14:00	0.0	0	0	0	0	1
12/07/2019 15:00	0.0	0	0	0	0	1
12/07/2019 16:00	0.0	0	0	0	0	1
12/07/2019 17:00	0.0	0	0	0	0	1
12/07/2019 18:00	0.0	0	0	0	0	1
12/07/2019 19:00	0.0	0	0	0	0	1
12/07/2019 20:00	0.0	0	0	0	0	1
12/07/2019 21:00	0.0	0	0	0	0	1
12/07/2019 22:00	0.0	0	0	0	0	1
12/07/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/08/2019 00:00	0.0	0	0	0	0	1
12/08/2019 01:00	0.0	0	0	0	0	1
12/08/2019 02:00	0.0	0	0	0	0	1
12/08/2019 03:00	0.0	0	0	0	0	1
12/08/2019 04:00	0.0	0	0	0	0	1
12/08/2019 05:00	0.0	0	0	0	0	1
12/08/2019 06:00	0.0	0	0	0	0	1
12/08/2019 07:00	0.0	0	0	0	0	1
12/08/2019 08:00	0.0	0	0	0	0	1
12/08/2019 09:00	0.0	0	0	0	0	1
12/08/2019 10:00	0.0	0	0	0	0	1
12/08/2019 11:00	0.0	0	0	0	0	1
12/08/2019 12:00	0.0	0	0	0	0	1
12/08/2019 13:00	0.0	0	0	0	0	1
12/08/2019 14:00	0.0	0	0	0	0	1
12/08/2019 15:00	0.0	0	0	0	0	1
12/08/2019 16:00	0.0	0	0	0	0	1
12/08/2019 17:00	0.0	0	0	0	0	1
12/08/2019 18:00	0.0	0	0	0	0	1
12/08/2019 19:00	0.0	0	0	0	0	1
12/08/2019 20:00	0.0	0	0	0	0	1
12/08/2019 21:00	0.0	0	0	0	0	1
12/08/2019 22:00	0.0	0	0	0	0	1
12/08/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/09/2019 00:00	0.0	0	0	0	0	1
12/09/2019 01:00	0.0	0	0	0	0	1
12/09/2019 02:00	0.0	0	0	0	0	1
12/09/2019 03:00	0.0	0	0	0	0	1
12/09/2019 04:00	0.0	0	0	0	0	1
12/09/2019 05:00	0.0	0	0	0	0	1
12/09/2019 06:00	0.0	0	0	0	0	1
12/09/2019 07:00	0.0	0	0	0	0	1
12/09/2019 08:00	0.0	0	0	0	0	1
12/09/2019 09:00	0.0	0	0	0	0	1
12/09/2019 10:00	0.0	0	0	0	0	1
12/09/2019 11:00	0.0	0	0	0	0	1
12/09/2019 12:00	0.0	0	0	0	0	1
12/09/2019 13:00	0.0	0	0	0	0	1
12/09/2019 14:00	0.0	0	0	0	0	1
12/09/2019 15:00	0.0	0	0	0	0	1
12/09/2019 16:00	0.0	0	0	0	0	1
12/09/2019 17:00	0.0	0	0	0	0	1
12/09/2019 18:00	0.0	0	0	0	0	1
12/09/2019 19:00	0.0	0	0	0	0	1
12/09/2019 20:00	0.0	0	0	0	0	1
12/09/2019 21:00	0.0	0	0	0	0	1
12/09/2019 22:00	0.0	0	0	0	0	1
12/09/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/10/2019 00:00	0.0	0	0	0	0	1
12/10/2019 01:00	0.0	0	0	0	0	1
12/10/2019 02:00	0.0	0	0	0	0	1
12/10/2019 03:00	0.0	0	0	0	0	1
12/10/2019 04:00	0.0	0	0	0	0	1
12/10/2019 05:00	0.0	0	0	0	0	1
12/10/2019 06:00	0.0	0	0	0	0	1
12/10/2019 07:00	0.0	0	0	0	0	1
12/10/2019 08:00	0.0	0	0	0	0	1
12/10/2019 09:00	0.0	0	0	0	0	1
12/10/2019 10:00	0.0	0	0	0	0	1
12/10/2019 11:00	0.0	0	0	0	0	1
12/10/2019 12:00	0.0	0	0	0	0	1
12/10/2019 13:00	0.0	0	0	0	0	1
12/10/2019 14:00	0.0	0	0	0	0	1
12/10/2019 15:00	0.0	0	0	0	0	1
12/10/2019 16:00	0.0	0	0	0	0	1
12/10/2019 17:00	0.0	0	0	0	0	1
12/10/2019 18:00	0.0	0	0	0	0	1
12/10/2019 19:00	0.0	0	0	0	0	1
12/10/2019 20:00	0.0	0	0	0	0	1
12/10/2019 21:00	0.0	0	0	0	0	1
12/10/2019 22:00	0.0	0	0	0	0	1
12/10/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/11/2019 00:00	0.0	0	0	0	0	1
12/11/2019 01:00	0.0	0	0	0	0	1
12/11/2019 02:00	0.0	0	0	0	0	1
12/11/2019 03:00	0.0	0	0	0	0	1
12/11/2019 04:00	0.0	0	0	0	0	1
12/11/2019 05:00	0.0	0	0	0	0	1
12/11/2019 06:00	0.0	0	0	0	0	1
12/11/2019 07:00	0.0	0	0	0	0	1
12/11/2019 08:00	0.0	0	0	0	0	1
12/11/2019 09:00	0.0	0	0	0	0	1
12/11/2019 10:00	0.0	0	0	0	0	1
12/11/2019 11:00	0.0	0	0	0	0	1
12/11/2019 12:00	0.0	0	0	0	0	1
12/11/2019 13:00	0.0	0	0	0	0	1
12/11/2019 14:00	0.0	0	0	0	0	1
12/11/2019 15:00	0.0	0	0	0	0	1
12/11/2019 16:00	0.0	0	0	0	0	1
12/11/2019 17:00	0.0	0	0	0	0	1
12/11/2019 18:00	0.0	0	0	0	0	1
12/11/2019 19:00	0.0	0	0	0	0	1
12/11/2019 20:00	0.0	0	0	0	0	1
12/11/2019 21:00	0.0	0	0	0	0	1
12/11/2019 22:00	0.0	0	0	0	0	1
12/11/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/12/2019 00:00	0.0	0	0	0	0	1
12/12/2019 01:00	0.0	0	0	0	0	1
12/12/2019 02:00	0.0	0	0	0	0	1
12/12/2019 03:00	0.0	0	0	0	0	1
12/12/2019 04:00	0.0	0	0	0	0	1
12/12/2019 05:00	0.0	0	0	0	0	1
12/12/2019 06:00	0.0	0	0	0	0	1
12/12/2019 07:00	0.0	0	0	0	0	1
12/12/2019 08:00	0.0	0	0	0	0	1
12/12/2019 09:00	0.0	0	0	0	0	1
12/12/2019 10:00	0.0	0	0	0	0	1
12/12/2019 11:00	0.0	0	0	0	0	1
12/12/2019 12:00	0.0	0	0	0	0	1
12/12/2019 13:00	0.0	0	0	0	0	1
12/12/2019 14:00	0.0	0	0	0	0	1
12/12/2019 15:00	0.0	0	0	0	0	1
12/12/2019 16:00	0.0	0	0	0	0	1
12/12/2019 17:00	0.0	0	0	0	0	1
12/12/2019 18:00	0.0	0	0	0	0	1
12/12/2019 19:00	0.0	0	0	0	0	1
12/12/2019 20:00	0.0	0	0	0	0	1
12/12/2019 21:00	0.0	0	0	0	0	1
12/12/2019 22:00	0.0	0	0	0	0	1
12/12/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/13/2019 00:00	66.2	0	0	0	1	0
12/13/2019 01:00	0.0	0	0	0	0	0
12/13/2019 02:00	0.0	0	0	0	0	0
12/13/2019 03:00	0.0	0	0	0	0	0
12/13/2019 04:00	2,615.1	0	0	1	0	0
12/13/2019 05:00	3,037.7	0	0	1	0	0
12/13/2019 06:00	0.0	0	0	0	0	1
12/13/2019 07:00	0.0	0	0	0	0	1
12/13/2019 08:00	0.0	0	0	0	0	1
12/13/2019 09:00	0.0	0	0	0	0	1
12/13/2019 10:00	0.0	0	0	0	0	1
12/13/2019 11:00	0.0	0	0	0	0	1
12/13/2019 12:00	0.0	0	0	0	0	1
12/13/2019 13:00	0.0	0	0	0	0	1
12/13/2019 14:00	0.0	0	0	0	0	1
12/13/2019 15:00	0.0	0	0	0	0	1
12/13/2019 16:00	0.0	0	0	0	0	1
12/13/2019 17:00	0.0	0	0	0	0	1
12/13/2019 18:00	0.0	0	0	0	0	1
12/13/2019 19:00	0.0	0	0	0	0	1
12/13/2019 20:00	0.0	0	0	0	0	1
12/13/2019 21:00	0.0	0	0	0	0	1
12/13/2019 22:00	0.0	0	0	0	0	1
12/13/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	5,719.0 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,037.7	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/14/2019 00:00	0.0	0	0	0	0	1
12/14/2019 01:00	0.0	0	0	0	0	1
12/14/2019 02:00	0.0	0	0	0	0	1
12/14/2019 03:00	0.0	0	0	0	0	1
12/14/2019 04:00	0.0	0	0	0	0	1
12/14/2019 05:00	0.0	0	0	0	0	1
12/14/2019 06:00	0.0	0	0	0	0	1
12/14/2019 07:00	0.0	0	0	0	0	1
12/14/2019 08:00	0.0	0	0	0	0	1
12/14/2019 09:00	0.0	0	0	0	0	1
12/14/2019 10:00	0.0	0	0	0	0	1
12/14/2019 11:00	0.0	0	0	0	0	1
12/14/2019 12:00	0.0	0	0	0	0	1
12/14/2019 13:00	0.0	0	0	0	0	1
12/14/2019 14:00	0.0	0	0	0	0	1
12/14/2019 15:00	0.0	0	0	0	0	1
12/14/2019 16:00	0.0	0	0	0	0	1
12/14/2019 17:00	0.0	0	0	0	0	1
12/14/2019 18:00	0.0	0	0	0	0	1
12/14/2019 19:00	0.0	0	0	0	0	1
12/14/2019 20:00	0.0	0	0	0	0	1
12/14/2019 21:00	0.0	0	0	0	0	1
12/14/2019 22:00	0.0	0	0	0	0	1
12/14/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/15/2019 00:00	0.0	0	0	0	0	1
12/15/2019 01:00	0.0	0	0	0	0	1
12/15/2019 02:00	0.0	0	0	0	0	1
12/15/2019 03:00	0.0	0	0	0	0	1
12/15/2019 04:00	0.0	0	0	0	0	1
12/15/2019 05:00	0.0	0	0	0	0	1
12/15/2019 06:00	0.0	0	0	0	0	1
12/15/2019 07:00	0.0	0	0	0	0	1
12/15/2019 08:00	0.0	0	0	0	0	1
12/15/2019 09:00	0.0	0	0	0	0	1
12/15/2019 10:00	0.0	0	0	0	0	1
12/15/2019 11:00	0.0	0	0	0	0	1
12/15/2019 12:00	0.0	0	0	0	0	1
12/15/2019 13:00	0.0	0	0	0	0	1
12/15/2019 14:00	0.0	0	0	0	0	1
12/15/2019 15:00	0.0	0	0	0	0	1
12/15/2019 16:00	0.0	0	0	0	0	1
12/15/2019 17:00	0.0	0	0	0	0	1
12/15/2019 18:00	0.0	0	0	0	0	1
12/15/2019 19:00	0.0	0	0	0	0	1
12/15/2019 20:00	0.0	0	0	0	0	1
12/15/2019 21:00	0.0	0	0	0	0	1
12/15/2019 22:00	0.0	0	0	0	0	1
12/15/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/16/2019 00:00	0.0	0	0	0	0	1
12/16/2019 01:00	0.0	0	0	0	0	1
12/16/2019 02:00	0.0	0	0	0	0	1
12/16/2019 03:00	0.0	0	0	0	0	1
12/16/2019 04:00	0.0	0	0	0	0	1
12/16/2019 05:00	0.0	0	0	0	0	1
12/16/2019 06:00	0.0	0	0	0	0	1
12/16/2019 07:00	0.0	0	0	0	0	1
12/16/2019 08:00	0.0	0	0	0	0	1
12/16/2019 09:00	0.0	0	0	0	0	1
12/16/2019 10:00	0.0	0	0	0	0	1
12/16/2019 11:00	0.0	0	0	0	0	1
12/16/2019 12:00	0.0	0	0	0	0	1
12/16/2019 13:00	0.0	0	0	0	0	1
12/16/2019 14:00	0.0	0	0	0	0	1
12/16/2019 15:00	0.0	0	0	0	0	1
12/16/2019 16:00	0.0	0	0	0	0	1
12/16/2019 17:00	0.0	0	0	0	0	1
12/16/2019 18:00	0.0	0	0	0	0	1
12/16/2019 19:00	0.0	0	0	0	0	1
12/16/2019 20:00	0.0	0	0	0	0	1
12/16/2019 21:00	0.0	0	0	0	0	1
12/16/2019 22:00	0.0	0	0	0	0	1
12/16/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/17/2019 00:00	0.0	0	0	0	0	1
12/17/2019 01:00	0.0	0	0	0	0	1
12/17/2019 02:00	0.0	0	0	0	0	1
12/17/2019 03:00	0.0	0	0	0	0	1
12/17/2019 04:00	0.0	0	0	0	0	1
12/17/2019 05:00	0.0	0	0	0	0	1
12/17/2019 06:00	0.0	0	0	0	0	1
12/17/2019 07:00	0.0	0	0	0	0	1
12/17/2019 08:00	0.0	0	0	0	0	1
12/17/2019 09:00	0.0	0	0	0	0	1
12/17/2019 10:00	0.0	0	0	0	0	1
12/17/2019 11:00	0.0	0	0	0	0	1
12/17/2019 12:00	0.0	0	0	0	0	1
12/17/2019 13:00	0.0	0	0	0	0	1
12/17/2019 14:00	0.0	0	0	0	0	1
12/17/2019 15:00	0.0	0	0	0	0	1
12/17/2019 16:00	0.0	0	0	0	0	1
12/17/2019 17:00	0.0	0	0	0	0	1
12/17/2019 18:00	0.0	0	0	0	0	1
12/17/2019 19:00	0.0	0	0	0	0	1
12/17/2019 20:00	0.0	0	0	0	0	1
12/17/2019 21:00	0.0	0	0	0	0	1
12/17/2019 22:00	0.0	0	0	0	0	1
12/17/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/18/2019 00:00	0.0	0	0	0	0	1
12/18/2019 01:00	0.0	0	0	0	0	1
12/18/2019 02:00	0.0	0	0	0	0	1
12/18/2019 03:00	0.0	0	0	0	0	1
12/18/2019 04:00	0.0	0	0	0	0	1
12/18/2019 05:00	0.0	0	0	0	0	1
12/18/2019 06:00	0.0	0	0	0	0	1
12/18/2019 07:00	0.0	0	0	0	0	1
12/18/2019 08:00	0.0	0	0	0	0	1
12/18/2019 09:00	0.0	0	0	0	0	1
12/18/2019 10:00	0.0	0	0	0	0	1
12/18/2019 11:00	0.0	0	0	0	0	1
12/18/2019 12:00	0.0	0	0	0	0	1
12/18/2019 13:00	0.0	0	0	0	0	1
12/18/2019 14:00	0.0	0	0	0	0	1
12/18/2019 15:00	0.0	0	0	0	0	1
12/18/2019 16:00	0.0	0	0	0	0	1
12/18/2019 17:00	0.0	0	0	0	0	1
12/18/2019 18:00	0.0	0	0	0	0	1
12/18/2019 19:00	0.0	0	0	0	0	1
12/18/2019 20:00	0.0	0	0	0	0	1
12/18/2019 21:00	0.0	0	0	0	0	1
12/18/2019 22:00	0.0	0	0	0	0	1
12/18/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/19/2019 00:00	0.0	0	0	0	0	1
12/19/2019 01:00	0.0	0	0	0	0	1
12/19/2019 02:00	0.0	0	0	0	0	1
12/19/2019 03:00	0.0	0	0	0	0	1
12/19/2019 04:00	0.0	0	0	0	0	1
12/19/2019 05:00	0.0	0	0	0	0	1
12/19/2019 06:00	0.0	0	0	0	0	1
12/19/2019 07:00	0.0	0	0	0	0	1
12/19/2019 08:00	0.0	0	0	0	0	1
12/19/2019 09:00	0.0	0	0	0	0	1
12/19/2019 10:00	0.0	0	0	0	0	1
12/19/2019 11:00	0.0	0	0	0	0	1
12/19/2019 12:00	0.0	0	0	0	0	1
12/19/2019 13:00	0.0	0	0	0	0	1
12/19/2019 14:00	0.0	0	0	0	0	1
12/19/2019 15:00	0.0	0	0	0	0	1
12/19/2019 16:00	0.0	0	0	0	0	1
12/19/2019 17:00	0.0	0	0	0	0	1
12/19/2019 18:00	0.0	0	0	0	0	1
12/19/2019 19:00	0.0	0	0	0	0	1
12/19/2019 20:00	0.0	0	0	0	0	1
12/19/2019 21:00	0.0	0	0	0	0	1
12/19/2019 22:00	0.0	0	0	0	0	1
12/19/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/20/2019 00:00	0.0	0	0	0	0	1
12/20/2019 01:00	0.0	0	0	0	0	1
12/20/2019 02:00	0.0	0	0	0	0	1
12/20/2019 03:00	0.0	0	0	0	0	1
12/20/2019 04:00	0.0	0	0	0	0	1
12/20/2019 05:00	0.0	0	0	0	0	1
12/20/2019 06:00	0.0	0	0	0	0	1
12/20/2019 07:00	0.0	0	0	0	0	1
12/20/2019 08:00	0.0	0	0	0	0	1
12/20/2019 09:00	0.0	0	0	0	0	1
12/20/2019 10:00	0.0	0	0	0	0	1
12/20/2019 11:00	0.0	0	0	0	0	1
12/20/2019 12:00	0.0	0	0	0	0	1
12/20/2019 13:00	0.0	0	0	0	0	1
12/20/2019 14:00	0.0	0	0	0	0	1
12/20/2019 15:00	0.0	0	0	0	0	1
12/20/2019 16:00	0.0	0	0	0	0	1
12/20/2019 17:00	0.0	0	0	0	0	1
12/20/2019 18:00	0.0	0	0	0	0	1
12/20/2019 19:00	0.0	0	0	0	0	1
12/20/2019 20:00	0.0	0	0	0	0	1
12/20/2019 21:00	0.0	0	0	0	0	1
12/20/2019 22:00	0.0	0	0	0	0	1
12/20/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/21/2019 00:00	0.0	0	0	0	0	1
12/21/2019 01:00	0.0	0	0	0	0	1
12/21/2019 02:00	0.0	0	0	0	0	1
12/21/2019 03:00	0.0	0	0	0	0	1
12/21/2019 04:00	0.0	0	0	0	0	1
12/21/2019 05:00	0.0	0	0	0	0	1
12/21/2019 06:00	0.0	0	0	0	0	1
12/21/2019 07:00	0.0	0	0	0	0	1
12/21/2019 08:00	0.0	0	0	0	0	1
12/21/2019 09:00	0.0	0	0	0	0	1
12/21/2019 10:00	0.0	0	0	0	0	1
12/21/2019 11:00	0.0	0	0	0	0	1
12/21/2019 12:00	0.0	0	0	0	0	1
12/21/2019 13:00	0.0	0	0	0	0	1
12/21/2019 14:00	0.0	0	0	0	0	1
12/21/2019 15:00	0.0	0	0	0	0	1
12/21/2019 16:00	0.0	0	0	0	0	1
12/21/2019 17:00	0.0	0	0	0	0	1
12/21/2019 18:00	0.0	0	0	0	0	1
12/21/2019 19:00	0.0	0	0	0	0	1
12/21/2019 20:00	0.0	0	0	0	0	1
12/21/2019 21:00	0.0	0	0	0	0	1
12/21/2019 22:00	0.0	0	0	0	0	1
12/21/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/22/2019 00:00	0.0	0	0	0	0	1
12/22/2019 01:00	0.0	0	0	0	0	1
12/22/2019 02:00	0.0	0	0	0	0	1
12/22/2019 03:00	0.0	0	0	0	0	1
12/22/2019 04:00	0.0	0	0	0	0	1
12/22/2019 05:00	0.0	0	0	0	0	1
12/22/2019 06:00	0.0	0	0	0	0	1
12/22/2019 07:00	0.0	0	0	0	0	1
12/22/2019 08:00	0.0	0	0	0	0	1
12/22/2019 09:00	0.0	0	0	0	0	1
12/22/2019 10:00	0.0	0	0	0	0	1
12/22/2019 11:00	0.0	0	0	0	0	1
12/22/2019 12:00	0.0	0	0	0	0	1
12/22/2019 13:00	0.0	0	0	0	0	1
12/22/2019 14:00	0.0	0	0	0	0	1
12/22/2019 15:00	0.0	0	0	0	0	1
12/22/2019 16:00	0.0	0	0	0	0	1
12/22/2019 17:00	0.0	0	0	0	0	1
12/22/2019 18:00	0.0	0	0	0	0	1
12/22/2019 19:00	0.0	0	0	0	0	1
12/22/2019 20:00	0.0	0	0	0	0	1
12/22/2019 21:00	0.0	0	0	0	0	1
12/22/2019 22:00	0.0	0	0	0	0	1
12/22/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/23/2019 00:00	0.0	0	0	0	0	1
12/23/2019 01:00	0.0	0	0	0	0	1
12/23/2019 02:00	0.0	0	0	0	0	1
12/23/2019 03:00	0.0	0	0	0	0	1
12/23/2019 04:00	0.0	0	0	0	0	1
12/23/2019 05:00	0.0	0	0	0	0	1
12/23/2019 06:00	0.0	0	0	0	0	1
12/23/2019 07:00	0.0	0	0	0	0	1
12/23/2019 08:00	0.0	0	0	0	0	1
12/23/2019 09:00	0.0	0	0	0	0	1
12/23/2019 10:00	0.0	0	0	0	0	1
12/23/2019 11:00	0.0	0	0	0	0	1
12/23/2019 12:00	0.0	0	0	0	0	1
12/23/2019 13:00	0.0	0	0	0	0	1
12/23/2019 14:00	0.0	0	0	0	0	1
12/23/2019 15:00	0.0	0	0	0	0	1
12/23/2019 16:00	0.0	0	0	0	0	1
12/23/2019 17:00	0.0	0	0	0	0	1
12/23/2019 18:00	0.0	0	0	0	0	1
12/23/2019 19:00	0.0	0	0	0	0	1
12/23/2019 20:00	0.0	0	0	0	0	1
12/23/2019 21:00	0.0	0	0	0	0	1
12/23/2019 22:00	0.0	0	0	0	0	1
12/23/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/24/2019 00:00	0.0	0	0	0	0	1
12/24/2019 01:00	0.0	0	0	0	0	1
12/24/2019 02:00	0.0	0	0	0	0	1
12/24/2019 03:00	0.0	0	0	0	0	1
12/24/2019 04:00	0.0	0	0	0	0	1
12/24/2019 05:00	0.0	0	0	0	0	1
12/24/2019 06:00	0.0	0	0	0	0	1
12/24/2019 07:00	0.0	0	0	0	0	1
12/24/2019 08:00	0.0	0	0	0	0	1
12/24/2019 09:00	0.0	0	0	0	0	1
12/24/2019 10:00	0.0	0	0	0	0	1
12/24/2019 11:00	0.0	0	0	0	0	1
12/24/2019 12:00	0.0	0	0	0	0	1
12/24/2019 13:00	0.0	0	0	0	0	1
12/24/2019 14:00	0.0	0	0	0	0	1
12/24/2019 15:00	0.0	0	0	0	0	1
12/24/2019 16:00	0.0	0	0	0	0	1
12/24/2019 17:00	0.0	0	0	0	0	1
12/24/2019 18:00	0.0	0	0	0	0	1
12/24/2019 19:00	0.0	0	0	0	0	1
12/24/2019 20:00	0.0	0	0	0	0	1
12/24/2019 21:00	0.0	0	0	0	0	1
12/24/2019 22:00	0.0	0	0	0	0	1
12/24/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/25/2019 00:00	0.0	0	0	0	0	1
12/25/2019 01:00	0.0	0	0	0	0	1
12/25/2019 02:00	0.0	0	0	0	0	1
12/25/2019 03:00	0.0	0	0	0	0	1
12/25/2019 04:00	0.0	0	0	0	0	1
12/25/2019 05:00	0.0	0	0	0	0	1
12/25/2019 06:00	0.0	0	0	0	0	1
12/25/2019 07:00	0.0	0	0	0	0	1
12/25/2019 08:00	0.0	0	0	0	0	1
12/25/2019 09:00	0.0	0	0	0	0	1
12/25/2019 10:00	0.0	0	0	0	0	1
12/25/2019 11:00	0.0	0	0	0	0	1
12/25/2019 12:00	0.0	0	0	0	0	1
12/25/2019 13:00	0.0	0	0	0	0	1
12/25/2019 14:00	0.0	0	0	0	0	1
12/25/2019 15:00	0.0	0	0	0	0	1
12/25/2019 16:00	0.0	0	0	0	0	1
12/25/2019 17:00	0.0	0	0	0	0	1
12/25/2019 18:00	0.0	0	0	0	0	1
12/25/2019 19:00	0.0	0	0	0	0	1
12/25/2019 20:00	0.0	0	0	0	0	1
12/25/2019 21:00	0.0	0	0	0	0	1
12/25/2019 22:00	0.0	0	0	0	0	1
12/25/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/26/2019 00:00	0.0	0	0	0	0	1
12/26/2019 01:00	0.0	0	0	0	0	1
12/26/2019 02:00	0.0	0	0	0	0	1
12/26/2019 03:00	0.0	0	0	0	0	1
12/26/2019 04:00	0.0	0	0	0	0	1
12/26/2019 05:00	0.0	0	0	0	0	1
12/26/2019 06:00	0.0	0	0	0	0	1
12/26/2019 07:00	0.0	0	0	0	0	1
12/26/2019 08:00	0.0	0	0	0	0	1
12/26/2019 09:00	0.0	0	0	0	0	1
12/26/2019 10:00	0.0	0	0	0	0	1
12/26/2019 11:00	0.0	0	0	0	0	1
12/26/2019 12:00	0.0	0	0	0	0	1
12/26/2019 13:00	0.0	0	0	0	0	1
12/26/2019 14:00	0.0	0	0	0	0	1
12/26/2019 15:00	0.0	0	0	0	0	1
12/26/2019 16:00	0.0	0	0	0	0	1
12/26/2019 17:00	0.0	0	0	0	0	1
12/26/2019 18:00	0.0	0	0	0	0	1
12/26/2019 19:00	0.0	0	0	0	0	1
12/26/2019 20:00	0.0	0	0	0	0	1
12/26/2019 21:00	0.0	0	0	0	0	1
12/26/2019 22:00	0.0	0	0	0	0	1
12/26/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/27/2019 00:00	0.0	0	0	0	0	1
12/27/2019 01:00	0.0	0	0	0	0	1
12/27/2019 02:00	0.0	0	0	0	0	1
12/27/2019 03:00	0.0	0	0	0	0	1
12/27/2019 04:00	0.0	0	0	0	0	1
12/27/2019 05:00	0.0	0	0	0	0	1
12/27/2019 06:00	0.0	0	0	0	0	1
12/27/2019 07:00	0.0	0	0	0	0	1
12/27/2019 08:00	0.0	0	0	0	0	1
12/27/2019 09:00	0.0	0	0	0	0	1
12/27/2019 10:00	0.0	0	0	0	0	1
12/27/2019 11:00	0.0	0	0	0	0	1
12/27/2019 12:00	0.0	0	0	0	0	1
12/27/2019 13:00	0.0	0	0	0	0	1
12/27/2019 14:00	0.0	0	0	0	0	1
12/27/2019 15:00	0.0	0	0	0	0	1
12/27/2019 16:00	0.0	0	0	0	0	1
12/27/2019 17:00	0.0	0	0	0	0	1
12/27/2019 18:00	0.0	0	0	0	0	1
12/27/2019 19:00	0.0	0	0	0	0	1
12/27/2019 20:00	0.0	0	0	0	0	1
12/27/2019 21:00	0.0	0	0	0	0	1
12/27/2019 22:00	0.0	0	0	0	0	1
12/27/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/28/2019 00:00	0.0	0	0	0	0	1
12/28/2019 01:00	0.0	0	0	0	0	1
12/28/2019 02:00	0.0	0	0	0	0	1
12/28/2019 03:00	0.0	0	0	0	0	1
12/28/2019 04:00	0.0	0	0	0	0	1
12/28/2019 05:00	0.0	0	0	0	0	1
12/28/2019 06:00	0.0	0	0	0	0	1
12/28/2019 07:00	0.0	0	0	0	0	1
12/28/2019 08:00	0.0	0	0	0	0	1
12/28/2019 09:00	0.0	0	0	0	0	1
12/28/2019 10:00	0.0	0	0	0	0	1
12/28/2019 11:00	0.0	0	0	0	0	1
12/28/2019 12:00	0.0	0	0	0	0	1
12/28/2019 13:00	0.0	0	0	0	0	1
12/28/2019 14:00	0.0	0	0	0	0	1
12/28/2019 15:00	0.0	0	0	0	0	1
12/28/2019 16:00	0.0	0	0	0	0	1
12/28/2019 17:00	0.0	0	0	0	0	1
12/28/2019 18:00	0.0	0	0	0	0	1
12/28/2019 19:00	0.0	0	0	0	0	1
12/28/2019 20:00	0.0	0	0	0	0	1
12/28/2019 21:00	0.0	0	0	0	0	1
12/28/2019 22:00	0.0	0	0	0	0	1
12/28/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/29/2019 00:00	0.0	0	0	0	0	1
12/29/2019 01:00	0.0	0	0	0	0	1
12/29/2019 02:00	0.0	0	0	0	0	1
12/29/2019 03:00	0.0	0	0	0	0	1
12/29/2019 04:00	0.0	0	0	0	0	1
12/29/2019 05:00	0.0	0	0	0	0	1
12/29/2019 06:00	0.0	0	0	0	0	1
12/29/2019 07:00	0.0	0	0	0	0	1
12/29/2019 08:00	0.0	0	0	0	0	1
12/29/2019 09:00	0.0	0	0	0	0	1
12/29/2019 10:00	0.0	0	0	0	0	1
12/29/2019 11:00	0.0	0	0	0	0	1
12/29/2019 12:00	0.0	0	0	0	0	1
12/29/2019 13:00	0.0	0	0	0	0	1
12/29/2019 14:00	0.0	0	0	0	0	1
12/29/2019 15:00	0.0	0	0	0	0	1
12/29/2019 16:00	0.0	0	0	0	0	1
12/29/2019 17:00	0.0	0	0	0	0	1
12/29/2019 18:00	0.0	0	0	0	0	1
12/29/2019 19:00	0.0	0	0	0	0	1
12/29/2019 20:00	0.0	0	0	0	0	1
12/29/2019 21:00	0.0	0	0	0	0	1
12/29/2019 22:00	0.0	0	0	0	0	1
12/29/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/30/2019 00:00	0.0	0	0	0	0	1
12/30/2019 01:00	0.0	0	0	0	0	1
12/30/2019 02:00	0.0	0	0	0	0	1
12/30/2019 03:00	0.0	0	0	0	0	1
12/30/2019 04:00	0.0	0	0	0	0	1
12/30/2019 05:00	0.0	0	0	0	0	1
12/30/2019 06:00	0.0	0	0	0	0	1
12/30/2019 07:00	0.0	0	0	0	0	1
12/30/2019 08:00	0.0	0	0	0	0	1
12/30/2019 09:00	0.0	0	0	0	0	1
12/30/2019 10:00	0.0	0	0	0	0	1
12/30/2019 11:00	0.0	0	0	0	0	1
12/30/2019 12:00	0.0	0	0	0	0	1
12/30/2019 13:00	0.0	0	0	0	0	1
12/30/2019 14:00	0.0	0	0	0	0	1
12/30/2019 15:00	0.0	0	0	0	0	1
12/30/2019 16:00	0.0	0	0	0	0	1
12/30/2019 17:00	0.0	0	0	0	0	1
12/30/2019 18:00	0.0	0	0	0	0	1
12/30/2019 19:00	0.0	0	0	0	0	1
12/30/2019 20:00	0.0	0	0	0	0	1
12/30/2019 21:00	0.0	0	0	0	0	1
12/30/2019 22:00	0.0	0	0	0	0	1
12/30/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/31/2019 00:00	0.0	0	0	0	0	1
12/31/2019 01:00	0.0	0	0	0	0	1
12/31/2019 02:00	0.0	0	0	0	0	1
12/31/2019 03:00	0.0	0	0	0	0	1
12/31/2019 04:00	0.0	0	0	0	0	1
12/31/2019 05:00	0.0	0	0	0	0	1
12/31/2019 06:00	0.0	0	0	0	0	1
12/31/2019 07:00	0.0	0	0	0	0	1
12/31/2019 08:00	0.0	0	0	0	0	1
12/31/2019 09:00	0.0	0	0	0	0	1
12/31/2019 10:00	0.0	0	0	0	0	1
12/31/2019 11:00	0.0	0	0	0	0	1
12/31/2019 12:00	0.0	0	0	0	0	1
12/31/2019 13:00	0.0	0	0	0	0	1
12/31/2019 14:00	0.0	0	0	0	0	1
12/31/2019 15:00	0.0	0	0	0	0	1
12/31/2019 16:00	0.0	0	0	0	0	1
12/31/2019 17:00	0.0	0	0	0	0	1
12/31/2019 18:00	0.0	0	0	0	0	1
12/31/2019 19:00	0.0	0	0	0	0	1
12/31/2019 20:00	0.0	0	0	0	0	1
12/31/2019 21:00	0.0	0	0	0	0	1
12/31/2019 22:00	0.0	0	0	0	0	1
12/31/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/01/2019 00:00	0.1	0	0	0	1	0
10/01/2019 01:00	0.0	0	0	0	0	0
10/01/2019 02:00	0.0	0	0	0	0	0
10/01/2019 03:00	0.0	0	0	0	0	0
10/01/2019 04:00	2.7	0	0	1	0	0
10/01/2019 05:00	17.0	0	0	1	0	0
10/01/2019 06:00	0.0	0	0	0	0	1
10/01/2019 07:00	0.0	0	0	0	0	1
10/01/2019 08:00	0.0	0	0	0	0	1
10/01/2019 09:00	0.0	0	0	0	0	1
10/01/2019 10:00	0.0	0	0	0	0	1
10/01/2019 11:00	0.0	0	0	0	0	1
10/01/2019 12:00	0.0	0	0	0	0	1
10/01/2019 13:00	0.0	0	0	0	0	1
10/01/2019 14:00	0.0	0	0	0	0	1
10/01/2019 15:00	0.0	0	0	0	0	1
10/01/2019 16:00	0.0	0	0	0	0	1
10/01/2019 17:00	0.0	0	0	0	0	1
10/01/2019 18:00	0.0	0	0	0	0	1
10/01/2019 19:00	0.0	0	0	0	0	1
10/01/2019 20:00	0.0	0	0	0	0	1
10/01/2019 21:00	0.0	0	0	0	0	1
10/01/2019 22:00	0.0	0	0	0	0	1
10/01/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	19.8 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	17.0	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/02/2019 00:00	0.0	0	0	0	0	1
10/02/2019 01:00	0.0	0	0	0	0	1
10/02/2019 02:00	0.0	0	0	0	0	1
10/02/2019 03:00	0.0	0	0	0	0	1
10/02/2019 04:00	0.0	0	0	0	0	1
10/02/2019 05:00	0.0	0	0	0	0	1
10/02/2019 06:00	0.0	0	0	0	0	1
10/02/2019 07:00	0.0	0	0	0	0	1
10/02/2019 08:00	0.0	0	0	0	0	1
10/02/2019 09:00	0.0	0	0	0	0	1
10/02/2019 10:00	0.0	0	0	0	0	1
10/02/2019 11:00	0.0	0	0	0	0	1
10/02/2019 12:00	0.0	0	0	0	0	1
10/02/2019 13:00	0.0	0	0	0	0	1
10/02/2019 14:00	0.0	0	0	0	0	1
10/02/2019 15:00	0.0	0	0	0	0	1
10/02/2019 16:00	0.0	0	0	0	0	1
10/02/2019 17:00	0.0	0	0	0	0	1
10/02/2019 18:00	0.0	0	0	0	0	1
10/02/2019 19:00	0.0	0	0	0	0	1
10/02/2019 20:00	0.0	0	0	0	0	1
10/02/2019 21:00	0.0	0	0	0	0	1
10/02/2019 22:00	0.0	0	0	0	0	1
10/02/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/03/2019 00:00	0.0	0	0	0	0	1
10/03/2019 01:00	0.0	0	0	0	0	1
10/03/2019 02:00	0.0	0	0	0	0	1
10/03/2019 03:00	0.0	0	0	0	0	1
10/03/2019 04:00	0.0	0	0	0	0	1
10/03/2019 05:00	0.0	0	0	0	0	1
10/03/2019 06:00	0.0	0	0	0	0	1
10/03/2019 07:00	0.0	0	0	0	0	1
10/03/2019 08:00	0.0	0	0	0	0	1
10/03/2019 09:00	0.0	0	0	0	0	1
10/03/2019 10:00	0.0	0	0	0	0	1
10/03/2019 11:00	0.0	0	0	0	0	1
10/03/2019 12:00	0.0	0	0	0	0	1
10/03/2019 13:00	0.0	0	0	0	0	1
10/03/2019 14:00	0.0	0	0	0	0	1
10/03/2019 15:00	0.0	0	0	0	0	1
10/03/2019 16:00	0.0	0	0	0	0	1
10/03/2019 17:00	0.0	0	0	0	0	1
10/03/2019 18:00	0.0	0	0	0	0	1
10/03/2019 19:00	0.0	0	0	0	0	1
10/03/2019 20:00	0.0	0	0	0	0	1
10/03/2019 21:00	0.9	0	0	0	1	0
10/03/2019 22:00	0.0	0	0	0	0	0
10/03/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.9 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/04/2019 00:00	0.0	0	0	0	0	0
10/04/2019 01:00	0.0	0	0	0	0	0
10/04/2019 02:00	0.0	0	0	0	0	0
10/04/2019 03:00	0.0	0	0	0	0	0
10/04/2019 04:00	0.0	0	0	0	0	0
10/04/2019 05:00	0.0	0	0	0	0	0
10/04/2019 06:00	0.0	0	0	0	0	0
10/04/2019 07:00	0.0	0	0	0	0	0
10/04/2019 08:00	0.0	0	0	0	0	0
10/04/2019 09:00	0.0	0	0	0	0	0
10/04/2019 10:00	0.0	0	0	0	0	0
10/04/2019 11:00	0.0	0	0	0	0	0
10/04/2019 12:00	0.0	0	0	0	0	0
10/04/2019 13:00	30.3	0	1	0	0	0
10/04/2019 14:00	58.5	0	1	0	0	0
10/04/2019 15:00	0.0	0	0	0	0	1
10/04/2019 16:00	0.0	0	0	0	0	1
10/04/2019 17:00	0.0	0	0	0	0	1
10/04/2019 18:00	0.0	0	0	0	0	1
10/04/2019 19:00	0.0	0	0	0	0	1
10/04/2019 20:00	0.0	0	0	0	0	1
10/04/2019 21:00	0.0	0	0	0	0	1
10/04/2019 22:00	0.0	0	0	0	0	1
10/04/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	88.8 #	0 #	2 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	58.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/05/2019 00:00	0.0	0	0	0	0	1
10/05/2019 01:00	0.0	0	0	0	0	1
10/05/2019 02:00	0.0	0	0	0	0	1
10/05/2019 03:00	0.0	0	0	0	0	1
10/05/2019 04:00	0.0	0	0	0	0	1
10/05/2019 05:00	0.0	0	0	0	0	1
10/05/2019 06:00	0.0	0	0	0	0	1
10/05/2019 07:00	0.0	0	0	0	0	1
10/05/2019 08:00	0.0	0	0	0	0	1
10/05/2019 09:00	0.0	0	0	0	0	1
10/05/2019 10:00	0.0	0	0	0	0	1
10/05/2019 11:00	0.0	0	0	0	0	1
10/05/2019 12:00	0.0	0	0	0	0	1
10/05/2019 13:00	0.0	0	0	0	0	1
10/05/2019 14:00	0.0	0	0	0	0	1
10/05/2019 15:00	0.0	0	0	0	0	1
10/05/2019 16:00	0.0	0	0	0	0	1
10/05/2019 17:00	0.0	0	0	0	0	1
10/05/2019 18:00	0.0	0	0	0	0	1
10/05/2019 19:00	0.0	0	0	0	0	1
10/05/2019 20:00	0.0	0	0	0	0	1
10/05/2019 21:00	0.0	0	0	0	0	1
10/05/2019 22:00	0.0	0	0	0	0	1
10/05/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/06/2019 00:00	0.0	0	0	0	0	1
10/06/2019 01:00	0.0	0	0	0	0	1
10/06/2019 02:00	0.0	0	0	0	0	1
10/06/2019 03:00	0.0	0	0	0	0	1
10/06/2019 04:00	0.0	0	0	0	0	1
10/06/2019 05:00	0.0	0	0	0	0	1
10/06/2019 06:00	0.0	0	0	0	0	1
10/06/2019 07:00	0.0	0	0	0	0	1
10/06/2019 08:00	0.0	0	0	0	0	1
10/06/2019 09:00	0.0	0	0	0	0	1
10/06/2019 10:00	0.0	0	0	0	0	1
10/06/2019 11:00	0.0	0	0	0	0	1
10/06/2019 12:00	0.0	0	0	0	0	1
10/06/2019 13:00	0.0	0	0	0	0	1
10/06/2019 14:00	0.0	0	0	0	0	1
10/06/2019 15:00	0.0	0	0	0	0	1
10/06/2019 16:00	0.0	0	0	0	0	1
10/06/2019 17:00	0.0	0	0	0	0	1
10/06/2019 18:00	0.0	0	0	0	0	1
10/06/2019 19:00	0.0	0	0	0	0	1
10/06/2019 20:00	0.0	0	0	0	0	1
10/06/2019 21:00	0.0	0	0	0	0	1
10/06/2019 22:00	0.0	0	0	0	0	1
10/06/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/07/2019 00:00	0.0	0	0	0	0	1
10/07/2019 01:00	0.0	0	0	0	0	1
10/07/2019 02:00	0.0	0	0	0	0	1
10/07/2019 03:00	0.0	0	0	0	0	1
10/07/2019 04:00	0.0	0	0	0	0	1
10/07/2019 05:00	0.0	0	0	0	0	1
10/07/2019 06:00	0.0	0	0	0	0	1
10/07/2019 07:00	0.0	0	0	0	0	1
10/07/2019 08:00	0.0	0	0	0	0	1
10/07/2019 09:00	0.0	0	0	0	0	1
10/07/2019 10:00	0.0	0	0	0	0	1
10/07/2019 11:00	0.0	0	0	0	0	1
10/07/2019 12:00	0.0	0	0	0	0	1
10/07/2019 13:00	0.0	0	0	0	0	1
10/07/2019 14:00	0.0	0	0	0	0	1
10/07/2019 15:00	0.0	0	0	0	0	1
10/07/2019 16:00	0.0	0	0	0	0	1
10/07/2019 17:00	0.0	0	0	0	0	1
10/07/2019 18:00	0.0	0	0	0	0	1
10/07/2019 19:00	0.0	0	0	0	0	1
10/07/2019 20:00	0.0	0	0	0	0	1
10/07/2019 21:00	0.0	0	0	0	0	1
10/07/2019 22:00	0.0	0	0	0	0	1
10/07/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/08/2019 00:00	0.0	0	0	0	0	1
10/08/2019 01:00	0.0	0	0	0	0	1
10/08/2019 02:00	0.0	0	0	0	0	1
10/08/2019 03:00	0.0	0	0	0	0	1
10/08/2019 04:00	0.0	0	0	0	0	1
10/08/2019 05:00	0.0	0	0	0	0	1
10/08/2019 06:00	0.0	0	0	0	0	1
10/08/2019 07:00	0.0	0	0	0	0	1
10/08/2019 08:00	0.0	0	0	0	0	1
10/08/2019 09:00	0.0	0	0	0	0	1
10/08/2019 10:00	0.0	0	0	0	0	1
10/08/2019 11:00	0.0	0	0	0	0	1
10/08/2019 12:00	0.0	0	0	0	0	1
10/08/2019 13:00	0.0	0	0	0	0	1
10/08/2019 14:00	0.0	0	0	0	0	1
10/08/2019 15:00	0.0	0	0	0	0	1
10/08/2019 16:00	0.0	0	0	0	0	1
10/08/2019 17:00	0.0	0	0	0	0	1
10/08/2019 18:00	0.0	0	0	0	0	1
10/08/2019 19:00	0.0	0	0	0	0	1
10/08/2019 20:00	0.0	0	0	0	0	1
10/08/2019 21:00	0.0	0	0	0	0	1
10/08/2019 22:00	0.0	0	0	0	0	1
10/08/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/09/2019 00:00	0.0	0	0	0	0	1
10/09/2019 01:00	0.0	0	0	0	0	1
10/09/2019 02:00	0.0	0	0	0	0	1
10/09/2019 03:00	0.0	0	0	0	0	1
10/09/2019 04:00	0.0	0	0	0	0	1
10/09/2019 05:00	0.0	0	0	0	0	1
10/09/2019 06:00	0.0	0	0	0	0	1
10/09/2019 07:00	0.0	0	0	0	0	1
10/09/2019 08:00	0.0	0	0	0	0	1
10/09/2019 09:00	0.0	0	0	0	0	1
10/09/2019 10:00	0.0	0	0	0	0	1
10/09/2019 11:00	0.0	0	0	0	0	1
10/09/2019 12:00	0.0	0	0	0	0	1
10/09/2019 13:00	0.0	0	0	0	0	1
10/09/2019 14:00	0.0	0	0	0	0	1
10/09/2019 15:00	0.0	0	0	0	0	1
10/09/2019 16:00	0.0	0	0	0	0	1
10/09/2019 17:00	0.0	0	0	0	0	1
10/09/2019 18:00	0.0	0	0	0	0	1
10/09/2019 19:00	0.0	0	0	0	0	1
10/09/2019 20:00	0.0	0	0	0	0	1
10/09/2019 21:00	0.0	0	0	0	0	1
10/09/2019 22:00	0.0	0	0	0	0	1
10/09/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/10/2019 00:00	0.0	0	0	0	0	1
10/10/2019 01:00	0.0	0	0	0	0	1
10/10/2019 02:00	0.0	0	0	0	0	1
10/10/2019 03:00	0.0	0	0	0	0	1
10/10/2019 04:00	0.0	0	0	0	0	1
10/10/2019 05:00	0.0	0	0	0	0	1
10/10/2019 06:00	0.0	0	0	0	0	1
10/10/2019 07:00	0.0	0	0	0	0	1
10/10/2019 08:00	0.0	0	0	0	0	1
10/10/2019 09:00	0.0	0	0	0	0	1
10/10/2019 10:00	0.0	0	0	0	0	1
10/10/2019 11:00	0.0	0	0	0	0	1
10/10/2019 12:00	0.0	0	0	0	0	1
10/10/2019 13:00	0.0	0	0	0	0	1
10/10/2019 14:00	0.0	0	0	0	0	1
10/10/2019 15:00	0.0	0	0	0	0	1
10/10/2019 16:00	0.0	0	0	0	0	1
10/10/2019 17:00	0.0	0	0	0	0	1
10/10/2019 18:00	0.0	0	0	0	0	1
10/10/2019 19:00	0.0	0	0	0	0	1
10/10/2019 20:00	0.0	0	0	0	0	1
10/10/2019 21:00	0.0	0	0	0	0	1
10/10/2019 22:00	0.0	0	0	0	0	1
10/10/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/11/2019 00:00	0.0	0	0	0	0	1
10/11/2019 01:00	0.0	0	0	0	0	1
10/11/2019 02:00	0.0	0	0	0	0	1
10/11/2019 03:00	0.0	0	0	0	0	1
10/11/2019 04:00	0.0	0	0	0	0	1
10/11/2019 05:00	0.0	0	0	0	0	1
10/11/2019 06:00	0.0	0	0	0	0	1
10/11/2019 07:00	0.0	0	0	0	0	1
10/11/2019 08:00	0.0	0	0	0	0	1
10/11/2019 09:00	0.0	0	0	0	0	1
10/11/2019 10:00	0.0	0	0	0	0	1
10/11/2019 11:00	0.0	0	0	0	0	1
10/11/2019 12:00	0.0	0	0	0	0	1
10/11/2019 13:00	0.0	0	0	0	0	1
10/11/2019 14:00	0.0	0	0	0	0	1
10/11/2019 15:00	0.0	0	0	0	0	1
10/11/2019 16:00	0.0	0	0	0	0	1
10/11/2019 17:00	0.0	0	0	0	0	1
10/11/2019 18:00	0.0	0	0	0	0	1
10/11/2019 19:00	0.0	0	0	0	0	1
10/11/2019 20:00	0.0	0	0	0	0	1
10/11/2019 21:00	0.0	0	0	0	0	1
10/11/2019 22:00	0.0	0	0	0	0	1
10/11/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/12/2019 00:00	0.0	0	0	0	0	1
10/12/2019 01:00	0.0	0	0	0	0	1
10/12/2019 02:00	0.0	0	0	0	0	1
10/12/2019 03:00	0.0	0	0	0	0	1
10/12/2019 04:00	0.0	0	0	0	0	1
10/12/2019 05:00	0.0	0	0	0	0	1
10/12/2019 06:00	0.0	0	0	0	0	1
10/12/2019 07:00	1.2	0	0	0	1	0
10/12/2019 08:00	0.0	0	0	0	0	0
10/12/2019 09:00	0.0	0	0	0	0	0
10/12/2019 10:00	0.0	0	0	0	0	0
10/12/2019 11:00	0.0	0	0	0	0	0
10/12/2019 12:00	0.0	0	0	0	0	0
10/12/2019 13:00	0.0	0	0	0	0	0
10/12/2019 14:00	11.6	0	0	1	0	0
10/12/2019 15:00	36.3	0	0	1	0	0
10/12/2019 16:00	0.0	0	0	0	0	1
10/12/2019 17:00	0.0	0	0	0	0	1
10/12/2019 18:00	0.0	0	0	0	0	1
10/12/2019 19:00	0.0	0	0	0	0	1
10/12/2019 20:00	0.0	0	0	0	0	1
10/12/2019 21:00	0.0	0	0	0	0	1
10/12/2019 22:00	0.0	0	0	0	0	1
10/12/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	49.1 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	36.3	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/13/2019 00:00	0.0	0	0	0	0	1
10/13/2019 01:00	0.0	0	0	0	0	1
10/13/2019 02:00	0.0	0	0	0	0	1
10/13/2019 03:00	0.0	0	0	0	0	1
10/13/2019 04:00	0.0	0	0	0	0	1
10/13/2019 05:00	0.0	0	0	0	0	1
10/13/2019 06:00	0.0	0	0	0	0	1
10/13/2019 07:00	0.0	0	0	0	0	1
10/13/2019 08:00	0.0	0	0	0	0	1
10/13/2019 09:00	0.0	0	0	0	0	1
10/13/2019 10:00	0.0	0	0	0	0	1
10/13/2019 11:00	0.0	0	0	0	0	1
10/13/2019 12:00	0.0	0	0	0	0	1
10/13/2019 13:00	0.0	0	0	0	0	1
10/13/2019 14:00	0.0	0	0	0	0	1
10/13/2019 15:00	0.0	0	0	0	0	1
10/13/2019 16:00	0.0	0	0	0	0	1
10/13/2019 17:00	0.0	0	0	0	0	1
10/13/2019 18:00	0.0	0	0	0	0	1
10/13/2019 19:00	0.0	0	0	0	0	1
10/13/2019 20:00	0.0	0	0	0	0	1
10/13/2019 21:00	0.0	0	0	0	0	1
10/13/2019 22:00	0.0	0	0	0	0	1
10/13/2019 23:00	0.9	0	0	0	1	0
Average/Sum#:	0.9 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/14/2019 00:00	0.0	0	0	0	0	0
10/14/2019 01:00	0.0	0	0	0	0	0
10/14/2019 02:00	0.0	0	0	0	0	0
10/14/2019 03:00	0.0	0	0	0	0	0
10/14/2019 04:00	0.0	0	0	0	0	0
10/14/2019 05:00	0.0	0	0	0	0	0
10/14/2019 06:00	1.1	0	0	1	0	0
10/14/2019 07:00	23.3	0	0	1	0	0
10/14/2019 08:00	0.0	0	0	0	0	1
10/14/2019 09:00	0.0	0	0	0	0	1
10/14/2019 10:00	0.0	0	0	0	0	1
10/14/2019 11:00	0.0	0	0	0	0	1
10/14/2019 12:00	0.0	0	0	0	0	1
10/14/2019 13:00	0.0	0	0	0	0	1
10/14/2019 14:00	0.0	0	0	0	0	1
10/14/2019 15:00	0.0	0	0	0	0	1
10/14/2019 16:00	0.0	0	0	0	0	1
10/14/2019 17:00	0.0	0	0	0	0	1
10/14/2019 18:00	0.0	0	0	0	0	1
10/14/2019 19:00	0.0	0	0	0	0	1
10/14/2019 20:00	0.0	0	0	0	0	1
10/14/2019 21:00	0.0	0	0	0	0	1
10/14/2019 22:00	0.0	0	0	0	0	1
10/14/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	24.4 #	0 #	0 #	2 #	0 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	23.3	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/15/2019 00:00	0.0	0	0	0	0	1
10/15/2019 01:00	0.0	0	0	0	0	1
10/15/2019 02:00	0.0	0	0	0	0	1
10/15/2019 03:00	0.0	0	0	0	0	1
10/15/2019 04:00	0.0	0	0	0	0	1
10/15/2019 05:00	0.9	0	0	0	1	0
10/15/2019 06:00	4.7	0	0	1	0	0
10/15/2019 07:00	8.2	0	0	1	0	0
10/15/2019 08:00	0.0	0	0	0	0	1
10/15/2019 09:00	0.0	0	0	0	0	1
10/15/2019 10:00	0.0	0	0	0	0	1
10/15/2019 11:00	0.0	0	0	0	0	1
10/15/2019 12:00	0.0	0	0	0	0	1
10/15/2019 13:00	0.0	0	0	0	0	1
10/15/2019 14:00	0.0	0	0	0	0	1
10/15/2019 15:00	0.0	0	0	0	0	0
10/15/2019 16:00	0.0	0	0	0	0	0
10/15/2019 17:00	0.0	0	0	0	0	0
10/15/2019 18:00	0.0	0	0	0	0	0
10/15/2019 19:00	0.0	0	0	0	0	0
10/15/2019 20:00	0.0	0	0	0	0	0
10/15/2019 21:00	0.0	0	0	0	0	0
10/15/2019 22:00	0.0	0	0	0	0	0
10/15/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	13.8 #	0 #	0 #	2 #	1 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	8.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/16/2019 00:00	0.0	0	0	0	0	0
10/16/2019 01:00	0.0	0	0	0	0	0
10/16/2019 02:00	0.0	0	0	0	0	0
10/16/2019 03:00	0.0	0	0	0	0	0
10/16/2019 04:00	0.0	0	0	0	0	0
10/16/2019 05:00	0.0	0	0	0	0	0
10/16/2019 06:00	0.0	0	0	0	0	0
10/16/2019 07:00	0.0	0	0	0	0	0
10/16/2019 08:00	0.0	0	0	0	0	0
10/16/2019 09:00	0.0	0	0	0	0	0
10/16/2019 10:00	0.0	0	0	0	0	0
10/16/2019 11:00	0.0	0	0	0	0	0
10/16/2019 12:00	0.0	0	0	0	0	0
10/16/2019 13:00	0.0	0	0	0	0	0
10/16/2019 14:00	0.0	0	0	0	0	0
10/16/2019 15:00	0.0	0	0	0	0	0
10/16/2019 16:00	0.0	0	0	0	0	0
10/16/2019 17:00	0.0	0	0	0	0	0
10/16/2019 18:00	0.0	0	0	0	0	0
10/16/2019 19:00	0.0	0	0	0	0	0
10/16/2019 20:00	21.2	0	1	0	0	0
10/16/2019 21:00	70.1	0	1	0	0	0
10/16/2019 22:00	0.0	0	0	0	0	1
10/16/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	91.3 #	0 #	2 #	0 #	0 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	70.1	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/17/2019 00:00	0.0	0	0	0	0	1
10/17/2019 01:00	0.0	0	0	0	0	1
10/17/2019 02:00	0.0	0	0	0	0	1
10/17/2019 03:00	0.0	0	0	0	0	1
10/17/2019 04:00	0.0	0	0	0	0	1
10/17/2019 05:00	0.0	0	0	0	0	1
10/17/2019 06:00	0.0	0	0	0	0	1
10/17/2019 07:00	0.0	0	0	0	0	1
10/17/2019 08:00	0.0	0	0	0	0	1
10/17/2019 09:00	0.0	0	0	0	0	1
10/17/2019 10:00	0.0	0	0	0	0	1
10/17/2019 11:00	0.0	0	0	0	0	1
10/17/2019 12:00	0.0	0	0	0	0	1
10/17/2019 13:00	0.0	0	0	0	0	1
10/17/2019 14:00	0.0	0	0	0	0	1
10/17/2019 15:00	0.0	0	0	0	0	1
10/17/2019 16:00	0.0	0	0	0	0	1
10/17/2019 17:00	0.0	0	0	0	0	1
10/17/2019 18:00	0.0	0	0	0	0	1
10/17/2019 19:00	0.0	0	0	0	0	1
10/17/2019 20:00	0.0	0	0	0	0	1
10/17/2019 21:00	0.0	0	0	0	0	1
10/17/2019 22:00	0.0	0	0	0	0	1
10/17/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/18/2019 00:00	0.0	0	0	0	0	1
10/18/2019 01:00	0.0	0	0	0	0	1
10/18/2019 02:00	0.0	0	0	0	0	1
10/18/2019 03:00	0.0	0	0	0	0	1
10/18/2019 04:00	0.0	0	0	0	0	1
10/18/2019 05:00	0.0	0	0	0	0	1
10/18/2019 06:00	0.0	0	0	0	0	1
10/18/2019 07:00	0.0	0	0	0	0	1
10/18/2019 08:00	0.0	0	0	0	0	1
10/18/2019 09:00	0.0	0	0	0	0	1
10/18/2019 10:00	0.0	0	0	0	0	1
10/18/2019 11:00	0.0	0	0	0	0	1
10/18/2019 12:00	0.0	0	0	0	0	1
10/18/2019 13:00	0.0	0	0	0	0	1
10/18/2019 14:00	0.0	0	0	0	0	1
10/18/2019 15:00	0.0	0	0	0	0	1
10/18/2019 16:00	0.0	0	0	0	0	1
10/18/2019 17:00	0.0	0	0	0	0	1
10/18/2019 18:00	0.0	0	0	0	0	1
10/18/2019 19:00	0.0	0	0	0	0	1
10/18/2019 20:00	0.0	0	0	0	0	1
10/18/2019 21:00	0.0	0	0	0	0	1
10/18/2019 22:00	0.0	0	0	0	0	1
10/18/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/19/2019 00:00	0.0	0	0	0	0	1
10/19/2019 01:00	0.0	0	0	0	0	1
10/19/2019 02:00	0.0	0	0	0	0	1
10/19/2019 03:00	0.0	0	0	0	0	1
10/19/2019 04:00	0.0	0	0	0	0	1
10/19/2019 05:00	0.0	0	0	0	0	1
10/19/2019 06:00	0.0	0	0	0	0	1
10/19/2019 07:00	0.8	0	0	0	1	0
10/19/2019 08:00	0.0	0	0	0	0	0
10/19/2019 09:00	0.0	0	0	0	0	0
10/19/2019 10:00	0.0	0	0	0	0	0
10/19/2019 11:00	0.0	0	0	0	0	0
10/19/2019 12:00	0.0	0	0	0	0	0
10/19/2019 13:00	0.0	0	0	0	0	0
10/19/2019 14:00	0.0	0	0	0	0	0
10/19/2019 15:00	0.0	0	0	0	0	0
10/19/2019 16:00	0.0	0	0	0	0	0
10/19/2019 17:00	0.0	0	0	0	0	0
10/19/2019 18:00	0.0	0	0	0	0	0
10/19/2019 19:00	0.0	0	0	0	0	0
10/19/2019 20:00	0.0	0	0	0	0	0
10/19/2019 21:00	0.0	0	0	0	0	0
10/19/2019 22:00	0.0	0	0	0	0	0
10/19/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/20/2019 00:00	0.0	0	0	0	0	0
10/20/2019 01:00	0.0	0	0	0	0	0
10/20/2019 02:00	0.0	0	0	0	0	0
10/20/2019 03:00	0.0	0	0	0	0	0
10/20/2019 04:00	0.0	0	0	0	0	0
10/20/2019 05:00	0.0	0	0	0	0	0
10/20/2019 06:00	0.0	0	0	0	0	0
10/20/2019 07:00	0.0	0	0	0	0	0
10/20/2019 08:00	0.0	0	0	0	0	0
10/20/2019 09:00	0.0	0	0	0	0	0
10/20/2019 10:00	0.0	0	0	0	0	0
10/20/2019 11:00	0.0	0	0	0	0	0
10/20/2019 12:00	0.0	0	0	0	0	0
10/20/2019 13:00	0.0	0	0	0	0	0
10/20/2019 14:00	77.7	0	1	0	0	0
10/20/2019 15:00	36.4	0	1	0	0	0
10/20/2019 16:00	0.0	0	0	0	0	1
10/20/2019 17:00	0.0	0	0	0	0	1
10/20/2019 18:00	0.0	0	0	0	0	1
10/20/2019 19:00	0.0	0	0	0	0	1
10/20/2019 20:00	0.0	0	0	0	0	1
10/20/2019 21:00	0.0	0	0	0	0	1
10/20/2019 22:00	0.0	0	0	0	0	1
10/20/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	114.1 #	0 #	2 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	77.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/21/2019 00:00	0.0	0	0	0	0	1
10/21/2019 01:00	0.0	0	0	0	0	1
10/21/2019 02:00	0.0	0	0	0	0	1
10/21/2019 03:00	0.0	0	0	0	0	1
10/21/2019 04:00	0.0	0	0	0	0	1
10/21/2019 05:00	0.0	0	0	0	0	1
10/21/2019 06:00	0.0	0	0	0	0	1
10/21/2019 07:00	0.0	0	0	0	0	1
10/21/2019 08:00	0.0	0	0	0	0	1
10/21/2019 09:00	0.0	0	0	0	0	1
10/21/2019 10:00	0.0	0	0	0	0	1
10/21/2019 11:00	0.0	0	0	0	0	1
10/21/2019 12:00	0.0	0	0	0	0	1
10/21/2019 13:00	0.0	0	0	0	0	1
10/21/2019 14:00	0.0	0	0	0	0	1
10/21/2019 15:00	0.0	0	0	0	0	1
10/21/2019 16:00	0.0	0	0	0	0	1
10/21/2019 17:00	0.0	0	0	0	0	1
10/21/2019 18:00	0.0	0	0	0	0	1
10/21/2019 19:00	0.0	0	0	0	0	1
10/21/2019 20:00	0.0	0	0	0	0	1
10/21/2019 21:00	0.0	0	0	0	0	1
10/21/2019 22:00	0.0	0	0	0	0	1
10/21/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/22/2019 00:00	0.0	0	0	0	0	1
10/22/2019 01:00	0.0	0	0	0	0	1
10/22/2019 02:00	0.0	0	0	0	0	1
10/22/2019 03:00	0.0	0	0	0	0	1
10/22/2019 04:00	0.0	0	0	0	0	1
10/22/2019 05:00	0.0	0	0	0	0	1
10/22/2019 06:00	0.0	0	0	0	0	1
10/22/2019 07:00	0.0	0	0	0	0	1
10/22/2019 08:00	0.0	0	0	0	0	1
10/22/2019 09:00	0.0	0	0	0	0	1
10/22/2019 10:00	0.0	0	0	0	0	1
10/22/2019 11:00	0.0	0	0	0	0	1
10/22/2019 12:00	0.0	0	0	0	0	1
10/22/2019 13:00	0.0	0	0	0	0	1
10/22/2019 14:00	0.0	0	0	0	0	1
10/22/2019 15:00	0.0	0	0	0	0	1
10/22/2019 16:00	0.0	0	0	0	0	1
10/22/2019 17:00	0.0	0	0	0	0	1
10/22/2019 18:00	0.0	0	0	0	0	1
10/22/2019 19:00	0.0	0	0	0	0	1
10/22/2019 20:00	0.0	0	0	0	0	1
10/22/2019 21:00	0.0	0	0	0	0	1
10/22/2019 22:00	0.0	0	0	0	0	1
10/22/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/23/2019 00:00	0.0	0	0	0	0	1
10/23/2019 01:00	0.0	0	0	0	0	1
10/23/2019 02:00	0.0	0	0	0	0	1
10/23/2019 03:00	0.0	0	0	0	0	1
10/23/2019 04:00	0.0	0	0	0	0	1
10/23/2019 05:00	0.0	0	0	0	0	1
10/23/2019 06:00	0.0	0	0	0	0	1
10/23/2019 07:00	0.0	0	0	0	0	1
10/23/2019 08:00	0.0	0	0	0	0	1
10/23/2019 09:00	0.0	0	0	0	0	1
10/23/2019 10:00	0.0	0	0	0	0	1
10/23/2019 11:00	0.0	0	0	0	0	1
10/23/2019 12:00	0.0	0	0	0	0	1
10/23/2019 13:00	0.0	0	0	0	0	1
10/23/2019 14:00	0.0	0	0	0	0	1
10/23/2019 15:00	0.0	0	0	0	0	1
10/23/2019 16:00	0.0	0	0	0	0	1
10/23/2019 17:00	0.0	0	0	0	0	1
10/23/2019 18:00	0.0	0	0	0	0	1
10/23/2019 19:00	0.0	0	0	0	0	1
10/23/2019 20:00	0.0	0	0	0	0	1
10/23/2019 21:00	0.0	0	0	0	0	1
10/23/2019 22:00	0.0	0	0	0	0	1
10/23/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/24/2019 00:00	0.0	0	0	0	0	1
10/24/2019 01:00	0.0	0	0	0	0	1
10/24/2019 02:00	0.0	0	0	0	0	1
10/24/2019 03:00	0.0	0	0	0	0	1
10/24/2019 04:00	0.0	0	0	0	0	1
10/24/2019 05:00	0.0	0	0	0	0	1
10/24/2019 06:00	0.0	0	0	0	0	1
10/24/2019 07:00	0.0	0	0	0	0	1
10/24/2019 08:00	0.0	0	0	0	0	1
10/24/2019 09:00	0.0	0	0	0	0	1
10/24/2019 10:00	0.0	0	0	0	0	1
10/24/2019 11:00	0.0	0	0	0	0	1
10/24/2019 12:00	0.0	0	0	0	0	1
10/24/2019 13:00	0.0	0	0	0	0	1
10/24/2019 14:00	0.0	0	0	0	0	1
10/24/2019 15:00	0.0	0	0	0	0	1
10/24/2019 16:00	0.0	0	0	0	0	1
10/24/2019 17:00	0.0	0	0	0	0	1
10/24/2019 18:00	0.0	0	0	0	0	1
10/24/2019 19:00	0.0	0	0	0	0	1
10/24/2019 20:00	0.0	0	0	0	0	1
10/24/2019 21:00	0.0	0	0	0	0	1
10/24/2019 22:00	0.0	0	0	0	0	1
10/24/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/25/2019 00:00	0.0	0	0	0	0	1
10/25/2019 01:00	0.0	0	0	0	0	1
10/25/2019 02:00	0.0	0	0	0	0	1
10/25/2019 03:00	0.0	0	0	0	0	1
10/25/2019 04:00	0.0	0	0	0	0	1
10/25/2019 05:00	0.0	0	0	0	0	1
10/25/2019 06:00	0.0	0	0	0	0	1
10/25/2019 07:00	0.0	0	0	0	0	1
10/25/2019 08:00	0.0	0	0	0	0	1
10/25/2019 09:00	0.0	0	0	0	0	1
10/25/2019 10:00	0.0	0	0	0	0	1
10/25/2019 11:00	0.0	0	0	0	0	1
10/25/2019 12:00	0.0	0	0	0	0	1
10/25/2019 13:00	0.0	0	0	0	0	1
10/25/2019 14:00	0.0	0	0	0	0	1
10/25/2019 15:00	0.0	0	0	0	0	1
10/25/2019 16:00	0.0	0	0	0	0	1
10/25/2019 17:00	0.0	0	0	0	0	1
10/25/2019 18:00	0.0	0	0	0	0	1
10/25/2019 19:00	0.0	0	0	0	0	1
10/25/2019 20:00	0.0	0	0	0	0	1
10/25/2019 21:00	0.0	0	0	0	0	1
10/25/2019 22:00	0.0	0	0	0	0	1
10/25/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/26/2019 00:00	0.0	0	0	0	0	1
10/26/2019 01:00	0.0	0	0	0	0	1
10/26/2019 02:00	0.0	0	0	0	0	1
10/26/2019 03:00	0.0	0	0	0	0	1
10/26/2019 04:00	0.0	0	0	0	0	1
10/26/2019 05:00	0.0	0	0	0	0	1
10/26/2019 06:00	0.0	0	0	0	0	1
10/26/2019 07:00	0.0	0	0	0	0	1
10/26/2019 08:00	0.0	0	0	0	0	1
10/26/2019 09:00	0.0	0	0	0	0	1
10/26/2019 10:00	0.0	0	0	0	0	1
10/26/2019 11:00	0.0	0	0	0	0	1
10/26/2019 12:00	0.0	0	0	0	0	1
10/26/2019 13:00	0.0	0	0	0	0	1
10/26/2019 14:00	0.0	0	0	0	0	1
10/26/2019 15:00	0.0	0	0	0	0	1
10/26/2019 16:00	0.0	0	0	0	0	1
10/26/2019 17:00	0.0	0	0	0	0	1
10/26/2019 18:00	0.0	0	0	0	0	1
10/26/2019 19:00	0.0	0	0	0	0	1
10/26/2019 20:00	0.0	0	0	0	0	1
10/26/2019 21:00	0.0	0	0	0	0	1
10/26/2019 22:00	1.1	0	0	0	1	0
10/26/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.1 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/27/2019 00:00	0.0	0	0	0	0	0
10/27/2019 01:00	0.0	0	0	0	0	0
10/27/2019 02:00	0.0	0	0	0	0	0
10/27/2019 03:00	0.0	0	0	0	0	0
10/27/2019 04:00	0.0	0	0	0	0	0
10/27/2019 05:00	0.0	0	0	0	0	0
10/27/2019 06:00	0.0	0	0	0	0	0
10/27/2019 07:00	0.0	0	0	0	0	0
10/27/2019 08:00	0.0	0	0	0	0	0
10/27/2019 09:00	0.0	0	0	0	0	0
10/27/2019 10:00	0.0	0	0	0	0	0
10/27/2019 11:00	0.0	0	0	0	0	0
10/27/2019 12:00	0.0	0	0	0	0	0
10/27/2019 13:00	0.0	0	0	0	0	0
10/27/2019 14:00	0.0	0	0	0	0	0
10/27/2019 15:00	0.0	0	0	0	0	0
10/27/2019 16:00	0.0	0	0	0	0	0
10/27/2019 17:00	0.0	0	0	0	0	0
10/27/2019 18:00	0.0	0	0	0	0	0
10/27/2019 19:00	0.0	0	0	0	0	0
10/27/2019 20:00	0.0	0	0	0	0	0
10/27/2019 21:00	0.0	0	0	0	0	0
10/27/2019 22:00	0.0	0	0	0	0	0
10/27/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/28/2019 00:00	16.2	0	1	0	0	0
10/28/2019 01:00	110.9	0	1	0	0	0
10/28/2019 02:00	0.0	0	0	0	0	1
10/28/2019 03:00	0.0	0	0	0	0	1
10/28/2019 04:00	0.0	0	0	0	0	1
10/28/2019 05:00	0.0	0	0	0	0	1
10/28/2019 06:00	0.0	0	0	0	0	1
10/28/2019 07:00	0.0	0	0	0	0	1
10/28/2019 08:00	0.0	0	0	0	0	1
10/28/2019 09:00	0.0	0	0	0	0	1
10/28/2019 10:00	0.0	0	0	0	0	1
10/28/2019 11:00	0.0	0	0	0	0	1
10/28/2019 12:00	0.0	0	0	0	0	1
10/28/2019 13:00	0.0	0	0	0	0	1
10/28/2019 14:00	0.0	0	0	0	0	1
10/28/2019 15:00	0.0	0	0	0	0	1
10/28/2019 16:00	0.0	0	0	0	0	1
10/28/2019 17:00	0.0	0	0	0	0	1
10/28/2019 18:00	0.0	0	0	0	0	1
10/28/2019 19:00	0.0	0	0	0	0	1
10/28/2019 20:00	0.0	0	0	0	0	1
10/28/2019 21:00	0.0	0	0	0	0	1
10/28/2019 22:00	0.0	0	0	0	0	1
10/28/2019 23:00	1.2	0	0	0	1	0
Average/Sum#:	128.3 #	0 #	2 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	110.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/29/2019 00:00	0.0	0	0	0	0	0
10/29/2019 01:00	0.0	0	0	0	0	0
10/29/2019 02:00	0.0	0	0	0	0	0
10/29/2019 03:00	0.0	0	0	0	0	0
10/29/2019 04:00	0.0	0	0	0	0	0
10/29/2019 05:00	0.0	0	0	0	0	0
10/29/2019 06:00	0.0	0	0	0	0	0
10/29/2019 07:00	0.0	0	0	0	0	0
10/29/2019 08:00	0.0	0	0	0	0	0
10/29/2019 09:00	0.0	0	0	0	0	0
10/29/2019 10:00	0.0	0	0	0	0	0
10/29/2019 11:00	0.0	0	0	0	0	0
10/29/2019 12:00	0.0	0	0	0	0	0
10/29/2019 13:00	0.0	0	0	0	0	0
10/29/2019 14:00	0.0	0	0	0	0	0
10/29/2019 15:00	0.0	0	0	0	0	0
10/29/2019 16:00	0.0	0	0	0	0	0
10/29/2019 17:00	0.0	0	0	0	0	0
10/29/2019 18:00	0.0	0	0	0	0	0
10/29/2019 19:00	0.0	0	0	0	0	0
10/29/2019 20:00	0.0	0	0	0	0	0
10/29/2019 21:00	0.0	0	0	0	0	0
10/29/2019 22:00	0.0	0	0	0	0	0
10/29/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/30/2019 00:00	0.0	0	0	0	0	0
10/30/2019 01:00	0.0	0	0	0	0	0
10/30/2019 02:00	0.0	0	0	0	0	0
10/30/2019 03:00	0.0	0	0	0	0	0
10/30/2019 04:00	0.2	0	1	0	0	0
10/30/2019 05:00	93.5	0	1	0	0	0
10/30/2019 06:00	64.3	0	1	0	0	0
10/30/2019 07:00	0.0	0	0	0	0	1
10/30/2019 08:00	0.0	0	0	0	0	1
10/30/2019 09:00	0.0	0	0	0	0	1
10/30/2019 10:00	0.0	0	0	0	0	1
10/30/2019 11:00	0.0	0	0	0	0	1
10/30/2019 12:00	0.0	0	0	0	0	1
10/30/2019 13:00	0.0	0	0	0	0	1
10/30/2019 14:00	0.0	0	0	0	0	1
10/30/2019 15:00	0.0	0	0	0	0	1
10/30/2019 16:00	0.0	0	0	0	0	1
10/30/2019 17:00	0.0	0	0	0	0	1
10/30/2019 18:00	0.0	0	0	0	0	1
10/30/2019 19:00	0.0	0	0	0	0	1
10/30/2019 20:00	0.0	0	0	0	0	1
10/30/2019 21:00	0.0	0	0	0	0	1
10/30/2019 22:00	0.0	0	0	0	0	1
10/30/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	158.0 #	0 #	3 #	0 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	93.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/31/2019 00:00	0.0	0	0	0	0	1
10/31/2019 01:00	0.0	0	0	0	0	1
10/31/2019 02:00	0.0	0	0	0	0	1
10/31/2019 03:00	0.0	0	0	0	0	1
10/31/2019 04:00	0.0	0	0	0	0	1
10/31/2019 05:00	0.0	0	0	0	0	1
10/31/2019 06:00	0.0	0	0	0	0	1
10/31/2019 07:00	0.0	0	0	0	0	1
10/31/2019 08:00	0.0	0	0	0	0	1
10/31/2019 09:00	0.0	0	0	0	0	1
10/31/2019 10:00	0.0	0	0	0	0	1
10/31/2019 11:00	0.0	0	0	0	0	1
10/31/2019 12:00	0.0	0	0	0	0	1
10/31/2019 13:00	0.0	0	0	0	0	1
10/31/2019 14:00	0.0	0	0	0	0	1
10/31/2019 15:00	0.0	0	0	0	0	1
10/31/2019 16:00	0.0	0	0	0	0	1
10/31/2019 17:00	0.0	0	0	0	0	1
10/31/2019 18:00	0.0	0	0	0	0	1
10/31/2019 19:00	0.0	0	0	0	0	1
10/31/2019 20:00	0.0	0	0	0	0	1
10/31/2019 21:00	0.0	0	0	0	0	1
10/31/2019 22:00	0.0	0	0	0	0	1
10/31/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/01/2019 00:00	0.0	0	0	0	0	1
11/01/2019 01:00	0.0	0	0	0	0	1
11/01/2019 02:00	0.0	0	0	0	0	1
11/01/2019 03:00	0.0	0	0	0	0	1
11/01/2019 04:00	0.0	0	0	0	0	1
11/01/2019 05:00	0.0	0	0	0	0	1
11/01/2019 06:00	0.0	0	0	0	0	1
11/01/2019 07:00	0.0	0	0	0	0	1
11/01/2019 08:00	0.0	0	0	0	0	1
11/01/2019 09:00	0.0	0	0	0	0	1
11/01/2019 10:00	0.0	0	0	0	0	1
11/01/2019 11:00	0.0	0	0	0	0	1
11/01/2019 12:00	0.0	0	0	0	0	1
11/01/2019 13:00	0.0	0	0	0	0	1
11/01/2019 14:00	0.0	0	0	0	0	1
11/01/2019 15:00	0.0	0	0	0	0	1
11/01/2019 16:00	0.0	0	0	0	0	1
11/01/2019 17:00	0.0	0	0	0	0	1
11/01/2019 18:00	0.0	0	0	0	0	1
11/01/2019 19:00	0.0	0	0	0	0	1
11/01/2019 20:00	0.0	0	0	0	0	1
11/01/2019 21:00	0.0	0	0	0	0	1
11/01/2019 22:00	0.0	0	0	0	0	1
11/01/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/02/2019 00:00	0.0	0	0	0	0	1
11/02/2019 01:00	0.0	0	0	0	0	1
11/02/2019 02:00	0.0	0	0	0	0	1
11/02/2019 03:00	0.0	0	0	0	0	1
11/02/2019 04:00	0.0	0	0	0	0	1
11/02/2019 05:00	0.0	0	0	0	0	1
11/02/2019 06:00	0.0	0	0	0	0	1
11/02/2019 07:00	0.0	0	0	0	0	1
11/02/2019 08:00	0.0	0	0	0	0	1
11/02/2019 09:00	0.0	0	0	0	0	1
11/02/2019 10:00	0.0	0	0	0	0	1
11/02/2019 11:00	0.0	0	0	0	0	1
11/02/2019 12:00	0.0	0	0	0	0	1
11/02/2019 13:00	1.2	0	0	0	1	0
11/02/2019 14:00	0.0	0	0	0	0	0
11/02/2019 15:00	2.4	0	0	1	0	0
11/02/2019 16:00	12.6	0	0	1	0	0
11/02/2019 17:00	0.0	0	0	0	0	1
11/02/2019 18:00	0.0	0	0	0	0	1
11/02/2019 19:00	0.0	0	0	0	0	1
11/02/2019 20:00	0.0	0	0	0	0	1
11/02/2019 21:00	0.0	0	0	0	0	1
11/02/2019 22:00	0.0	0	0	0	0	1
11/02/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	16.2 #	0 #	0 #	2 #	1 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	12.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/03/2019 00:00	0.0	0	0	0	0	1
11/03/2019 01:00	0.0	0	0	0	0	1
11/03/2019 02:00	0.0	0	0	0	0	1
11/03/2019 03:00	0.0	0	0	0	0	1
11/03/2019 04:00	0.0	0	0	0	0	1
11/03/2019 05:00	0.0	0	0	0	0	1
11/03/2019 06:00	0.0	0	0	0	0	1
11/03/2019 07:00	0.0	0	0	0	0	1
11/03/2019 08:00	0.0	0	0	0	0	1
11/03/2019 09:00	0.0	0	0	0	0	1
11/03/2019 10:00	0.0	0	0	0	0	1
11/03/2019 11:00	0.0	0	0	0	0	1
11/03/2019 12:00	0.0	0	0	0	0	1
11/03/2019 13:00	0.0	0	0	0	0	1
11/03/2019 14:00	0.0	0	0	0	0	1
11/03/2019 15:00	0.0	0	0	0	0	1
11/03/2019 16:00	0.0	0	0	0	0	1
11/03/2019 17:00	0.0	0	0	0	0	1
11/03/2019 18:00	0.0	0	0	0	0	1
11/03/2019 19:00	0.0	0	0	0	0	1
11/03/2019 20:00	0.0	0	0	0	0	1
11/03/2019 21:00	0.0	0	0	0	0	1
11/03/2019 22:00	0.0	0	0	0	0	1
11/03/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/04/2019 00:00	0.0	0	0	0	0	1
11/04/2019 01:00	0.0	0	0	0	0	1
11/04/2019 02:00	0.0	0	0	0	0	1
11/04/2019 03:00	0.0	0	0	0	0	1
11/04/2019 04:00	0.0	0	0	0	0	1
11/04/2019 05:00	0.0	0	0	0	0	1
11/04/2019 06:00	0.0	0	0	0	0	1
11/04/2019 07:00	0.0	0	0	0	0	1
11/04/2019 08:00	0.0	0	0	0	0	1
11/04/2019 09:00	0.0	0	0	0	0	1
11/04/2019 10:00	0.0	0	0	0	0	1
11/04/2019 11:00	0.0	0	0	0	0	1
11/04/2019 12:00	0.0	0	0	0	0	1
11/04/2019 13:00	0.0	0	0	0	0	1
11/04/2019 14:00	0.0	0	0	0	0	1
11/04/2019 15:00	0.0	0	0	0	0	1
11/04/2019 16:00	0.0	0	0	0	0	1
11/04/2019 17:00	0.0	0	0	0	0	1
11/04/2019 18:00	0.0	0	0	0	0	1
11/04/2019 19:00	0.0	0	0	0	0	1
11/04/2019 20:00	0.0	0	0	0	0	1
11/04/2019 21:00	0.0	0	0	0	0	1
11/04/2019 22:00	0.0	0	0	0	0	1
11/04/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/05/2019 00:00	0.0	0	0	0	0	1
11/05/2019 01:00	0.0	0	0	0	0	1
11/05/2019 02:00	0.0	0	0	0	0	1
11/05/2019 03:00	0.0	0	0	0	0	1
11/05/2019 04:00	0.0	0	0	0	0	1
11/05/2019 05:00	0.0	0	0	0	0	1
11/05/2019 06:00	0.0	0	0	0	0	1
11/05/2019 07:00	0.0	0	0	0	0	1
11/05/2019 08:00	0.0	0	0	0	0	1
11/05/2019 09:00	0.0	0	0	0	0	1
11/05/2019 10:00	0.0	0	0	0	0	1
11/05/2019 11:00	0.0	0	0	0	0	1
11/05/2019 12:00	0.0	0	0	0	0	1
11/05/2019 13:00	0.0	0	0	0	0	1
11/05/2019 14:00	0.0	0	0	0	0	1
11/05/2019 15:00	0.0	0	0	0	0	1
11/05/2019 16:00	0.0	0	0	0	0	1
11/05/2019 17:00	0.0	0	0	0	0	1
11/05/2019 18:00	0.0	0	0	0	0	1
11/05/2019 19:00	0.0	0	0	0	0	1
11/05/2019 20:00	0.0	0	0	0	0	1
11/05/2019 21:00	0.0	0	0	0	0	1
11/05/2019 22:00	0.0	0	0	0	0	1
11/05/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/06/2019 00:00	0.0	0	0	0	0	1
11/06/2019 01:00	0.0	0	0	0	0	1
11/06/2019 02:00	0.0	0	0	0	0	1
11/06/2019 03:00	0.0	0	0	0	0	1
11/06/2019 04:00	0.0	0	0	0	0	1
11/06/2019 05:00	0.0	0	0	0	0	1
11/06/2019 06:00	0.0	0	0	0	0	1
11/06/2019 07:00	0.0	0	0	0	0	1
11/06/2019 08:00	0.0	0	0	0	0	1
11/06/2019 09:00	0.0	0	0	0	0	1
11/06/2019 10:00	0.0	0	0	0	0	1
11/06/2019 11:00	0.0	0	0	0	0	1
11/06/2019 12:00	0.0	0	0	0	0	1
11/06/2019 13:00	0.0	0	0	0	0	1
11/06/2019 14:00	0.0	0	0	0	0	1
11/06/2019 15:00	0.0	0	0	0	0	1
11/06/2019 16:00	0.0	0	0	0	0	1
11/06/2019 17:00	0.0	0	0	0	0	1
11/06/2019 18:00	0.0	0	0	0	0	1
11/06/2019 19:00	0.0	0	0	0	0	1
11/06/2019 20:00	0.0	0	0	0	0	1
11/06/2019 21:00	0.0	0	0	0	0	1
11/06/2019 22:00	0.0	0	0	0	0	1
11/06/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/07/2019 00:00	0.0	0	0	0	0	1
11/07/2019 01:00	0.0	0	0	0	0	1
11/07/2019 02:00	0.0	0	0	0	0	1
11/07/2019 03:00	0.0	0	0	0	0	1
11/07/2019 04:00	0.0	0	0	0	0	1
11/07/2019 05:00	0.0	0	0	0	0	1
11/07/2019 06:00	0.0	0	0	0	0	1
11/07/2019 07:00	0.0	0	0	0	0	1
11/07/2019 08:00	0.0	0	0	0	0	1
11/07/2019 09:00	0.0	0	0	0	0	1
11/07/2019 10:00	0.0	0	0	0	0	1
11/07/2019 11:00	0.0	0	0	0	0	1
11/07/2019 12:00	0.0	0	0	0	0	1
11/07/2019 13:00	0.0	0	0	0	0	1
11/07/2019 14:00	0.0	0	0	0	0	1
11/07/2019 15:00	0.0	0	0	0	0	1
11/07/2019 16:00	0.0	0	0	0	0	1
11/07/2019 17:00	0.0	0	0	0	0	1
11/07/2019 18:00	0.0	0	0	0	0	1
11/07/2019 19:00	0.0	0	0	0	0	1
11/07/2019 20:00	0.0	0	0	0	0	1
11/07/2019 21:00	0.0	0	0	0	0	1
11/07/2019 22:00	0.0	0	0	0	0	1
11/07/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/08/2019 00:00	0.0	0	0	0	0	1
11/08/2019 01:00	0.0	0	0	0	0	1
11/08/2019 02:00	0.0	0	0	0	0	1
11/08/2019 03:00	0.0	0	0	0	0	1
11/08/2019 04:00	0.0	0	0	0	0	1
11/08/2019 05:00	0.0	0	0	0	0	1
11/08/2019 06:00	0.0	0	0	0	0	1
11/08/2019 07:00	0.0	0	0	0	0	1
11/08/2019 08:00	0.0	0	0	0	0	1
11/08/2019 09:00	0.0	0	0	0	0	1
11/08/2019 10:00	0.0	0	0	0	0	1
11/08/2019 11:00	0.0	0	0	0	0	1
11/08/2019 12:00	0.0	0	0	0	0	1
11/08/2019 13:00	0.0	0	0	0	0	1
11/08/2019 14:00	0.0	0	0	0	0	1
11/08/2019 15:00	0.0	0	0	0	0	1
11/08/2019 16:00	0.0	0	0	0	0	1
11/08/2019 17:00	0.0	0	0	0	0	1
11/08/2019 18:00	0.0	0	0	0	0	1
11/08/2019 19:00	0.0	0	0	0	0	1
11/08/2019 20:00	0.0	0	0	0	0	1
11/08/2019 21:00	0.0	0	0	0	0	1
11/08/2019 22:00	0.0	0	0	0	0	1
11/08/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/09/2019 00:00	0.0	0	0	0	0	1
11/09/2019 01:00	0.0	0	0	0	0	1
11/09/2019 02:00	0.0	0	0	0	0	1
11/09/2019 03:00	0.0	0	0	0	0	1
11/09/2019 04:00	0.0	0	0	0	0	1
11/09/2019 05:00	0.0	0	0	0	0	1
11/09/2019 06:00	0.0	0	0	0	0	1
11/09/2019 07:00	0.0	0	0	0	0	1
11/09/2019 08:00	0.0	0	0	0	0	1
11/09/2019 09:00	0.0	0	0	0	0	1
11/09/2019 10:00	0.0	0	0	0	0	1
11/09/2019 11:00	0.0	0	0	0	0	1
11/09/2019 12:00	0.0	0	0	0	0	1
11/09/2019 13:00	0.0	0	0	0	0	1
11/09/2019 14:00	0.0	0	0	0	0	1
11/09/2019 15:00	0.0	0	0	0	0	1
11/09/2019 16:00	0.0	0	0	0	0	1
11/09/2019 17:00	0.0	0	0	0	0	1
11/09/2019 18:00	0.0	0	0	0	0	1
11/09/2019 19:00	0.0	0	0	0	0	1
11/09/2019 20:00	0.0	0	0	0	0	1
11/09/2019 21:00	0.0	0	0	0	0	1
11/09/2019 22:00	0.0	0	0	0	0	1
11/09/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/10/2019 00:00	0.0	0	0	0	0	1
11/10/2019 01:00	0.0	0	0	0	0	1
11/10/2019 02:00	0.0	0	0	0	0	1
11/10/2019 03:00	0.0	0	0	0	0	1
11/10/2019 04:00	0.0	0	0	0	0	1
11/10/2019 05:00	0.0	0	0	0	0	1
11/10/2019 06:00	0.0	0	0	0	0	1
11/10/2019 07:00	0.0	0	0	0	0	1
11/10/2019 08:00	0.0	0	0	0	0	1
11/10/2019 09:00	0.0	0	0	0	0	1
11/10/2019 10:00	0.0	0	0	0	0	1
11/10/2019 11:00	0.0	0	0	0	0	1
11/10/2019 12:00	0.0	0	0	0	0	1
11/10/2019 13:00	0.0	0	0	0	0	1
11/10/2019 14:00	0.0	0	0	0	0	1
11/10/2019 15:00	0.0	0	0	0	0	1
11/10/2019 16:00	0.0	0	0	0	0	1
11/10/2019 17:00	0.0	0	0	0	0	1
11/10/2019 18:00	0.0	0	0	0	0	1
11/10/2019 19:00	0.0	0	0	0	0	1
11/10/2019 20:00	0.0	0	0	0	0	1
11/10/2019 21:00	0.0	0	0	0	0	1
11/10/2019 22:00	0.0	0	0	0	0	1
11/10/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/11/2019 00:00	0.0	0	0	0	0	1
11/11/2019 01:00	0.0	0	0	0	0	1
11/11/2019 02:00	0.0	0	0	0	0	1
11/11/2019 03:00	0.0	0	0	0	0	1
11/11/2019 04:00	0.0	0	0	0	0	1
11/11/2019 05:00	0.0	0	0	0	0	1
11/11/2019 06:00	0.0	0	0	0	0	1
11/11/2019 07:00	0.0	0	0	0	0	1
11/11/2019 08:00	0.0	0	0	0	0	1
11/11/2019 09:00	0.0	0	0	0	0	1
11/11/2019 10:00	0.0	0	0	0	0	1
11/11/2019 11:00	0.0	0	0	0	0	1
11/11/2019 12:00	0.0	0	0	0	0	1
11/11/2019 13:00	0.0	0	0	0	0	1
11/11/2019 14:00	0.0	0	0	0	0	1
11/11/2019 15:00	0.0	0	0	0	0	1
11/11/2019 16:00	0.0	0	0	0	0	1
11/11/2019 17:00	0.0	0	0	0	0	1
11/11/2019 18:00	0.0	0	0	0	0	1
11/11/2019 19:00	0.0	0	0	0	0	1
11/11/2019 20:00	0.0	0	0	0	0	1
11/11/2019 21:00	0.0	0	0	0	0	1
11/11/2019 22:00	0.0	0	0	0	0	1
11/11/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/12/2019 00:00	0.0	0	0	0	0	1
11/12/2019 01:00	0.0	0	0	0	0	1
11/12/2019 02:00	0.0	0	0	0	0	1
11/12/2019 03:00	0.0	0	0	0	0	1
11/12/2019 04:00	0.0	0	0	0	0	1
11/12/2019 05:00	0.0	0	0	0	0	1
11/12/2019 06:00	0.0	0	0	0	0	1
11/12/2019 07:00	0.0	0	0	0	0	1
11/12/2019 08:00	0.0	0	0	0	0	1
11/12/2019 09:00	0.0	0	0	0	0	1
11/12/2019 10:00	0.0	0	0	0	0	1
11/12/2019 11:00	0.0	0	0	0	0	1
11/12/2019 12:00	0.0	0	0	0	0	1
11/12/2019 13:00	0.0	0	0	0	0	1
11/12/2019 14:00	0.0	0	0	0	0	1
11/12/2019 15:00	0.0	0	0	0	0	1
11/12/2019 16:00	0.0	0	0	0	0	1
11/12/2019 17:00	0.0	0	0	0	0	1
11/12/2019 18:00	0.0	0	0	0	0	1
11/12/2019 19:00	0.0	0	0	0	0	1
11/12/2019 20:00	0.0	0	0	0	0	1
11/12/2019 21:00	0.0	0	0	0	0	1
11/12/2019 22:00	0.0	0	0	0	0	1
11/12/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/13/2019 00:00	0.0	0	0	0	0	1
11/13/2019 01:00	0.0	0	0	0	0	1
11/13/2019 02:00	0.0	0	0	0	0	1
11/13/2019 03:00	0.0	0	0	0	0	1
11/13/2019 04:00	0.0	0	0	0	0	1
11/13/2019 05:00	0.0	0	0	0	0	1
11/13/2019 06:00	0.0	0	0	0	0	1
11/13/2019 07:00	0.0	0	0	0	0	1
11/13/2019 08:00	0.0	0	0	0	0	1
11/13/2019 09:00	0.0	0	0	0	0	1
11/13/2019 10:00	0.0	0	0	0	0	1
11/13/2019 11:00	0.0	0	0	0	0	1
11/13/2019 12:00	0.0	0	0	0	0	1
11/13/2019 13:00	0.0	0	0	0	0	1
11/13/2019 14:00	0.0	0	0	0	0	1
11/13/2019 15:00	0.0	0	0	0	0	1
11/13/2019 16:00	0.0	0	0	0	0	1
11/13/2019 17:00	0.0	0	0	0	0	1
11/13/2019 18:00	0.0	0	0	0	0	1
11/13/2019 19:00	0.0	0	0	0	0	1
11/13/2019 20:00	0.0	0	0	0	0	1
11/13/2019 21:00	0.0	0	0	0	0	1
11/13/2019 22:00	0.0	0	0	0	0	1
11/13/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/14/2019 00:00	0.0	0	0	0	0	1
11/14/2019 01:00	0.0	0	0	0	0	1
11/14/2019 02:00	0.0	0	0	0	0	1
11/14/2019 03:00	0.0	0	0	0	0	1
11/14/2019 04:00	0.0	0	0	0	0	1
11/14/2019 05:00	0.0	0	0	0	0	1
11/14/2019 06:00	0.0	0	0	0	0	1
11/14/2019 07:00	0.0	0	0	0	0	1
11/14/2019 08:00	0.0	0	0	0	0	1
11/14/2019 09:00	0.0	0	0	0	0	1
11/14/2019 10:00	0.0	0	0	0	0	1
11/14/2019 11:00	0.0	0	0	0	0	1
11/14/2019 12:00	0.0	0	0	0	0	1
11/14/2019 13:00	0.0	0	0	0	0	1
11/14/2019 14:00	0.0	0	0	0	0	1
11/14/2019 15:00	0.0	0	0	0	0	1
11/14/2019 16:00	0.0	0	0	0	0	1
11/14/2019 17:00	0.0	0	0	0	0	1
11/14/2019 18:00	0.0	0	0	0	0	1
11/14/2019 19:00	0.0	0	0	0	0	1
11/14/2019 20:00	0.0	0	0	0	0	1
11/14/2019 21:00	0.0	0	0	0	0	1
11/14/2019 22:00	0.0	0	0	0	0	1
11/14/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/15/2019 00:00	0.0	0	0	0	0	1
11/15/2019 01:00	0.0	0	0	0	0	1
11/15/2019 02:00	0.0	0	0	0	0	1
11/15/2019 03:00	0.0	0	0	0	0	1
11/15/2019 04:00	0.0	0	0	0	0	1
11/15/2019 05:00	0.0	0	0	0	0	1
11/15/2019 06:00	0.0	0	0	0	0	1
11/15/2019 07:00	0.0	0	0	0	0	1
11/15/2019 08:00	0.0	0	0	0	0	1
11/15/2019 09:00	0.0	0	0	0	0	1
11/15/2019 10:00	0.0	0	0	0	0	1
11/15/2019 11:00	0.0	0	0	0	0	1
11/15/2019 12:00	0.0	0	0	0	0	1
11/15/2019 13:00	0.0	0	0	0	0	1
11/15/2019 14:00	0.0	0	0	0	0	1
11/15/2019 15:00	0.0	0	0	0	0	1
11/15/2019 16:00	0.0	0	0	0	0	1
11/15/2019 17:00	0.0	0	0	0	0	1
11/15/2019 18:00	0.0	0	0	0	0	1
11/15/2019 19:00	0.0	0	0	0	0	1
11/15/2019 20:00	0.0	0	0	0	0	1
11/15/2019 21:00	0.0	0	0	0	0	1
11/15/2019 22:00	0.0	0	0	0	0	1
11/15/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/16/2019 00:00	0.0	0	0	0	0	1
11/16/2019 01:00	0.0	0	0	0	0	1
11/16/2019 02:00	0.0	0	0	0	0	1
11/16/2019 03:00	0.0	0	0	0	0	1
11/16/2019 04:00	0.0	0	0	0	0	1
11/16/2019 05:00	0.0	0	0	0	0	1
11/16/2019 06:00	0.0	0	0	0	0	1
11/16/2019 07:00	0.0	0	0	0	0	1
11/16/2019 08:00	0.0	0	0	0	0	1
11/16/2019 09:00	0.0	0	0	0	0	1
11/16/2019 10:00	0.0	0	0	0	0	1
11/16/2019 11:00	0.0	0	0	0	0	1
11/16/2019 12:00	0.0	0	0	0	0	1
11/16/2019 13:00	0.0	0	0	0	0	1
11/16/2019 14:00	0.0	0	0	0	0	1
11/16/2019 15:00	0.0	0	0	0	0	1
11/16/2019 16:00	0.0	0	0	0	0	1
11/16/2019 17:00	0.0	0	0	0	0	1
11/16/2019 18:00	0.0	0	0	0	0	1
11/16/2019 19:00	0.0	0	0	0	0	1
11/16/2019 20:00	0.0	0	0	0	0	1
11/16/2019 21:00	0.0	0	0	0	0	1
11/16/2019 22:00	0.0	0	0	0	0	1
11/16/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/17/2019 00:00	0.0	0	0	0	0	1
11/17/2019 01:00	0.0	0	0	0	0	1
11/17/2019 02:00	0.0	0	0	0	0	1
11/17/2019 03:00	0.0	0	0	0	0	1
11/17/2019 04:00	0.0	0	0	0	0	1
11/17/2019 05:00	0.0	0	0	0	0	1
11/17/2019 06:00	0.0	0	0	0	0	1
11/17/2019 07:00	0.0	0	0	0	0	1
11/17/2019 08:00	0.0	0	0	0	0	1
11/17/2019 09:00	0.0	0	0	0	0	1
11/17/2019 10:00	0.0	0	0	0	0	1
11/17/2019 11:00	0.0	0	0	0	0	1
11/17/2019 12:00	0.0	0	0	0	0	1
11/17/2019 13:00	0.0	0	0	0	0	1
11/17/2019 14:00	0.0	0	0	0	0	1
11/17/2019 15:00	0.0	0	0	0	0	1
11/17/2019 16:00	0.0	0	0	0	0	1
11/17/2019 17:00	0.0	0	0	0	0	1
11/17/2019 18:00	0.0	0	0	0	0	1
11/17/2019 19:00	0.0	0	0	0	0	1
11/17/2019 20:00	0.0	0	0	0	0	1
11/17/2019 21:00	0.0	0	0	0	0	1
11/17/2019 22:00	0.0	0	0	0	0	1
11/17/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/18/2019 00:00	0.0	0	0	0	0	1
11/18/2019 01:00	0.0	0	0	0	0	1
11/18/2019 02:00	0.0	0	0	0	0	1
11/18/2019 03:00	0.0	0	0	0	0	1
11/18/2019 04:00	0.0	0	0	0	0	1
11/18/2019 05:00	0.0	0	0	0	0	1
11/18/2019 06:00	0.0	0	0	0	0	1
11/18/2019 07:00	0.0	0	0	0	0	1
11/18/2019 08:00	0.0	0	0	0	0	1
11/18/2019 09:00	0.0	0	0	0	0	1
11/18/2019 10:00	0.0	0	0	0	0	1
11/18/2019 11:00	0.0	0	0	0	0	1
11/18/2019 12:00	0.0	0	0	0	0	1
11/18/2019 13:00	0.0	0	0	0	0	1
11/18/2019 14:00	0.0	0	0	0	0	1
11/18/2019 15:00	0.0	0	0	0	0	1
11/18/2019 16:00	0.0	0	0	0	0	1
11/18/2019 17:00	0.0	0	0	0	0	1
11/18/2019 18:00	0.0	0	0	0	0	1
11/18/2019 19:00	0.0	0	0	0	0	1
11/18/2019 20:00	0.0	0	0	0	0	1
11/18/2019 21:00	0.0	0	0	0	0	1
11/18/2019 22:00	0.0	0	0	0	0	1
11/18/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/19/2019 00:00	0.0	0	0	0	0	1
11/19/2019 01:00	0.0	0	0	0	0	1
11/19/2019 02:00	0.0	0	0	0	0	1
11/19/2019 03:00	0.0	0	0	0	0	1
11/19/2019 04:00	0.0	0	0	0	0	1
11/19/2019 05:00	0.0	0	0	0	0	1
11/19/2019 06:00	0.0	0	0	0	0	1
11/19/2019 07:00	0.0	0	0	0	0	1
11/19/2019 08:00	0.0	0	0	0	0	1
11/19/2019 09:00	0.0	0	0	0	0	1
11/19/2019 10:00	0.0	0	0	0	0	1
11/19/2019 11:00	0.0	0	0	0	0	1
11/19/2019 12:00	0.0	0	0	0	0	1
11/19/2019 13:00	0.0	0	0	0	0	1
11/19/2019 14:00	0.0	0	0	0	0	1
11/19/2019 15:00	0.0	0	0	0	0	1
11/19/2019 16:00	0.0	0	0	0	0	1
11/19/2019 17:00	0.0	0	0	0	0	1
11/19/2019 18:00	0.0	0	0	0	0	1
11/19/2019 19:00	0.0	0	0	0	0	1
11/19/2019 20:00	0.0	0	0	0	0	1
11/19/2019 21:00	0.0	0	0	0	0	1
11/19/2019 22:00	0.0	0	0	0	0	1
11/19/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/20/2019 00:00	0.0	0	0	0	0	1
11/20/2019 01:00	0.0	0	0	0	0	1
11/20/2019 02:00	0.0	0	0	0	0	1
11/20/2019 03:00	0.0	0	0	0	0	1
11/20/2019 04:00	0.0	0	0	0	0	1
11/20/2019 05:00	0.0	0	0	0	0	1
11/20/2019 06:00	0.0	0	0	0	0	1
11/20/2019 07:00	0.0	0	0	0	0	1
11/20/2019 08:00	0.0	0	0	0	0	1
11/20/2019 09:00	0.0	0	0	0	0	1
11/20/2019 10:00	0.0	0	0	0	0	1
11/20/2019 11:00	0.0	0	0	0	0	1
11/20/2019 12:00	0.0	0	0	0	0	1
11/20/2019 13:00	0.0	0	0	0	0	1
11/20/2019 14:00	0.0	0	0	0	0	1
11/20/2019 15:00	0.0	0	0	0	0	1
11/20/2019 16:00	0.0	0	0	0	0	1
11/20/2019 17:00	0.0	0	0	0	0	1
11/20/2019 18:00	0.0	0	0	0	0	1
11/20/2019 19:00	0.0	0	0	0	0	1
11/20/2019 20:00	0.0	0	0	0	0	1
11/20/2019 21:00	0.0	0	0	0	0	1
11/20/2019 22:00	0.0	0	0	0	0	1
11/20/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/21/2019 00:00	0.0	0	0	0	0	1
11/21/2019 01:00	0.0	0	0	0	0	1
11/21/2019 02:00	0.0	0	0	0	0	1
11/21/2019 03:00	0.0	0	0	0	0	1
11/21/2019 04:00	0.0	0	0	0	0	1
11/21/2019 05:00	0.0	0	0	0	0	1
11/21/2019 06:00	0.0	0	0	0	0	1
11/21/2019 07:00	0.0	0	0	0	0	1
11/21/2019 08:00	0.0	0	0	0	0	1
11/21/2019 09:00	0.0	0	0	0	0	1
11/21/2019 10:00	0.0	0	0	0	0	1
11/21/2019 11:00	0.0	0	0	0	0	1
11/21/2019 12:00	0.0	0	0	0	0	1
11/21/2019 13:00	0.0	0	0	0	0	1
11/21/2019 14:00	0.0	0	0	0	0	1
11/21/2019 15:00	0.0	0	0	0	0	1
11/21/2019 16:00	0.0	0	0	0	0	1
11/21/2019 17:00	0.0	0	0	0	0	1
11/21/2019 18:00	0.0	0	0	0	0	1
11/21/2019 19:00	0.0	0	0	0	0	1
11/21/2019 20:00	0.0	0	0	0	0	1
11/21/2019 21:00	0.0	0	0	0	0	1
11/21/2019 22:00	0.0	0	0	0	0	1
11/21/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/22/2019 00:00	0.0	0	0	0	0	1
11/22/2019 01:00	0.0	0	0	0	0	1
11/22/2019 02:00	0.0	0	0	0	0	1
11/22/2019 03:00	0.0	0	0	0	0	1
11/22/2019 04:00	0.0	0	0	0	0	1
11/22/2019 05:00	0.0	0	0	0	0	1
11/22/2019 06:00	0.0	0	0	0	0	1
11/22/2019 07:00	0.0	0	0	0	0	1
11/22/2019 08:00	0.0	0	0	0	0	1
11/22/2019 09:00	0.0	0	0	0	0	1
11/22/2019 10:00	0.0	0	0	0	0	1
11/22/2019 11:00	0.0	0	0	0	0	1
11/22/2019 12:00	0.0	0	0	0	0	1
11/22/2019 13:00	0.0	0	0	0	0	1
11/22/2019 14:00	0.0	0	0	0	0	1
11/22/2019 15:00	0.0	0	0	0	0	1
11/22/2019 16:00	0.0	0	0	0	0	1
11/22/2019 17:00	0.0	0	0	0	0	1
11/22/2019 18:00	0.0	0	0	0	0	1
11/22/2019 19:00	0.0	0	0	0	0	1
11/22/2019 20:00	0.0	0	0	0	0	1
11/22/2019 21:00	0.0	0	0	0	0	1
11/22/2019 22:00	0.0	0	0	0	0	1
11/22/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/23/2019 00:00	0.0	0	0	0	0	1
11/23/2019 01:00	0.0	0	0	0	0	1
11/23/2019 02:00	0.0	0	0	0	0	1
11/23/2019 03:00	0.0	0	0	0	0	1
11/23/2019 04:00	0.0	0	0	0	0	1
11/23/2019 05:00	0.0	0	0	0	0	1
11/23/2019 06:00	0.0	0	0	0	0	1
11/23/2019 07:00	0.0	0	0	0	0	1
11/23/2019 08:00	0.0	0	0	0	0	1
11/23/2019 09:00	0.0	0	0	0	0	1
11/23/2019 10:00	0.0	0	0	0	0	1
11/23/2019 11:00	0.0	0	0	0	0	1
11/23/2019 12:00	0.0	0	0	0	0	1
11/23/2019 13:00	0.0	0	0	0	0	1
11/23/2019 14:00	0.0	0	0	0	0	1
11/23/2019 15:00	0.0	0	0	0	0	1
11/23/2019 16:00	0.0	0	0	0	0	1
11/23/2019 17:00	0.0	0	0	0	0	1
11/23/2019 18:00	0.0	0	0	0	0	1
11/23/2019 19:00	0.0	0	0	0	0	1
11/23/2019 20:00	0.0	0	0	0	0	1
11/23/2019 21:00	0.0	0	0	0	0	1
11/23/2019 22:00	0.0	0	0	0	0	1
11/23/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/24/2019 00:00	0.0	0	0	0	0	1
11/24/2019 01:00	0.0	0	0	0	0	1
11/24/2019 02:00	0.0	0	0	0	0	1
11/24/2019 03:00	0.0	0	0	0	0	1
11/24/2019 04:00	0.0	0	0	0	0	1
11/24/2019 05:00	0.0	0	0	0	0	1
11/24/2019 06:00	0.0	0	0	0	0	1
11/24/2019 07:00	0.0	0	0	0	0	1
11/24/2019 08:00	0.0	0	0	0	0	1
11/24/2019 09:00	0.0	0	0	0	0	1
11/24/2019 10:00	0.0	0	0	0	0	1
11/24/2019 11:00	0.0	0	0	0	0	1
11/24/2019 12:00	0.0	0	0	0	0	1
11/24/2019 13:00	0.0	0	0	0	0	1
11/24/2019 14:00	0.0	0	0	0	0	1
11/24/2019 15:00	0.0	0	0	0	0	1
11/24/2019 16:00	0.0	0	0	0	0	1
11/24/2019 17:00	0.0	0	0	0	0	1
11/24/2019 18:00	0.0	0	0	0	0	1
11/24/2019 19:00	0.0	0	0	0	0	1
11/24/2019 20:00	0.0	0	0	0	0	1
11/24/2019 21:00	0.0	0	0	0	0	1
11/24/2019 22:00	0.0	0	0	0	0	1
11/24/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/25/2019 00:00	0.5	0	0	0	1	0
11/25/2019 01:00	0.0	0	0	0	0	0
11/25/2019 02:00	0.0	0	0	0	0	0
11/25/2019 03:00	0.0	0	0	0	0	0
11/25/2019 04:00	6.3	0	0	1	0	0
11/25/2019 05:00	12.1	0	0	1	0	0
11/25/2019 06:00	0.0	0	0	0	0	1
11/25/2019 07:00	0.0	0	0	0	0	1
11/25/2019 08:00	0.0	0	0	0	0	1
11/25/2019 09:00	0.0	0	0	0	0	1
11/25/2019 10:00	0.0	0	0	0	0	1
11/25/2019 11:00	0.0	0	0	0	0	1
11/25/2019 12:00	0.0	0	0	0	0	1
11/25/2019 13:00	0.0	0	0	0	0	1
11/25/2019 14:00	0.0	0	0	0	0	1
11/25/2019 15:00	0.0	0	0	0	0	1
11/25/2019 16:00	0.0	0	0	0	0	1
11/25/2019 17:00	0.0	0	0	0	0	1
11/25/2019 18:00	0.0	0	0	0	0	1
11/25/2019 19:00	0.0	0	0	0	0	1
11/25/2019 20:00	0.0	0	0	0	0	1
11/25/2019 21:00	0.0	0	0	0	0	1
11/25/2019 22:00	0.0	0	0	0	0	1
11/25/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	18.9 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	12.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/26/2019 00:00	0.0	0	0	0	0	1
11/26/2019 01:00	0.0	0	0	0	0	1
11/26/2019 02:00	0.0	0	0	0	0	1
11/26/2019 03:00	0.0	0	0	0	0	1
11/26/2019 04:00	0.0	0	0	0	0	1
11/26/2019 05:00	0.0	0	0	0	0	1
11/26/2019 06:00	0.0	0	0	0	0	1
11/26/2019 07:00	0.0	0	0	0	0	1
11/26/2019 08:00	0.0	0	0	0	0	1
11/26/2019 09:00	0.0	0	0	0	0	1
11/26/2019 10:00	0.0	0	0	0	0	1
11/26/2019 11:00	0.0	0	0	0	0	1
11/26/2019 12:00	0.0	0	0	0	0	1
11/26/2019 13:00	0.0	0	0	0	0	1
11/26/2019 14:00	0.0	0	0	0	0	1
11/26/2019 15:00	0.0	0	0	0	0	1
11/26/2019 16:00	0.0	0	0	0	0	1
11/26/2019 17:00	0.0	0	0	0	0	1
11/26/2019 18:00	0.0	0	0	0	0	1
11/26/2019 19:00	0.0	0	0	0	0	1
11/26/2019 20:00	0.0	0	0	0	0	1
11/26/2019 21:00	0.0	0	0	0	0	1
11/26/2019 22:00	0.0	0	0	0	0	1
11/26/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/27/2019 00:00	0.0	0	0	0	0	1
11/27/2019 01:00	0.0	0	0	0	0	1
11/27/2019 02:00	0.0	0	0	0	0	1
11/27/2019 03:00	0.0	0	0	0	0	1
11/27/2019 04:00	0.0	0	0	0	0	1
11/27/2019 05:00	0.0	0	0	0	0	1
11/27/2019 06:00	0.0	0	0	0	0	1
11/27/2019 07:00	0.0	0	0	0	0	1
11/27/2019 08:00	0.0	0	0	0	0	1
11/27/2019 09:00	0.0	0	0	0	0	1
11/27/2019 10:00	0.0	0	0	0	0	1
11/27/2019 11:00	0.0	0	0	0	0	1
11/27/2019 12:00	0.0	0	0	0	0	1
11/27/2019 13:00	0.0	0	0	0	0	1
11/27/2019 14:00	0.0	0	0	0	0	1
11/27/2019 15:00	0.0	0	0	0	0	1
11/27/2019 16:00	0.0	0	0	0	0	1
11/27/2019 17:00	0.0	0	0	0	0	1
11/27/2019 18:00	0.0	0	0	0	0	1
11/27/2019 19:00	0.0	0	0	0	0	1
11/27/2019 20:00	0.0	0	0	0	0	1
11/27/2019 21:00	0.0	0	0	0	0	1
11/27/2019 22:00	0.0	0	0	0	0	1
11/27/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/28/2019 00:00	0.0	0	0	0	0	1
11/28/2019 01:00	0.0	0	0	0	0	1
11/28/2019 02:00	0.0	0	0	0	0	1
11/28/2019 03:00	0.0	0	0	0	0	1
11/28/2019 04:00	0.0	0	0	0	0	1
11/28/2019 05:00	0.0	0	0	0	0	1
11/28/2019 06:00	0.0	0	0	0	0	1
11/28/2019 07:00	0.0	0	0	0	0	1
11/28/2019 08:00	0.0	0	0	0	0	1
11/28/2019 09:00	0.0	0	0	0	0	1
11/28/2019 10:00	0.0	0	0	0	0	1
11/28/2019 11:00	0.0	0	0	0	0	1
11/28/2019 12:00	0.0	0	0	0	0	1
11/28/2019 13:00	0.0	0	0	0	0	1
11/28/2019 14:00	0.0	0	0	0	0	1
11/28/2019 15:00	0.0	0	0	0	0	1
11/28/2019 16:00	0.0	0	0	0	0	1
11/28/2019 17:00	0.0	0	0	0	0	1
11/28/2019 18:00	0.0	0	0	0	0	1
11/28/2019 19:00	0.0	0	0	0	0	1
11/28/2019 20:00	0.0	0	0	0	0	1
11/28/2019 21:00	0.0	0	0	0	0	1
11/28/2019 22:00	0.0	0	0	0	0	1
11/28/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/29/2019 00:00	0.0	0	0	0	0	1
11/29/2019 01:00	0.0	0	0	0	0	1
11/29/2019 02:00	0.0	0	0	0	0	1
11/29/2019 03:00	0.0	0	0	0	0	1
11/29/2019 04:00	0.0	0	0	0	0	1
11/29/2019 05:00	0.0	0	0	0	0	1
11/29/2019 06:00	0.0	0	0	0	0	1
11/29/2019 07:00	0.0	0	0	0	0	1
11/29/2019 08:00	0.0	0	0	0	0	1
11/29/2019 09:00	0.0	0	0	0	0	1
11/29/2019 10:00	0.0	0	0	0	0	1
11/29/2019 11:00	0.0	0	0	0	0	1
11/29/2019 12:00	0.0	0	0	0	0	1
11/29/2019 13:00	0.0	0	0	0	0	1
11/29/2019 14:00	0.0	0	0	0	0	1
11/29/2019 15:00	0.0	0	0	0	0	1
11/29/2019 16:00	0.0	0	0	0	0	1
11/29/2019 17:00	0.0	0	0	0	0	1
11/29/2019 18:00	0.0	0	0	0	0	1
11/29/2019 19:00	0.0	0	0	0	0	1
11/29/2019 20:00	0.0	0	0	0	0	1
11/29/2019 21:00	0.0	0	0	0	0	1
11/29/2019 22:00	0.0	0	0	0	0	1
11/29/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/30/2019 00:00	0.0	0	0	0	0	1
11/30/2019 01:00	0.0	0	0	0	0	1
11/30/2019 02:00	0.0	0	0	0	0	1
11/30/2019 03:00	0.0	0	0	0	0	1
11/30/2019 04:00	0.0	0	0	0	0	1
11/30/2019 05:00	0.0	0	0	0	0	1
11/30/2019 06:00	0.0	0	0	0	0	1
11/30/2019 07:00	0.0	0	0	0	0	1
11/30/2019 08:00	0.0	0	0	0	0	1
11/30/2019 09:00	0.0	0	0	0	0	1
11/30/2019 10:00	0.0	0	0	0	0	1
11/30/2019 11:00	0.0	0	0	0	0	1
11/30/2019 12:00	0.0	0	0	0	0	1
11/30/2019 13:00	0.0	0	0	0	0	1
11/30/2019 14:00	0.0	0	0	0	0	1
11/30/2019 15:00	0.0	0	0	0	0	1
11/30/2019 16:00	0.0	0	0	0	0	1
11/30/2019 17:00	0.0	0	0	0	0	1
11/30/2019 18:00	0.0	0	0	0	0	1
11/30/2019 19:00	0.0	0	0	0	0	1
11/30/2019 20:00	0.0	0	0	0	0	1
11/30/2019 21:00	0.0	0	0	0	0	1
11/30/2019 22:00	0.0	0	0	0	0	1
11/30/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/01/2019 00:00	0.0	0	0	0	0	1
12/01/2019 01:00	0.0	0	0	0	0	1
12/01/2019 02:00	0.0	0	0	0	0	1
12/01/2019 03:00	0.0	0	0	0	0	1
12/01/2019 04:00	0.0	0	0	0	0	1
12/01/2019 05:00	0.0	0	0	0	0	1
12/01/2019 06:00	0.0	0	0	0	0	1
12/01/2019 07:00	0.0	0	0	0	0	1
12/01/2019 08:00	0.0	0	0	0	0	1
12/01/2019 09:00	0.0	0	0	0	0	1
12/01/2019 10:00	0.0	0	0	0	0	1
12/01/2019 11:00	0.0	0	0	0	0	1
12/01/2019 12:00	0.0	0	0	0	0	1
12/01/2019 13:00	0.0	0	0	0	0	1
12/01/2019 14:00	0.0	0	0	0	0	1
12/01/2019 15:00	0.0	0	0	0	0	1
12/01/2019 16:00	0.0	0	0	0	0	1
12/01/2019 17:00	0.0	0	0	0	0	1
12/01/2019 18:00	0.0	0	0	0	0	1
12/01/2019 19:00	0.0	0	0	0	0	1
12/01/2019 20:00	0.0	0	0	0	0	1
12/01/2019 21:00	0.0	0	0	0	0	1
12/01/2019 22:00	0.0	0	0	0	0	1
12/01/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/02/2019 00:00	0.0	0	0	0	0	1
12/02/2019 01:00	0.0	0	0	0	0	1
12/02/2019 02:00	0.0	0	0	0	0	1
12/02/2019 03:00	0.0	0	0	0	0	1
12/02/2019 04:00	0.0	0	0	0	0	1
12/02/2019 05:00	0.0	0	0	0	0	1
12/02/2019 06:00	0.0	0	0	0	0	1
12/02/2019 07:00	0.0	0	0	0	0	1
12/02/2019 08:00	0.0	0	0	0	0	1
12/02/2019 09:00	0.0	0	0	0	0	1
12/02/2019 10:00	0.0	0	0	0	0	1
12/02/2019 11:00	0.0	0	0	0	0	1
12/02/2019 12:00	0.0	0	0	0	0	1
12/02/2019 13:00	0.0	0	0	0	0	1
12/02/2019 14:00	0.0	0	0	0	0	1
12/02/2019 15:00	0.0	0	0	0	0	1
12/02/2019 16:00	0.0	0	0	0	0	1
12/02/2019 17:00	0.0	0	0	0	0	1
12/02/2019 18:00	0.0	0	0	0	0	1
12/02/2019 19:00	0.0	0	0	0	0	1
12/02/2019 20:00	0.0	0	0	0	0	1
12/02/2019 21:00	0.0	0	0	0	0	1
12/02/2019 22:00	0.0	0	0	0	0	1
12/02/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/03/2019 00:00	0.0	0	0	0	0	1
12/03/2019 01:00	0.0	0	0	0	0	1
12/03/2019 02:00	0.0	0	0	0	0	1
12/03/2019 03:00	0.0	0	0	0	0	1
12/03/2019 04:00	0.0	0	0	0	0	1
12/03/2019 05:00	0.0	0	0	0	0	1
12/03/2019 06:00	0.0	0	0	0	0	1
12/03/2019 07:00	0.0	0	0	0	0	1
12/03/2019 08:00	0.0	0	0	0	0	1
12/03/2019 09:00	0.0	0	0	0	0	1
12/03/2019 10:00	0.0	0	0	0	0	1
12/03/2019 11:00	0.0	0	0	0	0	1
12/03/2019 12:00	0.0	0	0	0	0	1
12/03/2019 13:00	0.0	0	0	0	0	1
12/03/2019 14:00	0.0	0	0	0	0	1
12/03/2019 15:00	0.0	0	0	0	0	1
12/03/2019 16:00	0.0	0	0	0	0	1
12/03/2019 17:00	0.0	0	0	0	0	1
12/03/2019 18:00	0.0	0	0	0	0	1
12/03/2019 19:00	0.0	0	0	0	0	1
12/03/2019 20:00	0.0	0	0	0	0	1
12/03/2019 21:00	0.0	0	0	0	0	1
12/03/2019 22:00	0.0	0	0	0	0	1
12/03/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/04/2019 00:00	0.0	0	0	0	0	1
12/04/2019 01:00	0.0	0	0	0	0	1
12/04/2019 02:00	0.0	0	0	0	0	1
12/04/2019 03:00	0.0	0	0	0	0	1
12/04/2019 04:00	0.0	0	0	0	0	1
12/04/2019 05:00	0.0	0	0	0	0	1
12/04/2019 06:00	0.0	0	0	0	0	1
12/04/2019 07:00	0.0	0	0	0	0	1
12/04/2019 08:00	0.0	0	0	0	0	1
12/04/2019 09:00	0.0	0	0	0	0	1
12/04/2019 10:00	0.0	0	0	0	0	1
12/04/2019 11:00	0.0	0	0	0	0	1
12/04/2019 12:00	0.0	0	0	0	0	1
12/04/2019 13:00	0.0	0	0	0	0	1
12/04/2019 14:00	0.0	0	0	0	0	1
12/04/2019 15:00	0.0	0	0	0	0	1
12/04/2019 16:00	0.0	0	0	0	0	1
12/04/2019 17:00	0.0	0	0	0	0	1
12/04/2019 18:00	0.0	0	0	0	0	1
12/04/2019 19:00	0.0	0	0	0	0	1
12/04/2019 20:00	0.0	0	0	0	0	1
12/04/2019 21:00	0.0	0	0	0	0	1
12/04/2019 22:00	0.0	0	0	0	0	1
12/04/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/05/2019 00:00	0.0	0	0	0	0	1
12/05/2019 01:00	0.0	0	0	0	0	1
12/05/2019 02:00	0.0	0	0	0	0	1
12/05/2019 03:00	0.0	0	0	0	0	1
12/05/2019 04:00	0.0	0	0	0	0	1
12/05/2019 05:00	0.0	0	0	0	0	1
12/05/2019 06:00	0.0	0	0	0	0	1
12/05/2019 07:00	0.0	0	0	0	0	1
12/05/2019 08:00	0.0	0	0	0	0	1
12/05/2019 09:00	0.0	0	0	0	0	1
12/05/2019 10:00	0.0	0	0	0	0	1
12/05/2019 11:00	0.0	0	0	0	0	1
12/05/2019 12:00	0.0	0	0	0	0	1
12/05/2019 13:00	0.0	0	0	0	0	1
12/05/2019 14:00	0.0	0	0	0	0	1
12/05/2019 15:00	0.0	0	0	0	0	1
12/05/2019 16:00	0.0	0	0	0	0	1
12/05/2019 17:00	0.0	0	0	0	0	1
12/05/2019 18:00	0.0	0	0	0	0	1
12/05/2019 19:00	0.0	0	0	0	0	1
12/05/2019 20:00	0.0	0	0	0	0	1
12/05/2019 21:00	0.0	0	0	0	0	1
12/05/2019 22:00	0.0	0	0	0	0	1
12/05/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/06/2019 00:00	0.0	0	0	0	0	1
12/06/2019 01:00	0.0	0	0	0	0	1
12/06/2019 02:00	0.0	0	0	0	0	1
12/06/2019 03:00	0.0	0	0	0	0	1
12/06/2019 04:00	0.0	0	0	0	0	1
12/06/2019 05:00	0.0	0	0	0	0	1
12/06/2019 06:00	0.0	0	0	0	0	1
12/06/2019 07:00	0.0	0	0	0	0	1
12/06/2019 08:00	0.0	0	0	0	0	1
12/06/2019 09:00	0.0	0	0	0	0	1
12/06/2019 10:00	0.0	0	0	0	0	1
12/06/2019 11:00	0.0	0	0	0	0	1
12/06/2019 12:00	0.0	0	0	0	0	1
12/06/2019 13:00	0.0	0	0	0	0	1
12/06/2019 14:00	0.0	0	0	0	0	1
12/06/2019 15:00	0.0	0	0	0	0	1
12/06/2019 16:00	0.0	0	0	0	0	1
12/06/2019 17:00	0.0	0	0	0	0	1
12/06/2019 18:00	0.0	0	0	0	0	1
12/06/2019 19:00	0.0	0	0	0	0	1
12/06/2019 20:00	0.0	0	0	0	0	1
12/06/2019 21:00	0.0	0	0	0	0	1
12/06/2019 22:00	0.0	0	0	0	0	1
12/06/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/07/2019 00:00	0.0	0	0	0	0	1
12/07/2019 01:00	0.0	0	0	0	0	1
12/07/2019 02:00	0.0	0	0	0	0	1
12/07/2019 03:00	0.0	0	0	0	0	1
12/07/2019 04:00	0.0	0	0	0	0	1
12/07/2019 05:00	0.0	0	0	0	0	1
12/07/2019 06:00	0.0	0	0	0	0	1
12/07/2019 07:00	0.0	0	0	0	0	1
12/07/2019 08:00	0.0	0	0	0	0	1
12/07/2019 09:00	0.0	0	0	0	0	1
12/07/2019 10:00	0.0	0	0	0	0	1
12/07/2019 11:00	0.0	0	0	0	0	1
12/07/2019 12:00	0.0	0	0	0	0	1
12/07/2019 13:00	0.0	0	0	0	0	1
12/07/2019 14:00	0.0	0	0	0	0	1
12/07/2019 15:00	0.0	0	0	0	0	1
12/07/2019 16:00	0.0	0	0	0	0	1
12/07/2019 17:00	0.0	0	0	0	0	1
12/07/2019 18:00	0.0	0	0	0	0	1
12/07/2019 19:00	0.0	0	0	0	0	1
12/07/2019 20:00	0.0	0	0	0	0	1
12/07/2019 21:00	0.0	0	0	0	0	1
12/07/2019 22:00	0.0	0	0	0	0	1
12/07/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/08/2019 00:00	0.0	0	0	0	0	1
12/08/2019 01:00	0.0	0	0	0	0	1
12/08/2019 02:00	0.0	0	0	0	0	1
12/08/2019 03:00	0.0	0	0	0	0	1
12/08/2019 04:00	0.0	0	0	0	0	1
12/08/2019 05:00	0.0	0	0	0	0	1
12/08/2019 06:00	0.0	0	0	0	0	1
12/08/2019 07:00	0.0	0	0	0	0	1
12/08/2019 08:00	0.0	0	0	0	0	1
12/08/2019 09:00	0.0	0	0	0	0	1
12/08/2019 10:00	0.0	0	0	0	0	1
12/08/2019 11:00	0.0	0	0	0	0	1
12/08/2019 12:00	0.0	0	0	0	0	1
12/08/2019 13:00	0.0	0	0	0	0	1
12/08/2019 14:00	0.0	0	0	0	0	1
12/08/2019 15:00	0.0	0	0	0	0	1
12/08/2019 16:00	0.0	0	0	0	0	1
12/08/2019 17:00	0.0	0	0	0	0	1
12/08/2019 18:00	0.0	0	0	0	0	1
12/08/2019 19:00	0.0	0	0	0	0	1
12/08/2019 20:00	0.0	0	0	0	0	1
12/08/2019 21:00	0.0	0	0	0	0	1
12/08/2019 22:00	0.0	0	0	0	0	1
12/08/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/09/2019 00:00	0.0	0	0	0	0	1
12/09/2019 01:00	0.0	0	0	0	0	1
12/09/2019 02:00	0.0	0	0	0	0	1
12/09/2019 03:00	0.0	0	0	0	0	1
12/09/2019 04:00	0.0	0	0	0	0	1
12/09/2019 05:00	0.0	0	0	0	0	1
12/09/2019 06:00	0.0	0	0	0	0	1
12/09/2019 07:00	0.0	0	0	0	0	1
12/09/2019 08:00	0.0	0	0	0	0	1
12/09/2019 09:00	0.0	0	0	0	0	1
12/09/2019 10:00	0.0	0	0	0	0	1
12/09/2019 11:00	0.0	0	0	0	0	1
12/09/2019 12:00	0.0	0	0	0	0	1
12/09/2019 13:00	0.0	0	0	0	0	1
12/09/2019 14:00	0.0	0	0	0	0	1
12/09/2019 15:00	0.0	0	0	0	0	1
12/09/2019 16:00	0.0	0	0	0	0	1
12/09/2019 17:00	0.0	0	0	0	0	1
12/09/2019 18:00	0.0	0	0	0	0	1
12/09/2019 19:00	0.0	0	0	0	0	1
12/09/2019 20:00	0.0	0	0	0	0	1
12/09/2019 21:00	0.0	0	0	0	0	1
12/09/2019 22:00	0.0	0	0	0	0	1
12/09/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/10/2019 00:00	0.0	0	0	0	0	1
12/10/2019 01:00	0.0	0	0	0	0	1
12/10/2019 02:00	0.0	0	0	0	0	1
12/10/2019 03:00	0.0	0	0	0	0	1
12/10/2019 04:00	0.0	0	0	0	0	1
12/10/2019 05:00	0.0	0	0	0	0	1
12/10/2019 06:00	0.0	0	0	0	0	1
12/10/2019 07:00	0.0	0	0	0	0	1
12/10/2019 08:00	0.0	0	0	0	0	1
12/10/2019 09:00	0.0	0	0	0	0	1
12/10/2019 10:00	0.0	0	0	0	0	1
12/10/2019 11:00	0.0	0	0	0	0	1
12/10/2019 12:00	0.0	0	0	0	0	1
12/10/2019 13:00	0.0	0	0	0	0	1
12/10/2019 14:00	0.0	0	0	0	0	1
12/10/2019 15:00	0.0	0	0	0	0	1
12/10/2019 16:00	0.0	0	0	0	0	1
12/10/2019 17:00	0.0	0	0	0	0	1
12/10/2019 18:00	0.0	0	0	0	0	1
12/10/2019 19:00	0.0	0	0	0	0	1
12/10/2019 20:00	0.0	0	0	0	0	1
12/10/2019 21:00	0.0	0	0	0	0	1
12/10/2019 22:00	0.0	0	0	0	0	1
12/10/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/11/2019 00:00	0.0	0	0	0	0	1
12/11/2019 01:00	0.0	0	0	0	0	1
12/11/2019 02:00	0.0	0	0	0	0	1
12/11/2019 03:00	0.0	0	0	0	0	1
12/11/2019 04:00	0.0	0	0	0	0	1
12/11/2019 05:00	0.0	0	0	0	0	1
12/11/2019 06:00	0.0	0	0	0	0	1
12/11/2019 07:00	0.0	0	0	0	0	1
12/11/2019 08:00	0.0	0	0	0	0	1
12/11/2019 09:00	0.0	0	0	0	0	1
12/11/2019 10:00	0.0	0	0	0	0	1
12/11/2019 11:00	0.0	0	0	0	0	1
12/11/2019 12:00	0.0	0	0	0	0	1
12/11/2019 13:00	0.0	0	0	0	0	1
12/11/2019 14:00	0.0	0	0	0	0	1
12/11/2019 15:00	0.0	0	0	0	0	1
12/11/2019 16:00	0.0	0	0	0	0	1
12/11/2019 17:00	0.0	0	0	0	0	1
12/11/2019 18:00	0.0	0	0	0	0	1
12/11/2019 19:00	0.0	0	0	0	0	1
12/11/2019 20:00	0.0	0	0	0	0	1
12/11/2019 21:00	0.0	0	0	0	0	1
12/11/2019 22:00	0.0	0	0	0	0	1
12/11/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/12/2019 00:00	0.0	0	0	0	0	1
12/12/2019 01:00	0.0	0	0	0	0	1
12/12/2019 02:00	0.0	0	0	0	0	1
12/12/2019 03:00	0.0	0	0	0	0	1
12/12/2019 04:00	0.0	0	0	0	0	1
12/12/2019 05:00	0.0	0	0	0	0	1
12/12/2019 06:00	0.0	0	0	0	0	1
12/12/2019 07:00	0.0	0	0	0	0	1
12/12/2019 08:00	0.0	0	0	0	0	1
12/12/2019 09:00	0.0	0	0	0	0	1
12/12/2019 10:00	0.0	0	0	0	0	1
12/12/2019 11:00	0.0	0	0	0	0	1
12/12/2019 12:00	0.0	0	0	0	0	1
12/12/2019 13:00	0.0	0	0	0	0	1
12/12/2019 14:00	0.0	0	0	0	0	1
12/12/2019 15:00	0.0	0	0	0	0	1
12/12/2019 16:00	0.0	0	0	0	0	1
12/12/2019 17:00	0.0	0	0	0	0	1
12/12/2019 18:00	0.0	0	0	0	0	1
12/12/2019 19:00	0.0	0	0	0	0	1
12/12/2019 20:00	0.0	0	0	0	0	1
12/12/2019 21:00	0.0	0	0	0	0	1
12/12/2019 22:00	0.0	0	0	0	0	1
12/12/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/13/2019 00:00	0.5	0	0	0	1	0
12/13/2019 01:00	0.0	0	0	0	0	0
12/13/2019 02:00	0.0	0	0	0	0	0
12/13/2019 03:00	0.0	0	0	0	0	0
12/13/2019 04:00	4.6	0	0	1	0	0
12/13/2019 05:00	5.7	0	0	1	0	0
12/13/2019 06:00	0.0	0	0	0	0	1
12/13/2019 07:00	0.0	0	0	0	0	1
12/13/2019 08:00	0.0	0	0	0	0	1
12/13/2019 09:00	0.0	0	0	0	0	1
12/13/2019 10:00	0.0	0	0	0	0	1
12/13/2019 11:00	0.0	0	0	0	0	1
12/13/2019 12:00	0.0	0	0	0	0	1
12/13/2019 13:00	0.0	0	0	0	0	1
12/13/2019 14:00	0.0	0	0	0	0	1
12/13/2019 15:00	0.0	0	0	0	0	1
12/13/2019 16:00	0.0	0	0	0	0	1
12/13/2019 17:00	0.0	0	0	0	0	1
12/13/2019 18:00	0.0	0	0	0	0	1
12/13/2019 19:00	0.0	0	0	0	0	1
12/13/2019 20:00	0.0	0	0	0	0	1
12/13/2019 21:00	0.0	0	0	0	0	1
12/13/2019 22:00	0.0	0	0	0	0	1
12/13/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	10.8 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5.7	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/14/2019 00:00	0.0	0	0	0	0	1
12/14/2019 01:00	0.0	0	0	0	0	1
12/14/2019 02:00	0.0	0	0	0	0	1
12/14/2019 03:00	0.0	0	0	0	0	1
12/14/2019 04:00	0.0	0	0	0	0	1
12/14/2019 05:00	0.0	0	0	0	0	1
12/14/2019 06:00	0.0	0	0	0	0	1
12/14/2019 07:00	0.0	0	0	0	0	1
12/14/2019 08:00	0.0	0	0	0	0	1
12/14/2019 09:00	0.0	0	0	0	0	1
12/14/2019 10:00	0.0	0	0	0	0	1
12/14/2019 11:00	0.0	0	0	0	0	1
12/14/2019 12:00	0.0	0	0	0	0	1
12/14/2019 13:00	0.0	0	0	0	0	1
12/14/2019 14:00	0.0	0	0	0	0	1
12/14/2019 15:00	0.0	0	0	0	0	1
12/14/2019 16:00	0.0	0	0	0	0	1
12/14/2019 17:00	0.0	0	0	0	0	1
12/14/2019 18:00	0.0	0	0	0	0	1
12/14/2019 19:00	0.0	0	0	0	0	1
12/14/2019 20:00	0.0	0	0	0	0	1
12/14/2019 21:00	0.0	0	0	0	0	1
12/14/2019 22:00	0.0	0	0	0	0	1
12/14/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/15/2019 00:00	0.0	0	0	0	0	1
12/15/2019 01:00	0.0	0	0	0	0	1
12/15/2019 02:00	0.0	0	0	0	0	1
12/15/2019 03:00	0.0	0	0	0	0	1
12/15/2019 04:00	0.0	0	0	0	0	1
12/15/2019 05:00	0.0	0	0	0	0	1
12/15/2019 06:00	0.0	0	0	0	0	1
12/15/2019 07:00	0.0	0	0	0	0	1
12/15/2019 08:00	0.0	0	0	0	0	1
12/15/2019 09:00	0.0	0	0	0	0	1
12/15/2019 10:00	0.0	0	0	0	0	1
12/15/2019 11:00	0.0	0	0	0	0	1
12/15/2019 12:00	0.0	0	0	0	0	1
12/15/2019 13:00	0.0	0	0	0	0	1
12/15/2019 14:00	0.0	0	0	0	0	1
12/15/2019 15:00	0.0	0	0	0	0	1
12/15/2019 16:00	0.0	0	0	0	0	1
12/15/2019 17:00	0.0	0	0	0	0	1
12/15/2019 18:00	0.0	0	0	0	0	1
12/15/2019 19:00	0.0	0	0	0	0	1
12/15/2019 20:00	0.0	0	0	0	0	1
12/15/2019 21:00	0.0	0	0	0	0	1
12/15/2019 22:00	0.0	0	0	0	0	1
12/15/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/16/2019 00:00	0.0	0	0	0	0	1
12/16/2019 01:00	0.0	0	0	0	0	1
12/16/2019 02:00	0.0	0	0	0	0	1
12/16/2019 03:00	0.0	0	0	0	0	1
12/16/2019 04:00	0.0	0	0	0	0	1
12/16/2019 05:00	0.0	0	0	0	0	1
12/16/2019 06:00	0.0	0	0	0	0	1
12/16/2019 07:00	0.0	0	0	0	0	1
12/16/2019 08:00	0.0	0	0	0	0	1
12/16/2019 09:00	0.0	0	0	0	0	1
12/16/2019 10:00	0.0	0	0	0	0	1
12/16/2019 11:00	0.0	0	0	0	0	1
12/16/2019 12:00	0.0	0	0	0	0	1
12/16/2019 13:00	0.0	0	0	0	0	1
12/16/2019 14:00	0.0	0	0	0	0	1
12/16/2019 15:00	0.0	0	0	0	0	1
12/16/2019 16:00	0.0	0	0	0	0	1
12/16/2019 17:00	0.0	0	0	0	0	1
12/16/2019 18:00	0.0	0	0	0	0	1
12/16/2019 19:00	0.0	0	0	0	0	1
12/16/2019 20:00	0.0	0	0	0	0	1
12/16/2019 21:00	0.0	0	0	0	0	1
12/16/2019 22:00	0.0	0	0	0	0	1
12/16/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/17/2019 00:00	0.0	0	0	0	0	1
12/17/2019 01:00	0.0	0	0	0	0	1
12/17/2019 02:00	0.0	0	0	0	0	1
12/17/2019 03:00	0.0	0	0	0	0	1
12/17/2019 04:00	0.0	0	0	0	0	1
12/17/2019 05:00	0.0	0	0	0	0	1
12/17/2019 06:00	0.0	0	0	0	0	1
12/17/2019 07:00	0.0	0	0	0	0	1
12/17/2019 08:00	0.0	0	0	0	0	1
12/17/2019 09:00	0.0	0	0	0	0	1
12/17/2019 10:00	0.0	0	0	0	0	1
12/17/2019 11:00	0.0	0	0	0	0	1
12/17/2019 12:00	0.0	0	0	0	0	1
12/17/2019 13:00	0.0	0	0	0	0	1
12/17/2019 14:00	0.0	0	0	0	0	1
12/17/2019 15:00	0.0	0	0	0	0	1
12/17/2019 16:00	0.0	0	0	0	0	1
12/17/2019 17:00	0.0	0	0	0	0	1
12/17/2019 18:00	0.0	0	0	0	0	1
12/17/2019 19:00	0.0	0	0	0	0	1
12/17/2019 20:00	0.0	0	0	0	0	1
12/17/2019 21:00	0.0	0	0	0	0	1
12/17/2019 22:00	0.0	0	0	0	0	1
12/17/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/18/2019 00:00	0.0	0	0	0	0	1
12/18/2019 01:00	0.0	0	0	0	0	1
12/18/2019 02:00	0.0	0	0	0	0	1
12/18/2019 03:00	0.0	0	0	0	0	1
12/18/2019 04:00	0.0	0	0	0	0	1
12/18/2019 05:00	0.0	0	0	0	0	1
12/18/2019 06:00	0.0	0	0	0	0	1
12/18/2019 07:00	0.0	0	0	0	0	1
12/18/2019 08:00	0.0	0	0	0	0	1
12/18/2019 09:00	0.0	0	0	0	0	1
12/18/2019 10:00	0.0	0	0	0	0	1
12/18/2019 11:00	0.0	0	0	0	0	1
12/18/2019 12:00	0.0	0	0	0	0	1
12/18/2019 13:00	0.0	0	0	0	0	1
12/18/2019 14:00	0.0	0	0	0	0	1
12/18/2019 15:00	0.0	0	0	0	0	1
12/18/2019 16:00	0.0	0	0	0	0	1
12/18/2019 17:00	0.0	0	0	0	0	1
12/18/2019 18:00	0.0	0	0	0	0	1
12/18/2019 19:00	0.0	0	0	0	0	1
12/18/2019 20:00	0.0	0	0	0	0	1
12/18/2019 21:00	0.0	0	0	0	0	1
12/18/2019 22:00	0.0	0	0	0	0	1
12/18/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/19/2019 00:00	0.0	0	0	0	0	1
12/19/2019 01:00	0.0	0	0	0	0	1
12/19/2019 02:00	0.0	0	0	0	0	1
12/19/2019 03:00	0.0	0	0	0	0	1
12/19/2019 04:00	0.0	0	0	0	0	1
12/19/2019 05:00	0.0	0	0	0	0	1
12/19/2019 06:00	0.0	0	0	0	0	1
12/19/2019 07:00	0.0	0	0	0	0	1
12/19/2019 08:00	0.0	0	0	0	0	1
12/19/2019 09:00	0.0	0	0	0	0	1
12/19/2019 10:00	0.0	0	0	0	0	1
12/19/2019 11:00	0.0	0	0	0	0	1
12/19/2019 12:00	0.0	0	0	0	0	1
12/19/2019 13:00	0.0	0	0	0	0	1
12/19/2019 14:00	0.0	0	0	0	0	1
12/19/2019 15:00	0.0	0	0	0	0	1
12/19/2019 16:00	0.0	0	0	0	0	1
12/19/2019 17:00	0.0	0	0	0	0	1
12/19/2019 18:00	0.0	0	0	0	0	1
12/19/2019 19:00	0.0	0	0	0	0	1
12/19/2019 20:00	0.0	0	0	0	0	1
12/19/2019 21:00	0.0	0	0	0	0	1
12/19/2019 22:00	0.0	0	0	0	0	1
12/19/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/20/2019 00:00	0.0	0	0	0	0	1
12/20/2019 01:00	0.0	0	0	0	0	1
12/20/2019 02:00	0.0	0	0	0	0	1
12/20/2019 03:00	0.0	0	0	0	0	1
12/20/2019 04:00	0.0	0	0	0	0	1
12/20/2019 05:00	0.0	0	0	0	0	1
12/20/2019 06:00	0.0	0	0	0	0	1
12/20/2019 07:00	0.0	0	0	0	0	1
12/20/2019 08:00	0.0	0	0	0	0	1
12/20/2019 09:00	0.0	0	0	0	0	1
12/20/2019 10:00	0.0	0	0	0	0	1
12/20/2019 11:00	0.0	0	0	0	0	1
12/20/2019 12:00	0.0	0	0	0	0	1
12/20/2019 13:00	0.0	0	0	0	0	1
12/20/2019 14:00	0.0	0	0	0	0	1
12/20/2019 15:00	0.0	0	0	0	0	1
12/20/2019 16:00	0.0	0	0	0	0	1
12/20/2019 17:00	0.0	0	0	0	0	1
12/20/2019 18:00	0.0	0	0	0	0	1
12/20/2019 19:00	0.0	0	0	0	0	1
12/20/2019 20:00	0.0	0	0	0	0	1
12/20/2019 21:00	0.0	0	0	0	0	1
12/20/2019 22:00	0.0	0	0	0	0	1
12/20/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/21/2019 00:00	0.0	0	0	0	0	1
12/21/2019 01:00	0.0	0	0	0	0	1
12/21/2019 02:00	0.0	0	0	0	0	1
12/21/2019 03:00	0.0	0	0	0	0	1
12/21/2019 04:00	0.0	0	0	0	0	1
12/21/2019 05:00	0.0	0	0	0	0	1
12/21/2019 06:00	0.0	0	0	0	0	1
12/21/2019 07:00	0.0	0	0	0	0	1
12/21/2019 08:00	0.0	0	0	0	0	1
12/21/2019 09:00	0.0	0	0	0	0	1
12/21/2019 10:00	0.0	0	0	0	0	1
12/21/2019 11:00	0.0	0	0	0	0	1
12/21/2019 12:00	0.0	0	0	0	0	1
12/21/2019 13:00	0.0	0	0	0	0	1
12/21/2019 14:00	0.0	0	0	0	0	1
12/21/2019 15:00	0.0	0	0	0	0	1
12/21/2019 16:00	0.0	0	0	0	0	1
12/21/2019 17:00	0.0	0	0	0	0	1
12/21/2019 18:00	0.0	0	0	0	0	1
12/21/2019 19:00	0.0	0	0	0	0	1
12/21/2019 20:00	0.0	0	0	0	0	1
12/21/2019 21:00	0.0	0	0	0	0	1
12/21/2019 22:00	0.0	0	0	0	0	1
12/21/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/22/2019 00:00	0.0	0	0	0	0	1
12/22/2019 01:00	0.0	0	0	0	0	1
12/22/2019 02:00	0.0	0	0	0	0	1
12/22/2019 03:00	0.0	0	0	0	0	1
12/22/2019 04:00	0.0	0	0	0	0	1
12/22/2019 05:00	0.0	0	0	0	0	1
12/22/2019 06:00	0.0	0	0	0	0	1
12/22/2019 07:00	0.0	0	0	0	0	1
12/22/2019 08:00	0.0	0	0	0	0	1
12/22/2019 09:00	0.0	0	0	0	0	1
12/22/2019 10:00	0.0	0	0	0	0	1
12/22/2019 11:00	0.0	0	0	0	0	1
12/22/2019 12:00	0.0	0	0	0	0	1
12/22/2019 13:00	0.0	0	0	0	0	1
12/22/2019 14:00	0.0	0	0	0	0	1
12/22/2019 15:00	0.0	0	0	0	0	1
12/22/2019 16:00	0.0	0	0	0	0	1
12/22/2019 17:00	0.0	0	0	0	0	1
12/22/2019 18:00	0.0	0	0	0	0	1
12/22/2019 19:00	0.0	0	0	0	0	1
12/22/2019 20:00	0.0	0	0	0	0	1
12/22/2019 21:00	0.0	0	0	0	0	1
12/22/2019 22:00	0.0	0	0	0	0	1
12/22/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/23/2019 00:00	0.0	0	0	0	0	1
12/23/2019 01:00	0.0	0	0	0	0	1
12/23/2019 02:00	0.0	0	0	0	0	1
12/23/2019 03:00	0.0	0	0	0	0	1
12/23/2019 04:00	0.0	0	0	0	0	1
12/23/2019 05:00	0.0	0	0	0	0	1
12/23/2019 06:00	0.0	0	0	0	0	1
12/23/2019 07:00	0.0	0	0	0	0	1
12/23/2019 08:00	0.0	0	0	0	0	1
12/23/2019 09:00	0.0	0	0	0	0	1
12/23/2019 10:00	0.0	0	0	0	0	1
12/23/2019 11:00	0.0	0	0	0	0	1
12/23/2019 12:00	0.0	0	0	0	0	1
12/23/2019 13:00	0.0	0	0	0	0	1
12/23/2019 14:00	0.0	0	0	0	0	1
12/23/2019 15:00	0.0	0	0	0	0	1
12/23/2019 16:00	0.0	0	0	0	0	1
12/23/2019 17:00	0.0	0	0	0	0	1
12/23/2019 18:00	0.0	0	0	0	0	1
12/23/2019 19:00	0.0	0	0	0	0	1
12/23/2019 20:00	0.0	0	0	0	0	1
12/23/2019 21:00	0.0	0	0	0	0	1
12/23/2019 22:00	0.0	0	0	0	0	1
12/23/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/24/2019 00:00	0.0	0	0	0	0	1
12/24/2019 01:00	0.0	0	0	0	0	1
12/24/2019 02:00	0.0	0	0	0	0	1
12/24/2019 03:00	0.0	0	0	0	0	1
12/24/2019 04:00	0.0	0	0	0	0	1
12/24/2019 05:00	0.0	0	0	0	0	1
12/24/2019 06:00	0.0	0	0	0	0	1
12/24/2019 07:00	0.0	0	0	0	0	1
12/24/2019 08:00	0.0	0	0	0	0	1
12/24/2019 09:00	0.0	0	0	0	0	1
12/24/2019 10:00	0.0	0	0	0	0	1
12/24/2019 11:00	0.0	0	0	0	0	1
12/24/2019 12:00	0.0	0	0	0	0	1
12/24/2019 13:00	0.0	0	0	0	0	1
12/24/2019 14:00	0.0	0	0	0	0	1
12/24/2019 15:00	0.0	0	0	0	0	1
12/24/2019 16:00	0.0	0	0	0	0	1
12/24/2019 17:00	0.0	0	0	0	0	1
12/24/2019 18:00	0.0	0	0	0	0	1
12/24/2019 19:00	0.0	0	0	0	0	1
12/24/2019 20:00	0.0	0	0	0	0	1
12/24/2019 21:00	0.0	0	0	0	0	1
12/24/2019 22:00	0.0	0	0	0	0	1
12/24/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/25/2019 00:00	0.0	0	0	0	0	1
12/25/2019 01:00	0.0	0	0	0	0	1
12/25/2019 02:00	0.0	0	0	0	0	1
12/25/2019 03:00	0.0	0	0	0	0	1
12/25/2019 04:00	0.0	0	0	0	0	1
12/25/2019 05:00	0.0	0	0	0	0	1
12/25/2019 06:00	0.0	0	0	0	0	1
12/25/2019 07:00	0.0	0	0	0	0	1
12/25/2019 08:00	0.0	0	0	0	0	1
12/25/2019 09:00	0.0	0	0	0	0	1
12/25/2019 10:00	0.0	0	0	0	0	1
12/25/2019 11:00	0.0	0	0	0	0	1
12/25/2019 12:00	0.0	0	0	0	0	1
12/25/2019 13:00	0.0	0	0	0	0	1
12/25/2019 14:00	0.0	0	0	0	0	1
12/25/2019 15:00	0.0	0	0	0	0	1
12/25/2019 16:00	0.0	0	0	0	0	1
12/25/2019 17:00	0.0	0	0	0	0	1
12/25/2019 18:00	0.0	0	0	0	0	1
12/25/2019 19:00	0.0	0	0	0	0	1
12/25/2019 20:00	0.0	0	0	0	0	1
12/25/2019 21:00	0.0	0	0	0	0	1
12/25/2019 22:00	0.0	0	0	0	0	1
12/25/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/26/2019 00:00	0.0	0	0	0	0	1
12/26/2019 01:00	0.0	0	0	0	0	1
12/26/2019 02:00	0.0	0	0	0	0	1
12/26/2019 03:00	0.0	0	0	0	0	1
12/26/2019 04:00	0.0	0	0	0	0	1
12/26/2019 05:00	0.0	0	0	0	0	1
12/26/2019 06:00	0.0	0	0	0	0	1
12/26/2019 07:00	0.0	0	0	0	0	1
12/26/2019 08:00	0.0	0	0	0	0	1
12/26/2019 09:00	0.0	0	0	0	0	1
12/26/2019 10:00	0.0	0	0	0	0	1
12/26/2019 11:00	0.0	0	0	0	0	1
12/26/2019 12:00	0.0	0	0	0	0	1
12/26/2019 13:00	0.0	0	0	0	0	1
12/26/2019 14:00	0.0	0	0	0	0	1
12/26/2019 15:00	0.0	0	0	0	0	1
12/26/2019 16:00	0.0	0	0	0	0	1
12/26/2019 17:00	0.0	0	0	0	0	1
12/26/2019 18:00	0.0	0	0	0	0	1
12/26/2019 19:00	0.0	0	0	0	0	1
12/26/2019 20:00	0.0	0	0	0	0	1
12/26/2019 21:00	0.0	0	0	0	0	1
12/26/2019 22:00	0.0	0	0	0	0	1
12/26/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/27/2019 00:00	0.0	0	0	0	0	1
12/27/2019 01:00	0.0	0	0	0	0	1
12/27/2019 02:00	0.0	0	0	0	0	1
12/27/2019 03:00	0.0	0	0	0	0	1
12/27/2019 04:00	0.0	0	0	0	0	1
12/27/2019 05:00	0.0	0	0	0	0	1
12/27/2019 06:00	0.0	0	0	0	0	1
12/27/2019 07:00	0.0	0	0	0	0	1
12/27/2019 08:00	0.0	0	0	0	0	1
12/27/2019 09:00	0.0	0	0	0	0	1
12/27/2019 10:00	0.0	0	0	0	0	1
12/27/2019 11:00	0.0	0	0	0	0	1
12/27/2019 12:00	0.0	0	0	0	0	1
12/27/2019 13:00	0.0	0	0	0	0	1
12/27/2019 14:00	0.0	0	0	0	0	1
12/27/2019 15:00	0.0	0	0	0	0	1
12/27/2019 16:00	0.0	0	0	0	0	1
12/27/2019 17:00	0.0	0	0	0	0	1
12/27/2019 18:00	0.0	0	0	0	0	1
12/27/2019 19:00	0.0	0	0	0	0	1
12/27/2019 20:00	0.0	0	0	0	0	1
12/27/2019 21:00	0.0	0	0	0	0	1
12/27/2019 22:00	0.0	0	0	0	0	1
12/27/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/28/2019 00:00	0.0	0	0	0	0	1
12/28/2019 01:00	0.0	0	0	0	0	1
12/28/2019 02:00	0.0	0	0	0	0	1
12/28/2019 03:00	0.0	0	0	0	0	1
12/28/2019 04:00	0.0	0	0	0	0	1
12/28/2019 05:00	0.0	0	0	0	0	1
12/28/2019 06:00	0.0	0	0	0	0	1
12/28/2019 07:00	0.0	0	0	0	0	1
12/28/2019 08:00	0.0	0	0	0	0	1
12/28/2019 09:00	0.0	0	0	0	0	1
12/28/2019 10:00	0.0	0	0	0	0	1
12/28/2019 11:00	0.0	0	0	0	0	1
12/28/2019 12:00	0.0	0	0	0	0	1
12/28/2019 13:00	0.0	0	0	0	0	1
12/28/2019 14:00	0.0	0	0	0	0	1
12/28/2019 15:00	0.0	0	0	0	0	1
12/28/2019 16:00	0.0	0	0	0	0	1
12/28/2019 17:00	0.0	0	0	0	0	1
12/28/2019 18:00	0.0	0	0	0	0	1
12/28/2019 19:00	0.0	0	0	0	0	1
12/28/2019 20:00	0.0	0	0	0	0	1
12/28/2019 21:00	0.0	0	0	0	0	1
12/28/2019 22:00	0.0	0	0	0	0	1
12/28/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/29/2019 00:00	0.0	0	0	0	0	1
12/29/2019 01:00	0.0	0	0	0	0	1
12/29/2019 02:00	0.0	0	0	0	0	1
12/29/2019 03:00	0.0	0	0	0	0	1
12/29/2019 04:00	0.0	0	0	0	0	1
12/29/2019 05:00	0.0	0	0	0	0	1
12/29/2019 06:00	0.0	0	0	0	0	1
12/29/2019 07:00	0.0	0	0	0	0	1
12/29/2019 08:00	0.0	0	0	0	0	1
12/29/2019 09:00	0.0	0	0	0	0	1
12/29/2019 10:00	0.0	0	0	0	0	1
12/29/2019 11:00	0.0	0	0	0	0	1
12/29/2019 12:00	0.0	0	0	0	0	1
12/29/2019 13:00	0.0	0	0	0	0	1
12/29/2019 14:00	0.0	0	0	0	0	1
12/29/2019 15:00	0.0	0	0	0	0	1
12/29/2019 16:00	0.0	0	0	0	0	1
12/29/2019 17:00	0.0	0	0	0	0	1
12/29/2019 18:00	0.0	0	0	0	0	1
12/29/2019 19:00	0.0	0	0	0	0	1
12/29/2019 20:00	0.0	0	0	0	0	1
12/29/2019 21:00	0.0	0	0	0	0	1
12/29/2019 22:00	0.0	0	0	0	0	1
12/29/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/30/2019 00:00	0.0	0	0	0	0	1
12/30/2019 01:00	0.0	0	0	0	0	1
12/30/2019 02:00	0.0	0	0	0	0	1
12/30/2019 03:00	0.0	0	0	0	0	1
12/30/2019 04:00	0.0	0	0	0	0	1
12/30/2019 05:00	0.0	0	0	0	0	1
12/30/2019 06:00	0.0	0	0	0	0	1
12/30/2019 07:00	0.0	0	0	0	0	1
12/30/2019 08:00	0.0	0	0	0	0	1
12/30/2019 09:00	0.0	0	0	0	0	1
12/30/2019 10:00	0.0	0	0	0	0	1
12/30/2019 11:00	0.0	0	0	0	0	1
12/30/2019 12:00	0.0	0	0	0	0	1
12/30/2019 13:00	0.0	0	0	0	0	1
12/30/2019 14:00	0.0	0	0	0	0	1
12/30/2019 15:00	0.0	0	0	0	0	1
12/30/2019 16:00	0.0	0	0	0	0	1
12/30/2019 17:00	0.0	0	0	0	0	1
12/30/2019 18:00	0.0	0	0	0	0	1
12/30/2019 19:00	0.0	0	0	0	0	1
12/30/2019 20:00	0.0	0	0	0	0	1
12/30/2019 21:00	0.0	0	0	0	0	1
12/30/2019 22:00	0.0	0	0	0	0	1
12/30/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/31/2019 00:00	0.0	0	0	0	0	1
12/31/2019 01:00	0.0	0	0	0	0	1
12/31/2019 02:00	0.0	0	0	0	0	1
12/31/2019 03:00	0.0	0	0	0	0	1
12/31/2019 04:00	0.0	0	0	0	0	1
12/31/2019 05:00	0.0	0	0	0	0	1
12/31/2019 06:00	0.0	0	0	0	0	1
12/31/2019 07:00	0.0	0	0	0	0	1
12/31/2019 08:00	0.0	0	0	0	0	1
12/31/2019 09:00	0.0	0	0	0	0	1
12/31/2019 10:00	0.0	0	0	0	0	1
12/31/2019 11:00	0.0	0	0	0	0	1
12/31/2019 12:00	0.0	0	0	0	0	1
12/31/2019 13:00	0.0	0	0	0	0	1
12/31/2019 14:00	0.0	0	0	0	0	1
12/31/2019 15:00	0.0	0	0	0	0	1
12/31/2019 16:00	0.0	0	0	0	0	1
12/31/2019 17:00	0.0	0	0	0	0	1
12/31/2019 18:00	0.0	0	0	0	0	1
12/31/2019 19:00	0.0	0	0	0	0	1
12/31/2019 20:00	0.0	0	0	0	0	1
12/31/2019 21:00	0.0	0	0	0	0	1
12/31/2019 22:00	0.0	0	0	0	0	1
12/31/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:58 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,046.47 Hours

Non-Operating Time: 161.53 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/01/2019 00:00 10/01/2019 00:04 Shut Down - Gas	5	0.2	483.5		
10/01/2019 04:30 10/01/2019 05:33 Hot Start - Gas	64	39.0	679.6		
10/03/2019 21:36 10/03/2019 21:42 Shut Down - Gas	7	1.1	483.5		
10/04/2019 13:35 10/04/2019 14:46 Warm Start - Gas	72	46.7	790.5		
10/12/2019 07:24 10/12/2019 07:29 Shut Down - Gas	6	1.0	483.5		
10/12/2019 14:33 10/12/2019 15:40 Hot Start - Gas	68	28.2	679.6		
10/13/2019 23:19 10/13/2019 23:24 Shut Down - Gas	6	0.8	483.5		
10/14/2019 06:44 10/14/2019 07:37 Hot Start - Gas	54	41.4	679.6		
10/15/2019 05:40 10/15/2019 05:45 Shut Down - Gas	6	0.8	483.5		
10/15/2019 06:36 10/15/2019 07:18 Hot Start - Gas	43	23.3	679.6		
10/16/2019 20:41 10/16/2019 21:47 Warm Start - Gas	67	55.0	790.5		
10/19/2019 07:25 10/19/2019 07:29 Shut Down - Gas	5	0.5	483.5		
10/20/2019 14:05 10/20/2019 15:42 Warm Start - Gas	98	66.7	790.5		

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:58 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,046.47 Hours

Non-Operating Time: 161.53 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/26/2019 22:23 10/26/2019 22:28 Shut Down - Gas	6	0.8	483.5		
10/28/2019 00:45 10/28/2019 01:58 Warm Start - Gas	74	77.9	790.5		
10/28/2019 23:08 10/28/2019 23:13 Shut Down - Gas	6	0.9	483.5		
10/30/2019 04:54 10/30/2019 06:55 Warm Start - Gas	122	111.0	790.5		
11/02/2019 13:16 11/02/2019 13:21 Shut Down - Gas	6	0.9	483.5		
11/02/2019 15:41 11/02/2019 16:23 Hot Start - Gas	43	23.4	679.6		
11/25/2019 00:33 11/25/2019 00:37 Shut Down - Gas	5	0.8	483.5		
11/25/2019 04:33 11/25/2019 05:28 Hot Start - Gas	56	43.3	679.6		
12/13/2019 00:46 12/13/2019 00:50 Shut Down - Gas	5	0.8	483.5		
12/13/2019 04:27 12/13/2019 05:18 Hot Start - Gas	52	32.9	679.6		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:58 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,046.47 Hours

Non-Operating Time: 161.53 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:58 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,046.47 Hours

Non-Operating Time: 161.53 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Pound Per Event Report

CT1 - NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:59 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,046.47 Hours

Non-Operating Time: 161.53 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/01/2019 00:00 10/01/2019 00:04 Shut Down - Gas	5	0.18	115.00		
10/01/2019 04:30 10/01/2019 05:33 Hot Start - Gas	64	26.44	259.90		
10/03/2019 21:36 10/03/2019 21:42 Shut Down - Gas	7	0.47	115.00		
10/04/2019 13:35 10/04/2019 14:46 Warm Start - Gas	72	95.80	456.20		
10/12/2019 07:24 10/12/2019 07:29 Shut Down - Gas	6	0.70	115.00		
10/12/2019 14:33 10/12/2019 15:40 Hot Start - Gas	68	55.66	259.90		
10/13/2019 23:19 10/13/2019 23:24 Shut Down - Gas	6	0.46	115.00		
10/14/2019 06:44 10/14/2019 07:37 Hot Start - Gas	54	33.20	259.90		
10/15/2019 05:40 10/15/2019 05:45 Shut Down - Gas	6	0.24	115.00		
10/15/2019 06:36 10/15/2019 07:18 Hot Start - Gas	43	21.84	259.90		
10/16/2019 20:41 10/16/2019 21:47 Warm Start - Gas	67	97.03	456.20		
10/19/2019 07:25 10/19/2019 07:29 Shut Down - Gas	5	0.21	115.00		
10/20/2019 14:05 10/20/2019 15:42 Warm Start - Gas	98	119.26	456.20		

Pound Per Event Report

CT1 - NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:59 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,046.47 Hours

Non-Operating Time: 161.53 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/26/2019 22:23 10/26/2019 22:28 Shut Down - Gas	6	0.34	115.00		
10/28/2019 00:45 10/28/2019 01:58 Warm Start - Gas	74	120.28	456.20		
10/28/2019 23:08 10/28/2019 23:13 Shut Down - Gas	6	0.57	115.00		
10/30/2019 04:54 10/30/2019 06:55 Warm Start - Gas	122	151.89	456.20		
11/02/2019 13:16 11/02/2019 13:21 Shut Down - Gas	6	0.41	115.00		
11/02/2019 15:41 11/02/2019 16:23 Hot Start - Gas	43	28.51	259.90		
11/25/2019 00:33 11/25/2019 00:37 Shut Down - Gas	5	0.31	115.00		
11/25/2019 04:33 11/25/2019 05:28 Hot Start - Gas	56	22.77	259.90		
12/13/2019 00:46 12/13/2019 00:50 Shut Down - Gas	5	0.27	115.00		
12/13/2019 04:27 12/13/2019 05:18 Hot Start - Gas	52	18.66	259.90		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT1 - NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:59 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,046.47 Hours

Non-Operating Time: 161.53 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT1 - NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 12:59 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,046.47 Hours

Non-Operating Time: 161.53 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:00 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,136.95 Hours

Non-Operating Time: 71.05 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
10/03/2019 21:40 10/03/2019 21:44 Shut Down - Gas	5	1.0		
10/04/2019 02:44 10/04/2019 03:42 Hot Start - Gas	59	115.0		
10/12/2019 07:25 10/12/2019 07:29 Shut Down - Gas	5	1.0		
10/12/2019 10:47 10/12/2019 12:01 Hot Start - Gas	75	130.8		
10/13/2019 23:19 10/13/2019 23:25 Shut Down - Gas	7	2.4		
10/14/2019 02:01 10/14/2019 03:02 Hot Start - Gas	62	109.8		
10/19/2019 07:25 10/19/2019 07:30 Shut Down - Gas	6	1.8		
10/19/2019 14:34 10/19/2019 15:54 Hot Start - Gas	81	142.7		
10/20/2019 02:06 10/20/2019 02:11 Shut Down - Gas	6	1.6		
10/20/2019 10:15 10/20/2019 11:44 Warm Start - Gas	90	153.4		
10/26/2019 22:23 10/26/2019 22:28 Shut Down - Gas	6	1.5		
10/27/2019 17:35 10/27/2019 19:49 Warm Start - Gas	135	244.4		
10/28/2019 23:08 10/28/2019 23:13 Shut Down - Gas	6	2.2		

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:00 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,136.95 Hours

Non-Operating Time: 71.05 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
10/30/2019 00:19 10/30/2019 02:43 Warm Start - Gas	145	262.1		
11/02/2019 13:11 11/02/2019 13:17 Shut Down - Gas	7	2.2		
11/02/2019 14:13 11/02/2019 15:04 Hot Start - Gas	52	101.5		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:00 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,136.95 Hours

Non-Operating Time: 71.05 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:00 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,136.95 Hours

Non-Operating Time: 71.05 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/01/2019 00:00	0.0	0	0	0	0	1
10/01/2019 01:00	0.0	0	0	0	0	1
10/01/2019 02:00	0.0	0	0	0	0	1
10/01/2019 03:00	0.0	0	0	0	0	1
10/01/2019 04:00	0.0	0	0	0	0	1
10/01/2019 05:00	0.0	0	0	0	0	1
10/01/2019 06:00	0.0	0	0	0	0	1
10/01/2019 07:00	0.0	0	0	0	0	1
10/01/2019 08:00	0.0	0	0	0	0	1
10/01/2019 09:00	0.0	0	0	0	0	1
10/01/2019 10:00	0.0	0	0	0	0	1
10/01/2019 11:00	0.0	0	0	0	0	1
10/01/2019 12:00	0.0	0	0	0	0	1
10/01/2019 13:00	0.0	0	0	0	0	1
10/01/2019 14:00	0.0	0	0	0	0	1
10/01/2019 15:00	0.0	0	0	0	0	1
10/01/2019 16:00	0.0	0	0	0	0	1
10/01/2019 17:00	0.0	0	0	0	0	1
10/01/2019 18:00	0.0	0	0	0	0	1
10/01/2019 19:00	0.0	0	0	0	0	1
10/01/2019 20:00	0.0	0	0	0	0	1
10/01/2019 21:00	0.0	0	0	0	0	1
10/01/2019 22:00	0.0	0	0	0	0	1
10/01/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/02/2019 00:00	0.0	0	0	0	0	1
10/02/2019 01:00	0.0	0	0	0	0	1
10/02/2019 02:00	0.0	0	0	0	0	1
10/02/2019 03:00	0.0	0	0	0	0	1
10/02/2019 04:00	0.0	0	0	0	0	1
10/02/2019 05:00	0.0	0	0	0	0	1
10/02/2019 06:00	0.0	0	0	0	0	1
10/02/2019 07:00	0.0	0	0	0	0	1
10/02/2019 08:00	0.0	0	0	0	0	1
10/02/2019 09:00	0.0	0	0	0	0	1
10/02/2019 10:00	0.0	0	0	0	0	1
10/02/2019 11:00	0.0	0	0	0	0	1
10/02/2019 12:00	0.0	0	0	0	0	1
10/02/2019 13:00	0.0	0	0	0	0	1
10/02/2019 14:00	0.0	0	0	0	0	1
10/02/2019 15:00	0.0	0	0	0	0	1
10/02/2019 16:00	0.0	0	0	0	0	1
10/02/2019 17:00	0.0	0	0	0	0	1
10/02/2019 18:00	0.0	0	0	0	0	1
10/02/2019 19:00	0.0	0	0	0	0	1
10/02/2019 20:00	0.0	0	0	0	0	1
10/02/2019 21:00	0.0	0	0	0	0	1
10/02/2019 22:00	0.0	0	0	0	0	1
10/02/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/03/2019 00:00	0.0	0	0	0	0	1
10/03/2019 01:00	0.0	0	0	0	0	1
10/03/2019 02:00	0.0	0	0	0	0	1
10/03/2019 03:00	0.0	0	0	0	0	1
10/03/2019 04:00	0.0	0	0	0	0	1
10/03/2019 05:00	0.0	0	0	0	0	1
10/03/2019 06:00	0.0	0	0	0	0	1
10/03/2019 07:00	0.0	0	0	0	0	1
10/03/2019 08:00	0.0	0	0	0	0	1
10/03/2019 09:00	0.0	0	0	0	0	1
10/03/2019 10:00	0.0	0	0	0	0	1
10/03/2019 11:00	0.0	0	0	0	0	1
10/03/2019 12:00	0.0	0	0	0	0	1
10/03/2019 13:00	0.0	0	0	0	0	1
10/03/2019 14:00	0.0	0	0	0	0	1
10/03/2019 15:00	0.0	0	0	0	0	1
10/03/2019 16:00	0.0	0	0	0	0	1
10/03/2019 17:00	0.0	0	0	0	0	1
10/03/2019 18:00	0.0	0	0	0	0	1
10/03/2019 19:00	0.0	0	0	0	0	1
10/03/2019 20:00	0.0	0	0	0	0	1
10/03/2019 21:00	0.7	0	0	0	1	0
10/03/2019 22:00	0.0	0	0	0	0	0
10/03/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.7 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/04/2019 00:00	0.0	0	0	0	0	0
10/04/2019 01:00	0.0	0	0	0	0	0
10/04/2019 02:00	5.6	0	0	1	0	0
10/04/2019 03:00	30.5	0	0	1	0	0
10/04/2019 04:00	0.0	0	0	0	0	1
10/04/2019 05:00	0.0	0	0	0	0	1
10/04/2019 06:00	0.0	0	0	0	0	1
10/04/2019 07:00	0.0	0	0	0	0	1
10/04/2019 08:00	0.0	0	0	0	0	1
10/04/2019 09:00	0.0	0	0	0	0	1
10/04/2019 10:00	0.0	0	0	0	0	1
10/04/2019 11:00	0.0	0	0	0	0	1
10/04/2019 12:00	0.0	0	0	0	0	1
10/04/2019 13:00	0.0	0	0	0	0	1
10/04/2019 14:00	0.0	0	0	0	0	1
10/04/2019 15:00	0.0	0	0	0	0	1
10/04/2019 16:00	0.0	0	0	0	0	1
10/04/2019 17:00	0.0	0	0	0	0	1
10/04/2019 18:00	0.0	0	0	0	0	1
10/04/2019 19:00	0.0	0	0	0	0	1
10/04/2019 20:00	0.0	0	0	0	0	1
10/04/2019 21:00	0.0	0	0	0	0	1
10/04/2019 22:00	0.0	0	0	0	0	1
10/04/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	36.1 #	0 #	0 #	2 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	30.5	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/05/2019 00:00	0.0	0	0	0	0	1
10/05/2019 01:00	0.0	0	0	0	0	1
10/05/2019 02:00	0.0	0	0	0	0	1
10/05/2019 03:00	0.0	0	0	0	0	1
10/05/2019 04:00	0.0	0	0	0	0	1
10/05/2019 05:00	0.0	0	0	0	0	1
10/05/2019 06:00	0.0	0	0	0	0	1
10/05/2019 07:00	0.0	0	0	0	0	1
10/05/2019 08:00	0.0	0	0	0	0	1
10/05/2019 09:00	0.0	0	0	0	0	1
10/05/2019 10:00	0.0	0	0	0	0	1
10/05/2019 11:00	0.0	0	0	0	0	1
10/05/2019 12:00	0.0	0	0	0	0	1
10/05/2019 13:00	0.0	0	0	0	0	1
10/05/2019 14:00	0.0	0	0	0	0	1
10/05/2019 15:00	0.0	0	0	0	0	1
10/05/2019 16:00	0.0	0	0	0	0	1
10/05/2019 17:00	0.0	0	0	0	0	1
10/05/2019 18:00	0.0	0	0	0	0	1
10/05/2019 19:00	0.0	0	0	0	0	1
10/05/2019 20:00	0.0	0	0	0	0	1
10/05/2019 21:00	0.0	0	0	0	0	1
10/05/2019 22:00	0.0	0	0	0	0	1
10/05/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/06/2019 00:00	0.0	0	0	0	0	1
10/06/2019 01:00	0.0	0	0	0	0	1
10/06/2019 02:00	0.0	0	0	0	0	1
10/06/2019 03:00	0.0	0	0	0	0	1
10/06/2019 04:00	0.0	0	0	0	0	1
10/06/2019 05:00	0.0	0	0	0	0	1
10/06/2019 06:00	0.0	0	0	0	0	1
10/06/2019 07:00	0.0	0	0	0	0	1
10/06/2019 08:00	0.0	0	0	0	0	1
10/06/2019 09:00	0.0	0	0	0	0	1
10/06/2019 10:00	0.0	0	0	0	0	1
10/06/2019 11:00	0.0	0	0	0	0	1
10/06/2019 12:00	0.0	0	0	0	0	1
10/06/2019 13:00	0.0	0	0	0	0	1
10/06/2019 14:00	0.0	0	0	0	0	1
10/06/2019 15:00	0.0	0	0	0	0	1
10/06/2019 16:00	0.0	0	0	0	0	1
10/06/2019 17:00	0.0	0	0	0	0	1
10/06/2019 18:00	0.0	0	0	0	0	1
10/06/2019 19:00	0.0	0	0	0	0	1
10/06/2019 20:00	0.0	0	0	0	0	1
10/06/2019 21:00	0.0	0	0	0	0	1
10/06/2019 22:00	0.0	0	0	0	0	1
10/06/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/07/2019 00:00	0.0	0	0	0	0	1
10/07/2019 01:00	0.0	0	0	0	0	1
10/07/2019 02:00	0.0	0	0	0	0	1
10/07/2019 03:00	0.0	0	0	0	0	1
10/07/2019 04:00	0.0	0	0	0	0	1
10/07/2019 05:00	0.0	0	0	0	0	1
10/07/2019 06:00	0.0	0	0	0	0	1
10/07/2019 07:00	0.0	0	0	0	0	1
10/07/2019 08:00	0.0	0	0	0	0	1
10/07/2019 09:00	0.0	0	0	0	0	1
10/07/2019 10:00	0.0	0	0	0	0	1
10/07/2019 11:00	0.0	0	0	0	0	1
10/07/2019 12:00	0.0	0	0	0	0	1
10/07/2019 13:00	0.0	0	0	0	0	1
10/07/2019 14:00	0.0	0	0	0	0	1
10/07/2019 15:00	0.0	0	0	0	0	1
10/07/2019 16:00	0.0	0	0	0	0	1
10/07/2019 17:00	0.0	0	0	0	0	1
10/07/2019 18:00	0.0	0	0	0	0	1
10/07/2019 19:00	0.0	0	0	0	0	1
10/07/2019 20:00	0.0	0	0	0	0	1
10/07/2019 21:00	0.0	0	0	0	0	1
10/07/2019 22:00	0.0	0	0	0	0	1
10/07/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/08/2019 00:00	0.0	0	0	0	0	1
10/08/2019 01:00	0.0	0	0	0	0	1
10/08/2019 02:00	0.0	0	0	0	0	1
10/08/2019 03:00	0.0	0	0	0	0	1
10/08/2019 04:00	0.0	0	0	0	0	1
10/08/2019 05:00	0.0	0	0	0	0	1
10/08/2019 06:00	0.0	0	0	0	0	1
10/08/2019 07:00	0.0	0	0	0	0	1
10/08/2019 08:00	0.0	0	0	0	0	1
10/08/2019 09:00	0.0	0	0	0	0	1
10/08/2019 10:00	0.0	0	0	0	0	1
10/08/2019 11:00	0.0	0	0	0	0	1
10/08/2019 12:00	0.0	0	0	0	0	1
10/08/2019 13:00	0.0	0	0	0	0	1
10/08/2019 14:00	0.0	0	0	0	0	1
10/08/2019 15:00	0.0	0	0	0	0	1
10/08/2019 16:00	0.0	0	0	0	0	1
10/08/2019 17:00	0.0	0	0	0	0	1
10/08/2019 18:00	0.0	0	0	0	0	1
10/08/2019 19:00	0.0	0	0	0	0	1
10/08/2019 20:00	0.0	0	0	0	0	1
10/08/2019 21:00	0.0	0	0	0	0	1
10/08/2019 22:00	0.0	0	0	0	0	1
10/08/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/09/2019 00:00	0.0	0	0	0	0	1
10/09/2019 01:00	0.0	0	0	0	0	1
10/09/2019 02:00	0.0	0	0	0	0	1
10/09/2019 03:00	0.0	0	0	0	0	1
10/09/2019 04:00	0.0	0	0	0	0	1
10/09/2019 05:00	0.0	0	0	0	0	1
10/09/2019 06:00	0.0	0	0	0	0	1
10/09/2019 07:00	0.0	0	0	0	0	1
10/09/2019 08:00	0.0	0	0	0	0	1
10/09/2019 09:00	0.0	0	0	0	0	1
10/09/2019 10:00	0.0	0	0	0	0	1
10/09/2019 11:00	0.0	0	0	0	0	1
10/09/2019 12:00	0.0	0	0	0	0	1
10/09/2019 13:00	0.0	0	0	0	0	1
10/09/2019 14:00	0.0	0	0	0	0	1
10/09/2019 15:00	0.0	0	0	0	0	1
10/09/2019 16:00	0.0	0	0	0	0	1
10/09/2019 17:00	0.0	0	0	0	0	1
10/09/2019 18:00	0.0	0	0	0	0	1
10/09/2019 19:00	0.0	0	0	0	0	1
10/09/2019 20:00	0.0	0	0	0	0	1
10/09/2019 21:00	0.0	0	0	0	0	1
10/09/2019 22:00	0.0	0	0	0	0	1
10/09/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/10/2019 00:00	0.0	0	0	0	0	1
10/10/2019 01:00	0.0	0	0	0	0	1
10/10/2019 02:00	0.0	0	0	0	0	1
10/10/2019 03:00	0.0	0	0	0	0	1
10/10/2019 04:00	0.0	0	0	0	0	1
10/10/2019 05:00	0.0	0	0	0	0	1
10/10/2019 06:00	0.0	0	0	0	0	1
10/10/2019 07:00	0.0	0	0	0	0	1
10/10/2019 08:00	0.0	0	0	0	0	1
10/10/2019 09:00	0.0	0	0	0	0	1
10/10/2019 10:00	0.0	0	0	0	0	1
10/10/2019 11:00	0.0	0	0	0	0	1
10/10/2019 12:00	0.0	0	0	0	0	1
10/10/2019 13:00	0.0	0	0	0	0	1
10/10/2019 14:00	0.0	0	0	0	0	1
10/10/2019 15:00	0.0	0	0	0	0	1
10/10/2019 16:00	0.0	0	0	0	0	1
10/10/2019 17:00	0.0	0	0	0	0	1
10/10/2019 18:00	0.0	0	0	0	0	1
10/10/2019 19:00	0.0	0	0	0	0	1
10/10/2019 20:00	0.0	0	0	0	0	1
10/10/2019 21:00	0.0	0	0	0	0	1
10/10/2019 22:00	0.0	0	0	0	0	1
10/10/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/11/2019 00:00	0.0	0	0	0	0	1
10/11/2019 01:00	0.0	0	0	0	0	1
10/11/2019 02:00	0.0	0	0	0	0	1
10/11/2019 03:00	0.0	0	0	0	0	1
10/11/2019 04:00	0.0	0	0	0	0	1
10/11/2019 05:00	0.0	0	0	0	0	1
10/11/2019 06:00	0.0	0	0	0	0	1
10/11/2019 07:00	0.0	0	0	0	0	1
10/11/2019 08:00	0.0	0	0	0	0	1
10/11/2019 09:00	0.0	0	0	0	0	1
10/11/2019 10:00	0.0	0	0	0	0	1
10/11/2019 11:00	0.0	0	0	0	0	1
10/11/2019 12:00	0.0	0	0	0	0	1
10/11/2019 13:00	0.0	0	0	0	0	1
10/11/2019 14:00	0.0	0	0	0	0	1
10/11/2019 15:00	0.0	0	0	0	0	1
10/11/2019 16:00	0.0	0	0	0	0	1
10/11/2019 17:00	0.0	0	0	0	0	1
10/11/2019 18:00	0.0	0	0	0	0	1
10/11/2019 19:00	0.0	0	0	0	0	1
10/11/2019 20:00	0.0	0	0	0	0	1
10/11/2019 21:00	0.0	0	0	0	0	1
10/11/2019 22:00	0.0	0	0	0	0	1
10/11/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/12/2019 00:00	0.0	0	0	0	0	1
10/12/2019 01:00	0.0	0	0	0	0	1
10/12/2019 02:00	0.0	0	0	0	0	1
10/12/2019 03:00	0.0	0	0	0	0	1
10/12/2019 04:00	0.0	0	0	0	0	1
10/12/2019 05:00	0.0	0	0	0	0	1
10/12/2019 06:00	0.0	0	0	0	0	1
10/12/2019 07:00	0.7	0	0	0	1	0
10/12/2019 08:00	0.0	0	0	0	0	0
10/12/2019 09:00	0.0	0	0	0	0	0
10/12/2019 10:00	1.2	0	0	1	0	0
10/12/2019 11:00	24.5	0	0	1	0	0
10/12/2019 12:00	0.0	0	0	1	0	0
10/12/2019 13:00	0.0	0	0	0	0	1
10/12/2019 14:00	0.0	0	0	0	0	1
10/12/2019 15:00	0.0	0	0	0	0	1
10/12/2019 16:00	0.0	0	0	0	0	1
10/12/2019 17:00	0.0	0	0	0	0	1
10/12/2019 18:00	0.0	0	0	0	0	1
10/12/2019 19:00	0.0	0	0	0	0	1
10/12/2019 20:00	0.0	0	0	0	0	1
10/12/2019 21:00	0.0	0	0	0	0	1
10/12/2019 22:00	0.0	0	0	0	0	1
10/12/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	26.4 #	0 #	0 #	3 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	24.5	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/13/2019 00:00	0.0	0	0	0	0	1
10/13/2019 01:00	0.0	0	0	0	0	1
10/13/2019 02:00	0.0	0	0	0	0	1
10/13/2019 03:00	0.0	0	0	0	0	1
10/13/2019 04:00	0.0	0	0	0	0	1
10/13/2019 05:00	0.0	0	0	0	0	1
10/13/2019 06:00	0.0	0	0	0	0	1
10/13/2019 07:00	0.0	0	0	0	0	1
10/13/2019 08:00	0.0	0	0	0	0	1
10/13/2019 09:00	0.0	0	0	0	0	1
10/13/2019 10:00	0.0	0	0	0	0	1
10/13/2019 11:00	0.0	0	0	0	0	1
10/13/2019 12:00	0.0	0	0	0	0	1
10/13/2019 13:00	0.0	0	0	0	0	1
10/13/2019 14:00	0.0	0	0	0	0	1
10/13/2019 15:00	0.0	0	0	0	0	1
10/13/2019 16:00	0.0	0	0	0	0	1
10/13/2019 17:00	0.0	0	0	0	0	1
10/13/2019 18:00	0.0	0	0	0	0	1
10/13/2019 19:00	0.0	0	0	0	0	1
10/13/2019 20:00	0.0	0	0	0	0	1
10/13/2019 21:00	0.0	0	0	0	0	1
10/13/2019 22:00	0.0	0	0	0	0	1
10/13/2019 23:00	1.2	0	0	0	1	0
Average/Sum#:	1.2 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/14/2019 00:00	0.0	0	0	0	0	0
10/14/2019 01:00	0.0	0	0	0	0	0
10/14/2019 02:00	24.1	0	0	1	0	0
10/14/2019 03:00	0.0	0	0	1	0	0
10/14/2019 04:00	0.0	0	0	0	0	1
10/14/2019 05:00	0.0	0	0	0	0	1
10/14/2019 06:00	0.0	0	0	0	0	1
10/14/2019 07:00	0.0	0	0	0	0	1
10/14/2019 08:00	0.0	0	0	0	0	1
10/14/2019 09:00	0.0	0	0	0	0	1
10/14/2019 10:00	0.0	0	0	0	0	1
10/14/2019 11:00	0.0	0	0	0	0	1
10/14/2019 12:00	0.0	0	0	0	0	1
10/14/2019 13:00	0.0	0	0	0	0	1
10/14/2019 14:00	0.0	0	0	0	0	1
10/14/2019 15:00	0.0	0	0	0	0	1
10/14/2019 16:00	0.0	0	0	0	0	1
10/14/2019 17:00	0.0	0	0	0	0	1
10/14/2019 18:00	0.0	0	0	0	0	1
10/14/2019 19:00	0.0	0	0	0	0	1
10/14/2019 20:00	0.0	0	0	0	0	1
10/14/2019 21:00	0.0	0	0	0	0	1
10/14/2019 22:00	0.0	0	0	0	0	1
10/14/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	24.1 #	0 #	0 #	2 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	24.1	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/15/2019 00:00	0.0	0	0	0	0	1
10/15/2019 01:00	0.0	0	0	0	0	1
10/15/2019 02:00	0.0	0	0	0	0	1
10/15/2019 03:00	0.0	0	0	0	0	1
10/15/2019 04:00	0.0	0	0	0	0	1
10/15/2019 05:00	0.0	0	0	0	0	1
10/15/2019 06:00	0.0	0	0	0	0	1
10/15/2019 07:00	0.0	0	0	0	0	1
10/15/2019 08:00	0.0	0	0	0	0	1
10/15/2019 09:00	0.0	0	0	0	0	1
10/15/2019 10:00	0.0	0	0	0	0	1
10/15/2019 11:00	0.0	0	0	0	0	1
10/15/2019 12:00	0.0	0	0	0	0	1
10/15/2019 13:00	0.0	0	0	0	0	1
10/15/2019 14:00	0.0	0	0	0	0	1
10/15/2019 15:00	0.0	0	0	0	0	1
10/15/2019 16:00	0.0	0	0	0	0	1
10/15/2019 17:00	0.0	0	0	0	0	1
10/15/2019 18:00	0.0	0	0	0	0	1
10/15/2019 19:00	0.0	0	0	0	0	1
10/15/2019 20:00	0.0	0	0	0	0	1
10/15/2019 21:00	0.0	0	0	0	0	1
10/15/2019 22:00	0.0	0	0	0	0	1
10/15/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/16/2019 00:00	0.0	0	0	0	0	1
10/16/2019 01:00	0.0	0	0	0	0	1
10/16/2019 02:00	0.0	0	0	0	0	1
10/16/2019 03:00	0.0	0	0	0	0	1
10/16/2019 04:00	0.0	0	0	0	0	1
10/16/2019 05:00	0.0	0	0	0	0	1
10/16/2019 06:00	0.0	0	0	0	0	1
10/16/2019 07:00	0.0	0	0	0	0	1
10/16/2019 08:00	0.0	0	0	0	0	1
10/16/2019 09:00	0.0	0	0	0	0	1
10/16/2019 10:00	0.0	0	0	0	0	1
10/16/2019 11:00	0.0	0	0	0	0	1
10/16/2019 12:00	0.0	0	0	0	0	1
10/16/2019 13:00	0.0	0	0	0	0	1
10/16/2019 14:00	0.0	0	0	0	0	1
10/16/2019 15:00	0.0	0	0	0	0	1
10/16/2019 16:00	0.0	0	0	0	0	1
10/16/2019 17:00	0.0	0	0	0	0	1
10/16/2019 18:00	0.0	0	0	0	0	1
10/16/2019 19:00	0.0	0	0	0	0	1
10/16/2019 20:00	0.0	0	0	0	0	1
10/16/2019 21:00	0.0	0	0	0	0	1
10/16/2019 22:00	0.0	0	0	0	0	1
10/16/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/17/2019 00:00	0.0	0	0	0	0	1
10/17/2019 01:00	0.0	0	0	0	0	1
10/17/2019 02:00	0.0	0	0	0	0	1
10/17/2019 03:00	0.0	0	0	0	0	1
10/17/2019 04:00	0.0	0	0	0	0	1
10/17/2019 05:00	0.0	0	0	0	0	1
10/17/2019 06:00	0.0	0	0	0	0	1
10/17/2019 07:00	0.0	0	0	0	0	1
10/17/2019 08:00	0.0	0	0	0	0	1
10/17/2019 09:00	0.0	0	0	0	0	1
10/17/2019 10:00	0.0	0	0	0	0	1
10/17/2019 11:00	0.0	0	0	0	0	1
10/17/2019 12:00	0.0	0	0	0	0	1
10/17/2019 13:00	0.0	0	0	0	0	1
10/17/2019 14:00	0.0	0	0	0	0	1
10/17/2019 15:00	0.0	0	0	0	0	1
10/17/2019 16:00	0.0	0	0	0	0	1
10/17/2019 17:00	0.0	0	0	0	0	1
10/17/2019 18:00	0.0	0	0	0	0	1
10/17/2019 19:00	0.0	0	0	0	0	1
10/17/2019 20:00	0.0	0	0	0	0	1
10/17/2019 21:00	0.0	0	0	0	0	1
10/17/2019 22:00	0.0	0	0	0	0	1
10/17/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/18/2019 00:00	0.0	0	0	0	0	1
10/18/2019 01:00	0.0	0	0	0	0	1
10/18/2019 02:00	0.0	0	0	0	0	1
10/18/2019 03:00	0.0	0	0	0	0	1
10/18/2019 04:00	0.0	0	0	0	0	1
10/18/2019 05:00	0.0	0	0	0	0	1
10/18/2019 06:00	0.0	0	0	0	0	1
10/18/2019 07:00	0.0	0	0	0	0	1
10/18/2019 08:00	0.0	0	0	0	0	1
10/18/2019 09:00	0.0	0	0	0	0	1
10/18/2019 10:00	0.0	0	0	0	0	1
10/18/2019 11:00	0.0	0	0	0	0	1
10/18/2019 12:00	0.0	0	0	0	0	1
10/18/2019 13:00	0.0	0	0	0	0	1
10/18/2019 14:00	0.0	0	0	0	0	1
10/18/2019 15:00	0.0	0	0	0	0	1
10/18/2019 16:00	0.0	0	0	0	0	1
10/18/2019 17:00	0.0	0	0	0	0	1
10/18/2019 18:00	0.0	0	0	0	0	1
10/18/2019 19:00	0.0	0	0	0	0	1
10/18/2019 20:00	0.0	0	0	0	0	1
10/18/2019 21:00	0.0	0	0	0	0	1
10/18/2019 22:00	0.0	0	0	0	0	1
10/18/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/19/2019 00:00	0.0	0	0	0	0	1
10/19/2019 01:00	0.0	0	0	0	0	1
10/19/2019 02:00	0.0	0	0	0	0	1
10/19/2019 03:00	0.0	0	0	0	0	1
10/19/2019 04:00	0.0	0	0	0	0	1
10/19/2019 05:00	0.0	0	0	0	0	1
10/19/2019 06:00	0.0	0	0	0	0	1
10/19/2019 07:00	1.1	0	0	0	1	0
10/19/2019 08:00	0.0	0	0	0	0	0
10/19/2019 09:00	0.0	0	0	0	0	0
10/19/2019 10:00	0.0	0	0	0	0	0
10/19/2019 11:00	0.0	0	0	0	0	0
10/19/2019 12:00	0.0	0	0	0	0	0
10/19/2019 13:00	0.0	0	0	0	0	0
10/19/2019 14:00	7.7	0	0	1	0	0
10/19/2019 15:00	28.9	0	0	1	0	0
10/19/2019 16:00	0.0	0	0	0	0	1
10/19/2019 17:00	0.0	0	0	0	0	1
10/19/2019 18:00	0.0	0	0	0	0	1
10/19/2019 19:00	0.0	0	0	0	0	1
10/19/2019 20:00	0.0	0	0	0	0	1
10/19/2019 21:00	0.0	0	0	0	0	1
10/19/2019 22:00	0.0	0	0	0	0	1
10/19/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	37.7 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	28.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/20/2019 00:00	0.0	0	0	0	0	1
10/20/2019 01:00	0.0	0	0	0	0	1
10/20/2019 02:00	1.6	0	0	0	1	0
10/20/2019 03:00	0.0	0	0	0	0	0
10/20/2019 04:00	0.0	0	0	0	0	0
10/20/2019 05:00	0.0	0	0	0	0	0
10/20/2019 06:00	0.0	0	0	0	0	0
10/20/2019 07:00	0.0	0	0	0	0	0
10/20/2019 08:00	0.0	0	0	0	0	0
10/20/2019 09:00	0.0	0	0	0	0	0
10/20/2019 10:00	16.9	0	1	0	0	0
10/20/2019 11:00	19.7	0	1	0	0	0
10/20/2019 12:00	0.0	0	0	0	0	1
10/20/2019 13:00	0.0	0	0	0	0	1
10/20/2019 14:00	0.0	0	0	0	0	1
10/20/2019 15:00	0.0	0	0	0	0	1
10/20/2019 16:00	0.0	0	0	0	0	1
10/20/2019 17:00	0.0	0	0	0	0	1
10/20/2019 18:00	0.0	0	0	0	0	1
10/20/2019 19:00	0.0	0	0	0	0	1
10/20/2019 20:00	0.0	0	0	0	0	1
10/20/2019 21:00	0.0	0	0	0	0	1
10/20/2019 22:00	0.0	0	0	0	0	1
10/20/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	38.2 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	19.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/21/2019 00:00	0.0	0	0	0	0	1
10/21/2019 01:00	0.0	0	0	0	0	1
10/21/2019 02:00	0.0	0	0	0	0	1
10/21/2019 03:00	0.0	0	0	0	0	1
10/21/2019 04:00	0.0	0	0	0	0	1
10/21/2019 05:00	0.0	0	0	0	0	1
10/21/2019 06:00	0.0	0	0	0	0	1
10/21/2019 07:00	0.0	0	0	0	0	1
10/21/2019 08:00	0.0	0	0	0	0	1
10/21/2019 09:00	0.0	0	0	0	0	1
10/21/2019 10:00	0.0	0	0	0	0	1
10/21/2019 11:00	0.0	0	0	0	0	1
10/21/2019 12:00	0.0	0	0	0	0	1
10/21/2019 13:00	0.0	0	0	0	0	1
10/21/2019 14:00	0.0	0	0	0	0	1
10/21/2019 15:00	0.0	0	0	0	0	1
10/21/2019 16:00	0.0	0	0	0	0	1
10/21/2019 17:00	0.0	0	0	0	0	1
10/21/2019 18:00	0.0	0	0	0	0	1
10/21/2019 19:00	0.0	0	0	0	0	1
10/21/2019 20:00	0.0	0	0	0	0	1
10/21/2019 21:00	0.0	0	0	0	0	1
10/21/2019 22:00	0.0	0	0	0	0	1
10/21/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/22/2019 00:00	0.0	0	0	0	0	1
10/22/2019 01:00	0.0	0	0	0	0	1
10/22/2019 02:00	0.0	0	0	0	0	1
10/22/2019 03:00	0.0	0	0	0	0	1
10/22/2019 04:00	0.0	0	0	0	0	1
10/22/2019 05:00	0.0	0	0	0	0	1
10/22/2019 06:00	0.0	0	0	0	0	1
10/22/2019 07:00	0.0	0	0	0	0	1
10/22/2019 08:00	0.0	0	0	0	0	1
10/22/2019 09:00	0.0	0	0	0	0	1
10/22/2019 10:00	0.0	0	0	0	0	1
10/22/2019 11:00	0.0	0	0	0	0	1
10/22/2019 12:00	0.0	0	0	0	0	1
10/22/2019 13:00	0.0	0	0	0	0	1
10/22/2019 14:00	0.0	0	0	0	0	1
10/22/2019 15:00	0.0	0	0	0	0	1
10/22/2019 16:00	0.0	0	0	0	0	1
10/22/2019 17:00	0.0	0	0	0	0	1
10/22/2019 18:00	0.0	0	0	0	0	1
10/22/2019 19:00	0.0	0	0	0	0	1
10/22/2019 20:00	0.0	0	0	0	0	1
10/22/2019 21:00	0.0	0	0	0	0	1
10/22/2019 22:00	0.0	0	0	0	0	1
10/22/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/23/2019 00:00	0.0	0	0	0	0	1
10/23/2019 01:00	0.0	0	0	0	0	1
10/23/2019 02:00	0.0	0	0	0	0	1
10/23/2019 03:00	0.0	0	0	0	0	1
10/23/2019 04:00	0.0	0	0	0	0	1
10/23/2019 05:00	0.0	0	0	0	0	1
10/23/2019 06:00	0.0	0	0	0	0	1
10/23/2019 07:00	0.0	0	0	0	0	1
10/23/2019 08:00	0.0	0	0	0	0	1
10/23/2019 09:00	0.0	0	0	0	0	1
10/23/2019 10:00	0.0	0	0	0	0	1
10/23/2019 11:00	0.0	0	0	0	0	1
10/23/2019 12:00	0.0	0	0	0	0	1
10/23/2019 13:00	0.0	0	0	0	0	1
10/23/2019 14:00	0.0	0	0	0	0	1
10/23/2019 15:00	0.0	0	0	0	0	1
10/23/2019 16:00	0.0	0	0	0	0	1
10/23/2019 17:00	0.0	0	0	0	0	1
10/23/2019 18:00	0.0	0	0	0	0	1
10/23/2019 19:00	0.0	0	0	0	0	1
10/23/2019 20:00	0.0	0	0	0	0	1
10/23/2019 21:00	0.0	0	0	0	0	1
10/23/2019 22:00	0.0	0	0	0	0	1
10/23/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/24/2019 00:00	0.0	0	0	0	0	1
10/24/2019 01:00	0.0	0	0	0	0	1
10/24/2019 02:00	0.0	0	0	0	0	1
10/24/2019 03:00	0.0	0	0	0	0	1
10/24/2019 04:00	0.0	0	0	0	0	1
10/24/2019 05:00	0.0	0	0	0	0	1
10/24/2019 06:00	0.0	0	0	0	0	1
10/24/2019 07:00	0.0	0	0	0	0	1
10/24/2019 08:00	0.0	0	0	0	0	1
10/24/2019 09:00	0.0	0	0	0	0	1
10/24/2019 10:00	0.0	0	0	0	0	1
10/24/2019 11:00	0.0	0	0	0	0	1
10/24/2019 12:00	0.0	0	0	0	0	1
10/24/2019 13:00	0.0	0	0	0	0	1
10/24/2019 14:00	0.0	0	0	0	0	1
10/24/2019 15:00	0.0	0	0	0	0	1
10/24/2019 16:00	0.0	0	0	0	0	1
10/24/2019 17:00	0.0	0	0	0	0	1
10/24/2019 18:00	0.0	0	0	0	0	1
10/24/2019 19:00	0.0	0	0	0	0	1
10/24/2019 20:00	0.0	0	0	0	0	1
10/24/2019 21:00	0.0	0	0	0	0	1
10/24/2019 22:00	0.0	0	0	0	0	1
10/24/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/25/2019 00:00	0.0	0	0	0	0	1
10/25/2019 01:00	0.0	0	0	0	0	1
10/25/2019 02:00	0.0	0	0	0	0	1
10/25/2019 03:00	0.0	0	0	0	0	1
10/25/2019 04:00	0.0	0	0	0	0	1
10/25/2019 05:00	0.0	0	0	0	0	1
10/25/2019 06:00	0.0	0	0	0	0	1
10/25/2019 07:00	0.0	0	0	0	0	1
10/25/2019 08:00	0.0	0	0	0	0	1
10/25/2019 09:00	0.0	0	0	0	0	1
10/25/2019 10:00	0.0	0	0	0	0	1
10/25/2019 11:00	0.0	0	0	0	0	1
10/25/2019 12:00	0.0	0	0	0	0	1
10/25/2019 13:00	0.0	0	0	0	0	1
10/25/2019 14:00	0.0	0	0	0	0	1
10/25/2019 15:00	0.0	0	0	0	0	1
10/25/2019 16:00	0.0	0	0	0	0	1
10/25/2019 17:00	0.0	0	0	0	0	1
10/25/2019 18:00	0.0	0	0	0	0	1
10/25/2019 19:00	0.0	0	0	0	0	1
10/25/2019 20:00	0.0	0	0	0	0	1
10/25/2019 21:00	0.0	0	0	0	0	1
10/25/2019 22:00	0.0	0	0	0	0	1
10/25/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/26/2019 00:00	0.0	0	0	0	0	1
10/26/2019 01:00	0.0	0	0	0	0	1
10/26/2019 02:00	0.0	0	0	0	0	1
10/26/2019 03:00	0.0	0	0	0	0	1
10/26/2019 04:00	0.0	0	0	0	0	1
10/26/2019 05:00	0.0	0	0	0	0	1
10/26/2019 06:00	0.0	0	0	0	0	1
10/26/2019 07:00	0.0	0	0	0	0	1
10/26/2019 08:00	0.0	0	0	0	0	1
10/26/2019 09:00	0.0	0	0	0	0	1
10/26/2019 10:00	0.0	0	0	0	0	1
10/26/2019 11:00	0.0	0	0	0	0	1
10/26/2019 12:00	0.0	0	0	0	0	1
10/26/2019 13:00	0.0	0	0	0	0	1
10/26/2019 14:00	0.0	0	0	0	0	1
10/26/2019 15:00	0.0	0	0	0	0	1
10/26/2019 16:00	0.0	0	0	0	0	1
10/26/2019 17:00	0.0	0	0	0	0	1
10/26/2019 18:00	0.0	0	0	0	0	1
10/26/2019 19:00	0.0	0	0	0	0	1
10/26/2019 20:00	0.0	0	0	0	0	1
10/26/2019 21:00	0.0	0	0	0	0	1
10/26/2019 22:00	1.3	0	0	0	1	0
10/26/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.3 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/27/2019 00:00	0.0	0	0	0	0	0
10/27/2019 01:00	0.0	0	0	0	0	0
10/27/2019 02:00	0.0	0	0	0	0	0
10/27/2019 03:00	0.0	0	0	0	0	0
10/27/2019 04:00	0.0	0	0	0	0	0
10/27/2019 05:00	0.0	0	0	0	0	0
10/27/2019 06:00	0.0	0	0	0	0	0
10/27/2019 07:00	0.0	0	0	0	0	0
10/27/2019 08:00	0.0	0	0	0	0	0
10/27/2019 09:00	0.0	0	0	0	0	0
10/27/2019 10:00	0.0	0	0	0	0	0
10/27/2019 11:00	0.0	0	0	0	0	0
10/27/2019 12:00	0.0	0	0	0	0	0
10/27/2019 13:00	0.0	0	0	0	0	0
10/27/2019 14:00	0.0	0	0	0	0	0
10/27/2019 15:00	0.0	0	0	0	0	0
10/27/2019 16:00	0.0	0	0	0	0	0
10/27/2019 17:00	47.0	0	1	0	0	0
10/27/2019 18:00	35.6	0	1	0	0	0
10/27/2019 19:00	34.4	0	1	0	0	0
10/27/2019 20:00	0.0	0	0	0	0	1
10/27/2019 21:00	0.0	0	0	0	0	1
10/27/2019 22:00	0.0	0	0	0	0	1
10/27/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	117.0 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	47.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/28/2019 00:00	0.0	0	0	0	0	1
10/28/2019 01:00	0.0	0	0	0	0	1
10/28/2019 02:00	0.0	0	0	0	0	1
10/28/2019 03:00	0.0	0	0	0	0	1
10/28/2019 04:00	0.0	0	0	0	0	1
10/28/2019 05:00	0.0	0	0	0	0	1
10/28/2019 06:00	0.0	0	0	0	0	1
10/28/2019 07:00	0.0	0	0	0	0	1
10/28/2019 08:00	0.0	0	0	0	0	1
10/28/2019 09:00	0.0	0	0	0	0	1
10/28/2019 10:00	0.0	0	0	0	0	1
10/28/2019 11:00	0.0	0	0	0	0	1
10/28/2019 12:00	0.0	0	0	0	0	1
10/28/2019 13:00	0.0	0	0	0	0	1
10/28/2019 14:00	0.0	0	0	0	0	1
10/28/2019 15:00	0.0	0	0	0	0	1
10/28/2019 16:00	0.0	0	0	0	0	1
10/28/2019 17:00	0.0	0	0	0	0	1
10/28/2019 18:00	0.0	0	0	0	0	1
10/28/2019 19:00	0.0	0	0	0	0	1
10/28/2019 20:00	0.0	0	0	0	0	1
10/28/2019 21:00	0.0	0	0	0	0	1
10/28/2019 22:00	0.0	0	0	0	0	1
10/28/2019 23:00	1.3	0	0	0	1	0
Average/Sum#:	1.3 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/29/2019 00:00	0.0	0	0	0	0	0
10/29/2019 01:00	0.0	0	0	0	0	0
10/29/2019 02:00	0.0	0	0	0	0	0
10/29/2019 03:00	0.0	0	0	0	0	0
10/29/2019 04:00	0.0	0	0	0	0	0
10/29/2019 05:00	0.0	0	0	0	0	0
10/29/2019 06:00	0.0	0	0	0	0	0
10/29/2019 07:00	0.0	0	0	0	0	0
10/29/2019 08:00	0.0	0	0	0	0	0
10/29/2019 09:00	0.0	0	0	0	0	0
10/29/2019 10:00	0.0	0	0	0	0	0
10/29/2019 11:00	0.0	0	0	0	0	0
10/29/2019 12:00	0.0	0	0	0	0	0
10/29/2019 13:00	0.0	0	0	0	0	0
10/29/2019 14:00	0.0	0	0	0	0	0
10/29/2019 15:00	0.0	0	0	0	0	0
10/29/2019 16:00	0.0	0	0	0	0	0
10/29/2019 17:00	0.0	0	0	0	0	0
10/29/2019 18:00	0.0	0	0	0	0	0
10/29/2019 19:00	0.0	0	0	0	0	0
10/29/2019 20:00	0.0	0	0	0	0	0
10/29/2019 21:00	0.0	0	0	0	0	0
10/29/2019 22:00	0.0	0	0	0	0	0
10/29/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/30/2019 00:00	64.9	0	1	0	0	0
10/30/2019 01:00	47.7	0	1	0	0	0
10/30/2019 02:00	32.0	0	1	0	0	0
10/30/2019 03:00	0.0	0	0	0	0	1
10/30/2019 04:00	0.0	0	0	0	0	1
10/30/2019 05:00	0.0	0	0	0	0	1
10/30/2019 06:00	0.0	0	0	0	0	1
10/30/2019 07:00	0.0	0	0	0	0	1
10/30/2019 08:00	0.0	0	0	0	0	1
10/30/2019 09:00	0.0	0	0	0	0	1
10/30/2019 10:00	0.0	0	0	0	0	1
10/30/2019 11:00	0.0	0	0	0	0	1
10/30/2019 12:00	0.0	0	0	0	0	1
10/30/2019 13:00	0.0	0	0	0	0	1
10/30/2019 14:00	0.0	0	0	0	0	1
10/30/2019 15:00	0.0	0	0	0	0	1
10/30/2019 16:00	0.0	0	0	0	0	1
10/30/2019 17:00	0.0	0	0	0	0	1
10/30/2019 18:00	0.0	0	0	0	0	1
10/30/2019 19:00	0.0	0	0	0	0	1
10/30/2019 20:00	0.0	0	0	0	0	1
10/30/2019 21:00	0.0	0	0	0	0	1
10/30/2019 22:00	0.0	0	0	0	0	1
10/30/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	144.6 #	0 #	3 #	0 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	64.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/31/2019 00:00	0.0	0	0	0	0	1
10/31/2019 01:00	0.0	0	0	0	0	1
10/31/2019 02:00	0.0	0	0	0	0	1
10/31/2019 03:00	0.0	0	0	0	0	1
10/31/2019 04:00	0.0	0	0	0	0	1
10/31/2019 05:00	0.0	0	0	0	0	1
10/31/2019 06:00	0.0	0	0	0	0	1
10/31/2019 07:00	0.0	0	0	0	0	1
10/31/2019 08:00	0.0	0	0	0	0	1
10/31/2019 09:00	0.0	0	0	0	0	1
10/31/2019 10:00	0.0	0	0	0	0	1
10/31/2019 11:00	0.0	0	0	0	0	1
10/31/2019 12:00	0.0	0	0	0	0	1
10/31/2019 13:00	0.0	0	0	0	0	1
10/31/2019 14:00	0.0	0	0	0	0	1
10/31/2019 15:00	0.0	0	0	0	0	1
10/31/2019 16:00	0.0	0	0	0	0	1
10/31/2019 17:00	0.0	0	0	0	0	1
10/31/2019 18:00	0.0	0	0	0	0	1
10/31/2019 19:00	0.0	0	0	0	0	1
10/31/2019 20:00	0.0	0	0	0	0	1
10/31/2019 21:00	0.0	0	0	0	0	1
10/31/2019 22:00	0.0	0	0	0	0	1
10/31/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/01/2019 00:00	0.0	0	0	0	0	1
11/01/2019 01:00	0.0	0	0	0	0	1
11/01/2019 02:00	0.0	0	0	0	0	1
11/01/2019 03:00	0.0	0	0	0	0	1
11/01/2019 04:00	0.0	0	0	0	0	1
11/01/2019 05:00	0.0	0	0	0	0	1
11/01/2019 06:00	0.0	0	0	0	0	1
11/01/2019 07:00	0.0	0	0	0	0	1
11/01/2019 08:00	0.0	0	0	0	0	1
11/01/2019 09:00	0.0	0	0	0	0	1
11/01/2019 10:00	0.0	0	0	0	0	1
11/01/2019 11:00	0.0	0	0	0	0	1
11/01/2019 12:00	0.0	0	0	0	0	1
11/01/2019 13:00	0.0	0	0	0	0	1
11/01/2019 14:00	0.0	0	0	0	0	1
11/01/2019 15:00	0.0	0	0	0	0	1
11/01/2019 16:00	0.0	0	0	0	0	1
11/01/2019 17:00	0.0	0	0	0	0	1
11/01/2019 18:00	0.0	0	0	0	0	1
11/01/2019 19:00	0.0	0	0	0	0	1
11/01/2019 20:00	0.0	0	0	0	0	1
11/01/2019 21:00	0.0	0	0	0	0	1
11/01/2019 22:00	0.0	0	0	0	0	1
11/01/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/02/2019 00:00	0.0	0	0	0	0	1
11/02/2019 01:00	0.0	0	0	0	0	1
11/02/2019 02:00	0.0	0	0	0	0	1
11/02/2019 03:00	0.0	0	0	0	0	1
11/02/2019 04:00	0.0	0	0	0	0	1
11/02/2019 05:00	0.0	0	0	0	0	1
11/02/2019 06:00	0.0	0	0	0	0	1
11/02/2019 07:00	0.0	0	0	0	0	1
11/02/2019 08:00	0.0	0	0	0	0	1
11/02/2019 09:00	0.0	0	0	0	0	1
11/02/2019 10:00	0.0	0	0	0	0	1
11/02/2019 11:00	0.0	0	0	0	0	1
11/02/2019 12:00	0.0	0	0	0	0	1
11/02/2019 13:00	1.6	0	0	0	1	0
11/02/2019 14:00	25.6	0	0	1	0	0
11/02/2019 15:00	0.0	0	0	1	0	0
11/02/2019 16:00	0.0	0	0	0	0	1
11/02/2019 17:00	0.0	0	0	0	0	1
11/02/2019 18:00	0.0	0	0	0	0	1
11/02/2019 19:00	0.0	0	0	0	0	1
11/02/2019 20:00	0.0	0	0	0	0	1
11/02/2019 21:00	0.0	0	0	0	0	1
11/02/2019 22:00	0.0	0	0	0	0	1
11/02/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	27.2 #	0 #	0 #	2 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	25.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/03/2019 00:00	0.0	0	0	0	0	1
11/03/2019 01:00	0.0	0	0	0	0	1
11/03/2019 02:00	0.0	0	0	0	0	1
11/03/2019 03:00	0.0	0	0	0	0	1
11/03/2019 04:00	0.0	0	0	0	0	1
11/03/2019 05:00	0.0	0	0	0	0	1
11/03/2019 06:00	0.0	0	0	0	0	1
11/03/2019 07:00	0.0	0	0	0	0	1
11/03/2019 08:00	0.0	0	0	0	0	1
11/03/2019 09:00	0.0	0	0	0	0	1
11/03/2019 10:00	0.0	0	0	0	0	1
11/03/2019 11:00	0.0	0	0	0	0	1
11/03/2019 12:00	0.0	0	0	0	0	1
11/03/2019 13:00	0.0	0	0	0	0	1
11/03/2019 14:00	0.0	0	0	0	0	1
11/03/2019 15:00	0.0	0	0	0	0	1
11/03/2019 16:00	0.0	0	0	0	0	1
11/03/2019 17:00	0.0	0	0	0	0	1
11/03/2019 18:00	0.0	0	0	0	0	1
11/03/2019 19:00	0.0	0	0	0	0	1
11/03/2019 20:00	0.0	0	0	0	0	1
11/03/2019 21:00	0.0	0	0	0	0	1
11/03/2019 22:00	0.0	0	0	0	0	1
11/03/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/04/2019 00:00	0.0	0	0	0	0	1
11/04/2019 01:00	0.0	0	0	0	0	1
11/04/2019 02:00	0.0	0	0	0	0	1
11/04/2019 03:00	0.0	0	0	0	0	1
11/04/2019 04:00	0.0	0	0	0	0	1
11/04/2019 05:00	0.0	0	0	0	0	1
11/04/2019 06:00	0.0	0	0	0	0	1
11/04/2019 07:00	0.0	0	0	0	0	1
11/04/2019 08:00	0.0	0	0	0	0	1
11/04/2019 09:00	0.0	0	0	0	0	1
11/04/2019 10:00	0.0	0	0	0	0	1
11/04/2019 11:00	0.0	0	0	0	0	1
11/04/2019 12:00	0.0	0	0	0	0	1
11/04/2019 13:00	0.0	0	0	0	0	1
11/04/2019 14:00	0.0	0	0	0	0	1
11/04/2019 15:00	0.0	0	0	0	0	1
11/04/2019 16:00	0.0	0	0	0	0	1
11/04/2019 17:00	0.0	0	0	0	0	1
11/04/2019 18:00	0.0	0	0	0	0	1
11/04/2019 19:00	0.0	0	0	0	0	1
11/04/2019 20:00	0.0	0	0	0	0	1
11/04/2019 21:00	0.0	0	0	0	0	1
11/04/2019 22:00	0.0	0	0	0	0	1
11/04/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/05/2019 00:00	0.0	0	0	0	0	1
11/05/2019 01:00	0.0	0	0	0	0	1
11/05/2019 02:00	0.0	0	0	0	0	1
11/05/2019 03:00	0.0	0	0	0	0	1
11/05/2019 04:00	0.0	0	0	0	0	1
11/05/2019 05:00	0.0	0	0	0	0	1
11/05/2019 06:00	0.0	0	0	0	0	1
11/05/2019 07:00	0.0	0	0	0	0	1
11/05/2019 08:00	0.0	0	0	0	0	1
11/05/2019 09:00	0.0	0	0	0	0	1
11/05/2019 10:00	0.0	0	0	0	0	1
11/05/2019 11:00	0.0	0	0	0	0	1
11/05/2019 12:00	0.0	0	0	0	0	1
11/05/2019 13:00	0.0	0	0	0	0	1
11/05/2019 14:00	0.0	0	0	0	0	1
11/05/2019 15:00	0.0	0	0	0	0	1
11/05/2019 16:00	0.0	0	0	0	0	1
11/05/2019 17:00	0.0	0	0	0	0	1
11/05/2019 18:00	0.0	0	0	0	0	1
11/05/2019 19:00	0.0	0	0	0	0	1
11/05/2019 20:00	0.0	0	0	0	0	1
11/05/2019 21:00	0.0	0	0	0	0	1
11/05/2019 22:00	0.0	0	0	0	0	1
11/05/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/06/2019 00:00	0.0	0	0	0	0	1
11/06/2019 01:00	0.0	0	0	0	0	1
11/06/2019 02:00	0.0	0	0	0	0	1
11/06/2019 03:00	0.0	0	0	0	0	1
11/06/2019 04:00	0.0	0	0	0	0	1
11/06/2019 05:00	0.0	0	0	0	0	1
11/06/2019 06:00	0.0	0	0	0	0	1
11/06/2019 07:00	0.0	0	0	0	0	1
11/06/2019 08:00	0.0	0	0	0	0	1
11/06/2019 09:00	0.0	0	0	0	0	1
11/06/2019 10:00	0.0	0	0	0	0	1
11/06/2019 11:00	0.0	0	0	0	0	1
11/06/2019 12:00	0.0	0	0	0	0	1
11/06/2019 13:00	0.0	0	0	0	0	1
11/06/2019 14:00	0.0	0	0	0	0	1
11/06/2019 15:00	0.0	0	0	0	0	1
11/06/2019 16:00	0.0	0	0	0	0	1
11/06/2019 17:00	0.0	0	0	0	0	1
11/06/2019 18:00	0.0	0	0	0	0	1
11/06/2019 19:00	0.0	0	0	0	0	1
11/06/2019 20:00	0.0	0	0	0	0	1
11/06/2019 21:00	0.0	0	0	0	0	1
11/06/2019 22:00	0.0	0	0	0	0	1
11/06/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/07/2019 00:00	0.0	0	0	0	0	1
11/07/2019 01:00	0.0	0	0	0	0	1
11/07/2019 02:00	0.0	0	0	0	0	1
11/07/2019 03:00	0.0	0	0	0	0	1
11/07/2019 04:00	0.0	0	0	0	0	1
11/07/2019 05:00	0.0	0	0	0	0	1
11/07/2019 06:00	0.0	0	0	0	0	1
11/07/2019 07:00	0.0	0	0	0	0	1
11/07/2019 08:00	0.0	0	0	0	0	1
11/07/2019 09:00	0.0	0	0	0	0	1
11/07/2019 10:00	0.0	0	0	0	0	1
11/07/2019 11:00	0.0	0	0	0	0	1
11/07/2019 12:00	0.0	0	0	0	0	1
11/07/2019 13:00	0.0	0	0	0	0	1
11/07/2019 14:00	0.0	0	0	0	0	1
11/07/2019 15:00	0.0	0	0	0	0	1
11/07/2019 16:00	0.0	0	0	0	0	1
11/07/2019 17:00	0.0	0	0	0	0	1
11/07/2019 18:00	0.0	0	0	0	0	1
11/07/2019 19:00	0.0	0	0	0	0	1
11/07/2019 20:00	0.0	0	0	0	0	1
11/07/2019 21:00	0.0	0	0	0	0	1
11/07/2019 22:00	0.0	0	0	0	0	1
11/07/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/08/2019 00:00	0.0	0	0	0	0	1
11/08/2019 01:00	0.0	0	0	0	0	1
11/08/2019 02:00	0.0	0	0	0	0	1
11/08/2019 03:00	0.0	0	0	0	0	1
11/08/2019 04:00	0.0	0	0	0	0	1
11/08/2019 05:00	0.0	0	0	0	0	1
11/08/2019 06:00	0.0	0	0	0	0	1
11/08/2019 07:00	0.0	0	0	0	0	1
11/08/2019 08:00	0.0	0	0	0	0	1
11/08/2019 09:00	0.0	0	0	0	0	1
11/08/2019 10:00	0.0	0	0	0	0	1
11/08/2019 11:00	0.0	0	0	0	0	1
11/08/2019 12:00	0.0	0	0	0	0	1
11/08/2019 13:00	0.0	0	0	0	0	1
11/08/2019 14:00	0.0	0	0	0	0	1
11/08/2019 15:00	0.0	0	0	0	0	1
11/08/2019 16:00	0.0	0	0	0	0	1
11/08/2019 17:00	0.0	0	0	0	0	1
11/08/2019 18:00	0.0	0	0	0	0	1
11/08/2019 19:00	0.0	0	0	0	0	1
11/08/2019 20:00	0.0	0	0	0	0	1
11/08/2019 21:00	0.0	0	0	0	0	1
11/08/2019 22:00	0.0	0	0	0	0	1
11/08/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/09/2019 00:00	0.0	0	0	0	0	1
11/09/2019 01:00	0.0	0	0	0	0	1
11/09/2019 02:00	0.0	0	0	0	0	1
11/09/2019 03:00	0.0	0	0	0	0	1
11/09/2019 04:00	0.0	0	0	0	0	1
11/09/2019 05:00	0.0	0	0	0	0	1
11/09/2019 06:00	0.0	0	0	0	0	1
11/09/2019 07:00	0.0	0	0	0	0	1
11/09/2019 08:00	0.0	0	0	0	0	1
11/09/2019 09:00	0.0	0	0	0	0	1
11/09/2019 10:00	0.0	0	0	0	0	1
11/09/2019 11:00	0.0	0	0	0	0	1
11/09/2019 12:00	0.0	0	0	0	0	1
11/09/2019 13:00	0.0	0	0	0	0	1
11/09/2019 14:00	0.0	0	0	0	0	1
11/09/2019 15:00	0.0	0	0	0	0	1
11/09/2019 16:00	0.0	0	0	0	0	1
11/09/2019 17:00	0.0	0	0	0	0	1
11/09/2019 18:00	0.0	0	0	0	0	1
11/09/2019 19:00	0.0	0	0	0	0	1
11/09/2019 20:00	0.0	0	0	0	0	1
11/09/2019 21:00	0.0	0	0	0	0	1
11/09/2019 22:00	0.0	0	0	0	0	1
11/09/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/10/2019 00:00	0.0	0	0	0	0	1
11/10/2019 01:00	0.0	0	0	0	0	1
11/10/2019 02:00	0.0	0	0	0	0	1
11/10/2019 03:00	0.0	0	0	0	0	1
11/10/2019 04:00	0.0	0	0	0	0	1
11/10/2019 05:00	0.0	0	0	0	0	1
11/10/2019 06:00	0.0	0	0	0	0	1
11/10/2019 07:00	0.0	0	0	0	0	1
11/10/2019 08:00	0.0	0	0	0	0	1
11/10/2019 09:00	0.0	0	0	0	0	1
11/10/2019 10:00	0.0	0	0	0	0	1
11/10/2019 11:00	0.0	0	0	0	0	1
11/10/2019 12:00	0.0	0	0	0	0	1
11/10/2019 13:00	0.0	0	0	0	0	1
11/10/2019 14:00	0.0	0	0	0	0	1
11/10/2019 15:00	0.0	0	0	0	0	1
11/10/2019 16:00	0.0	0	0	0	0	1
11/10/2019 17:00	0.0	0	0	0	0	1
11/10/2019 18:00	0.0	0	0	0	0	1
11/10/2019 19:00	0.0	0	0	0	0	1
11/10/2019 20:00	0.0	0	0	0	0	1
11/10/2019 21:00	0.0	0	0	0	0	1
11/10/2019 22:00	0.0	0	0	0	0	1
11/10/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/11/2019 00:00	0.0	0	0	0	0	1
11/11/2019 01:00	0.0	0	0	0	0	1
11/11/2019 02:00	0.0	0	0	0	0	1
11/11/2019 03:00	0.0	0	0	0	0	1
11/11/2019 04:00	0.0	0	0	0	0	1
11/11/2019 05:00	0.0	0	0	0	0	1
11/11/2019 06:00	0.0	0	0	0	0	1
11/11/2019 07:00	0.0	0	0	0	0	1
11/11/2019 08:00	0.0	0	0	0	0	1
11/11/2019 09:00	0.0	0	0	0	0	1
11/11/2019 10:00	0.0	0	0	0	0	1
11/11/2019 11:00	0.0	0	0	0	0	1
11/11/2019 12:00	0.0	0	0	0	0	1
11/11/2019 13:00	0.0	0	0	0	0	1
11/11/2019 14:00	0.0	0	0	0	0	1
11/11/2019 15:00	0.0	0	0	0	0	1
11/11/2019 16:00	0.0	0	0	0	0	1
11/11/2019 17:00	0.0	0	0	0	0	1
11/11/2019 18:00	0.0	0	0	0	0	1
11/11/2019 19:00	0.0	0	0	0	0	1
11/11/2019 20:00	0.0	0	0	0	0	1
11/11/2019 21:00	0.0	0	0	0	0	1
11/11/2019 22:00	0.0	0	0	0	0	1
11/11/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/12/2019 00:00	0.0	0	0	0	0	1
11/12/2019 01:00	0.0	0	0	0	0	1
11/12/2019 02:00	0.0	0	0	0	0	1
11/12/2019 03:00	0.0	0	0	0	0	1
11/12/2019 04:00	0.0	0	0	0	0	1
11/12/2019 05:00	0.0	0	0	0	0	1
11/12/2019 06:00	0.0	0	0	0	0	1
11/12/2019 07:00	0.0	0	0	0	0	1
11/12/2019 08:00	0.0	0	0	0	0	1
11/12/2019 09:00	0.0	0	0	0	0	1
11/12/2019 10:00	0.0	0	0	0	0	1
11/12/2019 11:00	0.0	0	0	0	0	1
11/12/2019 12:00	0.0	0	0	0	0	1
11/12/2019 13:00	0.0	0	0	0	0	1
11/12/2019 14:00	0.0	0	0	0	0	1
11/12/2019 15:00	0.0	0	0	0	0	1
11/12/2019 16:00	0.0	0	0	0	0	1
11/12/2019 17:00	0.0	0	0	0	0	1
11/12/2019 18:00	0.0	0	0	0	0	1
11/12/2019 19:00	0.0	0	0	0	0	1
11/12/2019 20:00	0.0	0	0	0	0	1
11/12/2019 21:00	0.0	0	0	0	0	1
11/12/2019 22:00	0.0	0	0	0	0	1
11/12/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/13/2019 00:00	0.0	0	0	0	0	1
11/13/2019 01:00	0.0	0	0	0	0	1
11/13/2019 02:00	0.0	0	0	0	0	1
11/13/2019 03:00	0.0	0	0	0	0	1
11/13/2019 04:00	0.0	0	0	0	0	1
11/13/2019 05:00	0.0	0	0	0	0	1
11/13/2019 06:00	0.0	0	0	0	0	1
11/13/2019 07:00	0.0	0	0	0	0	1
11/13/2019 08:00	0.0	0	0	0	0	1
11/13/2019 09:00	0.0	0	0	0	0	1
11/13/2019 10:00	0.0	0	0	0	0	1
11/13/2019 11:00	0.0	0	0	0	0	1
11/13/2019 12:00	0.0	0	0	0	0	1
11/13/2019 13:00	0.0	0	0	0	0	1
11/13/2019 14:00	0.0	0	0	0	0	1
11/13/2019 15:00	0.0	0	0	0	0	1
11/13/2019 16:00	0.0	0	0	0	0	1
11/13/2019 17:00	0.0	0	0	0	0	1
11/13/2019 18:00	0.0	0	0	0	0	1
11/13/2019 19:00	0.0	0	0	0	0	1
11/13/2019 20:00	0.0	0	0	0	0	1
11/13/2019 21:00	0.0	0	0	0	0	1
11/13/2019 22:00	0.0	0	0	0	0	1
11/13/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/14/2019 00:00	0.0	0	0	0	0	1
11/14/2019 01:00	0.0	0	0	0	0	1
11/14/2019 02:00	0.0	0	0	0	0	1
11/14/2019 03:00	0.0	0	0	0	0	1
11/14/2019 04:00	0.0	0	0	0	0	1
11/14/2019 05:00	0.0	0	0	0	0	1
11/14/2019 06:00	0.0	0	0	0	0	1
11/14/2019 07:00	0.0	0	0	0	0	1
11/14/2019 08:00	0.0	0	0	0	0	1
11/14/2019 09:00	0.0	0	0	0	0	1
11/14/2019 10:00	0.0	0	0	0	0	1
11/14/2019 11:00	0.0	0	0	0	0	1
11/14/2019 12:00	0.0	0	0	0	0	1
11/14/2019 13:00	0.0	0	0	0	0	1
11/14/2019 14:00	0.0	0	0	0	0	1
11/14/2019 15:00	0.0	0	0	0	0	1
11/14/2019 16:00	0.0	0	0	0	0	1
11/14/2019 17:00	0.0	0	0	0	0	1
11/14/2019 18:00	0.0	0	0	0	0	1
11/14/2019 19:00	0.0	0	0	0	0	1
11/14/2019 20:00	0.0	0	0	0	0	1
11/14/2019 21:00	0.0	0	0	0	0	1
11/14/2019 22:00	0.0	0	0	0	0	1
11/14/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/15/2019 00:00	0.0	0	0	0	0	1
11/15/2019 01:00	0.0	0	0	0	0	1
11/15/2019 02:00	0.0	0	0	0	0	1
11/15/2019 03:00	0.0	0	0	0	0	1
11/15/2019 04:00	0.0	0	0	0	0	1
11/15/2019 05:00	0.0	0	0	0	0	1
11/15/2019 06:00	0.0	0	0	0	0	1
11/15/2019 07:00	0.0	0	0	0	0	1
11/15/2019 08:00	0.0	0	0	0	0	1
11/15/2019 09:00	0.0	0	0	0	0	1
11/15/2019 10:00	0.0	0	0	0	0	1
11/15/2019 11:00	0.0	0	0	0	0	1
11/15/2019 12:00	0.0	0	0	0	0	1
11/15/2019 13:00	0.0	0	0	0	0	1
11/15/2019 14:00	0.0	0	0	0	0	1
11/15/2019 15:00	0.0	0	0	0	0	1
11/15/2019 16:00	0.0	0	0	0	0	1
11/15/2019 17:00	0.0	0	0	0	0	1
11/15/2019 18:00	0.0	0	0	0	0	1
11/15/2019 19:00	0.0	0	0	0	0	1
11/15/2019 20:00	0.0	0	0	0	0	1
11/15/2019 21:00	0.0	0	0	0	0	1
11/15/2019 22:00	0.0	0	0	0	0	1
11/15/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/16/2019 00:00	0.0	0	0	0	0	1
11/16/2019 01:00	0.0	0	0	0	0	1
11/16/2019 02:00	0.0	0	0	0	0	1
11/16/2019 03:00	0.0	0	0	0	0	1
11/16/2019 04:00	0.0	0	0	0	0	1
11/16/2019 05:00	0.0	0	0	0	0	1
11/16/2019 06:00	0.0	0	0	0	0	1
11/16/2019 07:00	0.0	0	0	0	0	1
11/16/2019 08:00	0.0	0	0	0	0	1
11/16/2019 09:00	0.0	0	0	0	0	1
11/16/2019 10:00	0.0	0	0	0	0	1
11/16/2019 11:00	0.0	0	0	0	0	1
11/16/2019 12:00	0.0	0	0	0	0	1
11/16/2019 13:00	0.0	0	0	0	0	1
11/16/2019 14:00	0.0	0	0	0	0	1
11/16/2019 15:00	0.0	0	0	0	0	1
11/16/2019 16:00	0.0	0	0	0	0	1
11/16/2019 17:00	0.0	0	0	0	0	1
11/16/2019 18:00	0.0	0	0	0	0	1
11/16/2019 19:00	0.0	0	0	0	0	1
11/16/2019 20:00	0.0	0	0	0	0	1
11/16/2019 21:00	0.0	0	0	0	0	1
11/16/2019 22:00	0.0	0	0	0	0	1
11/16/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/17/2019 00:00	0.0	0	0	0	0	1
11/17/2019 01:00	0.0	0	0	0	0	1
11/17/2019 02:00	0.0	0	0	0	0	1
11/17/2019 03:00	0.0	0	0	0	0	1
11/17/2019 04:00	0.0	0	0	0	0	1
11/17/2019 05:00	0.0	0	0	0	0	1
11/17/2019 06:00	0.0	0	0	0	0	1
11/17/2019 07:00	0.0	0	0	0	0	1
11/17/2019 08:00	0.0	0	0	0	0	1
11/17/2019 09:00	0.0	0	0	0	0	1
11/17/2019 10:00	0.0	0	0	0	0	1
11/17/2019 11:00	0.0	0	0	0	0	1
11/17/2019 12:00	0.0	0	0	0	0	1
11/17/2019 13:00	0.0	0	0	0	0	1
11/17/2019 14:00	0.0	0	0	0	0	1
11/17/2019 15:00	0.0	0	0	0	0	1
11/17/2019 16:00	0.0	0	0	0	0	1
11/17/2019 17:00	0.0	0	0	0	0	1
11/17/2019 18:00	0.0	0	0	0	0	1
11/17/2019 19:00	0.0	0	0	0	0	1
11/17/2019 20:00	0.0	0	0	0	0	1
11/17/2019 21:00	0.0	0	0	0	0	1
11/17/2019 22:00	0.0	0	0	0	0	1
11/17/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/18/2019 00:00	0.0	0	0	0	0	1
11/18/2019 01:00	0.0	0	0	0	0	1
11/18/2019 02:00	0.0	0	0	0	0	1
11/18/2019 03:00	0.0	0	0	0	0	1
11/18/2019 04:00	0.0	0	0	0	0	1
11/18/2019 05:00	0.0	0	0	0	0	1
11/18/2019 06:00	0.0	0	0	0	0	1
11/18/2019 07:00	0.0	0	0	0	0	1
11/18/2019 08:00	0.0	0	0	0	0	1
11/18/2019 09:00	0.0	0	0	0	0	1
11/18/2019 10:00	0.0	0	0	0	0	1
11/18/2019 11:00	0.0	0	0	0	0	1
11/18/2019 12:00	0.0	0	0	0	0	1
11/18/2019 13:00	0.0	0	0	0	0	1
11/18/2019 14:00	0.0	0	0	0	0	1
11/18/2019 15:00	0.0	0	0	0	0	1
11/18/2019 16:00	0.0	0	0	0	0	1
11/18/2019 17:00	0.0	0	0	0	0	1
11/18/2019 18:00	0.0	0	0	0	0	1
11/18/2019 19:00	0.0	0	0	0	0	1
11/18/2019 20:00	0.0	0	0	0	0	1
11/18/2019 21:00	0.0	0	0	0	0	1
11/18/2019 22:00	0.0	0	0	0	0	1
11/18/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/19/2019 00:00	0.0	0	0	0	0	1
11/19/2019 01:00	0.0	0	0	0	0	1
11/19/2019 02:00	0.0	0	0	0	0	1
11/19/2019 03:00	0.0	0	0	0	0	1
11/19/2019 04:00	0.0	0	0	0	0	1
11/19/2019 05:00	0.0	0	0	0	0	1
11/19/2019 06:00	0.0	0	0	0	0	1
11/19/2019 07:00	0.0	0	0	0	0	1
11/19/2019 08:00	0.0	0	0	0	0	1
11/19/2019 09:00	0.0	0	0	0	0	1
11/19/2019 10:00	0.0	0	0	0	0	1
11/19/2019 11:00	0.0	0	0	0	0	1
11/19/2019 12:00	0.0	0	0	0	0	1
11/19/2019 13:00	0.0	0	0	0	0	1
11/19/2019 14:00	0.0	0	0	0	0	1
11/19/2019 15:00	0.0	0	0	0	0	1
11/19/2019 16:00	0.0	0	0	0	0	1
11/19/2019 17:00	0.0	0	0	0	0	1
11/19/2019 18:00	0.0	0	0	0	0	1
11/19/2019 19:00	0.0	0	0	0	0	1
11/19/2019 20:00	0.0	0	0	0	0	1
11/19/2019 21:00	0.0	0	0	0	0	1
11/19/2019 22:00	0.0	0	0	0	0	1
11/19/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/20/2019 00:00	0.0	0	0	0	0	1
11/20/2019 01:00	0.0	0	0	0	0	1
11/20/2019 02:00	0.0	0	0	0	0	1
11/20/2019 03:00	0.0	0	0	0	0	1
11/20/2019 04:00	0.0	0	0	0	0	1
11/20/2019 05:00	0.0	0	0	0	0	1
11/20/2019 06:00	0.0	0	0	0	0	1
11/20/2019 07:00	0.0	0	0	0	0	1
11/20/2019 08:00	0.0	0	0	0	0	1
11/20/2019 09:00	0.0	0	0	0	0	1
11/20/2019 10:00	0.0	0	0	0	0	1
11/20/2019 11:00	0.0	0	0	0	0	1
11/20/2019 12:00	0.0	0	0	0	0	1
11/20/2019 13:00	0.0	0	0	0	0	1
11/20/2019 14:00	0.0	0	0	0	0	1
11/20/2019 15:00	0.0	0	0	0	0	1
11/20/2019 16:00	0.0	0	0	0	0	1
11/20/2019 17:00	0.0	0	0	0	0	1
11/20/2019 18:00	0.0	0	0	0	0	1
11/20/2019 19:00	0.0	0	0	0	0	1
11/20/2019 20:00	0.0	0	0	0	0	1
11/20/2019 21:00	0.0	0	0	0	0	1
11/20/2019 22:00	0.0	0	0	0	0	1
11/20/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/21/2019 00:00	0.0	0	0	0	0	1
11/21/2019 01:00	0.0	0	0	0	0	1
11/21/2019 02:00	0.0	0	0	0	0	1
11/21/2019 03:00	0.0	0	0	0	0	1
11/21/2019 04:00	0.0	0	0	0	0	1
11/21/2019 05:00	0.0	0	0	0	0	1
11/21/2019 06:00	0.0	0	0	0	0	1
11/21/2019 07:00	0.0	0	0	0	0	1
11/21/2019 08:00	0.0	0	0	0	0	1
11/21/2019 09:00	0.0	0	0	0	0	1
11/21/2019 10:00	0.0	0	0	0	0	1
11/21/2019 11:00	0.0	0	0	0	0	1
11/21/2019 12:00	0.0	0	0	0	0	1
11/21/2019 13:00	0.0	0	0	0	0	1
11/21/2019 14:00	0.0	0	0	0	0	1
11/21/2019 15:00	0.0	0	0	0	0	1
11/21/2019 16:00	0.0	0	0	0	0	1
11/21/2019 17:00	0.0	0	0	0	0	1
11/21/2019 18:00	0.0	0	0	0	0	1
11/21/2019 19:00	0.0	0	0	0	0	1
11/21/2019 20:00	0.0	0	0	0	0	1
11/21/2019 21:00	0.0	0	0	0	0	1
11/21/2019 22:00	0.0	0	0	0	0	1
11/21/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/22/2019 00:00	0.0	0	0	0	0	1
11/22/2019 01:00	0.0	0	0	0	0	1
11/22/2019 02:00	0.0	0	0	0	0	1
11/22/2019 03:00	0.0	0	0	0	0	1
11/22/2019 04:00	0.0	0	0	0	0	1
11/22/2019 05:00	0.0	0	0	0	0	1
11/22/2019 06:00	0.0	0	0	0	0	1
11/22/2019 07:00	0.0	0	0	0	0	1
11/22/2019 08:00	0.0	0	0	0	0	1
11/22/2019 09:00	0.0	0	0	0	0	1
11/22/2019 10:00	0.0	0	0	0	0	1
11/22/2019 11:00	0.0	0	0	0	0	1
11/22/2019 12:00	0.0	0	0	0	0	1
11/22/2019 13:00	0.0	0	0	0	0	1
11/22/2019 14:00	0.0	0	0	0	0	1
11/22/2019 15:00	0.0	0	0	0	0	1
11/22/2019 16:00	0.0	0	0	0	0	1
11/22/2019 17:00	0.0	0	0	0	0	1
11/22/2019 18:00	0.0	0	0	0	0	1
11/22/2019 19:00	0.0	0	0	0	0	1
11/22/2019 20:00	0.0	0	0	0	0	1
11/22/2019 21:00	0.0	0	0	0	0	1
11/22/2019 22:00	0.0	0	0	0	0	1
11/22/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/23/2019 00:00	0.0	0	0	0	0	1
11/23/2019 01:00	0.0	0	0	0	0	1
11/23/2019 02:00	0.0	0	0	0	0	1
11/23/2019 03:00	0.0	0	0	0	0	1
11/23/2019 04:00	0.0	0	0	0	0	1
11/23/2019 05:00	0.0	0	0	0	0	1
11/23/2019 06:00	0.0	0	0	0	0	1
11/23/2019 07:00	0.0	0	0	0	0	1
11/23/2019 08:00	0.0	0	0	0	0	1
11/23/2019 09:00	0.0	0	0	0	0	1
11/23/2019 10:00	0.0	0	0	0	0	1
11/23/2019 11:00	0.0	0	0	0	0	1
11/23/2019 12:00	0.0	0	0	0	0	1
11/23/2019 13:00	0.0	0	0	0	0	1
11/23/2019 14:00	0.0	0	0	0	0	1
11/23/2019 15:00	0.0	0	0	0	0	1
11/23/2019 16:00	0.0	0	0	0	0	1
11/23/2019 17:00	0.0	0	0	0	0	1
11/23/2019 18:00	0.0	0	0	0	0	1
11/23/2019 19:00	0.0	0	0	0	0	1
11/23/2019 20:00	0.0	0	0	0	0	1
11/23/2019 21:00	0.0	0	0	0	0	1
11/23/2019 22:00	0.0	0	0	0	0	1
11/23/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/24/2019 00:00	0.0	0	0	0	0	1
11/24/2019 01:00	0.0	0	0	0	0	1
11/24/2019 02:00	0.0	0	0	0	0	1
11/24/2019 03:00	0.0	0	0	0	0	1
11/24/2019 04:00	0.0	0	0	0	0	1
11/24/2019 05:00	0.0	0	0	0	0	1
11/24/2019 06:00	0.0	0	0	0	0	1
11/24/2019 07:00	0.0	0	0	0	0	1
11/24/2019 08:00	0.0	0	0	0	0	1
11/24/2019 09:00	0.0	0	0	0	0	1
11/24/2019 10:00	0.0	0	0	0	0	1
11/24/2019 11:00	0.0	0	0	0	0	1
11/24/2019 12:00	0.0	0	0	0	0	1
11/24/2019 13:00	0.0	0	0	0	0	1
11/24/2019 14:00	0.0	0	0	0	0	1
11/24/2019 15:00	0.0	0	0	0	0	1
11/24/2019 16:00	0.0	0	0	0	0	1
11/24/2019 17:00	0.0	0	0	0	0	1
11/24/2019 18:00	0.0	0	0	0	0	1
11/24/2019 19:00	0.0	0	0	0	0	1
11/24/2019 20:00	0.0	0	0	0	0	1
11/24/2019 21:00	0.0	0	0	0	0	1
11/24/2019 22:00	0.0	0	0	0	0	1
11/24/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/25/2019 00:00	0.0	0	0	0	0	1
11/25/2019 01:00	0.0	0	0	0	0	1
11/25/2019 02:00	0.0	0	0	0	0	1
11/25/2019 03:00	0.0	0	0	0	0	1
11/25/2019 04:00	0.0	0	0	0	0	1
11/25/2019 05:00	0.0	0	0	0	0	1
11/25/2019 06:00	0.0	0	0	0	0	1
11/25/2019 07:00	0.0	0	0	0	0	1
11/25/2019 08:00	0.0	0	0	0	0	1
11/25/2019 09:00	0.0	0	0	0	0	1
11/25/2019 10:00	0.0	0	0	0	0	1
11/25/2019 11:00	0.0	0	0	0	0	1
11/25/2019 12:00	0.0	0	0	0	0	1
11/25/2019 13:00	0.0	0	0	0	0	1
11/25/2019 14:00	0.0	0	0	0	0	1
11/25/2019 15:00	0.0	0	0	0	0	1
11/25/2019 16:00	0.0	0	0	0	0	1
11/25/2019 17:00	0.0	0	0	0	0	1
11/25/2019 18:00	0.0	0	0	0	0	1
11/25/2019 19:00	0.0	0	0	0	0	1
11/25/2019 20:00	0.0	0	0	0	0	1
11/25/2019 21:00	0.0	0	0	0	0	1
11/25/2019 22:00	0.0	0	0	0	0	1
11/25/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/26/2019 00:00	0.0	0	0	0	0	1
11/26/2019 01:00	0.0	0	0	0	0	1
11/26/2019 02:00	0.0	0	0	0	0	1
11/26/2019 03:00	0.0	0	0	0	0	1
11/26/2019 04:00	0.0	0	0	0	0	1
11/26/2019 05:00	0.0	0	0	0	0	1
11/26/2019 06:00	0.0	0	0	0	0	1
11/26/2019 07:00	0.0	0	0	0	0	1
11/26/2019 08:00	0.0	0	0	0	0	1
11/26/2019 09:00	0.0	0	0	0	0	1
11/26/2019 10:00	0.0	0	0	0	0	1
11/26/2019 11:00	0.0	0	0	0	0	1
11/26/2019 12:00	0.0	0	0	0	0	1
11/26/2019 13:00	0.0	0	0	0	0	1
11/26/2019 14:00	0.0	0	0	0	0	1
11/26/2019 15:00	0.0	0	0	0	0	1
11/26/2019 16:00	0.0	0	0	0	0	1
11/26/2019 17:00	0.0	0	0	0	0	1
11/26/2019 18:00	0.0	0	0	0	0	1
11/26/2019 19:00	0.0	0	0	0	0	1
11/26/2019 20:00	0.0	0	0	0	0	1
11/26/2019 21:00	0.0	0	0	0	0	1
11/26/2019 22:00	0.0	0	0	0	0	1
11/26/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/27/2019 00:00	0.0	0	0	0	0	1
11/27/2019 01:00	0.0	0	0	0	0	1
11/27/2019 02:00	0.0	0	0	0	0	1
11/27/2019 03:00	0.0	0	0	0	0	1
11/27/2019 04:00	0.0	0	0	0	0	1
11/27/2019 05:00	0.0	0	0	0	0	1
11/27/2019 06:00	0.0	0	0	0	0	1
11/27/2019 07:00	0.0	0	0	0	0	1
11/27/2019 08:00	0.0	0	0	0	0	1
11/27/2019 09:00	0.0	0	0	0	0	1
11/27/2019 10:00	0.0	0	0	0	0	1
11/27/2019 11:00	0.0	0	0	0	0	1
11/27/2019 12:00	0.0	0	0	0	0	1
11/27/2019 13:00	0.0	0	0	0	0	1
11/27/2019 14:00	0.0	0	0	0	0	1
11/27/2019 15:00	0.0	0	0	0	0	1
11/27/2019 16:00	0.0	0	0	0	0	1
11/27/2019 17:00	0.0	0	0	0	0	1
11/27/2019 18:00	0.0	0	0	0	0	1
11/27/2019 19:00	0.0	0	0	0	0	1
11/27/2019 20:00	0.0	0	0	0	0	1
11/27/2019 21:00	0.0	0	0	0	0	1
11/27/2019 22:00	0.0	0	0	0	0	1
11/27/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/28/2019 00:00	0.0	0	0	0	0	1
11/28/2019 01:00	0.0	0	0	0	0	1
11/28/2019 02:00	0.0	0	0	0	0	1
11/28/2019 03:00	0.0	0	0	0	0	1
11/28/2019 04:00	0.0	0	0	0	0	1
11/28/2019 05:00	0.0	0	0	0	0	1
11/28/2019 06:00	0.0	0	0	0	0	1
11/28/2019 07:00	0.0	0	0	0	0	1
11/28/2019 08:00	0.0	0	0	0	0	1
11/28/2019 09:00	0.0	0	0	0	0	1
11/28/2019 10:00	0.0	0	0	0	0	1
11/28/2019 11:00	0.0	0	0	0	0	1
11/28/2019 12:00	0.0	0	0	0	0	1
11/28/2019 13:00	0.0	0	0	0	0	1
11/28/2019 14:00	0.0	0	0	0	0	1
11/28/2019 15:00	0.0	0	0	0	0	1
11/28/2019 16:00	0.0	0	0	0	0	1
11/28/2019 17:00	0.0	0	0	0	0	1
11/28/2019 18:00	0.0	0	0	0	0	1
11/28/2019 19:00	0.0	0	0	0	0	1
11/28/2019 20:00	0.0	0	0	0	0	1
11/28/2019 21:00	0.0	0	0	0	0	1
11/28/2019 22:00	0.0	0	0	0	0	1
11/28/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/29/2019 00:00	0.0	0	0	0	0	1
11/29/2019 01:00	0.0	0	0	0	0	1
11/29/2019 02:00	0.0	0	0	0	0	1
11/29/2019 03:00	0.0	0	0	0	0	1
11/29/2019 04:00	0.0	0	0	0	0	1
11/29/2019 05:00	0.0	0	0	0	0	1
11/29/2019 06:00	0.0	0	0	0	0	1
11/29/2019 07:00	0.0	0	0	0	0	1
11/29/2019 08:00	0.0	0	0	0	0	1
11/29/2019 09:00	0.0	0	0	0	0	1
11/29/2019 10:00	0.0	0	0	0	0	1
11/29/2019 11:00	0.0	0	0	0	0	1
11/29/2019 12:00	0.0	0	0	0	0	1
11/29/2019 13:00	0.0	0	0	0	0	1
11/29/2019 14:00	0.0	0	0	0	0	1
11/29/2019 15:00	0.0	0	0	0	0	1
11/29/2019 16:00	0.0	0	0	0	0	1
11/29/2019 17:00	0.0	0	0	0	0	1
11/29/2019 18:00	0.0	0	0	0	0	1
11/29/2019 19:00	0.0	0	0	0	0	1
11/29/2019 20:00	0.0	0	0	0	0	1
11/29/2019 21:00	0.0	0	0	0	0	1
11/29/2019 22:00	0.0	0	0	0	0	1
11/29/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/30/2019 00:00	0.0	0	0	0	0	1
11/30/2019 01:00	0.0	0	0	0	0	1
11/30/2019 02:00	0.0	0	0	0	0	1
11/30/2019 03:00	0.0	0	0	0	0	1
11/30/2019 04:00	0.0	0	0	0	0	1
11/30/2019 05:00	0.0	0	0	0	0	1
11/30/2019 06:00	0.0	0	0	0	0	1
11/30/2019 07:00	0.0	0	0	0	0	1
11/30/2019 08:00	0.0	0	0	0	0	1
11/30/2019 09:00	0.0	0	0	0	0	1
11/30/2019 10:00	0.0	0	0	0	0	1
11/30/2019 11:00	0.0	0	0	0	0	1
11/30/2019 12:00	0.0	0	0	0	0	1
11/30/2019 13:00	0.0	0	0	0	0	1
11/30/2019 14:00	0.0	0	0	0	0	1
11/30/2019 15:00	0.0	0	0	0	0	1
11/30/2019 16:00	0.0	0	0	0	0	1
11/30/2019 17:00	0.0	0	0	0	0	1
11/30/2019 18:00	0.0	0	0	0	0	1
11/30/2019 19:00	0.0	0	0	0	0	1
11/30/2019 20:00	0.0	0	0	0	0	1
11/30/2019 21:00	0.0	0	0	0	0	1
11/30/2019 22:00	0.0	0	0	0	0	1
11/30/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/01/2019 00:00	0.0	0	0	0	0	1
12/01/2019 01:00	0.0	0	0	0	0	1
12/01/2019 02:00	0.0	0	0	0	0	1
12/01/2019 03:00	0.0	0	0	0	0	1
12/01/2019 04:00	0.0	0	0	0	0	1
12/01/2019 05:00	0.0	0	0	0	0	1
12/01/2019 06:00	0.0	0	0	0	0	1
12/01/2019 07:00	0.0	0	0	0	0	1
12/01/2019 08:00	0.0	0	0	0	0	1
12/01/2019 09:00	0.0	0	0	0	0	1
12/01/2019 10:00	0.0	0	0	0	0	1
12/01/2019 11:00	0.0	0	0	0	0	1
12/01/2019 12:00	0.0	0	0	0	0	1
12/01/2019 13:00	0.0	0	0	0	0	1
12/01/2019 14:00	0.0	0	0	0	0	1
12/01/2019 15:00	0.0	0	0	0	0	1
12/01/2019 16:00	0.0	0	0	0	0	1
12/01/2019 17:00	0.0	0	0	0	0	1
12/01/2019 18:00	0.0	0	0	0	0	1
12/01/2019 19:00	0.0	0	0	0	0	1
12/01/2019 20:00	0.0	0	0	0	0	1
12/01/2019 21:00	0.0	0	0	0	0	1
12/01/2019 22:00	0.0	0	0	0	0	1
12/01/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/02/2019 00:00	0.0	0	0	0	0	1
12/02/2019 01:00	0.0	0	0	0	0	1
12/02/2019 02:00	0.0	0	0	0	0	1
12/02/2019 03:00	0.0	0	0	0	0	1
12/02/2019 04:00	0.0	0	0	0	0	1
12/02/2019 05:00	0.0	0	0	0	0	1
12/02/2019 06:00	0.0	0	0	0	0	1
12/02/2019 07:00	0.0	0	0	0	0	1
12/02/2019 08:00	0.0	0	0	0	0	1
12/02/2019 09:00	0.0	0	0	0	0	1
12/02/2019 10:00	0.0	0	0	0	0	1
12/02/2019 11:00	0.0	0	0	0	0	1
12/02/2019 12:00	0.0	0	0	0	0	1
12/02/2019 13:00	0.0	0	0	0	0	1
12/02/2019 14:00	0.0	0	0	0	0	1
12/02/2019 15:00	0.0	0	0	0	0	1
12/02/2019 16:00	0.0	0	0	0	0	1
12/02/2019 17:00	0.0	0	0	0	0	1
12/02/2019 18:00	0.0	0	0	0	0	1
12/02/2019 19:00	0.0	0	0	0	0	1
12/02/2019 20:00	0.0	0	0	0	0	1
12/02/2019 21:00	0.0	0	0	0	0	1
12/02/2019 22:00	0.0	0	0	0	0	1
12/02/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/03/2019 00:00	0.0	0	0	0	0	1
12/03/2019 01:00	0.0	0	0	0	0	1
12/03/2019 02:00	0.0	0	0	0	0	1
12/03/2019 03:00	0.0	0	0	0	0	1
12/03/2019 04:00	0.0	0	0	0	0	1
12/03/2019 05:00	0.0	0	0	0	0	1
12/03/2019 06:00	0.0	0	0	0	0	1
12/03/2019 07:00	0.0	0	0	0	0	1
12/03/2019 08:00	0.0	0	0	0	0	1
12/03/2019 09:00	0.0	0	0	0	0	1
12/03/2019 10:00	0.0	0	0	0	0	1
12/03/2019 11:00	0.0	0	0	0	0	1
12/03/2019 12:00	0.0	0	0	0	0	1
12/03/2019 13:00	0.0	0	0	0	0	1
12/03/2019 14:00	0.0	0	0	0	0	1
12/03/2019 15:00	0.0	0	0	0	0	1
12/03/2019 16:00	0.0	0	0	0	0	1
12/03/2019 17:00	0.0	0	0	0	0	1
12/03/2019 18:00	0.0	0	0	0	0	1
12/03/2019 19:00	0.0	0	0	0	0	1
12/03/2019 20:00	0.0	0	0	0	0	1
12/03/2019 21:00	0.0	0	0	0	0	1
12/03/2019 22:00	0.0	0	0	0	0	1
12/03/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/04/2019 00:00	0.0	0	0	0	0	1
12/04/2019 01:00	0.0	0	0	0	0	1
12/04/2019 02:00	0.0	0	0	0	0	1
12/04/2019 03:00	0.0	0	0	0	0	1
12/04/2019 04:00	0.0	0	0	0	0	1
12/04/2019 05:00	0.0	0	0	0	0	1
12/04/2019 06:00	0.0	0	0	0	0	1
12/04/2019 07:00	0.0	0	0	0	0	1
12/04/2019 08:00	0.0	0	0	0	0	1
12/04/2019 09:00	0.0	0	0	0	0	1
12/04/2019 10:00	0.0	0	0	0	0	1
12/04/2019 11:00	0.0	0	0	0	0	1
12/04/2019 12:00	0.0	0	0	0	0	1
12/04/2019 13:00	0.0	0	0	0	0	1
12/04/2019 14:00	0.0	0	0	0	0	1
12/04/2019 15:00	0.0	0	0	0	0	1
12/04/2019 16:00	0.0	0	0	0	0	1
12/04/2019 17:00	0.0	0	0	0	0	1
12/04/2019 18:00	0.0	0	0	0	0	1
12/04/2019 19:00	0.0	0	0	0	0	1
12/04/2019 20:00	0.0	0	0	0	0	1
12/04/2019 21:00	0.0	0	0	0	0	1
12/04/2019 22:00	0.0	0	0	0	0	1
12/04/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/05/2019 00:00	0.0	0	0	0	0	1
12/05/2019 01:00	0.0	0	0	0	0	1
12/05/2019 02:00	0.0	0	0	0	0	1
12/05/2019 03:00	0.0	0	0	0	0	1
12/05/2019 04:00	0.0	0	0	0	0	1
12/05/2019 05:00	0.0	0	0	0	0	1
12/05/2019 06:00	0.0	0	0	0	0	1
12/05/2019 07:00	0.0	0	0	0	0	1
12/05/2019 08:00	0.0	0	0	0	0	1
12/05/2019 09:00	0.0	0	0	0	0	1
12/05/2019 10:00	0.0	0	0	0	0	1
12/05/2019 11:00	0.0	0	0	0	0	1
12/05/2019 12:00	0.0	0	0	0	0	1
12/05/2019 13:00	0.0	0	0	0	0	1
12/05/2019 14:00	0.0	0	0	0	0	1
12/05/2019 15:00	0.0	0	0	0	0	1
12/05/2019 16:00	0.0	0	0	0	0	1
12/05/2019 17:00	0.0	0	0	0	0	1
12/05/2019 18:00	0.0	0	0	0	0	1
12/05/2019 19:00	0.0	0	0	0	0	1
12/05/2019 20:00	0.0	0	0	0	0	1
12/05/2019 21:00	0.0	0	0	0	0	1
12/05/2019 22:00	0.0	0	0	0	0	1
12/05/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/06/2019 00:00	0.0	0	0	0	0	1
12/06/2019 01:00	0.0	0	0	0	0	1
12/06/2019 02:00	0.0	0	0	0	0	1
12/06/2019 03:00	0.0	0	0	0	0	1
12/06/2019 04:00	0.0	0	0	0	0	1
12/06/2019 05:00	0.0	0	0	0	0	1
12/06/2019 06:00	0.0	0	0	0	0	1
12/06/2019 07:00	0.0	0	0	0	0	1
12/06/2019 08:00	0.0	0	0	0	0	1
12/06/2019 09:00	0.0	0	0	0	0	1
12/06/2019 10:00	0.0	0	0	0	0	1
12/06/2019 11:00	0.0	0	0	0	0	1
12/06/2019 12:00	0.0	0	0	0	0	1
12/06/2019 13:00	0.0	0	0	0	0	1
12/06/2019 14:00	0.0	0	0	0	0	1
12/06/2019 15:00	0.0	0	0	0	0	1
12/06/2019 16:00	0.0	0	0	0	0	1
12/06/2019 17:00	0.0	0	0	0	0	1
12/06/2019 18:00	0.0	0	0	0	0	1
12/06/2019 19:00	0.0	0	0	0	0	1
12/06/2019 20:00	0.0	0	0	0	0	1
12/06/2019 21:00	0.0	0	0	0	0	1
12/06/2019 22:00	0.0	0	0	0	0	1
12/06/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/07/2019 00:00	0.0	0	0	0	0	1
12/07/2019 01:00	0.0	0	0	0	0	1
12/07/2019 02:00	0.0	0	0	0	0	1
12/07/2019 03:00	0.0	0	0	0	0	1
12/07/2019 04:00	0.0	0	0	0	0	1
12/07/2019 05:00	0.0	0	0	0	0	1
12/07/2019 06:00	0.0	0	0	0	0	1
12/07/2019 07:00	0.0	0	0	0	0	1
12/07/2019 08:00	0.0	0	0	0	0	1
12/07/2019 09:00	0.0	0	0	0	0	1
12/07/2019 10:00	0.0	0	0	0	0	1
12/07/2019 11:00	0.0	0	0	0	0	1
12/07/2019 12:00	0.0	0	0	0	0	1
12/07/2019 13:00	0.0	0	0	0	0	1
12/07/2019 14:00	0.0	0	0	0	0	1
12/07/2019 15:00	0.0	0	0	0	0	1
12/07/2019 16:00	0.0	0	0	0	0	1
12/07/2019 17:00	0.0	0	0	0	0	1
12/07/2019 18:00	0.0	0	0	0	0	1
12/07/2019 19:00	0.0	0	0	0	0	1
12/07/2019 20:00	0.0	0	0	0	0	1
12/07/2019 21:00	0.0	0	0	0	0	1
12/07/2019 22:00	0.0	0	0	0	0	1
12/07/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/08/2019 00:00	0.0	0	0	0	0	1
12/08/2019 01:00	0.0	0	0	0	0	1
12/08/2019 02:00	0.0	0	0	0	0	1
12/08/2019 03:00	0.0	0	0	0	0	1
12/08/2019 04:00	0.0	0	0	0	0	1
12/08/2019 05:00	0.0	0	0	0	0	1
12/08/2019 06:00	0.0	0	0	0	0	1
12/08/2019 07:00	0.0	0	0	0	0	1
12/08/2019 08:00	0.0	0	0	0	0	1
12/08/2019 09:00	0.0	0	0	0	0	1
12/08/2019 10:00	0.0	0	0	0	0	1
12/08/2019 11:00	0.0	0	0	0	0	1
12/08/2019 12:00	0.0	0	0	0	0	1
12/08/2019 13:00	0.0	0	0	0	0	1
12/08/2019 14:00	0.0	0	0	0	0	1
12/08/2019 15:00	0.0	0	0	0	0	1
12/08/2019 16:00	0.0	0	0	0	0	1
12/08/2019 17:00	0.0	0	0	0	0	1
12/08/2019 18:00	0.0	0	0	0	0	1
12/08/2019 19:00	0.0	0	0	0	0	1
12/08/2019 20:00	0.0	0	0	0	0	1
12/08/2019 21:00	0.0	0	0	0	0	1
12/08/2019 22:00	0.0	0	0	0	0	1
12/08/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/09/2019 00:00	0.0	0	0	0	0	1
12/09/2019 01:00	0.0	0	0	0	0	1
12/09/2019 02:00	0.0	0	0	0	0	1
12/09/2019 03:00	0.0	0	0	0	0	1
12/09/2019 04:00	0.0	0	0	0	0	1
12/09/2019 05:00	0.0	0	0	0	0	1
12/09/2019 06:00	0.0	0	0	0	0	1
12/09/2019 07:00	0.0	0	0	0	0	1
12/09/2019 08:00	0.0	0	0	0	0	1
12/09/2019 09:00	0.0	0	0	0	0	1
12/09/2019 10:00	0.0	0	0	0	0	1
12/09/2019 11:00	0.0	0	0	0	0	1
12/09/2019 12:00	0.0	0	0	0	0	1
12/09/2019 13:00	0.0	0	0	0	0	1
12/09/2019 14:00	0.0	0	0	0	0	1
12/09/2019 15:00	0.0	0	0	0	0	1
12/09/2019 16:00	0.0	0	0	0	0	1
12/09/2019 17:00	0.0	0	0	0	0	1
12/09/2019 18:00	0.0	0	0	0	0	1
12/09/2019 19:00	0.0	0	0	0	0	1
12/09/2019 20:00	0.0	0	0	0	0	1
12/09/2019 21:00	0.0	0	0	0	0	1
12/09/2019 22:00	0.0	0	0	0	0	1
12/09/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/10/2019 00:00	0.0	0	0	0	0	1
12/10/2019 01:00	0.0	0	0	0	0	1
12/10/2019 02:00	0.0	0	0	0	0	1
12/10/2019 03:00	0.0	0	0	0	0	1
12/10/2019 04:00	0.0	0	0	0	0	1
12/10/2019 05:00	0.0	0	0	0	0	1
12/10/2019 06:00	0.0	0	0	0	0	1
12/10/2019 07:00	0.0	0	0	0	0	1
12/10/2019 08:00	0.0	0	0	0	0	1
12/10/2019 09:00	0.0	0	0	0	0	1
12/10/2019 10:00	0.0	0	0	0	0	1
12/10/2019 11:00	0.0	0	0	0	0	1
12/10/2019 12:00	0.0	0	0	0	0	1
12/10/2019 13:00	0.0	0	0	0	0	1
12/10/2019 14:00	0.0	0	0	0	0	1
12/10/2019 15:00	0.0	0	0	0	0	1
12/10/2019 16:00	0.0	0	0	0	0	1
12/10/2019 17:00	0.0	0	0	0	0	1
12/10/2019 18:00	0.0	0	0	0	0	1
12/10/2019 19:00	0.0	0	0	0	0	1
12/10/2019 20:00	0.0	0	0	0	0	1
12/10/2019 21:00	0.0	0	0	0	0	1
12/10/2019 22:00	0.0	0	0	0	0	1
12/10/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/11/2019 00:00	0.0	0	0	0	0	1
12/11/2019 01:00	0.0	0	0	0	0	1
12/11/2019 02:00	0.0	0	0	0	0	1
12/11/2019 03:00	0.0	0	0	0	0	1
12/11/2019 04:00	0.0	0	0	0	0	1
12/11/2019 05:00	0.0	0	0	0	0	1
12/11/2019 06:00	0.0	0	0	0	0	1
12/11/2019 07:00	0.0	0	0	0	0	1
12/11/2019 08:00	0.0	0	0	0	0	1
12/11/2019 09:00	0.0	0	0	0	0	1
12/11/2019 10:00	0.0	0	0	0	0	1
12/11/2019 11:00	0.0	0	0	0	0	1
12/11/2019 12:00	0.0	0	0	0	0	1
12/11/2019 13:00	0.0	0	0	0	0	1
12/11/2019 14:00	0.0	0	0	0	0	1
12/11/2019 15:00	0.0	0	0	0	0	1
12/11/2019 16:00	0.0	0	0	0	0	1
12/11/2019 17:00	0.0	0	0	0	0	1
12/11/2019 18:00	0.0	0	0	0	0	1
12/11/2019 19:00	0.0	0	0	0	0	1
12/11/2019 20:00	0.0	0	0	0	0	1
12/11/2019 21:00	0.0	0	0	0	0	1
12/11/2019 22:00	0.0	0	0	0	0	1
12/11/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/12/2019 00:00	0.0	0	0	0	0	1
12/12/2019 01:00	0.0	0	0	0	0	1
12/12/2019 02:00	0.0	0	0	0	0	1
12/12/2019 03:00	0.0	0	0	0	0	1
12/12/2019 04:00	0.0	0	0	0	0	1
12/12/2019 05:00	0.0	0	0	0	0	1
12/12/2019 06:00	0.0	0	0	0	0	1
12/12/2019 07:00	0.0	0	0	0	0	1
12/12/2019 08:00	0.0	0	0	0	0	1
12/12/2019 09:00	0.0	0	0	0	0	1
12/12/2019 10:00	0.0	0	0	0	0	1
12/12/2019 11:00	0.0	0	0	0	0	1
12/12/2019 12:00	0.0	0	0	0	0	1
12/12/2019 13:00	0.0	0	0	0	0	1
12/12/2019 14:00	0.0	0	0	0	0	1
12/12/2019 15:00	0.0	0	0	0	0	1
12/12/2019 16:00	0.0	0	0	0	0	1
12/12/2019 17:00	0.0	0	0	0	0	1
12/12/2019 18:00	0.0	0	0	0	0	1
12/12/2019 19:00	0.0	0	0	0	0	1
12/12/2019 20:00	0.0	0	0	0	0	1
12/12/2019 21:00	0.0	0	0	0	0	1
12/12/2019 22:00	0.0	0	0	0	0	1
12/12/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/13/2019 00:00	0.0	0	0	0	0	1
12/13/2019 01:00	0.0	0	0	0	0	1
12/13/2019 02:00	0.0	0	0	0	0	1
12/13/2019 03:00	0.0	0	0	0	0	1
12/13/2019 04:00	0.0	0	0	0	0	1
12/13/2019 05:00	0.0	0	0	0	0	1
12/13/2019 06:00	0.0	0	0	0	0	1
12/13/2019 07:00	0.0	0	0	0	0	1
12/13/2019 08:00	0.0	0	0	0	0	1
12/13/2019 09:00	0.0	0	0	0	0	1
12/13/2019 10:00	0.0	0	0	0	0	1
12/13/2019 11:00	0.0	0	0	0	0	1
12/13/2019 12:00	0.0	0	0	0	0	1
12/13/2019 13:00	0.0	0	0	0	0	1
12/13/2019 14:00	0.0	0	0	0	0	1
12/13/2019 15:00	0.0	0	0	0	0	1
12/13/2019 16:00	0.0	0	0	0	0	1
12/13/2019 17:00	0.0	0	0	0	0	1
12/13/2019 18:00	0.0	0	0	0	0	1
12/13/2019 19:00	0.0	0	0	0	0	1
12/13/2019 20:00	0.0	0	0	0	0	1
12/13/2019 21:00	0.0	0	0	0	0	1
12/13/2019 22:00	0.0	0	0	0	0	1
12/13/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/14/2019 00:00	0.0	0	0	0	0	1
12/14/2019 01:00	0.0	0	0	0	0	1
12/14/2019 02:00	0.0	0	0	0	0	1
12/14/2019 03:00	0.0	0	0	0	0	1
12/14/2019 04:00	0.0	0	0	0	0	1
12/14/2019 05:00	0.0	0	0	0	0	1
12/14/2019 06:00	0.0	0	0	0	0	1
12/14/2019 07:00	0.0	0	0	0	0	1
12/14/2019 08:00	0.0	0	0	0	0	1
12/14/2019 09:00	0.0	0	0	0	0	1
12/14/2019 10:00	0.0	0	0	0	0	1
12/14/2019 11:00	0.0	0	0	0	0	1
12/14/2019 12:00	0.0	0	0	0	0	1
12/14/2019 13:00	0.0	0	0	0	0	1
12/14/2019 14:00	0.0	0	0	0	0	1
12/14/2019 15:00	0.0	0	0	0	0	1
12/14/2019 16:00	0.0	0	0	0	0	1
12/14/2019 17:00	0.0	0	0	0	0	1
12/14/2019 18:00	0.0	0	0	0	0	1
12/14/2019 19:00	0.0	0	0	0	0	1
12/14/2019 20:00	0.0	0	0	0	0	1
12/14/2019 21:00	0.0	0	0	0	0	1
12/14/2019 22:00	0.0	0	0	0	0	1
12/14/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/15/2019 00:00	0.0	0	0	0	0	1
12/15/2019 01:00	0.0	0	0	0	0	1
12/15/2019 02:00	0.0	0	0	0	0	1
12/15/2019 03:00	0.0	0	0	0	0	1
12/15/2019 04:00	0.0	0	0	0	0	1
12/15/2019 05:00	0.0	0	0	0	0	1
12/15/2019 06:00	0.0	0	0	0	0	1
12/15/2019 07:00	0.0	0	0	0	0	1
12/15/2019 08:00	0.0	0	0	0	0	1
12/15/2019 09:00	0.0	0	0	0	0	1
12/15/2019 10:00	0.0	0	0	0	0	1
12/15/2019 11:00	0.0	0	0	0	0	1
12/15/2019 12:00	0.0	0	0	0	0	1
12/15/2019 13:00	0.0	0	0	0	0	1
12/15/2019 14:00	0.0	0	0	0	0	1
12/15/2019 15:00	0.0	0	0	0	0	1
12/15/2019 16:00	0.0	0	0	0	0	1
12/15/2019 17:00	0.0	0	0	0	0	1
12/15/2019 18:00	0.0	0	0	0	0	1
12/15/2019 19:00	0.0	0	0	0	0	1
12/15/2019 20:00	0.0	0	0	0	0	1
12/15/2019 21:00	0.0	0	0	0	0	1
12/15/2019 22:00	0.0	0	0	0	0	1
12/15/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/16/2019 00:00	0.0	0	0	0	0	1
12/16/2019 01:00	0.0	0	0	0	0	1
12/16/2019 02:00	0.0	0	0	0	0	1
12/16/2019 03:00	0.0	0	0	0	0	1
12/16/2019 04:00	0.0	0	0	0	0	1
12/16/2019 05:00	0.0	0	0	0	0	1
12/16/2019 06:00	0.0	0	0	0	0	1
12/16/2019 07:00	0.0	0	0	0	0	1
12/16/2019 08:00	0.0	0	0	0	0	1
12/16/2019 09:00	0.0	0	0	0	0	1
12/16/2019 10:00	0.0	0	0	0	0	1
12/16/2019 11:00	0.0	0	0	0	0	1
12/16/2019 12:00	0.0	0	0	0	0	1
12/16/2019 13:00	0.0	0	0	0	0	1
12/16/2019 14:00	0.0	0	0	0	0	1
12/16/2019 15:00	0.0	0	0	0	0	1
12/16/2019 16:00	0.0	0	0	0	0	1
12/16/2019 17:00	0.0	0	0	0	0	1
12/16/2019 18:00	0.0	0	0	0	0	1
12/16/2019 19:00	0.0	0	0	0	0	1
12/16/2019 20:00	0.0	0	0	0	0	1
12/16/2019 21:00	0.0	0	0	0	0	1
12/16/2019 22:00	0.0	0	0	0	0	1
12/16/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/17/2019 00:00	0.0	0	0	0	0	1
12/17/2019 01:00	0.0	0	0	0	0	1
12/17/2019 02:00	0.0	0	0	0	0	1
12/17/2019 03:00	0.0	0	0	0	0	1
12/17/2019 04:00	0.0	0	0	0	0	1
12/17/2019 05:00	0.0	0	0	0	0	1
12/17/2019 06:00	0.0	0	0	0	0	1
12/17/2019 07:00	0.0	0	0	0	0	1
12/17/2019 08:00	0.0	0	0	0	0	1
12/17/2019 09:00	0.0	0	0	0	0	1
12/17/2019 10:00	0.0	0	0	0	0	1
12/17/2019 11:00	0.0	0	0	0	0	1
12/17/2019 12:00	0.0	0	0	0	0	1
12/17/2019 13:00	0.0	0	0	0	0	1
12/17/2019 14:00	0.0	0	0	0	0	1
12/17/2019 15:00	0.0	0	0	0	0	1
12/17/2019 16:00	0.0	0	0	0	0	1
12/17/2019 17:00	0.0	0	0	0	0	1
12/17/2019 18:00	0.0	0	0	0	0	1
12/17/2019 19:00	0.0	0	0	0	0	1
12/17/2019 20:00	0.0	0	0	0	0	1
12/17/2019 21:00	0.0	0	0	0	0	1
12/17/2019 22:00	0.0	0	0	0	0	1
12/17/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/18/2019 00:00	0.0	0	0	0	0	1
12/18/2019 01:00	0.0	0	0	0	0	1
12/18/2019 02:00	0.0	0	0	0	0	1
12/18/2019 03:00	0.0	0	0	0	0	1
12/18/2019 04:00	0.0	0	0	0	0	1
12/18/2019 05:00	0.0	0	0	0	0	1
12/18/2019 06:00	0.0	0	0	0	0	1
12/18/2019 07:00	0.0	0	0	0	0	1
12/18/2019 08:00	0.0	0	0	0	0	1
12/18/2019 09:00	0.0	0	0	0	0	1
12/18/2019 10:00	0.0	0	0	0	0	1
12/18/2019 11:00	0.0	0	0	0	0	1
12/18/2019 12:00	0.0	0	0	0	0	1
12/18/2019 13:00	0.0	0	0	0	0	1
12/18/2019 14:00	0.0	0	0	0	0	1
12/18/2019 15:00	0.0	0	0	0	0	1
12/18/2019 16:00	0.0	0	0	0	0	1
12/18/2019 17:00	0.0	0	0	0	0	1
12/18/2019 18:00	0.0	0	0	0	0	1
12/18/2019 19:00	0.0	0	0	0	0	1
12/18/2019 20:00	0.0	0	0	0	0	1
12/18/2019 21:00	0.0	0	0	0	0	1
12/18/2019 22:00	0.0	0	0	0	0	1
12/18/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/19/2019 00:00	0.0	0	0	0	0	1
12/19/2019 01:00	0.0	0	0	0	0	1
12/19/2019 02:00	0.0	0	0	0	0	1
12/19/2019 03:00	0.0	0	0	0	0	1
12/19/2019 04:00	0.0	0	0	0	0	1
12/19/2019 05:00	0.0	0	0	0	0	1
12/19/2019 06:00	0.0	0	0	0	0	1
12/19/2019 07:00	0.0	0	0	0	0	1
12/19/2019 08:00	0.0	0	0	0	0	1
12/19/2019 09:00	0.0	0	0	0	0	1
12/19/2019 10:00	0.0	0	0	0	0	1
12/19/2019 11:00	0.0	0	0	0	0	1
12/19/2019 12:00	0.0	0	0	0	0	1
12/19/2019 13:00	0.0	0	0	0	0	1
12/19/2019 14:00	0.0	0	0	0	0	1
12/19/2019 15:00	0.0	0	0	0	0	1
12/19/2019 16:00	0.0	0	0	0	0	1
12/19/2019 17:00	0.0	0	0	0	0	1
12/19/2019 18:00	0.0	0	0	0	0	1
12/19/2019 19:00	0.0	0	0	0	0	1
12/19/2019 20:00	0.0	0	0	0	0	1
12/19/2019 21:00	0.0	0	0	0	0	1
12/19/2019 22:00	0.0	0	0	0	0	1
12/19/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/20/2019 00:00	0.0	0	0	0	0	1
12/20/2019 01:00	0.0	0	0	0	0	1
12/20/2019 02:00	0.0	0	0	0	0	1
12/20/2019 03:00	0.0	0	0	0	0	1
12/20/2019 04:00	0.0	0	0	0	0	1
12/20/2019 05:00	0.0	0	0	0	0	1
12/20/2019 06:00	0.0	0	0	0	0	1
12/20/2019 07:00	0.0	0	0	0	0	1
12/20/2019 08:00	0.0	0	0	0	0	1
12/20/2019 09:00	0.0	0	0	0	0	1
12/20/2019 10:00	0.0	0	0	0	0	1
12/20/2019 11:00	0.0	0	0	0	0	1
12/20/2019 12:00	0.0	0	0	0	0	1
12/20/2019 13:00	0.0	0	0	0	0	1
12/20/2019 14:00	0.0	0	0	0	0	1
12/20/2019 15:00	0.0	0	0	0	0	1
12/20/2019 16:00	0.0	0	0	0	0	1
12/20/2019 17:00	0.0	0	0	0	0	1
12/20/2019 18:00	0.0	0	0	0	0	1
12/20/2019 19:00	0.0	0	0	0	0	1
12/20/2019 20:00	0.0	0	0	0	0	1
12/20/2019 21:00	0.0	0	0	0	0	1
12/20/2019 22:00	0.0	0	0	0	0	1
12/20/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/21/2019 00:00	0.0	0	0	0	0	1
12/21/2019 01:00	0.0	0	0	0	0	1
12/21/2019 02:00	0.0	0	0	0	0	1
12/21/2019 03:00	0.0	0	0	0	0	1
12/21/2019 04:00	0.0	0	0	0	0	1
12/21/2019 05:00	0.0	0	0	0	0	1
12/21/2019 06:00	0.0	0	0	0	0	1
12/21/2019 07:00	0.0	0	0	0	0	1
12/21/2019 08:00	0.0	0	0	0	0	1
12/21/2019 09:00	0.0	0	0	0	0	1
12/21/2019 10:00	0.0	0	0	0	0	1
12/21/2019 11:00	0.0	0	0	0	0	1
12/21/2019 12:00	0.0	0	0	0	0	1
12/21/2019 13:00	0.0	0	0	0	0	1
12/21/2019 14:00	0.0	0	0	0	0	1
12/21/2019 15:00	0.0	0	0	0	0	1
12/21/2019 16:00	0.0	0	0	0	0	1
12/21/2019 17:00	0.0	0	0	0	0	1
12/21/2019 18:00	0.0	0	0	0	0	1
12/21/2019 19:00	0.0	0	0	0	0	1
12/21/2019 20:00	0.0	0	0	0	0	1
12/21/2019 21:00	0.0	0	0	0	0	1
12/21/2019 22:00	0.0	0	0	0	0	1
12/21/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/22/2019 00:00	0.0	0	0	0	0	1
12/22/2019 01:00	0.0	0	0	0	0	1
12/22/2019 02:00	0.0	0	0	0	0	1
12/22/2019 03:00	0.0	0	0	0	0	1
12/22/2019 04:00	0.0	0	0	0	0	1
12/22/2019 05:00	0.0	0	0	0	0	1
12/22/2019 06:00	0.0	0	0	0	0	1
12/22/2019 07:00	0.0	0	0	0	0	1
12/22/2019 08:00	0.0	0	0	0	0	1
12/22/2019 09:00	0.0	0	0	0	0	1
12/22/2019 10:00	0.0	0	0	0	0	1
12/22/2019 11:00	0.0	0	0	0	0	1
12/22/2019 12:00	0.0	0	0	0	0	1
12/22/2019 13:00	0.0	0	0	0	0	1
12/22/2019 14:00	0.0	0	0	0	0	1
12/22/2019 15:00	0.0	0	0	0	0	1
12/22/2019 16:00	0.0	0	0	0	0	1
12/22/2019 17:00	0.0	0	0	0	0	1
12/22/2019 18:00	0.0	0	0	0	0	1
12/22/2019 19:00	0.0	0	0	0	0	1
12/22/2019 20:00	0.0	0	0	0	0	1
12/22/2019 21:00	0.0	0	0	0	0	1
12/22/2019 22:00	0.0	0	0	0	0	1
12/22/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/23/2019 00:00	0.0	0	0	0	0	1
12/23/2019 01:00	0.0	0	0	0	0	1
12/23/2019 02:00	0.0	0	0	0	0	1
12/23/2019 03:00	0.0	0	0	0	0	1
12/23/2019 04:00	0.0	0	0	0	0	1
12/23/2019 05:00	0.0	0	0	0	0	1
12/23/2019 06:00	0.0	0	0	0	0	1
12/23/2019 07:00	0.0	0	0	0	0	1
12/23/2019 08:00	0.0	0	0	0	0	1
12/23/2019 09:00	0.0	0	0	0	0	1
12/23/2019 10:00	0.0	0	0	0	0	1
12/23/2019 11:00	0.0	0	0	0	0	1
12/23/2019 12:00	0.0	0	0	0	0	1
12/23/2019 13:00	0.0	0	0	0	0	1
12/23/2019 14:00	0.0	0	0	0	0	1
12/23/2019 15:00	0.0	0	0	0	0	1
12/23/2019 16:00	0.0	0	0	0	0	1
12/23/2019 17:00	0.0	0	0	0	0	1
12/23/2019 18:00	0.0	0	0	0	0	1
12/23/2019 19:00	0.0	0	0	0	0	1
12/23/2019 20:00	0.0	0	0	0	0	1
12/23/2019 21:00	0.0	0	0	0	0	1
12/23/2019 22:00	0.0	0	0	0	0	1
12/23/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/24/2019 00:00	0.0	0	0	0	0	1
12/24/2019 01:00	0.0	0	0	0	0	1
12/24/2019 02:00	0.0	0	0	0	0	1
12/24/2019 03:00	0.0	0	0	0	0	1
12/24/2019 04:00	0.0	0	0	0	0	1
12/24/2019 05:00	0.0	0	0	0	0	1
12/24/2019 06:00	0.0	0	0	0	0	1
12/24/2019 07:00	0.0	0	0	0	0	1
12/24/2019 08:00	0.0	0	0	0	0	1
12/24/2019 09:00	0.0	0	0	0	0	1
12/24/2019 10:00	0.0	0	0	0	0	1
12/24/2019 11:00	0.0	0	0	0	0	1
12/24/2019 12:00	0.0	0	0	0	0	1
12/24/2019 13:00	0.0	0	0	0	0	1
12/24/2019 14:00	0.0	0	0	0	0	1
12/24/2019 15:00	0.0	0	0	0	0	1
12/24/2019 16:00	0.0	0	0	0	0	1
12/24/2019 17:00	0.0	0	0	0	0	1
12/24/2019 18:00	0.0	0	0	0	0	1
12/24/2019 19:00	0.0	0	0	0	0	1
12/24/2019 20:00	0.0	0	0	0	0	1
12/24/2019 21:00	0.0	0	0	0	0	1
12/24/2019 22:00	0.0	0	0	0	0	1
12/24/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/25/2019 00:00	0.0	0	0	0	0	1
12/25/2019 01:00	0.0	0	0	0	0	1
12/25/2019 02:00	0.0	0	0	0	0	1
12/25/2019 03:00	0.0	0	0	0	0	1
12/25/2019 04:00	0.0	0	0	0	0	1
12/25/2019 05:00	0.0	0	0	0	0	1
12/25/2019 06:00	0.0	0	0	0	0	1
12/25/2019 07:00	0.0	0	0	0	0	1
12/25/2019 08:00	0.0	0	0	0	0	1
12/25/2019 09:00	0.0	0	0	0	0	1
12/25/2019 10:00	0.0	0	0	0	0	1
12/25/2019 11:00	0.0	0	0	0	0	1
12/25/2019 12:00	0.0	0	0	0	0	1
12/25/2019 13:00	0.0	0	0	0	0	1
12/25/2019 14:00	0.0	0	0	0	0	1
12/25/2019 15:00	0.0	0	0	0	0	1
12/25/2019 16:00	0.0	0	0	0	0	1
12/25/2019 17:00	0.0	0	0	0	0	1
12/25/2019 18:00	0.0	0	0	0	0	1
12/25/2019 19:00	0.0	0	0	0	0	1
12/25/2019 20:00	0.0	0	0	0	0	1
12/25/2019 21:00	0.0	0	0	0	0	1
12/25/2019 22:00	0.0	0	0	0	0	1
12/25/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/26/2019 00:00	0.0	0	0	0	0	1
12/26/2019 01:00	0.0	0	0	0	0	1
12/26/2019 02:00	0.0	0	0	0	0	1
12/26/2019 03:00	0.0	0	0	0	0	1
12/26/2019 04:00	0.0	0	0	0	0	1
12/26/2019 05:00	0.0	0	0	0	0	1
12/26/2019 06:00	0.0	0	0	0	0	1
12/26/2019 07:00	0.0	0	0	0	0	1
12/26/2019 08:00	0.0	0	0	0	0	1
12/26/2019 09:00	0.0	0	0	0	0	1
12/26/2019 10:00	0.0	0	0	0	0	1
12/26/2019 11:00	0.0	0	0	0	0	1
12/26/2019 12:00	0.0	0	0	0	0	1
12/26/2019 13:00	0.0	0	0	0	0	1
12/26/2019 14:00	0.0	0	0	0	0	1
12/26/2019 15:00	0.0	0	0	0	0	1
12/26/2019 16:00	0.0	0	0	0	0	1
12/26/2019 17:00	0.0	0	0	0	0	1
12/26/2019 18:00	0.0	0	0	0	0	1
12/26/2019 19:00	0.0	0	0	0	0	1
12/26/2019 20:00	0.0	0	0	0	0	1
12/26/2019 21:00	0.0	0	0	0	0	1
12/26/2019 22:00	0.0	0	0	0	0	1
12/26/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/27/2019 00:00	0.0	0	0	0	0	1
12/27/2019 01:00	0.0	0	0	0	0	1
12/27/2019 02:00	0.0	0	0	0	0	1
12/27/2019 03:00	0.0	0	0	0	0	1
12/27/2019 04:00	0.0	0	0	0	0	1
12/27/2019 05:00	0.0	0	0	0	0	1
12/27/2019 06:00	0.0	0	0	0	0	1
12/27/2019 07:00	0.0	0	0	0	0	1
12/27/2019 08:00	0.0	0	0	0	0	1
12/27/2019 09:00	0.0	0	0	0	0	1
12/27/2019 10:00	0.0	0	0	0	0	1
12/27/2019 11:00	0.0	0	0	0	0	1
12/27/2019 12:00	0.0	0	0	0	0	1
12/27/2019 13:00	0.0	0	0	0	0	1
12/27/2019 14:00	0.0	0	0	0	0	1
12/27/2019 15:00	0.0	0	0	0	0	1
12/27/2019 16:00	0.0	0	0	0	0	1
12/27/2019 17:00	0.0	0	0	0	0	1
12/27/2019 18:00	0.0	0	0	0	0	1
12/27/2019 19:00	0.0	0	0	0	0	1
12/27/2019 20:00	0.0	0	0	0	0	1
12/27/2019 21:00	0.0	0	0	0	0	1
12/27/2019 22:00	0.0	0	0	0	0	1
12/27/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/28/2019 00:00	0.0	0	0	0	0	1
12/28/2019 01:00	0.0	0	0	0	0	1
12/28/2019 02:00	0.0	0	0	0	0	1
12/28/2019 03:00	0.0	0	0	0	0	1
12/28/2019 04:00	0.0	0	0	0	0	1
12/28/2019 05:00	0.0	0	0	0	0	1
12/28/2019 06:00	0.0	0	0	0	0	1
12/28/2019 07:00	0.0	0	0	0	0	1
12/28/2019 08:00	0.0	0	0	0	0	1
12/28/2019 09:00	0.0	0	0	0	0	1
12/28/2019 10:00	0.0	0	0	0	0	1
12/28/2019 11:00	0.0	0	0	0	0	1
12/28/2019 12:00	0.0	0	0	0	0	1
12/28/2019 13:00	0.0	0	0	0	0	1
12/28/2019 14:00	0.0	0	0	0	0	1
12/28/2019 15:00	0.0	0	0	0	0	1
12/28/2019 16:00	0.0	0	0	0	0	1
12/28/2019 17:00	0.0	0	0	0	0	1
12/28/2019 18:00	0.0	0	0	0	0	1
12/28/2019 19:00	0.0	0	0	0	0	1
12/28/2019 20:00	0.0	0	0	0	0	1
12/28/2019 21:00	0.0	0	0	0	0	1
12/28/2019 22:00	0.0	0	0	0	0	1
12/28/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/29/2019 00:00	0.0	0	0	0	0	1
12/29/2019 01:00	0.0	0	0	0	0	1
12/29/2019 02:00	0.0	0	0	0	0	1
12/29/2019 03:00	0.0	0	0	0	0	1
12/29/2019 04:00	0.0	0	0	0	0	1
12/29/2019 05:00	0.0	0	0	0	0	1
12/29/2019 06:00	0.0	0	0	0	0	1
12/29/2019 07:00	0.0	0	0	0	0	1
12/29/2019 08:00	0.0	0	0	0	0	1
12/29/2019 09:00	0.0	0	0	0	0	1
12/29/2019 10:00	0.0	0	0	0	0	1
12/29/2019 11:00	0.0	0	0	0	0	1
12/29/2019 12:00	0.0	0	0	0	0	1
12/29/2019 13:00	0.0	0	0	0	0	1
12/29/2019 14:00	0.0	0	0	0	0	1
12/29/2019 15:00	0.0	0	0	0	0	1
12/29/2019 16:00	0.0	0	0	0	0	1
12/29/2019 17:00	0.0	0	0	0	0	1
12/29/2019 18:00	0.0	0	0	0	0	1
12/29/2019 19:00	0.0	0	0	0	0	1
12/29/2019 20:00	0.0	0	0	0	0	1
12/29/2019 21:00	0.0	0	0	0	0	1
12/29/2019 22:00	0.0	0	0	0	0	1
12/29/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/30/2019 00:00	0.0	0	0	0	0	1
12/30/2019 01:00	0.0	0	0	0	0	1
12/30/2019 02:00	0.0	0	0	0	0	1
12/30/2019 03:00	0.0	0	0	0	0	1
12/30/2019 04:00	0.0	0	0	0	0	1
12/30/2019 05:00	0.0	0	0	0	0	1
12/30/2019 06:00	0.0	0	0	0	0	1
12/30/2019 07:00	0.0	0	0	0	0	1
12/30/2019 08:00	0.0	0	0	0	0	1
12/30/2019 09:00	0.0	0	0	0	0	1
12/30/2019 10:00	0.0	0	0	0	0	1
12/30/2019 11:00	0.0	0	0	0	0	1
12/30/2019 12:00	0.0	0	0	0	0	1
12/30/2019 13:00	0.0	0	0	0	0	1
12/30/2019 14:00	0.0	0	0	0	0	1
12/30/2019 15:00	0.0	0	0	0	0	1
12/30/2019 16:00	0.0	0	0	0	0	1
12/30/2019 17:00	0.0	0	0	0	0	1
12/30/2019 18:00	0.0	0	0	0	0	1
12/30/2019 19:00	0.0	0	0	0	0	1
12/30/2019 20:00	0.0	0	0	0	0	1
12/30/2019 21:00	0.0	0	0	0	0	1
12/30/2019 22:00	0.0	0	0	0	0	1
12/30/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/31/2019 00:00	0.0	0	0	0	0	1
12/31/2019 01:00	0.0	0	0	0	0	1
12/31/2019 02:00	0.0	0	0	0	0	1
12/31/2019 03:00	0.0	0	0	0	0	1
12/31/2019 04:00	0.0	0	0	0	0	1
12/31/2019 05:00	0.0	0	0	0	0	1
12/31/2019 06:00	0.0	0	0	0	0	1
12/31/2019 07:00	0.0	0	0	0	0	1
12/31/2019 08:00	0.0	0	0	0	0	1
12/31/2019 09:00	0.0	0	0	0	0	1
12/31/2019 10:00	0.0	0	0	0	0	1
12/31/2019 11:00	0.0	0	0	0	0	1
12/31/2019 12:00	0.0	0	0	0	0	1
12/31/2019 13:00	0.0	0	0	0	0	1
12/31/2019 14:00	0.0	0	0	0	0	1
12/31/2019 15:00	0.0	0	0	0	0	1
12/31/2019 16:00	0.0	0	0	0	0	1
12/31/2019 17:00	0.0	0	0	0	0	1
12/31/2019 18:00	0.0	0	0	0	0	1
12/31/2019 19:00	0.0	0	0	0	0	1
12/31/2019 20:00	0.0	0	0	0	0	1
12/31/2019 21:00	0.0	0	0	0	0	1
12/31/2019 22:00	0.0	0	0	0	0	1
12/31/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/01/2019 00:00	0.0	0	0	0	0	1
10/01/2019 01:00	0.0	0	0	0	0	1
10/01/2019 02:00	0.0	0	0	0	0	1
10/01/2019 03:00	0.0	0	0	0	0	1
10/01/2019 04:00	0.0	0	0	0	0	1
10/01/2019 05:00	0.0	0	0	0	0	1
10/01/2019 06:00	0.0	0	0	0	0	1
10/01/2019 07:00	0.0	0	0	0	0	1
10/01/2019 08:00	0.0	0	0	0	0	1
10/01/2019 09:00	0.0	0	0	0	0	1
10/01/2019 10:00	0.0	0	0	0	0	1
10/01/2019 11:00	0.0	0	0	0	0	1
10/01/2019 12:00	0.0	0	0	0	0	1
10/01/2019 13:00	0.0	0	0	0	0	1
10/01/2019 14:00	0.0	0	0	0	0	1
10/01/2019 15:00	0.0	0	0	0	0	1
10/01/2019 16:00	0.0	0	0	0	0	1
10/01/2019 17:00	0.0	0	0	0	0	1
10/01/2019 18:00	0.0	0	0	0	0	1
10/01/2019 19:00	0.0	0	0	0	0	1
10/01/2019 20:00	0.0	0	0	0	0	1
10/01/2019 21:00	0.0	0	0	0	0	1
10/01/2019 22:00	0.0	0	0	0	0	1
10/01/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/02/2019 00:00	0.0	0	0	0	0	1
10/02/2019 01:00	0.0	0	0	0	0	1
10/02/2019 02:00	0.0	0	0	0	0	1
10/02/2019 03:00	0.0	0	0	0	0	1
10/02/2019 04:00	0.0	0	0	0	0	1
10/02/2019 05:00	0.0	0	0	0	0	1
10/02/2019 06:00	0.0	0	0	0	0	1
10/02/2019 07:00	0.0	0	0	0	0	1
10/02/2019 08:00	0.0	0	0	0	0	1
10/02/2019 09:00	0.0	0	0	0	0	1
10/02/2019 10:00	0.0	0	0	0	0	1
10/02/2019 11:00	0.0	0	0	0	0	1
10/02/2019 12:00	0.0	0	0	0	0	1
10/02/2019 13:00	0.0	0	0	0	0	1
10/02/2019 14:00	0.0	0	0	0	0	1
10/02/2019 15:00	0.0	0	0	0	0	1
10/02/2019 16:00	0.0	0	0	0	0	1
10/02/2019 17:00	0.0	0	0	0	0	1
10/02/2019 18:00	0.0	0	0	0	0	1
10/02/2019 19:00	0.0	0	0	0	0	1
10/02/2019 20:00	0.0	0	0	0	0	1
10/02/2019 21:00	0.0	0	0	0	0	1
10/02/2019 22:00	0.0	0	0	0	0	1
10/02/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/03/2019 00:00	0.0	0	0	0	0	1
10/03/2019 01:00	0.0	0	0	0	0	1
10/03/2019 02:00	0.0	0	0	0	0	1
10/03/2019 03:00	0.0	0	0	0	0	1
10/03/2019 04:00	0.0	0	0	0	0	1
10/03/2019 05:00	0.0	0	0	0	0	1
10/03/2019 06:00	0.0	0	0	0	0	1
10/03/2019 07:00	0.0	0	0	0	0	1
10/03/2019 08:00	0.0	0	0	0	0	1
10/03/2019 09:00	0.0	0	0	0	0	1
10/03/2019 10:00	0.0	0	0	0	0	1
10/03/2019 11:00	0.0	0	0	0	0	1
10/03/2019 12:00	0.0	0	0	0	0	1
10/03/2019 13:00	0.0	0	0	0	0	1
10/03/2019 14:00	0.0	0	0	0	0	1
10/03/2019 15:00	0.0	0	0	0	0	1
10/03/2019 16:00	0.0	0	0	0	0	1
10/03/2019 17:00	0.0	0	0	0	0	1
10/03/2019 18:00	0.0	0	0	0	0	1
10/03/2019 19:00	0.0	0	0	0	0	1
10/03/2019 20:00	0.0	0	0	0	0	1
10/03/2019 21:00	60.1	0	0	0	1	0
10/03/2019 22:00	0.0	0	0	0	0	0
10/03/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	60.1 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	60.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/04/2019 00:00	0.0	0	0	0	0	0
10/04/2019 01:00	0.0	0	0	0	0	0
10/04/2019 02:00	960.9	0	0	1	0	0
10/04/2019 03:00	5,936.4	0	0	1	0	0
10/04/2019 04:00	0.0	0	0	0	0	1
10/04/2019 05:00	0.0	0	0	0	0	1
10/04/2019 06:00	0.0	0	0	0	0	1
10/04/2019 07:00	0.0	0	0	0	0	1
10/04/2019 08:00	0.0	0	0	0	0	1
10/04/2019 09:00	0.0	0	0	0	0	1
10/04/2019 10:00	0.0	0	0	0	0	1
10/04/2019 11:00	0.0	0	0	0	0	1
10/04/2019 12:00	0.0	0	0	0	0	1
10/04/2019 13:00	0.0	0	0	0	0	1
10/04/2019 14:00	0.0	0	0	0	0	1
10/04/2019 15:00	0.0	0	0	0	0	1
10/04/2019 16:00	0.0	0	0	0	0	1
10/04/2019 17:00	0.0	0	0	0	0	1
10/04/2019 18:00	0.0	0	0	0	0	1
10/04/2019 19:00	0.0	0	0	0	0	1
10/04/2019 20:00	0.0	0	0	0	0	1
10/04/2019 21:00	0.0	0	0	0	0	1
10/04/2019 22:00	0.0	0	0	0	0	1
10/04/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,897.3 #	0 #	0 #	2 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,936.4	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/05/2019 00:00	0.0	0	0	0	0	1
10/05/2019 01:00	0.0	0	0	0	0	1
10/05/2019 02:00	0.0	0	0	0	0	1
10/05/2019 03:00	0.0	0	0	0	0	1
10/05/2019 04:00	0.0	0	0	0	0	1
10/05/2019 05:00	0.0	0	0	0	0	1
10/05/2019 06:00	0.0	0	0	0	0	1
10/05/2019 07:00	0.0	0	0	0	0	1
10/05/2019 08:00	0.0	0	0	0	0	1
10/05/2019 09:00	0.0	0	0	0	0	1
10/05/2019 10:00	0.0	0	0	0	0	1
10/05/2019 11:00	0.0	0	0	0	0	1
10/05/2019 12:00	0.0	0	0	0	0	1
10/05/2019 13:00	0.0	0	0	0	0	1
10/05/2019 14:00	0.0	0	0	0	0	1
10/05/2019 15:00	0.0	0	0	0	0	1
10/05/2019 16:00	0.0	0	0	0	0	1
10/05/2019 17:00	0.0	0	0	0	0	1
10/05/2019 18:00	0.0	0	0	0	0	1
10/05/2019 19:00	0.0	0	0	0	0	1
10/05/2019 20:00	0.0	0	0	0	0	1
10/05/2019 21:00	0.0	0	0	0	0	1
10/05/2019 22:00	0.0	0	0	0	0	1
10/05/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/06/2019 00:00	0.0	0	0	0	0	1
10/06/2019 01:00	0.0	0	0	0	0	1
10/06/2019 02:00	0.0	0	0	0	0	1
10/06/2019 03:00	0.0	0	0	0	0	1
10/06/2019 04:00	0.0	0	0	0	0	1
10/06/2019 05:00	0.0	0	0	0	0	1
10/06/2019 06:00	0.0	0	0	0	0	1
10/06/2019 07:00	0.0	0	0	0	0	1
10/06/2019 08:00	0.0	0	0	0	0	1
10/06/2019 09:00	0.0	0	0	0	0	1
10/06/2019 10:00	0.0	0	0	0	0	1
10/06/2019 11:00	0.0	0	0	0	0	1
10/06/2019 12:00	0.0	0	0	0	0	1
10/06/2019 13:00	0.0	0	0	0	0	1
10/06/2019 14:00	0.0	0	0	0	0	1
10/06/2019 15:00	0.0	0	0	0	0	1
10/06/2019 16:00	0.0	0	0	0	0	1
10/06/2019 17:00	0.0	0	0	0	0	1
10/06/2019 18:00	0.0	0	0	0	0	1
10/06/2019 19:00	0.0	0	0	0	0	1
10/06/2019 20:00	0.0	0	0	0	0	1
10/06/2019 21:00	0.0	0	0	0	0	1
10/06/2019 22:00	0.0	0	0	0	0	1
10/06/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/07/2019 00:00	0.0	0	0	0	0	1
10/07/2019 01:00	0.0	0	0	0	0	1
10/07/2019 02:00	0.0	0	0	0	0	1
10/07/2019 03:00	0.0	0	0	0	0	1
10/07/2019 04:00	0.0	0	0	0	0	1
10/07/2019 05:00	0.0	0	0	0	0	1
10/07/2019 06:00	0.0	0	0	0	0	1
10/07/2019 07:00	0.0	0	0	0	0	1
10/07/2019 08:00	0.0	0	0	0	0	1
10/07/2019 09:00	0.0	0	0	0	0	1
10/07/2019 10:00	0.0	0	0	0	0	1
10/07/2019 11:00	0.0	0	0	0	0	1
10/07/2019 12:00	0.0	0	0	0	0	1
10/07/2019 13:00	0.0	0	0	0	0	1
10/07/2019 14:00	0.0	0	0	0	0	1
10/07/2019 15:00	0.0	0	0	0	0	1
10/07/2019 16:00	0.0	0	0	0	0	1
10/07/2019 17:00	0.0	0	0	0	0	1
10/07/2019 18:00	0.0	0	0	0	0	1
10/07/2019 19:00	0.0	0	0	0	0	1
10/07/2019 20:00	0.0	0	0	0	0	1
10/07/2019 21:00	0.0	0	0	0	0	1
10/07/2019 22:00	0.0	0	0	0	0	1
10/07/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/08/2019 00:00	0.0	0	0	0	0	1
10/08/2019 01:00	0.0	0	0	0	0	1
10/08/2019 02:00	0.0	0	0	0	0	1
10/08/2019 03:00	0.0	0	0	0	0	1
10/08/2019 04:00	0.0	0	0	0	0	1
10/08/2019 05:00	0.0	0	0	0	0	1
10/08/2019 06:00	0.0	0	0	0	0	1
10/08/2019 07:00	0.0	0	0	0	0	1
10/08/2019 08:00	0.0	0	0	0	0	1
10/08/2019 09:00	0.0	0	0	0	0	1
10/08/2019 10:00	0.0	0	0	0	0	1
10/08/2019 11:00	0.0	0	0	0	0	1
10/08/2019 12:00	0.0	0	0	0	0	1
10/08/2019 13:00	0.0	0	0	0	0	1
10/08/2019 14:00	0.0	0	0	0	0	1
10/08/2019 15:00	0.0	0	0	0	0	1
10/08/2019 16:00	0.0	0	0	0	0	1
10/08/2019 17:00	0.0	0	0	0	0	1
10/08/2019 18:00	0.0	0	0	0	0	1
10/08/2019 19:00	0.0	0	0	0	0	1
10/08/2019 20:00	0.0	0	0	0	0	1
10/08/2019 21:00	0.0	0	0	0	0	1
10/08/2019 22:00	0.0	0	0	0	0	1
10/08/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/09/2019 00:00	0.0	0	0	0	0	1
10/09/2019 01:00	0.0	0	0	0	0	1
10/09/2019 02:00	0.0	0	0	0	0	1
10/09/2019 03:00	0.0	0	0	0	0	1
10/09/2019 04:00	0.0	0	0	0	0	1
10/09/2019 05:00	0.0	0	0	0	0	1
10/09/2019 06:00	0.0	0	0	0	0	1
10/09/2019 07:00	0.0	0	0	0	0	1
10/09/2019 08:00	0.0	0	0	0	0	1
10/09/2019 09:00	0.0	0	0	0	0	1
10/09/2019 10:00	0.0	0	0	0	0	1
10/09/2019 11:00	0.0	0	0	0	0	1
10/09/2019 12:00	0.0	0	0	0	0	1
10/09/2019 13:00	0.0	0	0	0	0	1
10/09/2019 14:00	0.0	0	0	0	0	1
10/09/2019 15:00	0.0	0	0	0	0	1
10/09/2019 16:00	0.0	0	0	0	0	1
10/09/2019 17:00	0.0	0	0	0	0	1
10/09/2019 18:00	0.0	0	0	0	0	1
10/09/2019 19:00	0.0	0	0	0	0	1
10/09/2019 20:00	0.0	0	0	0	0	1
10/09/2019 21:00	0.0	0	0	0	0	1
10/09/2019 22:00	0.0	0	0	0	0	1
10/09/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/10/2019 00:00	0.0	0	0	0	0	1
10/10/2019 01:00	0.0	0	0	0	0	1
10/10/2019 02:00	0.0	0	0	0	0	1
10/10/2019 03:00	0.0	0	0	0	0	1
10/10/2019 04:00	0.0	0	0	0	0	1
10/10/2019 05:00	0.0	0	0	0	0	1
10/10/2019 06:00	0.0	0	0	0	0	1
10/10/2019 07:00	0.0	0	0	0	0	1
10/10/2019 08:00	0.0	0	0	0	0	1
10/10/2019 09:00	0.0	0	0	0	0	1
10/10/2019 10:00	0.0	0	0	0	0	1
10/10/2019 11:00	0.0	0	0	0	0	1
10/10/2019 12:00	0.0	0	0	0	0	1
10/10/2019 13:00	0.0	0	0	0	0	1
10/10/2019 14:00	0.0	0	0	0	0	1
10/10/2019 15:00	0.0	0	0	0	0	1
10/10/2019 16:00	0.0	0	0	0	0	1
10/10/2019 17:00	0.0	0	0	0	0	1
10/10/2019 18:00	0.0	0	0	0	0	1
10/10/2019 19:00	0.0	0	0	0	0	1
10/10/2019 20:00	0.0	0	0	0	0	1
10/10/2019 21:00	0.0	0	0	0	0	1
10/10/2019 22:00	0.0	0	0	0	0	1
10/10/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/11/2019 00:00	0.0	0	0	0	0	1
10/11/2019 01:00	0.0	0	0	0	0	1
10/11/2019 02:00	0.0	0	0	0	0	1
10/11/2019 03:00	0.0	0	0	0	0	1
10/11/2019 04:00	0.0	0	0	0	0	1
10/11/2019 05:00	0.0	0	0	0	0	1
10/11/2019 06:00	0.0	0	0	0	0	1
10/11/2019 07:00	0.0	0	0	0	0	1
10/11/2019 08:00	0.0	0	0	0	0	1
10/11/2019 09:00	0.0	0	0	0	0	1
10/11/2019 10:00	0.0	0	0	0	0	1
10/11/2019 11:00	0.0	0	0	0	0	1
10/11/2019 12:00	0.0	0	0	0	0	1
10/11/2019 13:00	0.0	0	0	0	0	1
10/11/2019 14:00	0.0	0	0	0	0	1
10/11/2019 15:00	0.0	0	0	0	0	1
10/11/2019 16:00	0.0	0	0	0	0	1
10/11/2019 17:00	0.0	0	0	0	0	1
10/11/2019 18:00	0.0	0	0	0	0	1
10/11/2019 19:00	0.0	0	0	0	0	1
10/11/2019 20:00	0.0	0	0	0	0	1
10/11/2019 21:00	0.0	0	0	0	0	1
10/11/2019 22:00	0.0	0	0	0	0	1
10/11/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/12/2019 00:00	0.0	0	0	0	0	1
10/12/2019 01:00	0.0	0	0	0	0	1
10/12/2019 02:00	0.0	0	0	0	0	1
10/12/2019 03:00	0.0	0	0	0	0	1
10/12/2019 04:00	0.0	0	0	0	0	1
10/12/2019 05:00	0.0	0	0	0	0	1
10/12/2019 06:00	0.0	0	0	0	0	1
10/12/2019 07:00	58.1	0	0	0	1	0
10/12/2019 08:00	0.0	0	0	0	0	0
10/12/2019 09:00	0.0	0	0	0	0	0
10/12/2019 10:00	610.6	0	0	1	0	0
10/12/2019 11:00	6,791.1	0	0	1	0	0
10/12/2019 12:00	444.5	0	0	1	0	0
10/12/2019 13:00	0.0	0	0	0	0	1
10/12/2019 14:00	0.0	0	0	0	0	1
10/12/2019 15:00	0.0	0	0	0	0	1
10/12/2019 16:00	0.0	0	0	0	0	1
10/12/2019 17:00	0.0	0	0	0	0	1
10/12/2019 18:00	0.0	0	0	0	0	1
10/12/2019 19:00	0.0	0	0	0	0	1
10/12/2019 20:00	0.0	0	0	0	0	1
10/12/2019 21:00	0.0	0	0	0	0	1
10/12/2019 22:00	0.0	0	0	0	0	1
10/12/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,904.3 #	0 #	0 #	3 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,791.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/13/2019 00:00	0.0	0	0	0	0	1
10/13/2019 01:00	0.0	0	0	0	0	1
10/13/2019 02:00	0.0	0	0	0	0	1
10/13/2019 03:00	0.0	0	0	0	0	1
10/13/2019 04:00	0.0	0	0	0	0	1
10/13/2019 05:00	0.0	0	0	0	0	1
10/13/2019 06:00	0.0	0	0	0	0	1
10/13/2019 07:00	0.0	0	0	0	0	1
10/13/2019 08:00	0.0	0	0	0	0	1
10/13/2019 09:00	0.0	0	0	0	0	1
10/13/2019 10:00	0.0	0	0	0	0	1
10/13/2019 11:00	0.0	0	0	0	0	1
10/13/2019 12:00	0.0	0	0	0	0	1
10/13/2019 13:00	0.0	0	0	0	0	1
10/13/2019 14:00	0.0	0	0	0	0	1
10/13/2019 15:00	0.0	0	0	0	0	1
10/13/2019 16:00	0.0	0	0	0	0	1
10/13/2019 17:00	0.0	0	0	0	0	1
10/13/2019 18:00	0.0	0	0	0	0	1
10/13/2019 19:00	0.0	0	0	0	0	1
10/13/2019 20:00	0.0	0	0	0	0	1
10/13/2019 21:00	0.0	0	0	0	0	1
10/13/2019 22:00	0.0	0	0	0	0	1
10/13/2019 23:00	141.6	0	0	0	1	0
Average/Sum#:	141.6 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	141.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/14/2019 00:00	0.0	0	0	0	0	0
10/14/2019 01:00	0.0	0	0	0	0	0
10/14/2019 02:00	5,891.7	0	0	1	0	0
10/14/2019 03:00	697.6	0	0	1	0	0
10/14/2019 04:00	0.0	0	0	0	0	1
10/14/2019 05:00	0.0	0	0	0	0	1
10/14/2019 06:00	0.0	0	0	0	0	1
10/14/2019 07:00	0.0	0	0	0	0	1
10/14/2019 08:00	0.0	0	0	0	0	1
10/14/2019 09:00	0.0	0	0	0	0	1
10/14/2019 10:00	0.0	0	0	0	0	1
10/14/2019 11:00	0.0	0	0	0	0	1
10/14/2019 12:00	0.0	0	0	0	0	1
10/14/2019 13:00	0.0	0	0	0	0	1
10/14/2019 14:00	0.0	0	0	0	0	1
10/14/2019 15:00	0.0	0	0	0	0	1
10/14/2019 16:00	0.0	0	0	0	0	1
10/14/2019 17:00	0.0	0	0	0	0	1
10/14/2019 18:00	0.0	0	0	0	0	1
10/14/2019 19:00	0.0	0	0	0	0	1
10/14/2019 20:00	0.0	0	0	0	0	1
10/14/2019 21:00	0.0	0	0	0	0	1
10/14/2019 22:00	0.0	0	0	0	0	1
10/14/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,589.3 #	0 #	0 #	2 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,891.7	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/15/2019 00:00	0.0	0	0	0	0	1
10/15/2019 01:00	0.0	0	0	0	0	1
10/15/2019 02:00	0.0	0	0	0	0	1
10/15/2019 03:00	0.0	0	0	0	0	1
10/15/2019 04:00	0.0	0	0	0	0	1
10/15/2019 05:00	0.0	0	0	0	0	1
10/15/2019 06:00	0.0	0	0	0	0	1
10/15/2019 07:00	0.0	0	0	0	0	1
10/15/2019 08:00	0.0	0	0	0	0	1
10/15/2019 09:00	0.0	0	0	0	0	1
10/15/2019 10:00	0.0	0	0	0	0	1
10/15/2019 11:00	0.0	0	0	0	0	1
10/15/2019 12:00	0.0	0	0	0	0	1
10/15/2019 13:00	0.0	0	0	0	0	1
10/15/2019 14:00	0.0	0	0	0	0	1
10/15/2019 15:00	0.0	0	0	0	0	1
10/15/2019 16:00	0.0	0	0	0	0	1
10/15/2019 17:00	0.0	0	0	0	0	1
10/15/2019 18:00	0.0	0	0	0	0	1
10/15/2019 19:00	0.0	0	0	0	0	1
10/15/2019 20:00	0.0	0	0	0	0	1
10/15/2019 21:00	0.0	0	0	0	0	1
10/15/2019 22:00	0.0	0	0	0	0	1
10/15/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/16/2019 00:00	0.0	0	0	0	0	1
10/16/2019 01:00	0.0	0	0	0	0	1
10/16/2019 02:00	0.0	0	0	0	0	1
10/16/2019 03:00	0.0	0	0	0	0	1
10/16/2019 04:00	0.0	0	0	0	0	1
10/16/2019 05:00	0.0	0	0	0	0	1
10/16/2019 06:00	0.0	0	0	0	0	1
10/16/2019 07:00	0.0	0	0	0	0	1
10/16/2019 08:00	0.0	0	0	0	0	1
10/16/2019 09:00	0.0	0	0	0	0	1
10/16/2019 10:00	0.0	0	0	0	0	1
10/16/2019 11:00	0.0	0	0	0	0	1
10/16/2019 12:00	0.0	0	0	0	0	1
10/16/2019 13:00	0.0	0	0	0	0	1
10/16/2019 14:00	0.0	0	0	0	0	1
10/16/2019 15:00	0.0	0	0	0	0	1
10/16/2019 16:00	0.0	0	0	0	0	1
10/16/2019 17:00	0.0	0	0	0	0	1
10/16/2019 18:00	0.0	0	0	0	0	1
10/16/2019 19:00	0.0	0	0	0	0	1
10/16/2019 20:00	0.0	0	0	0	0	1
10/16/2019 21:00	0.0	0	0	0	0	1
10/16/2019 22:00	0.0	0	0	0	0	1
10/16/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/17/2019 00:00	0.0	0	0	0	0	1
10/17/2019 01:00	0.0	0	0	0	0	1
10/17/2019 02:00	0.0	0	0	0	0	1
10/17/2019 03:00	0.0	0	0	0	0	1
10/17/2019 04:00	0.0	0	0	0	0	1
10/17/2019 05:00	0.0	0	0	0	0	1
10/17/2019 06:00	0.0	0	0	0	0	1
10/17/2019 07:00	0.0	0	0	0	0	1
10/17/2019 08:00	0.0	0	0	0	0	1
10/17/2019 09:00	0.0	0	0	0	0	1
10/17/2019 10:00	0.0	0	0	0	0	1
10/17/2019 11:00	0.0	0	0	0	0	1
10/17/2019 12:00	0.0	0	0	0	0	1
10/17/2019 13:00	0.0	0	0	0	0	1
10/17/2019 14:00	0.0	0	0	0	0	1
10/17/2019 15:00	0.0	0	0	0	0	1
10/17/2019 16:00	0.0	0	0	0	0	1
10/17/2019 17:00	0.0	0	0	0	0	1
10/17/2019 18:00	0.0	0	0	0	0	1
10/17/2019 19:00	0.0	0	0	0	0	1
10/17/2019 20:00	0.0	0	0	0	0	1
10/17/2019 21:00	0.0	0	0	0	0	1
10/17/2019 22:00	0.0	0	0	0	0	1
10/17/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/18/2019 00:00	0.0	0	0	0	0	1
10/18/2019 01:00	0.0	0	0	0	0	1
10/18/2019 02:00	0.0	0	0	0	0	1
10/18/2019 03:00	0.0	0	0	0	0	1
10/18/2019 04:00	0.0	0	0	0	0	1
10/18/2019 05:00	0.0	0	0	0	0	1
10/18/2019 06:00	0.0	0	0	0	0	1
10/18/2019 07:00	0.0	0	0	0	0	1
10/18/2019 08:00	0.0	0	0	0	0	1
10/18/2019 09:00	0.0	0	0	0	0	1
10/18/2019 10:00	0.0	0	0	0	0	1
10/18/2019 11:00	0.0	0	0	0	0	1
10/18/2019 12:00	0.0	0	0	0	0	1
10/18/2019 13:00	0.0	0	0	0	0	1
10/18/2019 14:00	0.0	0	0	0	0	1
10/18/2019 15:00	0.0	0	0	0	0	1
10/18/2019 16:00	0.0	0	0	0	0	1
10/18/2019 17:00	0.0	0	0	0	0	1
10/18/2019 18:00	0.0	0	0	0	0	1
10/18/2019 19:00	0.0	0	0	0	0	1
10/18/2019 20:00	0.0	0	0	0	0	1
10/18/2019 21:00	0.0	0	0	0	0	1
10/18/2019 22:00	0.0	0	0	0	0	1
10/18/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/19/2019 00:00	0.0	0	0	0	0	1
10/19/2019 01:00	0.0	0	0	0	0	1
10/19/2019 02:00	0.0	0	0	0	0	1
10/19/2019 03:00	0.0	0	0	0	0	1
10/19/2019 04:00	0.0	0	0	0	0	1
10/19/2019 05:00	0.0	0	0	0	0	1
10/19/2019 06:00	0.0	0	0	0	0	1
10/19/2019 07:00	107.1	0	0	0	1	0
10/19/2019 08:00	0.0	0	0	0	0	0
10/19/2019 09:00	0.0	0	0	0	0	0
10/19/2019 10:00	0.0	0	0	0	0	0
10/19/2019 11:00	0.0	0	0	0	0	0
10/19/2019 12:00	0.0	0	0	0	0	0
10/19/2019 13:00	0.0	0	0	0	0	0
10/19/2019 14:00	1,745.7	0	0	1	0	0
10/19/2019 15:00	6,819.2	0	0	1	0	0
10/19/2019 16:00	0.0	0	0	0	0	1
10/19/2019 17:00	0.0	0	0	0	0	1
10/19/2019 18:00	0.0	0	0	0	0	1
10/19/2019 19:00	0.0	0	0	0	0	1
10/19/2019 20:00	0.0	0	0	0	0	1
10/19/2019 21:00	0.0	0	0	0	0	1
10/19/2019 22:00	0.0	0	0	0	0	1
10/19/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,672.0 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,819.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/20/2019 00:00	0.0	0	0	0	0	1
10/20/2019 01:00	0.0	0	0	0	0	1
10/20/2019 02:00	96.4	0	0	0	1	0
10/20/2019 03:00	0.0	0	0	0	0	0
10/20/2019 04:00	0.0	0	0	0	0	0
10/20/2019 05:00	0.0	0	0	0	0	0
10/20/2019 06:00	0.0	0	0	0	0	0
10/20/2019 07:00	0.0	0	0	0	0	0
10/20/2019 08:00	0.0	0	0	0	0	0
10/20/2019 09:00	0.0	0	0	0	0	0
10/20/2019 10:00	3,366.4	0	1	0	0	0
10/20/2019 11:00	5,839.0	0	1	0	0	0
10/20/2019 12:00	0.0	0	0	0	0	1
10/20/2019 13:00	0.0	0	0	0	0	1
10/20/2019 14:00	0.0	0	0	0	0	1
10/20/2019 15:00	0.0	0	0	0	0	1
10/20/2019 16:00	0.0	0	0	0	0	1
10/20/2019 17:00	0.0	0	0	0	0	1
10/20/2019 18:00	0.0	0	0	0	0	1
10/20/2019 19:00	0.0	0	0	0	0	1
10/20/2019 20:00	0.0	0	0	0	0	1
10/20/2019 21:00	0.0	0	0	0	0	1
10/20/2019 22:00	0.0	0	0	0	0	1
10/20/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,301.8 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,839.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/21/2019 00:00	0.0	0	0	0	0	1
10/21/2019 01:00	0.0	0	0	0	0	1
10/21/2019 02:00	0.0	0	0	0	0	1
10/21/2019 03:00	0.0	0	0	0	0	1
10/21/2019 04:00	0.0	0	0	0	0	1
10/21/2019 05:00	0.0	0	0	0	0	1
10/21/2019 06:00	0.0	0	0	0	0	1
10/21/2019 07:00	0.0	0	0	0	0	1
10/21/2019 08:00	0.0	0	0	0	0	1
10/21/2019 09:00	0.0	0	0	0	0	1
10/21/2019 10:00	0.0	0	0	0	0	1
10/21/2019 11:00	0.0	0	0	0	0	1
10/21/2019 12:00	0.0	0	0	0	0	1
10/21/2019 13:00	0.0	0	0	0	0	1
10/21/2019 14:00	0.0	0	0	0	0	1
10/21/2019 15:00	0.0	0	0	0	0	1
10/21/2019 16:00	0.0	0	0	0	0	1
10/21/2019 17:00	0.0	0	0	0	0	1
10/21/2019 18:00	0.0	0	0	0	0	1
10/21/2019 19:00	0.0	0	0	0	0	1
10/21/2019 20:00	0.0	0	0	0	0	1
10/21/2019 21:00	0.0	0	0	0	0	1
10/21/2019 22:00	0.0	0	0	0	0	1
10/21/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/22/2019 00:00	0.0	0	0	0	0	1
10/22/2019 01:00	0.0	0	0	0	0	1
10/22/2019 02:00	0.0	0	0	0	0	1
10/22/2019 03:00	0.0	0	0	0	0	1
10/22/2019 04:00	0.0	0	0	0	0	1
10/22/2019 05:00	0.0	0	0	0	0	1
10/22/2019 06:00	0.0	0	0	0	0	1
10/22/2019 07:00	0.0	0	0	0	0	1
10/22/2019 08:00	0.0	0	0	0	0	1
10/22/2019 09:00	0.0	0	0	0	0	1
10/22/2019 10:00	0.0	0	0	0	0	1
10/22/2019 11:00	0.0	0	0	0	0	1
10/22/2019 12:00	0.0	0	0	0	0	1
10/22/2019 13:00	0.0	0	0	0	0	1
10/22/2019 14:00	0.0	0	0	0	0	1
10/22/2019 15:00	0.0	0	0	0	0	1
10/22/2019 16:00	0.0	0	0	0	0	1
10/22/2019 17:00	0.0	0	0	0	0	1
10/22/2019 18:00	0.0	0	0	0	0	1
10/22/2019 19:00	0.0	0	0	0	0	1
10/22/2019 20:00	0.0	0	0	0	0	1
10/22/2019 21:00	0.0	0	0	0	0	1
10/22/2019 22:00	0.0	0	0	0	0	1
10/22/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/23/2019 00:00	0.0	0	0	0	0	1
10/23/2019 01:00	0.0	0	0	0	0	1
10/23/2019 02:00	0.0	0	0	0	0	1
10/23/2019 03:00	0.0	0	0	0	0	1
10/23/2019 04:00	0.0	0	0	0	0	1
10/23/2019 05:00	0.0	0	0	0	0	1
10/23/2019 06:00	0.0	0	0	0	0	1
10/23/2019 07:00	0.0	0	0	0	0	1
10/23/2019 08:00	0.0	0	0	0	0	1
10/23/2019 09:00	0.0	0	0	0	0	1
10/23/2019 10:00	0.0	0	0	0	0	1
10/23/2019 11:00	0.0	0	0	0	0	1
10/23/2019 12:00	0.0	0	0	0	0	1
10/23/2019 13:00	0.0	0	0	0	0	1
10/23/2019 14:00	0.0	0	0	0	0	1
10/23/2019 15:00	0.0	0	0	0	0	1
10/23/2019 16:00	0.0	0	0	0	0	1
10/23/2019 17:00	0.0	0	0	0	0	1
10/23/2019 18:00	0.0	0	0	0	0	1
10/23/2019 19:00	0.0	0	0	0	0	1
10/23/2019 20:00	0.0	0	0	0	0	1
10/23/2019 21:00	0.0	0	0	0	0	1
10/23/2019 22:00	0.0	0	0	0	0	1
10/23/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/24/2019 00:00	0.0	0	0	0	0	1
10/24/2019 01:00	0.0	0	0	0	0	1
10/24/2019 02:00	0.0	0	0	0	0	1
10/24/2019 03:00	0.0	0	0	0	0	1
10/24/2019 04:00	0.0	0	0	0	0	1
10/24/2019 05:00	0.0	0	0	0	0	1
10/24/2019 06:00	0.0	0	0	0	0	1
10/24/2019 07:00	0.0	0	0	0	0	1
10/24/2019 08:00	0.0	0	0	0	0	1
10/24/2019 09:00	0.0	0	0	0	0	1
10/24/2019 10:00	0.0	0	0	0	0	1
10/24/2019 11:00	0.0	0	0	0	0	1
10/24/2019 12:00	0.0	0	0	0	0	1
10/24/2019 13:00	0.0	0	0	0	0	1
10/24/2019 14:00	0.0	0	0	0	0	1
10/24/2019 15:00	0.0	0	0	0	0	1
10/24/2019 16:00	0.0	0	0	0	0	1
10/24/2019 17:00	0.0	0	0	0	0	1
10/24/2019 18:00	0.0	0	0	0	0	1
10/24/2019 19:00	0.0	0	0	0	0	1
10/24/2019 20:00	0.0	0	0	0	0	1
10/24/2019 21:00	0.0	0	0	0	0	1
10/24/2019 22:00	0.0	0	0	0	0	1
10/24/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/25/2019 00:00	0.0	0	0	0	0	1
10/25/2019 01:00	0.0	0	0	0	0	1
10/25/2019 02:00	0.0	0	0	0	0	1
10/25/2019 03:00	0.0	0	0	0	0	1
10/25/2019 04:00	0.0	0	0	0	0	1
10/25/2019 05:00	0.0	0	0	0	0	1
10/25/2019 06:00	0.0	0	0	0	0	1
10/25/2019 07:00	0.0	0	0	0	0	1
10/25/2019 08:00	0.0	0	0	0	0	1
10/25/2019 09:00	0.0	0	0	0	0	1
10/25/2019 10:00	0.0	0	0	0	0	1
10/25/2019 11:00	0.0	0	0	0	0	1
10/25/2019 12:00	0.0	0	0	0	0	1
10/25/2019 13:00	0.0	0	0	0	0	1
10/25/2019 14:00	0.0	0	0	0	0	1
10/25/2019 15:00	0.0	0	0	0	0	1
10/25/2019 16:00	0.0	0	0	0	0	1
10/25/2019 17:00	0.0	0	0	0	0	1
10/25/2019 18:00	0.0	0	0	0	0	1
10/25/2019 19:00	0.0	0	0	0	0	1
10/25/2019 20:00	0.0	0	0	0	0	1
10/25/2019 21:00	0.0	0	0	0	0	1
10/25/2019 22:00	0.0	0	0	0	0	1
10/25/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/26/2019 00:00	0.0	0	0	0	0	1
10/26/2019 01:00	0.0	0	0	0	0	1
10/26/2019 02:00	0.0	0	0	0	0	1
10/26/2019 03:00	0.0	0	0	0	0	1
10/26/2019 04:00	0.0	0	0	0	0	1
10/26/2019 05:00	0.0	0	0	0	0	1
10/26/2019 06:00	0.0	0	0	0	0	1
10/26/2019 07:00	0.0	0	0	0	0	1
10/26/2019 08:00	0.0	0	0	0	0	1
10/26/2019 09:00	0.0	0	0	0	0	1
10/26/2019 10:00	0.0	0	0	0	0	1
10/26/2019 11:00	0.0	0	0	0	0	1
10/26/2019 12:00	0.0	0	0	0	0	1
10/26/2019 13:00	0.0	0	0	0	0	1
10/26/2019 14:00	0.0	0	0	0	0	1
10/26/2019 15:00	0.0	0	0	0	0	1
10/26/2019 16:00	0.0	0	0	0	0	1
10/26/2019 17:00	0.0	0	0	0	0	1
10/26/2019 18:00	0.0	0	0	0	0	1
10/26/2019 19:00	0.0	0	0	0	0	1
10/26/2019 20:00	0.0	0	0	0	0	1
10/26/2019 21:00	0.0	0	0	0	0	1
10/26/2019 22:00	91.2	0	0	0	1	0
10/26/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	91.2 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	91.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/27/2019 00:00	0.0	0	0	0	0	0
10/27/2019 01:00	0.0	0	0	0	0	0
10/27/2019 02:00	0.0	0	0	0	0	0
10/27/2019 03:00	0.0	0	0	0	0	0
10/27/2019 04:00	0.0	0	0	0	0	0
10/27/2019 05:00	0.0	0	0	0	0	0
10/27/2019 06:00	0.0	0	0	0	0	0
10/27/2019 07:00	0.0	0	0	0	0	0
10/27/2019 08:00	0.0	0	0	0	0	0
10/27/2019 09:00	0.0	0	0	0	0	0
10/27/2019 10:00	0.0	0	0	0	0	0
10/27/2019 11:00	0.0	0	0	0	0	0
10/27/2019 12:00	0.0	0	0	0	0	0
10/27/2019 13:00	0.0	0	0	0	0	0
10/27/2019 14:00	0.0	0	0	0	0	0
10/27/2019 15:00	0.0	0	0	0	0	0
10/27/2019 16:00	0.0	0	0	0	0	0
10/27/2019 17:00	1,689.5	0	1	0	0	0
10/27/2019 18:00	6,253.9	0	1	0	0	0
10/27/2019 19:00	6,721.9	0	1	0	0	0
10/27/2019 20:00	0.0	0	0	0	0	1
10/27/2019 21:00	0.0	0	0	0	0	1
10/27/2019 22:00	0.0	0	0	0	0	1
10/27/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	14,665.3 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,721.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/28/2019 00:00	0.0	0	0	0	0	1
10/28/2019 01:00	0.0	0	0	0	0	1
10/28/2019 02:00	0.0	0	0	0	0	1
10/28/2019 03:00	0.0	0	0	0	0	1
10/28/2019 04:00	0.0	0	0	0	0	1
10/28/2019 05:00	0.0	0	0	0	0	1
10/28/2019 06:00	0.0	0	0	0	0	1
10/28/2019 07:00	0.0	0	0	0	0	1
10/28/2019 08:00	0.0	0	0	0	0	1
10/28/2019 09:00	0.0	0	0	0	0	1
10/28/2019 10:00	0.0	0	0	0	0	1
10/28/2019 11:00	0.0	0	0	0	0	1
10/28/2019 12:00	0.0	0	0	0	0	1
10/28/2019 13:00	0.0	0	0	0	0	1
10/28/2019 14:00	0.0	0	0	0	0	1
10/28/2019 15:00	0.0	0	0	0	0	1
10/28/2019 16:00	0.0	0	0	0	0	1
10/28/2019 17:00	0.0	0	0	0	0	1
10/28/2019 18:00	0.0	0	0	0	0	1
10/28/2019 19:00	0.0	0	0	0	0	1
10/28/2019 20:00	0.0	0	0	0	0	1
10/28/2019 21:00	0.0	0	0	0	0	1
10/28/2019 22:00	0.0	0	0	0	0	1
10/28/2019 23:00	133.8	0	0	0	1	0
Average/Sum#:	133.8 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	133.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/29/2019 00:00	0.0	0	0	0	0	0
10/29/2019 01:00	0.0	0	0	0	0	0
10/29/2019 02:00	0.0	0	0	0	0	0
10/29/2019 03:00	0.0	0	0	0	0	0
10/29/2019 04:00	0.0	0	0	0	0	0
10/29/2019 05:00	0.0	0	0	0	0	0
10/29/2019 06:00	0.0	0	0	0	0	0
10/29/2019 07:00	0.0	0	0	0	0	0
10/29/2019 08:00	0.0	0	0	0	0	0
10/29/2019 09:00	0.0	0	0	0	0	0
10/29/2019 10:00	0.0	0	0	0	0	0
10/29/2019 11:00	0.0	0	0	0	0	0
10/29/2019 12:00	0.0	0	0	0	0	0
10/29/2019 13:00	0.0	0	0	0	0	0
10/29/2019 14:00	0.0	0	0	0	0	0
10/29/2019 15:00	0.0	0	0	0	0	0
10/29/2019 16:00	0.0	0	0	0	0	0
10/29/2019 17:00	0.0	0	0	0	0	0
10/29/2019 18:00	0.0	0	0	0	0	0
10/29/2019 19:00	0.0	0	0	0	0	0
10/29/2019 20:00	0.0	0	0	0	0	0
10/29/2019 21:00	0.0	0	0	0	0	0
10/29/2019 22:00	0.0	0	0	0	0	0
10/29/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/30/2019 00:00	3,033.5	0	1	0	0	0
10/30/2019 01:00	6,726.3	0	1	0	0	0
10/30/2019 02:00	5,968.5	0	1	0	0	0
10/30/2019 03:00	0.0	0	0	0	0	1
10/30/2019 04:00	0.0	0	0	0	0	1
10/30/2019 05:00	0.0	0	0	0	0	1
10/30/2019 06:00	0.0	0	0	0	0	1
10/30/2019 07:00	0.0	0	0	0	0	1
10/30/2019 08:00	0.0	0	0	0	0	1
10/30/2019 09:00	0.0	0	0	0	0	1
10/30/2019 10:00	0.0	0	0	0	0	1
10/30/2019 11:00	0.0	0	0	0	0	1
10/30/2019 12:00	0.0	0	0	0	0	1
10/30/2019 13:00	0.0	0	0	0	0	1
10/30/2019 14:00	0.0	0	0	0	0	1
10/30/2019 15:00	0.0	0	0	0	0	1
10/30/2019 16:00	0.0	0	0	0	0	1
10/30/2019 17:00	0.0	0	0	0	0	1
10/30/2019 18:00	0.0	0	0	0	0	1
10/30/2019 19:00	0.0	0	0	0	0	1
10/30/2019 20:00	0.0	0	0	0	0	1
10/30/2019 21:00	0.0	0	0	0	0	1
10/30/2019 22:00	0.0	0	0	0	0	1
10/30/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	15,728.3 #	0 #	3 #	0 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,726.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/31/2019 00:00	0.0	0	0	0	0	1
10/31/2019 01:00	0.0	0	0	0	0	1
10/31/2019 02:00	0.0	0	0	0	0	1
10/31/2019 03:00	0.0	0	0	0	0	1
10/31/2019 04:00	0.0	0	0	0	0	1
10/31/2019 05:00	0.0	0	0	0	0	1
10/31/2019 06:00	0.0	0	0	0	0	1
10/31/2019 07:00	0.0	0	0	0	0	1
10/31/2019 08:00	0.0	0	0	0	0	1
10/31/2019 09:00	0.0	0	0	0	0	1
10/31/2019 10:00	0.0	0	0	0	0	1
10/31/2019 11:00	0.0	0	0	0	0	1
10/31/2019 12:00	0.0	0	0	0	0	1
10/31/2019 13:00	0.0	0	0	0	0	1
10/31/2019 14:00	0.0	0	0	0	0	1
10/31/2019 15:00	0.0	0	0	0	0	1
10/31/2019 16:00	0.0	0	0	0	0	1
10/31/2019 17:00	0.0	0	0	0	0	1
10/31/2019 18:00	0.0	0	0	0	0	1
10/31/2019 19:00	0.0	0	0	0	0	1
10/31/2019 20:00	0.0	0	0	0	0	1
10/31/2019 21:00	0.0	0	0	0	0	1
10/31/2019 22:00	0.0	0	0	0	0	1
10/31/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/01/2019 00:00	0.0	0	0	0	0	1
11/01/2019 01:00	0.0	0	0	0	0	1
11/01/2019 02:00	0.0	0	0	0	0	1
11/01/2019 03:00	0.0	0	0	0	0	1
11/01/2019 04:00	0.0	0	0	0	0	1
11/01/2019 05:00	0.0	0	0	0	0	1
11/01/2019 06:00	0.0	0	0	0	0	1
11/01/2019 07:00	0.0	0	0	0	0	1
11/01/2019 08:00	0.0	0	0	0	0	1
11/01/2019 09:00	0.0	0	0	0	0	1
11/01/2019 10:00	0.0	0	0	0	0	1
11/01/2019 11:00	0.0	0	0	0	0	1
11/01/2019 12:00	0.0	0	0	0	0	1
11/01/2019 13:00	0.0	0	0	0	0	1
11/01/2019 14:00	0.0	0	0	0	0	1
11/01/2019 15:00	0.0	0	0	0	0	1
11/01/2019 16:00	0.0	0	0	0	0	1
11/01/2019 17:00	0.0	0	0	0	0	1
11/01/2019 18:00	0.0	0	0	0	0	1
11/01/2019 19:00	0.0	0	0	0	0	1
11/01/2019 20:00	0.0	0	0	0	0	1
11/01/2019 21:00	0.0	0	0	0	0	1
11/01/2019 22:00	0.0	0	0	0	0	1
11/01/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/02/2019 00:00	0.0	0	0	0	0	1
11/02/2019 01:00	0.0	0	0	0	0	1
11/02/2019 02:00	0.0	0	0	0	0	1
11/02/2019 03:00	0.0	0	0	0	0	1
11/02/2019 04:00	0.0	0	0	0	0	1
11/02/2019 05:00	0.0	0	0	0	0	1
11/02/2019 06:00	0.0	0	0	0	0	1
11/02/2019 07:00	0.0	0	0	0	0	1
11/02/2019 08:00	0.0	0	0	0	0	1
11/02/2019 09:00	0.0	0	0	0	0	1
11/02/2019 10:00	0.0	0	0	0	0	1
11/02/2019 11:00	0.0	0	0	0	0	1
11/02/2019 12:00	0.0	0	0	0	0	1
11/02/2019 13:00	134.5	0	0	0	1	0
11/02/2019 14:00	4,976.2	0	0	1	0	0
11/02/2019 15:00	1,114.3	0	0	1	0	0
11/02/2019 16:00	0.0	0	0	0	0	1
11/02/2019 17:00	0.0	0	0	0	0	1
11/02/2019 18:00	0.0	0	0	0	0	1
11/02/2019 19:00	0.0	0	0	0	0	1
11/02/2019 20:00	0.0	0	0	0	0	1
11/02/2019 21:00	0.0	0	0	0	0	1
11/02/2019 22:00	0.0	0	0	0	0	1
11/02/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,225.0 #	0 #	0 #	2 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,976.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/03/2019 00:00	0.0	0	0	0	0	1
11/03/2019 01:00	0.0	0	0	0	0	1
11/03/2019 02:00	0.0	0	0	0	0	1
11/03/2019 03:00	0.0	0	0	0	0	1
11/03/2019 04:00	0.0	0	0	0	0	1
11/03/2019 05:00	0.0	0	0	0	0	1
11/03/2019 06:00	0.0	0	0	0	0	1
11/03/2019 07:00	0.0	0	0	0	0	1
11/03/2019 08:00	0.0	0	0	0	0	1
11/03/2019 09:00	0.0	0	0	0	0	1
11/03/2019 10:00	0.0	0	0	0	0	1
11/03/2019 11:00	0.0	0	0	0	0	1
11/03/2019 12:00	0.0	0	0	0	0	1
11/03/2019 13:00	0.0	0	0	0	0	1
11/03/2019 14:00	0.0	0	0	0	0	1
11/03/2019 15:00	0.0	0	0	0	0	1
11/03/2019 16:00	0.0	0	0	0	0	1
11/03/2019 17:00	0.0	0	0	0	0	1
11/03/2019 18:00	0.0	0	0	0	0	1
11/03/2019 19:00	0.0	0	0	0	0	1
11/03/2019 20:00	0.0	0	0	0	0	1
11/03/2019 21:00	0.0	0	0	0	0	1
11/03/2019 22:00	0.0	0	0	0	0	1
11/03/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/04/2019 00:00	0.0	0	0	0	0	1
11/04/2019 01:00	0.0	0	0	0	0	1
11/04/2019 02:00	0.0	0	0	0	0	1
11/04/2019 03:00	0.0	0	0	0	0	1
11/04/2019 04:00	0.0	0	0	0	0	1
11/04/2019 05:00	0.0	0	0	0	0	1
11/04/2019 06:00	0.0	0	0	0	0	1
11/04/2019 07:00	0.0	0	0	0	0	1
11/04/2019 08:00	0.0	0	0	0	0	1
11/04/2019 09:00	0.0	0	0	0	0	1
11/04/2019 10:00	0.0	0	0	0	0	1
11/04/2019 11:00	0.0	0	0	0	0	1
11/04/2019 12:00	0.0	0	0	0	0	1
11/04/2019 13:00	0.0	0	0	0	0	1
11/04/2019 14:00	0.0	0	0	0	0	1
11/04/2019 15:00	0.0	0	0	0	0	1
11/04/2019 16:00	0.0	0	0	0	0	1
11/04/2019 17:00	0.0	0	0	0	0	1
11/04/2019 18:00	0.0	0	0	0	0	1
11/04/2019 19:00	0.0	0	0	0	0	1
11/04/2019 20:00	0.0	0	0	0	0	1
11/04/2019 21:00	0.0	0	0	0	0	1
11/04/2019 22:00	0.0	0	0	0	0	1
11/04/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/05/2019 00:00	0.0	0	0	0	0	1
11/05/2019 01:00	0.0	0	0	0	0	1
11/05/2019 02:00	0.0	0	0	0	0	1
11/05/2019 03:00	0.0	0	0	0	0	1
11/05/2019 04:00	0.0	0	0	0	0	1
11/05/2019 05:00	0.0	0	0	0	0	1
11/05/2019 06:00	0.0	0	0	0	0	1
11/05/2019 07:00	0.0	0	0	0	0	1
11/05/2019 08:00	0.0	0	0	0	0	1
11/05/2019 09:00	0.0	0	0	0	0	1
11/05/2019 10:00	0.0	0	0	0	0	1
11/05/2019 11:00	0.0	0	0	0	0	1
11/05/2019 12:00	0.0	0	0	0	0	1
11/05/2019 13:00	0.0	0	0	0	0	1
11/05/2019 14:00	0.0	0	0	0	0	1
11/05/2019 15:00	0.0	0	0	0	0	1
11/05/2019 16:00	0.0	0	0	0	0	1
11/05/2019 17:00	0.0	0	0	0	0	1
11/05/2019 18:00	0.0	0	0	0	0	1
11/05/2019 19:00	0.0	0	0	0	0	1
11/05/2019 20:00	0.0	0	0	0	0	1
11/05/2019 21:00	0.0	0	0	0	0	1
11/05/2019 22:00	0.0	0	0	0	0	1
11/05/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/06/2019 00:00	0.0	0	0	0	0	1
11/06/2019 01:00	0.0	0	0	0	0	1
11/06/2019 02:00	0.0	0	0	0	0	1
11/06/2019 03:00	0.0	0	0	0	0	1
11/06/2019 04:00	0.0	0	0	0	0	1
11/06/2019 05:00	0.0	0	0	0	0	1
11/06/2019 06:00	0.0	0	0	0	0	1
11/06/2019 07:00	0.0	0	0	0	0	1
11/06/2019 08:00	0.0	0	0	0	0	1
11/06/2019 09:00	0.0	0	0	0	0	1
11/06/2019 10:00	0.0	0	0	0	0	1
11/06/2019 11:00	0.0	0	0	0	0	1
11/06/2019 12:00	0.0	0	0	0	0	1
11/06/2019 13:00	0.0	0	0	0	0	1
11/06/2019 14:00	0.0	0	0	0	0	1
11/06/2019 15:00	0.0	0	0	0	0	1
11/06/2019 16:00	0.0	0	0	0	0	1
11/06/2019 17:00	0.0	0	0	0	0	1
11/06/2019 18:00	0.0	0	0	0	0	1
11/06/2019 19:00	0.0	0	0	0	0	1
11/06/2019 20:00	0.0	0	0	0	0	1
11/06/2019 21:00	0.0	0	0	0	0	1
11/06/2019 22:00	0.0	0	0	0	0	1
11/06/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/07/2019 00:00	0.0	0	0	0	0	1
11/07/2019 01:00	0.0	0	0	0	0	1
11/07/2019 02:00	0.0	0	0	0	0	1
11/07/2019 03:00	0.0	0	0	0	0	1
11/07/2019 04:00	0.0	0	0	0	0	1
11/07/2019 05:00	0.0	0	0	0	0	1
11/07/2019 06:00	0.0	0	0	0	0	1
11/07/2019 07:00	0.0	0	0	0	0	1
11/07/2019 08:00	0.0	0	0	0	0	1
11/07/2019 09:00	0.0	0	0	0	0	1
11/07/2019 10:00	0.0	0	0	0	0	1
11/07/2019 11:00	0.0	0	0	0	0	1
11/07/2019 12:00	0.0	0	0	0	0	1
11/07/2019 13:00	0.0	0	0	0	0	1
11/07/2019 14:00	0.0	0	0	0	0	1
11/07/2019 15:00	0.0	0	0	0	0	1
11/07/2019 16:00	0.0	0	0	0	0	1
11/07/2019 17:00	0.0	0	0	0	0	1
11/07/2019 18:00	0.0	0	0	0	0	1
11/07/2019 19:00	0.0	0	0	0	0	1
11/07/2019 20:00	0.0	0	0	0	0	1
11/07/2019 21:00	0.0	0	0	0	0	1
11/07/2019 22:00	0.0	0	0	0	0	1
11/07/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/08/2019 00:00	0.0	0	0	0	0	1
11/08/2019 01:00	0.0	0	0	0	0	1
11/08/2019 02:00	0.0	0	0	0	0	1
11/08/2019 03:00	0.0	0	0	0	0	1
11/08/2019 04:00	0.0	0	0	0	0	1
11/08/2019 05:00	0.0	0	0	0	0	1
11/08/2019 06:00	0.0	0	0	0	0	1
11/08/2019 07:00	0.0	0	0	0	0	1
11/08/2019 08:00	0.0	0	0	0	0	1
11/08/2019 09:00	0.0	0	0	0	0	1
11/08/2019 10:00	0.0	0	0	0	0	1
11/08/2019 11:00	0.0	0	0	0	0	1
11/08/2019 12:00	0.0	0	0	0	0	1
11/08/2019 13:00	0.0	0	0	0	0	1
11/08/2019 14:00	0.0	0	0	0	0	1
11/08/2019 15:00	0.0	0	0	0	0	1
11/08/2019 16:00	0.0	0	0	0	0	1
11/08/2019 17:00	0.0	0	0	0	0	1
11/08/2019 18:00	0.0	0	0	0	0	1
11/08/2019 19:00	0.0	0	0	0	0	1
11/08/2019 20:00	0.0	0	0	0	0	1
11/08/2019 21:00	0.0	0	0	0	0	1
11/08/2019 22:00	0.0	0	0	0	0	1
11/08/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/09/2019 00:00	0.0	0	0	0	0	1
11/09/2019 01:00	0.0	0	0	0	0	1
11/09/2019 02:00	0.0	0	0	0	0	1
11/09/2019 03:00	0.0	0	0	0	0	1
11/09/2019 04:00	0.0	0	0	0	0	1
11/09/2019 05:00	0.0	0	0	0	0	1
11/09/2019 06:00	0.0	0	0	0	0	1
11/09/2019 07:00	0.0	0	0	0	0	1
11/09/2019 08:00	0.0	0	0	0	0	1
11/09/2019 09:00	0.0	0	0	0	0	1
11/09/2019 10:00	0.0	0	0	0	0	1
11/09/2019 11:00	0.0	0	0	0	0	1
11/09/2019 12:00	0.0	0	0	0	0	1
11/09/2019 13:00	0.0	0	0	0	0	1
11/09/2019 14:00	0.0	0	0	0	0	1
11/09/2019 15:00	0.0	0	0	0	0	1
11/09/2019 16:00	0.0	0	0	0	0	1
11/09/2019 17:00	0.0	0	0	0	0	1
11/09/2019 18:00	0.0	0	0	0	0	1
11/09/2019 19:00	0.0	0	0	0	0	1
11/09/2019 20:00	0.0	0	0	0	0	1
11/09/2019 21:00	0.0	0	0	0	0	1
11/09/2019 22:00	0.0	0	0	0	0	1
11/09/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/10/2019 00:00	0.0	0	0	0	0	1
11/10/2019 01:00	0.0	0	0	0	0	1
11/10/2019 02:00	0.0	0	0	0	0	1
11/10/2019 03:00	0.0	0	0	0	0	1
11/10/2019 04:00	0.0	0	0	0	0	1
11/10/2019 05:00	0.0	0	0	0	0	1
11/10/2019 06:00	0.0	0	0	0	0	1
11/10/2019 07:00	0.0	0	0	0	0	1
11/10/2019 08:00	0.0	0	0	0	0	1
11/10/2019 09:00	0.0	0	0	0	0	1
11/10/2019 10:00	0.0	0	0	0	0	1
11/10/2019 11:00	0.0	0	0	0	0	1
11/10/2019 12:00	0.0	0	0	0	0	1
11/10/2019 13:00	0.0	0	0	0	0	1
11/10/2019 14:00	0.0	0	0	0	0	1
11/10/2019 15:00	0.0	0	0	0	0	1
11/10/2019 16:00	0.0	0	0	0	0	1
11/10/2019 17:00	0.0	0	0	0	0	1
11/10/2019 18:00	0.0	0	0	0	0	1
11/10/2019 19:00	0.0	0	0	0	0	1
11/10/2019 20:00	0.0	0	0	0	0	1
11/10/2019 21:00	0.0	0	0	0	0	1
11/10/2019 22:00	0.0	0	0	0	0	1
11/10/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/11/2019 00:00	0.0	0	0	0	0	1
11/11/2019 01:00	0.0	0	0	0	0	1
11/11/2019 02:00	0.0	0	0	0	0	1
11/11/2019 03:00	0.0	0	0	0	0	1
11/11/2019 04:00	0.0	0	0	0	0	1
11/11/2019 05:00	0.0	0	0	0	0	1
11/11/2019 06:00	0.0	0	0	0	0	1
11/11/2019 07:00	0.0	0	0	0	0	1
11/11/2019 08:00	0.0	0	0	0	0	1
11/11/2019 09:00	0.0	0	0	0	0	1
11/11/2019 10:00	0.0	0	0	0	0	1
11/11/2019 11:00	0.0	0	0	0	0	1
11/11/2019 12:00	0.0	0	0	0	0	1
11/11/2019 13:00	0.0	0	0	0	0	1
11/11/2019 14:00	0.0	0	0	0	0	1
11/11/2019 15:00	0.0	0	0	0	0	1
11/11/2019 16:00	0.0	0	0	0	0	1
11/11/2019 17:00	0.0	0	0	0	0	1
11/11/2019 18:00	0.0	0	0	0	0	1
11/11/2019 19:00	0.0	0	0	0	0	1
11/11/2019 20:00	0.0	0	0	0	0	1
11/11/2019 21:00	0.0	0	0	0	0	1
11/11/2019 22:00	0.0	0	0	0	0	1
11/11/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/12/2019 00:00	0.0	0	0	0	0	1
11/12/2019 01:00	0.0	0	0	0	0	1
11/12/2019 02:00	0.0	0	0	0	0	1
11/12/2019 03:00	0.0	0	0	0	0	1
11/12/2019 04:00	0.0	0	0	0	0	1
11/12/2019 05:00	0.0	0	0	0	0	1
11/12/2019 06:00	0.0	0	0	0	0	1
11/12/2019 07:00	0.0	0	0	0	0	1
11/12/2019 08:00	0.0	0	0	0	0	1
11/12/2019 09:00	0.0	0	0	0	0	1
11/12/2019 10:00	0.0	0	0	0	0	1
11/12/2019 11:00	0.0	0	0	0	0	1
11/12/2019 12:00	0.0	0	0	0	0	1
11/12/2019 13:00	0.0	0	0	0	0	1
11/12/2019 14:00	0.0	0	0	0	0	1
11/12/2019 15:00	0.0	0	0	0	0	1
11/12/2019 16:00	0.0	0	0	0	0	1
11/12/2019 17:00	0.0	0	0	0	0	1
11/12/2019 18:00	0.0	0	0	0	0	1
11/12/2019 19:00	0.0	0	0	0	0	1
11/12/2019 20:00	0.0	0	0	0	0	1
11/12/2019 21:00	0.0	0	0	0	0	1
11/12/2019 22:00	0.0	0	0	0	0	1
11/12/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/13/2019 00:00	0.0	0	0	0	0	1
11/13/2019 01:00	0.0	0	0	0	0	1
11/13/2019 02:00	0.0	0	0	0	0	1
11/13/2019 03:00	0.0	0	0	0	0	1
11/13/2019 04:00	0.0	0	0	0	0	1
11/13/2019 05:00	0.0	0	0	0	0	1
11/13/2019 06:00	0.0	0	0	0	0	1
11/13/2019 07:00	0.0	0	0	0	0	1
11/13/2019 08:00	0.0	0	0	0	0	1
11/13/2019 09:00	0.0	0	0	0	0	1
11/13/2019 10:00	0.0	0	0	0	0	1
11/13/2019 11:00	0.0	0	0	0	0	1
11/13/2019 12:00	0.0	0	0	0	0	1
11/13/2019 13:00	0.0	0	0	0	0	1
11/13/2019 14:00	0.0	0	0	0	0	1
11/13/2019 15:00	0.0	0	0	0	0	1
11/13/2019 16:00	0.0	0	0	0	0	1
11/13/2019 17:00	0.0	0	0	0	0	1
11/13/2019 18:00	0.0	0	0	0	0	1
11/13/2019 19:00	0.0	0	0	0	0	1
11/13/2019 20:00	0.0	0	0	0	0	1
11/13/2019 21:00	0.0	0	0	0	0	1
11/13/2019 22:00	0.0	0	0	0	0	1
11/13/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/14/2019 00:00	0.0	0	0	0	0	1
11/14/2019 01:00	0.0	0	0	0	0	1
11/14/2019 02:00	0.0	0	0	0	0	1
11/14/2019 03:00	0.0	0	0	0	0	1
11/14/2019 04:00	0.0	0	0	0	0	1
11/14/2019 05:00	0.0	0	0	0	0	1
11/14/2019 06:00	0.0	0	0	0	0	1
11/14/2019 07:00	0.0	0	0	0	0	1
11/14/2019 08:00	0.0	0	0	0	0	1
11/14/2019 09:00	0.0	0	0	0	0	1
11/14/2019 10:00	0.0	0	0	0	0	1
11/14/2019 11:00	0.0	0	0	0	0	1
11/14/2019 12:00	0.0	0	0	0	0	1
11/14/2019 13:00	0.0	0	0	0	0	1
11/14/2019 14:00	0.0	0	0	0	0	1
11/14/2019 15:00	0.0	0	0	0	0	1
11/14/2019 16:00	0.0	0	0	0	0	1
11/14/2019 17:00	0.0	0	0	0	0	1
11/14/2019 18:00	0.0	0	0	0	0	1
11/14/2019 19:00	0.0	0	0	0	0	1
11/14/2019 20:00	0.0	0	0	0	0	1
11/14/2019 21:00	0.0	0	0	0	0	1
11/14/2019 22:00	0.0	0	0	0	0	1
11/14/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/15/2019 00:00	0.0	0	0	0	0	1
11/15/2019 01:00	0.0	0	0	0	0	1
11/15/2019 02:00	0.0	0	0	0	0	1
11/15/2019 03:00	0.0	0	0	0	0	1
11/15/2019 04:00	0.0	0	0	0	0	1
11/15/2019 05:00	0.0	0	0	0	0	1
11/15/2019 06:00	0.0	0	0	0	0	1
11/15/2019 07:00	0.0	0	0	0	0	1
11/15/2019 08:00	0.0	0	0	0	0	1
11/15/2019 09:00	0.0	0	0	0	0	1
11/15/2019 10:00	0.0	0	0	0	0	1
11/15/2019 11:00	0.0	0	0	0	0	1
11/15/2019 12:00	0.0	0	0	0	0	1
11/15/2019 13:00	0.0	0	0	0	0	1
11/15/2019 14:00	0.0	0	0	0	0	1
11/15/2019 15:00	0.0	0	0	0	0	1
11/15/2019 16:00	0.0	0	0	0	0	1
11/15/2019 17:00	0.0	0	0	0	0	1
11/15/2019 18:00	0.0	0	0	0	0	1
11/15/2019 19:00	0.0	0	0	0	0	1
11/15/2019 20:00	0.0	0	0	0	0	1
11/15/2019 21:00	0.0	0	0	0	0	1
11/15/2019 22:00	0.0	0	0	0	0	1
11/15/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/16/2019 00:00	0.0	0	0	0	0	1
11/16/2019 01:00	0.0	0	0	0	0	1
11/16/2019 02:00	0.0	0	0	0	0	1
11/16/2019 03:00	0.0	0	0	0	0	1
11/16/2019 04:00	0.0	0	0	0	0	1
11/16/2019 05:00	0.0	0	0	0	0	1
11/16/2019 06:00	0.0	0	0	0	0	1
11/16/2019 07:00	0.0	0	0	0	0	1
11/16/2019 08:00	0.0	0	0	0	0	1
11/16/2019 09:00	0.0	0	0	0	0	1
11/16/2019 10:00	0.0	0	0	0	0	1
11/16/2019 11:00	0.0	0	0	0	0	1
11/16/2019 12:00	0.0	0	0	0	0	1
11/16/2019 13:00	0.0	0	0	0	0	1
11/16/2019 14:00	0.0	0	0	0	0	1
11/16/2019 15:00	0.0	0	0	0	0	1
11/16/2019 16:00	0.0	0	0	0	0	1
11/16/2019 17:00	0.0	0	0	0	0	1
11/16/2019 18:00	0.0	0	0	0	0	1
11/16/2019 19:00	0.0	0	0	0	0	1
11/16/2019 20:00	0.0	0	0	0	0	1
11/16/2019 21:00	0.0	0	0	0	0	1
11/16/2019 22:00	0.0	0	0	0	0	1
11/16/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/17/2019 00:00	0.0	0	0	0	0	1
11/17/2019 01:00	0.0	0	0	0	0	1
11/17/2019 02:00	0.0	0	0	0	0	1
11/17/2019 03:00	0.0	0	0	0	0	1
11/17/2019 04:00	0.0	0	0	0	0	1
11/17/2019 05:00	0.0	0	0	0	0	1
11/17/2019 06:00	0.0	0	0	0	0	1
11/17/2019 07:00	0.0	0	0	0	0	1
11/17/2019 08:00	0.0	0	0	0	0	1
11/17/2019 09:00	0.0	0	0	0	0	1
11/17/2019 10:00	0.0	0	0	0	0	1
11/17/2019 11:00	0.0	0	0	0	0	1
11/17/2019 12:00	0.0	0	0	0	0	1
11/17/2019 13:00	0.0	0	0	0	0	1
11/17/2019 14:00	0.0	0	0	0	0	1
11/17/2019 15:00	0.0	0	0	0	0	1
11/17/2019 16:00	0.0	0	0	0	0	1
11/17/2019 17:00	0.0	0	0	0	0	1
11/17/2019 18:00	0.0	0	0	0	0	1
11/17/2019 19:00	0.0	0	0	0	0	1
11/17/2019 20:00	0.0	0	0	0	0	1
11/17/2019 21:00	0.0	0	0	0	0	1
11/17/2019 22:00	0.0	0	0	0	0	1
11/17/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/18/2019 00:00	0.0	0	0	0	0	1
11/18/2019 01:00	0.0	0	0	0	0	1
11/18/2019 02:00	0.0	0	0	0	0	1
11/18/2019 03:00	0.0	0	0	0	0	1
11/18/2019 04:00	0.0	0	0	0	0	1
11/18/2019 05:00	0.0	0	0	0	0	1
11/18/2019 06:00	0.0	0	0	0	0	1
11/18/2019 07:00	0.0	0	0	0	0	1
11/18/2019 08:00	0.0	0	0	0	0	1
11/18/2019 09:00	0.0	0	0	0	0	1
11/18/2019 10:00	0.0	0	0	0	0	1
11/18/2019 11:00	0.0	0	0	0	0	1
11/18/2019 12:00	0.0	0	0	0	0	1
11/18/2019 13:00	0.0	0	0	0	0	1
11/18/2019 14:00	0.0	0	0	0	0	1
11/18/2019 15:00	0.0	0	0	0	0	1
11/18/2019 16:00	0.0	0	0	0	0	1
11/18/2019 17:00	0.0	0	0	0	0	1
11/18/2019 18:00	0.0	0	0	0	0	1
11/18/2019 19:00	0.0	0	0	0	0	1
11/18/2019 20:00	0.0	0	0	0	0	1
11/18/2019 21:00	0.0	0	0	0	0	1
11/18/2019 22:00	0.0	0	0	0	0	1
11/18/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/19/2019 00:00	0.0	0	0	0	0	1
11/19/2019 01:00	0.0	0	0	0	0	1
11/19/2019 02:00	0.0	0	0	0	0	1
11/19/2019 03:00	0.0	0	0	0	0	1
11/19/2019 04:00	0.0	0	0	0	0	1
11/19/2019 05:00	0.0	0	0	0	0	1
11/19/2019 06:00	0.0	0	0	0	0	1
11/19/2019 07:00	0.0	0	0	0	0	1
11/19/2019 08:00	0.0	0	0	0	0	1
11/19/2019 09:00	0.0	0	0	0	0	1
11/19/2019 10:00	0.0	0	0	0	0	1
11/19/2019 11:00	0.0	0	0	0	0	1
11/19/2019 12:00	0.0	0	0	0	0	1
11/19/2019 13:00	0.0	0	0	0	0	1
11/19/2019 14:00	0.0	0	0	0	0	1
11/19/2019 15:00	0.0	0	0	0	0	1
11/19/2019 16:00	0.0	0	0	0	0	1
11/19/2019 17:00	0.0	0	0	0	0	1
11/19/2019 18:00	0.0	0	0	0	0	1
11/19/2019 19:00	0.0	0	0	0	0	1
11/19/2019 20:00	0.0	0	0	0	0	1
11/19/2019 21:00	0.0	0	0	0	0	1
11/19/2019 22:00	0.0	0	0	0	0	1
11/19/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/20/2019 00:00	0.0	0	0	0	0	1
11/20/2019 01:00	0.0	0	0	0	0	1
11/20/2019 02:00	0.0	0	0	0	0	1
11/20/2019 03:00	0.0	0	0	0	0	1
11/20/2019 04:00	0.0	0	0	0	0	1
11/20/2019 05:00	0.0	0	0	0	0	1
11/20/2019 06:00	0.0	0	0	0	0	1
11/20/2019 07:00	0.0	0	0	0	0	1
11/20/2019 08:00	0.0	0	0	0	0	1
11/20/2019 09:00	0.0	0	0	0	0	1
11/20/2019 10:00	0.0	0	0	0	0	1
11/20/2019 11:00	0.0	0	0	0	0	1
11/20/2019 12:00	0.0	0	0	0	0	1
11/20/2019 13:00	0.0	0	0	0	0	1
11/20/2019 14:00	0.0	0	0	0	0	1
11/20/2019 15:00	0.0	0	0	0	0	1
11/20/2019 16:00	0.0	0	0	0	0	1
11/20/2019 17:00	0.0	0	0	0	0	1
11/20/2019 18:00	0.0	0	0	0	0	1
11/20/2019 19:00	0.0	0	0	0	0	1
11/20/2019 20:00	0.0	0	0	0	0	1
11/20/2019 21:00	0.0	0	0	0	0	1
11/20/2019 22:00	0.0	0	0	0	0	1
11/20/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/21/2019 00:00	0.0	0	0	0	0	1
11/21/2019 01:00	0.0	0	0	0	0	1
11/21/2019 02:00	0.0	0	0	0	0	1
11/21/2019 03:00	0.0	0	0	0	0	1
11/21/2019 04:00	0.0	0	0	0	0	1
11/21/2019 05:00	0.0	0	0	0	0	1
11/21/2019 06:00	0.0	0	0	0	0	1
11/21/2019 07:00	0.0	0	0	0	0	1
11/21/2019 08:00	0.0	0	0	0	0	1
11/21/2019 09:00	0.0	0	0	0	0	1
11/21/2019 10:00	0.0	0	0	0	0	1
11/21/2019 11:00	0.0	0	0	0	0	1
11/21/2019 12:00	0.0	0	0	0	0	1
11/21/2019 13:00	0.0	0	0	0	0	1
11/21/2019 14:00	0.0	0	0	0	0	1
11/21/2019 15:00	0.0	0	0	0	0	1
11/21/2019 16:00	0.0	0	0	0	0	1
11/21/2019 17:00	0.0	0	0	0	0	1
11/21/2019 18:00	0.0	0	0	0	0	1
11/21/2019 19:00	0.0	0	0	0	0	1
11/21/2019 20:00	0.0	0	0	0	0	1
11/21/2019 21:00	0.0	0	0	0	0	1
11/21/2019 22:00	0.0	0	0	0	0	1
11/21/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/22/2019 00:00	0.0	0	0	0	0	1
11/22/2019 01:00	0.0	0	0	0	0	1
11/22/2019 02:00	0.0	0	0	0	0	1
11/22/2019 03:00	0.0	0	0	0	0	1
11/22/2019 04:00	0.0	0	0	0	0	1
11/22/2019 05:00	0.0	0	0	0	0	1
11/22/2019 06:00	0.0	0	0	0	0	1
11/22/2019 07:00	0.0	0	0	0	0	1
11/22/2019 08:00	0.0	0	0	0	0	1
11/22/2019 09:00	0.0	0	0	0	0	1
11/22/2019 10:00	0.0	0	0	0	0	1
11/22/2019 11:00	0.0	0	0	0	0	1
11/22/2019 12:00	0.0	0	0	0	0	1
11/22/2019 13:00	0.0	0	0	0	0	1
11/22/2019 14:00	0.0	0	0	0	0	1
11/22/2019 15:00	0.0	0	0	0	0	1
11/22/2019 16:00	0.0	0	0	0	0	1
11/22/2019 17:00	0.0	0	0	0	0	1
11/22/2019 18:00	0.0	0	0	0	0	1
11/22/2019 19:00	0.0	0	0	0	0	1
11/22/2019 20:00	0.0	0	0	0	0	1
11/22/2019 21:00	0.0	0	0	0	0	1
11/22/2019 22:00	0.0	0	0	0	0	1
11/22/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/23/2019 00:00	0.0	0	0	0	0	1
11/23/2019 01:00	0.0	0	0	0	0	1
11/23/2019 02:00	0.0	0	0	0	0	1
11/23/2019 03:00	0.0	0	0	0	0	1
11/23/2019 04:00	0.0	0	0	0	0	1
11/23/2019 05:00	0.0	0	0	0	0	1
11/23/2019 06:00	0.0	0	0	0	0	1
11/23/2019 07:00	0.0	0	0	0	0	1
11/23/2019 08:00	0.0	0	0	0	0	1
11/23/2019 09:00	0.0	0	0	0	0	1
11/23/2019 10:00	0.0	0	0	0	0	1
11/23/2019 11:00	0.0	0	0	0	0	1
11/23/2019 12:00	0.0	0	0	0	0	1
11/23/2019 13:00	0.0	0	0	0	0	1
11/23/2019 14:00	0.0	0	0	0	0	1
11/23/2019 15:00	0.0	0	0	0	0	1
11/23/2019 16:00	0.0	0	0	0	0	1
11/23/2019 17:00	0.0	0	0	0	0	1
11/23/2019 18:00	0.0	0	0	0	0	1
11/23/2019 19:00	0.0	0	0	0	0	1
11/23/2019 20:00	0.0	0	0	0	0	1
11/23/2019 21:00	0.0	0	0	0	0	1
11/23/2019 22:00	0.0	0	0	0	0	1
11/23/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/24/2019 00:00	0.0	0	0	0	0	1
11/24/2019 01:00	0.0	0	0	0	0	1
11/24/2019 02:00	0.0	0	0	0	0	1
11/24/2019 03:00	0.0	0	0	0	0	1
11/24/2019 04:00	0.0	0	0	0	0	1
11/24/2019 05:00	0.0	0	0	0	0	1
11/24/2019 06:00	0.0	0	0	0	0	1
11/24/2019 07:00	0.0	0	0	0	0	1
11/24/2019 08:00	0.0	0	0	0	0	1
11/24/2019 09:00	0.0	0	0	0	0	1
11/24/2019 10:00	0.0	0	0	0	0	1
11/24/2019 11:00	0.0	0	0	0	0	1
11/24/2019 12:00	0.0	0	0	0	0	1
11/24/2019 13:00	0.0	0	0	0	0	1
11/24/2019 14:00	0.0	0	0	0	0	1
11/24/2019 15:00	0.0	0	0	0	0	1
11/24/2019 16:00	0.0	0	0	0	0	1
11/24/2019 17:00	0.0	0	0	0	0	1
11/24/2019 18:00	0.0	0	0	0	0	1
11/24/2019 19:00	0.0	0	0	0	0	1
11/24/2019 20:00	0.0	0	0	0	0	1
11/24/2019 21:00	0.0	0	0	0	0	1
11/24/2019 22:00	0.0	0	0	0	0	1
11/24/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/25/2019 00:00	0.0	0	0	0	0	1
11/25/2019 01:00	0.0	0	0	0	0	1
11/25/2019 02:00	0.0	0	0	0	0	1
11/25/2019 03:00	0.0	0	0	0	0	1
11/25/2019 04:00	0.0	0	0	0	0	1
11/25/2019 05:00	0.0	0	0	0	0	1
11/25/2019 06:00	0.0	0	0	0	0	1
11/25/2019 07:00	0.0	0	0	0	0	1
11/25/2019 08:00	0.0	0	0	0	0	1
11/25/2019 09:00	0.0	0	0	0	0	1
11/25/2019 10:00	0.0	0	0	0	0	1
11/25/2019 11:00	0.0	0	0	0	0	1
11/25/2019 12:00	0.0	0	0	0	0	1
11/25/2019 13:00	0.0	0	0	0	0	1
11/25/2019 14:00	0.0	0	0	0	0	1
11/25/2019 15:00	0.0	0	0	0	0	1
11/25/2019 16:00	0.0	0	0	0	0	1
11/25/2019 17:00	0.0	0	0	0	0	1
11/25/2019 18:00	0.0	0	0	0	0	1
11/25/2019 19:00	0.0	0	0	0	0	1
11/25/2019 20:00	0.0	0	0	0	0	1
11/25/2019 21:00	0.0	0	0	0	0	1
11/25/2019 22:00	0.0	0	0	0	0	1
11/25/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/26/2019 00:00	0.0	0	0	0	0	1
11/26/2019 01:00	0.0	0	0	0	0	1
11/26/2019 02:00	0.0	0	0	0	0	1
11/26/2019 03:00	0.0	0	0	0	0	1
11/26/2019 04:00	0.0	0	0	0	0	1
11/26/2019 05:00	0.0	0	0	0	0	1
11/26/2019 06:00	0.0	0	0	0	0	1
11/26/2019 07:00	0.0	0	0	0	0	1
11/26/2019 08:00	0.0	0	0	0	0	1
11/26/2019 09:00	0.0	0	0	0	0	1
11/26/2019 10:00	0.0	0	0	0	0	1
11/26/2019 11:00	0.0	0	0	0	0	1
11/26/2019 12:00	0.0	0	0	0	0	1
11/26/2019 13:00	0.0	0	0	0	0	1
11/26/2019 14:00	0.0	0	0	0	0	1
11/26/2019 15:00	0.0	0	0	0	0	1
11/26/2019 16:00	0.0	0	0	0	0	1
11/26/2019 17:00	0.0	0	0	0	0	1
11/26/2019 18:00	0.0	0	0	0	0	1
11/26/2019 19:00	0.0	0	0	0	0	1
11/26/2019 20:00	0.0	0	0	0	0	1
11/26/2019 21:00	0.0	0	0	0	0	1
11/26/2019 22:00	0.0	0	0	0	0	1
11/26/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/27/2019 00:00	0.0	0	0	0	0	1
11/27/2019 01:00	0.0	0	0	0	0	1
11/27/2019 02:00	0.0	0	0	0	0	1
11/27/2019 03:00	0.0	0	0	0	0	1
11/27/2019 04:00	0.0	0	0	0	0	1
11/27/2019 05:00	0.0	0	0	0	0	1
11/27/2019 06:00	0.0	0	0	0	0	1
11/27/2019 07:00	0.0	0	0	0	0	1
11/27/2019 08:00	0.0	0	0	0	0	1
11/27/2019 09:00	0.0	0	0	0	0	1
11/27/2019 10:00	0.0	0	0	0	0	1
11/27/2019 11:00	0.0	0	0	0	0	1
11/27/2019 12:00	0.0	0	0	0	0	1
11/27/2019 13:00	0.0	0	0	0	0	1
11/27/2019 14:00	0.0	0	0	0	0	1
11/27/2019 15:00	0.0	0	0	0	0	1
11/27/2019 16:00	0.0	0	0	0	0	1
11/27/2019 17:00	0.0	0	0	0	0	1
11/27/2019 18:00	0.0	0	0	0	0	1
11/27/2019 19:00	0.0	0	0	0	0	1
11/27/2019 20:00	0.0	0	0	0	0	1
11/27/2019 21:00	0.0	0	0	0	0	1
11/27/2019 22:00	0.0	0	0	0	0	1
11/27/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/28/2019 00:00	0.0	0	0	0	0	1
11/28/2019 01:00	0.0	0	0	0	0	1
11/28/2019 02:00	0.0	0	0	0	0	1
11/28/2019 03:00	0.0	0	0	0	0	1
11/28/2019 04:00	0.0	0	0	0	0	1
11/28/2019 05:00	0.0	0	0	0	0	1
11/28/2019 06:00	0.0	0	0	0	0	1
11/28/2019 07:00	0.0	0	0	0	0	1
11/28/2019 08:00	0.0	0	0	0	0	1
11/28/2019 09:00	0.0	0	0	0	0	1
11/28/2019 10:00	0.0	0	0	0	0	1
11/28/2019 11:00	0.0	0	0	0	0	1
11/28/2019 12:00	0.0	0	0	0	0	1
11/28/2019 13:00	0.0	0	0	0	0	1
11/28/2019 14:00	0.0	0	0	0	0	1
11/28/2019 15:00	0.0	0	0	0	0	1
11/28/2019 16:00	0.0	0	0	0	0	1
11/28/2019 17:00	0.0	0	0	0	0	1
11/28/2019 18:00	0.0	0	0	0	0	1
11/28/2019 19:00	0.0	0	0	0	0	1
11/28/2019 20:00	0.0	0	0	0	0	1
11/28/2019 21:00	0.0	0	0	0	0	1
11/28/2019 22:00	0.0	0	0	0	0	1
11/28/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/29/2019 00:00	0.0	0	0	0	0	1
11/29/2019 01:00	0.0	0	0	0	0	1
11/29/2019 02:00	0.0	0	0	0	0	1
11/29/2019 03:00	0.0	0	0	0	0	1
11/29/2019 04:00	0.0	0	0	0	0	1
11/29/2019 05:00	0.0	0	0	0	0	1
11/29/2019 06:00	0.0	0	0	0	0	1
11/29/2019 07:00	0.0	0	0	0	0	1
11/29/2019 08:00	0.0	0	0	0	0	1
11/29/2019 09:00	0.0	0	0	0	0	1
11/29/2019 10:00	0.0	0	0	0	0	1
11/29/2019 11:00	0.0	0	0	0	0	1
11/29/2019 12:00	0.0	0	0	0	0	1
11/29/2019 13:00	0.0	0	0	0	0	1
11/29/2019 14:00	0.0	0	0	0	0	1
11/29/2019 15:00	0.0	0	0	0	0	1
11/29/2019 16:00	0.0	0	0	0	0	1
11/29/2019 17:00	0.0	0	0	0	0	1
11/29/2019 18:00	0.0	0	0	0	0	1
11/29/2019 19:00	0.0	0	0	0	0	1
11/29/2019 20:00	0.0	0	0	0	0	1
11/29/2019 21:00	0.0	0	0	0	0	1
11/29/2019 22:00	0.0	0	0	0	0	1
11/29/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/30/2019 00:00	0.0	0	0	0	0	1
11/30/2019 01:00	0.0	0	0	0	0	1
11/30/2019 02:00	0.0	0	0	0	0	1
11/30/2019 03:00	0.0	0	0	0	0	1
11/30/2019 04:00	0.0	0	0	0	0	1
11/30/2019 05:00	0.0	0	0	0	0	1
11/30/2019 06:00	0.0	0	0	0	0	1
11/30/2019 07:00	0.0	0	0	0	0	1
11/30/2019 08:00	0.0	0	0	0	0	1
11/30/2019 09:00	0.0	0	0	0	0	1
11/30/2019 10:00	0.0	0	0	0	0	1
11/30/2019 11:00	0.0	0	0	0	0	1
11/30/2019 12:00	0.0	0	0	0	0	1
11/30/2019 13:00	0.0	0	0	0	0	1
11/30/2019 14:00	0.0	0	0	0	0	1
11/30/2019 15:00	0.0	0	0	0	0	1
11/30/2019 16:00	0.0	0	0	0	0	1
11/30/2019 17:00	0.0	0	0	0	0	1
11/30/2019 18:00	0.0	0	0	0	0	1
11/30/2019 19:00	0.0	0	0	0	0	1
11/30/2019 20:00	0.0	0	0	0	0	1
11/30/2019 21:00	0.0	0	0	0	0	1
11/30/2019 22:00	0.0	0	0	0	0	1
11/30/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/01/2019 00:00	0.0	0	0	0	0	1
12/01/2019 01:00	0.0	0	0	0	0	1
12/01/2019 02:00	0.0	0	0	0	0	1
12/01/2019 03:00	0.0	0	0	0	0	1
12/01/2019 04:00	0.0	0	0	0	0	1
12/01/2019 05:00	0.0	0	0	0	0	1
12/01/2019 06:00	0.0	0	0	0	0	1
12/01/2019 07:00	0.0	0	0	0	0	1
12/01/2019 08:00	0.0	0	0	0	0	1
12/01/2019 09:00	0.0	0	0	0	0	1
12/01/2019 10:00	0.0	0	0	0	0	1
12/01/2019 11:00	0.0	0	0	0	0	1
12/01/2019 12:00	0.0	0	0	0	0	1
12/01/2019 13:00	0.0	0	0	0	0	1
12/01/2019 14:00	0.0	0	0	0	0	1
12/01/2019 15:00	0.0	0	0	0	0	1
12/01/2019 16:00	0.0	0	0	0	0	1
12/01/2019 17:00	0.0	0	0	0	0	1
12/01/2019 18:00	0.0	0	0	0	0	1
12/01/2019 19:00	0.0	0	0	0	0	1
12/01/2019 20:00	0.0	0	0	0	0	1
12/01/2019 21:00	0.0	0	0	0	0	1
12/01/2019 22:00	0.0	0	0	0	0	1
12/01/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/02/2019 00:00	0.0	0	0	0	0	1
12/02/2019 01:00	0.0	0	0	0	0	1
12/02/2019 02:00	0.0	0	0	0	0	1
12/02/2019 03:00	0.0	0	0	0	0	1
12/02/2019 04:00	0.0	0	0	0	0	1
12/02/2019 05:00	0.0	0	0	0	0	1
12/02/2019 06:00	0.0	0	0	0	0	1
12/02/2019 07:00	0.0	0	0	0	0	1
12/02/2019 08:00	0.0	0	0	0	0	1
12/02/2019 09:00	0.0	0	0	0	0	1
12/02/2019 10:00	0.0	0	0	0	0	1
12/02/2019 11:00	0.0	0	0	0	0	1
12/02/2019 12:00	0.0	0	0	0	0	1
12/02/2019 13:00	0.0	0	0	0	0	1
12/02/2019 14:00	0.0	0	0	0	0	1
12/02/2019 15:00	0.0	0	0	0	0	1
12/02/2019 16:00	0.0	0	0	0	0	1
12/02/2019 17:00	0.0	0	0	0	0	1
12/02/2019 18:00	0.0	0	0	0	0	1
12/02/2019 19:00	0.0	0	0	0	0	1
12/02/2019 20:00	0.0	0	0	0	0	1
12/02/2019 21:00	0.0	0	0	0	0	1
12/02/2019 22:00	0.0	0	0	0	0	1
12/02/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/03/2019 00:00	0.0	0	0	0	0	1
12/03/2019 01:00	0.0	0	0	0	0	1
12/03/2019 02:00	0.0	0	0	0	0	1
12/03/2019 03:00	0.0	0	0	0	0	1
12/03/2019 04:00	0.0	0	0	0	0	1
12/03/2019 05:00	0.0	0	0	0	0	1
12/03/2019 06:00	0.0	0	0	0	0	1
12/03/2019 07:00	0.0	0	0	0	0	1
12/03/2019 08:00	0.0	0	0	0	0	1
12/03/2019 09:00	0.0	0	0	0	0	1
12/03/2019 10:00	0.0	0	0	0	0	1
12/03/2019 11:00	0.0	0	0	0	0	1
12/03/2019 12:00	0.0	0	0	0	0	1
12/03/2019 13:00	0.0	0	0	0	0	1
12/03/2019 14:00	0.0	0	0	0	0	1
12/03/2019 15:00	0.0	0	0	0	0	1
12/03/2019 16:00	0.0	0	0	0	0	1
12/03/2019 17:00	0.0	0	0	0	0	1
12/03/2019 18:00	0.0	0	0	0	0	1
12/03/2019 19:00	0.0	0	0	0	0	1
12/03/2019 20:00	0.0	0	0	0	0	1
12/03/2019 21:00	0.0	0	0	0	0	1
12/03/2019 22:00	0.0	0	0	0	0	1
12/03/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/04/2019 00:00	0.0	0	0	0	0	1
12/04/2019 01:00	0.0	0	0	0	0	1
12/04/2019 02:00	0.0	0	0	0	0	1
12/04/2019 03:00	0.0	0	0	0	0	1
12/04/2019 04:00	0.0	0	0	0	0	1
12/04/2019 05:00	0.0	0	0	0	0	1
12/04/2019 06:00	0.0	0	0	0	0	1
12/04/2019 07:00	0.0	0	0	0	0	1
12/04/2019 08:00	0.0	0	0	0	0	1
12/04/2019 09:00	0.0	0	0	0	0	1
12/04/2019 10:00	0.0	0	0	0	0	1
12/04/2019 11:00	0.0	0	0	0	0	1
12/04/2019 12:00	0.0	0	0	0	0	1
12/04/2019 13:00	0.0	0	0	0	0	1
12/04/2019 14:00	0.0	0	0	0	0	1
12/04/2019 15:00	0.0	0	0	0	0	1
12/04/2019 16:00	0.0	0	0	0	0	1
12/04/2019 17:00	0.0	0	0	0	0	1
12/04/2019 18:00	0.0	0	0	0	0	1
12/04/2019 19:00	0.0	0	0	0	0	1
12/04/2019 20:00	0.0	0	0	0	0	1
12/04/2019 21:00	0.0	0	0	0	0	1
12/04/2019 22:00	0.0	0	0	0	0	1
12/04/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/05/2019 00:00	0.0	0	0	0	0	1
12/05/2019 01:00	0.0	0	0	0	0	1
12/05/2019 02:00	0.0	0	0	0	0	1
12/05/2019 03:00	0.0	0	0	0	0	1
12/05/2019 04:00	0.0	0	0	0	0	1
12/05/2019 05:00	0.0	0	0	0	0	1
12/05/2019 06:00	0.0	0	0	0	0	1
12/05/2019 07:00	0.0	0	0	0	0	1
12/05/2019 08:00	0.0	0	0	0	0	1
12/05/2019 09:00	0.0	0	0	0	0	1
12/05/2019 10:00	0.0	0	0	0	0	1
12/05/2019 11:00	0.0	0	0	0	0	1
12/05/2019 12:00	0.0	0	0	0	0	1
12/05/2019 13:00	0.0	0	0	0	0	1
12/05/2019 14:00	0.0	0	0	0	0	1
12/05/2019 15:00	0.0	0	0	0	0	1
12/05/2019 16:00	0.0	0	0	0	0	1
12/05/2019 17:00	0.0	0	0	0	0	1
12/05/2019 18:00	0.0	0	0	0	0	1
12/05/2019 19:00	0.0	0	0	0	0	1
12/05/2019 20:00	0.0	0	0	0	0	1
12/05/2019 21:00	0.0	0	0	0	0	1
12/05/2019 22:00	0.0	0	0	0	0	1
12/05/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/06/2019 00:00	0.0	0	0	0	0	1
12/06/2019 01:00	0.0	0	0	0	0	1
12/06/2019 02:00	0.0	0	0	0	0	1
12/06/2019 03:00	0.0	0	0	0	0	1
12/06/2019 04:00	0.0	0	0	0	0	1
12/06/2019 05:00	0.0	0	0	0	0	1
12/06/2019 06:00	0.0	0	0	0	0	1
12/06/2019 07:00	0.0	0	0	0	0	1
12/06/2019 08:00	0.0	0	0	0	0	1
12/06/2019 09:00	0.0	0	0	0	0	1
12/06/2019 10:00	0.0	0	0	0	0	1
12/06/2019 11:00	0.0	0	0	0	0	1
12/06/2019 12:00	0.0	0	0	0	0	1
12/06/2019 13:00	0.0	0	0	0	0	1
12/06/2019 14:00	0.0	0	0	0	0	1
12/06/2019 15:00	0.0	0	0	0	0	1
12/06/2019 16:00	0.0	0	0	0	0	1
12/06/2019 17:00	0.0	0	0	0	0	1
12/06/2019 18:00	0.0	0	0	0	0	1
12/06/2019 19:00	0.0	0	0	0	0	1
12/06/2019 20:00	0.0	0	0	0	0	1
12/06/2019 21:00	0.0	0	0	0	0	1
12/06/2019 22:00	0.0	0	0	0	0	1
12/06/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/07/2019 00:00	0.0	0	0	0	0	1
12/07/2019 01:00	0.0	0	0	0	0	1
12/07/2019 02:00	0.0	0	0	0	0	1
12/07/2019 03:00	0.0	0	0	0	0	1
12/07/2019 04:00	0.0	0	0	0	0	1
12/07/2019 05:00	0.0	0	0	0	0	1
12/07/2019 06:00	0.0	0	0	0	0	1
12/07/2019 07:00	0.0	0	0	0	0	1
12/07/2019 08:00	0.0	0	0	0	0	1
12/07/2019 09:00	0.0	0	0	0	0	1
12/07/2019 10:00	0.0	0	0	0	0	1
12/07/2019 11:00	0.0	0	0	0	0	1
12/07/2019 12:00	0.0	0	0	0	0	1
12/07/2019 13:00	0.0	0	0	0	0	1
12/07/2019 14:00	0.0	0	0	0	0	1
12/07/2019 15:00	0.0	0	0	0	0	1
12/07/2019 16:00	0.0	0	0	0	0	1
12/07/2019 17:00	0.0	0	0	0	0	1
12/07/2019 18:00	0.0	0	0	0	0	1
12/07/2019 19:00	0.0	0	0	0	0	1
12/07/2019 20:00	0.0	0	0	0	0	1
12/07/2019 21:00	0.0	0	0	0	0	1
12/07/2019 22:00	0.0	0	0	0	0	1
12/07/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/08/2019 00:00	0.0	0	0	0	0	1
12/08/2019 01:00	0.0	0	0	0	0	1
12/08/2019 02:00	0.0	0	0	0	0	1
12/08/2019 03:00	0.0	0	0	0	0	1
12/08/2019 04:00	0.0	0	0	0	0	1
12/08/2019 05:00	0.0	0	0	0	0	1
12/08/2019 06:00	0.0	0	0	0	0	1
12/08/2019 07:00	0.0	0	0	0	0	1
12/08/2019 08:00	0.0	0	0	0	0	1
12/08/2019 09:00	0.0	0	0	0	0	1
12/08/2019 10:00	0.0	0	0	0	0	1
12/08/2019 11:00	0.0	0	0	0	0	1
12/08/2019 12:00	0.0	0	0	0	0	1
12/08/2019 13:00	0.0	0	0	0	0	1
12/08/2019 14:00	0.0	0	0	0	0	1
12/08/2019 15:00	0.0	0	0	0	0	1
12/08/2019 16:00	0.0	0	0	0	0	1
12/08/2019 17:00	0.0	0	0	0	0	1
12/08/2019 18:00	0.0	0	0	0	0	1
12/08/2019 19:00	0.0	0	0	0	0	1
12/08/2019 20:00	0.0	0	0	0	0	1
12/08/2019 21:00	0.0	0	0	0	0	1
12/08/2019 22:00	0.0	0	0	0	0	1
12/08/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/09/2019 00:00	0.0	0	0	0	0	1
12/09/2019 01:00	0.0	0	0	0	0	1
12/09/2019 02:00	0.0	0	0	0	0	1
12/09/2019 03:00	0.0	0	0	0	0	1
12/09/2019 04:00	0.0	0	0	0	0	1
12/09/2019 05:00	0.0	0	0	0	0	1
12/09/2019 06:00	0.0	0	0	0	0	1
12/09/2019 07:00	0.0	0	0	0	0	1
12/09/2019 08:00	0.0	0	0	0	0	1
12/09/2019 09:00	0.0	0	0	0	0	1
12/09/2019 10:00	0.0	0	0	0	0	1
12/09/2019 11:00	0.0	0	0	0	0	1
12/09/2019 12:00	0.0	0	0	0	0	1
12/09/2019 13:00	0.0	0	0	0	0	1
12/09/2019 14:00	0.0	0	0	0	0	1
12/09/2019 15:00	0.0	0	0	0	0	1
12/09/2019 16:00	0.0	0	0	0	0	1
12/09/2019 17:00	0.0	0	0	0	0	1
12/09/2019 18:00	0.0	0	0	0	0	1
12/09/2019 19:00	0.0	0	0	0	0	1
12/09/2019 20:00	0.0	0	0	0	0	1
12/09/2019 21:00	0.0	0	0	0	0	1
12/09/2019 22:00	0.0	0	0	0	0	1
12/09/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/10/2019 00:00	0.0	0	0	0	0	1
12/10/2019 01:00	0.0	0	0	0	0	1
12/10/2019 02:00	0.0	0	0	0	0	1
12/10/2019 03:00	0.0	0	0	0	0	1
12/10/2019 04:00	0.0	0	0	0	0	1
12/10/2019 05:00	0.0	0	0	0	0	1
12/10/2019 06:00	0.0	0	0	0	0	1
12/10/2019 07:00	0.0	0	0	0	0	1
12/10/2019 08:00	0.0	0	0	0	0	1
12/10/2019 09:00	0.0	0	0	0	0	1
12/10/2019 10:00	0.0	0	0	0	0	1
12/10/2019 11:00	0.0	0	0	0	0	1
12/10/2019 12:00	0.0	0	0	0	0	1
12/10/2019 13:00	0.0	0	0	0	0	1
12/10/2019 14:00	0.0	0	0	0	0	1
12/10/2019 15:00	0.0	0	0	0	0	1
12/10/2019 16:00	0.0	0	0	0	0	1
12/10/2019 17:00	0.0	0	0	0	0	1
12/10/2019 18:00	0.0	0	0	0	0	1
12/10/2019 19:00	0.0	0	0	0	0	1
12/10/2019 20:00	0.0	0	0	0	0	1
12/10/2019 21:00	0.0	0	0	0	0	1
12/10/2019 22:00	0.0	0	0	0	0	1
12/10/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/11/2019 00:00	0.0	0	0	0	0	1
12/11/2019 01:00	0.0	0	0	0	0	1
12/11/2019 02:00	0.0	0	0	0	0	1
12/11/2019 03:00	0.0	0	0	0	0	1
12/11/2019 04:00	0.0	0	0	0	0	1
12/11/2019 05:00	0.0	0	0	0	0	1
12/11/2019 06:00	0.0	0	0	0	0	1
12/11/2019 07:00	0.0	0	0	0	0	1
12/11/2019 08:00	0.0	0	0	0	0	1
12/11/2019 09:00	0.0	0	0	0	0	1
12/11/2019 10:00	0.0	0	0	0	0	1
12/11/2019 11:00	0.0	0	0	0	0	1
12/11/2019 12:00	0.0	0	0	0	0	1
12/11/2019 13:00	0.0	0	0	0	0	1
12/11/2019 14:00	0.0	0	0	0	0	1
12/11/2019 15:00	0.0	0	0	0	0	1
12/11/2019 16:00	0.0	0	0	0	0	1
12/11/2019 17:00	0.0	0	0	0	0	1
12/11/2019 18:00	0.0	0	0	0	0	1
12/11/2019 19:00	0.0	0	0	0	0	1
12/11/2019 20:00	0.0	0	0	0	0	1
12/11/2019 21:00	0.0	0	0	0	0	1
12/11/2019 22:00	0.0	0	0	0	0	1
12/11/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/12/2019 00:00	0.0	0	0	0	0	1
12/12/2019 01:00	0.0	0	0	0	0	1
12/12/2019 02:00	0.0	0	0	0	0	1
12/12/2019 03:00	0.0	0	0	0	0	1
12/12/2019 04:00	0.0	0	0	0	0	1
12/12/2019 05:00	0.0	0	0	0	0	1
12/12/2019 06:00	0.0	0	0	0	0	1
12/12/2019 07:00	0.0	0	0	0	0	1
12/12/2019 08:00	0.0	0	0	0	0	1
12/12/2019 09:00	0.0	0	0	0	0	1
12/12/2019 10:00	0.0	0	0	0	0	1
12/12/2019 11:00	0.0	0	0	0	0	1
12/12/2019 12:00	0.0	0	0	0	0	1
12/12/2019 13:00	0.0	0	0	0	0	1
12/12/2019 14:00	0.0	0	0	0	0	1
12/12/2019 15:00	0.0	0	0	0	0	1
12/12/2019 16:00	0.0	0	0	0	0	1
12/12/2019 17:00	0.0	0	0	0	0	1
12/12/2019 18:00	0.0	0	0	0	0	1
12/12/2019 19:00	0.0	0	0	0	0	1
12/12/2019 20:00	0.0	0	0	0	0	1
12/12/2019 21:00	0.0	0	0	0	0	1
12/12/2019 22:00	0.0	0	0	0	0	1
12/12/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/13/2019 00:00	0.0	0	0	0	0	1
12/13/2019 01:00	0.0	0	0	0	0	1
12/13/2019 02:00	0.0	0	0	0	0	1
12/13/2019 03:00	0.0	0	0	0	0	1
12/13/2019 04:00	0.0	0	0	0	0	1
12/13/2019 05:00	0.0	0	0	0	0	1
12/13/2019 06:00	0.0	0	0	0	0	1
12/13/2019 07:00	0.0	0	0	0	0	1
12/13/2019 08:00	0.0	0	0	0	0	1
12/13/2019 09:00	0.0	0	0	0	0	1
12/13/2019 10:00	0.0	0	0	0	0	1
12/13/2019 11:00	0.0	0	0	0	0	1
12/13/2019 12:00	0.0	0	0	0	0	1
12/13/2019 13:00	0.0	0	0	0	0	1
12/13/2019 14:00	0.0	0	0	0	0	1
12/13/2019 15:00	0.0	0	0	0	0	1
12/13/2019 16:00	0.0	0	0	0	0	1
12/13/2019 17:00	0.0	0	0	0	0	1
12/13/2019 18:00	0.0	0	0	0	0	1
12/13/2019 19:00	0.0	0	0	0	0	1
12/13/2019 20:00	0.0	0	0	0	0	1
12/13/2019 21:00	0.0	0	0	0	0	1
12/13/2019 22:00	0.0	0	0	0	0	1
12/13/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/14/2019 00:00	0.0	0	0	0	0	1
12/14/2019 01:00	0.0	0	0	0	0	1
12/14/2019 02:00	0.0	0	0	0	0	1
12/14/2019 03:00	0.0	0	0	0	0	1
12/14/2019 04:00	0.0	0	0	0	0	1
12/14/2019 05:00	0.0	0	0	0	0	1
12/14/2019 06:00	0.0	0	0	0	0	1
12/14/2019 07:00	0.0	0	0	0	0	1
12/14/2019 08:00	0.0	0	0	0	0	1
12/14/2019 09:00	0.0	0	0	0	0	1
12/14/2019 10:00	0.0	0	0	0	0	1
12/14/2019 11:00	0.0	0	0	0	0	1
12/14/2019 12:00	0.0	0	0	0	0	1
12/14/2019 13:00	0.0	0	0	0	0	1
12/14/2019 14:00	0.0	0	0	0	0	1
12/14/2019 15:00	0.0	0	0	0	0	1
12/14/2019 16:00	0.0	0	0	0	0	1
12/14/2019 17:00	0.0	0	0	0	0	1
12/14/2019 18:00	0.0	0	0	0	0	1
12/14/2019 19:00	0.0	0	0	0	0	1
12/14/2019 20:00	0.0	0	0	0	0	1
12/14/2019 21:00	0.0	0	0	0	0	1
12/14/2019 22:00	0.0	0	0	0	0	1
12/14/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/15/2019 00:00	0.0	0	0	0	0	1
12/15/2019 01:00	0.0	0	0	0	0	1
12/15/2019 02:00	0.0	0	0	0	0	1
12/15/2019 03:00	0.0	0	0	0	0	1
12/15/2019 04:00	0.0	0	0	0	0	1
12/15/2019 05:00	0.0	0	0	0	0	1
12/15/2019 06:00	0.0	0	0	0	0	1
12/15/2019 07:00	0.0	0	0	0	0	1
12/15/2019 08:00	0.0	0	0	0	0	1
12/15/2019 09:00	0.0	0	0	0	0	1
12/15/2019 10:00	0.0	0	0	0	0	1
12/15/2019 11:00	0.0	0	0	0	0	1
12/15/2019 12:00	0.0	0	0	0	0	1
12/15/2019 13:00	0.0	0	0	0	0	1
12/15/2019 14:00	0.0	0	0	0	0	1
12/15/2019 15:00	0.0	0	0	0	0	1
12/15/2019 16:00	0.0	0	0	0	0	1
12/15/2019 17:00	0.0	0	0	0	0	1
12/15/2019 18:00	0.0	0	0	0	0	1
12/15/2019 19:00	0.0	0	0	0	0	1
12/15/2019 20:00	0.0	0	0	0	0	1
12/15/2019 21:00	0.0	0	0	0	0	1
12/15/2019 22:00	0.0	0	0	0	0	1
12/15/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/16/2019 00:00	0.0	0	0	0	0	1
12/16/2019 01:00	0.0	0	0	0	0	1
12/16/2019 02:00	0.0	0	0	0	0	1
12/16/2019 03:00	0.0	0	0	0	0	1
12/16/2019 04:00	0.0	0	0	0	0	1
12/16/2019 05:00	0.0	0	0	0	0	1
12/16/2019 06:00	0.0	0	0	0	0	1
12/16/2019 07:00	0.0	0	0	0	0	1
12/16/2019 08:00	0.0	0	0	0	0	1
12/16/2019 09:00	0.0	0	0	0	0	1
12/16/2019 10:00	0.0	0	0	0	0	1
12/16/2019 11:00	0.0	0	0	0	0	1
12/16/2019 12:00	0.0	0	0	0	0	1
12/16/2019 13:00	0.0	0	0	0	0	1
12/16/2019 14:00	0.0	0	0	0	0	1
12/16/2019 15:00	0.0	0	0	0	0	1
12/16/2019 16:00	0.0	0	0	0	0	1
12/16/2019 17:00	0.0	0	0	0	0	1
12/16/2019 18:00	0.0	0	0	0	0	1
12/16/2019 19:00	0.0	0	0	0	0	1
12/16/2019 20:00	0.0	0	0	0	0	1
12/16/2019 21:00	0.0	0	0	0	0	1
12/16/2019 22:00	0.0	0	0	0	0	1
12/16/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/17/2019 00:00	0.0	0	0	0	0	1
12/17/2019 01:00	0.0	0	0	0	0	1
12/17/2019 02:00	0.0	0	0	0	0	1
12/17/2019 03:00	0.0	0	0	0	0	1
12/17/2019 04:00	0.0	0	0	0	0	1
12/17/2019 05:00	0.0	0	0	0	0	1
12/17/2019 06:00	0.0	0	0	0	0	1
12/17/2019 07:00	0.0	0	0	0	0	1
12/17/2019 08:00	0.0	0	0	0	0	1
12/17/2019 09:00	0.0	0	0	0	0	1
12/17/2019 10:00	0.0	0	0	0	0	1
12/17/2019 11:00	0.0	0	0	0	0	1
12/17/2019 12:00	0.0	0	0	0	0	1
12/17/2019 13:00	0.0	0	0	0	0	1
12/17/2019 14:00	0.0	0	0	0	0	1
12/17/2019 15:00	0.0	0	0	0	0	1
12/17/2019 16:00	0.0	0	0	0	0	1
12/17/2019 17:00	0.0	0	0	0	0	1
12/17/2019 18:00	0.0	0	0	0	0	1
12/17/2019 19:00	0.0	0	0	0	0	1
12/17/2019 20:00	0.0	0	0	0	0	1
12/17/2019 21:00	0.0	0	0	0	0	1
12/17/2019 22:00	0.0	0	0	0	0	1
12/17/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/18/2019 00:00	0.0	0	0	0	0	1
12/18/2019 01:00	0.0	0	0	0	0	1
12/18/2019 02:00	0.0	0	0	0	0	1
12/18/2019 03:00	0.0	0	0	0	0	1
12/18/2019 04:00	0.0	0	0	0	0	1
12/18/2019 05:00	0.0	0	0	0	0	1
12/18/2019 06:00	0.0	0	0	0	0	1
12/18/2019 07:00	0.0	0	0	0	0	1
12/18/2019 08:00	0.0	0	0	0	0	1
12/18/2019 09:00	0.0	0	0	0	0	1
12/18/2019 10:00	0.0	0	0	0	0	1
12/18/2019 11:00	0.0	0	0	0	0	1
12/18/2019 12:00	0.0	0	0	0	0	1
12/18/2019 13:00	0.0	0	0	0	0	1
12/18/2019 14:00	0.0	0	0	0	0	1
12/18/2019 15:00	0.0	0	0	0	0	1
12/18/2019 16:00	0.0	0	0	0	0	1
12/18/2019 17:00	0.0	0	0	0	0	1
12/18/2019 18:00	0.0	0	0	0	0	1
12/18/2019 19:00	0.0	0	0	0	0	1
12/18/2019 20:00	0.0	0	0	0	0	1
12/18/2019 21:00	0.0	0	0	0	0	1
12/18/2019 22:00	0.0	0	0	0	0	1
12/18/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/19/2019 00:00	0.0	0	0	0	0	1
12/19/2019 01:00	0.0	0	0	0	0	1
12/19/2019 02:00	0.0	0	0	0	0	1
12/19/2019 03:00	0.0	0	0	0	0	1
12/19/2019 04:00	0.0	0	0	0	0	1
12/19/2019 05:00	0.0	0	0	0	0	1
12/19/2019 06:00	0.0	0	0	0	0	1
12/19/2019 07:00	0.0	0	0	0	0	1
12/19/2019 08:00	0.0	0	0	0	0	1
12/19/2019 09:00	0.0	0	0	0	0	1
12/19/2019 10:00	0.0	0	0	0	0	1
12/19/2019 11:00	0.0	0	0	0	0	1
12/19/2019 12:00	0.0	0	0	0	0	1
12/19/2019 13:00	0.0	0	0	0	0	1
12/19/2019 14:00	0.0	0	0	0	0	1
12/19/2019 15:00	0.0	0	0	0	0	1
12/19/2019 16:00	0.0	0	0	0	0	1
12/19/2019 17:00	0.0	0	0	0	0	1
12/19/2019 18:00	0.0	0	0	0	0	1
12/19/2019 19:00	0.0	0	0	0	0	1
12/19/2019 20:00	0.0	0	0	0	0	1
12/19/2019 21:00	0.0	0	0	0	0	1
12/19/2019 22:00	0.0	0	0	0	0	1
12/19/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/20/2019 00:00	0.0	0	0	0	0	1
12/20/2019 01:00	0.0	0	0	0	0	1
12/20/2019 02:00	0.0	0	0	0	0	1
12/20/2019 03:00	0.0	0	0	0	0	1
12/20/2019 04:00	0.0	0	0	0	0	1
12/20/2019 05:00	0.0	0	0	0	0	1
12/20/2019 06:00	0.0	0	0	0	0	1
12/20/2019 07:00	0.0	0	0	0	0	1
12/20/2019 08:00	0.0	0	0	0	0	1
12/20/2019 09:00	0.0	0	0	0	0	1
12/20/2019 10:00	0.0	0	0	0	0	1
12/20/2019 11:00	0.0	0	0	0	0	1
12/20/2019 12:00	0.0	0	0	0	0	1
12/20/2019 13:00	0.0	0	0	0	0	1
12/20/2019 14:00	0.0	0	0	0	0	1
12/20/2019 15:00	0.0	0	0	0	0	1
12/20/2019 16:00	0.0	0	0	0	0	1
12/20/2019 17:00	0.0	0	0	0	0	1
12/20/2019 18:00	0.0	0	0	0	0	1
12/20/2019 19:00	0.0	0	0	0	0	1
12/20/2019 20:00	0.0	0	0	0	0	1
12/20/2019 21:00	0.0	0	0	0	0	1
12/20/2019 22:00	0.0	0	0	0	0	1
12/20/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/21/2019 00:00	0.0	0	0	0	0	1
12/21/2019 01:00	0.0	0	0	0	0	1
12/21/2019 02:00	0.0	0	0	0	0	1
12/21/2019 03:00	0.0	0	0	0	0	1
12/21/2019 04:00	0.0	0	0	0	0	1
12/21/2019 05:00	0.0	0	0	0	0	1
12/21/2019 06:00	0.0	0	0	0	0	1
12/21/2019 07:00	0.0	0	0	0	0	1
12/21/2019 08:00	0.0	0	0	0	0	1
12/21/2019 09:00	0.0	0	0	0	0	1
12/21/2019 10:00	0.0	0	0	0	0	1
12/21/2019 11:00	0.0	0	0	0	0	1
12/21/2019 12:00	0.0	0	0	0	0	1
12/21/2019 13:00	0.0	0	0	0	0	1
12/21/2019 14:00	0.0	0	0	0	0	1
12/21/2019 15:00	0.0	0	0	0	0	1
12/21/2019 16:00	0.0	0	0	0	0	1
12/21/2019 17:00	0.0	0	0	0	0	1
12/21/2019 18:00	0.0	0	0	0	0	1
12/21/2019 19:00	0.0	0	0	0	0	1
12/21/2019 20:00	0.0	0	0	0	0	1
12/21/2019 21:00	0.0	0	0	0	0	1
12/21/2019 22:00	0.0	0	0	0	0	1
12/21/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/22/2019 00:00	0.0	0	0	0	0	1
12/22/2019 01:00	0.0	0	0	0	0	1
12/22/2019 02:00	0.0	0	0	0	0	1
12/22/2019 03:00	0.0	0	0	0	0	1
12/22/2019 04:00	0.0	0	0	0	0	1
12/22/2019 05:00	0.0	0	0	0	0	1
12/22/2019 06:00	0.0	0	0	0	0	1
12/22/2019 07:00	0.0	0	0	0	0	1
12/22/2019 08:00	0.0	0	0	0	0	1
12/22/2019 09:00	0.0	0	0	0	0	1
12/22/2019 10:00	0.0	0	0	0	0	1
12/22/2019 11:00	0.0	0	0	0	0	1
12/22/2019 12:00	0.0	0	0	0	0	1
12/22/2019 13:00	0.0	0	0	0	0	1
12/22/2019 14:00	0.0	0	0	0	0	1
12/22/2019 15:00	0.0	0	0	0	0	1
12/22/2019 16:00	0.0	0	0	0	0	1
12/22/2019 17:00	0.0	0	0	0	0	1
12/22/2019 18:00	0.0	0	0	0	0	1
12/22/2019 19:00	0.0	0	0	0	0	1
12/22/2019 20:00	0.0	0	0	0	0	1
12/22/2019 21:00	0.0	0	0	0	0	1
12/22/2019 22:00	0.0	0	0	0	0	1
12/22/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/23/2019 00:00	0.0	0	0	0	0	1
12/23/2019 01:00	0.0	0	0	0	0	1
12/23/2019 02:00	0.0	0	0	0	0	1
12/23/2019 03:00	0.0	0	0	0	0	1
12/23/2019 04:00	0.0	0	0	0	0	1
12/23/2019 05:00	0.0	0	0	0	0	1
12/23/2019 06:00	0.0	0	0	0	0	1
12/23/2019 07:00	0.0	0	0	0	0	1
12/23/2019 08:00	0.0	0	0	0	0	1
12/23/2019 09:00	0.0	0	0	0	0	1
12/23/2019 10:00	0.0	0	0	0	0	1
12/23/2019 11:00	0.0	0	0	0	0	1
12/23/2019 12:00	0.0	0	0	0	0	1
12/23/2019 13:00	0.0	0	0	0	0	1
12/23/2019 14:00	0.0	0	0	0	0	1
12/23/2019 15:00	0.0	0	0	0	0	1
12/23/2019 16:00	0.0	0	0	0	0	1
12/23/2019 17:00	0.0	0	0	0	0	1
12/23/2019 18:00	0.0	0	0	0	0	1
12/23/2019 19:00	0.0	0	0	0	0	1
12/23/2019 20:00	0.0	0	0	0	0	1
12/23/2019 21:00	0.0	0	0	0	0	1
12/23/2019 22:00	0.0	0	0	0	0	1
12/23/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/24/2019 00:00	0.0	0	0	0	0	1
12/24/2019 01:00	0.0	0	0	0	0	1
12/24/2019 02:00	0.0	0	0	0	0	1
12/24/2019 03:00	0.0	0	0	0	0	1
12/24/2019 04:00	0.0	0	0	0	0	1
12/24/2019 05:00	0.0	0	0	0	0	1
12/24/2019 06:00	0.0	0	0	0	0	1
12/24/2019 07:00	0.0	0	0	0	0	1
12/24/2019 08:00	0.0	0	0	0	0	1
12/24/2019 09:00	0.0	0	0	0	0	1
12/24/2019 10:00	0.0	0	0	0	0	1
12/24/2019 11:00	0.0	0	0	0	0	1
12/24/2019 12:00	0.0	0	0	0	0	1
12/24/2019 13:00	0.0	0	0	0	0	1
12/24/2019 14:00	0.0	0	0	0	0	1
12/24/2019 15:00	0.0	0	0	0	0	1
12/24/2019 16:00	0.0	0	0	0	0	1
12/24/2019 17:00	0.0	0	0	0	0	1
12/24/2019 18:00	0.0	0	0	0	0	1
12/24/2019 19:00	0.0	0	0	0	0	1
12/24/2019 20:00	0.0	0	0	0	0	1
12/24/2019 21:00	0.0	0	0	0	0	1
12/24/2019 22:00	0.0	0	0	0	0	1
12/24/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/25/2019 00:00	0.0	0	0	0	0	1
12/25/2019 01:00	0.0	0	0	0	0	1
12/25/2019 02:00	0.0	0	0	0	0	1
12/25/2019 03:00	0.0	0	0	0	0	1
12/25/2019 04:00	0.0	0	0	0	0	1
12/25/2019 05:00	0.0	0	0	0	0	1
12/25/2019 06:00	0.0	0	0	0	0	1
12/25/2019 07:00	0.0	0	0	0	0	1
12/25/2019 08:00	0.0	0	0	0	0	1
12/25/2019 09:00	0.0	0	0	0	0	1
12/25/2019 10:00	0.0	0	0	0	0	1
12/25/2019 11:00	0.0	0	0	0	0	1
12/25/2019 12:00	0.0	0	0	0	0	1
12/25/2019 13:00	0.0	0	0	0	0	1
12/25/2019 14:00	0.0	0	0	0	0	1
12/25/2019 15:00	0.0	0	0	0	0	1
12/25/2019 16:00	0.0	0	0	0	0	1
12/25/2019 17:00	0.0	0	0	0	0	1
12/25/2019 18:00	0.0	0	0	0	0	1
12/25/2019 19:00	0.0	0	0	0	0	1
12/25/2019 20:00	0.0	0	0	0	0	1
12/25/2019 21:00	0.0	0	0	0	0	1
12/25/2019 22:00	0.0	0	0	0	0	1
12/25/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/26/2019 00:00	0.0	0	0	0	0	1
12/26/2019 01:00	0.0	0	0	0	0	1
12/26/2019 02:00	0.0	0	0	0	0	1
12/26/2019 03:00	0.0	0	0	0	0	1
12/26/2019 04:00	0.0	0	0	0	0	1
12/26/2019 05:00	0.0	0	0	0	0	1
12/26/2019 06:00	0.0	0	0	0	0	1
12/26/2019 07:00	0.0	0	0	0	0	1
12/26/2019 08:00	0.0	0	0	0	0	1
12/26/2019 09:00	0.0	0	0	0	0	1
12/26/2019 10:00	0.0	0	0	0	0	1
12/26/2019 11:00	0.0	0	0	0	0	1
12/26/2019 12:00	0.0	0	0	0	0	1
12/26/2019 13:00	0.0	0	0	0	0	1
12/26/2019 14:00	0.0	0	0	0	0	1
12/26/2019 15:00	0.0	0	0	0	0	1
12/26/2019 16:00	0.0	0	0	0	0	1
12/26/2019 17:00	0.0	0	0	0	0	1
12/26/2019 18:00	0.0	0	0	0	0	1
12/26/2019 19:00	0.0	0	0	0	0	1
12/26/2019 20:00	0.0	0	0	0	0	1
12/26/2019 21:00	0.0	0	0	0	0	1
12/26/2019 22:00	0.0	0	0	0	0	1
12/26/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/27/2019 00:00	0.0	0	0	0	0	1
12/27/2019 01:00	0.0	0	0	0	0	1
12/27/2019 02:00	0.0	0	0	0	0	1
12/27/2019 03:00	0.0	0	0	0	0	1
12/27/2019 04:00	0.0	0	0	0	0	1
12/27/2019 05:00	0.0	0	0	0	0	1
12/27/2019 06:00	0.0	0	0	0	0	1
12/27/2019 07:00	0.0	0	0	0	0	1
12/27/2019 08:00	0.0	0	0	0	0	1
12/27/2019 09:00	0.0	0	0	0	0	1
12/27/2019 10:00	0.0	0	0	0	0	1
12/27/2019 11:00	0.0	0	0	0	0	1
12/27/2019 12:00	0.0	0	0	0	0	1
12/27/2019 13:00	0.0	0	0	0	0	1
12/27/2019 14:00	0.0	0	0	0	0	1
12/27/2019 15:00	0.0	0	0	0	0	1
12/27/2019 16:00	0.0	0	0	0	0	1
12/27/2019 17:00	0.0	0	0	0	0	1
12/27/2019 18:00	0.0	0	0	0	0	1
12/27/2019 19:00	0.0	0	0	0	0	1
12/27/2019 20:00	0.0	0	0	0	0	1
12/27/2019 21:00	0.0	0	0	0	0	1
12/27/2019 22:00	0.0	0	0	0	0	1
12/27/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/28/2019 00:00	0.0	0	0	0	0	1
12/28/2019 01:00	0.0	0	0	0	0	1
12/28/2019 02:00	0.0	0	0	0	0	1
12/28/2019 03:00	0.0	0	0	0	0	1
12/28/2019 04:00	0.0	0	0	0	0	1
12/28/2019 05:00	0.0	0	0	0	0	1
12/28/2019 06:00	0.0	0	0	0	0	1
12/28/2019 07:00	0.0	0	0	0	0	1
12/28/2019 08:00	0.0	0	0	0	0	1
12/28/2019 09:00	0.0	0	0	0	0	1
12/28/2019 10:00	0.0	0	0	0	0	1
12/28/2019 11:00	0.0	0	0	0	0	1
12/28/2019 12:00	0.0	0	0	0	0	1
12/28/2019 13:00	0.0	0	0	0	0	1
12/28/2019 14:00	0.0	0	0	0	0	1
12/28/2019 15:00	0.0	0	0	0	0	1
12/28/2019 16:00	0.0	0	0	0	0	1
12/28/2019 17:00	0.0	0	0	0	0	1
12/28/2019 18:00	0.0	0	0	0	0	1
12/28/2019 19:00	0.0	0	0	0	0	1
12/28/2019 20:00	0.0	0	0	0	0	1
12/28/2019 21:00	0.0	0	0	0	0	1
12/28/2019 22:00	0.0	0	0	0	0	1
12/28/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/29/2019 00:00	0.0	0	0	0	0	1
12/29/2019 01:00	0.0	0	0	0	0	1
12/29/2019 02:00	0.0	0	0	0	0	1
12/29/2019 03:00	0.0	0	0	0	0	1
12/29/2019 04:00	0.0	0	0	0	0	1
12/29/2019 05:00	0.0	0	0	0	0	1
12/29/2019 06:00	0.0	0	0	0	0	1
12/29/2019 07:00	0.0	0	0	0	0	1
12/29/2019 08:00	0.0	0	0	0	0	1
12/29/2019 09:00	0.0	0	0	0	0	1
12/29/2019 10:00	0.0	0	0	0	0	1
12/29/2019 11:00	0.0	0	0	0	0	1
12/29/2019 12:00	0.0	0	0	0	0	1
12/29/2019 13:00	0.0	0	0	0	0	1
12/29/2019 14:00	0.0	0	0	0	0	1
12/29/2019 15:00	0.0	0	0	0	0	1
12/29/2019 16:00	0.0	0	0	0	0	1
12/29/2019 17:00	0.0	0	0	0	0	1
12/29/2019 18:00	0.0	0	0	0	0	1
12/29/2019 19:00	0.0	0	0	0	0	1
12/29/2019 20:00	0.0	0	0	0	0	1
12/29/2019 21:00	0.0	0	0	0	0	1
12/29/2019 22:00	0.0	0	0	0	0	1
12/29/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/30/2019 00:00	0.0	0	0	0	0	1
12/30/2019 01:00	0.0	0	0	0	0	1
12/30/2019 02:00	0.0	0	0	0	0	1
12/30/2019 03:00	0.0	0	0	0	0	1
12/30/2019 04:00	0.0	0	0	0	0	1
12/30/2019 05:00	0.0	0	0	0	0	1
12/30/2019 06:00	0.0	0	0	0	0	1
12/30/2019 07:00	0.0	0	0	0	0	1
12/30/2019 08:00	0.0	0	0	0	0	1
12/30/2019 09:00	0.0	0	0	0	0	1
12/30/2019 10:00	0.0	0	0	0	0	1
12/30/2019 11:00	0.0	0	0	0	0	1
12/30/2019 12:00	0.0	0	0	0	0	1
12/30/2019 13:00	0.0	0	0	0	0	1
12/30/2019 14:00	0.0	0	0	0	0	1
12/30/2019 15:00	0.0	0	0	0	0	1
12/30/2019 16:00	0.0	0	0	0	0	1
12/30/2019 17:00	0.0	0	0	0	0	1
12/30/2019 18:00	0.0	0	0	0	0	1
12/30/2019 19:00	0.0	0	0	0	0	1
12/30/2019 20:00	0.0	0	0	0	0	1
12/30/2019 21:00	0.0	0	0	0	0	1
12/30/2019 22:00	0.0	0	0	0	0	1
12/30/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/31/2019 00:00	0.0	0	0	0	0	1
12/31/2019 01:00	0.0	0	0	0	0	1
12/31/2019 02:00	0.0	0	0	0	0	1
12/31/2019 03:00	0.0	0	0	0	0	1
12/31/2019 04:00	0.0	0	0	0	0	1
12/31/2019 05:00	0.0	0	0	0	0	1
12/31/2019 06:00	0.0	0	0	0	0	1
12/31/2019 07:00	0.0	0	0	0	0	1
12/31/2019 08:00	0.0	0	0	0	0	1
12/31/2019 09:00	0.0	0	0	0	0	1
12/31/2019 10:00	0.0	0	0	0	0	1
12/31/2019 11:00	0.0	0	0	0	0	1
12/31/2019 12:00	0.0	0	0	0	0	1
12/31/2019 13:00	0.0	0	0	0	0	1
12/31/2019 14:00	0.0	0	0	0	0	1
12/31/2019 15:00	0.0	0	0	0	0	1
12/31/2019 16:00	0.0	0	0	0	0	1
12/31/2019 17:00	0.0	0	0	0	0	1
12/31/2019 18:00	0.0	0	0	0	0	1
12/31/2019 19:00	0.0	0	0	0	0	1
12/31/2019 20:00	0.0	0	0	0	0	1
12/31/2019 21:00	0.0	0	0	0	0	1
12/31/2019 22:00	0.0	0	0	0	0	1
12/31/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/01/2019 00:00	0.1	0	0	0	1	0
10/01/2019 01:00	0.0	0	0	0	0	0
10/01/2019 02:00	0.0	0	0	0	0	0
10/01/2019 03:00	0.0	0	0	0	0	0
10/01/2019 04:00	2.7	0	0	1	0	0
10/01/2019 05:00	17.0	0	0	1	0	0
10/01/2019 06:00	0.0	0	0	0	0	1
10/01/2019 07:00	0.0	0	0	0	0	1
10/01/2019 08:00	0.0	0	0	0	0	1
10/01/2019 09:00	0.0	0	0	0	0	1
10/01/2019 10:00	0.0	0	0	0	0	1
10/01/2019 11:00	0.0	0	0	0	0	1
10/01/2019 12:00	0.0	0	0	0	0	1
10/01/2019 13:00	0.0	0	0	0	0	1
10/01/2019 14:00	0.0	0	0	0	0	1
10/01/2019 15:00	0.0	0	0	0	0	1
10/01/2019 16:00	0.0	0	0	0	0	1
10/01/2019 17:00	0.0	0	0	0	0	1
10/01/2019 18:00	0.0	0	0	0	0	1
10/01/2019 19:00	0.0	0	0	0	0	1
10/01/2019 20:00	0.0	0	0	0	0	1
10/01/2019 21:00	0.0	0	0	0	0	1
10/01/2019 22:00	0.0	0	0	0	0	1
10/01/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	19.8 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	17.0	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/02/2019 00:00	0.0	0	0	0	0	1
10/02/2019 01:00	0.0	0	0	0	0	1
10/02/2019 02:00	0.0	0	0	0	0	1
10/02/2019 03:00	0.0	0	0	0	0	1
10/02/2019 04:00	0.0	0	0	0	0	1
10/02/2019 05:00	0.0	0	0	0	0	1
10/02/2019 06:00	0.0	0	0	0	0	1
10/02/2019 07:00	0.0	0	0	0	0	1
10/02/2019 08:00	0.0	0	0	0	0	1
10/02/2019 09:00	0.0	0	0	0	0	1
10/02/2019 10:00	0.0	0	0	0	0	1
10/02/2019 11:00	0.0	0	0	0	0	1
10/02/2019 12:00	0.0	0	0	0	0	1
10/02/2019 13:00	0.0	0	0	0	0	1
10/02/2019 14:00	0.0	0	0	0	0	1
10/02/2019 15:00	0.0	0	0	0	0	1
10/02/2019 16:00	0.0	0	0	0	0	1
10/02/2019 17:00	0.0	0	0	0	0	1
10/02/2019 18:00	0.0	0	0	0	0	1
10/02/2019 19:00	0.0	0	0	0	0	1
10/02/2019 20:00	0.0	0	0	0	0	1
10/02/2019 21:00	0.0	0	0	0	0	1
10/02/2019 22:00	0.0	0	0	0	0	1
10/02/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/03/2019 00:00	0.0	0	0	0	0	1
10/03/2019 01:00	0.0	0	0	0	0	1
10/03/2019 02:00	0.0	0	0	0	0	1
10/03/2019 03:00	0.0	0	0	0	0	1
10/03/2019 04:00	0.0	0	0	0	0	1
10/03/2019 05:00	0.0	0	0	0	0	1
10/03/2019 06:00	0.0	0	0	0	0	1
10/03/2019 07:00	0.0	0	0	0	0	1
10/03/2019 08:00	0.0	0	0	0	0	1
10/03/2019 09:00	0.0	0	0	0	0	1
10/03/2019 10:00	0.0	0	0	0	0	1
10/03/2019 11:00	0.0	0	0	0	0	1
10/03/2019 12:00	0.0	0	0	0	0	1
10/03/2019 13:00	0.0	0	0	0	0	1
10/03/2019 14:00	0.0	0	0	0	0	1
10/03/2019 15:00	0.0	0	0	0	0	1
10/03/2019 16:00	0.0	0	0	0	0	1
10/03/2019 17:00	0.0	0	0	0	0	1
10/03/2019 18:00	0.0	0	0	0	0	1
10/03/2019 19:00	0.0	0	0	0	0	1
10/03/2019 20:00	0.0	0	0	0	0	1
10/03/2019 21:00	0.9	0	0	0	1	0
10/03/2019 22:00	0.0	0	0	0	0	0
10/03/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.9 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/04/2019 00:00	0.0	0	0	0	0	0
10/04/2019 01:00	0.0	0	0	0	0	0
10/04/2019 02:00	0.0	0	0	0	0	0
10/04/2019 03:00	0.0	0	0	0	0	0
10/04/2019 04:00	0.0	0	0	0	0	0
10/04/2019 05:00	0.0	0	0	0	0	0
10/04/2019 06:00	0.0	0	0	0	0	0
10/04/2019 07:00	0.0	0	0	0	0	0
10/04/2019 08:00	0.0	0	0	0	0	0
10/04/2019 09:00	0.0	0	0	0	0	0
10/04/2019 10:00	0.0	0	0	0	0	0
10/04/2019 11:00	0.0	0	0	0	0	0
10/04/2019 12:00	0.0	0	0	0	0	0
10/04/2019 13:00	30.3	0	1	0	0	0
10/04/2019 14:00	58.5	0	1	0	0	0
10/04/2019 15:00	0.0	0	0	0	0	1
10/04/2019 16:00	0.0	0	0	0	0	1
10/04/2019 17:00	0.0	0	0	0	0	1
10/04/2019 18:00	0.0	0	0	0	0	1
10/04/2019 19:00	0.0	0	0	0	0	1
10/04/2019 20:00	0.0	0	0	0	0	1
10/04/2019 21:00	0.0	0	0	0	0	1
10/04/2019 22:00	0.0	0	0	0	0	1
10/04/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	88.8 #	0 #	2 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	58.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/05/2019 00:00	0.0	0	0	0	0	1
10/05/2019 01:00	0.0	0	0	0	0	1
10/05/2019 02:00	0.0	0	0	0	0	1
10/05/2019 03:00	0.0	0	0	0	0	1
10/05/2019 04:00	0.0	0	0	0	0	1
10/05/2019 05:00	0.0	0	0	0	0	1
10/05/2019 06:00	0.0	0	0	0	0	1
10/05/2019 07:00	0.0	0	0	0	0	1
10/05/2019 08:00	0.0	0	0	0	0	1
10/05/2019 09:00	0.0	0	0	0	0	1
10/05/2019 10:00	0.0	0	0	0	0	1
10/05/2019 11:00	0.0	0	0	0	0	1
10/05/2019 12:00	0.0	0	0	0	0	1
10/05/2019 13:00	0.0	0	0	0	0	1
10/05/2019 14:00	0.0	0	0	0	0	1
10/05/2019 15:00	0.0	0	0	0	0	1
10/05/2019 16:00	0.0	0	0	0	0	1
10/05/2019 17:00	0.0	0	0	0	0	1
10/05/2019 18:00	0.0	0	0	0	0	1
10/05/2019 19:00	0.0	0	0	0	0	1
10/05/2019 20:00	0.0	0	0	0	0	1
10/05/2019 21:00	0.0	0	0	0	0	1
10/05/2019 22:00	0.0	0	0	0	0	1
10/05/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/06/2019 00:00	0.0	0	0	0	0	1
10/06/2019 01:00	0.0	0	0	0	0	1
10/06/2019 02:00	0.0	0	0	0	0	1
10/06/2019 03:00	0.0	0	0	0	0	1
10/06/2019 04:00	0.0	0	0	0	0	1
10/06/2019 05:00	0.0	0	0	0	0	1
10/06/2019 06:00	0.0	0	0	0	0	1
10/06/2019 07:00	0.0	0	0	0	0	1
10/06/2019 08:00	0.0	0	0	0	0	1
10/06/2019 09:00	0.0	0	0	0	0	1
10/06/2019 10:00	0.0	0	0	0	0	1
10/06/2019 11:00	0.0	0	0	0	0	1
10/06/2019 12:00	0.0	0	0	0	0	1
10/06/2019 13:00	0.0	0	0	0	0	1
10/06/2019 14:00	0.0	0	0	0	0	1
10/06/2019 15:00	0.0	0	0	0	0	1
10/06/2019 16:00	0.0	0	0	0	0	1
10/06/2019 17:00	0.0	0	0	0	0	1
10/06/2019 18:00	0.0	0	0	0	0	1
10/06/2019 19:00	0.0	0	0	0	0	1
10/06/2019 20:00	0.0	0	0	0	0	1
10/06/2019 21:00	0.0	0	0	0	0	1
10/06/2019 22:00	0.0	0	0	0	0	1
10/06/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/07/2019 00:00	0.0	0	0	0	0	1
10/07/2019 01:00	0.0	0	0	0	0	1
10/07/2019 02:00	0.0	0	0	0	0	1
10/07/2019 03:00	0.0	0	0	0	0	1
10/07/2019 04:00	0.0	0	0	0	0	1
10/07/2019 05:00	0.0	0	0	0	0	1
10/07/2019 06:00	0.0	0	0	0	0	1
10/07/2019 07:00	0.0	0	0	0	0	1
10/07/2019 08:00	0.0	0	0	0	0	1
10/07/2019 09:00	0.0	0	0	0	0	1
10/07/2019 10:00	0.0	0	0	0	0	1
10/07/2019 11:00	0.0	0	0	0	0	1
10/07/2019 12:00	0.0	0	0	0	0	1
10/07/2019 13:00	0.0	0	0	0	0	1
10/07/2019 14:00	0.0	0	0	0	0	1
10/07/2019 15:00	0.0	0	0	0	0	1
10/07/2019 16:00	0.0	0	0	0	0	1
10/07/2019 17:00	0.0	0	0	0	0	1
10/07/2019 18:00	0.0	0	0	0	0	1
10/07/2019 19:00	0.0	0	0	0	0	1
10/07/2019 20:00	0.0	0	0	0	0	1
10/07/2019 21:00	0.0	0	0	0	0	1
10/07/2019 22:00	0.0	0	0	0	0	1
10/07/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/08/2019 00:00	0.0	0	0	0	0	1
10/08/2019 01:00	0.0	0	0	0	0	1
10/08/2019 02:00	0.0	0	0	0	0	1
10/08/2019 03:00	0.0	0	0	0	0	1
10/08/2019 04:00	0.0	0	0	0	0	1
10/08/2019 05:00	0.0	0	0	0	0	1
10/08/2019 06:00	0.0	0	0	0	0	1
10/08/2019 07:00	0.0	0	0	0	0	1
10/08/2019 08:00	0.0	0	0	0	0	1
10/08/2019 09:00	0.0	0	0	0	0	1
10/08/2019 10:00	0.0	0	0	0	0	1
10/08/2019 11:00	0.0	0	0	0	0	1
10/08/2019 12:00	0.0	0	0	0	0	1
10/08/2019 13:00	0.0	0	0	0	0	1
10/08/2019 14:00	0.0	0	0	0	0	1
10/08/2019 15:00	0.0	0	0	0	0	1
10/08/2019 16:00	0.0	0	0	0	0	1
10/08/2019 17:00	0.0	0	0	0	0	1
10/08/2019 18:00	0.0	0	0	0	0	1
10/08/2019 19:00	0.0	0	0	0	0	1
10/08/2019 20:00	0.0	0	0	0	0	1
10/08/2019 21:00	0.0	0	0	0	0	1
10/08/2019 22:00	0.0	0	0	0	0	1
10/08/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/09/2019 00:00	0.0	0	0	0	0	1
10/09/2019 01:00	0.0	0	0	0	0	1
10/09/2019 02:00	0.0	0	0	0	0	1
10/09/2019 03:00	0.0	0	0	0	0	1
10/09/2019 04:00	0.0	0	0	0	0	1
10/09/2019 05:00	0.0	0	0	0	0	1
10/09/2019 06:00	0.0	0	0	0	0	1
10/09/2019 07:00	0.0	0	0	0	0	1
10/09/2019 08:00	0.0	0	0	0	0	1
10/09/2019 09:00	0.0	0	0	0	0	1
10/09/2019 10:00	0.0	0	0	0	0	1
10/09/2019 11:00	0.0	0	0	0	0	1
10/09/2019 12:00	0.0	0	0	0	0	1
10/09/2019 13:00	0.0	0	0	0	0	1
10/09/2019 14:00	0.0	0	0	0	0	1
10/09/2019 15:00	0.0	0	0	0	0	1
10/09/2019 16:00	0.0	0	0	0	0	1
10/09/2019 17:00	0.0	0	0	0	0	1
10/09/2019 18:00	0.0	0	0	0	0	1
10/09/2019 19:00	0.0	0	0	0	0	1
10/09/2019 20:00	0.0	0	0	0	0	1
10/09/2019 21:00	0.0	0	0	0	0	1
10/09/2019 22:00	0.0	0	0	0	0	1
10/09/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/10/2019 00:00	0.0	0	0	0	0	1
10/10/2019 01:00	0.0	0	0	0	0	1
10/10/2019 02:00	0.0	0	0	0	0	1
10/10/2019 03:00	0.0	0	0	0	0	1
10/10/2019 04:00	0.0	0	0	0	0	1
10/10/2019 05:00	0.0	0	0	0	0	1
10/10/2019 06:00	0.0	0	0	0	0	1
10/10/2019 07:00	0.0	0	0	0	0	1
10/10/2019 08:00	0.0	0	0	0	0	1
10/10/2019 09:00	0.0	0	0	0	0	1
10/10/2019 10:00	0.0	0	0	0	0	1
10/10/2019 11:00	0.0	0	0	0	0	1
10/10/2019 12:00	0.0	0	0	0	0	1
10/10/2019 13:00	0.0	0	0	0	0	1
10/10/2019 14:00	0.0	0	0	0	0	1
10/10/2019 15:00	0.0	0	0	0	0	1
10/10/2019 16:00	0.0	0	0	0	0	1
10/10/2019 17:00	0.0	0	0	0	0	1
10/10/2019 18:00	0.0	0	0	0	0	1
10/10/2019 19:00	0.0	0	0	0	0	1
10/10/2019 20:00	0.0	0	0	0	0	1
10/10/2019 21:00	0.0	0	0	0	0	1
10/10/2019 22:00	0.0	0	0	0	0	1
10/10/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/11/2019 00:00	0.0	0	0	0	0	1
10/11/2019 01:00	0.0	0	0	0	0	1
10/11/2019 02:00	0.0	0	0	0	0	1
10/11/2019 03:00	0.0	0	0	0	0	1
10/11/2019 04:00	0.0	0	0	0	0	1
10/11/2019 05:00	0.0	0	0	0	0	1
10/11/2019 06:00	0.0	0	0	0	0	1
10/11/2019 07:00	0.0	0	0	0	0	1
10/11/2019 08:00	0.0	0	0	0	0	1
10/11/2019 09:00	0.0	0	0	0	0	1
10/11/2019 10:00	0.0	0	0	0	0	1
10/11/2019 11:00	0.0	0	0	0	0	1
10/11/2019 12:00	0.0	0	0	0	0	1
10/11/2019 13:00	0.0	0	0	0	0	1
10/11/2019 14:00	0.0	0	0	0	0	1
10/11/2019 15:00	0.0	0	0	0	0	1
10/11/2019 16:00	0.0	0	0	0	0	1
10/11/2019 17:00	0.0	0	0	0	0	1
10/11/2019 18:00	0.0	0	0	0	0	1
10/11/2019 19:00	0.0	0	0	0	0	1
10/11/2019 20:00	0.0	0	0	0	0	1
10/11/2019 21:00	0.0	0	0	0	0	1
10/11/2019 22:00	0.0	0	0	0	0	1
10/11/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/12/2019 00:00	0.0	0	0	0	0	1
10/12/2019 01:00	0.0	0	0	0	0	1
10/12/2019 02:00	0.0	0	0	0	0	1
10/12/2019 03:00	0.0	0	0	0	0	1
10/12/2019 04:00	0.0	0	0	0	0	1
10/12/2019 05:00	0.0	0	0	0	0	1
10/12/2019 06:00	0.0	0	0	0	0	1
10/12/2019 07:00	1.2	0	0	0	1	0
10/12/2019 08:00	0.0	0	0	0	0	0
10/12/2019 09:00	0.0	0	0	0	0	0
10/12/2019 10:00	0.0	0	0	0	0	0
10/12/2019 11:00	0.0	0	0	0	0	0
10/12/2019 12:00	0.0	0	0	0	0	0
10/12/2019 13:00	0.0	0	0	0	0	0
10/12/2019 14:00	11.6	0	0	1	0	0
10/12/2019 15:00	36.3	0	0	1	0	0
10/12/2019 16:00	0.0	0	0	0	0	1
10/12/2019 17:00	0.0	0	0	0	0	1
10/12/2019 18:00	0.0	0	0	0	0	1
10/12/2019 19:00	0.0	0	0	0	0	1
10/12/2019 20:00	0.0	0	0	0	0	1
10/12/2019 21:00	0.0	0	0	0	0	1
10/12/2019 22:00	0.0	0	0	0	0	1
10/12/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	49.1 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	36.3	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/13/2019 00:00	0.0	0	0	0	0	1
10/13/2019 01:00	0.0	0	0	0	0	1
10/13/2019 02:00	0.0	0	0	0	0	1
10/13/2019 03:00	0.0	0	0	0	0	1
10/13/2019 04:00	0.0	0	0	0	0	1
10/13/2019 05:00	0.0	0	0	0	0	1
10/13/2019 06:00	0.0	0	0	0	0	1
10/13/2019 07:00	0.0	0	0	0	0	1
10/13/2019 08:00	0.0	0	0	0	0	1
10/13/2019 09:00	0.0	0	0	0	0	1
10/13/2019 10:00	0.0	0	0	0	0	1
10/13/2019 11:00	0.0	0	0	0	0	1
10/13/2019 12:00	0.0	0	0	0	0	1
10/13/2019 13:00	0.0	0	0	0	0	1
10/13/2019 14:00	0.0	0	0	0	0	1
10/13/2019 15:00	0.0	0	0	0	0	1
10/13/2019 16:00	0.0	0	0	0	0	1
10/13/2019 17:00	0.0	0	0	0	0	1
10/13/2019 18:00	0.0	0	0	0	0	1
10/13/2019 19:00	0.0	0	0	0	0	1
10/13/2019 20:00	0.0	0	0	0	0	1
10/13/2019 21:00	0.0	0	0	0	0	1
10/13/2019 22:00	0.0	0	0	0	0	1
10/13/2019 23:00	0.9	0	0	0	1	0
Average/Sum#:	0.9 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/14/2019 00:00	0.0	0	0	0	0	0
10/14/2019 01:00	0.0	0	0	0	0	0
10/14/2019 02:00	0.0	0	0	0	0	0
10/14/2019 03:00	0.0	0	0	0	0	0
10/14/2019 04:00	0.0	0	0	0	0	0
10/14/2019 05:00	0.0	0	0	0	0	0
10/14/2019 06:00	1.1	0	0	1	0	0
10/14/2019 07:00	23.3	0	0	1	0	0
10/14/2019 08:00	0.0	0	0	0	0	1
10/14/2019 09:00	0.0	0	0	0	0	1
10/14/2019 10:00	0.0	0	0	0	0	1
10/14/2019 11:00	0.0	0	0	0	0	1
10/14/2019 12:00	0.0	0	0	0	0	1
10/14/2019 13:00	0.0	0	0	0	0	1
10/14/2019 14:00	0.0	0	0	0	0	1
10/14/2019 15:00	0.0	0	0	0	0	1
10/14/2019 16:00	0.0	0	0	0	0	1
10/14/2019 17:00	0.0	0	0	0	0	1
10/14/2019 18:00	0.0	0	0	0	0	1
10/14/2019 19:00	0.0	0	0	0	0	1
10/14/2019 20:00	0.0	0	0	0	0	1
10/14/2019 21:00	0.0	0	0	0	0	1
10/14/2019 22:00	0.0	0	0	0	0	1
10/14/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	24.4 #	0 #	0 #	2 #	0 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	23.3	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/15/2019 00:00	0.0	0	0	0	0	1
10/15/2019 01:00	0.0	0	0	0	0	1
10/15/2019 02:00	0.0	0	0	0	0	1
10/15/2019 03:00	0.0	0	0	0	0	1
10/15/2019 04:00	0.0	0	0	0	0	1
10/15/2019 05:00	0.9	0	0	0	1	0
10/15/2019 06:00	4.7	0	0	1	0	0
10/15/2019 07:00	8.2	0	0	1	0	0
10/15/2019 08:00	0.0	0	0	0	0	1
10/15/2019 09:00	0.0	0	0	0	0	1
10/15/2019 10:00	0.0	0	0	0	0	1
10/15/2019 11:00	0.0	0	0	0	0	1
10/15/2019 12:00	0.0	0	0	0	0	1
10/15/2019 13:00	0.0	0	0	0	0	1
10/15/2019 14:00	0.0	0	0	0	0	1
10/15/2019 15:00	0.0	0	0	0	0	0
10/15/2019 16:00	0.0	0	0	0	0	0
10/15/2019 17:00	0.0	0	0	0	0	0
10/15/2019 18:00	0.0	0	0	0	0	0
10/15/2019 19:00	0.0	0	0	0	0	0
10/15/2019 20:00	0.0	0	0	0	0	0
10/15/2019 21:00	0.0	0	0	0	0	0
10/15/2019 22:00	0.0	0	0	0	0	0
10/15/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	13.8 #	0 #	0 #	2 #	1 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	8.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/16/2019 00:00	0.0	0	0	0	0	0
10/16/2019 01:00	0.0	0	0	0	0	0
10/16/2019 02:00	0.0	0	0	0	0	0
10/16/2019 03:00	0.0	0	0	0	0	0
10/16/2019 04:00	0.0	0	0	0	0	0
10/16/2019 05:00	0.0	0	0	0	0	0
10/16/2019 06:00	0.0	0	0	0	0	0
10/16/2019 07:00	0.0	0	0	0	0	0
10/16/2019 08:00	0.0	0	0	0	0	0
10/16/2019 09:00	0.0	0	0	0	0	0
10/16/2019 10:00	0.0	0	0	0	0	0
10/16/2019 11:00	0.0	0	0	0	0	0
10/16/2019 12:00	0.0	0	0	0	0	0
10/16/2019 13:00	0.0	0	0	0	0	0
10/16/2019 14:00	0.0	0	0	0	0	0
10/16/2019 15:00	0.0	0	0	0	0	0
10/16/2019 16:00	0.0	0	0	0	0	0
10/16/2019 17:00	0.0	0	0	0	0	0
10/16/2019 18:00	0.0	0	0	0	0	0
10/16/2019 19:00	0.0	0	0	0	0	0
10/16/2019 20:00	21.2	0	1	0	0	0
10/16/2019 21:00	70.1	0	1	0	0	0
10/16/2019 22:00	0.0	0	0	0	0	1
10/16/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	91.3 #	0 #	2 #	0 #	0 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	70.1	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/17/2019 00:00	0.0	0	0	0	0	1
10/17/2019 01:00	0.0	0	0	0	0	1
10/17/2019 02:00	0.0	0	0	0	0	1
10/17/2019 03:00	0.0	0	0	0	0	1
10/17/2019 04:00	0.0	0	0	0	0	1
10/17/2019 05:00	0.0	0	0	0	0	1
10/17/2019 06:00	0.0	0	0	0	0	1
10/17/2019 07:00	0.0	0	0	0	0	1
10/17/2019 08:00	0.0	0	0	0	0	1
10/17/2019 09:00	0.0	0	0	0	0	1
10/17/2019 10:00	0.0	0	0	0	0	1
10/17/2019 11:00	0.0	0	0	0	0	1
10/17/2019 12:00	0.0	0	0	0	0	1
10/17/2019 13:00	0.0	0	0	0	0	1
10/17/2019 14:00	0.0	0	0	0	0	1
10/17/2019 15:00	0.0	0	0	0	0	1
10/17/2019 16:00	0.0	0	0	0	0	1
10/17/2019 17:00	0.0	0	0	0	0	1
10/17/2019 18:00	0.0	0	0	0	0	1
10/17/2019 19:00	0.0	0	0	0	0	1
10/17/2019 20:00	0.0	0	0	0	0	1
10/17/2019 21:00	0.0	0	0	0	0	1
10/17/2019 22:00	0.0	0	0	0	0	1
10/17/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/18/2019 00:00	0.0	0	0	0	0	1
10/18/2019 01:00	0.0	0	0	0	0	1
10/18/2019 02:00	0.0	0	0	0	0	1
10/18/2019 03:00	0.0	0	0	0	0	1
10/18/2019 04:00	0.0	0	0	0	0	1
10/18/2019 05:00	0.0	0	0	0	0	1
10/18/2019 06:00	0.0	0	0	0	0	1
10/18/2019 07:00	0.0	0	0	0	0	1
10/18/2019 08:00	0.0	0	0	0	0	1
10/18/2019 09:00	0.0	0	0	0	0	1
10/18/2019 10:00	0.0	0	0	0	0	1
10/18/2019 11:00	0.0	0	0	0	0	1
10/18/2019 12:00	0.0	0	0	0	0	1
10/18/2019 13:00	0.0	0	0	0	0	1
10/18/2019 14:00	0.0	0	0	0	0	1
10/18/2019 15:00	0.0	0	0	0	0	1
10/18/2019 16:00	0.0	0	0	0	0	1
10/18/2019 17:00	0.0	0	0	0	0	1
10/18/2019 18:00	0.0	0	0	0	0	1
10/18/2019 19:00	0.0	0	0	0	0	1
10/18/2019 20:00	0.0	0	0	0	0	1
10/18/2019 21:00	0.0	0	0	0	0	1
10/18/2019 22:00	0.0	0	0	0	0	1
10/18/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/19/2019 00:00	0.0	0	0	0	0	1
10/19/2019 01:00	0.0	0	0	0	0	1
10/19/2019 02:00	0.0	0	0	0	0	1
10/19/2019 03:00	0.0	0	0	0	0	1
10/19/2019 04:00	0.0	0	0	0	0	1
10/19/2019 05:00	0.0	0	0	0	0	1
10/19/2019 06:00	0.0	0	0	0	0	1
10/19/2019 07:00	0.8	0	0	0	1	0
10/19/2019 08:00	0.0	0	0	0	0	0
10/19/2019 09:00	0.0	0	0	0	0	0
10/19/2019 10:00	0.0	0	0	0	0	0
10/19/2019 11:00	0.0	0	0	0	0	0
10/19/2019 12:00	0.0	0	0	0	0	0
10/19/2019 13:00	0.0	0	0	0	0	0
10/19/2019 14:00	0.0	0	0	0	0	0
10/19/2019 15:00	0.0	0	0	0	0	0
10/19/2019 16:00	0.0	0	0	0	0	0
10/19/2019 17:00	0.0	0	0	0	0	0
10/19/2019 18:00	0.0	0	0	0	0	0
10/19/2019 19:00	0.0	0	0	0	0	0
10/19/2019 20:00	0.0	0	0	0	0	0
10/19/2019 21:00	0.0	0	0	0	0	0
10/19/2019 22:00	0.0	0	0	0	0	0
10/19/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/20/2019 00:00	0.0	0	0	0	0	0
10/20/2019 01:00	0.0	0	0	0	0	0
10/20/2019 02:00	0.0	0	0	0	0	0
10/20/2019 03:00	0.0	0	0	0	0	0
10/20/2019 04:00	0.0	0	0	0	0	0
10/20/2019 05:00	0.0	0	0	0	0	0
10/20/2019 06:00	0.0	0	0	0	0	0
10/20/2019 07:00	0.0	0	0	0	0	0
10/20/2019 08:00	0.0	0	0	0	0	0
10/20/2019 09:00	0.0	0	0	0	0	0
10/20/2019 10:00	0.0	0	0	0	0	0
10/20/2019 11:00	0.0	0	0	0	0	0
10/20/2019 12:00	0.0	0	0	0	0	0
10/20/2019 13:00	0.0	0	0	0	0	0
10/20/2019 14:00	77.7	0	1	0	0	0
10/20/2019 15:00	36.4	0	1	0	0	0
10/20/2019 16:00	0.0	0	0	0	0	1
10/20/2019 17:00	0.0	0	0	0	0	1
10/20/2019 18:00	0.0	0	0	0	0	1
10/20/2019 19:00	0.0	0	0	0	0	1
10/20/2019 20:00	0.0	0	0	0	0	1
10/20/2019 21:00	0.0	0	0	0	0	1
10/20/2019 22:00	0.0	0	0	0	0	1
10/20/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	114.1 #	0 #	2 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	77.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/21/2019 00:00	0.0	0	0	0	0	1
10/21/2019 01:00	0.0	0	0	0	0	1
10/21/2019 02:00	0.0	0	0	0	0	1
10/21/2019 03:00	0.0	0	0	0	0	1
10/21/2019 04:00	0.0	0	0	0	0	1
10/21/2019 05:00	0.0	0	0	0	0	1
10/21/2019 06:00	0.0	0	0	0	0	1
10/21/2019 07:00	0.0	0	0	0	0	1
10/21/2019 08:00	0.0	0	0	0	0	1
10/21/2019 09:00	0.0	0	0	0	0	1
10/21/2019 10:00	0.0	0	0	0	0	1
10/21/2019 11:00	0.0	0	0	0	0	1
10/21/2019 12:00	0.0	0	0	0	0	1
10/21/2019 13:00	0.0	0	0	0	0	1
10/21/2019 14:00	0.0	0	0	0	0	1
10/21/2019 15:00	0.0	0	0	0	0	1
10/21/2019 16:00	0.0	0	0	0	0	1
10/21/2019 17:00	0.0	0	0	0	0	1
10/21/2019 18:00	0.0	0	0	0	0	1
10/21/2019 19:00	0.0	0	0	0	0	1
10/21/2019 20:00	0.0	0	0	0	0	1
10/21/2019 21:00	0.0	0	0	0	0	1
10/21/2019 22:00	0.0	0	0	0	0	1
10/21/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/22/2019 00:00	0.0	0	0	0	0	1
10/22/2019 01:00	0.0	0	0	0	0	1
10/22/2019 02:00	0.0	0	0	0	0	1
10/22/2019 03:00	0.0	0	0	0	0	1
10/22/2019 04:00	0.0	0	0	0	0	1
10/22/2019 05:00	0.0	0	0	0	0	1
10/22/2019 06:00	0.0	0	0	0	0	1
10/22/2019 07:00	0.0	0	0	0	0	1
10/22/2019 08:00	0.0	0	0	0	0	1
10/22/2019 09:00	0.0	0	0	0	0	1
10/22/2019 10:00	0.0	0	0	0	0	1
10/22/2019 11:00	0.0	0	0	0	0	1
10/22/2019 12:00	0.0	0	0	0	0	1
10/22/2019 13:00	0.0	0	0	0	0	1
10/22/2019 14:00	0.0	0	0	0	0	1
10/22/2019 15:00	0.0	0	0	0	0	1
10/22/2019 16:00	0.0	0	0	0	0	1
10/22/2019 17:00	0.0	0	0	0	0	1
10/22/2019 18:00	0.0	0	0	0	0	1
10/22/2019 19:00	0.0	0	0	0	0	1
10/22/2019 20:00	0.0	0	0	0	0	1
10/22/2019 21:00	0.0	0	0	0	0	1
10/22/2019 22:00	0.0	0	0	0	0	1
10/22/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/23/2019 00:00	0.0	0	0	0	0	1
10/23/2019 01:00	0.0	0	0	0	0	1
10/23/2019 02:00	0.0	0	0	0	0	1
10/23/2019 03:00	0.0	0	0	0	0	1
10/23/2019 04:00	0.0	0	0	0	0	1
10/23/2019 05:00	0.0	0	0	0	0	1
10/23/2019 06:00	0.0	0	0	0	0	1
10/23/2019 07:00	0.0	0	0	0	0	1
10/23/2019 08:00	0.0	0	0	0	0	1
10/23/2019 09:00	0.0	0	0	0	0	1
10/23/2019 10:00	0.0	0	0	0	0	1
10/23/2019 11:00	0.0	0	0	0	0	1
10/23/2019 12:00	0.0	0	0	0	0	1
10/23/2019 13:00	0.0	0	0	0	0	1
10/23/2019 14:00	0.0	0	0	0	0	1
10/23/2019 15:00	0.0	0	0	0	0	1
10/23/2019 16:00	0.0	0	0	0	0	1
10/23/2019 17:00	0.0	0	0	0	0	1
10/23/2019 18:00	0.0	0	0	0	0	1
10/23/2019 19:00	0.0	0	0	0	0	1
10/23/2019 20:00	0.0	0	0	0	0	1
10/23/2019 21:00	0.0	0	0	0	0	1
10/23/2019 22:00	0.0	0	0	0	0	1
10/23/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/24/2019 00:00	0.0	0	0	0	0	1
10/24/2019 01:00	0.0	0	0	0	0	1
10/24/2019 02:00	0.0	0	0	0	0	1
10/24/2019 03:00	0.0	0	0	0	0	1
10/24/2019 04:00	0.0	0	0	0	0	1
10/24/2019 05:00	0.0	0	0	0	0	1
10/24/2019 06:00	0.0	0	0	0	0	1
10/24/2019 07:00	0.0	0	0	0	0	1
10/24/2019 08:00	0.0	0	0	0	0	1
10/24/2019 09:00	0.0	0	0	0	0	1
10/24/2019 10:00	0.0	0	0	0	0	1
10/24/2019 11:00	0.0	0	0	0	0	1
10/24/2019 12:00	0.0	0	0	0	0	1
10/24/2019 13:00	0.0	0	0	0	0	1
10/24/2019 14:00	0.0	0	0	0	0	1
10/24/2019 15:00	0.0	0	0	0	0	1
10/24/2019 16:00	0.0	0	0	0	0	1
10/24/2019 17:00	0.0	0	0	0	0	1
10/24/2019 18:00	0.0	0	0	0	0	1
10/24/2019 19:00	0.0	0	0	0	0	1
10/24/2019 20:00	0.0	0	0	0	0	1
10/24/2019 21:00	0.0	0	0	0	0	1
10/24/2019 22:00	0.0	0	0	0	0	1
10/24/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/25/2019 00:00	0.0	0	0	0	0	1
10/25/2019 01:00	0.0	0	0	0	0	1
10/25/2019 02:00	0.0	0	0	0	0	1
10/25/2019 03:00	0.0	0	0	0	0	1
10/25/2019 04:00	0.0	0	0	0	0	1
10/25/2019 05:00	0.0	0	0	0	0	1
10/25/2019 06:00	0.0	0	0	0	0	1
10/25/2019 07:00	0.0	0	0	0	0	1
10/25/2019 08:00	0.0	0	0	0	0	1
10/25/2019 09:00	0.0	0	0	0	0	1
10/25/2019 10:00	0.0	0	0	0	0	1
10/25/2019 11:00	0.0	0	0	0	0	1
10/25/2019 12:00	0.0	0	0	0	0	1
10/25/2019 13:00	0.0	0	0	0	0	1
10/25/2019 14:00	0.0	0	0	0	0	1
10/25/2019 15:00	0.0	0	0	0	0	1
10/25/2019 16:00	0.0	0	0	0	0	1
10/25/2019 17:00	0.0	0	0	0	0	1
10/25/2019 18:00	0.0	0	0	0	0	1
10/25/2019 19:00	0.0	0	0	0	0	1
10/25/2019 20:00	0.0	0	0	0	0	1
10/25/2019 21:00	0.0	0	0	0	0	1
10/25/2019 22:00	0.0	0	0	0	0	1
10/25/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/26/2019 00:00	0.0	0	0	0	0	1
10/26/2019 01:00	0.0	0	0	0	0	1
10/26/2019 02:00	0.0	0	0	0	0	1
10/26/2019 03:00	0.0	0	0	0	0	1
10/26/2019 04:00	0.0	0	0	0	0	1
10/26/2019 05:00	0.0	0	0	0	0	1
10/26/2019 06:00	0.0	0	0	0	0	1
10/26/2019 07:00	0.0	0	0	0	0	1
10/26/2019 08:00	0.0	0	0	0	0	1
10/26/2019 09:00	0.0	0	0	0	0	1
10/26/2019 10:00	0.0	0	0	0	0	1
10/26/2019 11:00	0.0	0	0	0	0	1
10/26/2019 12:00	0.0	0	0	0	0	1
10/26/2019 13:00	0.0	0	0	0	0	1
10/26/2019 14:00	0.0	0	0	0	0	1
10/26/2019 15:00	0.0	0	0	0	0	1
10/26/2019 16:00	0.0	0	0	0	0	1
10/26/2019 17:00	0.0	0	0	0	0	1
10/26/2019 18:00	0.0	0	0	0	0	1
10/26/2019 19:00	0.0	0	0	0	0	1
10/26/2019 20:00	0.0	0	0	0	0	1
10/26/2019 21:00	0.0	0	0	0	0	1
10/26/2019 22:00	1.1	0	0	0	1	0
10/26/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.1 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/27/2019 00:00	0.0	0	0	0	0	0
10/27/2019 01:00	0.0	0	0	0	0	0
10/27/2019 02:00	0.0	0	0	0	0	0
10/27/2019 03:00	0.0	0	0	0	0	0
10/27/2019 04:00	0.0	0	0	0	0	0
10/27/2019 05:00	0.0	0	0	0	0	0
10/27/2019 06:00	0.0	0	0	0	0	0
10/27/2019 07:00	0.0	0	0	0	0	0
10/27/2019 08:00	0.0	0	0	0	0	0
10/27/2019 09:00	0.0	0	0	0	0	0
10/27/2019 10:00	0.0	0	0	0	0	0
10/27/2019 11:00	0.0	0	0	0	0	0
10/27/2019 12:00	0.0	0	0	0	0	0
10/27/2019 13:00	0.0	0	0	0	0	0
10/27/2019 14:00	0.0	0	0	0	0	0
10/27/2019 15:00	0.0	0	0	0	0	0
10/27/2019 16:00	0.0	0	0	0	0	0
10/27/2019 17:00	0.0	0	0	0	0	0
10/27/2019 18:00	0.0	0	0	0	0	0
10/27/2019 19:00	0.0	0	0	0	0	0
10/27/2019 20:00	0.0	0	0	0	0	0
10/27/2019 21:00	0.0	0	0	0	0	0
10/27/2019 22:00	0.0	0	0	0	0	0
10/27/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/28/2019 00:00	16.2	0	1	0	0	0
10/28/2019 01:00	110.9	0	1	0	0	0
10/28/2019 02:00	0.0	0	0	0	0	1
10/28/2019 03:00	0.0	0	0	0	0	1
10/28/2019 04:00	0.0	0	0	0	0	1
10/28/2019 05:00	0.0	0	0	0	0	1
10/28/2019 06:00	0.0	0	0	0	0	1
10/28/2019 07:00	0.0	0	0	0	0	1
10/28/2019 08:00	0.0	0	0	0	0	1
10/28/2019 09:00	0.0	0	0	0	0	1
10/28/2019 10:00	0.0	0	0	0	0	1
10/28/2019 11:00	0.0	0	0	0	0	1
10/28/2019 12:00	0.0	0	0	0	0	1
10/28/2019 13:00	0.0	0	0	0	0	1
10/28/2019 14:00	0.0	0	0	0	0	1
10/28/2019 15:00	0.0	0	0	0	0	1
10/28/2019 16:00	0.0	0	0	0	0	1
10/28/2019 17:00	0.0	0	0	0	0	1
10/28/2019 18:00	0.0	0	0	0	0	1
10/28/2019 19:00	0.0	0	0	0	0	1
10/28/2019 20:00	0.0	0	0	0	0	1
10/28/2019 21:00	0.0	0	0	0	0	1
10/28/2019 22:00	0.0	0	0	0	0	1
10/28/2019 23:00	1.2	0	0	0	1	0
Average/Sum#:	128.3 #	0 #	2 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	110.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/29/2019 00:00	0.0	0	0	0	0	0
10/29/2019 01:00	0.0	0	0	0	0	0
10/29/2019 02:00	0.0	0	0	0	0	0
10/29/2019 03:00	0.0	0	0	0	0	0
10/29/2019 04:00	0.0	0	0	0	0	0
10/29/2019 05:00	0.0	0	0	0	0	0
10/29/2019 06:00	0.0	0	0	0	0	0
10/29/2019 07:00	0.0	0	0	0	0	0
10/29/2019 08:00	0.0	0	0	0	0	0
10/29/2019 09:00	0.0	0	0	0	0	0
10/29/2019 10:00	0.0	0	0	0	0	0
10/29/2019 11:00	0.0	0	0	0	0	0
10/29/2019 12:00	0.0	0	0	0	0	0
10/29/2019 13:00	0.0	0	0	0	0	0
10/29/2019 14:00	0.0	0	0	0	0	0
10/29/2019 15:00	0.0	0	0	0	0	0
10/29/2019 16:00	0.0	0	0	0	0	0
10/29/2019 17:00	0.0	0	0	0	0	0
10/29/2019 18:00	0.0	0	0	0	0	0
10/29/2019 19:00	0.0	0	0	0	0	0
10/29/2019 20:00	0.0	0	0	0	0	0
10/29/2019 21:00	0.0	0	0	0	0	0
10/29/2019 22:00	0.0	0	0	0	0	0
10/29/2019 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/30/2019 00:00	0.0	0	0	0	0	0
10/30/2019 01:00	0.0	0	0	0	0	0
10/30/2019 02:00	0.0	0	0	0	0	0
10/30/2019 03:00	0.0	0	0	0	0	0
10/30/2019 04:00	0.2	0	1	0	0	0
10/30/2019 05:00	93.5	0	1	0	0	0
10/30/2019 06:00	64.3	0	1	0	0	0
10/30/2019 07:00	0.0	0	0	0	0	1
10/30/2019 08:00	0.0	0	0	0	0	1
10/30/2019 09:00	0.0	0	0	0	0	1
10/30/2019 10:00	0.0	0	0	0	0	1
10/30/2019 11:00	0.0	0	0	0	0	1
10/30/2019 12:00	0.0	0	0	0	0	1
10/30/2019 13:00	0.0	0	0	0	0	1
10/30/2019 14:00	0.0	0	0	0	0	1
10/30/2019 15:00	0.0	0	0	0	0	1
10/30/2019 16:00	0.0	0	0	0	0	1
10/30/2019 17:00	0.0	0	0	0	0	1
10/30/2019 18:00	0.0	0	0	0	0	1
10/30/2019 19:00	0.0	0	0	0	0	1
10/30/2019 20:00	0.0	0	0	0	0	1
10/30/2019 21:00	0.0	0	0	0	0	1
10/30/2019 22:00	0.0	0	0	0	0	1
10/30/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	158.0 #	0 #	3 #	0 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	93.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/31/2019 00:00	0.0	0	0	0	0	1
10/31/2019 01:00	0.0	0	0	0	0	1
10/31/2019 02:00	0.0	0	0	0	0	1
10/31/2019 03:00	0.0	0	0	0	0	1
10/31/2019 04:00	0.0	0	0	0	0	1
10/31/2019 05:00	0.0	0	0	0	0	1
10/31/2019 06:00	0.0	0	0	0	0	1
10/31/2019 07:00	0.0	0	0	0	0	1
10/31/2019 08:00	0.0	0	0	0	0	1
10/31/2019 09:00	0.0	0	0	0	0	1
10/31/2019 10:00	0.0	0	0	0	0	1
10/31/2019 11:00	0.0	0	0	0	0	1
10/31/2019 12:00	0.0	0	0	0	0	1
10/31/2019 13:00	0.0	0	0	0	0	1
10/31/2019 14:00	0.0	0	0	0	0	1
10/31/2019 15:00	0.0	0	0	0	0	1
10/31/2019 16:00	0.0	0	0	0	0	1
10/31/2019 17:00	0.0	0	0	0	0	1
10/31/2019 18:00	0.0	0	0	0	0	1
10/31/2019 19:00	0.0	0	0	0	0	1
10/31/2019 20:00	0.0	0	0	0	0	1
10/31/2019 21:00	0.0	0	0	0	0	1
10/31/2019 22:00	0.0	0	0	0	0	1
10/31/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/01/2019 00:00	0.0	0	0	0	0	1
11/01/2019 01:00	0.0	0	0	0	0	1
11/01/2019 02:00	0.0	0	0	0	0	1
11/01/2019 03:00	0.0	0	0	0	0	1
11/01/2019 04:00	0.0	0	0	0	0	1
11/01/2019 05:00	0.0	0	0	0	0	1
11/01/2019 06:00	0.0	0	0	0	0	1
11/01/2019 07:00	0.0	0	0	0	0	1
11/01/2019 08:00	0.0	0	0	0	0	1
11/01/2019 09:00	0.0	0	0	0	0	1
11/01/2019 10:00	0.0	0	0	0	0	1
11/01/2019 11:00	0.0	0	0	0	0	1
11/01/2019 12:00	0.0	0	0	0	0	1
11/01/2019 13:00	0.0	0	0	0	0	1
11/01/2019 14:00	0.0	0	0	0	0	1
11/01/2019 15:00	0.0	0	0	0	0	1
11/01/2019 16:00	0.0	0	0	0	0	1
11/01/2019 17:00	0.0	0	0	0	0	1
11/01/2019 18:00	0.0	0	0	0	0	1
11/01/2019 19:00	0.0	0	0	0	0	1
11/01/2019 20:00	0.0	0	0	0	0	1
11/01/2019 21:00	0.0	0	0	0	0	1
11/01/2019 22:00	0.0	0	0	0	0	1
11/01/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/02/2019 00:00	0.0	0	0	0	0	1
11/02/2019 01:00	0.0	0	0	0	0	1
11/02/2019 02:00	0.0	0	0	0	0	1
11/02/2019 03:00	0.0	0	0	0	0	1
11/02/2019 04:00	0.0	0	0	0	0	1
11/02/2019 05:00	0.0	0	0	0	0	1
11/02/2019 06:00	0.0	0	0	0	0	1
11/02/2019 07:00	0.0	0	0	0	0	1
11/02/2019 08:00	0.0	0	0	0	0	1
11/02/2019 09:00	0.0	0	0	0	0	1
11/02/2019 10:00	0.0	0	0	0	0	1
11/02/2019 11:00	0.0	0	0	0	0	1
11/02/2019 12:00	0.0	0	0	0	0	1
11/02/2019 13:00	1.2	0	0	0	1	0
11/02/2019 14:00	0.0	0	0	0	0	0
11/02/2019 15:00	2.4	0	0	1	0	0
11/02/2019 16:00	12.6	0	0	1	0	0
11/02/2019 17:00	0.0	0	0	0	0	1
11/02/2019 18:00	0.0	0	0	0	0	1
11/02/2019 19:00	0.0	0	0	0	0	1
11/02/2019 20:00	0.0	0	0	0	0	1
11/02/2019 21:00	0.0	0	0	0	0	1
11/02/2019 22:00	0.0	0	0	0	0	1
11/02/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	16.2 #	0 #	0 #	2 #	1 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	12.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/03/2019 00:00	0.0	0	0	0	0	1
11/03/2019 01:00	0.0	0	0	0	0	1
11/03/2019 02:00	0.0	0	0	0	0	1
11/03/2019 03:00	0.0	0	0	0	0	1
11/03/2019 04:00	0.0	0	0	0	0	1
11/03/2019 05:00	0.0	0	0	0	0	1
11/03/2019 06:00	0.0	0	0	0	0	1
11/03/2019 07:00	0.0	0	0	0	0	1
11/03/2019 08:00	0.0	0	0	0	0	1
11/03/2019 09:00	0.0	0	0	0	0	1
11/03/2019 10:00	0.0	0	0	0	0	1
11/03/2019 11:00	0.0	0	0	0	0	1
11/03/2019 12:00	0.0	0	0	0	0	1
11/03/2019 13:00	0.0	0	0	0	0	1
11/03/2019 14:00	0.0	0	0	0	0	1
11/03/2019 15:00	0.0	0	0	0	0	1
11/03/2019 16:00	0.0	0	0	0	0	1
11/03/2019 17:00	0.0	0	0	0	0	1
11/03/2019 18:00	0.0	0	0	0	0	1
11/03/2019 19:00	0.0	0	0	0	0	1
11/03/2019 20:00	0.0	0	0	0	0	1
11/03/2019 21:00	0.0	0	0	0	0	1
11/03/2019 22:00	0.0	0	0	0	0	1
11/03/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/04/2019 00:00	0.0	0	0	0	0	1
11/04/2019 01:00	0.0	0	0	0	0	1
11/04/2019 02:00	0.0	0	0	0	0	1
11/04/2019 03:00	0.0	0	0	0	0	1
11/04/2019 04:00	0.0	0	0	0	0	1
11/04/2019 05:00	0.0	0	0	0	0	1
11/04/2019 06:00	0.0	0	0	0	0	1
11/04/2019 07:00	0.0	0	0	0	0	1
11/04/2019 08:00	0.0	0	0	0	0	1
11/04/2019 09:00	0.0	0	0	0	0	1
11/04/2019 10:00	0.0	0	0	0	0	1
11/04/2019 11:00	0.0	0	0	0	0	1
11/04/2019 12:00	0.0	0	0	0	0	1
11/04/2019 13:00	0.0	0	0	0	0	1
11/04/2019 14:00	0.0	0	0	0	0	1
11/04/2019 15:00	0.0	0	0	0	0	1
11/04/2019 16:00	0.0	0	0	0	0	1
11/04/2019 17:00	0.0	0	0	0	0	1
11/04/2019 18:00	0.0	0	0	0	0	1
11/04/2019 19:00	0.0	0	0	0	0	1
11/04/2019 20:00	0.0	0	0	0	0	1
11/04/2019 21:00	0.0	0	0	0	0	1
11/04/2019 22:00	0.0	0	0	0	0	1
11/04/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/05/2019 00:00	0.0	0	0	0	0	1
11/05/2019 01:00	0.0	0	0	0	0	1
11/05/2019 02:00	0.0	0	0	0	0	1
11/05/2019 03:00	0.0	0	0	0	0	1
11/05/2019 04:00	0.0	0	0	0	0	1
11/05/2019 05:00	0.0	0	0	0	0	1
11/05/2019 06:00	0.0	0	0	0	0	1
11/05/2019 07:00	0.0	0	0	0	0	1
11/05/2019 08:00	0.0	0	0	0	0	1
11/05/2019 09:00	0.0	0	0	0	0	1
11/05/2019 10:00	0.0	0	0	0	0	1
11/05/2019 11:00	0.0	0	0	0	0	1
11/05/2019 12:00	0.0	0	0	0	0	1
11/05/2019 13:00	0.0	0	0	0	0	1
11/05/2019 14:00	0.0	0	0	0	0	1
11/05/2019 15:00	0.0	0	0	0	0	1
11/05/2019 16:00	0.0	0	0	0	0	1
11/05/2019 17:00	0.0	0	0	0	0	1
11/05/2019 18:00	0.0	0	0	0	0	1
11/05/2019 19:00	0.0	0	0	0	0	1
11/05/2019 20:00	0.0	0	0	0	0	1
11/05/2019 21:00	0.0	0	0	0	0	1
11/05/2019 22:00	0.0	0	0	0	0	1
11/05/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/06/2019 00:00	0.0	0	0	0	0	1
11/06/2019 01:00	0.0	0	0	0	0	1
11/06/2019 02:00	0.0	0	0	0	0	1
11/06/2019 03:00	0.0	0	0	0	0	1
11/06/2019 04:00	0.0	0	0	0	0	1
11/06/2019 05:00	0.0	0	0	0	0	1
11/06/2019 06:00	0.0	0	0	0	0	1
11/06/2019 07:00	0.0	0	0	0	0	1
11/06/2019 08:00	0.0	0	0	0	0	1
11/06/2019 09:00	0.0	0	0	0	0	1
11/06/2019 10:00	0.0	0	0	0	0	1
11/06/2019 11:00	0.0	0	0	0	0	1
11/06/2019 12:00	0.0	0	0	0	0	1
11/06/2019 13:00	0.0	0	0	0	0	1
11/06/2019 14:00	0.0	0	0	0	0	1
11/06/2019 15:00	0.0	0	0	0	0	1
11/06/2019 16:00	0.0	0	0	0	0	1
11/06/2019 17:00	0.0	0	0	0	0	1
11/06/2019 18:00	0.0	0	0	0	0	1
11/06/2019 19:00	0.0	0	0	0	0	1
11/06/2019 20:00	0.0	0	0	0	0	1
11/06/2019 21:00	0.0	0	0	0	0	1
11/06/2019 22:00	0.0	0	0	0	0	1
11/06/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/07/2019 00:00	0.0	0	0	0	0	1
11/07/2019 01:00	0.0	0	0	0	0	1
11/07/2019 02:00	0.0	0	0	0	0	1
11/07/2019 03:00	0.0	0	0	0	0	1
11/07/2019 04:00	0.0	0	0	0	0	1
11/07/2019 05:00	0.0	0	0	0	0	1
11/07/2019 06:00	0.0	0	0	0	0	1
11/07/2019 07:00	0.0	0	0	0	0	1
11/07/2019 08:00	0.0	0	0	0	0	1
11/07/2019 09:00	0.0	0	0	0	0	1
11/07/2019 10:00	0.0	0	0	0	0	1
11/07/2019 11:00	0.0	0	0	0	0	1
11/07/2019 12:00	0.0	0	0	0	0	1
11/07/2019 13:00	0.0	0	0	0	0	1
11/07/2019 14:00	0.0	0	0	0	0	1
11/07/2019 15:00	0.0	0	0	0	0	1
11/07/2019 16:00	0.0	0	0	0	0	1
11/07/2019 17:00	0.0	0	0	0	0	1
11/07/2019 18:00	0.0	0	0	0	0	1
11/07/2019 19:00	0.0	0	0	0	0	1
11/07/2019 20:00	0.0	0	0	0	0	1
11/07/2019 21:00	0.0	0	0	0	0	1
11/07/2019 22:00	0.0	0	0	0	0	1
11/07/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/08/2019 00:00	0.0	0	0	0	0	1
11/08/2019 01:00	0.0	0	0	0	0	1
11/08/2019 02:00	0.0	0	0	0	0	1
11/08/2019 03:00	0.0	0	0	0	0	1
11/08/2019 04:00	0.0	0	0	0	0	1
11/08/2019 05:00	0.0	0	0	0	0	1
11/08/2019 06:00	0.0	0	0	0	0	1
11/08/2019 07:00	0.0	0	0	0	0	1
11/08/2019 08:00	0.0	0	0	0	0	1
11/08/2019 09:00	0.0	0	0	0	0	1
11/08/2019 10:00	0.0	0	0	0	0	1
11/08/2019 11:00	0.0	0	0	0	0	1
11/08/2019 12:00	0.0	0	0	0	0	1
11/08/2019 13:00	0.0	0	0	0	0	1
11/08/2019 14:00	0.0	0	0	0	0	1
11/08/2019 15:00	0.0	0	0	0	0	1
11/08/2019 16:00	0.0	0	0	0	0	1
11/08/2019 17:00	0.0	0	0	0	0	1
11/08/2019 18:00	0.0	0	0	0	0	1
11/08/2019 19:00	0.0	0	0	0	0	1
11/08/2019 20:00	0.0	0	0	0	0	1
11/08/2019 21:00	0.0	0	0	0	0	1
11/08/2019 22:00	0.0	0	0	0	0	1
11/08/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/09/2019 00:00	0.0	0	0	0	0	1
11/09/2019 01:00	0.0	0	0	0	0	1
11/09/2019 02:00	0.0	0	0	0	0	1
11/09/2019 03:00	0.0	0	0	0	0	1
11/09/2019 04:00	0.0	0	0	0	0	1
11/09/2019 05:00	0.0	0	0	0	0	1
11/09/2019 06:00	0.0	0	0	0	0	1
11/09/2019 07:00	0.0	0	0	0	0	1
11/09/2019 08:00	0.0	0	0	0	0	1
11/09/2019 09:00	0.0	0	0	0	0	1
11/09/2019 10:00	0.0	0	0	0	0	1
11/09/2019 11:00	0.0	0	0	0	0	1
11/09/2019 12:00	0.0	0	0	0	0	1
11/09/2019 13:00	0.0	0	0	0	0	1
11/09/2019 14:00	0.0	0	0	0	0	1
11/09/2019 15:00	0.0	0	0	0	0	1
11/09/2019 16:00	0.0	0	0	0	0	1
11/09/2019 17:00	0.0	0	0	0	0	1
11/09/2019 18:00	0.0	0	0	0	0	1
11/09/2019 19:00	0.0	0	0	0	0	1
11/09/2019 20:00	0.0	0	0	0	0	1
11/09/2019 21:00	0.0	0	0	0	0	1
11/09/2019 22:00	0.0	0	0	0	0	1
11/09/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/10/2019 00:00	0.0	0	0	0	0	1
11/10/2019 01:00	0.0	0	0	0	0	1
11/10/2019 02:00	0.0	0	0	0	0	1
11/10/2019 03:00	0.0	0	0	0	0	1
11/10/2019 04:00	0.0	0	0	0	0	1
11/10/2019 05:00	0.0	0	0	0	0	1
11/10/2019 06:00	0.0	0	0	0	0	1
11/10/2019 07:00	0.0	0	0	0	0	1
11/10/2019 08:00	0.0	0	0	0	0	1
11/10/2019 09:00	0.0	0	0	0	0	1
11/10/2019 10:00	0.0	0	0	0	0	1
11/10/2019 11:00	0.0	0	0	0	0	1
11/10/2019 12:00	0.0	0	0	0	0	1
11/10/2019 13:00	0.0	0	0	0	0	1
11/10/2019 14:00	0.0	0	0	0	0	1
11/10/2019 15:00	0.0	0	0	0	0	1
11/10/2019 16:00	0.0	0	0	0	0	1
11/10/2019 17:00	0.0	0	0	0	0	1
11/10/2019 18:00	0.0	0	0	0	0	1
11/10/2019 19:00	0.0	0	0	0	0	1
11/10/2019 20:00	0.0	0	0	0	0	1
11/10/2019 21:00	0.0	0	0	0	0	1
11/10/2019 22:00	0.0	0	0	0	0	1
11/10/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/11/2019 00:00	0.0	0	0	0	0	1
11/11/2019 01:00	0.0	0	0	0	0	1
11/11/2019 02:00	0.0	0	0	0	0	1
11/11/2019 03:00	0.0	0	0	0	0	1
11/11/2019 04:00	0.0	0	0	0	0	1
11/11/2019 05:00	0.0	0	0	0	0	1
11/11/2019 06:00	0.0	0	0	0	0	1
11/11/2019 07:00	0.0	0	0	0	0	1
11/11/2019 08:00	0.0	0	0	0	0	1
11/11/2019 09:00	0.0	0	0	0	0	1
11/11/2019 10:00	0.0	0	0	0	0	1
11/11/2019 11:00	0.0	0	0	0	0	1
11/11/2019 12:00	0.0	0	0	0	0	1
11/11/2019 13:00	0.0	0	0	0	0	1
11/11/2019 14:00	0.0	0	0	0	0	1
11/11/2019 15:00	0.0	0	0	0	0	1
11/11/2019 16:00	0.0	0	0	0	0	1
11/11/2019 17:00	0.0	0	0	0	0	1
11/11/2019 18:00	0.0	0	0	0	0	1
11/11/2019 19:00	0.0	0	0	0	0	1
11/11/2019 20:00	0.0	0	0	0	0	1
11/11/2019 21:00	0.0	0	0	0	0	1
11/11/2019 22:00	0.0	0	0	0	0	1
11/11/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/12/2019 00:00	0.0	0	0	0	0	1
11/12/2019 01:00	0.0	0	0	0	0	1
11/12/2019 02:00	0.0	0	0	0	0	1
11/12/2019 03:00	0.0	0	0	0	0	1
11/12/2019 04:00	0.0	0	0	0	0	1
11/12/2019 05:00	0.0	0	0	0	0	1
11/12/2019 06:00	0.0	0	0	0	0	1
11/12/2019 07:00	0.0	0	0	0	0	1
11/12/2019 08:00	0.0	0	0	0	0	1
11/12/2019 09:00	0.0	0	0	0	0	1
11/12/2019 10:00	0.0	0	0	0	0	1
11/12/2019 11:00	0.0	0	0	0	0	1
11/12/2019 12:00	0.0	0	0	0	0	1
11/12/2019 13:00	0.0	0	0	0	0	1
11/12/2019 14:00	0.0	0	0	0	0	1
11/12/2019 15:00	0.0	0	0	0	0	1
11/12/2019 16:00	0.0	0	0	0	0	1
11/12/2019 17:00	0.0	0	0	0	0	1
11/12/2019 18:00	0.0	0	0	0	0	1
11/12/2019 19:00	0.0	0	0	0	0	1
11/12/2019 20:00	0.0	0	0	0	0	1
11/12/2019 21:00	0.0	0	0	0	0	1
11/12/2019 22:00	0.0	0	0	0	0	1
11/12/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/13/2019 00:00	0.0	0	0	0	0	1
11/13/2019 01:00	0.0	0	0	0	0	1
11/13/2019 02:00	0.0	0	0	0	0	1
11/13/2019 03:00	0.0	0	0	0	0	1
11/13/2019 04:00	0.0	0	0	0	0	1
11/13/2019 05:00	0.0	0	0	0	0	1
11/13/2019 06:00	0.0	0	0	0	0	1
11/13/2019 07:00	0.0	0	0	0	0	1
11/13/2019 08:00	0.0	0	0	0	0	1
11/13/2019 09:00	0.0	0	0	0	0	1
11/13/2019 10:00	0.0	0	0	0	0	1
11/13/2019 11:00	0.0	0	0	0	0	1
11/13/2019 12:00	0.0	0	0	0	0	1
11/13/2019 13:00	0.0	0	0	0	0	1
11/13/2019 14:00	0.0	0	0	0	0	1
11/13/2019 15:00	0.0	0	0	0	0	1
11/13/2019 16:00	0.0	0	0	0	0	1
11/13/2019 17:00	0.0	0	0	0	0	1
11/13/2019 18:00	0.0	0	0	0	0	1
11/13/2019 19:00	0.0	0	0	0	0	1
11/13/2019 20:00	0.0	0	0	0	0	1
11/13/2019 21:00	0.0	0	0	0	0	1
11/13/2019 22:00	0.0	0	0	0	0	1
11/13/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/14/2019 00:00	0.0	0	0	0	0	1
11/14/2019 01:00	0.0	0	0	0	0	1
11/14/2019 02:00	0.0	0	0	0	0	1
11/14/2019 03:00	0.0	0	0	0	0	1
11/14/2019 04:00	0.0	0	0	0	0	1
11/14/2019 05:00	0.0	0	0	0	0	1
11/14/2019 06:00	0.0	0	0	0	0	1
11/14/2019 07:00	0.0	0	0	0	0	1
11/14/2019 08:00	0.0	0	0	0	0	1
11/14/2019 09:00	0.0	0	0	0	0	1
11/14/2019 10:00	0.0	0	0	0	0	1
11/14/2019 11:00	0.0	0	0	0	0	1
11/14/2019 12:00	0.0	0	0	0	0	1
11/14/2019 13:00	0.0	0	0	0	0	1
11/14/2019 14:00	0.0	0	0	0	0	1
11/14/2019 15:00	0.0	0	0	0	0	1
11/14/2019 16:00	0.0	0	0	0	0	1
11/14/2019 17:00	0.0	0	0	0	0	1
11/14/2019 18:00	0.0	0	0	0	0	1
11/14/2019 19:00	0.0	0	0	0	0	1
11/14/2019 20:00	0.0	0	0	0	0	1
11/14/2019 21:00	0.0	0	0	0	0	1
11/14/2019 22:00	0.0	0	0	0	0	1
11/14/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/15/2019 00:00	0.0	0	0	0	0	1
11/15/2019 01:00	0.0	0	0	0	0	1
11/15/2019 02:00	0.0	0	0	0	0	1
11/15/2019 03:00	0.0	0	0	0	0	1
11/15/2019 04:00	0.0	0	0	0	0	1
11/15/2019 05:00	0.0	0	0	0	0	1
11/15/2019 06:00	0.0	0	0	0	0	1
11/15/2019 07:00	0.0	0	0	0	0	1
11/15/2019 08:00	0.0	0	0	0	0	1
11/15/2019 09:00	0.0	0	0	0	0	1
11/15/2019 10:00	0.0	0	0	0	0	1
11/15/2019 11:00	0.0	0	0	0	0	1
11/15/2019 12:00	0.0	0	0	0	0	1
11/15/2019 13:00	0.0	0	0	0	0	1
11/15/2019 14:00	0.0	0	0	0	0	1
11/15/2019 15:00	0.0	0	0	0	0	1
11/15/2019 16:00	0.0	0	0	0	0	1
11/15/2019 17:00	0.0	0	0	0	0	1
11/15/2019 18:00	0.0	0	0	0	0	1
11/15/2019 19:00	0.0	0	0	0	0	1
11/15/2019 20:00	0.0	0	0	0	0	1
11/15/2019 21:00	0.0	0	0	0	0	1
11/15/2019 22:00	0.0	0	0	0	0	1
11/15/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/16/2019 00:00	0.0	0	0	0	0	1
11/16/2019 01:00	0.0	0	0	0	0	1
11/16/2019 02:00	0.0	0	0	0	0	1
11/16/2019 03:00	0.0	0	0	0	0	1
11/16/2019 04:00	0.0	0	0	0	0	1
11/16/2019 05:00	0.0	0	0	0	0	1
11/16/2019 06:00	0.0	0	0	0	0	1
11/16/2019 07:00	0.0	0	0	0	0	1
11/16/2019 08:00	0.0	0	0	0	0	1
11/16/2019 09:00	0.0	0	0	0	0	1
11/16/2019 10:00	0.0	0	0	0	0	1
11/16/2019 11:00	0.0	0	0	0	0	1
11/16/2019 12:00	0.0	0	0	0	0	1
11/16/2019 13:00	0.0	0	0	0	0	1
11/16/2019 14:00	0.0	0	0	0	0	1
11/16/2019 15:00	0.0	0	0	0	0	1
11/16/2019 16:00	0.0	0	0	0	0	1
11/16/2019 17:00	0.0	0	0	0	0	1
11/16/2019 18:00	0.0	0	0	0	0	1
11/16/2019 19:00	0.0	0	0	0	0	1
11/16/2019 20:00	0.0	0	0	0	0	1
11/16/2019 21:00	0.0	0	0	0	0	1
11/16/2019 22:00	0.0	0	0	0	0	1
11/16/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/17/2019 00:00	0.0	0	0	0	0	1
11/17/2019 01:00	0.0	0	0	0	0	1
11/17/2019 02:00	0.0	0	0	0	0	1
11/17/2019 03:00	0.0	0	0	0	0	1
11/17/2019 04:00	0.0	0	0	0	0	1
11/17/2019 05:00	0.0	0	0	0	0	1
11/17/2019 06:00	0.0	0	0	0	0	1
11/17/2019 07:00	0.0	0	0	0	0	1
11/17/2019 08:00	0.0	0	0	0	0	1
11/17/2019 09:00	0.0	0	0	0	0	1
11/17/2019 10:00	0.0	0	0	0	0	1
11/17/2019 11:00	0.0	0	0	0	0	1
11/17/2019 12:00	0.0	0	0	0	0	1
11/17/2019 13:00	0.0	0	0	0	0	1
11/17/2019 14:00	0.0	0	0	0	0	1
11/17/2019 15:00	0.0	0	0	0	0	1
11/17/2019 16:00	0.0	0	0	0	0	1
11/17/2019 17:00	0.0	0	0	0	0	1
11/17/2019 18:00	0.0	0	0	0	0	1
11/17/2019 19:00	0.0	0	0	0	0	1
11/17/2019 20:00	0.0	0	0	0	0	1
11/17/2019 21:00	0.0	0	0	0	0	1
11/17/2019 22:00	0.0	0	0	0	0	1
11/17/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/18/2019 00:00	0.0	0	0	0	0	1
11/18/2019 01:00	0.0	0	0	0	0	1
11/18/2019 02:00	0.0	0	0	0	0	1
11/18/2019 03:00	0.0	0	0	0	0	1
11/18/2019 04:00	0.0	0	0	0	0	1
11/18/2019 05:00	0.0	0	0	0	0	1
11/18/2019 06:00	0.0	0	0	0	0	1
11/18/2019 07:00	0.0	0	0	0	0	1
11/18/2019 08:00	0.0	0	0	0	0	1
11/18/2019 09:00	0.0	0	0	0	0	1
11/18/2019 10:00	0.0	0	0	0	0	1
11/18/2019 11:00	0.0	0	0	0	0	1
11/18/2019 12:00	0.0	0	0	0	0	1
11/18/2019 13:00	0.0	0	0	0	0	1
11/18/2019 14:00	0.0	0	0	0	0	1
11/18/2019 15:00	0.0	0	0	0	0	1
11/18/2019 16:00	0.0	0	0	0	0	1
11/18/2019 17:00	0.0	0	0	0	0	1
11/18/2019 18:00	0.0	0	0	0	0	1
11/18/2019 19:00	0.0	0	0	0	0	1
11/18/2019 20:00	0.0	0	0	0	0	1
11/18/2019 21:00	0.0	0	0	0	0	1
11/18/2019 22:00	0.0	0	0	0	0	1
11/18/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/19/2019 00:00	0.0	0	0	0	0	1
11/19/2019 01:00	0.0	0	0	0	0	1
11/19/2019 02:00	0.0	0	0	0	0	1
11/19/2019 03:00	0.0	0	0	0	0	1
11/19/2019 04:00	0.0	0	0	0	0	1
11/19/2019 05:00	0.0	0	0	0	0	1
11/19/2019 06:00	0.0	0	0	0	0	1
11/19/2019 07:00	0.0	0	0	0	0	1
11/19/2019 08:00	0.0	0	0	0	0	1
11/19/2019 09:00	0.0	0	0	0	0	1
11/19/2019 10:00	0.0	0	0	0	0	1
11/19/2019 11:00	0.0	0	0	0	0	1
11/19/2019 12:00	0.0	0	0	0	0	1
11/19/2019 13:00	0.0	0	0	0	0	1
11/19/2019 14:00	0.0	0	0	0	0	1
11/19/2019 15:00	0.0	0	0	0	0	1
11/19/2019 16:00	0.0	0	0	0	0	1
11/19/2019 17:00	0.0	0	0	0	0	1
11/19/2019 18:00	0.0	0	0	0	0	1
11/19/2019 19:00	0.0	0	0	0	0	1
11/19/2019 20:00	0.0	0	0	0	0	1
11/19/2019 21:00	0.0	0	0	0	0	1
11/19/2019 22:00	0.0	0	0	0	0	1
11/19/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/20/2019 00:00	0.0	0	0	0	0	1
11/20/2019 01:00	0.0	0	0	0	0	1
11/20/2019 02:00	0.0	0	0	0	0	1
11/20/2019 03:00	0.0	0	0	0	0	1
11/20/2019 04:00	0.0	0	0	0	0	1
11/20/2019 05:00	0.0	0	0	0	0	1
11/20/2019 06:00	0.0	0	0	0	0	1
11/20/2019 07:00	0.0	0	0	0	0	1
11/20/2019 08:00	0.0	0	0	0	0	1
11/20/2019 09:00	0.0	0	0	0	0	1
11/20/2019 10:00	0.0	0	0	0	0	1
11/20/2019 11:00	0.0	0	0	0	0	1
11/20/2019 12:00	0.0	0	0	0	0	1
11/20/2019 13:00	0.0	0	0	0	0	1
11/20/2019 14:00	0.0	0	0	0	0	1
11/20/2019 15:00	0.0	0	0	0	0	1
11/20/2019 16:00	0.0	0	0	0	0	1
11/20/2019 17:00	0.0	0	0	0	0	1
11/20/2019 18:00	0.0	0	0	0	0	1
11/20/2019 19:00	0.0	0	0	0	0	1
11/20/2019 20:00	0.0	0	0	0	0	1
11/20/2019 21:00	0.0	0	0	0	0	1
11/20/2019 22:00	0.0	0	0	0	0	1
11/20/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/21/2019 00:00	0.0	0	0	0	0	1
11/21/2019 01:00	0.0	0	0	0	0	1
11/21/2019 02:00	0.0	0	0	0	0	1
11/21/2019 03:00	0.0	0	0	0	0	1
11/21/2019 04:00	0.0	0	0	0	0	1
11/21/2019 05:00	0.0	0	0	0	0	1
11/21/2019 06:00	0.0	0	0	0	0	1
11/21/2019 07:00	0.0	0	0	0	0	1
11/21/2019 08:00	0.0	0	0	0	0	1
11/21/2019 09:00	0.0	0	0	0	0	1
11/21/2019 10:00	0.0	0	0	0	0	1
11/21/2019 11:00	0.0	0	0	0	0	1
11/21/2019 12:00	0.0	0	0	0	0	1
11/21/2019 13:00	0.0	0	0	0	0	1
11/21/2019 14:00	0.0	0	0	0	0	1
11/21/2019 15:00	0.0	0	0	0	0	1
11/21/2019 16:00	0.0	0	0	0	0	1
11/21/2019 17:00	0.0	0	0	0	0	1
11/21/2019 18:00	0.0	0	0	0	0	1
11/21/2019 19:00	0.0	0	0	0	0	1
11/21/2019 20:00	0.0	0	0	0	0	1
11/21/2019 21:00	0.0	0	0	0	0	1
11/21/2019 22:00	0.0	0	0	0	0	1
11/21/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/22/2019 00:00	0.0	0	0	0	0	1
11/22/2019 01:00	0.0	0	0	0	0	1
11/22/2019 02:00	0.0	0	0	0	0	1
11/22/2019 03:00	0.0	0	0	0	0	1
11/22/2019 04:00	0.0	0	0	0	0	1
11/22/2019 05:00	0.0	0	0	0	0	1
11/22/2019 06:00	0.0	0	0	0	0	1
11/22/2019 07:00	0.0	0	0	0	0	1
11/22/2019 08:00	0.0	0	0	0	0	1
11/22/2019 09:00	0.0	0	0	0	0	1
11/22/2019 10:00	0.0	0	0	0	0	1
11/22/2019 11:00	0.0	0	0	0	0	1
11/22/2019 12:00	0.0	0	0	0	0	1
11/22/2019 13:00	0.0	0	0	0	0	1
11/22/2019 14:00	0.0	0	0	0	0	1
11/22/2019 15:00	0.0	0	0	0	0	1
11/22/2019 16:00	0.0	0	0	0	0	1
11/22/2019 17:00	0.0	0	0	0	0	1
11/22/2019 18:00	0.0	0	0	0	0	1
11/22/2019 19:00	0.0	0	0	0	0	1
11/22/2019 20:00	0.0	0	0	0	0	1
11/22/2019 21:00	0.0	0	0	0	0	1
11/22/2019 22:00	0.0	0	0	0	0	1
11/22/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/23/2019 00:00	0.0	0	0	0	0	1
11/23/2019 01:00	0.0	0	0	0	0	1
11/23/2019 02:00	0.0	0	0	0	0	1
11/23/2019 03:00	0.0	0	0	0	0	1
11/23/2019 04:00	0.0	0	0	0	0	1
11/23/2019 05:00	0.0	0	0	0	0	1
11/23/2019 06:00	0.0	0	0	0	0	1
11/23/2019 07:00	0.0	0	0	0	0	1
11/23/2019 08:00	0.0	0	0	0	0	1
11/23/2019 09:00	0.0	0	0	0	0	1
11/23/2019 10:00	0.0	0	0	0	0	1
11/23/2019 11:00	0.0	0	0	0	0	1
11/23/2019 12:00	0.0	0	0	0	0	1
11/23/2019 13:00	0.0	0	0	0	0	1
11/23/2019 14:00	0.0	0	0	0	0	1
11/23/2019 15:00	0.0	0	0	0	0	1
11/23/2019 16:00	0.0	0	0	0	0	1
11/23/2019 17:00	0.0	0	0	0	0	1
11/23/2019 18:00	0.0	0	0	0	0	1
11/23/2019 19:00	0.0	0	0	0	0	1
11/23/2019 20:00	0.0	0	0	0	0	1
11/23/2019 21:00	0.0	0	0	0	0	1
11/23/2019 22:00	0.0	0	0	0	0	1
11/23/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/24/2019 00:00	0.0	0	0	0	0	1
11/24/2019 01:00	0.0	0	0	0	0	1
11/24/2019 02:00	0.0	0	0	0	0	1
11/24/2019 03:00	0.0	0	0	0	0	1
11/24/2019 04:00	0.0	0	0	0	0	1
11/24/2019 05:00	0.0	0	0	0	0	1
11/24/2019 06:00	0.0	0	0	0	0	1
11/24/2019 07:00	0.0	0	0	0	0	1
11/24/2019 08:00	0.0	0	0	0	0	1
11/24/2019 09:00	0.0	0	0	0	0	1
11/24/2019 10:00	0.0	0	0	0	0	1
11/24/2019 11:00	0.0	0	0	0	0	1
11/24/2019 12:00	0.0	0	0	0	0	1
11/24/2019 13:00	0.0	0	0	0	0	1
11/24/2019 14:00	0.0	0	0	0	0	1
11/24/2019 15:00	0.0	0	0	0	0	1
11/24/2019 16:00	0.0	0	0	0	0	1
11/24/2019 17:00	0.0	0	0	0	0	1
11/24/2019 18:00	0.0	0	0	0	0	1
11/24/2019 19:00	0.0	0	0	0	0	1
11/24/2019 20:00	0.0	0	0	0	0	1
11/24/2019 21:00	0.0	0	0	0	0	1
11/24/2019 22:00	0.0	0	0	0	0	1
11/24/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/25/2019 00:00	0.5	0	0	0	1	0
11/25/2019 01:00	0.0	0	0	0	0	0
11/25/2019 02:00	0.0	0	0	0	0	0
11/25/2019 03:00	0.0	0	0	0	0	0
11/25/2019 04:00	6.3	0	0	1	0	0
11/25/2019 05:00	12.1	0	0	1	0	0
11/25/2019 06:00	0.0	0	0	0	0	1
11/25/2019 07:00	0.0	0	0	0	0	1
11/25/2019 08:00	0.0	0	0	0	0	1
11/25/2019 09:00	0.0	0	0	0	0	1
11/25/2019 10:00	0.0	0	0	0	0	1
11/25/2019 11:00	0.0	0	0	0	0	1
11/25/2019 12:00	0.0	0	0	0	0	1
11/25/2019 13:00	0.0	0	0	0	0	1
11/25/2019 14:00	0.0	0	0	0	0	1
11/25/2019 15:00	0.0	0	0	0	0	1
11/25/2019 16:00	0.0	0	0	0	0	1
11/25/2019 17:00	0.0	0	0	0	0	1
11/25/2019 18:00	0.0	0	0	0	0	1
11/25/2019 19:00	0.0	0	0	0	0	1
11/25/2019 20:00	0.0	0	0	0	0	1
11/25/2019 21:00	0.0	0	0	0	0	1
11/25/2019 22:00	0.0	0	0	0	0	1
11/25/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	18.9 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	12.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/26/2019 00:00	0.0	0	0	0	0	1
11/26/2019 01:00	0.0	0	0	0	0	1
11/26/2019 02:00	0.0	0	0	0	0	1
11/26/2019 03:00	0.0	0	0	0	0	1
11/26/2019 04:00	0.0	0	0	0	0	1
11/26/2019 05:00	0.0	0	0	0	0	1
11/26/2019 06:00	0.0	0	0	0	0	1
11/26/2019 07:00	0.0	0	0	0	0	1
11/26/2019 08:00	0.0	0	0	0	0	1
11/26/2019 09:00	0.0	0	0	0	0	1
11/26/2019 10:00	0.0	0	0	0	0	1
11/26/2019 11:00	0.0	0	0	0	0	1
11/26/2019 12:00	0.0	0	0	0	0	1
11/26/2019 13:00	0.0	0	0	0	0	1
11/26/2019 14:00	0.0	0	0	0	0	1
11/26/2019 15:00	0.0	0	0	0	0	1
11/26/2019 16:00	0.0	0	0	0	0	1
11/26/2019 17:00	0.0	0	0	0	0	1
11/26/2019 18:00	0.0	0	0	0	0	1
11/26/2019 19:00	0.0	0	0	0	0	1
11/26/2019 20:00	0.0	0	0	0	0	1
11/26/2019 21:00	0.0	0	0	0	0	1
11/26/2019 22:00	0.0	0	0	0	0	1
11/26/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/27/2019 00:00	0.0	0	0	0	0	1
11/27/2019 01:00	0.0	0	0	0	0	1
11/27/2019 02:00	0.0	0	0	0	0	1
11/27/2019 03:00	0.0	0	0	0	0	1
11/27/2019 04:00	0.0	0	0	0	0	1
11/27/2019 05:00	0.0	0	0	0	0	1
11/27/2019 06:00	0.0	0	0	0	0	1
11/27/2019 07:00	0.0	0	0	0	0	1
11/27/2019 08:00	0.0	0	0	0	0	1
11/27/2019 09:00	0.0	0	0	0	0	1
11/27/2019 10:00	0.0	0	0	0	0	1
11/27/2019 11:00	0.0	0	0	0	0	1
11/27/2019 12:00	0.0	0	0	0	0	1
11/27/2019 13:00	0.0	0	0	0	0	1
11/27/2019 14:00	0.0	0	0	0	0	1
11/27/2019 15:00	0.0	0	0	0	0	1
11/27/2019 16:00	0.0	0	0	0	0	1
11/27/2019 17:00	0.0	0	0	0	0	1
11/27/2019 18:00	0.0	0	0	0	0	1
11/27/2019 19:00	0.0	0	0	0	0	1
11/27/2019 20:00	0.0	0	0	0	0	1
11/27/2019 21:00	0.0	0	0	0	0	1
11/27/2019 22:00	0.0	0	0	0	0	1
11/27/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/28/2019 00:00	0.0	0	0	0	0	1
11/28/2019 01:00	0.0	0	0	0	0	1
11/28/2019 02:00	0.0	0	0	0	0	1
11/28/2019 03:00	0.0	0	0	0	0	1
11/28/2019 04:00	0.0	0	0	0	0	1
11/28/2019 05:00	0.0	0	0	0	0	1
11/28/2019 06:00	0.0	0	0	0	0	1
11/28/2019 07:00	0.0	0	0	0	0	1
11/28/2019 08:00	0.0	0	0	0	0	1
11/28/2019 09:00	0.0	0	0	0	0	1
11/28/2019 10:00	0.0	0	0	0	0	1
11/28/2019 11:00	0.0	0	0	0	0	1
11/28/2019 12:00	0.0	0	0	0	0	1
11/28/2019 13:00	0.0	0	0	0	0	1
11/28/2019 14:00	0.0	0	0	0	0	1
11/28/2019 15:00	0.0	0	0	0	0	1
11/28/2019 16:00	0.0	0	0	0	0	1
11/28/2019 17:00	0.0	0	0	0	0	1
11/28/2019 18:00	0.0	0	0	0	0	1
11/28/2019 19:00	0.0	0	0	0	0	1
11/28/2019 20:00	0.0	0	0	0	0	1
11/28/2019 21:00	0.0	0	0	0	0	1
11/28/2019 22:00	0.0	0	0	0	0	1
11/28/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/29/2019 00:00	0.0	0	0	0	0	1
11/29/2019 01:00	0.0	0	0	0	0	1
11/29/2019 02:00	0.0	0	0	0	0	1
11/29/2019 03:00	0.0	0	0	0	0	1
11/29/2019 04:00	0.0	0	0	0	0	1
11/29/2019 05:00	0.0	0	0	0	0	1
11/29/2019 06:00	0.0	0	0	0	0	1
11/29/2019 07:00	0.0	0	0	0	0	1
11/29/2019 08:00	0.0	0	0	0	0	1
11/29/2019 09:00	0.0	0	0	0	0	1
11/29/2019 10:00	0.0	0	0	0	0	1
11/29/2019 11:00	0.0	0	0	0	0	1
11/29/2019 12:00	0.0	0	0	0	0	1
11/29/2019 13:00	0.0	0	0	0	0	1
11/29/2019 14:00	0.0	0	0	0	0	1
11/29/2019 15:00	0.0	0	0	0	0	1
11/29/2019 16:00	0.0	0	0	0	0	1
11/29/2019 17:00	0.0	0	0	0	0	1
11/29/2019 18:00	0.0	0	0	0	0	1
11/29/2019 19:00	0.0	0	0	0	0	1
11/29/2019 20:00	0.0	0	0	0	0	1
11/29/2019 21:00	0.0	0	0	0	0	1
11/29/2019 22:00	0.0	0	0	0	0	1
11/29/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/30/2019 00:00	0.0	0	0	0	0	1
11/30/2019 01:00	0.0	0	0	0	0	1
11/30/2019 02:00	0.0	0	0	0	0	1
11/30/2019 03:00	0.0	0	0	0	0	1
11/30/2019 04:00	0.0	0	0	0	0	1
11/30/2019 05:00	0.0	0	0	0	0	1
11/30/2019 06:00	0.0	0	0	0	0	1
11/30/2019 07:00	0.0	0	0	0	0	1
11/30/2019 08:00	0.0	0	0	0	0	1
11/30/2019 09:00	0.0	0	0	0	0	1
11/30/2019 10:00	0.0	0	0	0	0	1
11/30/2019 11:00	0.0	0	0	0	0	1
11/30/2019 12:00	0.0	0	0	0	0	1
11/30/2019 13:00	0.0	0	0	0	0	1
11/30/2019 14:00	0.0	0	0	0	0	1
11/30/2019 15:00	0.0	0	0	0	0	1
11/30/2019 16:00	0.0	0	0	0	0	1
11/30/2019 17:00	0.0	0	0	0	0	1
11/30/2019 18:00	0.0	0	0	0	0	1
11/30/2019 19:00	0.0	0	0	0	0	1
11/30/2019 20:00	0.0	0	0	0	0	1
11/30/2019 21:00	0.0	0	0	0	0	1
11/30/2019 22:00	0.0	0	0	0	0	1
11/30/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/01/2019 00:00	0.0	0	0	0	0	1
12/01/2019 01:00	0.0	0	0	0	0	1
12/01/2019 02:00	0.0	0	0	0	0	1
12/01/2019 03:00	0.0	0	0	0	0	1
12/01/2019 04:00	0.0	0	0	0	0	1
12/01/2019 05:00	0.0	0	0	0	0	1
12/01/2019 06:00	0.0	0	0	0	0	1
12/01/2019 07:00	0.0	0	0	0	0	1
12/01/2019 08:00	0.0	0	0	0	0	1
12/01/2019 09:00	0.0	0	0	0	0	1
12/01/2019 10:00	0.0	0	0	0	0	1
12/01/2019 11:00	0.0	0	0	0	0	1
12/01/2019 12:00	0.0	0	0	0	0	1
12/01/2019 13:00	0.0	0	0	0	0	1
12/01/2019 14:00	0.0	0	0	0	0	1
12/01/2019 15:00	0.0	0	0	0	0	1
12/01/2019 16:00	0.0	0	0	0	0	1
12/01/2019 17:00	0.0	0	0	0	0	1
12/01/2019 18:00	0.0	0	0	0	0	1
12/01/2019 19:00	0.0	0	0	0	0	1
12/01/2019 20:00	0.0	0	0	0	0	1
12/01/2019 21:00	0.0	0	0	0	0	1
12/01/2019 22:00	0.0	0	0	0	0	1
12/01/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/02/2019 00:00	0.0	0	0	0	0	1
12/02/2019 01:00	0.0	0	0	0	0	1
12/02/2019 02:00	0.0	0	0	0	0	1
12/02/2019 03:00	0.0	0	0	0	0	1
12/02/2019 04:00	0.0	0	0	0	0	1
12/02/2019 05:00	0.0	0	0	0	0	1
12/02/2019 06:00	0.0	0	0	0	0	1
12/02/2019 07:00	0.0	0	0	0	0	1
12/02/2019 08:00	0.0	0	0	0	0	1
12/02/2019 09:00	0.0	0	0	0	0	1
12/02/2019 10:00	0.0	0	0	0	0	1
12/02/2019 11:00	0.0	0	0	0	0	1
12/02/2019 12:00	0.0	0	0	0	0	1
12/02/2019 13:00	0.0	0	0	0	0	1
12/02/2019 14:00	0.0	0	0	0	0	1
12/02/2019 15:00	0.0	0	0	0	0	1
12/02/2019 16:00	0.0	0	0	0	0	1
12/02/2019 17:00	0.0	0	0	0	0	1
12/02/2019 18:00	0.0	0	0	0	0	1
12/02/2019 19:00	0.0	0	0	0	0	1
12/02/2019 20:00	0.0	0	0	0	0	1
12/02/2019 21:00	0.0	0	0	0	0	1
12/02/2019 22:00	0.0	0	0	0	0	1
12/02/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/03/2019 00:00	0.0	0	0	0	0	1
12/03/2019 01:00	0.0	0	0	0	0	1
12/03/2019 02:00	0.0	0	0	0	0	1
12/03/2019 03:00	0.0	0	0	0	0	1
12/03/2019 04:00	0.0	0	0	0	0	1
12/03/2019 05:00	0.0	0	0	0	0	1
12/03/2019 06:00	0.0	0	0	0	0	1
12/03/2019 07:00	0.0	0	0	0	0	1
12/03/2019 08:00	0.0	0	0	0	0	1
12/03/2019 09:00	0.0	0	0	0	0	1
12/03/2019 10:00	0.0	0	0	0	0	1
12/03/2019 11:00	0.0	0	0	0	0	1
12/03/2019 12:00	0.0	0	0	0	0	1
12/03/2019 13:00	0.0	0	0	0	0	1
12/03/2019 14:00	0.0	0	0	0	0	1
12/03/2019 15:00	0.0	0	0	0	0	1
12/03/2019 16:00	0.0	0	0	0	0	1
12/03/2019 17:00	0.0	0	0	0	0	1
12/03/2019 18:00	0.0	0	0	0	0	1
12/03/2019 19:00	0.0	0	0	0	0	1
12/03/2019 20:00	0.0	0	0	0	0	1
12/03/2019 21:00	0.0	0	0	0	0	1
12/03/2019 22:00	0.0	0	0	0	0	1
12/03/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/04/2019 00:00	0.0	0	0	0	0	1
12/04/2019 01:00	0.0	0	0	0	0	1
12/04/2019 02:00	0.0	0	0	0	0	1
12/04/2019 03:00	0.0	0	0	0	0	1
12/04/2019 04:00	0.0	0	0	0	0	1
12/04/2019 05:00	0.0	0	0	0	0	1
12/04/2019 06:00	0.0	0	0	0	0	1
12/04/2019 07:00	0.0	0	0	0	0	1
12/04/2019 08:00	0.0	0	0	0	0	1
12/04/2019 09:00	0.0	0	0	0	0	1
12/04/2019 10:00	0.0	0	0	0	0	1
12/04/2019 11:00	0.0	0	0	0	0	1
12/04/2019 12:00	0.0	0	0	0	0	1
12/04/2019 13:00	0.0	0	0	0	0	1
12/04/2019 14:00	0.0	0	0	0	0	1
12/04/2019 15:00	0.0	0	0	0	0	1
12/04/2019 16:00	0.0	0	0	0	0	1
12/04/2019 17:00	0.0	0	0	0	0	1
12/04/2019 18:00	0.0	0	0	0	0	1
12/04/2019 19:00	0.0	0	0	0	0	1
12/04/2019 20:00	0.0	0	0	0	0	1
12/04/2019 21:00	0.0	0	0	0	0	1
12/04/2019 22:00	0.0	0	0	0	0	1
12/04/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/05/2019 00:00	0.0	0	0	0	0	1
12/05/2019 01:00	0.0	0	0	0	0	1
12/05/2019 02:00	0.0	0	0	0	0	1
12/05/2019 03:00	0.0	0	0	0	0	1
12/05/2019 04:00	0.0	0	0	0	0	1
12/05/2019 05:00	0.0	0	0	0	0	1
12/05/2019 06:00	0.0	0	0	0	0	1
12/05/2019 07:00	0.0	0	0	0	0	1
12/05/2019 08:00	0.0	0	0	0	0	1
12/05/2019 09:00	0.0	0	0	0	0	1
12/05/2019 10:00	0.0	0	0	0	0	1
12/05/2019 11:00	0.0	0	0	0	0	1
12/05/2019 12:00	0.0	0	0	0	0	1
12/05/2019 13:00	0.0	0	0	0	0	1
12/05/2019 14:00	0.0	0	0	0	0	1
12/05/2019 15:00	0.0	0	0	0	0	1
12/05/2019 16:00	0.0	0	0	0	0	1
12/05/2019 17:00	0.0	0	0	0	0	1
12/05/2019 18:00	0.0	0	0	0	0	1
12/05/2019 19:00	0.0	0	0	0	0	1
12/05/2019 20:00	0.0	0	0	0	0	1
12/05/2019 21:00	0.0	0	0	0	0	1
12/05/2019 22:00	0.0	0	0	0	0	1
12/05/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/06/2019 00:00	0.0	0	0	0	0	1
12/06/2019 01:00	0.0	0	0	0	0	1
12/06/2019 02:00	0.0	0	0	0	0	1
12/06/2019 03:00	0.0	0	0	0	0	1
12/06/2019 04:00	0.0	0	0	0	0	1
12/06/2019 05:00	0.0	0	0	0	0	1
12/06/2019 06:00	0.0	0	0	0	0	1
12/06/2019 07:00	0.0	0	0	0	0	1
12/06/2019 08:00	0.0	0	0	0	0	1
12/06/2019 09:00	0.0	0	0	0	0	1
12/06/2019 10:00	0.0	0	0	0	0	1
12/06/2019 11:00	0.0	0	0	0	0	1
12/06/2019 12:00	0.0	0	0	0	0	1
12/06/2019 13:00	0.0	0	0	0	0	1
12/06/2019 14:00	0.0	0	0	0	0	1
12/06/2019 15:00	0.0	0	0	0	0	1
12/06/2019 16:00	0.0	0	0	0	0	1
12/06/2019 17:00	0.0	0	0	0	0	1
12/06/2019 18:00	0.0	0	0	0	0	1
12/06/2019 19:00	0.0	0	0	0	0	1
12/06/2019 20:00	0.0	0	0	0	0	1
12/06/2019 21:00	0.0	0	0	0	0	1
12/06/2019 22:00	0.0	0	0	0	0	1
12/06/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/07/2019 00:00	0.0	0	0	0	0	1
12/07/2019 01:00	0.0	0	0	0	0	1
12/07/2019 02:00	0.0	0	0	0	0	1
12/07/2019 03:00	0.0	0	0	0	0	1
12/07/2019 04:00	0.0	0	0	0	0	1
12/07/2019 05:00	0.0	0	0	0	0	1
12/07/2019 06:00	0.0	0	0	0	0	1
12/07/2019 07:00	0.0	0	0	0	0	1
12/07/2019 08:00	0.0	0	0	0	0	1
12/07/2019 09:00	0.0	0	0	0	0	1
12/07/2019 10:00	0.0	0	0	0	0	1
12/07/2019 11:00	0.0	0	0	0	0	1
12/07/2019 12:00	0.0	0	0	0	0	1
12/07/2019 13:00	0.0	0	0	0	0	1
12/07/2019 14:00	0.0	0	0	0	0	1
12/07/2019 15:00	0.0	0	0	0	0	1
12/07/2019 16:00	0.0	0	0	0	0	1
12/07/2019 17:00	0.0	0	0	0	0	1
12/07/2019 18:00	0.0	0	0	0	0	1
12/07/2019 19:00	0.0	0	0	0	0	1
12/07/2019 20:00	0.0	0	0	0	0	1
12/07/2019 21:00	0.0	0	0	0	0	1
12/07/2019 22:00	0.0	0	0	0	0	1
12/07/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/08/2019 00:00	0.0	0	0	0	0	1
12/08/2019 01:00	0.0	0	0	0	0	1
12/08/2019 02:00	0.0	0	0	0	0	1
12/08/2019 03:00	0.0	0	0	0	0	1
12/08/2019 04:00	0.0	0	0	0	0	1
12/08/2019 05:00	0.0	0	0	0	0	1
12/08/2019 06:00	0.0	0	0	0	0	1
12/08/2019 07:00	0.0	0	0	0	0	1
12/08/2019 08:00	0.0	0	0	0	0	1
12/08/2019 09:00	0.0	0	0	0	0	1
12/08/2019 10:00	0.0	0	0	0	0	1
12/08/2019 11:00	0.0	0	0	0	0	1
12/08/2019 12:00	0.0	0	0	0	0	1
12/08/2019 13:00	0.0	0	0	0	0	1
12/08/2019 14:00	0.0	0	0	0	0	1
12/08/2019 15:00	0.0	0	0	0	0	1
12/08/2019 16:00	0.0	0	0	0	0	1
12/08/2019 17:00	0.0	0	0	0	0	1
12/08/2019 18:00	0.0	0	0	0	0	1
12/08/2019 19:00	0.0	0	0	0	0	1
12/08/2019 20:00	0.0	0	0	0	0	1
12/08/2019 21:00	0.0	0	0	0	0	1
12/08/2019 22:00	0.0	0	0	0	0	1
12/08/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/09/2019 00:00	0.0	0	0	0	0	1
12/09/2019 01:00	0.0	0	0	0	0	1
12/09/2019 02:00	0.0	0	0	0	0	1
12/09/2019 03:00	0.0	0	0	0	0	1
12/09/2019 04:00	0.0	0	0	0	0	1
12/09/2019 05:00	0.0	0	0	0	0	1
12/09/2019 06:00	0.0	0	0	0	0	1
12/09/2019 07:00	0.0	0	0	0	0	1
12/09/2019 08:00	0.0	0	0	0	0	1
12/09/2019 09:00	0.0	0	0	0	0	1
12/09/2019 10:00	0.0	0	0	0	0	1
12/09/2019 11:00	0.0	0	0	0	0	1
12/09/2019 12:00	0.0	0	0	0	0	1
12/09/2019 13:00	0.0	0	0	0	0	1
12/09/2019 14:00	0.0	0	0	0	0	1
12/09/2019 15:00	0.0	0	0	0	0	1
12/09/2019 16:00	0.0	0	0	0	0	1
12/09/2019 17:00	0.0	0	0	0	0	1
12/09/2019 18:00	0.0	0	0	0	0	1
12/09/2019 19:00	0.0	0	0	0	0	1
12/09/2019 20:00	0.0	0	0	0	0	1
12/09/2019 21:00	0.0	0	0	0	0	1
12/09/2019 22:00	0.0	0	0	0	0	1
12/09/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/10/2019 00:00	0.0	0	0	0	0	1
12/10/2019 01:00	0.0	0	0	0	0	1
12/10/2019 02:00	0.0	0	0	0	0	1
12/10/2019 03:00	0.0	0	0	0	0	1
12/10/2019 04:00	0.0	0	0	0	0	1
12/10/2019 05:00	0.0	0	0	0	0	1
12/10/2019 06:00	0.0	0	0	0	0	1
12/10/2019 07:00	0.0	0	0	0	0	1
12/10/2019 08:00	0.0	0	0	0	0	1
12/10/2019 09:00	0.0	0	0	0	0	1
12/10/2019 10:00	0.0	0	0	0	0	1
12/10/2019 11:00	0.0	0	0	0	0	1
12/10/2019 12:00	0.0	0	0	0	0	1
12/10/2019 13:00	0.0	0	0	0	0	1
12/10/2019 14:00	0.0	0	0	0	0	1
12/10/2019 15:00	0.0	0	0	0	0	1
12/10/2019 16:00	0.0	0	0	0	0	1
12/10/2019 17:00	0.0	0	0	0	0	1
12/10/2019 18:00	0.0	0	0	0	0	1
12/10/2019 19:00	0.0	0	0	0	0	1
12/10/2019 20:00	0.0	0	0	0	0	1
12/10/2019 21:00	0.0	0	0	0	0	1
12/10/2019 22:00	0.0	0	0	0	0	1
12/10/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/11/2019 00:00	0.0	0	0	0	0	1
12/11/2019 01:00	0.0	0	0	0	0	1
12/11/2019 02:00	0.0	0	0	0	0	1
12/11/2019 03:00	0.0	0	0	0	0	1
12/11/2019 04:00	0.0	0	0	0	0	1
12/11/2019 05:00	0.0	0	0	0	0	1
12/11/2019 06:00	0.0	0	0	0	0	1
12/11/2019 07:00	0.0	0	0	0	0	1
12/11/2019 08:00	0.0	0	0	0	0	1
12/11/2019 09:00	0.0	0	0	0	0	1
12/11/2019 10:00	0.0	0	0	0	0	1
12/11/2019 11:00	0.0	0	0	0	0	1
12/11/2019 12:00	0.0	0	0	0	0	1
12/11/2019 13:00	0.0	0	0	0	0	1
12/11/2019 14:00	0.0	0	0	0	0	1
12/11/2019 15:00	0.0	0	0	0	0	1
12/11/2019 16:00	0.0	0	0	0	0	1
12/11/2019 17:00	0.0	0	0	0	0	1
12/11/2019 18:00	0.0	0	0	0	0	1
12/11/2019 19:00	0.0	0	0	0	0	1
12/11/2019 20:00	0.0	0	0	0	0	1
12/11/2019 21:00	0.0	0	0	0	0	1
12/11/2019 22:00	0.0	0	0	0	0	1
12/11/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/12/2019 00:00	0.0	0	0	0	0	1
12/12/2019 01:00	0.0	0	0	0	0	1
12/12/2019 02:00	0.0	0	0	0	0	1
12/12/2019 03:00	0.0	0	0	0	0	1
12/12/2019 04:00	0.0	0	0	0	0	1
12/12/2019 05:00	0.0	0	0	0	0	1
12/12/2019 06:00	0.0	0	0	0	0	1
12/12/2019 07:00	0.0	0	0	0	0	1
12/12/2019 08:00	0.0	0	0	0	0	1
12/12/2019 09:00	0.0	0	0	0	0	1
12/12/2019 10:00	0.0	0	0	0	0	1
12/12/2019 11:00	0.0	0	0	0	0	1
12/12/2019 12:00	0.0	0	0	0	0	1
12/12/2019 13:00	0.0	0	0	0	0	1
12/12/2019 14:00	0.0	0	0	0	0	1
12/12/2019 15:00	0.0	0	0	0	0	1
12/12/2019 16:00	0.0	0	0	0	0	1
12/12/2019 17:00	0.0	0	0	0	0	1
12/12/2019 18:00	0.0	0	0	0	0	1
12/12/2019 19:00	0.0	0	0	0	0	1
12/12/2019 20:00	0.0	0	0	0	0	1
12/12/2019 21:00	0.0	0	0	0	0	1
12/12/2019 22:00	0.0	0	0	0	0	1
12/12/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/13/2019 00:00	0.5	0	0	0	1	0
12/13/2019 01:00	0.0	0	0	0	0	0
12/13/2019 02:00	0.0	0	0	0	0	0
12/13/2019 03:00	0.0	0	0	0	0	0
12/13/2019 04:00	4.6	0	0	1	0	0
12/13/2019 05:00	5.7	0	0	1	0	0
12/13/2019 06:00	0.0	0	0	0	0	1
12/13/2019 07:00	0.0	0	0	0	0	1
12/13/2019 08:00	0.0	0	0	0	0	1
12/13/2019 09:00	0.0	0	0	0	0	1
12/13/2019 10:00	0.0	0	0	0	0	1
12/13/2019 11:00	0.0	0	0	0	0	1
12/13/2019 12:00	0.0	0	0	0	0	1
12/13/2019 13:00	0.0	0	0	0	0	1
12/13/2019 14:00	0.0	0	0	0	0	1
12/13/2019 15:00	0.0	0	0	0	0	1
12/13/2019 16:00	0.0	0	0	0	0	1
12/13/2019 17:00	0.0	0	0	0	0	1
12/13/2019 18:00	0.0	0	0	0	0	1
12/13/2019 19:00	0.0	0	0	0	0	1
12/13/2019 20:00	0.0	0	0	0	0	1
12/13/2019 21:00	0.0	0	0	0	0	1
12/13/2019 22:00	0.0	0	0	0	0	1
12/13/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	10.8 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5.7	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/14/2019 00:00	0.0	0	0	0	0	1
12/14/2019 01:00	0.0	0	0	0	0	1
12/14/2019 02:00	0.0	0	0	0	0	1
12/14/2019 03:00	0.0	0	0	0	0	1
12/14/2019 04:00	0.0	0	0	0	0	1
12/14/2019 05:00	0.0	0	0	0	0	1
12/14/2019 06:00	0.0	0	0	0	0	1
12/14/2019 07:00	0.0	0	0	0	0	1
12/14/2019 08:00	0.0	0	0	0	0	1
12/14/2019 09:00	0.0	0	0	0	0	1
12/14/2019 10:00	0.0	0	0	0	0	1
12/14/2019 11:00	0.0	0	0	0	0	1
12/14/2019 12:00	0.0	0	0	0	0	1
12/14/2019 13:00	0.0	0	0	0	0	1
12/14/2019 14:00	0.0	0	0	0	0	1
12/14/2019 15:00	0.0	0	0	0	0	1
12/14/2019 16:00	0.0	0	0	0	0	1
12/14/2019 17:00	0.0	0	0	0	0	1
12/14/2019 18:00	0.0	0	0	0	0	1
12/14/2019 19:00	0.0	0	0	0	0	1
12/14/2019 20:00	0.0	0	0	0	0	1
12/14/2019 21:00	0.0	0	0	0	0	1
12/14/2019 22:00	0.0	0	0	0	0	1
12/14/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/15/2019 00:00	0.0	0	0	0	0	1
12/15/2019 01:00	0.0	0	0	0	0	1
12/15/2019 02:00	0.0	0	0	0	0	1
12/15/2019 03:00	0.0	0	0	0	0	1
12/15/2019 04:00	0.0	0	0	0	0	1
12/15/2019 05:00	0.0	0	0	0	0	1
12/15/2019 06:00	0.0	0	0	0	0	1
12/15/2019 07:00	0.0	0	0	0	0	1
12/15/2019 08:00	0.0	0	0	0	0	1
12/15/2019 09:00	0.0	0	0	0	0	1
12/15/2019 10:00	0.0	0	0	0	0	1
12/15/2019 11:00	0.0	0	0	0	0	1
12/15/2019 12:00	0.0	0	0	0	0	1
12/15/2019 13:00	0.0	0	0	0	0	1
12/15/2019 14:00	0.0	0	0	0	0	1
12/15/2019 15:00	0.0	0	0	0	0	1
12/15/2019 16:00	0.0	0	0	0	0	1
12/15/2019 17:00	0.0	0	0	0	0	1
12/15/2019 18:00	0.0	0	0	0	0	1
12/15/2019 19:00	0.0	0	0	0	0	1
12/15/2019 20:00	0.0	0	0	0	0	1
12/15/2019 21:00	0.0	0	0	0	0	1
12/15/2019 22:00	0.0	0	0	0	0	1
12/15/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/16/2019 00:00	0.0	0	0	0	0	1
12/16/2019 01:00	0.0	0	0	0	0	1
12/16/2019 02:00	0.0	0	0	0	0	1
12/16/2019 03:00	0.0	0	0	0	0	1
12/16/2019 04:00	0.0	0	0	0	0	1
12/16/2019 05:00	0.0	0	0	0	0	1
12/16/2019 06:00	0.0	0	0	0	0	1
12/16/2019 07:00	0.0	0	0	0	0	1
12/16/2019 08:00	0.0	0	0	0	0	1
12/16/2019 09:00	0.0	0	0	0	0	1
12/16/2019 10:00	0.0	0	0	0	0	1
12/16/2019 11:00	0.0	0	0	0	0	1
12/16/2019 12:00	0.0	0	0	0	0	1
12/16/2019 13:00	0.0	0	0	0	0	1
12/16/2019 14:00	0.0	0	0	0	0	1
12/16/2019 15:00	0.0	0	0	0	0	1
12/16/2019 16:00	0.0	0	0	0	0	1
12/16/2019 17:00	0.0	0	0	0	0	1
12/16/2019 18:00	0.0	0	0	0	0	1
12/16/2019 19:00	0.0	0	0	0	0	1
12/16/2019 20:00	0.0	0	0	0	0	1
12/16/2019 21:00	0.0	0	0	0	0	1
12/16/2019 22:00	0.0	0	0	0	0	1
12/16/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/17/2019 00:00	0.0	0	0	0	0	1
12/17/2019 01:00	0.0	0	0	0	0	1
12/17/2019 02:00	0.0	0	0	0	0	1
12/17/2019 03:00	0.0	0	0	0	0	1
12/17/2019 04:00	0.0	0	0	0	0	1
12/17/2019 05:00	0.0	0	0	0	0	1
12/17/2019 06:00	0.0	0	0	0	0	1
12/17/2019 07:00	0.0	0	0	0	0	1
12/17/2019 08:00	0.0	0	0	0	0	1
12/17/2019 09:00	0.0	0	0	0	0	1
12/17/2019 10:00	0.0	0	0	0	0	1
12/17/2019 11:00	0.0	0	0	0	0	1
12/17/2019 12:00	0.0	0	0	0	0	1
12/17/2019 13:00	0.0	0	0	0	0	1
12/17/2019 14:00	0.0	0	0	0	0	1
12/17/2019 15:00	0.0	0	0	0	0	1
12/17/2019 16:00	0.0	0	0	0	0	1
12/17/2019 17:00	0.0	0	0	0	0	1
12/17/2019 18:00	0.0	0	0	0	0	1
12/17/2019 19:00	0.0	0	0	0	0	1
12/17/2019 20:00	0.0	0	0	0	0	1
12/17/2019 21:00	0.0	0	0	0	0	1
12/17/2019 22:00	0.0	0	0	0	0	1
12/17/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/18/2019 00:00	0.0	0	0	0	0	1
12/18/2019 01:00	0.0	0	0	0	0	1
12/18/2019 02:00	0.0	0	0	0	0	1
12/18/2019 03:00	0.0	0	0	0	0	1
12/18/2019 04:00	0.0	0	0	0	0	1
12/18/2019 05:00	0.0	0	0	0	0	1
12/18/2019 06:00	0.0	0	0	0	0	1
12/18/2019 07:00	0.0	0	0	0	0	1
12/18/2019 08:00	0.0	0	0	0	0	1
12/18/2019 09:00	0.0	0	0	0	0	1
12/18/2019 10:00	0.0	0	0	0	0	1
12/18/2019 11:00	0.0	0	0	0	0	1
12/18/2019 12:00	0.0	0	0	0	0	1
12/18/2019 13:00	0.0	0	0	0	0	1
12/18/2019 14:00	0.0	0	0	0	0	1
12/18/2019 15:00	0.0	0	0	0	0	1
12/18/2019 16:00	0.0	0	0	0	0	1
12/18/2019 17:00	0.0	0	0	0	0	1
12/18/2019 18:00	0.0	0	0	0	0	1
12/18/2019 19:00	0.0	0	0	0	0	1
12/18/2019 20:00	0.0	0	0	0	0	1
12/18/2019 21:00	0.0	0	0	0	0	1
12/18/2019 22:00	0.0	0	0	0	0	1
12/18/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/19/2019 00:00	0.0	0	0	0	0	1
12/19/2019 01:00	0.0	0	0	0	0	1
12/19/2019 02:00	0.0	0	0	0	0	1
12/19/2019 03:00	0.0	0	0	0	0	1
12/19/2019 04:00	0.0	0	0	0	0	1
12/19/2019 05:00	0.0	0	0	0	0	1
12/19/2019 06:00	0.0	0	0	0	0	1
12/19/2019 07:00	0.0	0	0	0	0	1
12/19/2019 08:00	0.0	0	0	0	0	1
12/19/2019 09:00	0.0	0	0	0	0	1
12/19/2019 10:00	0.0	0	0	0	0	1
12/19/2019 11:00	0.0	0	0	0	0	1
12/19/2019 12:00	0.0	0	0	0	0	1
12/19/2019 13:00	0.0	0	0	0	0	1
12/19/2019 14:00	0.0	0	0	0	0	1
12/19/2019 15:00	0.0	0	0	0	0	1
12/19/2019 16:00	0.0	0	0	0	0	1
12/19/2019 17:00	0.0	0	0	0	0	1
12/19/2019 18:00	0.0	0	0	0	0	1
12/19/2019 19:00	0.0	0	0	0	0	1
12/19/2019 20:00	0.0	0	0	0	0	1
12/19/2019 21:00	0.0	0	0	0	0	1
12/19/2019 22:00	0.0	0	0	0	0	1
12/19/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/20/2019 00:00	0.0	0	0	0	0	1
12/20/2019 01:00	0.0	0	0	0	0	1
12/20/2019 02:00	0.0	0	0	0	0	1
12/20/2019 03:00	0.0	0	0	0	0	1
12/20/2019 04:00	0.0	0	0	0	0	1
12/20/2019 05:00	0.0	0	0	0	0	1
12/20/2019 06:00	0.0	0	0	0	0	1
12/20/2019 07:00	0.0	0	0	0	0	1
12/20/2019 08:00	0.0	0	0	0	0	1
12/20/2019 09:00	0.0	0	0	0	0	1
12/20/2019 10:00	0.0	0	0	0	0	1
12/20/2019 11:00	0.0	0	0	0	0	1
12/20/2019 12:00	0.0	0	0	0	0	1
12/20/2019 13:00	0.0	0	0	0	0	1
12/20/2019 14:00	0.0	0	0	0	0	1
12/20/2019 15:00	0.0	0	0	0	0	1
12/20/2019 16:00	0.0	0	0	0	0	1
12/20/2019 17:00	0.0	0	0	0	0	1
12/20/2019 18:00	0.0	0	0	0	0	1
12/20/2019 19:00	0.0	0	0	0	0	1
12/20/2019 20:00	0.0	0	0	0	0	1
12/20/2019 21:00	0.0	0	0	0	0	1
12/20/2019 22:00	0.0	0	0	0	0	1
12/20/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/21/2019 00:00	0.0	0	0	0	0	1
12/21/2019 01:00	0.0	0	0	0	0	1
12/21/2019 02:00	0.0	0	0	0	0	1
12/21/2019 03:00	0.0	0	0	0	0	1
12/21/2019 04:00	0.0	0	0	0	0	1
12/21/2019 05:00	0.0	0	0	0	0	1
12/21/2019 06:00	0.0	0	0	0	0	1
12/21/2019 07:00	0.0	0	0	0	0	1
12/21/2019 08:00	0.0	0	0	0	0	1
12/21/2019 09:00	0.0	0	0	0	0	1
12/21/2019 10:00	0.0	0	0	0	0	1
12/21/2019 11:00	0.0	0	0	0	0	1
12/21/2019 12:00	0.0	0	0	0	0	1
12/21/2019 13:00	0.0	0	0	0	0	1
12/21/2019 14:00	0.0	0	0	0	0	1
12/21/2019 15:00	0.0	0	0	0	0	1
12/21/2019 16:00	0.0	0	0	0	0	1
12/21/2019 17:00	0.0	0	0	0	0	1
12/21/2019 18:00	0.0	0	0	0	0	1
12/21/2019 19:00	0.0	0	0	0	0	1
12/21/2019 20:00	0.0	0	0	0	0	1
12/21/2019 21:00	0.0	0	0	0	0	1
12/21/2019 22:00	0.0	0	0	0	0	1
12/21/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/22/2019 00:00	0.0	0	0	0	0	1
12/22/2019 01:00	0.0	0	0	0	0	1
12/22/2019 02:00	0.0	0	0	0	0	1
12/22/2019 03:00	0.0	0	0	0	0	1
12/22/2019 04:00	0.0	0	0	0	0	1
12/22/2019 05:00	0.0	0	0	0	0	1
12/22/2019 06:00	0.0	0	0	0	0	1
12/22/2019 07:00	0.0	0	0	0	0	1
12/22/2019 08:00	0.0	0	0	0	0	1
12/22/2019 09:00	0.0	0	0	0	0	1
12/22/2019 10:00	0.0	0	0	0	0	1
12/22/2019 11:00	0.0	0	0	0	0	1
12/22/2019 12:00	0.0	0	0	0	0	1
12/22/2019 13:00	0.0	0	0	0	0	1
12/22/2019 14:00	0.0	0	0	0	0	1
12/22/2019 15:00	0.0	0	0	0	0	1
12/22/2019 16:00	0.0	0	0	0	0	1
12/22/2019 17:00	0.0	0	0	0	0	1
12/22/2019 18:00	0.0	0	0	0	0	1
12/22/2019 19:00	0.0	0	0	0	0	1
12/22/2019 20:00	0.0	0	0	0	0	1
12/22/2019 21:00	0.0	0	0	0	0	1
12/22/2019 22:00	0.0	0	0	0	0	1
12/22/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/23/2019 00:00	0.0	0	0	0	0	1
12/23/2019 01:00	0.0	0	0	0	0	1
12/23/2019 02:00	0.0	0	0	0	0	1
12/23/2019 03:00	0.0	0	0	0	0	1
12/23/2019 04:00	0.0	0	0	0	0	1
12/23/2019 05:00	0.0	0	0	0	0	1
12/23/2019 06:00	0.0	0	0	0	0	1
12/23/2019 07:00	0.0	0	0	0	0	1
12/23/2019 08:00	0.0	0	0	0	0	1
12/23/2019 09:00	0.0	0	0	0	0	1
12/23/2019 10:00	0.0	0	0	0	0	1
12/23/2019 11:00	0.0	0	0	0	0	1
12/23/2019 12:00	0.0	0	0	0	0	1
12/23/2019 13:00	0.0	0	0	0	0	1
12/23/2019 14:00	0.0	0	0	0	0	1
12/23/2019 15:00	0.0	0	0	0	0	1
12/23/2019 16:00	0.0	0	0	0	0	1
12/23/2019 17:00	0.0	0	0	0	0	1
12/23/2019 18:00	0.0	0	0	0	0	1
12/23/2019 19:00	0.0	0	0	0	0	1
12/23/2019 20:00	0.0	0	0	0	0	1
12/23/2019 21:00	0.0	0	0	0	0	1
12/23/2019 22:00	0.0	0	0	0	0	1
12/23/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/24/2019 00:00	0.0	0	0	0	0	1
12/24/2019 01:00	0.0	0	0	0	0	1
12/24/2019 02:00	0.0	0	0	0	0	1
12/24/2019 03:00	0.0	0	0	0	0	1
12/24/2019 04:00	0.0	0	0	0	0	1
12/24/2019 05:00	0.0	0	0	0	0	1
12/24/2019 06:00	0.0	0	0	0	0	1
12/24/2019 07:00	0.0	0	0	0	0	1
12/24/2019 08:00	0.0	0	0	0	0	1
12/24/2019 09:00	0.0	0	0	0	0	1
12/24/2019 10:00	0.0	0	0	0	0	1
12/24/2019 11:00	0.0	0	0	0	0	1
12/24/2019 12:00	0.0	0	0	0	0	1
12/24/2019 13:00	0.0	0	0	0	0	1
12/24/2019 14:00	0.0	0	0	0	0	1
12/24/2019 15:00	0.0	0	0	0	0	1
12/24/2019 16:00	0.0	0	0	0	0	1
12/24/2019 17:00	0.0	0	0	0	0	1
12/24/2019 18:00	0.0	0	0	0	0	1
12/24/2019 19:00	0.0	0	0	0	0	1
12/24/2019 20:00	0.0	0	0	0	0	1
12/24/2019 21:00	0.0	0	0	0	0	1
12/24/2019 22:00	0.0	0	0	0	0	1
12/24/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/25/2019 00:00	0.0	0	0	0	0	1
12/25/2019 01:00	0.0	0	0	0	0	1
12/25/2019 02:00	0.0	0	0	0	0	1
12/25/2019 03:00	0.0	0	0	0	0	1
12/25/2019 04:00	0.0	0	0	0	0	1
12/25/2019 05:00	0.0	0	0	0	0	1
12/25/2019 06:00	0.0	0	0	0	0	1
12/25/2019 07:00	0.0	0	0	0	0	1
12/25/2019 08:00	0.0	0	0	0	0	1
12/25/2019 09:00	0.0	0	0	0	0	1
12/25/2019 10:00	0.0	0	0	0	0	1
12/25/2019 11:00	0.0	0	0	0	0	1
12/25/2019 12:00	0.0	0	0	0	0	1
12/25/2019 13:00	0.0	0	0	0	0	1
12/25/2019 14:00	0.0	0	0	0	0	1
12/25/2019 15:00	0.0	0	0	0	0	1
12/25/2019 16:00	0.0	0	0	0	0	1
12/25/2019 17:00	0.0	0	0	0	0	1
12/25/2019 18:00	0.0	0	0	0	0	1
12/25/2019 19:00	0.0	0	0	0	0	1
12/25/2019 20:00	0.0	0	0	0	0	1
12/25/2019 21:00	0.0	0	0	0	0	1
12/25/2019 22:00	0.0	0	0	0	0	1
12/25/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/26/2019 00:00	0.0	0	0	0	0	1
12/26/2019 01:00	0.0	0	0	0	0	1
12/26/2019 02:00	0.0	0	0	0	0	1
12/26/2019 03:00	0.0	0	0	0	0	1
12/26/2019 04:00	0.0	0	0	0	0	1
12/26/2019 05:00	0.0	0	0	0	0	1
12/26/2019 06:00	0.0	0	0	0	0	1
12/26/2019 07:00	0.0	0	0	0	0	1
12/26/2019 08:00	0.0	0	0	0	0	1
12/26/2019 09:00	0.0	0	0	0	0	1
12/26/2019 10:00	0.0	0	0	0	0	1
12/26/2019 11:00	0.0	0	0	0	0	1
12/26/2019 12:00	0.0	0	0	0	0	1
12/26/2019 13:00	0.0	0	0	0	0	1
12/26/2019 14:00	0.0	0	0	0	0	1
12/26/2019 15:00	0.0	0	0	0	0	1
12/26/2019 16:00	0.0	0	0	0	0	1
12/26/2019 17:00	0.0	0	0	0	0	1
12/26/2019 18:00	0.0	0	0	0	0	1
12/26/2019 19:00	0.0	0	0	0	0	1
12/26/2019 20:00	0.0	0	0	0	0	1
12/26/2019 21:00	0.0	0	0	0	0	1
12/26/2019 22:00	0.0	0	0	0	0	1
12/26/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/27/2019 00:00	0.0	0	0	0	0	1
12/27/2019 01:00	0.0	0	0	0	0	1
12/27/2019 02:00	0.0	0	0	0	0	1
12/27/2019 03:00	0.0	0	0	0	0	1
12/27/2019 04:00	0.0	0	0	0	0	1
12/27/2019 05:00	0.0	0	0	0	0	1
12/27/2019 06:00	0.0	0	0	0	0	1
12/27/2019 07:00	0.0	0	0	0	0	1
12/27/2019 08:00	0.0	0	0	0	0	1
12/27/2019 09:00	0.0	0	0	0	0	1
12/27/2019 10:00	0.0	0	0	0	0	1
12/27/2019 11:00	0.0	0	0	0	0	1
12/27/2019 12:00	0.0	0	0	0	0	1
12/27/2019 13:00	0.0	0	0	0	0	1
12/27/2019 14:00	0.0	0	0	0	0	1
12/27/2019 15:00	0.0	0	0	0	0	1
12/27/2019 16:00	0.0	0	0	0	0	1
12/27/2019 17:00	0.0	0	0	0	0	1
12/27/2019 18:00	0.0	0	0	0	0	1
12/27/2019 19:00	0.0	0	0	0	0	1
12/27/2019 20:00	0.0	0	0	0	0	1
12/27/2019 21:00	0.0	0	0	0	0	1
12/27/2019 22:00	0.0	0	0	0	0	1
12/27/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/28/2019 00:00	0.0	0	0	0	0	1
12/28/2019 01:00	0.0	0	0	0	0	1
12/28/2019 02:00	0.0	0	0	0	0	1
12/28/2019 03:00	0.0	0	0	0	0	1
12/28/2019 04:00	0.0	0	0	0	0	1
12/28/2019 05:00	0.0	0	0	0	0	1
12/28/2019 06:00	0.0	0	0	0	0	1
12/28/2019 07:00	0.0	0	0	0	0	1
12/28/2019 08:00	0.0	0	0	0	0	1
12/28/2019 09:00	0.0	0	0	0	0	1
12/28/2019 10:00	0.0	0	0	0	0	1
12/28/2019 11:00	0.0	0	0	0	0	1
12/28/2019 12:00	0.0	0	0	0	0	1
12/28/2019 13:00	0.0	0	0	0	0	1
12/28/2019 14:00	0.0	0	0	0	0	1
12/28/2019 15:00	0.0	0	0	0	0	1
12/28/2019 16:00	0.0	0	0	0	0	1
12/28/2019 17:00	0.0	0	0	0	0	1
12/28/2019 18:00	0.0	0	0	0	0	1
12/28/2019 19:00	0.0	0	0	0	0	1
12/28/2019 20:00	0.0	0	0	0	0	1
12/28/2019 21:00	0.0	0	0	0	0	1
12/28/2019 22:00	0.0	0	0	0	0	1
12/28/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/29/2019 00:00	0.0	0	0	0	0	1
12/29/2019 01:00	0.0	0	0	0	0	1
12/29/2019 02:00	0.0	0	0	0	0	1
12/29/2019 03:00	0.0	0	0	0	0	1
12/29/2019 04:00	0.0	0	0	0	0	1
12/29/2019 05:00	0.0	0	0	0	0	1
12/29/2019 06:00	0.0	0	0	0	0	1
12/29/2019 07:00	0.0	0	0	0	0	1
12/29/2019 08:00	0.0	0	0	0	0	1
12/29/2019 09:00	0.0	0	0	0	0	1
12/29/2019 10:00	0.0	0	0	0	0	1
12/29/2019 11:00	0.0	0	0	0	0	1
12/29/2019 12:00	0.0	0	0	0	0	1
12/29/2019 13:00	0.0	0	0	0	0	1
12/29/2019 14:00	0.0	0	0	0	0	1
12/29/2019 15:00	0.0	0	0	0	0	1
12/29/2019 16:00	0.0	0	0	0	0	1
12/29/2019 17:00	0.0	0	0	0	0	1
12/29/2019 18:00	0.0	0	0	0	0	1
12/29/2019 19:00	0.0	0	0	0	0	1
12/29/2019 20:00	0.0	0	0	0	0	1
12/29/2019 21:00	0.0	0	0	0	0	1
12/29/2019 22:00	0.0	0	0	0	0	1
12/29/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/30/2019 00:00	0.0	0	0	0	0	1
12/30/2019 01:00	0.0	0	0	0	0	1
12/30/2019 02:00	0.0	0	0	0	0	1
12/30/2019 03:00	0.0	0	0	0	0	1
12/30/2019 04:00	0.0	0	0	0	0	1
12/30/2019 05:00	0.0	0	0	0	0	1
12/30/2019 06:00	0.0	0	0	0	0	1
12/30/2019 07:00	0.0	0	0	0	0	1
12/30/2019 08:00	0.0	0	0	0	0	1
12/30/2019 09:00	0.0	0	0	0	0	1
12/30/2019 10:00	0.0	0	0	0	0	1
12/30/2019 11:00	0.0	0	0	0	0	1
12/30/2019 12:00	0.0	0	0	0	0	1
12/30/2019 13:00	0.0	0	0	0	0	1
12/30/2019 14:00	0.0	0	0	0	0	1
12/30/2019 15:00	0.0	0	0	0	0	1
12/30/2019 16:00	0.0	0	0	0	0	1
12/30/2019 17:00	0.0	0	0	0	0	1
12/30/2019 18:00	0.0	0	0	0	0	1
12/30/2019 19:00	0.0	0	0	0	0	1
12/30/2019 20:00	0.0	0	0	0	0	1
12/30/2019 21:00	0.0	0	0	0	0	1
12/30/2019 22:00	0.0	0	0	0	0	1
12/30/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/31/2019 00:00	0.0	0	0	0	0	1
12/31/2019 01:00	0.0	0	0	0	0	1
12/31/2019 02:00	0.0	0	0	0	0	1
12/31/2019 03:00	0.0	0	0	0	0	1
12/31/2019 04:00	0.0	0	0	0	0	1
12/31/2019 05:00	0.0	0	0	0	0	1
12/31/2019 06:00	0.0	0	0	0	0	1
12/31/2019 07:00	0.0	0	0	0	0	1
12/31/2019 08:00	0.0	0	0	0	0	1
12/31/2019 09:00	0.0	0	0	0	0	1
12/31/2019 10:00	0.0	0	0	0	0	1
12/31/2019 11:00	0.0	0	0	0	0	1
12/31/2019 12:00	0.0	0	0	0	0	1
12/31/2019 13:00	0.0	0	0	0	0	1
12/31/2019 14:00	0.0	0	0	0	0	1
12/31/2019 15:00	0.0	0	0	0	0	1
12/31/2019 16:00	0.0	0	0	0	0	1
12/31/2019 17:00	0.0	0	0	0	0	1
12/31/2019 18:00	0.0	0	0	0	0	1
12/31/2019 19:00	0.0	0	0	0	0	1
12/31/2019 20:00	0.0	0	0	0	0	1
12/31/2019 21:00	0.0	0	0	0	0	1
12/31/2019 22:00	0.0	0	0	0	0	1
12/31/2019 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Pound Per Event Report

CT2 - CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,046.47 Hours

Non-Operating Time: 161.53 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/03/2019 21:40 10/03/2019 21:44 Shut Down - Gas	5	0.2	483.5		
10/04/2019 02:44 10/04/2019 03:42 Hot Start - Gas	59	39.3	679.6		
10/12/2019 07:25 10/12/2019 07:29 Shut Down - Gas	5	0.2	483.5		
10/12/2019 10:47 10/12/2019 12:01 Hot Start - Gas	75	24.1	679.6		
10/13/2019 23:19 10/13/2019 23:25 Shut Down - Gas	7	0.9	483.5		
10/14/2019 02:01 10/14/2019 03:02 Hot Start - Gas	62	22.2	679.6		
10/19/2019 07:25 10/19/2019 07:30 Shut Down - Gas	6	0.8	483.5		
10/19/2019 14:34 10/19/2019 15:54 Hot Start - Gas	81	34.9	679.6		
10/20/2019 02:06 10/20/2019 02:11 Shut Down - Gas	6	0.8	483.5		
10/20/2019 10:15 10/20/2019 11:44 Warm Start - Gas	90	38.6	790.5		
10/26/2019 22:23 10/26/2019 22:28 Shut Down - Gas	6	0.8	483.5		
10/27/2019 17:35 10/27/2019 19:49 Warm Start - Gas	135	117.7	790.5		
10/28/2019 23:08 10/28/2019 23:13 Shut Down - Gas	6	0.9	483.5		

Pound Per Event Report

CT2 - CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,046.47 Hours

Non-Operating Time: 161.53 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/30/2019 00:19 10/30/2019 02:43 Warm Start - Gas	145	157.7	790.5		
11/02/2019 13:11 11/02/2019 13:17 Shut Down - Gas	7	1.0	483.5		
11/02/2019 14:13 11/02/2019 15:04 Hot Start - Gas	52	24.5	679.6		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT2 - CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,046.47 Hours

Non-Operating Time: 161.53 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT2 - CO Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:03 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,046.47 Hours

Non-Operating Time: 161.53 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Pound Per Event Report

CT2 - NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:05 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,136.95 Hours

Non-Operating Time: 71.05 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/03/2019 21:40 10/03/2019 21:44 Shut Down - Gas	5	0.12	115.00		
10/04/2019 02:44 10/04/2019 03:42 Hot Start - Gas	59	51.65	259.90		
10/12/2019 07:25 10/12/2019 07:29 Shut Down - Gas	5	0.34	115.00		
10/12/2019 10:47 10/12/2019 12:01 Hot Start - Gas	75	44.99	259.90		
10/13/2019 23:19 10/13/2019 23:25 Shut Down - Gas	7	0.64	115.00		
10/14/2019 02:01 10/14/2019 03:02 Hot Start - Gas	62	31.29	259.90		
10/19/2019 07:25 10/19/2019 07:30 Shut Down - Gas	6	0.43	115.00		
10/19/2019 14:34 10/19/2019 15:54 Hot Start - Gas	81	52.93	259.90		
10/20/2019 02:06 10/20/2019 02:11 Shut Down - Gas	6	0.23	115.00		
10/20/2019 10:15 10/20/2019 11:44 Warm Start - Gas	90	96.08	456.20		
10/26/2019 22:23 10/26/2019 22:28 Shut Down - Gas	6	0.44	115.00		
10/27/2019 17:35 10/27/2019 19:49 Warm Start - Gas	135	189.36	456.20		
10/28/2019 23:08 10/28/2019 23:13 Shut Down - Gas	6	0.79	115.00		

Pound Per Event Report

CT2 - NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:05 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,136.95 Hours

Non-Operating Time: 71.05 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/30/2019 00:19 10/30/2019 02:43 Warm Start - Gas	145	199.73	456.20		
11/02/2019 13:11 11/02/2019 13:17 Shut Down - Gas	7	0.66	115.00		
11/02/2019 14:13 11/02/2019 15:04 Hot Start - Gas	52	33.98	259.90		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT2 - NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:05 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,136.95 Hours

Non-Operating Time: 71.05 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT2 - NOx Lbs

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/28/2020 13:05 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,136.95 Hours

Non-Operating Time: 71.05 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 13:06 **Location:** Maxwell, CA

Unit Offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
10/01/2019 01:00	10/01/2019 03:00	3
10/03/2019 22:00	10/04/2019 12:00	15
10/12/2019 08:00	10/12/2019 13:00	6
10/14/2019 00:00	10/14/2019 05:00	6
10/15/2019 15:00	10/16/2019 19:00	29
10/19/2019 08:00	10/20/2019 13:00	30
10/26/2019 23:00	10/27/2019 23:00	25
10/29/2019 00:00	10/30/2019 03:00	28
11/02/2019 14:00	11/02/2019 14:00	1
11/25/2019 01:00	11/25/2019 03:00	3
12/13/2019 01:00	12/13/2019 03:00	3

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 13:06 **Location:** Maxwell, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	149.00 Hour(s)
Offline Percentage:	6.75 %
Total Online:	2,059.00 Hour(s)
Online Percentage:	93.25 %

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 13:06 **Location:** Maxwell, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/01/2019 04:00	10/01/2019 05:00	Hot Startup	2
2	10/04/2019 13:00	10/04/2019 14:00	Warm Startup	2
3	10/12/2019 14:00	10/12/2019 15:00	Hot Startup	2
4	10/14/2019 06:00	10/14/2019 07:00	Hot Startup	2
5	10/15/2019 06:00	10/15/2019 07:00	Hot Startup	2
6	10/16/2019 20:00	10/16/2019 21:00	Warm Startup	2
7	10/20/2019 14:00	10/20/2019 15:00	Warm Startup	2
8	10/28/2019 00:00	10/28/2019 01:00	Warm Startup	2
9	10/30/2019 04:00	10/30/2019 06:00	Warm Startup	3
10	11/02/2019 15:00	11/02/2019 16:00	Hot Startup	2
11	11/25/2019 04:00	11/25/2019 05:00	Hot Startup	2
12	12/13/2019 04:00	12/13/2019 05:00	Hot Startup	2

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 13:06 **Location:** Maxwell, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	0		0.00
Hot Startup/Startup Shutdown Event Text 02 Add	7	14	0.68
Warm Startup	5	11	0.53
Total Process Events:	12	25	1.21

Total Report Time:	2,208 Hour(s)
Total Operating Time:	2,059 Hour(s)
Total Startup Time:	25 Hour(s)
Total Shutdown Time:	0 Hour(s)
Total Startup/Shutdown Time:	25 Hour(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	1.21 %

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 13:07 **Location:** Maxwell, CA

Unit Offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
10/03/2019 22:00	10/04/2019 01:00	4
10/12/2019 08:00	10/12/2019 09:00	2
10/14/2019 00:00	10/14/2019 01:00	2
10/19/2019 08:00	10/19/2019 13:00	6
10/20/2019 03:00	10/20/2019 09:00	7
10/26/2019 23:00	10/27/2019 16:00	18
10/29/2019 00:00	10/29/2019 23:00	24

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 13:07 **Location:** Maxwell, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	63.00 Hour(s)
Offline Percentage:	2.85 %
Total Online:	2,145.00 Hour(s)
Online Percentage:	97.15 %

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 13:07 **Location:** Maxwell, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/04/2019 02:00	10/04/2019 03:00	Hot Startup	2
2	10/12/2019 10:00	10/12/2019 12:00	Hot Startup	3
3	10/14/2019 02:00	10/14/2019 03:00	Hot Startup	2
4	10/19/2019 14:00	10/19/2019 15:00	Hot Startup	2
5	10/20/2019 10:00	10/20/2019 11:00	Warm startup	2
6	10/27/2019 17:00	10/27/2019 19:00	Warm startup	3
7	10/30/2019 00:00	10/30/2019 02:00	Warm startup	3
8	11/02/2019 14:00	11/02/2019 15:00	Hot Startup	2

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/28/2020 13:07 **Location:** Maxwell, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	0		0.00
Hot Startup	5	11	0.51
Warm startup	3	8	0.37
Total Process Events:	8	19	0.89

Total Report Time:	2,208 Hour(s)
Total Operating Time:	2,145 Hour(s)
Total Startup Time:	19 Hour(s)
Total Shutdown Time:	0 Hour(s)
Total Startup/Shutdown Time:	19 Hour(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.89 %

ATTACHMENT 13
Water Bath Heater Operations
FCD: AQ-17
Title V: #6

The Natural Gas Fired Water Bath Heater did not operate in the 4th Quarter of 2019.

ATTACHMENT 14
Toxics

FCD: AQ-29
Title V: #6

TOXICS TRACKING AND COMPLIANCE PLAN

PG&E Colusa Generating Station

Reporting/Tracking Year: 2019

Combustion Turbines/HRSGs

	CAS #	Emissions Factors lb/mmbtu	Emissions Factors lb/mmscf	EF Source	Source Test Results lb/hr	Max Hourly Emissions lbs	Annual Emissions lbs	Annual Emissions tons
Ammonia Unit #1	7664417	0.00E+00	0.00E+00	Test*	5	5	26860.00	13.430
Formaldehyde Unit #1	50000	7.00E-05	9.19E-02	Test*	0.02	0.02	107.44	0.054
Ammonia Unit #2	7664417	0.00E+00	0.00E+00	Test*	2	2	12046.00	6.023
Formaldehyde Unit #2	50000	7.00E-05	9.19E-02	Test*	0.009	0.009	54.21	0.027
1-3 Butadiene	106990	1.24E-07	1.27E-04	CATEF	0	0.001	2.67	0.001
Acetaldehyde	75070	1.34E-04	1.37E-01	CATEF	0	0.580	2881.32	1.441
Acrolein	107028	1.85E-05	1.89E-02	CATEF	0	0.080	397.50	0.199
Benzene	71432	1.30E-05	1.33E-02	CATEF	0	0.056	279.72	0.140
Ethylbenzene	100414	1.75E-05	1.79E-02	CATEF	0	0.076	376.46	0.188
Hexane	110543	2.53E-04	2.59E-01	CATEF	0	1.097	5447.16	2.724
Propylene	115071	7.53E-04	7.71E-01	CATEF	0	3.264	16215.29	8.108
Propylene Oxide	75569	4.67E-05	4.78E-02	CATEF	0	0.202	1005.31	0.503
Toluene	108883	6.93E-05	7.10E-02	CATEF	0	0.301	1493.24	0.747
Xylenes	1330207	2.55E-05	2.61E-02	CATEF	0	0.111	548.92	0.274
Naphthalene	91203	1.62E-06	1.66E-03	CATEF	0	0.007	34.91	0.017
Total PAH w/o Naph	1151	1.30E-07	1.31E-04	CATEF	0	0.001	2.76	0.001

Total Turbines/HRSGs

Fuel Use Rate Data			
NG HHV	1022	btu/scf	
Fuel Meter Data			
Max Hourly Fuel Use	4.2338	mmscf	(for both units)
Annual Fuel Use	21031.50	mmscf	(for both units)
Calculated Heat Rate Data			
Max Hourly Heat Rate	4326.94	mmbtu	(for both units)
Annual Heat Rate	21494193.0	mmbtu	(for both units)
DAHS/Op Log Data			
Unit #1 Annual Ops Hrs	5372	Hrs/Yr	
Unit #2 Annual Ops Hrs	6023	Hrs/Yr	
Total Hrs, All Units	11395	Hrs/Yr	(for both units)
CT1 Annual Fuel Use	10027.3	mmscf	
CT2 Annual Fuel Use	11004.2	mmscf	

Fuel Gas Heater (10 mmbtu/hr)

	CAS #	Emissions Factors lb/mmbtu	Emissions Factors lb/mmscf	EF Source	Source Test Results lb/hr	Max Hourly Emissions lbs	Annual Emissions lbs	Annual Emissions tons
Acetaldehyde	75070	8.66E-06	8.87E-03	CATEF	0	0.0000	0.000	0.0000
Benzene	71432	4.21E-06	4.31E-03	CATEF	0	0.0000	0.000	0.0000
Formaldehyde	50000	2.16E-04	2.21E-01	CATEF	0	0.0000	0.000	0.0000

Total FG Heater

Fuel Use Rate Data		
NG HHV	1022	btu/scf
Fuel Use Data		
Max Hourly Fuel Use	0.00000	mmscf
Annual Fuel Use	0.00	mmscf
Calculated Heat Rate Data		
Max Hourly Heat Rate	0.00	mmbtu
Annual Heat Rate	0.00	mmbtu

*Testing conducted Oct-19
Reporting Quarter 4

TOXICS AND GHG TRACKING AND COMPLIANCE PLAN

PG&E Colusa Generating Station

Toxics Plan:
1. perform annual testing for ammonia per CCAPCD Permit Condition #9 (3-2-09)
2. perform annual testing for formaldehyde per CCAPCD Permit Condition #9 (3-2-09)
3. comply with all other provisions of CCAPCD Permit Condition #9 (3-2-09)
4. quantify other identified toxic pollutants via the emissions factors delineated in the AFC Appendix L (Public Health)
5. report toxic emissions to the CCAPCD annually and show compliance with CCAPCD Permit Condition #28 (3-2-09)

Data and Source References:
1. CGS plant and operational data (CEMS, DAHS, purchase records, and ops logs)
2. CCAR General Protocol, Version 3.1, January 2009.
3. CCAR Power Sector Protocol, Version 1.1, May 2009.
4. Other references as noted on the calculation tab.

Attachment 10: Maximum Emissions

Attachment 11: CGA / Linearity

Attachment 12: Startup / Shutdown Emissions

Attachment 13: Water Bath Heater Operations

Attachment 14: Toxics

If you have any questions, please contact me at (530) 393-2926.

Sincerely,

TJ Gomez
Senior Environmental Field Specialist

cc:

Tim Wisdom, PG&E
Sam Garcia, PG&E