

| DOCKETED | |
|-------------------------|---|
| Docket Number: | 18-BSTD-02 |
| Project Title: | 2019 ENERGY CODE COMPLIANCE MANUALS |
| TN #: | 232778-1 |
| Document Title: | 2019-CF2R-PLB-01a-NonHERS-MultifamilyCentralHotWaterSystemDistributionpdf |
| Description: | N/A |
| Filer: | Corrine Fishman |
| Organization: | California Energy Commission |
| Submitter Role: | Public Agency |
| Submission Date: | 4/20/2020 8:45:49 AM |
| Docketed Date: | 4/20/2020 |

MULTIFAMILY CENTRAL HOT WATER SYSTEM DISTRIBUTION

CEC-CF2R-PLB-01-E (Revised 01/19)

CALIFORNIA ENERGY COMMISSION



| | | |
|---|---------------------|----------------|
| CERTIFICATE OF INSTALLATION | | CF2R-PLB-01-E |
| Multifamily Central Hot Water System Distribution | | (Page 1 of 4) |
| Project Name: | Enforcement Agency: | Permit Number: |
| Dwelling Address: | City | Zip Code |

A. General Information

| | |
|----|---------------|
| 01 | Building Name |
|----|---------------|

B. Design Central Water Heating Systems Information

This table reports the water heating system features that were specified on the registered CF1R compliance document for this project.

| 01 | 02 | 03 | 04 | 05 | 06 | 07 | 08 | 09 | 10 | 11 | 12 |
|---------------------------------|---------------------------|-------------------|------------------------------|-----------------------------------|-----------|------------------|-------------------|-------------------------|--------------------------|------------------|-------------------------|
| Water Heating System ID or Name | Water Heating System Type | Water Heater Type | # of Water Heaters in System | Water Heater Storage Volume (gal) | Fuel Type | Rated Input Type | Rated Input Value | Heating Efficiency Type | Heating Efficiency Value | Standby Loss (%) | Exterior Insul. R-Value |
| | | | | | | | | | | | |

C. Installed Central Water Heating Systems Information

This table reports the water heating system features that were specified on the registered CF1R compliance document for this project.

| 01 | 02 | 03 | 04 | 05 | 06 | 07 | 08 | 09 | 10 | 11 | 12 |
|---------------------------------|---------------------------|-------------------|------------------------------|-----------------------------------|-----------|------------------|-------------------|-------------------------|--------------------------|------------------|-------------------------|
| Water Heating System ID or Name | Water Heating System Type | Water Heater Type | # of Water Heaters in System | Water Heater Storage Volume (gal) | Fuel Type | Rated Input Type | Rated Input Value | Heating Efficiency Type | Heating Efficiency Value | Standby Loss (%) | Exterior Insul. R-Value |
| | | | | | | | | | | | |

D. Design Central Water Heating Distribution Systems Information

This table reports the water heating distribution types specified on the registered CF1R compliance document for this project.

| 01 | 02 | 03 |
|---------------------------------|--------------------------------------|--|
| Water Heating System ID or Name | Central DHW System Distribution Type | Dwelling Unit DHW System Distribution Type |
| | | |

E. Installed Central Water Heating Distribution Systems Information

This table reports the water heating distribution types specified on the registered CF1R compliance document for this project.

| 01 | 02 | 03 |
|---------------------------------|--------------------------------------|--|
| Water Heating System ID or Name | Central DHW System Distribution Type | Dwelling Unit DHW System Distribution Type |
| | | |

F. Installed Water Heater Manufacturer Information

| 01 | 02 | 03 |
|---------------------------------|--------------|--------------|
| Water Heating System ID or Name | Manufacturer | Model Number |
| | | |

G. Mandatory Requirements for All Central Domestic Hot Water Systems

| | |
|----|---|
| 01 | On systems that have a total capacity greater than 167,000 Btu/hr, outlets that require higher than service water temperatures as listed in the ASHRAE Handbook have separate remote heaters, heat exchangers, or boosters to supply the outlet with the higher temperature. (Section 110.3 (c)1) |
| 02 | Systems with circulating pumps or with electrical heat trace systems shall be capable of automatically turning off the system. (Section 110.3(c)2). |

Registration Number:

Registration Date/Time:

HERS Provider:

CA Building Energy Efficiency Standards - 2019 Residential Compliance

January 2019



| | | |
|---|---------------------|----------------|
| CERTIFICATE OF INSTALLATION | | CF2R-PLB-01-E |
| Multifamily Central Hot Water System Distribution | | (Page 2 of 4) |
| Project Name: | Enforcement Agency: | Permit Number: |
| Dwelling Address: | City | Zip Code |

| | |
|---|--|
| 03 | Unfired storage tanks are insulated with an external R-12 or combination of R-16 internal and external insulation. (Section 110.3(c)4). |
| 04 | <p>Recirculation loops shall meet the following requirements:</p> <ul style="list-style-type: none"> The recirculation pump is mounted on a vertical section of the return line, OR an automatic air release valve is installed on a riser at least 12 inches in length, on the inlet side of the recirculation pump, no more than 4 feet from the pump. (Section 110.3(c)4A). A check valve is located between the recirculation pump and the water heater. (Section 110.3(c)4B). A hose bib is installed between the pump and the water heating equipment with an isolation valve between the hose bib and the water heating equipment. (Section 110.3(c)4C). Isolation valves shall be installed on both sides of the pump, of which the valve required in 110.3(c)4C can be one. (Section 110.3(c)4D). The cold water piping and the recirculation loop piping shall not be connected to the hot water storage tank drain port. (Section 110.3(c)4E). A check valve shall be installed on the cold water supply line between the hot water system and the next closest tee on the cold water supply line. (Section 110.3(c)4F). |
| 05 | Instantaneous water heaters with an input greater than 6.8 kBtu/hr. (2kW) shall have isolation valves on both the cold water supply and the hot water line. (Section 110.3 (c)6). |
| 06 | <p>All domestic hot water piping shall be insulated as specified in Section 609.11 of the California Plumbing Code. In addition, the following piping conditions shall have a minimum insulation wall thickness of 1 inch or a minimum insulation R-value of 7.7 (RA4.4.1)</p> <ul style="list-style-type: none"> The first 5 feet (1.5 meters) of cold water pipes from the storage tank. All piping with a nominal diameter of 3/4 inch (19 millimeter) and less than 1 inch. All hot water piping from the heating source to the kitchen fixtures. Piping from the heating source to storage tank or between tanks. All piping associated with a recirculation system All underground piping. <ul style="list-style-type: none"> Insulation buried below grade must be installed in a waterproof and non-crushable casing or sleeve. Piping that penetrates framing members shall not be required to have pipe insulation for the distance of the framing penetration. Piping that penetrates metal framing shall use grommets, plugs, wrapping or other insulating material to assure that no contact is made with the metal framing. Insulation shall butt securely against all framing members. Piping installed in interior or exterior walls that is surrounded on all sides by at least 1 inch (5 cm) of insulation. Piping installed in crawlspace with a minimum of 1 inches (5 cm) of crawlspace insulation above and below. Piping installed in attics with a minimum of 4 inches (10 cm) of attic insulation on top. Pipe insulation shall fit tightly and all elbows and tees shall be fully insulated. |
| The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met. | |

H. Multiple Dwelling Units – Recirculation Temperature Modulation Control Requirements (RA4.4.11)

Systems that utilize this distribution type shall comply with these requirements.

| | |
|----|--|
| 01 | Controls have been installed that reduce the hot water supply temperature when hot water demand is determined to be low by the control system. The control system may use a fixed control schedule or dynamic control schedules based on measurements of hot water demand. |
| 02 | Daily hot water supply temperature reduction (which is defined as the sum of temperature reduction by the control in each hour within a 24-hour period) shall be more than 50°F. |

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

I. Multiple Dwelling Units – Recirculation Continuous Monitoring Systems Requirements (RA4.4.12)

Systems that utilize this distribution type shall comply with these requirements.

| | |
|----|--|
| 01 | The water heating system must have a means of communicating with the remote monitoring facility. |
| 02 | The monitoring system must record no less frequently than hourly measurement of key system operation parameters; including hot water supply and return temperatures, and status of gas valve relays. |
| 03 | A current contract must be available that demonstrates the system will be monitored. |

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.



| | | |
|---|---------------------|----------------|
| CERTIFICATE OF INSTALLATION | | CF2R-PLB-01-E |
| Multifamily Central Hot Water System Distribution | | (Page 3 of 4) |
| Project Name: | Enforcement Agency: | Permit Number: |
| Dwelling Address: | City | Zip Code |

J. Multiple Dwelling Units – Demand Recirculation Requirements (RA4.4.13)

Systems that utilize this distribution type shall comply with these requirements.

| | |
|---|---|
| 01 | The system operates "on-demand", meaning that the pump begins to operate shortly before or immediately after hot water draw begins, and stops when the return water temperature reaches a certain threshold value. |
| 02 | After the pump has been activated, the controls shall allow the pump to operate until the water temperature at the thermo-sensor rises to one of the following values: <ul style="list-style-type: none"> • Not more than 10°F (5.6°C) above the initial temperature of the water in the pipe; or • Not more than 102°F (38.9°C). |
| 03 | The controls shall limit pump operation to a maximum of 10 minutes following any activation. This is provided in the event that the normal means of shutting off the pump have failed. |
| 04 | Pump and control placement shall meet one of the following criteria: <ul style="list-style-type: none"> • When a dedicated return line has been installed the pump, controls and thermo-sensor are installed at the end of the supply portion of the recirculation loop; or • The pump and controls are installed on the dedicated return line near the water heater and the thermo-sensor is installed in an accessible location as close to the end of the supply portion of the recirculation loop as possible; or • When the cold water line is used as the return, the pump, demand controls and thermo-sensor shall be installed in an accessible location at the end of supply portion of the hot water distribution line (typically under a sink). |
| 05 | Insulation is not required on the cold water line when it is used as the return. |
| 06 | Manual or sensor controls shall be installed and, if powered, each control has standby power of 1 Watt or less. Controls may be located in individual units or on the loop. Controls may be activated by wired or wireless mechanisms, including buttons, motion sensors, door switches and flow switches. |
| The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met. | |

K. Multiple Dwelling Units – Non-Demand Control Recirculation Systems Requirements

Systems that utilize this distribution type shall comply with these requirements

| | |
|---|---|
| 01 | The active control shall be either: timer, temperature, or time and temperature. Timers shall be set to less than 24 hours. The temperature sensor shall be connected to the piping and to the controls for the pump. |
| The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met. | |



| | | |
|---|---------------------|----------------|
| CERTIFICATE OF INSTALLATION | | CF2R-PLB-01-E |
| Multifamily Central Hot Water System Distribution | | (Page 4 of 4) |
| Project Name: | Enforcement Agency: | Permit Number: |
| Dwelling Address: | City | Zip Code |

DOCUMENTATION AUTHOR'S DECLARATION STATEMENT

1. I certify that this Certificate of Installation documentation is accurate and complete.

| | |
|------------------------------------|--|
| Documentation Author Name: | Documentation Author Signature: |
| Documentation Author Company Name: | Date Signed: |
| Address: | CEA/HERS Certification Identification (if applicable): |
| City/State/Zip: | Phone: |

RESPONSIBLE PERSON'S DECLARATION STATEMENT

I certify the following under penalty of perjury, under the laws of the State of California:

- The information provided on this Certificate of Installation is true and correct.
- I am either: a) a responsible person eligible under Division 3 of the Business and Professions Code in the applicable classification to accept responsibility for the system design, construction, or installation of features, materials, components, or manufactured devices for the scope of work identified on this Certificate of Installation, and attest to the declarations in this statement, or b) I am an authorized representative of the responsible person and attest to the declarations in this statement on the responsible person's behalf.
- The constructed or installed features, materials, components or manufactured devices (the installation) identified on this Certificate of Installation conforms to all applicable codes and regulations and the installation conforms to the requirements given on the Certificate of Compliance, plans, and specifications approved by the enforcement agency.
- I will ensure that a registered copy of this Certificate of Installation shall be posted or made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a registered copy of this Certificate of Installation is required to be included with the documentation the builder provides to the building owner at occupancy.

| | | |
|---|--|--------------|
| Responsible Builder/Installer Name: | Responsible Builder/Installer Signature: | |
| Company Name: (Installing Subcontractor or General Contractor or Builder/Owner) | Position With Company (Title): | |
| Address: | CSLB License: | |
| City/State/Zip: | Phone: | Date Signed: |

CF2R-PLB-01-E User Instructions**A. General Information**

This table reports the building location as specified on the Registered CF1R.

B. Design Central Water Heating Systems Information

This table reports the water heating system features that were specified on the registered CF1R compliance document for this project. This section is for information/verification purposes only and requires no user input.

C. Installed Central Water Heating Systems Information

This table reports the water heating system information that is being installed. Require one line for each central system.

- 01 Water Heating System ID or Name – Reference information from CF1R.
- 02 Water Heating System Type – Reference information from CF1R. The different kinds of water heating system type are DHW or Combined Hydronic.
- 03 Water Heater Type – Information from CF1R. The different kinds of water heaters are Large/Commercial Storage, Small/Consumer Storage, Residential-Duty Commercial Storage, Heat Pump, Boiler, Large/Commercial Instantaneous, Small/Consumer Instantaneous, Residential-Duty Commercial Instantaneous or Indirect.
- 04 # of Water Heaters in System – Reference information from CF1R.
- 05 Water Heater Storage Volume (gal) – User input. Value may be N/A if water heater type is instantaneous with zero storage.
- 06 Fuel Type – Reference information from CF1R. The different kinds of fuel types are natural gas, propane, oil, or electricity.
- 07 Rated Input Type – Reference information from CF1R. For natural gas, propane and oil fuel type the input type is Btu/hr. For electric the input type is kW.
- 08 Rated Input Value – User input. Numerical value of the rated input. Must be equal to or less than value indicated on the CF1R.
- 09 Heating Efficiency Type – Reference information from CF1R. Different efficiency types are Energy Factor, AFUE, UEF and Thermal Efficiency.
- 10 Heating Efficiency Value – User input. Numerical value of the Heating Efficiency. Must be equal to or higher efficiency than value indicated on the CF1R.
- 11 Standby Loss – User input. Must be equal to or less than value indicated on the CF1R. Value may be N/A if CF1R value is N/A.
- 12 Exterior Insulation. R-Value – User input. Must be equal to or higher than value indicated on the CF1R. Value may be N/A if CF1R value is N/A.

D. Design Central Water Heating Distribution Systems Information

This table reports the water heating distribution types specified on the registered CF1R compliance document for this project.

E. Installed Central Water Heating Distribution Systems Information

- 01 Water Heating System ID or Name – Reference information from CF1R.
- 02 Central DHW System Distribution Type = Reference information from CF1R.
- 03 Dwelling Unit DHW System Distribution Type = Reference information from CF1R.

F. Installed Water Heater Manufacturer Information

This table reports the manufacturer information of the installed water heater(s). Require one line for each installed water heater

- 01 Water Heating System ID or Name – Reference information from CF1R.
- 02 Manufacturer – User input. Enter the name of the water heater manufacturer.
- 03 Model Number – User input. Enter the model number of the water heater.

G. Mandatory Requirements for All Central Domestic Hot Water Recirculation Systems

This table lists the requirements for all central recirculation systems. Installer must ensure all the requirements in this table are met.

H. Multiple Dwelling Units – Recirculation Temperature Modulation Control Requirements

This table only applies to systems indicated as **Recirculation Temperature Modulation Control**. In addition to the mandatory requirements in Table G, the installer must ensure the requirements on this table are met.

I. Multiple Dwelling Units – Recirculation Continuous Monitoring Systems Requirements

This table only applies to systems indicated as **Recirculation Continuous Monitoring Systems**. In addition to the mandatory requirements in Table G, the installer must ensure the requirements on this table are met.

J. Multiple Dwelling Units – Demand Recirculation Requirements

This table only applies to systems indicated as **Demand Recirculation**. In addition to the mandatory requirements in Table G, the installer must ensure the requirements on this table are met.

K. Multiple Dwelling Units – Non-Demand Control Recirculation Systems Requirements

This table only applies to systems indicated as **Non-Demand Control Recirculation Systems**. In addition to the mandatory requirements in Table G, the installer must ensure the requirements on this table are met.