

DOCKETED	
Docket Number:	19-BSTD-03
Project Title:	2022 Energy Code Pre-Rulemaking
TN #:	233870
Document Title:	Frank Moskowitz Comments - Airscan Expert
Description:	N/A
Filer:	System
Organization:	Frank Moskowitz
Submitter Role:	Public
Submission Date:	7/14/2020 1:31:08 PM
Docketed Date:	7/14/2020

Comment Received From: Frank Moskowitz
Submitted On: 7/14/2020
Docket Number: 19-BSTD-03

Airscan Expert

7.2

1A. This section should be clarified it's not clear whether the size of the VSD should be for one base load compressor, all the base load compressors, or the compressors that are running

5B. The section should include the calculation for determining the velocity based on flow and pipe diameter