DOCKETED	
Docket Number:	06-AFC-09C
Project Title:	Colusa Generating Station - Compliance
TN #:	234006
Document Title:	2020 Q2 Operating Report
Description:	Quarterly Operating Report
Filer:	Anthony TJ Gomez
Organization:	Pacific Gas and Electric
Submitter Role:	Applicant
Submission Date:	7/24/2020 6:48:53 AM
Docketed Date:	7/24/2020

ATTACHMENT 1
Complaints
FCD: AQ-5
Title V: #5

During the first quarter of 2020, there were no complaints issued from the public for the Colusa Generating Station. The site continues to be available for inspection by representatives of the CCAPCD and the CEC.

ATTACHMENT 2
Fuel Quality Data

FCD: AQ-10 & 11
Title V: #16

Atmospheric Analysis & Consulting, Inc.

CLIENT	: PG&E
PROJECT NAME	: Natural Gas Sampling
AAC PROJECT NO.	: 200605
REPORT DATE	: 04/16/2020

On April 9, 2020, Atmospheric Analysis & Consulting, Inc. received one (1) 1.0-Liter Silonite Canister for Total Reduced Sulfur analysis by ASTM D-5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-APR-A	200605-7276	671.4

This analysis is performed in accordance with AAC's Quality Manual. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample.

The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 5 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 04/08/2020**
PROJECT NO.	**: 200605**	**RECEIVING DATE**	**: 04/09/2020**
MATRIX	**: AIR**	**ANALYSIS DATE**	**: 04/15/2020**
UNITS	**: grains/100 dscf**	**REPORT DATE**	**: 04/16/2020**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-APR-A**
AAC ID	**200605-7276**
Canister Dil. Fac.	**2.5**
Analyte	**Result**
Hydrogen Sulfide	**0.02477**
COS / SO2	**0.02357**
Methyl Mercaptan	< 0.00754
Ethyl Mercaptan	< 0.00754
Dimethyl Sulfide	< 0.00754
Carbon Disulfide	< 0.00754
Isopropyl Mercaptan	< 0.00754
tert-Butyl Mercaptan	**0.03754**
n-Propyl Mercaptan	< 0.00754
Methylethylsulfide	< 0.00754
sec-Butyl Mercaptan / Thiophene	< 0.00754
iso-Butyl Mercaptan	< 0.00754
Diethyl Sulfide	< 0.00754
n-Butyl Mercaptan	< 0.00754
Dimethyl Disulfide	< 0.00754
2-Methylthiophene	< 0.00754
3-Methylthiophene	< 0.00754
Tetrahydrothiophene	**0.05565**
Bromothiophene	< 0.00754
Thiophenol	< 0.00754
Diethyl Disulfide	< 0.00754
Total Unidentified Sulfur	< 0.00754
Total Reduced Sulfurs	**0.11796**
Total Sulfurs	**0.14153**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 04/08/2020**
PROJECT NO.	**: 200605**	**RECEIVING DATE**	**: 04/09/2020**
MATRIX	**: AIR**	**ANALYSIS DATE**	**: 04/15/2020**
UNITS	**: ppmV**	**REPORT DATE**	**: 04/16/2020**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-APR-A**
AAC ID	**200605-7276**
Canister Dil. Fac.	**2.5**
Analyte	**Result**
Hydrogen Sulfide	**0.407**
COS / SO2	**0.387**
Methyl Mercaptan	< 0.124
Ethyl Mercaptan	< 0.124
Dimethyl Sulfide	< 0.124
Carbon Disulfide	< 0.124
Isopropyl Mercaptan	< 0.124
tert-Butyl Mercaptan	**0.616**
n-Propyl Mercaptan	< 0.124
Methylethylsulfide	< 0.124
sec-Butyl Mercaptan / Thiophene	< 0.124
iso-Butyl Mercaptan	< 0.124
Diethyl Sulfide	< 0.124
n-Butyl Mercaptan	< 0.124
Dimethyl Disulfide	< 0.124
2-Methylthiophene	< 0.124
3-Methylthiophene	< 0.124
Tetrahydrothiophene	**0.914**
Bromothiophene	< 0.124
Thiophenol	< 0.124
Diethyl Disulfide	< 0.124
Total Unidentified Sulfur	< 0.124
Total Reduced Sulfurs	**1.94**
Total Sulfurs	**2.32**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 4/15/2020
Analyst: DL
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 3/9/2020

Opening Calibration Verification Standard

523.0 ppbV H2S (SS1192)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	4681	518	99.0	1.1
Duplicate	4761	527	100.7	0.5
Triplicate	4764	527	100.8	0.6

547.5 ppbV H2S (SS1192)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	5770	535	97.7	1.3
Duplicate	5837	541	98.8	0.2
Triplicate	5938	550	100.5	1.5

535.8 ppbV H2S (SS1192)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	6573	533	99.6	0.2
Duplicate	6487	526	98.3	1.1
Triplicate	6614	537	100.2	0.9

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis **Sample ID** 200605-7276

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	161.1	167.6	164.3	3.9
MeSH	27.8	27.6	27.7	0.7
DMS	<PQL	<PQL	0.0	0.0

Matrix Spike & Duplicate **Sample ID** 200605-7276 x10

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	16.4	261.5	284.1	286.3	102.2	103.0	0.8
MeSH	2.8	273.8	276.0	282.8	99.8	102.3	2.4
DMS	<PQL	267.9	266.2	274.5	99.4	102.5	3.0

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	523.0	559.6	107.0
MeSH	547.5	562.1	102.7
DMS	535.8	549.9	102.6

Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, * Must be < 5% RPD from Mean result.***

H2S: PQL = 10.0 ppbV, MDL = 1.60 ppbV
MeSH: PQL = 10.0 ppbV, MDL = 1.60 ppbV
DMS: PQL = 10.0 ppbV, MDL = 1.60 ppbV

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

200605

SAM #										Preparation and Analysis
Client: PG&E Environmental Services			Project Manager: Surinder Sidhu				Date: 4/8/20			
Address: 3400 Crow Canyon Road			Telephone Number: 925-866-5245	Email: SKSG@pge.com			Laboratory: AAC Labs			
City: San Ramon	State: CA	Zip: 94583	Site Contacat:				Laboratory Phone: 805-650-1642			
Project Number/Name: Natural Gas Sampling			Sampler: Steve North 925-785-3039				Laboratory Fax:			
Contract Number, PO Number:			Laboratory Contact: Marcus Hueppe - 1534 Eastman Ave. Suite A Ventura CA 93003							

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Type	No.	Preservative	Condition on Receipt/Comments	Sulfur ASTM D-5504
CPP-GS-APR-A	7276	4/8/20	1200	Gas	1 liter	cyl	1	None		X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.COM) and Evan Cavalli (EMCM@PGE.COM)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

1. Relinquished By: Steve North (via UPS)	Date: 4/8/20	Time: 1440	1. Received By		Date	Time
2. Relinquished By	Date	Time	2. Received By		Date	Time
3. Relinquished By	Date	Time	3. Received By		Date: 4/9/20	Time: 1150

Comments:

UPS 1x 1.0L Can

Atmospheric Analysis & Consulting, Inc.

CLIENT	: PG&E
PROJECT NAME	: Natural Gas Sampling
AAC PROJECT NO.	: 200940
REPORT DATE	: 06/04/2020

On June 2, 2020, Atmospheric Analysis & Consulting, Inc. received one (1) 1.0-Liter Silonite Canister for Total Reduced Sulfur analysis by ASTM D-5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-MAY-A	200940-8604	688.6

This analysis is performed in accordance with AAC's Quality Manual. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample.

The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 5 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 05/28/2020**
PROJECT NO.	**: 200940**	**RECEIVING DATE**	**: 06/02/2020**
MATRIX	**: AIR**	**ANALYSIS DATE**	**: 06/03/2020**
UNITS	**: ppmV**	**REPORT DATE**	**: 06/04/2020**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-MAY-A**
AAC ID	**200940-8604**
Canister Dil. Fac.	**2.3**
Analyte	**Result**
Hydrogen Sulfide	**0.721**
COS / SO2	**0.789**
Methyl Mercaptan	< 0.114
Ethyl Mercaptan	< 0.114
Dimethyl Sulfide	< 0.114
Carbon Disulfide	< 0.114
Isopropyl Mercaptan	< 0.114
tert-Butyl Mercaptan	**0.707**
n-Propyl Mercaptan	< 0.114
Methylethylsulfide	< 0.114
sec-Butyl Mercaptan / Thiophene	< 0.114
iso-Butyl Mercaptan	< 0.114
Diethyl Sulfide	< 0.114
n-Butyl Mercaptan	< 0.114
Dimethyl Disulfide	< 0.114
2-Methylthiophene	< 0.114
3-Methylthiophene	< 0.114
Tetrahydrothiophene	**0.940**
Bromothiophene	< 0.114
Thiophenol	< 0.114
Diethyl Disulfide	< 0.114
Total Unidentified Sulfur	< 0.114
Total Reduced Sulfurs	**2.37**
Total Sulfurs	**3.16**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 05/28/2020**
PROJECT NO.	**: 200940**	**RECEIVING DATE**	**: 06/02/2020**
MATRIX	**: AIR**	**ANALYSIS DATE**	**: 06/03/2020**
UNITS	**: grains/100 dscf**	**REPORT DATE**	**: 06/04/2020**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-MAY-A**
AAC ID	**200940-8604**
Canister Dil. Fac.	**2.3**
Analyte	**Result**
Hydrogen Sulfide	**0.04390**
COS / SO2	**0.04808**
Methyl Mercaptan	< 0.00693
Ethyl Mercaptan	< 0.00693
Dimethyl Sulfide	< 0.00693
Carbon Disulfide	< 0.00693
Isopropyl Mercaptan	< 0.00693
tert-Butyl Mercaptan	**0.04309**
n-Propyl Mercaptan	< 0.00693
Methylethylsulfide	< 0.00693
sec-Butyl Mercaptan / Thiophene	< 0.00693
iso-Butyl Mercaptan	< 0.00693
Diethyl Sulfide	< 0.00693
n-Butyl Mercaptan	< 0.00693
Dimethyl Disulfide	< 0.00693
2-Methylthiophene	< 0.00693
3-Methylthiophene	< 0.00693
Tetrahydrothiophene	**0.05726**
Bromothiophene	< 0.00693
Thiophenol	< 0.00693
Diethyl Disulfide	< 0.00693
Total Unidentified Sulfur	< 0.00693
Total Reduced Sulfurs	**0.14425**
Total Sulfurs	**0.19232**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 6/3/2020
Analyst: DL
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 4/20/2020

Opening Calibration Verification Standard

523.0 ppbV H2S (SSI192)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	4591	507	97.0	0.6
Duplicate	4672	516	98.7	1.1
Triplicate	4599	508	97.2	0.5

547.5 ppbV H2S (SSI192)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	5803	534	97.5	0.2
Duplicate	5813	535	97.7	0.4
Triplicate	5755	529	96.7	0.6

535.8 ppbV H2S (SSI192)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	6645	533	99.6	0.4
Duplicate	6513	523	97.6	1.6
Triplicate	6691	537	100.2	1.1

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis **Sample ID** 200940-8604

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	310.4	322.8	316.6	3.9
MeSH	<PQL	<PQL	0.0	0.0
DMS	<PQL	<PQL	0.0	0.0

Matrix Spike & Duplicate **Sample ID** 200940-8604 x10

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	31.7	261.5	297.4	284.9	101.5	97.2	4.3
MeSH	<PQL	273.8	264.0	267.4	96.4	97.7	1.3
DMS	<PQL	267.9	258.7	263.8	96.6	98.5	1.9

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	523.0	572.1	109.4
MeSH	547.5	582.1	106.3
DMS	535.8	584.7	109.1

** Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.*

H2S: PQL = 10.0 ppbV, MDL = 1.60 ppbV
MeSH: PQL = 10.0 ppbV, MDL = 1.60 ppbV
DMS: PQL = 10.0 ppbV, MDL = 1.60 ppbV

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

200940

SAM #										Preparation and Analysis
Client: PG&E Environmental Services			Project Manager: Surinder Sidhu				Date			
Address: 3400 Crow Canyon Road			Telephone Number: 925-866-5245	Email: SKSG@pge.com			Laboratory: AAC Labs			
City: San Ramon	State: CA	Zip: 94583	Site Contacat				Laboratory Phone: 805-650-1642			
Project Number/Name: Natural Gas Sampling			Sampler: Steve North 925-785-3039				Laboratory Fax			
Contract Number, PO Number			Laboratory Contact: Marcus Hueppe - 1534 Eastman Ave. Suite A Ventura CA 93003							

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Type	No.	Preservative	Condition on Receipt/Comments	Sulfur ASTM D-5504
CPP-GS-MAY-A		5/28/20	1745	Gas	1 liter	cyl	1	None	8604	X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.COM) and Evan Cavalli (EMCM@PGE.COM)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

1. Relinquished By: Steve North (via GSO)	Date: 5/29/20	Time: 0900	1. Received By		Date	Time
2. Relinquished By	Date	Time	2. Received By		Date	Time
3. Relinquished By	Date	Time	3. Received By		Date: 6/2/20	Time: 0955

Comments

GSO 1x 1.0L can

Atmospheric Analysis & Consulting, Inc.

CLIENT	: PG&E
PROJECT NAME	: Natural Gas Sampling
AAC PROJECT NO.	: 201025
REPORT DATE	: 06/17/2020

On June 12, 2020, Atmospheric Analysis & Consulting, Inc. received one (1) 1.0-Liter Silonite Canister for Total Reduced Sulfur analysis by ASTM D-5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-JUN-A	201025-8996	576.2

This analysis is performed in accordance with AAC's Quality Manual. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample.

The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 4 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 06/10/2020**
PROJECT NO.	**: 201025**	**RECEIVING DATE**	**: 06/12/2020**
MATRIX	**: AIR**	**ANALYSIS DATE**	**: 06/15/2020**
UNITS	**: ppmV**	**REPORT DATE**	**: 06/17/2020**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-JUN-A**
AAC ID	**201025-8996**
Canister Dil. Fac.	**3.2**
Analyte	**Result**
Hydrogen Sulfide	**0.490**
COS / SO2	**0.685**
Methyl Mercaptan	< 0.159
Ethyl Mercaptan	< 0.159
Dimethyl Sulfide	< 0.159
Carbon Disulfide	< 0.159
Isopropyl Mercaptan	< 0.159
tert-Butyl Mercaptan	**0.335**
n-Propyl Mercaptan	< 0.159
Methylethylsulfide	< 0.159
sec-Butyl Mercaptan / Thiophene	< 0.159
iso-Butyl Mercaptan	< 0.159
Diethyl Sulfide	< 0.159
n-Butyl Mercaptan	< 0.159
Dimethyl Disulfide	< 0.159
2-Methylthiophene	< 0.159
3-Methylthiophene	< 0.159
Tetrahydrothiophene	**0.966**
Bromothiophene	< 0.159
Thiophenol	< 0.159
Diethyl Disulfide	< 0.159
Total Unidentified Sulfur	< 0.159
Total Reduced Sulfurs	**1.79**
Total Sulfurs	**2.48**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 6/15/2020
Analyst: DL
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 4/20/2020

Opening Calibration Verification Standard

523.0 ppbV H2S (SS1192)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	4654	514	98.3	0.4
Duplicate	4597	508	97.1	0.8
Triplicate	4656	515	98.4	0.4

547.5 ppbV H2S (SS1192)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	5909	544	99.3	1.1
Duplicate	5987	551	100.6	0.3
Triplicate	6020	554	101.1	0.8

535.8 ppbV H2S (SS1192)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	6781	544	101.6	0.8
Duplicate	6799	546	101.9	0.5
Triplicate	6919	555	103.7	1.3

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis **Sample ID** 201025-8996

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	153.7	153.8	153.7	0.1
MeSH	<PQL	<PQL	0.0	0.0
DMS	<PQL	<PQL	0.0	0.0

Matrix Spike & Duplicate **Sample ID** 201025-8996 x10

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	15.4	261.5	266.0	275.5	96.1	99.5	3.5
MeSH	<PQL	273.8	282.8	275.4	103.3	100.6	2.7
DMS	<PQL	267.9	273.3	270.6	102.0	101.0	1.0

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	523.0	541.4	103.5
MeSH	547.5	496.9	90.8
DMS	535.8	485.2	90.6

** Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.*

H2S: PQL = 10.0 ppbV, MDL = 1.60 ppbV
MeSH: PQL = 10.0 ppbV, MDL = 1.60 ppbV
DMS: PQL = 10.0 ppbV, MDL = 1.60 ppbV

Suona Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

201025

SAM #									Preparation and Analysis
Client: PG&E Environmental Services			Project Manager: Surinder Sidhu		Date: 6/10/20				
Address: 3400 Crow Canyon Road			Telephone Number: 925-866-5245	Email: SKSG@pge.com	Laboratory: AAC Labs				
City: San Ramon	State: CA	Zip: 94583	Site Contacat		Laboratory Phone: 805-650-1642				
Project Number/Name: Natural Gas Sampling			Sampler: Steve North 925-785-3039		Laboratory Fax				
Contract Number, PO Number			Laboratory Contact: Marcus Hueppe - 1534 Eastman Ave. Suite A Ventura CA 93003						

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Type	No.	Preservative	Condition on Receipt/Comments	Sulfur ASTM D-5504
CPP-GS-JUN-A		6/10/20	1219	Gas	1 liter	cyl	1	None		X
8996										

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.COM) and Evan Cavalli (EMCM@PGE.COM)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

1. Relinquished By: Steve North (via GSO 6/11)	Date: 6/10/20	Time: 1515	1. Received By		Date	Time
2. Relinquished By	Date	Time	2. Received By		Date	Time
3. Relinquished By	Date	Time	3. Received By		Date: 6/12/20	Time: 1520

Comments

GSO lv 1.0L can

2020 Monthly Sulfur Content - Colusa Generating Station

All Units in Grains of Sulfur per 100 Standard Cubic Foot

Month	Jan-20	Feb-20	Mar-20	Apr-20	May-20	Jun-20	Jul-20	Aug-20	Sep-20	Oct-20	Nov-20	Dec-20	Avg
Gr/100SCF	0.296	0.377	0.316	0.141	0.316	0.248							0.282

Permit Limits:

0.75 Grains/100SCF per Month (PSD Condition X.I.4); 0.3 Grains/100SCF Annual Average (Title V # 16)

ATTACHMENT 3
40 CFR 60 Section KKKK

FCD: AQ-13
Title V: #8, 9, 25, 25, 30

40 CFR 60 KKKK Emission Limits:

Natural Gas Fired Combustion Turbine > 850 MMBtu

15 ppmvdc @ 15% O_2; 4 Hour Rolling Average

During Normal Operations

96 ppmvdc @ 15% O_2; 4 Hour Rolling Average

Turbines operating at less than 75% of Peak Load (Startup/Shutdown)

KKKK Compliance (Colusa Generating Station)

40 CFR Part 60 Subpart KKKK applies to all stationary gas turbines rated at greater than or equal to 10 MMBtu/hr that commence construction, modification, or reconstruction after February 18, 2005. The gas turbines involved in this project have a rating of 1612 MMBtu/hr and were installed after February 18, 2005, therefore, this subpart applies.

Compliance with the applicable provisions of NSPS KKKK are summarized below. Specific data to support the compliance determinations listed below are included as attachments. The non-applicable portions of KKKK are not listed in the compliance summary:

Section	Requirement	Compliance Status
60.4305	CGS Turbines/HRSGs rated at larger than 10 MMBtu/hr and construction commenced after February 18, 2005. Subpart KKKK applies.	IN COMPLIANCE
60.4310	No exemptions apply.	No exemptions apply.
60.4315	Pollutants regulated under Subpart KKKK: NO_x and SO_2.	IN COMPLIANCE
60.4320	NOx emissions limit: 15 ppmv @15% O_2	IN COMPLIANCE
60.4330	SO_2 emissions limit: 0.90 lbs SO_2/MWh (gross output), or cannot burn any fuel which contains total potential sulfur emissions in excess of 0.060 lbs SO_2/MMBtu (heat input).	IN COMPLIANCE Based on monthly fuel sampling.
60.4333	Operate turbine/HRSG, APC systems, and monitoring equipment to minimize emissions at all times including during startup, shutdown, and malfunction.	IN COMPLIANCE
60.4340(b)(1)	For units with SCR, install a NO_x CEMS per 60.4335(b) or 60.4345. If Part 75 applies, NO_x can be monitored per Appendix E of Part 75. (CGS QAP applies here)	IN COMPLIANCE CT1 and CT2 utilize SCR and NO_x CEMS per 60.4335(b) or 60.4345. Part 75 applies and NO_x is monitored per Appendix E of Part 75.
60.4345	Meet all CEMS Performance Specs and develop a QA Plan for the CEMS. (CGS QAP applies here)	IN COMPLIANCE
60.4350	All CEMS data must be reduced to hourly averages per 60.13(h). (CGS QAP applies here)	IN COMPLIANCE

60.4355	If applicable, develop and insure all parametric monitoring and monitoring plans comply with this section. (CGS QAP applies here)	IN COMPLIANCE
60.4360	Monitor fuel sulfur content, or invoke exemption per 60.4365.	Exemption per 60.4365
60.4365	Exemption for fuel sulfur monitoring if fuel is demonstrated not to exceed potential sulfur emissions of 0.060 lb SO_2/MMBtu. Use PG&E gas quality data to show that exemption applies per 60.4365 (a) or (b).	IN COMPLIANCE Pipeline quality natural gas used with sulfur content less than 0.30 gr/100 SCF (0.0008 lb/MMBtu as SO_2). Annual compliance based on PG&E supplied fuel analysis data. See Attachment 2.
60.4375	Submit excess emissions reports per 60.7(c). Within 30 days following the end of each 6 month period (see 60.4395).	IN COMPLIANCE
60.4380(b)	Determine excess emissions and monitor downtime per (b) (1-3)	IN COMPLIANCE See Attachment 4.
60.4400	Initial and annual NO_X performance tests not required if CEMS used per 60.4340(b)(1)	IN COMPLIANCE NO_x CEMs used per 60.4340(b)(1). NO_x, CO, and VOC tested annually.
60.4415	Perform initial SO_2 performance test per 60.4415 (2) or (3). This test must be conducted even if the 60.4365 exemption is invoked.	IN COMPLIANCE Initial SO_2 source test performed in 2010; results available upon request. Ongoing compliance determined by fuel sampling (60.4415(a)(1)(ii)).

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/01/2020 00:00	1	0
04/01/2020 01:00	1	0
04/01/2020 02:00	1	0
04/01/2020 03:00	13	0
04/01/2020 04:00	21	0
04/01/2020 05:00	20	1
04/01/2020 06:00	20	1
04/01/2020 07:00	9	0
04/01/2020 08:00	1	0
04/01/2020 09:00	1	0
04/01/2020 10:00	1	0
04/01/2020 11:00	1	0
04/01/2020 12:00	1	0
04/01/2020 13:00	1	0
04/01/2020 14:00	1	0
04/01/2020 15:00	1	1
04/01/2020 16:00	1	1
04/01/2020 17:00	1	1
04/01/2020 18:00	1	1
04/01/2020 19:00	1	1
04/01/2020 20:00	1	1
04/01/2020 21:00	1	1
04/01/2020 22:00	1	1
04/01/2020 23:00	1	1
Average/Sum#:	4	0
Minimum:	1	0
Maximum:	21	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/02/2020 00:00	1	1
04/02/2020 01:00	1	1
04/02/2020 02:00	1	1
04/02/2020 03:00	1	1
04/02/2020 04:00	1	1
04/02/2020 05:00	1	1
04/02/2020 06:00	1	1
04/02/2020 07:00	1	1
04/02/2020 08:00	1	1
04/02/2020 09:00	1	1
04/02/2020 10:00	1	1
04/02/2020 11:00	1	1
04/02/2020 12:00	1	1
04/02/2020 13:00	1	1
04/02/2020 14:00	1	1
04/02/2020 15:00	1	1
04/02/2020 16:00	1	1
04/02/2020 17:00	1	1
04/02/2020 18:00	1	1
04/02/2020 19:00	1	1
04/02/2020 20:00	1	1
04/02/2020 21:00	1	2
04/02/2020 22:00	1	2
04/02/2020 23:00	1	2
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/03/2020 00:00	1	2
04/03/2020 01:00	1	2
04/03/2020 02:00	1	2
04/03/2020 03:00	1	2
04/03/2020 04:00	1	2
04/03/2020 05:00	1	2
04/03/2020 06:00	1	2
04/03/2020 07:00	1	2
04/03/2020 08:00	1	2
04/03/2020 09:00	1	2
04/03/2020 10:00	1	2
04/03/2020 11:00	1	2
04/03/2020 12:00	1	2
04/03/2020 13:00	1	2
04/03/2020 14:00	1	2
04/03/2020 15:00	1	2
04/03/2020 16:00	1	2
04/03/2020 17:00	1	2
04/03/2020 18:00	1	2
04/03/2020 19:00	1	2
04/03/2020 20:00	1	17
04/03/2020 21:00	1	21
04/03/2020 22:00	1	24
04/03/2020 23:00	1	23
Average/Sum#:	1	5
Minimum:	1	2
Maximum:	1	24
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/04/2020 00:00	1	8
04/04/2020 01:00	14	4
04/04/2020 02:00	16	1
04/04/2020 03:00	16	1
04/04/2020 04:00	16	1
04/04/2020 05:00	3	1
04/04/2020 06:00	1	1
04/04/2020 07:00	1	1
04/04/2020 08:00	1	1
04/04/2020 09:00	1	1
04/04/2020 10:00	1	1
04/04/2020 11:00	1	1
04/04/2020 12:00	1	1
04/04/2020 13:00	1	1
04/04/2020 14:00	1	1
04/04/2020 15:00	1	1
04/04/2020 16:00	1	1
04/04/2020 17:00	1	1
04/04/2020 18:00	1	1
04/04/2020 19:00	1	1
04/04/2020 20:00	1	1
04/04/2020 21:00	1	1
04/04/2020 22:00	1	1
04/04/2020 23:00	1	1
Average/Sum#:	4	1
Minimum:	1	1
Maximum:	16	8
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/05/2020 00:00	1	1
04/05/2020 01:00	1	1
04/05/2020 02:00	1	1
04/05/2020 03:00	1	1
04/05/2020 04:00	1	1
04/05/2020 05:00	1	1
04/05/2020 06:00	1	1
04/05/2020 07:00	1	1
04/05/2020 08:00	1	1
04/05/2020 09:00	1	1
04/05/2020 10:00	1	1
04/05/2020 11:00	1	1
04/05/2020 12:00	1	1
04/05/2020 13:00	1	1
04/05/2020 14:00	1	1
04/05/2020 15:00	1	1
04/05/2020 16:00	1	1
04/05/2020 17:00	1	1
04/05/2020 18:00	1	1
04/05/2020 19:00	1	1
04/05/2020 20:00	1	1
04/05/2020 21:00	1	1
04/05/2020 22:00	1	1
04/05/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/06/2020 00:00	1	1
04/06/2020 01:00	1	1
04/06/2020 02:00	1	1
04/06/2020 03:00	1	1
04/06/2020 04:00	1	1
04/06/2020 05:00	1	1
04/06/2020 06:00	1	1
04/06/2020 07:00	1	1
04/06/2020 08:00	1	1
04/06/2020 09:00	1	1
04/06/2020 10:00	0	1
04/06/2020 11:00	0	0
04/06/2020 12:00	0	0
04/06/2020 13:00	0	0
04/06/2020 14:00	1	0
04/06/2020 15:00	1	0
04/06/2020 16:00	1	0
04/06/2020 17:00	1	1
04/06/2020 18:00	1	1
04/06/2020 19:00	1	1
04/06/2020 20:00	1	1
04/06/2020 21:00	1	1
04/06/2020 22:00	1	1
04/06/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/07/2020 00:00	1	1
04/07/2020 01:00	1	1
04/07/2020 02:00	1	1
04/07/2020 03:00	1	1
04/07/2020 04:00	1	1
04/07/2020 05:00	1	1
04/07/2020 06:00	1	1
04/07/2020 07:00	1	1
04/07/2020 08:00	1	1
04/07/2020 09:00	1	1
04/07/2020 10:00	1	1
04/07/2020 11:00	1	1
04/07/2020 12:00	1	1
04/07/2020 13:00	1	1
04/07/2020 14:00	1	1
04/07/2020 15:00	1	1
04/07/2020 16:00	1	1
04/07/2020 17:00	1	1
04/07/2020 18:00	1	1
04/07/2020 19:00	1	1
04/07/2020 20:00	1	1
04/07/2020 21:00	1	1
04/07/2020 22:00	1	1
04/07/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/08/2020 00:00	1	1
04/08/2020 01:00	1	1
04/08/2020 02:00	1	1
04/08/2020 03:00	1	1
04/08/2020 04:00	1	1
04/08/2020 05:00	1	1
04/08/2020 06:00	1	1
04/08/2020 07:00	1	1
04/08/2020 08:00	1	1
04/08/2020 09:00	1	1
04/08/2020 10:00	1	1
04/08/2020 11:00	1	1
04/08/2020 12:00	1	1
04/08/2020 13:00	1	1
04/08/2020 14:00	1	1
04/08/2020 15:00	1	1
04/08/2020 16:00	1	1
04/08/2020 17:00	1	1
04/08/2020 18:00	1	1
04/08/2020 19:00	1	1
04/08/2020 20:00	1	1
04/08/2020 21:00	1	1
04/08/2020 22:00	1	1
04/08/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/09/2020 00:00	1	1
04/09/2020 01:00	1	1
04/09/2020 02:00	1	1
04/09/2020 03:00	1	1
04/09/2020 04:00	1	1
04/09/2020 05:00	1	1
04/09/2020 06:00	1	1
04/09/2020 07:00	1	1
04/09/2020 08:00	1	1
04/09/2020 09:00	1	1
04/09/2020 10:00	1	1
04/09/2020 11:00	1	1
04/09/2020 12:00	1	1
04/09/2020 13:00	1	1
04/09/2020 14:00	1	1
04/09/2020 15:00	1	1
04/09/2020 16:00	1	1
04/09/2020 17:00	1	1
04/09/2020 18:00	1	1
04/09/2020 19:00	1	1
04/09/2020 20:00	1	1
04/09/2020 21:00	1	1
04/09/2020 22:00	1	1
04/09/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/10/2020 00:00	1	1
04/10/2020 01:00	1	1
04/10/2020 02:00	1	1
04/10/2020 03:00	1	1
04/10/2020 04:00	1	1
04/10/2020 05:00	1	1
04/10/2020 06:00	1	1
04/10/2020 07:00	1	1
04/10/2020 08:00	1	1
04/10/2020 09:00	1	1
04/10/2020 10:00	1	1
04/10/2020 11:00	1	1
04/10/2020 12:00	1	1
04/10/2020 13:00	1	1
04/10/2020 14:00	1	1
04/10/2020 15:00	1	1
04/10/2020 16:00	1	1
04/10/2020 17:00	1	1
04/10/2020 18:00	1	1
04/10/2020 19:00	1	1
04/10/2020 20:00	1	1
04/10/2020 21:00	1	1
04/10/2020 22:00	1	1
04/10/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/11/2020 00:00	1	1
04/11/2020 01:00	1	1
04/11/2020 02:00	1	1
04/11/2020 03:00	1	1
04/11/2020 04:00	1	1
04/11/2020 05:00	1	1
04/11/2020 06:00	1	1
04/11/2020 07:00	1	1
04/11/2020 08:00	1	1
04/11/2020 09:00	1	1
04/11/2020 10:00	1	1
04/11/2020 11:00	1	1
04/11/2020 12:00	1	1
04/11/2020 13:00	1	1
04/11/2020 14:00	1	1
04/11/2020 15:00	1	1
04/11/2020 16:00	1	1
04/11/2020 17:00	1	1
04/11/2020 18:00	1	1
04/11/2020 19:00	1	1
04/11/2020 20:00	1	1
04/11/2020 21:00	1	1
04/11/2020 22:00	2	1
04/11/2020 23:00	2	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	2	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/12/2020 00:00	1	1
04/12/2020 01:00	1	1
04/12/2020 02:00	1	1
04/12/2020 03:00	1	1
04/12/2020 04:00	1	1
04/12/2020 05:00	1	1
04/12/2020 06:00	1	1
04/12/2020 07:00	1	1
04/12/2020 08:00	1	1
04/12/2020 09:00	1	1
04/12/2020 10:00	1	1
04/12/2020 11:00	1	1
04/12/2020 12:00	1	1
04/12/2020 13:00	1	1
04/12/2020 14:00	1	1
04/12/2020 15:00	1	1
04/12/2020 16:00	1	1
04/12/2020 17:00	1	1
04/12/2020 18:00	1	1
04/12/2020 19:00	1	1
04/12/2020 20:00	1	1
04/12/2020 21:00	1	1
04/12/2020 22:00	1	1
04/12/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/13/2020 00:00	1	1
04/13/2020 01:00	1	1
04/13/2020 02:00	1	1
04/13/2020 03:00	1	1
04/13/2020 04:00	1	1
04/13/2020 05:00	1	1
04/13/2020 06:00	1	1
04/13/2020 07:00	1	1
04/13/2020 08:00	1	1
04/13/2020 09:00	1	1
04/13/2020 10:00	1	1
04/13/2020 11:00	1	1
04/13/2020 12:00	1	1
04/13/2020 13:00	1	1
04/13/2020 14:00	1	1
04/13/2020 15:00	1	1
04/13/2020 16:00	1	1
04/13/2020 17:00	1	1
04/13/2020 18:00	1	1
04/13/2020 19:00	1	1
04/13/2020 20:00	1	1
04/13/2020 21:00	1	1
04/13/2020 22:00	1	1
04/13/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/14/2020 00:00	1	1
04/14/2020 01:00	1	1
04/14/2020 02:00	1	1
04/14/2020 03:00	1	1
04/14/2020 04:00	1	1
04/14/2020 05:00	1	1
04/14/2020 06:00	1	1
04/14/2020 07:00	1	1
04/14/2020 08:00	1	1
04/14/2020 09:00	1	1
04/14/2020 10:00	1	1
04/14/2020 11:00	1	1
04/14/2020 12:00	1	1
04/14/2020 13:00	1	1
04/14/2020 14:00	1	1
04/14/2020 15:00	1	1
04/14/2020 16:00	1	1
04/14/2020 17:00	1	1
04/14/2020 18:00	1	1
04/14/2020 19:00	1	1
04/14/2020 20:00	1	1
04/14/2020 21:00	1	1
04/14/2020 22:00	1	1
04/14/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/15/2020 00:00	1	1
04/15/2020 01:00	1	1
04/15/2020 02:00	1	1
04/15/2020 03:00	1	1
04/15/2020 04:00	1	1
04/15/2020 05:00	1	1
04/15/2020 06:00	1	1
04/15/2020 07:00	1	1
04/15/2020 08:00	1	1
04/15/2020 09:00	1	1
04/15/2020 10:00	1	1
04/15/2020 11:00	1	1
04/15/2020 12:00	1	1
04/15/2020 13:00	1	1
04/15/2020 14:00	1	1
04/15/2020 15:00	1	1
04/15/2020 16:00	1	1
04/15/2020 17:00	1	1
04/15/2020 18:00	1	1
04/15/2020 19:00	1	1
04/15/2020 20:00	1	1
04/15/2020 21:00	1	1
04/15/2020 22:00	1	1
04/15/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/16/2020 00:00	1	1
04/16/2020 01:00	1	1
04/16/2020 02:00	1	1
04/16/2020 03:00	1	1
04/16/2020 04:00	1	1
04/16/2020 05:00	1	1
04/16/2020 06:00	1	1
04/16/2020 07:00	1	1
04/16/2020 08:00	1	1
04/16/2020 09:00	1	1
04/16/2020 10:00	1	1
04/16/2020 11:00	1	1
04/16/2020 12:00	1	1
04/16/2020 13:00	1	1
04/16/2020 14:00	1	1
04/16/2020 15:00	1	1
04/16/2020 16:00	1	1
04/16/2020 17:00	1	1
04/16/2020 18:00	1	1
04/16/2020 19:00	1	1
04/16/2020 20:00	1	1
04/16/2020 21:00	1	1
04/16/2020 22:00	1	1
04/16/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/17/2020 00:00	1	1
04/17/2020 01:00	1	1
04/17/2020 02:00	1	1
04/17/2020 03:00	1	1
04/17/2020 04:00	1	1
04/17/2020 05:00	1	1
04/17/2020 06:00	1	1
04/17/2020 07:00	1	1
04/17/2020 08:00	1	1
04/17/2020 09:00	1	1
04/17/2020 10:00	1	1
04/17/2020 11:00	1	1
04/17/2020 12:00	1	1
04/17/2020 13:00	1	1
04/17/2020 14:00	1	1
04/17/2020 15:00	1	1
04/17/2020 16:00	1	1
04/17/2020 17:00	1	1
04/17/2020 18:00	1	1
04/17/2020 19:00	1	1
04/17/2020 20:00	1	1
04/17/2020 21:00	1	1
04/17/2020 22:00	1	1
04/17/2020 23:00	1	2
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/18/2020 00:00	1	2
04/18/2020 01:00	1	2
04/18/2020 02:00	1	2
04/18/2020 03:00	1	2
04/18/2020 04:00	1	2
04/18/2020 05:00	1	2
04/18/2020 06:00	1	2
04/18/2020 07:00	1	2
04/18/2020 08:00	1	2
04/18/2020 09:00	1	2
04/18/2020 10:00	1	2
04/18/2020 11:00	1	2
04/18/2020 12:00	1	2
04/18/2020 13:00	1	2
04/18/2020 14:00	1	2
04/18/2020 15:00	1	2
04/18/2020 16:00	1	2
04/18/2020 17:00	1	2
04/18/2020 18:00	1	2
04/18/2020 19:00	1	2
04/18/2020 20:00	1	2
04/18/2020 21:00	1	2
04/18/2020 22:00	1	2
04/18/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/19/2020 00:00	1	2
04/19/2020 01:00	1	2
04/19/2020 02:00	1	2
04/19/2020 03:00	1	2
04/19/2020 04:00	1	2
04/19/2020 05:00	1	2
04/19/2020 06:00	1	2
04/19/2020 07:00	1	2
04/19/2020 08:00	1	2
04/19/2020 09:00	1	2
04/19/2020 10:00	1	2
04/19/2020 11:00	1	2
04/19/2020 12:00	1	2
04/19/2020 13:00	1	2
04/19/2020 14:00	1	2
04/19/2020 15:00	1	2
04/19/2020 16:00	1	2
04/19/2020 17:00	1	16
04/19/2020 18:00	1	22
04/19/2020 19:00	1	25
04/19/2020 20:00	1	24
04/19/2020 21:00	1	10
04/19/2020 22:00	1	4
04/19/2020 23:00	1	0
Average/Sum#:	1	6
Minimum:	1	0
Maximum:	1	25
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/20/2020 00:00	1	0
04/20/2020 01:00	1	0
04/20/2020 02:00	15	0
04/20/2020 03:00	18	0
04/20/2020 04:00	18	1
04/20/2020 05:00	18	1
04/20/2020 06:00	4	1
04/20/2020 07:00	1	1
04/20/2020 08:00	1	1
04/20/2020 09:00	1	1
04/20/2020 10:00	1	1
04/20/2020 11:00	1	1
04/20/2020 12:00	1	1
04/20/2020 13:00	1	1
04/20/2020 14:00	1	1
04/20/2020 15:00	1	1
04/20/2020 16:00	1	1
04/20/2020 17:00	1	1
04/20/2020 18:00	1	1
04/20/2020 19:00	1	1
04/20/2020 20:00	1	1
04/20/2020 21:00	1	1
04/20/2020 22:00	1	1
04/20/2020 23:00	2	2
Average/Sum#:	4	1
Minimum:	1	0
Maximum:	18	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/21/2020 00:00	2	2
04/21/2020 01:00	2	2
04/21/2020 02:00	2	2
04/21/2020 03:00	2	2
04/21/2020 04:00	2	2
04/21/2020 05:00	2	2
04/21/2020 06:00	2	2
04/21/2020 07:00	2	2
04/21/2020 08:00	2	2
04/21/2020 09:00	2	2
04/21/2020 10:00	2	2
04/21/2020 11:00	2	2
04/21/2020 12:00	2	2
04/21/2020 13:00	2	2
04/21/2020 14:00	2	2
04/21/2020 15:00	2	2
04/21/2020 16:00	2	2
04/21/2020 17:00	2	2
04/21/2020 18:00	2	2
04/21/2020 19:00	2	2
04/21/2020 20:00	2	2
04/21/2020 21:00	2	2
04/21/2020 22:00	2	2
04/21/2020 23:00	2	2
Average/Sum#:	2	2
Minimum:	2	2
Maximum:	2	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/22/2020 00:00	2	2
04/22/2020 01:00	2	2
04/22/2020 02:00	2	2
04/22/2020 03:00	2	2
04/22/2020 04:00	2	16
04/22/2020 05:00	2	18
04/22/2020 06:00	2	20
04/22/2020 07:00	14	19
04/22/2020 08:00	22	5
04/22/2020 09:00	23	2
04/22/2020 10:00	22	1
04/22/2020 11:00	11	1
04/22/2020 12:00	11	0
04/22/2020 13:00	11	2
04/22/2020 14:00	11	2
04/22/2020 15:00	11	2
04/22/2020 16:00	11	2
04/22/2020 17:00	11	2
04/22/2020 18:00	11	4
04/22/2020 19:00	11	8
04/22/2020 20:00	11	8
04/22/2020 21:00	11	7
04/22/2020 22:00	11	4
04/22/2020 23:00	11	0
Average/Sum#:	10	5
Minimum:	2	0
Maximum:	23	20
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/23/2020 00:00	11	0
04/23/2020 01:00	11	0
04/23/2020 02:00	11	2
04/23/2020 03:00	11	2
04/23/2020 04:00	11	2
04/23/2020 05:00	11	2
04/23/2020 06:00	11	2
04/23/2020 07:00	11	2
04/23/2020 08:00	11	2
04/23/2020 09:00	11	2
04/23/2020 10:00	11	2
04/23/2020 11:00	11	2
04/23/2020 12:00	11	2
04/23/2020 13:00	11	2
04/23/2020 14:00	11	2
04/23/2020 15:00	11	2
04/23/2020 16:00	11	2
04/23/2020 17:00	11	2
04/23/2020 18:00	11	2
04/23/2020 19:00	11	2
04/23/2020 20:00	11	2
04/23/2020 21:00	11	2
04/23/2020 22:00	11	2
04/23/2020 23:00	11	2
Average/Sum#:	11	2
Minimum:	11	0
Maximum:	11	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/24/2020 00:00	11	2
04/24/2020 01:00	11	2
04/24/2020 02:00	11	2
04/24/2020 03:00	11	2
04/24/2020 04:00	11	2
04/24/2020 05:00	11	2
04/24/2020 06:00	11	2
04/24/2020 07:00	11	2
04/24/2020 08:00	11	2
04/24/2020 09:00	11	16
04/24/2020 10:00	11	21
04/24/2020 11:00	11	25
04/24/2020 12:00	11	24
04/24/2020 13:00	11	9
04/24/2020 14:00	5	5
04/24/2020 15:00	0	0
04/24/2020 16:00	0	0
04/24/2020 17:00	0	1
04/24/2020 18:00	0	1
04/24/2020 19:00	0	1
04/24/2020 20:00	0	1
04/24/2020 21:00	1	1
04/24/2020 22:00	2	1
04/24/2020 23:00	2	1
Average/Sum#:	9	5
Minimum:	1	0
Maximum:	11	25
%SI	25.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/25/2020 00:00	2	1
04/25/2020 01:00	2	1
04/25/2020 02:00	2	1
04/25/2020 03:00	2	1
04/25/2020 04:00	2	1
04/25/2020 05:00	2	1
04/25/2020 06:00	2	1
04/25/2020 07:00	2	1
04/25/2020 08:00	2	1
04/25/2020 09:00	2	1
04/25/2020 10:00	2	1
04/25/2020 11:00	2	1
04/25/2020 12:00	2	1
04/25/2020 13:00	2	1
04/25/2020 14:00	2	1
04/25/2020 15:00	2	1
04/25/2020 16:00	2	1
04/25/2020 17:00	2	1
04/25/2020 18:00	2	1
04/25/2020 19:00	2	1
04/25/2020 20:00	2	1
04/25/2020 21:00	2	1
04/25/2020 22:00	2	1
04/25/2020 23:00	2	1
Average/Sum#:	2	1
Minimum:	2	1
Maximum:	2	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/26/2020 00:00	2	1
04/26/2020 01:00	2	1
04/26/2020 02:00	2	1
04/26/2020 03:00	2	1
04/26/2020 04:00	2	1
04/26/2020 05:00	2	1
04/26/2020 06:00	2	1
04/26/2020 07:00	2	1
04/26/2020 08:00	2	1
04/26/2020 09:00	2	1
04/26/2020 10:00	2	1
04/26/2020 11:00	2	1
04/26/2020 12:00	2	1
04/26/2020 13:00	2	1
04/26/2020 14:00	2	1
04/26/2020 15:00	2	1
04/26/2020 16:00	2	1
04/26/2020 17:00	2	1
04/26/2020 18:00	2	1
04/26/2020 19:00	2	1
04/26/2020 20:00	2	1
04/26/2020 21:00	2	1
04/26/2020 22:00	2	1
04/26/2020 23:00	2	1
Average/Sum#:	2	1
Minimum:	2	1
Maximum:	2	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/27/2020 00:00	2	1
04/27/2020 01:00	2	1
04/27/2020 02:00	2	1
04/27/2020 03:00	2	1
04/27/2020 04:00	2	1
04/27/2020 05:00	2	1
04/27/2020 06:00	2	1
04/27/2020 07:00	2	1
04/27/2020 08:00	2	1
04/27/2020 09:00	2	1
04/27/2020 10:00	2	1
04/27/2020 11:00	2	1
04/27/2020 12:00	2	1
04/27/2020 13:00	2	16
04/27/2020 14:00	2	23
04/27/2020 15:00	2	26
04/27/2020 16:00	2	26
04/27/2020 17:00	2	11
04/27/2020 18:00	2	4
04/27/2020 19:00	2	1
04/27/2020 20:00	2	1
04/27/2020 21:00	2	1
04/27/2020 22:00	2	1
04/27/2020 23:00	2	1
Average/Sum#:	2	5
Minimum:	2	1
Maximum:	2	26
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/28/2020 00:00	2	0
04/28/2020 01:00	2	0
04/28/2020 02:00	2	0
04/28/2020 03:00	2	0
04/28/2020 04:00	2	0
04/28/2020 05:00	2	0
04/28/2020 06:00	2	0
04/28/2020 07:00	2	0
04/28/2020 08:00	2	0
04/28/2020 09:00	2	0
04/28/2020 10:00	2	0
04/28/2020 11:00	2	0
04/28/2020 12:00	2	0
04/28/2020 13:00	17	0
04/28/2020 14:00	24	0
04/28/2020 15:00	24	0
04/28/2020 16:00	23	0
04/28/2020 17:00	8	1
04/28/2020 18:00	1	1
04/28/2020 19:00	1	1
04/28/2020 20:00	1	1
04/28/2020 21:00	1	1
04/28/2020 22:00	1	1
04/28/2020 23:00	1	1
Average/Sum#:	5	0
Minimum:	1	0
Maximum:	24	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/29/2020 00:00	1	1
04/29/2020 01:00	1	1
04/29/2020 02:00	1	1
04/29/2020 03:00	1	1
04/29/2020 04:00	1	1
04/29/2020 05:00	1	1
04/29/2020 06:00	1	1
04/29/2020 07:00	1	1
04/29/2020 08:00	1	1
04/29/2020 09:00	1	1
04/29/2020 10:00	1	1
04/29/2020 11:00	1	1
04/29/2020 12:00	1	1
04/29/2020 13:00	1	12
04/29/2020 14:00	1	16
04/29/2020 15:00	1	17
04/29/2020 16:00	1	16
04/29/2020 17:00	1	5
04/29/2020 18:00	1	1
04/29/2020 19:00	1	1
04/29/2020 20:00	1	1
04/29/2020 21:00	1	1
04/29/2020 22:00	1	1
04/29/2020 23:00	1	1
Average/Sum#:	1	4
Minimum:	1	1
Maximum:	1	17
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
04/30/2020 00:00	1	0
04/30/2020 01:00	1	0
04/30/2020 02:00	1	0
04/30/2020 03:00	1	0
04/30/2020 04:00	1	0
04/30/2020 05:00	1	0
04/30/2020 06:00	1	0
04/30/2020 07:00	1	2
04/30/2020 08:00	1	2
04/30/2020 09:00	1	2
04/30/2020 10:00	1	2
04/30/2020 11:00	1	2
04/30/2020 12:00	1	2
04/30/2020 13:00	1	2
04/30/2020 14:00	1	2
04/30/2020 15:00	1	2
04/30/2020 16:00	1	2
04/30/2020 17:00	1	2
04/30/2020 18:00	1	2
04/30/2020 19:00	1	2
04/30/2020 20:00	1	2
04/30/2020 21:00	1	2
04/30/2020 22:00	1	2
04/30/2020 23:00	1	2
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/01/2020 00:00	1	2
05/01/2020 01:00	1	2
05/01/2020 02:00	1	2
05/01/2020 03:00	1	2
05/01/2020 04:00	1	2
05/01/2020 05:00	1	2
05/01/2020 06:00	1	2
05/01/2020 07:00	1	2
05/01/2020 08:00	1	2
05/01/2020 09:00	1	2
05/01/2020 10:00	1	2
05/01/2020 11:00	1	2
05/01/2020 12:00	1	2
05/01/2020 13:00	1	2
05/01/2020 14:00	1	2
05/01/2020 15:00	1	2
05/01/2020 16:00	1	2
05/01/2020 17:00	1	2
05/01/2020 18:00	1	2
05/01/2020 19:00	1	2
05/01/2020 20:00	1	2
05/01/2020 21:00	1	2
05/01/2020 22:00	1	2
05/01/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/02/2020 00:00	1	2
05/02/2020 01:00	1	2
05/02/2020 02:00	1	2
05/02/2020 03:00	1	2
05/02/2020 04:00	1	2
05/02/2020 05:00	1	2
05/02/2020 06:00	1	2
05/02/2020 07:00	1	2
05/02/2020 08:00	1	2
05/02/2020 09:00	1	2
05/02/2020 10:00	1	2
05/02/2020 11:00	1	2
05/02/2020 12:00	1	2
05/02/2020 13:00	1	2
05/02/2020 14:00	1	2
05/02/2020 15:00	1	2
05/02/2020 16:00	1	2
05/02/2020 17:00	1	2
05/02/2020 18:00	1	2
05/02/2020 19:00	1	2
05/02/2020 20:00	1	2
05/02/2020 21:00	1	2
05/02/2020 22:00	1	2
05/02/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/03/2020 00:00	1	2
05/03/2020 01:00	1	2
05/03/2020 02:00	1	2
05/03/2020 03:00	1	2
05/03/2020 04:00	1	2
05/03/2020 05:00	1	2
05/03/2020 06:00	1	2
05/03/2020 07:00	1	2
05/03/2020 08:00	1	2
05/03/2020 09:00	1	2
05/03/2020 10:00	1	2
05/03/2020 11:00	1	2
05/03/2020 12:00	1	2
05/03/2020 13:00	1	2
05/03/2020 14:00	1	2
05/03/2020 15:00	1	2
05/03/2020 16:00	1	2
05/03/2020 17:00	1	2
05/03/2020 18:00	1	2
05/03/2020 19:00	1	2
05/03/2020 20:00	1	2
05/03/2020 21:00	1	2
05/03/2020 22:00	1	2
05/03/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/04/2020 00:00	1	2
05/04/2020 01:00	1	2
05/04/2020 02:00	1	2
05/04/2020 03:00	1	2
05/04/2020 04:00	1	2
05/04/2020 05:00	1	2
05/04/2020 06:00	1	2
05/04/2020 07:00	1	2
05/04/2020 08:00	1	2
05/04/2020 09:00	1	2
05/04/2020 10:00	1	2
05/04/2020 11:00	1	2
05/04/2020 12:00	1	2
05/04/2020 13:00	1	2
05/04/2020 14:00	1	2
05/04/2020 15:00	1	2
05/04/2020 16:00	1	2
05/04/2020 17:00	1	2
05/04/2020 18:00	1	2
05/04/2020 19:00	1	2
05/04/2020 20:00	1	2
05/04/2020 21:00	1	2
05/04/2020 22:00	1	2
05/04/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/05/2020 00:00	1	2
05/05/2020 01:00	1	2
05/05/2020 02:00	1	2
05/05/2020 03:00	1	2
05/05/2020 04:00	1	2
05/05/2020 05:00	1	2
05/05/2020 06:00	1	2
05/05/2020 07:00	1	2
05/05/2020 08:00	1	2
05/05/2020 09:00	1	2
05/05/2020 10:00	1	2
05/05/2020 11:00	1	2
05/05/2020 12:00	1	2
05/05/2020 13:00	1	2
05/05/2020 14:00	1	2
05/05/2020 15:00	1	2
05/05/2020 16:00	1	2
05/05/2020 17:00	1	2
05/05/2020 18:00	1	2
05/05/2020 19:00	1	2
05/05/2020 20:00	1	2
05/05/2020 21:00	1	2
05/05/2020 22:00	1	2
05/05/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/06/2020 00:00	1	2
05/06/2020 01:00	1	2
05/06/2020 02:00	1	2
05/06/2020 03:00	1	2
05/06/2020 04:00	1	2
05/06/2020 05:00	1	2
05/06/2020 06:00	1	2
05/06/2020 07:00	1	2
05/06/2020 08:00	1	2
05/06/2020 09:00	1	2
05/06/2020 10:00	1	2
05/06/2020 11:00	1	2
05/06/2020 12:00	1	2
05/06/2020 13:00	1	2
05/06/2020 14:00	1	2
05/06/2020 15:00	1	2
05/06/2020 16:00	1	2
05/06/2020 17:00	1	2
05/06/2020 18:00	1	2
05/06/2020 19:00	1	2
05/06/2020 20:00	1	2
05/06/2020 21:00	1	2
05/06/2020 22:00	1	2
05/06/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/07/2020 00:00	1	2
05/07/2020 01:00	1	2
05/07/2020 02:00	1	2
05/07/2020 03:00	1	2
05/07/2020 04:00	1	2
05/07/2020 05:00	1	2
05/07/2020 06:00	1	2
05/07/2020 07:00	1	2
05/07/2020 08:00	1	2
05/07/2020 09:00	1	2
05/07/2020 10:00	1	2
05/07/2020 11:00	1	2
05/07/2020 12:00	1	2
05/07/2020 13:00	1	2
05/07/2020 14:00	1	2
05/07/2020 15:00	1	2
05/07/2020 16:00	1	2
05/07/2020 17:00	1	2
05/07/2020 18:00	1	2
05/07/2020 19:00	1	2
05/07/2020 20:00	1	2
05/07/2020 21:00	1	2
05/07/2020 22:00	1	2
05/07/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/08/2020 00:00	1	2
05/08/2020 01:00	1	2
05/08/2020 02:00	1	2
05/08/2020 03:00	1	2
05/08/2020 04:00	1	2
05/08/2020 05:00	1	2
05/08/2020 06:00	1	2
05/08/2020 07:00	1	2
05/08/2020 08:00	1	2
05/08/2020 09:00	1	2
05/08/2020 10:00	1	2
05/08/2020 11:00	1	2
05/08/2020 12:00	1	2
05/08/2020 13:00	1	2
05/08/2020 14:00	1	2
05/08/2020 15:00	1	2
05/08/2020 16:00	1	2
05/08/2020 17:00	1	2
05/08/2020 18:00	1	2
05/08/2020 19:00	1	2
05/08/2020 20:00	1	2
05/08/2020 21:00	1	2
05/08/2020 22:00	1	2
05/08/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/09/2020 00:00	1	2
05/09/2020 01:00	1	2
05/09/2020 02:00	1	2
05/09/2020 03:00	1	2
05/09/2020 04:00	1	2
05/09/2020 05:00	1	2
05/09/2020 06:00	1	2
05/09/2020 07:00	1	2
05/09/2020 08:00	1	2
05/09/2020 09:00	1	2
05/09/2020 10:00	1	2
05/09/2020 11:00	1	2
05/09/2020 12:00	1	2
05/09/2020 13:00	1	2
05/09/2020 14:00	1	2
05/09/2020 15:00	1	2
05/09/2020 16:00	1	2
05/09/2020 17:00	1	2
05/09/2020 18:00	1	2
05/09/2020 19:00	1	2
05/09/2020 20:00	1	2
05/09/2020 21:00	1	2
05/09/2020 22:00	1	2
05/09/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/10/2020 00:00	1	2
05/10/2020 01:00	1	2
05/10/2020 02:00	1	2
05/10/2020 03:00	1	2
05/10/2020 04:00	1	2
05/10/2020 05:00	1	2
05/10/2020 06:00	1	2
05/10/2020 07:00	1	2
05/10/2020 08:00	1	2
05/10/2020 09:00	1	2
05/10/2020 10:00	1	2
05/10/2020 11:00	1	2
05/10/2020 12:00	1	2
05/10/2020 13:00	1	2
05/10/2020 14:00	1	2
05/10/2020 15:00	1	2
05/10/2020 16:00	1	2
05/10/2020 17:00	1	2
05/10/2020 18:00	1	2
05/10/2020 19:00	1	2
05/10/2020 20:00	1	2
05/10/2020 21:00	1	2
05/10/2020 22:00	1	2
05/10/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/11/2020 00:00	1	2
05/11/2020 01:00	1	2
05/11/2020 02:00	1	2
05/11/2020 03:00	1	2
05/11/2020 04:00	1	2
05/11/2020 05:00	1	2
05/11/2020 06:00	1	2
05/11/2020 07:00	1	2
05/11/2020 08:00	1	2
05/11/2020 09:00	1	2
05/11/2020 10:00	1	2
05/11/2020 11:00	1	2
05/11/2020 12:00	1	2
05/11/2020 13:00	1	2
05/11/2020 14:00	1	2
05/11/2020 15:00	1	2
05/11/2020 16:00	1	2
05/11/2020 17:00	1	2
05/11/2020 18:00	1	2
05/11/2020 19:00	1	2
05/11/2020 20:00	1	2
05/11/2020 21:00	1	2
05/11/2020 22:00	1	2
05/11/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/12/2020 00:00	1	2
05/12/2020 01:00	1	2
05/12/2020 02:00	1	2
05/12/2020 03:00	1	2
05/12/2020 04:00	1	2
05/12/2020 05:00	1	2
05/12/2020 06:00	1	2
05/12/2020 07:00	1	2
05/12/2020 08:00	1	2
05/12/2020 09:00	1	2
05/12/2020 10:00	1	2
05/12/2020 11:00	1	2
05/12/2020 12:00	1	2
05/12/2020 13:00	1	2
05/12/2020 14:00	1	2
05/12/2020 15:00	1	2
05/12/2020 16:00	1	2
05/12/2020 17:00	1	2
05/12/2020 18:00	1	2
05/12/2020 19:00	1	2
05/12/2020 20:00	1	2
05/12/2020 21:00	1	2
05/12/2020 22:00	1	2
05/12/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/13/2020 00:00	1	2
05/13/2020 01:00	1	2
05/13/2020 02:00	1	2
05/13/2020 03:00	1	2
05/13/2020 04:00	1	2
05/13/2020 05:00	1	2
05/13/2020 06:00	1	2
05/13/2020 07:00	1	2
05/13/2020 08:00	1	2
05/13/2020 09:00	1	2
05/13/2020 10:00	1	2
05/13/2020 11:00	1	2
05/13/2020 12:00	1	2
05/13/2020 13:00	1	2
05/13/2020 14:00	1	2
05/13/2020 15:00	1	2
05/13/2020 16:00	1	2
05/13/2020 17:00	1	2
05/13/2020 18:00	1	2
05/13/2020 19:00	1	2
05/13/2020 20:00	1	2
05/13/2020 21:00	1	2
05/13/2020 22:00	1	2
05/13/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/14/2020 00:00	1	2
05/14/2020 01:00	1	2
05/14/2020 02:00	1	2
05/14/2020 03:00	1	2
05/14/2020 04:00	1	2
05/14/2020 05:00	1	2
05/14/2020 06:00	1	2
05/14/2020 07:00	1	2
05/14/2020 08:00	1	2
05/14/2020 09:00	1	2
05/14/2020 10:00	1	2
05/14/2020 11:00	1	2
05/14/2020 12:00	1	2
05/14/2020 13:00	1	2
05/14/2020 14:00	1	2
05/14/2020 15:00	1	2
05/14/2020 16:00	1	2
05/14/2020 17:00	1	2
05/14/2020 18:00	1	2
05/14/2020 19:00	1	2
05/14/2020 20:00	1	2
05/14/2020 21:00	1	2
05/14/2020 22:00	1	2
05/14/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/15/2020 00:00	1	2
05/15/2020 01:00	1	2
05/15/2020 02:00	1	2
05/15/2020 03:00	1	2
05/15/2020 04:00	1	2
05/15/2020 05:00	1	2
05/15/2020 06:00	1	2
05/15/2020 07:00	1	2
05/15/2020 08:00	1	2
05/15/2020 09:00	1	2
05/15/2020 10:00	1	2
05/15/2020 11:00	1	2
05/15/2020 12:00	1	2
05/15/2020 13:00	1	2
05/15/2020 14:00	1	2
05/15/2020 15:00	1	2
05/15/2020 16:00	1	2
05/15/2020 17:00	1	2
05/15/2020 18:00	1	2
05/15/2020 19:00	1	2
05/15/2020 20:00	1	2
05/15/2020 21:00	1	2
05/15/2020 22:00	1	2
05/15/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/16/2020 00:00	1	2
05/16/2020 01:00	1	2
05/16/2020 02:00	1	2
05/16/2020 03:00	1	2
05/16/2020 04:00	1	2
05/16/2020 05:00	1	2
05/16/2020 06:00	1	2
05/16/2020 07:00	1	2
05/16/2020 08:00	1	2
05/16/2020 09:00	1	2
05/16/2020 10:00	1	2
05/16/2020 11:00	1	2
05/16/2020 12:00	1	2
05/16/2020 13:00	1	2
05/16/2020 14:00	1	2
05/16/2020 15:00	1	2
05/16/2020 16:00	1	2
05/16/2020 17:00	1	2
05/16/2020 18:00	1	2
05/16/2020 19:00	1	2
05/16/2020 20:00	1	2
05/16/2020 21:00	1	2
05/16/2020 22:00	1	2
05/16/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/17/2020 00:00	1	2
05/17/2020 01:00	1	2
05/17/2020 02:00	1	2
05/17/2020 03:00	1	2
05/17/2020 04:00	1	2
05/17/2020 05:00	1	2
05/17/2020 06:00	1	2
05/17/2020 07:00	1	2
05/17/2020 08:00	1	2
05/17/2020 09:00	1	2
05/17/2020 10:00	1	2
05/17/2020 11:00	1	2
05/17/2020 12:00	1	2
05/17/2020 13:00	1	2
05/17/2020 14:00	1	2
05/17/2020 15:00	1	2
05/17/2020 16:00	1	2
05/17/2020 17:00	1	2
05/17/2020 18:00	1	2
05/17/2020 19:00	1	2
05/17/2020 20:00	1	2
05/17/2020 21:00	1	2
05/17/2020 22:00	1	2
05/17/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/18/2020 00:00	1	2
05/18/2020 01:00	1	2
05/18/2020 02:00	1	2
05/18/2020 03:00	1	2
05/18/2020 04:00	1	2
05/18/2020 05:00	1	2
05/18/2020 06:00	1	2
05/18/2020 07:00	1	2
05/18/2020 08:00	1	2
05/18/2020 09:00	1	2
05/18/2020 10:00	1	2
05/18/2020 11:00	1	2
05/18/2020 12:00	1	2
05/18/2020 13:00	1	2
05/18/2020 14:00	1	2
05/18/2020 15:00	1	2
05/18/2020 16:00	1	2
05/18/2020 17:00	1	2
05/18/2020 18:00	1	2
05/18/2020 19:00	1	2
05/18/2020 20:00	1	2
05/18/2020 21:00	1	2
05/18/2020 22:00	1	2
05/18/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/19/2020 00:00	1	2
05/19/2020 01:00	1	2
05/19/2020 02:00	1	2
05/19/2020 03:00	1	2
05/19/2020 04:00	1	2
05/19/2020 05:00	1	2
05/19/2020 06:00	1	2
05/19/2020 07:00	1	2
05/19/2020 08:00	1	2
05/19/2020 09:00	1	2
05/19/2020 10:00	1	2
05/19/2020 11:00	1	2
05/19/2020 12:00	1	2
05/19/2020 13:00	1	2
05/19/2020 14:00	1	2
05/19/2020 15:00	1	2
05/19/2020 16:00	1	2
05/19/2020 17:00	1	2
05/19/2020 18:00	1	2
05/19/2020 19:00	1	2
05/19/2020 20:00	1	2
05/19/2020 21:00	1	2
05/19/2020 22:00	1	2
05/19/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/20/2020 00:00	1	2
05/20/2020 01:00	1	2
05/20/2020 02:00	1	2
05/20/2020 03:00	1	2
05/20/2020 04:00	1	2
05/20/2020 05:00	1	2
05/20/2020 06:00	1	2
05/20/2020 07:00	1	2
05/20/2020 08:00	1	2
05/20/2020 09:00	1	2
05/20/2020 10:00	1	2
05/20/2020 11:00	1	2
05/20/2020 12:00	1	2
05/20/2020 13:00	1	2
05/20/2020 14:00	1	2
05/20/2020 15:00	1	2
05/20/2020 16:00	1	2
05/20/2020 17:00	1	2
05/20/2020 18:00	1	2
05/20/2020 19:00	1	2
05/20/2020 20:00	1	2
05/20/2020 21:00	1	2
05/20/2020 22:00	1	2
05/20/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/21/2020 00:00	1	2
05/21/2020 01:00	1	2
05/21/2020 02:00	1	2
05/21/2020 03:00	1	2
05/21/2020 04:00	1	2
05/21/2020 05:00	1	2
05/21/2020 06:00	1	2
05/21/2020 07:00	1	2
05/21/2020 08:00	1	2
05/21/2020 09:00	1	2
05/21/2020 10:00	1	2
05/21/2020 11:00	1	2
05/21/2020 12:00	1	2
05/21/2020 13:00	1	2
05/21/2020 14:00	1	2
05/21/2020 15:00	1	2
05/21/2020 16:00	1	2
05/21/2020 17:00	1	2
05/21/2020 18:00	1	2
05/21/2020 19:00	1	2
05/21/2020 20:00	1	2
05/21/2020 21:00	1	2
05/21/2020 22:00	1	2
05/21/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/22/2020 00:00	1	2
05/22/2020 01:00	1	2
05/22/2020 02:00	1	2
05/22/2020 03:00	1	2
05/22/2020 04:00	1	2
05/22/2020 05:00	1	2
05/22/2020 06:00	1	2
05/22/2020 07:00	1	2
05/22/2020 08:00	1	2
05/22/2020 09:00	1	2
05/22/2020 10:00	1	2
05/22/2020 11:00	1	2
05/22/2020 12:00	1	2
05/22/2020 13:00	1	2
05/22/2020 14:00	1	2
05/22/2020 15:00	1	2
05/22/2020 16:00	1	2
05/22/2020 17:00	1	2
05/22/2020 18:00	1	2
05/22/2020 19:00	1	2
05/22/2020 20:00	1	2
05/22/2020 21:00	1	2
05/22/2020 22:00	1	2
05/22/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/23/2020 00:00	1	2
05/23/2020 01:00	1	2
05/23/2020 02:00	1	2
05/23/2020 03:00	1	2
05/23/2020 04:00	1	2
05/23/2020 05:00	1	2
05/23/2020 06:00	1	2
05/23/2020 07:00	1	2
05/23/2020 08:00	1	2
05/23/2020 09:00	1	2
05/23/2020 10:00	1	2
05/23/2020 11:00	1	2
05/23/2020 12:00	1	2
05/23/2020 13:00	1	2
05/23/2020 14:00	1	2
05/23/2020 15:00	1	2
05/23/2020 16:00	1	2
05/23/2020 17:00	1	2
05/23/2020 18:00	1	2
05/23/2020 19:00	1	2
05/23/2020 20:00	1	2
05/23/2020 21:00	1	2
05/23/2020 22:00	1	2
05/23/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/24/2020 00:00	1	2
05/24/2020 01:00	1	2
05/24/2020 02:00	1	2
05/24/2020 03:00	1	2
05/24/2020 04:00	1	2
05/24/2020 05:00	1	2
05/24/2020 06:00	1	2
05/24/2020 07:00	1	2
05/24/2020 08:00	1	2
05/24/2020 09:00	1	2
05/24/2020 10:00	1	2
05/24/2020 11:00	1	2
05/24/2020 12:00	1	2
05/24/2020 13:00	1	2
05/24/2020 14:00	1	2
05/24/2020 15:00	1	2
05/24/2020 16:00	1	2
05/24/2020 17:00	1	2
05/24/2020 18:00	1	2
05/24/2020 19:00	1	2
05/24/2020 20:00	1	2
05/24/2020 21:00	1	2
05/24/2020 22:00	1	2
05/24/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/25/2020 00:00	1	2
05/25/2020 01:00	1	2
05/25/2020 02:00	1	2
05/25/2020 03:00	1	2
05/25/2020 04:00	1	2
05/25/2020 05:00	1	2
05/25/2020 06:00	1	2
05/25/2020 07:00	1	2
05/25/2020 08:00	1	2
05/25/2020 09:00	1	2
05/25/2020 10:00	1	2
05/25/2020 11:00	1	2
05/25/2020 12:00	1	2
05/25/2020 13:00	1	2
05/25/2020 14:00	1	2
05/25/2020 15:00	1	2
05/25/2020 16:00	1	2
05/25/2020 17:00	1	2
05/25/2020 18:00	1	2
05/25/2020 19:00	1	2
05/25/2020 20:00	1	2
05/25/2020 21:00	1	2
05/25/2020 22:00	1	2
05/25/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/26/2020 00:00	1	2
05/26/2020 01:00	1	2
05/26/2020 02:00	1	2
05/26/2020 03:00	1	2
05/26/2020 04:00	1	2
05/26/2020 05:00	1	2
05/26/2020 06:00	1	2
05/26/2020 07:00	1	2
05/26/2020 08:00	1	2
05/26/2020 09:00	1	2
05/26/2020 10:00	13	2
05/26/2020 11:00	20	2
05/26/2020 12:00	30	2
05/26/2020 13:00	33	2
05/26/2020 14:00	23	2
05/26/2020 15:00	19	2
05/26/2020 16:00	19	2
05/26/2020 17:00	19	2
05/26/2020 18:00	19	2
05/26/2020 19:00	19	2
05/26/2020 20:00	19	2
05/26/2020 21:00	19	2
05/26/2020 22:00	19	2
05/26/2020 23:00	19	2
Average/Sum#:	13	2
Minimum:	1	2
Maximum:	33	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/27/2020 00:00	19	2
05/27/2020 01:00	19	2
05/27/2020 02:00	19	2
05/27/2020 03:00	19	2
05/27/2020 04:00	19	2
05/27/2020 05:00	19	2
05/27/2020 06:00	19	2
05/27/2020 07:00	19	2
05/27/2020 08:00	19	2
05/27/2020 09:00	19	0
05/27/2020 10:00	19	0
05/27/2020 11:00	19	0
05/27/2020 12:00	19	0
05/27/2020 13:00	19	0
05/27/2020 14:00	19	0
05/27/2020 15:00	19	0
05/27/2020 16:00	19	0
05/27/2020 17:00	19	0
05/27/2020 18:00	19	0
05/27/2020 19:00	19	0
05/27/2020 20:00	19	0
05/27/2020 21:00	19	0
05/27/2020 22:00	19	0
05/27/2020 23:00	19	0
Average/Sum#:	19	2
Minimum:	19	2
Maximum:	19	2
%SI	0.00	62.50

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/28/2020 00:00	19	0
05/28/2020 01:00	19	0
05/28/2020 02:00	19	0
05/28/2020 03:00	19	0
05/28/2020 04:00	19	0
05/28/2020 05:00	19	0
05/28/2020 06:00	19	0
05/28/2020 07:00	19	0
05/28/2020 08:00	19	0
05/28/2020 09:00	19	0
05/28/2020 10:00	19	0
05/28/2020 11:00	19	0
05/28/2020 12:00	11	0
05/28/2020 13:00	0	0
05/28/2020 14:00	0	0
05/28/2020 15:00	0	0
05/28/2020 16:00	0	0
05/28/2020 17:00	0	0
05/28/2020 18:00	0	9
05/28/2020 19:00	1	15
05/28/2020 20:00	1	15
05/28/2020 21:00	1	14
05/28/2020 22:00	1	9
05/28/2020 23:00	1	1
Average/Sum#:	14	11
Minimum:	1	1
Maximum:	19	15
%SI	25.00	75.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/29/2020 00:00	1	1
05/29/2020 01:00	1	1
05/29/2020 02:00	1	1
05/29/2020 03:00	1	1
05/29/2020 04:00	1	1
05/29/2020 05:00	1	1
05/29/2020 06:00	1	1
05/29/2020 07:00	1	1
05/29/2020 08:00	1	1
05/29/2020 09:00	1	1
05/29/2020 10:00	1	1
05/29/2020 11:00	1	1
05/29/2020 12:00	1	1
05/29/2020 13:00	1	1
05/29/2020 14:00	1	1
05/29/2020 15:00	1	1
05/29/2020 16:00	1	1
05/29/2020 17:00	1	1
05/29/2020 18:00	1	1
05/29/2020 19:00	1	1
05/29/2020 20:00	1	13
05/29/2020 21:00	1	19
05/29/2020 22:00	1	22
05/29/2020 23:00	1	22
Average/Sum#:	1	4
Minimum:	1	1
Maximum:	1	22
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/30/2020 00:00	1	9
05/30/2020 01:00	1	3
05/30/2020 02:00	1	0
05/30/2020 03:00	1	0
05/30/2020 04:00	1	0
05/30/2020 05:00	1	0
05/30/2020 06:00	1	0
05/30/2020 07:00	1	0
05/30/2020 08:00	1	1
05/30/2020 09:00	1	1
05/30/2020 10:00	1	1
05/30/2020 11:00	1	1
05/30/2020 12:00	1	1
05/30/2020 13:00	1	1
05/30/2020 14:00	1	8
05/30/2020 15:00	1	8
05/30/2020 16:00	1	7
05/30/2020 17:00	1	9
05/30/2020 18:00	1	0
05/30/2020 19:00	1	0
05/30/2020 20:00	1	0
05/30/2020 21:00	1	0
05/30/2020 22:00	1	0
05/30/2020 23:00	1	0
Average/Sum#:	1	3
Minimum:	1	0
Maximum:	1	9
%SI	0.00	25.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
05/31/2020 00:00	1	0
05/31/2020 01:00	1	0
05/31/2020 02:00	1	0
05/31/2020 03:00	1	0
05/31/2020 04:00	1	0
05/31/2020 05:00	1	0
05/31/2020 06:00	1	0
05/31/2020 07:00	1	0
05/31/2020 08:00	1	0
05/31/2020 09:00	1	0
05/31/2020 10:00	1	0
05/31/2020 11:00	1	0
05/31/2020 12:00	1	0
05/31/2020 13:00	1	0
05/31/2020 14:00	1	15
05/31/2020 15:00	1	19
05/31/2020 16:00	1	19
05/31/2020 17:00	1	14
05/31/2020 18:00	1	3
05/31/2020 19:00	1	0
05/31/2020 20:00	1	1
05/31/2020 21:00	1	1
05/31/2020 22:00	1	1
05/31/2020 23:00	1	1
Average/Sum#:	1	3
Minimum:	1	0
Maximum:	1	19
%SI	0.00	4.17

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/01/2020 00:00	1	0
06/01/2020 01:00	1	0
06/01/2020 02:00	1	1
06/01/2020 03:00	1	1
06/01/2020 04:00	1	1
06/01/2020 05:00	1	1
06/01/2020 06:00	1	1
06/01/2020 07:00	1	1
06/01/2020 08:00	1	1
06/01/2020 09:00	1	1
06/01/2020 10:00	1	1
06/01/2020 11:00	1	1
06/01/2020 12:00	10	1
06/01/2020 13:00	25	1
06/01/2020 14:00	27	1
06/01/2020 15:00	27	1
06/01/2020 16:00	17	1
06/01/2020 17:00	3	1
06/01/2020 18:00	1	1
06/01/2020 19:00	1	1
06/01/2020 20:00	1	1
06/01/2020 21:00	1	1
06/01/2020 22:00	1	1
06/01/2020 23:00	1	1
Average/Sum#:	5	1
Minimum:	1	0
Maximum:	27	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/02/2020 00:00	1	1
06/02/2020 01:00	1	1
06/02/2020 02:00	1	1
06/02/2020 03:00	1	1
06/02/2020 04:00	1	1
06/02/2020 05:00	1	1
06/02/2020 06:00	1	1
06/02/2020 07:00	1	1
06/02/2020 08:00	1	1
06/02/2020 09:00	1	1
06/02/2020 10:00	1	1
06/02/2020 11:00	1	1
06/02/2020 12:00	1	1
06/02/2020 13:00	1	1
06/02/2020 14:00	1	1
06/02/2020 15:00	1	1
06/02/2020 16:00	1	1
06/02/2020 17:00	1	1
06/02/2020 18:00	1	1
06/02/2020 19:00	1	1
06/02/2020 20:00	1	1
06/02/2020 21:00	1	1
06/02/2020 22:00	1	1
06/02/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/03/2020 00:00	1	1
06/03/2020 01:00	1	1
06/03/2020 02:00	1	1
06/03/2020 03:00	1	1
06/03/2020 04:00	1	1
06/03/2020 05:00	1	0
06/03/2020 06:00	1	0
06/03/2020 07:00	1	0
06/03/2020 08:00	1	0
06/03/2020 09:00	1	1
06/03/2020 10:00	1	1
06/03/2020 11:00	1	1
06/03/2020 12:00	1	1
06/03/2020 13:00	1	1
06/03/2020 14:00	1	1
06/03/2020 15:00	1	1
06/03/2020 16:00	1	1
06/03/2020 17:00	1	1
06/03/2020 18:00	1	1
06/03/2020 19:00	1	1
06/03/2020 20:00	1	1
06/03/2020 21:00	1	1
06/03/2020 22:00	1	1
06/03/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/04/2020 00:00	1	1
06/04/2020 01:00	1	1
06/04/2020 02:00	1	1
06/04/2020 03:00	1	1
06/04/2020 04:00	1	1
06/04/2020 05:00	1	1
06/04/2020 06:00	2	1
06/04/2020 07:00	5	1
06/04/2020 08:00	5	1
06/04/2020 09:00	4	1
06/04/2020 10:00	3	11
06/04/2020 11:00	0	14
06/04/2020 12:00	1	14
06/04/2020 13:00	1	14
06/04/2020 14:00	1	4
06/04/2020 15:00	1	1
06/04/2020 16:00	1	1
06/04/2020 17:00	1	1
06/04/2020 18:00	1	1
06/04/2020 19:00	1	1
06/04/2020 20:00	1	1
06/04/2020 21:00	1	1
06/04/2020 22:00	1	1
06/04/2020 23:00	1	1
Average/Sum#:	2	3
Minimum:	0	1
Maximum:	5	14
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/05/2020 00:00	1	1
06/05/2020 01:00	1	1
06/05/2020 02:00	1	1
06/05/2020 03:00	1	1
06/05/2020 04:00	1	1
06/05/2020 05:00	1	1
06/05/2020 06:00	1	1
06/05/2020 07:00	1	1
06/05/2020 08:00	1	1
06/05/2020 09:00	1	1
06/05/2020 10:00	1	1
06/05/2020 11:00	1	1
06/05/2020 12:00	1	1
06/05/2020 13:00	1	1
06/05/2020 14:00	1	1
06/05/2020 15:00	1	1
06/05/2020 16:00	1	1
06/05/2020 17:00	1	1
06/05/2020 18:00	1	1
06/05/2020 19:00	1	1
06/05/2020 20:00	1	1
06/05/2020 21:00	1	1
06/05/2020 22:00	1	1
06/05/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/06/2020 00:00	1	1
06/06/2020 01:00	1	1
06/06/2020 02:00	1	1
06/06/2020 03:00	1	1
06/06/2020 04:00	1	1
06/06/2020 05:00	1	1
06/06/2020 06:00	1	1
06/06/2020 07:00	1	1
06/06/2020 08:00	1	1
06/06/2020 09:00	1	1
06/06/2020 10:00	1	1
06/06/2020 11:00	1	1
06/06/2020 12:00	1	1
06/06/2020 13:00	1	1
06/06/2020 14:00	1	1
06/06/2020 15:00	1	1
06/06/2020 16:00	1	1
06/06/2020 17:00	1	1
06/06/2020 18:00	1	1
06/06/2020 19:00	1	1
06/06/2020 20:00	1	1
06/06/2020 21:00	1	1
06/06/2020 22:00	1	1
06/06/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/07/2020 00:00	1	1
06/07/2020 01:00	1	1
06/07/2020 02:00	1	1
06/07/2020 03:00	1	1
06/07/2020 04:00	1	1
06/07/2020 05:00	1	1
06/07/2020 06:00	1	1
06/07/2020 07:00	1	1
06/07/2020 08:00	1	1
06/07/2020 09:00	1	1
06/07/2020 10:00	1	1
06/07/2020 11:00	1	1
06/07/2020 12:00	1	1
06/07/2020 13:00	1	1
06/07/2020 14:00	1	1
06/07/2020 15:00	1	1
06/07/2020 16:00	1	1
06/07/2020 17:00	1	1
06/07/2020 18:00	1	1
06/07/2020 19:00	1	1
06/07/2020 20:00	1	1
06/07/2020 21:00	1	1
06/07/2020 22:00	1	1
06/07/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/08/2020 00:00	1	1
06/08/2020 01:00	1	1
06/08/2020 02:00	1	1
06/08/2020 03:00	1	1
06/08/2020 04:00	1	1
06/08/2020 05:00	1	1
06/08/2020 06:00	1	1
06/08/2020 07:00	1	1
06/08/2020 08:00	1	1
06/08/2020 09:00	1	13
06/08/2020 10:00	1	22
06/08/2020 11:00	1	26
06/08/2020 12:00	1	29
06/08/2020 13:00	1	17
06/08/2020 14:00	1	8
06/08/2020 15:00	17	4
06/08/2020 16:00	27	0
06/08/2020 17:00	29	1
06/08/2020 18:00	30	1
06/08/2020 19:00	14	1
06/08/2020 20:00	4	1
06/08/2020 21:00	2	1
06/08/2020 22:00	1	1
06/08/2020 23:00	1	1
Average/Sum#:	6	6
Minimum:	1	0
Maximum:	30	29
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/09/2020 00:00	1	1
06/09/2020 01:00	1	1
06/09/2020 02:00	1	1
06/09/2020 03:00	1	1
06/09/2020 04:00	1	1
06/09/2020 05:00	1	1
06/09/2020 06:00	1	1
06/09/2020 07:00	1	1
06/09/2020 08:00	1	10
06/09/2020 09:00	1	14
06/09/2020 10:00	1	18
06/09/2020 11:00	1	18
06/09/2020 12:00	12	8
06/09/2020 13:00	19	5
06/09/2020 14:00	21	0
06/09/2020 15:00	20	1
06/09/2020 16:00	9	1
06/09/2020 17:00	2	1
06/09/2020 18:00	1	1
06/09/2020 19:00	1	1
06/09/2020 20:00	1	1
06/09/2020 21:00	1	1
06/09/2020 22:00	1	1
06/09/2020 23:00	1	1
Average/Sum#:	4	4
Minimum:	1	0
Maximum:	21	18
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/10/2020 00:00	1	1
06/10/2020 01:00	1	1
06/10/2020 02:00	1	1
06/10/2020 03:00	1	1
06/10/2020 04:00	1	1
06/10/2020 05:00	1	1
06/10/2020 06:00	1	1
06/10/2020 07:00	1	9
06/10/2020 08:00	1	12
06/10/2020 09:00	1	12
06/10/2020 10:00	8	12
06/10/2020 11:00	11	4
06/10/2020 12:00	11	0
06/10/2020 13:00	11	1
06/10/2020 14:00	4	1
06/10/2020 15:00	1	1
06/10/2020 16:00	1	1
06/10/2020 17:00	1	1
06/10/2020 18:00	1	1
06/10/2020 19:00	1	1
06/10/2020 20:00	1	1
06/10/2020 21:00	1	1
06/10/2020 22:00	1	1
06/10/2020 23:00	1	1
Average/Sum#:	3	3
Minimum:	1	0
Maximum:	11	12
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/11/2020 00:00	1	1
06/11/2020 01:00	1	1
06/11/2020 02:00	1	1
06/11/2020 03:00	1	1
06/11/2020 04:00	1	1
06/11/2020 05:00	1	1
06/11/2020 06:00	1	1
06/11/2020 07:00	1	1
06/11/2020 08:00	1	1
06/11/2020 09:00	1	1
06/11/2020 10:00	1	1
06/11/2020 11:00	1	1
06/11/2020 12:00	1	1
06/11/2020 13:00	1	1
06/11/2020 14:00	1	1
06/11/2020 15:00	1	1
06/11/2020 16:00	1	1
06/11/2020 17:00	1	1
06/11/2020 18:00	1	1
06/11/2020 19:00	1	1
06/11/2020 20:00	1	1
06/11/2020 21:00	1	1
06/11/2020 22:00	1	1
06/11/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/12/2020 00:00	1	1
06/12/2020 01:00	1	1
06/12/2020 02:00	1	1
06/12/2020 03:00	1	1
06/12/2020 04:00	1	1
06/12/2020 05:00	1	1
06/12/2020 06:00	1	1
06/12/2020 07:00	1	1
06/12/2020 08:00	1	1
06/12/2020 09:00	1	1
06/12/2020 10:00	1	1
06/12/2020 11:00	1	1
06/12/2020 12:00	1	1
06/12/2020 13:00	1	1
06/12/2020 14:00	1	1
06/12/2020 15:00	1	1
06/12/2020 16:00	1	1
06/12/2020 17:00	1	1
06/12/2020 18:00	1	1
06/12/2020 19:00	1	1
06/12/2020 20:00	1	1
06/12/2020 21:00	1	1
06/12/2020 22:00	1	1
06/12/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/13/2020 00:00	1	1
06/13/2020 01:00	1	1
06/13/2020 02:00	1	1
06/13/2020 03:00	1	1
06/13/2020 04:00	1	1
06/13/2020 05:00	1	1
06/13/2020 06:00	1	1
06/13/2020 07:00	1	1
06/13/2020 08:00	1	1
06/13/2020 09:00	1	1
06/13/2020 10:00	1	1
06/13/2020 11:00	1	1
06/13/2020 12:00	1	1
06/13/2020 13:00	1	1
06/13/2020 14:00	1	1
06/13/2020 15:00	1	1
06/13/2020 16:00	1	1
06/13/2020 17:00	1	1
06/13/2020 18:00	1	1
06/13/2020 19:00	1	1
06/13/2020 20:00	1	1
06/13/2020 21:00	1	1
06/13/2020 22:00	1	1
06/13/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/14/2020 00:00	1	1
06/14/2020 01:00	1	1
06/14/2020 02:00	1	1
06/14/2020 03:00	1	1
06/14/2020 04:00	1	1
06/14/2020 05:00	1	1
06/14/2020 06:00	1	1
06/14/2020 07:00	1	1
06/14/2020 08:00	1	1
06/14/2020 09:00	1	1
06/14/2020 10:00	1	1
06/14/2020 11:00	1	1
06/14/2020 12:00	1	14
06/14/2020 13:00	1	20
06/14/2020 14:00	1	25
06/14/2020 15:00	1	24
06/14/2020 16:00	1	11
06/14/2020 17:00	1	5
06/14/2020 18:00	1	1
06/14/2020 19:00	1	1
06/14/2020 20:00	1	1
06/14/2020 21:00	1	1
06/14/2020 22:00	1	1
06/14/2020 23:00	1	2
Average/Sum#:	1	5
Minimum:	1	1
Maximum:	1	25
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/15/2020 00:00	1	2
06/15/2020 01:00	1	2
06/15/2020 02:00	1	2
06/15/2020 03:00	1	2
06/15/2020 04:00	1	2
06/15/2020 05:00	1	2
06/15/2020 06:00	1	2
06/15/2020 07:00	1	2
06/15/2020 08:00	1	2
06/15/2020 09:00	1	2
06/15/2020 10:00	1	2
06/15/2020 11:00	1	2
06/15/2020 12:00	1	2
06/15/2020 13:00	1	2
06/15/2020 14:00	1	2
06/15/2020 15:00	1	2
06/15/2020 16:00	1	2
06/15/2020 17:00	1	2
06/15/2020 18:00	1	2
06/15/2020 19:00	1	2
06/15/2020 20:00	1	2
06/15/2020 21:00	1	2
06/15/2020 22:00	1	2
06/15/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/16/2020 00:00	1	2
06/16/2020 01:00	1	2
06/16/2020 02:00	1	2
06/16/2020 03:00	1	2
06/16/2020 04:00	1	2
06/16/2020 05:00	1	2
06/16/2020 06:00	1	2
06/16/2020 07:00	1	2
06/16/2020 08:00	1	2
06/16/2020 09:00	1	2
06/16/2020 10:00	1	2
06/16/2020 11:00	1	2
06/16/2020 12:00	1	2
06/16/2020 13:00	1	2
06/16/2020 14:00	1	2
06/16/2020 15:00	1	2
06/16/2020 16:00	1	2
06/16/2020 17:00	1	2
06/16/2020 18:00	1	2
06/16/2020 19:00	1	2
06/16/2020 20:00	1	2
06/16/2020 21:00	1	2
06/16/2020 22:00	1	2
06/16/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/17/2020 00:00	1	2
06/17/2020 01:00	1	2
06/17/2020 02:00	1	2
06/17/2020 03:00	1	2
06/17/2020 04:00	1	2
06/17/2020 05:00	1	2
06/17/2020 06:00	1	2
06/17/2020 07:00	1	2
06/17/2020 08:00	1	2
06/17/2020 09:00	1	15
06/17/2020 10:00	1	19
06/17/2020 11:00	1	22
06/17/2020 12:00	14	21
06/17/2020 13:00	24	7
06/17/2020 14:00	26	3
06/17/2020 15:00	27	1
06/17/2020 16:00	14	1
06/17/2020 17:00	4	1
06/17/2020 18:00	2	1
06/17/2020 19:00	1	1
06/17/2020 20:00	1	1
06/17/2020 21:00	1	1
06/17/2020 22:00	1	1
06/17/2020 23:00	1	2
Average/Sum#:	5	5
Minimum:	1	1
Maximum:	27	22
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/18/2020 00:00	1	2
06/18/2020 01:00	1	2
06/18/2020 02:00	1	2
06/18/2020 03:00	1	2
06/18/2020 04:00	1	2
06/18/2020 05:00	1	2
06/18/2020 06:00	1	2
06/18/2020 07:00	1	11
06/18/2020 08:00	1	15
06/18/2020 09:00	1	15
06/18/2020 10:00	1	15
06/18/2020 11:00	13	5
06/18/2020 12:00	16	1
06/18/2020 13:00	16	1
06/18/2020 14:00	15	1
06/18/2020 15:00	3	1
06/18/2020 16:00	1	1
06/18/2020 17:00	1	1
06/18/2020 18:00	1	1
06/18/2020 19:00	1	1
06/18/2020 20:00	1	1
06/18/2020 21:00	1	1
06/18/2020 22:00	1	1
06/18/2020 23:00	1	2
Average/Sum#:	3	4
Minimum:	1	1
Maximum:	16	15
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/19/2020 00:00	1	2
06/19/2020 01:00	1	2
06/19/2020 02:00	1	2
06/19/2020 03:00	1	2
06/19/2020 04:00	1	2
06/19/2020 05:00	1	2
06/19/2020 06:00	1	2
06/19/2020 07:00	1	2
06/19/2020 08:00	1	2
06/19/2020 09:00	1	2
06/19/2020 10:00	1	2
06/19/2020 11:00	1	2
06/19/2020 12:00	1	2
06/19/2020 13:00	1	2
06/19/2020 14:00	1	2
06/19/2020 15:00	1	2
06/19/2020 16:00	1	2
06/19/2020 17:00	1	2
06/19/2020 18:00	1	2
06/19/2020 19:00	1	2
06/19/2020 20:00	1	2
06/19/2020 21:00	1	2
06/19/2020 22:00	1	2
06/19/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/20/2020 00:00	1	2
06/20/2020 01:00	1	2
06/20/2020 02:00	1	2
06/20/2020 03:00	1	2
06/20/2020 04:00	1	2
06/20/2020 05:00	1	2
06/20/2020 06:00	1	2
06/20/2020 07:00	1	2
06/20/2020 08:00	1	2
06/20/2020 09:00	1	2
06/20/2020 10:00	1	2
06/20/2020 11:00	1	2
06/20/2020 12:00	1	2
06/20/2020 13:00	1	2
06/20/2020 14:00	1	2
06/20/2020 15:00	1	2
06/20/2020 16:00	1	2
06/20/2020 17:00	1	2
06/20/2020 18:00	1	2
06/20/2020 19:00	1	2
06/20/2020 20:00	1	12
06/20/2020 21:00	1	14
06/20/2020 22:00	1	15
06/20/2020 23:00	1	14
Average/Sum#:	1	4
Minimum:	1	2
Maximum:	1	15
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/21/2020 00:00	1	4
06/21/2020 01:00	1	2
06/21/2020 02:00	1	1
06/21/2020 03:00	1	1
06/21/2020 04:00	1	1
06/21/2020 05:00	1	1
06/21/2020 06:00	1	1
06/21/2020 07:00	1	1
06/21/2020 08:00	1	1
06/21/2020 09:00	1	1
06/21/2020 10:00	1	1
06/21/2020 11:00	1	1
06/21/2020 12:00	1	1
06/21/2020 13:00	1	1
06/21/2020 14:00	1	1
06/21/2020 15:00	1	1
06/21/2020 16:00	1	1
06/21/2020 17:00	1	1
06/21/2020 18:00	1	1
06/21/2020 19:00	1	1
06/21/2020 20:00	1	1
06/21/2020 21:00	1	1
06/21/2020 22:00	1	1
06/21/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	4
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/22/2020 00:00	1	1
06/22/2020 01:00	1	1
06/22/2020 02:00	1	1
06/22/2020 03:00	1	1
06/22/2020 04:00	1	1
06/22/2020 05:00	1	1
06/22/2020 06:00	1	1
06/22/2020 07:00	1	1
06/22/2020 08:00	1	1
06/22/2020 09:00	13	1
06/22/2020 10:00	23	1
06/22/2020 11:00	27	1
06/22/2020 12:00	27	1
06/22/2020 13:00	15	1
06/22/2020 14:00	5	1
06/22/2020 15:00	1	1
06/22/2020 16:00	1	1
06/22/2020 17:00	1	1
06/22/2020 18:00	1	1
06/22/2020 19:00	1	1
06/22/2020 20:00	1	1
06/22/2020 21:00	1	1
06/22/2020 22:00	1	1
06/22/2020 23:00	1	1
Average/Sum#:	5	1
Minimum:	1	1
Maximum:	27	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/23/2020 00:00	1	1
06/23/2020 01:00	1	1
06/23/2020 02:00	1	1
06/23/2020 03:00	1	1
06/23/2020 04:00	1	1
06/23/2020 05:00	1	1
06/23/2020 06:00	1	1
06/23/2020 07:00	1	1
06/23/2020 08:00	3	1
06/23/2020 09:00	3	1
06/23/2020 10:00	2	1
06/23/2020 11:00	3	1
06/23/2020 12:00	1	8
06/23/2020 13:00	1	11
06/23/2020 14:00	1	11
06/23/2020 15:00	1	11
06/23/2020 16:00	1	4
06/23/2020 17:00	1	1
06/23/2020 18:00	1	1
06/23/2020 19:00	1	1
06/23/2020 20:00	1	1
06/23/2020 21:00	1	1
06/23/2020 22:00	1	1
06/23/2020 23:00	1	1
Average/Sum#:	1	3
Minimum:	1	1
Maximum:	3	11
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/24/2020 00:00	1	1
06/24/2020 01:00	1	1
06/24/2020 02:00	1	1
06/24/2020 03:00	1	1
06/24/2020 04:00	1	1
06/24/2020 05:00	1	1
06/24/2020 06:00	1	1
06/24/2020 07:00	1	1
06/24/2020 08:00	1	1
06/24/2020 09:00	1	1
06/24/2020 10:00	1	1
06/24/2020 11:00	1	1
06/24/2020 12:00	1	1
06/24/2020 13:00	1	1
06/24/2020 14:00	1	1
06/24/2020 15:00	1	1
06/24/2020 16:00	1	1
06/24/2020 17:00	1	1
06/24/2020 18:00	1	1
06/24/2020 19:00	1	1
06/24/2020 20:00	1	1
06/24/2020 21:00	1	1
06/24/2020 22:00	1	1
06/24/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/25/2020 00:00	1	1
06/25/2020 01:00	1	1
06/25/2020 02:00	1	1
06/25/2020 03:00	1	1
06/25/2020 04:00	1	1
06/25/2020 05:00	1	1
06/25/2020 06:00	1	1
06/25/2020 07:00	1	1
06/25/2020 08:00	1	4
06/25/2020 09:00	1	8
06/25/2020 10:00	1	8
06/25/2020 11:00	1	8
06/25/2020 12:00	4	4
06/25/2020 13:00	7	1
06/25/2020 14:00	7	1
06/25/2020 15:00	7	1
06/25/2020 16:00	3	1
06/25/2020 17:00	1	1
06/25/2020 18:00	1	1
06/25/2020 19:00	1	1
06/25/2020 20:00	1	1
06/25/2020 21:00	1	1
06/25/2020 22:00	1	1
06/25/2020 23:00	1	1
Average/Sum#:	2	2
Minimum:	1	1
Maximum:	7	8
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/26/2020 00:00	1	1
06/26/2020 01:00	1	1
06/26/2020 02:00	1	1
06/26/2020 03:00	1	1
06/26/2020 04:00	1	1
06/26/2020 05:00	1	4
06/26/2020 06:00	1	7
06/26/2020 07:00	1	7
06/26/2020 08:00	1	7
06/26/2020 09:00	1	4
06/26/2020 10:00	4	1
06/26/2020 11:00	6	1
06/26/2020 12:00	7	1
06/26/2020 13:00	7	1
06/26/2020 14:00	7	1
06/26/2020 15:00	7	1
06/26/2020 16:00	7	1
06/26/2020 17:00	4	1
06/26/2020 18:00	2	1
06/26/2020 19:00	1	1
06/26/2020 20:00	1	1
06/26/2020 21:00	1	1
06/26/2020 22:00	1	1
06/26/2020 23:00	1	1
Average/Sum#:	3	2
Minimum:	1	1
Maximum:	7	7
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/27/2020 00:00	1	1
06/27/2020 01:00	1	1
06/27/2020 02:00	1	1
06/27/2020 03:00	1	1
06/27/2020 04:00	1	1
06/27/2020 05:00	1	1
06/27/2020 06:00	1	1
06/27/2020 07:00	1	1
06/27/2020 08:00	1	1
06/27/2020 09:00	1	1
06/27/2020 10:00	1	1
06/27/2020 11:00	1	1
06/27/2020 12:00	1	1
06/27/2020 13:00	1	1
06/27/2020 14:00	1	1
06/27/2020 15:00	1	1
06/27/2020 16:00	1	1
06/27/2020 17:00	1	1
06/27/2020 18:00	1	1
06/27/2020 19:00	1	1
06/27/2020 20:00	1	1
06/27/2020 21:00	1	1
06/27/2020 22:00	1	1
06/27/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/28/2020 00:00	1	1
06/28/2020 01:00	1	1
06/28/2020 02:00	1	1
06/28/2020 03:00	1	1
06/28/2020 04:00	1	1
06/28/2020 05:00	1	1
06/28/2020 06:00	1	1
06/28/2020 07:00	1	1
06/28/2020 08:00	1	1
06/28/2020 09:00	1	1
06/28/2020 10:00	1	1
06/28/2020 11:00	1	1
06/28/2020 12:00	1	1
06/28/2020 13:00	1	1
06/28/2020 14:00	1	1
06/28/2020 15:00	1	1
06/28/2020 16:00	1	1
06/28/2020 17:00	1	1
06/28/2020 18:00	1	1
06/28/2020 19:00	1	1
06/28/2020 20:00	1	1
06/28/2020 21:00	1	1
06/28/2020 22:00	1	1
06/28/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/29/2020 00:00	1	1
06/29/2020 01:00	1	1
06/29/2020 02:00	1	1
06/29/2020 03:00	1	1
06/29/2020 04:00	1	1
06/29/2020 05:00	1	1
06/29/2020 06:00	1	1
06/29/2020 07:00	1	1
06/29/2020 08:00	1	1
06/29/2020 09:00	1	1
06/29/2020 10:00	1	1
06/29/2020 11:00	1	1
06/29/2020 12:00	1	1
06/29/2020 13:00	1	1
06/29/2020 14:00	1	1
06/29/2020 15:00	1	1
06/29/2020 16:00	1	1
06/29/2020 17:00	1	1
06/29/2020 18:00	1	1
06/29/2020 19:00	1	1
06/29/2020 20:00	1	1
06/29/2020 21:00	1	1
06/29/2020 22:00	1	1
06/29/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 06:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
06/30/2020 00:00	1	1
06/30/2020 01:00	1	1
06/30/2020 02:00	1	1
06/30/2020 03:00	1	1
06/30/2020 04:00	1	1
06/30/2020 05:00	1	1
06/30/2020 06:00	1	1
06/30/2020 07:00	1	1
06/30/2020 08:00	1	12
06/30/2020 09:00	1	20
06/30/2020 10:00	1	23
06/30/2020 11:00	1	27
06/30/2020 12:00	1	16
06/30/2020 13:00	1	7
06/30/2020 14:00	15	4
06/30/2020 15:00	21	1
06/30/2020 16:00	21	1
06/30/2020 17:00	21	1
06/30/2020 18:00	7	1
06/30/2020 19:00	1	1
06/30/2020 20:00	1	1
06/30/2020 21:00	1	1
06/30/2020 22:00	1	1
06/30/2020 23:00	1	1
Average/Sum#:	4	5
Minimum:	1	1
Maximum:	21	27
%SI	0.00	0.00

Excess Emission Report

CT1 NOx 30 Day Rolling Average (KKKK)

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 06:55 **Location:** Maxwell, CA

Tag Name: CT1_NOx_30D_Ppmvdc_1D
Total Operating Time: 41.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 50.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**41.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 NOx 30 Day Rolling Average (KKKK)

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 06:56 **Location:** Maxwell, CA

Tag Name: CT2_NOx_30D_Ppmvdc_1D
Total Operating Time: 53.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 38.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**53.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 4
Excess Emission/Downtime Report

FCD: AQ-4
Title V: #29

EDS-CMS Reports

EDS/CMS Summary Report

CT1 - CO LbPerHr

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59
Generated: 07/10/2020 06:56

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_CO_LbPerHr_1H
EDS Data from: CT1_CONormalOp_LbPerHr_1H
Emission Limitation: CT1_COLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 697.00 Hour(s)
Operating time for CMS: 697.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	10
e. Unknown causes	0
2. Total CMS Downtime	11
3. Total Downtime as a percentage of operating time	1.58
4. Total Availability as a percentage of operating time	98.42

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - CO Ppmvdc

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 06:57 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_CO_Ppmvdc_1H
EDS Data from: CT1_CO_3Hr_Ppmvdc_1H
Emission Limitation: CT1_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 697.00 Hour(s)
Operating time for CMS: 697.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	10
e. Unknown causes	0
2. Total CMS Downtime	11
3. Total Downtime as a percentage of operating time	1.58
4. Total Availability as a percentage of operating time	98.42

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx LbPerHr

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59
Generated: 07/10/2020 06:58

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_NOx_LbPerHr_1H
EDS Data from: CT1_NOxNormalOp_LbPerHr_1H
Emission Limitation: CT1_NOxLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 697.00 Hour(s)
Operating time for CMS: 697.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	10
e. Unknown causes	0
2. Total CMS Downtime	11
3. Total Downtime as a percentage of operating time	1.58
4. Total Availability as a percentage of operating time	98.42

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx Ppmvdc

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59
Generated: 07/10/2020 06:58

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Ppmvdc_1H
EDS Data from: CT1_NOx_Ppmvdc_1H
Emission Limitation: CT1_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 697.00 Hour(s)
Operating time for CMS: 697.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	10
e. Unknown causes	0
2. Total CMS Downtime	11
3. Total Downtime as a percentage of operating time	1.58
4. Total Availability as a percentage of operating time	98.42

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO LbPerHr

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59
Generated: 07/10/2020 06:59

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_CO_LbPerHr_1H
EDS Data from: CT2_CONormalOp_LbPerHr_1H
Emission Limitation: CT2_COLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 903.00 Hour(s)
Operating time for CMS: 903.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	2
d. Other known causes	8
e. Unknown causes	0
2. Total CMS Downtime	10
3. Total Downtime as a percentage of operating time	1.11
4. Total Availability as a percentage of operating time	98.89

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO Ppmvdc

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59
Generated: 07/10/2020 06:59

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_CO_Ppmvdc_1H
EDS Data from: CT2_CO_3Hr_Ppmvdc_1H
Emission Limitation: CT2_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 903.00 Hour(s)
Operating time for CMS: 903.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	2
d. Other known causes	8
e. Unknown causes	0
2. Total CMS Downtime	10
3. Total Downtime as a percentage of operating time	1.11
4. Total Availability as a percentage of operating time	98.89

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - NOx LbPerHr

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59
Generated: 07/10/2020 07:00

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_NOx_LbPerHr_1H
EDS Data from: CT2_NOxNormalOp_LbPerHr_1H
Emission Limitation: CT2_NOxLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 903.00 Hour(s)
Operating time for CMS: 903.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	2
d. Other known causes	12
e. Unknown causes	0
2. Total CMS Downtime	14
3. Total Downtime as a percentage of operating time	1.55
4. Total Availability as a percentage of operating time	98.45

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - NOx Ppmvdc

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59
Generated: 07/10/2020 07:00

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_NOx_Ppmvdc_1H
EDS Data from: CT2_NOx_Ppmvdc_1H
Emission Limitation: CT2_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 903.00 Hour(s)
Operating time for CMS: 903.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	2
d. Other known causes	12
e. Unknown causes	0
2. Total CMS Downtime	14
3. Total Downtime as a percentage of operating time	1.55
4. Total Availability as a percentage of operating time	98.45

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

Excess Emission Report

CT1 - CO LbPerHr Normal Operating 1-Hour Block Average

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:01 **Location:** Maxwell, CA

Tag Name: CT1_CONormalOp_LbPerHr_1H
Total Operating Time: 697.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,487.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**697.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - CO Ppmvdc 3-Hour Rolling Average

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:01 **Location:** Maxwell, CA

Tag Name: CT1_CO_3Hr_Ppmvdc_1H
Total Operating Time: 697.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,487.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**697.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NOx LbPerHr Normal Operating 1-Hour Block Average

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:02 **Location:** Maxwell, CA

Tag Name: CT1_NOxNormalOp_LbPerHr_1H
Total Operating Time: 697.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,487.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**697.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NOx Ppmvdc 1-Hour Block Average

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:03 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Ppmvdc_1H
Total Operating Time: 697.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,487.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**697.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO LbPerHr Normal Operating 1-Hour Block Average

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:03 **Location:** Maxwell, CA

Tag Name: CT2_CONormalOp_LbPerHr_1H
Total Operating Time: 903.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,281.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**903.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO Ppmvdc 3-Hour Rolling Average

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:04 **Location:** Maxwell, CA

Tag Name: CT2_CO_3Hr_Ppmvdc_1H
Total Operating Time: 903.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,281.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**903.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx LbPerHr Normal Operating 1-Hour Block Average

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:05 **Location:** Maxwell, CA

Tag Name: CT2_NOxNormalOp_LbPerHr_1H
Total Operating Time: 903.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,281.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**903.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx Ppmvdc 1-Hour Block Average

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:05 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Ppmvdc_1H
Total Operating Time: 903.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,281.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**903.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Invalid Data Report

CT1 - Stack CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:06 **Location:** Maxwell, CA

Tag Name: CT1_CO_LbPerHr_1H
Total Operating Time: 697.00 Hour(s)
Non-Operating Time: 1,487.00 Hour(s) Report Time: 2,184.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	04/06/2020 07:00	04/06/2020 07:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga
2	04/24/2020 14:00	04/24/2020 18:59	5	4 - Other known causes	14 - Engine Calc Halted error message, CEMS rebooted
3	05/28/2020 12:00	05/28/2020 16:59	5	4 - Other known causes	13 - Faulty Equipment, Equipment Replaced

Total Operating Time:	**697.00 Hour(s)**
Total Monitor Downtime (Online only):	**11.00 Hour(s)**
Percent Monitor Availability:	**98.42 %**
Percent Monitor Downtime:	**1.58 %**

Report Code	Type	Text	Duration	Duration Percent
4	Reason	Other known causes	10	90.91
3	Reason	Quality assurance calibration	1	9.09
14	Action	Engine Calc Halted error message, CEMS rebooted	5	45.45
13	Action	Faulty Equipment, Equipment Replaced	5	45.45
4	Action	Quarterly linearity/cga	1	9.09

Invalid Data Report

CT1 - Stack NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:07 **Location:** Maxwell, CA

Tag Name: CT1_NOx_LbPerHr_1H
Total Operating Time: 697.00 Hour(s)
Non-Operating Time: 1,487.00 Hour(s) Report Time: 2,184.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	04/06/2020 07:00	04/06/2020 07:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga
2	04/24/2020 14:00	04/24/2020 18:59	5	4 - Other known causes	14 - Engine Calc Halted error message, CEMS rebooted
3	05/28/2020 12:00	05/28/2020 16:59	5	4 - Other known causes	13 - Faulty Equipment, Equipment Replaced

Total Operating Time:	**697.00 Hour(s)**
Total Monitor Downtime (Online only):	**11.00 Hour(s)**
Percent Monitor Availability:	**98.42 %**
Percent Monitor Downtime:	**1.58 %**

Report Code	Type	Text	Duration	Duration Percent
4	Reason	Other known causes	10	90.91
3	Reason	Quality assurance calibration	1	9.09
14	Action	Engine Calc Halted error message, CEMS rebooted	5	45.45
13	Action	Faulty Equipment, Equipment Replaced	5	45.45
4	Action	Quarterly linearity/cga	1	9.09

Invalid Data Report

CT2 - Stack CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:07 **Location:** Maxwell, CA

Tag Name: CT2_CO_LbPerHr_1H
Total Operating Time: 903.00 Hour(s)
Non-Operating Time: 1,281.00 Hour(s) Report Time: 2,184.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	04/06/2020 08:00	04/06/2020 08:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga
2	04/06/2020 12:00	04/06/2020 12:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga
3	05/27/2020 08:00	05/27/2020 12:59	5	4 - Other known causes	13 - Faulty Equipment, Equipment Replaced
4	05/30/2020 21:00	05/30/2020 22:59	2	4 - Other known causes	6 - Replaced malfunctioning component, performed calibration sequence
5	05/31/2020 06:00	05/31/2020 06:59	1	7 - CEM ALARM	1 - Investigated alarm, no problem found

Total Operating Time:	**903.00 Hour(s)**
Total Monitor Downtime (Online only):	**10.00 Hour(s)**
Percent Monitor Availability:	**98.89 %**
Percent Monitor Downtime:	**1.11 %**

Report Code	Type	Text	Duration	Duration Percent
7	Reason	CEM ALARM	1	10.00
4	Reason	Other known causes	7	70.00
3	Reason	Quality assurance calibration	2	20.00
13	Action	Faulty Equipment, Equipment Replaced	5	50.00
1	Action	Investigated alarm, no problem found	1	10.00
4	Action	Quarterly linearity/cga	2	20.00
6	Action	Replaced malfunctioning component, performed calibration sequence	2	20.00

Invalid Data Report

CT2 - Stack NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:08 **Location:** Maxwell, CA

Tag Name: CT2_NOx_LbPerHr_1H
Total Operating Time: 903.00 Hour(s)
Non-Operating Time: 1,281.00 Hour(s) Report Time: 2,184.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	04/06/2020 08:00	04/06/2020 08:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga
2	04/06/2020 12:00	04/06/2020 12:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga
3	05/27/2020 08:00	05/27/2020 12:59	5	4 - Other known causes	13 - Faulty Equipment, Equipment Replaced
4	05/30/2020 17:00	05/30/2020 22:59	6	4 - Other known causes	6 - Replaced malfunctioning component, performed calibration sequence
5	05/31/2020 06:00	05/31/2020 06:59	1	7 - CEM ALARM	1 - Investigated alarm, no problem found

Total Operating Time:	**903.00 Hour(s)**
Total Monitor Downtime (Online only):	**14.00 Hour(s)**
Percent Monitor Availability:	**98.45 %**
Percent Monitor Downtime:	**1.55 %**

Report Code	Type	Text	Duration	Duration Percent
7	Reason	CEM ALARM	1	7.14
4	Reason	Other known causes	11	78.57
3	Reason	Quality assurance calibration	2	14.29
13	Action	Faulty Equipment, Equipment Replaced	5	35.71
1	Action	Investigated alarm, no problem found	1	7.14
4	Action	Quarterly linearity/cga	2	14.29
6	Action	Replaced malfunctioning component, performed calibration sequence	6	42.86

ATTACHMENT 5
Hourly Emissions – VOC

FCD: AQ-14
Title V: #6

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/01/2020 03:00	0.0	18.4	353.0	0.0	0.2	1	0	0
04/01/2020 04:00	0.0	15.8	811.8	0.0	0.6	1	0	0
04/01/2020 05:00	0.6	13.9	1,557.8	0.6	1.1	1	1	0
04/01/2020 06:00	0.6	13.9	1,506.9	0.6	1.1	1	1	0
04/01/2020 07:00	0.6	13.9	1,584.0	0.6	1.1	1	1	0
04/01/2020 08:00	0.6	14.0	1,489.8	0.6	1.0	1	1	0
04/01/2020 09:00	0.6	14.0	1,404.4	0.6	1.0	1	1	0
04/01/2020 10:00	0.6	14.0	1,313.0	0.6	0.9	1	1	0
04/01/2020 11:00	0.6	14.1	1,289.9	0.6	0.9	1	1	0
04/01/2020 12:00	0.6	14.1	1,302.9	0.6	0.9	1	1	0
04/01/2020 13:00	0.6	14.0	1,478.7	0.6	1.0	1	1	0
04/01/2020 14:00	0.6	14.0	1,535.9	0.6	1.1	1	1	0
04/01/2020 15:00	0.6	14.0	1,611.1	0.6	1.1	1	1	0
04/01/2020 16:00	0.6	14.0	1,639.0	0.6	1.1	1	1	0
04/01/2020 17:00	0.7	14.0	1,579.7	0.7	1.1	1	1	1
04/01/2020 18:00	-0.1	12.8	1,985.9	0.1	1.4	1	1	1
04/01/2020 19:00	-0.1	12.1	2,127.7	0.2	1.5	1	1	1
04/01/2020 20:00	0.1	12.1	2,105.9	0.2	1.5	1	1	1
04/01/2020 21:00	0.1	12.1	2,106.5	0.2	1.5	1	1	1
04/01/2020 22:00	0.1	12.2	2,101.2	0.2	1.5	1	1	1
04/01/2020 23:00	0.2	12.4	2,033.1	0.4	1.4	1	1	1
Average/Sum#:	0.4	13.8	1,567.5	0.4	1.1	21 #	19 #	7 #
Minimum:	-0.1	12.1	353.0	0.0	0.2	0	0	0
Maximum:	0.7	18.4	2,127.7	0.7	1.5	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/02/2020 00:00	0.6	14.0	1,537.8	0.6	1.1	1	1	0
04/02/2020 01:00	0.6	13.9	1,508.4	0.6	1.1	1	1	0
04/02/2020 02:00	0.6	13.9	1,599.4	0.6	1.1	1	1	0
04/02/2020 03:00	0.6	13.9	1,659.7	0.6	1.2	1	1	0
04/02/2020 04:00	0.6	13.9	1,652.7	0.6	1.2	1	1	0
04/02/2020 05:00	0.6	13.9	1,567.0	0.6	1.1	1	1	0
04/02/2020 06:00	0.6	13.9	1,659.3	0.6	1.2	1	1	0
04/02/2020 07:00	0.6	13.9	1,613.9	0.6	1.1	1	1	0
04/02/2020 08:00	0.6	13.9	1,662.5	0.6	1.2	1	1	0
04/02/2020 09:00	0.6	14.0	1,651.3	0.6	1.2	1	1	0
04/02/2020 10:00	0.6	14.0	1,621.9	0.6	1.1	1	1	0
04/02/2020 11:00	0.6	14.0	1,541.9	0.6	1.1	1	1	0
04/02/2020 12:00	0.6	14.0	1,581.1	0.6	1.1	1	1	0
04/02/2020 13:00	0.6	14.0	1,639.6	0.6	1.1	1	1	0
04/02/2020 14:00	0.6	14.0	1,650.7	0.6	1.2	1	1	0
04/02/2020 15:00	0.6	14.0	1,649.1	0.6	1.2	1	1	0
04/02/2020 16:00	0.6	14.0	1,611.3	0.6	1.1	1	1	0
04/02/2020 17:00	0.7	13.9	1,605.5	0.7	1.1	1	1	1
04/02/2020 18:00	-0.1	12.8	1,981.5	0.1	1.4	1	1	1
04/02/2020 19:00	-0.1	12.6	2,016.3	0.1	1.4	1	1	1
04/02/2020 20:00	0.1	12.6	2,019.0	0.2	1.4	1	1	1
04/02/2020 21:00	0.0	14.4	1,191.0	0.0	0.8	1	0	1
04/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.5	13.8	1,646.4	0.5	1.2	22 #	21 #	5 #
Minimum:	-0.1	12.6	1,191.0	0.0	0.8	0	0	0
Maximum:	0.7	14.4	2,019.0	0.7	1.4	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/04/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/04/2020 01:00	0.0	17.6	462.0	0.0	0.3	1	0	0
04/04/2020 02:00	0.0	15.0	1,036.3	0.0	0.7	1	0	0
04/04/2020 03:00	0.6	13.9	1,662.5	0.6	1.2	1	1	0
04/04/2020 04:00	0.6	13.9	1,644.8	0.6	1.2	1	1	0
04/04/2020 05:00	0.6	13.9	1,663.3	0.6	1.2	1	1	0
04/04/2020 06:00	0.6	13.9	1,642.1	0.6	1.1	1	1	0
04/04/2020 07:00	0.6	13.9	1,663.5	0.6	1.2	1	1	0
04/04/2020 08:00	0.6	13.9	1,652.0	0.6	1.2	1	1	0
04/04/2020 09:00	0.6	13.9	1,640.7	0.6	1.1	1	1	0
04/04/2020 10:00	0.6	13.9	1,619.1	0.6	1.1	1	1	0
04/04/2020 11:00	0.6	13.9	1,642.1	0.6	1.1	1	1	0
04/04/2020 12:00	0.6	13.9	1,656.0	0.6	1.2	1	1	0
04/04/2020 13:00	0.6	13.9	1,655.6	0.6	1.2	1	1	0
04/04/2020 14:00	0.6	13.9	1,658.9	0.6	1.2	1	1	0
04/04/2020 15:00	0.6	13.9	1,625.9	0.6	1.1	1	1	0
04/04/2020 16:00	0.6	13.9	1,653.4	0.6	1.2	1	1	0
04/04/2020 17:00	0.7	13.9	1,620.9	0.7	1.1	1	1	1
04/04/2020 18:00	-0.1	12.6	1,980.0	0.1	1.4	1	1	1
04/04/2020 19:00	0.1	11.7	2,149.7	0.2	1.5	1	1	1
04/04/2020 20:00	0.1	11.9	2,113.6	0.2	1.5	1	1	1
04/04/2020 21:00	0.1	11.9	2,103.1	0.2	1.5	1	1	1
04/04/2020 22:00	0.1	11.9	2,096.2	0.2	1.5	1	1	1
04/04/2020 23:00	0.1	12.0	2,099.4	0.2	1.5	1	1	1
Average/Sum#:	0.4	13.6	1,684.4	0.4	1.2	23 #	21 #	7 #
Minimum:	-0.1	11.7	462.0	0.0	0.3	0	0	0
Maximum:	0.7	17.6	2,149.7	0.7	1.5	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/05/2020 00:00	0.1	12.0	2,095.2	0.2	1.5	1	1	1
04/05/2020 01:00	0.7	13.6	1,685.9	0.7	1.2	1	1	1
04/05/2020 02:00	0.6	13.9	1,642.4	0.6	1.1	1	1	0
04/05/2020 03:00	0.6	13.9	1,637.4	0.6	1.1	1	1	0
04/05/2020 04:00	0.6	13.9	1,637.2	0.6	1.1	1	1	0
04/05/2020 05:00	0.6	13.9	1,650.3	0.6	1.2	1	1	0
04/05/2020 06:00	0.6	13.9	1,641.6	0.6	1.1	1	1	0
04/05/2020 07:00	0.6	13.9	1,609.9	0.6	1.1	1	1	0
04/05/2020 08:00	0.6	13.9	1,651.9	0.6	1.2	1	1	0
04/05/2020 09:00	0.6	13.9	1,627.5	0.6	1.1	1	1	0
04/05/2020 10:00	0.6	13.9	1,609.1	0.6	1.1	1	1	0
04/05/2020 11:00	0.6	13.9	1,590.4	0.6	1.1	1	1	0
04/05/2020 12:00	0.6	13.9	1,555.2	0.6	1.1	1	1	0
04/05/2020 13:00	0.6	14.0	1,632.7	0.6	1.1	1	1	0
04/05/2020 14:00	0.6	14.0	1,634.9	0.6	1.1	1	1	0
04/05/2020 15:00	0.6	14.0	1,633.0	0.6	1.1	1	1	0
04/05/2020 16:00	0.5	13.4	1,759.4	0.5	1.2	1	1	1
04/05/2020 17:00	0.1	12.1	2,083.0	0.2	1.5	1	1	1
04/05/2020 18:00	0.1	12.2	2,055.1	0.2	1.4	1	1	1
04/05/2020 19:00	0.1	12.3	2,047.8	0.2	1.4	1	1	1
04/05/2020 20:00	0.1	12.3	2,053.2	0.2	1.4	1	1	1
04/05/2020 21:00	0.1	12.2	2,068.9	0.2	1.4	1	1	1
04/05/2020 22:00	0.4	12.4	2,037.4	0.5	1.4	1	1	1
04/05/2020 23:00	0.1	12.3	2,062.5	0.2	1.4	1	1	1
Average/Sum#:	0.4	13.3	1,779.2	0.5	1.2	24 #	24 #	10 #
Minimum:	0.1	12.0	1,555.2	0.2	1.1	1	1	0
Maximum:	0.7	14.0	2,095.2	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/06/2020 00:00	0.1	12.3	2,067.4	0.2	1.4	1	1	1
04/06/2020 01:00	0.1	12.3	2,068.9	0.2	1.4	1	1	1
04/06/2020 02:00	0.1	12.1	2,093.7	0.2	1.5	1	1	1
04/06/2020 03:00	0.1	12.2	2,083.5	0.2	1.5	1	1	1
04/06/2020 04:00	0.1	12.5	2,038.7	0.2	1.4	1	1	1
04/06/2020 05:00	-0.1	12.3	2,052.4	0.2	1.4	1	1	1
04/06/2020 06:00	-0.1	12.3	2,073.6	0.2	1.5	1	1	1
04/06/2020 07:00	0.7	0.0	2,021.6	0.7	1.4	1	1	1
04/06/2020 08:00	0.6	13.9	1,626.6	0.6	1.1	1	1	0
04/06/2020 09:00	0.6	13.9	1,641.8	0.6	1.1	1	1	0
04/06/2020 10:00	0.6	13.9	1,652.5	0.6	1.2	1	1	0
04/06/2020 11:00	0.6	13.9	1,591.2	0.6	1.1	1	1	0
04/06/2020 12:00	0.6	13.9	1,586.5	0.6	1.1	1	1	0
04/06/2020 13:00	0.6	14.0	1,564.8	0.6	1.1	1	1	0
04/06/2020 14:00	0.6	14.0	1,633.7	0.6	1.1	1	1	0
04/06/2020 15:00	0.6	14.0	1,641.7	0.6	1.1	1	1	0
04/06/2020 16:00	0.7	13.9	1,527.3	0.7	1.1	1	1	1
04/06/2020 17:00	-0.1	12.7	1,981.1	0.1	1.4	1	1	1
04/06/2020 18:00	-0.1	12.5	2,005.1	0.1	1.4	1	1	1
04/06/2020 19:00	0.1	12.8	1,953.7	0.2	1.4	1	1	1
04/06/2020 20:00	0.1	12.6	2,000.2	0.2	1.4	1	1	1
04/06/2020 21:00	0.1	12.4	2,043.5	0.2	1.4	1	1	1
04/06/2020 22:00	0.1	12.4	2,039.7	0.2	1.4	1	1	1
04/06/2020 23:00	0.1	12.2	2,079.0	0.2	1.5	1	1	1
Average/Sum#:	0.3	13.0	1,877.8	0.4	1.3	24 #	24 #	16 #
Minimum:	-0.1	12.1	1,527.3	0.1	1.1	1	1	0
Maximum:	0.7	14.0	2,093.7	0.7	1.5	1	1	1
%SI	4.17	4.17	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/07/2020 00:00	0.1	12.6	2,007.9	0.2	1.4	1	1	1
04/07/2020 01:00	0.1	12.7	2,002.7	0.2	1.4	1	1	1
04/07/2020 02:00	0.1	12.7	2,005.4	0.2	1.4	1	1	1
04/07/2020 03:00	0.1	12.7	1,997.8	0.2	1.4	1	1	1
04/07/2020 04:00	0.1	12.7	1,994.6	0.2	1.4	1	1	1
04/07/2020 05:00	0.1	12.7	1,998.6	0.2	1.4	1	1	1
04/07/2020 06:00	0.1	12.9	1,933.9	0.2	1.4	1	1	1
04/07/2020 07:00	0.6	13.9	1,606.0	0.6	1.1	1	1	0
04/07/2020 08:00	0.6	13.9	1,615.6	0.6	1.1	1	1	0
04/07/2020 09:00	0.6	13.9	1,645.3	0.6	1.2	1	1	0
04/07/2020 10:00	0.6	13.9	1,642.5	0.6	1.1	1	1	0
04/07/2020 11:00	0.6	13.9	1,651.8	0.6	1.2	1	1	0
04/07/2020 12:00	0.6	13.9	1,651.0	0.6	1.2	1	1	0
04/07/2020 13:00	0.6	13.9	1,604.9	0.6	1.1	1	1	0
04/07/2020 14:00	0.6	14.0	1,586.4	0.6	1.1	1	1	0
04/07/2020 15:00	0.6	14.0	1,649.5	0.6	1.2	1	1	0
04/07/2020 16:00	0.6	14.0	1,657.1	0.6	1.2	1	1	0
04/07/2020 17:00	0.7	13.9	1,579.6	0.7	1.1	1	1	1
04/07/2020 18:00	-0.1	12.7	1,957.2	0.1	1.4	1	1	1
04/07/2020 19:00	0.1	12.5	2,006.4	0.2	1.4	1	1	1
04/07/2020 20:00	0.1	12.0	2,089.5	0.2	1.5	1	1	1
04/07/2020 21:00	0.1	12.0	2,095.7	0.2	1.5	1	1	1
04/07/2020 22:00	0.1	12.0	2,097.9	0.2	1.5	1	1	1
04/07/2020 23:00	0.1	12.1	2,101.5	0.2	1.5	1	1	1
Average/Sum#:	0.3	13.1	1,840.8	0.4	1.3	24 #	24 #	14 #
Minimum:	-0.1	12.0	1,579.6	0.1	1.1	1	1	0
Maximum:	0.7	14.0	2,101.5	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/08/2020 00:00	0.1	12.4	1,995.2	0.2	1.4	1	1	1
04/08/2020 01:00	0.6	13.9	1,635.7	0.6	1.1	1	1	0
04/08/2020 02:00	0.6	13.9	1,604.4	0.6	1.1	1	1	0
04/08/2020 03:00	0.6	13.9	1,635.9	0.6	1.1	1	1	0
04/08/2020 04:00	0.6	13.9	1,596.3	0.6	1.1	1	1	0
04/08/2020 05:00	0.6	13.9	1,643.9	0.6	1.2	1	1	0
04/08/2020 06:00	0.6	13.9	1,655.1	0.6	1.2	1	1	0
04/08/2020 07:00	0.6	13.9	1,624.4	0.6	1.1	1	1	0
04/08/2020 08:00	0.6	13.9	1,648.3	0.6	1.2	1	1	0
04/08/2020 09:00	0.6	13.9	1,658.4	0.6	1.2	1	1	0
04/08/2020 10:00	0.6	13.9	1,653.4	0.6	1.2	1	1	0
04/08/2020 11:00	0.6	13.9	1,616.0	0.6	1.1	1	1	0
04/08/2020 12:00	0.6	14.0	1,653.6	0.6	1.2	1	1	0
04/08/2020 13:00	0.6	13.9	1,647.6	0.6	1.2	1	1	0
04/08/2020 14:00	0.6	13.9	1,653.7	0.6	1.2	1	1	0
04/08/2020 15:00	0.6	13.9	1,646.7	0.6	1.2	1	1	0
04/08/2020 16:00	0.6	13.9	1,642.3	0.6	1.1	1	1	0
04/08/2020 17:00	0.5	13.5	1,740.3	0.5	1.2	1	1	1
04/08/2020 18:00	-0.1	12.1	2,064.2	0.2	1.4	1	1	1
04/08/2020 19:00	0.1	11.6	2,171.9	0.2	1.5	1	1	1
04/08/2020 20:00	0.1	11.9	2,115.9	0.2	1.5	1	1	1
04/08/2020 21:00	0.1	12.0	2,096.0	0.2	1.5	1	1	1
04/08/2020 22:00	0.1	12.0	2,095.2	0.2	1.5	1	1	1
04/08/2020 23:00	0.1	12.0	2,096.4	0.2	1.5	1	1	1
Average/Sum#:	0.4	13.3	1,774.6	0.5	1.3	24 #	24 #	8 #
Minimum:	-0.1	11.6	1,596.3	0.2	1.1	1	1	0
Maximum:	0.6	14.0	2,171.9	0.6	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/09/2020 00:00	0.1	12.0	2,104.2	0.2	1.5	1	1	1
04/09/2020 01:00	0.1	12.0	2,105.4	0.2	1.5	1	1	1
04/09/2020 02:00	0.1	12.0	2,104.8	0.2	1.5	1	1	1
04/09/2020 03:00	0.1	12.1	2,098.4	0.2	1.5	1	1	1
04/09/2020 04:00	0.1	12.3	2,060.4	0.2	1.4	1	1	1
04/09/2020 05:00	-0.1	12.3	2,055.3	0.2	1.4	1	1	1
04/09/2020 06:00	-0.1	12.1	2,096.3	0.2	1.5	1	1	1
04/09/2020 07:00	0.1	12.1	2,099.4	0.2	1.5	1	1	1
04/09/2020 08:00	0.1	12.1	2,095.5	0.2	1.5	1	1	1
04/09/2020 09:00	0.1	12.1	2,095.1	0.2	1.5	1	1	1
04/09/2020 10:00	0.1	12.1	2,086.3	0.2	1.5	1	1	1
04/09/2020 11:00	0.1	12.4	2,024.7	0.2	1.4	1	1	1
04/09/2020 12:00	0.1	12.2	2,066.1	0.2	1.4	1	1	1
04/09/2020 13:00	0.1	12.1	2,066.8	0.2	1.4	1	1	1
04/09/2020 14:00	0.1	12.2	2,049.1	0.2	1.4	1	1	1
04/09/2020 15:00	0.1	12.1	2,059.3	0.2	1.4	1	1	1
04/09/2020 16:00	0.1	12.2	2,045.4	0.2	1.4	1	1	1
04/09/2020 17:00	0.1	12.1	2,062.5	0.2	1.4	1	1	1
04/09/2020 18:00	0.1	12.1	2,073.9	0.2	1.5	1	1	1
04/09/2020 19:00	0.1	12.0	2,094.3	0.2	1.5	1	1	1
04/09/2020 20:00	0.1	11.9	2,097.1	0.2	1.5	1	1	1
04/09/2020 21:00	0.1	12.1	2,075.1	0.2	1.5	1	1	1
04/09/2020 22:00	0.1	12.2	2,057.1	0.2	1.4	1	1	1
04/09/2020 23:00	0.1	12.0	2,100.7	0.2	1.5	1	1	1
Average/Sum#:	0.1	12.1	2,078.1	0.2	1.5	24 #	24 #	24 #
Minimum:	-0.1	11.9	2,024.7	0.2	1.4	1	1	1
Maximum:	0.1	12.4	2,105.4	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/10/2020 00:00	0.1	12.1	2,094.3	0.2	1.5	1	1	1
04/10/2020 01:00	0.1	12.1	2,087.2	0.2	1.5	1	1	1
04/10/2020 02:00	0.1	12.1	2,085.2	0.2	1.5	1	1	1
04/10/2020 03:00	0.1	12.1	2,081.4	0.2	1.5	1	1	1
04/10/2020 04:00	0.1	12.3	2,048.3	0.2	1.4	1	1	1
04/10/2020 05:00	0.1	12.5	2,018.6	0.2	1.4	1	1	1
04/10/2020 06:00	0.1	12.2	2,082.2	0.2	1.5	1	1	1
04/10/2020 07:00	0.7	13.6	1,667.8	0.7	1.2	1	1	1
04/10/2020 08:00	0.6	13.9	1,529.5	0.6	1.1	1	1	0
04/10/2020 09:00	0.6	13.9	1,655.0	0.6	1.2	1	1	0
04/10/2020 10:00	0.6	13.9	1,630.1	0.6	1.1	1	1	0
04/10/2020 11:00	0.6	13.9	1,526.5	0.6	1.1	1	1	0
04/10/2020 12:00	0.6	13.9	1,642.9	0.6	1.2	1	1	0
04/10/2020 13:00	0.6	14.0	1,539.6	0.6	1.1	1	1	0
04/10/2020 14:00	0.6	13.9	1,573.9	0.6	1.1	1	1	0
04/10/2020 15:00	0.6	13.9	1,622.9	0.6	1.1	1	1	0
04/10/2020 16:00	0.6	13.9	1,630.9	0.6	1.1	1	1	0
04/10/2020 17:00	0.7	13.9	1,447.3	0.7	1.0	1	1	1
04/10/2020 18:00	-0.2	12.3	1,986.9	0.1	1.4	1	1	1
04/10/2020 19:00	-0.1	11.9	2,060.9	0.2	1.4	1	1	1
04/10/2020 20:00	-0.1	12.1	2,045.1	0.2	1.4	1	1	1
04/10/2020 21:00	-0.1	12.2	2,040.0	0.2	1.4	1	1	1
04/10/2020 22:00	-0.1	12.2	2,039.1	0.2	1.4	1	1	1
04/10/2020 23:00	0.1	12.9	1,883.2	0.2	1.3	1	1	1
Average/Sum#:	0.3	13.0	1,834.1	0.4	1.3	24 #	24 #	15 #
Minimum:	-0.2	11.9	1,447.3	0.1	1.0	1	1	0
Maximum:	0.7	14.0	2,094.3	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/11/2020 00:00	0.6	13.9	1,584.9	0.6	1.1	1	1	0
04/11/2020 01:00	0.6	13.9	1,643.0	0.6	1.2	1	1	0
04/11/2020 02:00	0.6	13.9	1,641.3	0.6	1.1	1	1	0
04/11/2020 03:00	0.6	13.9	1,634.0	0.6	1.1	1	1	0
04/11/2020 04:00	0.6	13.9	1,628.1	0.6	1.1	1	1	0
04/11/2020 05:00	0.6	13.8	1,633.7	0.6	1.1	1	1	0
04/11/2020 06:00	0.6	13.9	1,567.3	0.6	1.1	1	1	0
04/11/2020 07:00	0.6	13.9	1,642.3	0.6	1.1	1	1	0
04/11/2020 08:00	0.6	13.9	1,635.2	0.6	1.1	1	1	0
04/11/2020 09:00	0.6	13.9	1,634.1	0.6	1.1	1	1	0
04/11/2020 10:00	0.6	13.9	1,640.5	0.6	1.1	1	1	0
04/11/2020 11:00	0.6	13.9	1,645.8	0.6	1.2	1	1	0
04/11/2020 12:00	0.6	13.9	1,539.9	0.6	1.1	1	1	0
04/11/2020 13:00	0.6	13.9	1,628.2	0.6	1.1	1	1	0
04/11/2020 14:00	0.6	13.9	1,638.6	0.6	1.1	1	1	0
04/11/2020 15:00	0.6	13.9	1,640.2	0.6	1.1	1	1	0
04/11/2020 16:00	0.6	13.9	1,659.9	0.6	1.2	1	1	0
04/11/2020 17:00	0.6	13.9	1,646.2	0.6	1.2	1	1	0
04/11/2020 18:00	0.7	13.9	1,548.4	0.7	1.1	1	1	1
04/11/2020 19:00	-0.2	12.4	1,979.1	0.1	1.4	1	1	1
04/11/2020 20:00	-0.1	12.2	2,022.1	0.2	1.4	1	1	1
04/11/2020 21:00	-0.1	12.2	2,056.4	0.2	1.4	1	1	1
04/11/2020 22:00	-0.1	12.4	2,016.1	0.2	1.4	1	1	1
04/11/2020 23:00	0.1	12.6	1,940.1	0.2	1.4	1	1	1
Average/Sum#:	0.5	13.6	1,701.9	0.5	1.2	24 #	24 #	6 #
Minimum:	-0.2	12.2	1,539.9	0.1	1.1	1	1	0
Maximum:	0.7	13.9	2,056.4	0.7	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/12/2020 00:00	0.6	13.9	1,627.1	0.6	1.1	1	1	0
04/12/2020 01:00	0.6	13.9	1,644.8	0.6	1.2	1	1	0
04/12/2020 02:00	0.6	13.9	1,641.5	0.6	1.1	1	1	0
04/12/2020 03:00	0.6	13.9	1,568.2	0.6	1.1	1	1	0
04/12/2020 04:00	0.6	13.9	1,634.6	0.6	1.1	1	1	0
04/12/2020 05:00	0.6	13.9	1,648.5	0.6	1.2	1	1	0
04/12/2020 06:00	0.6	13.9	1,599.3	0.6	1.1	1	1	0
04/12/2020 07:00	0.6	13.9	1,659.2	0.6	1.2	1	1	0
04/12/2020 08:00	0.6	13.9	1,661.1	0.6	1.2	1	1	0
04/12/2020 09:00	0.6	13.9	1,638.0	0.6	1.1	1	1	0
04/12/2020 10:00	0.6	13.9	1,617.9	0.6	1.1	1	1	0
04/12/2020 11:00	0.6	14.0	1,567.2	0.6	1.1	1	1	0
04/12/2020 12:00	0.6	14.0	1,636.4	0.6	1.1	1	1	0
04/12/2020 13:00	0.6	14.0	1,639.3	0.6	1.1	1	1	0
04/12/2020 14:00	0.6	14.0	1,649.6	0.6	1.2	1	1	0
04/12/2020 15:00	0.6	14.0	1,629.1	0.6	1.1	1	1	0
04/12/2020 16:00	0.6	14.0	1,645.0	0.6	1.2	1	1	0
04/12/2020 17:00	0.6	14.0	1,532.8	0.6	1.1	1	1	0
04/12/2020 18:00	0.6	14.0	1,583.5	0.6	1.1	1	1	0
04/12/2020 19:00	0.6	14.0	1,597.9	0.6	1.1	1	1	0
04/12/2020 20:00	0.6	14.0	1,604.1	0.6	1.1	1	1	0
04/12/2020 21:00	0.6	13.9	1,595.6	0.6	1.1	1	1	0
04/12/2020 22:00	0.6	13.9	1,592.6	0.6	1.1	1	1	0
04/12/2020 23:00	0.4	13.4	1,790.6	0.4	1.3	1	1	1
Average/Sum#:	0.6	13.9	1,625.2	0.6	1.1	24 #	24 #	1 #
Minimum:	0.4	13.4	1,532.8	0.4	1.1	1	1	0
Maximum:	0.6	14.0	1,790.6	0.6	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/13/2020 00:00	-0.1	12.4	2,011.4	0.2	1.4	1	1	1
04/13/2020 01:00	0.6	13.9	1,650.0	0.6	1.2	1	1	0
04/13/2020 02:00	0.6	13.9	1,653.9	0.6	1.2	1	1	0
04/13/2020 03:00	0.6	13.9	1,631.6	0.6	1.1	1	1	0
04/13/2020 04:00	0.6	13.9	1,601.3	0.6	1.1	1	1	0
04/13/2020 05:00	0.6	13.8	1,634.6	0.6	1.1	1	1	0
04/13/2020 06:00	0.6	13.9	1,639.5	0.6	1.1	1	1	0
04/13/2020 07:00	0.6	14.0	1,622.6	0.6	1.1	1	1	0
04/13/2020 08:00	0.6	14.0	1,635.7	0.6	1.1	1	1	0
04/13/2020 09:00	0.6	14.0	1,663.9	0.6	1.2	1	1	0
04/13/2020 10:00	0.6	14.0	1,663.1	0.6	1.2	1	1	0
04/13/2020 11:00	0.6	14.0	1,667.0	0.6	1.2	1	1	0
04/13/2020 12:00	0.6	14.0	1,647.8	0.6	1.2	1	1	0
04/13/2020 13:00	0.6	14.0	1,579.5	0.6	1.1	1	1	0
04/13/2020 14:00	0.6	14.0	1,643.9	0.6	1.2	1	1	0
04/13/2020 15:00	0.6	14.0	1,661.4	0.6	1.2	1	1	0
04/13/2020 16:00	0.6	14.0	1,629.6	0.6	1.1	1	1	0
04/13/2020 17:00	0.7	14.0	1,500.3	0.7	1.1	1	1	1
04/13/2020 18:00	-0.1	12.8	1,935.5	0.1	1.4	1	1	1
04/13/2020 19:00	0.1	12.3	2,026.8	0.2	1.4	1	1	1
04/13/2020 20:00	0.1	12.4	2,022.3	0.2	1.4	1	1	1
04/13/2020 21:00	0.1	12.4	2,023.9	0.2	1.4	1	1	1
04/13/2020 22:00	0.1	12.5	2,009.0	0.2	1.4	1	1	1
04/13/2020 23:00	0.2	12.9	1,895.9	0.4	1.3	1	1	1
Average/Sum#:	0.4	13.5	1,735.4	0.5	1.2	24 #	24 #	8 #
Minimum:	-0.1	12.3	1,500.3	0.1	1.1	1	1	0
Maximum:	0.7	14.0	2,026.8	0.7	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/14/2020 00:00	0.6	14.0	1,689.3	0.6	1.2	1	1	0
04/14/2020 01:00	0.6	14.0	1,496.1	0.6	1.0	1	1	0
04/14/2020 02:00	0.6	14.0	1,599.0	0.6	1.1	1	1	0
04/14/2020 03:00	0.6	14.0	1,506.9	0.6	1.1	1	1	0
04/14/2020 04:00	0.6	14.0	1,601.0	0.6	1.1	1	1	0
04/14/2020 05:00	0.6	13.9	1,558.2	0.6	1.1	1	1	0
04/14/2020 06:00	0.6	13.9	1,639.9	0.6	1.1	1	1	0
04/14/2020 07:00	0.6	14.0	1,559.9	0.6	1.1	1	1	0
04/14/2020 08:00	0.6	14.0	1,612.2	0.6	1.1	1	1	0
04/14/2020 09:00	0.6	14.0	1,637.9	0.6	1.1	1	1	0
04/14/2020 10:00	0.6	14.0	1,651.3	0.6	1.2	1	1	0
04/14/2020 11:00	0.6	14.0	1,644.3	0.6	1.2	1	1	0
04/14/2020 12:00	0.6	14.0	1,534.6	0.6	1.1	1	1	0
04/14/2020 13:00	0.6	14.0	1,655.9	0.6	1.2	1	1	0
04/14/2020 14:00	0.6	14.0	1,637.7	0.6	1.1	1	1	0
04/14/2020 15:00	0.6	14.0	1,626.5	0.6	1.1	1	1	0
04/14/2020 16:00	0.6	14.0	1,559.5	0.6	1.1	1	1	0
04/14/2020 17:00	0.7	13.9	1,503.1	0.7	1.1	1	1	1
04/14/2020 18:00	0.1	12.6	1,943.4	0.2	1.4	1	1	1
04/14/2020 19:00	-0.1	12.2	2,012.7	0.2	1.4	1	1	1
04/14/2020 20:00	0.1	12.3	2,000.5	0.2	1.4	1	1	1
04/14/2020 21:00	0.1	12.5	1,969.2	0.2	1.4	1	1	1
04/14/2020 22:00	0.1	12.4	1,998.8	0.2	1.4	1	1	1
04/14/2020 23:00	0.1	12.5	2,007.7	0.2	1.4	1	1	1
Average/Sum#:	0.5	13.6	1,693.6	0.5	1.2	24 #	24 #	7 #
Minimum:	-0.1	12.2	1,496.1	0.2	1.0	1	1	0
Maximum:	0.7	14.0	2,012.7	0.7	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/15/2020 00:00	0.2	13.0	1,892.1	0.4	1.3	1	1	1
04/15/2020 01:00	0.6	13.9	1,566.3	0.6	1.1	1	1	0
04/15/2020 02:00	0.6	13.9	1,636.5	0.6	1.1	1	1	0
04/15/2020 03:00	0.6	13.9	1,552.3	0.6	1.1	1	1	0
04/15/2020 04:00	0.6	13.9	1,537.9	0.6	1.1	1	1	0
04/15/2020 05:00	0.6	13.9	1,646.0	0.6	1.2	1	1	0
04/15/2020 06:00	0.6	13.9	1,644.6	0.6	1.2	1	1	0
04/15/2020 07:00	0.6	13.9	1,621.2	0.6	1.1	1	1	0
04/15/2020 08:00	0.6	13.9	1,655.3	0.6	1.2	1	1	0
04/15/2020 09:00	0.6	13.9	1,656.0	0.6	1.2	1	1	0
04/15/2020 10:00	0.6	14.0	1,661.3	0.6	1.2	1	1	0
04/15/2020 11:00	0.6	14.0	1,661.1	0.6	1.2	1	1	0
04/15/2020 12:00	0.6	14.0	1,645.0	0.6	1.2	1	1	0
04/15/2020 13:00	0.6	13.9	1,660.1	0.6	1.2	1	1	0
04/15/2020 14:00	0.6	13.9	1,637.4	0.6	1.1	1	1	0
04/15/2020 15:00	0.6	13.9	1,600.1	0.6	1.1	1	1	0
04/15/2020 16:00	0.6	13.9	1,606.8	0.6	1.1	1	1	0
04/15/2020 17:00	0.7	13.9	1,492.8	0.7	1.0	1	1	1
04/15/2020 18:00	-0.1	12.4	1,956.6	0.2	1.4	1	1	1
04/15/2020 19:00	-0.1	11.9	2,061.2	0.2	1.4	1	1	1
04/15/2020 20:00	-0.2	11.8	2,075.5	0.1	1.5	1	1	1
04/15/2020 21:00	-0.2	12.2	2,024.5	0.1	1.4	1	1	1
04/15/2020 22:00	0.1	12.9	1,897.4	0.2	1.3	1	1	1
04/15/2020 23:00	0.2	12.9	1,870.2	0.4	1.3	1	1	1
Average/Sum#:	0.4	13.5	1,719.1	0.5	1.2	24 #	24 #	8 #
Minimum:	-0.2	11.8	1,492.8	0.1	1.0	1	1	0
Maximum:	0.7	14.0	2,075.5	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/16/2020 00:00	0.6	13.9	1,478.8	0.6	1.0	1	1	0
04/16/2020 01:00	0.6	13.9	1,470.8	0.6	1.0	1	1	0
04/16/2020 02:00	0.6	13.9	1,499.0	0.6	1.0	1	1	0
04/16/2020 03:00	0.6	13.9	1,467.0	0.6	1.0	1	1	0
04/16/2020 04:00	0.6	13.9	1,551.1	0.6	1.1	1	1	0
04/16/2020 05:00	0.6	13.9	1,637.5	0.6	1.1	1	1	0
04/16/2020 06:00	0.6	13.9	1,518.9	0.6	1.1	1	1	0
04/16/2020 07:00	0.6	13.9	1,621.3	0.6	1.1	1	1	0
04/16/2020 08:00	0.6	14.0	1,653.8	0.6	1.2	1	1	0
04/16/2020 09:00	0.6	14.0	1,639.8	0.6	1.1	1	1	0
04/16/2020 10:00	0.6	14.0	1,656.3	0.6	1.2	1	1	0
04/16/2020 11:00	0.6	14.0	1,631.4	0.6	1.1	1	1	0
04/16/2020 12:00	0.6	13.9	1,659.0	0.6	1.2	1	1	0
04/16/2020 13:00	0.6	13.9	1,648.5	0.6	1.2	1	1	0
04/16/2020 14:00	0.6	13.9	1,564.2	0.6	1.1	1	1	0
04/16/2020 15:00	0.6	13.9	1,608.8	0.6	1.1	1	1	0
04/16/2020 16:00	0.6	14.0	1,601.6	0.6	1.1	1	1	0
04/16/2020 17:00	0.7	14.0	1,525.6	0.7	1.1	1	1	1
04/16/2020 18:00	-0.1	12.5	1,937.8	0.1	1.4	1	1	1
04/16/2020 19:00	0.1	12.0	2,054.5	0.2	1.4	1	1	1
04/16/2020 20:00	0.2	11.8	2,089.2	0.4	1.5	1	1	1
04/16/2020 21:00	0.2	12.0	2,056.5	0.4	1.4	1	1	1
04/16/2020 22:00	0.1	12.6	1,927.3	0.2	1.3	1	1	1
04/16/2020 23:00	0.1	12.9	1,870.5	0.2	1.3	1	1	1
Average/Sum#:	0.5	13.5	1,682.1	0.5	1.2	24 #	24 #	7 #
Minimum:	-0.1	11.8	1,467.0	0.1	1.0	1	1	0
Maximum:	0.7	14.0	2,089.2	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/17/2020 00:00	0.6	13.9	1,423.2	0.6	1.0	1	1	0
04/17/2020 01:00	0.6	13.9	1,326.3	0.6	0.9	1	1	0
04/17/2020 02:00	0.6	13.9	1,310.7	0.6	0.9	1	1	0
04/17/2020 03:00	0.6	13.9	1,308.7	0.6	0.9	1	1	0
04/17/2020 04:00	0.6	13.9	1,286.9	0.6	0.9	1	1	0
04/17/2020 05:00	0.6	13.9	1,635.4	0.6	1.1	1	1	0
04/17/2020 06:00	0.6	13.9	1,602.5	0.6	1.1	1	1	0
04/17/2020 07:00	0.6	13.9	1,578.8	0.6	1.1	1	1	0
04/17/2020 08:00	0.6	13.9	1,645.2	0.6	1.2	1	1	0
04/17/2020 09:00	0.6	14.0	1,622.4	0.6	1.1	1	1	0
04/17/2020 10:00	0.6	14.0	1,531.5	0.6	1.1	1	1	0
04/17/2020 11:00	0.6	14.0	1,612.5	0.6	1.1	1	1	0
04/17/2020 12:00	0.6	14.0	1,434.2	0.6	1.0	1	1	0
04/17/2020 13:00	0.6	14.0	1,582.8	0.6	1.1	1	1	0
04/17/2020 14:00	0.6	13.9	1,642.7	0.6	1.1	1	1	0
04/17/2020 15:00	0.6	13.9	1,652.6	0.6	1.2	1	1	0
04/17/2020 16:00	0.6	13.9	1,621.5	0.6	1.1	1	1	0
04/17/2020 17:00	0.7	13.9	1,500.6	0.7	1.1	1	1	1
04/17/2020 18:00	-0.4	12.5	1,962.0	-0.1	1.4	1	1	1
04/17/2020 19:00	-0.2	12.2	2,020.3	0.1	1.4	1	1	1
04/17/2020 20:00	-0.2	12.3	2,016.3	0.1	1.4	1	1	1
04/17/2020 21:00	-0.2	12.3	2,015.0	0.1	1.4	1	1	1
04/17/2020 22:00	-0.2	12.3	2,037.6	0.1	1.4	1	1	1
04/17/2020 23:00	0.0	14.1	1,222.9	0.0	0.9	1	0	1
Average/Sum#:	0.4	13.6	1,608.0	0.5	1.1	24 #	23 #	7 #
Minimum:	-0.4	12.2	1,222.9	-0.1	0.9	1	0	0
Maximum:	0.7	14.1	2,037.6	0.7	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/18/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/19/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/20/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/20/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/20/2020 02:00	0.0	17.4	490.9	0.0	0.3	1	0	0
04/20/2020 03:00	0.0	14.8	1,025.2	0.0	0.7	1	0	0
04/20/2020 04:00	0.6	13.9	1,635.4	0.6	1.1	1	1	0
04/20/2020 05:00	0.6	13.9	1,646.9	0.6	1.2	1	1	0
04/20/2020 06:00	0.6	13.9	1,636.2	0.6	1.1	1	1	0
04/20/2020 07:00	0.6	13.9	1,648.4	0.6	1.2	1	1	0
04/20/2020 08:00	0.6	13.9	1,607.8	0.6	1.1	1	1	0
04/20/2020 09:00	0.6	13.9	1,559.2	0.6	1.1	1	1	0
04/20/2020 10:00	0.6	13.9	1,550.8	0.6	1.1	1	1	0
04/20/2020 11:00	0.6	13.9	1,651.3	0.6	1.2	1	1	0
04/20/2020 12:00	0.6	13.9	1,638.7	0.6	1.1	1	1	0
04/20/2020 13:00	0.6	13.9	1,646.3	0.6	1.2	1	1	0
04/20/2020 14:00	0.6	13.9	1,491.4	0.6	1.0	1	1	0
04/20/2020 15:00	0.6	13.9	1,623.6	0.6	1.1	1	1	0
04/20/2020 16:00	0.6	13.9	1,589.6	0.6	1.1	1	1	0
04/20/2020 17:00	0.7	13.9	1,508.9	0.7	1.1	1	1	1
04/20/2020 18:00	-0.2	12.6	1,957.3	0.1	1.4	1	1	1
04/20/2020 19:00	-0.2	12.4	2,009.0	0.1	1.4	1	1	1
04/20/2020 20:00	-0.1	12.4	2,012.1	0.2	1.4	1	1	1
04/20/2020 21:00	-0.1	12.4	2,018.1	0.2	1.4	1	1	1
04/20/2020 22:00	0.1	12.8	1,914.2	0.2	1.3	1	1	1
04/20/2020 23:00	0.0	15.8	552.1	0.0	0.4	1	0	0
Average/Sum#:	0.4	13.9	1,564.2	0.4	1.1	22 #	19 #	6 #
Minimum:	-0.2	12.4	490.9	0.0	0.3	0	0	0
Maximum:	0.7	17.4	2,018.1	0.7	1.4	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/21/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 07:00	0.0	18.0	399.8	0.0	0.3	1	0	0
04/22/2020 08:00	0.0	16.5	598.5	0.0	0.4	1	0	0
04/22/2020 09:00	0.0	14.2	1,202.4	0.0	0.8	1	0	0
04/22/2020 10:00	0.6	14.0	1,251.5	0.6	0.9	1	1	0
04/22/2020 11:00	0.0	17.0	225.3	0.0	0.2	1	0	0
04/22/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.1	15.9	735.5	0.1	0.5	5 #	1 #	0 #
Minimum:	0.0	14.0	225.3	0.0	0.2	0	0	0
Maximum:	0.6	18.0	1,251.5	0.6	0.9	1	1	0
%SI	79.17	79.17	79.17	79.17	79.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/23/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 14:00	0.0	0.0	454.0	0.0	0.3	1	0	0
04/24/2020 15:00	0.0	0.0	717.7	0.0	0.5	1	0	0
04/24/2020 16:00	0.0	0.0	1,511.5	0.0	1.1	1	0	0
04/24/2020 17:00	0.6	0.0	1,529.9	0.6	1.1	1	1	0
04/24/2020 18:00	0.7	0.0	1,772.4	0.7	1.2	1	1	1
04/24/2020 19:00	0.2	11.8	2,051.6	0.4	1.4	1	1	1
04/24/2020 20:00	0.2	11.9	2,039.4	0.4	1.4	1	1	1
04/24/2020 21:00	0.2	12.7	1,865.3	0.4	1.3	1	1	1
04/24/2020 22:00	0.0	15.9	533.0	0.0	0.4	1	0	0
04/24/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.2	13.1	1,386.1	0.3	1.0	9 #	5 #	4 #
Minimum:	0.0	11.8	454.0	0.0	0.3	0	0	0
Maximum:	0.7	15.9	2,051.6	0.4	1.4	1	1	1
%SI	62.50	83.33	62.50	83.33	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/28/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/28/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/28/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/28/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/28/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/28/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/28/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/28/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/28/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/28/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/28/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/28/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/28/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/28/2020 13:00	0.0	17.6	438.5	0.0	0.3	1	0	0
04/28/2020 14:00	0.0	15.7	737.6	0.0	0.5	1	0	0
04/28/2020 15:00	0.0	14.0	1,508.3	0.0	1.1	1	0	0
04/28/2020 16:00	0.7	13.9	1,462.7	0.7	1.0	1	1	1
04/28/2020 17:00	0.1	12.0	2,000.9	0.2	1.4	1	1	1
04/28/2020 18:00	0.2	11.5	2,079.8	0.4	1.5	1	1	1
04/28/2020 19:00	0.2	11.5	2,088.2	0.4	1.5	1	1	1
04/28/2020 20:00	0.2	11.5	2,091.3	0.4	1.5	1	1	1
04/28/2020 21:00	0.0	12.8	1,584.4	0.0	1.1	1	0	1
04/28/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/28/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.2	13.4	1,554.6	0.2	1.1	9 #	5 #	6 #
Minimum:	0.0	11.5	438.5	0.0	0.3	0	0	0
Maximum:	0.7	17.6	2,091.3	0.7	1.5	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/30/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/04/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/05/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/07/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/10/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/11/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/13/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/14/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/15/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/17/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/18/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/19/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/20/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/21/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/23/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 10:00	0.0	18.3	2,022.9	0.0	1.4	1	0	0
05/26/2020 11:00	0.0	20.0	2,014.1	0.0	1.4	1	0	0
05/26/2020 12:00	0.0	17.3	2,025.6	0.0	1.4	1	0	0
05/26/2020 13:00	0.0	17.2	2,025.8	0.0	1.4	1	0	0
05/26/2020 14:00	0.0	15.9	2,088.3	0.0	1.5	1	0	0
05/26/2020 15:00	0.0	16.4	2,086.1	0.0	1.5	1	0	0
05/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	17.5	2,043.8	0.0	1.4	6 #	0 #	0 #
Minimum:	0.0	15.9	2,014.1	0.0	1.4	0	0	0
Maximum:	0.0	20.0	2,088.3	0.0	1.5	1	0	0
%SI	75.00	75.00	75.00	75.00	75.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/28/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 12:00	0.0	0.0	2,033.2	0.0	1.4	1	0	0
05/28/2020 13:00	0.0	0.0	2,037.2	0.0	1.4	1	0	0
05/28/2020 14:00	0.0	0.0	2,093.7	0.0	1.5	1	0	0
05/28/2020 15:00	0.0	0.0	2,081.8	0.0	1.5	1	0	0
05/28/2020 16:00	0.6	0.0	2,094.2	0.6	1.5	1	1	0
05/28/2020 17:00	0.6	14.0	2,024.2	0.6	1.4	1	1	0
05/28/2020 18:00	0.6	13.9	2,047.5	0.6	1.4	1	1	0
05/28/2020 19:00	0.6	14.1	2,052.1	0.6	1.4	1	1	0
05/28/2020 20:00	0.6	14.1	2,056.2	0.6	1.4	1	1	0
05/28/2020 21:00	0.6	14.1	2,060.5	0.6	1.4	1	1	0
05/28/2020 22:00	0.6	14.1	2,058.2	0.6	1.4	1	1	0
05/28/2020 23:00	0.6	14.0	2,056.5	0.6	1.4	1	1	0
Average/Sum#:	0.4	14.0	2,057.9	0.6	1.4	12 #	8 #	0 #
Minimum:	0.0	13.9	2,024.2	0.6	1.4	0	0	0
Maximum:	0.6	14.1	2,094.2	0.6	1.5	1	1	0
%SI	50.00	70.83	50.00	70.83	50.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/29/2020 00:00	0.6	13.9	2,057.9	0.6	1.4	1	1	0
05/29/2020 01:00	0.0	14.6	2,063.9	0.0	1.4	1	0	0
05/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.3	14.3	2,060.9	0.3	1.4	2 #	1 #	0 #
Minimum:	0.0	13.9	2,057.9	0.0	1.4	0	0	0
Maximum:	0.6	14.6	2,063.9	0.6	1.4	1	1	0
%SI	91.67	91.67	91.67	91.67	91.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/30/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/31/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/01/2020 12:00	0.0	19.0	2,017.0	0.0	1.4	1	0	0
06/01/2020 13:00	0.0	17.3	2,026.3	0.0	1.4	1	0	0
06/01/2020 14:00	0.0	16.3	2,052.5	0.0	1.4	1	0	0
06/01/2020 15:00	0.7	14.0	2,047.6	0.7	1.4	1	1	1
06/01/2020 16:00	0.6	14.2	2,069.4	0.6	1.4	1	1	0
06/01/2020 17:00	0.6	14.1	2,087.4	0.6	1.5	1	1	0
06/01/2020 18:00	0.6	14.1	2,091.8	0.6	1.5	1	1	0
06/01/2020 19:00	0.6	14.1	2,067.0	0.6	1.4	1	1	0
06/01/2020 20:00	0.6	14.1	2,071.7	0.6	1.5	1	1	0
06/01/2020 21:00	0.6	14.1	2,073.3	0.6	1.5	1	1	0
06/01/2020 22:00	0.6	14.2	2,086.3	0.6	1.5	1	1	0
06/01/2020 23:00	0.6	14.1	2,068.4	0.6	1.4	1	1	0
Average/Sum#:	0.5	15.0	2,063.2	0.5	1.4	12 #	9 #	1 #
Minimum:	0.0	14.0	2,017.0	0.0	1.4	0	0	0
Maximum:	0.7	19.0	2,091.8	0.7	1.5	1	1	1
%SI	50.00	50.00	50.00	50.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/02/2020 00:00	0.6	14.1	2,087.7	0.6	1.5	1	1	0
06/02/2020 01:00	0.6	14.1	2,080.2	0.6	1.5	1	1	0
06/02/2020 02:00	0.6	14.1	2,070.6	0.6	1.4	1	1	0
06/02/2020 03:00	0.6	14.1	2,061.3	0.6	1.4	1	1	0
06/02/2020 04:00	0.6	14.1	2,065.5	0.6	1.4	1	1	0
06/02/2020 05:00	0.6	14.1	2,053.2	0.6	1.4	1	1	0
06/02/2020 06:00	0.6	14.1	2,060.3	0.6	1.4	1	1	0
06/02/2020 07:00	0.6	14.1	2,070.5	0.6	1.4	1	1	0
06/02/2020 08:00	0.6	14.1	2,061.8	0.6	1.4	1	1	0
06/02/2020 09:00	0.6	14.1	2,083.5	0.6	1.5	1	1	0
06/02/2020 10:00	0.6	14.1	2,060.0	0.6	1.4	1	1	0
06/02/2020 11:00	0.6	14.2	2,035.2	0.6	1.4	1	1	0
06/02/2020 12:00	0.7	14.0	2,067.7	0.7	1.4	1	1	1
06/02/2020 13:00	0.2	12.1	2,426.9	0.4	1.7	1	1	1
06/02/2020 14:00	0.4	11.7	2,488.6	0.5	1.7	1	1	1
06/02/2020 15:00	0.5	11.7	2,504.8	0.5	1.8	1	1	1
06/02/2020 16:00	0.5	11.8	2,500.3	0.5	1.8	1	1	1
06/02/2020 17:00	0.5	12.1	2,418.5	0.5	1.7	1	1	1
06/02/2020 18:00	0.5	12.1	2,455.8	0.5	1.7	1	1	1
06/02/2020 19:00	0.4	12.1	2,434.3	0.5	1.7	1	1	1
06/02/2020 20:00	0.2	12.1	2,435.2	0.4	1.7	1	1	1
06/02/2020 21:00	0.4	12.2	2,419.4	0.5	1.7	1	1	1
06/02/2020 22:00	0.4	12.2	2,404.9	0.5	1.7	1	1	1
06/02/2020 23:00	0.4	12.2	2,401.3	0.5	1.7	1	1	1
Average/Sum#:	0.5	13.2	2,239.5	0.6	1.6	24 #	24 #	12 #
Minimum:	0.2	11.7	2,035.2	0.4	1.4	1	1	0
Maximum:	0.7	14.2	2,504.8	0.7	1.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/03/2020 00:00	0.4	12.3	2,377.1	0.5	1.7	1	1	1
06/03/2020 01:00	0.6	14.1	2,057.7	0.6	1.4	1	1	0
06/03/2020 02:00	0.6	14.1	2,052.1	0.6	1.4	1	1	0
06/03/2020 03:00	0.6	14.1	2,042.6	0.6	1.4	1	1	0
06/03/2020 04:00	0.6	14.1	2,059.3	0.6	1.4	1	1	0
06/03/2020 05:00	0.6	14.1	2,064.3	0.6	1.4	1	1	0
06/03/2020 06:00	0.6	14.1	2,036.7	0.6	1.4	1	1	0
06/03/2020 07:00	0.6	14.1	2,047.9	0.6	1.4	1	1	0
06/03/2020 08:00	0.6	14.1	2,101.9	0.6	1.5	1	1	0
06/03/2020 09:00	0.6	14.1	2,056.4	0.6	1.4	1	1	0
06/03/2020 10:00	0.7	14.0	2,052.4	0.7	1.4	1	1	1
06/03/2020 11:00	-0.2	12.2	2,392.3	0.1	1.7	1	1	1
06/03/2020 12:00	0.1	11.6	2,486.0	0.2	1.7	1	1	1
06/03/2020 13:00	0.2	11.6	2,501.5	0.4	1.8	1	1	1
06/03/2020 14:00	0.4	11.6	2,489.1	0.5	1.7	1	1	1
06/03/2020 15:00	0.4	11.6	2,453.6	0.5	1.7	1	1	1
06/03/2020 16:00	0.4	11.6	2,481.4	0.5	1.7	1	1	1
06/03/2020 17:00	0.2	11.6	2,482.6	0.4	1.7	1	1	1
06/03/2020 18:00	0.1	11.8	2,462.2	0.2	1.7	1	1	1
06/03/2020 19:00	0.1	11.7	2,456.2	0.2	1.7	1	1	1
06/03/2020 20:00	-0.1	12.0	2,415.4	0.2	1.7	1	1	1
06/03/2020 21:00	-0.1	12.2	2,399.2	0.2	1.7	1	1	1
06/03/2020 22:00	-0.1	12.3	2,373.6	0.2	1.7	1	1	1
06/03/2020 23:00	0.1	11.9	2,428.4	0.2	1.7	1	1	1
Average/Sum#:	0.3	12.8	2,282.1	0.4	1.6	24 #	24 #	15 #
Minimum:	-0.2	11.6	2,036.7	0.1	1.4	1	1	0
Maximum:	0.7	14.1	2,501.5	0.7	1.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/04/2020 00:00	0.0	14.0	2,118.3	0.0	1.5	1	0	1
06/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 06:00	0.0	18.4	2,034.1	0.0	1.4	1	0	0
06/04/2020 07:00	0.0	15.8	2,079.3	0.0	1.5	1	0	0
06/04/2020 08:00	0.6	14.2	2,057.8	0.6	1.4	1	1	0
06/04/2020 09:00	0.6	14.2	2,053.6	0.6	1.4	1	1	0
06/04/2020 10:00	0.6	14.1	2,051.4	0.6	1.4	1	1	0
06/04/2020 11:00	0.6	14.2	2,044.8	0.6	1.4	1	1	0
06/04/2020 12:00	0.6	14.2	2,041.2	0.6	1.4	1	1	0
06/04/2020 13:00	0.7	14.1	2,064.5	0.7	1.4	1	1	1
06/04/2020 14:00	-0.1	12.2	2,395.8	0.2	1.7	1	1	1
06/04/2020 15:00	0.1	11.8	2,469.1	0.2	1.7	1	1	1
06/04/2020 16:00	0.1	11.7	2,467.6	0.2	1.7	1	1	1
06/04/2020 17:00	0.1	11.7	2,470.8	0.2	1.7	1	1	1
06/04/2020 18:00	0.1	11.7	2,445.7	0.2	1.7	1	1	1
06/04/2020 19:00	-0.1	11.9	2,418.1	0.2	1.7	1	1	1
06/04/2020 20:00	-0.1	11.8	2,498.2	0.2	1.7	1	1	1
06/04/2020 21:00	0.1	11.7	2,468.9	0.2	1.7	1	1	1
06/04/2020 22:00	-0.1	12.0	2,421.8	0.2	1.7	1	1	1
06/04/2020 23:00	-0.1	12.2	2,382.8	0.2	1.7	1	1	1
Average/Sum#:	0.2	13.3	2,262.3	0.3	1.6	19 #	16 #	12 #
Minimum:	-0.1	11.7	2,034.1	0.0	1.4	0	0	0
Maximum:	0.7	18.4	2,498.2	0.7	1.7	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/05/2020 00:00	0.0	14.2	2,086.7	0.0	1.5	1	0	1
06/05/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	14.2	2,086.7	0.0	1.5	1 #	0 #	1 #
Minimum:	0.0	14.2	2,086.7	0.0	1.5	0	0	0
Maximum:	0.0	14.2	2,086.7	0.0	1.5	1	0	1
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/07/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 15:00	0.0	17.9	2,123.3	0.0	1.5	1	0	0
06/08/2020 16:00	0.0	16.3	2,024.2	0.0	1.4	1	0	0
06/08/2020 17:00	0.0	18.1	2,093.2	0.0	1.5	1	0	0
06/08/2020 18:00	0.0	14.6	2,349.7	0.0	1.6	1	0	0
06/08/2020 19:00	0.7	14.0	2,097.9	0.7	1.5	1	1	1
06/08/2020 20:00	-0.4	12.8	2,264.5	-0.1	1.6	1	1	1
06/08/2020 21:00	-0.4	12.4	2,333.6	-0.1	1.6	1	1	1
06/08/2020 22:00	-0.4	12.6	2,318.9	-0.1	1.6	1	1	1
06/08/2020 23:00	0.0	13.7	2,124.4	0.0	1.5	1	0	1
Average/Sum#:	-0.1	14.7	2,192.2	0.0	1.5	9 #	4 #	5 #
Minimum:	-0.4	12.4	2,024.2	-0.1	1.4	0	0	0
Maximum:	0.7	18.1	2,349.7	0.7	1.6	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 12:00	0.0	18.3	2,006.8	0.0	1.4	1	0	0
06/09/2020 13:00	0.0	17.5	1,994.2	0.0	1.4	1	0	0
06/09/2020 14:00	0.0	16.8	2,140.6	0.0	1.5	1	0	0
06/09/2020 15:00	0.0	14.0	2,140.5	0.0	1.5	1	0	0
06/09/2020 16:00	0.7	14.0	2,038.3	0.7	1.4	1	1	1
06/09/2020 17:00	-0.4	12.4	2,336.5	-0.1	1.6	1	1	1
06/09/2020 18:00	-0.2	12.0	2,418.2	0.1	1.7	1	1	1
06/09/2020 19:00	-0.2	11.9	2,431.1	0.1	1.7	1	1	1
06/09/2020 20:00	-0.4	12.1	2,389.5	-0.1	1.7	1	1	1
06/09/2020 21:00	-0.4	12.3	2,363.6	-0.1	1.7	1	1	1
06/09/2020 22:00	-0.4	12.5	2,322.2	-0.1	1.6	1	1	1
06/09/2020 23:00	0.0	14.2	2,103.2	0.0	1.5	1	0	1
Average/Sum#:	-0.1	14.0	2,223.7	0.0	1.6	12 #	7 #	8 #
Minimum:	-0.4	11.9	1,994.2	-0.1	1.4	0	0	0
Maximum:	0.7	18.3	2,431.1	0.7	1.7	1	1	1
%SI	50.00	50.00	50.00	50.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/10/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 10:00	0.0	17.7	2,008.6	0.0	1.4	1	0	0
06/10/2020 11:00	0.0	15.7	2,288.9	0.0	1.6	1	0	0
06/10/2020 12:00	0.0	14.2	2,052.4	0.0	1.4	1	0	0
06/10/2020 13:00	0.6	14.0	2,044.6	0.6	1.4	1	1	0
06/10/2020 14:00	0.7	13.9	2,093.0	0.7	1.5	1	1	1
06/10/2020 15:00	-0.5	12.2	2,406.4	-0.1	1.7	1	1	1
06/10/2020 16:00	-0.2	11.6	2,701.4	0.1	1.9	1	1	1
06/10/2020 17:00	-0.2	11.8	2,656.5	0.1	1.9	1	1	1
06/10/2020 18:00	-0.2	11.7	2,569.2	0.1	1.8	1	1	1
06/10/2020 19:00	-0.2	11.9	2,415.8	0.1	1.7	1	1	1
06/10/2020 20:00	-0.2	12.0	2,406.3	0.1	1.7	1	1	1
06/10/2020 21:00	-0.2	12.1	2,393.9	0.1	1.7	1	1	1
06/10/2020 22:00	-0.4	12.4	2,303.2	-0.1	1.6	1	1	1
06/10/2020 23:00	-0.4	12.3	2,357.2	-0.1	1.7	1	1	1
Average/Sum#:	-0.1	13.1	2,335.5	0.1	1.6	14 #	11 #	10 #
Minimum:	-0.5	11.6	2,008.6	-0.1	1.4	0	0	0
Maximum:	0.7	17.7	2,701.4	0.7	1.9	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/11/2020 00:00	0.1	12.7	2,290.6	0.2	1.6	1	1	1
06/11/2020 01:00	0.2	12.6	2,300.1	0.4	1.6	1	1	1
06/11/2020 02:00	-0.1	12.8	2,264.9	0.1	1.6	1	1	1
06/11/2020 03:00	-0.1	12.6	2,305.9	0.1	1.6	1	1	1
06/11/2020 04:00	-0.1	12.9	2,219.8	0.1	1.6	1	1	1
06/11/2020 05:00	0.6	13.8	2,044.7	0.6	1.4	1	1	0
06/11/2020 06:00	0.6	13.9	2,064.7	0.6	1.4	1	1	0
06/11/2020 07:00	0.6	13.8	2,038.9	0.6	1.4	1	1	0
06/11/2020 08:00	0.6	13.8	2,059.4	0.6	1.4	1	1	0
06/11/2020 09:00	0.6	13.8	2,005.3	0.6	1.4	1	1	0
06/11/2020 10:00	0.6	13.7	2,012.8	0.6	1.4	1	1	0
06/11/2020 11:00	0.6	14.0	2,020.5	0.6	1.4	1	1	0
06/11/2020 12:00	0.6	14.0	2,008.2	0.6	1.4	1	1	0
06/11/2020 13:00	0.6	14.1	2,013.0	0.6	1.4	1	1	0
06/11/2020 14:00	0.6	14.0	2,023.1	0.6	1.4	1	1	0
06/11/2020 15:00	0.6	14.0	1,999.1	0.6	1.4	1	1	0
06/11/2020 16:00	0.6	14.0	2,029.7	0.6	1.4	1	1	0
06/11/2020 17:00	0.7	14.0	2,024.1	0.7	1.4	1	1	1
06/11/2020 18:00	-0.5	12.3	2,325.7	-0.1	1.6	1	1	1
06/11/2020 19:00	-0.1	11.6	2,452.8	0.2	1.7	1	1	1
06/11/2020 20:00	-0.2	11.9	2,376.0	0.1	1.7	1	1	1
06/11/2020 21:00	-0.2	12.2	2,358.4	0.1	1.7	1	1	1
06/11/2020 22:00	-0.2	12.4	2,283.7	0.1	1.6	1	1	1
06/11/2020 23:00	0.0	14.4	2,062.6	0.0	1.4	1	0	1
Average/Sum#:	0.3	13.3	2,149.3	0.4	1.5	24 #	23 #	12 #
Minimum:	-0.5	11.6	1,999.1	-0.1	1.4	1	0	0
Maximum:	0.7	14.4	2,452.8	0.7	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/13/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/14/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/15/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/17/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 12:00	0.0	18.3	1,972.6	0.0	1.4	1	0	0
06/17/2020 13:00	0.0	17.4	1,978.3	0.0	1.4	1	0	0
06/17/2020 14:00	0.0	17.3	2,152.7	0.0	1.5	1	0	0
06/17/2020 15:00	0.0	15.9	2,192.9	0.0	1.5	1	0	0
06/17/2020 16:00	0.6	14.1	2,315.5	0.6	1.6	1	1	0
06/17/2020 17:00	0.7	13.9	2,356.2	0.7	1.6	1	1	1
06/17/2020 18:00	-0.4	12.4	2,642.5	-0.1	1.8	1	1	1
06/17/2020 19:00	-0.2	11.8	2,801.8	0.1	2.0	1	1	1
06/17/2020 20:00	-0.2	11.9	2,575.7	0.1	1.8	1	1	1
06/17/2020 21:00	-0.2	12.2	2,434.5	0.1	1.7	1	1	1
06/17/2020 22:00	-0.4	12.3	2,382.1	-0.1	1.7	1	1	1
06/17/2020 23:00	0.0	14.4	2,091.5	0.0	1.5	1	0	1
Average/Sum#:	0.0	14.3	2,324.7	0.1	1.6	12 #	7 #	7 #
Minimum:	-0.4	11.8	1,972.6	-0.1	1.4	0	0	0
Maximum:	0.7	18.3	2,801.8	0.7	2.0	1	1	1
%SI	50.00	50.00	50.00	50.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/18/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 11:00	0.0	18.0	1,999.5	0.0	1.4	1	0	0
06/18/2020 12:00	0.0	15.3	2,008.2	0.0	1.4	1	0	0
06/18/2020 13:00	0.6	14.0	2,074.3	0.6	1.5	1	1	0
06/18/2020 14:00	0.7	14.0	2,087.3	0.7	1.5	1	1	1
06/18/2020 15:00	-0.5	12.5	2,325.2	-0.2	1.6	1	1	1
06/18/2020 16:00	-0.2	11.9	2,411.4	0.1	1.7	1	1	1
06/18/2020 17:00	-0.2	11.9	2,541.7	0.1	1.8	1	1	1
06/18/2020 18:00	-0.2	11.9	2,730.5	0.1	1.9	1	1	1
06/18/2020 19:00	-0.2	11.9	2,755.7	0.1	1.9	1	1	1
06/18/2020 20:00	-0.2	12.0	2,786.9	0.1	2.0	1	1	1
06/18/2020 21:00	-0.2	12.1	2,604.6	0.1	1.8	1	1	1
06/18/2020 22:00	-0.2	12.7	2,299.1	0.1	1.6	1	1	1
06/18/2020 23:00	0.0	15.8	2,016.9	0.0	1.4	1	0	0
Average/Sum#:	0.0	13.4	2,357.0	0.1	1.7	13 #	10 #	9 #
Minimum:	-0.5	11.9	1,999.5	-0.2	1.4	0	0	0
Maximum:	0.7	18.0	2,786.9	0.7	2.0	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/19/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/20/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/21/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/21/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/21/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/21/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/21/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/21/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/21/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/21/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/21/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/21/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/21/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/21/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/21/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/21/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/21/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/21/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/21/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/21/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/21/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/21/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/21/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/21/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/21/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/22/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/22/2020 09:00	0.0	17.9	1,984.6	0.0	1.4	1	0	0
06/22/2020 10:00	0.0	18.5	1,975.6	0.0	1.4	1	0	0
06/22/2020 11:00	0.0	16.2	2,021.1	0.0	1.4	1	0	0
06/22/2020 12:00	0.0	14.1	2,258.4	0.0	1.6	1	0	0
06/22/2020 13:00	0.7	13.9	2,346.7	0.7	1.6	1	1	1
06/22/2020 14:00	-0.4	12.1	2,501.3	-0.1	1.8	1	1	1
06/22/2020 15:00	-0.2	11.7	2,428.2	0.1	1.7	1	1	1
06/22/2020 16:00	-0.2	11.7	2,411.1	0.1	1.7	1	1	1
06/22/2020 17:00	-0.2	11.8	2,419.0	0.1	1.7	1	1	1
06/22/2020 18:00	-0.1	11.6	2,447.9	0.2	1.7	1	1	1
06/22/2020 19:00	-0.1	11.5	2,762.0	0.2	1.9	1	1	1
06/22/2020 20:00	-0.1	11.5	2,879.1	0.2	2.0	1	1	1
06/22/2020 21:00	-0.2	11.7	2,785.1	0.1	1.9	1	1	1
06/22/2020 22:00	-0.4	11.9	2,633.9	-0.1	1.8	1	1	1
06/22/2020 23:00	-0.4	12.5	2,681.4	-0.1	1.9	1	1	1
Average/Sum#:	-0.1	13.2	2,435.7	0.1	1.7	15 #	11 #	11 #
Minimum:	-0.4	11.5	1,975.6	-0.1	1.4	0	0	0
Maximum:	0.7	18.5	2,879.1	0.7	2.0	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/23/2020 00:00	0.0	14.3	2,464.3	0.0	1.7	1	0	1
06/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 07:00	0.0	19.5	174.2	0.0	0.1	1	0	0
06/23/2020 08:00	0.0	15.9	671.3	0.0	0.5	1	0	0
06/23/2020 09:00	0.0	14.0	1,348.9	0.0	0.9	1	0	0
06/23/2020 10:00	0.6	14.0	1,333.7	0.6	0.9	1	1	0
06/23/2020 11:00	0.6	14.0	1,429.7	0.6	1.0	1	1	0
06/23/2020 12:00	0.6	14.0	1,528.9	0.6	1.1	1	1	0
06/23/2020 13:00	0.6	13.9	1,481.3	0.6	1.0	1	1	0
06/23/2020 14:00	0.6	14.0	1,335.9	0.6	0.9	1	1	0
06/23/2020 15:00	0.7	13.8	1,623.7	0.7	1.1	1	1	1
06/23/2020 16:00	-0.4	11.8	2,035.6	-0.1	1.4	1	1	1
06/23/2020 17:00	-0.2	11.6	2,069.4	0.1	1.4	1	1	1
06/23/2020 18:00	-0.1	11.7	2,063.4	0.2	1.4	1	1	1
06/23/2020 19:00	-0.1	11.6	2,091.1	0.2	1.5	1	1	1
06/23/2020 20:00	-0.1	11.5	2,119.6	0.2	1.5	1	1	1
06/23/2020 21:00	-0.2	11.7	2,077.4	0.1	1.5	1	1	1
06/23/2020 22:00	-0.2	11.8	2,070.4	0.1	1.4	1	1	1
06/23/2020 23:00	-0.2	11.8	2,067.6	0.1	1.4	1	1	1
Average/Sum#:	0.1	13.4	1,665.9	0.3	1.2	18 #	14 #	10 #
Minimum:	-0.4	11.5	174.2	-0.1	0.1	0	0	0
Maximum:	0.7	19.5	2,464.3	0.7	1.7	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/24/2020 00:00	-0.2	12.5	1,967.1	0.1	1.4	1	1	1
06/24/2020 01:00	-0.2	12.8	1,915.1	0.1	1.3	1	1	1
06/24/2020 02:00	-0.2	12.8	1,908.8	0.1	1.3	1	1	1
06/24/2020 03:00	-0.2	12.8	1,906.8	0.1	1.3	1	1	1
06/24/2020 04:00	-0.4	12.4	1,990.9	-0.1	1.4	1	1	1
06/24/2020 05:00	-0.5	12.1	2,037.9	-0.1	1.4	1	1	1
06/24/2020 06:00	-0.5	12.5	1,930.3	-0.2	1.4	1	1	1
06/24/2020 07:00	0.6	14.0	1,548.2	0.6	1.1	1	1	0
06/24/2020 08:00	0.6	14.0	1,545.0	0.6	1.1	1	1	0
06/24/2020 09:00	0.6	14.0	1,547.4	0.6	1.1	1	1	0
06/24/2020 10:00	0.6	14.0	1,501.9	0.6	1.1	1	1	0
06/24/2020 11:00	0.7	13.9	1,553.2	0.7	1.1	1	1	1
06/24/2020 12:00	-0.5	12.0	2,025.2	-0.1	1.4	1	1	1
06/24/2020 13:00	-0.4	11.7	2,072.1	0.1	1.5	1	1	1
06/24/2020 14:00	-0.2	11.6	2,077.9	0.1	1.5	1	1	1
06/24/2020 15:00	-0.2	11.6	2,080.8	0.1	1.5	1	1	1
06/24/2020 16:00	-0.2	11.6	2,073.8	0.1	1.5	1	1	1
06/24/2020 17:00	-0.2	11.6	2,077.2	0.1	1.5	1	1	1
06/24/2020 18:00	-0.2	11.5	2,090.3	0.1	1.5	1	1	1
06/24/2020 19:00	-0.2	11.6	2,080.7	0.1	1.5	1	1	1
06/24/2020 20:00	-0.2	11.6	2,083.2	0.1	1.5	1	1	1
06/24/2020 21:00	-0.2	11.6	2,084.9	0.1	1.5	1	1	1
06/24/2020 22:00	-0.4	11.7	2,060.9	0.1	1.4	1	1	1
06/24/2020 23:00	-0.5	11.8	2,056.6	-0.1	1.4	1	1	1
Average/Sum#:	-0.1	12.4	1,925.7	0.2	1.4	24 #	24 #	20 #
Minimum:	-0.5	11.5	1,501.9	-0.2	1.1	1	1	0
Maximum:	0.7	14.0	2,090.3	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/25/2020 00:00	0.0	13.8	1,286.4	0.0	0.9	1	0	1
06/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 12:00	0.0	18.6	293.8	0.0	0.2	1	0	0
06/25/2020 13:00	0.0	15.1	966.6	0.0	0.7	1	0	0
06/25/2020 14:00	0.6	14.1	1,280.4	0.6	0.9	1	1	0
06/25/2020 15:00	0.6	14.0	1,371.6	0.6	1.0	1	1	0
06/25/2020 16:00	0.6	14.1	1,313.9	0.6	0.9	1	1	0
06/25/2020 17:00	0.7	13.9	1,605.8	0.7	1.1	1	1	1
06/25/2020 18:00	-0.4	11.8	2,029.5	-0.1	1.4	1	1	1
06/25/2020 19:00	-0.2	11.9	2,021.5	0.1	1.4	1	1	1
06/25/2020 20:00	-0.2	12.0	1,984.7	0.1	1.4	1	1	1
06/25/2020 21:00	-0.4	12.2	1,959.2	-0.1	1.4	1	1	1
06/25/2020 22:00	0.0	13.4	1,442.5	0.0	1.0	1	0	1
06/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.1	13.7	1,463.0	0.2	1.0	12 #	8 #	7 #
Minimum:	-0.4	11.8	293.8	-0.1	0.2	0	0	0
Maximum:	0.7	18.6	2,029.5	0.7	1.4	1	1	1
%SI	50.00	50.00	50.00	50.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 10:00	0.0	18.7	292.8	0.0	0.2	1	0	0
06/26/2020 11:00	0.0	15.3	868.5	0.0	0.6	1	0	0
06/26/2020 12:00	0.0	17.3	173.6	0.0	0.1	1	0	0
06/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 16:00	0.0	17.3	469.4	0.0	0.3	1	0	0
06/26/2020 17:00	0.0	13.5	1,499.5	0.0	1.0	1	0	1
06/26/2020 18:00	-0.1	11.5	2,073.3	0.2	1.5	1	1	1
06/26/2020 19:00	-0.1	11.4	2,088.2	0.2	1.5	1	1	1
06/26/2020 20:00	0.1	11.5	2,085.8	0.2	1.5	1	1	1
06/26/2020 21:00	0.1	11.8	2,062.5	0.2	1.4	1	1	1
06/26/2020 22:00	-0.4	12.3	1,952.1	-0.1	1.4	1	1	1
06/26/2020 23:00	0.7	13.6	1,444.4	0.7	1.0	1	1	1
Average/Sum#:	0.0	14.0	1,364.6	0.1	1.0	11 #	6 #	7 #
Minimum:	-0.4	11.4	173.6	-0.1	0.1	0	0	0
Maximum:	0.7	18.7	2,088.2	0.7	1.5	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/27/2020 00:00	0.0	14.5	1,044.5	0.0	0.7	1	0	0
06/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	14.5	1,044.5	0.0	0.7	1 #	0 #	0 #
Minimum:	0.0	14.5	1,044.5	0.0	0.7	0	0	0
Maximum:	0.0	14.5	1,044.5	0.0	0.7	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/28/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/30/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 14:00	0.0	17.7	417.5	0.0	0.3	1	0	0
06/30/2020 15:00	0.0	15.8	737.2	0.0	0.5	1	0	0
06/30/2020 16:00	0.6	14.1	1,330.2	0.6	0.9	1	1	0
06/30/2020 17:00	0.7	14.0	1,512.0	0.7	1.1	1	1	1
06/30/2020 18:00	-0.4	12.1	2,042.6	-0.1	1.4	1	1	1
06/30/2020 19:00	-0.2	11.8	2,098.6	0.1	1.5	1	1	1
06/30/2020 20:00	-0.2	11.8	2,088.8	0.1	1.5	1	1	1
06/30/2020 21:00	-0.2	12.0	2,067.6	0.1	1.4	1	1	1
06/30/2020 22:00	0.0	13.9	1,216.5	0.0	0.9	1	0	1
06/30/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	13.7	1,501.2	0.2	1.1	9 #	6 #	6 #
Minimum:	-0.4	11.8	417.5	-0.1	0.3	0	0	0
Maximum:	0.7	17.7	2,098.6	0.7	1.5	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/01/2020 00:00	0.6	13.9	1,350.6	0.6	0.4	1	1	0
04/01/2020 01:00	0.6	13.9	1,354.2	0.6	0.4	1	1	0
04/01/2020 02:00	0.6	13.9	1,349.8	0.6	0.4	1	1	0
04/01/2020 03:00	0.6	13.8	1,592.9	0.6	0.5	1	1	0
04/01/2020 04:00	0.6	13.9	1,592.9	0.6	0.5	1	1	0
04/01/2020 05:00	0.6	13.9	1,581.7	0.6	0.5	1	1	0
04/01/2020 06:00	0.6	13.9	1,533.5	0.6	0.5	1	1	0
04/01/2020 07:00	0.6	13.9	1,612.1	0.6	0.5	1	1	0
04/01/2020 08:00	0.6	13.9	1,519.3	0.6	0.5	1	1	0
04/01/2020 09:00	0.6	13.9	1,439.4	0.6	0.4	1	1	0
04/01/2020 10:00	0.6	14.0	1,343.9	0.6	0.4	1	1	0
04/01/2020 11:00	0.6	14.0	1,318.4	0.6	0.4	1	1	0
04/01/2020 12:00	0.6	14.0	1,329.7	0.6	0.4	1	1	0
04/01/2020 13:00	0.6	14.0	1,505.8	0.6	0.5	1	1	0
04/01/2020 14:00	0.6	14.0	1,562.1	0.6	0.5	1	1	0
04/01/2020 15:00	0.6	13.9	1,642.9	0.6	0.5	1	1	0
04/01/2020 16:00	0.6	13.9	1,666.3	0.6	0.5	1	1	0
04/01/2020 17:00	0.7	13.9	1,607.3	0.7	0.5	1	1	1
04/01/2020 18:00	0.7	12.9	2,015.8	0.7	0.6	1	1	1
04/01/2020 19:00	0.7	12.3	2,142.4	0.7	0.6	1	1	1
04/01/2020 20:00	0.7	12.3	2,124.8	0.7	0.6	1	1	1
04/01/2020 21:00	0.7	12.3	2,123.4	0.7	0.6	1	1	1
04/01/2020 22:00	0.7	12.4	2,118.7	0.7	0.6	1	1	1
04/01/2020 23:00	0.7	12.5	2,069.3	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.6	1,645.7	0.6	0.5	24 #	24 #	7 #
Minimum:	0.6	12.3	1,318.4	0.6	0.4	1	1	0
Maximum:	0.7	14.0	2,142.4	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/02/2020 00:00	0.7	13.9	1,569.0	0.7	0.5	1	1	1
04/02/2020 01:00	0.6	13.9	1,538.5	0.6	0.5	1	1	0
04/02/2020 02:00	0.6	13.9	1,633.7	0.6	0.5	1	1	0
04/02/2020 03:00	0.6	13.9	1,697.6	0.6	0.5	1	1	0
04/02/2020 04:00	0.6	13.9	1,690.0	0.6	0.5	1	1	0
04/02/2020 05:00	0.6	13.9	1,594.2	0.6	0.5	1	1	0
04/02/2020 06:00	0.6	13.9	1,688.0	0.6	0.5	1	1	0
04/02/2020 07:00	0.6	13.9	1,642.4	0.6	0.5	1	1	0
04/02/2020 08:00	0.6	13.9	1,694.9	0.6	0.5	1	1	0
04/02/2020 09:00	0.6	13.9	1,685.9	0.6	0.5	1	1	0
04/02/2020 10:00	0.6	13.9	1,659.7	0.6	0.5	1	1	0
04/02/2020 11:00	0.6	13.9	1,574.7	0.6	0.5	1	1	0
04/02/2020 12:00	0.6	13.9	1,612.6	0.6	0.5	1	1	0
04/02/2020 13:00	0.6	14.0	1,670.6	0.6	0.5	1	1	0
04/02/2020 14:00	0.6	14.0	1,683.4	0.6	0.5	1	1	0
04/02/2020 15:00	0.6	14.0	1,681.6	0.6	0.5	1	1	0
04/02/2020 16:00	0.6	14.0	1,645.2	0.6	0.5	1	1	0
04/02/2020 17:00	0.7	13.9	1,634.0	0.7	0.5	1	1	1
04/02/2020 18:00	0.7	12.9	1,990.0	0.7	0.6	1	1	1
04/02/2020 19:00	0.7	12.7	2,050.3	0.7	0.6	1	1	1
04/02/2020 20:00	0.7	12.7	2,051.0	0.7	0.6	1	1	1
04/02/2020 21:00	0.0	14.4	1,219.3	0.0	0.4	1	0	1
04/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.6	13.8	1,677.6	0.6	0.5	22 #	21 #	6 #
Minimum:	0.0	12.7	1,219.3	0.0	0.4	0	0	0
Maximum:	0.7	14.4	2,051.0	0.7	0.6	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 20:00	0.0	17.6	457.7	0.0	0.1	1	0	0
04/03/2020 21:00	0.0	17.1	520.6	0.0	0.2	1	0	0
04/03/2020 22:00	0.0	15.5	873.8	0.0	0.3	1	0	0
04/03/2020 23:00	0.6	13.9	1,546.0	0.6	0.5	1	1	0
Average/Sum#:	0.2	16.0	849.5	0.2	0.3	4 #	1 #	0 #
Minimum:	0.0	13.9	457.7	0.0	0.1	0	0	0
Maximum:	0.6	17.6	1,546.0	0.6	0.5	1	1	0
%SI	83.33	83.33	83.33	83.33	83.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/04/2020 00:00	0.6	13.9	1,617.2	0.6	0.5	1	1	0
04/04/2020 01:00	0.6	13.8	1,703.6	0.6	0.5	1	1	0
04/04/2020 02:00	0.6	13.9	1,457.2	0.6	0.4	1	1	0
04/04/2020 03:00	0.6	13.8	1,693.5	0.6	0.5	1	1	0
04/04/2020 04:00	0.6	13.8	1,672.0	0.6	0.5	1	1	0
04/04/2020 05:00	0.6	13.8	1,692.6	0.6	0.5	1	1	0
04/04/2020 06:00	0.6	13.8	1,672.4	0.6	0.5	1	1	0
04/04/2020 07:00	0.6	13.8	1,693.9	0.6	0.5	1	1	0
04/04/2020 08:00	0.6	13.8	1,682.5	0.6	0.5	1	1	0
04/04/2020 09:00	0.6	13.8	1,674.2	0.6	0.5	1	1	0
04/04/2020 10:00	0.6	13.8	1,652.7	0.6	0.5	1	1	0
04/04/2020 11:00	0.6	13.8	1,677.1	0.6	0.5	1	1	0
04/04/2020 12:00	0.6	13.8	1,690.6	0.6	0.5	1	1	0
04/04/2020 13:00	0.6	13.8	1,687.9	0.6	0.5	1	1	0
04/04/2020 14:00	0.6	13.8	1,698.3	0.6	0.5	1	1	0
04/04/2020 15:00	0.6	13.8	1,661.3	0.6	0.5	1	1	0
04/04/2020 16:00	0.6	13.8	1,691.4	0.6	0.5	1	1	0
04/04/2020 17:00	0.7	13.8	1,652.9	0.7	0.5	1	1	1
04/04/2020 18:00	0.7	12.7	2,001.5	0.7	0.6	1	1	1
04/04/2020 19:00	0.7	12.0	2,148.5	0.7	0.6	1	1	1
04/04/2020 20:00	0.7	12.1	2,126.3	0.7	0.6	1	1	1
04/04/2020 21:00	0.7	12.2	2,117.8	0.7	0.6	1	1	1
04/04/2020 22:00	0.7	12.2	2,111.9	0.7	0.6	1	1	1
04/04/2020 23:00	0.7	12.2	2,113.8	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.4	1,774.6	0.6	0.5	24 #	24 #	7 #
Minimum:	0.6	12.0	1,457.2	0.6	0.4	1	1	0
Maximum:	0.7	13.9	2,148.5	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/05/2020 00:00	0.7	12.2	2,107.3	0.7	0.6	1	1	1
04/05/2020 01:00	0.7	13.6	1,720.7	0.7	0.5	1	1	1
04/05/2020 02:00	0.6	13.8	1,675.4	0.6	0.5	1	1	0
04/05/2020 03:00	0.6	13.8	1,671.3	0.6	0.5	1	1	0
04/05/2020 04:00	0.6	13.8	1,669.7	0.6	0.5	1	1	0
04/05/2020 05:00	0.6	13.8	1,683.3	0.6	0.5	1	1	0
04/05/2020 06:00	0.6	13.8	1,673.0	0.6	0.5	1	1	0
04/05/2020 07:00	0.6	13.8	1,643.0	0.6	0.5	1	1	0
04/05/2020 08:00	0.6	13.8	1,682.6	0.6	0.5	1	1	0
04/05/2020 09:00	0.6	13.8	1,658.3	0.6	0.5	1	1	0
04/05/2020 10:00	0.6	13.8	1,641.6	0.6	0.5	1	1	0
04/05/2020 11:00	0.6	13.8	1,623.8	0.6	0.5	1	1	0
04/05/2020 12:00	0.6	13.8	1,589.3	0.6	0.5	1	1	0
04/05/2020 13:00	0.6	13.9	1,670.3	0.6	0.5	1	1	0
04/05/2020 14:00	0.6	13.9	1,668.0	0.6	0.5	1	1	0
04/05/2020 15:00	0.6	13.9	1,671.0	0.6	0.5	1	1	0
04/05/2020 16:00	0.7	13.4	1,790.9	0.7	0.5	1	1	1
04/05/2020 17:00	0.7	12.3	2,087.3	0.7	0.6	1	1	1
04/05/2020 18:00	0.7	12.4	2,066.7	0.7	0.6	1	1	1
04/05/2020 19:00	0.7	12.4	2,062.5	0.7	0.6	1	1	1
04/05/2020 20:00	0.7	12.4	2,073.7	0.7	0.6	1	1	1
04/05/2020 21:00	0.7	12.4	2,094.4	0.7	0.6	1	1	1
04/05/2020 22:00	0.7	12.5	2,067.6	0.7	0.6	1	1	1
04/05/2020 23:00	0.7	12.5	2,086.0	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.3	1,807.4	0.6	0.5	24 #	24 #	10 #
Minimum:	0.6	12.2	1,589.3	0.6	0.5	1	1	0
Maximum:	0.7	13.9	2,107.3	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/06/2020 00:00	0.7	12.4	2,092.2	0.7	0.6	1	1	1
04/06/2020 01:00	0.7	12.4	2,094.1	0.7	0.6	1	1	1
04/06/2020 02:00	0.7	12.3	2,111.2	0.7	0.6	1	1	1
04/06/2020 03:00	0.7	12.4	2,103.6	0.7	0.6	1	1	1
04/06/2020 04:00	0.7	12.6	2,066.0	0.7	0.6	1	1	1
04/06/2020 05:00	0.7	12.6	2,075.1	0.7	0.6	1	1	1
04/06/2020 06:00	0.7	12.5	2,092.5	0.7	0.6	1	1	1
04/06/2020 07:00	0.7	12.2	2,044.3	0.7	0.6	1	1	1
04/06/2020 08:00	0.6	0.0	1,661.0	0.6	0.5	1	1	0
04/06/2020 09:00	0.6	13.8	1,678.7	0.6	0.5	1	1	0
04/06/2020 10:00	0.6	13.8	1,688.8	0.6	0.5	1	1	0
04/06/2020 11:00	0.6	13.9	1,626.7	0.6	0.5	1	1	0
04/06/2020 12:00	0.6	0.0	1,620.2	0.6	0.5	1	1	0
04/06/2020 13:00	0.6	13.9	1,595.6	0.6	0.5	1	1	0
04/06/2020 14:00	0.6	13.9	1,664.5	0.6	0.5	1	1	0
04/06/2020 15:00	0.6	13.9	1,674.1	0.6	0.5	1	1	0
04/06/2020 16:00	0.7	13.9	1,556.8	0.7	0.5	1	1	1
04/06/2020 17:00	0.7	12.8	2,011.7	0.7	0.6	1	1	1
04/06/2020 18:00	0.7	12.6	2,038.7	0.7	0.6	1	1	1
04/06/2020 19:00	0.7	12.8	1,989.5	0.7	0.6	1	1	1
04/06/2020 20:00	0.7	12.6	2,030.5	0.7	0.6	1	1	1
04/06/2020 21:00	0.7	12.5	2,068.6	0.7	0.6	1	1	1
04/06/2020 22:00	0.7	12.5	2,068.9	0.7	0.6	1	1	1
04/06/2020 23:00	0.7	12.4	2,099.4	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.9	1,906.4	0.7	0.6	24 #	24 #	16 #
Minimum:	0.6	12.2	1,556.8	0.6	0.5	1	1	0
Maximum:	0.7	13.9	2,111.2	0.7	0.6	1	1	1
%SI	8.33	8.33	0.00	8.33	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/07/2020 00:00	0.7	12.7	2,038.6	0.7	0.6	1	1	1
04/07/2020 01:00	0.7	12.8	2,029.6	0.7	0.6	1	1	1
04/07/2020 02:00	0.7	12.8	2,030.8	0.7	0.6	1	1	1
04/07/2020 03:00	0.7	12.8	2,024.5	0.7	0.6	1	1	1
04/07/2020 04:00	0.7	12.8	2,023.2	0.7	0.6	1	1	1
04/07/2020 05:00	0.7	12.8	2,027.8	0.7	0.6	1	1	1
04/07/2020 06:00	0.7	13.0	1,965.8	0.7	0.6	1	1	1
04/07/2020 07:00	0.6	13.8	1,635.9	0.6	0.5	1	1	0
04/07/2020 08:00	0.6	13.8	1,647.1	0.6	0.5	1	1	0
04/07/2020 09:00	0.6	13.8	1,681.9	0.6	0.5	1	1	0
04/07/2020 10:00	0.6	13.9	1,681.1	0.6	0.5	1	1	0
04/07/2020 11:00	0.6	13.9	1,688.0	0.6	0.5	1	1	0
04/07/2020 12:00	0.6	13.9	1,682.6	0.6	0.5	1	1	0
04/07/2020 13:00	0.6	13.9	1,635.6	0.6	0.5	1	1	0
04/07/2020 14:00	0.6	13.9	1,618.0	0.6	0.5	1	1	0
04/07/2020 15:00	0.6	13.9	1,682.9	0.6	0.5	1	1	0
04/07/2020 16:00	0.6	13.9	1,690.6	0.6	0.5	1	1	0
04/07/2020 17:00	0.7	13.8	1,608.8	0.7	0.5	1	1	1
04/07/2020 18:00	0.7	12.8	1,988.2	0.7	0.6	1	1	1
04/07/2020 19:00	0.7	12.6	2,031.3	0.7	0.6	1	1	1
04/07/2020 20:00	0.7	12.3	2,101.4	0.7	0.6	1	1	1
04/07/2020 21:00	0.7	12.2	2,105.3	0.7	0.6	1	1	1
04/07/2020 22:00	0.7	12.3	2,107.4	0.7	0.6	1	1	1
04/07/2020 23:00	0.7	12.3	2,110.7	0.7	0.6	1	1	1
Average/Sum#:	0.7	13.2	1,868.2	0.7	0.6	24 #	24 #	14 #
Minimum:	0.6	12.2	1,608.8	0.6	0.5	1	1	0
Maximum:	0.7	13.9	2,110.7	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/08/2020 00:00	0.7	12.5	2,014.5	0.7	0.6	1	1	1
04/08/2020 01:00	0.6	13.9	1,673.2	0.6	0.5	1	1	0
04/08/2020 02:00	0.6	13.9	1,643.2	0.6	0.5	1	1	0
04/08/2020 03:00	0.6	13.8	1,676.2	0.6	0.5	1	1	0
04/08/2020 04:00	0.6	13.9	1,634.5	0.6	0.5	1	1	0
04/08/2020 05:00	0.6	13.8	1,680.0	0.6	0.5	1	1	0
04/08/2020 06:00	0.6	13.8	1,690.4	0.6	0.5	1	1	0
04/08/2020 07:00	0.6	13.8	1,661.3	0.6	0.5	1	1	0
04/08/2020 08:00	0.6	13.8	1,687.0	0.6	0.5	1	1	0
04/08/2020 09:00	0.6	13.8	1,693.3	0.6	0.5	1	1	0
04/08/2020 10:00	0.6	13.8	1,685.3	0.6	0.5	1	1	0
04/08/2020 11:00	0.6	13.9	1,649.3	0.6	0.5	1	1	0
04/08/2020 12:00	0.6	13.9	1,692.2	0.6	0.5	1	1	0
04/08/2020 13:00	0.6	13.8	1,686.0	0.6	0.5	1	1	0
04/08/2020 14:00	0.6	13.8	1,693.5	0.6	0.5	1	1	0
04/08/2020 15:00	0.6	13.8	1,677.7	0.6	0.5	1	1	0
04/08/2020 16:00	0.6	13.8	1,675.0	0.6	0.5	1	1	0
04/08/2020 17:00	0.7	13.4	1,775.8	0.7	0.5	1	1	1
04/08/2020 18:00	0.7	12.2	2,086.7	0.7	0.6	1	1	1
04/08/2020 19:00	0.7	11.9	2,168.2	0.7	0.7	1	1	1
04/08/2020 20:00	0.7	12.1	2,129.7	0.7	0.6	1	1	1
04/08/2020 21:00	0.7	12.2	2,108.8	0.7	0.6	1	1	1
04/08/2020 22:00	0.7	12.2	2,108.0	0.7	0.6	1	1	1
04/08/2020 23:00	0.7	12.2	2,109.9	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.3	1,804.2	0.6	0.5	24 #	24 #	8 #
Minimum:	0.6	11.9	1,634.5	0.6	0.5	1	1	0
Maximum:	0.7	13.9	2,168.2	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/09/2020 00:00	0.7	12.2	2,117.4	0.7	0.6	1	1	1
04/09/2020 01:00	0.7	12.2	2,117.3	0.7	0.6	1	1	1
04/09/2020 02:00	0.7	12.2	2,114.3	0.7	0.6	1	1	1
04/09/2020 03:00	0.7	12.3	2,109.4	0.7	0.6	1	1	1
04/09/2020 04:00	0.7	12.4	2,074.3	0.7	0.6	1	1	1
04/09/2020 05:00	0.7	12.5	2,070.3	0.7	0.6	1	1	1
04/09/2020 06:00	0.7	12.3	2,106.2	0.7	0.6	1	1	1
04/09/2020 07:00	0.7	12.3	2,108.2	0.7	0.6	1	1	1
04/09/2020 08:00	0.7	12.3	2,105.7	0.7	0.6	1	1	1
04/09/2020 09:00	0.7	12.3	2,104.7	0.7	0.6	1	1	1
04/09/2020 10:00	0.7	12.3	2,099.8	0.7	0.6	1	1	1
04/09/2020 11:00	0.7	12.5	2,046.6	0.7	0.6	1	1	1
04/09/2020 12:00	0.7	12.3	2,078.1	0.7	0.6	1	1	1
04/09/2020 13:00	0.7	12.3	2,077.5	0.7	0.6	1	1	1
04/09/2020 14:00	0.7	12.4	2,061.4	0.7	0.6	1	1	1
04/09/2020 15:00	0.7	12.3	2,077.4	0.7	0.6	1	1	1
04/09/2020 16:00	0.7	12.3	2,090.4	0.7	0.6	1	1	1
04/09/2020 17:00	0.7	12.3	2,104.4	0.7	0.6	1	1	1
04/09/2020 18:00	0.7	12.2	2,110.7	0.7	0.6	1	1	1
04/09/2020 19:00	0.7	12.2	2,128.7	0.7	0.6	1	1	1
04/09/2020 20:00	0.7	12.1	2,131.3	0.7	0.6	1	1	1
04/09/2020 21:00	0.7	12.2	2,112.2	0.7	0.6	1	1	1
04/09/2020 22:00	0.7	12.3	2,095.0	0.7	0.6	1	1	1
04/09/2020 23:00	0.7	12.2	2,126.7	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.3	2,098.7	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	12.1	2,046.6	0.7	0.6	1	1	1
Maximum:	0.7	12.5	2,131.3	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/10/2020 00:00	0.7	12.3	2,115.9	0.7	0.6	1	1	1
04/10/2020 01:00	0.7	12.3	2,106.8	0.7	0.6	1	1	1
04/10/2020 02:00	0.7	12.3	2,105.4	0.7	0.6	1	1	1
04/10/2020 03:00	0.7	12.3	2,101.1	0.7	0.6	1	1	1
04/10/2020 04:00	0.7	12.4	2,073.4	0.7	0.6	1	1	1
04/10/2020 05:00	0.7	12.5	2,046.7	0.7	0.6	1	1	1
04/10/2020 06:00	0.7	12.3	2,101.4	0.7	0.6	1	1	1
04/10/2020 07:00	0.7	13.6	1,704.4	0.7	0.5	1	1	1
04/10/2020 08:00	0.6	13.8	1,560.8	0.6	0.5	1	1	0
04/10/2020 09:00	0.6	13.8	1,687.5	0.6	0.5	1	1	0
04/10/2020 10:00	0.6	13.9	1,660.7	0.6	0.5	1	1	0
04/10/2020 11:00	0.6	13.9	1,552.7	0.6	0.5	1	1	0
04/10/2020 12:00	0.6	13.9	1,669.7	0.6	0.5	1	1	0
04/10/2020 13:00	0.6	13.9	1,572.7	0.6	0.5	1	1	0
04/10/2020 14:00	0.6	13.9	1,604.9	0.6	0.5	1	1	0
04/10/2020 15:00	0.6	13.8	1,654.9	0.6	0.5	1	1	0
04/10/2020 16:00	0.6	13.8	1,662.2	0.6	0.5	1	1	0
04/10/2020 17:00	0.7	13.8	1,475.7	0.7	0.4	1	1	1
04/10/2020 18:00	0.7	12.4	2,043.5	0.7	0.6	1	1	1
04/10/2020 19:00	0.7	12.1	2,102.9	0.7	0.6	1	1	1
04/10/2020 20:00	0.7	12.3	2,077.9	0.7	0.6	1	1	1
04/10/2020 21:00	0.7	12.3	2,066.7	0.7	0.6	1	1	1
04/10/2020 22:00	0.7	12.4	2,062.4	0.7	0.6	1	1	1
04/10/2020 23:00	0.7	13.0	1,915.7	0.7	0.6	1	1	1
Average/Sum#:	0.7	13.0	1,863.6	0.7	0.6	24 #	24 #	15 #
Minimum:	0.6	12.1	1,475.7	0.6	0.4	1	1	0
Maximum:	0.7	13.9	2,115.9	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/11/2020 00:00	0.6	13.8	1,616.2	0.6	0.5	1	1	0
04/11/2020 01:00	0.6	13.8	1,678.7	0.6	0.5	1	1	0
04/11/2020 02:00	0.6	13.8	1,680.0	0.6	0.5	1	1	0
04/11/2020 03:00	0.6	13.8	1,673.3	0.6	0.5	1	1	0
04/11/2020 04:00	0.6	13.8	1,667.0	0.6	0.5	1	1	0
04/11/2020 05:00	0.6	13.8	1,673.6	0.6	0.5	1	1	0
04/11/2020 06:00	0.6	13.8	1,605.9	0.6	0.5	1	1	0
04/11/2020 07:00	0.6	13.8	1,684.0	0.6	0.5	1	1	0
04/11/2020 08:00	0.6	13.8	1,670.0	0.6	0.5	1	1	0
04/11/2020 09:00	0.6	13.8	1,669.1	0.6	0.5	1	1	0
04/11/2020 10:00	0.6	13.8	1,672.7	0.6	0.5	1	1	0
04/11/2020 11:00	0.6	13.9	1,677.2	0.6	0.5	1	1	0
04/11/2020 12:00	0.6	13.9	1,569.7	0.6	0.5	1	1	0
04/11/2020 13:00	0.6	13.9	1,661.2	0.6	0.5	1	1	0
04/11/2020 14:00	0.6	13.8	1,674.0	0.6	0.5	1	1	0
04/11/2020 15:00	0.6	13.8	1,672.8	0.6	0.5	1	1	0
04/11/2020 16:00	0.6	13.8	1,691.6	0.6	0.5	1	1	0
04/11/2020 17:00	0.6	13.8	1,677.5	0.6	0.5	1	1	0
04/11/2020 18:00	0.7	13.8	1,578.4	0.7	0.5	1	1	1
04/11/2020 19:00	0.7	12.6	2,007.7	0.7	0.6	1	1	1
04/11/2020 20:00	0.7	12.4	2,050.8	0.7	0.6	1	1	1
04/11/2020 21:00	0.7	12.3	2,074.6	0.7	0.6	1	1	1
04/11/2020 22:00	0.7	12.5	2,040.2	0.7	0.6	1	1	1
04/11/2020 23:00	0.7	12.7	1,973.4	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.5	1,735.0	0.6	0.5	24 #	24 #	6 #
Minimum:	0.6	12.3	1,569.7	0.6	0.5	1	1	0
Maximum:	0.7	13.9	2,074.6	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/12/2020 00:00	0.6	13.8	1,661.9	0.6	0.5	1	1	0
04/12/2020 01:00	0.6	13.8	1,684.1	0.6	0.5	1	1	0
04/12/2020 02:00	0.6	13.8	1,681.4	0.6	0.5	1	1	0
04/12/2020 03:00	0.6	13.8	1,600.0	0.6	0.5	1	1	0
04/12/2020 04:00	0.6	13.8	1,673.2	0.6	0.5	1	1	0
04/12/2020 05:00	0.6	13.8	1,687.8	0.6	0.5	1	1	0
04/12/2020 06:00	0.6	13.8	1,635.1	0.6	0.5	1	1	0
04/12/2020 07:00	0.6	13.8	1,692.0	0.6	0.5	1	1	0
04/12/2020 08:00	0.6	13.8	1,694.7	0.6	0.5	1	1	0
04/12/2020 09:00	0.6	13.8	1,669.1	0.6	0.5	1	1	0
04/12/2020 10:00	0.6	13.8	1,651.1	0.6	0.5	1	1	0
04/12/2020 11:00	0.6	13.9	1,601.2	0.6	0.5	1	1	0
04/12/2020 12:00	0.6	13.9	1,672.7	0.6	0.5	1	1	0
04/12/2020 13:00	0.6	13.9	1,675.8	0.6	0.5	1	1	0
04/12/2020 14:00	0.6	13.9	1,687.8	0.6	0.5	1	1	0
04/12/2020 15:00	0.6	13.9	1,664.7	0.6	0.5	1	1	0
04/12/2020 16:00	0.6	13.9	1,683.1	0.6	0.5	1	1	0
04/12/2020 17:00	0.6	14.0	1,559.0	0.6	0.5	1	1	0
04/12/2020 18:00	0.6	14.0	1,614.7	0.6	0.5	1	1	0
04/12/2020 19:00	0.6	13.9	1,630.4	0.6	0.5	1	1	0
04/12/2020 20:00	0.6	13.9	1,638.7	0.6	0.5	1	1	0
04/12/2020 21:00	0.6	13.9	1,629.8	0.6	0.5	1	1	0
04/12/2020 22:00	0.6	13.9	1,623.8	0.6	0.5	1	1	0
04/12/2020 23:00	0.7	13.4	1,818.9	0.7	0.5	1	1	1
Average/Sum#:	0.6	13.8	1,659.6	0.6	0.5	24 #	24 #	1 #
Minimum:	0.6	13.4	1,559.0	0.6	0.5	1	1	0
Maximum:	0.7	14.0	1,818.9	0.7	0.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/13/2020 00:00	0.7	12.5	2,028.5	0.7	0.6	1	1	1
04/13/2020 01:00	0.6	13.8	1,688.5	0.6	0.5	1	1	0
04/13/2020 02:00	0.6	13.8	1,690.3	0.6	0.5	1	1	0
04/13/2020 03:00	0.6	13.8	1,671.5	0.6	0.5	1	1	0
04/13/2020 04:00	0.6	13.8	1,637.1	0.6	0.5	1	1	0
04/13/2020 05:00	0.6	13.8	1,663.7	0.6	0.5	1	1	0
04/13/2020 06:00	0.6	13.9	1,678.0	0.6	0.5	1	1	0
04/13/2020 07:00	0.6	13.9	1,656.8	0.6	0.5	1	1	0
04/13/2020 08:00	0.6	13.9	1,669.6	0.6	0.5	1	1	0
04/13/2020 09:00	0.6	13.9	1,696.3	0.6	0.5	1	1	0
04/13/2020 10:00	0.6	13.9	1,692.0	0.6	0.5	1	1	0
04/13/2020 11:00	0.6	13.9	1,693.0	0.6	0.5	1	1	0
04/13/2020 12:00	0.6	13.9	1,673.5	0.6	0.5	1	1	0
04/13/2020 13:00	0.6	13.9	1,610.5	0.6	0.5	1	1	0
04/13/2020 14:00	0.6	13.9	1,677.2	0.6	0.5	1	1	0
04/13/2020 15:00	0.6	13.8	1,687.2	0.6	0.5	1	1	0
04/13/2020 16:00	0.6	13.8	1,656.5	0.6	0.5	1	1	0
04/13/2020 17:00	0.7	13.9	1,531.0	0.7	0.5	1	1	1
04/13/2020 18:00	0.5	12.8	2,011.3	0.5	0.6	1	1	1
04/13/2020 19:00	0.7	12.4	2,105.8	0.7	0.6	1	1	1
04/13/2020 20:00	0.7	12.4	2,096.9	0.7	0.6	1	1	1
04/13/2020 21:00	0.5	12.4	2,100.1	0.5	0.6	1	1	1
04/13/2020 22:00	0.7	12.6	2,074.2	0.7	0.6	1	1	1
04/13/2020 23:00	0.7	13.0	1,923.5	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.5	1,775.5	0.6	0.5	24 #	24 #	8 #
Minimum:	0.5	12.4	1,531.0	0.5	0.5	1	1	0
Maximum:	0.7	13.9	2,105.8	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/14/2020 00:00	0.6	13.9	1,725.2	0.6	0.5	1	1	0
04/14/2020 01:00	0.6	13.9	1,524.5	0.6	0.5	1	1	0
04/14/2020 02:00	0.6	13.9	1,630.9	0.6	0.5	1	1	0
04/14/2020 03:00	0.6	13.9	1,538.1	0.6	0.5	1	1	0
04/14/2020 04:00	0.6	13.9	1,638.1	0.6	0.5	1	1	0
04/14/2020 05:00	0.6	13.9	1,594.0	0.6	0.5	1	1	0
04/14/2020 06:00	0.6	13.9	1,674.9	0.6	0.5	1	1	0
04/14/2020 07:00	0.6	13.9	1,591.5	0.6	0.5	1	1	0
04/14/2020 08:00	0.6	13.9	1,641.7	0.6	0.5	1	1	0
04/14/2020 09:00	0.6	13.9	1,666.9	0.6	0.5	1	1	0
04/14/2020 10:00	0.6	14.0	1,685.4	0.6	0.5	1	1	0
04/14/2020 11:00	0.6	14.0	1,680.0	0.6	0.5	1	1	0
04/14/2020 12:00	0.6	14.0	1,565.2	0.6	0.5	1	1	0
04/14/2020 13:00	0.6	13.9	1,691.7	0.6	0.5	1	1	0
04/14/2020 14:00	0.6	13.9	1,673.2	0.6	0.5	1	1	0
04/14/2020 15:00	0.6	13.9	1,663.3	0.6	0.5	1	1	0
04/14/2020 16:00	0.6	14.0	1,593.8	0.6	0.5	1	1	0
04/14/2020 17:00	0.7	13.9	1,540.3	0.7	0.5	1	1	1
04/14/2020 18:00	0.5	12.6	2,056.3	0.5	0.6	1	1	1
04/14/2020 19:00	0.7	12.3	2,103.7	0.7	0.6	1	1	1
04/14/2020 20:00	0.5	12.4	2,089.4	0.5	0.6	1	1	1
04/14/2020 21:00	0.5	12.6	2,050.2	0.5	0.6	1	1	1
04/14/2020 22:00	0.5	12.4	2,083.8	0.5	0.6	1	1	1
04/14/2020 23:00	0.5	12.6	2,071.6	0.5	0.6	1	1	1
Average/Sum#:	0.6	13.6	1,740.6	0.6	0.5	24 #	24 #	7 #
Minimum:	0.5	12.3	1,524.5	0.5	0.5	1	1	0
Maximum:	0.7	14.0	2,103.7	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/15/2020 00:00	0.7	13.0	1,949.1	0.7	0.6	1	1	1
04/15/2020 01:00	0.6	13.9	1,595.0	0.6	0.5	1	1	0
04/15/2020 02:00	0.6	13.9	1,671.2	0.6	0.5	1	1	0
04/15/2020 03:00	0.6	13.9	1,580.3	0.6	0.5	1	1	0
04/15/2020 04:00	0.6	13.9	1,566.1	0.6	0.5	1	1	0
04/15/2020 05:00	0.6	13.9	1,682.5	0.6	0.5	1	1	0
04/15/2020 06:00	0.6	13.9	1,678.9	0.6	0.5	1	1	0
04/15/2020 07:00	0.6	13.9	1,653.1	0.6	0.5	1	1	0
04/15/2020 08:00	0.6	13.9	1,683.6	0.6	0.5	1	1	0
04/15/2020 09:00	0.6	13.9	1,686.0	0.6	0.5	1	1	0
04/15/2020 10:00	0.6	13.9	1,693.6	0.6	0.5	1	1	0
04/15/2020 11:00	0.6	13.9	1,693.0	0.6	0.5	1	1	0
04/15/2020 12:00	0.6	13.9	1,676.4	0.6	0.5	1	1	0
04/15/2020 13:00	0.6	13.8	1,693.1	0.6	0.5	1	1	0
04/15/2020 14:00	0.6	13.8	1,670.7	0.6	0.5	1	1	0
04/15/2020 15:00	0.6	13.8	1,630.0	0.6	0.5	1	1	0
04/15/2020 16:00	0.6	13.8	1,637.4	0.6	0.5	1	1	0
04/15/2020 17:00	0.7	13.9	1,517.0	0.7	0.5	1	1	1
04/15/2020 18:00	0.5	12.5	2,036.6	0.5	0.6	1	1	1
04/15/2020 19:00	0.7	12.1	2,117.0	0.7	0.6	1	1	1
04/15/2020 20:00	0.7	12.1	2,123.2	0.7	0.6	1	1	1
04/15/2020 21:00	0.7	12.3	2,075.0	0.7	0.6	1	1	1
04/15/2020 22:00	0.5	12.9	1,952.8	0.5	0.6	1	1	1
04/15/2020 23:00	0.7	13.0	1,912.5	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.5	1,757.3	0.6	0.5	24 #	24 #	8 #
Minimum:	0.5	12.1	1,517.0	0.5	0.5	1	1	0
Maximum:	0.7	13.9	2,123.2	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/16/2020 00:00	0.6	13.9	1,505.4	0.6	0.5	1	1	0
04/16/2020 01:00	0.6	13.9	1,494.2	0.6	0.4	1	1	0
04/16/2020 02:00	0.6	13.9	1,525.3	0.6	0.5	1	1	0
04/16/2020 03:00	0.6	13.9	1,492.3	0.6	0.4	1	1	0
04/16/2020 04:00	0.6	13.9	1,578.8	0.6	0.5	1	1	0
04/16/2020 05:00	0.6	13.9	1,668.8	0.6	0.5	1	1	0
04/16/2020 06:00	0.6	13.9	1,545.9	0.6	0.5	1	1	0
04/16/2020 07:00	0.6	13.9	1,649.8	0.6	0.5	1	1	0
04/16/2020 08:00	0.6	13.9	1,683.4	0.6	0.5	1	1	0
04/16/2020 09:00	0.6	13.9	1,669.2	0.6	0.5	1	1	0
04/16/2020 10:00	0.6	13.9	1,690.2	0.6	0.5	1	1	0
04/16/2020 11:00	0.6	13.9	1,666.2	0.6	0.5	1	1	0
04/16/2020 12:00	0.6	13.8	1,699.3	0.6	0.5	1	1	0
04/16/2020 13:00	0.6	13.8	1,684.4	0.6	0.5	1	1	0
04/16/2020 14:00	0.6	13.9	1,596.8	0.6	0.5	1	1	0
04/16/2020 15:00	0.6	13.9	1,636.6	0.6	0.5	1	1	0
04/16/2020 16:00	0.6	13.9	1,630.8	0.6	0.5	1	1	0
04/16/2020 17:00	0.7	13.9	1,563.7	0.7	0.5	1	1	1
04/16/2020 18:00	0.5	12.6	2,023.8	0.5	0.6	1	1	1
04/16/2020 19:00	0.7	12.1	2,111.7	0.7	0.6	1	1	1
04/16/2020 20:00	0.7	12.0	2,137.3	0.7	0.6	1	1	1
04/16/2020 21:00	0.7	12.1	2,111.1	0.7	0.6	1	1	1
04/16/2020 22:00	0.5	12.7	1,990.3	0.5	0.6	1	1	1
04/16/2020 23:00	0.5	12.9	1,924.2	0.5	0.6	1	1	1
Average/Sum#:	0.6	13.5	1,720.0	0.6	0.5	24 #	24 #	7 #
Minimum:	0.5	12.0	1,492.3	0.5	0.4	1	1	0
Maximum:	0.7	13.9	2,137.3	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/17/2020 00:00	0.6	13.9	1,450.7	0.6	0.4	1	1	0
04/17/2020 01:00	0.6	13.9	1,352.6	0.6	0.4	1	1	0
04/17/2020 02:00	0.6	13.9	1,337.4	0.6	0.4	1	1	0
04/17/2020 03:00	0.6	13.9	1,336.7	0.6	0.4	1	1	0
04/17/2020 04:00	0.6	13.9	1,312.9	0.6	0.4	1	1	0
04/17/2020 05:00	0.6	13.8	1,670.2	0.6	0.5	1	1	0
04/17/2020 06:00	0.6	13.8	1,638.7	0.6	0.5	1	1	0
04/17/2020 07:00	0.6	13.9	1,612.0	0.6	0.5	1	1	0
04/17/2020 08:00	0.6	13.9	1,674.4	0.6	0.5	1	1	0
04/17/2020 09:00	0.6	13.9	1,652.6	0.6	0.5	1	1	0
04/17/2020 10:00	0.6	13.9	1,562.0	0.6	0.5	1	1	0
04/17/2020 11:00	0.6	13.9	1,650.8	0.6	0.5	1	1	0
04/17/2020 12:00	0.6	14.0	1,461.9	0.6	0.4	1	1	0
04/17/2020 13:00	0.6	13.9	1,617.2	0.6	0.5	1	1	0
04/17/2020 14:00	0.6	13.8	1,677.0	0.6	0.5	1	1	0
04/17/2020 15:00	0.6	13.8	1,687.8	0.6	0.5	1	1	0
04/17/2020 16:00	0.6	13.8	1,655.5	0.6	0.5	1	1	0
04/17/2020 17:00	0.7	13.9	1,528.2	0.7	0.5	1	1	1
04/17/2020 18:00	0.5	12.6	2,026.7	0.5	0.6	1	1	1
04/17/2020 19:00	0.7	12.3	2,069.6	0.7	0.6	1	1	1
04/17/2020 20:00	0.7	12.4	2,063.9	0.7	0.6	1	1	1
04/17/2020 21:00	0.7	12.5	2,051.9	0.7	0.6	1	1	1
04/17/2020 22:00	0.7	12.5	2,068.5	0.7	0.6	1	1	1
04/17/2020 23:00	0.0	14.2	1,255.2	0.0	0.4	1	0	1
Average/Sum#:	0.6	13.6	1,642.3	0.6	0.5	24 #	23 #	7 #
Minimum:	0.0	12.3	1,255.2	0.0	0.4	1	0	0
Maximum:	0.7	14.2	2,069.6	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/18/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/19/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 17:00	0.0	17.6	461.0	0.0	0.1	1	0	0
04/19/2020 18:00	0.0	17.1	521.3	0.0	0.2	1	0	0
04/19/2020 19:00	0.0	15.5	857.7	0.0	0.3	1	0	0
04/19/2020 20:00	0.6	13.9	1,383.7	0.6	0.4	1	1	0
04/19/2020 21:00	0.6	13.9	1,431.6	0.6	0.4	1	1	0
04/19/2020 22:00	0.6	13.9	1,346.6	0.6	0.4	1	1	0
04/19/2020 23:00	0.6	13.9	1,342.0	0.6	0.4	1	1	0
Average/Sum#:	0.3	15.1	1,049.1	0.3	0.3	7 #	4 #	0 #
Minimum:	0.0	13.9	461.0	0.0	0.1	0	0	0
Maximum:	0.6	17.6	1,431.6	0.6	0.4	1	1	0
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/20/2020 00:00	0.6	13.9	1,337.6	0.6	0.4	1	1	0
04/20/2020 01:00	0.6	13.9	1,343.6	0.6	0.4	1	1	0
04/20/2020 02:00	0.6	13.8	1,598.2	0.6	0.5	1	1	0
04/20/2020 03:00	0.6	13.8	1,479.3	0.6	0.4	1	1	0
04/20/2020 04:00	0.6	13.8	1,673.3	0.6	0.5	1	1	0
04/20/2020 05:00	0.6	13.8	1,685.2	0.6	0.5	1	1	0
04/20/2020 06:00	0.6	13.8	1,675.2	0.6	0.5	1	1	0
04/20/2020 07:00	0.6	13.8	1,687.9	0.6	0.5	1	1	0
04/20/2020 08:00	0.6	13.8	1,644.0	0.6	0.5	1	1	0
04/20/2020 09:00	0.6	13.8	1,590.5	0.6	0.5	1	1	0
04/20/2020 10:00	0.6	13.8	1,580.8	0.6	0.5	1	1	0
04/20/2020 11:00	0.6	13.8	1,682.8	0.6	0.5	1	1	0
04/20/2020 12:00	0.6	13.9	1,670.9	0.6	0.5	1	1	0
04/20/2020 13:00	0.6	13.9	1,680.5	0.6	0.5	1	1	0
04/20/2020 14:00	0.6	13.9	1,520.3	0.6	0.5	1	1	0
04/20/2020 15:00	0.6	13.9	1,656.3	0.6	0.5	1	1	0
04/20/2020 16:00	0.6	13.9	1,618.7	0.6	0.5	1	1	0
04/20/2020 17:00	0.7	13.9	1,539.4	0.7	0.5	1	1	1
04/20/2020 18:00	0.7	12.7	2,006.1	0.7	0.6	1	1	1
04/20/2020 19:00	0.7	12.5	2,053.3	0.7	0.6	1	1	1
04/20/2020 20:00	0.7	12.5	2,053.9	0.7	0.6	1	1	1
04/20/2020 21:00	0.7	12.5	2,058.5	0.7	0.6	1	1	1
04/20/2020 22:00	0.7	12.8	1,961.5	0.7	0.6	1	1	1
04/20/2020 23:00	0.0	15.8	577.8	0.0	0.2	1	0	0
Average/Sum#:	0.6	13.7	1,640.7	0.6	0.5	24 #	23 #	6 #
Minimum:	0.0	12.5	577.8	0.0	0.2	1	0	0
Maximum:	0.7	15.8	2,058.5	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/21/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 04:00	0.0	17.6	467.0	0.0	0.1	1	0	0
04/22/2020 05:00	0.0	17.1	525.0	0.0	0.2	1	0	0
04/22/2020 06:00	0.0	15.7	834.1	0.0	0.3	1	0	0
04/22/2020 07:00	0.6	13.7	1,788.3	0.6	0.5	1	1	0
04/22/2020 08:00	0.6	13.7	1,785.0	0.6	0.5	1	1	0
04/22/2020 09:00	0.6	13.9	1,349.8	0.6	0.4	1	1	0
04/22/2020 10:00	0.6	13.9	1,305.7	0.6	0.4	1	1	0
04/22/2020 11:00	0.6	13.9	1,517.6	0.6	0.5	1	1	0
04/22/2020 12:00	0.6	13.9	1,517.1	0.6	0.5	1	1	0
04/22/2020 13:00	0.0	16.3	404.9	0.0	0.1	1	0	0
04/22/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 18:00	0.0	18.6	298.6	0.0	0.1	1	0	0
04/22/2020 19:00	0.0	15.7	840.9	0.0	0.3	1	0	0
04/22/2020 20:00	0.6	13.9	1,474.7	0.6	0.4	1	1	0
04/22/2020 21:00	0.6	13.9	1,540.1	0.6	0.5	1	1	0
04/22/2020 22:00	0.6	13.9	1,404.1	0.6	0.4	1	1	0
04/22/2020 23:00	0.6	13.9	1,348.9	0.6	0.4	1	1	0
Average/Sum#:	0.4	15.0	1,150.1	0.4	0.4	16 #	10 #	0 #
Minimum:	0.0	13.7	298.6	0.0	0.1	0	0	0
Maximum:	0.6	18.6	1,788.3	0.6	0.5	1	1	0
%SI	33.33	33.33	33.33	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/23/2020 00:00	0.6	13.9	1,345.6	0.6	0.4	1	1	0
04/23/2020 01:00	0.6	13.9	1,335.0	0.6	0.4	1	1	0
04/23/2020 02:00	0.0	16.7	332.1	0.0	0.1	1	0	0
04/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.4	14.8	1,004.2	0.4	0.3	3 #	2 #	0 #
Minimum:	0.0	13.9	332.1	0.0	0.1	0	0	0
Maximum:	0.6	16.7	1,345.6	0.6	0.4	1	1	0
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 09:00	0.0	17.6	457.1	0.0	0.1	1	0	0
04/24/2020 10:00	0.0	17.1	522.5	0.0	0.2	1	0	0
04/24/2020 11:00	0.0	15.2	898.2	0.0	0.3	1	0	0
04/24/2020 12:00	0.6	14.0	1,374.1	0.6	0.4	1	1	0
04/24/2020 13:00	0.6	14.0	1,362.2	0.6	0.4	1	1	0
04/24/2020 14:00	0.6	14.0	1,520.8	0.6	0.5	1	1	0
04/24/2020 15:00	0.6	14.0	1,493.2	0.6	0.4	1	1	0
04/24/2020 16:00	0.6	13.9	1,525.7	0.6	0.5	1	1	0
04/24/2020 17:00	0.6	13.9	1,552.4	0.6	0.5	1	1	0
04/24/2020 18:00	0.7	12.7	1,922.8	0.7	0.6	1	1	1
04/24/2020 19:00	0.7	12.0	2,119.6	0.7	0.6	1	1	1
04/24/2020 20:00	0.7	12.1	2,105.9	0.7	0.6	1	1	1
04/24/2020 21:00	0.7	12.7	1,953.0	0.7	0.6	1	1	1
04/24/2020 22:00	0.0	14.6	1,024.9	0.0	0.3	1	0	0
04/24/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.5	14.1	1,416.6	0.5	0.4	14 #	10 #	4 #
Minimum:	0.0	12.0	457.1	0.0	0.1	0	0	0
Maximum:	0.7	17.6	2,119.6	0.7	0.6	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 13:00	0.0	17.6	456.1	0.0	0.1	1	0	0
04/27/2020 14:00	0.0	16.2	635.3	0.0	0.2	1	0	0
04/27/2020 15:00	0.0	14.8	1,004.8	0.0	0.3	1	0	0
04/27/2020 16:00	0.6	13.9	1,428.7	0.6	0.4	1	1	0
04/27/2020 17:00	0.5	12.8	1,944.7	0.5	0.6	1	1	1
04/27/2020 18:00	0.5	12.6	1,980.3	0.5	0.6	1	1	1
04/27/2020 19:00	0.5	12.7	1,971.3	0.5	0.6	1	1	1
04/27/2020 20:00	0.5	12.8	1,931.4	0.5	0.6	1	1	1
04/27/2020 21:00	0.6	13.9	1,408.9	0.6	0.4	1	1	0
04/27/2020 22:00	0.6	13.9	1,419.0	0.6	0.4	1	1	0
04/27/2020 23:00	0.6	13.9	1,473.2	0.6	0.4	1	1	0
Average/Sum#:	0.4	14.1	1,423.1	0.4	0.4	11 #	8 #	4 #
Minimum:	0.0	12.6	456.1	0.0	0.1	0	0	0
Maximum:	0.6	17.6	1,980.3	0.6	0.6	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/28/2020 00:00	0.6	13.9	1,385.0	0.6	0.4	1	1	0
04/28/2020 01:00	0.6	13.9	1,385.9	0.6	0.4	1	1	0
04/28/2020 02:00	0.6	13.9	1,385.2	0.6	0.4	1	1	0
04/28/2020 03:00	0.6	13.9	1,379.9	0.6	0.4	1	1	0
04/28/2020 04:00	0.6	13.9	1,377.6	0.6	0.4	1	1	0
04/28/2020 05:00	0.6	13.9	1,377.0	0.6	0.4	1	1	0
04/28/2020 06:00	0.6	13.9	1,379.5	0.6	0.4	1	1	0
04/28/2020 07:00	0.6	13.9	1,392.6	0.6	0.4	1	1	0
04/28/2020 08:00	0.6	13.9	1,397.6	0.6	0.4	1	1	0
04/28/2020 09:00	0.6	13.9	1,385.3	0.6	0.4	1	1	0
04/28/2020 10:00	0.6	13.9	1,367.7	0.6	0.4	1	1	0
04/28/2020 11:00	0.6	13.9	1,368.7	0.6	0.4	1	1	0
04/28/2020 12:00	0.6	13.9	1,370.3	0.6	0.4	1	1	0
04/28/2020 13:00	0.6	13.9	1,511.2	0.6	0.5	1	1	0
04/28/2020 14:00	0.6	13.9	1,504.3	0.6	0.5	1	1	0
04/28/2020 15:00	0.6	13.9	1,541.3	0.6	0.5	1	1	0
04/28/2020 16:00	0.7	13.9	1,490.8	0.7	0.4	1	1	1
04/28/2020 17:00	0.7	12.0	2,083.9	0.7	0.6	1	1	1
04/28/2020 18:00	0.7	11.8	2,134.4	0.7	0.6	1	1	1
04/28/2020 19:00	0.7	11.8	2,135.0	0.7	0.6	1	1	1
04/28/2020 20:00	0.7	11.8	2,128.7	0.7	0.6	1	1	1
04/28/2020 21:00	0.0	13.0	1,625.0	0.0	0.5	1	0	1
04/28/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/28/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.6	13.5	1,550.3	0.6	0.5	22 #	21 #	6 #
Minimum:	0.0	11.8	1,367.7	0.0	0.4	0	0	0
Maximum:	0.7	13.9	2,135.0	0.7	0.6	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 13:00	0.0	17.5	460.9	0.0	0.1	1	0	0
04/29/2020 14:00	0.0	15.3	726.6	0.0	0.2	1	0	0
04/29/2020 15:00	0.0	14.1	1,420.9	0.0	0.4	1	0	0
04/29/2020 16:00	0.6	13.9	1,379.1	0.6	0.4	1	1	0
04/29/2020 17:00	0.2	12.7	1,939.6	0.4	0.6	1	1	1
04/29/2020 18:00	0.2	12.5	1,979.0	0.4	0.6	1	1	1
04/29/2020 19:00	0.2	12.6	1,969.7	0.4	0.6	1	1	1
04/29/2020 20:00	0.2	12.7	1,930.5	0.4	0.6	1	1	1
04/29/2020 21:00	0.6	13.8	1,361.5	0.6	0.4	1	1	0
04/29/2020 22:00	0.6	13.9	1,344.5	0.6	0.4	1	1	0
04/29/2020 23:00	0.6	13.9	1,343.7	0.6	0.4	1	1	0
Average/Sum#:	0.3	13.9	1,441.5	0.4	0.4	11 #	8 #	4 #
Minimum:	0.0	12.5	460.9	0.0	0.1	0	0	0
Maximum:	0.6	17.5	1,979.0	0.6	0.6	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/30/2020 00:00	0.6	13.9	1,342.5	0.6	0.4	1	1	0
04/30/2020 01:00	0.6	13.9	1,342.3	0.6	0.4	1	1	0
04/30/2020 02:00	0.6	13.9	1,342.5	0.6	0.4	1	1	0
04/30/2020 03:00	0.6	13.9	1,343.3	0.6	0.4	1	1	0
04/30/2020 04:00	0.6	13.9	1,342.9	0.6	0.4	1	1	0
04/30/2020 05:00	0.6	13.8	1,344.9	0.6	0.4	1	1	0
04/30/2020 06:00	0.6	13.8	1,333.6	0.6	0.4	1	1	0
04/30/2020 07:00	0.0	16.6	348.8	0.0	0.1	1	0	0
04/30/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.5	14.2	1,217.6	0.5	0.4	8 #	7 #	0 #
Minimum:	0.0	13.8	348.8	0.0	0.1	0	0	0
Maximum:	0.6	16.6	1,344.9	0.6	0.4	1	1	0
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/04/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/05/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/07/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/10/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/11/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 16:00	0.0	21.0	0.2	0.0	0.0	1	0	0
05/11/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	21.0	0.2	0.0	0.0	1 #	0 #	0 #
Minimum:	0.0	21.0	0.2	0.0	0.0	0	0	0
Maximum:	0.0	21.0	0.2	0.0	0.0	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/13/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/14/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/15/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/17/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/18/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/19/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/20/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/21/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/23/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 08:00	0.0	0.0	387.2	0.0	0.1	1	0	0
05/27/2020 09:00	0.0	0.0	520.3	0.0	0.2	1	0	0
05/27/2020 10:00	0.0	0.0	516.8	0.0	0.2	1	0	0
05/27/2020 11:00	0.0	0.0	857.6	0.0	0.3	1	0	0
05/27/2020 12:00	0.6	0.0	1,388.5	0.6	0.4	1	1	0
05/27/2020 13:00	0.6	13.8	1,455.2	0.6	0.4	1	1	0
05/27/2020 14:00	0.0	15.5	723.2	0.0	0.2	1	0	0
05/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.2	14.7	835.5	0.3	0.3	7 #	2 #	0 #
Minimum:	0.0	13.8	387.2	0.0	0.1	0	0	0
Maximum:	0.6	15.5	1,455.2	0.6	0.4	1	1	0
%SI	70.83	91.67	70.83	91.67	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/28/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 18:00	0.0	19.3	200.0	0.0	0.1	1	0	0
05/28/2020 19:00	0.0	16.4	590.8	0.0	0.2	1	0	0
05/28/2020 20:00	0.0	14.0	1,407.0	0.0	0.4	1	0	0
05/28/2020 21:00	0.6	13.7	1,638.8	0.6	0.5	1	1	0
05/28/2020 22:00	0.6	13.8	1,619.8	0.6	0.5	1	1	0
05/28/2020 23:00	0.7	13.8	1,613.1	0.7	0.5	1	1	1
Average/Sum#:	0.3	15.2	1,178.3	0.3	0.4	6 #	3 #	1 #
Minimum:	0.0	13.7	200.0	0.0	0.1	0	0	0
Maximum:	0.7	19.3	1,638.8	0.7	0.5	1	1	1
%SI	75.00	75.00	75.00	75.00	75.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/29/2020 00:00	0.7	13.3	1,693.2	0.7	0.5	1	1	1
05/29/2020 01:00	0.0	14.4	1,259.5	0.0	0.4	1	0	0
05/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 20:00	0.0	17.7	430.4	0.0	0.1	1	0	0
05/29/2020 21:00	0.0	15.7	696.4	0.0	0.2	1	0	0
05/29/2020 22:00	0.0	14.8	1,015.5	0.0	0.3	1	0	0
05/29/2020 23:00	0.6	13.9	1,381.9	0.6	0.4	1	1	0
Average/Sum#:	0.2	15.0	1,079.5	0.2	0.3	6 #	2 #	1 #
Minimum:	0.0	13.3	430.4	0.0	0.1	0	0	0
Maximum:	0.7	17.7	1,693.2	0.7	0.5	1	1	1
%SI	75.00	75.00	75.00	75.00	75.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/30/2020 00:00	0.6	13.9	1,373.6	0.6	0.4	1	1	0
05/30/2020 01:00	0.6	13.9	1,371.1	0.6	0.4	1	1	0
05/30/2020 02:00	0.6	13.9	1,370.2	0.6	0.4	1	1	0
05/30/2020 03:00	0.6	13.8	1,371.0	0.6	0.4	1	1	0
05/30/2020 04:00	0.6	13.8	1,376.6	0.6	0.4	1	1	0
05/30/2020 05:00	0.6	13.8	1,379.5	0.6	0.4	1	1	0
05/30/2020 06:00	0.6	13.8	1,383.6	0.6	0.4	1	1	0
05/30/2020 07:00	0.6	13.8	1,369.8	0.6	0.4	1	1	0
05/30/2020 08:00	0.0	16.3	397.2	0.0	0.1	1	0	0
05/30/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 13:00	0.0	20.0	116.6	0.0	0.0	1	0	0
05/30/2020 14:00	0.0	16.1	668.2	0.0	0.2	1	0	0
05/30/2020 15:00	0.0	13.9	1,392.1	0.0	0.4	1	0	0
05/30/2020 16:00	0.6	13.9	1,377.8	0.6	0.4	1	1	0
05/30/2020 17:00	0.6	13.9	1,395.1	0.6	0.4	1	1	0
05/30/2020 18:00	0.7	12.9	1,949.1	0.7	0.6	1	1	1
05/30/2020 19:00	0.7	12.8	1,962.9	0.7	0.6	1	1	1
05/30/2020 20:00	0.7	12.8	1,942.5	0.7	0.6	1	1	1
05/30/2020 21:00	0.6	0.0	1,384.2	0.6	0.4	1	1	0
05/30/2020 22:00	0.6	0.0	1,376.4	0.6	0.4	1	1	0
05/30/2020 23:00	0.4	13.9	1,374.3	0.4	0.4	1	1	0
Average/Sum#:	0.5	14.3	1,316.6	0.5	0.4	20 #	16 #	3 #
Minimum:	0.0	12.8	116.6	0.0	0.0	0	0	0
Maximum:	0.7	20.0	1,962.9	0.7	0.6	1	1	1
%SI	25.00	25.00	16.67	25.00	16.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/31/2020 00:00	0.4	13.9	1,373.7	0.4	0.4	1	1	0
05/31/2020 01:00	0.4	13.9	1,373.2	0.4	0.4	1	1	0
05/31/2020 02:00	0.4	13.9	1,373.5	0.4	0.4	1	1	0
05/31/2020 03:00	0.4	13.9	1,373.6	0.4	0.4	1	1	0
05/31/2020 04:00	0.4	13.9	1,375.0	0.4	0.4	1	1	0
05/31/2020 05:00	0.4	13.9	1,362.7	0.4	0.4	1	1	0
05/31/2020 06:00	0.0	0.0	388.5	0.0	0.1	1	0	0
05/31/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 14:00	0.0	17.6	446.1	0.0	0.1	1	0	0
05/31/2020 15:00	0.0	15.1	1,010.2	0.0	0.3	1	0	0
05/31/2020 16:00	0.5	13.9	1,385.2	0.5	0.4	1	1	0
05/31/2020 17:00	0.5	13.9	1,389.8	0.5	0.4	1	1	0
05/31/2020 18:00	0.1	13.4	1,754.7	0.2	0.5	1	1	1
05/31/2020 19:00	-0.4	12.8	1,952.1	-0.1	0.6	1	1	1
05/31/2020 20:00	-0.4	12.8	1,929.3	-0.1	0.6	1	1	1
05/31/2020 21:00	0.4	13.9	1,416.2	0.4	0.4	1	1	0
05/31/2020 22:00	0.4	13.9	1,369.6	0.4	0.4	1	1	0
05/31/2020 23:00	0.4	13.9	1,367.6	0.4	0.4	1	1	0
Average/Sum#:	0.2	14.0	1,331.8	0.3	0.4	17 #	14 #	3 #
Minimum:	-0.4	12.8	388.5	-0.1	0.1	0	0	0
Maximum:	0.5	17.6	1,952.1	0.5	0.6	1	1	1
%SI	33.33	33.33	29.17	33.33	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/01/2020 00:00	0.4	13.9	1,369.5	0.4	0.4	1	1	0
06/01/2020 01:00	0.4	13.9	1,369.0	0.4	0.4	1	1	0
06/01/2020 02:00	0.4	13.9	1,367.5	0.4	0.4	1	1	0
06/01/2020 03:00	0.4	13.9	1,368.2	0.4	0.4	1	1	0
06/01/2020 04:00	0.4	13.9	1,355.8	0.4	0.4	1	1	0
06/01/2020 05:00	0.4	13.9	1,335.9	0.4	0.4	1	1	0
06/01/2020 06:00	0.4	13.9	1,341.8	0.4	0.4	1	1	0
06/01/2020 07:00	0.4	13.9	1,343.5	0.4	0.4	1	1	0
06/01/2020 08:00	0.4	13.9	1,345.5	0.4	0.4	1	1	0
06/01/2020 09:00	0.4	13.9	1,353.4	0.4	0.4	1	1	0
06/01/2020 10:00	0.4	13.9	1,356.4	0.4	0.4	1	1	0
06/01/2020 11:00	0.4	13.9	1,358.5	0.4	0.4	1	1	0
06/01/2020 12:00	0.4	13.9	1,383.5	0.4	0.4	1	1	0
06/01/2020 13:00	0.4	13.8	1,620.1	0.4	0.5	1	1	0
06/01/2020 14:00	0.4	13.7	1,683.4	0.4	0.5	1	1	0
06/01/2020 15:00	0.4	13.8	1,661.5	0.4	0.5	1	1	0
06/01/2020 16:00	0.4	13.9	1,524.9	0.4	0.5	1	1	0
06/01/2020 17:00	0.4	13.9	1,620.6	0.4	0.5	1	1	0
06/01/2020 18:00	0.4	13.9	1,540.2	0.4	0.5	1	1	0
06/01/2020 19:00	0.4	13.9	1,504.2	0.4	0.5	1	1	0
06/01/2020 20:00	0.4	14.0	1,511.0	0.4	0.5	1	1	0
06/01/2020 21:00	0.4	14.0	1,439.3	0.4	0.4	1	1	0
06/01/2020 22:00	0.4	14.0	1,344.4	0.4	0.4	1	1	0
06/01/2020 23:00	0.4	13.8	1,667.3	0.4	0.5	1	1	0
Average/Sum#:	0.4	13.9	1,448.6	0.4	0.4	24 #	24 #	0 #
Minimum:	0.4	13.7	1,335.9	0.4	0.4	1	1	0
Maximum:	0.4	14.0	1,683.4	0.4	0.5	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/02/2020 00:00	0.4	14.0	1,495.8	0.4	0.4	1	1	0
06/02/2020 01:00	0.4	13.9	1,515.5	0.4	0.5	1	1	0
06/02/2020 02:00	0.4	13.9	1,430.1	0.4	0.4	1	1	0
06/02/2020 03:00	0.4	13.9	1,538.0	0.4	0.5	1	1	0
06/02/2020 04:00	0.4	13.9	1,686.0	0.4	0.5	1	1	0
06/02/2020 05:00	0.4	13.9	1,665.8	0.4	0.5	1	1	0
06/02/2020 06:00	0.4	13.9	1,479.7	0.4	0.4	1	1	0
06/02/2020 07:00	0.4	13.9	1,379.4	0.4	0.4	1	1	0
06/02/2020 08:00	0.4	13.9	1,330.3	0.4	0.4	1	1	0
06/02/2020 09:00	0.4	13.9	1,510.8	0.4	0.5	1	1	0
06/02/2020 10:00	0.4	13.9	1,481.1	0.4	0.4	1	1	0
06/02/2020 11:00	0.5	13.9	1,310.5	0.5	0.4	1	1	0
06/02/2020 12:00	0.4	13.8	1,662.9	0.4	0.5	1	1	1
06/02/2020 13:00	-0.1	12.2	2,058.6	0.2	0.6	1	1	1
06/02/2020 14:00	0.2	11.9	2,034.6	0.4	0.6	1	1	1
06/02/2020 15:00	0.4	11.9	2,027.2	0.5	0.6	1	1	1
06/02/2020 16:00	0.2	11.9	2,066.0	0.4	0.6	1	1	1
06/02/2020 17:00	-0.1	12.1	2,060.7	0.2	0.6	1	1	1
06/02/2020 18:00	0.1	12.1	2,071.1	0.2	0.6	1	1	1
06/02/2020 19:00	0.1	12.1	2,067.4	0.2	0.6	1	1	1
06/02/2020 20:00	0.1	12.1	2,063.5	0.2	0.6	1	1	1
06/02/2020 21:00	0.1	12.2	2,051.7	0.2	0.6	1	1	1
06/02/2020 22:00	0.1	12.2	2,055.4	0.2	0.6	1	1	1
06/02/2020 23:00	-0.1	12.2	2,053.4	0.2	0.6	1	1	1
Average/Sum#:	0.3	13.1	1,754.0	0.3	0.5	24 #	24 #	12 #
Minimum:	-0.1	11.9	1,310.5	0.2	0.4	1	1	0
Maximum:	0.5	14.0	2,071.1	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/03/2020 00:00	0.1	12.3	2,028.9	0.2	0.6	1	1	1
06/03/2020 01:00	0.4	13.9	1,417.0	0.4	0.4	1	1	0
06/03/2020 02:00	0.4	13.9	1,376.3	0.4	0.4	1	1	0
06/03/2020 03:00	0.4	13.9	1,324.9	0.4	0.4	1	1	0
06/03/2020 04:00	0.4	13.8	1,656.2	0.4	0.5	1	1	0
06/03/2020 05:00	0.4	13.9	1,482.0	0.4	0.4	1	1	0
06/03/2020 06:00	0.4	13.9	1,364.2	0.4	0.4	1	1	0
06/03/2020 07:00	0.4	13.9	1,449.7	0.4	0.4	1	1	0
06/03/2020 08:00	0.4	13.9	1,487.7	0.4	0.4	1	1	0
06/03/2020 09:00	0.4	13.9	1,574.4	0.4	0.5	1	1	0
06/03/2020 10:00	0.2	13.9	1,501.2	0.2	0.5	1	1	1
06/03/2020 11:00	-0.1	12.3	2,012.8	0.2	0.6	1	1	1
06/03/2020 12:00	0.2	11.9	2,066.2	0.4	0.6	1	1	1
06/03/2020 13:00	0.2	11.9	2,056.7	0.4	0.6	1	1	1
06/03/2020 14:00	0.2	11.9	2,053.7	0.4	0.6	1	1	1
06/03/2020 15:00	0.2	11.9	2,049.2	0.4	0.6	1	1	1
06/03/2020 16:00	0.2	11.9	2,048.2	0.4	0.6	1	1	1
06/03/2020 17:00	0.2	11.9	2,048.9	0.4	0.6	1	1	1
06/03/2020 18:00	0.2	11.9	2,061.8	0.4	0.6	1	1	1
06/03/2020 19:00	0.2	11.8	2,083.2	0.4	0.6	1	1	1
06/03/2020 20:00	0.1	12.1	2,044.4	0.2	0.6	1	1	1
06/03/2020 21:00	0.1	12.2	2,036.4	0.2	0.6	1	1	1
06/03/2020 22:00	0.1	12.3	2,032.4	0.2	0.6	1	1	1
06/03/2020 23:00	0.1	12.1	2,086.6	0.2	0.6	1	1	1
Average/Sum#:	0.2	12.8	1,806.0	0.3	0.5	24 #	24 #	15 #
Minimum:	-0.1	11.8	1,324.9	0.2	0.4	1	1	0
Maximum:	0.4	13.9	2,086.6	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/04/2020 00:00	0.0	14.1	1,188.7	0.0	0.4	1	0	1
06/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 10:00	0.0	17.9	407.5	0.0	0.1	1	0	0
06/04/2020 11:00	0.0	15.2	869.1	0.0	0.3	1	0	0
06/04/2020 12:00	0.4	13.9	1,557.5	0.4	0.5	1	1	0
06/04/2020 13:00	0.4	13.9	1,515.8	0.4	0.5	1	1	1
06/04/2020 14:00	-0.1	12.1	2,028.5	0.2	0.6	1	1	1
06/04/2020 15:00	0.1	11.8	2,074.1	0.2	0.6	1	1	1
06/04/2020 16:00	0.1	11.8	2,078.8	0.2	0.6	1	1	1
06/04/2020 17:00	0.1	11.8	2,075.4	0.2	0.6	1	1	1
06/04/2020 18:00	0.1	11.8	2,072.2	0.2	0.6	1	1	1
06/04/2020 19:00	0.1	12.0	2,049.1	0.2	0.6	1	1	1
06/04/2020 20:00	0.1	11.9	2,065.6	0.2	0.6	1	1	1
06/04/2020 21:00	0.2	11.9	2,082.1	0.4	0.6	1	1	1
06/04/2020 22:00	0.1	12.1	2,061.2	0.2	0.6	1	1	1
06/04/2020 23:00	0.1	12.1	2,049.6	0.2	0.6	1	1	1
Average/Sum#:	0.1	13.0	1,745.0	0.2	0.5	15 #	12 #	12 #
Minimum:	-0.1	11.8	407.5	0.0	0.1	0	0	0
Maximum:	0.4	17.9	2,082.1	0.4	0.6	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/05/2020 00:00	0.0	14.1	1,201.9	0.0	0.4	1	0	1
06/05/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	14.1	1,201.9	0.0	0.4	1 #	0 #	1 #
Minimum:	0.0	14.1	1,201.9	0.0	0.4	0	0	0
Maximum:	0.0	14.1	1,201.9	0.0	0.4	1	0	1
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/07/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 09:00	0.0	17.9	418.2	0.0	0.1	1	0	0
06/08/2020 10:00	0.0	17.1	526.4	0.0	0.2	1	0	0
06/08/2020 11:00	0.0	16.9	556.0	0.0	0.2	1	0	0
06/08/2020 12:00	0.0	15.4	927.5	0.0	0.3	1	0	0
06/08/2020 13:00	0.4	13.9	1,360.3	0.4	0.4	1	1	0
06/08/2020 14:00	0.4	13.9	1,352.5	0.4	0.4	1	1	0
06/08/2020 15:00	0.4	13.9	1,534.9	0.4	0.5	1	1	0
06/08/2020 16:00	0.4	13.9	1,558.6	0.4	0.5	1	1	0
06/08/2020 17:00	0.4	13.7	1,693.4	0.4	0.5	1	1	0
06/08/2020 18:00	0.4	13.8	1,517.5	0.4	0.5	1	1	0
06/08/2020 19:00	0.2	13.8	1,705.9	0.4	0.5	1	1	1
06/08/2020 20:00	-0.4	12.7	2,013.0	-0.1	0.6	1	1	1
06/08/2020 21:00	-0.2	12.3	2,088.5	0.1	0.6	1	1	1
06/08/2020 22:00	-0.2	12.4	2,058.4	0.1	0.6	1	1	1
06/08/2020 23:00	0.0	13.6	1,572.8	0.0	0.5	1	0	1
Average/Sum#:	0.1	14.3	1,392.3	0.2	0.4	15 #	10 #	5 #
Minimum:	-0.4	12.3	418.2	-0.1	0.1	0	0	0
Maximum:	0.4	17.9	2,088.5	0.4	0.6	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 08:00	0.0	17.6	429.7	0.0	0.1	1	0	0
06/09/2020 09:00	0.0	16.9	523.3	0.0	0.2	1	0	0
06/09/2020 10:00	0.0	15.0	921.1	0.0	0.3	1	0	0
06/09/2020 11:00	0.4	13.9	1,370.4	0.4	0.4	1	1	0
06/09/2020 12:00	0.4	13.9	1,361.9	0.4	0.4	1	1	0
06/09/2020 13:00	0.4	13.8	1,529.4	0.4	0.5	1	1	0
06/09/2020 14:00	0.3	13.8	1,560.0	0.4	0.5	1	1	0
06/09/2020 15:00	0.4	13.8	1,533.6	0.4	0.5	1	1	0
06/09/2020 16:00	0.2	13.8	1,511.4	0.4	0.5	1	1	1
06/09/2020 17:00	-0.4	12.4	2,023.8	-0.1	0.6	1	1	1
06/09/2020 18:00	-0.1	12.0	2,088.7	0.2	0.6	1	1	1
06/09/2020 19:00	-0.1	12.0	2,094.4	0.2	0.6	1	1	1
06/09/2020 20:00	-0.2	12.1	2,066.3	0.1	0.6	1	1	1
06/09/2020 21:00	-0.2	12.3	2,050.2	0.1	0.6	1	1	1
06/09/2020 22:00	-0.2	12.4	2,019.4	0.1	0.6	1	1	1
06/09/2020 23:00	0.0	14.2	1,189.1	0.0	0.4	1	0	1
Average/Sum#:	0.1	13.7	1,517.0	0.2	0.5	16 #	12 #	8 #
Minimum:	-0.4	12.0	429.7	-0.1	0.1	0	0	0
Maximum:	0.4	17.6	2,094.4	0.4	0.6	1	1	1
%SI	33.33	33.33	33.33	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/10/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 07:00	0.0	17.9	394.7	0.0	0.1	1	0	0
06/10/2020 08:00	0.0	14.8	1,015.9	0.0	0.3	1	0	0
06/10/2020 09:00	0.4	13.9	1,374.2	0.4	0.4	1	1	0
06/10/2020 10:00	0.4	13.9	1,390.4	0.4	0.4	1	1	0
06/10/2020 11:00	0.4	13.9	1,393.9	0.4	0.4	1	1	0
06/10/2020 12:00	0.4	13.9	1,397.6	0.4	0.4	1	1	0
06/10/2020 13:00	0.3	13.7	1,679.9	0.4	0.5	1	1	0
06/10/2020 14:00	-0.1	13.6	1,608.4	0.1	0.5	1	1	1
06/10/2020 15:00	-0.2	12.2	2,035.8	0.1	0.6	1	1	1
06/10/2020 16:00	-0.1	11.8	2,113.4	0.2	0.6	1	1	1
06/10/2020 17:00	-0.1	11.9	2,097.6	0.2	0.6	1	1	1
06/10/2020 18:00	-0.1	11.8	2,102.5	0.2	0.6	1	1	1
06/10/2020 19:00	-0.1	12.0	2,068.0	0.2	0.6	1	1	1
06/10/2020 20:00	-0.1	12.0	2,079.4	0.2	0.6	1	1	1
06/10/2020 21:00	-0.1	12.1	2,096.1	0.2	0.6	1	1	1
06/10/2020 22:00	-0.2	12.4	2,028.6	0.1	0.6	1	1	1
06/10/2020 23:00	-0.2	12.2	2,062.2	0.1	0.6	1	1	1
Average/Sum#:	0.0	13.2	1,702.3	0.2	0.5	17 #	15 #	10 #
Minimum:	-0.2	11.8	394.7	0.0	0.1	0	0	0
Maximum:	0.4	17.9	2,113.4	0.4	0.6	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/11/2020 00:00	-0.1	12.6	1,961.8	0.1	0.6	1	1	1
06/11/2020 01:00	0.1	12.6	1,951.3	0.2	0.6	1	1	1
06/11/2020 02:00	-0.1	12.7	1,941.4	0.1	0.6	1	1	1
06/11/2020 03:00	-0.1	12.5	1,991.8	0.1	0.6	1	1	1
06/11/2020 04:00	-0.2	12.7	1,919.3	0.1	0.6	1	1	1
06/11/2020 05:00	0.4	13.6	1,749.0	0.4	0.5	1	1	0
06/11/2020 06:00	0.4	13.6	1,749.1	0.4	0.5	1	1	0
06/11/2020 07:00	0.4	13.6	1,737.9	0.4	0.5	1	1	0
06/11/2020 08:00	0.4	13.6	1,721.5	0.4	0.5	1	1	0
06/11/2020 09:00	0.4	13.6	1,709.5	0.4	0.5	1	1	0
06/11/2020 10:00	0.3	13.6	1,693.4	0.4	0.5	1	1	0
06/11/2020 11:00	0.4	13.8	1,394.1	0.4	0.4	1	1	0
06/11/2020 12:00	0.3	13.7	1,648.5	0.4	0.5	1	1	0
06/11/2020 13:00	0.3	13.8	1,638.4	0.4	0.5	1	1	0
06/11/2020 14:00	0.4	13.8	1,626.6	0.4	0.5	1	1	0
06/11/2020 15:00	0.4	13.7	1,640.2	0.4	0.5	1	1	0
06/11/2020 16:00	0.4	13.8	1,633.9	0.4	0.5	1	1	0
06/11/2020 17:00	0.1	13.7	1,699.8	0.2	0.5	1	1	1
06/11/2020 18:00	-0.2	12.3	2,038.6	0.1	0.6	1	1	1
06/11/2020 19:00	-0.1	11.8	2,146.5	0.2	0.6	1	1	1
06/11/2020 20:00	-0.1	12.0	2,099.0	0.2	0.6	1	1	1
06/11/2020 21:00	-0.1	12.2	2,069.4	0.2	0.6	1	1	1
06/11/2020 22:00	-0.2	12.4	2,021.4	0.1	0.6	1	1	1
06/11/2020 23:00	0.0	14.2	1,190.7	0.0	0.4	1	0	1
Average/Sum#:	0.1	13.2	1,790.5	0.3	0.5	24 #	23 #	12 #
Minimum:	-0.2	11.8	1,190.7	0.0	0.4	1	0	0
Maximum:	0.4	14.2	2,146.5	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/13/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/14/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 12:00	0.0	17.5	463.3	0.0	0.1	1	0	0
06/14/2020 13:00	0.0	15.9	664.5	0.0	0.2	1	0	0
06/14/2020 14:00	0.0	15.5	839.5	0.0	0.3	1	0	0
06/14/2020 15:00	0.1	13.9	1,405.8	0.1	0.4	1	1	0
06/14/2020 16:00	-0.5	12.8	1,923.1	-0.2	0.6	1	1	1
06/14/2020 17:00	-0.5	12.6	1,965.6	-0.2	0.6	1	1	1
06/14/2020 18:00	-0.5	12.3	2,029.4	-0.1	0.6	1	1	1
06/14/2020 19:00	-0.5	12.4	2,018.6	-0.2	0.6	1	1	1
06/14/2020 20:00	-0.5	12.4	2,007.4	-0.2	0.6	1	1	1
06/14/2020 21:00	-0.7	12.8	1,924.1	-0.4	0.6	1	1	1
06/14/2020 22:00	0.4	13.9	1,352.9	0.4	0.4	1	1	0
06/14/2020 23:00	0.0	16.3	408.4	0.0	0.1	1	0	0
Average/Sum#:	-0.2	14.0	1,416.9	-0.1	0.4	12 #	8 #	6 #
Minimum:	-0.7	12.3	408.4	-0.4	0.1	0	0	0
Maximum:	0.4	17.5	2,029.4	0.4	0.6	1	1	1
%SI	50.00	50.00	50.00	50.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/15/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/17/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 09:00	0.0	17.4	471.9	0.0	0.1	1	0	0
06/17/2020 10:00	0.0	17.0	523.0	0.0	0.2	1	0	0
06/17/2020 11:00	0.0	15.3	974.1	0.0	0.3	1	0	0
06/17/2020 12:00	0.4	14.0	1,386.9	0.4	0.4	1	1	0
06/17/2020 13:00	0.4	14.0	1,334.9	0.4	0.4	1	1	0
06/17/2020 14:00	0.4	13.9	1,503.5	0.4	0.5	1	1	0
06/17/2020 15:00	0.4	13.9	1,490.8	0.4	0.4	1	1	0
06/17/2020 16:00	0.4	13.9	1,595.7	0.4	0.5	1	1	0
06/17/2020 17:00	0.2	13.8	1,554.7	0.4	0.5	1	1	1
06/17/2020 18:00	-0.2	12.4	2,050.9	0.1	0.6	1	1	1
06/17/2020 19:00	-0.1	12.0	2,139.1	0.2	0.6	1	1	1
06/17/2020 20:00	-0.1	12.1	2,133.6	0.2	0.6	1	1	1
06/17/2020 21:00	-0.1	12.2	2,093.3	0.2	0.6	1	1	1
06/17/2020 22:00	-0.2	12.4	2,067.0	0.1	0.6	1	1	1
06/17/2020 23:00	0.0	14.3	1,206.4	0.0	0.4	1	0	1
Average/Sum#:	0.1	13.9	1,501.7	0.2	0.4	15 #	11 #	7 #
Minimum:	-0.2	12.0	471.9	0.0	0.1	0	0	0
Maximum:	0.4	17.4	2,139.1	0.4	0.6	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/18/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 07:00	0.0	17.9	399.7	0.0	0.1	1	0	0
06/18/2020 08:00	0.0	15.7	834.3	0.0	0.3	1	0	0
06/18/2020 09:00	0.4	14.0	1,406.2	0.4	0.4	1	1	0
06/18/2020 10:00	0.4	14.0	1,396.6	0.4	0.4	1	1	0
06/18/2020 11:00	0.4	13.9	1,599.8	0.4	0.5	1	1	0
06/18/2020 12:00	0.4	14.0	1,421.5	0.4	0.4	1	1	0
06/18/2020 13:00	0.4	13.9	1,635.1	0.4	0.5	1	1	0
06/18/2020 14:00	0.2	13.9	1,607.8	0.2	0.5	1	1	1
06/18/2020 15:00	-0.4	12.5	2,025.0	-0.1	0.6	1	1	1
06/18/2020 16:00	-0.1	12.0	2,120.1	0.2	0.6	1	1	1
06/18/2020 17:00	-0.1	12.1	2,101.7	0.2	0.6	1	1	1
06/18/2020 18:00	-0.1	12.0	2,097.6	0.2	0.6	1	1	1
06/18/2020 19:00	-0.1	12.1	2,096.8	0.2	0.6	1	1	1
06/18/2020 20:00	-0.1	12.1	2,102.1	0.2	0.6	1	1	1
06/18/2020 21:00	-0.1	12.2	2,082.9	0.2	0.6	1	1	1
06/18/2020 22:00	-0.2	12.7	1,947.9	0.1	0.6	1	1	1
06/18/2020 23:00	0.0	15.7	626.2	0.0	0.2	1	0	0
Average/Sum#:	0.1	13.6	1,617.7	0.2	0.5	17 #	14 #	9 #
Minimum:	-0.4	12.0	399.7	-0.1	0.1	0	0	0
Maximum:	0.4	17.9	2,120.1	0.4	0.6	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/19/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/20/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 20:00	0.0	17.4	467.0	0.0	0.1	1	0	0
06/20/2020 21:00	0.0	17.0	514.1	0.0	0.2	1	0	0
06/20/2020 22:00	0.0	14.9	1,000.8	0.0	0.3	1	0	0
06/20/2020 23:00	0.3	13.8	1,386.9	0.4	0.4	1	1	0
Average/Sum#:	0.1	15.8	842.2	0.1	0.3	4 #	1 #	0 #
Minimum:	0.0	13.8	467.0	0.0	0.1	0	0	0
Maximum:	0.3	17.4	1,386.9	0.4	0.4	1	1	0
%SI	83.33	83.33	83.33	83.33	83.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/21/2020 00:00	0.4	13.8	1,347.7	0.4	0.4	1	1	0
06/21/2020 01:00	0.4	13.8	1,344.8	0.4	0.4	1	1	0
06/21/2020 02:00	0.4	13.9	1,343.1	0.4	0.4	1	1	0
06/21/2020 03:00	0.4	13.9	1,342.2	0.4	0.4	1	1	0
06/21/2020 04:00	0.4	13.9	1,344.1	0.4	0.4	1	1	0
06/21/2020 05:00	0.4	13.9	1,348.4	0.4	0.4	1	1	0
06/21/2020 06:00	0.3	13.9	1,347.9	0.4	0.4	1	1	0
06/21/2020 07:00	0.4	13.9	1,347.9	0.4	0.4	1	1	0
06/21/2020 08:00	0.4	13.9	1,352.3	0.4	0.4	1	1	0
06/21/2020 09:00	0.4	13.9	1,358.7	0.4	0.4	1	1	0
06/21/2020 10:00	0.4	13.9	1,361.3	0.4	0.4	1	1	0
06/21/2020 11:00	0.4	13.9	1,361.3	0.4	0.4	1	1	0
06/21/2020 12:00	0.4	13.9	1,360.6	0.4	0.4	1	1	0
06/21/2020 13:00	0.4	13.9	1,361.1	0.4	0.4	1	1	0
06/21/2020 14:00	0.4	13.9	1,363.1	0.4	0.4	1	1	0
06/21/2020 15:00	0.4	13.9	1,366.2	0.4	0.4	1	1	0
06/21/2020 16:00	0.4	13.9	1,398.5	0.4	0.4	1	1	0
06/21/2020 17:00	-0.7	12.7	1,924.8	-0.2	0.6	1	1	1
06/21/2020 18:00	-0.4	12.0	2,075.6	-0.1	0.6	1	1	1
06/21/2020 19:00	-0.4	11.8	2,111.5	-0.1	0.6	1	1	1
06/21/2020 20:00	-0.4	12.1	2,051.6	-0.1	0.6	1	1	1
06/21/2020 21:00	-0.5	12.4	1,966.4	-0.2	0.6	1	1	1
06/21/2020 22:00	0.4	13.9	1,368.6	0.4	0.4	1	1	0
06/21/2020 23:00	0.4	13.9	1,358.7	0.4	0.4	1	1	0
Average/Sum#:	0.2	13.5	1,496.1	0.3	0.4	24 #	24 #	5 #
Minimum:	-0.7	11.8	1,342.2	-0.2	0.4	1	1	0
Maximum:	0.4	13.9	2,111.5	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/22/2020 00:00	0.2	13.8	1,346.5	0.3	0.4	1	1	0
06/22/2020 01:00	0.3	13.9	1,340.7	0.4	0.4	1	1	0
06/22/2020 02:00	0.3	13.9	1,342.2	0.4	0.4	1	1	0
06/22/2020 03:00	0.3	13.9	1,349.0	0.4	0.4	1	1	0
06/22/2020 04:00	0.3	13.9	1,343.9	0.4	0.4	1	1	0
06/22/2020 05:00	0.3	13.9	1,410.1	0.4	0.4	1	1	0
06/22/2020 06:00	0.4	13.9	1,345.6	0.4	0.4	1	1	0
06/22/2020 07:00	0.4	13.9	1,352.5	0.4	0.4	1	1	0
06/22/2020 08:00	0.4	13.9	1,361.4	0.4	0.4	1	1	0
06/22/2020 09:00	0.4	13.9	1,371.7	0.4	0.4	1	1	0
06/22/2020 10:00	0.4	13.8	1,519.1	0.4	0.5	1	1	0
06/22/2020 11:00	0.3	13.8	1,539.9	0.4	0.5	1	1	0
06/22/2020 12:00	0.3	13.8	1,625.6	0.4	0.5	1	1	0
06/22/2020 13:00	0.1	13.8	1,628.6	0.2	0.5	1	1	1
06/22/2020 14:00	-0.2	12.1	2,029.7	0.1	0.6	1	1	1
06/22/2020 15:00	-0.1	11.9	2,068.2	0.2	0.6	1	1	1
06/22/2020 16:00	-0.1	11.9	2,061.1	0.2	0.6	1	1	1
06/22/2020 17:00	0.1	11.9	2,060.8	0.2	0.6	1	1	1
06/22/2020 18:00	0.1	11.8	2,080.1	0.2	0.6	1	1	1
06/22/2020 19:00	0.1	11.8	2,089.9	0.2	0.6	1	1	1
06/22/2020 20:00	0.1	11.8	2,098.5	0.2	0.6	1	1	1
06/22/2020 21:00	-0.1	11.9	2,077.8	0.2	0.6	1	1	1
06/22/2020 22:00	-0.1	12.0	2,065.3	0.2	0.6	1	1	1
06/22/2020 23:00	-0.2	12.1	2,044.8	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.1	1,689.7	0.3	0.5	24 #	24 #	11 #
Minimum:	-0.2	11.8	1,340.7	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,098.5	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/23/2020 00:00	0.0	14.0	1,192.7	0.0	0.4	1	0	1
06/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 12:00	0.0	18.2	355.7	0.0	0.1	1	0	0
06/23/2020 13:00	0.0	15.8	661.7	0.0	0.2	1	0	0
06/23/2020 14:00	0.0	14.0	1,344.1	0.0	0.4	1	0	0
06/23/2020 15:00	0.1	13.7	1,651.2	0.2	0.5	1	1	1
06/23/2020 16:00	-0.1	12.0	2,038.6	0.2	0.6	1	1	1
06/23/2020 17:00	0.1	11.8	2,061.5	0.2	0.6	1	1	1
06/23/2020 18:00	0.1	11.9	2,053.0	0.2	0.6	1	1	1
06/23/2020 19:00	0.1	11.8	2,073.5	0.2	0.6	1	1	1
06/23/2020 20:00	0.1	11.8	2,092.6	0.2	0.6	1	1	1
06/23/2020 21:00	0.1	11.9	2,057.5	0.2	0.6	1	1	1
06/23/2020 22:00	0.1	12.0	2,054.1	0.2	0.6	1	1	1
06/23/2020 23:00	0.1	12.0	2,055.4	0.2	0.6	1	1	1
Average/Sum#:	0.1	13.1	1,668.6	0.1	0.5	13 #	9 #	10 #
Minimum:	-0.1	11.8	355.7	0.0	0.1	0	0	0
Maximum:	0.1	18.2	2,092.6	0.2	0.6	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/24/2020 00:00	-0.1	12.5	1,977.9	0.1	0.6	1	1	1
06/24/2020 01:00	-0.1	12.8	1,934.3	0.1	0.6	1	1	1
06/24/2020 02:00	-0.2	12.8	1,936.5	0.1	0.6	1	1	1
06/24/2020 03:00	-0.2	12.8	1,940.1	0.1	0.6	1	1	1
06/24/2020 04:00	-0.1	12.5	2,016.8	0.1	0.6	1	1	1
06/24/2020 05:00	-0.1	12.3	2,057.2	0.2	0.6	1	1	1
06/24/2020 06:00	-0.2	12.8	1,960.3	0.1	0.6	1	1	1
06/24/2020 07:00	0.4	13.8	1,580.0	0.4	0.5	1	1	0
06/24/2020 08:00	0.4	13.8	1,580.0	0.4	0.5	1	1	0
06/24/2020 09:00	0.4	13.8	1,582.0	0.4	0.5	1	1	0
06/24/2020 10:00	0.4	13.9	1,534.4	0.4	0.5	1	1	0
06/24/2020 11:00	0.1	13.7	1,575.6	0.2	0.5	1	1	1
06/24/2020 12:00	-0.2	12.1	2,030.3	0.1	0.6	1	1	1
06/24/2020 13:00	-0.1	11.8	2,065.4	0.2	0.6	1	1	1
06/24/2020 14:00	-0.1	11.8	2,068.8	0.2	0.6	1	1	1
06/24/2020 15:00	-0.1	11.8	2,070.7	0.2	0.6	1	1	1
06/24/2020 16:00	-0.1	11.8	2,063.8	0.2	0.6	1	1	1
06/24/2020 17:00	-0.1	11.8	2,066.0	0.2	0.6	1	1	1
06/24/2020 18:00	0.1	11.8	2,075.1	0.2	0.6	1	1	1
06/24/2020 19:00	0.1	11.8	2,065.2	0.2	0.6	1	1	1
06/24/2020 20:00	0.1	11.8	2,066.1	0.2	0.6	1	1	1
06/24/2020 21:00	0.1	11.8	2,068.5	0.2	0.6	1	1	1
06/24/2020 22:00	-0.1	11.9	2,052.6	0.2	0.6	1	1	1
06/24/2020 23:00	-0.1	11.9	2,053.3	0.2	0.6	1	1	1
Average/Sum#:	0.0	12.5	1,934.2	0.2	0.6	24 #	24 #	20 #
Minimum:	-0.2	11.8	1,534.4	0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,075.1	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/25/2020 00:00	0.0	13.8	1,305.0	0.0	0.4	1	0	1
06/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 08:00	0.0	18.7	288.8	0.0	0.1	1	0	0
06/25/2020 09:00	0.0	15.4	922.6	0.0	0.3	1	0	0
06/25/2020 10:00	0.4	13.9	1,414.1	0.4	0.4	1	1	0
06/25/2020 11:00	0.4	13.9	1,420.7	0.4	0.4	1	1	0
06/25/2020 12:00	0.4	13.8	1,595.0	0.4	0.5	1	1	0
06/25/2020 13:00	0.4	13.8	1,409.5	0.4	0.4	1	1	0
06/25/2020 14:00	0.4	13.9	1,310.8	0.4	0.4	1	1	0
06/25/2020 15:00	0.3	13.8	1,404.5	0.4	0.4	1	1	0
06/25/2020 16:00	0.4	13.9	1,345.0	0.4	0.4	1	1	0
06/25/2020 17:00	0.1	13.7	1,641.6	0.2	0.5	1	1	1
06/25/2020 18:00	-0.2	12.3	1,959.7	0.1	0.6	1	1	1
06/25/2020 19:00	-0.2	12.2	1,976.5	0.1	0.6	1	1	1
06/25/2020 20:00	-0.1	12.2	1,969.5	0.2	0.6	1	1	1
06/25/2020 21:00	-0.1	12.3	1,962.0	0.2	0.6	1	1	1
06/25/2020 22:00	0.0	13.4	1,455.8	0.0	0.4	1	0	1
06/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.1	13.8	1,461.3	0.2	0.4	16 #	12 #	7 #
Minimum:	-0.2	12.2	288.8	0.0	0.1	0	0	0
Maximum:	0.4	18.7	1,976.5	0.4	0.6	1	1	1
%SI	33.33	33.33	33.33	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 05:00	0.0	18.6	299.2	0.0	0.1	1	0	0
06/26/2020 06:00	0.0	15.8	762.7	0.0	0.2	1	0	0
06/26/2020 07:00	0.4	13.9	1,389.5	0.4	0.4	1	1	0
06/26/2020 08:00	0.4	13.8	1,394.7	0.4	0.4	1	1	0
06/26/2020 09:00	0.4	13.9	1,407.3	0.4	0.4	1	1	0
06/26/2020 10:00	0.4	13.7	1,607.1	0.4	0.5	1	1	0
06/26/2020 11:00	0.4	13.9	1,436.8	0.4	0.4	1	1	0
06/26/2020 12:00	0.2	13.7	1,556.9	0.3	0.5	1	1	0
06/26/2020 13:00	0.3	13.6	1,683.4	0.4	0.5	1	1	0
06/26/2020 14:00	0.3	13.6	1,684.7	0.4	0.5	1	1	0
06/26/2020 15:00	0.2	13.6	1,681.1	0.3	0.5	1	1	0
06/26/2020 16:00	0.3	13.6	1,683.0	0.4	0.5	1	1	0
06/26/2020 17:00	-0.1	13.1	1,639.2	0.1	0.5	1	1	1
06/26/2020 18:00	0.1	11.7	2,063.8	0.2	0.6	1	1	1
06/26/2020 19:00	0.1	11.7	2,073.5	0.2	0.6	1	1	1
06/26/2020 20:00	0.1	11.8	2,070.5	0.2	0.6	1	1	1
06/26/2020 21:00	0.1	11.9	2,057.0	0.2	0.6	1	1	1
06/26/2020 22:00	-0.2	12.3	1,960.5	0.1	0.6	1	1	1
06/26/2020 23:00	0.2	13.5	1,470.0	0.4	0.4	1	1	1
Average/Sum#:	0.2	13.6	1,574.8	0.3	0.5	19 #	17 #	7 #
Minimum:	-0.2	11.7	299.2	0.0	0.1	0	0	0
Maximum:	0.4	18.6	2,073.5	0.4	0.6	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/27/2020 00:00	0.0	14.4	1,069.5	0.0	0.3	1	0	0
06/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	14.4	1,069.5	0.0	0.3	1 #	0 #	0 #
Minimum:	0.0	14.4	1,069.5	0.0	0.3	0	0	0
Maximum:	0.0	14.4	1,069.5	0.0	0.3	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/28/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/30/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 08:00	0.0	17.8	411.2	0.0	0.1	1	0	0
06/30/2020 09:00	0.0	17.1	515.4	0.0	0.2	1	0	0
06/30/2020 10:00	0.0	16.7	566.3	0.0	0.2	1	0	0
06/30/2020 11:00	0.0	15.4	879.5	0.0	0.3	1	0	0
06/30/2020 12:00	0.4	14.0	1,368.0	0.4	0.4	1	1	0
06/30/2020 13:00	0.4	14.0	1,361.5	0.4	0.4	1	1	0
06/30/2020 14:00	0.4	14.0	1,504.2	0.4	0.5	1	1	0
06/30/2020 15:00	0.4	14.0	1,481.8	0.4	0.4	1	1	0
06/30/2020 16:00	0.4	14.0	1,353.2	0.4	0.4	1	1	0
06/30/2020 17:00	0.2	13.8	1,540.8	0.4	0.5	1	1	1
06/30/2020 18:00	-0.2	12.2	2,044.0	0.1	0.6	1	1	1
06/30/2020 19:00	0.1	12.0	2,096.2	0.2	0.6	1	1	1
06/30/2020 20:00	-0.1	12.0	2,087.1	0.2	0.6	1	1	1
06/30/2020 21:00	-0.1	12.1	2,068.1	0.2	0.6	1	1	1
06/30/2020 22:00	0.0	13.9	1,231.7	0.0	0.4	1	0	1
06/30/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.1	14.2	1,367.3	0.2	0.4	15 #	10 #	6 #
Minimum:	-0.2	12.0	411.2	0.0	0.1	0	0	0
Maximum:	0.4	17.8	2,096.2	0.4	0.6	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Excess Emission Report

CT1 - VOC Lb 1-Day Block Average

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:16 **Location:** Maxwell, CA

Tag Name: CT1_VOC_Lb_1D
Total Operating Time: 41.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 50.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**41.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - VOC LbPerHr 1-Hour Block Average

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:16 **Location:** Maxwell, CA

Tag Name: CT1_VOC_LbPerHr_1H
Total Operating Time: 615.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,569.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**615.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - VOC Ppmvdc 1-Hour Block Average

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:17 **Location:** Maxwell, CA

Tag Name: CT1_VOC_Ppmvdc_1H
Total Operating Time: 615.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,569.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**615.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - VOC Ppmvdc 1-Hour Block Average

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:18 **Location:** Maxwell, CA

Tag Name: CT2_VOC_Ppmvdc_1H
Total Operating Time: 809.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,375.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**809.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - VOC LbPerHr 1-Hour Block Average

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:19 **Location:** Maxwell, CA

Tag Name: CT2_VOC_LbPerHr_1H
Total Operating Time: 809.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,375.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**809.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - VOC Ppmvdc 1-Hour Block Average

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:20 **Location:** Maxwell, CA

Tag Name: CT2_VOC_Ppmvdc_1H
Total Operating Time: 809.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,375.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**809.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 6
Hourly Emissions – NOx

FCD: AQ-15
Title V: #6

Excess Emission Report

CT1 - NOx Lb 1-Day Block Average

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:23 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Lb_1D
Total Operating Time: 697.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,487.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**697.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx Lb 1-Day Block Average

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:23 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Lb_1D
Total Operating Time: 903.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,281.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**903.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/01/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/01/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/01/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/01/2020 03:00	19.6	18.4	353.0	46.3	16.80	1	0	0
04/01/2020 04:00	28.0	15.8	811.8	32.4	96.60	1	0	0
04/01/2020 05:00	0.6	13.9	1,557.8	0.5	3.10	1	1	0
04/01/2020 06:00	0.8	13.9	1,506.9	0.7	3.00	1	1	0
04/01/2020 07:00	0.9	13.9	1,584.0	0.8	4.80	1	1	0
04/01/2020 08:00	0.9	14.0	1,489.8	0.8	4.50	1	1	0
04/01/2020 09:00	0.8	14.0	1,404.4	0.7	4.20	1	1	0
04/01/2020 10:00	0.7	14.0	1,313.0	0.6	2.60	1	1	0
04/01/2020 11:00	0.6	14.1	1,289.9	0.5	2.60	1	1	0
04/01/2020 12:00	0.6	14.1	1,302.9	0.5	2.60	1	1	0
04/01/2020 13:00	0.8	14.0	1,478.7	0.7	4.40	1	1	0
04/01/2020 14:00	0.8	14.0	1,535.9	0.7	4.60	1	1	0
04/01/2020 15:00	0.9	14.0	1,611.1	0.8	4.80	1	1	0
04/01/2020 16:00	0.9	14.0	1,639.0	0.8	4.90	1	1	0
04/01/2020 17:00	0.9	14.0	1,579.7	0.8	4.70	1	1	1
04/01/2020 18:00	1.2	12.8	1,985.9	0.9	6.00	1	1	1
04/01/2020 19:00	1.4	12.1	2,127.7	0.9	6.40	1	1	1
04/01/2020 20:00	1.3	12.1	2,105.9	0.9	6.30	1	1	1
04/01/2020 21:00	1.3	12.1	2,106.5	0.9	6.30	1	1	1
04/01/2020 22:00	1.3	12.2	2,101.2	0.9	6.30	1	1	1
04/01/2020 23:00	1.2	12.4	2,033.1	0.8	6.10	1	1	1
Average/Sum#:	3.1	13.8	1,567.5	4.4	201.60 #	21 #	19 #	7 #
Minimum:	0.6	12.1	353.0	0.5	2.60	0	0	0
Maximum:	28.0	18.4	2,127.7	46.3	96.60	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/02/2020 00:00	0.8	14.0	1,537.8	0.7	4.60	1	1	0
04/02/2020 01:00	0.9	13.9	1,508.4	0.8	4.50	1	1	0
04/02/2020 02:00	0.9	13.9	1,599.4	0.8	4.80	1	1	0
04/02/2020 03:00	0.9	13.9	1,659.7	0.8	5.00	1	1	0
04/02/2020 04:00	0.9	13.9	1,652.7	0.8	5.00	1	1	0
04/02/2020 05:00	0.8	13.9	1,567.0	0.7	3.10	1	1	0
04/02/2020 06:00	0.9	13.9	1,659.3	0.8	5.00	1	1	0
04/02/2020 07:00	0.9	13.9	1,613.9	0.8	4.80	1	1	0
04/02/2020 08:00	0.9	13.9	1,662.5	0.8	5.00	1	1	0
04/02/2020 09:00	0.9	14.0	1,651.3	0.8	5.00	1	1	0
04/02/2020 10:00	0.9	14.0	1,621.9	0.8	4.90	1	1	0
04/02/2020 11:00	0.8	14.0	1,541.9	0.7	4.60	1	1	0
04/02/2020 12:00	0.9	14.0	1,581.1	0.8	4.70	1	1	0
04/02/2020 13:00	0.9	14.0	1,639.6	0.8	4.90	1	1	0
04/02/2020 14:00	0.9	14.0	1,650.7	0.8	5.00	1	1	0
04/02/2020 15:00	0.9	14.0	1,649.1	0.8	4.90	1	1	0
04/02/2020 16:00	0.9	14.0	1,611.3	0.8	4.80	1	1	0
04/02/2020 17:00	0.9	13.9	1,605.5	0.8	4.80	1	1	1
04/02/2020 18:00	1.3	12.8	1,981.5	0.9	5.90	1	1	1
04/02/2020 19:00	1.3	12.6	2,016.3	0.9	6.00	1	1	1
04/02/2020 20:00	1.3	12.6	2,019.0	0.9	6.10	1	1	1
04/02/2020 21:00	2.5	14.4	1,191.0	2.3	4.47	1	0	1
04/02/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/02/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.0	13.8	1,646.4	0.9	107.87 #	22 #	21 #	5 #
Minimum:	0.8	12.6	1,191.0	0.7	3.10	0	0	0
Maximum:	2.5	14.4	2,019.0	2.3	6.10	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/03/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/04/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/04/2020 01:00	28.4	17.6	462.0	50.8	80.35	1	0	0
04/04/2020 02:00	11.1	15.0	1,036.3	11.1	42.50	1	0	0
04/04/2020 03:00	0.9	13.9	1,662.5	0.8	5.00	1	1	0
04/04/2020 04:00	0.9	13.9	1,644.8	0.8	4.90	1	1	0
04/04/2020 05:00	0.9	13.9	1,663.3	0.8	5.00	1	1	0
04/04/2020 06:00	0.8	13.9	1,642.1	0.7	3.30	1	1	0
04/04/2020 07:00	0.9	13.9	1,663.5	0.8	5.00	1	1	0
04/04/2020 08:00	0.9	13.9	1,652.0	0.8	5.00	1	1	0
04/04/2020 09:00	0.9	13.9	1,640.7	0.8	4.90	1	1	0
04/04/2020 10:00	0.9	13.9	1,619.1	0.8	4.90	1	1	0
04/04/2020 11:00	0.9	13.9	1,642.1	0.8	4.90	1	1	0
04/04/2020 12:00	0.9	13.9	1,656.0	0.8	5.00	1	1	0
04/04/2020 13:00	0.9	13.9	1,655.6	0.8	5.00	1	1	0
04/04/2020 14:00	0.9	13.9	1,658.9	0.8	5.00	1	1	0
04/04/2020 15:00	0.9	13.9	1,625.9	0.8	4.90	1	1	0
04/04/2020 16:00	0.9	13.9	1,653.4	0.8	5.00	1	1	0
04/04/2020 17:00	0.9	13.9	1,620.9	0.8	4.90	1	1	1
04/04/2020 18:00	1.3	12.6	1,980.0	0.9	5.90	1	1	1
04/04/2020 19:00	1.4	11.7	2,149.7	0.9	6.40	1	1	1
04/04/2020 20:00	1.4	11.9	2,113.6	0.9	6.30	1	1	1
04/04/2020 21:00	1.4	11.9	2,103.1	0.9	6.30	1	1	1
04/04/2020 22:00	1.3	11.9	2,096.2	0.9	6.30	1	1	1
04/04/2020 23:00	1.3	12.0	2,099.4	0.9	6.30	1	1	1
Average/Sum#:	2.7	13.6	1,684.4	3.4	233.05 #	23 #	21 #	7 #
Minimum:	0.8	11.7	462.0	0.7	3.30	0	0	0
Maximum:	28.4	17.6	2,149.7	50.8	80.35	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/05/2020 00:00	1.4	12.0	2,095.2	0.9	6.30	1	1	1
04/05/2020 01:00	0.9	13.6	1,685.9	0.7	5.10	1	1	1
04/05/2020 02:00	0.9	13.9	1,642.4	0.8	4.90	1	1	0
04/05/2020 03:00	0.9	13.9	1,637.4	0.8	4.90	1	1	0
04/05/2020 04:00	0.9	13.9	1,637.2	0.8	4.90	1	1	0
04/05/2020 05:00	0.9	13.9	1,650.3	0.8	5.00	1	1	0
04/05/2020 06:00	0.9	13.9	1,641.6	0.8	4.90	1	1	0
04/05/2020 07:00	0.9	13.9	1,609.9	0.8	4.80	1	1	0
04/05/2020 08:00	0.9	13.9	1,651.9	0.8	5.00	1	1	0
04/05/2020 09:00	0.9	13.9	1,627.5	0.8	4.90	1	1	0
04/05/2020 10:00	0.8	13.9	1,609.1	0.7	3.20	1	1	0
04/05/2020 11:00	0.9	13.9	1,590.4	0.8	4.80	1	1	0
04/05/2020 12:00	0.9	13.9	1,555.2	0.8	4.70	1	1	0
04/05/2020 13:00	0.9	14.0	1,632.7	0.8	4.90	1	1	0
04/05/2020 14:00	0.9	14.0	1,634.9	0.8	4.90	1	1	0
04/05/2020 15:00	0.9	14.0	1,633.0	0.8	4.90	1	1	0
04/05/2020 16:00	1.1	13.4	1,759.4	0.9	5.30	1	1	1
04/05/2020 17:00	1.3	12.1	2,083.0	0.9	6.20	1	1	1
04/05/2020 18:00	1.3	12.2	2,055.1	0.9	6.20	1	1	1
04/05/2020 19:00	1.3	12.3	2,047.8	0.9	6.10	1	1	1
04/05/2020 20:00	1.3	12.3	2,053.2	0.9	6.20	1	1	1
04/05/2020 21:00	1.3	12.2	2,068.9	0.9	6.20	1	1	1
04/05/2020 22:00	1.3	12.4	2,037.4	0.9	6.10	1	1	1
04/05/2020 23:00	1.3	12.3	2,062.5	0.9	6.20	1	1	1
Average/Sum#:	1.0	13.3	1,779.2	0.8	126.60 #	24 #	24 #	10 #
Minimum:	0.8	12.0	1,555.2	0.7	3.20	1	1	0
Maximum:	1.4	14.0	2,095.2	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/06/2020 00:00	1.3	12.3	2,067.4	0.9	6.20	1	1	1
04/06/2020 01:00	1.3	12.3	2,068.9	0.9	6.20	1	1	1
04/06/2020 02:00	1.3	12.1	2,093.7	0.9	6.30	1	1	1
04/06/2020 03:00	1.4	12.2	2,083.5	0.9	6.30	1	1	1
04/06/2020 04:00	1.3	12.5	2,038.7	0.9	6.10	1	1	1
04/06/2020 05:00	1.3	12.3	2,052.4	0.9	6.20	1	1	1
04/06/2020 06:00	1.2	12.3	2,073.6	0.8	6.20	1	1	1
04/06/2020 07:00	0.0	0.0	2,021.6	0.0	0.00	1	1	1
04/06/2020 08:00	0.5	13.9	1,626.6	0.4	3.30	1	1	0
04/06/2020 09:00	0.5	13.9	1,641.8	0.4	3.30	1	1	0
04/06/2020 10:00	0.5	13.9	1,652.5	0.4	3.30	1	1	0
04/06/2020 11:00	0.6	13.9	1,591.2	0.5	3.20	1	1	0
04/06/2020 12:00	0.7	13.9	1,586.5	0.6	3.20	1	1	0
04/06/2020 13:00	0.5	14.0	1,564.8	0.4	3.10	1	1	0
04/06/2020 14:00	0.6	14.0	1,633.7	0.5	3.30	1	1	0
04/06/2020 15:00	0.6	14.0	1,641.7	0.5	3.30	1	1	0
04/06/2020 16:00	0.8	13.9	1,527.3	0.7	3.10	1	1	1
04/06/2020 17:00	1.3	12.7	1,981.1	0.9	5.90	1	1	1
04/06/2020 18:00	1.3	12.5	2,005.1	0.9	6.00	1	1	1
04/06/2020 19:00	1.3	12.8	1,953.7	0.9	5.90	1	1	1
04/06/2020 20:00	1.3	12.6	2,000.2	0.9	6.00	1	1	1
04/06/2020 21:00	1.3	12.4	2,043.5	0.9	6.10	1	1	1
04/06/2020 22:00	1.3	12.4	2,039.7	0.9	6.10	1	1	1
04/06/2020 23:00	1.3	12.2	2,079.0	0.9	6.20	1	1	1
Average/Sum#:	1.0	13.0	1,877.8	0.7	114.80 #	24 #	24 #	16 #
Minimum:	0.5	12.1	1,527.3	0.4	3.10	1	1	0
Maximum:	1.4	14.0	2,093.7	0.9	6.30	1	1	1
%SI	4.17	4.17	0.00	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/07/2020 00:00	1.3	12.6	2,007.9	0.9	6.00	1	1	1
04/07/2020 01:00	1.3	12.7	2,002.7	0.9	6.00	1	1	1
04/07/2020 02:00	1.3	12.7	2,005.4	0.9	6.00	1	1	1
04/07/2020 03:00	1.3	12.7	1,997.8	0.9	6.00	1	1	1
04/07/2020 04:00	1.2	12.7	1,994.6	0.9	6.00	1	1	1
04/07/2020 05:00	1.1	12.7	1,998.6	0.8	6.00	1	1	1
04/07/2020 06:00	1.2	12.9	1,933.9	0.9	5.80	1	1	1
04/07/2020 07:00	0.8	13.9	1,606.0	0.7	3.20	1	1	0
04/07/2020 08:00	0.8	13.9	1,615.6	0.7	3.20	1	1	0
04/07/2020 09:00	0.8	13.9	1,645.3	0.7	3.30	1	1	0
04/07/2020 10:00	0.9	13.9	1,642.5	0.8	4.90	1	1	0
04/07/2020 11:00	0.9	13.9	1,651.8	0.8	5.00	1	1	0
04/07/2020 12:00	0.9	13.9	1,651.0	0.8	5.00	1	1	0
04/07/2020 13:00	0.8	13.9	1,604.9	0.7	3.20	1	1	0
04/07/2020 14:00	0.8	14.0	1,586.4	0.7	4.80	1	1	0
04/07/2020 15:00	0.9	14.0	1,649.5	0.8	4.90	1	1	0
04/07/2020 16:00	0.9	14.0	1,657.1	0.8	5.00	1	1	0
04/07/2020 17:00	0.9	13.9	1,579.6	0.8	4.70	1	1	1
04/07/2020 18:00	1.3	12.7	1,957.2	0.9	5.90	1	1	1
04/07/2020 19:00	1.3	12.5	2,006.4	0.9	6.00	1	1	1
04/07/2020 20:00	1.3	12.0	2,089.5	0.9	6.30	1	1	1
04/07/2020 21:00	1.3	12.0	2,095.7	0.9	6.30	1	1	1
04/07/2020 22:00	1.3	12.0	2,097.9	0.9	6.30	1	1	1
04/07/2020 23:00	1.3	12.1	2,101.5	0.9	6.30	1	1	1
Average/Sum#:	1.1	13.1	1,840.8	0.8	126.10 #	24 #	24 #	14 #
Minimum:	0.8	12.0	1,579.6	0.7	3.20	1	1	0
Maximum:	1.3	14.0	2,101.5	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/08/2020 00:00	1.3	12.4	1,995.2	0.9	6.00	1	1	1
04/08/2020 01:00	0.8	13.9	1,635.7	0.7	3.30	1	1	0
04/08/2020 02:00	0.8	13.9	1,604.4	0.7	3.20	1	1	0
04/08/2020 03:00	0.9	13.9	1,635.9	0.8	4.90	1	1	0
04/08/2020 04:00	0.8	13.9	1,596.3	0.7	3.20	1	1	0
04/08/2020 05:00	0.9	13.9	1,643.9	0.8	4.90	1	1	0
04/08/2020 06:00	0.9	13.9	1,655.1	0.8	5.00	1	1	0
04/08/2020 07:00	0.9	13.9	1,624.4	0.8	4.90	1	1	0
04/08/2020 08:00	0.9	13.9	1,648.3	0.8	4.90	1	1	0
04/08/2020 09:00	0.9	13.9	1,658.4	0.8	5.00	1	1	0
04/08/2020 10:00	0.9	13.9	1,653.4	0.8	5.00	1	1	0
04/08/2020 11:00	0.9	13.9	1,616.0	0.8	4.80	1	1	0
04/08/2020 12:00	1.0	14.0	1,653.6	0.9	5.00	1	1	0
04/08/2020 13:00	1.0	13.9	1,647.6	0.8	4.90	1	1	0
04/08/2020 14:00	1.0	13.9	1,653.7	0.8	5.00	1	1	0
04/08/2020 15:00	1.0	13.9	1,646.7	0.8	4.90	1	1	0
04/08/2020 16:00	0.9	13.9	1,642.3	0.8	4.90	1	1	0
04/08/2020 17:00	1.0	13.5	1,740.3	0.8	5.20	1	1	1
04/08/2020 18:00	1.3	12.1	2,064.2	0.9	6.20	1	1	1
04/08/2020 19:00	1.4	11.6	2,171.9	0.9	6.50	1	1	1
04/08/2020 20:00	1.4	11.9	2,115.9	0.9	6.30	1	1	1
04/08/2020 21:00	1.3	12.0	2,096.0	0.9	6.30	1	1	1
04/08/2020 22:00	1.3	12.0	2,095.2	0.9	6.30	1	1	1
04/08/2020 23:00	1.3	12.0	2,096.4	0.9	6.30	1	1	1
Average/Sum#:	1.0	13.3	1,774.6	0.8	122.90 #	24 #	24 #	8 #
Minimum:	0.8	11.6	1,596.3	0.7	3.20	1	1	0
Maximum:	1.4	14.0	2,171.9	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/09/2020 00:00	1.3	12.0	2,104.2	0.9	6.30	1	1	1
04/09/2020 01:00	1.3	12.0	2,105.4	0.9	6.30	1	1	1
04/09/2020 02:00	1.3	12.0	2,104.8	0.9	6.30	1	1	1
04/09/2020 03:00	1.3	12.1	2,098.4	0.9	6.30	1	1	1
04/09/2020 04:00	1.3	12.3	2,060.4	0.9	6.20	1	1	1
04/09/2020 05:00	1.2	12.3	2,055.3	0.8	6.20	1	1	1
04/09/2020 06:00	1.3	12.1	2,096.3	0.9	6.30	1	1	1
04/09/2020 07:00	1.3	12.1	2,099.4	0.9	6.30	1	1	1
04/09/2020 08:00	1.3	12.1	2,095.5	0.9	6.30	1	1	1
04/09/2020 09:00	1.3	12.1	2,095.1	0.9	6.30	1	1	1
04/09/2020 10:00	1.3	12.1	2,086.3	0.9	6.30	1	1	1
04/09/2020 11:00	1.3	12.4	2,024.7	0.9	6.10	1	1	1
04/09/2020 12:00	1.3	12.2	2,066.1	0.9	6.20	1	1	1
04/09/2020 13:00	1.3	12.1	2,066.8	0.9	6.20	1	1	1
04/09/2020 14:00	1.3	12.2	2,049.1	0.9	6.10	1	1	1
04/09/2020 15:00	1.3	12.1	2,059.3	0.9	6.20	1	1	1
04/09/2020 16:00	1.3	12.2	2,045.4	0.9	6.10	1	1	1
04/09/2020 17:00	1.3	12.1	2,062.5	0.9	6.20	1	1	1
04/09/2020 18:00	1.3	12.1	2,073.9	0.9	6.20	1	1	1
04/09/2020 19:00	1.3	12.0	2,094.3	0.9	6.30	1	1	1
04/09/2020 20:00	1.3	11.9	2,097.1	0.9	6.30	1	1	1
04/09/2020 21:00	1.3	12.1	2,075.1	0.9	6.20	1	1	1
04/09/2020 22:00	1.3	12.2	2,057.1	0.9	6.20	1	1	1
04/09/2020 23:00	1.3	12.0	2,100.7	0.9	6.30	1	1	1
Average/Sum#:	1.3	12.1	2,078.1	0.9	149.70 #	24 #	24 #	24 #
Minimum:	1.2	11.9	2,024.7	0.8	6.10	1	1	1
Maximum:	1.3	12.4	2,105.4	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/10/2020 00:00	1.3	12.1	2,094.3	0.9	6.30	1	1	1
04/10/2020 01:00	1.3	12.1	2,087.2	0.9	6.30	1	1	1
04/10/2020 02:00	1.3	12.1	2,085.2	0.9	6.30	1	1	1
04/10/2020 03:00	1.3	12.1	2,081.4	0.9	6.20	1	1	1
04/10/2020 04:00	1.3	12.3	2,048.3	0.9	6.10	1	1	1
04/10/2020 05:00	1.0	12.5	2,018.6	0.7	6.10	1	1	1
04/10/2020 06:00	1.3	12.2	2,082.2	0.9	6.20	1	1	1
04/10/2020 07:00	0.9	13.6	1,667.8	0.7	5.00	1	1	1
04/10/2020 08:00	0.8	13.9	1,529.5	0.7	3.10	1	1	0
04/10/2020 09:00	0.9	13.9	1,655.0	0.8	5.00	1	1	0
04/10/2020 10:00	0.9	13.9	1,630.1	0.8	4.90	1	1	0
04/10/2020 11:00	0.9	13.9	1,526.5	0.8	4.60	1	1	0
04/10/2020 12:00	1.0	13.9	1,642.9	0.8	4.90	1	1	0
04/10/2020 13:00	0.9	14.0	1,539.6	0.8	4.60	1	1	0
04/10/2020 14:00	1.0	13.9	1,573.9	0.8	4.70	1	1	0
04/10/2020 15:00	1.0	13.9	1,622.9	0.8	4.90	1	1	0
04/10/2020 16:00	1.0	13.9	1,630.9	0.8	4.90	1	1	0
04/10/2020 17:00	0.8	13.9	1,447.3	0.7	2.90	1	1	1
04/10/2020 18:00	1.3	12.3	1,986.9	0.9	6.00	1	1	1
04/10/2020 19:00	1.3	11.9	2,060.9	0.9	6.20	1	1	1
04/10/2020 20:00	1.3	12.1	2,045.1	0.9	6.10	1	1	1
04/10/2020 21:00	1.3	12.2	2,040.0	0.9	6.10	1	1	1
04/10/2020 22:00	1.3	12.2	2,039.1	0.9	6.10	1	1	1
04/10/2020 23:00	1.2	12.9	1,883.2	0.9	5.60	1	1	1
Average/Sum#:	1.1	13.0	1,834.1	0.8	129.10 #	24 #	24 #	15 #
Minimum:	0.8	11.9	1,447.3	0.7	2.90	1	1	0
Maximum:	1.3	14.0	2,094.3	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/11/2020 00:00	0.8	13.9	1,584.9	0.7	3.20	1	1	0
04/11/2020 01:00	0.9	13.9	1,643.0	0.8	4.90	1	1	0
04/11/2020 02:00	0.9	13.9	1,641.3	0.8	4.90	1	1	0
04/11/2020 03:00	0.9	13.9	1,634.0	0.8	4.90	1	1	0
04/11/2020 04:00	0.9	13.9	1,628.1	0.8	4.90	1	1	0
04/11/2020 05:00	0.9	13.8	1,633.7	0.7	4.90	1	1	0
04/11/2020 06:00	0.9	13.9	1,567.3	0.8	4.70	1	1	0
04/11/2020 07:00	0.9	13.9	1,642.3	0.8	4.90	1	1	0
04/11/2020 08:00	0.9	13.9	1,635.2	0.8	4.90	1	1	0
04/11/2020 09:00	0.9	13.9	1,634.1	0.8	4.90	1	1	0
04/11/2020 10:00	0.9	13.9	1,640.5	0.8	4.90	1	1	0
04/11/2020 11:00	1.0	13.9	1,645.8	0.8	4.90	1	1	0
04/11/2020 12:00	0.9	13.9	1,539.9	0.8	4.60	1	1	0
04/11/2020 13:00	1.0	13.9	1,628.2	0.8	4.90	1	1	0
04/11/2020 14:00	1.1	13.9	1,638.6	0.9	4.90	1	1	0
04/11/2020 15:00	1.2	13.9	1,640.2	1.0	6.60	1	1	0
04/11/2020 16:00	1.2	13.9	1,659.9	1.0	6.60	1	1	0
04/11/2020 17:00	1.2	13.9	1,646.2	1.0	6.60	1	1	0
04/11/2020 18:00	1.1	13.9	1,548.4	0.9	4.60	1	1	1
04/11/2020 19:00	2.2	12.4	1,979.1	1.5	11.90	1	1	1
04/11/2020 20:00	2.5	12.2	2,022.1	1.7	12.10	1	1	1
04/11/2020 21:00	2.5	12.2	2,056.4	1.7	12.30	1	1	1
04/11/2020 22:00	2.4	12.4	2,016.1	1.7	12.10	1	1	1
04/11/2020 23:00	2.3	12.6	1,940.1	1.6	11.60	1	1	1
Average/Sum#:	1.3	13.6	1,701.9	1.0	155.70 #	24 #	24 #	6 #
Minimum:	0.8	12.2	1,539.9	0.7	3.20	1	1	0
Maximum:	2.5	13.9	2,056.4	1.7	12.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/12/2020 00:00	1.0	13.9	1,627.1	0.8	4.90	1	1	0
04/12/2020 01:00	0.9	13.9	1,644.8	0.8	4.90	1	1	0
04/12/2020 02:00	0.9	13.9	1,641.5	0.8	4.90	1	1	0
04/12/2020 03:00	0.9	13.9	1,568.2	0.8	4.70	1	1	0
04/12/2020 04:00	0.9	13.9	1,634.6	0.8	4.90	1	1	0
04/12/2020 05:00	1.0	13.9	1,648.5	0.8	4.90	1	1	0
04/12/2020 06:00	0.9	13.9	1,599.3	0.8	4.80	1	1	0
04/12/2020 07:00	0.9	13.9	1,659.2	0.8	5.00	1	1	0
04/12/2020 08:00	1.0	13.9	1,661.1	0.8	5.00	1	1	0
04/12/2020 09:00	1.0	13.9	1,638.0	0.8	4.90	1	1	0
04/12/2020 10:00	0.9	13.9	1,617.9	0.8	4.90	1	1	0
04/12/2020 11:00	0.9	14.0	1,567.2	0.8	4.70	1	1	0
04/12/2020 12:00	1.0	14.0	1,636.4	0.9	4.90	1	1	0
04/12/2020 13:00	1.0	14.0	1,639.3	0.9	4.90	1	1	0
04/12/2020 14:00	1.0	14.0	1,649.6	0.9	4.90	1	1	0
04/12/2020 15:00	1.0	14.0	1,629.1	0.9	4.90	1	1	0
04/12/2020 16:00	1.0	14.0	1,645.0	0.9	4.90	1	1	0
04/12/2020 17:00	0.8	14.0	1,532.8	0.7	4.60	1	1	0
04/12/2020 18:00	0.7	14.0	1,583.5	0.6	3.20	1	1	0
04/12/2020 19:00	0.8	14.0	1,597.9	0.7	4.80	1	1	0
04/12/2020 20:00	0.8	14.0	1,604.1	0.7	4.80	1	1	0
04/12/2020 21:00	0.8	13.9	1,595.6	0.7	3.20	1	1	0
04/12/2020 22:00	0.8	13.9	1,592.6	0.7	3.20	1	1	0
04/12/2020 23:00	1.1	13.4	1,790.6	0.9	5.40	1	1	1
Average/Sum#:	0.9	13.9	1,625.2	0.8	112.20 #	24 #	24 #	1 #
Minimum:	0.7	13.4	1,532.8	0.6	3.20	1	1	0
Maximum:	1.1	14.0	1,790.6	0.9	5.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/13/2020 00:00	1.3	12.4	2,011.4	0.9	6.00	1	1	1
04/13/2020 01:00	0.8	13.9	1,650.0	0.7	3.30	1	1	0
04/13/2020 02:00	0.9	13.9	1,653.9	0.8	5.00	1	1	0
04/13/2020 03:00	0.9	13.9	1,631.6	0.8	4.90	1	1	0
04/13/2020 04:00	0.9	13.9	1,601.3	0.8	4.80	1	1	0
04/13/2020 05:00	0.9	13.8	1,634.6	0.7	4.90	1	1	0
04/13/2020 06:00	0.9	13.9	1,639.5	0.8	4.90	1	1	0
04/13/2020 07:00	0.9	14.0	1,622.6	0.8	4.90	1	1	0
04/13/2020 08:00	0.9	14.0	1,635.7	0.8	4.90	1	1	0
04/13/2020 09:00	0.9	14.0	1,663.9	0.8	5.00	1	1	0
04/13/2020 10:00	0.9	14.0	1,663.1	0.8	5.00	1	1	0
04/13/2020 11:00	1.0	14.0	1,667.0	0.9	5.00	1	1	0
04/13/2020 12:00	1.0	14.0	1,647.8	0.9	4.90	1	1	0
04/13/2020 13:00	0.9	14.0	1,579.5	0.8	4.70	1	1	0
04/13/2020 14:00	1.0	14.0	1,643.9	0.9	4.90	1	1	0
04/13/2020 15:00	1.1	14.0	1,661.4	0.9	5.00	1	1	0
04/13/2020 16:00	1.0	14.0	1,629.6	0.9	4.90	1	1	0
04/13/2020 17:00	0.9	14.0	1,500.3	0.8	4.50	1	1	1
04/13/2020 18:00	1.2	12.8	1,935.5	0.9	5.80	1	1	1
04/13/2020 19:00	1.3	12.3	2,026.8	0.9	6.10	1	1	1
04/13/2020 20:00	1.3	12.4	2,022.3	0.9	6.10	1	1	1
04/13/2020 21:00	1.3	12.4	2,023.9	0.9	6.10	1	1	1
04/13/2020 22:00	1.2	12.5	2,009.0	0.8	6.00	1	1	1
04/13/2020 23:00	1.2	12.9	1,895.9	0.9	5.70	1	1	1
Average/Sum#:	1.0	13.5	1,735.4	0.8	123.30 #	24 #	24 #	8 #
Minimum:	0.8	12.3	1,500.3	0.7	3.30	1	1	0
Maximum:	1.3	14.0	2,026.8	0.9	6.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/14/2020 00:00	0.9	14.0	1,689.3	0.8	5.10	1	1	0
04/14/2020 01:00	0.7	14.0	1,496.1	0.6	3.00	1	1	0
04/14/2020 02:00	0.8	14.0	1,599.0	0.7	4.80	1	1	0
04/14/2020 03:00	0.8	14.0	1,506.9	0.7	4.50	1	1	0
04/14/2020 04:00	0.8	14.0	1,601.0	0.7	4.80	1	1	0
04/14/2020 05:00	0.8	13.9	1,558.2	0.7	3.10	1	1	0
04/14/2020 06:00	0.8	13.9	1,639.9	0.7	3.30	1	1	0
04/14/2020 07:00	0.8	14.0	1,559.9	0.7	4.70	1	1	0
04/14/2020 08:00	0.8	14.0	1,612.2	0.7	4.80	1	1	0
04/14/2020 09:00	0.9	14.0	1,637.9	0.8	4.90	1	1	0
04/14/2020 10:00	1.0	14.0	1,651.3	0.9	5.00	1	1	0
04/14/2020 11:00	1.0	14.0	1,644.3	0.9	4.90	1	1	0
04/14/2020 12:00	0.8	14.0	1,534.6	0.7	4.60	1	1	0
04/14/2020 13:00	1.0	14.0	1,655.9	0.9	5.00	1	1	0
04/14/2020 14:00	1.0	14.0	1,637.7	0.9	4.90	1	1	0
04/14/2020 15:00	0.9	14.0	1,626.5	0.8	4.90	1	1	0
04/14/2020 16:00	0.9	14.0	1,559.5	0.8	4.70	1	1	0
04/14/2020 17:00	0.9	13.9	1,503.1	0.8	4.50	1	1	1
04/14/2020 18:00	1.3	12.6	1,943.4	0.9	5.80	1	1	1
04/14/2020 19:00	1.3	12.2	2,012.7	0.9	6.00	1	1	1
04/14/2020 20:00	1.3	12.3	2,000.5	0.9	6.00	1	1	1
04/14/2020 21:00	1.3	12.5	1,969.2	0.9	5.90	1	1	1
04/14/2020 22:00	1.3	12.4	1,998.8	0.9	6.00	1	1	1
04/14/2020 23:00	1.3	12.5	2,007.7	0.9	6.00	1	1	1
Average/Sum#:	1.0	13.6	1,693.6	0.8	117.20 #	24 #	24 #	7 #
Minimum:	0.7	12.2	1,496.1	0.6	3.00	1	1	0
Maximum:	1.3	14.0	2,012.7	0.9	6.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/15/2020 00:00	1.2	13.0	1,892.1	0.9	5.70	1	1	1
04/15/2020 01:00	0.8	13.9	1,566.3	0.7	3.10	1	1	0
04/15/2020 02:00	0.9	13.9	1,636.5	0.8	4.90	1	1	0
04/15/2020 03:00	0.8	13.9	1,552.3	0.7	3.10	1	1	0
04/15/2020 04:00	0.8	13.9	1,537.9	0.7	3.10	1	1	0
04/15/2020 05:00	0.9	13.9	1,646.0	0.8	4.90	1	1	0
04/15/2020 06:00	0.9	13.9	1,644.6	0.8	4.90	1	1	0
04/15/2020 07:00	0.9	13.9	1,621.2	0.8	4.90	1	1	0
04/15/2020 08:00	0.9	13.9	1,655.3	0.8	5.00	1	1	0
04/15/2020 09:00	0.9	13.9	1,656.0	0.8	5.00	1	1	0
04/15/2020 10:00	1.0	14.0	1,661.3	0.9	5.00	1	1	0
04/15/2020 11:00	1.1	14.0	1,661.1	0.9	5.00	1	1	0
04/15/2020 12:00	1.1	14.0	1,645.0	0.9	4.90	1	1	0
04/15/2020 13:00	1.0	13.9	1,660.1	0.8	5.00	1	1	0
04/15/2020 14:00	1.0	13.9	1,637.4	0.8	4.90	1	1	0
04/15/2020 15:00	1.0	13.9	1,600.1	0.8	4.80	1	1	0
04/15/2020 16:00	1.1	13.9	1,606.8	0.9	4.80	1	1	0
04/15/2020 17:00	0.8	13.9	1,492.8	0.7	3.00	1	1	1
04/15/2020 18:00	1.3	12.4	1,956.6	0.9	5.90	1	1	1
04/15/2020 19:00	1.3	11.9	2,061.2	0.9	6.20	1	1	1
04/15/2020 20:00	1.4	11.8	2,075.5	0.9	6.20	1	1	1
04/15/2020 21:00	1.3	12.2	2,024.5	0.9	6.10	1	1	1
04/15/2020 22:00	1.2	12.9	1,897.4	0.9	5.70	1	1	1
04/15/2020 23:00	1.2	12.9	1,870.2	0.9	5.60	1	1	1
Average/Sum#:	1.0	13.5	1,719.1	0.8	117.70 #	24 #	24 #	8 #
Minimum:	0.8	11.8	1,492.8	0.7	3.00	1	1	0
Maximum:	1.4	14.0	2,075.5	0.9	6.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/16/2020 00:00	0.8	13.9	1,478.8	0.7	3.00	1	1	0
04/16/2020 01:00	0.9	13.9	1,470.8	0.8	4.40	1	1	0
04/16/2020 02:00	0.9	13.9	1,499.0	0.8	4.50	1	1	0
04/16/2020 03:00	0.9	13.9	1,467.0	0.8	4.40	1	1	0
04/16/2020 04:00	0.9	13.9	1,551.1	0.8	4.70	1	1	0
04/16/2020 05:00	1.0	13.9	1,637.5	0.8	4.90	1	1	0
04/16/2020 06:00	0.9	13.9	1,518.9	0.8	4.60	1	1	0
04/16/2020 07:00	0.9	13.9	1,621.3	0.8	4.90	1	1	0
04/16/2020 08:00	0.9	14.0	1,653.8	0.8	5.00	1	1	0
04/16/2020 09:00	0.9	14.0	1,639.8	0.8	4.90	1	1	0
04/16/2020 10:00	1.0	14.0	1,656.3	0.9	5.00	1	1	0
04/16/2020 11:00	1.0	14.0	1,631.4	0.9	4.90	1	1	0
04/16/2020 12:00	1.1	13.9	1,659.0	0.9	5.00	1	1	0
04/16/2020 13:00	1.0	13.9	1,648.5	0.8	4.90	1	1	0
04/16/2020 14:00	0.9	13.9	1,564.2	0.8	4.70	1	1	0
04/16/2020 15:00	1.0	13.9	1,608.8	0.8	4.80	1	1	0
04/16/2020 16:00	0.9	14.0	1,601.6	0.8	4.80	1	1	0
04/16/2020 17:00	0.8	14.0	1,525.6	0.7	4.60	1	1	1
04/16/2020 18:00	1.3	12.5	1,937.8	0.9	5.80	1	1	1
04/16/2020 19:00	1.3	12.0	2,054.5	0.9	6.20	1	1	1
04/16/2020 20:00	1.3	11.8	2,089.2	0.8	6.30	1	1	1
04/16/2020 21:00	1.3	12.0	2,056.5	0.9	6.20	1	1	1
04/16/2020 22:00	1.2	12.6	1,927.3	0.9	5.80	1	1	1
04/16/2020 23:00	1.2	12.9	1,870.5	0.9	5.60	1	1	1
Average/Sum#:	1.0	13.5	1,682.1	0.8	119.90 #	24 #	24 #	7 #
Minimum:	0.8	11.8	1,467.0	0.7	3.00	1	1	0
Maximum:	1.3	14.0	2,089.2	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/17/2020 00:00	0.7	13.9	1,423.2	0.6	2.80	1	1	0
04/17/2020 01:00	0.7	13.9	1,326.3	0.6	2.70	1	1	0
04/17/2020 02:00	0.7	13.9	1,310.7	0.6	2.60	1	1	0
04/17/2020 03:00	0.7	13.9	1,308.7	0.6	2.60	1	1	0
04/17/2020 04:00	0.7	13.9	1,286.9	0.6	2.60	1	1	0
04/17/2020 05:00	0.9	13.9	1,635.4	0.8	4.90	1	1	0
04/17/2020 06:00	0.9	13.9	1,602.5	0.8	4.80	1	1	0
04/17/2020 07:00	0.9	13.9	1,578.8	0.8	4.70	1	1	0
04/17/2020 08:00	0.9	13.9	1,645.2	0.8	4.90	1	1	0
04/17/2020 09:00	0.9	14.0	1,622.4	0.8	4.90	1	1	0
04/17/2020 10:00	0.9	14.0	1,531.5	0.8	4.60	1	1	0
04/17/2020 11:00	1.0	14.0	1,612.5	0.9	4.80	1	1	0
04/17/2020 12:00	0.8	14.0	1,434.2	0.7	4.30	1	1	0
04/17/2020 13:00	1.0	14.0	1,582.8	0.9	4.70	1	1	0
04/17/2020 14:00	1.0	13.9	1,642.7	0.8	4.90	1	1	0
04/17/2020 15:00	1.0	13.9	1,652.6	0.8	5.00	1	1	0
04/17/2020 16:00	1.0	13.9	1,621.5	0.8	4.90	1	1	0
04/17/2020 17:00	0.9	13.9	1,500.6	0.8	4.50	1	1	1
04/17/2020 18:00	1.3	12.5	1,962.0	0.9	5.90	1	1	1
04/17/2020 19:00	1.3	12.2	2,020.3	0.9	6.10	1	1	1
04/17/2020 20:00	1.3	12.3	2,016.3	0.9	6.00	1	1	1
04/17/2020 21:00	1.3	12.3	2,015.0	0.9	6.00	1	1	1
04/17/2020 22:00	1.3	12.3	2,037.6	0.9	6.10	1	1	1
04/17/2020 23:00	2.5	14.1	1,222.9	2.2	4.70	1	0	1
Average/Sum#:	1.0	13.6	1,608.0	0.8	110.00 #	24 #	23 #	7 #
Minimum:	0.7	12.2	1,222.9	0.6	2.60	1	0	0
Maximum:	2.5	14.1	2,037.6	2.2	6.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/18/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/19/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/20/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/20/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/20/2020 02:00	32.4	17.4	490.9	54.6	93.77	1	0	0
04/20/2020 03:00	14.9	14.8	1,025.2	14.4	54.30	1	0	0
04/20/2020 04:00	0.9	13.9	1,635.4	0.8	4.90	1	1	0
04/20/2020 05:00	0.9	13.9	1,646.9	0.8	4.90	1	1	0
04/20/2020 06:00	0.9	13.9	1,636.2	0.8	4.90	1	1	0
04/20/2020 07:00	0.9	13.9	1,648.4	0.8	4.90	1	1	0
04/20/2020 08:00	0.9	13.9	1,607.8	0.8	4.80	1	1	0
04/20/2020 09:00	0.9	13.9	1,559.2	0.8	4.70	1	1	0
04/20/2020 10:00	0.9	13.9	1,550.8	0.8	4.70	1	1	0
04/20/2020 11:00	1.0	13.9	1,651.3	0.8	5.00	1	1	0
04/20/2020 12:00	0.9	13.9	1,638.7	0.8	4.90	1	1	0
04/20/2020 13:00	0.9	13.9	1,646.3	0.8	4.90	1	1	0
04/20/2020 14:00	0.8	13.9	1,491.4	0.7	3.00	1	1	0
04/20/2020 15:00	0.9	13.9	1,623.6	0.8	4.90	1	1	0
04/20/2020 16:00	0.8	13.9	1,589.6	0.7	3.20	1	1	0
04/20/2020 17:00	0.8	13.9	1,508.9	0.7	3.00	1	1	1
04/20/2020 18:00	1.3	12.6	1,957.3	0.9	5.90	1	1	1
04/20/2020 19:00	1.3	12.4	2,009.0	0.9	6.00	1	1	1
04/20/2020 20:00	1.3	12.4	2,012.1	0.9	6.00	1	1	1
04/20/2020 21:00	1.3	12.4	2,018.1	0.9	6.10	1	1	1
04/20/2020 22:00	1.2	12.8	1,914.2	0.9	5.70	1	1	1
04/20/2020 23:00	4.3	15.8	552.1	5.0	2.28	1	0	0
Average/Sum#:	3.2	13.9	1,564.2	4.1	242.75 #	22 #	19 #	6 #
Minimum:	0.8	12.4	490.9	0.7	2.28	0	0	0
Maximum:	32.4	17.4	2,018.1	54.6	93.77	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/21/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/22/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 07:00	24.1	18.0	399.8	49.0	27.51	1	0	0
04/22/2020 08:00	23.6	16.5	598.5	31.6	70.00	1	0	0
04/22/2020 09:00	5.6	14.2	1,202.4	4.9	21.60	1	0	0
04/22/2020 10:00	0.7	14.0	1,251.5	0.6	2.50	1	1	0
04/22/2020 11:00	5.3	17.0	225.3	8.0	0.88	1	0	0
04/22/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	11.9	15.9	735.5	18.8	122.49 #	5 #	1 #	0 #
Minimum:	0.7	14.0	225.3	0.6	0.88	0	0	0
Maximum:	24.1	18.0	1,251.5	49.0	70.00	1	1	0
%SI	79.17	79.17	79.17	79.17	79.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/23/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/24/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/24/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/24/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/24/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/24/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/24/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/24/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/24/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/24/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/24/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/24/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/24/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/24/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/24/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/24/2020 14:00	0.0	0.0	454.0	0.0	0.00	1	0	0
04/24/2020 15:00	0.0	0.0	717.7	0.0	0.00	1	0	0
04/24/2020 16:00	0.0	0.0	1,511.5	0.0	0.00	1	0	0
04/24/2020 17:00	0.0	0.0	1,529.9	0.0	0.00	1	1	0
04/24/2020 18:00	0.0	0.0	1,772.4	0.0	0.00	1	1	1
04/24/2020 19:00	1.3	11.8	2,051.6	0.8	6.20	1	1	1
04/24/2020 20:00	1.3	11.9	2,039.4	0.9	6.10	1	1	1
04/24/2020 21:00	1.2	12.7	1,865.3	0.9	5.60	1	1	1
04/24/2020 22:00	4.4	15.9	533.0	5.2	2.32	1	0	0
04/24/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.1	13.1	1,386.1	2.0	20.22 #	9 #	5 #	4 #
Minimum:	1.2	11.8	454.0	0.8	2.32	0	0	0
Maximum:	4.4	15.9	2,051.6	5.2	6.20	1	1	1
%SI	83.33	83.33	62.50	83.33	83.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/25/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/26/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/27/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/28/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/28/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/28/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/28/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/28/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/28/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/28/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/28/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/28/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/28/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/28/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/28/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/28/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/28/2020 13:00	34.0	17.6	438.5	60.8	65.79	1	0	0
04/28/2020 14:00	26.5	15.7	737.6	30.1	81.90	1	0	0
04/28/2020 15:00	0.5	14.0	1,508.3	0.4	3.00	1	0	0
04/28/2020 16:00	0.8	13.9	1,462.7	0.7	2.90	1	1	1
04/28/2020 17:00	1.4	12.0	2,000.9	0.9	6.00	1	1	1
04/28/2020 18:00	1.4	11.5	2,079.8	0.9	6.20	1	1	1
04/28/2020 19:00	1.4	11.5	2,088.2	0.9	6.30	1	1	1
04/28/2020 20:00	1.4	11.5	2,091.3	0.9	6.30	1	1	1
04/28/2020 21:00	1.8	12.8	1,584.4	1.3	7.90	1	0	1
04/28/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/28/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	7.7	13.4	1,554.6	10.8	186.29 #	9 #	5 #	6 #
Minimum:	0.5	11.5	438.5	0.4	2.90	0	0	0
Maximum:	34.0	17.6	2,091.3	60.8	81.90	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/29/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/30/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/01/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/02/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/03/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/04/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/05/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/06/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/07/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/08/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/09/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/10/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/11/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/12/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/13/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/14/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/15/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/16/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/17/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/18/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/19/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/20/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/21/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/22/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/23/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/24/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/25/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/26/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 10:00	22.4	18.3	2,022.9	50.8	177.80	1	0	0
05/26/2020 11:00	4.1	20.0	2,014.1	26.9	11.36	1	0	0
05/26/2020 12:00	26.2	17.3	2,025.6	42.9	320.00	1	0	0
05/26/2020 13:00	7.4	17.2	2,025.8	11.8	87.10	1	0	0
05/26/2020 14:00	9.8	15.9	2,088.3	11.6	89.80	1	0	0
05/26/2020 15:00	7.8	16.4	2,086.1	10.2	26.17	1	0	0
05/26/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	13.0	17.5	2,043.8	25.7	712.23 #	6 #	0 #	0 #
Minimum:	4.1	15.9	2,014.1	10.2	11.36	0	0	0
Maximum:	26.2	20.0	2,088.3	50.8	320.00	1	0	0
%SI	75.00	75.00	75.00	75.00	75.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/27/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/28/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 12:00	0.0	0.0	2,033.2	0.0	0.00	1	0	0
05/28/2020 13:00	0.0	0.0	2,037.2	0.0	0.00	1	0	0
05/28/2020 14:00	0.0	0.0	2,093.7	0.0	0.00	1	0	0
05/28/2020 15:00	0.0	0.0	2,081.8	0.0	0.00	1	0	0
05/28/2020 16:00	0.0	0.0	2,094.2	0.0	0.00	1	1	0
05/28/2020 17:00	1.1	14.0	2,024.2	0.9	6.10	1	1	0
05/28/2020 18:00	1.1	13.9	2,047.5	0.9	6.10	1	1	0
05/28/2020 19:00	1.0	14.1	2,052.1	0.9	6.20	1	1	0
05/28/2020 20:00	0.9	14.1	2,056.2	0.8	6.20	1	1	0
05/28/2020 21:00	1.1	14.1	2,060.5	1.0	8.20	1	1	0
05/28/2020 22:00	1.1	14.1	2,058.2	1.0	8.20	1	1	0
05/28/2020 23:00	1.0	14.0	2,056.5	0.9	6.20	1	1	0
Average/Sum#:	1.0	14.0	2,057.9	0.9	47.20 #	12 #	8 #	0 #
Minimum:	0.9	13.9	2,024.2	0.8	6.10	0	0	0
Maximum:	1.1	14.1	2,094.2	1.0	8.20	1	1	0
%SI	70.83	70.83	50.00	70.83	70.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/29/2020 00:00	1.0	13.9	2,057.9	0.8	6.20	1	1	0
05/29/2020 01:00	1.4	14.6	2,063.9	1.3	7.52	1	0	0
05/29/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.2	14.3	2,060.9	1.1	13.72 #	2 #	1 #	0 #
Minimum:	1.0	13.9	2,057.9	0.8	6.20	0	0	0
Maximum:	1.4	14.6	2,063.9	1.3	7.52	1	1	0
%SI	91.67	91.67	91.67	91.67	91.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/30/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/31/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/01/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/01/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/01/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/01/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/01/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/01/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/01/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/01/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/01/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/01/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/01/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/01/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/01/2020 12:00	12.5	19.0	2,017.0	38.8	57.68	1	0	0
06/01/2020 13:00	36.0	17.3	2,026.3	59.0	320.98	1	0	0
06/01/2020 14:00	6.2	16.3	2,052.5	8.0	37.49	1	0	0
06/01/2020 15:00	0.7	14.0	2,047.6	0.6	4.10	1	1	1
06/01/2020 16:00	0.9	14.2	2,069.4	0.8	6.20	1	1	0
06/01/2020 17:00	0.9	14.1	2,087.4	0.8	6.30	1	1	0
06/01/2020 18:00	0.8	14.1	2,091.8	0.7	6.30	1	1	0
06/01/2020 19:00	0.9	14.1	2,067.0	0.8	6.20	1	1	0
06/01/2020 20:00	0.9	14.1	2,071.7	0.8	6.20	1	1	0
06/01/2020 21:00	0.8	14.1	2,073.3	0.7	6.20	1	1	0
06/01/2020 22:00	0.7	14.2	2,086.3	0.6	4.20	1	1	0
06/01/2020 23:00	1.0	14.1	2,068.4	0.9	6.20	1	1	0
Average/Sum#:	5.2	15.0	2,063.2	9.4	468.05 #	12 #	9 #	1 #
Minimum:	0.7	14.0	2,017.0	0.6	4.10	0	0	0
Maximum:	36.0	19.0	2,091.8	59.0	320.98	1	1	1
%SI	50.00	50.00	50.00	50.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/02/2020 00:00	0.8	14.1	2,087.7	0.7	6.30	1	1	0
06/02/2020 01:00	0.9	14.1	2,080.2	0.8	6.20	1	1	0
06/02/2020 02:00	0.9	14.1	2,070.6	0.8	6.20	1	1	0
06/02/2020 03:00	0.9	14.1	2,061.3	0.8	6.20	1	1	0
06/02/2020 04:00	0.9	14.1	2,065.5	0.8	6.20	1	1	0
06/02/2020 05:00	0.9	14.1	2,053.2	0.8	6.20	1	1	0
06/02/2020 06:00	0.8	14.1	2,060.3	0.7	6.20	1	1	0
06/02/2020 07:00	0.8	14.1	2,070.5	0.7	6.20	1	1	0
06/02/2020 08:00	0.7	14.1	2,061.8	0.6	4.10	1	1	0
06/02/2020 09:00	0.9	14.1	2,083.5	0.8	6.30	1	1	0
06/02/2020 10:00	1.0	14.1	2,060.0	0.9	6.20	1	1	0
06/02/2020 11:00	0.7	14.2	2,035.2	0.6	4.10	1	1	0
06/02/2020 12:00	1.0	14.0	2,067.7	0.9	6.20	1	1	1
06/02/2020 13:00	1.3	12.1	2,426.9	0.9	7.30	1	1	1
06/02/2020 14:00	1.3	11.7	2,488.6	0.8	7.50	1	1	1
06/02/2020 15:00	1.4	11.7	2,504.8	0.9	7.50	1	1	1
06/02/2020 16:00	1.3	11.8	2,500.3	0.8	7.50	1	1	1
06/02/2020 17:00	1.3	12.1	2,418.5	0.9	7.30	1	1	1
06/02/2020 18:00	1.2	12.1	2,455.8	0.8	7.40	1	1	1
06/02/2020 19:00	1.3	12.1	2,434.3	0.9	7.30	1	1	1
06/02/2020 20:00	1.3	12.1	2,435.2	0.9	7.30	1	1	1
06/02/2020 21:00	1.3	12.2	2,419.4	0.9	7.30	1	1	1
06/02/2020 22:00	1.3	12.2	2,404.9	0.9	7.20	1	1	1
06/02/2020 23:00	1.2	12.2	2,401.3	0.8	7.20	1	1	1
Average/Sum#:	1.1	13.2	2,239.5	0.8	157.40 #	24 #	24 #	12 #
Minimum:	0.7	11.7	2,035.2	0.6	4.10	1	1	0
Maximum:	1.4	14.2	2,504.8	0.9	7.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/03/2020 00:00	1.3	12.3	2,377.1	0.9	7.10	1	1	1
06/03/2020 01:00	0.7	14.1	2,057.7	0.6	4.10	1	1	0
06/03/2020 02:00	0.8	14.1	2,052.1	0.7	6.20	1	1	0
06/03/2020 03:00	0.6	14.1	2,042.6	0.5	4.10	1	1	0
06/03/2020 04:00	0.9	14.1	2,059.3	0.8	6.20	1	1	0
06/03/2020 05:00	0.6	14.1	2,064.3	0.5	4.10	1	1	0
06/03/2020 06:00	0.6	14.1	2,036.7	0.5	4.10	1	1	0
06/03/2020 07:00	0.8	14.1	2,047.9	0.7	6.10	1	1	0
06/03/2020 08:00	0.9	14.1	2,101.9	0.8	6.30	1	1	0
06/03/2020 09:00	0.9	14.1	2,056.4	0.8	6.20	1	1	0
06/03/2020 10:00	0.9	14.0	2,052.4	0.8	6.20	1	1	1
06/03/2020 11:00	1.3	12.2	2,392.3	0.9	7.20	1	1	1
06/03/2020 12:00	1.4	11.6	2,486.0	0.9	7.50	1	1	1
06/03/2020 13:00	1.3	11.6	2,501.5	0.8	7.50	1	1	1
06/03/2020 14:00	1.3	11.6	2,489.1	0.8	7.50	1	1	1
06/03/2020 15:00	1.4	11.6	2,453.6	0.9	7.40	1	1	1
06/03/2020 16:00	1.4	11.6	2,481.4	0.9	7.40	1	1	1
06/03/2020 17:00	1.4	11.6	2,482.6	0.9	7.40	1	1	1
06/03/2020 18:00	1.4	11.8	2,462.2	0.9	7.40	1	1	1
06/03/2020 19:00	1.4	11.7	2,456.2	0.9	7.40	1	1	1
06/03/2020 20:00	1.3	12.0	2,415.4	0.9	7.20	1	1	1
06/03/2020 21:00	1.3	12.2	2,399.2	0.9	7.20	1	1	1
06/03/2020 22:00	1.3	12.3	2,373.6	0.9	7.10	1	1	1
06/03/2020 23:00	1.4	11.9	2,428.4	0.9	7.30	1	1	1
Average/Sum#:	1.1	12.8	2,282.1	0.8	156.20 #	24 #	24 #	15 #
Minimum:	0.6	11.6	2,036.7	0.5	4.10	1	1	0
Maximum:	1.4	14.1	2,501.5	0.9	7.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/04/2020 00:00	3.1	14.0	2,118.3	2.7	10.18	1	0	1
06/04/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/04/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/04/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/04/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/04/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/04/2020 06:00	2.1	18.4	2,034.1	5.0	11.71	1	0	0
06/04/2020 07:00	10.3	15.8	2,079.3	11.9	91.50	1	0	0
06/04/2020 08:00	0.3	14.2	2,057.8	0.3	2.10	1	1	0
06/04/2020 09:00	0.5	14.2	2,053.6	0.4	4.10	1	1	0
06/04/2020 10:00	0.8	14.1	2,051.4	0.7	6.20	1	1	0
06/04/2020 11:00	0.6	14.2	2,044.8	0.5	4.10	1	1	0
06/04/2020 12:00	0.7	14.2	2,041.2	0.6	4.10	1	1	0
06/04/2020 13:00	0.7	14.1	2,064.5	0.6	4.10	1	1	1
06/04/2020 14:00	1.3	12.2	2,395.8	0.9	7.20	1	1	1
06/04/2020 15:00	1.4	11.8	2,469.1	0.9	7.40	1	1	1
06/04/2020 16:00	1.4	11.7	2,467.6	0.9	7.40	1	1	1
06/04/2020 17:00	1.4	11.7	2,470.8	0.9	7.40	1	1	1
06/04/2020 18:00	1.4	11.7	2,445.7	0.9	7.30	1	1	1
06/04/2020 19:00	1.4	11.9	2,418.1	0.9	7.30	1	1	1
06/04/2020 20:00	1.4	11.8	2,498.2	0.9	7.50	1	1	1
06/04/2020 21:00	1.4	11.7	2,468.9	0.9	7.40	1	1	1
06/04/2020 22:00	1.4	12.0	2,421.8	0.9	7.30	1	1	1
06/04/2020 23:00	1.3	12.2	2,382.8	0.9	7.10	1	1	1
Average/Sum#:	1.7	13.3	2,262.3	1.7	211.39 #	19 #	16 #	12 #
Minimum:	0.3	11.7	2,034.1	0.3	2.10	0	0	0
Maximum:	10.3	18.4	2,498.2	11.9	91.50	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/05/2020 00:00	1.8	14.2	2,086.7	1.6	6.63	1	0	1
06/05/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.8	14.2	2,086.7	1.6	6.63 #	1 #	0 #	1 #
Minimum:	1.8	14.2	2,086.7	1.6	6.63	0	0	0
Maximum:	1.8	14.2	2,086.7	1.6	6.63	1	0	1
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/06/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/07/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/08/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/08/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/08/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/08/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/08/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/08/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/08/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/08/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/08/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/08/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/08/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/08/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/08/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/08/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/08/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/08/2020 15:00	32.5	17.9	2,123.3	63.9	259.48	1	0	0
06/08/2020 16:00	31.9	16.3	2,024.2	40.9	305.70	1	0	0
06/08/2020 17:00	3.9	18.1	2,093.2	8.2	23.86	1	0	0
06/08/2020 18:00	6.6	14.6	2,349.7	6.2	54.00	1	0	0
06/08/2020 19:00	0.9	14.0	2,097.9	0.8	6.30	1	1	1
06/08/2020 20:00	1.3	12.8	2,264.5	0.9	6.80	1	1	1
06/08/2020 21:00	1.3	12.4	2,333.6	0.9	7.00	1	1	1
06/08/2020 22:00	1.3	12.6	2,318.9	0.9	7.00	1	1	1
06/08/2020 23:00	1.7	13.7	2,124.4	1.4	10.60	1	0	1
Average/Sum#:	9.0	14.7	2,192.2	13.8	680.74 #	9 #	4 #	5 #
Minimum:	0.9	12.4	2,024.2	0.8	6.30	0	0	0
Maximum:	32.5	18.1	2,349.7	63.9	305.70	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/09/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/09/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/09/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/09/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/09/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/09/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/09/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/09/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/09/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/09/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/09/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/09/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/09/2020 12:00	19.6	18.3	2,006.8	44.5	131.64	1	0	0
06/09/2020 13:00	17.4	17.5	1,994.2	30.2	88.56	1	0	0
06/09/2020 14:00	4.1	16.8	2,140.6	5.9	40.04	1	0	0
06/09/2020 15:00	0.5	14.0	2,140.5	0.4	4.30	1	0	0
06/09/2020 16:00	0.7	14.0	2,038.3	0.6	4.10	1	1	1
06/09/2020 17:00	1.3	12.4	2,336.5	0.9	7.00	1	1	1
06/09/2020 18:00	1.4	12.0	2,418.2	0.9	7.30	1	1	1
06/09/2020 19:00	1.4	11.9	2,431.1	0.9	7.30	1	1	1
06/09/2020 20:00	1.3	12.1	2,389.5	0.9	7.20	1	1	1
06/09/2020 21:00	1.3	12.3	2,363.6	0.9	7.10	1	1	1
06/09/2020 22:00	1.3	12.5	2,322.2	0.9	7.00	1	1	1
06/09/2020 23:00	2.2	14.2	2,103.2	1.9	6.91	1	0	1
Average/Sum#:	4.4	14.0	2,223.7	7.4	318.45 #	12 #	7 #	8 #
Minimum:	0.5	11.9	1,994.2	0.4	4.10	0	0	0
Maximum:	19.6	18.3	2,431.1	44.5	131.64	1	1	1
%SI	50.00	50.00	50.00	50.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/10/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/10/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/10/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/10/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/10/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/10/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/10/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/10/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/10/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/10/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/10/2020 10:00	16.2	17.7	2,008.6	29.9	154.63	1	0	0
06/10/2020 11:00	9.9	15.7	2,288.9	11.2	93.80	1	0	0
06/10/2020 12:00	2.0	14.2	2,052.4	1.8	12.30	1	0	0
06/10/2020 13:00	0.8	14.0	2,044.6	0.7	6.10	1	1	0
06/10/2020 14:00	0.8	13.9	2,093.0	0.7	4.20	1	1	1
06/10/2020 15:00	1.1	12.2	2,406.4	0.7	7.20	1	1	1
06/10/2020 16:00	1.2	11.6	2,701.4	0.8	8.10	1	1	1
06/10/2020 17:00	1.1	11.8	2,656.5	0.7	8.00	1	1	1
06/10/2020 18:00	1.1	11.7	2,569.2	0.7	7.70	1	1	1
06/10/2020 19:00	1.1	11.9	2,415.8	0.7	7.20	1	1	1
06/10/2020 20:00	1.1	12.0	2,406.3	0.7	7.20	1	1	1
06/10/2020 21:00	1.1	12.1	2,393.9	0.7	7.20	1	1	1
06/10/2020 22:00	1.0	12.4	2,303.2	0.7	6.90	1	1	1
06/10/2020 23:00	1.1	12.3	2,357.2	0.8	7.10	1	1	1
Average/Sum#:	2.8	13.1	2,335.5	3.6	337.63 #	14 #	11 #	10 #
Minimum:	0.8	11.6	2,008.6	0.7	4.20	0	0	0
Maximum:	16.2	17.7	2,701.4	29.9	154.63	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/11/2020 00:00	1.0	12.7	2,290.6	0.7	6.90	1	1	1
06/11/2020 01:00	1.0	12.6	2,300.1	0.7	6.90	1	1	1
06/11/2020 02:00	1.0	12.8	2,264.9	0.7	6.80	1	1	1
06/11/2020 03:00	1.0	12.6	2,305.9	0.7	6.90	1	1	1
06/11/2020 04:00	1.0	12.9	2,219.8	0.7	6.70	1	1	1
06/11/2020 05:00	0.8	13.8	2,044.7	0.7	4.10	1	1	0
06/11/2020 06:00	0.9	13.9	2,064.7	0.8	6.20	1	1	0
06/11/2020 07:00	0.9	13.8	2,038.9	0.7	6.10	1	1	0
06/11/2020 08:00	0.9	13.8	2,059.4	0.7	6.20	1	1	0
06/11/2020 09:00	0.9	13.8	2,005.3	0.7	6.00	1	1	0
06/11/2020 10:00	0.9	13.7	2,012.8	0.7	6.00	1	1	0
06/11/2020 11:00	0.6	14.0	2,020.5	0.5	4.00	1	1	0
06/11/2020 12:00	0.8	14.0	2,008.2	0.7	6.00	1	1	0
06/11/2020 13:00	0.8	14.1	2,013.0	0.7	6.00	1	1	0
06/11/2020 14:00	0.8	14.0	2,023.1	0.7	6.10	1	1	0
06/11/2020 15:00	0.9	14.0	1,999.1	0.8	6.00	1	1	0
06/11/2020 16:00	0.8	14.0	2,029.7	0.7	6.10	1	1	0
06/11/2020 17:00	0.8	14.0	2,024.1	0.7	6.10	1	1	1
06/11/2020 18:00	1.1	12.3	2,325.7	0.8	7.00	1	1	1
06/11/2020 19:00	1.1	11.6	2,452.8	0.7	7.40	1	1	1
06/11/2020 20:00	1.1	11.9	2,376.0	0.7	7.10	1	1	1
06/11/2020 21:00	1.1	12.2	2,358.4	0.7	7.10	1	1	1
06/11/2020 22:00	1.1	12.4	2,283.7	0.8	6.90	1	1	1
06/11/2020 23:00	1.5	14.4	2,062.6	1.4	4.94	1	0	1
Average/Sum#:	1.0	13.3	2,149.3	0.7	149.54 #	24 #	23 #	12 #
Minimum:	0.6	11.6	1,999.1	0.5	4.00	1	0	0
Maximum:	1.5	14.4	2,452.8	1.4	7.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/12/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/13/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/14/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/15/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/16/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/17/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/17/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/17/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/17/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/17/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/17/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/17/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/17/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/17/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/17/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/17/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/17/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/17/2020 12:00	24.2	18.3	1,972.6	54.9	147.45	1	0	0
06/17/2020 13:00	22.9	17.4	1,978.3	38.6	280.90	1	0	0
06/17/2020 14:00	5.6	17.3	2,152.7	9.2	73.20	1	0	0
06/17/2020 15:00	5.5	15.9	2,192.9	6.5	52.60	1	0	0
06/17/2020 16:00	0.6	14.1	2,315.5	0.5	4.60	1	1	0
06/17/2020 17:00	0.7	13.9	2,356.2	0.6	4.70	1	1	1
06/17/2020 18:00	1.1	12.4	2,642.5	0.8	7.90	1	1	1
06/17/2020 19:00	1.1	11.8	2,801.8	0.7	8.40	1	1	1
06/17/2020 20:00	1.1	11.9	2,575.7	0.7	7.70	1	1	1
06/17/2020 21:00	1.1	12.2	2,434.5	0.7	7.30	1	1	1
06/17/2020 22:00	1.1	12.3	2,382.1	0.8	7.10	1	1	1
06/17/2020 23:00	1.8	14.4	2,091.5	1.6	6.25	1	0	1
Average/Sum#:	5.6	14.3	2,324.7	9.6	608.10 #	12 #	7 #	7 #
Minimum:	0.6	11.8	1,972.6	0.5	4.60	0	0	0
Maximum:	24.2	18.3	2,801.8	54.9	280.90	1	1	1
%SI	50.00	50.00	50.00	50.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/18/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/18/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/18/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/18/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/18/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/18/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/18/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/18/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/18/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/18/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/18/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/18/2020 11:00	24.6	18.0	1,999.5	50.0	165.56	1	0	0
06/18/2020 12:00	9.2	15.3	2,008.2	9.7	72.30	1	0	0
06/18/2020 13:00	1.0	14.0	2,074.3	0.9	6.20	1	1	0
06/18/2020 14:00	0.8	14.0	2,087.3	0.7	6.30	1	1	1
06/18/2020 15:00	1.6	12.5	2,325.2	1.1	9.30	1	1	1
06/18/2020 16:00	2.1	11.9	2,411.4	1.4	12.10	1	1	1
06/18/2020 17:00	1.2	11.9	2,541.7	0.8	7.60	1	1	1
06/18/2020 18:00	1.1	11.9	2,730.5	0.7	8.20	1	1	1
06/18/2020 19:00	1.1	11.9	2,755.7	0.7	8.30	1	1	1
06/18/2020 20:00	1.1	12.0	2,786.9	0.7	8.40	1	1	1
06/18/2020 21:00	1.1	12.1	2,604.6	0.7	7.80	1	1	1
06/18/2020 22:00	1.0	12.7	2,299.1	0.7	6.90	1	1	1
06/18/2020 23:00	2.4	15.8	2,016.9	2.8	5.05	1	0	0
Average/Sum#:	3.7	13.4	2,357.0	5.5	324.01 #	13 #	10 #	9 #
Minimum:	0.8	11.9	1,999.5	0.7	5.05	0	0	0
Maximum:	24.6	18.0	2,786.9	50.0	165.56	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/19/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/20/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/21/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/21/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/21/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/21/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/21/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/21/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/21/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/21/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/21/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/21/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/21/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/21/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/21/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/21/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/21/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/21/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/21/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/21/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/21/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/21/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/21/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/21/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/21/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/21/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/22/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/22/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/22/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/22/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/22/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/22/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/22/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/22/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/22/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/22/2020 09:00	23.7	17.9	1,984.6	46.6	204.84	1	0	0
06/22/2020 10:00	16.8	18.5	1,975.6	41.3	96.10	1	0	0
06/22/2020 11:00	13.5	16.2	2,021.1	16.9	125.30	1	0	0
06/22/2020 12:00	2.2	14.1	2,258.4	1.9	15.80	1	0	0
06/22/2020 13:00	0.8	13.9	2,346.7	0.7	4.70	1	1	1
06/22/2020 14:00	1.1	12.1	2,501.3	0.7	7.50	1	1	1
06/22/2020 15:00	1.1	11.7	2,428.2	0.7	7.30	1	1	1
06/22/2020 16:00	1.1	11.7	2,411.1	0.7	7.20	1	1	1
06/22/2020 17:00	1.1	11.8	2,419.0	0.7	7.30	1	1	1
06/22/2020 18:00	1.2	11.6	2,447.9	0.8	7.30	1	1	1
06/22/2020 19:00	1.2	11.5	2,762.0	0.8	8.30	1	1	1
06/22/2020 20:00	1.2	11.5	2,879.1	0.8	8.60	1	1	1
06/22/2020 21:00	1.2	11.7	2,785.1	0.8	8.40	1	1	1
06/22/2020 22:00	1.1	11.9	2,633.9	0.7	7.90	1	1	1
06/22/2020 23:00	1.0	12.5	2,681.4	0.7	8.00	1	1	1
Average/Sum#:	4.6	13.2	2,435.7	7.7	524.54 #	15 #	11 #	11 #
Minimum:	0.8	11.5	1,975.6	0.7	4.70	0	0	0
Maximum:	23.7	18.5	2,879.1	46.6	204.84	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/23/2020 00:00	1.5	14.3	2,464.3	1.3	5.90	1	0	1
06/23/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/23/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/23/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/23/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/23/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/23/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/23/2020 07:00	0.0	19.5	174.2	0.0	0.00	1	0	0
06/23/2020 08:00	7.0	15.9	671.3	8.3	20.10	1	0	0
06/23/2020 09:00	1.2	14.0	1,348.9	1.0	5.40	1	0	0
06/23/2020 10:00	0.7	14.0	1,333.7	0.6	2.70	1	1	0
06/23/2020 11:00	0.8	14.0	1,429.7	0.7	4.30	1	1	0
06/23/2020 12:00	0.8	14.0	1,528.9	0.7	4.60	1	1	0
06/23/2020 13:00	0.9	13.9	1,481.3	0.8	4.40	1	1	0
06/23/2020 14:00	0.7	14.0	1,335.9	0.6	2.70	1	1	0
06/23/2020 15:00	0.8	13.8	1,623.7	0.7	3.20	1	1	1
06/23/2020 16:00	1.1	11.8	2,035.6	0.7	6.10	1	1	1
06/23/2020 17:00	1.2	11.6	2,069.4	0.8	6.20	1	1	1
06/23/2020 18:00	1.2	11.7	2,063.4	0.8	6.20	1	1	1
06/23/2020 19:00	1.3	11.6	2,091.1	0.8	6.30	1	1	1
06/23/2020 20:00	1.3	11.5	2,119.6	0.8	6.40	1	1	1
06/23/2020 21:00	1.3	11.7	2,077.4	0.8	6.20	1	1	1
06/23/2020 22:00	1.2	11.8	2,070.4	0.8	6.20	1	1	1
06/23/2020 23:00	1.3	11.8	2,067.6	0.8	6.20	1	1	1
Average/Sum#:	1.4	13.4	1,665.9	1.2	103.10 #	18 #	14 #	10 #
Minimum:	0.0	11.5	174.2	0.0	0.00	0	0	0
Maximum:	7.0	19.5	2,464.3	8.3	20.10	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/24/2020 00:00	1.2	12.5	1,967.1	0.8	5.90	1	1	1
06/24/2020 01:00	1.1	12.8	1,915.1	0.8	5.70	1	1	1
06/24/2020 02:00	1.1	12.8	1,908.8	0.8	5.70	1	1	1
06/24/2020 03:00	1.1	12.8	1,906.8	0.8	5.70	1	1	1
06/24/2020 04:00	1.2	12.4	1,990.9	0.8	6.00	1	1	1
06/24/2020 05:00	1.2	12.1	2,037.9	0.8	6.10	1	1	1
06/24/2020 06:00	1.1	12.5	1,930.3	0.8	5.80	1	1	1
06/24/2020 07:00	0.8	14.0	1,548.2	0.7	4.60	1	1	0
06/24/2020 08:00	0.8	14.0	1,545.0	0.7	4.60	1	1	0
06/24/2020 09:00	0.8	14.0	1,547.4	0.7	4.60	1	1	0
06/24/2020 10:00	0.9	14.0	1,501.9	0.8	4.50	1	1	0
06/24/2020 11:00	0.9	13.9	1,553.2	0.8	4.70	1	1	1
06/24/2020 12:00	1.3	12.0	2,025.2	0.9	6.10	1	1	1
06/24/2020 13:00	1.3	11.7	2,072.1	0.8	6.20	1	1	1
06/24/2020 14:00	1.3	11.6	2,077.9	0.8	6.20	1	1	1
06/24/2020 15:00	1.3	11.6	2,080.8	0.8	6.20	1	1	1
06/24/2020 16:00	1.3	11.6	2,073.8	0.8	6.20	1	1	1
06/24/2020 17:00	1.3	11.6	2,077.2	0.8	6.20	1	1	1
06/24/2020 18:00	1.3	11.5	2,090.3	0.8	6.30	1	1	1
06/24/2020 19:00	1.3	11.6	2,080.7	0.8	6.20	1	1	1
06/24/2020 20:00	1.3	11.6	2,083.2	0.8	6.20	1	1	1
06/24/2020 21:00	1.3	11.6	2,084.9	0.8	6.30	1	1	1
06/24/2020 22:00	1.3	11.7	2,060.9	0.8	6.20	1	1	1
06/24/2020 23:00	1.3	11.8	2,056.6	0.8	6.20	1	1	1
Average/Sum#:	1.2	12.4	1,925.7	0.8	138.40 #	24 #	24 #	20 #
Minimum:	0.8	11.5	1,501.9	0.7	4.50	1	1	0
Maximum:	1.3	14.0	2,090.3	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/25/2020 00:00	1.5	13.8	1,286.4	1.2	3.97	1	0	1
06/25/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/25/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/25/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/25/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/25/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/25/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/25/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/25/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/25/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/25/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/25/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/25/2020 12:00	5.8	18.6	293.8	14.9	3.56	1	0	0
06/25/2020 13:00	11.3	15.1	966.6	11.5	40.60	1	0	0
06/25/2020 14:00	0.5	14.1	1,280.4	0.4	2.60	1	1	0
06/25/2020 15:00	0.8	14.0	1,371.6	0.7	4.10	1	1	0
06/25/2020 16:00	0.7	14.1	1,313.9	0.6	2.60	1	1	0
06/25/2020 17:00	0.9	13.9	1,605.8	0.8	4.80	1	1	1
06/25/2020 18:00	1.3	11.8	2,029.5	0.8	6.10	1	1	1
06/25/2020 19:00	1.3	11.9	2,021.5	0.9	6.10	1	1	1
06/25/2020 20:00	1.2	12.0	1,984.7	0.8	6.00	1	1	1
06/25/2020 21:00	1.2	12.2	1,959.2	0.8	5.90	1	1	1
06/25/2020 22:00	1.5	13.4	1,442.5	1.2	4.23	1	0	1
06/25/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.3	13.7	1,463.0	2.9	90.56 #	12 #	8 #	7 #
Minimum:	0.5	11.8	293.8	0.4	2.60	0	0	0
Maximum:	11.3	18.6	2,029.5	14.9	40.60	1	1	1
%SI	50.00	50.00	50.00	50.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/26/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/26/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/26/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/26/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/26/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/26/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/26/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/26/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/26/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/26/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/26/2020 10:00	4.3	18.7	292.8	11.5	2.46	1	0	0
06/26/2020 11:00	10.9	15.3	868.5	11.5	36.50	1	0	0
06/26/2020 12:00	1.2	17.3	173.6	2.0	0.16	1	0	0
06/26/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/26/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/26/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/26/2020 16:00	0.9	17.3	469.4	1.5	1.45	1	0	0
06/26/2020 17:00	2.0	13.5	1,499.5	1.6	9.00	1	0	1
06/26/2020 18:00	2.1	11.5	2,073.3	1.3	10.40	1	1	1
06/26/2020 19:00	2.3	11.4	2,088.2	1.4	10.40	1	1	1
06/26/2020 20:00	2.3	11.5	2,085.8	1.4	10.40	1	1	1
06/26/2020 21:00	1.1	11.8	2,062.5	0.7	6.20	1	1	1
06/26/2020 22:00	1.2	12.3	1,952.1	0.8	5.90	1	1	1
06/26/2020 23:00	0.7	13.6	1,444.4	0.6	2.90	1	1	1
Average/Sum#:	2.6	14.0	1,364.6	3.1	95.77 #	11 #	6 #	7 #
Minimum:	0.7	11.4	173.6	0.6	0.16	0	0	0
Maximum:	10.9	18.7	2,088.2	11.5	36.50	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/27/2020 00:00	1.0	14.5	1,044.5	0.9	2.33	1	0	0
06/27/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.0	14.5	1,044.5	0.9	2.33 #	1 #	0 #	0 #
Minimum:	1.0	14.5	1,044.5	0.9	2.33	0	0	0
Maximum:	1.0	14.5	1,044.5	0.9	2.33	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/28/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/29/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/30/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/30/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/30/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/30/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/30/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/30/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/30/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/30/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/30/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/30/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/30/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/30/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/30/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/30/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/30/2020 14:00	32.0	17.7	417.5	59.0	48.02	1	0	0
06/30/2020 15:00	21.9	15.8	737.2	25.3	68.60	1	0	0
06/30/2020 16:00	0.3	14.1	1,330.2	0.3	1.30	1	1	0
06/30/2020 17:00	0.7	14.0	1,512.0	0.6	3.00	1	1	1
06/30/2020 18:00	1.2	12.1	2,042.6	0.8	6.10	1	1	1
06/30/2020 19:00	1.1	11.8	2,098.6	0.7	6.30	1	1	1
06/30/2020 20:00	1.3	11.8	2,088.8	0.8	6.30	1	1	1
06/30/2020 21:00	1.2	12.0	2,067.6	0.8	6.20	1	1	1
06/30/2020 22:00	1.6	13.9	1,216.5	1.3	2.93	1	0	1
06/30/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	6.8	13.7	1,501.2	10.0	148.75 #	9 #	6 #	6 #
Minimum:	0.3	11.8	417.5	0.3	1.30	0	0	0
Maximum:	32.0	17.7	2,098.6	59.0	68.60	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/01/2020 00:00	0.5	13.9	1,350.6	0.4	2.70	1	1	0
04/01/2020 01:00	0.5	13.9	1,354.2	0.4	2.70	1	1	0
04/01/2020 02:00	0.5	13.9	1,349.8	0.4	2.70	1	1	0
04/01/2020 03:00	0.7	13.8	1,592.9	0.6	3.20	1	1	0
04/01/2020 04:00	0.6	13.9	1,592.9	0.5	3.20	1	1	0
04/01/2020 05:00	0.6	13.9	1,581.7	0.5	3.20	1	1	0
04/01/2020 06:00	0.5	13.9	1,533.5	0.4	3.10	1	1	0
04/01/2020 07:00	0.6	13.9	1,612.1	0.5	3.20	1	1	0
04/01/2020 08:00	0.5	13.9	1,519.3	0.4	3.00	1	1	0
04/01/2020 09:00	0.5	13.9	1,439.4	0.4	2.90	1	1	0
04/01/2020 10:00	0.5	14.0	1,343.9	0.4	2.70	1	1	0
04/01/2020 11:00	0.4	14.0	1,318.4	0.3	1.30	1	1	0
04/01/2020 12:00	0.5	14.0	1,329.7	0.4	2.70	1	1	0
04/01/2020 13:00	0.6	14.0	1,505.8	0.5	3.00	1	1	0
04/01/2020 14:00	0.6	14.0	1,562.1	0.5	3.10	1	1	0
04/01/2020 15:00	0.7	13.9	1,642.9	0.6	3.30	1	1	0
04/01/2020 16:00	0.7	13.9	1,666.3	0.6	3.30	1	1	0
04/01/2020 17:00	0.7	13.9	1,607.3	0.6	3.20	1	1	1
04/01/2020 18:00	1.5	12.9	2,015.8	1.1	8.10	1	1	1
04/01/2020 19:00	1.7	12.3	2,142.4	1.2	8.60	1	1	1
04/01/2020 20:00	1.6	12.3	2,124.8	1.1	8.50	1	1	1
04/01/2020 21:00	1.6	12.3	2,123.4	1.1	8.50	1	1	1
04/01/2020 22:00	1.6	12.4	2,118.7	1.1	8.50	1	1	1
04/01/2020 23:00	1.6	12.5	2,069.3	1.1	8.30	1	1	1
Average/Sum#:	0.8	13.6	1,645.7	0.6	103.00 #	24 #	24 #	7 #
Minimum:	0.4	12.3	1,318.4	0.3	1.30	1	1	0
Maximum:	1.7	14.0	2,142.4	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/02/2020 00:00	0.7	13.9	1,569.0	0.6	3.10	1	1	1
04/02/2020 01:00	0.6	13.9	1,538.5	0.5	3.10	1	1	0
04/02/2020 02:00	0.6	13.9	1,633.7	0.5	3.30	1	1	0
04/02/2020 03:00	0.7	13.9	1,697.6	0.6	3.40	1	1	0
04/02/2020 04:00	0.7	13.9	1,690.0	0.6	3.40	1	1	0
04/02/2020 05:00	0.6	13.9	1,594.2	0.5	3.20	1	1	0
04/02/2020 06:00	0.8	13.9	1,688.0	0.7	3.40	1	1	0
04/02/2020 07:00	0.7	13.9	1,642.4	0.6	3.30	1	1	0
04/02/2020 08:00	0.7	13.9	1,694.9	0.6	3.40	1	1	0
04/02/2020 09:00	0.7	13.9	1,685.9	0.6	3.40	1	1	0
04/02/2020 10:00	0.7	13.9	1,659.7	0.6	3.30	1	1	0
04/02/2020 11:00	0.6	13.9	1,574.7	0.5	3.10	1	1	0
04/02/2020 12:00	0.7	13.9	1,612.6	0.6	3.20	1	1	0
04/02/2020 13:00	0.7	14.0	1,670.6	0.6	3.30	1	1	0
04/02/2020 14:00	0.7	14.0	1,683.4	0.6	3.40	1	1	0
04/02/2020 15:00	0.7	14.0	1,681.6	0.6	3.40	1	1	0
04/02/2020 16:00	0.7	14.0	1,645.2	0.6	3.30	1	1	0
04/02/2020 17:00	0.9	13.9	1,634.0	0.8	4.90	1	1	1
04/02/2020 18:00	1.5	12.9	1,990.0	1.1	8.00	1	1	1
04/02/2020 19:00	1.6	12.7	2,050.3	1.2	8.20	1	1	1
04/02/2020 20:00	1.6	12.7	2,051.0	1.2	8.20	1	1	1
04/02/2020 21:00	5.2	14.4	1,219.3	4.7	9.73	1	0	1
04/02/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/02/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.0	13.8	1,677.6	0.9	95.03 #	22 #	21 #	6 #
Minimum:	0.6	12.7	1,219.3	0.5	3.10	0	0	0
Maximum:	5.2	14.4	2,051.0	4.7	9.73	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/03/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/03/2020 20:00	33.9	17.6	457.7	60.6	73.51	1	0	0
04/03/2020 21:00	11.1	17.1	520.6	17.2	32.80	1	0	0
04/03/2020 22:00	13.6	15.5	873.8	14.9	48.10	1	0	0
04/03/2020 23:00	0.5	13.9	1,546.0	0.4	3.10	1	1	0
Average/Sum#:	14.8	16.0	849.5	23.3	157.51 #	4 #	1 #	0 #
Minimum:	0.5	13.9	457.7	0.4	3.10	0	0	0
Maximum:	33.9	17.6	1,546.0	60.6	73.51	1	1	0
%SI	83.33	83.33	83.33	83.33	83.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/04/2020 00:00	0.6	13.9	1,617.2	0.5	3.20	1	1	0
04/04/2020 01:00	0.8	13.8	1,703.6	0.7	3.40	1	1	0
04/04/2020 02:00	0.6	13.9	1,457.2	0.5	2.90	1	1	0
04/04/2020 03:00	0.7	13.8	1,693.5	0.6	3.40	1	1	0
04/04/2020 04:00	0.7	13.8	1,672.0	0.6	3.30	1	1	0
04/04/2020 05:00	0.7	13.8	1,692.6	0.6	3.40	1	1	0
04/04/2020 06:00	0.7	13.8	1,672.4	0.6	3.30	1	1	0
04/04/2020 07:00	0.7	13.8	1,693.9	0.6	3.40	1	1	0
04/04/2020 08:00	0.7	13.8	1,682.5	0.6	3.40	1	1	0
04/04/2020 09:00	0.7	13.8	1,674.2	0.6	3.30	1	1	0
04/04/2020 10:00	0.7	13.8	1,652.7	0.6	3.30	1	1	0
04/04/2020 11:00	0.7	13.8	1,677.1	0.6	3.40	1	1	0
04/04/2020 12:00	0.7	13.8	1,690.6	0.6	3.40	1	1	0
04/04/2020 13:00	0.7	13.8	1,687.9	0.6	3.40	1	1	0
04/04/2020 14:00	0.8	13.8	1,698.3	0.7	3.40	1	1	0
04/04/2020 15:00	0.8	13.8	1,661.3	0.7	3.30	1	1	0
04/04/2020 16:00	0.8	13.8	1,691.4	0.7	3.40	1	1	0
04/04/2020 17:00	0.7	13.8	1,652.9	0.6	3.30	1	1	1
04/04/2020 18:00	1.5	12.7	2,001.5	1.1	8.00	1	1	1
04/04/2020 19:00	1.8	12.0	2,148.5	1.2	8.60	1	1	1
04/04/2020 20:00	1.7	12.1	2,126.3	1.1	8.50	1	1	1
04/04/2020 21:00	1.7	12.2	2,117.8	1.2	8.50	1	1	1
04/04/2020 22:00	1.7	12.2	2,111.9	1.2	8.40	1	1	1
04/04/2020 23:00	1.7	12.2	2,113.8	1.2	8.50	1	1	1
Average/Sum#:	1.0	13.4	1,774.6	0.8	110.40 #	24 #	24 #	7 #
Minimum:	0.6	12.0	1,457.2	0.5	2.90	1	1	0
Maximum:	1.8	13.9	2,148.5	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/05/2020 00:00	1.7	12.2	2,107.3	1.2	8.40	1	1	1
04/05/2020 01:00	1.0	13.6	1,720.7	0.8	5.20	1	1	1
04/05/2020 02:00	0.7	13.8	1,675.4	0.6	3.40	1	1	0
04/05/2020 03:00	0.7	13.8	1,671.3	0.6	3.30	1	1	0
04/05/2020 04:00	0.7	13.8	1,669.7	0.6	3.30	1	1	0
04/05/2020 05:00	0.7	13.8	1,683.3	0.6	3.40	1	1	0
04/05/2020 06:00	0.8	13.8	1,673.0	0.7	3.30	1	1	0
04/05/2020 07:00	0.7	13.8	1,643.0	0.6	3.30	1	1	0
04/05/2020 08:00	0.8	13.8	1,682.6	0.7	3.40	1	1	0
04/05/2020 09:00	0.7	13.8	1,658.3	0.6	3.30	1	1	0
04/05/2020 10:00	0.7	13.8	1,641.6	0.6	3.30	1	1	0
04/05/2020 11:00	0.7	13.8	1,623.8	0.6	3.20	1	1	0
04/05/2020 12:00	0.7	13.8	1,589.3	0.6	3.20	1	1	0
04/05/2020 13:00	0.8	13.9	1,670.3	0.7	3.30	1	1	0
04/05/2020 14:00	0.8	13.9	1,668.0	0.7	3.30	1	1	0
04/05/2020 15:00	0.8	13.9	1,671.0	0.7	3.30	1	1	0
04/05/2020 16:00	1.1	13.4	1,790.9	0.9	5.40	1	1	1
04/05/2020 17:00	1.7	12.3	2,087.3	1.2	8.30	1	1	1
04/05/2020 18:00	1.6	12.4	2,066.7	1.1	8.30	1	1	1
04/05/2020 19:00	1.6	12.4	2,062.5	1.1	8.30	1	1	1
04/05/2020 20:00	1.7	12.4	2,073.7	1.2	8.30	1	1	1
04/05/2020 21:00	1.7	12.4	2,094.4	1.2	8.40	1	1	1
04/05/2020 22:00	1.7	12.5	2,067.6	1.2	8.30	1	1	1
04/05/2020 23:00	1.7	12.5	2,086.0	1.2	8.30	1	1	1
Average/Sum#:	1.1	13.3	1,807.4	0.8	123.50 #	24 #	24 #	10 #
Minimum:	0.7	12.2	1,589.3	0.6	3.20	1	1	0
Maximum:	1.7	13.9	2,107.3	1.2	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/06/2020 00:00	1.7	12.4	2,092.2	1.2	8.40	1	1	1
04/06/2020 01:00	1.7	12.4	2,094.1	1.2	8.40	1	1	1
04/06/2020 02:00	1.7	12.3	2,111.2	1.2	8.40	1	1	1
04/06/2020 03:00	1.7	12.4	2,103.6	1.2	8.40	1	1	1
04/06/2020 04:00	1.6	12.6	2,066.0	1.1	8.30	1	1	1
04/06/2020 05:00	1.7	12.6	2,075.1	1.2	8.30	1	1	1
04/06/2020 06:00	1.5	12.5	2,092.5	1.1	8.40	1	1	1
04/06/2020 07:00	1.7	12.2	2,044.3	1.2	8.20	1	1	1
04/06/2020 08:00	0.0	0.0	1,661.0	0.0	0.00	1	1	0
04/06/2020 09:00	0.4	13.8	1,678.7	0.3	1.70	1	1	0
04/06/2020 10:00	0.4	13.8	1,688.8	0.3	1.70	1	1	0
04/06/2020 11:00	0.3	13.9	1,626.7	0.3	1.60	1	1	0
04/06/2020 12:00	0.0	0.0	1,620.2	0.0	0.00	1	1	0
04/06/2020 13:00	0.3	13.9	1,595.6	0.3	1.60	1	1	0
04/06/2020 14:00	0.4	13.9	1,664.5	0.3	1.70	1	1	0
04/06/2020 15:00	0.5	13.9	1,674.1	0.4	3.30	1	1	0
04/06/2020 16:00	0.6	13.9	1,556.8	0.5	3.10	1	1	1
04/06/2020 17:00	1.3	12.8	2,011.7	0.9	6.00	1	1	1
04/06/2020 18:00	1.6	12.6	2,038.7	1.1	8.20	1	1	1
04/06/2020 19:00	1.6	12.8	1,989.5	1.2	8.00	1	1	1
04/06/2020 20:00	1.6	12.6	2,030.5	1.1	8.10	1	1	1
04/06/2020 21:00	1.7	12.5	2,068.6	1.2	8.30	1	1	1
04/06/2020 22:00	1.7	12.5	2,068.9	1.2	8.30	1	1	1
04/06/2020 23:00	1.6	12.4	2,099.4	1.1	8.40	1	1	1
Average/Sum#:	1.2	12.9	1,906.4	0.9	136.80 #	24 #	24 #	16 #
Minimum:	0.3	12.2	1,556.8	0.3	1.60	1	1	0
Maximum:	1.7	13.9	2,111.2	1.2	8.40	1	1	1
%SI	8.33	8.33	0.00	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/07/2020 00:00	1.6	12.7	2,038.6	1.2	8.20	1	1	1
04/07/2020 01:00	1.6	12.8	2,029.6	1.2	8.10	1	1	1
04/07/2020 02:00	1.6	12.8	2,030.8	1.2	8.10	1	1	1
04/07/2020 03:00	1.6	12.8	2,024.5	1.2	8.10	1	1	1
04/07/2020 04:00	1.6	12.8	2,023.2	1.2	8.10	1	1	1
04/07/2020 05:00	1.6	12.8	2,027.8	1.2	8.10	1	1	1
04/07/2020 06:00	1.3	13.0	1,965.8	1.0	7.90	1	1	1
04/07/2020 07:00	0.7	13.8	1,635.9	0.6	3.30	1	1	0
04/07/2020 08:00	0.7	13.8	1,647.1	0.6	3.30	1	1	0
04/07/2020 09:00	0.8	13.8	1,681.9	0.7	3.40	1	1	0
04/07/2020 10:00	0.8	13.9	1,681.1	0.7	3.40	1	1	0
04/07/2020 11:00	0.8	13.9	1,688.0	0.7	3.40	1	1	0
04/07/2020 12:00	0.8	13.9	1,682.6	0.7	3.40	1	1	0
04/07/2020 13:00	0.7	13.9	1,635.6	0.6	3.30	1	1	0
04/07/2020 14:00	0.7	13.9	1,618.0	0.6	3.20	1	1	0
04/07/2020 15:00	0.8	13.9	1,682.9	0.7	3.40	1	1	0
04/07/2020 16:00	0.8	13.9	1,690.6	0.7	3.40	1	1	0
04/07/2020 17:00	0.8	13.8	1,608.8	0.7	3.20	1	1	1
04/07/2020 18:00	1.5	12.8	1,988.2	1.1	8.00	1	1	1
04/07/2020 19:00	1.6	12.6	2,031.3	1.1	8.10	1	1	1
04/07/2020 20:00	1.6	12.3	2,101.4	1.1	8.40	1	1	1
04/07/2020 21:00	1.7	12.2	2,105.3	1.2	8.40	1	1	1
04/07/2020 22:00	1.7	12.3	2,107.4	1.2	8.40	1	1	1
04/07/2020 23:00	1.7	12.3	2,110.7	1.2	8.40	1	1	1
Average/Sum#:	1.2	13.2	1,868.2	0.9	143.00 #	24 #	24 #	14 #
Minimum:	0.7	12.2	1,608.8	0.6	3.20	1	1	0
Maximum:	1.7	13.9	2,110.7	1.2	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/08/2020 00:00	1.6	12.5	2,014.5	1.1	8.10	1	1	1
04/08/2020 01:00	0.8	13.9	1,673.2	0.7	3.30	1	1	0
04/08/2020 02:00	0.7	13.9	1,643.2	0.6	3.30	1	1	0
04/08/2020 03:00	0.8	13.8	1,676.2	0.7	3.40	1	1	0
04/08/2020 04:00	0.7	13.9	1,634.5	0.6	3.30	1	1	0
04/08/2020 05:00	0.8	13.8	1,680.0	0.7	3.40	1	1	0
04/08/2020 06:00	0.7	13.8	1,690.4	0.6	3.40	1	1	0
04/08/2020 07:00	0.7	13.8	1,661.3	0.6	3.30	1	1	0
04/08/2020 08:00	0.7	13.8	1,687.0	0.6	3.40	1	1	0
04/08/2020 09:00	0.8	13.8	1,693.3	0.7	3.40	1	1	0
04/08/2020 10:00	0.8	13.8	1,685.3	0.7	3.40	1	1	0
04/08/2020 11:00	0.8	13.9	1,649.3	0.7	3.30	1	1	0
04/08/2020 12:00	0.8	13.9	1,692.2	0.7	3.40	1	1	0
04/08/2020 13:00	0.9	13.8	1,686.0	0.7	5.10	1	1	0
04/08/2020 14:00	1.0	13.8	1,693.5	0.8	5.10	1	1	0
04/08/2020 15:00	0.9	13.8	1,677.7	0.7	5.00	1	1	0
04/08/2020 16:00	0.8	13.8	1,675.0	0.7	3.40	1	1	0
04/08/2020 17:00	1.1	13.4	1,775.8	0.9	5.30	1	1	1
04/08/2020 18:00	1.7	12.2	2,086.7	1.2	8.30	1	1	1
04/08/2020 19:00	1.8	11.9	2,168.2	1.2	8.70	1	1	1
04/08/2020 20:00	1.8	12.1	2,129.7	1.2	8.50	1	1	1
04/08/2020 21:00	1.7	12.2	2,108.8	1.2	8.40	1	1	1
04/08/2020 22:00	1.7	12.2	2,108.0	1.2	8.40	1	1	1
04/08/2020 23:00	1.7	12.2	2,109.9	1.2	8.40	1	1	1
Average/Sum#:	1.1	13.3	1,804.2	0.8	123.00 #	24 #	24 #	8 #
Minimum:	0.7	11.9	1,634.5	0.6	3.30	1	1	0
Maximum:	1.8	13.9	2,168.2	1.2	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/09/2020 00:00	1.7	12.2	2,117.4	1.2	8.50	1	1	1
04/09/2020 01:00	1.8	12.2	2,117.3	1.2	8.50	1	1	1
04/09/2020 02:00	1.7	12.2	2,114.3	1.2	8.50	1	1	1
04/09/2020 03:00	1.7	12.3	2,109.4	1.2	8.40	1	1	1
04/09/2020 04:00	1.7	12.4	2,074.3	1.2	8.30	1	1	1
04/09/2020 05:00	1.7	12.5	2,070.3	1.2	8.30	1	1	1
04/09/2020 06:00	1.7	12.3	2,106.2	1.2	8.40	1	1	1
04/09/2020 07:00	1.7	12.3	2,108.2	1.2	8.40	1	1	1
04/09/2020 08:00	1.7	12.3	2,105.7	1.2	8.40	1	1	1
04/09/2020 09:00	1.7	12.3	2,104.7	1.2	8.40	1	1	1
04/09/2020 10:00	1.7	12.3	2,099.8	1.2	8.40	1	1	1
04/09/2020 11:00	1.7	12.5	2,046.6	1.2	8.20	1	1	1
04/09/2020 12:00	1.7	12.3	2,078.1	1.2	8.30	1	1	1
04/09/2020 13:00	1.7	12.3	2,077.5	1.2	8.30	1	1	1
04/09/2020 14:00	1.7	12.4	2,061.4	1.2	8.20	1	1	1
04/09/2020 15:00	1.7	12.3	2,077.4	1.2	8.30	1	1	1
04/09/2020 16:00	1.7	12.3	2,090.4	1.2	8.40	1	1	1
04/09/2020 17:00	1.7	12.3	2,104.4	1.2	8.40	1	1	1
04/09/2020 18:00	1.7	12.2	2,110.7	1.2	8.40	1	1	1
04/09/2020 19:00	1.7	12.2	2,128.7	1.2	8.50	1	1	1
04/09/2020 20:00	1.7	12.1	2,131.3	1.1	8.50	1	1	1
04/09/2020 21:00	1.7	12.2	2,112.2	1.2	8.40	1	1	1
04/09/2020 22:00	1.7	12.3	2,095.0	1.2	8.40	1	1	1
04/09/2020 23:00	1.7	12.2	2,126.7	1.2	8.50	1	1	1
Average/Sum#:	1.7	12.3	2,098.7	1.2	201.30 #	24 #	24 #	24 #
Minimum:	1.7	12.1	2,046.6	1.1	8.20	1	1	1
Maximum:	1.8	12.5	2,131.3	1.2	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/10/2020 00:00	1.7	12.3	2,115.9	1.2	8.50	1	1	1
04/10/2020 01:00	1.7	12.3	2,106.8	1.2	8.40	1	1	1
04/10/2020 02:00	1.7	12.3	2,105.4	1.2	8.40	1	1	1
04/10/2020 03:00	1.7	12.3	2,101.1	1.2	8.40	1	1	1
04/10/2020 04:00	1.6	12.4	2,073.4	1.1	8.30	1	1	1
04/10/2020 05:00	1.7	12.5	2,046.7	1.2	8.20	1	1	1
04/10/2020 06:00	1.5	12.3	2,101.4	1.0	8.40	1	1	1
04/10/2020 07:00	0.9	13.6	1,704.4	0.7	5.10	1	1	1
04/10/2020 08:00	0.7	13.8	1,560.8	0.6	3.10	1	1	0
04/10/2020 09:00	0.8	13.8	1,687.5	0.7	3.40	1	1	0
04/10/2020 10:00	0.8	13.9	1,660.7	0.7	3.30	1	1	0
04/10/2020 11:00	0.7	13.9	1,552.7	0.6	3.10	1	1	0
04/10/2020 12:00	0.8	13.9	1,669.7	0.7	3.30	1	1	0
04/10/2020 13:00	0.7	13.9	1,572.7	0.6	3.10	1	1	0
04/10/2020 14:00	0.8	13.9	1,604.9	0.7	3.20	1	1	0
04/10/2020 15:00	0.9	13.8	1,654.9	0.7	5.00	1	1	0
04/10/2020 16:00	1.0	13.8	1,662.2	0.8	5.00	1	1	0
04/10/2020 17:00	0.8	13.8	1,475.7	0.7	3.00	1	1	1
04/10/2020 18:00	1.6	12.4	2,043.5	1.1	8.20	1	1	1
04/10/2020 19:00	1.7	12.1	2,102.9	1.1	8.40	1	1	1
04/10/2020 20:00	1.7	12.3	2,077.9	1.2	8.30	1	1	1
04/10/2020 21:00	1.7	12.3	2,066.7	1.2	8.30	1	1	1
04/10/2020 22:00	1.7	12.4	2,062.4	1.2	8.20	1	1	1
04/10/2020 23:00	1.6	13.0	1,915.7	1.2	7.70	1	1	1
Average/Sum#:	1.3	13.0	1,863.6	0.9	148.30 #	24 #	24 #	15 #
Minimum:	0.7	12.1	1,475.7	0.6	3.00	1	1	0
Maximum:	1.7	13.9	2,115.9	1.2	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/11/2020 00:00	0.8	13.8	1,616.2	0.7	3.20	1	1	0
04/11/2020 01:00	0.8	13.8	1,678.7	0.7	3.40	1	1	0
04/11/2020 02:00	0.7	13.8	1,680.0	0.6	3.40	1	1	0
04/11/2020 03:00	0.7	13.8	1,673.3	0.6	3.30	1	1	0
04/11/2020 04:00	0.7	13.8	1,667.0	0.6	3.30	1	1	0
04/11/2020 05:00	0.7	13.8	1,673.6	0.6	3.30	1	1	0
04/11/2020 06:00	0.7	13.8	1,605.9	0.6	3.20	1	1	0
04/11/2020 07:00	0.8	13.8	1,684.0	0.7	3.40	1	1	0
04/11/2020 08:00	0.8	13.8	1,670.0	0.7	3.30	1	1	0
04/11/2020 09:00	0.8	13.8	1,669.1	0.7	3.30	1	1	0
04/11/2020 10:00	0.9	13.8	1,672.7	0.7	5.00	1	1	0
04/11/2020 11:00	0.9	13.9	1,677.2	0.8	5.00	1	1	0
04/11/2020 12:00	0.8	13.9	1,569.7	0.7	3.10	1	1	0
04/11/2020 13:00	0.9	13.9	1,661.2	0.8	5.00	1	1	0
04/11/2020 14:00	0.9	13.8	1,674.0	0.7	5.00	1	1	0
04/11/2020 15:00	1.0	13.8	1,672.8	0.8	5.00	1	1	0
04/11/2020 16:00	1.0	13.8	1,691.6	0.8	5.10	1	1	0
04/11/2020 17:00	0.9	13.8	1,677.5	0.7	5.00	1	1	0
04/11/2020 18:00	0.8	13.8	1,578.4	0.7	3.20	1	1	1
04/11/2020 19:00	1.6	12.6	2,007.7	1.1	8.00	1	1	1
04/11/2020 20:00	1.7	12.4	2,050.8	1.2	8.20	1	1	1
04/11/2020 21:00	1.7	12.3	2,074.6	1.2	8.30	1	1	1
04/11/2020 22:00	1.7	12.5	2,040.2	1.2	8.20	1	1	1
04/11/2020 23:00	1.6	12.7	1,973.4	1.2	7.90	1	1	1
Average/Sum#:	1.0	13.5	1,735.0	0.8	115.10 #	24 #	24 #	6 #
Minimum:	0.7	12.3	1,569.7	0.6	3.10	1	1	0
Maximum:	1.7	13.9	2,074.6	1.2	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/12/2020 00:00	0.8	13.8	1,661.9	0.7	3.30	1	1	0
04/12/2020 01:00	0.8	13.8	1,684.1	0.7	3.40	1	1	0
04/12/2020 02:00	0.8	13.8	1,681.4	0.7	3.40	1	1	0
04/12/2020 03:00	0.7	13.8	1,600.0	0.6	3.20	1	1	0
04/12/2020 04:00	0.8	13.8	1,673.2	0.7	3.30	1	1	0
04/12/2020 05:00	0.8	13.8	1,687.8	0.7	3.40	1	1	0
04/12/2020 06:00	0.7	13.8	1,635.1	0.6	3.30	1	1	0
04/12/2020 07:00	0.8	13.8	1,692.0	0.7	3.40	1	1	0
04/12/2020 08:00	0.9	13.8	1,694.7	0.7	5.10	1	1	0
04/12/2020 09:00	0.9	13.8	1,669.1	0.7	5.00	1	1	0
04/12/2020 10:00	0.8	13.8	1,651.1	0.7	3.30	1	1	0
04/12/2020 11:00	0.8	13.9	1,601.2	0.7	3.20	1	1	0
04/12/2020 12:00	0.8	13.9	1,672.7	0.7	3.30	1	1	0
04/12/2020 13:00	0.9	13.9	1,675.8	0.8	5.00	1	1	0
04/12/2020 14:00	1.0	13.9	1,687.8	0.8	5.10	1	1	0
04/12/2020 15:00	1.0	13.9	1,664.7	0.8	5.00	1	1	0
04/12/2020 16:00	1.2	13.9	1,683.1	1.0	6.70	1	1	0
04/12/2020 17:00	0.8	14.0	1,559.0	0.7	4.70	1	1	0
04/12/2020 18:00	0.7	14.0	1,614.7	0.6	3.20	1	1	0
04/12/2020 19:00	0.8	13.9	1,630.4	0.7	3.30	1	1	0
04/12/2020 20:00	0.8	13.9	1,638.7	0.7	3.30	1	1	0
04/12/2020 21:00	0.8	13.9	1,629.8	0.7	3.30	1	1	0
04/12/2020 22:00	0.8	13.9	1,623.8	0.7	3.20	1	1	0
04/12/2020 23:00	1.1	13.4	1,818.9	0.9	5.50	1	1	1
Average/Sum#:	0.8	13.8	1,659.6	0.7	94.90 #	24 #	24 #	1 #
Minimum:	0.7	13.4	1,559.0	0.6	3.20	1	1	0
Maximum:	1.2	14.0	1,818.9	1.0	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/13/2020 00:00	1.6	12.5	2,028.5	1.1	8.10	1	1	1
04/13/2020 01:00	0.8	13.8	1,688.5	0.7	3.40	1	1	0
04/13/2020 02:00	0.8	13.8	1,690.3	0.7	3.40	1	1	0
04/13/2020 03:00	0.8	13.8	1,671.5	0.7	3.30	1	1	0
04/13/2020 04:00	0.7	13.8	1,637.1	0.6	3.30	1	1	0
04/13/2020 05:00	0.8	13.8	1,663.7	0.7	3.30	1	1	0
04/13/2020 06:00	0.8	13.9	1,678.0	0.7	3.40	1	1	0
04/13/2020 07:00	0.8	13.9	1,656.8	0.7	3.30	1	1	0
04/13/2020 08:00	0.7	13.9	1,669.6	0.6	3.30	1	1	0
04/13/2020 09:00	0.8	13.9	1,696.3	0.7	3.40	1	1	0
04/13/2020 10:00	0.8	13.9	1,692.0	0.7	3.40	1	1	0
04/13/2020 11:00	0.8	13.9	1,693.0	0.7	3.40	1	1	0
04/13/2020 12:00	0.8	13.9	1,673.5	0.7	3.30	1	1	0
04/13/2020 13:00	0.8	13.9	1,610.5	0.7	3.20	1	1	0
04/13/2020 14:00	0.8	13.9	1,677.2	0.7	3.40	1	1	0
04/13/2020 15:00	0.9	13.8	1,687.2	0.7	5.10	1	1	0
04/13/2020 16:00	0.9	13.8	1,656.5	0.7	5.00	1	1	0
04/13/2020 17:00	0.8	13.9	1,531.0	0.7	3.10	1	1	1
04/13/2020 18:00	1.6	12.8	2,011.3	1.2	8.00	1	1	1
04/13/2020 19:00	1.7	12.4	2,105.8	1.2	8.40	1	1	1
04/13/2020 20:00	1.7	12.4	2,096.9	1.2	8.40	1	1	1
04/13/2020 21:00	1.7	12.4	2,100.1	1.2	8.40	1	1	1
04/13/2020 22:00	1.7	12.6	2,074.2	1.2	8.30	1	1	1
04/13/2020 23:00	1.4	13.0	1,923.5	1.0	7.70	1	1	1
Average/Sum#:	1.0	13.5	1,775.5	0.8	117.30 #	24 #	24 #	8 #
Minimum:	0.7	12.4	1,531.0	0.6	3.10	1	1	0
Maximum:	1.7	13.9	2,105.8	1.2	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/14/2020 00:00	0.8	13.9	1,725.2	0.7	3.50	1	1	0
04/14/2020 01:00	0.6	13.9	1,524.5	0.5	3.00	1	1	0
04/14/2020 02:00	0.7	13.9	1,630.9	0.6	3.30	1	1	0
04/14/2020 03:00	0.6	13.9	1,538.1	0.5	3.10	1	1	0
04/14/2020 04:00	0.7	13.9	1,638.1	0.6	3.30	1	1	0
04/14/2020 05:00	0.6	13.9	1,594.0	0.5	3.20	1	1	0
04/14/2020 06:00	0.8	13.9	1,674.9	0.7	3.30	1	1	0
04/14/2020 07:00	0.6	13.9	1,591.5	0.5	3.20	1	1	0
04/14/2020 08:00	0.7	13.9	1,641.7	0.6	3.30	1	1	0
04/14/2020 09:00	0.7	13.9	1,666.9	0.6	3.30	1	1	0
04/14/2020 10:00	0.7	14.0	1,685.4	0.6	3.40	1	1	0
04/14/2020 11:00	0.7	14.0	1,680.0	0.6	3.40	1	1	0
04/14/2020 12:00	0.7	14.0	1,565.2	0.6	3.10	1	1	0
04/14/2020 13:00	0.8	13.9	1,691.7	0.7	3.40	1	1	0
04/14/2020 14:00	0.8	13.9	1,673.2	0.7	3.30	1	1	0
04/14/2020 15:00	0.9	13.9	1,663.3	0.8	5.00	1	1	0
04/14/2020 16:00	0.8	14.0	1,593.8	0.7	4.80	1	1	0
04/14/2020 17:00	0.9	13.9	1,540.3	0.8	4.60	1	1	1
04/14/2020 18:00	1.6	12.6	2,056.3	1.1	8.20	1	1	1
04/14/2020 19:00	1.7	12.3	2,103.7	1.2	8.40	1	1	1
04/14/2020 20:00	1.7	12.4	2,089.4	1.2	8.40	1	1	1
04/14/2020 21:00	1.7	12.6	2,050.2	1.2	8.20	1	1	1
04/14/2020 22:00	1.7	12.4	2,083.8	1.2	8.30	1	1	1
04/14/2020 23:00	1.7	12.6	2,071.6	1.2	8.30	1	1	1
Average/Sum#:	1.0	13.6	1,740.6	0.8	113.30 #	24 #	24 #	7 #
Minimum:	0.6	12.3	1,524.5	0.5	3.00	1	1	0
Maximum:	1.7	14.0	2,103.7	1.2	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/15/2020 00:00	1.6	13.0	1,949.1	1.2	7.80	1	1	1
04/15/2020 01:00	0.7	13.9	1,595.0	0.6	3.20	1	1	0
04/15/2020 02:00	0.7	13.9	1,671.2	0.6	3.30	1	1	0
04/15/2020 03:00	0.6	13.9	1,580.3	0.5	3.20	1	1	0
04/15/2020 04:00	0.6	13.9	1,566.1	0.5	3.10	1	1	0
04/15/2020 05:00	0.7	13.9	1,682.5	0.6	3.40	1	1	0
04/15/2020 06:00	0.7	13.9	1,678.9	0.6	3.40	1	1	0
04/15/2020 07:00	0.7	13.9	1,653.1	0.6	3.30	1	1	0
04/15/2020 08:00	0.8	13.9	1,683.6	0.7	3.40	1	1	0
04/15/2020 09:00	0.8	13.9	1,686.0	0.7	3.40	1	1	0
04/15/2020 10:00	0.8	13.9	1,693.6	0.7	3.40	1	1	0
04/15/2020 11:00	0.8	13.9	1,693.0	0.7	3.40	1	1	0
04/15/2020 12:00	0.8	13.9	1,676.4	0.7	3.40	1	1	0
04/15/2020 13:00	1.0	13.8	1,693.1	0.8	5.10	1	1	0
04/15/2020 14:00	1.2	13.8	1,670.7	1.0	6.70	1	1	0
04/15/2020 15:00	1.1	13.8	1,630.0	0.9	4.90	1	1	0
04/15/2020 16:00	1.2	13.8	1,637.4	1.0	6.50	1	1	0
04/15/2020 17:00	0.9	13.9	1,517.0	0.8	4.60	1	1	1
04/15/2020 18:00	1.6	12.5	2,036.6	1.1	8.10	1	1	1
04/15/2020 19:00	1.8	12.1	2,117.0	1.2	8.50	1	1	1
04/15/2020 20:00	1.8	12.1	2,123.2	1.2	8.50	1	1	1
04/15/2020 21:00	1.7	12.3	2,075.0	1.2	8.30	1	1	1
04/15/2020 22:00	1.6	12.9	1,952.8	1.2	7.80	1	1	1
04/15/2020 23:00	1.5	13.0	1,912.5	1.1	7.70	1	1	1
Average/Sum#:	1.1	13.5	1,757.3	0.8	124.40 #	24 #	24 #	8 #
Minimum:	0.6	12.1	1,517.0	0.5	3.10	1	1	0
Maximum:	1.8	13.9	2,123.2	1.2	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/16/2020 00:00	0.8	13.9	1,505.4	0.7	3.00	1	1	0
04/16/2020 01:00	0.7	13.9	1,494.2	0.6	3.00	1	1	0
04/16/2020 02:00	0.7	13.9	1,525.3	0.6	3.10	1	1	0
04/16/2020 03:00	0.6	13.9	1,492.3	0.5	3.00	1	1	0
04/16/2020 04:00	0.7	13.9	1,578.8	0.6	3.20	1	1	0
04/16/2020 05:00	0.8	13.9	1,668.8	0.7	3.30	1	1	0
04/16/2020 06:00	0.6	13.9	1,545.9	0.5	3.10	1	1	0
04/16/2020 07:00	0.7	13.9	1,649.8	0.6	3.30	1	1	0
04/16/2020 08:00	0.8	13.9	1,683.4	0.7	3.40	1	1	0
04/16/2020 09:00	0.8	13.9	1,669.2	0.7	3.30	1	1	0
04/16/2020 10:00	0.8	13.9	1,690.2	0.7	3.40	1	1	0
04/16/2020 11:00	0.8	13.9	1,666.2	0.7	3.30	1	1	0
04/16/2020 12:00	1.0	13.8	1,699.3	0.8	5.10	1	1	0
04/16/2020 13:00	1.0	13.8	1,684.4	0.8	5.10	1	1	0
04/16/2020 14:00	0.9	13.9	1,596.8	0.8	4.80	1	1	0
04/16/2020 15:00	1.1	13.9	1,636.6	0.9	4.90	1	1	0
04/16/2020 16:00	0.9	13.9	1,630.8	0.8	4.90	1	1	0
04/16/2020 17:00	0.8	13.9	1,563.7	0.7	3.10	1	1	1
04/16/2020 18:00	1.6	12.6	2,023.8	1.1	8.10	1	1	1
04/16/2020 19:00	1.7	12.1	2,111.7	1.1	8.40	1	1	1
04/16/2020 20:00	1.8	12.0	2,137.3	1.2	8.50	1	1	1
04/16/2020 21:00	1.8	12.1	2,111.1	1.2	8.40	1	1	1
04/16/2020 22:00	1.7	12.7	1,990.3	1.2	10.00	1	1	1
04/16/2020 23:00	1.6	12.9	1,924.2	1.2	7.70	1	1	1
Average/Sum#:	1.0	13.5	1,720.0	0.8	117.40 #	24 #	24 #	7 #
Minimum:	0.6	12.0	1,492.3	0.5	3.00	1	1	0
Maximum:	1.8	13.9	2,137.3	1.2	10.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/17/2020 00:00	0.7	13.9	1,450.7	0.6	2.90	1	1	0
04/17/2020 01:00	0.6	13.9	1,352.6	0.5	2.70	1	1	0
04/17/2020 02:00	0.6	13.9	1,337.4	0.5	2.70	1	1	0
04/17/2020 03:00	0.6	13.9	1,336.7	0.5	2.70	1	1	0
04/17/2020 04:00	0.6	13.9	1,312.9	0.5	2.60	1	1	0
04/17/2020 05:00	0.8	13.8	1,670.2	0.7	3.30	1	1	0
04/17/2020 06:00	0.8	13.8	1,638.7	0.7	3.30	1	1	0
04/17/2020 07:00	0.7	13.9	1,612.0	0.6	3.20	1	1	0
04/17/2020 08:00	0.8	13.9	1,674.4	0.7	3.30	1	1	0
04/17/2020 09:00	0.7	13.9	1,652.6	0.6	3.30	1	1	0
04/17/2020 10:00	0.7	13.9	1,562.0	0.6	3.10	1	1	0
04/17/2020 11:00	0.8	13.9	1,650.8	0.7	3.30	1	1	0
04/17/2020 12:00	0.6	14.0	1,461.9	0.5	2.90	1	1	0
04/17/2020 13:00	0.8	13.9	1,617.2	0.7	3.20	1	1	0
04/17/2020 14:00	1.0	13.8	1,677.0	0.8	5.00	1	1	0
04/17/2020 15:00	1.1	13.8	1,687.8	0.9	5.10	1	1	0
04/17/2020 16:00	1.1	13.8	1,655.5	0.9	5.00	1	1	0
04/17/2020 17:00	0.8	13.9	1,528.2	0.7	3.10	1	1	1
04/17/2020 18:00	1.5	12.6	2,026.7	1.1	8.10	1	1	1
04/17/2020 19:00	1.7	12.3	2,069.6	1.2	8.30	1	1	1
04/17/2020 20:00	1.7	12.4	2,063.9	1.2	8.30	1	1	1
04/17/2020 21:00	1.7	12.5	2,051.9	1.2	8.20	1	1	1
04/17/2020 22:00	1.7	12.5	2,068.5	1.2	8.30	1	1	1
04/17/2020 23:00	3.5	14.2	1,255.2	3.1	6.62	1	0	1
Average/Sum#:	1.1	13.6	1,642.3	0.9	108.52 #	24 #	23 #	7 #
Minimum:	0.6	12.3	1,255.2	0.5	2.60	1	0	0
Maximum:	3.5	14.2	2,069.6	3.1	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/18/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/18/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/19/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/19/2020 17:00	31.8	17.6	461.0	56.9	67.41	1	0	0
04/19/2020 18:00	16.2	17.1	521.3	25.2	48.50	1	0	0
04/19/2020 19:00	13.6	15.5	857.7	14.9	47.20	1	0	0
04/19/2020 20:00	0.3	13.9	1,383.7	0.3	1.40	1	1	0
04/19/2020 21:00	0.6	13.9	1,431.6	0.5	2.90	1	1	0
04/19/2020 22:00	0.5	13.9	1,346.6	0.4	2.70	1	1	0
04/19/2020 23:00	0.5	13.9	1,342.0	0.4	2.70	1	1	0
Average/Sum#:	9.1	15.1	1,049.1	14.1	172.81 #	7 #	4 #	0 #
Minimum:	0.3	13.9	461.0	0.3	1.40	0	0	0
Maximum:	31.8	17.6	1,431.6	56.9	67.41	1	1	0
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/20/2020 00:00	0.5	13.9	1,337.6	0.4	2.70	1	1	0
04/20/2020 01:00	0.5	13.9	1,343.6	0.4	2.70	1	1	0
04/20/2020 02:00	0.7	13.8	1,598.2	0.6	3.20	1	1	0
04/20/2020 03:00	0.6	13.8	1,479.3	0.5	3.00	1	1	0
04/20/2020 04:00	0.8	13.8	1,673.3	0.7	3.30	1	1	0
04/20/2020 05:00	0.8	13.8	1,685.2	0.7	3.40	1	1	0
04/20/2020 06:00	0.7	13.8	1,675.2	0.6	3.40	1	1	0
04/20/2020 07:00	0.8	13.8	1,687.9	0.7	3.40	1	1	0
04/20/2020 08:00	0.7	13.8	1,644.0	0.6	3.30	1	1	0
04/20/2020 09:00	0.7	13.8	1,590.5	0.6	3.20	1	1	0
04/20/2020 10:00	0.7	13.8	1,580.8	0.6	3.20	1	1	0
04/20/2020 11:00	0.8	13.8	1,682.8	0.7	3.40	1	1	0
04/20/2020 12:00	0.8	13.9	1,670.9	0.7	3.30	1	1	0
04/20/2020 13:00	0.9	13.9	1,680.5	0.8	5.00	1	1	0
04/20/2020 14:00	0.7	13.9	1,520.3	0.6	3.00	1	1	0
04/20/2020 15:00	0.8	13.9	1,656.3	0.7	3.30	1	1	0
04/20/2020 16:00	0.7	13.9	1,618.7	0.6	3.20	1	1	0
04/20/2020 17:00	0.7	13.9	1,539.4	0.6	3.10	1	1	1
04/20/2020 18:00	1.4	12.7	2,006.1	1.0	8.00	1	1	1
04/20/2020 19:00	1.5	12.5	2,053.3	1.1	8.20	1	1	1
04/20/2020 20:00	1.6	12.5	2,053.9	1.1	8.20	1	1	1
04/20/2020 21:00	1.6	12.5	2,058.5	1.1	8.20	1	1	1
04/20/2020 22:00	1.5	12.8	1,961.5	1.1	7.80	1	1	1
04/20/2020 23:00	5.5	15.8	577.8	6.4	3.06	1	0	0
Average/Sum#:	1.1	13.7	1,640.7	1.0	102.56 #	24 #	23 #	6 #
Minimum:	0.5	12.5	577.8	0.4	2.70	1	0	0
Maximum:	5.5	15.8	2,058.5	6.4	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/21/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/21/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/22/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 04:00	29.9	17.6	467.0	53.5	62.56	1	0	0
04/22/2020 05:00	8.2	17.1	525.0	12.7	24.70	1	0	0
04/22/2020 06:00	6.6	15.7	834.1	7.5	23.40	1	0	0
04/22/2020 07:00	0.8	13.7	1,788.3	0.7	3.60	1	1	0
04/22/2020 08:00	1.2	13.7	1,785.0	1.0	7.10	1	1	0
04/22/2020 09:00	0.4	13.9	1,349.8	0.3	1.30	1	1	0
04/22/2020 10:00	0.4	13.9	1,305.7	0.3	1.30	1	1	0
04/22/2020 11:00	0.7	13.9	1,517.6	0.6	3.00	1	1	0
04/22/2020 12:00	0.7	13.9	1,517.1	0.6	3.00	1	1	0
04/22/2020 13:00	5.2	16.3	404.9	6.7	1.82	1	0	0
04/22/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/22/2020 18:00	3.7	18.6	298.6	9.5	2.31	1	0	0
04/22/2020 19:00	13.8	15.7	840.9	15.7	48.80	1	0	0
04/22/2020 20:00	0.4	13.9	1,474.7	0.3	1.50	1	1	0
04/22/2020 21:00	0.6	13.9	1,540.1	0.5	3.10	1	1	0
04/22/2020 22:00	0.5	13.9	1,404.1	0.4	2.80	1	1	0
04/22/2020 23:00	0.4	13.9	1,348.9	0.3	1.30	1	1	0
Average/Sum#:	4.6	15.0	1,150.1	6.9	191.59 #	16 #	10 #	0 #
Minimum:	0.4	13.7	298.6	0.3	1.30	0	0	0
Maximum:	29.9	18.6	1,788.3	53.5	62.56	1	1	0
%SI	33.33	33.33	33.33	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/23/2020 00:00	0.4	13.9	1,345.6	0.3	1.30	1	1	0
04/23/2020 01:00	0.4	13.9	1,335.0	0.3	1.30	1	1	0
04/23/2020 02:00	4.6	16.7	332.1	6.5	1.36	1	0	0
04/23/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/23/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.8	14.8	1,004.2	2.4	3.96 #	3 #	2 #	0 #
Minimum:	0.4	13.9	332.1	0.3	1.30	0	0	0
Maximum:	4.6	16.7	1,345.6	6.5	1.36	1	1	0
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/24/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/24/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/24/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/24/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/24/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/24/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/24/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/24/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/24/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/24/2020 09:00	31.9	17.6	457.1	57.0	67.20	1	0	0
04/24/2020 10:00	12.6	17.1	522.5	19.6	37.60	1	0	0
04/24/2020 11:00	16.6	15.2	898.2	17.2	56.60	1	0	0
04/24/2020 12:00	0.3	14.0	1,374.1	0.3	1.40	1	1	0
04/24/2020 13:00	0.4	14.0	1,362.2	0.3	1.40	1	1	0
04/24/2020 14:00	0.6	14.0	1,520.8	0.5	3.00	1	1	0
04/24/2020 15:00	0.6	14.0	1,493.2	0.5	3.00	1	1	0
04/24/2020 16:00	0.7	13.9	1,525.7	0.6	3.10	1	1	0
04/24/2020 17:00	0.8	13.9	1,552.4	0.7	3.10	1	1	0
04/24/2020 18:00	1.4	12.7	1,922.8	1.0	7.70	1	1	1
04/24/2020 19:00	1.7	12.0	2,119.6	1.1	8.50	1	1	1
04/24/2020 20:00	1.7	12.1	2,105.9	1.1	8.40	1	1	1
04/24/2020 21:00	1.5	12.7	1,953.0	1.1	7.80	1	1	1
04/24/2020 22:00	2.1	14.6	1,024.9	2.0	4.32	1	0	0
04/24/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	5.2	14.1	1,416.6	7.4	213.12 #	14 #	10 #	4 #
Minimum:	0.3	12.0	457.1	0.3	1.40	0	0	0
Maximum:	31.9	17.6	2,119.6	57.0	67.20	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/25/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/25/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/26/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/26/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/27/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/27/2020 13:00	32.8	17.6	456.1	58.6	66.00	1	0	0
04/27/2020 14:00	24.2	16.2	635.3	30.4	71.20	1	0	0
04/27/2020 15:00	13.2	14.8	1,004.8	12.8	47.20	1	0	0
04/27/2020 16:00	0.4	13.9	1,428.7	0.3	1.40	1	1	0
04/27/2020 17:00	1.4	12.8	1,944.7	1.0	7.80	1	1	1
04/27/2020 18:00	1.6	12.6	1,980.3	1.1	7.90	1	1	1
04/27/2020 19:00	1.6	12.7	1,971.3	1.2	7.90	1	1	1
04/27/2020 20:00	1.6	12.8	1,931.4	1.2	7.70	1	1	1
04/27/2020 21:00	0.6	13.9	1,408.9	0.5	2.80	1	1	0
04/27/2020 22:00	0.5	13.9	1,419.0	0.4	2.80	1	1	0
04/27/2020 23:00	0.6	13.9	1,473.2	0.5	2.90	1	1	0
Average/Sum#:	7.1	14.1	1,423.1	9.8	225.60 #	11 #	8 #	4 #
Minimum:	0.4	12.6	456.1	0.3	1.40	0	0	0
Maximum:	32.8	17.6	1,980.3	58.6	71.20	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/28/2020 00:00	0.5	13.9	1,385.0	0.4	2.80	1	1	0
04/28/2020 01:00	0.5	13.9	1,385.9	0.4	2.80	1	1	0
04/28/2020 02:00	0.5	13.9	1,385.2	0.4	2.80	1	1	0
04/28/2020 03:00	0.5	13.9	1,379.9	0.4	2.80	1	1	0
04/28/2020 04:00	0.5	13.9	1,377.6	0.4	2.80	1	1	0
04/28/2020 05:00	0.5	13.9	1,377.0	0.4	2.80	1	1	0
04/28/2020 06:00	0.5	13.9	1,379.5	0.4	2.80	1	1	0
04/28/2020 07:00	0.5	13.9	1,392.6	0.4	2.80	1	1	0
04/28/2020 08:00	0.5	13.9	1,397.6	0.4	2.80	1	1	0
04/28/2020 09:00	0.4	13.9	1,385.3	0.3	1.40	1	1	0
04/28/2020 10:00	0.4	13.9	1,367.7	0.3	1.40	1	1	0
04/28/2020 11:00	0.3	13.9	1,368.7	0.3	1.40	1	1	0
04/28/2020 12:00	0.4	13.9	1,370.3	0.3	1.40	1	1	0
04/28/2020 13:00	0.5	13.9	1,511.2	0.4	3.00	1	1	0
04/28/2020 14:00	0.6	13.9	1,504.3	0.5	3.00	1	1	0
04/28/2020 15:00	0.6	13.9	1,541.3	0.5	3.10	1	1	0
04/28/2020 16:00	0.6	13.9	1,490.8	0.5	3.00	1	1	1
04/28/2020 17:00	1.5	12.0	2,083.9	1.0	8.30	1	1	1
04/28/2020 18:00	1.8	11.8	2,134.4	1.2	8.50	1	1	1
04/28/2020 19:00	1.8	11.8	2,135.0	1.2	8.50	1	1	1
04/28/2020 20:00	1.8	11.8	2,128.7	1.2	8.50	1	1	1
04/28/2020 21:00	2.3	13.0	1,625.0	1.7	9.80	1	0	1
04/28/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/28/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.8	13.5	1,550.3	0.6	86.50 #	22 #	21 #	6 #
Minimum:	0.3	11.8	1,367.7	0.3	1.40	0	0	0
Maximum:	2.3	13.9	2,135.0	1.7	9.80	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/29/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/29/2020 13:00	25.6	17.5	460.9	44.4	51.41	1	0	0
04/29/2020 14:00	16.7	15.3	726.6	17.6	47.20	1	0	0
04/29/2020 15:00	3.0	14.1	1,420.9	2.6	14.20	1	0	0
04/29/2020 16:00	0.6	13.9	1,379.1	0.5	2.80	1	1	0
04/29/2020 17:00	1.5	12.7	1,939.6	1.1	7.80	1	1	1
04/29/2020 18:00	1.7	12.5	1,979.0	1.2	7.90	1	1	1
04/29/2020 19:00	1.6	12.6	1,969.7	1.1	7.90	1	1	1
04/29/2020 20:00	1.6	12.7	1,930.5	1.2	7.70	1	1	1
04/29/2020 21:00	0.6	13.8	1,361.5	0.5	2.70	1	1	0
04/29/2020 22:00	0.5	13.9	1,344.5	0.4	2.70	1	1	0
04/29/2020 23:00	0.4	13.9	1,343.7	0.3	1.30	1	1	0
Average/Sum#:	4.9	13.9	1,441.5	6.4	153.61 #	11 #	8 #	4 #
Minimum:	0.4	12.5	460.9	0.3	1.30	0	0	0
Maximum:	25.6	17.5	1,979.0	44.4	51.41	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/30/2020 00:00	0.4	13.9	1,342.5	0.3	1.30	1	1	0
04/30/2020 01:00	0.5	13.9	1,342.3	0.4	2.70	1	1	0
04/30/2020 02:00	0.5	13.9	1,342.5	0.4	2.70	1	1	0
04/30/2020 03:00	0.4	13.9	1,343.3	0.3	1.30	1	1	0
04/30/2020 04:00	0.4	13.9	1,342.9	0.3	1.30	1	1	0
04/30/2020 05:00	0.4	13.8	1,344.9	0.3	1.30	1	1	0
04/30/2020 06:00	0.5	13.8	1,333.6	0.4	2.70	1	1	0
04/30/2020 07:00	4.4	16.6	348.8	6.0	1.31	1	0	0
04/30/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
04/30/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.9	14.2	1,217.6	1.1	14.61 #	8 #	7 #	0 #
Minimum:	0.4	13.8	348.8	0.3	1.30	0	0	0
Maximum:	4.4	16.6	1,344.9	6.0	2.70	1	1	0
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/01/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/01/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/02/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/02/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/03/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/03/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/04/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/04/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/05/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/05/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/06/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/06/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/07/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/07/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/08/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/08/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/09/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/09/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/10/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/10/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/11/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 16:00	0.0	21.0	0.2	0.0	0.00	1	0	0
05/11/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/11/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	21.0	0.2	0.0	0.00 #	1 #	0 #	0 #
Minimum:	0.0	21.0	0.2	0.0	0.00	0	0	0
Maximum:	0.0	21.0	0.2	0.0	0.00	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/12/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/12/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/13/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/13/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/14/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/14/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/15/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/15/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/16/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/16/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/17/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/17/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/18/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/18/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/19/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/19/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/20/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/20/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/21/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/21/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/22/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/22/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/23/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/23/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/24/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/24/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/25/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/25/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/26/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/26/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/27/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 08:00	0.0	0.0	387.2	0.0	0.00	1	0	0
05/27/2020 09:00	0.0	0.0	520.3	0.0	0.00	1	0	0
05/27/2020 10:00	0.0	0.0	516.8	0.0	0.00	1	0	0
05/27/2020 11:00	0.0	0.0	857.6	0.0	0.00	1	0	0
05/27/2020 12:00	0.0	0.0	1,388.5	0.0	0.00	1	1	0
05/27/2020 13:00	0.8	13.8	1,455.2	0.7	2.90	1	1	0
05/27/2020 14:00	3.4	15.5	723.2	3.7	2.83	1	0	0
05/27/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/27/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.1	14.7	835.5	2.2	5.73 #	7 #	2 #	0 #
Minimum:	0.8	13.8	387.2	0.7	2.83	0	0	0
Maximum:	3.4	15.5	1,455.2	3.7	2.90	1	1	0
%SI	91.67	91.67	70.83	91.67	91.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/28/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/28/2020 18:00	6.1	19.3	200.0	22.5	2.38	1	0	0
05/28/2020 19:00	24.7	16.4	590.8	32.4	70.30	1	0	0
05/28/2020 20:00	2.5	14.0	1,407.0	2.1	11.30	1	0	0
05/28/2020 21:00	0.9	13.7	1,638.8	0.7	4.90	1	1	0
05/28/2020 22:00	0.8	13.8	1,619.8	0.7	3.20	1	1	0
05/28/2020 23:00	0.8	13.8	1,613.1	0.7	3.20	1	1	1
Average/Sum#:	6.0	15.2	1,178.3	9.9	95.28 #	6 #	3 #	1 #
Minimum:	0.8	13.7	200.0	0.7	2.38	0	0	0
Maximum:	24.7	19.3	1,638.8	32.4	70.30	1	1	1
%SI	75.00	75.00	75.00	75.00	75.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/29/2020 00:00	1.1	13.3	1,693.2	0.9	5.10	1	1	1
05/29/2020 01:00	1.6	14.4	1,259.5	1.5	4.60	1	0	0
05/29/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/29/2020 20:00	27.3	17.7	430.4	50.3	42.19	1	0	0
05/29/2020 21:00	21.8	15.7	696.4	24.7	63.40	1	0	0
05/29/2020 22:00	12.7	14.8	1,015.5	12.3	45.70	1	0	0
05/29/2020 23:00	0.4	13.9	1,381.9	0.3	1.40	1	1	0
Average/Sum#:	10.8	15.0	1,079.5	15.0	162.39 #	6 #	2 #	1 #
Minimum:	0.4	13.3	430.4	0.3	1.40	0	0	0
Maximum:	27.3	17.7	1,693.2	50.3	63.40	1	1	1
%SI	75.00	75.00	75.00	75.00	75.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/30/2020 00:00	0.5	13.9	1,373.6	0.4	2.70	1	1	0
05/30/2020 01:00	0.5	13.9	1,371.1	0.4	2.70	1	1	0
05/30/2020 02:00	0.5	13.9	1,370.2	0.4	2.70	1	1	0
05/30/2020 03:00	0.5	13.8	1,371.0	0.4	2.70	1	1	0
05/30/2020 04:00	0.5	13.8	1,376.6	0.4	2.80	1	1	0
05/30/2020 05:00	0.5	13.8	1,379.5	0.4	2.80	1	1	0
05/30/2020 06:00	0.5	13.8	1,383.6	0.4	2.80	1	1	0
05/30/2020 07:00	0.4	13.8	1,369.8	0.3	1.40	1	1	0
05/30/2020 08:00	3.2	16.3	397.2	4.1	1.02	1	0	0
05/30/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/30/2020 13:00	0.0	20.0	116.6	0.0	0.00	1	0	0
05/30/2020 14:00	21.4	16.1	668.2	26.3	64.80	1	0	0
05/30/2020 15:00	0.7	13.9	1,392.1	0.6	2.80	1	0	0
05/30/2020 16:00	0.0	13.9	1,377.8	0.0	0.00	1	1	0
05/30/2020 17:00	0.0	13.9	1,395.1	0.0	0.00	1	1	0
05/30/2020 18:00	0.0	12.9	1,949.1	0.0	0.00	1	1	1
05/30/2020 19:00	0.0	12.8	1,962.9	0.0	0.00	1	1	1
05/30/2020 20:00	0.0	12.8	1,942.5	0.0	0.00	1	1	1
05/30/2020 21:00	0.0	0.0	1,384.2	0.0	0.00	1	1	0
05/30/2020 22:00	0.0	0.0	1,376.4	0.0	0.00	1	1	0
05/30/2020 23:00	0.4	13.9	1,374.3	0.3	1.40	1	1	0
Average/Sum#:	2.1	14.3	1,316.6	2.5	90.62 #	20 #	16 #	3 #
Minimum:	0.0	12.8	116.6	0.0	0.00	0	0	0
Maximum:	21.4	20.0	1,962.9	26.3	64.80	1	1	1
%SI	41.67	25.00	16.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/31/2020 00:00	0.4	13.9	1,373.7	0.3	1.40	1	1	0
05/31/2020 01:00	0.3	13.9	1,373.2	0.3	1.40	1	1	0
05/31/2020 02:00	0.3	13.9	1,373.5	0.3	1.40	1	1	0
05/31/2020 03:00	0.3	13.9	1,373.6	0.3	1.40	1	1	0
05/31/2020 04:00	0.3	13.9	1,375.0	0.3	1.40	1	1	0
05/31/2020 05:00	0.4	13.9	1,362.7	0.3	1.40	1	1	0
05/31/2020 06:00	0.0	0.0	388.5	0.0	0.00	1	0	0
05/31/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
05/31/2020 14:00	25.5	17.6	446.1	45.6	52.43	1	0	0
05/31/2020 15:00	9.8	15.1	1,010.2	10.0	37.40	1	0	0
05/31/2020 16:00	0.2	13.9	1,385.2	0.2	1.40	1	1	0
05/31/2020 17:00	0.4	13.9	1,389.8	0.3	1.40	1	1	0
05/31/2020 18:00	0.7	13.4	1,754.7	0.6	3.50	1	1	1
05/31/2020 19:00	0.9	12.8	1,952.1	0.7	3.90	1	1	1
05/31/2020 20:00	1.4	12.8	1,929.3	1.0	7.70	1	1	1
05/31/2020 21:00	0.5	13.9	1,416.2	0.4	2.80	1	1	0
05/31/2020 22:00	0.3	13.9	1,369.6	0.3	1.40	1	1	0
05/31/2020 23:00	0.5	13.9	1,367.6	0.4	2.70	1	1	0
Average/Sum#:	2.6	14.0	1,331.8	3.8	123.03 #	17 #	14 #	3 #
Minimum:	0.2	12.8	388.5	0.2	1.40	0	0	0
Maximum:	25.5	17.6	1,952.1	45.6	52.43	1	1	1
%SI	33.33	33.33	29.17	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/01/2020 00:00	0.6	13.9	1,369.5	0.5	2.70	1	1	0
06/01/2020 01:00	0.7	13.9	1,369.0	0.6	2.70	1	1	0
06/01/2020 02:00	0.7	13.9	1,367.5	0.6	2.70	1	1	0
06/01/2020 03:00	0.7	13.9	1,368.2	0.6	2.70	1	1	0
06/01/2020 04:00	0.7	13.9	1,355.8	0.6	2.70	1	1	0
06/01/2020 05:00	0.7	13.9	1,335.9	0.6	2.70	1	1	0
06/01/2020 06:00	0.7	13.9	1,341.8	0.6	2.70	1	1	0
06/01/2020 07:00	0.7	13.9	1,343.5	0.6	2.70	1	1	0
06/01/2020 08:00	0.7	13.9	1,345.5	0.6	2.70	1	1	0
06/01/2020 09:00	0.7	13.9	1,353.4	0.6	2.70	1	1	0
06/01/2020 10:00	0.6	13.9	1,356.4	0.5	2.70	1	1	0
06/01/2020 11:00	0.6	13.9	1,358.5	0.5	2.70	1	1	0
06/01/2020 12:00	0.7	13.9	1,383.5	0.6	2.80	1	1	0
06/01/2020 13:00	1.0	13.8	1,620.1	0.8	4.90	1	1	0
06/01/2020 14:00	1.2	13.7	1,683.4	1.0	6.70	1	1	0
06/01/2020 15:00	0.9	13.8	1,661.5	0.7	5.00	1	1	0
06/01/2020 16:00	0.8	13.9	1,524.9	0.7	3.00	1	1	0
06/01/2020 17:00	0.9	13.9	1,620.6	0.8	4.90	1	1	0
06/01/2020 18:00	0.8	13.9	1,540.2	0.7	3.10	1	1	0
06/01/2020 19:00	0.7	13.9	1,504.2	0.6	3.00	1	1	0
06/01/2020 20:00	0.7	14.0	1,511.0	0.6	3.00	1	1	0
06/01/2020 21:00	0.6	14.0	1,439.3	0.5	2.90	1	1	0
06/01/2020 22:00	0.6	14.0	1,344.4	0.5	2.70	1	1	0
06/01/2020 23:00	0.9	13.8	1,667.3	0.7	5.00	1	1	0
Average/Sum#:	0.7	13.9	1,448.6	0.6	79.40 #	24 #	24 #	0 #
Minimum:	0.6	13.7	1,335.9	0.5	2.70	1	1	0
Maximum:	1.2	14.0	1,683.4	1.0	6.70	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/02/2020 00:00	0.7	14.0	1,495.8	0.6	3.00	1	1	0
06/02/2020 01:00	0.7	13.9	1,515.5	0.6	3.00	1	1	0
06/02/2020 02:00	0.6	13.9	1,430.1	0.5	2.90	1	1	0
06/02/2020 03:00	0.7	13.9	1,538.0	0.6	3.10	1	1	0
06/02/2020 04:00	0.9	13.9	1,686.0	0.8	5.10	1	1	0
06/02/2020 05:00	0.9	13.9	1,665.8	0.8	5.00	1	1	0
06/02/2020 06:00	0.7	13.9	1,479.7	0.6	3.00	1	1	0
06/02/2020 07:00	0.6	13.9	1,379.4	0.5	2.80	1	1	0
06/02/2020 08:00	0.6	13.9	1,330.3	0.5	2.70	1	1	0
06/02/2020 09:00	0.8	13.9	1,510.8	0.7	3.00	1	1	0
06/02/2020 10:00	0.7	13.9	1,481.1	0.6	3.00	1	1	0
06/02/2020 11:00	0.6	13.9	1,310.5	0.5	2.60	1	1	0
06/02/2020 12:00	1.1	13.8	1,662.9	0.9	5.00	1	1	1
06/02/2020 13:00	1.7	12.2	2,058.6	1.2	8.20	1	1	1
06/02/2020 14:00	1.7	11.9	2,034.6	1.1	8.10	1	1	1
06/02/2020 15:00	1.7	11.9	2,027.2	1.1	8.10	1	1	1
06/02/2020 16:00	1.7	11.9	2,066.0	1.1	8.30	1	1	1
06/02/2020 17:00	1.7	12.1	2,060.7	1.1	8.20	1	1	1
06/02/2020 18:00	1.7	12.1	2,071.1	1.1	8.30	1	1	1
06/02/2020 19:00	1.7	12.1	2,067.4	1.1	8.30	1	1	1
06/02/2020 20:00	1.7	12.1	2,063.5	1.1	8.30	1	1	1
06/02/2020 21:00	1.7	12.2	2,051.7	1.2	8.20	1	1	1
06/02/2020 22:00	1.7	12.2	2,055.4	1.2	8.20	1	1	1
06/02/2020 23:00	1.7	12.2	2,053.4	1.2	8.20	1	1	1
Average/Sum#:	1.2	13.1	1,754.0	0.9	134.60 #	24 #	24 #	12 #
Minimum:	0.6	11.9	1,310.5	0.5	2.60	1	1	0
Maximum:	1.7	14.0	2,071.1	1.2	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/03/2020 00:00	1.6	12.3	2,028.9	1.1	8.10	1	1	1
06/03/2020 01:00	0.7	13.9	1,417.0	0.6	2.80	1	1	0
06/03/2020 02:00	0.6	13.9	1,376.3	0.5	2.80	1	1	0
06/03/2020 03:00	0.5	13.9	1,324.9	0.4	2.60	1	1	0
06/03/2020 04:00	0.7	13.8	1,656.2	0.6	3.30	1	1	0
06/03/2020 05:00	0.5	13.9	1,482.0	0.4	3.00	1	1	0
06/03/2020 06:00	0.5	13.9	1,364.2	0.4	2.70	1	1	0
06/03/2020 07:00	0.6	13.9	1,449.7	0.5	2.90	1	1	0
06/03/2020 08:00	0.6	13.9	1,487.7	0.5	3.00	1	1	0
06/03/2020 09:00	0.7	13.9	1,574.4	0.6	3.10	1	1	0
06/03/2020 10:00	0.7	13.9	1,501.2	0.6	3.00	1	1	1
06/03/2020 11:00	1.5	12.3	2,012.8	1.0	8.10	1	1	1
06/03/2020 12:00	1.6	11.9	2,066.2	1.0	8.30	1	1	1
06/03/2020 13:00	1.6	11.9	2,056.7	1.0	8.20	1	1	1
06/03/2020 14:00	1.6	11.9	2,053.7	1.0	8.20	1	1	1
06/03/2020 15:00	1.5	11.9	2,049.2	1.0	8.20	1	1	1
06/03/2020 16:00	1.5	11.9	2,048.2	1.0	8.20	1	1	1
06/03/2020 17:00	1.5	11.9	2,048.9	1.0	8.20	1	1	1
06/03/2020 18:00	1.5	11.9	2,061.8	1.0	8.20	1	1	1
06/03/2020 19:00	1.6	11.8	2,083.2	1.0	8.30	1	1	1
06/03/2020 20:00	1.5	12.1	2,044.4	1.0	8.20	1	1	1
06/03/2020 21:00	1.5	12.2	2,036.4	1.0	8.10	1	1	1
06/03/2020 22:00	1.4	12.3	2,032.4	1.0	8.10	1	1	1
06/03/2020 23:00	1.5	12.1	2,086.6	1.0	8.30	1	1	1
Average/Sum#:	1.1	12.8	1,806.0	0.8	143.90 #	24 #	24 #	15 #
Minimum:	0.5	11.8	1,324.9	0.4	2.60	1	1	0
Maximum:	1.6	13.9	2,086.6	1.1	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/04/2020 00:00	2.4	14.1	1,188.7	2.1	4.56	1	0	1
06/04/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/04/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/04/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/04/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/04/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/04/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/04/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/04/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/04/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/04/2020 10:00	20.8	17.9	407.5	40.9	26.45	1	0	0
06/04/2020 11:00	13.1	15.2	869.1	13.6	43.50	1	0	0
06/04/2020 12:00	0.6	13.9	1,557.5	0.5	3.10	1	1	0
06/04/2020 13:00	0.7	13.9	1,515.8	0.6	3.00	1	1	1
06/04/2020 14:00	1.3	12.1	2,028.5	0.9	6.10	1	1	1
06/04/2020 15:00	1.5	11.8	2,074.1	1.0	8.30	1	1	1
06/04/2020 16:00	1.6	11.8	2,078.8	1.0	8.30	1	1	1
06/04/2020 17:00	1.6	11.8	2,075.4	1.0	8.30	1	1	1
06/04/2020 18:00	1.5	11.8	2,072.2	1.0	8.30	1	1	1
06/04/2020 19:00	1.5	12.0	2,049.1	1.0	8.20	1	1	1
06/04/2020 20:00	1.5	11.9	2,065.6	1.0	8.30	1	1	1
06/04/2020 21:00	1.6	11.9	2,082.1	1.0	8.30	1	1	1
06/04/2020 22:00	1.5	12.1	2,061.2	1.0	8.20	1	1	1
06/04/2020 23:00	1.5	12.1	2,049.6	1.0	8.20	1	1	1
Average/Sum#:	3.5	13.0	1,745.0	4.5	161.11 #	15 #	12 #	12 #
Minimum:	0.6	11.8	407.5	0.5	3.00	0	0	0
Maximum:	20.8	17.9	2,082.1	40.9	43.50	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/05/2020 00:00	2.4	14.1	1,201.9	2.1	5.09	1	0	1
06/05/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/05/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.4	14.1	1,201.9	2.1	5.09 #	1 #	0 #	1 #
Minimum:	2.4	14.1	1,201.9	2.1	5.09	0	0	0
Maximum:	2.4	14.1	1,201.9	2.1	5.09	1	0	1
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/06/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/06/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/07/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/07/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/08/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/08/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/08/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/08/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/08/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/08/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/08/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/08/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/08/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/08/2020 09:00	24.3	17.9	418.2	47.8	31.65	1	0	0
06/08/2020 10:00	24.2	17.1	526.4	37.6	72.60	1	0	0
06/08/2020 11:00	9.9	16.9	556.0	14.6	30.00	1	0	0
06/08/2020 12:00	15.0	15.4	927.5	16.1	54.70	1	0	0
06/08/2020 13:00	0.4	13.9	1,360.3	0.3	1.40	1	1	0
06/08/2020 14:00	0.5	13.9	1,352.5	0.4	2.70	1	1	0
06/08/2020 15:00	0.6	13.9	1,534.9	0.5	3.10	1	1	0
06/08/2020 16:00	0.6	13.9	1,558.6	0.5	3.10	1	1	0
06/08/2020 17:00	1.1	13.7	1,693.4	0.9	5.10	1	1	0
06/08/2020 18:00	0.7	13.8	1,517.5	0.6	3.00	1	1	0
06/08/2020 19:00	1.0	13.8	1,705.9	0.8	5.10	1	1	1
06/08/2020 20:00	1.3	12.7	2,013.0	0.9	6.00	1	1	1
06/08/2020 21:00	1.5	12.3	2,088.5	1.0	8.40	1	1	1
06/08/2020 22:00	1.5	12.4	2,058.4	1.0	8.20	1	1	1
06/08/2020 23:00	2.2	13.6	1,572.8	1.8	11.00	1	0	1
Average/Sum#:	5.7	14.3	1,392.3	8.3	246.05 #	15 #	10 #	5 #
Minimum:	0.4	12.3	418.2	0.3	1.40	0	0	0
Maximum:	24.3	17.9	2,088.5	47.8	72.60	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/09/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/09/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/09/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/09/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/09/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/09/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/09/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/09/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/09/2020 08:00	20.8	17.6	429.7	37.2	31.22	1	0	0
06/09/2020 09:00	9.9	16.9	523.3	14.6	28.30	1	0	0
06/09/2020 10:00	17.9	15.0	921.1	17.9	60.80	1	0	0
06/09/2020 11:00	0.4	13.9	1,370.4	0.3	1.40	1	1	0
06/09/2020 12:00	0.5	13.9	1,361.9	0.4	2.70	1	1	0
06/09/2020 13:00	0.7	13.8	1,529.4	0.6	3.10	1	1	0
06/09/2020 14:00	0.7	13.8	1,560.0	0.6	3.10	1	1	0
06/09/2020 15:00	0.7	13.8	1,533.6	0.6	3.10	1	1	0
06/09/2020 16:00	0.7	13.8	1,511.4	0.6	3.00	1	1	1
06/09/2020 17:00	1.4	12.4	2,023.8	1.0	8.10	1	1	1
06/09/2020 18:00	1.6	12.0	2,088.7	1.1	8.40	1	1	1
06/09/2020 19:00	1.6	12.0	2,094.4	1.1	8.40	1	1	1
06/09/2020 20:00	1.6	12.1	2,066.3	1.1	8.30	1	1	1
06/09/2020 21:00	1.5	12.3	2,050.2	1.0	8.20	1	1	1
06/09/2020 22:00	1.5	12.4	2,019.4	1.0	8.10	1	1	1
06/09/2020 23:00	2.9	14.2	1,189.1	2.6	5.14	1	0	1
Average/Sum#:	4.0	13.7	1,517.0	5.1	191.36 #	16 #	12 #	8 #
Minimum:	0.4	12.0	429.7	0.3	1.40	0	0	0
Maximum:	20.8	17.6	2,094.4	37.2	60.80	1	1	1
%SI	33.33	33.33	33.33	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/10/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/10/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/10/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/10/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/10/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/10/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/10/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/10/2020 07:00	16.1	17.9	394.7	31.7	17.09	1	0	0
06/10/2020 08:00	13.9	14.8	1,015.9	13.4	50.80	1	0	0
06/10/2020 09:00	0.5	13.9	1,374.2	0.4	2.70	1	1	0
06/10/2020 10:00	0.6	13.9	1,390.4	0.5	2.80	1	1	0
06/10/2020 11:00	0.6	13.9	1,393.9	0.5	2.80	1	1	0
06/10/2020 12:00	0.6	13.9	1,397.6	0.5	2.80	1	1	0
06/10/2020 13:00	0.9	13.7	1,679.9	0.7	5.00	1	1	0
06/10/2020 14:00	1.0	13.6	1,608.4	0.8	4.80	1	1	1
06/10/2020 15:00	1.3	12.2	2,035.8	0.9	6.10	1	1	1
06/10/2020 16:00	1.5	11.8	2,113.4	1.0	8.50	1	1	1
06/10/2020 17:00	1.5	11.9	2,097.6	1.0	8.40	1	1	1
06/10/2020 18:00	1.5	11.8	2,102.5	1.0	8.40	1	1	1
06/10/2020 19:00	1.5	12.0	2,068.0	1.0	8.30	1	1	1
06/10/2020 20:00	1.5	12.0	2,079.4	1.0	8.30	1	1	1
06/10/2020 21:00	1.5	12.1	2,096.1	1.0	8.40	1	1	1
06/10/2020 22:00	1.4	12.4	2,028.6	1.0	8.10	1	1	1
06/10/2020 23:00	1.4	12.2	2,062.2	0.9	6.20	1	1	1
Average/Sum#:	2.8	13.2	1,702.3	3.4	159.49 #	17 #	15 #	10 #
Minimum:	0.5	11.8	394.7	0.4	2.70	0	0	0
Maximum:	16.1	17.9	2,113.4	31.7	50.80	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/11/2020 00:00	1.4	12.6	1,961.8	1.0	7.80	1	1	1
06/11/2020 01:00	1.4	12.6	1,951.3	1.0	7.80	1	1	1
06/11/2020 02:00	1.4	12.7	1,941.4	1.0	7.80	1	1	1
06/11/2020 03:00	1.4	12.5	1,991.8	1.0	8.00	1	1	1
06/11/2020 04:00	1.3	12.7	1,919.3	0.9	5.80	1	1	1
06/11/2020 05:00	1.0	13.6	1,749.0	0.8	5.20	1	1	0
06/11/2020 06:00	1.1	13.6	1,749.1	0.9	5.20	1	1	0
06/11/2020 07:00	1.1	13.6	1,737.9	0.9	5.20	1	1	0
06/11/2020 08:00	1.0	13.6	1,721.5	0.8	5.20	1	1	0
06/11/2020 09:00	1.0	13.6	1,709.5	0.8	5.10	1	1	0
06/11/2020 10:00	1.0	13.6	1,693.4	0.8	5.10	1	1	0
06/11/2020 11:00	0.7	13.8	1,394.1	0.6	2.80	1	1	0
06/11/2020 12:00	0.9	13.7	1,648.5	0.7	4.90	1	1	0
06/11/2020 13:00	0.9	13.8	1,638.4	0.7	4.90	1	1	0
06/11/2020 14:00	0.9	13.8	1,626.6	0.7	4.90	1	1	0
06/11/2020 15:00	1.0	13.7	1,640.2	0.8	4.90	1	1	0
06/11/2020 16:00	0.9	13.8	1,633.9	0.7	4.90	1	1	0
06/11/2020 17:00	1.0	13.7	1,699.8	0.8	5.10	1	1	1
06/11/2020 18:00	1.3	12.3	2,038.6	0.9	6.10	1	1	1
06/11/2020 19:00	1.6	11.8	2,146.5	1.0	8.60	1	1	1
06/11/2020 20:00	1.5	12.0	2,099.0	1.0	8.40	1	1	1
06/11/2020 21:00	1.5	12.2	2,069.4	1.0	8.30	1	1	1
06/11/2020 22:00	1.4	12.4	2,021.4	1.0	8.10	1	1	1
06/11/2020 23:00	2.8	14.2	1,190.7	2.5	5.14	1	0	1
Average/Sum#:	1.2	13.2	1,790.5	0.9	145.24 #	24 #	23 #	12 #
Minimum:	0.7	11.8	1,190.7	0.6	2.80	1	0	0
Maximum:	2.8	14.2	2,146.5	2.5	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/12/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/12/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/13/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/13/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/14/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/14/2020 12:00	29.4	17.5	463.3	51.0	60.97	1	0	0
06/14/2020 13:00	21.9	15.9	664.5	25.8	63.10	1	0	0
06/14/2020 14:00	17.1	15.5	839.5	18.7	57.90	1	0	0
06/14/2020 15:00	0.4	13.9	1,405.8	0.3	1.40	1	1	0
06/14/2020 16:00	1.4	12.8	1,923.1	1.0	7.70	1	1	1
06/14/2020 17:00	1.5	12.6	1,965.6	1.1	7.90	1	1	1
06/14/2020 18:00	1.6	12.3	2,029.4	1.1	8.10	1	1	1
06/14/2020 19:00	1.6	12.4	2,018.6	1.1	8.10	1	1	1
06/14/2020 20:00	1.5	12.4	2,007.4	1.0	8.00	1	1	1
06/14/2020 21:00	1.5	12.8	1,924.1	1.1	7.70	1	1	1
06/14/2020 22:00	0.6	13.9	1,352.9	0.5	2.70	1	1	0
06/14/2020 23:00	4.1	16.3	408.4	5.3	1.40	1	0	0
Average/Sum#:	6.9	14.0	1,416.9	9.0	234.97 #	12 #	8 #	6 #
Minimum:	0.4	12.3	408.4	0.3	1.40	0	0	0
Maximum:	29.4	17.5	2,029.4	51.0	63.10	1	1	1
%SI	50.00	50.00	50.00	50.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/15/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/15/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/16/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/16/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/17/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/17/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/17/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/17/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/17/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/17/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/17/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/17/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/17/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/17/2020 09:00	32.4	17.4	471.9	54.6	82.56	1	0	0
06/17/2020 10:00	11.1	17.0	523.0	16.8	32.40	1	0	0
06/17/2020 11:00	11.2	15.3	974.1	11.8	41.90	1	0	0
06/17/2020 12:00	0.5	14.0	1,386.9	0.4	2.80	1	1	0
06/17/2020 13:00	0.5	14.0	1,334.9	0.4	2.70	1	1	0
06/17/2020 14:00	0.7	13.9	1,503.5	0.6	3.00	1	1	0
06/17/2020 15:00	0.8	13.9	1,490.8	0.7	3.00	1	1	0
06/17/2020 16:00	0.9	13.9	1,595.7	0.8	4.80	1	1	0
06/17/2020 17:00	0.8	13.8	1,554.7	0.7	3.10	1	1	1
06/17/2020 18:00	1.4	12.4	2,050.9	1.0	8.20	1	1	1
06/17/2020 19:00	1.6	12.0	2,139.1	1.1	8.60	1	1	1
06/17/2020 20:00	1.6	12.1	2,133.6	1.1	8.50	1	1	1
06/17/2020 21:00	1.6	12.2	2,093.3	1.1	8.40	1	1	1
06/17/2020 22:00	1.6	12.4	2,067.0	1.1	8.30	1	1	1
06/17/2020 23:00	3.0	14.3	1,206.4	2.7	6.05	1	0	1
Average/Sum#:	4.6	13.9	1,501.7	6.3	224.31 #	15 #	11 #	7 #
Minimum:	0.5	12.0	471.9	0.4	2.70	0	0	0
Maximum:	32.4	17.4	2,139.1	54.6	82.56	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/18/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/18/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/18/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/18/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/18/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/18/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/18/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/18/2020 07:00	20.6	17.9	399.7	40.5	22.05	1	0	0
06/18/2020 08:00	15.3	15.7	834.3	17.4	53.40	1	0	0
06/18/2020 09:00	0.5	14.0	1,406.2	0.4	2.80	1	1	0
06/18/2020 10:00	0.5	14.0	1,396.6	0.4	2.80	1	1	0
06/18/2020 11:00	0.9	13.9	1,599.8	0.8	4.80	1	1	0
06/18/2020 12:00	0.6	14.0	1,421.5	0.5	2.80	1	1	0
06/18/2020 13:00	1.0	13.9	1,635.1	0.8	4.90	1	1	0
06/18/2020 14:00	0.9	13.9	1,607.8	0.8	4.80	1	1	1
06/18/2020 15:00	1.4	12.5	2,025.0	1.0	8.10	1	1	1
06/18/2020 16:00	1.6	12.0	2,120.1	1.1	8.50	1	1	1
06/18/2020 17:00	1.6	12.1	2,101.7	1.1	8.40	1	1	1
06/18/2020 18:00	1.6	12.0	2,097.6	1.1	8.40	1	1	1
06/18/2020 19:00	1.6	12.1	2,096.8	1.1	8.40	1	1	1
06/18/2020 20:00	1.6	12.1	2,102.1	1.1	8.40	1	1	1
06/18/2020 21:00	1.5	12.2	2,082.9	1.0	8.30	1	1	1
06/18/2020 22:00	1.2	12.7	1,947.9	0.9	5.80	1	1	1
06/18/2020 23:00	4.9	15.7	626.2	5.6	3.13	1	0	0
Average/Sum#:	3.4	13.6	1,617.7	4.4	165.78 #	17 #	14 #	9 #
Minimum:	0.5	12.0	399.7	0.4	2.80	0	0	0
Maximum:	20.6	17.9	2,120.1	40.5	53.40	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/19/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/19/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/20/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/20/2020 20:00	24.9	17.4	467.0	42.0	68.78	1	0	0
06/20/2020 21:00	3.9	17.0	514.1	5.9	11.30	1	0	0
06/20/2020 22:00	8.2	14.9	1,000.8	8.1	30.00	1	0	0
06/20/2020 23:00	0.6	13.8	1,386.9	0.5	2.80	1	1	0
Average/Sum#:	9.4	15.8	842.2	14.1	112.88 #	4 #	1 #	0 #
Minimum:	0.6	13.8	467.0	0.5	2.80	0	0	0
Maximum:	24.9	17.4	1,386.9	42.0	68.78	1	1	0
%SI	83.33	83.33	83.33	83.33	83.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/21/2020 00:00	0.6	13.8	1,347.7	0.5	2.70	1	1	0
06/21/2020 01:00	0.6	13.8	1,344.8	0.5	2.70	1	1	0
06/21/2020 02:00	0.6	13.9	1,343.1	0.5	2.70	1	1	0
06/21/2020 03:00	0.6	13.9	1,342.2	0.5	2.70	1	1	0
06/21/2020 04:00	0.6	13.9	1,344.1	0.5	2.70	1	1	0
06/21/2020 05:00	0.6	13.9	1,348.4	0.5	2.70	1	1	0
06/21/2020 06:00	0.6	13.9	1,347.9	0.5	2.70	1	1	0
06/21/2020 07:00	0.6	13.9	1,347.9	0.5	2.70	1	1	0
06/21/2020 08:00	0.6	13.9	1,352.3	0.5	2.70	1	1	0
06/21/2020 09:00	0.6	13.9	1,358.7	0.5	2.70	1	1	0
06/21/2020 10:00	0.6	13.9	1,361.3	0.5	2.70	1	1	0
06/21/2020 11:00	0.6	13.9	1,361.3	0.5	2.70	1	1	0
06/21/2020 12:00	0.6	13.9	1,360.6	0.5	2.70	1	1	0
06/21/2020 13:00	0.6	13.9	1,361.1	0.5	2.70	1	1	0
06/21/2020 14:00	0.6	13.9	1,363.1	0.5	2.70	1	1	0
06/21/2020 15:00	0.6	13.9	1,366.2	0.5	2.70	1	1	0
06/21/2020 16:00	0.6	13.9	1,398.5	0.5	2.80	1	1	0
06/21/2020 17:00	1.5	12.7	1,924.8	1.1	7.70	1	1	1
06/21/2020 18:00	1.7	12.0	2,075.6	1.1	8.30	1	1	1
06/21/2020 19:00	1.6	11.8	2,111.5	1.0	8.40	1	1	1
06/21/2020 20:00	1.6	12.1	2,051.6	1.1	8.20	1	1	1
06/21/2020 21:00	1.6	12.4	1,966.4	1.1	7.90	1	1	1
06/21/2020 22:00	0.7	13.9	1,368.6	0.6	2.70	1	1	0
06/21/2020 23:00	0.6	13.9	1,358.7	0.5	2.70	1	1	0
Average/Sum#:	0.8	13.5	1,496.1	0.6	91.90 #	24 #	24 #	5 #
Minimum:	0.6	11.8	1,342.2	0.5	2.70	1	1	0
Maximum:	1.7	13.9	2,111.5	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/22/2020 00:00	0.6	13.8	1,346.5	0.5	2.70	1	1	0
06/22/2020 01:00	0.6	13.9	1,340.7	0.5	2.70	1	1	0
06/22/2020 02:00	0.6	13.9	1,342.2	0.5	2.70	1	1	0
06/22/2020 03:00	0.6	13.9	1,349.0	0.5	2.70	1	1	0
06/22/2020 04:00	0.6	13.9	1,343.9	0.5	2.70	1	1	0
06/22/2020 05:00	0.6	13.9	1,410.1	0.5	2.80	1	1	0
06/22/2020 06:00	0.6	13.9	1,345.6	0.5	2.70	1	1	0
06/22/2020 07:00	0.6	13.9	1,352.5	0.5	2.70	1	1	0
06/22/2020 08:00	0.6	13.9	1,361.4	0.5	2.70	1	1	0
06/22/2020 09:00	0.6	13.9	1,371.7	0.5	2.70	1	1	0
06/22/2020 10:00	0.8	13.8	1,519.1	0.7	3.00	1	1	0
06/22/2020 11:00	0.8	13.8	1,539.9	0.7	3.10	1	1	0
06/22/2020 12:00	0.8	13.8	1,625.6	0.7	3.30	1	1	0
06/22/2020 13:00	0.8	13.8	1,628.6	0.7	3.30	1	1	1
06/22/2020 14:00	1.3	12.1	2,029.7	0.9	6.10	1	1	1
06/22/2020 15:00	1.5	11.9	2,068.2	1.0	8.30	1	1	1
06/22/2020 16:00	1.5	11.9	2,061.1	1.0	8.20	1	1	1
06/22/2020 17:00	1.5	11.9	2,060.8	1.0	8.20	1	1	1
06/22/2020 18:00	1.5	11.8	2,080.1	1.0	8.30	1	1	1
06/22/2020 19:00	1.6	11.8	2,089.9	1.0	8.40	1	1	1
06/22/2020 20:00	1.6	11.8	2,098.5	1.0	8.40	1	1	1
06/22/2020 21:00	1.5	11.9	2,077.8	1.0	8.30	1	1	1
06/22/2020 22:00	1.5	12.0	2,065.3	1.0	8.30	1	1	1
06/22/2020 23:00	1.6	12.1	2,044.8	1.1	8.20	1	1	1
Average/Sum#:	1.0	13.1	1,689.7	0.7	120.50 #	24 #	24 #	11 #
Minimum:	0.6	11.8	1,340.7	0.5	2.70	1	1	0
Maximum:	1.6	13.9	2,098.5	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/23/2020 00:00	2.3	14.0	1,192.7	2.0	4.15	1	0	1
06/23/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/23/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/23/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/23/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/23/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/23/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/23/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/23/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/23/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/23/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/23/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/23/2020 12:00	12.5	18.2	355.7	27.3	10.05	1	0	0
06/23/2020 13:00	12.2	15.8	661.7	14.1	34.40	1	0	0
06/23/2020 14:00	1.9	14.0	1,344.1	1.6	8.10	1	0	0
06/23/2020 15:00	1.0	13.7	1,651.2	0.8	5.00	1	1	1
06/23/2020 16:00	1.4	12.0	2,038.6	0.9	6.10	1	1	1
06/23/2020 17:00	1.5	11.8	2,061.5	1.0	8.20	1	1	1
06/23/2020 18:00	1.5	11.9	2,053.0	1.0	8.20	1	1	1
06/23/2020 19:00	1.5	11.8	2,073.5	1.0	8.30	1	1	1
06/23/2020 20:00	1.5	11.8	2,092.6	1.0	8.40	1	1	1
06/23/2020 21:00	1.5	11.9	2,057.5	1.0	8.20	1	1	1
06/23/2020 22:00	1.5	12.0	2,054.1	1.0	8.20	1	1	1
06/23/2020 23:00	1.5	12.0	2,055.4	1.0	8.20	1	1	1
Average/Sum#:	3.2	13.1	1,668.6	4.1	125.50 #	13 #	9 #	10 #
Minimum:	1.0	11.8	355.7	0.8	4.15	0	0	0
Maximum:	12.5	18.2	2,092.6	27.3	34.40	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/24/2020 00:00	1.4	12.5	1,977.9	1.0	7.90	1	1	1
06/24/2020 01:00	1.3	12.8	1,934.3	0.9	5.80	1	1	1
06/24/2020 02:00	1.3	12.8	1,936.5	0.9	5.80	1	1	1
06/24/2020 03:00	1.3	12.8	1,940.1	0.9	5.80	1	1	1
06/24/2020 04:00	1.3	12.5	2,016.8	0.9	6.10	1	1	1
06/24/2020 05:00	1.4	12.3	2,057.2	1.0	8.20	1	1	1
06/24/2020 06:00	1.3	12.8	1,960.3	0.9	5.90	1	1	1
06/24/2020 07:00	0.8	13.8	1,580.0	0.7	3.20	1	1	0
06/24/2020 08:00	0.8	13.8	1,580.0	0.7	3.20	1	1	0
06/24/2020 09:00	0.8	13.8	1,582.0	0.7	3.20	1	1	0
06/24/2020 10:00	0.7	13.9	1,534.4	0.6	3.10	1	1	0
06/24/2020 11:00	0.9	13.7	1,575.6	0.7	4.70	1	1	1
06/24/2020 12:00	1.3	12.1	2,030.3	0.9	6.10	1	1	1
06/24/2020 13:00	1.5	11.8	2,065.4	1.0	8.30	1	1	1
06/24/2020 14:00	1.5	11.8	2,068.8	1.0	8.30	1	1	1
06/24/2020 15:00	1.6	11.8	2,070.7	1.0	8.30	1	1	1
06/24/2020 16:00	1.6	11.8	2,063.8	1.0	8.30	1	1	1
06/24/2020 17:00	1.6	11.8	2,066.0	1.0	8.30	1	1	1
06/24/2020 18:00	1.6	11.8	2,075.1	1.0	8.30	1	1	1
06/24/2020 19:00	1.6	11.8	2,065.2	1.0	8.30	1	1	1
06/24/2020 20:00	1.6	11.8	2,066.1	1.0	8.30	1	1	1
06/24/2020 21:00	1.6	11.8	2,068.5	1.0	8.30	1	1	1
06/24/2020 22:00	1.6	11.9	2,052.6	1.0	8.20	1	1	1
06/24/2020 23:00	1.6	11.9	2,053.3	1.0	8.20	1	1	1
Average/Sum#:	1.3	12.5	1,934.2	0.9	160.10 #	24 #	24 #	20 #
Minimum:	0.7	11.8	1,534.4	0.6	3.10	1	1	0
Maximum:	1.6	13.9	2,075.1	1.0	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/25/2020 00:00	2.2	13.8	1,305.0	1.8	5.64	1	0	1
06/25/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/25/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/25/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/25/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/25/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/25/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/25/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/25/2020 08:00	4.9	18.7	288.8	13.1	3.06	1	0	0
06/25/2020 09:00	15.0	15.4	922.6	16.1	54.40	1	0	0
06/25/2020 10:00	0.6	13.9	1,414.1	0.5	2.80	1	1	0
06/25/2020 11:00	0.6	13.9	1,420.7	0.5	2.80	1	1	0
06/25/2020 12:00	1.0	13.8	1,595.0	0.8	4.80	1	1	0
06/25/2020 13:00	0.8	13.8	1,409.5	0.7	2.80	1	1	0
06/25/2020 14:00	0.6	13.9	1,310.8	0.5	2.60	1	1	0
06/25/2020 15:00	0.7	13.8	1,404.5	0.6	2.80	1	1	0
06/25/2020 16:00	0.6	13.9	1,345.0	0.5	2.70	1	1	0
06/25/2020 17:00	1.0	13.7	1,641.6	0.8	4.90	1	1	1
06/25/2020 18:00	1.3	12.3	1,959.7	0.9	5.90	1	1	1
06/25/2020 19:00	1.4	12.2	1,976.5	0.9	5.90	1	1	1
06/25/2020 20:00	1.4	12.2	1,969.5	0.9	5.90	1	1	1
06/25/2020 21:00	1.4	12.3	1,962.0	1.0	7.80	1	1	1
06/25/2020 22:00	2.1	13.4	1,455.8	1.7	6.35	1	0	1
06/25/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.2	13.8	1,461.3	2.6	121.15 #	16 #	12 #	7 #
Minimum:	0.6	12.2	288.8	0.5	2.60	0	0	0
Maximum:	15.0	18.7	1,976.5	16.1	54.40	1	1	1
%SI	33.33	33.33	33.33	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/26/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/26/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/26/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/26/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/26/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/26/2020 05:00	5.2	18.6	299.2	13.3	3.23	1	0	0
06/26/2020 06:00	11.5	15.8	762.7	13.3	37.40	1	0	0
06/26/2020 07:00	0.4	13.9	1,389.5	0.3	1.40	1	1	0
06/26/2020 08:00	0.7	13.8	1,394.7	0.6	2.80	1	1	0
06/26/2020 09:00	0.7	13.9	1,407.3	0.6	2.80	1	1	0
06/26/2020 10:00	1.0	13.7	1,607.1	0.8	4.80	1	1	0
06/26/2020 11:00	0.8	13.9	1,436.8	0.7	2.90	1	1	0
06/26/2020 12:00	1.0	13.7	1,556.9	0.8	4.70	1	1	0
06/26/2020 13:00	1.2	13.6	1,683.4	1.0	6.70	1	1	0
06/26/2020 14:00	1.2	13.6	1,684.7	1.0	6.70	1	1	0
06/26/2020 15:00	1.2	13.6	1,681.1	1.0	6.70	1	1	0
06/26/2020 16:00	1.2	13.6	1,683.0	1.0	6.70	1	1	0
06/26/2020 17:00	1.0	13.1	1,639.2	0.8	4.90	1	1	1
06/26/2020 18:00	1.5	11.7	2,063.8	1.0	8.30	1	1	1
06/26/2020 19:00	1.6	11.7	2,073.5	1.0	8.30	1	1	1
06/26/2020 20:00	1.5	11.8	2,070.5	1.0	8.30	1	1	1
06/26/2020 21:00	1.5	11.9	2,057.0	1.0	8.20	1	1	1
06/26/2020 22:00	1.5	12.3	1,960.5	1.0	7.80	1	1	1
06/26/2020 23:00	0.9	13.5	1,470.0	0.7	4.40	1	1	1
Average/Sum#:	1.9	13.6	1,574.8	2.2	137.03 #	19 #	17 #	7 #
Minimum:	0.4	11.7	299.2	0.3	1.40	0	0	0
Maximum:	11.5	18.6	2,073.5	13.3	37.40	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/27/2020 00:00	1.2	14.4	1,069.5	1.1	3.23	1	0	0
06/27/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/27/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.2	14.4	1,069.5	1.1	3.23 #	1 #	0 #	0 #
Minimum:	1.2	14.4	1,069.5	1.1	3.23	0	0	0
Maximum:	1.2	14.4	1,069.5	1.1	3.23	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/28/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/28/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/29/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/29/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/30/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/30/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/30/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/30/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/30/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/30/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/30/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/30/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
06/30/2020 08:00	23.2	17.8	411.2	44.2	30.15	1	0	0
06/30/2020 09:00	22.3	17.1	515.4	34.6	66.00	1	0	0
06/30/2020 10:00	8.9	16.7	566.3	12.5	26.00	1	0	0
06/30/2020 11:00	14.9	15.4	879.5	16.0	51.90	1	0	0
06/30/2020 12:00	0.4	14.0	1,368.0	0.3	1.40	1	1	0
06/30/2020 13:00	0.6	14.0	1,361.5	0.5	2.70	1	1	0
06/30/2020 14:00	0.7	14.0	1,504.2	0.6	3.00	1	1	0
06/30/2020 15:00	0.7	14.0	1,481.8	0.6	3.00	1	1	0
06/30/2020 16:00	0.5	14.0	1,353.2	0.4	2.70	1	1	0
06/30/2020 17:00	0.8	13.8	1,540.8	0.7	3.10	1	1	1
06/30/2020 18:00	1.3	12.2	2,044.0	0.9	6.10	1	1	1
06/30/2020 19:00	1.5	12.0	2,096.2	1.0	8.40	1	1	1
06/30/2020 20:00	1.6	12.0	2,087.1	1.1	8.30	1	1	1
06/30/2020 21:00	1.5	12.1	2,068.1	1.0	8.30	1	1	1
06/30/2020 22:00	2.6	13.9	1,231.7	2.2	4.75	1	0	1
06/30/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	5.4	14.2	1,367.3	7.8	225.80 #	15 #	10 #	6 #
Minimum:	0.4	12.0	411.2	0.3	1.40	0	0	0
Maximum:	23.2	17.8	2,096.2	44.2	66.00	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

ATTACHMENT 7
Hourly Emissions – CO

FCD: AQ-16
Title V: #6

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/01/2020 03:00	66.5	18.4	353.0	0.0	34.7	1	1	0
04/01/2020 04:00	23.1	15.8	811.8	0.0	48.6	1	1	0
04/01/2020 05:00	0.0	13.9	1,557.8	0.0	0.0	1	1	0
04/01/2020 06:00	0.0	13.9	1,506.9	0.0	0.0	1	1	0
04/01/2020 07:00	0.0	13.9	1,584.0	0.0	0.0	1	1	0
04/01/2020 08:00	0.0	14.0	1,489.8	0.0	0.0	1	1	0
04/01/2020 09:00	0.0	14.0	1,404.4	0.0	0.0	1	1	0
04/01/2020 10:00	0.0	14.0	1,313.0	0.0	0.0	1	1	0
04/01/2020 11:00	0.0	14.1	1,289.9	0.0	0.0	1	1	0
04/01/2020 12:00	0.0	14.1	1,302.9	0.0	0.0	1	1	0
04/01/2020 13:00	0.0	14.0	1,478.7	0.0	0.0	1	1	0
04/01/2020 14:00	0.0	14.0	1,535.9	0.0	0.0	1	1	0
04/01/2020 15:00	0.0	14.0	1,611.1	0.0	0.0	1	1	0
04/01/2020 16:00	0.0	14.0	1,639.0	0.0	0.0	1	1	0
04/01/2020 17:00	0.0	14.0	1,579.7	0.0	0.0	1	1	1
04/01/2020 18:00	0.5	12.8	1,985.9	0.1	1.6	1	1	1
04/01/2020 19:00	0.5	12.1	2,127.7	0.2	1.6	1	1	1
04/01/2020 20:00	0.4	12.1	2,105.9	0.3	1.3	1	1	1
04/01/2020 21:00	0.4	12.1	2,106.5	0.3	1.3	1	1	1
04/01/2020 22:00	0.4	12.2	2,101.2	0.3	1.3	1	1	1
04/01/2020 23:00	0.3	12.4	2,033.1	0.3	0.9	1	1	1
Average/Sum#:	4.4	13.8	1,567.5	0.1	91.3 #	21 #	24 #	7 #
Minimum:	0.0	12.1	353.0	0.0	0.0	0	1	0
Maximum:	66.5	18.4	2,127.7	0.3	48.6	1	1	1
%SI	12.50	12.50	12.50	29.17	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/02/2020 00:00	0.0	14.0	1,537.8	0.2	0.0	1	1	0
04/02/2020 01:00	0.0	13.9	1,508.4	0.1	0.0	1	1	0
04/02/2020 02:00	0.0	13.9	1,599.4	0.0	0.0	1	1	0
04/02/2020 03:00	0.0	13.9	1,659.7	0.0	0.0	1	1	0
04/02/2020 04:00	0.0	13.9	1,652.7	0.0	0.0	1	1	0
04/02/2020 05:00	0.0	13.9	1,567.0	0.0	0.0	1	1	0
04/02/2020 06:00	0.0	13.9	1,659.3	0.0	0.0	1	1	0
04/02/2020 07:00	0.0	13.9	1,613.9	0.0	0.0	1	1	0
04/02/2020 08:00	0.0	13.9	1,662.5	0.0	0.0	1	1	0
04/02/2020 09:00	0.0	14.0	1,651.3	0.0	0.0	1	1	0
04/02/2020 10:00	0.0	14.0	1,621.9	0.0	0.0	1	1	0
04/02/2020 11:00	0.0	14.0	1,541.9	0.0	0.0	1	1	0
04/02/2020 12:00	0.0	14.0	1,581.1	0.0	0.0	1	1	0
04/02/2020 13:00	0.0	14.0	1,639.6	0.0	0.0	1	1	0
04/02/2020 14:00	0.0	14.0	1,650.7	0.0	0.0	1	1	0
04/02/2020 15:00	0.0	14.0	1,649.1	0.0	0.0	1	1	0
04/02/2020 16:00	0.0	14.0	1,611.3	0.0	0.0	1	1	0
04/02/2020 17:00	0.0	13.9	1,605.5	0.0	0.0	1	1	1
04/02/2020 18:00	0.5	12.8	1,981.5	0.1	1.6	1	1	1
04/02/2020 19:00	0.5	12.6	2,016.3	0.3	1.6	1	1	1
04/02/2020 20:00	0.4	12.6	2,019.0	0.4	1.3	1	1	1
04/02/2020 21:00	6.3	14.4	1,191.0	0.0	7.1	1	0	1
04/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.4	13.8	1,646.4	0.1	11.6 #	22 #	21 #	5 #
Minimum:	0.0	12.6	1,191.0	0.0	0.0	0	0	0
Maximum:	6.3	14.4	2,019.0	0.4	7.1	1	1	1
%SI	8.33	8.33	8.33	12.50	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	1 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/04/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/04/2020 01:00	38.6	17.6	462.0	0.0	66.4	1	1	0
04/04/2020 02:00	15.1	15.0	1,036.3	0.0	35.0	1	1	0
04/04/2020 03:00	0.0	13.9	1,662.5	0.0	0.0	1	1	0
04/04/2020 04:00	0.0	13.9	1,644.8	0.0	0.0	1	1	0
04/04/2020 05:00	0.0	13.9	1,663.3	0.0	0.0	1	1	0
04/04/2020 06:00	0.0	13.9	1,642.1	0.0	0.0	1	1	0
04/04/2020 07:00	0.0	13.9	1,663.5	0.0	0.0	1	1	0
04/04/2020 08:00	0.0	13.9	1,652.0	0.0	0.0	1	1	0
04/04/2020 09:00	0.0	13.9	1,640.7	0.0	0.0	1	1	0
04/04/2020 10:00	0.0	13.9	1,619.1	0.0	0.0	1	1	0
04/04/2020 11:00	0.0	13.9	1,642.1	0.0	0.0	1	1	0
04/04/2020 12:00	0.0	13.9	1,656.0	0.0	0.0	1	1	0
04/04/2020 13:00	0.0	13.9	1,655.6	0.0	0.0	1	1	0
04/04/2020 14:00	0.0	13.9	1,658.9	0.0	0.0	1	1	0
04/04/2020 15:00	0.0	13.9	1,625.9	0.0	0.0	1	1	0
04/04/2020 16:00	0.0	13.9	1,653.4	0.0	0.0	1	1	0
04/04/2020 17:00	0.0	13.9	1,620.9	0.0	0.0	1	1	1
04/04/2020 18:00	0.5	12.6	1,980.0	0.1	1.6	1	1	1
04/04/2020 19:00	0.4	11.7	2,149.7	0.2	1.2	1	1	1
04/04/2020 20:00	0.4	11.9	2,113.6	0.3	1.2	1	1	1
04/04/2020 21:00	0.4	11.9	2,103.1	0.3	1.2	1	1	1
04/04/2020 22:00	0.4	11.9	2,096.2	0.3	1.2	1	1	1
04/04/2020 23:00	0.4	12.0	2,099.4	0.3	1.2	1	1	1
Average/Sum#:	2.4	13.6	1,684.4	0.1	109.0 #	23 #	24 #	7 #
Minimum:	0.0	11.7	462.0	0.0	0.0	0	1	0
Maximum:	38.6	17.6	2,149.7	0.3	66.4	1	1	1
%SI	4.17	4.17	4.17	20.83	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/05/2020 00:00	0.4	12.0	2,095.2	0.3	1.2	1	1	1
04/05/2020 01:00	0.0	13.6	1,685.9	0.2	0.0	1	1	1
04/05/2020 02:00	0.0	13.9	1,642.4	0.1	0.0	1	1	0
04/05/2020 03:00	0.0	13.9	1,637.4	0.0	0.0	1	1	0
04/05/2020 04:00	0.0	13.9	1,637.2	0.0	0.0	1	1	0
04/05/2020 05:00	0.0	13.9	1,650.3	0.0	0.0	1	1	0
04/05/2020 06:00	0.0	13.9	1,641.6	0.0	0.0	1	1	0
04/05/2020 07:00	0.0	13.9	1,609.9	0.0	0.0	1	1	0
04/05/2020 08:00	0.0	13.9	1,651.9	0.0	0.0	1	1	0
04/05/2020 09:00	0.0	13.9	1,627.5	0.0	0.0	1	1	0
04/05/2020 10:00	0.0	13.9	1,609.1	0.0	0.0	1	1	0
04/05/2020 11:00	0.0	13.9	1,590.4	0.0	0.0	1	1	0
04/05/2020 12:00	0.0	13.9	1,555.2	0.0	0.0	1	1	0
04/05/2020 13:00	0.0	14.0	1,632.7	0.0	0.0	1	1	0
04/05/2020 14:00	0.0	14.0	1,634.9	0.0	0.0	1	1	0
04/05/2020 15:00	0.0	14.0	1,633.0	0.0	0.0	1	1	0
04/05/2020 16:00	0.1	13.4	1,759.4	0.0	0.3	1	1	1
04/05/2020 17:00	0.4	12.1	2,083.0	0.1	1.3	1	1	1
04/05/2020 18:00	0.4	12.2	2,055.1	0.2	1.2	1	1	1
04/05/2020 19:00	0.4	12.3	2,047.8	0.3	1.3	1	1	1
04/05/2020 20:00	0.4	12.3	2,053.2	0.3	1.3	1	1	1
04/05/2020 21:00	0.4	12.2	2,068.9	0.3	1.3	1	1	1
04/05/2020 22:00	0.2	12.4	2,037.4	0.2	0.6	1	1	1
04/05/2020 23:00	0.4	12.3	2,062.5	0.2	1.3	1	1	1
Average/Sum#:	0.1	13.3	1,779.2	0.1	9.8 #	24 #	24 #	10 #
Minimum:	0.0	12.0	1,555.2	0.0	0.0	1	1	0
Maximum:	0.4	14.0	2,095.2	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/06/2020 00:00	0.4	12.3	2,067.4	0.2	1.3	1	1	1
04/06/2020 01:00	0.4	12.3	2,068.9	0.3	1.3	1	1	1
04/06/2020 02:00	0.4	12.1	2,093.7	0.3	1.3	1	1	1
04/06/2020 03:00	0.4	12.2	2,083.5	0.3	1.3	1	1	1
04/06/2020 04:00	0.4	12.5	2,038.7	0.3	1.3	1	1	1
04/06/2020 05:00	0.5	12.3	2,052.4	0.3	1.6	1	1	1
04/06/2020 06:00	0.5	12.3	2,073.6	0.3	1.6	1	1	1
04/06/2020 07:00	0.0	0.0	2,021.6	0.0	0.0	1	1	1
04/06/2020 08:00	0.0	13.9	1,626.6	0.0	0.0	1	1	0
04/06/2020 09:00	0.0	13.9	1,641.8	0.0	0.0	1	1	0
04/06/2020 10:00	0.0	13.9	1,652.5	0.0	0.0	1	1	0
04/06/2020 11:00	0.0	13.9	1,591.2	0.0	0.0	1	1	0
04/06/2020 12:00	0.0	13.9	1,586.5	0.0	0.0	1	1	0
04/06/2020 13:00	0.0	14.0	1,564.8	0.0	0.0	1	1	0
04/06/2020 14:00	0.0	14.0	1,633.7	0.0	0.0	1	1	0
04/06/2020 15:00	0.0	14.0	1,641.7	0.0	0.0	1	1	0
04/06/2020 16:00	0.0	13.9	1,527.3	0.0	0.0	1	1	1
04/06/2020 17:00	0.5	12.7	1,981.1	0.1	1.6	1	1	1
04/06/2020 18:00	0.5	12.5	2,005.1	0.3	1.6	1	1	1
04/06/2020 19:00	0.4	12.8	1,953.7	0.4	1.3	1	1	1
04/06/2020 20:00	0.4	12.6	2,000.2	0.3	1.3	1	1	1
04/06/2020 21:00	0.4	12.4	2,043.5	0.3	1.3	1	1	1
04/06/2020 22:00	0.4	12.4	2,039.7	0.3	1.3	1	1	1
04/06/2020 23:00	0.4	12.2	2,079.0	0.3	1.3	1	1	1
Average/Sum#:	0.3	13.0	1,877.8	0.2	19.4 #	24 #	24 #	16 #
Minimum:	0.0	12.1	1,527.3	0.0	0.0	1	1	0
Maximum:	0.5	14.0	2,093.7	0.4	1.6	1	1	1
%SI	4.17	4.17	0.00	12.50	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/07/2020 00:00	0.4	12.6	2,007.9	0.3	1.3	1	1	1
04/07/2020 01:00	0.4	12.7	2,002.7	0.3	1.3	1	1	1
04/07/2020 02:00	0.4	12.7	2,005.4	0.3	1.3	1	1	1
04/07/2020 03:00	0.4	12.7	1,997.8	0.3	1.3	1	1	1
04/07/2020 04:00	0.4	12.7	1,994.6	0.3	1.3	1	1	1
04/07/2020 05:00	0.4	12.7	1,998.6	0.3	1.3	1	1	1
04/07/2020 06:00	0.4	12.9	1,933.9	0.3	1.3	1	1	1
04/07/2020 07:00	0.0	13.9	1,606.0	0.2	0.0	1	1	0
04/07/2020 08:00	0.0	13.9	1,615.6	0.1	0.0	1	1	0
04/07/2020 09:00	0.0	13.9	1,645.3	0.0	0.0	1	1	0
04/07/2020 10:00	0.0	13.9	1,642.5	0.0	0.0	1	1	0
04/07/2020 11:00	0.0	13.9	1,651.8	0.0	0.0	1	1	0
04/07/2020 12:00	0.0	13.9	1,651.0	0.0	0.0	1	1	0
04/07/2020 13:00	0.0	13.9	1,604.9	0.0	0.0	1	1	0
04/07/2020 14:00	0.0	14.0	1,586.4	0.0	0.0	1	1	0
04/07/2020 15:00	0.0	14.0	1,649.5	0.0	0.0	1	1	0
04/07/2020 16:00	0.0	14.0	1,657.1	0.0	0.0	1	1	0
04/07/2020 17:00	0.0	13.9	1,579.6	0.0	0.0	1	1	1
04/07/2020 18:00	0.5	12.7	1,957.2	0.1	1.6	1	1	1
04/07/2020 19:00	0.4	12.5	2,006.4	0.2	1.3	1	1	1
04/07/2020 20:00	0.4	12.0	2,089.5	0.3	1.2	1	1	1
04/07/2020 21:00	0.4	12.0	2,095.7	0.3	1.2	1	1	1
04/07/2020 22:00	0.4	12.0	2,097.9	0.3	1.2	1	1	1
04/07/2020 23:00	0.4	12.1	2,101.5	0.3	1.3	1	1	1
Average/Sum#:	0.2	13.1	1,840.8	0.2	16.9 #	24 #	24 #	14 #
Minimum:	0.0	12.0	1,579.6	0.0	0.0	1	1	0
Maximum:	0.5	14.0	2,101.5	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/08/2020 00:00	0.4	12.4	1,995.2	0.3	1.2	1	1	1
04/08/2020 01:00	0.0	13.9	1,635.7	0.2	0.0	1	1	0
04/08/2020 02:00	0.0	13.9	1,604.4	0.1	0.0	1	1	0
04/08/2020 03:00	0.0	13.9	1,635.9	0.0	0.0	1	1	0
04/08/2020 04:00	0.0	13.9	1,596.3	0.0	0.0	1	1	0
04/08/2020 05:00	0.0	13.9	1,643.9	0.0	0.0	1	1	0
04/08/2020 06:00	0.0	13.9	1,655.1	0.0	0.0	1	1	0
04/08/2020 07:00	0.0	13.9	1,624.4	0.0	0.0	1	1	0
04/08/2020 08:00	0.0	13.9	1,648.3	0.0	0.0	1	1	0
04/08/2020 09:00	0.0	13.9	1,658.4	0.0	0.0	1	1	0
04/08/2020 10:00	0.0	13.9	1,653.4	0.0	0.0	1	1	0
04/08/2020 11:00	0.0	13.9	1,616.0	0.0	0.0	1	1	0
04/08/2020 12:00	0.0	14.0	1,653.6	0.0	0.0	1	1	0
04/08/2020 13:00	0.0	13.9	1,647.6	0.0	0.0	1	1	0
04/08/2020 14:00	0.0	13.9	1,653.7	0.0	0.0	1	1	0
04/08/2020 15:00	0.0	13.9	1,646.7	0.0	0.0	1	1	0
04/08/2020 16:00	0.0	13.9	1,642.3	0.0	0.0	1	1	0
04/08/2020 17:00	0.1	13.5	1,740.3	0.0	0.3	1	1	1
04/08/2020 18:00	0.5	12.1	2,064.2	0.1	1.5	1	1	1
04/08/2020 19:00	0.4	11.6	2,171.9	0.2	1.2	1	1	1
04/08/2020 20:00	0.4	11.9	2,115.9	0.3	1.2	1	1	1
04/08/2020 21:00	0.4	12.0	2,096.0	0.3	1.2	1	1	1
04/08/2020 22:00	0.4	12.0	2,095.2	0.3	1.2	1	1	1
04/08/2020 23:00	0.4	12.0	2,096.4	0.3	1.2	1	1	1
Average/Sum#:	0.1	13.3	1,774.6	0.1	9.0 #	24 #	24 #	8 #
Minimum:	0.0	11.6	1,596.3	0.0	0.0	1	1	0
Maximum:	0.5	14.0	2,171.9	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/09/2020 00:00	0.4	12.0	2,104.2	0.3	1.2	1	1	1
04/09/2020 01:00	0.4	12.0	2,105.4	0.3	1.2	1	1	1
04/09/2020 02:00	0.4	12.0	2,104.8	0.3	1.2	1	1	1
04/09/2020 03:00	0.4	12.1	2,098.4	0.3	1.3	1	1	1
04/09/2020 04:00	0.4	12.3	2,060.4	0.3	1.3	1	1	1
04/09/2020 05:00	0.5	12.3	2,055.3	0.3	1.6	1	1	1
04/09/2020 06:00	0.5	12.1	2,096.3	0.3	1.6	1	1	1
04/09/2020 07:00	0.4	12.1	2,099.4	0.3	1.3	1	1	1
04/09/2020 08:00	0.4	12.1	2,095.5	0.3	1.3	1	1	1
04/09/2020 09:00	0.4	12.1	2,095.1	0.3	1.3	1	1	1
04/09/2020 10:00	0.4	12.1	2,086.3	0.3	1.3	1	1	1
04/09/2020 11:00	0.4	12.4	2,024.7	0.3	1.3	1	1	1
04/09/2020 12:00	0.4	12.2	2,066.1	0.3	1.3	1	1	1
04/09/2020 13:00	0.4	12.1	2,066.8	0.3	1.2	1	1	1
04/09/2020 14:00	0.4	12.2	2,049.1	0.3	1.2	1	1	1
04/09/2020 15:00	0.4	12.1	2,059.3	0.3	1.2	1	1	1
04/09/2020 16:00	0.4	12.2	2,045.4	0.3	1.2	1	1	1
04/09/2020 17:00	0.4	12.1	2,062.5	0.3	1.2	1	1	1
04/09/2020 18:00	0.4	12.1	2,073.9	0.3	1.2	1	1	1
04/09/2020 19:00	0.4	12.0	2,094.3	0.3	1.2	1	1	1
04/09/2020 20:00	0.4	11.9	2,097.1	0.3	1.2	1	1	1
04/09/2020 21:00	0.4	12.1	2,075.1	0.3	1.2	1	1	1
04/09/2020 22:00	0.4	12.2	2,057.1	0.3	1.2	1	1	1
04/09/2020 23:00	0.4	12.0	2,100.7	0.3	1.2	1	1	1
Average/Sum#:	0.4	12.1	2,078.1	0.3	30.4 #	24 #	24 #	24 #
Minimum:	0.4	11.9	2,024.7	0.3	1.2	1	1	1
Maximum:	0.5	12.4	2,105.4	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/10/2020 00:00	0.4	12.1	2,094.3	0.3	1.3	1	1	1
04/10/2020 01:00	0.4	12.1	2,087.2	0.3	1.3	1	1	1
04/10/2020 02:00	0.4	12.1	2,085.2	0.3	1.3	1	1	1
04/10/2020 03:00	0.4	12.1	2,081.4	0.3	1.2	1	1	1
04/10/2020 04:00	0.4	12.3	2,048.3	0.3	1.3	1	1	1
04/10/2020 05:00	0.4	12.5	2,018.6	0.3	1.3	1	1	1
04/10/2020 06:00	0.4	12.2	2,082.2	0.3	1.3	1	1	1
04/10/2020 07:00	0.0	13.6	1,667.8	0.2	0.0	1	1	1
04/10/2020 08:00	0.0	13.9	1,529.5	0.1	0.0	1	1	0
04/10/2020 09:00	0.0	13.9	1,655.0	0.0	0.0	1	1	0
04/10/2020 10:00	0.0	13.9	1,630.1	0.0	0.0	1	1	0
04/10/2020 11:00	0.0	13.9	1,526.5	0.0	0.0	1	1	0
04/10/2020 12:00	0.0	13.9	1,642.9	0.0	0.0	1	1	0
04/10/2020 13:00	0.0	14.0	1,539.6	0.0	0.0	1	1	0
04/10/2020 14:00	0.0	13.9	1,573.9	0.0	0.0	1	1	0
04/10/2020 15:00	0.0	13.9	1,622.9	0.0	0.0	1	1	0
04/10/2020 16:00	0.0	13.9	1,630.9	0.0	0.0	1	1	0
04/10/2020 17:00	0.0	13.9	1,447.3	0.0	0.0	1	1	1
04/10/2020 18:00	0.6	12.3	1,986.9	0.1	1.8	1	1	1
04/10/2020 19:00	0.5	11.9	2,060.9	0.2	1.5	1	1	1
04/10/2020 20:00	0.5	12.1	2,045.1	0.3	1.5	1	1	1
04/10/2020 21:00	0.5	12.2	2,040.0	0.3	1.5	1	1	1
04/10/2020 22:00	0.5	12.2	2,039.1	0.3	1.5	1	1	1
04/10/2020 23:00	0.4	12.9	1,883.2	0.3	1.2	1	1	1
Average/Sum#:	0.2	13.0	1,834.1	0.2	18.0 #	24 #	24 #	15 #
Minimum:	0.0	11.9	1,447.3	0.0	0.0	1	1	0
Maximum:	0.6	14.0	2,094.3	0.3	1.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/11/2020 00:00	0.0	13.9	1,584.9	0.2	0.0	1	1	0
04/11/2020 01:00	0.0	13.9	1,643.0	0.1	0.0	1	1	0
04/11/2020 02:00	0.0	13.9	1,641.3	0.0	0.0	1	1	0
04/11/2020 03:00	0.0	13.9	1,634.0	0.0	0.0	1	1	0
04/11/2020 04:00	0.0	13.9	1,628.1	0.0	0.0	1	1	0
04/11/2020 05:00	0.0	13.8	1,633.7	0.0	0.0	1	1	0
04/11/2020 06:00	0.0	13.9	1,567.3	0.0	0.0	1	1	0
04/11/2020 07:00	0.0	13.9	1,642.3	0.0	0.0	1	1	0
04/11/2020 08:00	0.0	13.9	1,635.2	0.0	0.0	1	1	0
04/11/2020 09:00	0.0	13.9	1,634.1	0.0	0.0	1	1	0
04/11/2020 10:00	0.0	13.9	1,640.5	0.0	0.0	1	1	0
04/11/2020 11:00	0.0	13.9	1,645.8	0.0	0.0	1	1	0
04/11/2020 12:00	0.0	13.9	1,539.9	0.0	0.0	1	1	0
04/11/2020 13:00	0.0	13.9	1,628.2	0.0	0.0	1	1	0
04/11/2020 14:00	0.0	13.9	1,638.6	0.0	0.0	1	1	0
04/11/2020 15:00	0.0	13.9	1,640.2	0.0	0.0	1	1	0
04/11/2020 16:00	0.0	13.9	1,659.9	0.0	0.0	1	1	0
04/11/2020 17:00	0.0	13.9	1,646.2	0.0	0.0	1	1	0
04/11/2020 18:00	0.0	13.9	1,548.4	0.0	0.0	1	1	1
04/11/2020 19:00	0.6	12.4	1,979.1	0.1	1.8	1	1	1
04/11/2020 20:00	0.5	12.2	2,022.1	0.2	1.5	1	1	1
04/11/2020 21:00	0.5	12.2	2,056.4	0.3	1.6	1	1	1
04/11/2020 22:00	0.5	12.4	2,016.1	0.3	1.6	1	1	1
04/11/2020 23:00	0.4	12.6	1,940.1	0.3	1.2	1	1	1
Average/Sum#:	0.1	13.6	1,701.9	0.1	7.7 #	24 #	24 #	6 #
Minimum:	0.0	12.2	1,539.9	0.0	0.0	1	1	0
Maximum:	0.6	13.9	2,056.4	0.3	1.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/12/2020 00:00	0.0	13.9	1,627.1	0.2	0.0	1	1	0
04/12/2020 01:00	0.0	13.9	1,644.8	0.1	0.0	1	1	0
04/12/2020 02:00	0.0	13.9	1,641.5	0.0	0.0	1	1	0
04/12/2020 03:00	0.0	13.9	1,568.2	0.0	0.0	1	1	0
04/12/2020 04:00	0.0	13.9	1,634.6	0.0	0.0	1	1	0
04/12/2020 05:00	0.0	13.9	1,648.5	0.0	0.0	1	1	0
04/12/2020 06:00	0.0	13.9	1,599.3	0.0	0.0	1	1	0
04/12/2020 07:00	0.0	13.9	1,659.2	0.0	0.0	1	1	0
04/12/2020 08:00	0.0	13.9	1,661.1	0.0	0.0	1	1	0
04/12/2020 09:00	0.0	13.9	1,638.0	0.0	0.0	1	1	0
04/12/2020 10:00	0.0	13.9	1,617.9	0.0	0.0	1	1	0
04/12/2020 11:00	0.0	14.0	1,567.2	0.0	0.0	1	1	0
04/12/2020 12:00	0.0	14.0	1,636.4	0.0	0.0	1	1	0
04/12/2020 13:00	0.0	14.0	1,639.3	0.0	0.0	1	1	0
04/12/2020 14:00	0.0	14.0	1,649.6	0.0	0.0	1	1	0
04/12/2020 15:00	0.0	14.0	1,629.1	0.0	0.0	1	1	0
04/12/2020 16:00	0.0	14.0	1,645.0	0.0	0.0	1	1	0
04/12/2020 17:00	0.0	14.0	1,532.8	0.0	0.0	1	1	0
04/12/2020 18:00	0.0	14.0	1,583.5	0.0	0.0	1	1	0
04/12/2020 19:00	0.0	14.0	1,597.9	0.0	0.0	1	1	0
04/12/2020 20:00	0.0	14.0	1,604.1	0.0	0.0	1	1	0
04/12/2020 21:00	0.0	13.9	1,595.6	0.0	0.0	1	1	0
04/12/2020 22:00	0.0	13.9	1,592.6	0.0	0.0	1	1	0
04/12/2020 23:00	0.2	13.4	1,790.6	0.1	0.6	1	1	1
Average/Sum#:	0.0	13.9	1,625.2	0.0	0.6 #	24 #	24 #	1 #
Minimum:	0.0	13.4	1,532.8	0.0	0.0	1	1	0
Maximum:	0.2	14.0	1,790.6	0.2	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/13/2020 00:00	0.5	12.4	2,011.4	0.2	1.6	1	1	1
04/13/2020 01:00	0.0	13.9	1,650.0	0.2	0.0	1	1	0
04/13/2020 02:00	0.0	13.9	1,653.9	0.1	0.0	1	1	0
04/13/2020 03:00	0.0	13.9	1,631.6	0.0	0.0	1	1	0
04/13/2020 04:00	0.0	13.9	1,601.3	0.0	0.0	1	1	0
04/13/2020 05:00	0.0	13.8	1,634.6	0.0	0.0	1	1	0
04/13/2020 06:00	0.0	13.9	1,639.5	0.0	0.0	1	1	0
04/13/2020 07:00	0.0	14.0	1,622.6	0.0	0.0	1	1	0
04/13/2020 08:00	0.0	14.0	1,635.7	0.0	0.0	1	1	0
04/13/2020 09:00	0.0	14.0	1,663.9	0.0	0.0	1	1	0
04/13/2020 10:00	0.0	14.0	1,663.1	0.0	0.0	1	1	0
04/13/2020 11:00	0.0	14.0	1,667.0	0.0	0.0	1	1	0
04/13/2020 12:00	0.0	14.0	1,647.8	0.0	0.0	1	1	0
04/13/2020 13:00	0.0	14.0	1,579.5	0.0	0.0	1	1	0
04/13/2020 14:00	0.0	14.0	1,643.9	0.0	0.0	1	1	0
04/13/2020 15:00	0.0	14.0	1,661.4	0.0	0.0	1	1	0
04/13/2020 16:00	0.0	14.0	1,629.6	0.0	0.0	1	1	0
04/13/2020 17:00	0.0	14.0	1,500.3	0.0	0.0	1	1	1
04/13/2020 18:00	0.5	12.8	1,935.5	0.1	1.6	1	1	1
04/13/2020 19:00	0.4	12.3	2,026.8	0.2	1.2	1	1	1
04/13/2020 20:00	0.4	12.4	2,022.3	0.3	1.3	1	1	1
04/13/2020 21:00	0.4	12.4	2,023.9	0.3	1.3	1	1	1
04/13/2020 22:00	0.4	12.5	2,009.0	0.3	1.3	1	1	1
04/13/2020 23:00	0.3	12.9	1,895.9	0.3	0.9	1	1	1
Average/Sum#:	0.1	13.5	1,735.4	0.1	9.2 #	24 #	24 #	8 #
Minimum:	0.0	12.3	1,500.3	0.0	0.0	1	1	0
Maximum:	0.5	14.0	2,026.8	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/14/2020 00:00	0.0	14.0	1,689.3	0.2	0.0	1	1	0
04/14/2020 01:00	0.0	14.0	1,496.1	0.1	0.0	1	1	0
04/14/2020 02:00	0.0	14.0	1,599.0	0.0	0.0	1	1	0
04/14/2020 03:00	0.0	14.0	1,506.9	0.0	0.0	1	1	0
04/14/2020 04:00	0.0	14.0	1,601.0	0.0	0.0	1	1	0
04/14/2020 05:00	0.0	13.9	1,558.2	0.0	0.0	1	1	0
04/14/2020 06:00	0.0	13.9	1,639.9	0.0	0.0	1	1	0
04/14/2020 07:00	0.0	14.0	1,559.9	0.0	0.0	1	1	0
04/14/2020 08:00	0.0	14.0	1,612.2	0.0	0.0	1	1	0
04/14/2020 09:00	0.0	14.0	1,637.9	0.0	0.0	1	1	0
04/14/2020 10:00	0.0	14.0	1,651.3	0.0	0.0	1	1	0
04/14/2020 11:00	0.0	14.0	1,644.3	0.0	0.0	1	1	0
04/14/2020 12:00	0.0	14.0	1,534.6	0.0	0.0	1	1	0
04/14/2020 13:00	0.0	14.0	1,655.9	0.0	0.0	1	1	0
04/14/2020 14:00	0.0	14.0	1,637.7	0.0	0.0	1	1	0
04/14/2020 15:00	0.0	14.0	1,626.5	0.0	0.0	1	1	0
04/14/2020 16:00	0.0	14.0	1,559.5	0.0	0.0	1	1	0
04/14/2020 17:00	0.0	13.9	1,503.1	0.0	0.0	1	1	1
04/14/2020 18:00	0.4	12.6	1,943.4	0.1	1.2	1	1	1
04/14/2020 19:00	0.5	12.2	2,012.7	0.2	1.5	1	1	1
04/14/2020 20:00	0.4	12.3	2,000.5	0.3	1.2	1	1	1
04/14/2020 21:00	0.4	12.5	1,969.2	0.3	1.2	1	1	1
04/14/2020 22:00	0.4	12.4	1,998.8	0.3	1.2	1	1	1
04/14/2020 23:00	0.4	12.5	2,007.7	0.3	1.3	1	1	1
Average/Sum#:	0.1	13.6	1,693.6	0.1	7.6 #	24 #	24 #	7 #
Minimum:	0.0	12.2	1,496.1	0.0	0.0	1	1	0
Maximum:	0.5	14.0	2,012.7	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/15/2020 00:00	0.3	13.0	1,892.1	0.3	0.9	1	1	1
04/15/2020 01:00	0.0	13.9	1,566.3	0.2	0.0	1	1	0
04/15/2020 02:00	0.0	13.9	1,636.5	0.1	0.0	1	1	0
04/15/2020 03:00	0.0	13.9	1,552.3	0.0	0.0	1	1	0
04/15/2020 04:00	0.0	13.9	1,537.9	0.0	0.0	1	1	0
04/15/2020 05:00	0.0	13.9	1,646.0	0.0	0.0	1	1	0
04/15/2020 06:00	0.0	13.9	1,644.6	0.0	0.0	1	1	0
04/15/2020 07:00	0.0	13.9	1,621.2	0.0	0.0	1	1	0
04/15/2020 08:00	0.0	13.9	1,655.3	0.0	0.0	1	1	0
04/15/2020 09:00	0.0	13.9	1,656.0	0.0	0.0	1	1	0
04/15/2020 10:00	0.0	14.0	1,661.3	0.0	0.0	1	1	0
04/15/2020 11:00	0.0	14.0	1,661.1	0.0	0.0	1	1	0
04/15/2020 12:00	0.0	14.0	1,645.0	0.0	0.0	1	1	0
04/15/2020 13:00	0.0	13.9	1,660.1	0.0	0.0	1	1	0
04/15/2020 14:00	0.0	13.9	1,637.4	0.0	0.0	1	1	0
04/15/2020 15:00	0.0	13.9	1,600.1	0.0	0.0	1	1	0
04/15/2020 16:00	0.0	13.9	1,606.8	0.0	0.0	1	1	0
04/15/2020 17:00	0.0	13.9	1,492.8	0.0	0.0	1	1	1
04/15/2020 18:00	0.5	12.4	1,956.6	0.1	1.5	1	1	1
04/15/2020 19:00	0.5	11.9	2,061.2	0.2	1.5	1	1	1
04/15/2020 20:00	0.6	11.8	2,075.5	0.3	1.8	1	1	1
04/15/2020 21:00	0.6	12.2	2,024.5	0.4	1.8	1	1	1
04/15/2020 22:00	0.4	12.9	1,897.4	0.4	1.3	1	1	1
04/15/2020 23:00	0.3	12.9	1,870.2	0.3	0.9	1	1	1
Average/Sum#:	0.1	13.5	1,719.1	0.1	9.7 #	24 #	24 #	8 #
Minimum:	0.0	11.8	1,492.8	0.0	0.0	1	1	0
Maximum:	0.6	14.0	2,075.5	0.4	1.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/16/2020 00:00	0.0	13.9	1,478.8	0.2	0.0	1	1	0
04/16/2020 01:00	0.0	13.9	1,470.8	0.1	0.0	1	1	0
04/16/2020 02:00	0.0	13.9	1,499.0	0.0	0.0	1	1	0
04/16/2020 03:00	0.0	13.9	1,467.0	0.0	0.0	1	1	0
04/16/2020 04:00	0.0	13.9	1,551.1	0.0	0.0	1	1	0
04/16/2020 05:00	0.0	13.9	1,637.5	0.0	0.0	1	1	0
04/16/2020 06:00	0.0	13.9	1,518.9	0.0	0.0	1	1	0
04/16/2020 07:00	0.0	13.9	1,621.3	0.0	0.0	1	1	0
04/16/2020 08:00	0.0	14.0	1,653.8	0.0	0.0	1	1	0
04/16/2020 09:00	0.0	14.0	1,639.8	0.0	0.0	1	1	0
04/16/2020 10:00	0.0	14.0	1,656.3	0.0	0.0	1	1	0
04/16/2020 11:00	0.0	14.0	1,631.4	0.0	0.0	1	1	0
04/16/2020 12:00	0.0	13.9	1,659.0	0.0	0.0	1	1	0
04/16/2020 13:00	0.0	13.9	1,648.5	0.0	0.0	1	1	0
04/16/2020 14:00	0.0	13.9	1,564.2	0.0	0.0	1	1	0
04/16/2020 15:00	0.0	13.9	1,608.8	0.0	0.0	1	1	0
04/16/2020 16:00	0.0	14.0	1,601.6	0.0	0.0	1	1	0
04/16/2020 17:00	0.0	14.0	1,525.6	0.0	0.0	1	1	1
04/16/2020 18:00	0.5	12.5	1,937.8	0.1	1.5	1	1	1
04/16/2020 19:00	0.4	12.0	2,054.5	0.2	1.2	1	1	1
04/16/2020 20:00	0.3	11.8	2,089.2	0.3	0.9	1	1	1
04/16/2020 21:00	0.3	12.0	2,056.5	0.2	0.9	1	1	1
04/16/2020 22:00	0.4	12.6	1,927.3	0.2	1.2	1	1	1
04/16/2020 23:00	0.4	12.9	1,870.5	0.3	1.2	1	1	1
Average/Sum#:	0.1	13.5	1,682.1	0.1	6.9 #	24 #	24 #	7 #
Minimum:	0.0	11.8	1,467.0	0.0	0.0	1	1	0
Maximum:	0.5	14.0	2,089.2	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/17/2020 00:00	0.0	13.9	1,423.2	0.2	0.0	1	1	0
04/17/2020 01:00	0.0	13.9	1,326.3	0.1	0.0	1	1	0
04/17/2020 02:00	0.0	13.9	1,310.7	0.0	0.0	1	1	0
04/17/2020 03:00	0.0	13.9	1,308.7	0.0	0.0	1	1	0
04/17/2020 04:00	0.0	13.9	1,286.9	0.0	0.0	1	1	0
04/17/2020 05:00	0.0	13.9	1,635.4	0.0	0.0	1	1	0
04/17/2020 06:00	0.0	13.9	1,602.5	0.0	0.0	1	1	0
04/17/2020 07:00	0.0	13.9	1,578.8	0.0	0.0	1	1	0
04/17/2020 08:00	0.0	13.9	1,645.2	0.0	0.0	1	1	0
04/17/2020 09:00	0.0	14.0	1,622.4	0.0	0.0	1	1	0
04/17/2020 10:00	0.0	14.0	1,531.5	0.0	0.0	1	1	0
04/17/2020 11:00	0.0	14.0	1,612.5	0.0	0.0	1	1	0
04/17/2020 12:00	0.0	14.0	1,434.2	0.0	0.0	1	1	0
04/17/2020 13:00	0.0	14.0	1,582.8	0.0	0.0	1	1	0
04/17/2020 14:00	0.0	13.9	1,642.7	0.0	0.0	1	1	0
04/17/2020 15:00	0.0	13.9	1,652.6	0.0	0.0	1	1	0
04/17/2020 16:00	0.0	13.9	1,621.5	0.0	0.0	1	1	0
04/17/2020 17:00	0.0	13.9	1,500.6	0.0	0.0	1	1	1
04/17/2020 18:00	0.7	12.5	1,962.0	0.2	2.2	1	1	1
04/17/2020 19:00	0.6	12.2	2,020.3	0.3	1.8	1	1	1
04/17/2020 20:00	0.6	12.3	2,016.3	0.4	1.9	1	1	1
04/17/2020 21:00	0.6	12.3	2,015.0	0.4	1.9	1	1	1
04/17/2020 22:00	0.6	12.3	2,037.6	0.4	1.9	1	1	1
04/17/2020 23:00	6.6	14.1	1,222.9	0.0	7.5	1	0	1
Average/Sum#:	0.4	13.6	1,608.0	0.1	17.2 #	24 #	23 #	7 #
Minimum:	0.0	12.2	1,222.9	0.0	0.0	1	0	0
Maximum:	6.6	14.1	2,037.6	0.4	7.5	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/18/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/19/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/19/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/19/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/19/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	4 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/20/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/20/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/20/2020 02:00	53.5	17.4	490.9	0.0	94.1	1	1	0
04/20/2020 03:00	19.9	14.8	1,025.2	0.0	44.2	1	1	0
04/20/2020 04:00	0.0	13.9	1,635.4	0.0	0.0	1	1	0
04/20/2020 05:00	0.0	13.9	1,646.9	0.0	0.0	1	1	0
04/20/2020 06:00	0.0	13.9	1,636.2	0.0	0.0	1	1	0
04/20/2020 07:00	0.0	13.9	1,648.4	0.0	0.0	1	1	0
04/20/2020 08:00	0.0	13.9	1,607.8	0.0	0.0	1	1	0
04/20/2020 09:00	0.0	13.9	1,559.2	0.0	0.0	1	1	0
04/20/2020 10:00	0.0	13.9	1,550.8	0.0	0.0	1	1	0
04/20/2020 11:00	0.0	13.9	1,651.3	0.0	0.0	1	1	0
04/20/2020 12:00	0.0	13.9	1,638.7	0.0	0.0	1	1	0
04/20/2020 13:00	0.0	13.9	1,646.3	0.0	0.0	1	1	0
04/20/2020 14:00	0.0	13.9	1,491.4	0.0	0.0	1	1	0
04/20/2020 15:00	0.0	13.9	1,623.6	0.0	0.0	1	1	0
04/20/2020 16:00	0.0	13.9	1,589.6	0.0	0.0	1	1	0
04/20/2020 17:00	0.0	13.9	1,508.9	0.0	0.0	1	1	1
04/20/2020 18:00	0.6	12.6	1,957.3	0.1	1.9	1	1	1
04/20/2020 19:00	0.6	12.4	2,009.0	0.3	1.9	1	1	1
04/20/2020 20:00	0.5	12.4	2,012.1	0.4	1.6	1	1	1
04/20/2020 21:00	0.5	12.4	2,018.1	0.3	1.6	1	1	1
04/20/2020 22:00	0.4	12.8	1,914.2	0.3	1.2	1	1	1
04/20/2020 23:00	13.0	15.8	552.1	0.0	4.3	1	0	0
Average/Sum#:	4.0	13.9	1,564.2	0.1	150.8 #	22 #	23 #	6 #
Minimum:	0.0	12.4	490.9	0.0	0.0	0	0	0
Maximum:	53.5	17.4	2,018.1	0.4	94.1	1	1	1
%SI	8.33	8.33	8.33	29.17	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/21/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 07:00	87.4	18.0	399.8	0.0	60.5	1	1	0
04/22/2020 08:00	24.8	16.5	598.5	0.0	44.6	1	1	0
04/22/2020 09:00	6.2	14.2	1,202.4	0.0	14.7	1	1	0
04/22/2020 10:00	0.0	14.0	1,251.5	0.0	0.0	1	1	0
04/22/2020 11:00	24.6	17.0	225.3	0.0	2.4	1	1	0
04/22/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/22/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/22/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/22/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/22/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	28.6	15.9	735.5	0.0	122.2 #	5 #	10 #	0 #
Minimum:	0.0	14.0	225.3	0.0	0.0	0	0	0
Maximum:	87.4	18.0	1,251.5	0.0	60.5	1	1	0
%SI	79.17	79.17	79.17	100.00	79.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/23/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	2 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/24/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/24/2020 14:00	48.3	0.0	454.0	0.0	9.7	1	1	0
04/24/2020 15:00	22.8	0.0	717.7	0.0	10.3	1	1	0
04/24/2020 16:00	0.0	0.0	1,511.5	0.0	0.0	1	1	0
04/24/2020 17:00	0.0	0.0	1,529.9	0.0	0.0	1	1	0
04/24/2020 18:00	0.0	0.0	1,772.4	0.0	0.0	1	1	1
04/24/2020 19:00	0.3	11.8	2,051.6	0.0	0.9	1	1	1
04/24/2020 20:00	0.3	11.9	2,039.4	0.0	0.9	1	1	1
04/24/2020 21:00	0.3	12.7	1,865.3	0.2	0.9	1	1	1
04/24/2020 22:00	12.0	15.9	533.0	0.0	3.9	1	0	0
04/24/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	9.3	13.1	1,386.1	0.2	6.6 #	9 #	10 #	4 #
Minimum:	0.0	11.8	454.0	0.2	0.9	0	0	0
Maximum:	48.3	15.9	2,051.6	0.2	3.9	1	1	1
%SI	62.50	83.33	62.50	95.83	83.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/27/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/27/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/27/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/27/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/27/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/27/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/27/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	8 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/28/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/28/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/28/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/28/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/28/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/28/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/28/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/28/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/28/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/28/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/28/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/28/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/28/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/28/2020 13:00	57.9	17.6	438.5	0.0	68.1	1	1	0
04/28/2020 14:00	22.2	15.7	737.6	0.0	41.6	1	1	0
04/28/2020 15:00	0.0	14.0	1,508.3	0.0	0.0	1	1	0
04/28/2020 16:00	0.0	13.9	1,462.7	0.0	0.0	1	1	1
04/28/2020 17:00	0.4	12.0	2,000.9	0.0	1.2	1	1	1
04/28/2020 18:00	0.3	11.5	2,079.8	0.2	0.9	1	1	1
04/28/2020 19:00	0.3	11.5	2,088.2	0.2	0.9	1	1	1
04/28/2020 20:00	0.3	11.5	2,091.3	0.2	0.9	1	1	1
04/28/2020 21:00	3.4	12.8	1,584.4	0.0	8.8	1	0	1
04/28/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/28/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	9.4	13.4	1,554.6	0.2	122.4 #	9 #	21 #	6 #
Minimum:	0.0	11.5	438.5	0.2	0.0	0	0	0
Maximum:	57.9	17.6	2,091.3	0.2	68.1	1	1	1
%SI	62.50	62.50	62.50	87.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/29/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/29/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/29/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/29/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/29/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/29/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/29/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	8 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
04/30/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/30/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/30/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/30/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/30/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/30/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/30/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
04/30/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	7 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/04/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/05/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/07/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/10/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/11/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/13/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/14/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/15/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/17/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/18/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/19/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/20/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/21/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/23/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 10:00	160.9	18.3	2,022.9	0.0	777.1 *	1	0	0
05/26/2020 11:00	38.2	20.0	2,014.1	0.0	135.5	1	0	0
05/26/2020 12:00	14.9	17.3	2,025.6	0.0	110.7	1	0	0
05/26/2020 13:00	12.6	17.2	2,025.8	0.0	91.1	1	0	0
05/26/2020 14:00	26.7	15.9	2,088.3	0.0	147.3	1	0	0
05/26/2020 15:00	26.8	16.4	2,086.1	0.0	54.2	1	0	0
05/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	46.7	17.5	2,043.8	0.0	1,315.9 #	6 #	0 #	0 #
Minimum:	12.6	15.9	2,014.1	0.0	54.2	0	0	0
Maximum:	160.9	20.0	2,088.3	0.0	777.1	1	0	0
%SI	75.00	75.00	75.00	100.00	75.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/27/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/27/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	2 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/28/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 12:00	100.7	0.0	2,033.2	0.0	47.9	1	0	0
05/28/2020 13:00	24.0	0.0	2,037.2	0.0	30.9	1	0	0
05/28/2020 14:00	30.7	0.0	2,093.7	0.0	40.6	1	0	0
05/28/2020 15:00	14.9	0.0	2,081.8	0.0	19.6	1	0	0
05/28/2020 16:00	0.0	0.0	2,094.2	0.0	0.0	1	0	0
05/28/2020 17:00	0.0	14.0	2,024.2	0.0	0.0	1	0	0
05/28/2020 18:00	0.0	13.9	2,047.5	0.0	0.0	1	0	0
05/28/2020 19:00	0.0	14.1	2,052.1	0.0	0.0	1	0	0
05/28/2020 20:00	0.0	14.1	2,056.2	0.0	0.0	1	0	0
05/28/2020 21:00	0.0	14.1	2,060.5	0.0	0.0	1	1	0
05/28/2020 22:00	0.0	14.1	2,058.2	0.0	0.0	1	1	0
05/28/2020 23:00	0.0	14.0	2,056.5	0.0	0.0	1	1	0
Average/Sum#:	14.2	14.0	2,057.9	0.0	0.0 #	12 #	3 #	0 #
Minimum:	0.0	13.9	2,024.2	0.0	0.0	0	0	0
Maximum:	100.7	14.1	2,094.2	0.0	0.0	1	1	0
%SI	50.00	70.83	50.00	79.17	70.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/29/2020 00:00	0.0	13.9	2,057.9	0.0	0.0	1	1	0
05/29/2020 01:00	4.9	14.6	2,063.9	0.0	15.5	1	0	0
05/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	2.5	14.3	2,060.9	0.0	15.5 #	2 #	2 #	0 #
Minimum:	0.0	13.9	2,057.9	0.0	0.0	0	0	0
Maximum:	4.9	14.6	2,063.9	0.0	15.5	1	1	0
%SI	91.67	91.67	91.67	95.83	91.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/30/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/30/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/30/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/30/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/30/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/30/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/30/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/30/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/30/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/30/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/30/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/30/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/30/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/30/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/30/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/30/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	16 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
05/31/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/31/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/31/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/31/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/31/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/31/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/31/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/31/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/31/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/31/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/31/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/31/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/31/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
05/31/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	14 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/01/2020 12:00	118.3	19.0	2,017.0	0.0	331.7	1	1	0
06/01/2020 13:00	37.4	17.3	2,026.3	0.0	202.9	1	1	0
06/01/2020 14:00	16.0	16.3	2,052.5	0.0	59.4	1	1	0
06/01/2020 15:00	0.0	14.0	2,047.6	0.0	0.0	1	1	1
06/01/2020 16:00	0.0	14.2	2,069.4	0.0	0.0	1	1	0
06/01/2020 17:00	0.0	14.1	2,087.4	0.0	0.0	1	1	0
06/01/2020 18:00	0.0	14.1	2,091.8	0.0	0.0	1	1	0
06/01/2020 19:00	0.0	14.1	2,067.0	0.0	0.0	1	1	0
06/01/2020 20:00	0.0	14.1	2,071.7	0.0	0.0	1	1	0
06/01/2020 21:00	0.0	14.1	2,073.3	0.0	0.0	1	1	0
06/01/2020 22:00	0.0	14.2	2,086.3	0.0	0.0	1	1	0
06/01/2020 23:00	0.0	14.1	2,068.4	0.0	0.0	1	1	0
Average/Sum#:	14.3	15.0	2,063.2	0.0	594.0 #	12 #	24 #	1 #
Minimum:	0.0	14.0	2,017.0	0.0	0.0	0	1	0
Maximum:	118.3	19.0	2,091.8	0.0	331.7	1	1	1
%SI	50.00	50.00	50.00	70.83	50.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/02/2020 00:00	0.0	14.1	2,087.7	0.0	0.0	1	1	0
06/02/2020 01:00	0.0	14.1	2,080.2	0.0	0.0	1	1	0
06/02/2020 02:00	0.0	14.1	2,070.6	0.0	0.0	1	1	0
06/02/2020 03:00	0.0	14.1	2,061.3	0.0	0.0	1	1	0
06/02/2020 04:00	0.0	14.1	2,065.5	0.0	0.0	1	1	0
06/02/2020 05:00	0.0	14.1	2,053.2	0.0	0.0	1	1	0
06/02/2020 06:00	0.0	14.1	2,060.3	0.0	0.0	1	1	0
06/02/2020 07:00	0.0	14.1	2,070.5	0.0	0.0	1	1	0
06/02/2020 08:00	0.0	14.1	2,061.8	0.0	0.0	1	1	0
06/02/2020 09:00	0.0	14.1	2,083.5	0.0	0.0	1	1	0
06/02/2020 10:00	0.0	14.1	2,060.0	0.0	0.0	1	1	0
06/02/2020 11:00	0.0	14.2	2,035.2	0.0	0.0	1	1	0
06/02/2020 12:00	0.0	14.0	2,067.7	0.0	0.0	1	1	1
06/02/2020 13:00	0.3	12.1	2,426.9	0.1	1.1	1	1	1
06/02/2020 14:00	0.2	11.7	2,488.6	0.1	0.7	1	1	1
06/02/2020 15:00	0.1	11.7	2,504.8	0.1	0.4	1	1	1
06/02/2020 16:00	0.1	11.8	2,500.3	0.1	0.4	1	1	1
06/02/2020 17:00	0.1	12.1	2,418.5	0.1	0.4	1	1	1
06/02/2020 18:00	0.1	12.1	2,455.8	0.1	0.4	1	1	1
06/02/2020 19:00	0.2	12.1	2,434.3	0.1	0.7	1	1	1
06/02/2020 20:00	0.3	12.1	2,435.2	0.1	1.1	1	1	1
06/02/2020 21:00	0.2	12.2	2,419.4	0.1	0.7	1	1	1
06/02/2020 22:00	0.2	12.2	2,404.9	0.1	0.7	1	1	1
06/02/2020 23:00	0.2	12.2	2,401.3	0.1	0.7	1	1	1
Average/Sum#:	0.1	13.2	2,239.5	0.0	7.3 #	24 #	24 #	12 #
Minimum:	0.0	11.7	2,035.2	0.0	0.0	1	1	0
Maximum:	0.3	14.2	2,504.8	0.1	1.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/03/2020 00:00	0.2	12.3	2,377.1	0.1	0.7	1	1	1
06/03/2020 01:00	0.0	14.1	2,057.7	0.1	0.0	1	1	0
06/03/2020 02:00	0.0	14.1	2,052.1	0.0	0.0	1	1	0
06/03/2020 03:00	0.0	14.1	2,042.6	0.0	0.0	1	1	0
06/03/2020 04:00	0.0	14.1	2,059.3	0.0	0.0	1	1	0
06/03/2020 05:00	0.0	14.1	2,064.3	0.0	0.0	1	1	0
06/03/2020 06:00	0.0	14.1	2,036.7	0.0	0.0	1	1	0
06/03/2020 07:00	0.0	14.1	2,047.9	0.0	0.0	1	1	0
06/03/2020 08:00	0.0	14.1	2,101.9	0.0	0.0	1	1	0
06/03/2020 09:00	0.0	14.1	2,056.4	0.0	0.0	1	1	0
06/03/2020 10:00	0.0	14.0	2,052.4	0.0	0.0	1	1	1
06/03/2020 11:00	0.6	12.2	2,392.3	0.1	2.2	1	1	1
06/03/2020 12:00	0.4	11.6	2,486.0	0.2	1.4	1	1	1
06/03/2020 13:00	0.3	11.6	2,501.5	0.3	1.1	1	1	1
06/03/2020 14:00	0.2	11.6	2,489.1	0.2	0.7	1	1	1
06/03/2020 15:00	0.2	11.6	2,453.6	0.1	0.7	1	1	1
06/03/2020 16:00	0.2	11.6	2,481.4	0.1	0.7	1	1	1
06/03/2020 17:00	0.3	11.6	2,482.6	0.1	1.1	1	1	1
06/03/2020 18:00	0.4	11.8	2,462.2	0.2	1.4	1	1	1
06/03/2020 19:00	0.4	11.7	2,456.2	0.3	1.4	1	1	1
06/03/2020 20:00	0.5	12.0	2,415.4	0.3	1.8	1	1	1
06/03/2020 21:00	0.5	12.2	2,399.2	0.3	1.8	1	1	1
06/03/2020 22:00	0.5	12.3	2,373.6	0.3	1.8	1	1	1
06/03/2020 23:00	0.4	11.9	2,428.4	0.3	1.4	1	1	1
Average/Sum#:	0.2	12.8	2,282.1	0.1	18.2 #	24 #	24 #	15 #
Minimum:	0.0	11.6	2,036.7	0.0	0.0	1	1	0
Maximum:	0.6	14.1	2,501.5	0.3	2.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/04/2020 00:00	6.8	14.0	2,118.3	0.0	13.2	1	0	1
06/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 06:00	12.6	18.4	2,034.1	0.0	43.3	1	0	0
06/04/2020 07:00	21.0	15.8	2,079.3	0.0	113.1	1	0	0
06/04/2020 08:00	0.0	14.2	2,057.8	0.0	0.0	1	0	0
06/04/2020 09:00	0.0	14.2	2,053.6	0.0	0.0	1	0	0
06/04/2020 10:00	0.0	14.1	2,051.4	0.0	0.0	1	0	0
06/04/2020 11:00	0.0	14.2	2,044.8	0.0	0.0	1	0	0
06/04/2020 12:00	0.0	14.2	2,041.2	0.0	0.0	1	1	0
06/04/2020 13:00	0.0	14.1	2,064.5	0.0	0.0	1	1	1
06/04/2020 14:00	0.5	12.2	2,395.8	0.1	1.8	1	1	1
06/04/2020 15:00	0.4	11.8	2,469.1	0.2	1.4	1	1	1
06/04/2020 16:00	0.4	11.7	2,467.6	0.3	1.4	1	1	1
06/04/2020 17:00	0.4	11.7	2,470.8	0.3	1.4	1	1	1
06/04/2020 18:00	0.4	11.7	2,445.7	0.3	1.4	1	1	1
06/04/2020 19:00	0.5	11.9	2,418.1	0.3	1.8	1	1	1
06/04/2020 20:00	0.5	11.8	2,498.2	0.3	1.8	1	1	1
06/04/2020 21:00	0.4	11.7	2,468.9	0.3	1.4	1	1	1
06/04/2020 22:00	0.5	12.0	2,421.8	0.3	1.8	1	1	1
06/04/2020 23:00	0.5	12.2	2,382.8	0.3	1.8	1	1	1
Average/Sum#:	2.4	13.3	2,262.3	0.2	185.6 #	19 #	12 #	12 #
Minimum:	0.0	11.7	2,034.1	0.0	0.0	0	0	0
Maximum:	21.0	18.4	2,498.2	0.3	113.1	1	1	1
%SI	20.83	20.83	20.83	41.67	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/05/2020 00:00	6.7	14.2	2,086.7	0.0	14.6	1	0	1
06/05/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	6.7	14.2	2,086.7	0.0	14.6 #	1 #	0 #	1 #
Minimum:	6.7	14.2	2,086.7	0.0	14.6	0	0	0
Maximum:	6.7	14.2	2,086.7	0.0	14.6	1	0	1
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/07/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/08/2020 15:00	67.2	17.9	2,123.3	0.0	326.6	1	1	0
06/08/2020 16:00	21.1	16.3	2,024.2	0.0	122.6	1	1	0
06/08/2020 17:00	12.3	18.1	2,093.2	0.0	46.1	1	1	0
06/08/2020 18:00	7.7	14.6	2,349.7	0.0	37.9	1	1	0
06/08/2020 19:00	0.0	14.0	2,097.9	0.0	0.0	1	1	1
06/08/2020 20:00	0.7	12.8	2,264.5	0.0	2.6	1	1	1
06/08/2020 21:00	0.7	12.4	2,333.6	0.3	2.5	1	1	1
06/08/2020 22:00	0.7	12.6	2,318.9	0.5	2.6	1	1	1
06/08/2020 23:00	3.7	13.7	2,124.4	0.0	14.4	1	0	1
Average/Sum#:	12.7	14.7	2,192.2	0.4	555.3 #	9 #	10 #	5 #
Minimum:	0.0	12.4	2,024.2	0.3	0.0	0	0	0
Maximum:	67.2	18.1	2,349.7	0.5	326.6	1	1	1
%SI	62.50	62.50	62.50	91.67	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/09/2020 12:00	16.3	18.3	2,006.8	0.0	66.5	1	1	0
06/09/2020 13:00	15.5	17.5	1,994.2	0.0	48.0	1	1	0
06/09/2020 14:00	16.1	16.8	2,140.6	0.0	94.4	1	1	0
06/09/2020 15:00	0.0	14.0	2,140.5	0.0	0.0	1	1	0
06/09/2020 16:00	0.0	14.0	2,038.3	0.0	0.0	1	1	1
06/09/2020 17:00	0.7	12.4	2,336.5	0.0	2.5	1	1	1
06/09/2020 18:00	0.6	12.0	2,418.2	0.3	2.2	1	1	1
06/09/2020 19:00	0.6	11.9	2,431.1	0.4	2.1	1	1	1
06/09/2020 20:00	0.7	12.1	2,389.5	0.4	2.5	1	1	1
06/09/2020 21:00	0.7	12.3	2,363.6	0.5	2.5	1	1	1
06/09/2020 22:00	0.7	12.5	2,322.2	0.5	2.6	1	1	1
06/09/2020 23:00	7.6	14.2	2,103.2	0.0	14.8	1	0	1
Average/Sum#:	5.0	14.0	2,223.7	0.4	238.1 #	12 #	12 #	8 #
Minimum:	0.0	11.9	1,994.2	0.3	0.0	0	0	0
Maximum:	16.3	18.3	2,431.1	0.5	94.4	1	1	1
%SI	50.00	50.00	50.00	79.17	50.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/10/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/10/2020 10:00	16.6	17.7	2,008.6	0.0	96.3	1	1	0
06/10/2020 11:00	42.8	15.7	2,288.9	0.0	248.8	1	1	0
06/10/2020 12:00	5.0	14.2	2,052.4	0.0	20.2	1	1	0
06/10/2020 13:00	0.0	14.0	2,044.6	0.0	0.0	1	1	0
06/10/2020 14:00	0.0	13.9	2,093.0	0.0	0.0	1	1	1
06/10/2020 15:00	0.8	12.2	2,406.4	0.2	2.9	1	1	1
06/10/2020 16:00	0.6	11.6	2,701.4	0.3	2.3	1	1	1
06/10/2020 17:00	0.6	11.8	2,656.5	0.4	2.3	1	1	1
06/10/2020 18:00	0.6	11.7	2,569.2	0.4	2.2	1	1	1
06/10/2020 19:00	0.6	11.9	2,415.8	0.4	2.1	1	1	1
06/10/2020 20:00	0.6	12.0	2,406.3	0.4	2.1	1	1	1
06/10/2020 21:00	0.6	12.1	2,393.9	0.4	2.2	1	1	1
06/10/2020 22:00	0.7	12.4	2,303.2	0.4	2.5	1	1	1
06/10/2020 23:00	0.7	12.3	2,357.2	0.5	2.5	1	1	1
Average/Sum#:	5.0	13.1	2,335.5	0.4	386.4 #	14 #	15 #	10 #
Minimum:	0.0	11.6	2,008.6	0.2	0.0	0	0	0
Maximum:	42.8	17.7	2,701.4	0.5	248.8	1	1	1
%SI	41.67	41.67	41.67	62.50	41.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/11/2020 00:00	0.4	12.7	2,290.6	0.4	1.5	1	1	1
06/11/2020 01:00	0.3	12.6	2,300.1	0.3	1.1	1	1	1
06/11/2020 02:00	0.5	12.8	2,264.9	0.3	1.8	1	1	1
06/11/2020 03:00	0.5	12.6	2,305.9	0.3	1.8	1	1	1
06/11/2020 04:00	0.5	12.9	2,219.8	0.4	1.8	1	1	1
06/11/2020 05:00	0.0	13.8	2,044.7	0.3	0.0	1	1	0
06/11/2020 06:00	0.0	13.9	2,064.7	0.1	0.0	1	1	0
06/11/2020 07:00	0.0	13.8	2,038.9	0.0	0.0	1	1	0
06/11/2020 08:00	0.0	13.8	2,059.4	0.0	0.0	1	1	0
06/11/2020 09:00	0.0	13.8	2,005.3	0.0	0.0	1	1	0
06/11/2020 10:00	0.0	13.7	2,012.8	0.0	0.0	1	1	0
06/11/2020 11:00	0.0	14.0	2,020.5	0.0	0.0	1	1	0
06/11/2020 12:00	0.0	14.0	2,008.2	0.0	0.0	1	1	0
06/11/2020 13:00	0.0	14.1	2,013.0	0.0	0.0	1	1	0
06/11/2020 14:00	0.0	14.0	2,023.1	0.0	0.0	1	1	0
06/11/2020 15:00	0.0	14.0	1,999.1	0.0	0.0	1	1	0
06/11/2020 16:00	0.0	14.0	2,029.7	0.0	0.0	1	1	0
06/11/2020 17:00	0.0	14.0	2,024.1	0.0	0.0	1	1	1
06/11/2020 18:00	0.8	12.3	2,325.7	0.2	2.9	1	1	1
06/11/2020 19:00	0.5	11.6	2,452.8	0.3	1.7	1	1	1
06/11/2020 20:00	0.6	11.9	2,376.0	0.4	2.1	1	1	1
06/11/2020 21:00	0.6	12.2	2,358.4	0.4	2.1	1	1	1
06/11/2020 22:00	0.6	12.4	2,283.7	0.4	2.1	1	1	1
06/11/2020 23:00	7.6	14.4	2,062.6	0.0	15.3	1	0	1
Average/Sum#:	0.5	13.3	2,149.3	0.2	34.2 #	24 #	23 #	12 #
Minimum:	0.0	11.6	1,999.1	0.0	0.0	1	0	0
Maximum:	7.6	14.4	2,452.8	0.4	15.3	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/13/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/14/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/14/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/14/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/14/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/14/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/14/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/14/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/14/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/14/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	8 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/15/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/17/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 12:00	91.1	18.3	1,972.6	0.0	337.7	1	1	0
06/17/2020 13:00	16.4	17.4	1,978.3	0.0	122.4	1	1	0
06/17/2020 14:00	11.2	17.3	2,152.7	0.0	88.5	1	1	0
06/17/2020 15:00	13.3	15.9	2,192.9	0.0	77.0	1	1	0
06/17/2020 16:00	0.0	14.1	2,315.5	0.0	0.0	1	1	0
06/17/2020 17:00	0.0	13.9	2,356.2	0.0	0.0	1	1	1
06/17/2020 18:00	0.7	12.4	2,642.5	0.2	2.9	1	1	1
06/17/2020 19:00	0.6	11.8	2,801.8	0.3	2.4	1	1	1
06/17/2020 20:00	0.6	11.9	2,575.7	0.4	2.3	1	1	1
06/17/2020 21:00	0.6	12.2	2,434.5	0.4	2.2	1	1	1
06/17/2020 22:00	0.7	12.3	2,382.1	0.4	2.6	1	1	1
06/17/2020 23:00	6.9	14.4	2,091.5	0.0	14.7	1	0	1
Average/Sum#:	11.8	14.3	2,324.7	0.3	652.7 #	12 #	11 #	7 #
Minimum:	0.0	11.8	1,972.6	0.2	0.0	0	0	0
Maximum:	91.1	18.3	2,801.8	0.4	337.7	1	1	1
%SI	50.00	50.00	50.00	79.17	50.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/18/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/18/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/18/2020 11:00	14.1	18.0	1,999.5	0.0	57.8	1	1	0
06/18/2020 12:00	11.3	15.3	2,008.2	0.0	53.5	1	1	0
06/18/2020 13:00	0.0	14.0	2,074.3	0.0	0.0	1	1	0
06/18/2020 14:00	0.0	14.0	2,087.3	0.0	0.0	1	1	1
06/18/2020 15:00	0.8	12.5	2,325.2	0.2	2.9	1	1	1
06/18/2020 16:00	0.6	11.9	2,411.4	0.3	2.1	1	1	1
06/18/2020 17:00	0.6	11.9	2,541.7	0.5	2.2	1	1	1
06/18/2020 18:00	0.6	11.9	2,730.5	0.4	2.4	1	1	1
06/18/2020 19:00	0.6	11.9	2,755.7	0.4	2.4	1	1	1
06/18/2020 20:00	0.6	12.0	2,786.9	0.4	2.5	1	1	1
06/18/2020 21:00	0.6	12.1	2,604.6	0.4	2.3	1	1	1
06/18/2020 22:00	0.6	12.7	2,299.1	0.4	2.2	1	1	1
06/18/2020 23:00	12.9	15.8	2,016.9	0.0	16.9	1	0	0
Average/Sum#:	3.3	13.4	2,357.0	0.4	147.2 #	13 #	14 #	9 #
Minimum:	0.0	11.9	1,999.5	0.2	0.0	0	0	0
Maximum:	14.1	18.0	2,786.9	0.5	57.8	1	1	1
%SI	45.83	45.83	45.83	66.67	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/19/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/20/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	1 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/21/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/21/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/21/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/21/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/21/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/21/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/21/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/21/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/21/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/21/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/21/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/21/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/21/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/21/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/21/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/21/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/21/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/21/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/21/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/21/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/21/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/21/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/21/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	24 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	1	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/22/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/22/2020 09:00	84.7	17.9	1,984.6	0.0	444.0 *	1	1	0
06/22/2020 10:00	11.9	18.5	1,975.6	0.0	41.4	1	1	0
06/22/2020 11:00	33.0	16.2	2,021.1	0.0	187.4	1	1	0
06/22/2020 12:00	4.4	14.1	2,258.4	0.0	19.3	1	1	0
06/22/2020 13:00	0.0	13.9	2,346.7	0.0	0.0	1	1	1
06/22/2020 14:00	0.7	12.1	2,501.3	0.0	2.6	1	1	1
06/22/2020 15:00	0.6	11.7	2,428.2	0.3	2.1	1	1	1
06/22/2020 16:00	0.6	11.7	2,411.1	0.4	2.1	1	1	1
06/22/2020 17:00	0.6	11.8	2,419.0	0.4	2.1	1	1	1
06/22/2020 18:00	0.5	11.6	2,447.9	0.4	1.7	1	1	1
06/22/2020 19:00	0.5	11.5	2,762.0	0.3	1.9	1	1	1
06/22/2020 20:00	0.5	11.5	2,879.1	0.3	2.0	1	1	1
06/22/2020 21:00	0.6	11.7	2,785.1	0.3	2.4	1	1	1
06/22/2020 22:00	0.7	11.9	2,633.9	0.4	2.7	1	1	1
06/22/2020 23:00	0.7	12.5	2,681.4	0.5	3.0	1	1	1
Average/Sum#:	9.3	13.2	2,435.7	0.4	714.7 #	15 #	24 #	11 #
Minimum:	0.0	11.5	1,975.6	0.3	0.0	0	1	0
Maximum:	84.7	18.5	2,879.1	0.5	444.0	1	1	1
%SI	37.50	37.50	37.50	62.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/23/2020 00:00	8.6	14.3	2,464.3	0.0	20.4	1	0	1
06/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 07:00	4.8	19.5	174.2	0.0	1.0	1	0	0
06/23/2020 08:00	48.3	15.9	671.3	0.0	85.6	1	0	0
06/23/2020 09:00	0.3	14.0	1,348.9	0.0	0.8	1	0	0
06/23/2020 10:00	0.0	14.0	1,333.7	0.0	0.0	1	0	0
06/23/2020 11:00	0.0	14.0	1,429.7	0.0	0.0	1	0	0
06/23/2020 12:00	0.0	14.0	1,528.9	0.0	0.0	1	0	0
06/23/2020 13:00	0.0	13.9	1,481.3	0.0	0.0	1	0	0
06/23/2020 14:00	0.0	14.0	1,335.9	0.0	0.0	1	0	0
06/23/2020 15:00	0.0	13.8	1,623.7	0.0	0.0	1	1	1
06/23/2020 16:00	0.7	11.8	2,035.6	0.2	2.1	1	1	1
06/23/2020 17:00	0.6	11.6	2,069.4	0.3	1.8	1	1	1
06/23/2020 18:00	0.5	11.7	2,063.4	0.4	1.5	1	1	1
06/23/2020 19:00	0.5	11.6	2,091.1	0.3	1.5	1	1	1
06/23/2020 20:00	0.5	11.5	2,119.6	0.3	1.5	1	1	1
06/23/2020 21:00	0.6	11.7	2,077.4	0.3	1.8	1	1	1
06/23/2020 22:00	0.6	11.8	2,070.4	0.4	1.8	1	1	1
06/23/2020 23:00	0.6	11.8	2,067.6	0.4	1.8	1	1	1
Average/Sum#:	3.7	13.4	1,665.9	0.2	121.6 #	18 #	9 #	10 #
Minimum:	0.0	11.5	174.2	0.0	0.0	0	0	0
Maximum:	48.3	19.5	2,464.3	0.4	85.6	1	1	1
%SI	25.00	25.00	25.00	50.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/24/2020 00:00	0.6	12.5	1,967.1	0.4	1.9	1	1	1
06/24/2020 01:00	0.6	12.8	1,915.1	0.4	1.9	1	1	1
06/24/2020 02:00	0.6	12.8	1,908.8	0.4	1.9	1	1	1
06/24/2020 03:00	0.6	12.8	1,906.8	0.4	1.9	1	1	1
06/24/2020 04:00	0.7	12.4	1,990.9	0.4	2.2	1	1	1
06/24/2020 05:00	0.8	12.1	2,037.9	0.5	2.4	1	1	1
06/24/2020 06:00	0.8	12.5	1,930.3	0.5	2.4	1	1	1
06/24/2020 07:00	0.0	14.0	1,548.2	0.4	0.0	1	1	0
06/24/2020 08:00	0.0	14.0	1,545.0	0.2	0.0	1	1	0
06/24/2020 09:00	0.0	14.0	1,547.4	0.0	0.0	1	1	0
06/24/2020 10:00	0.0	14.0	1,501.9	0.0	0.0	1	1	0
06/24/2020 11:00	0.0	13.9	1,553.2	0.0	0.0	1	1	1
06/24/2020 12:00	0.8	12.0	2,025.2	0.2	2.4	1	1	1
06/24/2020 13:00	0.7	11.7	2,072.1	0.3	2.1	1	1	1
06/24/2020 14:00	0.6	11.6	2,077.9	0.4	1.8	1	1	1
06/24/2020 15:00	0.6	11.6	2,080.8	0.4	1.8	1	1	1
06/24/2020 16:00	0.6	11.6	2,073.8	0.4	1.8	1	1	1
06/24/2020 17:00	0.6	11.6	2,077.2	0.4	1.8	1	1	1
06/24/2020 18:00	0.6	11.5	2,090.3	0.4	1.8	1	1	1
06/24/2020 19:00	0.6	11.6	2,080.7	0.4	1.8	1	1	1
06/24/2020 20:00	0.6	11.6	2,083.2	0.4	1.8	1	1	1
06/24/2020 21:00	0.6	11.6	2,084.9	0.4	1.8	1	1	1
06/24/2020 22:00	0.7	11.7	2,060.9	0.4	2.1	1	1	1
06/24/2020 23:00	0.8	11.8	2,056.6	0.4	2.4	1	1	1
Average/Sum#:	0.5	12.4	1,925.7	0.3	38.0 #	24 #	24 #	20 #
Minimum:	0.0	11.5	1,501.9	0.0	0.0	1	1	0
Maximum:	0.8	14.0	2,090.3	0.5	2.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/25/2020 00:00	8.9	13.8	1,286.4	0.0	13.2	1	0	1
06/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/25/2020 12:00	25.8	18.6	293.8	0.0	9.6	1	1	0
06/25/2020 13:00	17.5	15.1	966.6	0.0	38.5	1	1	0
06/25/2020 14:00	0.0	14.1	1,280.4	0.0	0.0	1	1	0
06/25/2020 15:00	0.0	14.0	1,371.6	0.0	0.0	1	1	0
06/25/2020 16:00	0.0	14.1	1,313.9	0.0	0.0	1	1	0
06/25/2020 17:00	0.0	13.9	1,605.8	0.0	0.0	1	1	1
06/25/2020 18:00	0.7	11.8	2,029.5	0.2	2.1	1	1	1
06/25/2020 19:00	0.6	11.9	2,021.5	0.3	1.8	1	1	1
06/25/2020 20:00	0.6	12.0	1,984.7	0.4	1.8	1	1	1
06/25/2020 21:00	0.7	12.2	1,959.2	0.4	2.1	1	1	1
06/25/2020 22:00	6.8	13.4	1,442.5	0.0	12.6	1	0	1
06/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	5.1	13.7	1,463.0	0.2	81.7 #	12 #	12 #	7 #
Minimum:	0.0	11.8	293.8	0.0	0.0	0	0	0
Maximum:	25.8	18.6	2,029.5	0.4	38.5	1	1	1
%SI	50.00	50.00	50.00	75.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/26/2020 10:00	23.0	18.7	292.8	0.0	8.1	1	1	0
06/26/2020 11:00	22.7	15.3	868.5	0.0	46.5	1	1	0
06/26/2020 12:00	35.4	17.3	173.6	0.0	2.9	1	1	0
06/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/26/2020 16:00	19.1	17.3	469.4	0.0	20.7	1	1	0
06/26/2020 17:00	6.4	13.5	1,499.5	0.0	17.1	1	1	1
06/26/2020 18:00	0.5	11.5	2,073.3	0.0	1.5	1	1	1
06/26/2020 19:00	0.5	11.4	2,088.2	0.0	1.5	1	1	1
06/26/2020 20:00	0.4	11.5	2,085.8	0.3	1.2	1	1	1
06/26/2020 21:00	0.4	11.8	2,062.5	0.3	1.2	1	1	1
06/26/2020 22:00	0.7	12.3	1,952.1	0.4	2.1	1	1	1
06/26/2020 23:00	0.0	13.6	1,444.4	0.3	0.0	1	1	1
Average/Sum#:	9.9	14.0	1,364.6	0.3	102.8 #	11 #	17 #	7 #
Minimum:	0.0	11.4	173.6	0.3	0.0	0	0	0
Maximum:	35.4	18.7	2,088.2	0.4	46.5	1	1	1
%SI	54.17	54.17	54.17	83.33	54.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/27/2020 00:00	4.7	14.5	1,044.5	0.0	7.6	1	0	0
06/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	4.7	14.5	1,044.5	0.0	7.6 #	1 #	0 #	0 #
Minimum:	4.7	14.5	1,044.5	0.0	7.6	0	0	0
Maximum:	4.7	14.5	1,044.5	0.0	7.6	1	0	0
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/28/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
06/30/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/30/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
06/30/2020 14:00	65.2	17.7	417.5	0.0	59.5	1	1	0
06/30/2020 15:00	21.4	15.8	737.2	0.0	40.9	1	1	0
06/30/2020 16:00	0.0	14.1	1,330.2	0.0	0.0	1	1	0
06/30/2020 17:00	0.0	14.0	1,512.0	0.0	0.0	1	1	1
06/30/2020 18:00	0.7	12.1	2,042.6	0.2	2.1	1	1	1
06/30/2020 19:00	0.6	11.8	2,098.6	0.3	1.8	1	1	1
06/30/2020 20:00	0.6	11.8	2,088.8	0.4	1.8	1	1	1
06/30/2020 21:00	0.6	12.0	2,067.6	0.4	1.8	1	1	1
06/30/2020 22:00	7.6	13.9	1,216.5	0.0	8.4	1	0	1
06/30/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	10.7	13.7	1,501.2	0.3	116.3 #	9 #	10 #	6 #
Minimum:	0.0	11.8	417.5	0.2	0.0	0	0	0
Maximum:	65.2	17.7	2,098.6	0.4	59.5	1	1	1
%SI	62.50	62.50	62.50	83.33	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/01/2020 00:00	0.0	13.9	1,350.6	0.0	0.0	1	1	0
04/01/2020 01:00	0.0	13.9	1,354.2	0.0	0.0	1	1	0
04/01/2020 02:00	0.0	13.9	1,349.8	0.0	0.0	1	1	0
04/01/2020 03:00	0.0	13.8	1,592.9	0.0	0.0	1	1	0
04/01/2020 04:00	0.0	13.9	1,592.9	0.0	0.0	1	1	0
04/01/2020 05:00	0.0	13.9	1,581.7	0.0	0.0	1	1	0
04/01/2020 06:00	0.0	13.9	1,533.5	0.0	0.0	1	1	0
04/01/2020 07:00	0.0	13.9	1,612.1	0.0	0.0	1	1	0
04/01/2020 08:00	0.0	13.9	1,519.3	0.0	0.0	1	1	0
04/01/2020 09:00	0.0	13.9	1,439.4	0.0	0.0	1	1	0
04/01/2020 10:00	0.0	14.0	1,343.9	0.0	0.0	1	1	0
04/01/2020 11:00	0.0	14.0	1,318.4	0.0	0.0	1	1	0
04/01/2020 12:00	0.0	14.0	1,329.7	0.0	0.0	1	1	0
04/01/2020 13:00	0.0	14.0	1,505.8	0.0	0.0	1	1	0
04/01/2020 14:00	0.0	14.0	1,562.1	0.0	0.0	1	1	0
04/01/2020 15:00	0.0	13.9	1,642.9	0.0	0.0	1	1	0
04/01/2020 16:00	0.0	13.9	1,666.3	0.0	0.0	1	1	0
04/01/2020 17:00	0.0	13.9	1,607.3	0.0	0.0	1	1	1
04/01/2020 18:00	0.0	12.9	2,015.8	0.0	0.0	1	1	1
04/01/2020 19:00	0.0	12.3	2,142.4	0.0	0.0	1	1	1
04/01/2020 20:00	0.0	12.3	2,124.8	0.0	0.0	1	1	1
04/01/2020 21:00	0.0	12.3	2,123.4	0.0	0.0	1	1	1
04/01/2020 22:00	0.0	12.4	2,118.7	0.0	0.0	1	1	1
04/01/2020 23:00	0.0	12.5	2,069.3	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.6	1,645.7	0.0	0.0 #	24 #	24 #	7 #
Minimum:	0.0	12.3	1,318.4	0.0	0.0	1	1	0
Maximum:	0.0	14.0	2,142.4	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/02/2020 00:00	0.0	13.9	1,569.0	0.0	0.0	1	1	1
04/02/2020 01:00	0.0	13.9	1,538.5	0.0	0.0	1	1	0
04/02/2020 02:00	0.0	13.9	1,633.7	0.0	0.0	1	1	0
04/02/2020 03:00	0.0	13.9	1,697.6	0.0	0.0	1	1	0
04/02/2020 04:00	0.0	13.9	1,690.0	0.0	0.0	1	1	0
04/02/2020 05:00	0.0	13.9	1,594.2	0.0	0.0	1	1	0
04/02/2020 06:00	0.0	13.9	1,688.0	0.0	0.0	1	1	0
04/02/2020 07:00	0.0	13.9	1,642.4	0.0	0.0	1	1	0
04/02/2020 08:00	0.0	13.9	1,694.9	0.0	0.0	1	1	0
04/02/2020 09:00	0.0	13.9	1,685.9	0.0	0.0	1	1	0
04/02/2020 10:00	0.0	13.9	1,659.7	0.0	0.0	1	1	0
04/02/2020 11:00	0.0	13.9	1,574.7	0.0	0.0	1	1	0
04/02/2020 12:00	0.0	13.9	1,612.6	0.0	0.0	1	1	0
04/02/2020 13:00	0.0	14.0	1,670.6	0.0	0.0	1	1	0
04/02/2020 14:00	0.0	14.0	1,683.4	0.0	0.0	1	1	0
04/02/2020 15:00	0.0	14.0	1,681.6	0.0	0.0	1	1	0
04/02/2020 16:00	0.0	14.0	1,645.2	0.0	0.0	1	1	0
04/02/2020 17:00	0.0	13.9	1,634.0	0.0	0.0	1	1	1
04/02/2020 18:00	0.0	12.9	1,990.0	0.0	0.0	1	1	1
04/02/2020 19:00	0.0	12.7	2,050.3	0.0	0.0	1	1	1
04/02/2020 20:00	0.0	12.7	2,051.0	0.0	0.0	1	1	1
04/02/2020 21:00	5.3	14.4	1,219.3	0.0	6.2	1	0	1
04/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.2	13.8	1,677.6	0.0	6.2 #	22 #	21 #	6 #
Minimum:	0.0	12.7	1,219.3	0.0	0.0	0	0	0
Maximum:	5.3	14.4	2,051.0	0.0	6.2	1	1	1
%SI	8.33	8.33	8.33	12.50	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/03/2020 20:00	37.4	17.6	457.7	0.0	49.3	1	0	0
04/03/2020 21:00	9.1	17.1	520.6	0.0	16.5	1	0	0
04/03/2020 22:00	16.5	15.5	873.8	0.0	35.3	1	0	0
04/03/2020 23:00	0.0	13.9	1,546.0	0.0	0.0	1	1	0
Average/Sum#:	15.8	16.0	849.5	0.0	101.1 #	4 #	1 #	0 #
Minimum:	0.0	13.9	457.7	0.0	0.0	0	0	0
Maximum:	37.4	17.6	1,546.0	0.0	49.3	1	1	0
%SI	83.33	83.33	83.33	100.00	83.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/04/2020 00:00	0.0	13.9	1,617.2	0.0	0.0	1	1	0
04/04/2020 01:00	0.0	13.8	1,703.6	0.0	0.0	1	1	0
04/04/2020 02:00	0.0	13.9	1,457.2	0.0	0.0	1	1	0
04/04/2020 03:00	0.0	13.8	1,693.5	0.0	0.0	1	1	0
04/04/2020 04:00	0.0	13.8	1,672.0	0.0	0.0	1	1	0
04/04/2020 05:00	0.0	13.8	1,692.6	0.0	0.0	1	1	0
04/04/2020 06:00	0.0	13.8	1,672.4	0.0	0.0	1	1	0
04/04/2020 07:00	0.0	13.8	1,693.9	0.0	0.0	1	1	0
04/04/2020 08:00	0.0	13.8	1,682.5	0.0	0.0	1	1	0
04/04/2020 09:00	0.0	13.8	1,674.2	0.0	0.0	1	1	0
04/04/2020 10:00	0.0	13.8	1,652.7	0.0	0.0	1	1	0
04/04/2020 11:00	0.0	13.8	1,677.1	0.0	0.0	1	1	0
04/04/2020 12:00	0.0	13.8	1,690.6	0.0	0.0	1	1	0
04/04/2020 13:00	0.0	13.8	1,687.9	0.0	0.0	1	1	0
04/04/2020 14:00	0.0	13.8	1,698.3	0.0	0.0	1	1	0
04/04/2020 15:00	0.0	13.8	1,661.3	0.0	0.0	1	1	0
04/04/2020 16:00	0.0	13.8	1,691.4	0.0	0.0	1	1	0
04/04/2020 17:00	0.0	13.8	1,652.9	0.0	0.0	1	1	1
04/04/2020 18:00	0.0	12.7	2,001.5	0.0	0.0	1	1	1
04/04/2020 19:00	0.0	12.0	2,148.5	0.0	0.0	1	1	1
04/04/2020 20:00	0.0	12.1	2,126.3	0.0	0.0	1	1	1
04/04/2020 21:00	0.0	12.2	2,117.8	0.0	0.0	1	1	1
04/04/2020 22:00	0.0	12.2	2,111.9	0.0	0.0	1	1	1
04/04/2020 23:00	0.0	12.2	2,113.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.4	1,774.6	0.0	0.0 #	24 #	24 #	7 #
Minimum:	0.0	12.0	1,457.2	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,148.5	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/05/2020 00:00	0.0	12.2	2,107.3	0.0	0.0	1	1	1
04/05/2020 01:00	0.0	13.6	1,720.7	0.0	0.0	1	1	1
04/05/2020 02:00	0.0	13.8	1,675.4	0.0	0.0	1	1	0
04/05/2020 03:00	0.0	13.8	1,671.3	0.0	0.0	1	1	0
04/05/2020 04:00	0.0	13.8	1,669.7	0.0	0.0	1	1	0
04/05/2020 05:00	0.0	13.8	1,683.3	0.0	0.0	1	1	0
04/05/2020 06:00	0.0	13.8	1,673.0	0.0	0.0	1	1	0
04/05/2020 07:00	0.0	13.8	1,643.0	0.0	0.0	1	1	0
04/05/2020 08:00	0.0	13.8	1,682.6	0.0	0.0	1	1	0
04/05/2020 09:00	0.0	13.8	1,658.3	0.0	0.0	1	1	0
04/05/2020 10:00	0.0	13.8	1,641.6	0.0	0.0	1	1	0
04/05/2020 11:00	0.0	13.8	1,623.8	0.0	0.0	1	1	0
04/05/2020 12:00	0.0	13.8	1,589.3	0.0	0.0	1	1	0
04/05/2020 13:00	0.0	13.9	1,670.3	0.0	0.0	1	1	0
04/05/2020 14:00	0.0	13.9	1,668.0	0.0	0.0	1	1	0
04/05/2020 15:00	0.0	13.9	1,671.0	0.0	0.0	1	1	0
04/05/2020 16:00	0.0	13.4	1,790.9	0.0	0.0	1	1	1
04/05/2020 17:00	0.0	12.3	2,087.3	0.0	0.0	1	1	1
04/05/2020 18:00	0.0	12.4	2,066.7	0.0	0.0	1	1	1
04/05/2020 19:00	0.0	12.4	2,062.5	0.0	0.0	1	1	1
04/05/2020 20:00	0.0	12.4	2,073.7	0.0	0.0	1	1	1
04/05/2020 21:00	0.0	12.4	2,094.4	0.0	0.0	1	1	1
04/05/2020 22:00	0.0	12.5	2,067.6	0.0	0.0	1	1	1
04/05/2020 23:00	0.0	12.5	2,086.0	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.3	1,807.4	0.0	0.0 #	24 #	24 #	10 #
Minimum:	0.0	12.2	1,589.3	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,107.3	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/06/2020 00:00	0.0	12.4	2,092.2	0.0	0.0	1	1	1
04/06/2020 01:00	0.0	12.4	2,094.1	0.0	0.0	1	1	1
04/06/2020 02:00	0.0	12.3	2,111.2	0.0	0.0	1	1	1
04/06/2020 03:00	0.0	12.4	2,103.6	0.0	0.0	1	1	1
04/06/2020 04:00	0.0	12.6	2,066.0	0.0	0.0	1	1	1
04/06/2020 05:00	0.0	12.6	2,075.1	0.0	0.0	1	1	1
04/06/2020 06:00	0.0	12.5	2,092.5	0.0	0.0	1	1	1
04/06/2020 07:00	0.0	12.2	2,044.3	0.0	0.0	1	1	1
04/06/2020 08:00	0.0	0.0	1,661.0	0.0	0.0	1	1	0
04/06/2020 09:00	0.0	13.8	1,678.7	0.0	0.0	1	1	0
04/06/2020 10:00	0.0	13.8	1,688.8	0.0	0.0	1	1	0
04/06/2020 11:00	0.0	13.9	1,626.7	0.0	0.0	1	1	0
04/06/2020 12:00	0.0	0.0	1,620.2	0.0	0.0	1	1	0
04/06/2020 13:00	0.0	13.9	1,595.6	0.0	0.0	1	1	0
04/06/2020 14:00	0.0	13.9	1,664.5	0.0	0.0	1	1	0
04/06/2020 15:00	0.0	13.9	1,674.1	0.0	0.0	1	1	0
04/06/2020 16:00	0.0	13.9	1,556.8	0.0	0.0	1	1	1
04/06/2020 17:00	0.0	12.8	2,011.7	0.0	0.0	1	1	1
04/06/2020 18:00	0.0	12.6	2,038.7	0.0	0.0	1	1	1
04/06/2020 19:00	0.0	12.8	1,989.5	0.0	0.0	1	1	1
04/06/2020 20:00	0.0	12.6	2,030.5	0.0	0.0	1	1	1
04/06/2020 21:00	0.0	12.5	2,068.6	0.0	0.0	1	1	1
04/06/2020 22:00	0.0	12.5	2,068.9	0.0	0.0	1	1	1
04/06/2020 23:00	0.0	12.4	2,099.4	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.9	1,906.4	0.0	0.0 #	24 #	24 #	16 #
Minimum:	0.0	12.2	1,556.8	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,111.2	0.0	0.0	1	1	1
%SI	8.33	8.33	0.00	25.00	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/07/2020 00:00	0.0	12.7	2,038.6	0.0	0.0	1	1	1
04/07/2020 01:00	0.0	12.8	2,029.6	0.0	0.0	1	1	1
04/07/2020 02:00	0.0	12.8	2,030.8	0.0	0.0	1	1	1
04/07/2020 03:00	0.0	12.8	2,024.5	0.0	0.0	1	1	1
04/07/2020 04:00	0.0	12.8	2,023.2	0.0	0.0	1	1	1
04/07/2020 05:00	0.0	12.8	2,027.8	0.0	0.0	1	1	1
04/07/2020 06:00	0.0	13.0	1,965.8	0.0	0.0	1	1	1
04/07/2020 07:00	0.0	13.8	1,635.9	0.0	0.0	1	1	0
04/07/2020 08:00	0.0	13.8	1,647.1	0.0	0.0	1	1	0
04/07/2020 09:00	0.0	13.8	1,681.9	0.0	0.0	1	1	0
04/07/2020 10:00	0.0	13.9	1,681.1	0.0	0.0	1	1	0
04/07/2020 11:00	0.0	13.9	1,688.0	0.0	0.0	1	1	0
04/07/2020 12:00	0.0	13.9	1,682.6	0.0	0.0	1	1	0
04/07/2020 13:00	0.0	13.9	1,635.6	0.0	0.0	1	1	0
04/07/2020 14:00	0.0	13.9	1,618.0	0.0	0.0	1	1	0
04/07/2020 15:00	0.0	13.9	1,682.9	0.0	0.0	1	1	0
04/07/2020 16:00	0.0	13.9	1,690.6	0.0	0.0	1	1	0
04/07/2020 17:00	0.0	13.8	1,608.8	0.0	0.0	1	1	1
04/07/2020 18:00	0.0	12.8	1,988.2	0.0	0.0	1	1	1
04/07/2020 19:00	0.0	12.6	2,031.3	0.0	0.0	1	1	1
04/07/2020 20:00	0.0	12.3	2,101.4	0.0	0.0	1	1	1
04/07/2020 21:00	0.0	12.2	2,105.3	0.0	0.0	1	1	1
04/07/2020 22:00	0.0	12.3	2,107.4	0.0	0.0	1	1	1
04/07/2020 23:00	0.0	12.3	2,110.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.2	1,868.2	0.0	0.0 #	24 #	24 #	14 #
Minimum:	0.0	12.2	1,608.8	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,110.7	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/08/2020 00:00	0.0	12.5	2,014.5	0.0	0.0	1	1	1
04/08/2020 01:00	0.0	13.9	1,673.2	0.0	0.0	1	1	0
04/08/2020 02:00	0.0	13.9	1,643.2	0.0	0.0	1	1	0
04/08/2020 03:00	0.0	13.8	1,676.2	0.0	0.0	1	1	0
04/08/2020 04:00	0.0	13.9	1,634.5	0.0	0.0	1	1	0
04/08/2020 05:00	0.0	13.8	1,680.0	0.0	0.0	1	1	0
04/08/2020 06:00	0.0	13.8	1,690.4	0.0	0.0	1	1	0
04/08/2020 07:00	0.0	13.8	1,661.3	0.0	0.0	1	1	0
04/08/2020 08:00	0.0	13.8	1,687.0	0.0	0.0	1	1	0
04/08/2020 09:00	0.0	13.8	1,693.3	0.0	0.0	1	1	0
04/08/2020 10:00	0.0	13.8	1,685.3	0.0	0.0	1	1	0
04/08/2020 11:00	0.0	13.9	1,649.3	0.0	0.0	1	1	0
04/08/2020 12:00	0.0	13.9	1,692.2	0.0	0.0	1	1	0
04/08/2020 13:00	0.0	13.8	1,686.0	0.0	0.0	1	1	0
04/08/2020 14:00	0.0	13.8	1,693.5	0.0	0.0	1	1	0
04/08/2020 15:00	0.0	13.8	1,677.7	0.0	0.0	1	1	0
04/08/2020 16:00	0.0	13.8	1,675.0	0.0	0.0	1	1	0
04/08/2020 17:00	0.0	13.4	1,775.8	0.0	0.0	1	1	1
04/08/2020 18:00	0.0	12.2	2,086.7	0.0	0.0	1	1	1
04/08/2020 19:00	0.0	11.9	2,168.2	0.0	0.0	1	1	1
04/08/2020 20:00	0.0	12.1	2,129.7	0.0	0.0	1	1	1
04/08/2020 21:00	0.0	12.2	2,108.8	0.0	0.0	1	1	1
04/08/2020 22:00	0.0	12.2	2,108.0	0.0	0.0	1	1	1
04/08/2020 23:00	0.0	12.2	2,109.9	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.3	1,804.2	0.0	0.0 #	24 #	24 #	8 #
Minimum:	0.0	11.9	1,634.5	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,168.2	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/09/2020 00:00	0.0	12.2	2,117.4	0.0	0.0	1	1	1
04/09/2020 01:00	0.0	12.2	2,117.3	0.0	0.0	1	1	1
04/09/2020 02:00	0.0	12.2	2,114.3	0.0	0.0	1	1	1
04/09/2020 03:00	0.0	12.3	2,109.4	0.0	0.0	1	1	1
04/09/2020 04:00	0.0	12.4	2,074.3	0.0	0.0	1	1	1
04/09/2020 05:00	0.0	12.5	2,070.3	0.0	0.0	1	1	1
04/09/2020 06:00	0.0	12.3	2,106.2	0.0	0.0	1	1	1
04/09/2020 07:00	0.0	12.3	2,108.2	0.0	0.0	1	1	1
04/09/2020 08:00	0.0	12.3	2,105.7	0.0	0.0	1	1	1
04/09/2020 09:00	0.0	12.3	2,104.7	0.0	0.0	1	1	1
04/09/2020 10:00	0.0	12.3	2,099.8	0.0	0.0	1	1	1
04/09/2020 11:00	0.0	12.5	2,046.6	0.0	0.0	1	1	1
04/09/2020 12:00	0.0	12.3	2,078.1	0.0	0.0	1	1	1
04/09/2020 13:00	0.0	12.3	2,077.5	0.0	0.0	1	1	1
04/09/2020 14:00	0.0	12.4	2,061.4	0.0	0.0	1	1	1
04/09/2020 15:00	0.0	12.3	2,077.4	0.0	0.0	1	1	1
04/09/2020 16:00	0.0	12.3	2,090.4	0.0	0.0	1	1	1
04/09/2020 17:00	0.0	12.3	2,104.4	0.0	0.0	1	1	1
04/09/2020 18:00	0.0	12.2	2,110.7	0.0	0.0	1	1	1
04/09/2020 19:00	0.0	12.2	2,128.7	0.0	0.0	1	1	1
04/09/2020 20:00	0.0	12.1	2,131.3	0.0	0.0	1	1	1
04/09/2020 21:00	0.0	12.2	2,112.2	0.0	0.0	1	1	1
04/09/2020 22:00	0.0	12.3	2,095.0	0.0	0.0	1	1	1
04/09/2020 23:00	0.0	12.2	2,126.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.3	2,098.7	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.1	2,046.6	0.0	0.0	1	1	1
Maximum:	0.0	12.5	2,131.3	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/10/2020 00:00	0.0	12.3	2,115.9	0.0	0.0	1	1	1
04/10/2020 01:00	0.0	12.3	2,106.8	0.0	0.0	1	1	1
04/10/2020 02:00	0.0	12.3	2,105.4	0.0	0.0	1	1	1
04/10/2020 03:00	0.0	12.3	2,101.1	0.0	0.0	1	1	1
04/10/2020 04:00	0.0	12.4	2,073.4	0.0	0.0	1	1	1
04/10/2020 05:00	0.0	12.5	2,046.7	0.0	0.0	1	1	1
04/10/2020 06:00	0.0	12.3	2,101.4	0.0	0.0	1	1	1
04/10/2020 07:00	0.0	13.6	1,704.4	0.0	0.0	1	1	1
04/10/2020 08:00	0.0	13.8	1,560.8	0.0	0.0	1	1	0
04/10/2020 09:00	0.0	13.8	1,687.5	0.0	0.0	1	1	0
04/10/2020 10:00	0.0	13.9	1,660.7	0.0	0.0	1	1	0
04/10/2020 11:00	0.0	13.9	1,552.7	0.0	0.0	1	1	0
04/10/2020 12:00	0.0	13.9	1,669.7	0.0	0.0	1	1	0
04/10/2020 13:00	0.0	13.9	1,572.7	0.0	0.0	1	1	0
04/10/2020 14:00	0.0	13.9	1,604.9	0.0	0.0	1	1	0
04/10/2020 15:00	0.0	13.8	1,654.9	0.0	0.0	1	1	0
04/10/2020 16:00	0.0	13.8	1,662.2	0.0	0.0	1	1	0
04/10/2020 17:00	0.0	13.8	1,475.7	0.0	0.0	1	1	1
04/10/2020 18:00	0.0	12.4	2,043.5	0.0	0.0	1	1	1
04/10/2020 19:00	0.0	12.1	2,102.9	0.0	0.0	1	1	1
04/10/2020 20:00	0.0	12.3	2,077.9	0.0	0.0	1	1	1
04/10/2020 21:00	0.0	12.3	2,066.7	0.0	0.0	1	1	1
04/10/2020 22:00	0.0	12.4	2,062.4	0.0	0.0	1	1	1
04/10/2020 23:00	0.0	13.0	1,915.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.0	1,863.6	0.0	0.0 #	24 #	24 #	15 #
Minimum:	0.0	12.1	1,475.7	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,115.9	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/11/2020 00:00	0.0	13.8	1,616.2	0.0	0.0	1	1	0
04/11/2020 01:00	0.0	13.8	1,678.7	0.0	0.0	1	1	0
04/11/2020 02:00	0.0	13.8	1,680.0	0.0	0.0	1	1	0
04/11/2020 03:00	0.0	13.8	1,673.3	0.0	0.0	1	1	0
04/11/2020 04:00	0.0	13.8	1,667.0	0.0	0.0	1	1	0
04/11/2020 05:00	0.0	13.8	1,673.6	0.0	0.0	1	1	0
04/11/2020 06:00	0.0	13.8	1,605.9	0.0	0.0	1	1	0
04/11/2020 07:00	0.0	13.8	1,684.0	0.0	0.0	1	1	0
04/11/2020 08:00	0.0	13.8	1,670.0	0.0	0.0	1	1	0
04/11/2020 09:00	0.0	13.8	1,669.1	0.0	0.0	1	1	0
04/11/2020 10:00	0.0	13.8	1,672.7	0.0	0.0	1	1	0
04/11/2020 11:00	0.0	13.9	1,677.2	0.0	0.0	1	1	0
04/11/2020 12:00	0.0	13.9	1,569.7	0.0	0.0	1	1	0
04/11/2020 13:00	0.0	13.9	1,661.2	0.0	0.0	1	1	0
04/11/2020 14:00	0.0	13.8	1,674.0	0.0	0.0	1	1	0
04/11/2020 15:00	0.0	13.8	1,672.8	0.0	0.0	1	1	0
04/11/2020 16:00	0.0	13.8	1,691.6	0.0	0.0	1	1	0
04/11/2020 17:00	0.0	13.8	1,677.5	0.0	0.0	1	1	0
04/11/2020 18:00	0.0	13.8	1,578.4	0.0	0.0	1	1	1
04/11/2020 19:00	0.0	12.6	2,007.7	0.0	0.0	1	1	1
04/11/2020 20:00	0.0	12.4	2,050.8	0.0	0.0	1	1	1
04/11/2020 21:00	0.0	12.3	2,074.6	0.0	0.0	1	1	1
04/11/2020 22:00	0.0	12.5	2,040.2	0.0	0.0	1	1	1
04/11/2020 23:00	0.0	12.7	1,973.4	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.5	1,735.0	0.0	0.0 #	24 #	24 #	6 #
Minimum:	0.0	12.3	1,569.7	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,074.6	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/12/2020 00:00	0.0	13.8	1,661.9	0.0	0.0	1	1	0
04/12/2020 01:00	0.0	13.8	1,684.1	0.0	0.0	1	1	0
04/12/2020 02:00	0.0	13.8	1,681.4	0.0	0.0	1	1	0
04/12/2020 03:00	0.0	13.8	1,600.0	0.0	0.0	1	1	0
04/12/2020 04:00	0.0	13.8	1,673.2	0.0	0.0	1	1	0
04/12/2020 05:00	0.0	13.8	1,687.8	0.0	0.0	1	1	0
04/12/2020 06:00	0.0	13.8	1,635.1	0.0	0.0	1	1	0
04/12/2020 07:00	0.0	13.8	1,692.0	0.0	0.0	1	1	0
04/12/2020 08:00	0.0	13.8	1,694.7	0.0	0.0	1	1	0
04/12/2020 09:00	0.0	13.8	1,669.1	0.0	0.0	1	1	0
04/12/2020 10:00	0.0	13.8	1,651.1	0.0	0.0	1	1	0
04/12/2020 11:00	0.0	13.9	1,601.2	0.0	0.0	1	1	0
04/12/2020 12:00	0.0	13.9	1,672.7	0.0	0.0	1	1	0
04/12/2020 13:00	0.0	13.9	1,675.8	0.0	0.0	1	1	0
04/12/2020 14:00	0.0	13.9	1,687.8	0.0	0.0	1	1	0
04/12/2020 15:00	0.0	13.9	1,664.7	0.0	0.0	1	1	0
04/12/2020 16:00	0.0	13.9	1,683.1	0.0	0.0	1	1	0
04/12/2020 17:00	0.0	14.0	1,559.0	0.0	0.0	1	1	0
04/12/2020 18:00	0.0	14.0	1,614.7	0.0	0.0	1	1	0
04/12/2020 19:00	0.0	13.9	1,630.4	0.0	0.0	1	1	0
04/12/2020 20:00	0.0	13.9	1,638.7	0.0	0.0	1	1	0
04/12/2020 21:00	0.0	13.9	1,629.8	0.0	0.0	1	1	0
04/12/2020 22:00	0.0	13.9	1,623.8	0.0	0.0	1	1	0
04/12/2020 23:00	0.0	13.4	1,818.9	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.8	1,659.6	0.0	0.0 #	24 #	24 #	1 #
Minimum:	0.0	13.4	1,559.0	0.0	0.0	1	1	0
Maximum:	0.0	14.0	1,818.9	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/13/2020 00:00	0.0	12.5	2,028.5	0.0	0.0	1	1	1
04/13/2020 01:00	0.0	13.8	1,688.5	0.0	0.0	1	1	0
04/13/2020 02:00	0.0	13.8	1,690.3	0.0	0.0	1	1	0
04/13/2020 03:00	0.0	13.8	1,671.5	0.0	0.0	1	1	0
04/13/2020 04:00	0.0	13.8	1,637.1	0.0	0.0	1	1	0
04/13/2020 05:00	0.0	13.8	1,663.7	0.0	0.0	1	1	0
04/13/2020 06:00	0.0	13.9	1,678.0	0.0	0.0	1	1	0
04/13/2020 07:00	0.0	13.9	1,656.8	0.0	0.0	1	1	0
04/13/2020 08:00	0.0	13.9	1,669.6	0.0	0.0	1	1	0
04/13/2020 09:00	0.0	13.9	1,696.3	0.0	0.0	1	1	0
04/13/2020 10:00	0.0	13.9	1,692.0	0.0	0.0	1	1	0
04/13/2020 11:00	0.0	13.9	1,693.0	0.0	0.0	1	1	0
04/13/2020 12:00	0.0	13.9	1,673.5	0.0	0.0	1	1	0
04/13/2020 13:00	0.0	13.9	1,610.5	0.0	0.0	1	1	0
04/13/2020 14:00	0.0	13.9	1,677.2	0.0	0.0	1	1	0
04/13/2020 15:00	0.0	13.8	1,687.2	0.0	0.0	1	1	0
04/13/2020 16:00	0.0	13.8	1,656.5	0.0	0.0	1	1	0
04/13/2020 17:00	0.0	13.9	1,531.0	0.0	0.0	1	1	1
04/13/2020 18:00	0.1	12.8	2,011.3	0.0	0.3	1	1	1
04/13/2020 19:00	0.0	12.4	2,105.8	0.0	0.0	1	1	1
04/13/2020 20:00	0.0	12.4	2,096.9	0.0	0.0	1	1	1
04/13/2020 21:00	0.1	12.4	2,100.1	0.0	0.3	1	1	1
04/13/2020 22:00	0.0	12.6	2,074.2	0.0	0.0	1	1	1
04/13/2020 23:00	0.0	13.0	1,923.5	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.5	1,775.5	0.0	0.6 #	24 #	24 #	8 #
Minimum:	0.0	12.4	1,531.0	0.0	0.0	1	1	0
Maximum:	0.1	13.9	2,105.8	0.0	0.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/14/2020 00:00	0.0	13.9	1,725.2	0.0	0.0	1	1	0
04/14/2020 01:00	0.0	13.9	1,524.5	0.0	0.0	1	1	0
04/14/2020 02:00	0.0	13.9	1,630.9	0.0	0.0	1	1	0
04/14/2020 03:00	0.0	13.9	1,538.1	0.0	0.0	1	1	0
04/14/2020 04:00	0.0	13.9	1,638.1	0.0	0.0	1	1	0
04/14/2020 05:00	0.0	13.9	1,594.0	0.0	0.0	1	1	0
04/14/2020 06:00	0.0	13.9	1,674.9	0.0	0.0	1	1	0
04/14/2020 07:00	0.0	13.9	1,591.5	0.0	0.0	1	1	0
04/14/2020 08:00	0.0	13.9	1,641.7	0.0	0.0	1	1	0
04/14/2020 09:00	0.0	13.9	1,666.9	0.0	0.0	1	1	0
04/14/2020 10:00	0.0	14.0	1,685.4	0.0	0.0	1	1	0
04/14/2020 11:00	0.0	14.0	1,680.0	0.0	0.0	1	1	0
04/14/2020 12:00	0.0	14.0	1,565.2	0.0	0.0	1	1	0
04/14/2020 13:00	0.0	13.9	1,691.7	0.0	0.0	1	1	0
04/14/2020 14:00	0.0	13.9	1,673.2	0.0	0.0	1	1	0
04/14/2020 15:00	0.0	13.9	1,663.3	0.0	0.0	1	1	0
04/14/2020 16:00	0.0	14.0	1,593.8	0.0	0.0	1	1	0
04/14/2020 17:00	0.0	13.9	1,540.3	0.0	0.0	1	1	1
04/14/2020 18:00	0.1	12.6	2,056.3	0.0	0.3	1	1	1
04/14/2020 19:00	0.0	12.3	2,103.7	0.0	0.0	1	1	1
04/14/2020 20:00	0.1	12.4	2,089.4	0.1	0.3	1	1	1
04/14/2020 21:00	0.1	12.6	2,050.2	0.1	0.3	1	1	1
04/14/2020 22:00	0.1	12.4	2,083.8	0.1	0.3	1	1	1
04/14/2020 23:00	0.1	12.6	2,071.6	0.1	0.3	1	1	1
Average/Sum#:	0.0	13.6	1,740.6	0.0	1.5 #	24 #	24 #	7 #
Minimum:	0.0	12.3	1,524.5	0.0	0.0	1	1	0
Maximum:	0.1	14.0	2,103.7	0.1	0.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/15/2020 00:00	0.0	13.0	1,949.1	0.1	0.0	1	1	1
04/15/2020 01:00	0.0	13.9	1,595.0	0.0	0.0	1	1	0
04/15/2020 02:00	0.0	13.9	1,671.2	0.0	0.0	1	1	0
04/15/2020 03:00	0.0	13.9	1,580.3	0.0	0.0	1	1	0
04/15/2020 04:00	0.0	13.9	1,566.1	0.0	0.0	1	1	0
04/15/2020 05:00	0.0	13.9	1,682.5	0.0	0.0	1	1	0
04/15/2020 06:00	0.0	13.9	1,678.9	0.0	0.0	1	1	0
04/15/2020 07:00	0.0	13.9	1,653.1	0.0	0.0	1	1	0
04/15/2020 08:00	0.0	13.9	1,683.6	0.0	0.0	1	1	0
04/15/2020 09:00	0.0	13.9	1,686.0	0.0	0.0	1	1	0
04/15/2020 10:00	0.0	13.9	1,693.6	0.0	0.0	1	1	0
04/15/2020 11:00	0.0	13.9	1,693.0	0.0	0.0	1	1	0
04/15/2020 12:00	0.0	13.9	1,676.4	0.0	0.0	1	1	0
04/15/2020 13:00	0.0	13.8	1,693.1	0.0	0.0	1	1	0
04/15/2020 14:00	0.0	13.8	1,670.7	0.0	0.0	1	1	0
04/15/2020 15:00	0.0	13.8	1,630.0	0.0	0.0	1	1	0
04/15/2020 16:00	0.0	13.8	1,637.4	0.0	0.0	1	1	0
04/15/2020 17:00	0.0	13.9	1,517.0	0.0	0.0	1	1	1
04/15/2020 18:00	0.1	12.5	2,036.6	0.0	0.3	1	1	1
04/15/2020 19:00	0.0	12.1	2,117.0	0.0	0.0	1	1	1
04/15/2020 20:00	0.0	12.1	2,123.2	0.0	0.0	1	1	1
04/15/2020 21:00	0.0	12.3	2,075.0	0.0	0.0	1	1	1
04/15/2020 22:00	0.1	12.9	1,952.8	0.0	0.3	1	1	1
04/15/2020 23:00	0.0	13.0	1,912.5	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.5	1,757.3	0.0	0.6 #	24 #	24 #	8 #
Minimum:	0.0	12.1	1,517.0	0.0	0.0	1	1	0
Maximum:	0.1	13.9	2,123.2	0.1	0.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/16/2020 00:00	0.0	13.9	1,505.4	0.0	0.0	1	1	0
04/16/2020 01:00	0.0	13.9	1,494.2	0.0	0.0	1	1	0
04/16/2020 02:00	0.0	13.9	1,525.3	0.0	0.0	1	1	0
04/16/2020 03:00	0.0	13.9	1,492.3	0.0	0.0	1	1	0
04/16/2020 04:00	0.0	13.9	1,578.8	0.0	0.0	1	1	0
04/16/2020 05:00	0.0	13.9	1,668.8	0.0	0.0	1	1	0
04/16/2020 06:00	0.0	13.9	1,545.9	0.0	0.0	1	1	0
04/16/2020 07:00	0.0	13.9	1,649.8	0.0	0.0	1	1	0
04/16/2020 08:00	0.0	13.9	1,683.4	0.0	0.0	1	1	0
04/16/2020 09:00	0.0	13.9	1,669.2	0.0	0.0	1	1	0
04/16/2020 10:00	0.0	13.9	1,690.2	0.0	0.0	1	1	0
04/16/2020 11:00	0.0	13.9	1,666.2	0.0	0.0	1	1	0
04/16/2020 12:00	0.0	13.8	1,699.3	0.0	0.0	1	1	0
04/16/2020 13:00	0.0	13.8	1,684.4	0.0	0.0	1	1	0
04/16/2020 14:00	0.0	13.9	1,596.8	0.0	0.0	1	1	0
04/16/2020 15:00	0.0	13.9	1,636.6	0.0	0.0	1	1	0
04/16/2020 16:00	0.0	13.9	1,630.8	0.0	0.0	1	1	0
04/16/2020 17:00	0.0	13.9	1,563.7	0.0	0.0	1	1	1
04/16/2020 18:00	0.1	12.6	2,023.8	0.0	0.3	1	1	1
04/16/2020 19:00	0.0	12.1	2,111.7	0.0	0.0	1	1	1
04/16/2020 20:00	0.0	12.0	2,137.3	0.0	0.0	1	1	1
04/16/2020 21:00	0.0	12.1	2,111.1	0.0	0.0	1	1	1
04/16/2020 22:00	0.1	12.7	1,990.3	0.0	0.3	1	1	1
04/16/2020 23:00	0.1	12.9	1,924.2	0.1	0.3	1	1	1
Average/Sum#:	0.0	13.5	1,720.0	0.0	0.9 #	24 #	24 #	7 #
Minimum:	0.0	12.0	1,492.3	0.0	0.0	1	1	0
Maximum:	0.1	13.9	2,137.3	0.1	0.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/17/2020 00:00	0.0	13.9	1,450.7	0.1	0.0	1	1	0
04/17/2020 01:00	0.0	13.9	1,352.6	0.0	0.0	1	1	0
04/17/2020 02:00	0.0	13.9	1,337.4	0.0	0.0	1	1	0
04/17/2020 03:00	0.0	13.9	1,336.7	0.0	0.0	1	1	0
04/17/2020 04:00	0.0	13.9	1,312.9	0.0	0.0	1	1	0
04/17/2020 05:00	0.0	13.8	1,670.2	0.0	0.0	1	1	0
04/17/2020 06:00	0.0	13.8	1,638.7	0.0	0.0	1	1	0
04/17/2020 07:00	0.0	13.9	1,612.0	0.0	0.0	1	1	0
04/17/2020 08:00	0.0	13.9	1,674.4	0.0	0.0	1	1	0
04/17/2020 09:00	0.0	13.9	1,652.6	0.0	0.0	1	1	0
04/17/2020 10:00	0.0	13.9	1,562.0	0.0	0.0	1	1	0
04/17/2020 11:00	0.0	13.9	1,650.8	0.0	0.0	1	1	0
04/17/2020 12:00	0.0	14.0	1,461.9	0.0	0.0	1	1	0
04/17/2020 13:00	0.0	13.9	1,617.2	0.0	0.0	1	1	0
04/17/2020 14:00	0.0	13.8	1,677.0	0.0	0.0	1	1	0
04/17/2020 15:00	0.0	13.8	1,687.8	0.0	0.0	1	1	0
04/17/2020 16:00	0.0	13.8	1,655.5	0.0	0.0	1	1	0
04/17/2020 17:00	0.0	13.9	1,528.2	0.0	0.0	1	1	1
04/17/2020 18:00	0.1	12.6	2,026.7	0.0	0.3	1	1	1
04/17/2020 19:00	0.0	12.3	2,069.6	0.0	0.0	1	1	1
04/17/2020 20:00	0.0	12.4	2,063.9	0.0	0.0	1	1	1
04/17/2020 21:00	0.0	12.5	2,051.9	0.0	0.0	1	1	1
04/17/2020 22:00	0.0	12.5	2,068.5	0.0	0.0	1	1	1
04/17/2020 23:00	5.0	14.2	1,255.2	0.0	6.0	1	0	1
Average/Sum#:	0.2	13.6	1,642.3	0.0	6.3 #	24 #	23 #	7 #
Minimum:	0.0	12.3	1,255.2	0.0	0.0	1	0	0
Maximum:	5.0	14.2	2,069.6	0.1	6.0	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/18/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/18/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/19/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/19/2020 17:00	59.6	17.6	461.0	0.0	77.0	1	0	0
04/19/2020 18:00	10.4	17.1	521.3	0.0	18.8	1	0	0
04/19/2020 19:00	16.4	15.5	857.7	0.0	34.4	1	0	0
04/19/2020 20:00	0.0	13.9	1,383.7	0.0	0.0	1	1	0
04/19/2020 21:00	0.0	13.9	1,431.6	0.0	0.0	1	1	0
04/19/2020 22:00	0.0	13.9	1,346.6	0.0	0.0	1	1	0
04/19/2020 23:00	0.0	13.9	1,342.0	0.0	0.0	1	1	0
Average/Sum#:	12.3	15.1	1,049.1	0.0	130.2 #	7 #	4 #	0 #
Minimum:	0.0	13.9	461.0	0.0	0.0	0	0	0
Maximum:	59.6	17.6	1,431.6	0.0	77.0	1	1	0
%SI	70.83	70.83	70.83	91.67	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/20/2020 00:00	0.0	13.9	1,337.6	0.0	0.0	1	1	0
04/20/2020 01:00	0.0	13.9	1,343.6	0.0	0.0	1	1	0
04/20/2020 02:00	0.0	13.8	1,598.2	0.0	0.0	1	1	0
04/20/2020 03:00	0.0	13.8	1,479.3	0.0	0.0	1	1	0
04/20/2020 04:00	0.0	13.8	1,673.3	0.0	0.0	1	1	0
04/20/2020 05:00	0.0	13.8	1,685.2	0.0	0.0	1	1	0
04/20/2020 06:00	0.0	13.8	1,675.2	0.0	0.0	1	1	0
04/20/2020 07:00	0.0	13.8	1,687.9	0.0	0.0	1	1	0
04/20/2020 08:00	0.0	13.8	1,644.0	0.0	0.0	1	1	0
04/20/2020 09:00	0.0	13.8	1,590.5	0.0	0.0	1	1	0
04/20/2020 10:00	0.0	13.8	1,580.8	0.0	0.0	1	1	0
04/20/2020 11:00	0.0	13.8	1,682.8	0.0	0.0	1	1	0
04/20/2020 12:00	0.0	13.9	1,670.9	0.0	0.0	1	1	0
04/20/2020 13:00	0.0	13.9	1,680.5	0.0	0.0	1	1	0
04/20/2020 14:00	0.0	13.9	1,520.3	0.0	0.0	1	1	0
04/20/2020 15:00	0.0	13.9	1,656.3	0.0	0.0	1	1	0
04/20/2020 16:00	0.0	13.9	1,618.7	0.0	0.0	1	1	0
04/20/2020 17:00	0.0	13.9	1,539.4	0.0	0.0	1	1	1
04/20/2020 18:00	0.0	12.7	2,006.1	0.0	0.0	1	1	1
04/20/2020 19:00	0.0	12.5	2,053.3	0.0	0.0	1	1	1
04/20/2020 20:00	0.0	12.5	2,053.9	0.0	0.0	1	1	1
04/20/2020 21:00	0.0	12.5	2,058.5	0.0	0.0	1	1	1
04/20/2020 22:00	0.0	12.8	1,961.5	0.0	0.0	1	1	1
04/20/2020 23:00	12.0	15.8	577.8	0.0	4.1	1	0	0
Average/Sum#:	0.5	13.7	1,640.7	0.0	4.1 #	24 #	23 #	6 #
Minimum:	0.0	12.5	577.8	0.0	0.0	1	0	0
Maximum:	12.0	15.8	2,058.5	0.0	4.1	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/21/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 04:00	52.3	17.6	467.0	0.0	66.4	1	0	0
04/22/2020 05:00	12.6	17.1	525.0	0.0	23.0	1	0	0
04/22/2020 06:00	15.0	15.7	834.1	0.0	31.8	1	0	0
04/22/2020 07:00	0.0	13.7	1,788.3	0.0	0.0	1	1	0
04/22/2020 08:00	0.0	13.7	1,785.0	0.0	0.0	1	1	0
04/22/2020 09:00	0.0	13.9	1,349.8	0.0	0.0	1	1	0
04/22/2020 10:00	0.0	13.9	1,305.7	0.0	0.0	1	1	0
04/22/2020 11:00	0.0	13.9	1,517.6	0.0	0.0	1	1	0
04/22/2020 12:00	0.0	13.9	1,517.1	0.0	0.0	1	1	0
04/22/2020 13:00	15.5	16.3	404.9	0.0	3.2	1	0	0
04/22/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/22/2020 18:00	7.2	18.6	298.6	0.0	2.7	1	0	0
04/22/2020 19:00	17.3	15.7	840.9	0.0	36.9	1	0	0
04/22/2020 20:00	0.0	13.9	1,474.7	0.0	0.0	1	1	0
04/22/2020 21:00	0.0	13.9	1,540.1	0.0	0.0	1	1	0
04/22/2020 22:00	0.0	13.9	1,404.1	0.0	0.0	1	1	0
04/22/2020 23:00	0.0	13.9	1,348.9	0.0	0.0	1	1	0
Average/Sum#:	7.5	15.0	1,150.1	0.0	164.0 #	16 #	10 #	0 #
Minimum:	0.0	13.7	298.6	0.0	0.0	0	0	0
Maximum:	52.3	18.6	1,788.3	0.0	66.4	1	1	0
%SI	33.33	33.33	33.33	75.00	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/23/2020 00:00	0.0	13.9	1,345.6	0.0	0.0	1	1	0
04/23/2020 01:00	0.0	13.9	1,335.0	0.0	0.0	1	1	0
04/23/2020 02:00	15.3	16.7	332.1	0.0	2.7	1	0	0
04/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	5.1	14.8	1,004.2	0.0	2.7 #	3 #	2 #	0 #
Minimum:	0.0	13.9	332.1	0.0	0.0	0	0	0
Maximum:	15.3	16.7	1,345.6	0.0	2.7	1	1	0
%SI	87.50	87.50	87.50	91.67	87.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/24/2020 09:00	49.3	17.6	457.1	0.0	63.1	1	0	0
04/24/2020 10:00	9.6	17.1	522.5	0.0	17.4	1	0	0
04/24/2020 11:00	16.8	15.2	898.2	0.0	35.0	1	0	0
04/24/2020 12:00	0.0	14.0	1,374.1	0.0	0.0	1	1	0
04/24/2020 13:00	0.0	14.0	1,362.2	0.0	0.0	1	1	0
04/24/2020 14:00	0.0	14.0	1,520.8	0.0	0.0	1	1	0
04/24/2020 15:00	0.0	14.0	1,493.2	0.0	0.0	1	1	0
04/24/2020 16:00	0.0	13.9	1,525.7	0.0	0.0	1	1	0
04/24/2020 17:00	0.0	13.9	1,552.4	0.0	0.0	1	1	0
04/24/2020 18:00	0.0	12.7	1,922.8	0.0	0.0	1	1	1
04/24/2020 19:00	0.0	12.0	2,119.6	0.0	0.0	1	1	1
04/24/2020 20:00	0.0	12.1	2,105.9	0.0	0.0	1	1	1
04/24/2020 21:00	0.0	12.7	1,953.0	0.0	0.0	1	1	1
04/24/2020 22:00	3.3	14.6	1,024.9	0.0	4.3	1	0	0
04/24/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	5.6	14.1	1,416.6	0.0	119.8 #	14 #	10 #	4 #
Minimum:	0.0	12.0	457.1	0.0	0.0	0	0	0
Maximum:	49.3	17.6	2,119.6	0.0	63.1	1	1	1
%SI	41.67	41.67	41.67	66.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/27/2020 13:00	53.0	17.6	456.1	0.0	64.8	1	0	0
04/27/2020 14:00	18.6	16.2	635.3	0.0	33.2	1	0	0
04/27/2020 15:00	15.2	14.8	1,004.8	0.0	33.1	1	0	0
04/27/2020 16:00	0.0	13.9	1,428.7	0.0	0.0	1	1	0
04/27/2020 17:00	0.1	12.8	1,944.7	0.0	0.3	1	1	1
04/27/2020 18:00	0.1	12.6	1,980.3	0.1	0.3	1	1	1
04/27/2020 19:00	0.1	12.7	1,971.3	0.1	0.3	1	1	1
04/27/2020 20:00	0.1	12.8	1,931.4	0.1	0.3	1	1	1
04/27/2020 21:00	0.0	13.9	1,408.9	0.1	0.0	1	1	0
04/27/2020 22:00	0.0	13.9	1,419.0	0.0	0.0	1	1	0
04/27/2020 23:00	0.0	13.9	1,473.2	0.0	0.0	1	1	0
Average/Sum#:	7.9	14.1	1,423.1	0.1	132.3 #	11 #	8 #	4 #
Minimum:	0.0	12.6	456.1	0.0	0.0	0	0	0
Maximum:	53.0	17.6	1,980.3	0.1	64.8	1	1	1
%SI	54.17	54.17	54.17	75.00	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/28/2020 00:00	0.0	13.9	1,385.0	0.0	0.0	1	1	0
04/28/2020 01:00	0.0	13.9	1,385.9	0.0	0.0	1	1	0
04/28/2020 02:00	0.0	13.9	1,385.2	0.0	0.0	1	1	0
04/28/2020 03:00	0.0	13.9	1,379.9	0.0	0.0	1	1	0
04/28/2020 04:00	0.0	13.9	1,377.6	0.0	0.0	1	1	0
04/28/2020 05:00	0.0	13.9	1,377.0	0.0	0.0	1	1	0
04/28/2020 06:00	0.0	13.9	1,379.5	0.0	0.0	1	1	0
04/28/2020 07:00	0.0	13.9	1,392.6	0.0	0.0	1	1	0
04/28/2020 08:00	0.0	13.9	1,397.6	0.0	0.0	1	1	0
04/28/2020 09:00	0.0	13.9	1,385.3	0.0	0.0	1	1	0
04/28/2020 10:00	0.0	13.9	1,367.7	0.0	0.0	1	1	0
04/28/2020 11:00	0.0	13.9	1,368.7	0.0	0.0	1	1	0
04/28/2020 12:00	0.0	13.9	1,370.3	0.0	0.0	1	1	0
04/28/2020 13:00	0.0	13.9	1,511.2	0.0	0.0	1	1	0
04/28/2020 14:00	0.0	13.9	1,504.3	0.0	0.0	1	1	0
04/28/2020 15:00	0.0	13.9	1,541.3	0.0	0.0	1	1	0
04/28/2020 16:00	0.0	13.9	1,490.8	0.0	0.0	1	1	1
04/28/2020 17:00	0.0	12.0	2,083.9	0.0	0.0	1	1	1
04/28/2020 18:00	0.0	11.8	2,134.4	0.0	0.0	1	1	1
04/28/2020 19:00	0.0	11.8	2,135.0	0.0	0.0	1	1	1
04/28/2020 20:00	0.0	11.8	2,128.7	0.0	0.0	1	1	1
04/28/2020 21:00	3.1	13.0	1,625.0	0.0	8.4	1	0	1
04/28/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/28/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.1	13.5	1,550.3	0.0	8.4 #	22 #	21 #	6 #
Minimum:	0.0	11.8	1,367.7	0.0	0.0	0	0	0
Maximum:	3.1	13.9	2,135.0	0.0	8.4	1	1	1
%SI	8.33	8.33	8.33	12.50	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/29/2020 13:00	35.5	17.5	460.9	0.0	43.2	1	0	0
04/29/2020 14:00	30.0	15.3	726.6	0.0	51.4	1	0	0
04/29/2020 15:00	5.7	14.1	1,420.9	0.0	15.7	1	0	0
04/29/2020 16:00	0.0	13.9	1,379.1	0.0	0.0	1	1	0
04/29/2020 17:00	0.3	12.7	1,939.6	0.0	0.9	1	1	1
04/29/2020 18:00	0.3	12.5	1,979.0	0.1	0.9	1	1	1
04/29/2020 19:00	0.3	12.6	1,969.7	0.2	0.9	1	1	1
04/29/2020 20:00	0.3	12.7	1,930.5	0.2	0.9	1	1	1
04/29/2020 21:00	0.0	13.8	1,361.5	0.1	0.0	1	1	0
04/29/2020 22:00	0.0	13.9	1,344.5	0.1	0.0	1	1	0
04/29/2020 23:00	0.0	13.9	1,343.7	0.0	0.0	1	1	0
Average/Sum#:	6.6	13.9	1,441.5	0.1	113.9 #	11 #	8 #	4 #
Minimum:	0.0	12.5	460.9	0.0	0.0	0	0	0
Maximum:	35.5	17.5	1,979.0	0.2	51.4	1	1	1
%SI	54.17	54.17	54.17	75.00	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
04/30/2020 00:00	0.0	13.9	1,342.5	0.0	0.0	1	1	0
04/30/2020 01:00	0.0	13.9	1,342.3	0.0	0.0	1	1	0
04/30/2020 02:00	0.0	13.9	1,342.5	0.0	0.0	1	1	0
04/30/2020 03:00	0.0	13.9	1,343.3	0.0	0.0	1	1	0
04/30/2020 04:00	0.0	13.9	1,342.9	0.0	0.0	1	1	0
04/30/2020 05:00	0.0	13.8	1,344.9	0.0	0.0	1	1	0
04/30/2020 06:00	0.0	13.8	1,333.6	0.0	0.0	1	1	0
04/30/2020 07:00	21.2	16.6	348.8	0.0	3.9	1	0	0
04/30/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
04/30/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	2.7	14.2	1,217.6	0.0	3.9 #	8 #	7 #	0 #
Minimum:	0.0	13.8	348.8	0.0	0.0	0	0	0
Maximum:	21.2	16.6	1,344.9	0.0	3.9	1	1	0
%SI	66.67	66.67	66.67	70.83	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/03/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/04/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/04/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/05/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/06/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/07/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/07/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/08/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/09/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/10/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/10/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/11/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 16:00	0.0	21.0	0.2	0.0	0.0	1	0	0
05/11/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/11/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	21.0	0.2	0.0	0.0 #	1 #	0 #	0 #
Minimum:	0.0	21.0	0.2	0.0	0.0	0	0	0
Maximum:	0.0	21.0	0.2	0.0	0.0	1	0	0
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/12/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/13/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/13/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/14/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/14/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/15/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/16/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/17/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/17/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/18/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/18/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/19/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/19/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/20/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/20/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/21/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/22/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/23/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/24/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 08:00	129.4	0.0	387.2	0.0	10.5	1	0	0
05/27/2020 09:00	18.5	0.0	520.3	0.0	6.1	1	0	0
05/27/2020 10:00	9.6	0.0	516.8	0.0	3.1	1	0	0
05/27/2020 11:00	26.8	0.0	857.6	0.0	14.5	1	0	0
05/27/2020 12:00	0.0	0.0	1,388.5	0.0	0.0	1	1	0
05/27/2020 13:00	0.0	13.8	1,455.2	0.0	0.0	1	1	0
05/27/2020 14:00	10.8	15.5	723.2	0.0	5.3	1	0	0
05/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/27/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	27.9	14.7	835.5	0.0	5.3 #	7 #	2 #	0 #
Minimum:	0.0	13.8	387.2	0.0	0.0	0	0	0
Maximum:	129.4	15.5	1,455.2	0.0	5.3	1	1	0
%SI	70.83	91.67	70.83	100.00	91.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/28/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/28/2020 18:00	111.9	19.3	200.0	0.0	31.4	1	0	0
05/28/2020 19:00	34.1	16.4	590.8	0.0	59.1	1	0	0
05/28/2020 20:00	3.9	14.0	1,407.0	0.0	10.5	1	0	0
05/28/2020 21:00	0.0	13.7	1,638.8	0.0	0.0	1	1	0
05/28/2020 22:00	0.0	13.8	1,619.8	0.0	0.0	1	1	0
05/28/2020 23:00	0.0	13.8	1,613.1	0.0	0.0	1	1	1
Average/Sum#:	25.0	15.2	1,178.3	0.0	101.0 #	6 #	3 #	1 #
Minimum:	0.0	13.7	200.0	0.0	0.0	0	0	0
Maximum:	111.9	19.3	1,638.8	0.0	59.1	1	1	1
%SI	75.00	75.00	75.00	95.83	75.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/29/2020 00:00	0.0	13.3	1,693.2	0.0	0.0	1	1	1
05/29/2020 01:00	4.1	14.4	1,259.5	0.0	7.7	1	0	0
05/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/29/2020 20:00	41.9	17.7	430.4	0.0	39.4	1	0	0
05/29/2020 21:00	32.6	15.7	696.4	0.0	57.7	1	0	0
05/29/2020 22:00	22.0	14.8	1,015.5	0.0	48.4	1	0	0
05/29/2020 23:00	0.0	13.9	1,381.9	0.0	0.0	1	1	0
Average/Sum#:	16.8	15.0	1,079.5	0.0	153.2 #	6 #	2 #	1 #
Minimum:	0.0	13.3	430.4	0.0	0.0	0	0	0
Maximum:	41.9	17.7	1,693.2	0.0	57.7	1	1	1
%SI	75.00	75.00	75.00	95.83	75.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/30/2020 00:00	0.0	13.9	1,373.6	0.0	0.0	1	1	0
05/30/2020 01:00	0.0	13.9	1,371.1	0.0	0.0	1	1	0
05/30/2020 02:00	0.0	13.9	1,370.2	0.0	0.0	1	1	0
05/30/2020 03:00	0.0	13.8	1,371.0	0.0	0.0	1	1	0
05/30/2020 04:00	0.0	13.8	1,376.6	0.0	0.0	1	1	0
05/30/2020 05:00	0.0	13.8	1,379.5	0.0	0.0	1	1	0
05/30/2020 06:00	0.0	13.8	1,383.6	0.0	0.0	1	1	0
05/30/2020 07:00	0.0	13.8	1,369.8	0.0	0.0	1	1	0
05/30/2020 08:00	14.2	16.3	397.2	0.0	2.8	1	0	0
05/30/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/30/2020 13:00	1.4	20.0	116.6	0.0	0.3	1	0	0
05/30/2020 14:00	29.5	16.1	668.2	0.0	54.2	1	0	0
05/30/2020 15:00	0.0	13.9	1,392.1	0.0	0.0	1	0	0
05/30/2020 16:00	0.0	13.9	1,377.8	0.0	0.0	1	1	0
05/30/2020 17:00	0.0	13.9	1,395.1	0.0	0.0	1	1	0
05/30/2020 18:00	0.0	12.9	1,949.1	0.0	0.0	1	1	1
05/30/2020 19:00	0.0	12.8	1,962.9	0.0	0.0	1	1	1
05/30/2020 20:00	0.0	12.8	1,942.5	0.0	0.0	1	1	1
05/30/2020 21:00	0.0	0.0	1,384.2	0.0	0.0	1	1	0
05/30/2020 22:00	0.0	0.0	1,376.4	0.0	0.0	1	1	0
05/30/2020 23:00	0.2	13.9	1,374.3	0.0	0.5	1	1	0
Average/Sum#:	2.5	14.3	1,316.6	0.0	57.8 #	20 #	16 #	3 #
Minimum:	0.0	12.8	116.6	0.0	0.0	0	0	0
Maximum:	29.5	20.0	1,962.9	0.0	54.2	1	1	1
%SI	25.00	25.00	16.67	58.33	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
05/31/2020 00:00	0.2	13.9	1,373.7	0.0	0.5	1	1	0
05/31/2020 01:00	0.2	13.9	1,373.2	0.2	0.5	1	1	0
05/31/2020 02:00	0.2	13.9	1,373.5	0.2	0.5	1	1	0
05/31/2020 03:00	0.2	13.9	1,373.6	0.2	0.5	1	1	0
05/31/2020 04:00	0.2	13.9	1,375.0	0.2	0.5	1	1	0
05/31/2020 05:00	0.2	13.9	1,362.7	0.2	0.5	1	1	0
05/31/2020 06:00	0.0	0.0	388.5	0.0	0.0	1	0	0
05/31/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
05/31/2020 14:00	15.8	17.6	446.1	0.0	19.7	1	0	0
05/31/2020 15:00	13.7	15.1	1,010.2	0.0	31.5	1	0	0
05/31/2020 16:00	0.1	13.9	1,385.2	0.0	0.3	1	1	0
05/31/2020 17:00	0.1	13.9	1,389.8	0.0	0.3	1	1	0
05/31/2020 18:00	0.4	13.4	1,754.7	0.2	1.2	1	1	1
05/31/2020 19:00	0.7	12.8	1,952.1	0.3	2.2	1	1	1
05/31/2020 20:00	0.7	12.8	1,929.3	0.4	2.2	1	1	1
05/31/2020 21:00	0.2	13.9	1,416.2	0.4	0.5	1	1	0
05/31/2020 22:00	0.2	13.9	1,369.6	0.3	0.5	1	1	0
05/31/2020 23:00	0.2	13.9	1,367.6	0.2	0.5	1	1	0
Average/Sum#:	2.1	14.0	1,331.8	0.3	61.9 #	17 #	14 #	3 #
Minimum:	0.1	12.8	388.5	0.2	0.3	0	0	0
Maximum:	15.8	17.6	1,952.1	0.4	31.5	1	1	1
%SI	33.33	33.33	29.17	54.17	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/01/2020 00:00	0.3	13.9	1,369.5	0.2	0.8	1	1	0
06/01/2020 01:00	0.2	13.9	1,369.0	0.2	0.5	1	1	0
06/01/2020 02:00	0.3	13.9	1,367.5	0.3	0.8	1	1	0
06/01/2020 03:00	0.2	13.9	1,368.2	0.2	0.5	1	1	0
06/01/2020 04:00	0.2	13.9	1,355.8	0.2	0.5	1	1	0
06/01/2020 05:00	0.2	13.9	1,335.9	0.2	0.5	1	1	0
06/01/2020 06:00	0.3	13.9	1,341.8	0.2	0.8	1	1	0
06/01/2020 07:00	0.2	13.9	1,343.5	0.2	0.5	1	1	0
06/01/2020 08:00	0.2	13.9	1,345.5	0.2	0.5	1	1	0
06/01/2020 09:00	0.2	13.9	1,353.4	0.2	0.5	1	1	0
06/01/2020 10:00	0.2	13.9	1,356.4	0.2	0.5	1	1	0
06/01/2020 11:00	0.2	13.9	1,358.5	0.2	0.5	1	1	0
06/01/2020 12:00	0.2	13.9	1,383.5	0.2	0.5	1	1	0
06/01/2020 13:00	0.3	13.8	1,620.1	0.2	0.9	1	1	0
06/01/2020 14:00	0.3	13.7	1,683.4	0.2	0.9	1	1	0
06/01/2020 15:00	0.3	13.8	1,661.5	0.2	0.9	1	1	0
06/01/2020 16:00	0.3	13.9	1,524.9	0.2	0.9	1	1	0
06/01/2020 17:00	0.2	13.9	1,620.6	0.2	0.6	1	1	0
06/01/2020 18:00	0.2	13.9	1,540.2	0.2	0.6	1	1	0
06/01/2020 19:00	0.2	13.9	1,504.2	0.2	0.6	1	1	0
06/01/2020 20:00	0.2	14.0	1,511.0	0.2	0.6	1	1	0
06/01/2020 21:00	0.2	14.0	1,439.3	0.2	0.6	1	1	0
06/01/2020 22:00	0.2	14.0	1,344.4	0.2	0.5	1	1	0
06/01/2020 23:00	0.2	13.8	1,667.3	0.2	0.6	1	1	0
Average/Sum#:	0.2	13.9	1,448.6	0.2	15.1 #	24 #	24 #	0 #
Minimum:	0.2	13.7	1,335.9	0.2	0.5	1	1	0
Maximum:	0.3	14.0	1,683.4	0.3	0.9	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/02/2020 00:00	0.2	14.0	1,495.8	0.2	0.6	1	1	0
06/02/2020 01:00	0.2	13.9	1,515.5	0.2	0.6	1	1	0
06/02/2020 02:00	0.2	13.9	1,430.1	0.2	0.5	1	1	0
06/02/2020 03:00	0.2	13.9	1,538.0	0.2	0.6	1	1	0
06/02/2020 04:00	0.2	13.9	1,686.0	0.2	0.6	1	1	0
06/02/2020 05:00	0.2	13.9	1,665.8	0.2	0.6	1	1	0
06/02/2020 06:00	0.2	13.9	1,479.7	0.2	0.6	1	1	0
06/02/2020 07:00	0.2	13.9	1,379.4	0.2	0.5	1	1	0
06/02/2020 08:00	0.2	13.9	1,330.3	0.2	0.5	1	1	0
06/02/2020 09:00	0.2	13.9	1,510.8	0.2	0.6	1	1	0
06/02/2020 10:00	0.2	13.9	1,481.1	0.2	0.6	1	1	0
06/02/2020 11:00	0.1	13.9	1,310.5	0.2	0.2	1	1	0
06/02/2020 12:00	0.2	13.8	1,662.9	0.2	0.6	1	1	1
06/02/2020 13:00	0.5	12.2	2,058.6	0.2	1.6	1	1	1
06/02/2020 14:00	0.3	11.9	2,034.6	0.2	0.9	1	1	1
06/02/2020 15:00	0.2	11.9	2,027.2	0.2	0.6	1	1	1
06/02/2020 16:00	0.3	11.9	2,066.0	0.2	0.9	1	1	1
06/02/2020 17:00	0.5	12.1	2,060.7	0.2	1.5	1	1	1
06/02/2020 18:00	0.4	12.1	2,071.1	0.3	1.2	1	1	1
06/02/2020 19:00	0.4	12.1	2,067.4	0.3	1.2	1	1	1
06/02/2020 20:00	0.4	12.1	2,063.5	0.3	1.2	1	1	1
06/02/2020 21:00	0.4	12.2	2,051.7	0.3	1.2	1	1	1
06/02/2020 22:00	0.4	12.2	2,055.4	0.3	1.2	1	1	1
06/02/2020 23:00	0.5	12.2	2,053.4	0.3	1.6	1	1	1
Average/Sum#:	0.3	13.1	1,754.0	0.2	20.2 #	24 #	24 #	12 #
Minimum:	0.1	11.9	1,310.5	0.2	0.2	1	1	0
Maximum:	0.5	14.0	2,071.1	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/03/2020 00:00	0.4	12.3	2,028.9	0.3	1.2	1	1	1
06/03/2020 01:00	0.2	13.9	1,417.0	0.3	0.5	1	1	0
06/03/2020 02:00	0.2	13.9	1,376.3	0.2	0.5	1	1	0
06/03/2020 03:00	0.2	13.9	1,324.9	0.2	0.5	1	1	0
06/03/2020 04:00	0.2	13.8	1,656.2	0.2	0.6	1	1	0
06/03/2020 05:00	0.2	13.9	1,482.0	0.2	0.6	1	1	0
06/03/2020 06:00	0.2	13.9	1,364.2	0.2	0.5	1	1	0
06/03/2020 07:00	0.2	13.9	1,449.7	0.2	0.5	1	1	0
06/03/2020 08:00	0.2	13.9	1,487.7	0.2	0.6	1	1	0
06/03/2020 09:00	0.2	13.9	1,574.4	0.2	0.6	1	1	0
06/03/2020 10:00	0.3	13.9	1,501.2	0.2	0.8	1	1	1
06/03/2020 11:00	0.5	12.3	2,012.8	0.3	1.5	1	1	1
06/03/2020 12:00	0.3	11.9	2,066.2	0.3	0.9	1	1	1
06/03/2020 13:00	0.3	11.9	2,056.7	0.2	0.9	1	1	1
06/03/2020 14:00	0.3	11.9	2,053.7	0.2	0.9	1	1	1
06/03/2020 15:00	0.3	11.9	2,049.2	0.2	0.9	1	1	1
06/03/2020 16:00	0.3	11.9	2,048.2	0.2	0.9	1	1	1
06/03/2020 17:00	0.3	11.9	2,048.9	0.2	0.9	1	1	1
06/03/2020 18:00	0.3	11.9	2,061.8	0.2	0.9	1	1	1
06/03/2020 19:00	0.3	11.8	2,083.2	0.2	0.9	1	1	1
06/03/2020 20:00	0.4	12.1	2,044.4	0.2	1.2	1	1	1
06/03/2020 21:00	0.4	12.2	2,036.4	0.3	1.2	1	1	1
06/03/2020 22:00	0.4	12.3	2,032.4	0.3	1.2	1	1	1
06/03/2020 23:00	0.4	12.1	2,086.6	0.3	1.3	1	1	1
Average/Sum#:	0.3	12.8	1,806.0	0.2	20.5 #	24 #	24 #	15 #
Minimum:	0.2	11.8	1,324.9	0.2	0.5	1	1	0
Maximum:	0.5	13.9	2,086.6	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/04/2020 00:00	5.5	14.1	1,188.7	0.0	6.1	1	0	1
06/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/04/2020 10:00	13.2	17.9	407.5	0.0	10.2	1	0	0
06/04/2020 11:00	18.7	15.2	869.1	0.0	37.7	1	0	0
06/04/2020 12:00	0.2	13.9	1,557.5	0.0	0.6	1	1	0
06/04/2020 13:00	0.2	13.9	1,515.8	0.0	0.6	1	1	1
06/04/2020 14:00	0.5	12.1	2,028.5	0.2	1.5	1	1	1
06/04/2020 15:00	0.4	11.8	2,074.1	0.3	1.2	1	1	1
06/04/2020 16:00	0.4	11.8	2,078.8	0.3	1.2	1	1	1
06/04/2020 17:00	0.4	11.8	2,075.4	0.3	1.2	1	1	1
06/04/2020 18:00	0.4	11.8	2,072.2	0.3	1.2	1	1	1
06/04/2020 19:00	0.4	12.0	2,049.1	0.3	1.2	1	1	1
06/04/2020 20:00	0.4	11.9	2,065.6	0.3	1.2	1	1	1
06/04/2020 21:00	0.3	11.9	2,082.1	0.3	0.9	1	1	1
06/04/2020 22:00	0.4	12.1	2,061.2	0.3	1.2	1	1	1
06/04/2020 23:00	0.4	12.1	2,049.6	0.3	1.2	1	1	1
Average/Sum#:	2.8	13.0	1,745.0	0.3	67.2 #	15 #	12 #	12 #
Minimum:	0.2	11.8	407.5	0.2	0.6	0	0	0
Maximum:	18.7	17.9	2,082.1	0.3	37.7	1	1	1
%SI	37.50	37.50	37.50	58.33	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/05/2020 00:00	6.0	14.1	1,201.9	0.0	7.4	1	0	1
06/05/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	6.0	14.1	1,201.9	0.0	7.4 #	1 #	0 #	1 #
Minimum:	6.0	14.1	1,201.9	0.0	7.4	0	0	0
Maximum:	6.0	14.1	1,201.9	0.0	7.4	1	0	1
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/06/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/07/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/07/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/08/2020 09:00	93.9	17.9	418.2	0.0	74.3	1	0	0
06/08/2020 10:00	10.8	17.1	526.4	0.0	19.8	1	0	0
06/08/2020 11:00	11.2	16.9	556.0	0.0	20.6	1	0	0
06/08/2020 12:00	29.1	15.4	927.5	0.0	64.8	1	0	0
06/08/2020 13:00	0.2	13.9	1,360.3	0.0	0.5	1	1	0
06/08/2020 14:00	0.2	13.9	1,352.5	0.0	0.5	1	1	0
06/08/2020 15:00	0.2	13.9	1,534.9	0.2	0.6	1	1	0
06/08/2020 16:00	0.2	13.9	1,558.6	0.2	0.6	1	1	0
06/08/2020 17:00	0.3	13.7	1,693.4	0.2	0.9	1	1	0
06/08/2020 18:00	0.3	13.8	1,517.5	0.2	0.8	1	1	0
06/08/2020 19:00	0.3	13.8	1,705.9	0.2	1.0	1	1	1
06/08/2020 20:00	0.7	12.7	2,013.0	0.3	2.3	1	1	1
06/08/2020 21:00	0.6	12.3	2,088.5	0.4	1.9	1	1	1
06/08/2020 22:00	0.6	12.4	2,058.4	0.4	1.9	1	1	1
06/08/2020 23:00	3.6	13.6	1,572.8	0.0	10.2	1	0	1
Average/Sum#:	10.1	14.3	1,392.3	0.3	200.7 #	15 #	10 #	5 #
Minimum:	0.2	12.3	418.2	0.2	0.5	0	0	0
Maximum:	93.9	17.9	2,088.5	0.4	74.3	1	1	1
%SI	37.50	37.50	37.50	66.67	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/09/2020 08:00	13.4	17.6	429.7	0.0	12.2	1	0	0
06/09/2020 09:00	13.1	16.9	523.3	0.0	22.6	1	0	0
06/09/2020 10:00	21.1	15.0	921.1	0.0	43.5	1	0	0
06/09/2020 11:00	0.2	13.9	1,370.4	0.0	0.5	1	1	0
06/09/2020 12:00	0.2	13.9	1,361.9	0.0	0.5	1	1	0
06/09/2020 13:00	0.3	13.8	1,529.4	0.2	0.9	1	1	0
06/09/2020 14:00	0.4	13.8	1,560.0	0.2	1.2	1	1	0
06/09/2020 15:00	0.3	13.8	1,533.6	0.2	0.9	1	1	0
06/09/2020 16:00	0.3	13.8	1,511.4	0.2	0.8	1	1	1
06/09/2020 17:00	0.7	12.4	2,023.8	0.3	2.2	1	1	1
06/09/2020 18:00	0.5	12.0	2,088.7	0.3	1.5	1	1	1
06/09/2020 19:00	0.5	12.0	2,094.4	0.4	1.6	1	1	1
06/09/2020 20:00	0.6	12.1	2,066.3	0.3	1.9	1	1	1
06/09/2020 21:00	0.6	12.3	2,050.2	0.4	1.9	1	1	1
06/09/2020 22:00	0.6	12.4	2,019.4	0.4	1.9	1	1	1
06/09/2020 23:00	6.3	14.2	1,189.1	0.0	7.1	1	0	1
Average/Sum#:	3.7	13.7	1,517.0	0.3	101.2 #	16 #	12 #	8 #
Minimum:	0.2	12.0	429.7	0.2	0.5	0	0	0
Maximum:	21.1	17.6	2,094.4	0.4	43.5	1	1	1
%SI	33.33	33.33	33.33	58.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/10/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/10/2020 07:00	13.9	17.9	394.7	0.0	9.0	1	0	0
06/10/2020 08:00	21.9	14.8	1,015.9	0.0	48.2	1	0	0
06/10/2020 09:00	0.3	13.9	1,374.2	0.0	0.8	1	1	0
06/10/2020 10:00	0.3	13.9	1,390.4	0.0	0.8	1	1	0
06/10/2020 11:00	0.3	13.9	1,393.9	0.3	0.8	1	1	0
06/10/2020 12:00	0.3	13.9	1,397.6	0.3	0.8	1	1	0
06/10/2020 13:00	0.4	13.7	1,679.9	0.3	1.2	1	1	0
06/10/2020 14:00	0.5	13.6	1,608.4	0.3	1.5	1	1	1
06/10/2020 15:00	0.6	12.2	2,035.8	0.4	1.9	1	1	1
06/10/2020 16:00	0.5	11.8	2,113.4	0.4	1.5	1	1	1
06/10/2020 17:00	0.5	11.9	2,097.6	0.3	1.5	1	1	1
06/10/2020 18:00	0.5	11.8	2,102.5	0.3	1.5	1	1	1
06/10/2020 19:00	0.5	12.0	2,068.0	0.3	1.5	1	1	1
06/10/2020 20:00	0.5	12.0	2,079.4	0.3	1.5	1	1	1
06/10/2020 21:00	0.5	12.1	2,096.1	0.3	1.6	1	1	1
06/10/2020 22:00	0.6	12.4	2,028.6	0.3	1.9	1	1	1
06/10/2020 23:00	0.6	12.2	2,062.2	0.4	1.9	1	1	1
Average/Sum#:	2.5	13.2	1,702.3	0.3	77.9 #	17 #	15 #	10 #
Minimum:	0.3	11.8	394.7	0.3	0.8	0	0	0
Maximum:	21.9	17.9	2,113.4	0.4	48.2	1	1	1
%SI	29.17	29.17	29.17	45.83	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/11/2020 00:00	0.5	12.6	1,961.8	0.4	1.6	1	1	1
06/11/2020 01:00	0.4	12.6	1,951.3	0.4	1.2	1	1	1
06/11/2020 02:00	0.5	12.7	1,941.4	0.4	1.6	1	1	1
06/11/2020 03:00	0.5	12.5	1,991.8	0.4	1.6	1	1	1
06/11/2020 04:00	0.6	12.7	1,919.3	0.4	1.9	1	1	1
06/11/2020 05:00	0.3	13.6	1,749.0	0.3	0.9	1	1	0
06/11/2020 06:00	0.3	13.6	1,749.1	0.3	0.9	1	1	0
06/11/2020 07:00	0.3	13.6	1,737.9	0.2	0.9	1	1	0
06/11/2020 08:00	0.3	13.6	1,721.5	0.2	0.9	1	1	0
06/11/2020 09:00	0.3	13.6	1,709.5	0.2	0.9	1	1	0
06/11/2020 10:00	0.4	13.6	1,693.4	0.2	1.2	1	1	0
06/11/2020 11:00	0.3	13.8	1,394.1	0.2	0.8	1	1	0
06/11/2020 12:00	0.4	13.7	1,648.5	0.3	1.2	1	1	0
06/11/2020 13:00	0.4	13.8	1,638.4	0.3	1.2	1	1	0
06/11/2020 14:00	0.3	13.8	1,626.6	0.3	0.9	1	1	0
06/11/2020 15:00	0.3	13.7	1,640.2	0.2	0.9	1	1	0
06/11/2020 16:00	0.3	13.8	1,633.9	0.2	0.9	1	1	0
06/11/2020 17:00	0.4	13.7	1,699.8	0.2	1.2	1	1	1
06/11/2020 18:00	0.6	12.3	2,038.6	0.3	1.9	1	1	1
06/11/2020 19:00	0.5	11.8	2,146.5	0.3	1.6	1	1	1
06/11/2020 20:00	0.5	12.0	2,099.0	0.3	1.6	1	1	1
06/11/2020 21:00	0.5	12.2	2,069.4	0.3	1.6	1	1	1
06/11/2020 22:00	0.6	12.4	2,021.4	0.3	1.9	1	1	1
06/11/2020 23:00	6.8	14.2	1,190.7	0.0	7.7	1	0	1
Average/Sum#:	0.7	13.2	1,790.5	0.3	37.0 #	24 #	23 #	12 #
Minimum:	0.3	11.8	1,190.7	0.2	0.8	1	0	0
Maximum:	6.8	14.2	2,146.5	0.4	7.7	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/12/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/13/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/13/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/14/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/14/2020 12:00	70.8	17.5	463.3	0.0	89.2	1	0	0
06/14/2020 13:00	24.0	15.9	664.5	0.0	42.1	1	0	0
06/14/2020 14:00	39.0	15.5	839.5	0.0	80.1	1	0	0
06/14/2020 15:00	0.7	13.9	1,405.8	0.0	1.9	1	1	0
06/14/2020 16:00	0.8	12.8	1,923.1	0.0	2.5	1	1	1
06/14/2020 17:00	0.8	12.6	1,965.6	0.6	2.5	1	1	1
06/14/2020 18:00	0.8	12.3	2,029.4	0.6	2.5	1	1	1
06/14/2020 19:00	0.8	12.4	2,018.6	0.6	2.5	1	1	1
06/14/2020 20:00	0.8	12.4	2,007.4	0.6	2.5	1	1	1
06/14/2020 21:00	0.9	12.8	1,924.1	0.6	2.8	1	1	1
06/14/2020 22:00	0.3	13.9	1,352.9	0.5	0.8	1	1	0
06/14/2020 23:00	17.0	16.3	408.4	0.0	3.6	1	0	0
Average/Sum#:	13.1	14.0	1,416.9	0.6	233.0 #	12 #	8 #	6 #
Minimum:	0.3	12.3	408.4	0.5	0.8	0	0	0
Maximum:	70.8	17.5	2,029.4	0.6	89.2	1	1	1
%SI	50.00	50.00	50.00	75.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/15/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/16/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/17/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/17/2020 09:00	50.2	17.4	471.9	0.0	77.8	1	0	0
06/17/2020 10:00	11.5	17.0	523.0	0.0	20.4	1	0	0
06/17/2020 11:00	11.1	15.3	974.1	0.0	25.5	1	0	0
06/17/2020 12:00	0.2	14.0	1,386.9	0.0	0.5	1	1	0
06/17/2020 13:00	0.2	14.0	1,334.9	0.0	0.5	1	1	0
06/17/2020 14:00	0.2	13.9	1,503.5	0.2	0.6	1	1	0
06/17/2020 15:00	0.2	13.9	1,490.8	0.2	0.6	1	1	0
06/17/2020 16:00	0.2	13.9	1,595.7	0.2	0.6	1	1	0
06/17/2020 17:00	0.3	13.8	1,554.7	0.2	0.9	1	1	1
06/17/2020 18:00	0.6	12.4	2,050.9	0.3	1.9	1	1	1
06/17/2020 19:00	0.5	12.0	2,139.1	0.3	1.6	1	1	1
06/17/2020 20:00	0.5	12.1	2,133.6	0.3	1.6	1	1	1
06/17/2020 21:00	0.5	12.2	2,093.3	0.3	1.6	1	1	1
06/17/2020 22:00	0.6	12.4	2,067.0	0.3	1.9	1	1	1
06/17/2020 23:00	5.8	14.3	1,206.4	0.0	7.0	1	0	1
Average/Sum#:	5.5	13.9	1,501.7	0.3	143.0 #	15 #	11 #	7 #
Minimum:	0.2	12.0	471.9	0.2	0.5	0	0	0
Maximum:	50.2	17.4	2,139.1	0.3	77.8	1	1	1
%SI	37.50	37.50	37.50	62.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/18/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/18/2020 07:00	12.4	17.9	399.7	0.0	8.1	1	0	0
06/18/2020 08:00	12.7	15.7	834.3	0.0	26.9	1	0	0
06/18/2020 09:00	0.2	14.0	1,406.2	0.0	0.5	1	1	0
06/18/2020 10:00	0.2	14.0	1,396.6	0.0	0.5	1	1	0
06/18/2020 11:00	0.2	13.9	1,599.8	0.2	0.6	1	1	0
06/18/2020 12:00	0.2	14.0	1,421.5	0.2	0.5	1	1	0
06/18/2020 13:00	0.2	13.9	1,635.1	0.2	0.6	1	1	0
06/18/2020 14:00	0.3	13.9	1,607.8	0.2	0.9	1	1	1
06/18/2020 15:00	0.7	12.5	2,025.0	0.3	2.2	1	1	1
06/18/2020 16:00	0.5	12.0	2,120.1	0.4	1.6	1	1	1
06/18/2020 17:00	0.5	12.1	2,101.7	0.4	1.6	1	1	1
06/18/2020 18:00	0.5	12.0	2,097.6	0.3	1.6	1	1	1
06/18/2020 19:00	0.5	12.1	2,096.8	0.3	1.6	1	1	1
06/18/2020 20:00	0.5	12.1	2,102.1	0.3	1.6	1	1	1
06/18/2020 21:00	0.5	12.2	2,082.9	0.3	1.6	1	1	1
06/18/2020 22:00	0.6	12.7	1,947.9	0.3	1.9	1	1	1
06/18/2020 23:00	12.0	15.7	626.2	0.0	4.8	1	0	0
Average/Sum#:	2.5	13.6	1,617.7	0.3	57.1 #	17 #	14 #	9 #
Minimum:	0.2	12.0	399.7	0.2	0.5	0	0	0
Maximum:	12.7	17.9	2,120.1	0.4	26.9	1	1	1
%SI	29.17	29.17	29.17	50.00	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/19/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/19/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/20/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/20/2020 20:00	52.9	17.4	467.0	0.0	88.5	1	0	0
06/20/2020 21:00	16.0	17.0	514.1	0.0	27.9	1	0	0
06/20/2020 22:00	22.7	14.9	1,000.8	0.0	50.0	1	0	0
06/20/2020 23:00	0.4	13.8	1,386.9	0.0	1.0	1	1	0
Average/Sum#:	23.0	15.8	842.2	0.0	167.4 #	4 #	1 #	0 #
Minimum:	0.4	13.8	467.0	0.0	1.0	0	0	0
Maximum:	52.9	17.4	1,386.9	0.0	88.5	1	1	0
%SI	83.33	83.33	83.33	100.00	83.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/21/2020 00:00	0.3	13.8	1,347.7	0.0	0.8	1	1	0
06/21/2020 01:00	0.3	13.8	1,344.8	0.2	0.8	1	1	0
06/21/2020 02:00	0.3	13.9	1,343.1	0.2	0.8	1	1	0
06/21/2020 03:00	0.3	13.9	1,342.2	0.3	0.8	1	1	0
06/21/2020 04:00	0.3	13.9	1,344.1	0.3	0.8	1	1	0
06/21/2020 05:00	0.3	13.9	1,348.4	0.3	0.8	1	1	0
06/21/2020 06:00	0.4	13.9	1,347.9	0.3	1.0	1	1	0
06/21/2020 07:00	0.3	13.9	1,347.9	0.3	0.8	1	1	0
06/21/2020 08:00	0.3	13.9	1,352.3	0.3	0.8	1	1	0
06/21/2020 09:00	0.3	13.9	1,358.7	0.3	0.8	1	1	0
06/21/2020 10:00	0.3	13.9	1,361.3	0.3	0.8	1	1	0
06/21/2020 11:00	0.3	13.9	1,361.3	0.3	0.8	1	1	0
06/21/2020 12:00	0.3	13.9	1,360.6	0.3	0.8	1	1	0
06/21/2020 13:00	0.3	13.9	1,361.1	0.3	0.8	1	1	0
06/21/2020 14:00	0.3	13.9	1,363.1	0.3	0.8	1	1	0
06/21/2020 15:00	0.3	13.9	1,366.2	0.3	0.8	1	1	0
06/21/2020 16:00	0.3	13.9	1,398.5	0.3	0.8	1	1	0
06/21/2020 17:00	0.9	12.7	1,924.8	0.4	2.8	1	1	1
06/21/2020 18:00	0.7	12.0	2,075.6	0.5	2.2	1	1	1
06/21/2020 19:00	0.7	11.8	2,111.5	0.5	2.1	1	1	1
06/21/2020 20:00	0.7	12.1	2,051.6	0.5	2.2	1	1	1
06/21/2020 21:00	0.8	12.4	1,966.4	0.5	2.4	1	1	1
06/21/2020 22:00	0.3	13.9	1,368.6	0.5	0.8	1	1	0
06/21/2020 23:00	0.3	13.9	1,358.7	0.4	0.8	1	1	0
Average/Sum#:	0.4	13.5	1,496.1	0.3	27.1 #	24 #	24 #	5 #
Minimum:	0.3	11.8	1,342.2	0.2	0.8	1	1	0
Maximum:	0.9	13.9	2,111.5	0.5	2.8	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/22/2020 00:00	0.5	13.8	1,346.5	0.3	1.3	1	1	0
06/22/2020 01:00	0.4	13.9	1,340.7	0.3	1.0	1	1	0
06/22/2020 02:00	0.4	13.9	1,342.2	0.3	1.0	1	1	0
06/22/2020 03:00	0.4	13.9	1,349.0	0.3	1.0	1	1	0
06/22/2020 04:00	0.4	13.9	1,343.9	0.3	1.0	1	1	0
06/22/2020 05:00	0.4	13.9	1,410.1	0.3	1.1	1	1	0
06/22/2020 06:00	0.3	13.9	1,345.6	0.3	0.8	1	1	0
06/22/2020 07:00	0.3	13.9	1,352.5	0.3	0.8	1	1	0
06/22/2020 08:00	0.3	13.9	1,361.4	0.3	0.8	1	1	0
06/22/2020 09:00	0.3	13.9	1,371.7	0.3	0.8	1	1	0
06/22/2020 10:00	0.3	13.8	1,519.1	0.3	0.8	1	1	0
06/22/2020 11:00	0.4	13.8	1,539.9	0.3	1.1	1	1	0
06/22/2020 12:00	0.4	13.8	1,625.6	0.3	1.2	1	1	0
06/22/2020 13:00	0.4	13.8	1,628.6	0.3	1.2	1	1	1
06/22/2020 14:00	0.6	12.1	2,029.7	0.3	1.8	1	1	1
06/22/2020 15:00	0.5	11.9	2,068.2	0.3	1.5	1	1	1
06/22/2020 16:00	0.5	11.9	2,061.1	0.3	1.5	1	1	1
06/22/2020 17:00	0.4	11.9	2,060.8	0.3	1.2	1	1	1
06/22/2020 18:00	0.4	11.8	2,080.1	0.3	1.2	1	1	1
06/22/2020 19:00	0.4	11.8	2,089.9	0.3	1.2	1	1	1
06/22/2020 20:00	0.4	11.8	2,098.5	0.3	1.2	1	1	1
06/22/2020 21:00	0.5	11.9	2,077.8	0.3	1.5	1	1	1
06/22/2020 22:00	0.5	12.0	2,065.3	0.3	1.5	1	1	1
06/22/2020 23:00	0.6	12.1	2,044.8	0.3	1.8	1	1	1
Average/Sum#:	0.4	13.1	1,689.7	0.3	28.3 #	24 #	24 #	11 #
Minimum:	0.3	11.8	1,340.7	0.3	0.8	1	1	0
Maximum:	0.6	13.9	2,098.5	0.3	1.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/23/2020 00:00	7.6	14.0	1,192.7	0.0	8.7	1	0	1
06/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/23/2020 12:00	14.9	18.2	355.7	0.0	7.3	1	0	0
06/23/2020 13:00	30.4	15.8	661.7	0.0	52.1	1	0	0
06/23/2020 14:00	2.1	14.0	1,344.1	0.0	5.4	1	0	0
06/23/2020 15:00	0.4	13.7	1,651.2	0.0	1.2	1	1	1
06/23/2020 16:00	0.5	12.0	2,038.6	0.0	1.5	1	1	1
06/23/2020 17:00	0.4	11.8	2,061.5	0.3	1.2	1	1	1
06/23/2020 18:00	0.4	11.9	2,053.0	0.3	1.2	1	1	1
06/23/2020 19:00	0.4	11.8	2,073.5	0.3	1.2	1	1	1
06/23/2020 20:00	0.4	11.8	2,092.6	0.3	1.2	1	1	1
06/23/2020 21:00	0.4	11.9	2,057.5	0.3	1.2	1	1	1
06/23/2020 22:00	0.4	12.0	2,054.1	0.3	1.2	1	1	1
06/23/2020 23:00	0.4	12.0	2,055.4	0.3	1.2	1	1	1
Average/Sum#:	4.5	13.1	1,668.6	0.3	84.6 #	13 #	9 #	10 #
Minimum:	0.4	11.8	355.7	0.3	1.2	0	0	0
Maximum:	30.4	18.2	2,092.6	0.3	52.1	1	1	1
%SI	45.83	45.83	45.83	70.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/24/2020 00:00	0.5	12.5	1,977.9	0.3	1.6	1	1	1
06/24/2020 01:00	0.5	12.8	1,934.3	0.4	1.6	1	1	1
06/24/2020 02:00	0.6	12.8	1,936.5	0.4	1.9	1	1	1
06/24/2020 03:00	0.6	12.8	1,940.1	0.4	1.9	1	1	1
06/24/2020 04:00	0.5	12.5	2,016.8	0.4	1.6	1	1	1
06/24/2020 05:00	0.5	12.3	2,057.2	0.4	1.6	1	1	1
06/24/2020 06:00	0.6	12.8	1,960.3	0.4	1.9	1	1	1
06/24/2020 07:00	0.3	13.8	1,580.0	0.3	0.9	1	1	0
06/24/2020 08:00	0.3	13.8	1,580.0	0.3	0.9	1	1	0
06/24/2020 09:00	0.3	13.8	1,582.0	0.2	0.9	1	1	0
06/24/2020 10:00	0.3	13.9	1,534.4	0.2	0.9	1	1	0
06/24/2020 11:00	0.4	13.7	1,575.6	0.3	1.2	1	1	1
06/24/2020 12:00	0.6	12.1	2,030.3	0.3	1.8	1	1	1
06/24/2020 13:00	0.5	11.8	2,065.4	0.3	1.5	1	1	1
06/24/2020 14:00	0.5	11.8	2,068.8	0.3	1.5	1	1	1
06/24/2020 15:00	0.5	11.8	2,070.7	0.3	1.5	1	1	1
06/24/2020 16:00	0.5	11.8	2,063.8	0.3	1.5	1	1	1
06/24/2020 17:00	0.5	11.8	2,066.0	0.3	1.5	1	1	1
06/24/2020 18:00	0.4	11.8	2,075.1	0.3	1.2	1	1	1
06/24/2020 19:00	0.4	11.8	2,065.2	0.3	1.2	1	1	1
06/24/2020 20:00	0.4	11.8	2,066.1	0.3	1.2	1	1	1
06/24/2020 21:00	0.4	11.8	2,068.5	0.3	1.2	1	1	1
06/24/2020 22:00	0.5	11.9	2,052.6	0.3	1.5	1	1	1
06/24/2020 23:00	0.5	11.9	2,053.3	0.3	1.5	1	1	1
Average/Sum#:	0.5	12.5	1,934.2	0.3	34.0 #	24 #	24 #	20 #
Minimum:	0.3	11.8	1,534.4	0.2	0.9	1	1	0
Maximum:	0.6	13.9	2,075.1	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/25/2020 00:00	7.0	13.8	1,305.0	0.0	10.5	1	0	1
06/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/25/2020 08:00	11.9	18.7	288.8	0.0	4.5	1	0	0
06/25/2020 09:00	17.2	15.4	922.6	0.0	38.1	1	0	0
06/25/2020 10:00	0.2	13.9	1,414.1	0.0	0.5	1	1	0
06/25/2020 11:00	0.2	13.9	1,420.7	0.0	0.5	1	1	0
06/25/2020 12:00	0.3	13.8	1,595.0	0.2	0.9	1	1	0
06/25/2020 13:00	0.3	13.8	1,409.5	0.2	0.8	1	1	0
06/25/2020 14:00	0.3	13.9	1,310.8	0.2	0.7	1	1	0
06/25/2020 15:00	0.4	13.8	1,404.5	0.3	1.0	1	1	0
06/25/2020 16:00	0.3	13.9	1,345.0	0.3	0.8	1	1	0
06/25/2020 17:00	0.4	13.7	1,641.6	0.3	1.2	1	1	1
06/25/2020 18:00	0.6	12.3	1,959.7	0.3	1.8	1	1	1
06/25/2020 19:00	0.6	12.2	1,976.5	0.4	1.8	1	1	1
06/25/2020 20:00	0.5	12.2	1,969.5	0.4	1.5	1	1	1
06/25/2020 21:00	0.5	12.3	1,962.0	0.3	1.5	1	1	1
06/25/2020 22:00	4.9	13.4	1,455.8	0.0	9.2	1	0	1
06/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	2.9	13.8	1,461.3	0.3	75.3 #	16 #	12 #	7 #
Minimum:	0.2	12.2	288.8	0.2	0.5	0	0	0
Maximum:	17.2	18.7	1,976.5	0.4	38.1	1	1	1
%SI	33.33	33.33	33.33	58.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/26/2020 05:00	10.4	18.6	299.2	0.0	3.9	1	0	0
06/26/2020 06:00	22.0	15.8	762.7	0.0	43.5	1	0	0
06/26/2020 07:00	0.2	13.9	1,389.5	0.0	0.5	1	1	0
06/26/2020 08:00	0.3	13.8	1,394.7	0.0	0.8	1	1	0
06/26/2020 09:00	0.3	13.9	1,407.3	0.2	0.8	1	1	0
06/26/2020 10:00	0.3	13.7	1,607.1	0.2	0.9	1	1	0
06/26/2020 11:00	0.3	13.9	1,436.8	0.3	0.8	1	1	0
06/26/2020 12:00	0.5	13.7	1,556.9	0.3	1.4	1	1	0
06/26/2020 13:00	0.4	13.6	1,683.4	0.3	1.2	1	1	0
06/26/2020 14:00	0.4	13.6	1,684.7	0.3	1.2	1	1	0
06/26/2020 15:00	0.5	13.6	1,681.1	0.3	1.5	1	1	0
06/26/2020 16:00	0.4	13.6	1,683.0	0.3	1.2	1	1	0
06/26/2020 17:00	0.5	13.1	1,639.2	0.4	1.4	1	1	1
06/26/2020 18:00	0.4	11.7	2,063.8	0.3	1.2	1	1	1
06/26/2020 19:00	0.4	11.7	2,073.5	0.3	1.2	1	1	1
06/26/2020 20:00	0.4	11.8	2,070.5	0.3	1.2	1	1	1
06/26/2020 21:00	0.4	11.9	2,057.0	0.3	1.2	1	1	1
06/26/2020 22:00	0.6	12.3	1,960.5	0.3	1.8	1	1	1
06/26/2020 23:00	0.3	13.5	1,470.0	0.3	0.8	1	1	1
Average/Sum#:	2.1	13.6	1,574.8	0.3	66.5 #	19 #	17 #	7 #
Minimum:	0.2	11.7	299.2	0.2	0.5	0	0	0
Maximum:	22.0	18.6	2,073.5	0.4	43.5	1	1	1
%SI	20.83	20.83	20.83	37.50	20.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/27/2020 00:00	4.1	14.4	1,069.5	0.0	6.7	1	0	0
06/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/27/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	4.1	14.4	1,069.5	0.0	6.7 #	1 #	0 #	0 #
Minimum:	4.1	14.4	1,069.5	0.0	6.7	0	0	0
Maximum:	4.1	14.4	1,069.5	0.0	6.7	1	0	0
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/28/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/28/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/29/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
06/30/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
06/30/2020 08:00	89.1	17.8	411.2	0.0	70.2	1	0	0
06/30/2020 09:00	13.7	17.1	515.4	0.0	24.5	1	0	0
06/30/2020 10:00	17.3	16.7	566.3	0.0	30.8	1	0	0
06/30/2020 11:00	37.3	15.4	879.5	0.0	78.8	1	0	0
06/30/2020 12:00	0.2	14.0	1,368.0	0.0	0.5	1	1	0
06/30/2020 13:00	0.2	14.0	1,361.5	0.0	0.5	1	1	0
06/30/2020 14:00	0.3	14.0	1,504.2	0.2	0.9	1	1	0
06/30/2020 15:00	0.3	14.0	1,481.8	0.3	0.9	1	1	0
06/30/2020 16:00	0.3	14.0	1,353.2	0.3	0.8	1	1	0
06/30/2020 17:00	0.3	13.8	1,540.8	0.3	0.9	1	1	1
06/30/2020 18:00	0.6	12.2	2,044.0	0.3	1.9	1	1	1
06/30/2020 19:00	0.4	12.0	2,096.2	0.3	1.2	1	1	1
06/30/2020 20:00	0.5	12.0	2,087.1	0.3	1.5	1	1	1
06/30/2020 21:00	0.5	12.1	2,068.1	0.3	1.6	1	1	1
06/30/2020 22:00	6.4	13.9	1,231.7	0.0	7.2	1	0	1
06/30/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	11.2	14.2	1,367.3	0.3	222.2 #	15 #	10 #	6 #
Minimum:	0.2	12.0	411.2	0.2	0.5	0	0	0
Maximum:	89.1	17.8	2,096.2	0.3	78.8	1	1	1
%SI	37.50	37.50	37.50	66.67	37.50	0.00	0.00	0.00

Excess Emission Report

CT1 - CO Lb 1-Day Block Average

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:27 **Location:** Maxwell, CA

Tag Name: CT1_CO_Lb_1D
Total Operating Time: 697.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,487.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**697.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO Lb 1-Day Block Average

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:32 **Location:** Maxwell, CA

Tag Name: CT2_CO_Lb_1D

Total Operating Time: 1,481.00 Hour(s) **No Exclusions Allowed**

Non-Operating Time: 703.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,481.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 8
Hourly Emissions – NH_3

FCD: AQ-18
Title V: #6

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/01/2020 03:00	29.8	17.9	58.6	0.1	1,933,627.2	353.0	0.0	0.0
04/01/2020 04:00	46.1	15.7	52.3	160.0	2,179,801.4	811.8	0.0	0.0
04/01/2020 05:00	8.4	13.9	7.1	108.9	3,047,556.2	1,557.8	1.2	0.8
04/01/2020 06:00	8.4	13.9	7.1	95.9	2,947,979.4	1,506.9	1.1	0.6
04/01/2020 07:00	8.4	13.9	7.1	100.6	3,098,811.7	1,584.0	1.1	0.6
04/01/2020 08:00	8.5	13.9	7.2	90.9	2,956,765.9	1,489.8	1.0	0.6
04/01/2020 09:00	8.7	14.0	7.4	90.7	2,787,274.8	1,404.4	1.1	0.6
04/01/2020 10:00	8.8	14.0	7.5	86.8	2,605,875.7	1,313.0	1.1	0.5
04/01/2020 11:00	9.0	14.0	7.7	86.3	2,597,677.2	1,289.9	1.1	0.5
04/01/2020 12:00	8.8	14.0	7.5	86.3	2,623,857.4	1,302.9	1.1	0.5
04/01/2020 13:00	8.5	14.0	7.3	94.8	2,934,736.0	1,478.7	1.1	0.6
04/01/2020 14:00	8.5	14.0	7.3	97.4	3,048,259.3	1,535.9	1.1	0.6
04/01/2020 15:00	8.4	14.0	7.2	101.6	3,197,506.7	1,611.1	1.1	0.6
04/01/2020 16:00	8.4	14.0	7.2	103.3	3,252,879.1	1,639.0	1.1	0.7
04/01/2020 17:00	9.0	13.9	7.6	103.4	3,135,188.0	1,579.7	1.1	0.6
04/01/2020 18:00	10.6	13.4	8.3	148.8	3,357,456.6	1,985.9	1.5	1.2
04/01/2020 19:00	10.6	13.3	8.2	173.4	3,311,050.3	2,127.7	1.8	1.5
04/01/2020 20:00	10.8	13.4	8.5	185.7	3,277,125.9	2,105.9	2.0	1.7
04/01/2020 21:00	10.7	13.4	8.4	182.8	3,278,059.6	2,106.5	1.9	1.5
04/01/2020 22:00	10.6	13.4	8.3	180.4	3,307,396.0	2,101.2	1.9	1.5
04/01/2020 23:00	10.3	13.4	8.1	176.7	3,275,502.0	2,033.1	1.9	1.4
Average/Sum#:	12.0	14.1	12.2	116.9	2,959,732.7	1,567.5	1.2	0.8
Minimum:	8.4	13.3	7.1	0.1	1,933,627.2	353.0	0.0	0.0
Maximum:	46.1	17.9	58.6	185.7	3,357,456.6	2,127.7	2.0	1.7
%SI	12.50	12.50	12.50	12.50	12.50	12.50	12.50	12.50

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/02/2020 00:00	8.0	13.9	6.7	97.7	3,052,030.2	1,537.8	1.1	0.6
04/02/2020 01:00	8.2	13.9	6.9	95.5	2,950,913.9	1,508.4	1.1	0.6
04/02/2020 02:00	8.3	13.9	7.0	101.3	3,128,939.1	1,599.4	1.1	0.6
04/02/2020 03:00	8.3	13.9	7.0	104.3	3,246,905.2	1,659.7	1.1	0.7
04/02/2020 04:00	8.3	13.9	7.0	104.2	3,233,211.0	1,652.7	1.1	0.7
04/02/2020 05:00	8.4	13.9	7.1	104.3	3,065,554.3	1,567.0	1.1	0.6
04/02/2020 06:00	8.5	13.9	7.2	105.2	3,246,122.7	1,659.3	1.1	0.7
04/02/2020 07:00	8.4	13.9	7.1	102.5	3,157,305.7	1,613.9	1.1	0.6
04/02/2020 08:00	8.4	13.9	7.1	105.1	3,252,382.9	1,662.5	1.1	0.7
04/02/2020 09:00	8.4	13.9	7.1	104.6	3,277,290.6	1,651.3	1.1	0.7
04/02/2020 10:00	8.4	13.9	7.1	102.7	3,218,941.2	1,621.9	1.1	0.6
04/02/2020 11:00	8.4	14.0	7.2	98.2	3,060,167.3	1,541.9	1.1	0.6
04/02/2020 12:00	8.5	14.0	7.3	100.5	3,137,966.5	1,581.1	1.1	0.6
04/02/2020 13:00	8.4	14.0	7.2	103.6	3,254,069.9	1,639.6	1.1	0.7
04/02/2020 14:00	8.4	14.0	7.2	104.2	3,276,099.8	1,650.7	1.1	0.7
04/02/2020 15:00	8.4	14.0	7.2	104.3	3,272,924.3	1,649.1	1.1	0.7
04/02/2020 16:00	8.4	14.0	7.2	102.3	3,197,903.6	1,611.3	1.1	0.6
04/02/2020 17:00	9.6	13.9	8.1	122.0	3,140,872.6	1,605.5	1.3	0.8
04/02/2020 18:00	10.8	13.4	8.5	147.6	3,350,017.8	1,981.5	1.5	1.2
04/02/2020 19:00	10.5	13.4	8.3	153.8	3,326,711.3	2,016.3	1.6	1.2
04/02/2020 20:00	10.4	13.4	8.2	157.3	3,331,166.1	2,019.0	1.6	1.2
04/02/2020 21:00	16.6	14.9	16.3	144.5	2,509,206.8	1,191.0	1.9	0.8
04/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	9.1	13.9	7.7	112.1	3,167,577.4	1,646.4	1.2	0.7
Minimum:	8.0	13.4	6.7	95.5	2,509,206.8	1,191.0	1.1	0.6
Maximum:	16.6	14.9	16.3	157.3	3,350,017.8	2,019.0	1.9	1.2
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/04/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/04/2020 01:00	41.2	17.4	69.5	67.3	1,917,194.1	462.0	0.0	0.0
04/04/2020 02:00	32.4	15.0	32.4	211.5	2,405,312.7	1,036.3	2.8	1.1
04/04/2020 03:00	8.5	13.9	7.2	107.2	3,252,382.9	1,662.5	1.1	0.7
04/04/2020 04:00	8.6	13.9	7.2	105.2	3,217,756.0	1,644.8	1.1	0.7
04/04/2020 05:00	8.6	13.9	7.2	108.1	3,253,948.0	1,663.3	1.1	0.7
04/04/2020 06:00	8.9	13.9	7.5	106.7	3,212,474.0	1,642.1	1.1	0.7
04/04/2020 07:00	8.8	13.9	7.4	106.7	3,254,339.2	1,663.5	1.1	0.7
04/04/2020 08:00	8.7	13.9	7.3	105.9	3,231,841.5	1,652.0	1.1	0.7
04/04/2020 09:00	8.7	13.9	7.3	105.1	3,209,735.1	1,640.7	1.1	0.7
04/04/2020 10:00	8.8	13.9	7.4	104.2	3,167,478.6	1,619.1	1.1	0.6
04/04/2020 11:00	8.7	13.9	7.3	105.2	3,212,474.0	1,642.1	1.1	0.7
04/04/2020 12:00	8.8	13.8	7.3	106.0	3,239,666.8	1,656.0	1.1	0.7
04/04/2020 13:00	8.9	13.8	7.4	106.1	3,238,884.3	1,655.6	1.1	0.7
04/04/2020 14:00	8.7	13.8	7.2	106.3	3,245,340.2	1,658.9	1.1	0.7
04/04/2020 15:00	8.8	13.9	7.4	104.2	3,180,781.6	1,625.9	1.1	0.7
04/04/2020 16:00	8.8	13.9	7.4	105.8	3,234,580.4	1,653.4	1.1	0.7
04/04/2020 17:00	9.1	13.9	7.7	104.1	3,171,000.0	1,620.9	1.1	0.6
04/04/2020 18:00	11.5	13.4	9.0	158.9	3,266,819.6	1,980.0	1.6	1.2
04/04/2020 19:00	11.4	13.3	8.9	196.2	3,199,838.7	2,149.7	2.1	1.7
04/04/2020 20:00	11.1	13.3	8.6	186.7	3,216,017.1	2,113.6	2.0	1.7
04/04/2020 21:00	10.9	13.3	8.5	180.7	3,200,040.5	2,103.1	2.0	1.7
04/04/2020 22:00	10.9	13.3	8.5	179.3	3,189,541.5	2,096.2	1.9	1.5
04/04/2020 23:00	10.7	13.3	8.3	179.6	3,230,302.9	2,099.4	1.9	1.5
Average/Sum#:	11.8	13.9	11.5	128.1	3,128,163.0	1,684.4	1.3	0.9
Minimum:	8.5	13.3	7.2	67.3	1,917,194.1	462.0	0.0	0.0
Maximum:	41.2	17.4	69.5	211.5	3,266,819.6	2,149.7	2.8	1.7
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/05/2020 00:00	10.6	13.3	8.2	177.8	3,223,840.4	2,095.2	1.9	1.5
04/05/2020 01:00	8.7	13.7	7.1	115.8	3,162,620.0	1,685.9	1.2	0.8
04/05/2020 02:00	8.5	13.8	7.1	104.6	3,213,060.9	1,642.4	1.1	0.7
04/05/2020 03:00	8.6	13.8	7.1	104.7	3,203,279.3	1,637.4	1.1	0.7
04/05/2020 04:00	8.6	13.8	7.1	104.6	3,202,888.0	1,637.2	1.1	0.7
04/05/2020 05:00	8.7	13.8	7.2	102.7	3,228,515.8	1,650.3	1.1	0.7
04/05/2020 06:00	8.8	13.8	7.3	105.2	3,211,495.8	1,641.6	1.1	0.7
04/05/2020 07:00	8.8	13.8	7.3	103.8	3,149,480.5	1,609.9	1.1	0.6
04/05/2020 08:00	8.8	13.8	7.3	105.6	3,231,645.9	1,651.9	1.1	0.7
04/05/2020 09:00	8.7	13.8	7.2	104.4	3,183,911.7	1,627.5	1.1	0.7
04/05/2020 10:00	8.7	13.8	7.2	103.3	3,147,915.4	1,609.1	1.1	0.6
04/05/2020 11:00	8.7	13.9	7.3	101.9	3,111,332.2	1,590.4	1.1	0.6
04/05/2020 12:00	8.8	13.9	7.4	100.4	3,042,469.7	1,555.2	1.1	0.6
04/05/2020 13:00	8.7	13.9	7.3	104.5	3,240,375.6	1,632.7	1.1	0.7
04/05/2020 14:00	8.6	13.9	7.2	104.2	3,244,741.9	1,634.9	1.1	0.7
04/05/2020 15:00	8.6	13.9	7.2	104.5	3,240,971.0	1,633.0	1.1	0.7
04/05/2020 16:00	10.3	13.7	8.4	134.7	3,212,487.0	1,759.4	1.4	0.9
04/05/2020 17:00	11.7	13.3	9.1	190.4	3,241,489.8	2,083.0	2.0	1.7
04/05/2020 18:00	11.3	13.4	8.9	179.7	3,234,832.2	2,055.1	1.9	1.4
04/05/2020 19:00	11.0	13.4	8.7	172.0	3,260,822.4	2,047.8	1.8	1.4
04/05/2020 20:00	10.9	13.3	8.5	171.5	3,269,421.1	2,053.2	1.8	1.4
04/05/2020 21:00	10.8	13.3	8.4	172.9	3,256,554.1	2,068.9	1.8	1.4
04/05/2020 22:00	10.6	13.3	8.2	165.9	3,282,429.7	2,037.4	1.7	1.4
04/05/2020 23:00	10.6	13.3	8.2	167.7	3,284,230.0	2,062.5	1.8	1.4
Average/Sum#:	9.5	13.7	7.7	129.3	3,211,700.4	1,779.2	1.4	0.9
Minimum:	8.5	13.3	7.1	100.4	3,042,469.7	1,555.2	1.1	0.6
Maximum:	11.7	13.9	9.1	190.4	3,284,230.0	2,095.2	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/06/2020 00:00	10.6	13.3	8.2	167.8	3,292,032.5	2,067.4	1.8	1.4
04/06/2020 01:00	10.6	13.3	8.2	168.8	3,294,421.1	2,068.9	1.8	1.4
04/06/2020 02:00	10.7	13.3	8.3	173.7	3,258,140.7	2,093.7	1.8	1.5
04/06/2020 03:00	10.4	13.3	8.1	165.3	3,279,535.3	2,083.5	1.7	1.5
04/06/2020 04:00	10.5	13.3	8.2	162.1	3,323,625.6	2,038.7	1.7	1.4
04/06/2020 05:00	10.6	13.3	8.2	194.2	3,268,147.2	2,052.4	2.1	1.6
04/06/2020 06:00	11.1	13.3	8.6	200.1	3,301,905.1	2,073.6	2.1	1.7
04/06/2020 07:00	10.5	13.4	8.3	170.3	1,324,606.9	2,021.6	4.6	3.6
04/06/2020 08:00	8.3	13.9	7.0	144.4	3,182,151.0	1,626.6	1.6	1.0
04/06/2020 09:00	8.4	13.9	7.1	138.0	3,211,887.1	1,641.8	1.5	1.0
04/06/2020 10:00	8.4	13.9	7.1	140.8	3,232,819.7	1,652.5	1.5	1.0
04/06/2020 11:00	8.4	13.9	7.1	132.3	3,112,897.3	1,591.2	1.4	0.8
04/06/2020 12:00	8.4	13.9	7.1	113.1	3,103,702.6	1,586.5	1.2	0.8
04/06/2020 13:00	8.5	13.9	7.2	127.6	3,105,616.3	1,564.8	1.4	0.8
04/06/2020 14:00	8.8	13.9	7.4	127.2	3,242,360.3	1,633.7	1.3	0.8
04/06/2020 15:00	8.8	13.9	7.4	117.7	3,258,237.7	1,641.7	1.2	0.8
04/06/2020 16:00	8.9	13.9	7.5	99.2	2,987,888.4	1,527.3	1.1	0.6
04/06/2020 17:00	11.2	13.4	8.8	149.5	3,308,495.9	1,981.1	1.5	1.2
04/06/2020 18:00	11.2	13.3	8.7	159.3	3,268,848.6	2,005.1	1.7	1.4
04/06/2020 19:00	10.9	13.4	8.6	151.7	3,303,017.8	1,953.7	1.6	1.2
04/06/2020 20:00	11.0	13.3	8.5	160.8	3,300,147.8	2,000.2	1.7	1.4
04/06/2020 21:00	10.8	13.3	8.4	169.0	3,292,257.3	2,043.5	1.8	1.4
04/06/2020 22:00	10.7	13.3	8.3	168.2	3,286,135.2	2,039.7	1.8	1.4
04/06/2020 23:00	10.8	13.3	8.4	175.6	3,272,452.1	2,079.0	1.8	1.5
Average/Sum#:	9.9	13.5	7.9	153.2	3,238,553.2	1,877.8	1.6	1.2
Minimum:	8.3	13.3	7.0	99.2	2,987,888.4	1,527.3	1.1	0.6
Maximum:	11.2	13.9	8.8	200.1	3,323,625.6	2,093.7	2.1	1.7
%SI	0.00	0.00	0.00	0.00	4.17	0.00	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/07/2020 00:00	10.6	13.4	8.3	159.6	3,312,852.1	2,007.9	1.6	1.2
04/07/2020 01:00	10.7	13.4	8.4	159.4	3,344,568.6	2,002.7	1.6	1.2
04/07/2020 02:00	10.6	13.4	8.3	157.2	3,349,077.6	2,005.4	1.6	1.2
04/07/2020 03:00	10.6	13.4	8.3	156.7	3,336,385.4	1,997.8	1.6	1.2
04/07/2020 04:00	10.7	13.4	8.4	155.0	3,331,041.3	1,994.6	1.6	1.2
04/07/2020 05:00	10.7	13.4	8.4	165.3	3,337,721.4	1,998.6	1.7	1.4
04/07/2020 06:00	10.5	13.5	8.4	143.4	3,310,412.3	1,933.9	1.5	1.2
04/07/2020 07:00	8.4	13.9	7.1	102.8	3,141,850.8	1,606.0	1.1	0.6
04/07/2020 08:00	8.4	13.9	7.1	102.9	3,160,631.5	1,615.6	1.1	0.6
04/07/2020 09:00	8.5	13.9	7.2	104.6	3,218,734.2	1,645.3	1.1	0.7
04/07/2020 10:00	8.6	13.9	7.2	104.9	3,213,256.5	1,642.5	1.1	0.7
04/07/2020 11:00	8.6	13.9	7.2	105.3	3,231,450.3	1,651.8	1.1	0.7
04/07/2020 12:00	8.6	13.9	7.2	105.1	3,229,885.2	1,651.0	1.1	0.7
04/07/2020 13:00	8.5	13.9	7.2	102.5	3,139,698.8	1,604.9	1.1	0.6
04/07/2020 14:00	8.6	13.9	7.2	101.1	3,148,485.3	1,586.4	1.1	0.6
04/07/2020 15:00	8.7	13.9	7.3	105.2	3,273,718.1	1,649.5	1.1	0.7
04/07/2020 16:00	8.9	13.9	7.5	106.0	3,288,801.7	1,657.1	1.1	0.7
04/07/2020 17:00	9.5	13.8	7.9	117.3	3,090,203.9	1,579.6	1.3	0.8
04/07/2020 18:00	11.1	13.4	8.7	147.5	3,268,582.2	1,957.2	1.5	1.2
04/07/2020 19:00	10.9	13.3	8.5	158.0	3,270,968.0	2,006.4	1.6	1.2
04/07/2020 20:00	11.1	13.3	8.6	184.2	3,215,069.9	2,089.5	2.0	1.7
04/07/2020 21:00	10.9	13.3	8.5	183.0	3,224,609.8	2,095.7	2.0	1.7
04/07/2020 22:00	10.8	13.3	8.4	184.1	3,227,994.8	2,097.9	2.0	1.7
04/07/2020 23:00	10.8	13.3	8.4	181.9	3,270,278.8	2,101.5	1.9	1.5
Average/Sum#:	9.8	13.6	7.9	137.2	3,247,344.9	1,840.8	1.4	1.0
Minimum:	8.4	13.3	7.1	101.1	3,090,203.9	1,579.6	1.1	0.6
Maximum:	11.1	13.9	8.7	184.2	3,349,077.6	2,101.5	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/08/2020 00:00	10.7	13.4	8.4	167.2	3,214,441.8	1,995.2	1.8	1.4
04/08/2020 01:00	8.3	13.9	7.0	104.9	3,199,953.5	1,635.7	1.1	0.7
04/08/2020 02:00	8.4	13.9	7.1	102.2	3,138,720.7	1,604.4	1.1	0.6
04/08/2020 03:00	8.5	13.9	7.2	104.0	3,200,344.8	1,635.9	1.1	0.7
04/08/2020 04:00	8.5	13.9	7.2	101.8	3,122,874.5	1,596.3	1.1	0.6
04/08/2020 05:00	8.6	13.9	7.2	100.9	3,215,995.3	1,643.9	1.0	0.7
04/08/2020 06:00	8.8	13.8	7.3	105.3	3,237,906.1	1,655.1	1.1	0.7
04/08/2020 07:00	8.8	13.8	7.3	104.0	3,177,847.1	1,624.4	1.1	0.6
04/08/2020 08:00	8.8	13.8	7.3	105.4	3,224,603.2	1,648.3	1.1	0.7
04/08/2020 09:00	8.7	13.9	7.3	105.3	3,244,362.0	1,658.4	1.1	0.7
04/08/2020 10:00	8.7	13.9	7.3	105.1	3,234,580.4	1,653.4	1.1	0.7
04/08/2020 11:00	8.7	13.9	7.3	102.9	3,161,414.0	1,616.0	1.1	0.6
04/08/2020 12:00	9.0	13.9	7.6	106.3	3,281,855.3	1,653.6	1.1	0.7
04/08/2020 13:00	9.3	13.9	7.8	107.9	3,223,233.7	1,647.6	1.1	0.7
04/08/2020 14:00	9.7	13.8	8.1	116.5	3,235,167.3	1,653.7	1.2	0.8
04/08/2020 15:00	9.1	13.9	7.7	108.0	3,221,473.0	1,646.7	1.1	0.7
04/08/2020 16:00	8.7	13.9	7.3	104.6	3,212,865.2	1,642.3	1.1	0.7
04/08/2020 17:00	10.0	13.7	8.2	126.3	3,220,553.0	1,740.3	1.3	0.9
04/08/2020 18:00	11.6	13.3	9.0	179.9	3,212,233.9	2,064.2	1.9	1.4
04/08/2020 19:00	11.1	13.2	8.5	198.7	3,198,121.3	2,171.9	2.2	1.7
04/08/2020 20:00	10.8	13.2	8.3	180.9	3,219,516.7	2,115.9	1.9	1.5
04/08/2020 21:00	10.9	13.3	8.5	177.9	3,225,071.4	2,096.0	1.9	1.5
04/08/2020 22:00	10.8	13.3	8.4	179.1	3,223,840.4	2,095.2	1.9	1.5
04/08/2020 23:00	10.8	13.3	8.4	179.6	3,225,686.8	2,096.4	1.9	1.5
Average/Sum#:	9.5	13.7	7.7	128.1	3,211,360.9	1,774.6	1.4	0.9
Minimum:	8.3	13.2	7.0	100.9	3,122,874.5	1,596.3	1.0	0.6
Maximum:	11.6	13.9	9.0	198.7	3,281,855.3	2,171.9	2.2	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/09/2020 00:00	10.6	13.3	8.2	178.0	3,237,688.5	2,104.2	1.9	1.5
04/09/2020 01:00	10.7	13.3	8.3	180.1	3,239,534.9	2,105.4	1.9	1.5
04/09/2020 02:00	10.6	13.3	8.2	177.5	3,238,611.7	2,104.8	1.9	1.5
04/09/2020 03:00	10.4	13.3	8.1	172.9	3,265,454.7	2,098.4	1.8	1.5
04/09/2020 04:00	10.4	13.3	8.1	162.4	3,280,886.0	2,060.4	1.7	1.4
04/09/2020 05:00	10.6	13.3	8.2	168.3	3,272,765.0	2,055.3	1.8	1.4
04/09/2020 06:00	11.1	13.3	8.6	171.8	3,262,186.7	2,096.3	1.8	1.5
04/09/2020 07:00	10.8	13.3	8.4	173.6	3,267,010.9	2,099.4	1.8	1.5
04/09/2020 08:00	10.7	13.3	8.3	175.0	3,260,941.8	2,095.5	1.9	1.5
04/09/2020 09:00	10.7	13.3	8.3	175.2	3,260,319.3	2,095.1	1.9	1.5
04/09/2020 10:00	10.7	13.3	8.3	174.7	3,246,625.1	2,086.3	1.9	1.5
04/09/2020 11:00	10.7	13.3	8.3	165.1	3,261,968.9	2,024.7	1.7	1.4
04/09/2020 12:00	10.8	13.3	8.4	175.7	3,252,146.8	2,066.1	1.9	1.4
04/09/2020 13:00	10.7	13.3	8.3	174.5	3,216,279.9	2,066.8	1.9	1.4
04/09/2020 14:00	10.6	13.3	8.2	165.9	3,225,387.9	2,049.1	1.8	1.4
04/09/2020 15:00	10.9	13.3	8.5	178.5	3,204,608.7	2,059.3	1.9	1.4
04/09/2020 16:00	10.7	13.3	8.3	171.6	3,219,563.9	2,045.4	1.8	1.4
04/09/2020 17:00	10.8	13.3	8.4	178.2	3,209,588.4	2,062.5	1.9	1.4
04/09/2020 18:00	10.8	13.3	8.4	178.1	3,227,328.7	2,073.9	1.9	1.5
04/09/2020 19:00	10.8	13.3	8.4	185.1	3,222,455.6	2,094.3	2.0	1.7
04/09/2020 20:00	10.9	13.3	8.5	187.6	3,190,911.0	2,097.1	2.0	1.7
04/09/2020 21:00	10.8	13.3	8.4	181.4	3,229,196.1	2,075.1	1.9	1.5
04/09/2020 22:00	10.9	13.3	8.5	176.7	3,237,980.3	2,057.1	1.9	1.4
04/09/2020 23:00	10.9	13.3	8.5	185.3	3,232,303.1	2,100.7	2.0	1.7
Average/Sum#:	10.7	13.3	8.3	175.6	3,240,072.7	2,078.1	1.9	1.5
Minimum:	10.4	13.3	8.1	162.4	3,190,911.0	2,024.7	1.7	1.4
Maximum:	11.1	13.3	8.6	187.6	3,280,886.0	2,105.4	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/10/2020 00:00	10.8	13.3	8.4	181.3	3,259,074.4	2,094.3	1.9	1.5
04/10/2020 01:00	10.6	13.3	8.2	176.9	3,248,025.7	2,087.2	1.9	1.5
04/10/2020 02:00	10.6	13.3	8.2	175.9	3,244,913.3	2,085.2	1.9	1.5
04/10/2020 03:00	10.5	13.3	8.2	173.9	3,238,999.9	2,081.4	1.9	1.5
04/10/2020 04:00	10.5	13.3	8.2	167.5	3,261,618.6	2,048.3	1.8	1.4
04/10/2020 05:00	10.7	13.3	8.3	197.6	3,290,857.2	2,018.6	2.1	1.6
04/10/2020 06:00	11.2	13.3	8.7	174.0	3,277,489.0	2,082.2	1.8	1.5
04/10/2020 07:00	8.7	13.8	7.2	115.0	3,128,665.7	1,667.8	1.2	0.8
04/10/2020 08:00	8.6	13.9	7.2	98.3	2,992,192.3	1,529.5	1.1	0.6
04/10/2020 09:00	8.6	13.9	7.2	104.7	3,237,710.5	1,655.0	1.1	0.7
04/10/2020 10:00	8.6	13.9	7.2	103.6	3,188,998.1	1,630.1	1.1	0.7
04/10/2020 11:00	8.6	13.9	7.2	97.5	2,986,323.3	1,526.5	1.1	0.6
04/10/2020 12:00	8.8	13.9	7.4	104.4	3,214,039.0	1,642.9	1.1	0.7
04/10/2020 13:00	8.9	13.9	7.5	99.2	3,055,602.6	1,539.6	1.1	0.6
04/10/2020 14:00	9.0	13.9	7.6	102.7	3,079,052.9	1,573.9	1.1	0.6
04/10/2020 15:00	9.3	13.9	7.8	108.8	3,174,912.6	1,622.9	1.1	0.6
04/10/2020 16:00	9.5	13.9	8.0	116.2	3,190,563.2	1,630.9	1.2	0.8
04/10/2020 17:00	9.3	13.9	7.8	108.7	2,831,382.7	1,447.3	1.3	0.7
04/10/2020 18:00	11.8	13.4	9.3	167.5	3,163,848.0	1,986.9	1.8	1.4
04/10/2020 19:00	11.7	13.3	9.1	191.3	3,135,829.7	2,060.9	2.1	1.6
04/10/2020 20:00	11.4	13.3	8.9	183.3	3,182,511.1	2,045.1	2.0	1.6
04/10/2020 21:00	11.1	13.3	8.6	177.0	3,211,064.1	2,040.0	1.9	1.4
04/10/2020 22:00	11.0	13.3	8.5	173.8	3,209,647.4	2,039.1	1.9	1.4
04/10/2020 23:00	10.7	13.4	8.4	150.6	3,223,625.0	1,883.2	1.6	1.1
Average/Sum#:	10.0	13.6	8.0	143.7	3,167,789.4	1,834.1	1.5	1.1
Minimum:	8.6	13.3	7.2	97.5	2,831,382.7	1,447.3	1.1	0.6
Maximum:	11.8	13.9	9.3	197.6	3,290,857.2	2,094.3	2.1	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/11/2020 00:00	8.5	13.8	7.1	103.1	3,100,572.4	1,584.9	1.1	0.6
04/11/2020 01:00	8.5	13.8	7.1	104.8	3,214,234.7	1,643.0	1.1	0.7
04/11/2020 02:00	8.6	13.8	7.1	105.2	3,210,908.9	1,641.3	1.1	0.7
04/11/2020 03:00	8.6	13.8	7.1	104.8	3,196,627.8	1,634.0	1.1	0.7
04/11/2020 04:00	8.7	13.8	7.2	104.8	3,185,085.5	1,628.1	1.1	0.7
04/11/2020 05:00	8.8	13.8	7.3	106.3	3,151,026.2	1,633.7	1.1	0.7
04/11/2020 06:00	8.9	13.8	7.4	102.2	3,066,141.2	1,567.3	1.1	0.6
04/11/2020 07:00	8.9	13.8	7.4	105.8	3,212,865.2	1,642.3	1.1	0.7
04/11/2020 08:00	8.8	13.8	7.3	105.1	3,198,975.4	1,635.2	1.1	0.7
04/11/2020 09:00	8.9	13.8	7.4	105.1	3,196,823.4	1,634.1	1.1	0.7
04/11/2020 10:00	8.8	13.9	7.4	105.0	3,209,343.9	1,640.5	1.1	0.7
04/11/2020 11:00	8.8	13.9	7.4	105.3	3,219,712.4	1,645.8	1.1	0.7
04/11/2020 12:00	8.9	13.9	7.5	99.6	3,012,538.0	1,539.9	1.1	0.6
04/11/2020 13:00	9.1	13.9	7.7	104.4	3,185,281.1	1,628.2	1.1	0.7
04/11/2020 14:00	9.3	13.9	7.8	105.8	3,205,626.9	1,638.6	1.1	0.7
04/11/2020 15:00	9.7	13.8	8.1	107.0	3,208,757.0	1,640.2	1.1	0.7
04/11/2020 16:00	9.9	13.8	8.2	108.7	3,247,296.5	1,659.9	1.1	0.7
04/11/2020 17:00	9.6	13.8	8.0	107.5	3,220,494.9	1,646.2	1.1	0.7
04/11/2020 18:00	9.4	13.8	7.8	100.4	3,029,166.7	1,548.4	1.1	0.6
04/11/2020 19:00	11.7	13.3	9.1	128.0	3,188,503.3	1,979.1	1.3	1.0
04/11/2020 20:00	11.3	13.3	8.8	132.0	3,182,888.6	2,022.1	1.4	1.0
04/11/2020 21:00	11.2	13.3	8.7	134.3	3,236,878.5	2,056.4	1.4	1.0
04/11/2020 22:00	11.0	13.3	8.5	130.0	3,248,113.5	2,016.1	1.4	1.0
04/11/2020 23:00	10.6	13.4	8.3	124.3	3,200,988.2	1,940.1	1.3	1.0
Average/Sum#:	9.4	13.7	7.7	110.0	3,180,368.8	1,701.9	1.2	0.7
Minimum:	8.5	13.3	7.1	99.6	3,012,538.0	1,539.9	1.1	0.6
Maximum:	11.7	13.9	9.1	134.3	3,248,113.5	2,056.4	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/12/2020 00:00	8.4	13.8	7.0	103.7	3,183,129.2	1,627.1	1.1	0.7
04/12/2020 01:00	8.6	13.8	7.1	105.4	3,217,756.0	1,644.8	1.1	0.7
04/12/2020 02:00	8.6	13.8	7.1	105.2	3,211,300.2	1,641.5	1.1	0.7
04/12/2020 03:00	8.7	13.8	7.2	101.1	3,067,901.9	1,568.2	1.1	0.6
04/12/2020 04:00	8.8	13.8	7.3	105.2	3,197,801.6	1,634.6	1.1	0.7
04/12/2020 05:00	8.7	13.8	7.2	103.1	3,224,994.4	1,648.5	1.1	0.7
04/12/2020 06:00	8.9	13.8	7.4	103.6	3,128,743.5	1,599.3	1.1	0.6
04/12/2020 07:00	8.9	13.8	7.4	106.6	3,245,927.1	1,659.2	1.1	0.7
04/12/2020 08:00	8.9	13.8	7.4	106.7	3,249,644.1	1,661.1	1.1	0.7
04/12/2020 09:00	8.8	13.8	7.3	105.2	3,204,453.1	1,638.0	1.1	0.7
04/12/2020 10:00	8.8	13.9	7.4	103.9	3,165,131.0	1,617.9	1.1	0.6
04/12/2020 11:00	8.8	13.9	7.4	100.9	3,110,379.6	1,567.2	1.1	0.6
04/12/2020 12:00	9.0	13.9	7.6	105.6	3,247,718.9	1,636.4	1.1	0.7
04/12/2020 13:00	9.4	13.9	7.9	111.1	3,253,474.5	1,639.3	1.1	0.7
04/12/2020 14:00	9.6	13.9	8.1	119.4	3,273,916.6	1,649.6	1.2	0.8
04/12/2020 15:00	9.2	14.0	7.9	109.0	3,233,230.8	1,629.1	1.1	0.7
04/12/2020 16:00	9.5	13.9	8.0	114.1	3,264,787.1	1,645.0	1.2	0.8
04/12/2020 17:00	9.2	14.0	7.9	116.8	3,042,106.8	1,532.8	1.3	0.8
04/12/2020 18:00	8.4	14.0	7.2	103.3	3,142,729.7	1,583.5	1.1	0.6
04/12/2020 19:00	8.5	14.0	7.3	102.0	3,171,309.0	1,597.9	1.1	0.6
04/12/2020 20:00	8.5	13.9	7.2	102.6	3,183,614.0	1,604.1	1.1	0.6
04/12/2020 21:00	8.5	13.9	7.2	102.2	3,121,505.1	1,595.6	1.1	0.6
04/12/2020 22:00	8.5	13.9	7.2	102.0	3,115,636.1	1,592.6	1.1	0.6
04/12/2020 23:00	10.1	13.6	8.2	131.2	3,269,455.1	1,790.6	1.3	0.9
Average/Sum#:	8.9	13.9	7.5	107.1	3,188,610.2	1,625.2	1.1	0.7
Minimum:	8.4	13.6	7.0	100.9	3,042,106.8	1,532.8	1.1	0.6
Maximum:	10.1	14.0	8.2	131.2	3,273,916.6	1,790.6	1.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/13/2020 00:00	11.3	13.4	8.9	173.2	3,240,541.4	2,011.4	1.8	1.4
04/13/2020 01:00	8.2	13.9	6.9	105.8	3,227,928.9	1,650.0	1.1	0.7
04/13/2020 02:00	8.5	13.9	7.2	104.8	3,235,558.6	1,653.9	1.1	0.7
04/13/2020 03:00	8.6	13.8	7.1	104.2	3,191,932.6	1,631.6	1.1	0.7
04/13/2020 04:00	8.7	13.8	7.2	102.8	3,132,656.1	1,601.3	1.1	0.6
04/13/2020 05:00	8.7	13.8	7.2	106.3	3,152,762.1	1,634.6	1.1	0.7
04/13/2020 06:00	8.7	13.9	7.3	104.6	3,207,387.5	1,639.5	1.1	0.7
04/13/2020 07:00	8.7	13.9	7.3	103.5	3,220,330.4	1,622.6	1.1	0.6
04/13/2020 08:00	8.5	13.9	7.2	103.6	3,246,329.7	1,635.7	1.1	0.7
04/13/2020 09:00	8.6	13.9	7.2	105.0	3,302,297.4	1,663.9	1.1	0.7
04/13/2020 10:00	8.7	14.0	7.4	105.2	3,300,709.7	1,663.1	1.1	0.7
04/13/2020 11:00	8.9	14.0	7.6	106.1	3,308,449.9	1,667.0	1.1	0.7
04/13/2020 12:00	8.9	14.0	7.6	105.0	3,270,344.2	1,647.8	1.1	0.7
04/13/2020 13:00	8.7	14.0	7.4	100.6	3,134,791.0	1,579.5	1.1	0.6
04/13/2020 14:00	8.8	14.0	7.5	104.6	3,262,604.0	1,643.9	1.1	0.7
04/13/2020 15:00	9.3	13.9	7.8	109.1	3,297,335.8	1,661.4	1.1	0.7
04/13/2020 16:00	9.2	13.9	7.8	106.0	3,234,223.2	1,629.6	1.1	0.7
04/13/2020 17:00	8.9	14.0	7.6	113.1	2,977,604.9	1,500.3	1.3	0.8
04/13/2020 18:00	11.6	13.5	9.2	163.4	3,272,248.0	1,935.5	1.7	1.4
04/13/2020 19:00	11.5	13.4	9.0	186.8	3,227,383.0	2,026.8	2.0	1.6
04/13/2020 20:00	11.2	13.4	8.8	178.5	3,258,102.3	2,022.3	1.9	1.4
04/13/2020 21:00	11.1	13.4	8.7	179.5	3,260,680.0	2,023.9	1.9	1.4
04/13/2020 22:00	11.0	13.4	8.7	174.0	3,275,206.7	2,009.0	1.8	1.4
04/13/2020 23:00	10.6	13.5	8.5	160.0	3,245,364.6	1,895.9	1.7	1.3
Average/Sum#:	9.5	13.8	7.8	125.2	3,228,448.8	1,735.4	1.3	0.9
Minimum:	8.2	13.4	6.9	100.6	2,977,604.9	1,500.3	1.1	0.6
Maximum:	11.6	14.0	9.2	186.8	3,308,449.9	2,026.8	2.0	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/14/2020 00:00	8.4	13.9	7.1	107.7	3,352,708.1	1,689.3	1.1	0.7
04/14/2020 01:00	8.2	14.0	7.0	95.2	2,969,269.3	1,496.1	1.1	0.6
04/14/2020 02:00	8.2	14.0	7.0	100.4	3,173,492.2	1,599.0	1.0	0.6
04/14/2020 03:00	8.3	14.0	7.1	95.2	2,990,703.8	1,506.9	1.1	0.6
04/14/2020 04:00	8.3	13.9	7.0	101.4	3,177,461.5	1,601.0	1.1	0.6
04/14/2020 05:00	8.3	13.9	7.0	94.9	3,048,338.7	1,558.2	1.0	0.6
04/14/2020 06:00	8.6	13.9	7.2	103.5	3,208,170.1	1,639.9	1.1	0.7
04/14/2020 07:00	8.5	13.9	7.2	99.1	3,095,891.4	1,559.9	1.1	0.6
04/14/2020 08:00	8.5	13.9	7.2	102.1	3,199,689.8	1,612.2	1.1	0.6
04/14/2020 09:00	8.7	14.0	7.4	103.7	3,250,695.9	1,637.9	1.1	0.7
04/14/2020 10:00	8.9	14.0	7.6	105.3	3,277,290.6	1,651.3	1.1	0.7
04/14/2020 11:00	8.8	14.0	7.5	104.8	3,263,397.8	1,644.3	1.1	0.7
04/14/2020 12:00	8.5	14.0	7.3	97.3	3,045,679.2	1,534.6	1.1	0.6
04/14/2020 13:00	9.3	14.0	8.0	109.4	3,286,420.1	1,655.9	1.1	0.7
04/14/2020 14:00	9.2	14.0	7.9	114.3	3,250,299.0	1,637.7	1.2	0.8
04/14/2020 15:00	9.3	14.0	8.0	106.8	3,228,070.7	1,626.5	1.1	0.7
04/14/2020 16:00	9.0	14.0	7.7	108.8	3,095,097.6	1,559.5	1.2	0.8
04/14/2020 17:00	9.9	13.9	8.3	118.8	2,940,545.4	1,503.1	1.4	0.8
04/14/2020 18:00	11.5	13.5	9.2	165.6	3,206,432.9	1,943.4	1.8	1.4
04/14/2020 19:00	11.5	13.5	9.2	189.2	3,168,092.5	2,012.7	2.1	1.6
04/14/2020 20:00	11.5	13.5	9.2	185.3	3,185,504.0	2,000.5	2.0	1.6
04/14/2020 21:00	11.3	13.5	9.0	172.2	3,210,322.0	1,969.2	1.8	1.4
04/14/2020 22:00	11.2	13.5	8.9	178.0	3,220,241.7	1,998.8	1.9	1.4
04/14/2020 23:00	10.8	13.4	8.5	168.7	3,273,087.3	2,007.7	1.8	1.4
Average/Sum#:	9.4	13.8	7.8	122.0	3,171,537.6	1,693.6	1.3	0.9
Minimum:	8.2	13.4	7.0	94.9	2,940,545.4	1,496.1	1.0	0.6
Maximum:	11.5	14.0	9.2	189.2	3,352,708.1	2,012.7	2.1	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/15/2020 00:00	10.7	13.5	8.5	155.0	3,279,858.1	1,892.1	1.6	1.1
04/15/2020 01:00	8.1	13.9	6.8	99.9	3,064,184.9	1,566.3	1.1	0.6
04/15/2020 02:00	8.4	13.9	7.1	103.4	3,201,518.6	1,636.5	1.1	0.7
04/15/2020 03:00	8.3	13.9	7.0	98.6	3,036,796.4	1,552.3	1.1	0.6
04/15/2020 04:00	8.4	13.9	7.1	97.6	3,008,625.4	1,537.9	1.1	0.6
04/15/2020 05:00	8.3	13.9	7.0	101.6	3,220,103.6	1,646.0	1.0	0.7
04/15/2020 06:00	8.6	13.9	7.2	104.5	3,217,364.8	1,644.6	1.1	0.7
04/15/2020 07:00	8.6	13.9	7.2	103.2	3,171,586.9	1,621.2	1.1	0.6
04/15/2020 08:00	8.6	13.9	7.2	104.8	3,238,297.4	1,655.3	1.1	0.7
04/15/2020 09:00	8.7	13.9	7.3	104.9	3,239,666.8	1,656.0	1.1	0.7
04/15/2020 10:00	8.9	13.9	7.5	105.7	3,297,137.3	1,661.3	1.1	0.7
04/15/2020 11:00	9.3	13.9	7.8	106.8	3,296,740.4	1,661.1	1.1	0.7
04/15/2020 12:00	9.2	13.9	7.8	107.7	3,264,787.1	1,645.0	1.1	0.7
04/15/2020 13:00	9.7	13.9	8.2	114.5	3,247,687.7	1,660.1	1.2	0.8
04/15/2020 14:00	9.8	13.9	8.3	126.9	3,203,279.3	1,637.4	1.3	0.8
04/15/2020 15:00	9.8	13.9	8.3	115.9	3,130,308.5	1,600.1	1.2	0.8
04/15/2020 16:00	9.7	13.9	8.2	120.7	3,143,415.9	1,606.8	1.3	0.8
04/15/2020 17:00	9.8	13.9	8.3	115.5	2,920,395.3	1,492.8	1.3	0.7
04/15/2020 18:00	11.6	13.4	9.1	165.7	3,152,253.8	1,956.6	1.8	1.4
04/15/2020 19:00	11.4	13.4	9.0	191.3	3,136,286.2	2,061.2	2.1	1.6
04/15/2020 20:00	11.5	13.3	8.9	198.9	3,123,341.0	2,075.5	2.2	1.7
04/15/2020 21:00	11.4	13.4	9.0	182.5	3,186,666.3	2,024.5	2.0	1.6
04/15/2020 22:00	10.8	13.4	8.5	151.1	3,247,932.3	1,897.4	1.6	1.1
04/15/2020 23:00	10.8	13.4	8.5	151.2	3,201,371.9	1,870.2	1.6	1.1
Average/Sum#:	9.6	13.8	7.9	126.2	3,176,233.6	1,719.1	1.3	0.9
Minimum:	8.1	13.3	6.8	97.6	2,920,395.3	1,492.8	1.0	0.6
Maximum:	11.6	13.9	9.1	198.9	3,297,137.3	2,075.5	2.2	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/16/2020 00:00	8.5	13.9	7.2	96.7	2,893,006.8	1,478.8	1.1	0.6
04/16/2020 01:00	8.6	13.9	7.2	93.9	2,877,356.3	1,470.8	1.1	0.6
04/16/2020 02:00	8.7	13.9	7.3	95.9	2,932,524.5	1,499.0	1.1	0.6
04/16/2020 03:00	8.6	13.9	7.2	93.6	2,869,922.2	1,467.0	1.1	0.6
04/16/2020 04:00	8.7	13.9	7.3	99.1	3,034,448.8	1,551.1	1.1	0.6
04/16/2020 05:00	8.6	13.9	7.2	98.2	3,203,474.9	1,637.5	1.0	0.7
04/16/2020 06:00	8.7	13.9	7.3	97.1	2,971,455.3	1,518.9	1.1	0.6
04/16/2020 07:00	8.7	13.9	7.3	102.9	3,171,782.5	1,621.3	1.1	0.6
04/16/2020 08:00	8.7	13.9	7.3	105.1	3,282,252.2	1,653.8	1.1	0.7
04/16/2020 09:00	8.7	13.9	7.3	104.1	3,254,466.8	1,639.8	1.1	0.7
04/16/2020 10:00	8.9	13.9	7.5	105.4	3,287,213.9	1,656.3	1.1	0.7
04/16/2020 11:00	8.9	13.9	7.5	109.0	3,237,795.6	1,631.4	1.1	0.7
04/16/2020 12:00	9.5	13.9	8.0	109.1	3,245,535.8	1,659.0	1.1	0.7
04/16/2020 13:00	9.8	13.9	8.3	121.8	3,224,994.4	1,648.5	1.3	0.8
04/16/2020 14:00	9.5	13.9	8.0	112.4	3,060,076.6	1,564.2	1.2	0.8
04/16/2020 15:00	9.9	13.9	8.3	118.7	3,147,328.5	1,608.8	1.3	0.8
04/16/2020 16:00	9.4	13.9	7.9	119.0	3,178,652.3	1,601.6	1.2	0.8
04/16/2020 17:00	9.3	13.9	7.8	114.5	3,027,817.2	1,525.6	1.3	0.8
04/16/2020 18:00	11.6	13.4	9.1	161.5	3,159,131.6	1,937.8	1.7	1.4
04/16/2020 19:00	11.1	13.4	8.7	186.4	3,161,216.2	2,054.5	2.0	1.6
04/16/2020 20:00	11.0	13.3	8.5	195.0	3,143,957.6	2,089.2	2.2	1.7
04/16/2020 21:00	11.0	13.4	8.7	189.3	3,164,293.5	2,056.5	2.1	1.6
04/16/2020 22:00	10.9	13.4	8.6	161.3	3,179,869.4	1,927.3	1.7	1.3
04/16/2020 23:00	10.9	13.5	8.7	153.8	3,201,885.4	1,870.5	1.6	1.1
Average/Sum#:	9.5	13.8	7.8	122.7	3,121,269.1	1,682.1	1.3	0.9
Minimum:	8.5	13.3	7.2	93.6	2,869,922.2	1,467.0	1.0	0.6
Maximum:	11.6	13.9	9.1	195.0	3,287,213.9	2,089.2	2.2	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/17/2020 00:00	8.5	13.9	7.2	101.0	2,784,235.4	1,423.2	1.2	0.7
04/17/2020 01:00	8.5	13.9	7.2	85.3	2,594,667.9	1,326.3	1.1	0.5
04/17/2020 02:00	8.7	13.9	7.3	85.4	2,564,149.3	1,310.7	1.1	0.5
04/17/2020 03:00	8.7	13.9	7.3	85.6	2,560,236.7	1,308.7	1.1	0.5
04/17/2020 04:00	9.0	13.9	7.6	86.2	2,517,588.9	1,286.9	1.1	0.5
04/17/2020 05:00	8.8	13.8	7.3	105.9	3,199,366.6	1,635.4	1.1	0.7
04/17/2020 06:00	8.8	13.9	7.4	103.3	3,135,003.7	1,602.5	1.1	0.6
04/17/2020 07:00	8.7	13.9	7.3	100.9	3,088,638.9	1,578.8	1.1	0.6
04/17/2020 08:00	8.7	13.9	7.3	104.8	3,218,538.6	1,645.2	1.1	0.7
04/17/2020 09:00	8.7	13.9	7.3	103.4	3,219,933.5	1,622.4	1.1	0.6
04/17/2020 10:00	8.7	14.0	7.4	98.3	3,039,526.7	1,531.5	1.1	0.6
04/17/2020 11:00	8.9	14.0	7.6	103.4	3,200,285.2	1,612.5	1.1	0.6
04/17/2020 12:00	8.6	14.0	7.4	92.4	2,846,418.0	1,434.2	1.1	0.6
04/17/2020 13:00	8.8	13.9	7.4	101.1	3,141,340.5	1,582.8	1.1	0.6
04/17/2020 14:00	9.4	13.9	7.9	112.8	3,213,647.8	1,642.7	1.2	0.8
04/17/2020 15:00	9.6	13.9	8.1	118.3	3,233,015.3	1,652.6	1.2	0.8
04/17/2020 16:00	9.5	13.9	8.0	112.6	3,172,173.8	1,621.5	1.2	0.8
04/17/2020 17:00	9.8	13.9	8.3	116.4	2,935,654.6	1,500.6	1.3	0.8
04/17/2020 18:00	11.8	13.4	9.3	164.4	3,198,584.1	1,962.0	1.7	1.4
04/17/2020 19:00	11.5	13.3	8.9	175.6	3,180,055.3	2,020.3	1.9	1.4
04/17/2020 20:00	11.2	13.3	8.7	172.0	3,210,663.2	2,016.3	1.8	1.4
04/17/2020 21:00	11.1	13.3	8.6	169.6	3,208,593.2	2,015.0	1.8	1.4
04/17/2020 22:00	11.0	13.3	8.5	173.5	3,244,580.4	2,037.6	1.8	1.4
04/17/2020 23:00	16.8	14.7	16.0	151.9	2,462,748.6	1,222.9	2.0	1.0
Average/Sum#:	9.7	13.8	8.1	117.7	3,007,068.6	1,608.0	1.3	0.8
Minimum:	8.5	13.3	7.2	85.3	2,462,748.6	1,222.9	1.1	0.5
Maximum:	16.8	14.7	16.0	175.6	3,244,580.4	2,037.6	2.0	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/18/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/19/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/20/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/20/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/20/2020 02:00	40.0	17.1	62.1	33.5	1,920,715.5	490.9	0.0	0.0
04/20/2020 03:00	36.5	14.8	35.3	221.8	2,301,530.9	1,025.2	3.2	1.2
04/20/2020 04:00	8.3	13.8	6.9	106.0	3,199,366.6	1,635.4	1.1	0.7
04/20/2020 05:00	8.4	13.8	7.0	104.3	3,221,864.3	1,646.9	1.1	0.7
04/20/2020 06:00	8.5	13.9	7.2	104.6	3,200,931.7	1,636.2	1.1	0.7
04/20/2020 07:00	8.6	13.9	7.2	105.0	3,224,798.8	1,648.4	1.1	0.7
04/20/2020 08:00	8.6	13.9	7.2	102.7	3,145,372.2	1,607.8	1.1	0.6
04/20/2020 09:00	8.6	13.9	7.2	99.7	3,050,295.0	1,559.2	1.1	0.6
04/20/2020 10:00	8.7	13.9	7.3	98.9	3,033,861.9	1,550.8	1.1	0.6
04/20/2020 11:00	8.6	13.9	7.2	104.4	3,230,472.1	1,651.3	1.1	0.7
04/20/2020 12:00	8.5	13.9	7.2	103.7	3,205,822.5	1,638.7	1.1	0.7
04/20/2020 13:00	8.6	13.9	7.2	104.2	3,220,690.5	1,646.3	1.1	0.7
04/20/2020 14:00	8.6	13.9	7.2	95.5	2,917,656.5	1,491.4	1.1	0.6
04/20/2020 15:00	8.6	13.9	7.2	102.9	3,176,282.0	1,623.6	1.1	0.6
04/20/2020 16:00	8.5	13.9	7.2	100.5	3,109,767.1	1,589.6	1.1	0.6
04/20/2020 17:00	9.1	13.9	7.7	98.2	2,951,892.1	1,508.9	1.1	0.6
04/20/2020 18:00	11.5	13.4	9.0	158.0	3,229,366.7	1,957.3	1.7	1.4
04/20/2020 19:00	11.3	13.4	8.9	162.8	3,236,674.8	2,009.0	1.7	1.4
04/20/2020 20:00	11.1	13.4	8.7	163.4	3,241,669.2	2,012.1	1.7	1.4
04/20/2020 21:00	10.9	13.4	8.6	161.9	3,251,335.7	2,018.1	1.7	1.4
04/20/2020 22:00	10.5	13.5	8.4	150.7	3,236,237.2	1,914.2	1.6	1.1
04/20/2020 23:00	24.3	16.3	31.2	158.5	1,482,469.0	552.1	3.4	0.7
Average/Sum#:	12.6	14.1	12.4	120.1	2,990,412.4	1,564.2	1.4	0.8
Minimum:	8.3	13.4	6.9	33.5	1,482,469.0	490.9	0.0	0.0
Maximum:	40.0	17.1	62.1	221.8	3,251,335.7	2,018.1	3.4	1.4
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/21/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 07:00	32.6	17.6	58.3	0.1	1,887,916.8	399.8	0.0	0.0
04/22/2020 08:00	47.9	16.5	64.2	170.0	1,862,728.4	598.5	0.0	0.0
04/22/2020 09:00	17.5	14.2	15.4	157.0	2,457,605.8	1,202.4	2.2	1.0
04/22/2020 10:00	10.9	14.0	9.3	93.7	2,483,818.3	1,251.5	1.2	0.6
04/22/2020 11:00	23.8	17.7	43.9	159.6	791,105.9	225.3	6.8	0.6
04/22/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	26.5	16.0	38.2	116.1	1,896,635.0	735.5	2.0	0.4
Minimum:	10.9	14.0	9.3	0.1	791,105.9	225.3	0.0	0.0
Maximum:	47.9	17.7	64.2	170.0	2,483,818.3	1,251.5	6.8	1.0
%SI	79.17	79.17	79.17	79.17	79.17	79.17	79.17	79.17

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/23/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/24/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/24/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/24/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/24/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/24/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/24/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/24/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/24/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/24/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/24/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/24/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/24/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/24/2020 14:00	43.9	17.3	71.9	2.8	297,473.0	454.0	0.0	0.0
04/24/2020 15:00	51.2	15.6	57.0	235.1	470,256.4	717.7	17.5	4.8
04/24/2020 16:00	8.4	14.0	7.2	129.7	990,375.6	1,511.5	4.8	2.7
04/24/2020 17:00	9.5	13.9	8.0	99.8	1,002,431.8	1,529.9	3.6	2.1
04/24/2020 18:00	10.9	13.6	8.8	134.7	1,161,324.3	1,772.4	4.2	2.8
04/24/2020 19:00	11.2	13.4	8.8	184.9	3,087,374.8	2,051.6	2.1	1.6
04/24/2020 20:00	10.8	13.4	8.5	177.5	3,103,115.7	2,039.4	2.0	1.6
04/24/2020 21:00	10.7	13.5	8.5	152.6	3,115,106.5	1,865.3	1.7	1.3
04/24/2020 22:00	25.4	16.4	33.3	160.4	1,459,806.4	533.0	3.5	0.7
04/24/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	20.2	14.6	23.6	141.9	2,691,350.9	1,386.1	2.3	1.3
Minimum:	8.4	13.4	7.2	2.8	1,459,806.4	454.0	1.7	0.7
Maximum:	51.2	17.3	71.9	235.1	3,115,106.5	2,051.6	3.5	1.6
%SI	62.50	62.50	62.50	62.50	83.33	62.50	83.33	83.33

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/28/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/28/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/28/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/28/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/28/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/28/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/28/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/28/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/28/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/28/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/28/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/28/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/28/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/28/2020 13:00	39.2	17.3	64.2	0.1	1,819,674.5	438.5	0.0	0.0
04/28/2020 14:00	51.3	15.6	57.1	222.2	1,942,475.8	737.6	3.7	1.0
04/28/2020 15:00	7.9	14.0	6.8	120.7	2,993,482.3	1,508.3	1.4	0.8
04/28/2020 16:00	9.2	13.9	7.8	101.7	2,861,510.1	1,462.7	1.2	0.7
04/28/2020 17:00	10.9	13.4	8.6	166.8	3,078,743.0	2,000.9	1.9	1.4
04/28/2020 18:00	10.8	13.4	8.5	186.5	3,029,924.3	2,079.8	2.1	1.7
04/28/2020 19:00	10.8	13.3	8.4	190.5	3,042,161.7	2,088.2	2.2	1.7
04/28/2020 20:00	10.7	13.3	8.3	188.5	3,046,677.9	2,091.3	2.2	1.7
04/28/2020 21:00	13.5	14.0	11.5	165.3	2,678,661.7	1,584.4	2.1	1.3
04/28/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/28/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	18.3	14.2	20.1	149.1	2,721,479.0	1,554.6	1.9	1.1
Minimum:	7.9	13.3	6.8	0.1	1,819,674.5	438.5	0.0	0.0
Maximum:	51.3	17.3	64.2	222.2	3,078,743.0	2,091.3	3.7	1.7
%SI	62.50	62.50	62.50	62.50	62.50	62.50	62.50	62.50

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
04/30/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/04/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/05/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/07/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/10/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/11/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/13/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/14/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/15/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/17/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/18/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/19/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/20/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/21/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/23/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 10:00	26.3	17.9	51.7	0.0	10,654,648.	2,022.9	0.0	0.0
05/26/2020 11:00	11.2	18.8	31.5	0.0	30,646,196.	2,014.1	0.0	0.0
05/26/2020 12:00	43.5	17.0	65.8	120.6	7,705,294.5	2,025.6	0.0	0.0
05/26/2020 13:00	39.2	16.9	57.8	247.6	7,497,783.6	2,025.8	0.2	0.2
05/26/2020 14:00	45.3	15.5	49.5	248.1	5,719,537.9	2,088.3	0.8	0.6
05/26/2020 15:00	36.3	16.2	45.6	219.0	6,348,347.1	2,086.1	0.5	0.4
05/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	33.6	17.1	50.3	139.2	11,428,634.6	2,043.8	0.3	0.2
Minimum:	11.2	15.5	31.5	0.0	5,719,537.9	2,014.1	0.0	0.0
Maximum:	45.3	18.8	65.8	248.1	30,646,196.1	2,088.3	0.8	0.6
%SI	75.00	75.00	75.00	75.00	75.00	75.00	75.00	75.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/28/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 12:00	29.4	17.5	51.0	0.0	1,332,207.5	2,033.2	0.0	0.0
05/28/2020 13:00	44.1	16.0	53.1	150.8	1,334,828.4	2,037.2	0.0	0.0
05/28/2020 14:00	46.2	15.3	48.7	249.0	1,371,848.7	2,093.7	5.7	4.6
05/28/2020 15:00	20.3	14.3	18.1	233.5	1,364,051.5	2,081.8	6.0	4.8
05/28/2020 16:00	9.7	13.9	8.2	103.0	1,372,176.3	2,094.2	2.6	2.1
05/28/2020 17:00	11.2	13.7	9.2	132.6	4,017,375.1	2,024.2	1.1	0.8
05/28/2020 18:00	11.4	13.7	9.3	132.3	4,005,566.3	2,047.5	1.1	0.8
05/28/2020 19:00	9.8	13.9	8.3	101.6	4,132,640.9	2,052.1	0.8	0.6
05/28/2020 20:00	10.2	13.9	8.6	100.3	4,140,897.7	2,056.2	0.7	0.6
05/28/2020 21:00	10.2	13.8	8.5	112.1	4,149,557.3	2,060.5	0.8	0.6
05/28/2020 22:00	9.8	13.9	8.3	104.5	4,144,925.4	2,058.2	0.8	0.6
05/28/2020 23:00	10.6	13.8	8.8	120.7	4,081,480.1	2,056.5	0.9	0.6
Average/Sum#:	18.6	14.5	20.0	128.4	4,096,063.3	2,057.9	0.9	0.7
Minimum:	9.7	13.7	8.2	0.0	4,005,566.3	2,024.2	0.7	0.6
Maximum:	46.2	17.5	53.1	249.0	4,149,557.3	2,094.2	1.1	0.8
%SI	50.00	50.00	50.00	50.00	70.83	50.00	70.83	70.83

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/29/2020 00:00	10.4	13.7	8.5	118.2	4,025,912.1	2,057.9	0.9	0.6
05/29/2020 01:00	14.5	14.5	13.4	134.3	4,486,277.8	2,063.9	0.9	0.6
05/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	12.5	14.1	11.0	126.3	4,256,095.0	2,060.9	0.9	0.6
Minimum:	10.4	13.7	8.5	118.2	4,025,912.1	2,057.9	0.9	0.6
Maximum:	14.5	14.5	13.4	134.3	4,486,277.8	2,063.9	0.9	0.6
%SI	91.67	91.67	91.67	91.67	91.67	91.67	91.67	91.67

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/30/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
05/31/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/01/2020 12:00	17.4	18.2	38.0	0.0	14,537,521.	2,017.0	0.0	0.0
06/01/2020 13:00	40.7	17.3	66.7	33.0	7,707,957.3	2,026.3	0.0	0.0
06/01/2020 14:00	36.9	15.9	43.5	233.1	6,110,312.1	2,052.5	0.7	0.6
06/01/2020 15:00	9.2	13.8	7.6	121.6	4,063,816.5	2,047.6	1.0	0.8
06/01/2020 16:00	8.8	14.0	7.5	96.3	4,229,681.8	2,069.4	0.7	0.6
06/01/2020 17:00	9.3	14.0	8.0	114.3	4,203,730.1	2,087.4	0.9	0.6
06/01/2020 18:00	9.0	14.0	7.7	98.1	4,212,591.1	2,091.8	0.7	0.6
06/01/2020 19:00	9.0	14.0	7.7	98.0	4,162,647.4	2,067.0	0.7	0.6
06/01/2020 20:00	9.0	14.0	7.7	95.5	4,172,112.5	2,071.7	0.7	0.6
06/01/2020 21:00	9.1	14.0	7.8	92.8	4,175,334.7	2,073.3	0.7	0.6
06/01/2020 22:00	9.2	14.0	7.9	87.1	4,264,224.0	2,086.3	0.6	0.4
06/01/2020 23:00	9.5	13.9	8.0	105.0	4,165,466.8	2,068.4	0.8	0.6
Average/Sum#:	14.8	14.8	18.2	97.9	5,500,449.6	2,063.2	0.6	0.5
Minimum:	8.8	13.8	7.5	0.0	4,063,816.5	2,017.0	0.0	0.0
Maximum:	40.7	18.2	66.7	233.1	14,537,521.0	2,091.8	1.0	0.8
%SI	50.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/02/2020 00:00	9.0	14.0	7.7	94.9	4,204,334.2	2,087.7	0.7	0.6
06/02/2020 01:00	9.0	14.0	7.7	95.7	4,189,230.3	2,080.2	0.7	0.6
06/02/2020 02:00	9.1	13.9	7.7	91.0	4,169,897.2	2,070.6	0.7	0.6
06/02/2020 03:00	9.0	13.9	7.6	96.9	4,151,168.4	2,061.3	0.7	0.6
06/02/2020 04:00	9.1	14.0	7.8	105.8	4,159,626.6	2,065.5	0.8	0.6
06/02/2020 05:00	8.9	13.9	7.5	105.7	4,134,856.1	2,053.2	0.8	0.6
06/02/2020 06:00	9.2	13.9	7.8	94.2	4,149,154.5	2,060.3	0.7	0.6
06/02/2020 07:00	9.4	14.0	8.0	89.6	4,169,695.9	2,070.5	0.6	0.4
06/02/2020 08:00	9.6	14.0	8.2	88.0	4,152,175.3	2,061.8	0.6	0.4
06/02/2020 09:00	9.3	13.9	7.8	97.9	4,195,876.0	2,083.5	0.7	0.6
06/02/2020 10:00	9.2	14.0	7.9	93.8	4,148,550.3	2,060.0	0.7	0.6
06/02/2020 11:00	9.6	14.0	8.2	87.9	4,159,779.9	2,035.2	0.6	0.4
06/02/2020 12:00	10.3	13.8	8.6	124.3	4,103,708.4	2,067.7	1.0	0.8
06/02/2020 13:00	11.3	13.5	9.0	164.4	3,776,654.6	2,426.9	1.5	1.5
06/02/2020 14:00	11.0	13.4	8.7	190.2	3,704,293.0	2,488.6	1.8	1.7
06/02/2020 15:00	10.9	13.4	8.6	184.7	3,728,406.7	2,504.8	1.7	1.8
06/02/2020 16:00	10.8	13.4	8.5	189.5	3,762,606.4	2,500.3	1.7	1.8
06/02/2020 17:00	10.7	13.5	8.5	171.3	3,763,582.8	2,418.5	1.5	1.5
06/02/2020 18:00	10.5	13.5	8.4	171.9	3,821,627.7	2,455.8	1.5	1.5
06/02/2020 19:00	10.6	13.5	8.5	171.8	3,788,170.2	2,434.3	1.5	1.5
06/02/2020 20:00	10.9	13.4	8.6	169.7	3,789,570.7	2,435.2	1.5	1.5
06/02/2020 21:00	10.7	13.4	8.4	168.7	3,808,259.0	2,419.4	1.5	1.5
06/02/2020 22:00	10.7	13.5	8.5	163.8	3,785,435.3	2,404.9	1.5	1.4
06/02/2020 23:00	10.8	13.5	8.6	169.7	3,779,768.7	2,401.3	1.5	1.4
Average/Sum#:	10.0	13.7	8.2	132.6	3,983,184.5	2,239.5	1.1	1.0
Minimum:	8.9	13.4	7.5	87.9	3,704,293.0	2,035.2	0.6	0.4
Maximum:	11.3	14.0	9.0	190.2	4,204,334.2	2,504.8	1.8	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/03/2020 00:00	10.7	13.4	8.4	167.9	3,785,184.5	2,377.1	1.5	1.4
06/03/2020 01:00	8.7	14.0	7.4	94.5	4,143,918.5	2,057.7	0.7	0.6
06/03/2020 02:00	8.9	14.0	7.6	89.1	4,132,640.9	2,052.1	0.7	0.6
06/03/2020 03:00	9.2	14.0	7.9	89.1	4,113,509.2	2,042.6	0.7	0.6
06/03/2020 04:00	9.4	13.9	7.9	110.0	4,147,140.6	2,059.3	0.8	0.6
06/03/2020 05:00	9.0	14.0	7.7	107.6	4,157,209.9	2,064.3	0.8	0.6
06/03/2020 06:00	9.4	14.0	8.0	91.9	4,101,627.4	2,036.7	0.7	0.6
06/03/2020 07:00	9.5	13.9	8.0	96.4	4,124,182.6	2,047.9	0.7	0.6
06/03/2020 08:00	9.3	13.9	7.8	97.0	4,232,931.0	2,101.9	0.7	0.6
06/03/2020 09:00	9.6	13.9	8.1	110.9	4,141,300.4	2,056.4	0.8	0.6
06/03/2020 10:00	9.8	13.9	8.3	101.9	4,073,342.9	2,052.4	0.8	0.6
06/03/2020 11:00	11.8	13.3	9.2	174.7	3,765,602.2	2,392.3	1.6	1.4
06/03/2020 12:00	11.6	13.2	8.9	195.8	3,660,633.4	2,486.0	1.8	1.7
06/03/2020 13:00	11.3	13.2	8.7	191.0	3,683,457.1	2,501.5	1.8	1.8
06/03/2020 14:00	11.3	13.2	8.7	197.0	3,665,198.1	2,489.1	1.8	1.7
06/03/2020 15:00	11.1	13.2	8.5	195.6	3,612,924.4	2,453.6	1.9	1.7
06/03/2020 16:00	11.2	13.2	8.6	195.4	3,653,859.9	2,481.4	1.8	1.7
06/03/2020 17:00	11.4	13.2	8.7	192.6	3,655,626.9	2,482.6	1.8	1.7
06/03/2020 18:00	11.2	13.3	8.7	181.0	3,705,271.1	2,462.2	1.7	1.7
06/03/2020 19:00	11.3	13.2	8.7	188.8	3,656,065.4	2,456.2	1.8	1.7
06/03/2020 20:00	11.4	13.3	8.9	180.8	3,716,525.5	2,415.4	1.6	1.4
06/03/2020 21:00	11.4	13.3	8.9	180.2	3,776,463.2	2,399.2	1.6	1.4
06/03/2020 22:00	11.4	13.3	8.9	171.1	3,779,611.3	2,373.6	1.5	1.4
06/03/2020 23:00	11.5	13.3	8.9	187.2	3,695,011.3	2,428.4	1.7	1.7
Average/Sum#:	10.5	13.5	8.4	149.5	3,882,468.2	2,282.1	1.3	1.2
Minimum:	8.7	13.2	7.4	89.1	3,612,924.4	2,036.7	0.7	0.6
Maximum:	11.8	14.0	9.2	197.0	4,232,931.0	2,501.5	1.9	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/04/2020 00:00	16.2	14.8	15.7	168.8	4,204,132.9	2,118.3	1.2	1.1
06/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/04/2020 06:00	25.1	17.9	49.4	146.9	11,142,184.	2,034.1	0.0	0.0
06/04/2020 07:00	44.7	15.6	49.8	253.8	5,583,223.8	2,079.3	0.9	0.6
06/04/2020 08:00	8.4	14.0	7.2	98.7	4,205,972.4	2,057.8	0.7	0.6
06/04/2020 09:00	8.6	14.0	7.4	88.0	4,197,387.9	2,053.6	0.6	0.4
06/04/2020 10:00	9.2	13.9	7.8	98.0	4,131,231.1	2,051.4	0.7	0.6
06/04/2020 11:00	8.9	14.0	7.6	95.4	4,179,401.5	2,044.8	0.7	0.6
06/04/2020 12:00	8.9	14.0	7.6	100.1	4,172,043.4	2,041.2	0.7	0.6
06/04/2020 13:00	9.5	13.9	8.0	113.5	4,157,612.7	2,064.5	0.9	0.6
06/04/2020 14:00	11.4	13.3	8.9	157.9	3,771,111.4	2,395.8	1.4	1.2
06/04/2020 15:00	11.3	13.2	8.7	183.0	3,715,654.7	2,469.1	1.7	1.7
06/04/2020 16:00	11.3	13.2	8.7	179.5	3,673,034.4	2,467.6	1.7	1.7
06/04/2020 17:00	11.2	13.2	8.6	182.6	3,677,797.6	2,470.8	1.7	1.7
06/04/2020 18:00	11.2	13.2	8.6	182.0	3,640,436.1	2,445.7	1.7	1.7
06/04/2020 19:00	11.2	13.2	8.6	171.1	3,679,339.0	2,418.1	1.6	1.5
06/04/2020 20:00	11.4	13.2	8.7	178.2	3,759,446.1	2,498.2	1.6	1.5
06/04/2020 21:00	11.2	13.2	8.6	183.2	3,674,969.4	2,468.9	1.7	1.7
06/04/2020 22:00	11.2	13.3	8.7	177.7	3,726,373.0	2,421.8	1.6	1.5
06/04/2020 23:00	11.3	13.3	8.8	171.6	3,750,648.8	2,382.8	1.5	1.4
Average/Sum#:	13.3	13.9	13.0	154.2	4,370,631.6	2,262.3	1.2	1.1
Minimum:	8.4	13.2	7.2	88.0	3,640,436.1	2,034.1	0.0	0.0
Maximum:	44.7	17.9	49.8	253.8	11,142,184.6	2,498.2	1.7	1.7
%SI	20.83	20.83	20.83	20.83	20.83	20.83	20.83	20.83

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/05/2020 00:00	15.3	14.7	14.6	147.6	4,265,041.6	2,086.7	1.0	0.8
06/05/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	15.3	14.7	14.6	147.6	4,265,041.6	2,086.7	1.0	0.8
Minimum:	15.3	14.7	14.6	147.6	4,265,041.6	2,086.7	1.0	0.8
Maximum:	15.3	14.7	14.6	147.6	4,265,041.6	2,086.7	1.0	0.8
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/07/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/08/2020 15:00	39.0	17.5	67.7	0.0	9,692,329.3	2,123.3	0.0	0.0
06/08/2020 16:00	54.7	16.2	68.7	174.2	6,026,062.7	2,024.2	0.0	0.0
06/08/2020 17:00	26.8	17.8	51.0	180.5	10,237,425.	2,093.2	-0.3	-0.2
06/08/2020 18:00	24.0	14.4	21.8	180.1	5,107,518.2	2,349.7	1.0	0.9
06/08/2020 19:00	8.8	13.9	7.4	106.4	4,163,645.5	2,097.9	0.8	0.6
06/08/2020 20:00	11.1	13.4	8.7	153.1	3,828,471.0	2,264.5	1.3	1.1
06/08/2020 21:00	11.2	13.4	8.8	168.4	3,759,633.8	2,333.6	1.5	1.4
06/08/2020 22:00	11.1	13.4	8.7	161.3	3,825,973.7	2,318.9	1.4	1.2
06/08/2020 23:00	13.7	14.1	11.9	149.8	4,040,562.7	2,124.4	1.2	1.1
Average/Sum#:	22.3	14.9	28.3	141.5	5,631,291.4	2,192.2	0.8	0.7
Minimum:	8.8	13.4	7.4	0.0	3,759,633.8	2,024.2	-0.3	-0.2
Maximum:	54.7	17.8	68.7	180.5	10,237,425.4	2,349.7	1.5	1.4
%SI	62.50	62.50	62.50	62.50	62.50	62.50	62.50	62.50

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/09/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/09/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/09/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/09/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/09/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/09/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/09/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/09/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/09/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/09/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/09/2020 12:00	30.3	17.8	57.7	0.0	10,569,849.	2,006.8	0.0	0.0
06/09/2020 13:00	41.3	17.5	71.7	183.7	8,032,076.8	1,994.2	0.0	0.0
06/09/2020 14:00	43.3	16.5	58.1	281.8	7,149,731.3	2,140.6	0.3	0.2
06/09/2020 15:00	8.5	13.9	7.2	122.6	4,248,192.6	2,140.5	0.9	0.6
06/09/2020 16:00	9.1	13.9	7.7	100.5	4,045,359.0	2,038.3	0.8	0.6
06/09/2020 17:00	11.0	13.3	8.5	147.4	3,764,306.0	2,336.5	1.3	1.2
06/09/2020 18:00	11.0	13.3	8.5	170.0	3,720,833.8	2,418.2	1.5	1.5
06/09/2020 19:00	11.0	13.3	8.5	173.4	3,699,119.6	2,431.1	1.6	1.5
06/09/2020 20:00	11.1	13.3	8.6	169.5	3,718,454.1	2,389.5	1.5	1.4
06/09/2020 21:00	11.0	13.3	8.5	160.2	3,763,687.8	2,363.6	1.4	1.2
06/09/2020 22:00	11.0	13.3	8.5	155.5	3,785,806.3	2,322.2	1.4	1.2
06/09/2020 23:00	17.0	14.7	16.2	161.6	4,298,766.2	2,103.2	1.1	0.8
Average/Sum#:	18.0	14.5	22.5	152.2	5,066,348.6	2,223.7	1.0	0.9
Minimum:	8.5	13.3	7.2	0.0	3,699,119.6	1,994.2	0.0	0.0
Maximum:	43.3	17.8	71.7	281.8	10,569,849.4	2,431.1	1.6	1.5
%SI	50.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/10/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/10/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/10/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/10/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/10/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/10/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/10/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/10/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/10/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/10/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/10/2020 10:00	37.6	17.4	63.4	107.1	8,595,705.7	2,008.6	0.0	0.0
06/10/2020 11:00	54.3	15.6	60.4	298.3	6,027,837.4	2,288.9	0.8	0.7
06/10/2020 12:00	14.0	14.1	12.1	162.7	4,194,935.2	2,052.4	1.2	1.0
06/10/2020 13:00	8.7	13.8	7.2	109.8	4,057,862.5	2,044.6	0.9	0.6
06/10/2020 14:00	9.3	13.8	7.7	124.9	4,094,578.9	2,093.0	1.0	0.8
06/10/2020 15:00	11.1	13.3	8.6	170.3	3,787,796.4	2,406.4	1.5	1.4
06/10/2020 16:00	11.1	13.2	8.5	199.1	3,977,809.7	2,701.4	1.7	1.9
06/10/2020 17:00	11.1	13.2	8.5	193.4	3,997,665.8	2,656.5	1.6	1.6
06/10/2020 18:00	11.1	13.2	8.5	196.9	3,824,266.4	2,569.2	1.8	1.8
06/10/2020 19:00	10.9	13.3	8.5	184.3	3,675,839.4	2,415.8	1.7	1.7
06/10/2020 20:00	10.9	13.3	8.5	185.1	3,702,523.5	2,406.3	1.7	1.7
06/10/2020 21:00	10.8	13.3	8.4	185.6	3,725,301.2	2,393.9	1.7	1.7
06/10/2020 22:00	10.7	13.4	8.4	157.8	3,710,656.8	2,303.2	1.4	1.2
06/10/2020 23:00	10.8	13.3	8.4	175.4	3,753,496.7	2,357.2	1.6	1.4
Average/Sum#:	15.9	13.9	16.2	175.1	4,366,162.5	2,335.5	1.3	1.3
Minimum:	8.7	13.2	7.2	107.1	3,675,839.4	2,008.6	0.0	0.0
Maximum:	54.3	17.4	63.4	298.3	8,595,705.7	2,701.4	1.8	1.9
%SI	41.67	41.67	41.67	41.67	41.67	41.67	41.67	41.67

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/11/2020 00:00	10.7	13.5	8.5	156.7	3,825,370.1	2,290.6	1.4	1.1
06/11/2020 01:00	10.6	13.5	8.5	156.2	3,794,955.5	2,300.1	1.4	1.2
06/11/2020 02:00	10.7	13.4	8.4	155.0	3,829,147.3	2,264.9	1.3	1.1
06/11/2020 03:00	10.8	13.4	8.5	160.5	3,804,524.9	2,305.9	1.4	1.2
06/11/2020 04:00	10.5	13.4	8.3	151.3	3,799,810.3	2,219.8	1.3	1.1
06/11/2020 05:00	9.2	13.7	7.5	127.5	3,943,749.3	2,044.7	1.1	0.8
06/11/2020 06:00	9.7	13.7	7.9	120.5	4,039,215.0	2,064.7	1.0	0.8
06/11/2020 07:00	10.3	13.7	8.4	134.1	3,932,562.5	2,038.9	1.1	0.8
06/11/2020 08:00	10.7	13.7	8.8	138.8	3,972,102.2	2,059.4	1.1	0.8
06/11/2020 09:00	10.7	13.7	8.8	136.2	3,867,755.9	2,005.3	1.1	0.8
06/11/2020 10:00	10.6	13.6	8.6	145.6	3,828,301.9	2,012.8	1.3	1.0
06/11/2020 11:00	9.4	13.9	7.9	105.2	4,010,031.8	2,020.5	0.8	0.6
06/11/2020 12:00	9.3	13.9	7.8	115.7	3,985,620.4	2,008.2	0.9	0.6
06/11/2020 13:00	9.0	13.9	7.6	108.2	4,053,898.9	2,013.0	0.8	0.6
06/11/2020 14:00	9.5	13.9	8.0	120.5	4,015,192.0	2,023.1	1.0	0.8
06/11/2020 15:00	10.1	13.8	8.4	124.2	3,967,559.8	1,999.1	1.0	0.8
06/11/2020 16:00	9.7	13.8	8.1	124.3	4,028,290.8	2,029.7	1.0	0.8
06/11/2020 17:00	8.9	13.8	7.4	111.8	4,017,176.7	2,024.1	0.9	0.6
06/11/2020 18:00	11.2	13.3	8.7	176.3	3,703,337.5	2,325.7	1.6	1.4
06/11/2020 19:00	11.3	13.2	8.7	205.0	3,611,746.4	2,452.8	2.0	2.0
06/11/2020 20:00	11.0	13.2	8.4	190.4	3,615,280.4	2,376.0	1.8	1.7
06/11/2020 21:00	10.7	13.3	8.3	177.4	3,712,241.9	2,358.4	1.6	1.4
06/11/2020 22:00	10.8	13.3	8.4	168.6	3,679,240.5	2,283.7	1.6	1.4
06/11/2020 23:00	16.1	14.8	15.6	162.4	4,345,499.6	2,062.6	1.1	0.8
Average/Sum#:	10.5	13.6	8.6	144.7	3,890,942.2	2,149.3	1.2	1.0
Minimum:	8.9	13.2	7.4	105.2	3,611,746.4	1,999.1	0.8	0.6
Maximum:	16.1	14.8	15.6	205.0	4,345,499.6	2,452.8	2.0	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/13/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/14/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/15/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/17/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2020 12:00	30.3	17.8	57.7	0.0	10,389,717.	1,972.6	0.0	0.0
06/17/2020 13:00	41.9	17.3	68.7	146.9	7,740,377.9	1,978.3	0.0	0.0
06/17/2020 14:00	38.1	17.3	62.4	282.0	8,188,777.4	2,152.7	0.1	0.0
06/17/2020 15:00	34.9	15.8	40.4	274.6	6,006,021.5	2,192.9	1.0	0.9
06/17/2020 16:00	8.8	14.0	7.5	117.5	4,663,091.4	2,315.5	0.8	0.7
06/17/2020 17:00	8.8	13.9	7.4	116.8	4,609,482.5	2,356.2	0.8	0.7
06/17/2020 18:00	11.0	13.4	8.7	172.9	4,257,298.7	2,642.5	1.4	1.3
06/17/2020 19:00	11.1	13.3	8.6	202.3	4,216,322.2	2,801.8	1.6	1.7
06/17/2020 20:00	11.1	13.3	8.6	202.8	3,919,140.4	2,575.7	1.8	1.8
06/17/2020 21:00	11.1	13.3	8.6	188.0	3,832,027.2	2,434.5	1.7	1.7
06/17/2020 22:00	11.1	13.3	8.6	180.2	3,793,146.3	2,382.1	1.6	1.4
06/17/2020 23:00	15.7	14.9	15.4	162.3	4,406,386.3	2,091.5	1.1	0.8
Average/Sum#:	19.5	14.8	25.2	170.5	5,501,815.8	2,324.7	1.0	0.9
Minimum:	8.8	13.3	7.4	0.0	3,793,146.3	1,972.6	0.0	0.0
Maximum:	41.9	17.8	68.7	282.0	10,389,717.5	2,801.8	1.8	1.8
%SI	50.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/18/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/18/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/18/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/18/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/18/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/18/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/18/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/18/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/18/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/18/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/18/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/18/2020 11:00	37.9	17.5	65.8	14.0	9,441,945.0	1,999.5	0.0	0.0
06/18/2020 12:00	36.7	15.1	37.3	232.9	4,910,853.7	2,008.2	1.2	1.0
06/18/2020 13:00	9.9	13.9	8.3	113.3	4,116,807.2	2,074.3	0.9	0.6
06/18/2020 14:00	8.7	13.9	7.3	105.8	4,142,608.0	2,087.3	0.8	0.6
06/18/2020 15:00	10.7	13.4	8.4	133.5	3,790,697.1	2,325.2	1.2	1.2
06/18/2020 16:00	10.9	13.3	8.5	146.5	3,669,144.4	2,411.4	1.3	1.2
06/18/2020 17:00	10.7	13.3	8.3	172.5	3,867,406.6	2,541.7	1.5	1.5
06/18/2020 18:00	10.9	13.3	8.5	194.7	4,154,681.4	2,730.5	1.6	1.6
06/18/2020 19:00	10.9	13.3	8.5	193.3	4,193,025.3	2,755.7	1.6	1.7
06/18/2020 20:00	10.9	13.3	8.5	195.1	4,288,144.7	2,786.9	1.5	1.7
06/18/2020 21:00	10.8	13.3	8.4	187.7	4,053,184.9	2,604.6	1.6	1.6
06/18/2020 22:00	10.3	13.4	8.1	161.3	3,839,565.4	2,299.1	1.4	1.1
06/18/2020 23:00	22.6	16.1	27.8	180.5	5,415,670.7	2,016.9	0.7	0.6
Average/Sum#:	15.5	14.1	16.4	156.2	4,606,441.1	2,357.0	1.2	1.1
Minimum:	8.7	13.3	7.3	14.0	3,669,144.4	1,999.5	0.0	0.0
Maximum:	37.9	17.5	65.8	232.9	9,441,945.0	2,786.9	1.6	1.7
%SI	45.83	45.83	45.83	45.83	45.83	45.83	45.83	45.83

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/19/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/20/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/21/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/21/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/21/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/21/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/21/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/21/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/21/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/21/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/21/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/21/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/21/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/21/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/21/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/21/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/21/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/21/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/21/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/21/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/21/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/21/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/21/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/21/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/21/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/22/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/22/2020 09:00	29.7	17.5	51.5	0.0	9,059,198.8	1,984.6	0.0	0.0
06/22/2020 10:00	19.6	18.1	41.3	0.0	11,272,645.	1,975.6	0.0	0.0
06/22/2020 11:00	50.5	16.0	60.8	252.0	5,888,816.2	2,021.1	0.6	0.4
06/22/2020 12:00	14.5	14.0	12.4	167.9	4,548,100.0	2,258.4	1.2	1.1
06/22/2020 13:00	8.9	13.8	7.4	108.2	4,590,897.4	2,346.7	0.7	0.7
06/22/2020 14:00	11.0	13.3	8.5	179.9	3,892,433.2	2,501.3	1.6	1.5
06/22/2020 15:00	11.0	13.2	8.4	180.7	3,614,387.3	2,428.2	1.7	1.7
06/22/2020 16:00	11.1	13.2	8.5	187.4	3,588,933.8	2,411.1	1.8	1.7
06/22/2020 17:00	11.0	13.2	8.4	185.0	3,640,261.1	2,419.0	1.7	1.7
06/22/2020 18:00	11.0	13.2	8.4	192.9	3,604,531.1	2,447.9	1.8	1.7
06/22/2020 19:00	10.9	13.2	8.4	198.0	4,023,776.8	2,762.0	1.7	1.9
06/22/2020 20:00	11.0	13.2	8.4	200.7	4,194,372.1	2,879.1	1.6	1.7
06/22/2020 21:00	11.0	13.2	8.4	193.0	4,145,634.6	2,785.1	1.6	1.7
06/22/2020 22:00	11.0	13.2	8.4	187.3	4,007,696.5	2,633.9	1.6	1.6
06/22/2020 23:00	11.0	13.3	8.5	166.9	4,371,398.3	2,681.4	1.3	1.3
Average/Sum#:	15.5	14.1	17.2	160.0	4,962,872.2	2,435.7	1.3	1.2
Minimum:	8.9	13.2	7.4	0.0	3,588,933.8	1,975.6	0.0	0.0
Maximum:	50.5	18.1	60.8	252.0	11,272,645.1	2,879.1	1.8	1.9
%SI	37.50	37.50	37.50	37.50	37.50	37.50	37.50	37.50

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/23/2020 00:00	16.2	14.7	15.4	165.6	5,113,140.2	2,464.3	0.9	0.7
06/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/23/2020 07:00	12.0	18.3	27.2	174.5	1,703,955.2	174.2	0.0	0.0
06/23/2020 08:00	51.7	15.8	59.8	264.5	1,838,589.2	671.3	4.3	1.1
06/23/2020 09:00	9.2	13.9	7.8	135.4	2,677,125.4	1,348.9	1.7	0.9
06/23/2020 10:00	8.9	13.9	7.5	91.5	2,646,958.4	1,333.7	1.1	0.5
06/23/2020 11:00	9.1	13.9	7.7	102.2	2,837,487.0	1,429.7	1.2	0.7
06/23/2020 12:00	9.1	13.8	7.6	108.6	3,034,366.6	1,528.9	1.2	0.8
06/23/2020 13:00	9.2	13.8	7.6	101.5	2,897,897.6	1,481.3	1.2	0.7
06/23/2020 14:00	9.3	13.9	7.8	92.5	2,651,324.7	1,335.9	1.2	0.7
06/23/2020 15:00	9.8	13.7	8.0	159.7	3,131,738.6	1,623.7	1.8	1.1
06/23/2020 16:00	11.1	13.2	8.5	166.2	3,063,297.0	2,035.6	1.9	1.4
06/23/2020 17:00	11.1	13.2	8.5	184.0	3,047,190.1	2,069.4	2.1	1.7
06/23/2020 18:00	10.9	13.2	8.4	177.3	3,071,380.7	2,063.4	2.0	1.7
06/23/2020 19:00	10.8	13.2	8.3	177.9	3,079,143.4	2,091.1	2.0	1.7
06/23/2020 20:00	10.8	13.2	8.3	184.7	3,087,906.3	2,119.6	2.1	1.7
06/23/2020 21:00	10.7	13.2	8.2	175.0	3,092,219.8	2,077.4	2.0	1.7
06/23/2020 22:00	10.7	13.2	8.2	175.0	3,115,666.2	2,070.4	1.9	1.4
06/23/2020 23:00	10.6	13.2	8.1	170.4	3,111,452.6	2,067.6	1.9	1.4
Average/Sum#:	12.8	14.0	12.4	155.9	2,955,602.2	1,665.9	1.7	1.1
Minimum:	8.9	13.2	7.5	91.5	1,703,955.2	174.2	0.0	0.0
Maximum:	51.7	18.3	59.8	264.5	5,113,140.2	2,464.3	4.3	1.7
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/24/2020 00:00	10.5	13.3	8.2	152.7	3,206,898.5	1,967.1	1.6	1.2
06/24/2020 01:00	10.4	13.4	8.2	141.6	3,237,758.8	1,915.1	1.5	1.1
06/24/2020 02:00	10.4	13.4	8.2	141.7	3,227,107.7	1,908.8	1.5	1.1
06/24/2020 03:00	10.4	13.4	8.2	141.7	3,223,726.4	1,906.8	1.5	1.1
06/24/2020 04:00	10.5	13.3	8.2	151.9	3,207,514.1	1,990.9	1.6	1.2
06/24/2020 05:00	10.6	13.3	8.2	164.7	3,171,306.8	2,037.9	1.8	1.4
06/24/2020 06:00	10.8	13.4	8.5	155.8	3,146,904.6	1,930.3	1.7	1.4
06/24/2020 07:00	8.8	13.8	7.3	103.2	3,072,670.8	1,548.2	1.1	0.6
06/24/2020 08:00	8.7	13.9	7.3	101.4	3,066,319.8	1,545.0	1.1	0.6
06/24/2020 09:00	8.8	13.9	7.4	101.6	3,071,083.0	1,547.4	1.1	0.6
06/24/2020 10:00	8.9	13.9	7.5	99.0	2,980,780.4	1,501.9	1.1	0.6
06/24/2020 11:00	9.4	13.8	7.8	116.7	3,038,557.1	1,553.2	1.3	0.8
06/24/2020 12:00	11.0	13.2	8.4	160.2	3,116,132.9	2,025.2	1.8	1.4
06/24/2020 13:00	11.0	13.2	8.4	175.8	3,084,330.7	2,072.1	2.0	1.7
06/24/2020 14:00	10.9	13.2	8.4	178.8	3,059,706.4	2,077.9	2.0	1.7
06/24/2020 15:00	10.8	13.2	8.3	181.3	3,063,976.6	2,080.8	2.1	1.7
06/24/2020 16:00	10.7	13.2	8.2	181.0	3,053,669.1	2,073.8	2.1	1.7
06/24/2020 17:00	10.7	13.2	8.2	181.7	3,058,675.6	2,077.2	2.1	1.7
06/24/2020 18:00	10.7	13.2	8.2	184.0	3,045,221.1	2,090.3	2.1	1.7
06/24/2020 19:00	10.7	13.2	8.2	180.2	3,063,829.4	2,080.7	2.0	1.7
06/24/2020 20:00	10.8	13.2	8.3	180.0	3,067,510.6	2,083.2	2.0	1.7
06/24/2020 21:00	10.8	13.2	8.3	178.9	3,070,013.9	2,084.9	2.0	1.7
06/24/2020 22:00	10.9	13.2	8.4	176.3	3,067,659.5	2,060.9	2.0	1.6
06/24/2020 23:00	10.9	13.2	8.4	176.8	3,094,899.1	2,056.6	2.0	1.6
Average/Sum#:	10.3	13.4	8.1	154.5	3,104,010.5	1,925.7	1.7	1.3
Minimum:	8.7	13.2	7.3	99.0	2,980,780.4	1,501.9	1.1	0.6
Maximum:	11.0	13.9	8.5	184.0	3,237,758.8	2,090.3	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/25/2020 00:00	14.5	14.5	13.4	161.9	2,481,165.5	1,286.4	2.2	1.0
06/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/25/2020 12:00	19.5	17.9	38.4	0.0	1,749,290.8	293.8	0.0	0.0
06/25/2020 13:00	31.3	15.0	31.3	174.6	2,282,216.6	966.6	2.4	0.9
06/25/2020 14:00	9.0	14.0	7.7	91.5	2,578,545.6	1,280.4	1.2	0.6
06/25/2020 15:00	9.2	13.9	7.8	91.9	2,722,177.5	1,371.6	1.1	0.5
06/25/2020 16:00	8.9	14.0	7.6	89.9	2,646,009.9	1,313.9	1.1	0.5
06/25/2020 17:00	9.8	13.7	8.0	115.2	3,141,459.5	1,605.8	1.2	0.8
06/25/2020 18:00	11.2	13.2	8.6	164.0	3,054,117.3	2,029.5	1.8	1.4
06/25/2020 19:00	11.0	13.2	8.4	167.8	3,075,879.3	2,021.5	1.9	1.4
06/25/2020 20:00	11.0	13.2	8.4	160.7	3,053,816.4	1,984.7	1.8	1.4
06/25/2020 21:00	11.0	13.2	8.4	155.9	3,083,880.8	1,959.2	1.7	1.4
06/25/2020 22:00	14.2	14.1	12.3	167.7	2,633,859.6	1,442.5	2.1	1.2
06/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	13.4	14.2	13.4	128.4	2,708,534.9	1,463.0	1.5	0.9
Minimum:	8.9	13.2	7.6	0.0	1,749,290.8	293.8	0.0	0.0
Maximum:	31.3	17.9	38.4	174.6	3,141,459.5	2,029.5	2.4	1.4
%SI	50.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/26/2020 10:00	19.2	17.8	36.5	0.0	1,822,579.4	292.8	0.0	0.0
06/26/2020 11:00	36.5	15.2	37.8	201.8	2,123,830.5	868.5	3.0	1.0
06/26/2020 12:00	17.7	18.0	36.0	185.2	660,366.9	173.6	9.8	0.7
06/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/26/2020 16:00	41.1	16.9	60.6	263.6	1,785,577.2	469.4	4.2	0.8
06/26/2020 17:00	19.3	13.8	16.0	184.5	2,774,935.0	1,499.5	2.2	1.2
06/26/2020 18:00	11.0	13.2	8.4	140.6	3,020,454.9	2,073.3	1.6	1.2
06/26/2020 19:00	10.9	13.2	8.4	141.4	3,010,138.9	2,088.2	1.6	1.3
06/26/2020 20:00	10.9	13.2	8.4	140.7	3,038,665.3	2,085.8	1.6	1.3
06/26/2020 21:00	10.8	13.3	8.4	176.1	3,103,777.8	2,062.5	2.0	1.7
06/26/2020 22:00	10.9	13.3	8.5	158.1	3,108,434.1	1,952.1	1.7	1.4
06/26/2020 23:00	9.3	13.7	7.6	111.0	2,709,584.4	1,444.4	1.4	0.7
Average/Sum#:	18.0	14.7	21.5	154.8	2,468,940.4	1,364.6	2.6	1.0
Minimum:	9.3	13.2	7.6	0.0	660,366.9	173.6	0.0	0.0
Maximum:	41.1	18.0	60.6	263.6	3,108,434.1	2,088.2	9.8	1.7
%SI	54.17	54.17	54.17	54.17	54.17	54.17	54.17	54.17

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/27/2020 00:00	13.8	14.6	12.9	119.9	2,234,943.4	1,044.5	1.7	0.7
06/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	13.8	14.6	12.9	119.9	2,234,943.4	1,044.5	1.7	0.7
Minimum:	13.8	14.6	12.9	119.9	2,234,943.4	1,044.5	1.7	0.7
Maximum:	13.8	14.6	12.9	119.9	2,234,943.4	1,044.5	1.7	0.7
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/28/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
06/30/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/30/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/30/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/30/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/30/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/30/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/30/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/30/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/30/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/30/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/30/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/30/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/30/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/30/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/30/2020 14:00	38.7	17.4	65.2	0.0	1,786,670.9	417.5	0.0	0.0
06/30/2020 15:00	46.1	15.7	52.3	201.9	1,979,489.5	737.2	0.0	0.0
06/30/2020 16:00	8.3	14.0	7.1	107.0	2,678,835.8	1,330.2	1.3	0.7
06/30/2020 17:00	8.7	13.9	7.3	99.1	3,000,825.6	1,512.0	1.1	0.6
06/30/2020 18:00	10.8	13.3	8.4	169.1	3,178,620.7	2,042.6	1.8	1.4
06/30/2020 19:00	10.9	13.3	8.5	170.6	3,158,103.3	2,098.6	1.9	1.5
06/30/2020 20:00	10.8	13.3	8.4	183.2	3,143,355.7	2,088.8	2.0	1.7
06/30/2020 21:00	10.8	13.3	8.4	177.7	3,181,372.9	2,067.6	1.9	1.4
06/30/2020 22:00	16.5	14.7	15.7	176.1	2,379,863.9	1,216.5	2.5	1.2
06/30/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	18.0	14.3	20.1	142.7	2,720,793.1	1,501.2	1.4	0.9
Minimum:	8.3	13.3	7.1	0.0	1,786,670.9	417.5	0.0	0.0
Maximum:	46.1	17.4	65.2	201.9	3,181,372.9	2,098.6	2.5	1.7
%SI	62.50	62.50	62.50	62.50	62.50	62.50	62.50	62.50

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/01/2020 00:00	7.3	13.9	6.2	77.1	2,642,206.5	1,350.6	0.9	0.4
04/01/2020 01:00	7.4	13.9	6.2	77.2	2,649,249.3	1,354.2	0.9	0.4
04/01/2020 02:00	7.1	13.9	6.0	76.2	2,640,641.5	1,349.8	0.9	0.4
04/01/2020 03:00	7.4	13.8	6.1	88.6	3,072,332.5	1,592.9	0.9	0.5
04/01/2020 04:00	7.2	13.8	6.0	89.2	3,116,223.0	1,592.9	0.9	0.5
04/01/2020 05:00	7.2	13.8	6.0	87.8	3,094,312.2	1,581.7	0.9	0.5
04/01/2020 06:00	7.2	13.8	6.0	86.9	3,000,017.6	1,533.5	0.9	0.5
04/01/2020 07:00	7.3	13.9	6.2	90.8	3,153,784.4	1,612.1	0.9	0.5
04/01/2020 08:00	7.2	13.9	6.1	85.3	2,972,237.8	1,519.3	0.9	0.5
04/01/2020 09:00	7.3	13.9	6.2	81.3	2,815,927.8	1,439.4	0.9	0.4
04/01/2020 10:00	7.5	13.9	6.3	78.1	2,667,202.1	1,343.9	0.9	0.4
04/01/2020 11:00	7.5	13.9	6.3	79.4	2,616,592.9	1,318.4	0.9	0.4
04/01/2020 12:00	7.4	14.0	6.3	78.3	2,639,019.7	1,329.7	0.9	0.4
04/01/2020 13:00	7.3	13.9	6.2	85.5	2,988,520.6	1,505.8	0.9	0.5
04/01/2020 14:00	7.2	13.9	6.1	87.3	3,100,257.7	1,562.1	0.9	0.5
04/01/2020 15:00	7.2	13.9	6.1	91.5	3,214,039.0	1,642.9	0.9	0.5
04/01/2020 16:00	7.2	13.9	6.1	93.0	3,259,816.9	1,666.3	0.9	0.5
04/01/2020 17:00	7.7	13.9	6.5	90.9	3,144,394.0	1,607.3	0.9	0.5
04/01/2020 18:00	8.6	13.4	6.8	110.7	3,450,607.1	2,015.8	1.0	0.8
04/01/2020 19:00	8.6	13.2	6.6	128.0	3,411,459.1	2,142.4	1.2	1.1
04/01/2020 20:00	8.7	13.3	6.8	135.7	3,383,433.6	2,124.8	1.3	1.1
04/01/2020 21:00	8.6	13.2	6.6	133.0	3,381,204.3	2,123.4	1.3	1.1
04/01/2020 22:00	8.6	13.2	6.6	132.9	3,413,411.1	2,118.7	1.3	1.1
04/01/2020 23:00	8.4	13.3	6.5	126.8	3,373,511.8	2,069.3	1.2	1.0
Average/Sum#:	7.6	13.7	6.3	95.5	3,050,016.8	1,645.7	1.0	0.6
Minimum:	7.1	13.2	6.0	76.2	2,616,592.9	1,318.4	0.9	0.4
Maximum:	8.7	14.0	6.8	135.7	3,450,607.1	2,142.4	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/02/2020 00:00	6.8	13.9	5.7	86.6	3,069,466.9	1,569.0	0.9	0.5
04/02/2020 01:00	7.0	13.9	5.9	85.1	3,009,799.2	1,538.5	0.9	0.5
04/02/2020 02:00	7.1	13.9	6.0	90.6	3,196,040.9	1,633.7	0.9	0.5
04/02/2020 03:00	7.4	13.9	6.2	95.2	3,321,049.8	1,697.6	0.9	0.5
04/02/2020 04:00	7.3	13.9	6.2	94.6	3,306,181.7	1,690.0	0.9	0.5
04/02/2020 05:00	7.1	13.9	6.0	89.3	3,118,766.2	1,594.2	0.9	0.5
04/02/2020 06:00	7.5	13.8	6.2	90.7	3,302,269.1	1,688.0	0.9	0.5
04/02/2020 07:00	7.5	13.9	6.3	93.4	3,213,060.9	1,642.4	0.9	0.5
04/02/2020 08:00	7.5	13.9	6.3	96.0	3,315,767.7	1,694.9	0.9	0.5
04/02/2020 09:00	7.4	13.9	6.2	95.3	3,298,160.8	1,685.9	0.9	0.5
04/02/2020 10:00	7.4	13.9	6.2	93.3	3,246,905.2	1,659.7	0.9	0.5
04/02/2020 11:00	7.3	13.9	6.2	88.7	3,080,618.0	1,574.7	0.9	0.5
04/02/2020 12:00	7.3	13.9	6.2	90.8	3,154,762.5	1,612.6	0.9	0.5
04/02/2020 13:00	7.3	13.9	6.2	93.9	3,315,594.7	1,670.6	0.9	0.5
04/02/2020 14:00	7.3	13.9	6.2	94.2	3,340,998.6	1,683.4	0.9	0.5
04/02/2020 15:00	7.3	13.9	6.2	94.3	3,337,426.2	1,681.6	0.9	0.5
04/02/2020 16:00	7.3	13.9	6.2	92.4	3,265,184.1	1,645.2	0.9	0.5
04/02/2020 17:00	8.1	13.9	6.8	94.3	3,196,627.8	1,634.0	0.9	0.5
04/02/2020 18:00	9.0	13.4	7.1	117.1	3,406,443.2	1,990.0	1.1	0.8
04/02/2020 19:00	8.3	13.3	6.4	112.9	3,424,062.0	2,050.3	1.1	0.8
04/02/2020 20:00	8.3	13.3	6.4	113.1	3,425,231.0	2,051.0	1.1	0.8
04/02/2020 21:00	14.9	14.8	14.4	135.7	2,568,829.5	1,219.3	1.7	0.9
04/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	7.8	13.9	6.6	97.2	3,223,329.4	1,677.6	1.0	0.6
Minimum:	6.8	13.3	5.7	85.1	2,568,829.5	1,219.3	0.9	0.5
Maximum:	14.9	14.8	14.4	135.7	3,425,231.0	2,051.0	1.7	0.9
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/03/2020 20:00	39.4	17.5	68.4	10.7	1,899,350.1	457.7	0.0	0.0
04/03/2020 21:00	36.9	17.2	58.8	256.3	1,876,111.4	520.6	3.9	0.8
04/03/2020 22:00	36.3	15.5	39.7	242.9	2,215,931.5	873.8	3.3	1.1
04/03/2020 23:00	6.7	13.9	5.6	87.8	3,024,471.6	1,546.0	0.9	0.5
Average/Sum#:	29.8	16.0	43.1	149.4	2,253,966.2	849.5	2.0	0.6
Minimum:	6.7	13.9	5.6	10.7	1,876,111.4	457.7	0.0	0.0
Maximum:	39.4	17.5	68.4	256.3	3,024,471.6	1,546.0	3.9	1.1
%SI	83.33	83.33	83.33	83.33	83.33	83.33	83.33	83.33

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/04/2020 00:00	7.0	13.9	5.9	87.3	3,163,761.6	1,617.2	0.9	0.5
04/04/2020 01:00	7.3	13.8	6.1	94.4	3,285,847.0	1,703.6	0.9	0.5
04/04/2020 02:00	7.4	13.8	6.1	84.0	2,850,750.3	1,457.2	0.9	0.4
04/04/2020 03:00	7.3	13.8	6.1	94.3	3,266,366.5	1,693.5	0.9	0.5
04/04/2020 04:00	7.2	13.8	6.0	93.9	3,224,898.0	1,672.0	0.9	0.5
04/04/2020 05:00	7.3	13.8	6.1	94.8	3,264,630.6	1,692.6	0.9	0.5
04/04/2020 06:00	7.3	13.8	6.1	93.2	3,225,669.5	1,672.4	0.9	0.5
04/04/2020 07:00	7.4	13.8	6.1	95.7	3,267,138.0	1,693.9	0.9	0.5
04/04/2020 08:00	7.3	13.8	6.1	94.8	3,245,150.0	1,682.5	0.9	0.5
04/04/2020 09:00	7.3	13.8	6.1	94.1	3,229,141.3	1,674.2	0.9	0.5
04/04/2020 10:00	7.3	13.8	6.1	92.8	3,187,672.8	1,652.7	0.9	0.5
04/04/2020 11:00	7.3	13.8	6.1	94.1	3,234,734.7	1,677.1	0.9	0.5
04/04/2020 12:00	7.4	13.8	6.1	95.2	3,260,773.0	1,690.6	0.9	0.5
04/04/2020 13:00	7.5	13.8	6.2	95.3	3,255,565.4	1,687.9	0.9	0.5
04/04/2020 14:00	7.7	13.8	6.4	96.7	3,275,624.6	1,698.3	0.9	0.5
04/04/2020 15:00	7.5	13.8	6.2	94.3	3,204,260.2	1,661.3	0.9	0.5
04/04/2020 16:00	7.6	13.8	6.3	96.0	3,262,316.1	1,691.4	0.9	0.5
04/04/2020 17:00	7.6	13.8	6.3	93.2	3,188,058.5	1,652.9	0.9	0.5
04/04/2020 18:00	8.9	13.3	6.9	113.2	3,342,564.5	2,001.5	1.1	0.8
04/04/2020 19:00	8.8	13.1	6.7	132.6	3,305,852.0	2,148.5	1.3	1.1
04/04/2020 20:00	8.5	13.1	6.4	126.9	3,308,871.7	2,126.3	1.2	1.1
04/04/2020 21:00	8.4	13.1	6.4	124.6	3,333,525.2	2,117.8	1.2	1.1
04/04/2020 22:00	8.4	13.1	6.4	123.3	3,324,238.3	2,111.9	1.2	1.1
04/04/2020 23:00	8.4	13.1	6.4	123.5	3,327,229.0	2,113.8	1.2	1.1
Average/Sum#:	7.7	13.6	6.2	101.2	3,243,110.0	1,774.6	1.0	0.6
Minimum:	7.0	13.1	5.9	84.0	2,850,750.3	1,457.2	0.9	0.4
Maximum:	8.9	13.9	6.9	132.6	3,342,564.5	2,148.5	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/05/2020 00:00	8.4	13.1	6.4	123.3	3,316,997.7	2,107.3	1.2	1.1
04/05/2020 01:00	7.2	13.7	5.9	97.3	3,227,902.1	1,720.7	1.0	0.7
04/05/2020 02:00	7.1	13.8	5.9	93.3	3,231,455.8	1,675.4	0.9	0.5
04/05/2020 03:00	7.3	13.8	6.1	93.8	3,223,547.8	1,671.3	0.9	0.5
04/05/2020 04:00	7.3	13.8	6.1	94.0	3,220,461.8	1,669.7	0.9	0.5
04/05/2020 05:00	7.4	13.8	6.1	94.9	3,246,693.0	1,683.3	0.9	0.5
04/05/2020 06:00	7.6	13.8	6.3	95.7	3,226,826.8	1,673.0	0.9	0.5
04/05/2020 07:00	7.5	13.8	6.2	93.6	3,168,963.8	1,643.0	0.9	0.5
04/05/2020 08:00	7.7	13.8	6.4	96.2	3,245,342.9	1,682.6	0.9	0.5
04/05/2020 09:00	7.5	13.8	6.2	94.4	3,198,473.9	1,658.3	0.9	0.5
04/05/2020 10:00	7.4	13.8	6.1	93.2	3,166,263.5	1,641.6	0.9	0.5
04/05/2020 11:00	7.5	13.8	6.2	92.1	3,131,931.4	1,623.8	0.9	0.5
04/05/2020 12:00	7.4	13.8	6.1	90.2	3,065,389.0	1,589.3	0.9	0.5
04/05/2020 13:00	7.5	13.9	6.3	94.7	3,267,642.2	1,670.3	0.9	0.5
04/05/2020 14:00	7.4	13.9	6.2	94.1	3,263,142.7	1,668.0	0.9	0.5
04/05/2020 15:00	7.4	13.9	6.2	94.3	3,269,011.6	1,671.0	0.9	0.5
04/05/2020 16:00	8.3	13.6	6.7	102.3	3,270,002.8	1,790.9	1.0	0.7
04/05/2020 17:00	9.1	13.2	7.0	133.1	3,323,720.4	2,087.3	1.3	1.0
04/05/2020 18:00	8.7	13.3	6.8	127.3	3,329,634.6	2,066.7	1.2	1.0
04/05/2020 19:00	8.5	13.3	6.6	122.3	3,322,868.0	2,062.5	1.2	1.0
04/05/2020 20:00	8.3	13.2	6.4	119.1	3,340,912.2	2,073.7	1.1	0.8
04/05/2020 21:00	8.3	13.2	6.4	120.6	3,374,261.7	2,094.4	1.1	0.8
04/05/2020 22:00	8.2	13.3	6.4	117.0	3,370,740.3	2,067.6	1.1	0.8
04/05/2020 23:00	8.2	13.2	6.3	118.0	3,400,737.2	2,086.0	1.1	0.8
Average/Sum#:	7.8	13.6	6.3	104.0	3,258,455.1	1,807.4	1.0	0.7
Minimum:	7.1	13.1	5.9	90.2	3,065,389.0	1,589.3	0.9	0.5
Maximum:	9.1	13.9	7.0	133.1	3,400,737.2	2,107.3	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/06/2020 00:00	8.2	13.2	6.3	118.3	3,370,717.3	2,092.2	1.1	0.8
04/06/2020 01:00	8.2	13.2	6.3	118.6	3,373,778.4	2,094.1	1.1	0.8
04/06/2020 02:00	8.3	13.2	6.4	120.7	3,361,777.6	2,111.2	1.2	1.1
04/06/2020 03:00	8.2	13.2	6.3	119.8	3,389,083.7	2,103.6	1.1	0.8
04/06/2020 04:00	8.1	13.3	6.3	115.1	3,408,711.8	2,066.0	1.1	0.8
04/06/2020 05:00	8.2	13.2	6.3	116.3	3,423,726.0	2,075.1	1.1	0.8
04/06/2020 06:00	8.5	13.2	6.5	125.1	3,411,334.0	2,092.5	1.2	1.0
04/06/2020 07:00	8.4	13.3	6.5	139.5	3,217,832.5	2,044.3	1.4	1.0
04/06/2020 08:00	6.9	13.8	5.7	146.3	1,088,332.0	1,661.0	4.6	3.0
04/06/2020 09:00	7.2	13.8	6.0	136.4	3,237,820.7	1,678.7	1.4	0.8
04/06/2020 10:00	7.4	13.8	6.1	139.3	3,257,301.3	1,688.8	1.4	0.8
04/06/2020 11:00	7.3	13.9	6.2	139.9	3,182,346.6	1,626.7	1.4	0.8
04/06/2020 12:00	7.2	13.9	6.1	131.4	1,061,598.7	1,620.2	4.2	2.6
04/06/2020 13:00	7.3	13.9	6.2	121.1	3,121,505.1	1,595.6	1.2	0.8
04/06/2020 14:00	0.0	0.0	0.0	119.9	3,256,295.6	1,664.5	1.3	0.8
04/06/2020 15:00	7.9	13.9	6.7	110.7	3,275,076.2	1,674.1	1.1	0.7
04/06/2020 16:00	7.8	13.8	6.5	90.1	3,045,599.8	1,556.8	0.9	0.5
04/06/2020 17:00	8.8	13.3	6.8	112.0	3,401,075.3	2,011.7	1.0	0.8
04/06/2020 18:00	8.4	13.3	6.5	113.6	3,363,669.3	2,038.7	1.1	0.8
04/06/2020 19:00	8.2	13.4	6.5	108.4	3,363,543.0	1,989.5	1.0	0.8
04/06/2020 20:00	8.4	13.3	6.5	116.3	3,350,140.0	2,030.5	1.1	0.8
04/06/2020 21:00	8.4	13.3	6.5	121.4	3,372,370.6	2,068.6	1.2	1.0
04/06/2020 22:00	8.3	13.3	6.4	119.8	3,372,859.7	2,068.9	1.1	0.8
04/06/2020 23:00	8.4	13.2	6.4	125.0	3,382,317.1	2,099.4	1.2	1.0
Average/Sum#:	8.0	13.5	6.3	121.9	3,315,403.7	1,906.4	1.2	0.8
Minimum:	6.9	13.2	5.7	90.1	3,045,599.8	1,556.8	0.9	0.5
Maximum:	8.8	13.9	6.8	146.3	3,423,726.0	2,111.2	1.4	1.1
%SI	4.17	4.17	4.17	0.00	8.33	0.00	12.50	12.50

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/07/2020 00:00	8.2	13.3	6.4	114.9	3,404,522.6	2,038.6	1.1	0.8
04/07/2020 01:00	8.1	13.3	6.3	112.5	3,431,337.9	2,029.6	1.0	0.8
04/07/2020 02:00	8.1	13.3	6.3	113.3	3,433,366.7	2,030.8	1.1	0.8
04/07/2020 03:00	8.1	13.3	6.3	111.5	3,422,715.6	2,024.5	1.0	0.8
04/07/2020 04:00	8.2	13.3	6.4	111.5	3,420,517.8	2,023.2	1.0	0.8
04/07/2020 05:00	8.2	13.3	6.4	113.4	3,428,294.8	2,027.8	1.1	0.8
04/07/2020 06:00	8.0	13.4	6.3	112.1	3,407,613.2	1,965.8	1.0	0.8
04/07/2020 07:00	7.0	13.8	5.8	91.6	3,155,269.5	1,635.9	0.9	0.5
04/07/2020 08:00	7.1	13.8	5.9	92.0	3,176,871.7	1,647.1	0.9	0.5
04/07/2020 09:00	7.4	13.8	6.1	94.6	3,243,992.8	1,681.9	0.9	0.5
04/07/2020 10:00	7.4	13.8	6.1	94.8	3,288,770.5	1,681.1	0.9	0.5
04/07/2020 11:00	7.4	13.9	6.2	95.0	3,302,269.1	1,688.0	0.9	0.5
04/07/2020 12:00	7.4	13.9	6.2	94.9	3,291,705.0	1,682.6	0.9	0.5
04/07/2020 13:00	7.4	13.9	6.2	93.0	3,199,757.9	1,635.6	0.9	0.5
04/07/2020 14:00	7.4	13.9	6.2	90.9	3,165,326.6	1,618.0	0.9	0.5
04/07/2020 15:00	7.4	13.9	6.2	94.6	3,292,291.9	1,682.9	0.9	0.5
04/07/2020 16:00	7.3	13.9	6.2	94.5	3,307,355.5	1,690.6	0.9	0.5
04/07/2020 17:00	7.7	13.8	6.4	91.4	3,102,999.9	1,608.8	0.9	0.5
04/07/2020 18:00	8.6	13.3	6.7	109.3	3,361,345.1	1,988.2	1.0	0.8
04/07/2020 19:00	8.5	13.3	6.6	116.0	3,351,459.9	2,031.3	1.1	0.8
04/07/2020 20:00	8.7	13.2	6.7	133.1	3,346,172.6	2,101.4	1.3	1.1
04/07/2020 21:00	8.5	13.2	6.5	129.5	3,313,849.6	2,105.3	1.3	1.1
04/07/2020 22:00	8.4	13.2	6.4	129.1	3,355,726.7	2,107.4	1.2	1.1
04/07/2020 23:00	8.4	13.2	6.4	126.5	3,360,981.5	2,110.7	1.2	1.1
Average/Sum#:	7.9	13.5	6.3	106.7	3,315,188.1	1,868.2	1.0	0.7
Minimum:	7.0	13.2	5.8	90.9	3,102,999.9	1,608.8	0.9	0.5
Maximum:	8.7	13.9	6.7	133.1	3,433,366.7	2,110.7	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/08/2020 00:00	8.2	13.3	6.4	118.7	3,284,173.1	2,014.5	1.2	1.0
04/08/2020 01:00	6.9	13.8	5.7	92.1	3,273,315.5	1,673.2	0.9	0.5
04/08/2020 02:00	7.1	13.8	5.9	91.3	3,214,625.9	1,643.2	0.9	0.5
04/08/2020 03:00	7.4	13.8	6.1	93.9	3,232,998.8	1,676.2	0.9	0.5
04/08/2020 04:00	7.3	13.8	6.1	91.6	3,197,605.9	1,634.5	0.9	0.5
04/08/2020 05:00	7.4	13.8	6.1	94.2	3,240,328.1	1,680.0	0.9	0.5
04/08/2020 06:00	7.4	13.8	6.1	94.6	3,260,387.3	1,690.4	0.9	0.5
04/08/2020 07:00	7.6	13.8	6.3	94.0	3,204,260.2	1,661.3	0.9	0.5
04/08/2020 08:00	7.5	13.8	6.2	94.8	3,253,829.5	1,687.0	0.9	0.5
04/08/2020 09:00	7.6	13.8	6.3	95.7	3,265,980.7	1,693.3	0.9	0.5
04/08/2020 10:00	7.6	13.8	6.3	95.4	3,250,550.6	1,685.3	0.9	0.5
04/08/2020 11:00	7.4	13.8	6.1	92.5	3,226,559.5	1,649.3	0.9	0.5
04/08/2020 12:00	7.5	13.9	6.3	94.7	3,310,485.6	1,692.2	0.9	0.5
04/08/2020 13:00	7.7	13.8	6.4	95.1	3,251,900.7	1,686.0	0.9	0.5
04/08/2020 14:00	8.0	13.8	6.6	96.5	3,266,366.5	1,693.5	0.9	0.5
04/08/2020 15:00	7.6	13.8	6.3	94.6	3,235,892.0	1,677.7	0.9	0.5
04/08/2020 16:00	7.5	13.8	6.2	94.6	3,230,684.3	1,675.0	0.9	0.5
04/08/2020 17:00	8.1	13.6	6.5	100.5	3,242,431.8	1,775.8	1.0	0.7
04/08/2020 18:00	8.9	13.2	6.8	124.4	3,284,572.3	2,086.7	1.2	1.0
04/08/2020 19:00	8.7	13.1	6.6	134.1	3,299,095.5	2,168.2	1.3	1.1
04/08/2020 20:00	8.4	13.1	6.4	123.6	3,314,162.6	2,129.7	1.2	1.1
04/08/2020 21:00	8.3	13.1	6.3	120.7	3,319,358.8	2,108.8	1.2	1.1
04/08/2020 22:00	8.4	13.1	6.4	123.4	3,318,099.5	2,108.0	1.2	1.1
04/08/2020 23:00	8.3	13.2	6.4	122.5	3,321,090.2	2,109.9	1.2	1.1
Average/Sum#:	7.8	13.6	6.3	103.1	3,262,448.1	1,804.2	1.0	0.7
Minimum:	6.9	13.1	5.7	91.3	3,197,605.9	1,634.5	0.9	0.5
Maximum:	8.9	13.9	6.8	134.1	3,321,090.2	2,168.2	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/09/2020 00:00	8.3	13.2	6.4	122.8	3,332,895.6	2,117.4	1.2	1.1
04/09/2020 01:00	8.3	13.2	6.4	121.7	3,332,738.2	2,117.3	1.2	1.1
04/09/2020 02:00	8.3	13.2	6.4	122.9	3,328,016.1	2,114.3	1.2	1.1
04/09/2020 03:00	8.2	13.2	6.3	120.1	3,358,911.4	2,109.4	1.2	1.1
04/09/2020 04:00	8.2	13.2	6.3	116.6	3,341,878.8	2,074.3	1.1	0.8
04/09/2020 05:00	8.2	13.2	6.3	115.9	3,375,142.0	2,070.3	1.1	0.8
04/09/2020 06:00	8.4	13.2	6.4	120.7	3,353,815.9	2,106.2	1.2	1.1
04/09/2020 07:00	8.5	13.2	6.5	121.4	3,357,000.6	2,108.2	1.2	1.1
04/09/2020 08:00	8.3	13.2	6.4	120.6	3,353,019.7	2,105.7	1.2	1.1
04/09/2020 09:00	8.2	13.2	6.3	120.1	3,351,427.3	2,104.7	1.2	1.1
04/09/2020 10:00	8.2	13.2	6.3	119.9	3,343,624.8	2,099.8	1.2	1.0
04/09/2020 11:00	8.2	13.3	6.4	114.9	3,336,504.7	2,046.6	1.1	0.8
04/09/2020 12:00	8.3	13.2	6.4	121.5	3,309,070.7	2,078.1	1.2	1.0
04/09/2020 13:00	8.4	13.2	6.4	123.1	3,308,115.3	2,077.5	1.2	1.0
04/09/2020 14:00	8.3	13.2	6.4	122.8	3,321,095.8	2,061.4	1.2	1.0
04/09/2020 15:00	8.4	13.2	6.4	124.4	3,307,956.1	2,077.4	1.2	1.0
04/09/2020 16:00	8.2	13.2	6.3	118.6	3,328,656.7	2,090.4	1.1	0.8
04/09/2020 17:00	8.2	13.1	6.2	120.1	3,350,949.6	2,104.4	1.2	1.1
04/09/2020 18:00	8.2	13.1	6.2	120.8	3,322,349.5	2,110.7	1.2	1.1
04/09/2020 19:00	8.2	13.1	6.2	123.1	3,350,682.4	2,128.7	1.2	1.1
04/09/2020 20:00	8.2	13.1	6.2	123.4	3,316,652.5	2,131.3	1.2	1.1
04/09/2020 21:00	8.2	13.1	6.2	120.8	3,324,710.6	2,112.2	1.2	1.1
04/09/2020 22:00	8.1	13.2	6.2	118.5	3,335,981.5	2,095.0	1.1	0.8
04/09/2020 23:00	8.2	13.1	6.2	122.6	3,347,534.3	2,126.7	1.2	1.1
Average/Sum#:	8.3	13.2	6.3	120.7	3,337,030.4	2,098.7	1.2	1.0
Minimum:	8.1	13.1	6.2	114.9	3,307,956.1	2,046.6	1.1	0.8
Maximum:	8.5	13.3	6.5	124.4	3,375,142.0	2,131.3	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/10/2020 00:00	8.2	13.1	6.2	121.5	3,369,261.7	2,115.9	1.2	1.1
04/10/2020 01:00	8.1	13.2	6.2	120.1	3,354,771.3	2,106.8	1.2	1.1
04/10/2020 02:00	8.1	13.2	6.2	119.9	3,352,542.0	2,105.4	1.2	1.1
04/10/2020 03:00	8.1	13.2	6.2	119.3	3,345,694.9	2,101.1	1.2	1.1
04/10/2020 04:00	8.0	13.2	6.1	117.0	3,340,428.8	2,073.4	1.1	0.8
04/10/2020 05:00	8.1	13.3	6.3	114.5	3,336,667.7	2,046.7	1.1	0.8
04/10/2020 06:00	8.5	13.2	6.5	128.4	3,346,172.6	2,101.4	1.2	1.1
04/10/2020 07:00	7.3	13.7	6.0	97.1	3,197,324.5	1,704.4	1.0	0.7
04/10/2020 08:00	7.2	13.8	6.0	87.8	3,010,419.1	1,560.8	0.9	0.5
04/10/2020 09:00	7.4	13.8	6.1	94.9	3,254,793.9	1,687.5	0.9	0.5
04/10/2020 10:00	7.4	13.8	6.1	93.6	3,248,861.5	1,660.7	0.9	0.5
04/10/2020 11:00	7.4	13.9	6.2	87.8	3,037,578.9	1,552.7	0.9	0.5
04/10/2020 12:00	7.4	13.9	6.2	94.0	3,266,468.4	1,669.7	0.9	0.5
04/10/2020 13:00	7.5	13.9	6.3	89.4	3,076,705.3	1,572.7	0.9	0.5
04/10/2020 14:00	7.5	13.8	6.2	91.0	3,139,698.8	1,604.9	0.9	0.5
04/10/2020 15:00	7.7	13.8	6.4	93.5	3,191,916.1	1,654.9	0.9	0.5
04/10/2020 16:00	7.8	13.8	6.5	93.9	3,205,996.1	1,662.2	0.9	0.5
04/10/2020 17:00	7.7	13.8	6.4	85.8	2,846,281.1	1,475.7	0.9	0.4
04/10/2020 18:00	8.9	13.2	6.8	116.2	3,292,257.3	2,043.5	1.1	0.8
04/10/2020 19:00	8.6	13.1	6.5	123.5	3,272,457.4	2,102.9	1.2	1.1
04/10/2020 20:00	8.5	13.1	6.4	120.2	3,308,752.2	2,077.9	1.2	1.0
04/10/2020 21:00	8.5	13.2	6.5	118.7	3,290,917.9	2,066.7	1.2	1.0
04/10/2020 22:00	8.5	13.2	6.5	118.5	3,322,706.9	2,062.4	1.1	0.8
04/10/2020 23:00	8.1	13.4	6.4	104.6	3,320,767.5	1,915.7	1.0	0.8
Average/Sum#:	7.9	13.5	6.3	106.3	3,238,726.7	1,863.6	1.0	0.8
Minimum:	7.2	13.1	6.0	85.8	2,846,281.1	1,475.7	0.9	0.4
Maximum:	8.9	13.9	6.8	128.4	3,369,261.7	2,115.9	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/11/2020 00:00	7.0	13.8	5.8	90.3	3,117,272.8	1,616.2	0.9	0.5
04/11/2020 01:00	7.3	13.8	6.1	93.8	3,237,820.7	1,678.7	0.9	0.5
04/11/2020 02:00	7.3	13.8	6.1	94.2	3,240,328.1	1,680.0	0.9	0.5
04/11/2020 03:00	7.3	13.8	6.1	94.0	3,227,405.4	1,673.3	0.9	0.5
04/11/2020 04:00	7.3	13.8	6.1	93.8	3,215,254.2	1,667.0	0.9	0.5
04/11/2020 05:00	7.3	13.8	6.1	94.2	3,227,984.0	1,673.6	0.9	0.5
04/11/2020 06:00	7.4	13.8	6.1	91.7	3,097,406.5	1,605.9	0.9	0.5
04/11/2020 07:00	7.6	13.8	6.3	95.6	3,248,043.2	1,684.0	0.9	0.5
04/11/2020 08:00	7.6	13.8	6.3	95.1	3,221,040.5	1,670.0	0.9	0.5
04/11/2020 09:00	7.7	13.8	6.4	95.5	3,219,304.6	1,669.1	0.9	0.5
04/11/2020 10:00	7.7	13.8	6.4	95.7	3,226,248.1	1,672.7	0.9	0.5
04/11/2020 11:00	7.6	13.8	6.3	95.6	3,281,140.8	1,677.2	0.9	0.5
04/11/2020 12:00	7.6	13.8	6.3	90.1	3,070,836.4	1,569.7	0.9	0.5
04/11/2020 13:00	7.7	13.8	6.4	94.1	3,249,839.7	1,661.2	0.9	0.5
04/11/2020 14:00	7.8	13.8	6.5	95.3	3,228,755.5	1,674.0	0.9	0.5
04/11/2020 15:00	7.9	13.8	6.6	95.9	3,226,441.0	1,672.8	0.9	0.5
04/11/2020 16:00	7.9	13.8	6.6	97.0	3,262,701.8	1,691.6	0.9	0.5
04/11/2020 17:00	7.8	13.8	6.5	96.1	3,235,506.2	1,677.5	0.9	0.5
04/11/2020 18:00	7.7	13.8	6.4	89.9	3,044,365.4	1,578.4	0.9	0.5
04/11/2020 19:00	9.1	13.3	7.1	115.7	3,312,522.1	2,007.7	1.1	0.8
04/11/2020 20:00	8.7	13.2	6.7	121.5	3,304,018.3	2,050.8	1.2	1.0
04/11/2020 21:00	8.5	13.2	6.5	122.4	3,303,497.5	2,074.6	1.2	1.0
04/11/2020 22:00	8.4	13.2	6.4	117.0	3,326,071.0	2,040.2	1.1	0.8
04/11/2020 23:00	8.2	13.3	6.4	111.5	3,295,636.7	1,973.4	1.1	0.8
Average/Sum#:	7.8	13.7	6.4	99.0	3,225,810.0	1,735.0	1.0	0.6
Minimum:	7.0	13.2	5.8	89.9	3,044,365.4	1,569.7	0.9	0.5
Maximum:	9.1	13.8	7.1	122.4	3,326,071.0	2,074.6	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/12/2020 00:00	7.1	13.8	5.9	92.4	3,205,417.4	1,661.9	0.9	0.5
04/12/2020 01:00	7.3	13.8	6.1	94.2	3,248,236.1	1,684.1	0.9	0.5
04/12/2020 02:00	7.3	13.8	6.1	94.5	3,243,028.4	1,681.4	0.9	0.5
04/12/2020 03:00	7.3	13.8	6.1	90.6	3,086,026.8	1,600.0	0.9	0.5
04/12/2020 04:00	7.4	13.8	6.1	94.3	3,227,212.5	1,673.2	0.9	0.5
04/12/2020 05:00	7.4	13.8	6.1	95.1	3,255,372.5	1,687.8	0.9	0.5
04/12/2020 06:00	7.5	13.8	6.2	95.9	3,153,726.5	1,635.1	1.0	0.7
04/12/2020 07:00	7.8	13.8	6.5	96.9	3,263,473.3	1,692.0	0.9	0.5
04/12/2020 08:00	7.8	13.8	6.5	97.2	3,268,681.0	1,694.7	0.9	0.5
04/12/2020 09:00	7.6	13.8	6.3	95.4	3,219,304.6	1,669.1	0.9	0.5
04/12/2020 10:00	7.6	13.8	6.3	94.3	3,184,586.8	1,651.1	0.9	0.5
04/12/2020 11:00	7.5	13.9	6.3	90.6	3,132,460.5	1,601.2	0.9	0.5
04/12/2020 12:00	7.5	13.9	6.3	94.4	3,272,337.4	1,672.7	0.9	0.5
04/12/2020 13:00	7.6	13.9	6.4	94.9	3,278,402.0	1,675.8	0.9	0.5
04/12/2020 14:00	8.0	13.9	6.7	96.9	3,301,877.8	1,687.8	0.9	0.5
04/12/2020 15:00	7.9	13.9	6.7	96.2	3,256,686.8	1,664.7	0.9	0.5
04/12/2020 16:00	8.5	13.9	7.2	103.6	3,292,683.1	1,683.1	1.0	0.7
04/12/2020 17:00	7.8	13.9	6.6	90.8	3,094,105.2	1,559.0	0.9	0.5
04/12/2020 18:00	7.2	14.0	6.2	91.2	3,204,651.5	1,614.7	0.9	0.5
04/12/2020 19:00	7.4	13.9	6.2	92.1	3,189,585.0	1,630.4	0.9	0.5
04/12/2020 20:00	7.4	13.9	6.2	92.9	3,205,822.5	1,638.7	0.9	0.5
04/12/2020 21:00	7.5	13.9	6.3	92.6	3,188,411.2	1,629.8	0.9	0.5
04/12/2020 22:00	7.5	13.9	6.3	92.6	3,176,673.3	1,623.8	0.9	0.5
04/12/2020 23:00	8.3	13.6	6.7	103.0	3,321,128.0	1,818.9	1.0	0.7
Average/Sum#:	7.6	13.8	6.3	94.7	3,219,578.8	1,659.6	0.9	0.5
Minimum:	7.1	13.6	5.9	90.6	3,086,026.8	1,559.0	0.9	0.5
Maximum:	8.5	14.0	7.2	103.6	3,321,128.0	1,818.9	1.0	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/13/2020 00:00	8.8	13.3	6.8	123.9	3,306,996.9	2,028.5	1.2	1.0
04/13/2020 01:00	7.1	13.8	5.9	93.9	3,256,722.6	1,688.5	0.9	0.5
04/13/2020 02:00	7.3	13.8	6.1	94.3	3,260,194.4	1,690.3	0.9	0.5
04/13/2020 03:00	7.3	13.8	6.1	93.2	3,223,933.6	1,671.5	0.9	0.5
04/13/2020 04:00	7.3	13.8	6.1	91.7	3,157,584.0	1,637.1	0.9	0.5
04/13/2020 05:00	7.3	13.8	6.1	93.2	3,208,889.2	1,663.7	0.9	0.5
04/13/2020 06:00	7.5	13.8	6.2	93.7	3,282,705.9	1,678.0	0.9	0.5
04/13/2020 07:00	7.6	13.9	6.4	94.0	3,241,231.9	1,656.8	0.9	0.5
04/13/2020 08:00	7.4	13.9	6.2	94.1	3,266,272.8	1,669.6	0.9	0.5
04/13/2020 09:00	7.4	13.9	6.2	94.9	3,318,506.5	1,696.3	0.9	0.5
04/13/2020 10:00	7.3	13.9	6.2	94.3	3,310,094.4	1,692.0	0.9	0.5
04/13/2020 11:00	7.2	13.9	6.1	93.7	3,312,050.7	1,693.0	0.9	0.5
04/13/2020 12:00	7.4	13.9	6.2	93.8	3,273,902.4	1,673.5	0.9	0.5
04/13/2020 13:00	7.6	13.9	6.4	91.4	3,150,654.2	1,610.5	0.9	0.5
04/13/2020 14:00	7.4	13.9	6.2	93.8	3,281,140.8	1,677.2	0.9	0.5
04/13/2020 15:00	7.7	13.8	6.4	95.8	3,254,215.2	1,687.2	0.9	0.5
04/13/2020 16:00	7.7	13.8	6.4	94.2	3,195,002.1	1,656.5	0.9	0.5
04/13/2020 17:00	8.0	13.9	6.7	88.5	2,995,126.8	1,531.0	0.9	0.5
04/13/2020 18:00	9.3	13.3	7.2	118.7	3,400,399.1	2,011.3	1.1	0.8
04/13/2020 19:00	9.2	13.2	7.0	128.9	3,392,628.1	2,105.8	1.2	1.1
04/13/2020 20:00	9.1	13.2	7.0	127.0	3,378,289.4	2,096.9	1.2	1.0
04/13/2020 21:00	9.2	13.2	7.0	128.0	3,383,444.9	2,100.1	1.2	1.1
04/13/2020 22:00	9.1	13.3	7.1	130.4	3,422,241.0	2,074.2	1.2	1.0
04/13/2020 23:00	8.9	13.5	7.1	127.3	3,334,288.4	1,923.5	1.2	1.0
Average/Sum#:	7.9	13.7	6.5	103.0	3,275,271.5	1,775.5	1.0	0.6
Minimum:	7.1	13.2	5.9	88.5	2,995,126.8	1,531.0	0.9	0.5
Maximum:	9.3	13.9	7.2	130.4	3,422,241.0	2,105.8	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/14/2020 00:00	6.8	13.9	5.7	94.3	3,375,044.2	1,725.2	0.9	0.5
04/14/2020 01:00	7.0	13.9	5.9	84.9	2,982,410.7	1,524.5	0.9	0.5
04/14/2020 02:00	7.0	13.9	5.9	90.0	3,190,563.2	1,630.9	0.9	0.5
04/14/2020 03:00	7.0	13.9	5.9	85.0	3,009,016.6	1,538.1	0.9	0.5
04/14/2020 04:00	7.0	13.9	5.9	90.7	3,204,648.7	1,638.1	0.9	0.5
04/14/2020 05:00	6.8	13.9	5.7	87.3	3,118,375.0	1,594.0	0.9	0.5
04/14/2020 06:00	7.3	13.9	6.2	87.2	3,276,641.3	1,674.9	0.8	0.5
04/14/2020 07:00	7.3	13.9	6.2	89.6	3,113,484.2	1,591.5	0.9	0.5
04/14/2020 08:00	7.3	13.9	6.2	91.9	3,211,691.4	1,641.7	0.9	0.5
04/14/2020 09:00	7.1	13.9	6.0	92.1	3,260,990.7	1,666.9	0.9	0.5
04/14/2020 10:00	7.1	13.9	6.0	92.7	3,344,967.9	1,685.4	0.9	0.5
04/14/2020 11:00	7.0	13.9	5.9	92.1	3,334,250.7	1,680.0	0.9	0.5
04/14/2020 12:00	7.1	14.0	6.1	87.1	3,106,410.2	1,565.2	0.9	0.5
04/14/2020 13:00	7.4	13.9	6.2	93.9	3,309,507.5	1,691.7	0.9	0.5
04/14/2020 14:00	7.3	13.9	6.2	92.9	3,273,315.5	1,673.2	0.9	0.5
04/14/2020 15:00	7.5	13.9	6.3	93.4	3,253,948.0	1,663.3	0.9	0.5
04/14/2020 16:00	7.3	13.9	6.2	89.1	3,163,171.9	1,593.8	0.9	0.5
04/14/2020 17:00	8.0	13.9	6.7	90.9	3,013,320.5	1,540.3	0.9	0.5
04/14/2020 18:00	9.1	13.3	7.1	118.4	3,392,707.7	2,056.3	1.1	0.8
04/14/2020 19:00	9.2	13.2	7.0	128.2	3,349,835.0	2,103.7	1.2	1.1
04/14/2020 20:00	9.1	13.2	7.0	126.7	3,366,206.2	2,089.4	1.2	1.0
04/14/2020 21:00	9.0	13.3	7.0	120.3	3,382,643.2	2,050.2	1.1	0.8
04/14/2020 22:00	9.1	13.2	7.0	124.9	3,357,184.2	2,083.8	1.2	1.0
04/14/2020 23:00	9.0	13.3	7.0	122.0	3,417,951.3	2,071.6	1.1	0.8
Average/Sum#:	7.7	13.7	6.3	98.6	3,242,011.9	1,740.6	1.0	0.6
Minimum:	6.8	13.2	5.7	84.9	2,982,410.7	1,524.5	0.8	0.5
Maximum:	9.2	14.0	7.1	128.2	3,417,951.3	2,103.7	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/15/2020 00:00	8.6	13.4	6.8	113.3	3,378,664.6	1,949.1	1.1	0.8
04/15/2020 01:00	6.9	13.9	5.8	88.8	3,120,331.3	1,595.0	0.9	0.5
04/15/2020 02:00	7.1	13.9	6.0	92.6	3,269,402.9	1,671.2	0.9	0.5
04/15/2020 03:00	7.0	13.9	5.9	88.0	3,091,573.4	1,580.3	0.9	0.5
04/15/2020 04:00	6.9	13.9	5.8	86.3	3,063,793.6	1,566.1	0.9	0.5
04/15/2020 05:00	7.2	13.9	6.1	93.2	3,291,509.3	1,682.5	0.9	0.5
04/15/2020 06:00	7.4	13.9	6.2	94.5	3,284,466.6	1,678.9	0.9	0.5
04/15/2020 07:00	7.4	13.9	6.2	93.3	3,233,993.5	1,653.1	0.9	0.5
04/15/2020 08:00	7.3	13.9	6.2	94.3	3,293,661.3	1,683.6	0.9	0.5
04/15/2020 09:00	7.3	13.9	6.2	94.4	3,298,356.4	1,686.0	0.9	0.5
04/15/2020 10:00	7.2	13.9	6.1	93.7	3,313,224.5	1,693.6	0.9	0.5
04/15/2020 11:00	7.3	13.9	6.2	93.7	3,312,050.7	1,693.0	0.9	0.5
04/15/2020 12:00	7.3	13.9	6.2	93.3	3,279,575.8	1,676.4	0.9	0.5
04/15/2020 13:00	7.7	13.8	6.4	95.2	3,265,595.0	1,693.1	0.9	0.5
04/15/2020 14:00	8.2	13.8	6.8	96.5	3,222,390.6	1,670.7	0.9	0.5
04/15/2020 15:00	8.2	13.8	6.8	94.3	3,143,889.8	1,630.0	0.9	0.5
04/15/2020 16:00	8.1	13.8	6.7	94.5	3,158,162.7	1,637.4	0.9	0.5
04/15/2020 17:00	8.0	13.8	6.6	89.5	2,967,738.3	1,517.0	0.9	0.5
04/15/2020 18:00	9.1	13.2	7.0	118.2	3,320,202.0	2,036.6	1.1	0.8
04/15/2020 19:00	9.2	13.1	7.0	130.7	3,294,399.3	2,117.0	1.3	1.1
04/15/2020 20:00	9.2	13.1	7.0	131.0	3,304,047.6	2,123.2	1.3	1.1
04/15/2020 21:00	9.0	13.2	6.9	124.2	3,304,134.4	2,075.0	1.2	1.0
04/15/2020 22:00	8.7	13.4	6.8	109.7	3,342,764.9	1,952.8	1.0	0.8
04/15/2020 23:00	8.5	13.4	6.7	107.8	3,315,220.4	1,912.5	1.0	0.8
Average/Sum#:	7.9	13.7	6.4	100.5	3,244,547.9	1,757.3	1.0	0.6
Minimum:	6.9	13.1	5.8	86.3	2,967,738.3	1,517.0	0.9	0.5
Maximum:	9.2	13.9	7.0	131.0	3,378,664.6	2,123.2	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/16/2020 00:00	7.0	13.9	5.9	84.5	2,945,045.0	1,505.4	0.9	0.5
04/16/2020 01:00	6.9	13.9	5.8	82.7	2,923,134.2	1,494.2	0.9	0.4
04/16/2020 02:00	7.0	13.9	5.9	84.5	2,983,975.7	1,525.3	0.9	0.5
04/16/2020 03:00	7.0	13.9	5.9	82.8	2,919,417.2	1,492.3	0.9	0.4
04/16/2020 04:00	7.1	13.8	5.9	87.6	3,088,638.9	1,578.8	0.9	0.5
04/16/2020 05:00	7.3	13.9	6.2	93.0	3,264,707.7	1,668.8	0.9	0.5
04/16/2020 06:00	7.1	13.9	6.0	88.9	3,024,275.9	1,545.9	0.9	0.5
04/16/2020 07:00	7.4	13.9	6.2	92.6	3,227,537.6	1,649.8	0.9	0.5
04/16/2020 08:00	7.3	13.9	6.2	94.0	3,293,270.0	1,683.4	0.9	0.5
04/16/2020 09:00	7.2	13.9	6.1	93.0	3,265,490.3	1,669.2	0.9	0.5
04/16/2020 10:00	7.2	13.9	6.1	93.7	3,306,573.0	1,690.2	0.9	0.5
04/16/2020 11:00	7.3	13.9	6.2	92.6	3,259,621.3	1,666.2	0.9	0.5
04/16/2020 12:00	7.8	13.8	6.5	95.9	3,277,553.3	1,699.3	0.9	0.5
04/16/2020 13:00	7.8	13.8	6.5	95.4	3,248,814.7	1,684.4	0.9	0.5
04/16/2020 14:00	7.7	13.9	6.5	91.1	3,123,852.7	1,596.8	0.9	0.5
04/16/2020 15:00	7.9	13.8	6.6	93.4	3,201,714.2	1,636.6	0.9	0.5
04/16/2020 16:00	7.5	13.9	6.3	91.5	3,190,367.6	1,630.8	0.9	0.5
04/16/2020 17:00	7.5	13.9	6.3	88.8	3,059,098.4	1,563.7	0.9	0.5
04/16/2020 18:00	9.0	13.2	6.9	114.4	3,339,085.6	2,023.8	1.1	0.8
04/16/2020 19:00	9.2	13.1	7.0	129.8	3,286,151.7	2,111.7	1.3	1.1
04/16/2020 20:00	9.2	13.1	7.0	133.3	3,288,618.8	2,137.3	1.3	1.1
04/16/2020 21:00	9.1	13.1	6.9	129.0	3,285,218.0	2,111.1	1.3	1.1
04/16/2020 22:00	8.8	13.3	6.8	113.6	3,323,860.2	1,990.3	1.1	0.8
04/16/2020 23:00	8.6	13.3	6.7	107.4	3,293,808.0	1,924.2	1.0	0.8
Average/Sum#:	7.7	13.7	6.4	98.1	3,184,159.6	1,720.0	1.0	0.6
Minimum:	6.9	13.1	5.8	82.7	2,919,417.2	1,492.3	0.9	0.4
Maximum:	9.2	13.9	7.0	133.3	3,339,085.6	2,137.3	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/17/2020 00:00	7.4	13.8	6.1	83.3	2,838,034.2	1,450.7	0.9	0.4
04/17/2020 01:00	7.4	13.8	6.1	77.1	2,646,119.2	1,352.6	0.9	0.4
04/17/2020 02:00	7.4	13.8	6.1	77.0	2,616,383.1	1,337.4	0.9	0.4
04/17/2020 03:00	7.4	13.8	6.1	77.0	2,615,013.7	1,336.7	0.9	0.4
04/17/2020 04:00	7.5	13.9	6.3	77.4	2,568,453.2	1,312.9	0.9	0.4
04/17/2020 05:00	7.4	13.8	6.1	93.3	3,221,426.2	1,670.2	0.9	0.5
04/17/2020 06:00	7.5	13.8	6.2	92.3	3,160,670.1	1,638.7	0.9	0.5
04/17/2020 07:00	7.5	13.8	6.2	90.8	3,153,588.7	1,612.0	0.9	0.5
04/17/2020 08:00	7.4	13.9	6.2	94.5	3,275,663.1	1,674.4	0.9	0.5
04/17/2020 09:00	7.3	13.9	6.2	92.7	3,233,015.3	1,652.6	0.9	0.5
04/17/2020 10:00	7.3	13.9	6.2	88.7	3,055,772.7	1,562.0	0.9	0.5
04/17/2020 11:00	7.3	13.9	6.2	91.6	3,229,494.0	1,650.8	0.9	0.5
04/17/2020 12:00	7.3	13.9	6.2	85.0	2,901,393.5	1,461.9	0.9	0.4
04/17/2020 13:00	7.4	13.9	6.2	90.6	3,163,761.6	1,617.2	0.9	0.5
04/17/2020 14:00	8.0	13.8	6.6	96.1	3,234,541.8	1,677.0	0.9	0.5
04/17/2020 15:00	8.2	13.8	6.8	96.8	3,255,372.5	1,687.8	0.9	0.5
04/17/2020 16:00	8.2	13.8	6.8	95.9	3,193,073.3	1,655.5	0.9	0.5
04/17/2020 17:00	8.0	13.8	6.6	90.8	2,989,649.1	1,528.2	0.9	0.5
04/17/2020 18:00	9.0	13.2	6.9	115.1	3,343,870.4	2,026.7	1.1	0.8
04/17/2020 19:00	8.9	13.2	6.8	119.9	3,295,535.7	2,069.6	1.2	1.0
04/17/2020 20:00	8.8	13.2	6.7	118.6	3,325,123.5	2,063.9	1.1	0.8
04/17/2020 21:00	8.7	13.2	6.7	117.2	3,345,145.1	2,051.9	1.1	0.8
04/17/2020 22:00	8.6	13.2	6.6	118.3	3,372,207.5	2,068.5	1.1	0.8
04/17/2020 23:00	14.2	14.6	13.3	136.8	2,565,524.6	1,255.2	1.7	0.9
Average/Sum#:	8.1	13.7	6.7	96.5	3,066,618.0	1,642.3	1.0	0.6
Minimum:	7.3	13.2	6.1	77.0	2,565,524.6	1,255.2	0.9	0.4
Maximum:	14.2	14.6	13.3	136.8	3,372,207.5	2,069.6	1.7	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/18/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/18/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/19/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2020 17:00	35.4	17.4	59.7	0.0	1,913,044.4	461.0	-0.1	0.0
04/19/2020 18:00	35.9	17.1	55.7	210.9	1,878,634.0	521.3	3.3	0.7
04/19/2020 19:00	36.4	15.5	39.8	243.6	2,175,102.4	857.7	3.4	1.1
04/19/2020 20:00	6.8	13.9	5.7	81.9	2,706,960.7	1,383.7	1.0	0.6
04/19/2020 21:00	7.1	13.9	6.0	82.0	2,800,668.5	1,431.6	0.9	0.4
04/19/2020 22:00	7.3	13.9	6.2	79.4	2,634,381.3	1,346.6	0.9	0.4
04/19/2020 23:00	7.5	13.9	6.3	79.7	2,625,382.2	1,342.0	0.9	0.4
Average/Sum#:	19.5	15.1	25.6	111.1	2,390,596.2	1,049.1	1.5	0.5
Minimum:	6.8	13.9	5.7	0.0	1,878,634.0	461.0	-0.1	0.0
Maximum:	36.4	17.4	59.7	243.6	2,800,668.5	1,431.6	3.4	1.1
%SI	70.83	70.83	70.83	70.83	70.83	70.83	70.83	70.83

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/20/2020 00:00	7.4	13.9	6.2	80.4	2,616,774.4	1,337.6	1.0	0.5
04/20/2020 01:00	7.4	13.9	6.2	79.6	2,628,512.3	1,343.6	0.9	0.4
04/20/2020 02:00	7.2	13.8	6.0	89.1	3,082,555.0	1,598.2	0.9	0.5
04/20/2020 03:00	7.4	13.8	6.1	84.5	2,853,224.6	1,479.3	0.9	0.4
04/20/2020 04:00	7.4	13.8	6.1	93.9	3,227,405.4	1,673.3	0.9	0.5
04/20/2020 05:00	7.4	13.8	6.1	94.7	3,250,357.7	1,685.2	0.9	0.5
04/20/2020 06:00	7.4	13.8	6.1	93.5	3,231,070.0	1,675.2	0.9	0.5
04/20/2020 07:00	7.7	13.8	6.4	95.8	3,255,565.4	1,687.9	0.9	0.5
04/20/2020 08:00	7.4	13.8	6.1	92.7	3,170,892.5	1,644.0	0.9	0.5
04/20/2020 09:00	7.3	13.8	6.1	89.7	3,067,703.5	1,590.5	0.9	0.5
04/20/2020 10:00	7.5	13.8	6.2	89.4	3,048,994.5	1,580.8	0.9	0.5
04/20/2020 11:00	7.6	13.8	6.3	95.1	3,245,728.7	1,682.8	0.9	0.5
04/20/2020 12:00	7.5	13.8	6.2	94.4	3,268,816.0	1,670.9	0.9	0.5
04/20/2020 13:00	7.5	13.9	6.3	94.3	3,287,596.7	1,680.5	0.9	0.5
04/20/2020 14:00	7.5	13.9	6.3	86.5	2,974,194.1	1,520.3	0.9	0.5
04/20/2020 15:00	7.6	13.9	6.4	93.7	3,240,253.7	1,656.3	0.9	0.5
04/20/2020 16:00	7.6	13.9	6.4	91.5	3,166,696.1	1,618.7	0.9	0.5
04/20/2020 17:00	7.7	13.9	6.5	89.0	3,011,559.9	1,539.4	0.9	0.5
04/20/2020 18:00	9.0	13.3	7.0	112.8	3,350,246.7	2,006.1	1.1	0.8
04/20/2020 19:00	8.9	13.2	6.8	117.4	3,347,427.5	2,053.3	1.1	0.8
04/20/2020 20:00	8.7	13.2	6.7	116.8	3,348,405.6	2,053.9	1.1	0.8
04/20/2020 21:00	8.7	13.2	6.7	117.1	3,355,904.9	2,058.5	1.1	0.8
04/20/2020 22:00	8.4	13.4	6.6	109.7	3,316,204.9	1,961.5	1.0	0.8
04/20/2020 23:00	21.6	16.2	27.1	171.7	1,551,477.3	577.8	3.5	0.8
Average/Sum#:	8.3	13.8	7.2	98.9	3,079,065.3	1,640.7	1.1	0.6
Minimum:	7.2	13.2	6.0	79.6	1,551,477.3	577.8	0.9	0.4
Maximum:	21.6	16.2	27.1	171.7	3,355,904.9	2,058.5	3.5	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/21/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 04:00	34.5	17.4	58.2	3.2	1,937,943.0	467.0	0.0	0.0
04/22/2020 05:00	33.0	17.1	51.2	252.8	1,891,967.9	525.0	3.9	0.8
04/22/2020 06:00	34.0	16.3	43.6	249.8	2,196,609.4	834.1	3.3	1.1
04/22/2020 07:00	8.0	13.7	6.6	110.1	3,401,307.8	1,788.3	1.0	0.7
04/22/2020 08:00	8.4	13.6	6.8	102.8	3,395,031.3	1,785.0	0.9	0.5
04/22/2020 09:00	7.6	13.9	6.4	86.6	2,640,641.5	1,349.8	1.0	0.5
04/22/2020 10:00	7.8	13.9	6.6	82.1	2,554,367.7	1,305.7	1.0	0.5
04/22/2020 11:00	7.4	13.9	6.2	86.4	2,968,912.1	1,517.6	0.9	0.5
04/22/2020 12:00	7.5	13.9	6.3	87.3	2,967,933.9	1,517.1	0.9	0.5
04/22/2020 13:00	27.8	16.8	40.0	202.3	1,205,391.2	404.9	5.2	0.8
04/22/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/22/2020 18:00	23.6	18.0	48.0	64.6	1,777,870.1	298.6	0.5	0.1
04/22/2020 19:00	38.4	15.6	42.7	218.6	2,214,517.2	840.9	2.9	0.9
04/22/2020 20:00	6.9	13.9	5.8	87.8	2,884,985.9	1,474.7	1.0	0.6
04/22/2020 21:00	7.2	13.9	6.1	87.5	3,012,929.3	1,540.1	0.9	0.5
04/22/2020 22:00	7.3	13.9	6.2	83.4	2,746,869.7	1,404.1	0.9	0.4
04/22/2020 23:00	7.4	13.9	6.2	82.0	2,638,880.8	1,348.9	1.0	0.5
Average/Sum#:	16.7	15.0	21.7	118.0	2,527,259.9	1,150.1	1.6	0.6
Minimum:	6.9	13.6	5.8	3.2	1,205,391.2	298.6	0.0	0.0
Maximum:	38.4	18.0	58.2	252.8	3,401,307.8	1,788.3	5.2	1.1
%SI	33.33	33.33	33.33	33.33	33.33	33.33	33.33	33.33

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/23/2020 00:00	7.5	13.9	6.3	82.0	2,632,424.9	1,345.6	1.0	0.5
04/23/2020 01:00	7.4	13.9	6.2	83.2	2,611,687.9	1,335.0	1.0	0.5
04/23/2020 02:00	28.7	17.2	45.8	200.1	1,082,823.4	332.1	5.7	0.7
04/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	14.5	15.0	19.4	121.8	2,108,978.7	1,004.2	2.6	0.6
Minimum:	7.4	13.9	6.2	82.0	1,082,823.4	332.1	1.0	0.5
Maximum:	28.7	17.2	45.8	200.1	2,632,424.9	1,345.6	5.7	0.7
%SI	87.50	87.50	87.50	87.50	87.50	87.50	87.50	87.50

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/24/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/24/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/24/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/24/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/24/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/24/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/24/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/24/2020 09:00	36.9	17.4	62.2	0.0	1,896,860.3	457.1	-0.1	0.0
04/24/2020 10:00	37.7	17.1	58.5	246.7	1,882,958.5	522.5	3.8	0.8
04/24/2020 11:00	41.1	15.2	42.5	248.6	2,157,924.5	898.2	3.5	1.2
04/24/2020 12:00	6.8	13.9	5.7	84.8	2,727,139.2	1,374.1	1.0	0.5
04/24/2020 13:00	7.2	13.9	6.1	83.9	2,703,521.6	1,362.2	1.0	0.5
04/24/2020 14:00	7.2	13.9	6.1	87.3	3,018,290.7	1,520.8	0.9	0.5
04/24/2020 15:00	7.2	13.9	6.1	86.1	2,963,513.8	1,493.2	0.9	0.4
04/24/2020 16:00	7.6	13.9	6.4	89.0	2,984,758.3	1,525.7	0.9	0.5
04/24/2020 17:00	7.8	13.9	6.6	91.1	3,036,992.0	1,552.4	0.9	0.5
04/24/2020 18:00	8.8	13.3	6.8	112.1	3,211,133.2	1,922.8	1.1	0.8
04/24/2020 19:00	9.0	13.1	6.8	126.5	3,261,384.2	2,119.6	1.2	1.1
04/24/2020 20:00	8.8	13.1	6.7	124.5	3,277,125.9	2,105.9	1.2	1.1
04/24/2020 21:00	8.5	13.3	6.6	110.9	3,261,568.1	1,953.0	1.1	0.8
04/24/2020 22:00	13.5	14.8	13.1	120.3	2,227,814.4	1,024.9	1.7	0.7
04/24/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	14.9	14.3	17.2	115.1	2,757,927.5	1,416.6	1.4	0.7
Minimum:	6.8	13.1	5.7	0.0	1,882,958.5	457.1	-0.1	0.0
Maximum:	41.1	17.4	62.2	248.6	3,277,125.9	2,119.6	3.8	1.2
%SI	41.67	41.67	41.67	41.67	41.67	41.67	41.67	41.67

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/27/2020 13:00	36.7	17.4	61.9	0.0	1,892,710.5	456.1	-0.1	0.0
04/27/2020 14:00	46.6	16.2	58.5	213.8	1,851,053.9	635.3	3.5	0.8
04/27/2020 15:00	32.7	14.8	31.6	222.9	2,255,733.8	1,004.8	3.1	1.2
04/27/2020 16:00	6.9	13.9	5.8	83.4	2,794,995.2	1,428.7	0.9	0.4
04/27/2020 17:00	8.5	13.3	6.6	106.5	3,287,802.0	1,944.7	1.0	0.8
04/27/2020 18:00	8.7	13.3	6.8	110.6	3,267,314.6	1,980.3	1.1	0.8
04/27/2020 19:00	8.7	13.3	6.8	109.7	3,292,129.6	1,971.3	1.1	0.8
04/27/2020 20:00	8.6	13.3	6.7	107.5	3,265,316.4	1,931.4	1.0	0.8
04/27/2020 21:00	7.5	13.9	6.3	82.7	2,756,260.0	1,408.9	0.9	0.4
04/27/2020 22:00	7.3	13.9	6.2	82.4	2,776,018.9	1,419.0	0.9	0.4
04/27/2020 23:00	7.3	13.9	6.2	84.1	2,882,051.4	1,473.2	0.9	0.4
Average/Sum#:	16.3	14.3	18.5	109.4	2,756,489.7	1,423.1	1.3	0.6
Minimum:	6.9	13.3	5.8	0.0	1,851,053.9	456.1	-0.1	0.0
Maximum:	46.6	17.4	61.9	222.9	3,292,129.6	1,980.3	3.5	1.2
%SI	54.17	54.17	54.17	54.17	54.17	54.17	54.17	54.17

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/28/2020 00:00	7.2	13.9	6.1	80.5	2,709,504.0	1,385.0	0.9	0.4
04/28/2020 01:00	7.2	13.9	6.1	79.8	2,711,264.6	1,385.9	0.9	0.4
04/28/2020 02:00	7.2	13.9	6.1	79.3	2,709,895.2	1,385.2	0.9	0.4
04/28/2020 03:00	7.2	13.9	6.1	79.2	2,699,526.7	1,379.9	0.9	0.4
04/28/2020 04:00	7.2	13.9	6.1	79.0	2,695,027.2	1,377.6	0.9	0.4
04/28/2020 05:00	7.3	13.9	6.2	78.6	2,693,853.4	1,377.0	0.9	0.4
04/28/2020 06:00	7.4	13.9	6.2	79.5	2,698,744.2	1,379.5	0.9	0.4
04/28/2020 07:00	7.5	13.9	6.3	82.0	2,724,372.0	1,392.6	0.9	0.4
04/28/2020 08:00	7.4	13.9	6.2	82.7	2,734,153.6	1,397.6	0.9	0.4
04/28/2020 09:00	7.4	13.9	6.2	84.9	2,710,090.9	1,385.3	1.0	0.6
04/28/2020 10:00	7.4	13.9	6.2	87.9	2,675,659.6	1,367.7	1.0	0.5
04/28/2020 11:00	7.4	13.9	6.2	89.2	2,677,615.9	1,368.7	1.0	0.5
04/28/2020 12:00	7.4	13.9	6.2	87.9	2,680,746.0	1,370.3	1.0	0.5
04/28/2020 13:00	7.4	13.9	6.2	89.1	2,956,391.6	1,511.2	0.9	0.5
04/28/2020 14:00	7.3	13.9	6.2	86.2	2,942,893.0	1,504.3	0.9	0.5
04/28/2020 15:00	7.4	13.9	6.2	87.7	3,015,276.9	1,541.3	0.9	0.5
04/28/2020 16:00	7.9	13.8	6.6	91.7	2,916,482.7	1,490.8	1.0	0.6
04/28/2020 17:00	9.3	13.1	7.0	122.8	3,206,453.3	2,083.9	1.2	1.0
04/28/2020 18:00	9.2	13.0	6.9	129.5	3,211,977.4	2,134.4	1.3	1.1
04/28/2020 19:00	9.1	13.0	6.8	128.8	3,212,880.3	2,135.0	1.3	1.1
04/28/2020 20:00	8.9	13.0	6.6	128.3	3,203,399.7	2,128.7	1.3	1.1
04/28/2020 21:00	11.4	13.8	9.5	132.7	2,816,854.0	1,625.0	1.5	1.0
04/28/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/28/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	7.9	13.7	6.5	94.0	2,845,593.7	1,550.3	1.0	0.6
Minimum:	7.2	13.0	6.1	78.6	2,675,659.6	1,367.7	0.9	0.4
Maximum:	11.4	13.9	9.5	132.7	3,212,880.3	2,135.0	1.5	1.1
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/29/2020 13:00	33.4	17.3	54.7	25.8	1,856,375.6	460.9	0.3	0.0
04/29/2020 14:00	49.4	15.3	52.0	269.5	1,776,828.1	726.6	4.6	1.3
04/29/2020 15:00	15.5	14.0	13.3	154.5	2,861,492.8	1,420.9	1.7	1.0
04/29/2020 16:00	7.7	13.8	6.4	84.9	2,697,961.7	1,379.1	1.0	0.6
04/29/2020 17:00	9.3	13.2	7.1	110.7	3,239,189.7	1,939.6	1.1	0.8
04/29/2020 18:00	9.4	13.2	7.2	114.7	3,226,298.6	1,979.0	1.1	0.8
04/29/2020 19:00	9.4	13.2	7.2	113.0	3,249,825.6	1,969.7	1.1	0.8
04/29/2020 20:00	9.2	13.2	7.0	110.7	3,223,992.4	1,930.5	1.1	0.8
04/29/2020 21:00	7.9	13.8	6.6	82.9	2,626,015.9	1,361.5	1.0	0.5
04/29/2020 22:00	7.7	13.8	6.4	81.6	2,630,273.0	1,344.5	1.0	0.5
04/29/2020 23:00	7.6	13.8	6.3	81.4	2,628,707.9	1,343.7	1.0	0.5
Average/Sum#:	15.1	14.1	15.8	111.8	2,728,814.7	1,441.5	1.4	0.7
Minimum:	7.6	13.2	6.3	25.8	1,776,828.1	460.9	0.3	0.0
Maximum:	49.4	17.3	54.7	269.5	3,249,825.6	1,979.0	4.6	1.3
%SI	54.17	54.17	54.17	54.17	54.17	54.17	54.17	54.17

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
04/30/2020 00:00	7.5	13.8	6.2	80.7	2,626,360.3	1,342.5	1.0	0.5
04/30/2020 01:00	7.5	13.8	6.2	79.8	2,625,969.1	1,342.3	0.9	0.4
04/30/2020 02:00	7.5	13.8	6.2	80.2	2,626,360.3	1,342.5	1.0	0.5
04/30/2020 03:00	7.6	13.8	6.3	80.9	2,627,925.4	1,343.3	1.0	0.5
04/30/2020 04:00	7.6	13.8	6.3	80.8	2,627,142.9	1,342.9	1.0	0.5
04/30/2020 05:00	7.6	13.8	6.3	80.6	2,593,998.4	1,344.9	1.0	0.5
04/30/2020 06:00	7.7	13.8	6.4	82.3	2,572,203.3	1,333.6	1.0	0.5
04/30/2020 07:00	29.3	17.1	45.5	202.2	1,110,826.1	348.8	5.6	0.8
04/30/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/30/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	10.3	14.2	11.2	95.9	2,426,348.2	1,217.6	1.6	0.5
Minimum:	7.5	13.8	6.2	79.8	1,110,826.1	348.8	0.9	0.4
Maximum:	29.3	17.1	45.5	202.2	2,627,925.4	1,344.9	5.6	0.8
%SI	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/03/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/04/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/04/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/05/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/06/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/07/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/07/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/08/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/09/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/10/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/10/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/11/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 16:00	0.0	21.0	0.0	0.0	0.0	0.2	0.0	0.0
05/11/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/11/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	21.0	0.0	0.0	0.0	0.2	0.0	0.0
Minimum:	0.0	21.0	0.0	0.0	0.0	0.2	0.0	0.0
Maximum:	0.0	21.0	0.0	0.0	0.0	0.2	0.0	0.0
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/12/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/13/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/13/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/14/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/14/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/15/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/16/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/17/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/17/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/18/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/18/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/19/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/19/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/20/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/20/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/21/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/22/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/23/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/24/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 08:00	27.8	17.7	51.3	0.0	253,703.9	387.2	-1.1	-0.2
05/27/2020 09:00	40.0	17.1	62.1	103.6	340,914.6	520.3	9.4	1.9
05/27/2020 10:00	34.2	17.1	53.1	264.6	338,621.3	516.8	26.4	5.3
05/27/2020 11:00	40.2	15.4	43.1	251.3	561,922.7	857.6	14.8	4.9
05/27/2020 12:00	7.1	13.9	6.0	85.2	909,782.7	1,388.5	3.2	1.7
05/27/2020 13:00	7.7	13.8	6.4	85.5	2,806,741.4	1,455.2	1.0	0.6
05/27/2020 14:00	21.2	15.8	24.5	158.3	1,834,014.3	723.2	2.6	0.7
05/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/27/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	25.5	15.8	35.2	135.5	2,320,377.9	835.5	1.8	0.7
Minimum:	7.1	13.8	6.0	0.0	1,834,014.3	387.2	1.0	0.6
Maximum:	40.2	17.7	62.1	264.6	2,806,741.4	1,455.2	2.6	0.7
%SI	70.83	70.83	70.83	70.83	91.67	70.83	91.67	91.67

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/28/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/28/2020 18:00	12.9	18.4	30.4	0.0	1,711,780.5	200.0	-0.2	0.0
05/28/2020 19:00	37.8	16.4	49.6	94.8	1,797,902.1	590.8	1.5	0.4
05/28/2020 20:00	14.4	14.0	12.3	144.3	2,792,434.9	1,407.0	1.6	0.8
05/28/2020 21:00	7.9	13.7	6.5	93.8	3,116,962.1	1,638.8	0.9	0.5
05/28/2020 22:00	7.9	13.8	6.6	92.8	3,124,216.4	1,619.8	0.9	0.5
05/28/2020 23:00	8.4	13.7	6.9	92.1	3,111,293.6	1,613.1	0.9	0.5
Average/Sum#:	14.9	15.0	18.7	86.3	2,609,098.3	1,178.3	0.9	0.5
Minimum:	7.9	13.7	6.5	0.0	1,711,780.5	200.0	-0.2	0.0
Maximum:	37.8	18.4	49.6	144.3	3,124,216.4	1,638.8	1.6	0.8
%SI	75.00	75.00	75.00	75.00	75.00	75.00	75.00	75.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/29/2020 00:00	8.6	13.5	6.9	98.5	3,050,933.4	1,693.2	1.0	0.7
05/29/2020 01:00	12.9	14.5	11.9	116.7	2,653,523.1	1,259.5	1.3	0.6
05/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/29/2020 20:00	35.2	17.4	59.3	0.0	1,841,875.8	430.4	-0.2	0.0
05/29/2020 21:00	51.3	15.6	57.1	219.4	1,833,975.3	696.4	3.5	0.9
05/29/2020 22:00	35.1	14.8	33.9	217.6	2,279,754.9	1,015.5	2.9	1.1
05/29/2020 23:00	7.2	13.9	6.1	80.4	2,703,439.4	1,381.9	0.9	0.4
Average/Sum#:	25.1	15.0	29.2	122.1	2,393,917.0	1,079.5	1.6	0.6
Minimum:	7.2	13.5	6.1	0.0	1,833,975.3	430.4	-0.2	0.0
Maximum:	51.3	17.4	59.3	219.4	3,050,933.4	1,693.2	3.5	1.1
%SI	75.00	75.00	75.00	75.00	75.00	75.00	75.00	75.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/30/2020 00:00	7.5	13.9	6.3	80.0	2,687,201.9	1,373.6	0.9	0.4
05/30/2020 01:00	7.5	13.8	6.2	79.0	2,682,311.1	1,371.1	0.9	0.4
05/30/2020 02:00	7.6	13.8	6.3	78.3	2,680,550.4	1,370.2	0.9	0.4
05/30/2020 03:00	7.6	13.8	6.3	78.3	2,644,339.2	1,371.0	0.9	0.4
05/30/2020 04:00	7.6	13.8	6.3	78.5	2,655,140.3	1,376.6	0.9	0.4
05/30/2020 05:00	7.6	13.8	6.3	78.7	2,660,733.7	1,379.5	0.9	0.4
05/30/2020 06:00	0.0	0.0	0.0	79.3	2,668,641.7	1,383.6	1.1	0.6
05/30/2020 07:00	0.0	0.0	0.0	79.1	2,642,024.7	1,369.8	1.1	0.5
05/30/2020 08:00	0.0	0.0	0.0	207.7	1,182,468.2	397.2	6.3	1.0
05/30/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/30/2020 13:00	0.0	0.0	0.0	0.0	1,774,165.4	116.6	0.0	0.0
05/30/2020 14:00	0.0	0.0	0.0	159.2	1,906,352.9	668.2	3.5	0.9
05/30/2020 15:00	0.0	0.0	0.0	104.4	2,723,393.8	1,392.1	1.4	0.7
05/30/2020 16:00	0.0	0.0	0.0	81.4	2,695,418.5	1,377.8	1.1	0.6
05/30/2020 17:00	0.0	0.0	0.0	83.5	2,729,262.8	1,395.1	1.1	0.6
05/30/2020 18:00	0.0	0.0	0.0	106.1	3,336,431.3	1,949.1	1.1	0.8
05/30/2020 19:00	0.0	0.0	0.0	108.5	3,318,571.8	1,962.9	1.1	0.8
05/30/2020 20:00	0.0	0.0	0.0	108.0	3,284,082.6	1,942.5	1.2	1.0
05/30/2020 21:00	0.0	0.0	0.0	79.5	906,965.2	1,384.2	3.1	1.7
05/30/2020 22:00	0.0	0.0	0.0	84.6	901,854.4	1,376.4	3.3	1.8
05/30/2020 23:00	0.0	0.0	0.0	93.0	2,688,571.3	1,374.3	1.2	0.7
Average/Sum#:	7.6	13.8	6.3	92.4	2,608,870.1	1,316.6	0.9	0.4
Minimum:	7.5	13.8	6.2	0.0	1,182,468.2	116.6	0.9	0.4
Maximum:	7.6	13.9	6.3	207.7	3,336,431.3	1,962.9	0.9	0.4
%SI	75.00	75.00	75.00	16.67	25.00	16.67	75.00	75.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
05/31/2020 00:00	0.0	0.0	0.0	102.0	2,687,397.5	1,373.7	1.3	0.7
05/31/2020 01:00	0.0	0.0	0.0	102.4	2,686,419.4	1,373.2	1.3	0.7
05/31/2020 02:00	0.0	0.0	0.0	103.2	2,687,006.3	1,373.5	1.4	0.7
05/31/2020 03:00	0.0	0.0	0.0	102.4	2,687,201.9	1,373.6	1.3	0.7
05/31/2020 04:00	0.0	0.0	0.0	102.1	2,689,940.8	1,375.0	1.3	0.7
05/31/2020 05:00	0.0	0.0	0.0	93.3	2,665,878.0	1,362.7	1.2	0.7
05/31/2020 06:00	0.0	0.0	0.0	77.6	254,555.7	388.5	10.7	1.6
05/31/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/31/2020 14:00	0.0	0.0	0.0	50.0	1,851,212.8	446.1	1.9	0.3
05/31/2020 15:00	0.0	0.0	0.0	222.5	2,385,159.5	1,010.2	3.5	1.3
05/31/2020 16:00	0.0	0.0	0.0	186.3	2,709,895.2	1,385.2	2.4	1.2
05/31/2020 17:00	0.0	0.0	0.0	104.1	2,718,894.3	1,389.8	1.4	0.7
05/31/2020 18:00	0.0	0.0	0.0	219.7	3,203,905.3	1,754.7	2.4	1.6
05/31/2020 19:00	0.0	0.0	0.0	156.7	3,300,312.8	1,952.1	1.7	1.4
05/31/2020 20:00	0.0	0.0	0.0	115.5	3,261,766.0	1,929.3	1.3	1.0
05/31/2020 21:00	0.0	0.0	0.0	115.2	2,770,541.2	1,416.2	1.5	0.8
05/31/2020 22:00	0.0	0.0	0.0	115.3	2,679,376.6	1,369.6	1.5	0.8
05/31/2020 23:00	0.0	0.0	0.0	91.2	2,675,464.0	1,367.6	1.2	0.7
Average/Sum#:	0.0	0.0	0.0	121.1	2,728,773.2	1,331.8	0.0	0.0
Minimum:	0.0	0.0	0.0	50.0	1,851,212.8	388.5	0.0	0.0
Maximum:	0.0	0.0	0.0	222.5	3,300,312.8	1,952.1	0.0	0.0
%SI	100.00	100.00	100.00	29.17	33.33	29.17	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/01/2020 00:00	0.0	0.0	0.0	78.0	2,679,181.0	1,369.5	1.0	0.5
06/01/2020 01:00	0.0	0.0	0.0	78.0	2,678,202.8	1,369.0	1.0	0.5
06/01/2020 02:00	0.0	0.0	0.0	77.9	2,675,268.4	1,367.5	1.0	0.5
06/01/2020 03:00	0.0	0.0	0.0	78.0	2,676,637.8	1,368.2	1.0	0.5
06/01/2020 04:00	0.0	0.0	0.0	77.9	2,652,379.4	1,355.8	1.0	0.5
06/01/2020 05:00	0.0	0.0	0.0	77.8	2,613,448.6	1,335.9	1.1	0.5
06/01/2020 06:00	0.0	0.0	0.0	77.4	2,624,990.9	1,341.8	1.0	0.5
06/01/2020 07:00	0.0	0.0	0.0	77.9	2,628,316.7	1,343.5	1.1	0.5
06/01/2020 08:00	0.0	0.0	0.0	77.9	2,632,229.3	1,345.5	1.1	0.5
06/01/2020 09:00	0.0	0.0	0.0	78.6	2,647,684.2	1,353.4	1.1	0.5
06/01/2020 10:00	0.0	0.0	0.0	80.6	2,653,553.2	1,356.4	1.1	0.5
06/01/2020 11:00	0.0	0.0	0.0	81.1	2,657,661.5	1,358.5	1.1	0.5
06/01/2020 12:00	0.0	0.0	0.0	81.1	2,706,569.5	1,383.5	1.1	0.6
06/01/2020 13:00	0.0	0.0	0.0	91.8	3,124,795.0	1,620.1	1.0	0.6
06/01/2020 14:00	0.0	0.0	0.0	94.7	3,201,790.3	1,683.4	1.1	0.7
06/01/2020 15:00	0.0	0.0	0.0	94.0	3,204,645.9	1,661.5	1.0	0.7
06/01/2020 16:00	0.0	0.0	0.0	86.9	2,983,193.2	1,524.9	1.0	0.6
06/01/2020 17:00	0.0	0.0	0.0	92.0	3,170,413.1	1,620.6	1.0	0.6
06/01/2020 18:00	0.0	0.0	0.0	87.3	3,013,124.9	1,540.2	1.0	0.6
06/01/2020 19:00	0.0	0.0	0.0	85.8	2,942,697.4	1,504.2	1.0	0.6
06/01/2020 20:00	0.0	0.0	0.0	85.9	2,998,840.9	1,511.0	1.0	0.6
06/01/2020 21:00	0.0	0.0	0.0	83.3	2,856,539.9	1,439.3	1.0	0.6
06/01/2020 22:00	0.0	0.0	0.0	78.3	2,668,194.4	1,344.4	1.0	0.5
06/01/2020 23:00	0.0	0.0	0.0	93.4	3,215,832.8	1,667.3	1.0	0.7
Average/Sum#:	0.0	0.0	0.0	83.2	2,829,424.6	1,448.6	0.0	0.0
Minimum:	0.0	0.0	0.0	77.4	2,613,448.6	1,335.9	0.0	0.0
Maximum:	0.0	0.0	0.0	94.7	3,215,832.8	1,683.4	0.0	0.0
%SI	100.00	100.00	100.00	0.00	0.00	0.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/02/2020 00:00	0.0	0.0	0.0	85.5	2,968,673.9	1,495.8	1.0	0.6
06/02/2020 01:00	0.0	0.0	0.0	86.2	2,964,803.8	1,515.5	1.0	0.6
06/02/2020 02:00	0.0	0.0	0.0	81.9	2,797,734.0	1,430.1	1.0	0.6
06/02/2020 03:00	0.0	0.0	0.0	87.2	3,008,821.0	1,538.0	1.0	0.6
06/02/2020 04:00	0.0	0.0	0.0	95.0	3,298,356.4	1,686.0	1.0	0.7
06/02/2020 05:00	0.0	0.0	0.0	94.4	3,258,838.8	1,665.8	1.0	0.7
06/02/2020 06:00	0.0	0.0	0.0	84.9	2,894,767.5	1,479.7	1.0	0.6
06/02/2020 07:00	0.0	0.0	0.0	80.1	2,698,548.6	1,379.4	1.1	0.6
06/02/2020 08:00	0.0	0.0	0.0	78.5	2,602,493.2	1,330.3	1.1	0.5
06/02/2020 09:00	0.0	0.0	0.0	85.6	2,955,609.1	1,510.8	1.0	0.6
06/02/2020 10:00	0.0	0.0	0.0	84.1	2,897,506.4	1,481.1	1.0	0.6
06/02/2020 11:00	0.0	0.0	0.0	80.3	2,563,758.1	1,310.5	1.1	0.5
06/02/2020 12:00	0.0	0.0	0.0	93.1	3,207,346.2	1,662.9	1.0	0.7
06/02/2020 13:00	0.0	0.0	0.0	118.9	3,240,341.4	2,058.6	1.3	1.0
06/02/2020 14:00	0.0	0.0	0.0	129.4	3,095,812.1	2,034.6	1.5	1.2
06/02/2020 15:00	0.0	0.0	0.0	127.1	3,084,552.3	2,027.2	1.5	1.2
06/02/2020 16:00	0.0	0.0	0.0	133.5	3,143,589.8	2,066.0	1.5	1.2
06/02/2020 17:00	0.0	0.0	0.0	127.1	3,206,787.3	2,060.7	1.4	1.0
06/02/2020 18:00	0.0	0.0	0.0	128.5	3,222,971.4	2,071.1	1.4	1.0
06/02/2020 19:00	0.0	0.0	0.0	127.1	3,217,213.6	2,067.4	1.4	1.0
06/02/2020 20:00	0.0	0.0	0.0	126.6	3,211,144.6	2,063.5	1.4	1.0
06/02/2020 21:00	0.0	0.0	0.0	125.2	3,229,480.5	2,051.7	1.4	1.0
06/02/2020 22:00	0.0	0.0	0.0	124.6	3,235,304.5	2,055.4	1.4	1.0
06/02/2020 23:00	0.0	0.0	0.0	124.0	3,232,156.4	2,053.4	1.4	1.0
Average/Sum#:	0.0	0.0	0.0	104.5	3,051,525.5	1,754.0	0.0	0.0
Minimum:	0.0	0.0	0.0	78.5	2,563,758.1	1,310.5	0.0	0.0
Maximum:	0.0	0.0	0.0	133.5	3,298,356.4	2,071.1	0.0	0.0
%SI	100.00	100.00	100.00	0.00	0.00	0.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/03/2020 00:00	0.0	0.0	0.0	123.1	3,230,726.9	2,028.9	1.4	1.0
06/03/2020 01:00	0.0	0.0	0.0	89.7	2,772,106.2	1,417.0	1.1	0.6
06/03/2020 02:00	0.0	0.0	0.0	85.7	2,692,484.0	1,376.3	1.1	0.6
06/03/2020 03:00	0.0	0.0	0.0	85.2	2,591,929.1	1,324.9	1.2	0.7
06/03/2020 04:00	0.0	0.0	0.0	101.5	3,194,423.5	1,656.2	1.1	0.7
06/03/2020 05:00	0.0	0.0	0.0	93.3	2,899,267.1	1,482.0	1.1	0.6
06/03/2020 06:00	0.0	0.0	0.0	87.0	2,668,812.5	1,364.2	1.2	0.7
06/03/2020 07:00	0.0	0.0	0.0	90.4	2,836,077.9	1,449.7	1.1	0.6
06/03/2020 08:00	0.0	0.0	0.0	92.4	2,910,418.1	1,487.7	1.1	0.6
06/03/2020 09:00	0.0	0.0	0.0	97.6	3,080,031.1	1,574.4	1.1	0.6
06/03/2020 10:00	0.0	0.0	0.0	94.4	2,936,828.4	1,501.2	1.1	0.6
06/03/2020 11:00	0.0	0.0	0.0	122.1	3,205,090.0	2,012.8	1.4	1.0
06/03/2020 12:00	0.0	0.0	0.0	134.4	3,143,894.1	2,066.2	1.5	1.2
06/03/2020 13:00	0.0	0.0	0.0	132.6	3,129,439.0	2,056.7	1.5	1.2
06/03/2020 14:00	0.0	0.0	0.0	131.9	3,124,874.3	2,053.7	1.5	1.2
06/03/2020 15:00	10.0	12.8	7.3	139.3	3,118,027.2	2,049.2	1.4	1.0
06/03/2020 16:00	9.7	12.8	7.1	139.5	3,116,505.6	2,048.2	1.4	1.0
06/03/2020 17:00	9.5	12.8	6.9	138.9	3,117,570.7	2,048.9	1.4	1.0
06/03/2020 18:00	9.4	12.8	6.8	136.3	3,137,199.1	2,061.8	1.4	1.0
06/03/2020 19:00	9.4	12.8	6.8	137.1	3,134,928.4	2,083.2	1.4	1.0
06/03/2020 20:00	9.3	12.9	6.9	132.0	3,181,421.8	2,044.4	1.3	1.0
06/03/2020 21:00	9.2	13.0	6.9	130.3	3,205,397.5	2,036.4	1.3	1.0
06/03/2020 22:00	9.1	13.0	6.8	129.1	3,236,300.1	2,032.4	1.3	1.0
06/03/2020 23:00	9.0	12.9	6.6	135.1	3,247,092.0	2,086.6	1.3	1.0
Average/Sum#:	9.4	12.9	6.9	115.8	3,037,951.9	1,806.0	1.4	1.0
Minimum:	9.0	12.8	6.6	85.2	2,591,929.1	1,324.9	1.3	1.0
Maximum:	10.0	13.0	7.3	139.5	3,247,092.0	2,086.6	1.4	1.0
%SI	62.50	62.50	62.50	0.00	0.00	0.00	62.50	62.50

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/04/2020 00:00	14.5	14.6	13.6	146.7	2,393,874.7	1,188.7	1.9	0.8
06/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/04/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/04/2020 10:00	32.2	17.4	54.3	20.4	1,860,134.8	407.5	0.1	0.0
06/04/2020 11:00	40.6	15.0	40.6	238.3	2,088,011.8	869.1	3.5	1.1
06/04/2020 12:00	7.4	13.7	6.1	102.6	3,046,969.3	1,557.5	1.1	0.6
06/04/2020 13:00	7.8	13.6	6.3	96.7	2,965,390.7	1,515.8	1.0	0.6
06/04/2020 14:00	9.2	12.9	6.8	128.5	3,156,678.8	2,028.5	1.3	1.0
06/04/2020 15:00	9.3	12.8	6.8	134.9	3,121,234.2	2,074.1	1.4	1.0
06/04/2020 16:00	9.2	12.8	6.7	135.8	3,128,307.0	2,078.8	1.4	1.0
06/04/2020 17:00	9.2	12.8	6.7	135.6	3,123,190.5	2,075.4	1.4	1.0
06/04/2020 18:00	9.1	12.8	6.6	135.4	3,118,375.0	2,072.2	1.4	1.0
06/04/2020 19:00	9.1	12.8	6.6	133.6	3,152,907.3	2,049.1	1.4	1.0
06/04/2020 20:00	9.1	12.9	6.7	134.8	3,142,981.1	2,065.6	1.4	1.0
06/04/2020 21:00	9.0	12.8	6.6	136.0	3,168,087.2	2,082.1	1.4	1.0
06/04/2020 22:00	8.9	12.9	6.6	133.0	3,207,565.4	2,061.2	1.3	1.0
06/04/2020 23:00	8.8	12.9	6.5	130.1	3,189,513.9	2,049.6	1.3	1.0
Average/Sum#:	12.9	13.5	12.5	129.5	2,924,214.8	1,745.0	1.4	0.9
Minimum:	7.4	12.8	6.1	20.4	1,860,134.8	407.5	0.1	0.0
Maximum:	40.6	17.4	54.3	238.3	3,207,565.4	2,082.1	3.5	1.1
%SI	37.50	37.50	37.50	37.50	37.50	37.50	37.50	37.50

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/05/2020 00:00	13.5	14.4	12.3	137.3	2,420,457.6	1,201.9	1.8	0.8
06/05/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	13.5	14.4	12.3	137.3	2,420,457.6	1,201.9	1.8	0.8
Minimum:	13.5	14.4	12.3	137.3	2,420,457.6	1,201.9	1.8	0.8
Maximum:	13.5	14.4	12.3	137.3	2,420,457.6	1,201.9	1.8	0.8
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/06/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/07/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/07/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/08/2020 09:00	29.5	17.5	51.2	0.0	1,908,977.6	418.2	-0.1	0.0
06/08/2020 10:00	37.8	17.0	57.2	141.7	1,897,013.1	526.4	2.2	0.4
06/08/2020 11:00	37.1	16.8	53.4	266.3	1,903,499.9	556.0	4.1	0.9
06/08/2020 12:00	36.2	15.2	37.5	235.9	2,309,347.5	927.5	3.1	1.1
06/08/2020 13:00	6.7	13.7	5.5	85.4	2,661,182.8	1,360.3	1.0	0.5
06/08/2020 14:00	7.0	13.7	5.7	84.0	2,645,923.5	1,352.5	1.0	0.5
06/08/2020 15:00	7.2	13.7	5.9	92.6	3,002,756.4	1,534.9	1.0	0.6
06/08/2020 16:00	7.2	13.7	5.9	94.9	3,049,121.2	1,558.6	1.0	0.6
06/08/2020 17:00	8.3	13.6	6.7	105.0	3,220,810.1	1,693.4	1.0	0.7
06/08/2020 18:00	7.6	13.6	6.1	94.2	2,926,903.5	1,517.5	1.0	0.6
06/08/2020 19:00	8.2	13.6	6.6	105.3	3,290,283.2	1,705.9	1.0	0.7
06/08/2020 20:00	8.9	13.1	6.7	121.3	3,361,769.9	2,013.0	1.1	0.8
06/08/2020 21:00	8.9	13.0	6.6	130.0	3,325,631.2	2,088.5	1.3	1.0
06/08/2020 22:00	8.8	13.0	6.6	126.8	3,316,262.5	2,058.4	1.2	1.0
06/08/2020 23:00	11.6	13.9	9.8	127.2	2,950,453.0	1,572.8	1.4	0.8
Average/Sum#:	15.4	14.3	18.1	120.7	2,784,662.4	1,392.3	1.4	0.7
Minimum:	6.7	13.0	5.5	0.0	1,897,013.1	418.2	-0.1	0.0
Maximum:	37.8	17.5	57.2	266.3	3,361,769.9	2,088.5	4.1	1.1
%SI	37.50	37.50	37.50	37.50	37.50	37.50	37.50	37.50

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/09/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/09/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/09/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/09/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/09/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/09/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/09/2020 08:00	34.5	17.3	56.5	52.6	1,783,156.5	429.7	0.6	0.1
06/09/2020 09:00	36.0	16.9	53.1	255.8	1,791,549.5	523.3	4.2	0.8
06/09/2020 10:00	40.6	14.8	39.3	237.3	2,137,926.8	921.1	3.5	1.2
06/09/2020 11:00	6.9	13.7	5.7	87.0	2,680,941.7	1,370.4	1.0	0.5
06/09/2020 12:00	7.3	13.7	6.0	85.7	2,664,313.0	1,361.9	1.0	0.5
06/09/2020 13:00	7.6	13.7	6.2	94.6	2,949,855.8	1,529.4	1.0	0.6
06/09/2020 14:00	7.5	13.6	6.1	97.8	3,008,876.1	1,560.0	1.0	0.6
06/09/2020 15:00	7.8	13.7	6.4	95.8	2,957,956.7	1,533.6	1.0	0.6
06/09/2020 16:00	7.9	13.6	6.4	95.0	2,915,138.0	1,511.4	1.0	0.6
06/09/2020 17:00	9.0	13.0	6.7	124.2	3,260,518.9	2,023.8	1.2	1.0
06/09/2020 18:00	8.9	12.9	6.6	132.6	3,213,839.0	2,088.7	1.3	1.0
06/09/2020 19:00	8.9	12.9	6.6	133.5	3,222,609.5	2,094.4	1.3	1.0
06/09/2020 20:00	8.8	12.9	6.5	129.5	3,215,501.8	2,066.3	1.3	1.0
06/09/2020 21:00	8.7	13.0	6.5	127.3	3,264,644.0	2,050.2	1.3	1.0
06/09/2020 22:00	8.6	13.0	6.4	123.5	3,253,430.1	2,019.4	1.2	1.0
06/09/2020 23:00	14.2	14.6	13.3	139.5	2,430,421.7	1,189.1	1.8	0.8
Average/Sum#:	14.0	14.0	14.9	125.7	2,796,917.4	1,517.0	1.5	0.8
Minimum:	6.9	12.9	5.7	52.6	1,783,156.5	429.7	0.6	0.1
Maximum:	40.6	17.3	56.5	255.8	3,264,644.0	2,094.4	4.2	1.2
%SI	33.33	33.33	33.33	33.33	33.33	33.33	33.33	33.33

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/10/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/10/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/10/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/10/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/10/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/10/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/10/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/10/2020 07:00	28.2	17.5	48.9	27.5	1,801,706.0	394.7	0.2	0.0
06/10/2020 08:00	35.6	14.6	33.3	206.2	2,280,652.8	1,015.9	2.8	1.1
06/10/2020 09:00	7.2	13.7	5.9	86.4	2,688,375.7	1,374.2	1.0	0.5
06/10/2020 10:00	7.3	13.7	6.0	86.2	2,720,068.1	1,390.4	1.0	0.6
06/10/2020 11:00	7.5	13.7	6.1	86.9	2,726,915.2	1,393.9	1.0	0.6
06/10/2020 12:00	7.8	13.7	6.4	88.7	2,734,153.6	1,397.6	1.0	0.6
06/10/2020 13:00	7.8	13.6	6.3	103.4	3,195,133.4	1,679.9	1.0	0.7
06/10/2020 14:00	8.0	13.5	6.4	100.1	3,017,235.9	1,608.4	1.1	0.6
06/10/2020 15:00	9.0	12.9	6.6	126.7	3,204,453.1	2,035.8	1.3	1.0
06/10/2020 16:00	8.9	12.8	6.5	136.0	3,180,375.3	2,113.4	1.4	1.1
06/10/2020 17:00	8.7	12.8	6.3	134.6	3,191,671.8	2,097.6	1.4	1.0
06/10/2020 18:00	8.6	12.8	6.3	134.9	3,163,972.3	2,102.5	1.4	1.1
06/10/2020 19:00	8.6	12.9	6.3	131.7	3,181,988.3	2,068.0	1.3	1.0
06/10/2020 20:00	8.5	12.9	6.3	131.6	3,199,529.3	2,079.4	1.3	1.0
06/10/2020 21:00	8.5	12.9	6.3	132.0	3,261,875.5	2,096.1	1.3	1.0
06/10/2020 22:00	8.3	13.0	6.2	123.7	3,268,252.1	2,028.6	1.2	1.0
06/10/2020 23:00	8.4	12.9	6.2	127.3	3,246,008.0	2,062.2	1.3	1.0
Average/Sum#:	11.0	13.5	10.4	115.5	2,944,845.1	1,702.3	1.2	0.8
Minimum:	7.2	12.8	5.9	27.5	1,801,706.0	394.7	0.2	0.0
Maximum:	35.6	17.5	48.9	206.2	3,268,252.1	2,113.4	2.8	1.1
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/11/2020 00:00	8.0	13.1	6.1	118.0	3,236,791.3	1,961.8	1.2	1.0
06/11/2020 01:00	7.8	13.1	5.9	116.7	3,219,467.2	1,951.3	1.2	1.0
06/11/2020 02:00	8.0	13.1	6.1	115.0	3,242,195.7	1,941.4	1.1	0.8
06/11/2020 03:00	8.3	13.0	6.2	120.8	3,247,166.1	1,991.8	1.2	1.0
06/11/2020 04:00	8.1	13.1	6.1	114.7	3,205,288.1	1,919.3	1.2	1.0
06/11/2020 05:00	7.7	13.4	6.1	107.2	3,280,990.7	1,749.0	1.0	0.7
06/11/2020 06:00	8.1	13.4	6.4	107.4	3,281,178.3	1,749.1	1.0	0.7
06/11/2020 07:00	8.3	13.4	6.5	108.6	3,260,168.0	1,737.9	1.1	0.7
06/11/2020 08:00	8.1	13.4	6.4	107.3	3,229,402.8	1,721.5	1.1	0.7
06/11/2020 09:00	8.1	13.5	6.5	106.6	3,206,891.8	1,709.5	1.1	0.7
06/11/2020 10:00	8.1	13.5	6.5	105.5	3,176,689.4	1,693.4	1.0	0.7
06/11/2020 11:00	7.8	13.7	6.4	90.6	2,688,893.7	1,394.1	1.1	0.6
06/11/2020 12:00	8.0	13.6	6.5	101.5	3,135,411.2	1,648.5	1.0	0.7
06/11/2020 13:00	7.9	13.6	6.4	101.5	3,160,091.4	1,638.4	1.0	0.7
06/11/2020 14:00	7.9	13.6	6.4	100.6	3,137,332.0	1,626.6	1.0	0.7
06/11/2020 15:00	8.0	13.5	6.4	101.8	3,119,624.8	1,640.2	1.0	0.7
06/11/2020 16:00	7.8	13.6	6.3	101.0	3,151,412.0	1,633.9	1.0	0.7
06/11/2020 17:00	7.8	13.5	6.2	104.5	3,232,982.7	1,699.8	1.0	0.7
06/11/2020 18:00	8.8	12.9	6.5	125.8	3,246,172.7	2,038.6	1.2	1.0
06/11/2020 19:00	8.8	12.8	6.4	137.5	3,230,186.2	2,146.5	1.4	1.1
06/11/2020 20:00	8.5	12.8	6.2	132.3	3,229,687.4	2,099.0	1.3	1.0
06/11/2020 21:00	8.4	12.9	6.2	128.2	3,257,341.2	2,069.4	1.3	1.0
06/11/2020 22:00	8.3	13.0	6.2	123.2	3,256,652.3	2,021.4	1.2	1.0
06/11/2020 23:00	13.7	14.5	12.6	138.1	2,433,692.0	1,190.7	1.8	0.8
Average/Sum#:	8.3	13.3	6.6	113.1	3,161,071.2	1,790.5	1.1	0.8
Minimum:	7.7	12.8	5.9	90.6	2,433,692.0	1,190.7	1.0	0.6
Maximum:	13.7	14.5	12.6	138.1	3,281,178.3	2,146.5	1.8	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/12/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/13/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/13/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/14/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/14/2020 12:00	32.2	17.2	51.3	0.0	1,866,042.1	463.3	0.0	0.0
06/14/2020 13:00	45.2	15.8	52.3	217.6	1,819,965.0	664.5	3.7	0.9
06/14/2020 14:00	41.8	15.3	44.0	257.7	2,128,947.7	839.5	3.7	1.2
06/14/2020 15:00	6.8	13.7	5.6	92.4	2,750,195.4	1,405.8	1.1	0.6
06/14/2020 16:00	8.4	13.1	6.4	117.7	3,251,284.0	1,923.1	1.2	1.0
06/14/2020 17:00	8.5	13.0	6.3	126.2	3,243,060.9	1,965.6	1.3	1.0
06/14/2020 18:00	8.8	12.9	6.5	137.3	3,231,523.1	2,029.4	1.4	1.0
06/14/2020 19:00	8.8	12.9	6.5	132.1	3,252,141.2	2,018.6	1.3	1.0
06/14/2020 20:00	8.7	13.0	6.5	132.6	3,234,097.1	2,007.4	1.3	1.0
06/14/2020 21:00	8.4	13.1	6.4	117.6	3,252,974.6	1,924.1	1.2	1.0
06/14/2020 22:00	7.5	13.7	6.1	85.9	2,646,706.1	1,352.9	1.0	0.5
06/14/2020 23:00	28.1	16.6	38.6	196.4	1,215,810.7	408.4	5.0	0.8
Average/Sum#:	17.8	14.2	19.7	134.5	2,657,729.0	1,416.9	1.9	0.8
Minimum:	6.8	12.9	5.6	0.0	1,215,810.7	408.4	0.0	0.0
Maximum:	45.2	17.2	52.3	257.7	3,252,974.6	2,029.4	5.0	1.2
%SI	50.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/15/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/16/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/17/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2020 09:00	35.8	17.2	57.1	9.5	1,846,375.3	471.9	0.1	0.0
06/17/2020 10:00	36.5	16.9	53.8	253.4	1,836,433.2	523.0	4.1	0.8
06/17/2020 11:00	30.0	15.1	30.5	218.6	2,382,064.8	974.1	2.8	1.1
06/17/2020 12:00	6.7	13.7	5.5	85.3	2,752,543.0	1,386.9	1.0	0.6
06/17/2020 13:00	6.9	13.8	5.7	83.8	2,649,340.0	1,334.9	1.0	0.5
06/17/2020 14:00	7.4	13.7	6.1	92.2	2,941,327.9	1,503.5	1.0	0.6
06/17/2020 15:00	7.4	13.7	6.1	93.4	2,916,482.7	1,490.8	1.0	0.6
06/17/2020 16:00	7.5	13.7	6.1	96.5	3,121,700.7	1,595.7	1.0	0.6
06/17/2020 17:00	7.5	13.6	6.1	95.3	2,998,653.6	1,554.7	1.0	0.6
06/17/2020 18:00	8.6	13.0	6.4	125.3	3,304,179.4	2,050.9	1.2	1.0
06/17/2020 19:00	8.6	12.9	6.3	137.6	3,291,388.4	2,139.1	1.4	1.1
06/17/2020 20:00	8.4	12.9	6.2	136.8	3,320,231.7	2,133.6	1.3	1.1
06/17/2020 21:00	8.3	12.9	6.1	131.1	3,294,961.0	2,093.3	1.3	1.0
06/17/2020 22:00	8.3	13.0	6.2	126.4	3,330,117.9	2,067.0	1.2	1.0
06/17/2020 23:00	13.8	14.6	12.9	137.7	2,503,141.8	1,206.4	1.7	0.8
Average/Sum#:	13.4	14.0	14.7	121.5	2,832,596.1	1,501.7	1.4	0.8
Minimum:	6.7	12.9	5.5	9.5	1,836,433.2	471.9	0.1	0.0
Maximum:	36.5	17.2	57.1	253.4	3,330,117.9	2,139.1	4.1	1.1
%SI	37.50	37.50	37.50	37.50	37.50	37.50	37.50	37.50

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/18/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/18/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/18/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/18/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/18/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/18/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/18/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/18/2020 07:00	31.6	17.5	54.8	14.1	1,824,529.8	399.7	0.0	0.0
06/18/2020 08:00	35.4	15.5	38.7	226.5	2,197,136.1	834.3	3.2	1.0
06/18/2020 09:00	6.5	13.7	5.3	88.0	2,790,847.2	1,406.2	1.0	0.6
06/18/2020 10:00	6.7	13.8	5.6	85.9	2,771,794.3	1,396.6	1.0	0.6
06/18/2020 11:00	7.5	13.7	6.1	97.3	3,129,721.6	1,599.8	1.0	0.6
06/18/2020 12:00	6.9	13.8	5.7	88.4	2,821,212.7	1,421.5	1.0	0.6
06/18/2020 13:00	7.9	13.6	6.4	100.3	3,198,779.7	1,635.1	1.0	0.7
06/18/2020 14:00	7.3	13.6	5.9	97.7	3,145,372.2	1,607.8	1.0	0.6
06/18/2020 15:00	8.6	13.0	6.4	123.2	3,301,290.9	2,025.0	1.2	1.0
06/18/2020 16:00	8.7	12.9	6.4	136.6	3,262,153.5	2,120.1	1.4	1.1
06/18/2020 17:00	8.6	12.9	6.3	135.3	3,270,590.0	2,101.7	1.3	1.1
06/18/2020 18:00	8.6	12.9	6.3	134.2	3,227,533.2	2,097.6	1.4	1.0
06/18/2020 19:00	8.5	12.9	6.3	134.4	3,262,964.8	2,096.8	1.3	1.0
06/18/2020 20:00	8.5	12.9	6.3	134.1	3,271,212.5	2,102.1	1.3	1.1
06/18/2020 21:00	8.5	12.9	6.3	134.3	3,278,590.9	2,082.9	1.3	1.0
06/18/2020 22:00	8.2	13.1	6.2	133.6	3,253,050.9	1,947.9	1.3	1.0
06/18/2020 23:00	19.9	15.8	23.0	126.2	1,649,103.0	626.2	2.3	0.6
Average/Sum#:	11.6	13.8	11.9	117.1	2,920,934.3	1,617.7	1.3	0.8
Minimum:	6.5	12.9	5.3	14.1	1,649,103.0	399.7	0.0	0.0
Maximum:	35.4	17.5	54.8	226.5	3,301,290.9	2,120.1	3.2	1.1
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/19/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/19/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/20/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/20/2020 20:00	29.4	17.1	45.6	42.5	1,827,203.4	467.0	0.7	0.1
06/20/2020 21:00	29.6	16.9	43.7	263.2	1,805,182.2	514.1	4.3	0.9
06/20/2020 22:00	30.6	14.7	29.1	219.8	2,284,199.9	1,000.8	2.9	1.1
06/20/2020 23:00	7.2	13.6	5.8	86.1	2,675,006.6	1,386.9	1.0	0.6
Average/Sum#:	24.2	15.6	31.1	152.9	2,147,898.0	842.2	2.2	0.7
Minimum:	7.2	13.6	5.8	42.5	1,805,182.2	467.0	0.7	0.1
Maximum:	30.6	17.1	45.6	263.2	2,675,006.6	1,386.9	4.3	1.1
%SI	83.33	83.33	83.33	83.33	83.33	83.33	83.33	83.33

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/21/2020 00:00	7.5	13.6	6.1	84.0	2,599,398.9	1,347.7	1.0	0.5
06/21/2020 01:00	7.5	13.6	6.1	84.3	2,593,805.5	1,344.8	1.0	0.5
06/21/2020 02:00	7.6	13.6	6.1	84.6	2,627,534.1	1,343.1	1.0	0.5
06/21/2020 03:00	7.6	13.6	6.1	84.6	2,625,773.4	1,342.2	1.0	0.5
06/21/2020 04:00	7.6	13.6	6.1	84.5	2,629,490.4	1,344.1	1.0	0.5
06/21/2020 05:00	7.6	13.6	6.1	84.6	2,637,902.6	1,348.4	1.0	0.5
06/21/2020 06:00	7.7	13.6	6.2	84.4	2,636,924.5	1,347.9	1.0	0.5
06/21/2020 07:00	7.8	13.6	6.3	85.5	2,636,924.5	1,347.9	1.0	0.5
06/21/2020 08:00	7.8	13.6	6.3	85.4	2,645,532.3	1,352.3	1.0	0.5
06/21/2020 09:00	7.8	13.6	6.3	85.6	2,658,052.7	1,358.7	1.0	0.5
06/21/2020 10:00	7.7	13.7	6.3	86.2	2,663,139.2	1,361.3	1.0	0.5
06/21/2020 11:00	7.7	13.7	6.3	87.9	2,663,139.2	1,361.3	1.0	0.5
06/21/2020 12:00	7.7	13.7	6.3	87.4	2,661,769.7	1,360.6	1.0	0.5
06/21/2020 13:00	7.8	13.7	6.4	87.3	2,662,747.9	1,361.1	1.0	0.5
06/21/2020 14:00	7.7	13.7	6.3	87.1	2,666,660.5	1,363.1	1.0	0.5
06/21/2020 15:00	7.7	13.7	6.3	87.0	2,672,725.1	1,366.2	1.0	0.5
06/21/2020 16:00	7.7	13.7	6.3	88.0	2,735,914.3	1,398.5	1.0	0.6
06/21/2020 17:00	9.0	13.0	6.7	120.0	3,214,473.2	1,924.8	1.2	1.0
06/21/2020 18:00	9.2	12.8	6.7	141.0	3,193,682.3	2,075.6	1.4	1.0
06/21/2020 19:00	9.3	12.8	6.8	148.8	3,177,516.0	2,111.5	1.5	1.3
06/21/2020 20:00	9.1	12.8	6.6	135.2	3,192,626.2	2,051.6	1.4	1.0
06/21/2020 21:00	9.0	12.9	6.6	126.4	3,168,042.5	1,966.4	1.3	1.0
06/21/2020 22:00	7.6	13.6	6.1	87.0	2,677,420.3	1,368.6	1.0	0.5
06/21/2020 23:00	7.5	13.7	6.1	84.5	2,658,052.7	1,358.7	1.0	0.5
Average/Sum#:	8.0	13.5	6.3	95.9	2,762,468.7	1,496.1	1.1	0.6
Minimum:	7.5	12.8	6.1	84.0	2,593,805.5	1,342.2	1.0	0.5
Maximum:	9.3	13.7	6.8	148.8	3,214,473.2	2,111.5	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/22/2020 00:00	7.5	13.6	6.1	84.4	2,597,084.4	1,346.5	1.0	0.5
06/22/2020 01:00	7.7	13.6	6.2	85.0	2,622,839.0	1,340.7	1.0	0.5
06/22/2020 02:00	7.6	13.6	6.1	84.8	2,625,773.4	1,342.2	1.0	0.5
06/22/2020 03:00	7.7	13.6	6.2	85.1	2,639,076.4	1,349.0	1.0	0.5
06/22/2020 04:00	7.6	13.6	6.1	84.8	2,629,099.2	1,343.9	1.0	0.5
06/22/2020 05:00	7.5	13.6	6.1	87.9	2,758,607.6	1,410.1	1.0	0.6
06/22/2020 06:00	7.7	13.6	6.2	85.3	2,632,424.9	1,345.6	1.0	0.5
06/22/2020 07:00	7.8	13.6	6.3	85.3	2,645,923.5	1,352.5	1.0	0.5
06/22/2020 08:00	7.6	13.6	6.1	85.1	2,663,334.8	1,361.4	1.0	0.5
06/22/2020 09:00	8.3	13.6	6.7	86.7	2,683,484.9	1,371.7	1.0	0.5
06/22/2020 10:00	8.6	13.6	7.0	95.7	2,929,989.6	1,519.1	1.0	0.6
06/22/2020 11:00	8.1	13.6	6.5	97.1	2,970,107.9	1,539.9	1.0	0.6
06/22/2020 12:00	8.3	13.5	6.6	101.8	3,135,403.2	1,625.6	1.0	0.7
06/22/2020 13:00	8.3	13.5	6.6	102.3	3,141,189.5	1,628.6	1.0	0.7
06/22/2020 14:00	9.6	12.8	7.0	128.9	3,158,546.2	2,029.7	1.3	1.0
06/22/2020 15:00	9.5	12.8	6.9	134.7	3,146,937.2	2,068.2	1.4	1.0
06/22/2020 16:00	9.4	12.8	6.8	134.2	3,136,134.0	2,061.1	1.4	1.0
06/22/2020 17:00	9.2	12.8	6.7	133.9	3,135,677.5	2,060.8	1.4	1.0
06/22/2020 18:00	9.3	12.7	6.7	135.2	3,130,263.4	2,080.1	1.4	1.0
06/22/2020 19:00	9.3	12.7	6.7	136.5	3,145,011.0	2,089.9	1.4	1.0
06/22/2020 20:00	9.3	12.7	6.7	137.6	3,157,952.8	2,098.5	1.4	1.0
06/22/2020 21:00	9.2	12.8	6.7	135.3	3,161,544.4	2,077.8	1.4	1.0
06/22/2020 22:00	9.3	12.8	6.8	134.2	3,177,833.9	2,065.3	1.4	1.0
06/22/2020 23:00	9.4	12.8	6.8	131.1	3,182,044.3	2,044.8	1.3	1.0
Average/Sum#:	8.5	13.2	6.5	108.0	2,925,261.8	1,689.7	1.2	0.7
Minimum:	7.5	12.7	6.1	84.4	2,597,084.4	1,340.7	1.0	0.5
Maximum:	9.6	13.6	7.0	137.6	3,182,044.3	2,098.5	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/23/2020 00:00	14.6	14.4	13.3	143.6	2,367,119.5	1,192.7	1.9	0.8
06/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/23/2020 12:00	24.5	17.6	43.8	0.0	1,804,089.8	355.7	-0.3	0.0
06/23/2020 13:00	43.7	15.6	48.6	222.0	1,776,761.0	661.7	3.7	0.9
06/23/2020 14:00	11.2	13.7	9.2	124.7	2,667,599.0	1,344.1	1.5	0.8
06/23/2020 15:00	8.7	13.4	6.8	104.1	3,140,546.6	1,651.2	1.0	0.7
06/23/2020 16:00	9.6	12.8	7.0	130.6	3,136,751.2	2,038.6	1.3	1.0
06/23/2020 17:00	9.4	12.7	6.8	134.3	3,102,272.9	2,061.5	1.4	1.0
06/23/2020 18:00	9.2	12.8	6.7	133.0	3,123,809.2	2,053.0	1.4	1.0
06/23/2020 19:00	9.1	12.8	6.6	134.3	3,120,331.3	2,073.5	1.4	1.0
06/23/2020 20:00	9.0	12.7	6.5	135.8	3,149,074.1	2,092.6	1.4	1.0
06/23/2020 21:00	9.1	12.8	6.6	133.4	3,130,656.3	2,057.5	1.4	1.0
06/23/2020 22:00	9.0	12.8	6.6	132.5	3,160,600.7	2,054.1	1.4	1.0
06/23/2020 23:00	9.0	12.8	6.6	131.7	3,162,601.0	2,055.4	1.3	1.0
Average/Sum#:	13.5	13.6	13.5	127.7	2,834,016.4	1,668.6	1.4	0.9
Minimum:	8.7	12.7	6.5	0.0	1,776,761.0	355.7	-0.3	0.0
Maximum:	43.7	17.6	48.6	222.0	3,162,601.0	2,092.6	3.7	1.0
%SI	45.83	45.83	45.83	45.83	45.83	45.83	45.83	45.83

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/24/2020 00:00	8.7	13.0	6.5	121.1	3,224,505.3	1,977.9	1.2	1.0
06/24/2020 01:00	8.5	13.1	6.4	115.3	3,270,219.2	1,934.3	1.1	0.8
06/24/2020 02:00	8.5	13.1	6.4	115.5	3,273,938.7	1,936.5	1.1	0.8
06/24/2020 03:00	8.5	13.1	6.4	115.4	3,280,025.0	1,940.1	1.1	0.8
06/24/2020 04:00	8.7	13.0	6.5	123.8	3,287,922.7	2,016.8	1.2	1.0
06/24/2020 05:00	8.7	12.9	6.4	128.4	3,275,790.5	2,057.2	1.3	1.0
06/24/2020 06:00	8.7	13.0	6.5	122.2	3,314,176.1	1,960.3	1.2	1.0
06/24/2020 07:00	7.7	13.6	6.2	98.8	3,047,451.4	1,580.0	1.0	0.6
06/24/2020 08:00	7.7	13.6	6.2	98.0	3,047,451.4	1,580.0	1.0	0.6
06/24/2020 09:00	7.8	13.6	6.3	98.0	3,051,309.0	1,582.0	1.0	0.6
06/24/2020 10:00	7.8	13.6	6.3	95.4	3,001,778.2	1,534.4	1.0	0.6
06/24/2020 11:00	8.3	13.5	6.6	98.5	2,996,757.0	1,575.6	1.0	0.6
06/24/2020 12:00	9.5	12.8	6.9	129.3	3,159,479.9	2,030.3	1.3	1.0
06/24/2020 13:00	9.5	12.8	6.9	134.9	3,108,141.9	2,065.4	1.4	1.0
06/24/2020 14:00	9.4	12.7	6.8	135.0	3,113,258.4	2,068.8	1.4	1.0
06/24/2020 15:00	9.3	12.7	6.7	134.9	3,116,117.7	2,070.7	1.4	1.0
06/24/2020 16:00	9.3	12.7	6.7	134.8	3,105,734.1	2,063.8	1.4	1.0
06/24/2020 17:00	9.2	12.8	6.7	134.6	3,109,044.8	2,066.0	1.4	1.0
06/24/2020 18:00	9.2	12.7	6.6	135.8	3,122,739.1	2,075.1	1.4	1.0
06/24/2020 19:00	9.2	12.7	6.6	135.0	3,107,840.9	2,065.2	1.4	1.0
06/24/2020 20:00	9.2	12.7	6.6	134.9	3,109,195.3	2,066.1	1.4	1.0
06/24/2020 21:00	9.2	12.7	6.6	135.1	3,112,807.0	2,068.5	1.4	1.0
06/24/2020 22:00	9.3	12.7	6.7	134.0	3,123,200.5	2,052.6	1.4	1.0
06/24/2020 23:00	9.4	12.8	6.8	133.6	3,124,265.7	2,053.3	1.4	1.0
Average/Sum#:	8.8	13.0	6.6	122.6	3,145,131.2	1,934.2	1.2	0.9
Minimum:	7.7	12.7	6.2	95.4	2,996,757.0	1,534.4	1.0	0.6
Maximum:	9.5	13.6	6.9	135.8	3,314,176.1	2,075.1	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/25/2020 00:00	13.3	14.2	11.7	137.1	2,517,040.6	1,305.0	1.7	0.9
06/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/25/2020 08:00	18.4	18.0	37.4	0.0	1,797,680.7	288.8	-0.5	-0.1
06/25/2020 09:00	34.2	15.1	34.8	168.0	2,297,147.2	922.6	2.2	0.7
06/25/2020 10:00	7.6	13.6	6.1	90.3	2,766,432.9	1,414.1	1.0	0.6
06/25/2020 11:00	7.9	13.7	6.5	89.8	2,779,344.6	1,420.7	1.0	0.6
06/25/2020 12:00	8.4	13.6	6.8	100.2	3,076,382.9	1,595.0	1.0	0.6
06/25/2020 13:00	8.3	13.6	6.7	93.2	2,718,596.7	1,409.5	1.1	0.6
06/25/2020 14:00	8.3	13.7	6.8	87.2	2,564,345.0	1,310.8	1.1	0.5
06/25/2020 15:00	8.3	13.6	6.7	89.7	2,708,952.9	1,404.5	1.0	0.6
06/25/2020 16:00	8.3	13.7	6.8	87.9	2,631,251.1	1,345.0	1.0	0.5
06/25/2020 17:00	8.9	13.4	7.0	104.0	3,122,287.6	1,641.6	1.0	0.7
06/25/2020 18:00	9.5	12.9	7.0	122.6	3,120,536.0	1,959.7	1.3	1.0
06/25/2020 19:00	9.3	12.9	6.9	124.1	3,111,111.8	1,976.5	1.3	1.0
06/25/2020 20:00	9.2	12.9	6.8	123.5	3,100,093.5	1,969.5	1.3	1.0
06/25/2020 21:00	9.2	12.9	6.8	122.6	3,124,198.4	1,962.0	1.3	1.0
06/25/2020 22:00	12.7	13.8	10.6	137.0	2,658,144.0	1,455.8	1.6	0.9
06/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	11.4	13.9	11.0	104.8	2,755,846.6	1,461.3	1.2	0.7
Minimum:	7.6	12.9	6.1	0.0	1,797,680.7	288.8	-0.5	-0.1
Maximum:	34.2	18.0	37.4	168.0	3,124,198.4	1,976.5	2.2	1.0
%SI	33.33	33.33	33.33	33.33	33.33	33.33	33.33	33.33

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/26/2020 05:00	20.2	17.9	39.7	0.0	1,781,442.5	299.2	-0.5	-0.1
06/26/2020 06:00	38.7	15.8	44.8	216.8	2,047,960.7	762.7	3.1	0.9
06/26/2020 07:00	7.8	13.6	6.3	105.3	2,718,307.4	1,389.5	1.2	0.7
06/26/2020 08:00	8.1	13.6	6.5	87.1	2,690,051.0	1,394.7	1.0	0.6
06/26/2020 09:00	8.1	13.6	6.5	88.5	2,753,129.9	1,407.3	1.0	0.6
06/26/2020 10:00	8.6	13.5	6.9	99.6	3,056,669.3	1,607.1	1.0	0.6
06/26/2020 11:00	8.2	13.6	6.6	91.2	2,810,841.4	1,436.8	1.0	0.6
06/26/2020 12:00	8.8	13.5	7.0	98.4	2,961,190.0	1,556.9	1.0	0.6
06/26/2020 13:00	9.2	13.3	7.1	107.6	3,157,930.1	1,683.4	1.1	0.7
06/26/2020 14:00	9.1	13.3	7.1	107.6	3,160,368.8	1,684.7	1.1	0.7
06/26/2020 15:00	9.1	13.3	7.1	107.5	3,153,615.5	1,681.1	1.1	0.7
06/26/2020 16:00	9.0	13.4	7.1	107.0	3,157,179.8	1,683.0	1.1	0.7
06/26/2020 17:00	9.0	13.2	6.9	107.9	2,877,898.0	1,639.2	1.2	0.8
06/26/2020 18:00	9.7	12.7	7.0	135.5	3,071,976.1	2,063.8	1.4	1.0
06/26/2020 19:00	9.4	12.7	6.8	135.7	3,086,414.6	2,073.5	1.4	1.0
06/26/2020 20:00	9.2	12.7	6.6	134.7	3,115,816.7	2,070.5	1.4	1.0
06/26/2020 21:00	8.9	12.8	6.5	132.6	3,129,895.5	2,057.0	1.4	1.0
06/26/2020 22:00	9.2	12.9	6.8	122.3	3,121,809.9	1,960.5	1.3	1.0
06/26/2020 23:00	8.0	13.4	6.3	97.1	2,720,343.0	1,470.0	1.1	0.6
Average/Sum#:	11.0	13.6	10.5	109.6	2,872,254.7	1,574.8	1.2	0.7
Minimum:	7.8	12.7	6.3	0.0	1,781,442.5	299.2	-0.5	-0.1
Maximum:	38.7	17.9	44.8	216.8	3,160,368.8	2,073.5	3.1	1.0
%SI	20.83	20.83	20.83	20.83	20.83	20.83	20.83	20.83

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/27/2020 00:00	12.6	14.3	11.3	111.6	2,253,229.8	1,069.5	1.5	0.6
06/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/27/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	12.6	14.3	11.3	111.6	2,253,229.8	1,069.5	1.5	0.6
Minimum:	12.6	14.3	11.3	111.6	2,253,229.8	1,069.5	1.5	0.6
Maximum:	12.6	14.3	11.3	111.6	2,253,229.8	1,069.5	1.5	0.6
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/28/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/28/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/29/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
06/30/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/30/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/30/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/30/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/30/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/30/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/30/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/30/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/30/2020 08:00	29.8	17.4	50.2	0.0	1,816,475.2	411.2	-0.1	0.0
06/30/2020 09:00	37.6	16.9	55.5	138.1	1,857,371.9	515.4	2.2	0.4
06/30/2020 10:00	39.9	16.6	54.7	263.7	1,846,440.5	566.3	4.1	0.9
06/30/2020 11:00	42.0	15.2	43.5	250.1	2,189,834.1	879.5	3.4	1.1
06/30/2020 12:00	7.2	13.7	5.9	89.3	2,715,032.7	1,368.0	1.0	0.5
06/30/2020 13:00	7.6	13.7	6.2	87.0	2,702,132.3	1,361.5	1.0	0.5
06/30/2020 14:00	7.9	13.7	6.5	93.6	2,985,345.2	1,504.2	1.0	0.6
06/30/2020 15:00	7.9	13.7	6.5	93.9	2,940,888.5	1,481.8	1.0	0.6
06/30/2020 16:00	7.8	13.8	6.5	86.8	2,685,659.5	1,353.2	1.0	0.5
06/30/2020 17:00	8.2	13.6	6.6	97.5	2,971,843.8	1,540.8	1.0	0.6
06/30/2020 18:00	9.4	12.9	6.9	128.9	3,217,360.3	2,044.0	1.3	1.0
06/30/2020 19:00	9.2	12.9	6.8	135.4	3,225,379.1	2,096.2	1.4	1.0
06/30/2020 20:00	9.1	12.9	6.7	134.3	3,211,377.1	2,087.1	1.4	1.0
06/30/2020 21:00	9.0	12.9	6.6	131.8	3,218,302.9	2,068.1	1.3	1.0
06/30/2020 22:00	14.9	14.3	13.3	146.3	2,409,600.0	1,231.7	1.9	0.9
06/30/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	16.5	14.3	18.8	125.1	2,666,202.9	1,367.3	1.5	0.7
Minimum:	7.2	12.9	5.9	0.0	1,816,475.2	411.2	-0.1	0.0
Maximum:	42.0	17.4	55.5	263.7	3,225,379.1	2,096.2	4.1	1.1
%SI	37.50	37.50	37.50	37.50	37.50	37.50	37.50	37.50

Excess Emission Report

CT1 - NH3 LbPerHr 1-Hour Block Average

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:34 **Location:** Maxwell, CA

Tag Name: CT1_NH3slip_LbPerHr_1H
Total Operating Time: 697.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,487.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**697.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NH3 Ppmvdc 1-Hour Block Average

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:35 **Location:** Maxwell, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H
Total Operating Time: 697.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,487.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**697.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NH3 LbPerHr 1-Hour Block Average

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:36 **Location:** Maxwell, CA

Tag Name: CT2_NH3slip_LbPerHr_1H
Total Operating Time: 903.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,281.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**903.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NH3 Ppmvdc 1-Hour Block Average

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:36 **Location:** Maxwell, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H
Total Operating Time: 903.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,281.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**903.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 9
Quarterly/Annual Emissions
(Fuel Use, Hours of Operation, and NH_3 Injection)

FCD: AQ-23, 26
Title V: #6, 14

Emissions Limits per AQ-26

Quarterly and Annual Combustion Emissions from CGS Facility					
Pollutant	1st Quarter Emissions (tons)	2nd Quarter Emissions (tons)	3rd Quarter Emissions (tons)	4th Quarter Emissions (tons)	Annual Emissions (tons)
NO_x	45.56	43.58	51.30	44.27	184.7
CO	54.29	52.49	107.15	53.95	267.9
VOC's	12.30	11.63	11.84	11.76	47.5
PM10	25.54	25.78	26.02	26.02	103.4
SO_2	4.07	3.85	3.89	3.89	15.7

Notes

1. Emissions based on CT1 and CT2.
2. VOC Mass Emissions based on Average Source Test Results (lb/MMBtu). CT1 EF = 0.0009 prior to 10/30/2013 and 0.0007 after 10/30/2013. CT2 EF = 0.0007 prior to 11/01/2014 and 0.0003 after 11/01/2014.
3. PM10 based on 2010 lb/MMBtu Source Test Results. CT1 EF = 0.0025; CT2 EF = 0.003

Quarterly Emissions

Cumulative Emissions Report

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:40 **Location:** Maxwell, CA

Month	PlantWide NOx, Tons 1 Day(s)	PlantWide CO, Tons 1 Day(s)	PlantWide VOC, Tons 1 Day(s)	PlantWide PM10, Tons 1 Day(s)	PlantWide SO2, Tons 1 Day(s)
April	3.0	0.8	0.4	2.2	0.0
May	0.6	0.9	0.0	0.1	0.0
June	3.8	2.9	0.3	1.4	0.0
Quarter 2	7.4	4.6	0.7	3.7	0.0
YTD	7.4	4.6	0.7	3.7	0.0

Cumulative Emissions Report

CT1

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:41 **Location:** Maxwell, CA

Month	Unit CT1 GasFlowCT, 100scf 1 Day(s)	Unit CT1 GasFlowDB, 100scf 1 Day(s)	Unit CT1 GasFlow, Total, 100scf 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)
April	6,698,643	409,906	7,108,547.7	423	128.7
May	342,126	0	342,125.6	20	154.6
June	4,497,570	441,842	4,939,409.8	254	153.8
Quarter 2	11,538,339	851,748	12,390,083.1	697	145.7
YTD	11,538,339	851,748	12,390,083.1	697	145.7

Cumulative Emissions Report

CT2

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:42 **Location:** Maxwell, CA

Month	Unit CT2 GasFlowCT, 100scf 1 Day(s)	Unit CT2 GasFlowDB, 100scf 1 Day(s)	Unit CT2 GasFlow, Total, 100scf 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)
April	7,793,643	403,514	8,197,154.3	502	52,208.2
May	635,348	9,727	645,073.9	57	6,105.5
June	4,905,174	431,495	5,336,666.2	344	39,146.1
Quarter 2	13,334,165	844,736	14,178,894.4	903	97,459.8
YTD	13,334,165	844,736	14,178,894.4	903	97,459.8

Monthly Summary By Day Report

VOC PM10

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:43 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
04/01/2020	22.9	81.8	11.9	118.5
04/02/2020	25.1	88.8	11.0	108.9
04/03/2020	0.0	0.0	1.1	9.8
04/04/2020	27.3	96.8	12.5	127.9
04/05/2020	29.4	106.7	12.8	130.1
04/06/2020	31.4	112.8	13.5	137.3
04/07/2020	31.2	110.1	13.3	134.4
04/08/2020	30.0	106.2	12.8	129.8
04/09/2020	35.0	124.6	14.4	150.9
04/10/2020	30.9	109.9	13.2	134.0
04/11/2020	28.3	102.1	12.5	124.6
04/12/2020	27.2	97.5	12.0	119.6
04/13/2020	29.2	104.3	12.7	127.9
04/14/2020	28.5	101.5	12.6	125.5
04/15/2020	29.0	103.2	12.7	126.6
04/16/2020	28.1	100.7	12.4	123.9
04/17/2020	26.4	95.0	11.6	116.5
04/18/2020	0.0	0.0	0.0	0.0
04/19/2020	0.0	0.0	2.2	21.7
04/20/2020	23.7	84.8	11.7	116.8
04/21/2020	0.0	0.0	0.0	0.0
04/22/2020	2.2	8.1	5.4	53.1
04/23/2020	0.0	0.0	0.8	8.2
04/24/2020	8.3	29.8	5.9	58.2
04/25/2020	0.0	0.0	0.0	0.0
04/26/2020	0.0	0.0	0.0	0.0
04/27/2020	0.0	0.0	4.6	46.4
04/28/2020	9.8	34.6	10.0	102.4
04/29/2020	0.0	0.0	4.7	47.1
04/30/2020	0.0	0.0	2.8	28.2
Monthly Avg/Sum*:	503.9 *	1,799.3 *	251.1 *	2,528.3 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	35.0	124.6	14.4	150.9
Apr 2020 - Apr 2020	503.9	1,799.3	251.1	2,528.3
QTD:	503.9 *	1,799.3 *	251.1 *	2,528.3 *
YTD 2020:	2,231.8 *	7,975.8 *	1,047.0 *	10,567.6 *

Monthly Summary By Day Report

VOC PM10

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:43 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
05/01/2020	0.0	0.0	0.0	0.0
05/02/2020	0.0	0.0	0.0	0.0
05/03/2020	0.0	0.0	0.0	0.0
05/04/2020	0.0	0.0	0.0	0.0
05/05/2020	0.0	0.0	0.0	0.0
05/06/2020	0.0	0.0	0.0	0.0
05/07/2020	0.0	0.0	0.0	0.0
05/08/2020	0.0	0.0	0.0	0.0
05/09/2020	0.0	0.0	0.0	0.0
05/10/2020	0.0	0.0	0.0	0.0
05/11/2020	0.0	0.0	0.0	0.0
05/12/2020	0.0	0.0	0.0	0.0
05/13/2020	0.0	0.0	0.0	0.0
05/14/2020	0.0	0.0	0.0	0.0
05/15/2020	0.0	0.0	0.0	0.0
05/16/2020	0.0	0.0	0.0	0.0
05/17/2020	0.0	0.0	0.0	0.0
05/18/2020	0.0	0.0	0.0	0.0
05/19/2020	0.0	0.0	0.0	0.0
05/20/2020	0.0	0.0	0.0	0.0
05/21/2020	0.0	0.0	0.0	0.0
05/22/2020	0.0	0.0	0.0	0.0
05/23/2020	0.0	0.0	0.0	0.0
05/24/2020	0.0	0.0	0.0	0.0
05/25/2020	0.0	0.0	0.0	0.0
05/26/2020	5.7	20.1	0.0	0.0
05/27/2020	0.0	0.0	1.6	15.4
05/28/2020	16.2	58.4	2.1	20.7
05/29/2020	2.4	8.9	1.8	17.8
05/30/2020	0.0	0.0	7.6	77.5
05/31/2020	0.0	0.0	6.5	66.5
Monthly Avg/Sum*:	24.3 *	87.4 *	19.6 *	197.9 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	16.2	58.4	7.6	77.5
Apr 2020 - May 2020	528.2	1,886.7	270.7	2,726.2
QTD:	528.2 *	1,886.7 *	270.7 *	2,726.2 *
YTD 2020:	2,256.1 *	8,063.2 *	1,066.6 *	10,765.5 *

Monthly Summary By Day Report

VOC PM10

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:43 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
06/01/2020	15.3	54.6	10.5	104.4
06/02/2020	37.4	134.6	12.4	126.3
06/03/2020	38.0	136.7	12.7	129.9
06/04/2020	28.0	101.2	7.5	75.7
06/05/2020	0.8	2.8	0.2	1.9
06/06/2020	0.0	0.0	0.0	0.0
06/07/2020	0.0	0.0	0.0	0.0
06/08/2020	12.2	43.6	6.3	62.2
06/09/2020	16.1	57.2	7.2	70.6
06/10/2020	22.6	80.1	8.3	85.9
06/11/2020	35.2	126.3	12.6	127.0
06/12/2020	0.0	0.0	0.0	0.0
06/13/2020	0.0	0.0	0.0	0.0
06/14/2020	0.0	0.0	5.0	49.7
06/15/2020	0.0	0.0	0.0	0.0
06/16/2020	0.0	0.0	0.0	0.0
06/17/2020	17.9	64.0	6.5	65.7
06/18/2020	19.7	70.1	7.9	80.3
06/19/2020	0.0	0.0	0.0	0.0
06/20/2020	0.0	0.0	1.0	10.0
06/21/2020	0.0	0.0	10.6	107.6
06/22/2020	23.9	86.1	12.0	121.5
06/23/2020	19.7	71.6	6.1	62.7
06/24/2020	32.7	115.8	13.9	139.2
06/25/2020	11.5	41.2	6.6	66.7
06/26/2020	10.1	36.2	8.7	89.1
06/27/2020	0.5	2.0	0.2	2.4
06/28/2020	0.0	0.0	0.0	0.0
06/29/2020	0.0	0.0	0.0	0.0
06/30/2020	8.9	31.5	5.9	58.8
Monthly Avg/Sum*:	350.5 *	1,255.6 *	162.1 *	1,637.6 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	38.0	136.7	13.9	139.2
Apr 2020 - Jun 2020	878.7	3,142.3	432.8	4,363.8
QTD:	878.7 *	3,142.3 *	432.8 *	4,363.8 *
YTD 2020:	2,606.6 *	9,318.8 *	1,228.7 *	12,403.1 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:44 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
04/01/2020	91.3	201.60	19.8	0.0	103.00	23.8
04/02/2020	11.6	107.87	21.4	6.2	95.03	21.6
04/03/2020	0.0	0.00	0.0	101.1	157.51	1.9
04/04/2020	109.0	233.05	23.6	0.0	110.40	25.6
04/05/2020	9.8	126.60	25.7	0.0	123.50	26.1
04/06/2020	19.4	114.80	27.0	0.0	136.80	27.5
04/07/2020	16.9	126.10	26.9	0.0	143.00	27.0
04/08/2020	9.0	122.90	25.9	0.0	123.00	26.1
04/09/2020	30.4	149.70	30.0	0.0	201.30	30.5
04/10/2020	18.0	129.10	26.3	0.0	148.30	26.7
04/11/2020	7.7	155.70	24.7	0.0	115.10	24.8
04/12/2020	0.6	112.20	23.8	0.0	94.90	24.0
04/13/2020	9.2	123.30	25.1	0.6	117.30	25.6
04/14/2020	7.6	117.20	24.5	1.5	113.30	25.1
04/15/2020	9.7	117.70	24.7	0.6	124.40	25.2
04/16/2020	6.9	119.90	24.4	0.9	117.40	24.8
04/17/2020	17.2	110.00	23.0	6.3	108.52	23.2
04/18/2020	0.0	0.00	0.0	0.0	0.00	0.0
04/19/2020	0.0	0.00	0.0	130.2	172.81	4.3
04/20/2020	150.8	242.75	20.5	4.1	102.56	23.3
04/21/2020	0.0	0.00	0.0	0.0	0.00	0.0
04/22/2020	122.2	122.49	2.0	164.0	191.59	10.5
04/23/2020	0.0	0.00	0.0	2.7	3.96	1.6
04/24/2020	6.6	20.22	7.1	119.8	213.12	11.6
04/25/2020	0.0	0.00	0.0	0.0	0.00	0.0
04/26/2020	0.0	0.00	0.0	0.0	0.00	0.0
04/27/2020	0.0	0.00	0.0	132.3	225.60	9.5
04/28/2020	122.4	186.29	8.4	8.4	86.50	20.2
04/29/2020	0.0	0.00	0.0	113.9	153.61	9.5
04/30/2020	0.0	0.00	0.0	3.9	14.61	5.6
Monthly Avg/Sum*:	776.3 *	2,739.47 *	434.8 *	796.5 *	3,297.12 *	505.6 *
Daily Min:	0.6	20.22	2.0	0.0	3.96	1.6
Daily Max:	150.8	242.75	30.0	164.0	225.60	30.5
Apr 2020 - Apr 2020	776.3	2,739.47	434.8	796.5	3,297.12	505.6
QTD:	776.3 *	2,739.47 *	434.8 *	796.5 *	3,297.12 *	505.6 *
YTD 2020:	3,944.8 *	12,173.53 *	1,915.6 *	3,160.7 *	13,733.21 *	2,112.5 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:44 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
05/01/2020	0.0	0.00	0.0	0.0	0.00	0.0
05/02/2020	0.0	0.00	0.0	0.0	0.00	0.0
05/03/2020	0.0	0.00	0.0	0.0	0.00	0.0
05/04/2020	0.0	0.00	0.0	0.0	0.00	0.0
05/05/2020	0.0	0.00	0.0	0.0	0.00	0.0
05/06/2020	0.0	0.00	0.0	0.0	0.00	0.0
05/07/2020	0.0	0.00	0.0	0.0	0.00	0.0
05/08/2020	0.0	0.00	0.0	0.0	0.00	0.0
05/09/2020	0.0	0.00	0.0	0.0	0.00	0.0
05/10/2020	0.0	0.00	0.0	0.0	0.00	0.0
05/11/2020	0.0	0.00	0.0	0.0	0.00	0.0
05/12/2020	0.0	0.00	0.0	0.0	0.00	0.0
05/13/2020	0.0	0.00	0.0	0.0	0.00	0.0
05/14/2020	0.0	0.00	0.0	0.0	0.00	0.0
05/15/2020	0.0	0.00	0.0	0.0	0.00	0.0
05/16/2020	0.0	0.00	0.0	0.0	0.00	0.0
05/17/2020	0.0	0.00	0.0	0.0	0.00	0.0
05/18/2020	0.0	0.00	0.0	0.0	0.00	0.0
05/19/2020	0.0	0.00	0.0	0.0	0.00	0.0
05/20/2020	0.0	0.00	0.0	0.0	0.00	0.0
05/21/2020	0.0	0.00	0.0	0.0	0.00	0.0
05/22/2020	0.0	0.00	0.0	0.0	0.00	0.0
05/23/2020	0.0	0.00	0.0	0.0	0.00	0.0
05/24/2020	0.0	0.00	0.0	0.0	0.00	0.0
05/25/2020	0.0	0.00	0.0	0.0	0.00	0.0
05/26/2020	1,315.9	712.23	4.8	0.0	0.00	0.0
05/27/2020	0.0	0.00	0.0	5.3	5.73	3.0
05/28/2020	0.0	47.20	13.9	101.0	95.28	4.2
05/29/2020	15.5	13.72	2.1	153.2	162.39	3.5
05/30/2020	0.0	0.00	0.0	57.8	90.62	15.2
05/31/2020	0.0	0.00	0.0	61.9	123.03	13.1
Monthly Avg/Sum*:	1,331.4 *	773.15 *	20.8 *	379.2 *	477.05 *	39.0 *
Daily Min:	0.0	13.72	2.1	0.0	0.00	0.0
Daily Max:	1,315.9	712.23	13.9	153.2	162.39	15.2
Apr 2020 - May 2020	2,107.7	3,512.62	455.6	1,175.7	3,774.17	544.6
QTD:	2,107.7 *	3,512.62 *	455.6 *	1,175.7 *	3,774.17 *	544.6 *
YTD 2020:	5,276.2 *	12,946.68 *	1,936.4 *	3,539.9 *	14,210.26 *	2,151.5 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 07:44 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
06/01/2020	594.0	468.05	13.0	15.1	79.40	20.7
06/02/2020	7.3	157.40	32.1	20.2	134.60	24.9
06/03/2020	18.2	156.20	32.6	20.5	143.90	25.7
06/04/2020	185.6	211.39	24.2	67.2	161.11	14.7
06/05/2020	14.6	6.63	0.7	7.4	5.09	0.4
06/06/2020	0.0	0.00	0.0	0.0	0.00	0.0
06/07/2020	0.0	0.00	0.0	0.0	0.00	0.0
06/08/2020	555.3	680.74	10.6	200.7	246.05	12.2
06/09/2020	238.1	318.45	13.8	101.2	191.36	13.9
06/10/2020	386.4	337.63	19.0	77.9	159.49	17.1
06/11/2020	34.2	149.54	30.2	37.0	145.24	25.3
06/12/2020	0.0	0.00	0.0	0.0	0.00	0.0
06/13/2020	0.0	0.00	0.0	0.0	0.00	0.0
06/14/2020	0.0	0.00	0.0	233.0	234.97	9.9
06/15/2020	0.0	0.00	0.0	0.0	0.00	0.0
06/16/2020	0.0	0.00	0.0	0.0	0.00	0.0
06/17/2020	652.7	608.10	15.3	143.0	224.31	13.1
06/18/2020	147.2	324.01	16.8	57.1	165.78	16.3
06/19/2020	0.0	0.00	0.0	0.0	0.00	0.0
06/20/2020	0.0	0.00	0.0	167.4	112.88	2.0
06/21/2020	0.0	0.00	0.0	27.1	91.90	21.3
06/22/2020	714.7	524.54	20.8	28.3	120.50	24.0
06/23/2020	121.6	103.10	17.0	84.6	125.50	12.4
06/24/2020	38.0	138.40	27.2	34.0	160.10	27.3
06/25/2020	81.7	90.56	9.9	75.3	121.15	13.4
06/26/2020	102.8	95.77	8.7	66.5	137.03	17.6
06/27/2020	7.6	2.33	0.5	6.7	3.23	0.5
06/28/2020	0.0	0.00	0.0	0.0	0.00	0.0
06/29/2020	0.0	0.00	0.0	0.0	0.00	0.0
06/30/2020	116.3	148.75	7.6	222.2	225.80	11.7
Monthly Avg/Sum*:	4,016.3 *	4,521.59 *	300.0 *	1,692.4 *	2,989.39 *	324.4 *
Daily Min:	7.3	2.33	0.5	6.7	3.23	0.4
Daily Max:	714.7	680.74	32.6	233.0	246.05	27.3
Apr 2020 - Jun 2020	6,124.0	8,034.21	755.6	2,868.1	6,763.56	869.0
QTD:	6,124.0 *	8,034.21 *	755.6 *	2,868.1 *	6,763.56 *	869.0 *
YTD 2020:	9,292.5 *	17,468.27 *	2,236.4 *	5,232.3 *	17,199.65 *	2,475.9 *

Monthly Summary By Day Report

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:44 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/01/2020	20.28	304,662.0	6.04	17,788.0	322,450.0	2,454.8	32,664.040
04/02/2020	21.47	344,989.8	3.25	6,339.7	351,329.5	2,465.7	35,589.670
04/03/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
04/04/2020	22.93	362,103.1	6.07	20,018.2	382,121.3	2,947.0	38,708.760
04/05/2020	24.00	397,032.5	8.73	24,505.3	421,537.8	3,102.8	42,701.900
04/06/2020	24.00	406,052.6	15.04	38,844.4	444,897.0	3,676.7	45,068.200
04/07/2020	24.00	404,740.0	13.01	31,378.6	436,118.6	3,293.0	44,178.800
04/08/2020	24.00	396,928.4	7.43	23,512.3	420,440.7	3,074.7	42,590.800
04/09/2020	24.00	418,021.2	24.00	74,310.5	492,331.7	4,213.2	49,873.200
04/10/2020	24.00	397,241.4	13.21	37,298.6	434,540.0	3,449.7	44,018.800
04/11/2020	24.00	390,481.7	5.02	12,730.8	403,212.5	2,639.5	40,845.400
04/12/2020	24.00	384,533.4	0.55	497.7	385,031.1	2,569.9	39,003.900
04/13/2020	24.00	393,602.1	6.97	17,557.3	411,159.4	3,005.7	41,650.500
04/14/2020	24.00	384,787.0	6.05	16,453.5	401,240.5	2,927.7	40,645.600
04/15/2020	24.00	389,817.7	6.95	17,472.6	407,290.3	3,027.9	41,258.200
04/16/2020	24.00	381,574.0	6.00	16,936.2	398,510.2	2,943.8	40,369.200
04/17/2020	23.48	360,884.8	5.23	13,809.0	374,693.8	2,824.1	37,956.692
04/18/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
04/19/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
04/20/2020	21.18	323,581.8	5.00	11,695.3	335,277.1	2,641.2	33,963.738
04/21/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
04/22/2020	3.51	31,921.4	0.00	0.0	31,921.4	580.4	3,233.613
04/23/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
04/24/2020	7.93	107,215.9	3.55	10,535.2	117,751.1	1,277.5	11,928.190
04/25/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
04/26/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
04/27/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
04/28/2020	8.67	118,472.0	4.79	18,221.7	136,693.7	1,342.3	13,846.995
04/29/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
04/30/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
Monthly Avg/Sum*:	417.45 *	6,698,642.8 *	146.89 *	409,904.9 *	7,108,547.7 *	54,457.6 *	720,096.198 *
Daily Min:	3.51	31,921.4	0.00	0.0	31,921.4	580.4	3,233.613
Daily Max:	24.00	418,021.2	24.00	74,310.5	492,331.7	4,213.2	49,873.200
Apr 2020 - Apr 2020	417.45	6,698,642.8	146.89	409,904.9	7,108,547.7	54,457.6	720,096.198
QTD:	417.45 *	6,698,642.8 *	146.89 *	409,904.9 *	7,108,547.7 *	54,457.6 *	720,096.198 *
YTD 2020:	1,749.20 *	28,965,763.5 *	930.86 *	2,336,786.8 *	31,302,550.3 *	240,508.6 *	3,190,658.422 *

Monthly Summary By Day Report

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:44 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/01/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/02/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/03/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/04/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/05/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/06/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/07/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/08/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/09/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/10/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/11/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/12/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/13/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/14/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/15/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/16/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/17/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/18/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/19/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/20/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/21/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/22/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/23/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/24/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/25/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/26/2020	3.92	78,401.5	0.00	0.0	78,401.5	835.3	8,020.568
05/27/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/28/2020	11.37	228,879.8	0.00	0.0	228,879.8	1,540.4	23,414.384
05/29/2020	1.73	34,844.3	0.00	0.0	34,844.3	252.5	3,564.547
05/30/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/31/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
Monthly Avg/Sum*:	17.02 *	342,125.6 *	0.00 *	0.0 *	342,125.6 *	2,628.2 *	34,999.499 *
Daily Min:	1.73	34,844.3	0.00	0.0	34,844.3	252.5	3,564.547
Daily Max:	11.37	228,879.8	0.00	0.0	228,879.8	1,540.4	23,414.384
Apr 2020 - May 2020	434.47	7,040,768.4	146.89	409,904.9	7,450,673.3	57,085.8	755,095.697
QTD:	434.47 *	7,040,768.4 *	146.89 *	409,904.9 *	7,450,673.3 *	57,085.8 *	755,095.697 *
YTD 2020:	1,766.22 *	29,307,889.1 *	930.86 *	2,336,786.8 *	31,644,675.9 *	243,136.8 *	3,225,657.921 *

Monthly Summary By Day Report

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:44 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/01/2020	10.56	213,455.0	0.15	20.7	213,475.7	1,174.8	21,838.574
06/02/2020	24.00	484,557.1	11.07	40,837.1	525,394.2	3,181.4	53,747.500
06/03/2020	24.00	481,935.4	14.03	53,447.2	535,382.6	3,587.5	54,769.900
06/04/2020	17.80	357,339.6	10.22	38,548.2	395,887.7	2,930.0	40,499.096
06/05/2020	0.53	10,625.0	0.20	186.1	10,811.1	147.6	1,105.951
06/06/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
06/07/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
06/08/2020	7.90	161,730.1	3.75	8,482.4	170,212.5	1,273.8	17,412.732
06/09/2020	10.12	204,467.5	6.25	18,879.2	223,346.7	1,826.2	22,848.314
06/10/2020	13.70	282,203.9	9.07	31,529.4	313,733.3	2,450.7	32,094.820
06/11/2020	23.48	470,227.3	10.20	27,722.0	497,949.2	3,472.4	50,511.448
06/12/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
06/13/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
06/14/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
06/15/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
06/16/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
06/17/2020	10.87	236,692.6	5.35	17,101.8	253,794.5	2,046.3	25,607.812
06/18/2020	11.70	251,023.5	8.02	26,766.6	277,790.1	2,031.1	28,028.900
06/19/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
06/20/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
06/21/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
06/22/2020	13.92	303,734.6	10.05	37,179.8	340,914.4	2,399.9	34,398.152
06/23/2020	16.61	252,245.9	8.23	30,739.5	282,985.4	2,806.5	28,553.410
06/24/2020	24.00	395,575.4	19.09	62,464.4	458,039.8	3,707.0	46,216.200
06/25/2020	10.57	149,008.5	4.82	14,008.2	163,016.7	1,541.1	16,448.429
06/26/2020	8.96	123,677.6	5.72	19,544.5	143,222.1	1,703.0	14,451.150
06/27/2020	0.75	7,763.9	0.00	0.0	7,763.9	119.9	783.375
06/28/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
06/29/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
06/30/2020	8.01	111,305.3	4.27	14,384.5	125,689.9	1,284.7	12,682.195
Monthly Avg/Sum*:	237.48 *	4,497,568.2 *	130.49 *	441,841.6 *	4,939,409.8 *	37,683.9 *	501,997.958 *
Daily Min:	0.53	7,763.9	0.00	0.0	7,763.9	119.9	783.375
Daily Max:	24.00	484,557.1	19.09	62,464.4	535,382.6	3,707.0	54,769.900
Apr 2020 - Jun 2020	671.95	11,538,336.6	277.38	851,746.5	12,390,083.1	94,769.7	1,257,093.655
QTD:	671.95 *	11,538,336.6 *	277.38 *	851,746.5 *	12,390,083.1 *	94,769.7 *	1,257,093.655 *
YTD 2020:	2,003.70 *	33,805,457.3 *	1,061.35 *	2,778,628.4 *	36,584,085.7 *	280,820.7 *	3,727,655.879 *

Monthly Summary By Day Report

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:45 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/01/2020	24.00	367,126.1	6.07	17,087.7	384,213.8	2,291.5	39,497.200
04/02/2020	21.47	346,435.1	3.30	6,292.4	352,727.5	2,137.5	36,260.371
04/03/2020	3.72	31,808.9	0.00	0.0	31,808.9	597.7	3,269.944
04/04/2020	24.00	395,633.0	6.07	18,676.6	414,309.6	2,428.2	42,591.100
04/05/2020	24.00	398,672.9	8.75	23,290.3	421,963.2	2,494.8	43,377.700
04/06/2020	24.00	407,799.1	15.02	37,266.0	445,065.1	2,925.0	45,752.700
04/07/2020	24.00	405,963.9	13.01	30,193.7	436,157.6	2,560.0	44,837.100
04/08/2020	24.00	399,188.2	7.43	22,014.4	421,202.6	2,473.5	43,299.700
04/09/2020	24.00	420,276.6	24.00	69,682.0	489,958.6	2,897.3	50,368.000
04/10/2020	24.00	399,878.3	13.19	35,199.6	435,077.9	2,551.2	44,726.000
04/11/2020	24.00	392,793.4	5.02	12,261.3	405,054.7	2,376.0	41,639.600
04/12/2020	24.00	386,956.9	0.55	503.3	387,460.2	2,272.6	39,831.000
04/13/2020	24.00	397,622.5	6.97	16,899.9	414,522.4	2,472.7	42,613.000
04/14/2020	24.00	390,747.6	6.02	15,610.4	406,358.0	2,365.6	41,773.700
04/15/2020	24.00	393,780.1	6.95	16,472.7	410,252.8	2,411.0	42,174.100
04/16/2020	24.00	385,715.5	6.00	15,835.1	401,550.6	2,353.5	41,279.500
04/17/2020	23.48	363,978.4	5.23	13,081.6	377,060.0	2,316.8	38,761.696
04/18/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
04/19/2020	6.70	70,094.5	0.00	0.0	70,094.5	777.5	7,205.600
04/20/2020	23.23	367,448.8	5.00	11,252.4	378,701.2	2,373.3	38,930.694
04/21/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
04/22/2020	14.08	172,054.9	0.00	0.0	172,054.9	1,887.3	17,687.434
04/23/2020	2.17	26,624.9	0.00	0.0	26,624.9	365.3	2,737.057
04/24/2020	13.30	177,190.0	3.75	10,409.5	187,599.5	1,611.8	19,285.310
04/25/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
04/26/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
04/27/2020	10.67	143,422.1	3.92	7,387.9	150,810.0	1,203.6	15,503.187
04/28/2020	22.00	315,572.6	4.79	16,207.5	331,780.1	2,067.3	34,106.900
04/29/2020	10.68	144,917.9	3.93	7,888.5	152,806.4	1,229.7	15,708.512
04/30/2020	7.17	91,939.3	0.00	0.0	91,939.3	767.5	9,451.296
Monthly Avg/Sum*:	494.67 *	7,793,641.5 *	154.97 *	403,512.8 *	8,197,154.3 *	52,208.2 *	842,668.401 *
Daily Min:	2.17	26,624.9	0.00	0.0	26,624.9	365.3	2,737.057
Daily Max:	24.00	420,276.6	24.00	69,682.0	489,958.6	2,925.0	50,368.000
Apr 2020 - Apr 2020	494.67	7,793,641.5	154.97	403,512.8	8,197,154.3	52,208.2	842,668.401
QTD:	494.67 *	7,793,641.5 *	154.97 *	403,512.8 *	8,197,154.3 *	52,208.2 *	842,668.401 *
YTD 2020:	1,961.14 *	31,971,748.8 *	959.06 *	2,297,099.2 *	34,268,848.2 *	212,078.3 *	3,522,839.520 *

Monthly Summary By Day Report

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:45 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/01/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/02/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/03/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/04/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/05/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/06/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/07/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/08/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/09/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/10/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/11/2020	0.05	0.0	0.00	0.0	0.1	0.0	0.010
05/12/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/13/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/14/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/15/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/16/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/17/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/18/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/19/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/20/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/21/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/22/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/23/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/24/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/25/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/26/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
05/27/2020	5.61	49,547.2	0.00	0.0	49,547.2	948.5	5,068.672
05/28/2020	5.17	67,482.9	0.05	0.8	67,483.7	517.8	6,903.500
05/29/2020	5.26	57,552.2	0.53	458.5	58,010.7	732.6	5,934.547
05/30/2020	18.29	247,857.2	2.98	5,314.6	253,171.8	1,847.1	25,899.516
05/31/2020	15.87	212,908.6	2.45	3,951.8	216,860.4	2,059.5	22,184.715
Monthly Avg/Sum*:	50.25 *	635,348.1 *	6.01 *	9,725.7 *	645,073.9 *	6,105.5 *	65,990.960 *
Daily Min:	0.05	0.0	0.00	0.0	0.1	0.0	0.010
Daily Max:	18.29	247,857.2	2.98	5,314.6	253,171.8	2,059.5	25,899.516
Apr 2020 - May 2020	544.92	8,428,989.6	160.98	413,238.5	8,842,228.2	58,313.7	908,659.361
QTD:	544.92 *	8,428,989.6 *	160.98 *	413,238.5 *	8,842,228.2 *	58,313.7 *	908,659.361 *
YTD 2020:	2,011.39 *	32,607,096.9 *	965.07 *	2,306,824.9 *	34,913,922.1 *	218,183.8 *	3,588,830.480 *

Monthly Summary By Day Report



From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 07:45 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/01/2020	24.00	339,838.9	0.00	0.0	339,838.9	1,995.6	34,765.400
06/02/2020	24.00	374,436.8	11.03	37,052.9	411,489.7	2,508.8	42,095.500
06/03/2020	24.00	378,491.3	14.03	45,191.8	423,683.1	2,778.9	43,343.000
06/04/2020	13.91	212,648.5	10.23	34,905.9	247,554.4	1,942.4	25,324.801
06/05/2020	0.53	6,020.7	0.22	206.0	6,226.8	137.3	637.007
06/06/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
06/07/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
06/08/2020	14.43	193,604.4	3.75	8,208.8	201,813.2	1,810.6	20,645.526
06/09/2020	15.01	211,649.7	6.23	17,602.2	229,251.9	2,011.7	23,452.409
06/10/2020	16.37	251,201.4	9.07	29,247.5	280,448.9	1,963.9	28,689.939
06/11/2020	23.48	387,268.9	10.22	26,746.8	414,015.8	2,714.4	42,353.936
06/12/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
06/13/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
06/14/2020	10.88	148,434.6	5.94	13,136.5	161,571.1	1,613.5	16,528.722
06/15/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
06/16/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
06/17/2020	14.37	197,776.4	5.35	15,920.4	213,696.7	1,822.9	21,861.253
06/18/2020	15.62	237,130.5	8.02	24,645.9	261,776.4	1,990.1	26,779.839
06/19/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
06/20/2020	3.95	32,703.1	0.00	0.0	32,703.1	611.6	3,345.450
06/21/2020	24.00	336,296.6	4.90	14,693.5	350,990.1	2,301.3	35,906.400
06/22/2020	24.00	361,730.0	10.05	34,682.8	396,412.8	2,592.9	40,553.000
06/23/2020	11.78	175,612.1	8.22	28,095.3	203,707.4	1,660.0	20,839.146
06/24/2020	24.00	395,603.8	19.07	58,168.2	453,772.0	2,942.3	46,420.900
06/25/2020	14.57	205,853.5	4.82	11,808.8	217,662.2	1,677.2	22,266.870
06/26/2020	18.22	272,320.2	5.70	17,881.1	290,201.3	2,082.4	29,687.524
06/27/2020	0.75	7,841.3	0.00	0.0	7,841.3	111.6	802.125
06/28/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
06/29/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
06/30/2020	13.93	178,710.0	4.27	13,299.0	192,009.1	1,876.7	19,642.356
Monthly Avg/Sum*:	331.80 *	4,905,172.7 *	141.12 *	431,493.4 *	5,336,666.2 *	39,146.1 *	545,941.103 *
Daily Min:	0.53	6,020.7	0.00	0.0	6,226.8	111.6	637.007
Daily Max:	24.00	395,603.8	19.07	58,168.2	453,772.0	2,942.3	46,420.900
Apr 2020 - Jun 2020	876.72	13,334,162.3	302.10	844,731.9	14,178,894.4	97,459.8	1,454,600.464
QTD:	876.72 *	13,334,162.3 *	302.10 *	844,731.9 *	14,178,894.4 *	97,459.8 *	1,454,600.464 *
YTD 2020:	2,343.19 *	37,512,269.6 *	1,106.19 *	2,738,318.3 *	40,250,588.3 *	257,329.9 *	4,134,771.583 *

ATTACHMENT 10
Maximum Emissions

FCD: AQ-25
Title V: #6

AQ-25 Emission Limits

Maximum Emissions Both Turbines (lbs)		
Pollutant	1-Hour Emissions	24-Hour Emissions
NO_x	666.60	2,994.60
CO	967.00	7,659.00
VOC	55.40	630.60
PM10	27.00	648.00
SO_2	14.80	355.20

Monthly Summary By Day Report

AQ-25

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
04/01/2020	304.6	91.3	34.8	200.3	23.8
04/02/2020	202.9	17.8	36.1	197.7	21.6
04/03/2020	157.5	101.1	1.1	9.8	1.9
04/04/2020	343.5	109.0	39.8	224.7	25.6
04/05/2020	250.1	9.8	42.2	236.8	26.1
04/06/2020	251.6	19.4	44.9	250.1	27.5
04/07/2020	269.1	16.9	44.5	244.5	27.0
04/08/2020	245.9	9.0	42.8	236.0	26.1
04/09/2020	351.0	30.4	49.4	275.5	30.5
04/10/2020	277.4	18.0	44.1	243.9	26.7
04/11/2020	270.8	7.7	40.8	226.7	24.8
04/12/2020	207.1	0.6	39.2	217.1	24.0
04/13/2020	240.6	9.8	41.9	232.2	25.6
04/14/2020	230.5	9.1	41.1	227.0	25.1
04/15/2020	242.1	10.3	41.7	229.8	25.2
04/16/2020	237.3	7.8	40.5	224.6	24.8
04/17/2020	218.5	23.5	38.0	211.5	23.2
04/18/2020	0.0	0.0	0.0	0.0	0.0
04/19/2020	172.8	130.2	2.2	21.7	4.3
04/20/2020	345.4	154.9	35.4	201.6	23.3
04/21/2020	0.0	0.0	0.0	0.0	0.0
04/22/2020	314.1	286.2	7.6	61.2	10.5
04/23/2020	4.0	2.7	0.8	8.2	1.6
04/24/2020	233.3	126.4	14.2	88.0	11.6
04/25/2020	0.0	0.0	0.0	0.0	0.0
04/26/2020	0.0	0.0	0.0	0.0	0.0
04/27/2020	225.6	132.3	4.6	46.4	9.5
04/28/2020	272.8	130.8	19.8	137.0	20.2
04/29/2020	153.6	113.9	4.7	47.1	9.5
04/30/2020	14.6	3.9	2.8	28.2	5.6
Monthly Avg/Sum*:	6,036.7 *	1,572.8 *	755.0 *	4,327.6 *	- *
Daily Min:	0.0	0.0	0.0	0.0	-
Daily Max:	351.0	286.2	49.4	275.5	-
Apr 2020 - Apr 2020	6,036.7	1,572.8	755.0	4,327.6	-
QTD:	6,036.7 *	1,572.8 *	755.0 *	4,327.6 *	0.0 *
YTD 2020:	25,907.3 *	7,105.5 *	3,278.8 *	18,543.4 *	46.1 *

Monthly Summary By Day Report

AQ-25

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
05/01/2020	0.0	0.0	0.0	0.0	0.0
05/02/2020	0.0	0.0	0.0	0.0	0.0
05/03/2020	0.0	0.0	0.0	0.0	0.0
05/04/2020	0.0	0.0	0.0	0.0	0.0
05/05/2020	0.0	0.0	0.0	0.0	0.0
05/06/2020	0.0	0.0	0.0	0.0	0.0
05/07/2020	0.0	0.0	0.0	0.0	0.0
05/08/2020	0.0	0.0	0.0	0.0	0.0
05/09/2020	0.0	0.0	0.0	0.0	0.0
05/10/2020	0.0	0.0	0.0	0.0	0.0
05/11/2020	0.0	0.0	0.0	0.0	0.0
05/12/2020	0.0	0.0	0.0	0.0	0.0
05/13/2020	0.0	0.0	0.0	0.0	0.0
05/14/2020	0.0	0.0	0.0	0.0	0.0
05/15/2020	0.0	0.0	0.0	0.0	0.0
05/16/2020	0.0	0.0	0.0	0.0	0.0
05/17/2020	0.0	0.0	0.0	0.0	0.0
05/18/2020	0.0	0.0	0.0	0.0	0.0
05/19/2020	0.0	0.0	0.0	0.0	0.0
05/20/2020	0.0	0.0	0.0	0.0	0.0
05/21/2020	0.0	0.0	0.0	0.0	0.0
05/22/2020	0.0	0.0	0.0	0.0	0.0
05/23/2020	0.0	0.0	0.0	0.0	0.0
05/24/2020	0.0	0.0	0.0	0.0	0.0
05/25/2020	0.0	0.0	0.0	0.0	0.0
05/26/2020	712.2	1,315.9	5.7	20.1	0.0
05/27/2020	5.7	5.3	1.6	15.4	3.0
05/28/2020	142.5	101.0	18.3	79.1	4.2
05/29/2020	176.1	168.7	4.2	26.7	3.5
05/30/2020	90.6	57.8	7.6	77.5	15.2
05/31/2020	123.0	61.9	6.5	66.5	13.1
Monthly Avg/Sum*:	1,250.1 *	1,710.6 *	43.9 *	285.3 *	- *
Daily Min:	0.0	0.0	0.0	0.0	-
Daily Max:	712.2	1,315.9	18.3	79.1	-
Apr 2020 - May 2020	7,286.8	3,283.4	798.9	4,612.9	-
QTD:	7,286.8 *	3,283.4 *	798.9 *	4,612.9 *	0.0 *
YTD 2020:	27,157.4 *	8,816.1 *	3,322.7 *	18,828.7 *	46.1 *

Monthly Summary By Day Report

AQ-25

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
06/01/2020	547.5	609.1	25.8	159.0	20.7
06/02/2020	292.0	27.5	49.8	260.9	24.9
06/03/2020	300.1	38.7	50.7	266.6	25.7
06/04/2020	372.5	252.8	35.5	176.9	14.7
06/05/2020	11.7	22.0	1.0	4.7	0.4
06/06/2020	0.0	0.0	0.0	0.0	0.0
06/07/2020	0.0	0.0	0.0	0.0	0.0
06/08/2020	926.8	756.0	18.5	105.8	12.2
06/09/2020	509.9	339.3	23.3	127.8	13.9
06/10/2020	497.1	464.3	30.9	166.0	17.1
06/11/2020	294.7	71.2	47.8	253.3	25.3
06/12/2020	0.0	0.0	0.0	0.0	0.0
06/13/2020	0.0	0.0	0.0	0.0	0.0
06/14/2020	235.0	233.0	5.0	49.7	9.9
06/15/2020	0.0	0.0	0.0	0.0	0.0
06/16/2020	0.0	0.0	0.0	0.0	0.0
06/17/2020	832.4	795.7	24.4	129.7	13.1
06/18/2020	489.8	204.3	27.6	150.4	16.3
06/19/2020	0.0	0.0	0.0	0.0	0.0
06/20/2020	112.9	167.4	1.0	10.0	2.0
06/21/2020	91.9	27.1	10.6	107.6	21.3
06/22/2020	645.0	743.0	35.9	207.6	24.0
06/23/2020	228.6	206.2	25.8	134.3	12.4
06/24/2020	298.5	72.0	46.6	255.0	27.3
06/25/2020	211.8	157.0	18.1	107.9	13.4
06/26/2020	232.8	169.3	18.8	125.3	17.6
06/27/2020	5.5	14.3	0.7	4.4	0.5
06/28/2020	0.0	0.0	0.0	0.0	0.0
06/29/2020	0.0	0.0	0.0	0.0	0.0
06/30/2020	374.6	338.5	14.8	90.3	11.7
Monthly Avg/Sum*:	7,511.1 *	5,708.7 *	512.6 *	2,893.2 *	- *
Daily Min:	0.0	0.0	0.0	0.0	-
Daily Max:	926.8	795.7	50.7	266.6	-
Apr 2020 - Jun 2020	14,797.9	8,992.1	1,311.5	7,506.1	-
QTD:	14,797.9 *	8,992.1 *	1,311.5 *	7,506.1 *	0.0 *
YTD 2020:	34,668.5 *	14,524.8 *	3,835.3 *	21,721.9 *	46.1 *

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/01/2020 00:00	2.7	0.0	0.4	4.1	0.8
04/01/2020 01:00	2.7	0.0	0.4	4.1	0.8
04/01/2020 02:00	2.7	0.0	0.4	4.0	0.8
04/01/2020 03:00	20.0	34.7	0.6	5.1	1.1
04/01/2020 04:00	99.8	48.6	1.1	6.8	1.5
04/01/2020 05:00	6.3	0.0	1.6	8.6	1.8
04/01/2020 06:00	6.1	0.0	1.6	8.4	1.8
04/01/2020 07:00	8.0	0.0	1.6	8.8	2.0
04/01/2020 08:00	7.5	0.0	1.5	8.3	1.8
04/01/2020 09:00	7.1	0.0	1.4	7.8	1.7
04/01/2020 10:00	5.3	0.0	1.3	7.3	1.6
04/01/2020 11:00	3.9	0.0	1.3	7.2	1.6
04/01/2020 12:00	5.3	0.0	1.3	7.3	1.6
04/01/2020 13:00	7.4	0.0	1.5	8.2	1.8
04/01/2020 14:00	7.7	0.0	1.6	8.5	1.8
04/01/2020 15:00	8.1	0.0	1.6	8.9	2.0
04/01/2020 16:00	8.2	0.0	1.6	9.1	2.0
04/01/2020 17:00	7.9	0.0	1.6	8.7	1.9
04/01/2020 18:00	14.1	1.6	2.0	11.0	2.4
04/01/2020 19:00	15.0	1.6	2.1	11.7	2.6
04/01/2020 20:00	14.8	1.3	2.1	11.7	2.6
04/01/2020 21:00	14.8	1.3	2.1	11.7	2.6
04/01/2020 22:00	14.8	1.3	2.1	11.7	2.6
04/01/2020 23:00	14.4	0.9	2.0	11.3	2.4
Average/Sum#:	304.6 #	91.3 #	34.8 #	200.3 #	43.6 #
Minimum:	2.7	0.0	0.4	4.0	0.8
Maximum:	99.8	48.6	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/02/2020 00:00	7.7	0.0	1.6	8.5	1.8
04/02/2020 01:00	7.6	0.0	1.6	8.4	1.8
04/02/2020 02:00	8.1	0.0	1.6	8.9	2.0
04/02/2020 03:00	8.4	0.0	1.7	9.2	2.0
04/02/2020 04:00	8.4	0.0	1.7	9.2	2.0
04/02/2020 05:00	6.3	0.0	1.6	8.7	1.9
04/02/2020 06:00	8.4	0.0	1.7	9.2	2.0
04/02/2020 07:00	8.1	0.0	1.6	8.9	2.0
04/02/2020 08:00	8.4	0.0	1.7	9.3	2.0
04/02/2020 09:00	8.4	0.0	1.7	9.2	2.0
04/02/2020 10:00	8.2	0.0	1.6	9.1	2.0
04/02/2020 11:00	7.7	0.0	1.6	8.6	1.8
04/02/2020 12:00	7.9	0.0	1.6	8.8	1.9
04/02/2020 13:00	8.2	0.0	1.6	9.1	2.0
04/02/2020 14:00	8.4	0.0	1.7	9.2	2.0
04/02/2020 15:00	8.3	0.0	1.7	9.1	2.0
04/02/2020 16:00	8.1	0.0	1.6	8.9	2.0
04/02/2020 17:00	9.7	0.0	1.6	8.9	2.0
04/02/2020 18:00	13.9	1.6	2.0	11.0	2.4
04/02/2020 19:00	14.2	1.6	2.0	11.2	2.4
04/02/2020 20:00	14.3	1.3	2.0	11.2	2.4
04/02/2020 21:00	14.2	13.3	0.6	3.1	0.6
04/02/2020 22:00	0.0	0.0	0.0	0.0	0.0
04/02/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	202.9 #	17.8 #	36.1 #	197.7 #	43.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	14.3	13.3	2.0	11.2	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/03/2020 00:00	0.0	0.0	0.0	0.0	0.0
04/03/2020 01:00	0.0	0.0	0.0	0.0	0.0
04/03/2020 02:00	0.0	0.0	0.0	0.0	0.0
04/03/2020 03:00	0.0	0.0	0.0	0.0	0.0
04/03/2020 04:00	0.0	0.0	0.0	0.0	0.0
04/03/2020 05:00	0.0	0.0	0.0	0.0	0.0
04/03/2020 06:00	0.0	0.0	0.0	0.0	0.0
04/03/2020 07:00	0.0	0.0	0.0	0.0	0.0
04/03/2020 08:00	0.0	0.0	0.0	0.0	0.0
04/03/2020 09:00	0.0	0.0	0.0	0.0	0.0
04/03/2020 10:00	0.0	0.0	0.0	0.0	0.0
04/03/2020 11:00	0.0	0.0	0.0	0.0	0.0
04/03/2020 12:00	0.0	0.0	0.0	0.0	0.0
04/03/2020 13:00	0.0	0.0	0.0	0.0	0.0
04/03/2020 14:00	0.0	0.0	0.0	0.0	0.0
04/03/2020 15:00	0.0	0.0	0.0	0.0	0.0
04/03/2020 16:00	0.0	0.0	0.0	0.0	0.0
04/03/2020 17:00	0.0	0.0	0.0	0.0	0.0
04/03/2020 18:00	0.0	0.0	0.0	0.0	0.0
04/03/2020 19:00	0.0	0.0	0.0	0.0	0.0
04/03/2020 20:00	73.5	49.3	0.1	1.0	0.2
04/03/2020 21:00	32.8	16.5	0.2	1.6	0.3
04/03/2020 22:00	48.1	35.3	0.3	2.6	0.5
04/03/2020 23:00	3.1	0.0	0.5	4.6	0.9
Average/Sum#:	157.5 #	101.1 #	1.1 #	9.8 #	1.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	73.5	49.3	0.5	4.6	0.9
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/04/2020 00:00	3.2	0.0	0.5	4.9	1.0
04/04/2020 01:00	83.8	66.4	0.8	6.2	1.3
04/04/2020 02:00	45.4	35.0	1.1	7.0	1.5
04/04/2020 03:00	8.4	0.0	1.7	9.3	2.0
04/04/2020 04:00	8.2	0.0	1.7	9.1	2.0
04/04/2020 05:00	8.4	0.0	1.7	9.3	2.0
04/04/2020 06:00	6.6	0.0	1.6	9.1	2.0
04/04/2020 07:00	8.4	0.0	1.7	9.3	2.0
04/04/2020 08:00	8.4	0.0	1.7	9.1	2.0
04/04/2020 09:00	8.2	0.0	1.6	9.1	2.0
04/04/2020 10:00	8.2	0.0	1.6	9.0	2.0
04/04/2020 11:00	8.3	0.0	1.6	9.1	2.0
04/04/2020 12:00	8.4	0.0	1.7	9.2	2.0
04/04/2020 13:00	8.4	0.0	1.7	9.2	2.0
04/04/2020 14:00	8.4	0.0	1.7	9.2	2.0
04/04/2020 15:00	8.2	0.0	1.6	9.1	2.0
04/04/2020 16:00	8.4	0.0	1.7	9.2	2.0
04/04/2020 17:00	8.2	0.0	1.6	9.1	2.0
04/04/2020 18:00	13.9	1.6	2.0	11.0	2.4
04/04/2020 19:00	15.0	1.2	2.1	11.8	2.6
04/04/2020 20:00	14.8	1.2	2.1	11.7	2.6
04/04/2020 21:00	14.8	1.2	2.1	11.7	2.6
04/04/2020 22:00	14.7	1.2	2.1	11.5	2.6
04/04/2020 23:00	14.8	1.2	2.1	11.5	2.6
Average/Sum#:	343.5 #	109.0 #	39.8 #	224.7 #	49.2 #
Minimum:	3.2	0.0	0.5	4.9	1.0
Maximum:	83.8	66.4	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/05/2020 00:00	14.7	1.2	2.1	11.5	2.6
04/05/2020 01:00	10.3	0.0	1.7	9.4	2.0
04/05/2020 02:00	8.3	0.0	1.6	9.1	2.0
04/05/2020 03:00	8.2	0.0	1.6	9.1	2.0
04/05/2020 04:00	8.2	0.0	1.6	9.1	2.0
04/05/2020 05:00	8.4	0.0	1.7	9.1	2.0
04/05/2020 06:00	8.2	0.0	1.6	9.1	2.0
04/05/2020 07:00	8.1	0.0	1.6	8.9	2.0
04/05/2020 08:00	8.4	0.0	1.7	9.1	2.0
04/05/2020 09:00	8.2	0.0	1.6	9.1	2.0
04/05/2020 10:00	6.5	0.0	1.6	8.9	2.0
04/05/2020 11:00	8.0	0.0	1.6	8.9	2.0
04/05/2020 12:00	7.9	0.0	1.6	8.7	1.9
04/05/2020 13:00	8.2	0.0	1.6	9.1	2.0
04/05/2020 14:00	8.2	0.0	1.6	9.1	2.0
04/05/2020 15:00	8.2	0.0	1.6	9.1	2.0
04/05/2020 16:00	10.7	0.3	1.7	9.8	2.2
04/05/2020 17:00	14.5	1.3	2.1	11.5	2.5
04/05/2020 18:00	14.5	1.2	2.0	11.3	2.4
04/05/2020 19:00	14.4	1.3	2.0	11.3	2.4
04/05/2020 20:00	14.5	1.3	2.0	11.3	2.4
04/05/2020 21:00	14.6	1.3	2.0	11.5	2.5
04/05/2020 22:00	14.4	0.6	2.0	11.3	2.4
04/05/2020 23:00	14.5	1.3	2.0	11.5	2.5
Average/Sum#:	250.1 #	9.8 #	42.2 #	236.8 #	51.8 #
Minimum:	6.5	0.0	1.6	8.7	1.9
Maximum:	14.7	1.3	2.1	11.5	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/06/2020 00:00	14.6	1.3	2.0	11.5	2.5
04/06/2020 01:00	14.6	1.3	2.0	11.5	2.5
04/06/2020 02:00	14.7	1.3	2.1	11.5	2.6
04/06/2020 03:00	14.7	1.3	2.1	11.5	2.6
04/06/2020 04:00	14.4	1.3	2.0	11.3	2.4
04/06/2020 05:00	14.5	1.6	2.0	11.3	2.4
04/06/2020 06:00	14.6	1.6	2.1	11.5	2.5
04/06/2020 07:00	8.2	0.0	2.0	11.2	2.4
04/06/2020 08:00	3.3	0.0	1.6	9.1	2.0
04/06/2020 09:00	5.0	0.0	1.6	9.1	2.0
04/06/2020 10:00	5.0	0.0	1.7	9.2	2.0
04/06/2020 11:00	4.8	0.0	1.6	8.9	2.0
04/06/2020 12:00	3.2	0.0	1.6	8.9	2.0
04/06/2020 13:00	4.7	0.0	1.6	8.7	1.9
04/06/2020 14:00	5.0	0.0	1.6	9.1	2.0
04/06/2020 15:00	6.6	0.0	1.6	9.1	2.0
04/06/2020 16:00	6.2	0.0	1.6	8.5	1.8
04/06/2020 17:00	11.9	1.6	2.0	11.0	2.4
04/06/2020 18:00	14.2	1.6	2.0	11.1	2.4
04/06/2020 19:00	13.9	1.3	2.0	10.9	2.4
04/06/2020 20:00	14.1	1.3	2.0	11.1	2.4
04/06/2020 21:00	14.4	1.3	2.0	11.3	2.4
04/06/2020 22:00	14.4	1.3	2.0	11.3	2.4
04/06/2020 23:00	14.6	1.3	2.1	11.5	2.5
Average/Sum#:	236.9 #	19.4 #	44.9 #	250.1 #	54.5 #
Minimum:	4.7	0.0	1.6	8.5	1.8
Maximum:	14.7	1.6	2.1	11.5	2.6
%SI	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/07/2020 00:00	14.2	1.3	2.0	11.1	2.4
04/07/2020 01:00	14.1	1.3	2.0	11.1	2.4
04/07/2020 02:00	14.1	1.3	2.0	11.1	2.4
04/07/2020 03:00	14.1	1.3	2.0	11.1	2.4
04/07/2020 04:00	14.1	1.3	2.0	11.1	2.4
04/07/2020 05:00	14.1	1.3	2.0	11.1	2.4
04/07/2020 06:00	13.7	1.3	2.0	10.7	2.4
04/07/2020 07:00	6.5	0.0	1.6	8.9	2.0
04/07/2020 08:00	6.5	0.0	1.6	8.9	2.0
04/07/2020 09:00	6.7	0.0	1.7	9.1	2.0
04/07/2020 10:00	8.3	0.0	1.6	9.1	2.0
04/07/2020 11:00	8.4	0.0	1.7	9.2	2.0
04/07/2020 12:00	8.4	0.0	1.7	9.1	2.0
04/07/2020 13:00	6.5	0.0	1.6	8.9	2.0
04/07/2020 14:00	8.0	0.0	1.6	8.9	2.0
04/07/2020 15:00	8.3	0.0	1.7	9.1	2.0
04/07/2020 16:00	8.4	0.0	1.7	9.2	2.0
04/07/2020 17:00	7.9	0.0	1.6	8.7	1.9
04/07/2020 18:00	13.9	1.6	2.0	10.9	2.4
04/07/2020 19:00	14.1	1.3	2.0	11.1	2.4
04/07/2020 20:00	14.7	1.2	2.1	11.5	2.6
04/07/2020 21:00	14.7	1.2	2.1	11.5	2.6
04/07/2020 22:00	14.7	1.2	2.1	11.5	2.6
04/07/2020 23:00	14.7	1.3	2.1	11.6	2.6
Average/Sum#:	269.1 #	16.9 #	44.5 #	244.5 #	53.9 #
Minimum:	6.5	0.0	1.6	8.7	1.9
Maximum:	14.7	1.6	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/08/2020 00:00	14.1	1.2	2.0	11.0	2.4
04/08/2020 01:00	6.6	0.0	1.6	9.1	2.0
04/08/2020 02:00	6.5	0.0	1.6	8.9	2.0
04/08/2020 03:00	8.3	0.0	1.6	9.1	2.0
04/08/2020 04:00	6.5	0.0	1.6	8.9	2.0
04/08/2020 05:00	8.3	0.0	1.7	9.1	2.0
04/08/2020 06:00	8.4	0.0	1.7	9.2	2.0
04/08/2020 07:00	8.2	0.0	1.6	9.1	2.0
04/08/2020 08:00	8.3	0.0	1.7	9.2	2.0
04/08/2020 09:00	8.4	0.0	1.7	9.2	2.0
04/08/2020 10:00	8.4	0.0	1.7	9.2	2.0
04/08/2020 11:00	8.1	0.0	1.6	8.9	2.0
04/08/2020 12:00	8.4	0.0	1.7	9.2	2.0
04/08/2020 13:00	10.0	0.0	1.7	9.2	2.0
04/08/2020 14:00	10.1	0.0	1.7	9.2	2.0
04/08/2020 15:00	9.9	0.0	1.7	9.1	2.0
04/08/2020 16:00	8.3	0.0	1.6	9.1	2.0
04/08/2020 17:00	10.5	0.3	1.7	9.7	2.1
04/08/2020 18:00	14.5	1.5	2.0	11.5	2.5
04/08/2020 19:00	15.2	1.2	2.2	11.9	2.6
04/08/2020 20:00	14.8	1.2	2.1	11.7	2.6
04/08/2020 21:00	14.7	1.2	2.1	11.5	2.6
04/08/2020 22:00	14.7	1.2	2.1	11.5	2.6
04/08/2020 23:00	14.7	1.2	2.1	11.5	2.6
Average/Sum#:	245.9 #	9.0 #	42.8 #	236.0 #	52.0 #
Minimum:	6.5	0.0	1.6	8.9	2.0
Maximum:	15.2	1.5	2.2	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/09/2020 00:00	14.8	1.2	2.1	11.7	2.6
04/09/2020 01:00	14.8	1.2	2.1	11.7	2.6
04/09/2020 02:00	14.8	1.2	2.1	11.6	2.6
04/09/2020 03:00	14.7	1.3	2.1	11.5	2.6
04/09/2020 04:00	14.5	1.3	2.0	11.4	2.4
04/09/2020 05:00	14.5	1.6	2.0	11.3	2.4
04/09/2020 06:00	14.7	1.6	2.1	11.5	2.6
04/09/2020 07:00	14.7	1.3	2.1	11.5	2.6
04/09/2020 08:00	14.7	1.3	2.1	11.5	2.6
04/09/2020 09:00	14.7	1.3	2.1	11.5	2.6
04/09/2020 10:00	14.7	1.3	2.1	11.5	2.6
04/09/2020 11:00	14.3	1.3	2.0	11.2	2.4
04/09/2020 12:00	14.5	1.3	2.0	11.4	2.4
04/09/2020 13:00	14.5	1.2	2.0	11.4	2.4
04/09/2020 14:00	14.3	1.2	2.0	11.3	2.4
04/09/2020 15:00	14.5	1.2	2.0	11.3	2.4
04/09/2020 16:00	14.5	1.2	2.0	11.4	2.5
04/09/2020 17:00	14.6	1.2	2.0	11.5	2.5
04/09/2020 18:00	14.6	1.2	2.1	11.5	2.5
04/09/2020 19:00	14.8	1.2	2.1	11.6	2.6
04/09/2020 20:00	14.8	1.2	2.1	11.6	2.6
04/09/2020 21:00	14.6	1.2	2.1	11.5	2.5
04/09/2020 22:00	14.6	1.2	2.0	11.4	2.5
04/09/2020 23:00	14.8	1.2	2.1	11.7	2.6
Average/Sum#:	351.0 #	30.4 #	49.4 #	275.5 #	60.5 #
Minimum:	14.3	1.2	2.0	11.2	2.4
Maximum:	14.8	1.6	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/10/2020 00:00	14.8	1.3	2.1	11.5	2.6
04/10/2020 01:00	14.7	1.3	2.1	11.5	2.6
04/10/2020 02:00	14.7	1.3	2.1	11.5	2.6
04/10/2020 03:00	14.6	1.2	2.1	11.5	2.5
04/10/2020 04:00	14.4	1.3	2.0	11.3	2.4
04/10/2020 05:00	14.3	1.3	2.0	11.1	2.4
04/10/2020 06:00	14.6	1.3	2.1	11.5	2.5
04/10/2020 07:00	10.1	0.0	1.7	9.3	2.0
04/10/2020 08:00	6.2	0.0	1.6	8.5	1.8
04/10/2020 09:00	8.4	0.0	1.7	9.2	2.0
04/10/2020 10:00	8.2	0.0	1.6	9.1	2.0
04/10/2020 11:00	7.7	0.0	1.6	8.5	1.8
04/10/2020 12:00	8.2	0.0	1.7	9.1	2.0
04/10/2020 13:00	7.7	0.0	1.6	8.5	1.8
04/10/2020 14:00	7.9	0.0	1.6	8.7	1.9
04/10/2020 15:00	9.9	0.0	1.6	9.1	2.0
04/10/2020 16:00	9.9	0.0	1.6	9.1	2.0
04/10/2020 17:00	5.9	0.0	1.4	8.0	1.8
04/10/2020 18:00	14.2	1.8	2.0	11.1	2.4
04/10/2020 19:00	14.6	1.5	2.0	11.5	2.5
04/10/2020 20:00	14.4	1.5	2.0	11.3	2.4
04/10/2020 21:00	14.4	1.5	2.0	11.3	2.4
04/10/2020 22:00	14.3	1.5	2.0	11.3	2.4
04/10/2020 23:00	13.3	1.2	1.9	10.4	2.2
Average/Sum#:	277.4 #	18.0 #	44.1 #	243.9 #	53.0 #
Minimum:	5.9	0.0	1.4	8.0	1.8
Maximum:	14.8	1.8	2.1	11.5	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/11/2020 00:00	6.4	0.0	1.6	8.8	2.0
04/11/2020 01:00	8.3	0.0	1.7	9.1	2.0
04/11/2020 02:00	8.3	0.0	1.6	9.1	2.0
04/11/2020 03:00	8.2	0.0	1.6	9.1	2.0
04/11/2020 04:00	8.2	0.0	1.6	9.1	2.0
04/11/2020 05:00	8.2	0.0	1.6	9.1	2.0
04/11/2020 06:00	7.9	0.0	1.6	8.7	1.9
04/11/2020 07:00	8.3	0.0	1.6	9.2	2.0
04/11/2020 08:00	8.2	0.0	1.6	9.1	2.0
04/11/2020 09:00	8.2	0.0	1.6	9.1	2.0
04/11/2020 10:00	9.9	0.0	1.6	9.1	2.0
04/11/2020 11:00	9.9	0.0	1.7	9.1	2.0
04/11/2020 12:00	7.7	0.0	1.6	8.5	1.8
04/11/2020 13:00	9.9	0.0	1.6	9.1	2.0
04/11/2020 14:00	9.9	0.0	1.6	9.1	2.0
04/11/2020 15:00	11.6	0.0	1.6	9.1	2.0
04/11/2020 16:00	11.7	0.0	1.7	9.2	2.0
04/11/2020 17:00	11.6	0.0	1.7	9.1	2.0
04/11/2020 18:00	7.8	0.0	1.6	8.6	1.8
04/11/2020 19:00	19.9	1.8	2.0	10.9	2.4
04/11/2020 20:00	20.3	1.5	2.0	11.3	2.4
04/11/2020 21:00	20.6	1.6	2.0	11.3	2.4
04/11/2020 22:00	20.3	1.6	2.0	11.1	2.4
04/11/2020 23:00	19.5	1.2	2.0	10.8	2.4
Average/Sum#:	270.8 #	7.7 #	40.8 #	226.7 #	49.5 #
Minimum:	6.4	0.0	1.6	8.5	1.8
Maximum:	20.6	1.8	2.0	11.3	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/12/2020 00:00	8.2	0.0	1.6	9.1	2.0
04/12/2020 01:00	8.3	0.0	1.7	9.2	2.0
04/12/2020 02:00	8.3	0.0	1.6	9.1	2.0
04/12/2020 03:00	7.9	0.0	1.6	8.7	1.9
04/12/2020 04:00	8.2	0.0	1.6	9.1	2.0
04/12/2020 05:00	8.3	0.0	1.7	9.2	2.0
04/12/2020 06:00	8.1	0.0	1.6	8.9	2.0
04/12/2020 07:00	8.4	0.0	1.7	9.2	2.0
04/12/2020 08:00	10.1	0.0	1.7	9.3	2.0
04/12/2020 09:00	9.9	0.0	1.6	9.1	2.0
04/12/2020 10:00	8.2	0.0	1.6	9.0	2.0
04/12/2020 11:00	7.9	0.0	1.6	8.7	1.9
04/12/2020 12:00	8.2	0.0	1.6	9.1	2.0
04/12/2020 13:00	9.9	0.0	1.6	9.1	2.0
04/12/2020 14:00	10.0	0.0	1.7	9.2	2.0
04/12/2020 15:00	9.9	0.0	1.6	9.1	2.0
04/12/2020 16:00	11.6	0.0	1.7	9.1	2.0
04/12/2020 17:00	9.3	0.0	1.6	8.5	1.8
04/12/2020 18:00	6.4	0.0	1.6	8.8	2.0
04/12/2020 19:00	8.1	0.0	1.6	8.9	2.0
04/12/2020 20:00	8.1	0.0	1.6	8.9	2.0
04/12/2020 21:00	6.5	0.0	1.6	8.9	2.0
04/12/2020 22:00	6.4	0.0	1.6	8.9	2.0
04/12/2020 23:00	10.9	0.6	1.8	10.0	2.2
Average/Sum#:	207.1 #	0.6 #	39.2 #	217.1 #	47.8 #
Minimum:	6.4	0.0	1.6	8.5	1.8
Maximum:	11.6	0.6	1.8	10.0	2.2
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/13/2020 00:00	14.1	1.6	2.0	11.1	2.4
04/13/2020 01:00	6.7	0.0	1.7	9.2	2.0
04/13/2020 02:00	8.4	0.0	1.7	9.2	2.0
04/13/2020 03:00	8.2	0.0	1.6	9.1	2.0
04/13/2020 04:00	8.1	0.0	1.6	8.9	2.0
04/13/2020 05:00	8.2	0.0	1.6	9.1	2.0
04/13/2020 06:00	8.3	0.0	1.6	9.1	2.0
04/13/2020 07:00	8.2	0.0	1.6	9.1	2.0
04/13/2020 08:00	8.2	0.0	1.6	9.1	2.0
04/13/2020 09:00	8.4	0.0	1.7	9.3	2.0
04/13/2020 10:00	8.4	0.0	1.7	9.3	2.0
04/13/2020 11:00	8.4	0.0	1.7	9.3	2.0
04/13/2020 12:00	8.2	0.0	1.7	9.1	2.0
04/13/2020 13:00	7.9	0.0	1.6	8.7	1.9
04/13/2020 14:00	8.3	0.0	1.7	9.1	2.0
04/13/2020 15:00	10.1	0.0	1.7	9.3	2.0
04/13/2020 16:00	9.9	0.0	1.6	9.1	2.0
04/13/2020 17:00	7.6	0.0	1.6	8.4	1.8
04/13/2020 18:00	13.8	1.9	2.0	10.8	2.4
04/13/2020 19:00	14.5	1.2	2.0	11.4	2.5
04/13/2020 20:00	14.5	1.3	2.0	11.4	2.5
04/13/2020 21:00	14.5	1.6	2.0	11.4	2.5
04/13/2020 22:00	14.3	1.3	2.0	11.2	2.4
04/13/2020 23:00	13.4	0.9	1.9	10.5	2.3
Average/Sum#:	240.6 #	9.8 #	41.9 #	232.2 #	50.7 #
Minimum:	6.7	0.0	1.6	8.4	1.8
Maximum:	14.5	1.9	2.0	11.4	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/14/2020 00:00	8.6	0.0	1.7	9.4	2.0
04/14/2020 01:00	6.0	0.0	1.5	8.3	1.8
04/14/2020 02:00	8.1	0.0	1.6	8.9	2.0
04/14/2020 03:00	7.6	0.0	1.6	8.4	1.8
04/14/2020 04:00	8.1	0.0	1.6	8.9	2.0
04/14/2020 05:00	6.3	0.0	1.6	8.7	1.9
04/14/2020 06:00	6.6	0.0	1.6	9.1	2.0
04/14/2020 07:00	7.9	0.0	1.6	8.7	1.9
04/14/2020 08:00	8.1	0.0	1.6	8.9	2.0
04/14/2020 09:00	8.2	0.0	1.6	9.1	2.0
04/14/2020 10:00	8.4	0.0	1.7	9.2	2.0
04/14/2020 11:00	8.3	0.0	1.7	9.1	2.0
04/14/2020 12:00	7.7	0.0	1.6	8.5	1.8
04/14/2020 13:00	8.4	0.0	1.7	9.2	2.0
04/14/2020 14:00	8.2	0.0	1.6	9.1	2.0
04/14/2020 15:00	9.9	0.0	1.6	9.1	2.0
04/14/2020 16:00	9.5	0.0	1.6	8.7	1.9
04/14/2020 17:00	9.1	0.0	1.6	8.4	1.8
04/14/2020 18:00	14.0	1.5	2.0	11.1	2.4
04/14/2020 19:00	14.4	1.5	2.0	11.3	2.5
04/14/2020 20:00	14.4	1.5	2.0	11.3	2.5
04/14/2020 21:00	14.1	1.5	2.0	11.1	2.4
04/14/2020 22:00	14.3	1.5	2.0	11.3	2.5
04/14/2020 23:00	14.3	1.6	2.0	11.2	2.4
Average/Sum#:	230.5 #	9.1 #	41.1 #	227.0 #	49.6 #
Minimum:	6.0	0.0	1.5	8.3	1.8
Maximum:	14.4	1.6	2.0	11.3	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/15/2020 00:00	13.5	0.9	1.9	10.5	2.3
04/15/2020 01:00	6.3	0.0	1.6	8.7	1.9
04/15/2020 02:00	8.2	0.0	1.6	9.1	2.0
04/15/2020 03:00	6.3	0.0	1.6	8.6	1.8
04/15/2020 04:00	6.2	0.0	1.6	8.5	1.8
04/15/2020 05:00	8.3	0.0	1.7	9.1	2.0
04/15/2020 06:00	8.3	0.0	1.7	9.1	2.0
04/15/2020 07:00	8.2	0.0	1.6	9.1	2.0
04/15/2020 08:00	8.4	0.0	1.7	9.2	2.0
04/15/2020 09:00	8.4	0.0	1.7	9.2	2.0
04/15/2020 10:00	8.4	0.0	1.7	9.3	2.0
04/15/2020 11:00	8.4	0.0	1.7	9.3	2.0
04/15/2020 12:00	8.3	0.0	1.7	9.1	2.0
04/15/2020 13:00	10.1	0.0	1.7	9.3	2.0
04/15/2020 14:00	11.6	0.0	1.6	9.1	2.0
04/15/2020 15:00	9.7	0.0	1.6	8.9	2.0
04/15/2020 16:00	11.3	0.0	1.6	8.9	2.0
04/15/2020 17:00	7.6	0.0	1.5	8.3	1.8
04/15/2020 18:00	14.0	1.8	2.0	11.0	2.4
04/15/2020 19:00	14.7	1.5	2.0	11.6	2.5
04/15/2020 20:00	14.7	1.8	2.1	11.6	2.5
04/15/2020 21:00	14.4	1.8	2.0	11.3	2.4
04/15/2020 22:00	13.5	1.6	1.9	10.6	2.3
04/15/2020 23:00	13.3	0.9	1.9	10.4	2.2
Average/Sum#:	242.1 #	10.3 #	41.7 #	229.8 #	49.9 #
Minimum:	6.2	0.0	1.5	8.3	1.8
Maximum:	14.7	1.8	2.1	11.6	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/16/2020 00:00	6.0	0.0	1.5	8.2	1.8
04/16/2020 01:00	7.4	0.0	1.4	8.2	1.8
04/16/2020 02:00	7.6	0.0	1.5	8.3	1.8
04/16/2020 03:00	7.4	0.0	1.4	8.2	1.8
04/16/2020 04:00	7.9	0.0	1.6	8.6	1.8
04/16/2020 05:00	8.2	0.0	1.6	9.1	2.0
04/16/2020 06:00	7.7	0.0	1.6	8.4	1.8
04/16/2020 07:00	8.2	0.0	1.6	9.0	2.0
04/16/2020 08:00	8.4	0.0	1.7	9.2	2.0
04/16/2020 09:00	8.2	0.0	1.6	9.1	2.0
04/16/2020 10:00	8.4	0.0	1.7	9.2	2.0
04/16/2020 11:00	8.2	0.0	1.6	9.1	2.0
04/16/2020 12:00	10.1	0.0	1.7	9.2	2.0
04/16/2020 13:00	10.0	0.0	1.7	9.2	2.0
04/16/2020 14:00	9.5	0.0	1.6	8.7	1.9
04/16/2020 15:00	9.7	0.0	1.6	8.9	2.0
04/16/2020 16:00	9.7	0.0	1.6	8.9	2.0
04/16/2020 17:00	7.7	0.0	1.6	8.5	1.8
04/16/2020 18:00	13.9	1.8	2.0	10.9	2.4
04/16/2020 19:00	14.6	1.2	2.0	11.4	2.5
04/16/2020 20:00	14.8	0.9	2.1	11.6	2.6
04/16/2020 21:00	14.6	0.9	2.0	11.4	2.5
04/16/2020 22:00	15.8	1.5	1.9	10.8	2.4
04/16/2020 23:00	13.3	1.5	1.9	10.5	2.3
Average/Sum#:	237.3 #	7.8 #	40.5 #	224.6 #	49.2 #
Minimum:	6.0	0.0	1.4	8.2	1.8
Maximum:	15.8	1.8	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/17/2020 00:00	5.7	0.0	1.4	8.0	1.8
04/17/2020 01:00	5.4	0.0	1.3	7.4	1.6
04/17/2020 02:00	5.3	0.0	1.3	7.3	1.6
04/17/2020 03:00	5.3	0.0	1.3	7.3	1.6
04/17/2020 04:00	5.2	0.0	1.3	7.1	1.6
04/17/2020 05:00	8.2	0.0	1.6	9.1	2.0
04/17/2020 06:00	8.1	0.0	1.6	8.9	2.0
04/17/2020 07:00	7.9	0.0	1.6	8.7	1.9
04/17/2020 08:00	8.2	0.0	1.7	9.1	2.0
04/17/2020 09:00	8.2	0.0	1.6	9.1	2.0
04/17/2020 10:00	7.7	0.0	1.6	8.5	1.8
04/17/2020 11:00	8.1	0.0	1.6	9.0	2.0
04/17/2020 12:00	7.2	0.0	1.4	8.0	1.8
04/17/2020 13:00	7.9	0.0	1.6	8.9	1.9
04/17/2020 14:00	9.9	0.0	1.6	9.1	2.0
04/17/2020 15:00	10.1	0.0	1.7	9.2	2.0
04/17/2020 16:00	9.9	0.0	1.6	9.1	2.0
04/17/2020 17:00	7.6	0.0	1.6	8.4	1.8
04/17/2020 18:00	14.0	2.5	2.0	11.0	2.4
04/17/2020 19:00	14.4	1.8	2.0	11.3	2.4
04/17/2020 20:00	14.3	1.9	2.0	11.2	2.4
04/17/2020 21:00	14.2	1.9	2.0	11.2	2.4
04/17/2020 22:00	14.4	1.9	2.0	11.3	2.4
04/17/2020 23:00	11.3	13.5	0.6	3.3	0.8
Average/Sum#:	218.5 #	23.5 #	38.0 #	211.5 #	46.2 #
Minimum:	5.2	0.0	0.6	3.3	0.8
Maximum:	14.4	13.5	2.0	11.3	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/18/2020 00:00	0.0	0.0	0.0	0.0	0.0
04/18/2020 01:00	0.0	0.0	0.0	0.0	0.0
04/18/2020 02:00	0.0	0.0	0.0	0.0	0.0
04/18/2020 03:00	0.0	0.0	0.0	0.0	0.0
04/18/2020 04:00	0.0	0.0	0.0	0.0	0.0
04/18/2020 05:00	0.0	0.0	0.0	0.0	0.0
04/18/2020 06:00	0.0	0.0	0.0	0.0	0.0
04/18/2020 07:00	0.0	0.0	0.0	0.0	0.0
04/18/2020 08:00	0.0	0.0	0.0	0.0	0.0
04/18/2020 09:00	0.0	0.0	0.0	0.0	0.0
04/18/2020 10:00	0.0	0.0	0.0	0.0	0.0
04/18/2020 11:00	0.0	0.0	0.0	0.0	0.0
04/18/2020 12:00	0.0	0.0	0.0	0.0	0.0
04/18/2020 13:00	0.0	0.0	0.0	0.0	0.0
04/18/2020 14:00	0.0	0.0	0.0	0.0	0.0
04/18/2020 15:00	0.0	0.0	0.0	0.0	0.0
04/18/2020 16:00	0.0	0.0	0.0	0.0	0.0
04/18/2020 17:00	0.0	0.0	0.0	0.0	0.0
04/18/2020 18:00	0.0	0.0	0.0	0.0	0.0
04/18/2020 19:00	0.0	0.0	0.0	0.0	0.0
04/18/2020 20:00	0.0	0.0	0.0	0.0	0.0
04/18/2020 21:00	0.0	0.0	0.0	0.0	0.0
04/18/2020 22:00	0.0	0.0	0.0	0.0	0.0
04/18/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/19/2020 00:00	0.0	0.0	0.0	0.0	0.0
04/19/2020 01:00	0.0	0.0	0.0	0.0	0.0
04/19/2020 02:00	0.0	0.0	0.0	0.0	0.0
04/19/2020 03:00	0.0	0.0	0.0	0.0	0.0
04/19/2020 04:00	0.0	0.0	0.0	0.0	0.0
04/19/2020 05:00	0.0	0.0	0.0	0.0	0.0
04/19/2020 06:00	0.0	0.0	0.0	0.0	0.0
04/19/2020 07:00	0.0	0.0	0.0	0.0	0.0
04/19/2020 08:00	0.0	0.0	0.0	0.0	0.0
04/19/2020 09:00	0.0	0.0	0.0	0.0	0.0
04/19/2020 10:00	0.0	0.0	0.0	0.0	0.0
04/19/2020 11:00	0.0	0.0	0.0	0.0	0.0
04/19/2020 12:00	0.0	0.0	0.0	0.0	0.0
04/19/2020 13:00	0.0	0.0	0.0	0.0	0.0
04/19/2020 14:00	0.0	0.0	0.0	0.0	0.0
04/19/2020 15:00	0.0	0.0	0.0	0.0	0.0
04/19/2020 16:00	0.0	0.0	0.0	0.0	0.0
04/19/2020 17:00	67.4	77.0	0.1	1.0	0.2
04/19/2020 18:00	48.5	18.8	0.2	1.6	0.3
04/19/2020 19:00	47.2	34.4	0.3	2.6	0.5
04/19/2020 20:00	1.4	0.0	0.4	4.2	0.8
04/19/2020 21:00	2.9	0.0	0.4	4.3	0.9
04/19/2020 22:00	2.7	0.0	0.4	4.0	0.8
04/19/2020 23:00	2.7	0.0	0.4	4.0	0.8
Average/Sum#:	172.8 #	130.2 #	2.2 #	21.7 #	4.3 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	67.4	77.0	0.4	4.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/20/2020 00:00	2.7	0.0	0.4	4.0	0.8
04/20/2020 01:00	2.7	0.0	0.4	4.0	0.8
04/20/2020 02:00	97.0	94.1	0.8	5.9	1.3
04/20/2020 03:00	57.3	44.2	1.1	7.0	1.5
04/20/2020 04:00	8.2	0.0	1.6	9.1	2.0
04/20/2020 05:00	8.3	0.0	1.7	9.2	2.0
04/20/2020 06:00	8.3	0.0	1.6	9.1	2.0
04/20/2020 07:00	8.3	0.0	1.7	9.2	2.0
04/20/2020 08:00	8.1	0.0	1.6	8.9	2.0
04/20/2020 09:00	7.9	0.0	1.6	8.7	1.9
04/20/2020 10:00	7.9	0.0	1.6	8.6	1.8
04/20/2020 11:00	8.4	0.0	1.7	9.1	2.0
04/20/2020 12:00	8.2	0.0	1.6	9.1	2.0
04/20/2020 13:00	9.9	0.0	1.7	9.1	2.0
04/20/2020 14:00	6.0	0.0	1.5	8.3	1.8
04/20/2020 15:00	8.2	0.0	1.6	9.1	2.0
04/20/2020 16:00	6.4	0.0	1.6	8.9	2.0
04/20/2020 17:00	6.1	0.0	1.6	8.4	1.8
04/20/2020 18:00	13.9	1.9	2.0	10.9	2.4
04/20/2020 19:00	14.2	1.9	2.0	11.2	2.4
04/20/2020 20:00	14.2	1.6	2.0	11.2	2.4
04/20/2020 21:00	14.3	1.6	2.0	11.2	2.4
04/20/2020 22:00	13.5	1.2	1.9	10.7	2.3
04/20/2020 23:00	5.3	8.4	0.1	0.7	0.2
Average/Sum#:	345.3 #	154.9 #	35.4 #	201.6 #	43.8 #
Minimum:	2.7	0.0	0.1	0.7	0.2
Maximum:	97.0	94.1	2.0	11.2	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/21/2020 00:00	0.0	0.0	0.0	0.0	0.0
04/21/2020 01:00	0.0	0.0	0.0	0.0	0.0
04/21/2020 02:00	0.0	0.0	0.0	0.0	0.0
04/21/2020 03:00	0.0	0.0	0.0	0.0	0.0
04/21/2020 04:00	0.0	0.0	0.0	0.0	0.0
04/21/2020 05:00	0.0	0.0	0.0	0.0	0.0
04/21/2020 06:00	0.0	0.0	0.0	0.0	0.0
04/21/2020 07:00	0.0	0.0	0.0	0.0	0.0
04/21/2020 08:00	0.0	0.0	0.0	0.0	0.0
04/21/2020 09:00	0.0	0.0	0.0	0.0	0.0
04/21/2020 10:00	0.0	0.0	0.0	0.0	0.0
04/21/2020 11:00	0.0	0.0	0.0	0.0	0.0
04/21/2020 12:00	0.0	0.0	0.0	0.0	0.0
04/21/2020 13:00	0.0	0.0	0.0	0.0	0.0
04/21/2020 14:00	0.0	0.0	0.0	0.0	0.0
04/21/2020 15:00	0.0	0.0	0.0	0.0	0.0
04/21/2020 16:00	0.0	0.0	0.0	0.0	0.0
04/21/2020 17:00	0.0	0.0	0.0	0.0	0.0
04/21/2020 18:00	0.0	0.0	0.0	0.0	0.0
04/21/2020 19:00	0.0	0.0	0.0	0.0	0.0
04/21/2020 20:00	0.0	0.0	0.0	0.0	0.0
04/21/2020 21:00	0.0	0.0	0.0	0.0	0.0
04/21/2020 22:00	0.0	0.0	0.0	0.0	0.0
04/21/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/22/2020 00:00	0.0	0.0	0.0	0.0	0.0
04/22/2020 01:00	0.0	0.0	0.0	0.0	0.0
04/22/2020 02:00	0.0	0.0	0.0	0.0	0.0
04/22/2020 03:00	0.0	0.0	0.0	0.0	0.0
04/22/2020 04:00	62.6	66.4	0.1	1.0	0.2
04/22/2020 05:00	24.7	23.0	0.2	1.6	0.3
04/22/2020 06:00	23.4	31.8	0.3	2.5	0.5
04/22/2020 07:00	31.1	60.5	0.6	5.8	1.2
04/22/2020 08:00	77.1	44.6	0.9	6.9	1.5
04/22/2020 09:00	22.9	14.7	1.2	7.0	1.5
04/22/2020 10:00	3.8	0.0	1.3	7.0	1.6
04/22/2020 11:00	3.9	2.4	0.5	4.7	0.9
04/22/2020 12:00	3.0	0.0	0.5	4.6	0.9
04/22/2020 13:00	1.8	3.2	0.0	0.2	0.0
04/22/2020 14:00	0.0	0.0	0.0	0.0	0.0
04/22/2020 15:00	0.0	0.0	0.0	0.0	0.0
04/22/2020 16:00	0.0	0.0	0.0	0.0	0.0
04/22/2020 17:00	0.0	0.0	0.0	0.0	0.0
04/22/2020 18:00	2.3	2.7	0.0	0.2	0.0
04/22/2020 19:00	48.8	36.9	0.3	2.5	0.5
04/22/2020 20:00	1.5	0.0	0.4	4.4	0.9
04/22/2020 21:00	3.1	0.0	0.5	4.6	0.9
04/22/2020 22:00	2.8	0.0	0.4	4.2	0.8
04/22/2020 23:00	1.3	0.0	0.4	4.0	0.8
Average/Sum#:	314.1 #	286.2 #	7.6 #	61.2 #	12.5 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	77.1	66.4	1.3	7.0	1.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/23/2020 00:00	1.3	0.0	0.4	4.0	0.8
04/23/2020 01:00	1.3	0.0	0.4	4.0	0.8
04/23/2020 02:00	1.4	2.7	0.0	0.2	0.0
04/23/2020 03:00	0.0	0.0	0.0	0.0	0.0
04/23/2020 04:00	0.0	0.0	0.0	0.0	0.0
04/23/2020 05:00	0.0	0.0	0.0	0.0	0.0
04/23/2020 06:00	0.0	0.0	0.0	0.0	0.0
04/23/2020 07:00	0.0	0.0	0.0	0.0	0.0
04/23/2020 08:00	0.0	0.0	0.0	0.0	0.0
04/23/2020 09:00	0.0	0.0	0.0	0.0	0.0
04/23/2020 10:00	0.0	0.0	0.0	0.0	0.0
04/23/2020 11:00	0.0	0.0	0.0	0.0	0.0
04/23/2020 12:00	0.0	0.0	0.0	0.0	0.0
04/23/2020 13:00	0.0	0.0	0.0	0.0	0.0
04/23/2020 14:00	0.0	0.0	0.0	0.0	0.0
04/23/2020 15:00	0.0	0.0	0.0	0.0	0.0
04/23/2020 16:00	0.0	0.0	0.0	0.0	0.0
04/23/2020 17:00	0.0	0.0	0.0	0.0	0.0
04/23/2020 18:00	0.0	0.0	0.0	0.0	0.0
04/23/2020 19:00	0.0	0.0	0.0	0.0	0.0
04/23/2020 20:00	0.0	0.0	0.0	0.0	0.0
04/23/2020 21:00	0.0	0.0	0.0	0.0	0.0
04/23/2020 22:00	0.0	0.0	0.0	0.0	0.0
04/23/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	4.0 #	2.7 #	0.8 #	8.2 #	1.6 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	1.4	2.7	0.4	4.0	0.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/24/2020 00:00	0.0	0.0	0.0	0.0	0.0
04/24/2020 01:00	0.0	0.0	0.0	0.0	0.0
04/24/2020 02:00	0.0	0.0	0.0	0.0	0.0
04/24/2020 03:00	0.0	0.0	0.0	0.0	0.0
04/24/2020 04:00	0.0	0.0	0.0	0.0	0.0
04/24/2020 05:00	0.0	0.0	0.0	0.0	0.0
04/24/2020 06:00	0.0	0.0	0.0	0.0	0.0
04/24/2020 07:00	0.0	0.0	0.0	0.0	0.0
04/24/2020 08:00	0.0	0.0	0.0	0.0	0.0
04/24/2020 09:00	67.2	63.1	0.1	1.0	0.2
04/24/2020 10:00	37.6	17.4	0.2	1.6	0.3
04/24/2020 11:00	56.6	35.0	0.3	2.7	0.5
04/24/2020 12:00	1.4	0.0	0.4	4.1	0.8
04/24/2020 13:00	1.4	0.0	0.4	4.1	0.8
04/24/2020 14:00	3.0	9.7	0.7	5.4	1.1
04/24/2020 15:00	3.0	10.3	0.9	6.3	1.3
04/24/2020 16:00	3.1	0.0	1.6	8.4	1.8
04/24/2020 17:00	3.1	0.0	1.6	8.5	1.8
04/24/2020 18:00	7.7	0.0	1.8	10.2	2.3
04/24/2020 19:00	14.7	0.9	2.0	11.5	2.5
04/24/2020 20:00	14.5	0.9	2.0	11.4	2.5
04/24/2020 21:00	13.4	0.9	1.9	10.6	2.3
04/24/2020 22:00	6.6	8.2	0.3	2.2	0.5
04/24/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	213.4 #	126.4 #	14.2 #	88.0 #	18.7 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	67.2	63.1	2.0	11.5	2.5
%SI	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/25/2020 00:00	0.0	0.0	0.0	0.0	0.0
04/25/2020 01:00	0.0	0.0	0.0	0.0	0.0
04/25/2020 02:00	0.0	0.0	0.0	0.0	0.0
04/25/2020 03:00	0.0	0.0	0.0	0.0	0.0
04/25/2020 04:00	0.0	0.0	0.0	0.0	0.0
04/25/2020 05:00	0.0	0.0	0.0	0.0	0.0
04/25/2020 06:00	0.0	0.0	0.0	0.0	0.0
04/25/2020 07:00	0.0	0.0	0.0	0.0	0.0
04/25/2020 08:00	0.0	0.0	0.0	0.0	0.0
04/25/2020 09:00	0.0	0.0	0.0	0.0	0.0
04/25/2020 10:00	0.0	0.0	0.0	0.0	0.0
04/25/2020 11:00	0.0	0.0	0.0	0.0	0.0
04/25/2020 12:00	0.0	0.0	0.0	0.0	0.0
04/25/2020 13:00	0.0	0.0	0.0	0.0	0.0
04/25/2020 14:00	0.0	0.0	0.0	0.0	0.0
04/25/2020 15:00	0.0	0.0	0.0	0.0	0.0
04/25/2020 16:00	0.0	0.0	0.0	0.0	0.0
04/25/2020 17:00	0.0	0.0	0.0	0.0	0.0
04/25/2020 18:00	0.0	0.0	0.0	0.0	0.0
04/25/2020 19:00	0.0	0.0	0.0	0.0	0.0
04/25/2020 20:00	0.0	0.0	0.0	0.0	0.0
04/25/2020 21:00	0.0	0.0	0.0	0.0	0.0
04/25/2020 22:00	0.0	0.0	0.0	0.0	0.0
04/25/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/26/2020 00:00	0.0	0.0	0.0	0.0	0.0
04/26/2020 01:00	0.0	0.0	0.0	0.0	0.0
04/26/2020 02:00	0.0	0.0	0.0	0.0	0.0
04/26/2020 03:00	0.0	0.0	0.0	0.0	0.0
04/26/2020 04:00	0.0	0.0	0.0	0.0	0.0
04/26/2020 05:00	0.0	0.0	0.0	0.0	0.0
04/26/2020 06:00	0.0	0.0	0.0	0.0	0.0
04/26/2020 07:00	0.0	0.0	0.0	0.0	0.0
04/26/2020 08:00	0.0	0.0	0.0	0.0	0.0
04/26/2020 09:00	0.0	0.0	0.0	0.0	0.0
04/26/2020 10:00	0.0	0.0	0.0	0.0	0.0
04/26/2020 11:00	0.0	0.0	0.0	0.0	0.0
04/26/2020 12:00	0.0	0.0	0.0	0.0	0.0
04/26/2020 13:00	0.0	0.0	0.0	0.0	0.0
04/26/2020 14:00	0.0	0.0	0.0	0.0	0.0
04/26/2020 15:00	0.0	0.0	0.0	0.0	0.0
04/26/2020 16:00	0.0	0.0	0.0	0.0	0.0
04/26/2020 17:00	0.0	0.0	0.0	0.0	0.0
04/26/2020 18:00	0.0	0.0	0.0	0.0	0.0
04/26/2020 19:00	0.0	0.0	0.0	0.0	0.0
04/26/2020 20:00	0.0	0.0	0.0	0.0	0.0
04/26/2020 21:00	0.0	0.0	0.0	0.0	0.0
04/26/2020 22:00	0.0	0.0	0.0	0.0	0.0
04/26/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/27/2020 00:00	0.0	0.0	0.0	0.0	0.0
04/27/2020 01:00	0.0	0.0	0.0	0.0	0.0
04/27/2020 02:00	0.0	0.0	0.0	0.0	0.0
04/27/2020 03:00	0.0	0.0	0.0	0.0	0.0
04/27/2020 04:00	0.0	0.0	0.0	0.0	0.0
04/27/2020 05:00	0.0	0.0	0.0	0.0	0.0
04/27/2020 06:00	0.0	0.0	0.0	0.0	0.0
04/27/2020 07:00	0.0	0.0	0.0	0.0	0.0
04/27/2020 08:00	0.0	0.0	0.0	0.0	0.0
04/27/2020 09:00	0.0	0.0	0.0	0.0	0.0
04/27/2020 10:00	0.0	0.0	0.0	0.0	0.0
04/27/2020 11:00	0.0	0.0	0.0	0.0	0.0
04/27/2020 12:00	0.0	0.0	0.0	0.0	0.0
04/27/2020 13:00	66.0	64.8	0.1	0.9	0.2
04/27/2020 14:00	71.2	33.2	0.2	1.9	0.4
04/27/2020 15:00	47.2	33.1	0.3	3.0	0.6
04/27/2020 16:00	1.4	0.0	0.4	4.3	0.9
04/27/2020 17:00	7.8	0.3	0.6	5.8	1.2
04/27/2020 18:00	7.9	0.3	0.6	5.9	1.2
04/27/2020 19:00	7.9	0.3	0.6	5.9	1.2
04/27/2020 20:00	7.7	0.3	0.6	5.8	1.2
04/27/2020 21:00	2.8	0.0	0.4	4.2	0.8
04/27/2020 22:00	2.8	0.0	0.4	4.3	0.9
04/27/2020 23:00	2.9	0.0	0.4	4.4	0.9
Average/Sum#:	225.6 #	132.3 #	4.6 #	46.4 #	9.5 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	71.2	64.8	0.6	5.9	1.2
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/28/2020 00:00	2.8	0.0	0.4	4.2	0.8
04/28/2020 01:00	2.8	0.0	0.4	4.2	0.8
04/28/2020 02:00	2.8	0.0	0.4	4.2	0.8
04/28/2020 03:00	2.8	0.0	0.4	4.1	0.8
04/28/2020 04:00	2.8	0.0	0.4	4.1	0.8
04/28/2020 05:00	2.8	0.0	0.4	4.1	0.8
04/28/2020 06:00	2.8	0.0	0.4	4.1	0.8
04/28/2020 07:00	2.8	0.0	0.4	4.2	0.8
04/28/2020 08:00	2.8	0.0	0.4	4.2	0.8
04/28/2020 09:00	1.4	0.0	0.4	4.2	0.8
04/28/2020 10:00	1.4	0.0	0.4	4.1	0.8
04/28/2020 11:00	1.4	0.0	0.4	4.1	0.8
04/28/2020 12:00	1.4	0.0	0.4	4.1	0.8
04/28/2020 13:00	68.8	68.1	0.7	5.2	1.1
04/28/2020 14:00	84.9	41.6	1.0	6.3	1.3
04/28/2020 15:00	6.1	0.0	1.6	8.4	1.8
04/28/2020 16:00	5.9	0.0	1.4	8.2	1.8
04/28/2020 17:00	14.3	1.2	2.0	11.3	2.5
04/28/2020 18:00	14.7	0.9	2.1	11.6	2.5
04/28/2020 19:00	14.8	0.9	2.1	11.6	2.6
04/28/2020 20:00	14.8	0.9	2.1	11.6	2.6
04/28/2020 21:00	17.7	17.2	1.6	8.9	2.0
04/28/2020 22:00	0.0	0.0	0.0	0.0	0.0
04/28/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	272.8 #	130.8 #	19.8 #	137.0 #	28.6 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	84.9	68.1	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/29/2020 00:00	0.0	0.0	0.0	0.0	0.0
04/29/2020 01:00	0.0	0.0	0.0	0.0	0.0
04/29/2020 02:00	0.0	0.0	0.0	0.0	0.0
04/29/2020 03:00	0.0	0.0	0.0	0.0	0.0
04/29/2020 04:00	0.0	0.0	0.0	0.0	0.0
04/29/2020 05:00	0.0	0.0	0.0	0.0	0.0
04/29/2020 06:00	0.0	0.0	0.0	0.0	0.0
04/29/2020 07:00	0.0	0.0	0.0	0.0	0.0
04/29/2020 08:00	0.0	0.0	0.0	0.0	0.0
04/29/2020 09:00	0.0	0.0	0.0	0.0	0.0
04/29/2020 10:00	0.0	0.0	0.0	0.0	0.0
04/29/2020 11:00	0.0	0.0	0.0	0.0	0.0
04/29/2020 12:00	0.0	0.0	0.0	0.0	0.0
04/29/2020 13:00	51.4	43.2	0.1	1.0	0.2
04/29/2020 14:00	47.2	51.4	0.2	2.2	0.4
04/29/2020 15:00	14.2	15.7	0.4	4.3	0.9
04/29/2020 16:00	2.8	0.0	0.4	4.1	0.8
04/29/2020 17:00	7.8	0.9	0.6	5.8	1.2
04/29/2020 18:00	7.9	0.9	0.6	5.9	1.2
04/29/2020 19:00	7.9	0.9	0.6	5.9	1.2
04/29/2020 20:00	7.7	0.9	0.6	5.8	1.2
04/29/2020 21:00	2.7	0.0	0.4	4.1	0.8
04/29/2020 22:00	2.7	0.0	0.4	4.0	0.8
04/29/2020 23:00	1.3	0.0	0.4	4.0	0.8
Average/Sum#:	153.6 #	113.9 #	4.7 #	47.1 #	9.5 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	51.4	51.4	0.6	5.9	1.2
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
04/30/2020 00:00	1.3	0.0	0.4	4.0	0.8
04/30/2020 01:00	2.7	0.0	0.4	4.0	0.8
04/30/2020 02:00	2.7	0.0	0.4	4.0	0.8
04/30/2020 03:00	1.3	0.0	0.4	4.0	0.8
04/30/2020 04:00	1.3	0.0	0.4	4.0	0.8
04/30/2020 05:00	1.3	0.0	0.4	4.0	0.8
04/30/2020 06:00	2.7	0.0	0.4	4.0	0.8
04/30/2020 07:00	1.3	3.9	0.0	0.2	0.0
04/30/2020 08:00	0.0	0.0	0.0	0.0	0.0
04/30/2020 09:00	0.0	0.0	0.0	0.0	0.0
04/30/2020 10:00	0.0	0.0	0.0	0.0	0.0
04/30/2020 11:00	0.0	0.0	0.0	0.0	0.0
04/30/2020 12:00	0.0	0.0	0.0	0.0	0.0
04/30/2020 13:00	0.0	0.0	0.0	0.0	0.0
04/30/2020 14:00	0.0	0.0	0.0	0.0	0.0
04/30/2020 15:00	0.0	0.0	0.0	0.0	0.0
04/30/2020 16:00	0.0	0.0	0.0	0.0	0.0
04/30/2020 17:00	0.0	0.0	0.0	0.0	0.0
04/30/2020 18:00	0.0	0.0	0.0	0.0	0.0
04/30/2020 19:00	0.0	0.0	0.0	0.0	0.0
04/30/2020 20:00	0.0	0.0	0.0	0.0	0.0
04/30/2020 21:00	0.0	0.0	0.0	0.0	0.0
04/30/2020 22:00	0.0	0.0	0.0	0.0	0.0
04/30/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	14.6 #	3.9 #	2.8 #	28.2 #	5.6 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	2.7	3.9	0.4	4.0	0.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/01/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/01/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/01/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/01/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/01/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/01/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/01/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/01/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/01/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/01/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/01/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/01/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/01/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/01/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/01/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/01/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/01/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/01/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/01/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/01/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/01/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/01/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/01/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/01/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/02/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/02/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/02/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/02/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/02/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/02/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/02/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/02/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/02/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/02/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/02/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/02/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/02/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/02/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/02/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/02/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/02/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/02/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/02/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/02/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/02/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/02/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/02/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/02/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/03/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/03/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/03/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/03/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/03/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/03/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/03/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/03/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/03/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/03/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/03/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/03/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/03/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/03/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/03/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/03/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/03/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/03/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/03/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/03/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/03/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/03/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/03/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/03/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/04/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/04/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/04/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/04/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/04/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/04/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/04/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/04/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/04/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/04/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/04/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/04/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/04/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/04/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/04/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/04/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/04/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/04/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/04/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/04/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/04/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/04/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/04/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/04/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/05/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/05/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/05/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/05/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/05/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/05/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/05/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/05/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/05/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/05/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/05/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/05/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/05/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/05/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/05/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/05/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/05/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/05/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/05/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/05/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/05/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/05/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/05/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/05/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/06/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/06/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/06/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/06/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/06/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/06/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/06/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/06/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/06/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/06/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/06/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/06/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/06/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/06/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/06/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/06/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/06/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/06/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/06/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/06/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/06/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/06/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/06/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/06/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/07/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/07/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/07/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/07/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/07/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/07/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/07/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/07/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/07/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/07/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/07/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/07/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/07/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/07/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/07/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/07/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/07/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/07/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/07/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/07/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/07/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/07/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/07/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/07/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/08/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/08/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/08/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/08/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/08/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/08/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/08/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/08/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/08/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/08/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/08/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/08/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/08/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/08/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/08/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/08/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/08/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/08/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/08/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/08/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/08/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/08/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/08/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/08/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/09/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/09/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/09/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/09/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/09/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/09/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/09/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/09/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/09/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/09/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/09/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/09/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/09/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/09/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/09/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/09/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/09/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/09/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/09/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/09/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/09/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/09/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/09/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/09/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/10/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/10/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/10/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/10/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/10/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/10/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/10/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/10/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/10/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/10/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/10/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/10/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/10/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/10/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/10/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/10/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/10/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/10/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/10/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/10/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/10/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/10/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/10/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/10/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/11/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/11/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/11/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/11/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/11/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/11/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/11/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/11/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/11/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/11/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/11/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/11/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/11/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/11/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/11/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/11/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/11/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/11/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/11/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/11/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/11/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/11/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/11/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/11/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/12/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/12/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/12/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/12/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/12/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/12/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/12/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/12/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/12/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/12/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/12/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/12/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/12/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/12/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/12/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/12/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/12/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/12/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/12/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/12/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/12/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/12/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/12/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/12/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/13/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/13/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/13/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/13/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/13/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/13/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/13/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/13/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/13/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/13/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/13/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/13/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/13/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/13/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/13/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/13/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/13/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/13/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/13/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/13/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/13/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/13/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/13/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/13/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/14/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/14/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/14/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/14/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/14/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/14/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/14/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/14/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/14/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/14/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/14/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/14/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/14/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/14/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/14/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/14/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/14/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/14/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/14/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/14/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/14/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/14/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/14/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/14/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/15/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/15/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/15/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/15/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/15/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/15/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/15/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/15/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/15/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/15/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/15/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/15/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/15/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/15/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/15/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/15/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/15/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/15/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/15/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/15/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/15/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/15/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/15/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/15/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/16/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/16/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/16/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/16/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/16/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/16/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/16/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/16/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/16/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/16/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/16/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/16/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/16/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/16/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/16/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/16/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/16/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/16/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/16/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/16/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/16/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/16/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/16/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/16/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/17/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/17/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/17/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/17/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/17/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/17/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/17/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/17/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/17/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/17/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/17/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/17/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/17/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/17/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/17/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/17/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/17/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/17/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/17/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/17/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/17/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/17/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/17/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/17/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/18/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/18/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/18/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/18/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/18/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/18/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/18/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/18/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/18/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/18/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/18/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/18/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/18/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/18/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/18/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/18/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/18/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/18/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/18/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/18/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/18/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/18/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/18/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/18/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/19/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/19/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/19/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/19/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/19/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/19/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/19/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/19/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/19/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/19/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/19/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/19/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/19/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/19/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/19/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/19/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/19/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/19/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/19/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/19/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/19/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/19/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/19/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/19/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/20/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/20/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/20/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/20/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/20/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/20/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/20/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/20/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/20/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/20/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/20/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/20/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/20/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/20/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/20/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/20/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/20/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/20/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/20/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/20/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/20/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/20/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/20/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/20/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/21/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/21/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/21/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/21/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/21/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/21/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/21/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/21/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/21/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/21/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/21/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/21/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/21/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/21/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/21/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/21/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/21/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/21/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/21/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/21/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/21/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/21/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/21/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/21/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/22/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/22/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/22/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/22/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/22/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/22/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/22/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/22/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/22/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/22/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/22/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/22/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/22/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/22/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/22/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/22/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/22/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/22/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/22/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/22/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/22/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/22/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/22/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/22/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/23/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/23/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/23/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/23/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/23/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/23/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/23/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/23/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/23/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/23/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/23/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/23/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/23/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/23/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/23/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/23/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/23/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/23/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/23/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/23/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/23/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/23/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/23/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/23/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/24/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/24/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/24/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/24/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/24/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/24/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/24/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/24/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/24/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/24/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/24/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/24/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/24/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/24/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/24/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/24/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/24/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/24/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/24/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/24/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/24/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/24/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/24/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/24/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/25/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/25/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/25/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/25/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/25/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/25/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/25/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/25/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/25/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/25/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/25/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/25/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/25/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/25/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/25/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/25/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/25/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/25/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/25/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/25/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/25/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/25/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/25/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/25/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/26/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/26/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/26/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/26/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/26/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/26/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/26/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/26/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/26/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/26/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/26/2020 10:00	177.8	777.1	0.7	2.4	0.6
05/26/2020 11:00	11.4	135.5	0.2	0.6	0.1
05/26/2020 12:00	320.0	110.7	1.4	5.1	1.2
05/26/2020 13:00	87.1	91.1	1.4	5.1	1.2
05/26/2020 14:00	89.8	147.3	1.5	5.2	1.3
05/26/2020 15:00	26.2	54.2	0.5	1.7	0.4
05/26/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/26/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/26/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/26/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/26/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/26/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/26/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/26/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	712.3 #	1,315.9 #	5.7 #	20.1 #	4.8 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	320.0	777.1	1.5	5.2	1.3
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/27/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/27/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/27/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/27/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/27/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/27/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/27/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/27/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/27/2020 08:00	0.0	10.5	0.0	0.4	0.1
05/27/2020 09:00	0.0	6.1	0.2	1.6	0.3
05/27/2020 10:00	0.0	3.1	0.2	1.6	0.3
05/27/2020 11:00	0.0	14.5	0.3	2.6	0.5
05/27/2020 12:00	0.0	0.0	0.4	4.2	0.8
05/27/2020 13:00	2.9	0.0	0.4	4.4	0.9
05/27/2020 14:00	2.8	5.3	0.1	0.6	0.1
05/27/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/27/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/27/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/27/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/27/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/27/2020 20:00	0.0	0.0	0.0	0.0	0.0
05/27/2020 21:00	0.0	0.0	0.0	0.0	0.0
05/27/2020 22:00	0.0	0.0	0.0	0.0	0.0
05/27/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	5.7 #	5.3 #	1.6 #	15.4 #	3.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	2.9	5.3	0.4	4.4	0.9
%SI	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/28/2020 00:00	0.0	0.0	0.0	0.0	0.0
05/28/2020 01:00	0.0	0.0	0.0	0.0	0.0
05/28/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/28/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/28/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/28/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/28/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/28/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/28/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/28/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/28/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/28/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/28/2020 12:00	0.0	47.9	0.5	1.9	0.5
05/28/2020 13:00	0.0	30.9	1.4	5.1	1.2
05/28/2020 14:00	0.0	40.6	1.5	5.2	1.3
05/28/2020 15:00	0.0	19.6	1.5	5.2	1.2
05/28/2020 16:00	0.0	0.0	1.5	5.2	1.3
05/28/2020 17:00	6.1	0.0	1.4	5.1	1.2
05/28/2020 18:00	8.5	31.4	1.4	5.2	1.2
05/28/2020 19:00	76.5	59.1	1.6	6.9	1.6
05/28/2020 20:00	17.5	10.5	1.8	9.3	2.0
05/28/2020 21:00	13.1	0.0	1.9	10.1	2.2
05/28/2020 22:00	11.4	0.0	1.9	10.0	2.2
05/28/2020 23:00	9.4	0.0	1.9	9.9	2.2
Average/Sum#:	142.5 #	101.0 #	18.3 #	79.1 #	18.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	76.5	59.1	1.9	10.1	2.2
%SI	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/29/2020 00:00	11.3	0.0	1.9	10.2	2.2
05/29/2020 01:00	12.1	23.2	1.3	6.6	1.5
05/29/2020 02:00	0.0	0.0	0.0	0.0	0.0
05/29/2020 03:00	0.0	0.0	0.0	0.0	0.0
05/29/2020 04:00	0.0	0.0	0.0	0.0	0.0
05/29/2020 05:00	0.0	0.0	0.0	0.0	0.0
05/29/2020 06:00	0.0	0.0	0.0	0.0	0.0
05/29/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/29/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/29/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/29/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/29/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/29/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/29/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/29/2020 14:00	0.0	0.0	0.0	0.0	0.0
05/29/2020 15:00	0.0	0.0	0.0	0.0	0.0
05/29/2020 16:00	0.0	0.0	0.0	0.0	0.0
05/29/2020 17:00	0.0	0.0	0.0	0.0	0.0
05/29/2020 18:00	0.0	0.0	0.0	0.0	0.0
05/29/2020 19:00	0.0	0.0	0.0	0.0	0.0
05/29/2020 20:00	42.2	39.4	0.1	0.7	0.1
05/29/2020 21:00	63.4	57.7	0.2	2.1	0.4
05/29/2020 22:00	45.7	48.4	0.3	3.0	0.6
05/29/2020 23:00	1.4	0.0	0.4	4.1	0.8
Average/Sum#:	176.1 #	168.7 #	4.2 #	26.7 #	5.6 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	63.4	57.7	1.9	10.2	2.2
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/30/2020 00:00	2.7	0.0	0.4	4.1	0.8
05/30/2020 01:00	2.7	0.0	0.4	4.1	0.8
05/30/2020 02:00	2.7	0.0	0.4	4.1	0.8
05/30/2020 03:00	2.7	0.0	0.4	4.1	0.8
05/30/2020 04:00	2.8	0.0	0.4	4.1	0.8
05/30/2020 05:00	2.8	0.0	0.4	4.1	0.8
05/30/2020 06:00	2.8	0.0	0.4	4.2	0.8
05/30/2020 07:00	1.4	0.0	0.4	4.1	0.8
05/30/2020 08:00	1.0	2.8	0.0	0.2	0.0
05/30/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/30/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/30/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/30/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/30/2020 13:00	0.0	0.3	0.0	0.0	0.0
05/30/2020 14:00	64.8	54.2	0.2	2.0	0.4
05/30/2020 15:00	2.8	0.0	0.4	4.2	0.8
05/30/2020 16:00	0.0	0.0	0.4	4.1	0.8
05/30/2020 17:00	0.0	0.0	0.4	4.2	0.8
05/30/2020 18:00	0.0	0.0	0.6	5.8	1.2
05/30/2020 19:00	0.0	0.0	0.6	5.9	1.2
05/30/2020 20:00	0.0	0.0	0.6	5.8	1.2
05/30/2020 21:00	0.0	0.0	0.4	4.2	0.8
05/30/2020 22:00	0.0	0.0	0.4	4.1	0.8
05/30/2020 23:00	1.4	0.5	0.4	4.1	0.8
Average/Sum#:	90.6 #	57.8 #	7.6 #	77.5 #	15.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	64.8	54.2	0.6	5.9	1.2
%SI	25.00	8.33	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
05/31/2020 00:00	1.4	0.5	0.4	4.1	0.8
05/31/2020 01:00	1.4	0.5	0.4	4.1	0.8
05/31/2020 02:00	1.4	0.5	0.4	4.1	0.8
05/31/2020 03:00	1.4	0.5	0.4	4.1	0.8
05/31/2020 04:00	1.4	0.5	0.4	4.1	0.8
05/31/2020 05:00	1.4	0.5	0.4	4.1	0.8
05/31/2020 06:00	0.0	0.0	0.0	0.2	0.0
05/31/2020 07:00	0.0	0.0	0.0	0.0	0.0
05/31/2020 08:00	0.0	0.0	0.0	0.0	0.0
05/31/2020 09:00	0.0	0.0	0.0	0.0	0.0
05/31/2020 10:00	0.0	0.0	0.0	0.0	0.0
05/31/2020 11:00	0.0	0.0	0.0	0.0	0.0
05/31/2020 12:00	0.0	0.0	0.0	0.0	0.0
05/31/2020 13:00	0.0	0.0	0.0	0.0	0.0
05/31/2020 14:00	52.4	19.7	0.1	0.9	0.2
05/31/2020 15:00	37.4	31.5	0.3	3.0	0.6
05/31/2020 16:00	1.4	0.3	0.4	4.2	0.8
05/31/2020 17:00	1.4	0.3	0.4	4.2	0.8
05/31/2020 18:00	3.5	1.2	0.5	5.3	1.1
05/31/2020 19:00	3.9	2.2	0.6	5.9	1.2
05/31/2020 20:00	7.7	2.2	0.6	5.8	1.2
05/31/2020 21:00	2.8	0.5	0.4	4.2	0.8
05/31/2020 22:00	1.4	0.5	0.4	4.1	0.8
05/31/2020 23:00	2.7	0.5	0.4	4.1	0.8
Average/Sum#:	123.0 #	61.9 #	6.5 #	66.5 #	13.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	52.4	31.5	0.6	5.9	1.2
%SI	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/01/2020 00:00	2.7	0.8	0.4	4.1	0.8
06/01/2020 01:00	2.7	0.5	0.4	4.1	0.8
06/01/2020 02:00	2.7	0.8	0.4	4.1	0.8
06/01/2020 03:00	2.7	0.5	0.4	4.1	0.8
06/01/2020 04:00	2.7	0.5	0.4	4.1	0.8
06/01/2020 05:00	2.7	0.5	0.4	4.0	0.8
06/01/2020 06:00	2.7	0.8	0.4	4.0	0.8
06/01/2020 07:00	2.7	0.5	0.4	4.0	0.8
06/01/2020 08:00	2.7	0.5	0.4	4.0	0.8
06/01/2020 09:00	2.7	0.5	0.4	4.1	0.8
06/01/2020 10:00	2.7	0.5	0.4	4.1	0.8
06/01/2020 11:00	2.7	0.5	0.4	4.1	0.8
06/01/2020 12:00	60.5	332.2	0.7	5.2	1.0
06/01/2020 13:00	325.9	203.8	1.5	8.6	1.9
06/01/2020 14:00	44.2	60.3	1.4	8.3	1.8
06/01/2020 15:00	9.1	0.9	1.9	10.1	2.2
06/01/2020 16:00	9.2	0.9	1.9	9.8	2.1
06/01/2020 17:00	11.2	0.6	2.0	10.1	2.3
06/01/2020 18:00	9.4	0.6	2.0	9.8	2.2
06/01/2020 19:00	9.2	0.6	1.9	9.7	2.1
06/01/2020 20:00	9.2	0.6	2.0	9.7	2.1
06/01/2020 21:00	9.1	0.6	1.9	9.5	2.1
06/01/2020 22:00	6.9	0.5	1.9	9.2	2.1
06/01/2020 23:00	11.2	0.6	1.9	10.2	2.2
Average/Sum#:	547.5 #	609.1 #	25.8 #	159.0 #	33.7 #
Minimum:	2.7	0.5	0.4	4.0	0.8
Maximum:	325.9	332.2	2.0	10.2	2.3
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/02/2020 00:00	9.3	0.6	1.9	9.7	2.2
06/02/2020 01:00	9.2	0.6	2.0	9.7	2.1
06/02/2020 02:00	9.1	0.5	1.8	9.5	2.1
06/02/2020 03:00	9.3	0.6	1.9	9.8	2.1
06/02/2020 04:00	11.3	0.6	1.9	10.3	2.2
06/02/2020 05:00	11.2	0.6	1.9	10.1	2.2
06/02/2020 06:00	9.2	0.6	1.8	9.6	2.1
06/02/2020 07:00	9.0	0.5	1.8	9.3	2.0
06/02/2020 08:00	6.8	0.5	1.8	9.2	2.0
06/02/2020 09:00	9.3	0.6	2.0	9.7	2.2
06/02/2020 10:00	9.2	0.6	1.8	9.6	2.1
06/02/2020 11:00	6.7	0.2	1.8	9.0	2.0
06/02/2020 12:00	11.2	0.6	1.9	10.2	2.2
06/02/2020 13:00	15.5	2.7	2.3	12.3	2.7
06/02/2020 14:00	15.6	1.6	2.3	12.3	2.7
06/02/2020 15:00	15.6	1.0	2.4	12.4	2.7
06/02/2020 16:00	15.8	1.3	2.4	12.5	2.7
06/02/2020 17:00	15.5	1.9	2.3	12.2	2.7
06/02/2020 18:00	15.7	1.6	2.3	12.3	2.7
06/02/2020 19:00	15.6	1.9	2.3	12.3	2.7
06/02/2020 20:00	15.6	2.3	2.3	12.3	2.7
06/02/2020 21:00	15.5	1.9	2.3	12.2	2.7
06/02/2020 22:00	15.4	1.9	2.3	12.2	2.6
06/02/2020 23:00	15.4	2.3	2.3	12.2	2.6
Average/Sum#:	292.0 #	27.5 #	49.8 #	260.9 #	57.0 #
Minimum:	6.7	0.2	1.8	9.0	2.0
Maximum:	15.8	2.7	2.4	12.5	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/03/2020 00:00	15.2	1.9	2.3	12.0	2.6
06/03/2020 01:00	6.9	0.5	1.8	9.4	2.1
06/03/2020 02:00	9.0	0.5	1.8	9.2	2.0
06/03/2020 03:00	6.7	0.5	1.8	9.1	2.0
06/03/2020 04:00	9.5	0.6	1.9	10.1	2.2
06/03/2020 05:00	7.1	0.6	1.8	9.6	2.1
06/03/2020 06:00	6.8	0.5	1.8	9.2	2.0
06/03/2020 07:00	9.0	0.5	1.8	9.4	2.1
06/03/2020 08:00	9.3	0.6	1.9	9.8	2.2
06/03/2020 09:00	9.3	0.6	1.9	9.8	2.1
06/03/2020 10:00	9.2	0.8	1.9	9.6	2.1
06/03/2020 11:00	15.3	3.7	2.3	12.0	2.6
06/03/2020 12:00	15.8	2.3	2.3	12.4	2.7
06/03/2020 13:00	15.7	2.0	2.4	12.5	2.7
06/03/2020 14:00	15.7	1.6	2.3	12.4	2.7
06/03/2020 15:00	15.6	1.6	2.3	12.2	2.7
06/03/2020 16:00	15.6	1.6	2.3	12.3	2.7
06/03/2020 17:00	15.6	2.0	2.3	12.3	2.7
06/03/2020 18:00	15.6	2.3	2.3	12.4	2.7
06/03/2020 19:00	15.7	2.3	2.3	12.3	2.7
06/03/2020 20:00	15.4	3.0	2.3	12.1	2.6
06/03/2020 21:00	15.3	3.0	2.3	12.1	2.6
06/03/2020 22:00	15.2	3.0	2.3	12.0	2.6
06/03/2020 23:00	15.6	2.7	2.3	12.4	2.8
Average/Sum#:	300.1 #	38.7 #	50.7 #	266.6 #	58.3 #
Minimum:	6.7	0.5	1.8	9.1	2.0
Maximum:	15.8	3.7	2.4	12.5	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/04/2020 00:00	14.7	19.3	0.9	4.2	0.9
06/04/2020 01:00	0.0	0.0	0.0	0.0	0.0
06/04/2020 02:00	0.0	0.0	0.0	0.0	0.0
06/04/2020 03:00	0.0	0.0	0.0	0.0	0.0
06/04/2020 04:00	0.0	0.0	0.0	0.0	0.0
06/04/2020 05:00	0.0	0.0	0.0	0.0	0.0
06/04/2020 06:00	11.7	43.3	0.4	1.6	0.4
06/04/2020 07:00	91.5	113.1	1.5	5.2	1.2
06/04/2020 08:00	2.1	0.0	1.4	5.1	1.2
06/04/2020 09:00	4.1	0.0	1.4	5.1	1.2
06/04/2020 10:00	32.7	10.2	1.4	5.6	1.3
06/04/2020 11:00	47.6	37.7	1.7	7.7	1.7
06/04/2020 12:00	7.2	0.6	1.9	9.8	2.1
06/04/2020 13:00	7.1	0.6	1.9	9.7	2.1
06/04/2020 14:00	13.3	3.3	2.3	12.1	2.6
06/04/2020 15:00	15.7	2.6	2.3	12.4	2.7
06/04/2020 16:00	15.7	2.6	2.3	12.4	2.7
06/04/2020 17:00	15.7	2.6	2.3	12.4	2.7
06/04/2020 18:00	15.6	2.6	2.3	12.3	2.7
06/04/2020 19:00	15.5	3.0	2.3	12.1	2.7
06/04/2020 20:00	15.8	3.0	2.3	12.4	2.7
06/04/2020 21:00	15.7	2.3	2.3	12.4	2.7
06/04/2020 22:00	15.5	3.0	2.3	12.3	2.7
06/04/2020 23:00	15.3	3.0	2.3	12.1	2.6
Average/Sum#:	372.5 #	252.8 #	35.5 #	176.9 #	38.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	91.5	113.1	2.3	12.4	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/05/2020 00:00	11.7	22.0	1.0	4.7	1.1
06/05/2020 01:00	0.0	0.0	0.0	0.0	0.0
06/05/2020 02:00	0.0	0.0	0.0	0.0	0.0
06/05/2020 03:00	0.0	0.0	0.0	0.0	0.0
06/05/2020 04:00	0.0	0.0	0.0	0.0	0.0
06/05/2020 05:00	0.0	0.0	0.0	0.0	0.0
06/05/2020 06:00	0.0	0.0	0.0	0.0	0.0
06/05/2020 07:00	0.0	0.0	0.0	0.0	0.0
06/05/2020 08:00	0.0	0.0	0.0	0.0	0.0
06/05/2020 09:00	0.0	0.0	0.0	0.0	0.0
06/05/2020 10:00	0.0	0.0	0.0	0.0	0.0
06/05/2020 11:00	0.0	0.0	0.0	0.0	0.0
06/05/2020 12:00	0.0	0.0	0.0	0.0	0.0
06/05/2020 13:00	0.0	0.0	0.0	0.0	0.0
06/05/2020 14:00	0.0	0.0	0.0	0.0	0.0
06/05/2020 15:00	0.0	0.0	0.0	0.0	0.0
06/05/2020 16:00	0.0	0.0	0.0	0.0	0.0
06/05/2020 17:00	0.0	0.0	0.0	0.0	0.0
06/05/2020 18:00	0.0	0.0	0.0	0.0	0.0
06/05/2020 19:00	0.0	0.0	0.0	0.0	0.0
06/05/2020 20:00	0.0	0.0	0.0	0.0	0.0
06/05/2020 21:00	0.0	0.0	0.0	0.0	0.0
06/05/2020 22:00	0.0	0.0	0.0	0.0	0.0
06/05/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	11.7 #	22.0 #	1.0 #	4.7 #	1.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	11.7	22.0	1.0	4.7	1.1
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/06/2020 00:00	0.0	0.0	0.0	0.0	0.0
06/06/2020 01:00	0.0	0.0	0.0	0.0	0.0
06/06/2020 02:00	0.0	0.0	0.0	0.0	0.0
06/06/2020 03:00	0.0	0.0	0.0	0.0	0.0
06/06/2020 04:00	0.0	0.0	0.0	0.0	0.0
06/06/2020 05:00	0.0	0.0	0.0	0.0	0.0
06/06/2020 06:00	0.0	0.0	0.0	0.0	0.0
06/06/2020 07:00	0.0	0.0	0.0	0.0	0.0
06/06/2020 08:00	0.0	0.0	0.0	0.0	0.0
06/06/2020 09:00	0.0	0.0	0.0	0.0	0.0
06/06/2020 10:00	0.0	0.0	0.0	0.0	0.0
06/06/2020 11:00	0.0	0.0	0.0	0.0	0.0
06/06/2020 12:00	0.0	0.0	0.0	0.0	0.0
06/06/2020 13:00	0.0	0.0	0.0	0.0	0.0
06/06/2020 14:00	0.0	0.0	0.0	0.0	0.0
06/06/2020 15:00	0.0	0.0	0.0	0.0	0.0
06/06/2020 16:00	0.0	0.0	0.0	0.0	0.0
06/06/2020 17:00	0.0	0.0	0.0	0.0	0.0
06/06/2020 18:00	0.0	0.0	0.0	0.0	0.0
06/06/2020 19:00	0.0	0.0	0.0	0.0	0.0
06/06/2020 20:00	0.0	0.0	0.0	0.0	0.0
06/06/2020 21:00	0.0	0.0	0.0	0.0	0.0
06/06/2020 22:00	0.0	0.0	0.0	0.0	0.0
06/06/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/07/2020 00:00	0.0	0.0	0.0	0.0	0.0
06/07/2020 01:00	0.0	0.0	0.0	0.0	0.0
06/07/2020 02:00	0.0	0.0	0.0	0.0	0.0
06/07/2020 03:00	0.0	0.0	0.0	0.0	0.0
06/07/2020 04:00	0.0	0.0	0.0	0.0	0.0
06/07/2020 05:00	0.0	0.0	0.0	0.0	0.0
06/07/2020 06:00	0.0	0.0	0.0	0.0	0.0
06/07/2020 07:00	0.0	0.0	0.0	0.0	0.0
06/07/2020 08:00	0.0	0.0	0.0	0.0	0.0
06/07/2020 09:00	0.0	0.0	0.0	0.0	0.0
06/07/2020 10:00	0.0	0.0	0.0	0.0	0.0
06/07/2020 11:00	0.0	0.0	0.0	0.0	0.0
06/07/2020 12:00	0.0	0.0	0.0	0.0	0.0
06/07/2020 13:00	0.0	0.0	0.0	0.0	0.0
06/07/2020 14:00	0.0	0.0	0.0	0.0	0.0
06/07/2020 15:00	0.0	0.0	0.0	0.0	0.0
06/07/2020 16:00	0.0	0.0	0.0	0.0	0.0
06/07/2020 17:00	0.0	0.0	0.0	0.0	0.0
06/07/2020 18:00	0.0	0.0	0.0	0.0	0.0
06/07/2020 19:00	0.0	0.0	0.0	0.0	0.0
06/07/2020 20:00	0.0	0.0	0.0	0.0	0.0
06/07/2020 21:00	0.0	0.0	0.0	0.0	0.0
06/07/2020 22:00	0.0	0.0	0.0	0.0	0.0
06/07/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/08/2020 00:00	0.0	0.0	0.0	0.0	0.0
06/08/2020 01:00	0.0	0.0	0.0	0.0	0.0
06/08/2020 02:00	0.0	0.0	0.0	0.0	0.0
06/08/2020 03:00	0.0	0.0	0.0	0.0	0.0
06/08/2020 04:00	0.0	0.0	0.0	0.0	0.0
06/08/2020 05:00	0.0	0.0	0.0	0.0	0.0
06/08/2020 06:00	0.0	0.0	0.0	0.0	0.0
06/08/2020 07:00	0.0	0.0	0.0	0.0	0.0
06/08/2020 08:00	0.0	0.0	0.0	0.0	0.0
06/08/2020 09:00	31.7	74.3	0.0	0.6	0.1
06/08/2020 10:00	72.6	19.8	0.2	1.6	0.3
06/08/2020 11:00	30.0	20.6	0.2	1.7	0.3
06/08/2020 12:00	54.7	64.8	0.3	2.8	0.6
06/08/2020 13:00	1.4	0.5	0.4	4.1	0.8
06/08/2020 14:00	2.7	0.5	0.4	4.1	0.8
06/08/2020 15:00	262.6	327.2	1.3	7.4	1.6
06/08/2020 16:00	308.8	123.2	1.9	9.8	2.1
06/08/2020 17:00	29.0	47.0	1.1	7.1	1.5
06/08/2020 18:00	57.0	38.7	2.1	10.5	2.3
06/08/2020 19:00	11.4	1.0	2.0	10.3	2.3
06/08/2020 20:00	12.8	4.9	2.2	11.7	2.6
06/08/2020 21:00	15.4	4.4	2.2	12.1	2.7
06/08/2020 22:00	15.2	4.5	2.2	12.0	2.6
06/08/2020 23:00	21.6	24.6	2.0	10.0	2.2
Average/Sum#:	926.9 #	756.0 #	18.5 #	105.8 #	22.8 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	308.8	327.2	2.2	12.1	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/09/2020 00:00	0.0	0.0	0.0	0.0	0.0
06/09/2020 01:00	0.0	0.0	0.0	0.0	0.0
06/09/2020 02:00	0.0	0.0	0.0	0.0	0.0
06/09/2020 03:00	0.0	0.0	0.0	0.0	0.0
06/09/2020 04:00	0.0	0.0	0.0	0.0	0.0
06/09/2020 05:00	0.0	0.0	0.0	0.0	0.0
06/09/2020 06:00	0.0	0.0	0.0	0.0	0.0
06/09/2020 07:00	0.0	0.0	0.0	0.0	0.0
06/09/2020 08:00	31.2	12.2	0.1	0.7	0.1
06/09/2020 09:00	28.3	22.6	0.2	1.6	0.3
06/09/2020 10:00	60.8	43.5	0.3	2.8	0.6
06/09/2020 11:00	1.4	0.5	0.4	4.1	0.8
06/09/2020 12:00	134.3	67.0	1.0	6.1	1.3
06/09/2020 13:00	91.7	48.9	1.1	6.6	1.4
06/09/2020 14:00	43.1	95.6	1.8	9.3	2.0
06/09/2020 15:00	7.4	0.9	2.0	10.0	2.2
06/09/2020 16:00	7.1	0.8	1.9	9.6	2.1
06/09/2020 17:00	15.1	4.7	2.2	11.9	2.6
06/09/2020 18:00	15.7	3.7	2.3	12.3	2.8
06/09/2020 19:00	15.7	3.7	2.3	12.4	2.8
06/09/2020 20:00	15.5	4.4	2.3	12.2	2.6
06/09/2020 21:00	15.3	4.4	2.3	12.1	2.6
06/09/2020 22:00	15.1	4.5	2.2	11.9	2.6
06/09/2020 23:00	12.1	21.9	0.9	4.2	0.9
Average/Sum#:	509.8 #	339.3 #	23.3 #	127.8 #	27.7 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	134.3	95.6	2.3	12.4	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/10/2020 00:00	0.0	0.0	0.0	0.0	0.0
06/10/2020 01:00	0.0	0.0	0.0	0.0	0.0
06/10/2020 02:00	0.0	0.0	0.0	0.0	0.0
06/10/2020 03:00	0.0	0.0	0.0	0.0	0.0
06/10/2020 04:00	0.0	0.0	0.0	0.0	0.0
06/10/2020 05:00	0.0	0.0	0.0	0.0	0.0
06/10/2020 06:00	0.0	0.0	0.0	0.0	0.0
06/10/2020 07:00	17.1	9.0	0.0	0.4	0.1
06/10/2020 08:00	50.8	48.2	0.3	3.0	0.6
06/10/2020 09:00	2.7	0.8	0.4	4.1	0.8
06/10/2020 10:00	157.4	97.1	1.4	7.7	1.6
06/10/2020 11:00	96.6	249.6	2.0	9.9	2.2
06/10/2020 12:00	15.1	21.0	1.8	9.3	2.0
06/10/2020 13:00	11.1	1.2	1.9	10.1	2.2
06/10/2020 14:00	9.0	1.5	2.0	10.0	2.3
06/10/2020 15:00	13.3	4.8	2.3	12.1	2.6
06/10/2020 16:00	16.6	3.8	2.5	13.1	2.9
06/10/2020 17:00	16.4	3.8	2.5	12.9	2.9
06/10/2020 18:00	16.1	3.7	2.4	12.7	2.8
06/10/2020 19:00	15.5	3.6	2.3	12.2	2.6
06/10/2020 20:00	15.5	3.6	2.3	12.2	2.6
06/10/2020 21:00	15.6	3.8	2.3	12.3	2.7
06/10/2020 22:00	15.0	4.4	2.2	11.9	2.6
06/10/2020 23:00	13.3	4.4	2.3	12.1	2.6
Average/Sum#:	497.1 #	464.3 #	30.9 #	166.0 #	36.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	157.4	249.6	2.5	13.1	2.9
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/11/2020 00:00	14.7	3.1	2.2	11.6	2.6
06/11/2020 01:00	14.7	2.3	2.2	11.7	2.6
06/11/2020 02:00	14.6	3.4	2.2	11.5	2.6
06/11/2020 03:00	14.9	3.4	2.2	11.8	2.6
06/11/2020 04:00	12.5	3.7	2.2	11.3	2.5
06/11/2020 05:00	9.3	0.9	1.9	10.3	2.2
06/11/2020 06:00	11.4	0.9	1.9	10.4	2.2
06/11/2020 07:00	11.3	0.9	1.9	10.3	2.2
06/11/2020 08:00	11.4	0.9	1.9	10.3	2.2
06/11/2020 09:00	11.1	0.9	1.9	10.1	2.2
06/11/2020 10:00	11.1	1.2	1.9	10.1	2.2
06/11/2020 11:00	6.8	0.8	1.8	9.3	2.0
06/11/2020 12:00	10.9	1.2	1.9	9.9	2.2
06/11/2020 13:00	10.9	1.2	1.9	9.9	2.2
06/11/2020 14:00	11.0	0.9	1.9	10.0	2.2
06/11/2020 15:00	10.9	0.9	1.9	9.9	2.2
06/11/2020 16:00	11.0	0.9	1.9	10.0	2.2
06/11/2020 17:00	11.2	1.2	1.9	10.2	2.2
06/11/2020 18:00	13.1	4.8	2.2	11.9	2.6
06/11/2020 19:00	16.0	3.3	2.3	12.5	2.8
06/11/2020 20:00	15.5	3.7	2.3	12.2	2.7
06/11/2020 21:00	15.4	3.7	2.3	12.1	2.6
06/11/2020 22:00	15.0	4.0	2.2	11.8	2.6
06/11/2020 23:00	10.1	23.0	0.9	4.2	0.9
Average/Sum#:	294.8 #	71.2 #	47.8 #	253.3 #	55.5 #
Minimum:	6.8	0.8	0.9	4.2	0.9
Maximum:	16.0	23.0	2.3	12.5	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/12/2020 00:00	0.0	0.0	0.0	0.0	0.0
06/12/2020 01:00	0.0	0.0	0.0	0.0	0.0
06/12/2020 02:00	0.0	0.0	0.0	0.0	0.0
06/12/2020 03:00	0.0	0.0	0.0	0.0	0.0
06/12/2020 04:00	0.0	0.0	0.0	0.0	0.0
06/12/2020 05:00	0.0	0.0	0.0	0.0	0.0
06/12/2020 06:00	0.0	0.0	0.0	0.0	0.0
06/12/2020 07:00	0.0	0.0	0.0	0.0	0.0
06/12/2020 08:00	0.0	0.0	0.0	0.0	0.0
06/12/2020 09:00	0.0	0.0	0.0	0.0	0.0
06/12/2020 10:00	0.0	0.0	0.0	0.0	0.0
06/12/2020 11:00	0.0	0.0	0.0	0.0	0.0
06/12/2020 12:00	0.0	0.0	0.0	0.0	0.0
06/12/2020 13:00	0.0	0.0	0.0	0.0	0.0
06/12/2020 14:00	0.0	0.0	0.0	0.0	0.0
06/12/2020 15:00	0.0	0.0	0.0	0.0	0.0
06/12/2020 16:00	0.0	0.0	0.0	0.0	0.0
06/12/2020 17:00	0.0	0.0	0.0	0.0	0.0
06/12/2020 18:00	0.0	0.0	0.0	0.0	0.0
06/12/2020 19:00	0.0	0.0	0.0	0.0	0.0
06/12/2020 20:00	0.0	0.0	0.0	0.0	0.0
06/12/2020 21:00	0.0	0.0	0.0	0.0	0.0
06/12/2020 22:00	0.0	0.0	0.0	0.0	0.0
06/12/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/13/2020 00:00	0.0	0.0	0.0	0.0	0.0
06/13/2020 01:00	0.0	0.0	0.0	0.0	0.0
06/13/2020 02:00	0.0	0.0	0.0	0.0	0.0
06/13/2020 03:00	0.0	0.0	0.0	0.0	0.0
06/13/2020 04:00	0.0	0.0	0.0	0.0	0.0
06/13/2020 05:00	0.0	0.0	0.0	0.0	0.0
06/13/2020 06:00	0.0	0.0	0.0	0.0	0.0
06/13/2020 07:00	0.0	0.0	0.0	0.0	0.0
06/13/2020 08:00	0.0	0.0	0.0	0.0	0.0
06/13/2020 09:00	0.0	0.0	0.0	0.0	0.0
06/13/2020 10:00	0.0	0.0	0.0	0.0	0.0
06/13/2020 11:00	0.0	0.0	0.0	0.0	0.0
06/13/2020 12:00	0.0	0.0	0.0	0.0	0.0
06/13/2020 13:00	0.0	0.0	0.0	0.0	0.0
06/13/2020 14:00	0.0	0.0	0.0	0.0	0.0
06/13/2020 15:00	0.0	0.0	0.0	0.0	0.0
06/13/2020 16:00	0.0	0.0	0.0	0.0	0.0
06/13/2020 17:00	0.0	0.0	0.0	0.0	0.0
06/13/2020 18:00	0.0	0.0	0.0	0.0	0.0
06/13/2020 19:00	0.0	0.0	0.0	0.0	0.0
06/13/2020 20:00	0.0	0.0	0.0	0.0	0.0
06/13/2020 21:00	0.0	0.0	0.0	0.0	0.0
06/13/2020 22:00	0.0	0.0	0.0	0.0	0.0
06/13/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/14/2020 00:00	0.0	0.0	0.0	0.0	0.0
06/14/2020 01:00	0.0	0.0	0.0	0.0	0.0
06/14/2020 02:00	0.0	0.0	0.0	0.0	0.0
06/14/2020 03:00	0.0	0.0	0.0	0.0	0.0
06/14/2020 04:00	0.0	0.0	0.0	0.0	0.0
06/14/2020 05:00	0.0	0.0	0.0	0.0	0.0
06/14/2020 06:00	0.0	0.0	0.0	0.0	0.0
06/14/2020 07:00	0.0	0.0	0.0	0.0	0.0
06/14/2020 08:00	0.0	0.0	0.0	0.0	0.0
06/14/2020 09:00	0.0	0.0	0.0	0.0	0.0
06/14/2020 10:00	0.0	0.0	0.0	0.0	0.0
06/14/2020 11:00	0.0	0.0	0.0	0.0	0.0
06/14/2020 12:00	61.0	89.2	0.1	1.0	0.2
06/14/2020 13:00	63.1	42.1	0.2	2.0	0.4
06/14/2020 14:00	57.9	80.1	0.3	2.5	0.5
06/14/2020 15:00	1.4	1.9	0.4	4.2	0.8
06/14/2020 16:00	7.7	2.5	0.6	5.8	1.2
06/14/2020 17:00	7.9	2.5	0.6	5.9	1.2
06/14/2020 18:00	8.1	2.5	0.6	6.1	1.2
06/14/2020 19:00	8.1	2.5	0.6	6.1	1.2
06/14/2020 20:00	8.0	2.5	0.6	6.0	1.2
06/14/2020 21:00	7.7	2.8	0.6	5.8	1.2
06/14/2020 22:00	2.7	0.8	0.4	4.1	0.8
06/14/2020 23:00	1.4	3.6	0.0	0.2	0.0
Average/Sum#:	235.0 #	233.0 #	5.0 #	49.7 #	9.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	63.1	89.2	0.6	6.1	1.2
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/15/2020 00:00	0.0	0.0	0.0	0.0	0.0
06/15/2020 01:00	0.0	0.0	0.0	0.0	0.0
06/15/2020 02:00	0.0	0.0	0.0	0.0	0.0
06/15/2020 03:00	0.0	0.0	0.0	0.0	0.0
06/15/2020 04:00	0.0	0.0	0.0	0.0	0.0
06/15/2020 05:00	0.0	0.0	0.0	0.0	0.0
06/15/2020 06:00	0.0	0.0	0.0	0.0	0.0
06/15/2020 07:00	0.0	0.0	0.0	0.0	0.0
06/15/2020 08:00	0.0	0.0	0.0	0.0	0.0
06/15/2020 09:00	0.0	0.0	0.0	0.0	0.0
06/15/2020 10:00	0.0	0.0	0.0	0.0	0.0
06/15/2020 11:00	0.0	0.0	0.0	0.0	0.0
06/15/2020 12:00	0.0	0.0	0.0	0.0	0.0
06/15/2020 13:00	0.0	0.0	0.0	0.0	0.0
06/15/2020 14:00	0.0	0.0	0.0	0.0	0.0
06/15/2020 15:00	0.0	0.0	0.0	0.0	0.0
06/15/2020 16:00	0.0	0.0	0.0	0.0	0.0
06/15/2020 17:00	0.0	0.0	0.0	0.0	0.0
06/15/2020 18:00	0.0	0.0	0.0	0.0	0.0
06/15/2020 19:00	0.0	0.0	0.0	0.0	0.0
06/15/2020 20:00	0.0	0.0	0.0	0.0	0.0
06/15/2020 21:00	0.0	0.0	0.0	0.0	0.0
06/15/2020 22:00	0.0	0.0	0.0	0.0	0.0
06/15/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/16/2020 00:00	0.0	0.0	0.0	0.0	0.0
06/16/2020 01:00	0.0	0.0	0.0	0.0	0.0
06/16/2020 02:00	0.0	0.0	0.0	0.0	0.0
06/16/2020 03:00	0.0	0.0	0.0	0.0	0.0
06/16/2020 04:00	0.0	0.0	0.0	0.0	0.0
06/16/2020 05:00	0.0	0.0	0.0	0.0	0.0
06/16/2020 06:00	0.0	0.0	0.0	0.0	0.0
06/16/2020 07:00	0.0	0.0	0.0	0.0	0.0
06/16/2020 08:00	0.0	0.0	0.0	0.0	0.0
06/16/2020 09:00	0.0	0.0	0.0	0.0	0.0
06/16/2020 10:00	0.0	0.0	0.0	0.0	0.0
06/16/2020 11:00	0.0	0.0	0.0	0.0	0.0
06/16/2020 12:00	0.0	0.0	0.0	0.0	0.0
06/16/2020 13:00	0.0	0.0	0.0	0.0	0.0
06/16/2020 14:00	0.0	0.0	0.0	0.0	0.0
06/16/2020 15:00	0.0	0.0	0.0	0.0	0.0
06/16/2020 16:00	0.0	0.0	0.0	0.0	0.0
06/16/2020 17:00	0.0	0.0	0.0	0.0	0.0
06/16/2020 18:00	0.0	0.0	0.0	0.0	0.0
06/16/2020 19:00	0.0	0.0	0.0	0.0	0.0
06/16/2020 20:00	0.0	0.0	0.0	0.0	0.0
06/16/2020 21:00	0.0	0.0	0.0	0.0	0.0
06/16/2020 22:00	0.0	0.0	0.0	0.0	0.0
06/16/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/17/2020 00:00	0.0	0.0	0.0	0.0	0.0
06/17/2020 01:00	0.0	0.0	0.0	0.0	0.0
06/17/2020 02:00	0.0	0.0	0.0	0.0	0.0
06/17/2020 03:00	0.0	0.0	0.0	0.0	0.0
06/17/2020 04:00	0.0	0.0	0.0	0.0	0.0
06/17/2020 05:00	0.0	0.0	0.0	0.0	0.0
06/17/2020 06:00	0.0	0.0	0.0	0.0	0.0
06/17/2020 07:00	0.0	0.0	0.0	0.0	0.0
06/17/2020 08:00	0.0	0.0	0.0	0.0	0.0
06/17/2020 09:00	82.6	77.8	0.1	1.2	0.2
06/17/2020 10:00	32.4	20.4	0.2	1.6	0.3
06/17/2020 11:00	41.9	25.5	0.3	2.9	0.6
06/17/2020 12:00	150.3	338.2	0.9	6.0	1.2
06/17/2020 13:00	283.6	122.9	1.8	8.9	2.0
06/17/2020 14:00	76.2	89.1	2.0	9.9	2.2
06/17/2020 15:00	55.6	77.6	1.9	10.0	2.2
06/17/2020 16:00	9.4	0.6	2.1	10.6	2.4
06/17/2020 17:00	7.8	0.9	2.1	10.6	2.3
06/17/2020 18:00	16.1	4.8	2.4	12.8	2.8
06/17/2020 19:00	17.0	4.0	2.6	13.4	3.0
06/17/2020 20:00	16.2	3.9	2.4	12.8	2.8
06/17/2020 21:00	15.7	3.8	2.3	12.4	2.8
06/17/2020 22:00	15.4	4.5	2.3	12.2	2.6
06/17/2020 23:00	12.3	21.7	1.0	4.4	1.0
Average/Sum#:	832.5 #	795.7 #	24.4 #	129.7 #	28.4 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	283.6	338.2	2.6	13.4	3.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/18/2020 00:00	0.0	0.0	0.0	0.0	0.0
06/18/2020 01:00	0.0	0.0	0.0	0.0	0.0
06/18/2020 02:00	0.0	0.0	0.0	0.0	0.0
06/18/2020 03:00	0.0	0.0	0.0	0.0	0.0
06/18/2020 04:00	0.0	0.0	0.0	0.0	0.0
06/18/2020 05:00	0.0	0.0	0.0	0.0	0.0
06/18/2020 06:00	0.0	0.0	0.0	0.0	0.0
06/18/2020 07:00	22.1	8.1	0.0	0.4	0.1
06/18/2020 08:00	53.4	26.9	0.3	2.5	0.5
06/18/2020 09:00	2.8	0.5	0.4	4.2	0.8
06/18/2020 10:00	2.8	0.5	0.4	4.2	0.8
06/18/2020 11:00	170.4	58.4	1.1	7.1	1.5
06/18/2020 12:00	75.1	54.0	1.8	9.3	2.1
06/18/2020 13:00	11.1	0.6	2.0	10.1	2.2
06/18/2020 14:00	11.1	0.9	2.0	10.0	2.3
06/18/2020 15:00	17.4	5.1	2.2	11.9	2.6
06/18/2020 16:00	20.6	3.7	2.3	12.4	2.7
06/18/2020 17:00	16.0	3.8	2.4	12.7	2.8
06/18/2020 18:00	16.6	4.0	2.5	13.1	2.9
06/18/2020 19:00	16.7	4.0	2.5	13.2	3.0
06/18/2020 20:00	16.8	4.1	2.6	13.3	3.0
06/18/2020 21:00	16.1	3.9	2.4	12.7	2.8
06/18/2020 22:00	12.7	4.1	2.2	11.5	2.6
06/18/2020 23:00	8.2	21.7	0.5	1.8	0.4
Average/Sum#:	489.9 #	204.3 #	27.6 #	150.4 #	33.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	170.4	58.4	2.6	13.3	3.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/19/2020 00:00	0.0	0.0	0.0	0.0	0.0
06/19/2020 01:00	0.0	0.0	0.0	0.0	0.0
06/19/2020 02:00	0.0	0.0	0.0	0.0	0.0
06/19/2020 03:00	0.0	0.0	0.0	0.0	0.0
06/19/2020 04:00	0.0	0.0	0.0	0.0	0.0
06/19/2020 05:00	0.0	0.0	0.0	0.0	0.0
06/19/2020 06:00	0.0	0.0	0.0	0.0	0.0
06/19/2020 07:00	0.0	0.0	0.0	0.0	0.0
06/19/2020 08:00	0.0	0.0	0.0	0.0	0.0
06/19/2020 09:00	0.0	0.0	0.0	0.0	0.0
06/19/2020 10:00	0.0	0.0	0.0	0.0	0.0
06/19/2020 11:00	0.0	0.0	0.0	0.0	0.0
06/19/2020 12:00	0.0	0.0	0.0	0.0	0.0
06/19/2020 13:00	0.0	0.0	0.0	0.0	0.0
06/19/2020 14:00	0.0	0.0	0.0	0.0	0.0
06/19/2020 15:00	0.0	0.0	0.0	0.0	0.0
06/19/2020 16:00	0.0	0.0	0.0	0.0	0.0
06/19/2020 17:00	0.0	0.0	0.0	0.0	0.0
06/19/2020 18:00	0.0	0.0	0.0	0.0	0.0
06/19/2020 19:00	0.0	0.0	0.0	0.0	0.0
06/19/2020 20:00	0.0	0.0	0.0	0.0	0.0
06/19/2020 21:00	0.0	0.0	0.0	0.0	0.0
06/19/2020 22:00	0.0	0.0	0.0	0.0	0.0
06/19/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/20/2020 00:00	0.0	0.0	0.0	0.0	0.0
06/20/2020 01:00	0.0	0.0	0.0	0.0	0.0
06/20/2020 02:00	0.0	0.0	0.0	0.0	0.0
06/20/2020 03:00	0.0	0.0	0.0	0.0	0.0
06/20/2020 04:00	0.0	0.0	0.0	0.0	0.0
06/20/2020 05:00	0.0	0.0	0.0	0.0	0.0
06/20/2020 06:00	0.0	0.0	0.0	0.0	0.0
06/20/2020 07:00	0.0	0.0	0.0	0.0	0.0
06/20/2020 08:00	0.0	0.0	0.0	0.0	0.0
06/20/2020 09:00	0.0	0.0	0.0	0.0	0.0
06/20/2020 10:00	0.0	0.0	0.0	0.0	0.0
06/20/2020 11:00	0.0	0.0	0.0	0.0	0.0
06/20/2020 12:00	0.0	0.0	0.0	0.0	0.0
06/20/2020 13:00	0.0	0.0	0.0	0.0	0.0
06/20/2020 14:00	0.0	0.0	0.0	0.0	0.0
06/20/2020 15:00	0.0	0.0	0.0	0.0	0.0
06/20/2020 16:00	0.0	0.0	0.0	0.0	0.0
06/20/2020 17:00	0.0	0.0	0.0	0.0	0.0
06/20/2020 18:00	0.0	0.0	0.0	0.0	0.0
06/20/2020 19:00	0.0	0.0	0.0	0.0	0.0
06/20/2020 20:00	68.8	88.5	0.1	1.3	0.3
06/20/2020 21:00	11.3	27.9	0.2	1.5	0.3
06/20/2020 22:00	30.0	50.0	0.3	3.0	0.6
06/20/2020 23:00	2.8	1.0	0.4	4.2	0.8
Average/Sum#:	112.9 #	167.4 #	1.0 #	10.0 #	2.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	68.8	88.5	0.4	4.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/21/2020 00:00	2.7	0.8	0.4	4.0	0.8
06/21/2020 01:00	2.7	0.8	0.4	4.0	0.8
06/21/2020 02:00	2.7	0.8	0.4	4.0	0.8
06/21/2020 03:00	2.7	0.8	0.4	4.0	0.8
06/21/2020 04:00	2.7	0.8	0.4	4.0	0.8
06/21/2020 05:00	2.7	0.8	0.4	4.0	0.8
06/21/2020 06:00	2.7	1.0	0.4	4.0	0.8
06/21/2020 07:00	2.7	0.8	0.4	4.0	0.8
06/21/2020 08:00	2.7	0.8	0.4	4.1	0.8
06/21/2020 09:00	2.7	0.8	0.4	4.1	0.8
06/21/2020 10:00	2.7	0.8	0.4	4.1	0.8
06/21/2020 11:00	2.7	0.8	0.4	4.1	0.8
06/21/2020 12:00	2.7	0.8	0.4	4.1	0.8
06/21/2020 13:00	2.7	0.8	0.4	4.1	0.8
06/21/2020 14:00	2.7	0.8	0.4	4.1	0.8
06/21/2020 15:00	2.7	0.8	0.4	4.1	0.8
06/21/2020 16:00	2.8	0.8	0.4	4.2	0.8
06/21/2020 17:00	7.7	2.8	0.6	5.8	1.2
06/21/2020 18:00	8.3	2.2	0.6	6.2	1.2
06/21/2020 19:00	8.4	2.1	0.6	6.3	1.3
06/21/2020 20:00	8.2	2.2	0.6	6.2	1.2
06/21/2020 21:00	7.9	2.4	0.6	5.9	1.2
06/21/2020 22:00	2.7	0.8	0.4	4.1	0.8
06/21/2020 23:00	2.7	0.8	0.4	4.1	0.8
Average/Sum#:	91.9 #	27.1 #	10.6 #	107.6 #	21.3 #
Minimum:	2.7	0.8	0.4	4.0	0.8
Maximum:	8.4	2.8	0.6	6.3	1.3
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/22/2020 00:00	2.7	1.3	0.4	4.0	0.8
06/22/2020 01:00	2.7	1.0	0.4	4.0	0.8
06/22/2020 02:00	2.7	1.0	0.4	4.0	0.8
06/22/2020 03:00	2.7	1.0	0.4	4.0	0.8
06/22/2020 04:00	2.7	1.0	0.4	4.0	0.8
06/22/2020 05:00	2.8	1.1	0.4	4.2	0.8
06/22/2020 06:00	2.7	0.8	0.4	4.0	0.8
06/22/2020 07:00	2.7	0.8	0.4	4.1	0.8
06/22/2020 08:00	2.7	0.8	0.4	4.1	0.8
06/22/2020 09:00	207.5	444.8	1.2	7.1	1.5
06/22/2020 10:00	99.1	42.2	0.9	6.2	1.3
06/22/2020 11:00	128.4	188.5	1.9	9.7	2.1
06/22/2020 12:00	19.1	20.5	2.1	10.5	2.4
06/22/2020 13:00	8.0	1.2	2.1	10.8	2.4
06/22/2020 14:00	13.6	4.4	2.4	12.4	2.7
06/22/2020 15:00	15.6	3.6	2.3	12.3	2.7
06/22/2020 16:00	15.4	3.6	2.3	12.2	2.6
06/22/2020 17:00	15.5	3.3	2.3	12.2	2.7
06/22/2020 18:00	15.6	2.9	2.3	12.3	2.7
06/22/2020 19:00	16.7	3.1	2.5	13.2	3.0
06/22/2020 20:00	17.0	3.2	2.6	13.5	3.0
06/22/2020 21:00	16.7	3.9	2.5	13.2	2.9
06/22/2020 22:00	16.2	4.2	2.4	12.8	2.8
06/22/2020 23:00	16.2	4.8	2.5	12.8	2.8
Average/Sum#:	645.0 #	743.0 #	35.9 #	207.6 #	44.8 #
Minimum:	2.7	0.8	0.4	4.0	0.8
Maximum:	207.5	444.8	2.6	13.5	3.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/23/2020 00:00	10.1	29.1	1.0	4.8	1.1
06/23/2020 01:00	0.0	0.0	0.0	0.0	0.0
06/23/2020 02:00	0.0	0.0	0.0	0.0	0.0
06/23/2020 03:00	0.0	0.0	0.0	0.0	0.0
06/23/2020 04:00	0.0	0.0	0.0	0.0	0.0
06/23/2020 05:00	0.0	0.0	0.0	0.0	0.0
06/23/2020 06:00	0.0	0.0	0.0	0.0	0.0
06/23/2020 07:00	0.0	1.0	0.0	0.1	0.0
06/23/2020 08:00	20.1	85.6	0.5	1.7	0.4
06/23/2020 09:00	5.4	0.8	0.9	3.4	0.8
06/23/2020 10:00	2.7	0.0	0.9	3.3	0.8
06/23/2020 11:00	4.3	0.0	1.0	3.6	0.9
06/23/2020 12:00	14.7	7.3	1.1	4.1	1.0
06/23/2020 13:00	38.8	52.1	1.2	5.7	1.3
06/23/2020 14:00	10.8	5.4	1.3	7.3	1.6
06/23/2020 15:00	8.2	1.2	1.6	9.1	2.0
06/23/2020 16:00	12.2	3.6	2.0	11.2	2.4
06/23/2020 17:00	14.4	3.0	2.0	11.4	2.4
06/23/2020 18:00	14.4	2.7	2.0	11.4	2.4
06/23/2020 19:00	14.6	2.7	2.1	11.4	2.5
06/23/2020 20:00	14.8	2.7	2.1	11.6	2.6
06/23/2020 21:00	14.4	3.0	2.1	11.4	2.4
06/23/2020 22:00	14.4	3.0	2.0	11.4	2.4
06/23/2020 23:00	14.4	3.0	2.0	11.4	2.4
Average/Sum#:	228.7 #	206.2 #	25.8 #	134.3 #	29.4 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	38.8	85.6	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/24/2020 00:00	13.8	3.5	2.0	10.8	2.4
06/24/2020 01:00	11.5	3.5	1.9	10.6	2.3
06/24/2020 02:00	11.5	3.8	1.9	10.6	2.3
06/24/2020 03:00	11.5	3.8	1.9	10.6	2.3
06/24/2020 04:00	12.1	3.8	2.0	11.1	2.4
06/24/2020 05:00	14.3	4.0	2.0	11.3	2.4
06/24/2020 06:00	11.7	4.3	2.0	10.7	2.4
06/24/2020 07:00	7.8	0.9	1.6	8.6	1.8
06/24/2020 08:00	7.8	0.9	1.6	8.6	1.8
06/24/2020 09:00	7.8	0.9	1.6	8.6	1.8
06/24/2020 10:00	7.6	0.9	1.6	8.4	1.8
06/24/2020 11:00	9.4	1.2	1.6	8.6	1.8
06/24/2020 12:00	12.2	4.2	2.0	11.2	2.4
06/24/2020 13:00	14.5	3.6	2.1	11.4	2.4
06/24/2020 14:00	14.5	3.3	2.1	11.4	2.4
06/24/2020 15:00	14.5	3.3	2.1	11.4	2.4
06/24/2020 16:00	14.5	3.3	2.1	11.4	2.4
06/24/2020 17:00	14.5	3.3	2.1	11.4	2.4
06/24/2020 18:00	14.6	3.0	2.1	11.4	2.5
06/24/2020 19:00	14.5	3.0	2.1	11.4	2.4
06/24/2020 20:00	14.5	3.0	2.1	11.4	2.4
06/24/2020 21:00	14.6	3.0	2.1	11.4	2.5
06/24/2020 22:00	14.4	3.6	2.0	11.4	2.4
06/24/2020 23:00	14.4	3.9	2.0	11.3	2.4
Average/Sum#:	298.5 #	72.0 #	46.6 #	255.0 #	54.5 #
Minimum:	7.6	0.9	1.6	8.4	1.8
Maximum:	14.6	4.3	2.1	11.4	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/25/2020 00:00	9.6	23.7	0.8	4.4	1.0
06/25/2020 01:00	0.0	0.0	0.0	0.0	0.0
06/25/2020 02:00	0.0	0.0	0.0	0.0	0.0
06/25/2020 03:00	0.0	0.0	0.0	0.0	0.0
06/25/2020 04:00	0.0	0.0	0.0	0.0	0.0
06/25/2020 05:00	0.0	0.0	0.0	0.0	0.0
06/25/2020 06:00	0.0	0.0	0.0	0.0	0.0
06/25/2020 07:00	0.0	0.0	0.0	0.0	0.0
06/25/2020 08:00	3.1	4.5	0.0	0.2	0.0
06/25/2020 09:00	54.4	38.1	0.3	2.8	0.6
06/25/2020 10:00	2.8	0.5	0.4	4.2	0.8
06/25/2020 11:00	2.8	0.5	0.4	4.3	0.9
06/25/2020 12:00	8.4	10.5	0.5	5.0	1.0
06/25/2020 13:00	43.4	39.3	1.1	6.6	1.4
06/25/2020 14:00	5.2	0.7	1.3	7.1	1.6
06/25/2020 15:00	6.9	1.0	1.4	7.6	1.6
06/25/2020 16:00	5.3	0.8	1.3	7.3	1.6
06/25/2020 17:00	9.7	1.2	1.6	8.9	2.0
06/25/2020 18:00	12.0	3.9	2.0	11.0	2.4
06/25/2020 19:00	12.0	3.6	2.0	11.0	2.4
06/25/2020 20:00	11.9	3.3	2.0	10.9	2.4
06/25/2020 21:00	13.7	3.6	2.0	10.8	2.4
06/25/2020 22:00	10.6	21.8	1.0	5.8	1.2
06/25/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	211.8 #	157.0 #	18.1 #	107.9 #	23.3 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	54.4	39.3	2.0	11.0	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/26/2020 00:00	0.0	0.0	0.0	0.0	0.0
06/26/2020 01:00	0.0	0.0	0.0	0.0	0.0
06/26/2020 02:00	0.0	0.0	0.0	0.0	0.0
06/26/2020 03:00	0.0	0.0	0.0	0.0	0.0
06/26/2020 04:00	0.0	0.0	0.0	0.0	0.0
06/26/2020 05:00	3.2	3.9	0.0	0.2	0.0
06/26/2020 06:00	37.4	43.5	0.2	2.3	0.5
06/26/2020 07:00	1.4	0.5	0.4	4.2	0.8
06/26/2020 08:00	2.8	0.8	0.4	4.2	0.8
06/26/2020 09:00	2.8	0.8	0.4	4.2	0.8
06/26/2020 10:00	7.3	9.0	0.5	4.9	1.0
06/26/2020 11:00	39.4	47.3	1.0	6.5	1.4
06/26/2020 12:00	4.9	4.3	0.5	4.8	0.9
06/26/2020 13:00	6.7	1.2	0.5	5.1	1.0
06/26/2020 14:00	6.7	1.2	0.5	5.1	1.0
06/26/2020 15:00	6.7	1.5	0.5	5.0	1.0
06/26/2020 16:00	8.2	21.9	0.7	5.8	1.2
06/26/2020 17:00	13.9	18.5	1.5	8.6	1.9
06/26/2020 18:00	18.7	2.7	2.1	11.4	2.4
06/26/2020 19:00	18.7	2.7	2.1	11.4	2.5
06/26/2020 20:00	18.7	2.4	2.1	11.4	2.5
06/26/2020 21:00	14.4	2.4	2.0	11.4	2.4
06/26/2020 22:00	13.7	3.9	2.0	10.8	2.4
06/26/2020 23:00	7.3	0.8	1.4	8.0	1.8
Average/Sum#:	232.9 #	169.3 #	18.8 #	125.3 #	26.3 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	39.4	47.3	2.1	11.4	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/27/2020 00:00	5.6	14.3	0.7	4.4	1.0
06/27/2020 01:00	0.0	0.0	0.0	0.0	0.0
06/27/2020 02:00	0.0	0.0	0.0	0.0	0.0
06/27/2020 03:00	0.0	0.0	0.0	0.0	0.0
06/27/2020 04:00	0.0	0.0	0.0	0.0	0.0
06/27/2020 05:00	0.0	0.0	0.0	0.0	0.0
06/27/2020 06:00	0.0	0.0	0.0	0.0	0.0
06/27/2020 07:00	0.0	0.0	0.0	0.0	0.0
06/27/2020 08:00	0.0	0.0	0.0	0.0	0.0
06/27/2020 09:00	0.0	0.0	0.0	0.0	0.0
06/27/2020 10:00	0.0	0.0	0.0	0.0	0.0
06/27/2020 11:00	0.0	0.0	0.0	0.0	0.0
06/27/2020 12:00	0.0	0.0	0.0	0.0	0.0
06/27/2020 13:00	0.0	0.0	0.0	0.0	0.0
06/27/2020 14:00	0.0	0.0	0.0	0.0	0.0
06/27/2020 15:00	0.0	0.0	0.0	0.0	0.0
06/27/2020 16:00	0.0	0.0	0.0	0.0	0.0
06/27/2020 17:00	0.0	0.0	0.0	0.0	0.0
06/27/2020 18:00	0.0	0.0	0.0	0.0	0.0
06/27/2020 19:00	0.0	0.0	0.0	0.0	0.0
06/27/2020 20:00	0.0	0.0	0.0	0.0	0.0
06/27/2020 21:00	0.0	0.0	0.0	0.0	0.0
06/27/2020 22:00	0.0	0.0	0.0	0.0	0.0
06/27/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	5.6 #	14.3 #	0.7 #	4.4 #	1.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	5.6	14.3	0.7	4.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/28/2020 00:00	0.0	0.0	0.0	0.0	0.0
06/28/2020 01:00	0.0	0.0	0.0	0.0	0.0
06/28/2020 02:00	0.0	0.0	0.0	0.0	0.0
06/28/2020 03:00	0.0	0.0	0.0	0.0	0.0
06/28/2020 04:00	0.0	0.0	0.0	0.0	0.0
06/28/2020 05:00	0.0	0.0	0.0	0.0	0.0
06/28/2020 06:00	0.0	0.0	0.0	0.0	0.0
06/28/2020 07:00	0.0	0.0	0.0	0.0	0.0
06/28/2020 08:00	0.0	0.0	0.0	0.0	0.0
06/28/2020 09:00	0.0	0.0	0.0	0.0	0.0
06/28/2020 10:00	0.0	0.0	0.0	0.0	0.0
06/28/2020 11:00	0.0	0.0	0.0	0.0	0.0
06/28/2020 12:00	0.0	0.0	0.0	0.0	0.0
06/28/2020 13:00	0.0	0.0	0.0	0.0	0.0
06/28/2020 14:00	0.0	0.0	0.0	0.0	0.0
06/28/2020 15:00	0.0	0.0	0.0	0.0	0.0
06/28/2020 16:00	0.0	0.0	0.0	0.0	0.0
06/28/2020 17:00	0.0	0.0	0.0	0.0	0.0
06/28/2020 18:00	0.0	0.0	0.0	0.0	0.0
06/28/2020 19:00	0.0	0.0	0.0	0.0	0.0
06/28/2020 20:00	0.0	0.0	0.0	0.0	0.0
06/28/2020 21:00	0.0	0.0	0.0	0.0	0.0
06/28/2020 22:00	0.0	0.0	0.0	0.0	0.0
06/28/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/29/2020 00:00	0.0	0.0	0.0	0.0	0.0
06/29/2020 01:00	0.0	0.0	0.0	0.0	0.0
06/29/2020 02:00	0.0	0.0	0.0	0.0	0.0
06/29/2020 03:00	0.0	0.0	0.0	0.0	0.0
06/29/2020 04:00	0.0	0.0	0.0	0.0	0.0
06/29/2020 05:00	0.0	0.0	0.0	0.0	0.0
06/29/2020 06:00	0.0	0.0	0.0	0.0	0.0
06/29/2020 07:00	0.0	0.0	0.0	0.0	0.0
06/29/2020 08:00	0.0	0.0	0.0	0.0	0.0
06/29/2020 09:00	0.0	0.0	0.0	0.0	0.0
06/29/2020 10:00	0.0	0.0	0.0	0.0	0.0
06/29/2020 11:00	0.0	0.0	0.0	0.0	0.0
06/29/2020 12:00	0.0	0.0	0.0	0.0	0.0
06/29/2020 13:00	0.0	0.0	0.0	0.0	0.0
06/29/2020 14:00	0.0	0.0	0.0	0.0	0.0
06/29/2020 15:00	0.0	0.0	0.0	0.0	0.0
06/29/2020 16:00	0.0	0.0	0.0	0.0	0.0
06/29/2020 17:00	0.0	0.0	0.0	0.0	0.0
06/29/2020 18:00	0.0	0.0	0.0	0.0	0.0
06/29/2020 19:00	0.0	0.0	0.0	0.0	0.0
06/29/2020 20:00	0.0	0.0	0.0	0.0	0.0
06/29/2020 21:00	0.0	0.0	0.0	0.0	0.0
06/29/2020 22:00	0.0	0.0	0.0	0.0	0.0
06/29/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
06/30/2020 00:00	0.0	0.0	0.0	0.0	0.0
06/30/2020 01:00	0.0	0.0	0.0	0.0	0.0
06/30/2020 02:00	0.0	0.0	0.0	0.0	0.0
06/30/2020 03:00	0.0	0.0	0.0	0.0	0.0
06/30/2020 04:00	0.0	0.0	0.0	0.0	0.0
06/30/2020 05:00	0.0	0.0	0.0	0.0	0.0
06/30/2020 06:00	0.0	0.0	0.0	0.0	0.0
06/30/2020 07:00	0.0	0.0	0.0	0.0	0.0
06/30/2020 08:00	30.2	70.2	0.0	0.5	0.1
06/30/2020 09:00	66.0	24.5	0.2	1.5	0.3
06/30/2020 10:00	26.0	30.8	0.2	1.7	0.3
06/30/2020 11:00	51.9	78.8	0.3	2.6	0.5
06/30/2020 12:00	1.4	0.5	0.4	4.1	0.8
06/30/2020 13:00	2.7	0.5	0.4	4.1	0.8
06/30/2020 14:00	51.0	60.4	0.7	5.0	1.0
06/30/2020 15:00	71.6	41.8	0.9	6.2	1.3
06/30/2020 16:00	4.0	0.8	1.3	7.4	1.6
06/30/2020 17:00	6.1	0.9	1.6	8.4	1.8
06/30/2020 18:00	12.2	4.0	2.0	11.2	2.4
06/30/2020 19:00	14.7	3.0	2.1	11.5	2.6
06/30/2020 20:00	14.6	3.3	2.1	11.5	2.6
06/30/2020 21:00	14.5	3.4	2.0	11.4	2.4
06/30/2020 22:00	7.7	15.6	0.6	3.2	0.8
06/30/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	374.6 #	338.5 #	14.8 #	90.3 #	19.3 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	71.6	78.8	2.1	11.5	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Excess Emission Report

CT1 and CT2 CO Lb/Day

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:10 **Location:** Maxwell, CA

Tag Name: ALL_CO_Lb_1D
Total Operating Time: 54.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 37.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**54.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 CO Lb/Hr

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:10 **Location:** Maxwell, CA

Tag Name: ALL_CO_Lb_1H
Total Operating Time: 924.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,260.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**924.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 NOx Lb/Day

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:11 **Location:** Maxwell, CA

Tag Name: ALL_NOx_Lb_1D
Total Operating Time: 54.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 37.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**54.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 NOx Lb/Hr

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:11 **Location:** Maxwell, CA

Tag Name: ALL_NOx_Lb_1H
Total Operating Time: 924.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,260.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**924.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 PM10 Lb/Hr

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:12 **Location:** Maxwell, CA

Tag Name: ALL_PM10_Lb_1H
Total Operating Time: 924.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,260.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**924.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 PM10 Lb/Hr

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:13 **Location:** Maxwell, CA

Tag Name: ALL_PM10_Lb_1H
Total Operating Time: 924.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,260.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**924.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 SO2 Lb/Day

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:13 **Location:** Maxwell, CA

Tag Name: ALL_SO2_Lb_1D
Total Operating Time: 54.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 37.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**54.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 SO2 Lb/Hr

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:14 **Location:** Maxwell, CA

Tag Name: ALL_SO2_Lb_1H
Total Operating Time: 924.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,260.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**924.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 VOC Lb/Day

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:14 **Location:** Maxwell, CA

Tag Name: ALL_VOC_Lb_1D
Total Operating Time: 54.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 37.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**54.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 VOC Lb/Hr

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:15 **Location:** Maxwell, CA

Tag Name: ALL_VOC_Lb_1H
Total Operating Time: 924.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,260.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**924.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 11
CGA/Linearity

FCD: AQ-19
Title V: #13

Linearity Report

ORIS Code: 56298
EDR Site ID: CT1
Facility Name: COLUSA GENERATION
Component ID: A11
Component Type: NOXA
ReasonForTest: QA
Grace Period: 0
Instrument Name: CT1_NOXDualRg_P_Instrume
Test End Date/Time: 04/06/2020
Scale: High
Performance Spec: 5 %
Test No.: 94
Highest Error: 1.8
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
04/06/2020	0625	L	200.0	50.7	49.4		25.4 %
04/06/2020	0631	M	200.0	110.9	111.5		55.5 %
04/06/2020	0637	H	200.0	178.8	180.8		89.4 %
04/06/2020	0646	L	200.0	50.7	49.9		25.4 %
04/06/2020	0652	M	200.0	110.9	111.8		55.5 %
04/06/2020	0658	H	200.0	178.8	180.9		89.4 %
04/06/2020	0706	L	200.0	50.7	50.0		25.4 %
04/06/2020	0712	M	200.0	110.9	111.7		55.5 %
04/06/2020	0718	H	200.0	178.8	181.1		89.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	50.700	49.767	No	**1.8**
M	110.900	111.667	No	**0.7**
H	178.800	180.933	No	**1.2**

Linearity Report

ORIS Code: 56298
EDR Site ID: CT1
Instrument Name: CT1_O2D_P_Instrument
Performance Spec: 5 %

Facility Name: COLUSA GENERATION
Component ID: A12
Component Type: O2D
Test End Date/Time: 04/06/2020
Test No.: 95
Status (Pass/Fail): **Passed**

ReasonForTest: QA
Grace Period: 0
Scale: High
Highest Error: 1.8

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
04/06/2020	0739	L	25.0	5.5	5.4		22.0 %
04/06/2020	0745	M	25.0	13.1	13.0		52.4 %
04/06/2020	0751	H	25.0	21.0	21.0		84.0 %
04/06/2020	0800	L	25.0	5.5	5.4		22.0 %
04/06/2020	0806	M	25.0	13.1	13.0		52.4 %
04/06/2020	0812	H	25.0	21.0	21.0		84.0 %
04/06/2020	0820	L	25.0	5.5	5.4		22.0 %
04/06/2020	0826	M	25.0	13.1	13.0		52.4 %
04/06/2020	0832	H	25.0	21.0	21.0		84.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.400	No	**1.8**
M	13.100	13.000	No	**0.8**
H	21.000	21.000	No	**0.0**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: NOX / Low

Test Date: 04/06/2020
Test Result: **Pass**

Instrument Name: CT1_NOXDualRg_P_Instru
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
04/06/2020	12:26	L	10	2.400	1.700	24.0 %
04/06/2020	12:32	M	10	5.500	5.200	55.0 %
04/06/2020	12:41	L	10	2.400	1.800	24.0 %
04/06/2020	12:47	M	10	5.500	5.300	55.0 %
04/06/2020	12:55	L	10	2.400	1.800	24.0 %
04/06/2020	13:01	M	10	5.500	5.300	55.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.400	1.767	Alt	**0.6**
M	5.500	5.267	Std	**4.2**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: CO / High
Test Date: 04/06/2020
Test Result: **Pass**
Instrument Name: CT1_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
04/06/2020	10:53	L	2000	505.500	478.300	25.3 %
04/06/2020	10:59	M	2000	1139.000	1154.200	57.0 %
04/06/2020	11:08	L	2000	505.500	478.600	25.3 %
04/06/2020	11:14	M	2000	1139.000	1153.900	57.0 %
04/06/2020	11:22	L	2000	505.500	478.600	25.3 %
04/06/2020	11:28	M	2000	1139.000	1155.600	57.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	505.500	478.500	Std	**5.3**
M	1139.000	1154.567	Std	**1.4**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: CO / Low
Test Date: 04/06/2020
Test Result: **Pass**
Instrument Name: CT1_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
04/06/2020	09:41	L	20	4.700	4.400	23.5 %
04/06/2020	09:47	M	20	10.800	10.800	54.0 %
04/06/2020	09:56	L	20	4.700	4.400	23.5 %
04/06/2020	10:02	M	20	10.800	10.800	54.0 %
04/06/2020	10:10	L	20	4.700	4.400	23.5 %
04/06/2020	10:16	M	20	10.800	10.800	54.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	4.700	4.400	Std	**6.4**
M	10.800	10.800	Std	**0.0**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: NOX / High
Test Date: 04/06/2020
Test Result: **Pass**
Instrument Name: CT1_NOXInlet_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
04/06/2020	13:25	L	200	50.700	49.700	25.4 %
04/06/2020	13:31	M	200	110.900	110.300	55.5 %
04/06/2020	13:40	L	200	50.700	50.000	25.4 %
04/06/2020	13:46	M	200	110.900	110.600	55.5 %
04/06/2020	13:54	L	200	50.700	50.100	25.4 %
04/06/2020	14:00	M	200	110.900	110.700	55.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.700	49.933	Std	**1.5**
M	110.900	110.533	Std	**0.3**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: O2D / High

Test Date: 04/06/2020
Test Result: **Pass**

Instrument Name: CT1_O2DInlet_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 0 Pct

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
04/06/2020	14:27	L	25	5.500	5.500	22.0 %
04/06/2020	14:33	M	25	13.100	13.000	52.4 %
04/06/2020	14:42	L	25	5.500	5.500	22.0 %
04/06/2020	14:48	M	25	13.100	13.000	52.4 %
04/06/2020	14:56	L	25	5.500	5.500	22.0 %
04/06/2020	15:02	M	25	13.100	13.000	52.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	5.500	5.500	Std	**0.0**
M	13.100	13.000	Std	**0.8**

Airgas
an Air Liquide company

IN SERVICE 02 APR 2020

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT-1
CV 1

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A42D0	Reference Number:	153-401616319-1
Cylinder Number:	CC160457	Cylinder Volume:	144.4 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72019	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Oct 22, 2019

Expiration Date: Oct 22, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	180.0 PPM	178.8 PPM	G1	+/- 1.1% NIST Traceable	10/15/2019, 10/22/2019
NITRIC OXIDE	180.0 PPM	178.6 PPM	G1	+/- 1.0% NIST Traceable	10/15/2019, 10/22/2019
CARBON MONOXIDE	1150 PPM	1139 PPM	G1	+/- 1.0% NIST Traceable	10/15/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	18060119	KAL004212	249.9 PPM NITRIC OXIDE/NITROGEN	0.4%	Nov 08, 2023
PRM	12376	D562879	10.01 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Aug 17, 2018
GMIS	7302017111	CC511391	4.634 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Aug 15, 2021
NTRM	14060144	CC436645	990.9 PPM CARBON MONOXIDE/NITROGEN	0.6%	Nov 18, 2019

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 CO HCO	FTIR	Sep 26, 2019
Nicolet 6700 AHR0801550 NO MNO	FTIR	Oct 16, 2019
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Oct 17, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

IN SERVICE 02 APR 2020

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT-1
CU2

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI79E15AC046	Reference Number:	153-401669802-1
Cylinder Number:	ALM044425	Cylinder Volume:	146.2 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72019	Valve Outlet:	590
		Certification Date:	Dec 05, 2019

Expiration Date: Dec 05, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	21.00 %	20.99 %	G1	+/- 0.3% NIST Traceable	12/05/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12062019	CC367606	22.883 % OXYGEN/NITROGEN	0.050%	May 14, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Nov 27, 2019

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

Approved for Release

Airgas
an Air Liquide company

IN SERVICE: 21 FEB 20

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT 1
CV 3

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A7635	Reference Number:	153-401536238-1
Cylinder Number:	EB0106619	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72019	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Jul 09, 2019

Expiration Date: Jul 09, 2022

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	9.165 PPM	G1	+/- 1.1% NIST Traceable	07/02/2019, 07/09/2019
NITRIC OXIDE	9.000 PPM	9.072 PPM	G1	+/- 1.1% NIST Traceable	07/02/2019, 07/09/2019
CARBON MONOXIDE	11.00 PPM	10.78 PPM	G1	+/- 0.4% NIST Traceable	07/02/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060719	CC437477	10.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Oct 16, 2022
PRM	12376	D562879	10.01 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Aug 17, 2018
GMIS	7301017103	CC506597	4.451 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Dec 18, 2020
NTRM	15010203	KAL003073	24.35 PPM CARBON MONOXIDE/NITROGEN	0.3%	Sep 04, 2021

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 CO LCO	FTIR	Jun 11, 2019
Nicolet 6700 AHR0801550 NO LNO	FTIR	Jun 12, 2019
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Jun 26, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

IN SERVICE 13 JAN 2026

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

UNIT #1
CV4

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0093	Reference Number:	153-401144291-1
Cylinder Number:	CC268605	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72018	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Mar 12, 2018

Expiration Date: Mar 12, 2026

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	110.0 PPM	110.9 PPM	G1	+/- 1.0% NIST Traceable	03/05/2018, 03/12/2018
NITRIC OXIDE	110.0 PPM	110.7 PPM	G1	+/- 1.0% NIST Traceable	03/05/2018, 03/12/2018
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	13010413	KAL004013	97.6 PPM NITRIC OXIDE/NITROGEN	0.8%	May 09, 2019
PRM	12367	APEX1099237	9.82 PPM NITROGEN DIOXIDE/NITROGEN	1.6%	May 29, 2016
GMIS	1114201604	CC507567	4.955 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Nov 14, 2019

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 NO LNO	FTIR	Mar 07, 2018
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Mar 07, 2018

Triad Data Available Upon Request

Approved for Release

IN SERVICE: 09Jul19 ANLYR #1 CV-5

Airgas

Airgas Specialty Gases
11711 South Alameda Street
Los Angeles, CA 90059
(323) 568-2203 Fax: (323) 567-3686
www.airgas.com

CERTIFICATE OF ANALYSIS
Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0147	Reference Number:	48-124363135-1
Cylinder Number:	CC276685	Cylinder Volume:	144.3 CF
Laboratory:	ASG - Los Angeles - CA	Cylinder Pressure:	2015 PSIG
PGVP Number:	B32013	Valve Outlet:	660
Gas Code:	NO	Certification Date:	Mar 12, 2013

Expiration Date: Mar 12, 2021

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	50.00 PPM	50.71 PPM	G1	+/- 1.2% NIST Traceable	03/05/2013, 03/12/2013
NITRIC OXIDE	50.00 PPM	50.55 PPM	G1	+/- 1.0% NIST Traceable	03/05/2013, 03/12/2013
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12060833	CC283887	49.95 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Dec 16, 2017
PRM	12312	680179	10.01 PPM NITROGEN DIOXIDE/NITROGEN	+/- 2.0%	Feb 14, 2012
GMIS	124208889129	CC323206	4.835 PPM NITROGEN DIOXIDE/NITROGEN	+/-2.0%	Oct 11, 2013

The SRM or PRM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801551 NO	FTIR	Feb 16, 2013
Nicolet 6700 AHR0801551 NO2	FTIR	Mar 07, 2013

Triad Data Available Upon Request

Notes:

Approved for Release

IN SERVICE 08/08/19 ✓

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
11711 S. Alameda Street
Los Angeles, CA 90059
Airgas.com

UNIT 1

CV6

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A42C9	Reference Number:	48-400996728-1
Cylinder Number:	CC185484	Cylinder Volume:	144.3 CF
Laboratory:	124 - Los Angeles (SAP) - CA	Cylinder Pressure:	2015 PSIG
PGVP Number:	B32017	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Sep 22, 2017

Expiration Date: Sep 22, 2020

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	5.500 PPM	5.497 PPM	G1	+/- 1.1% NIST Traceable	09/15/2017, 09/22/2017
NITRIC OXIDE	5.500 PPM	5.360 PPM	G1	+/- 1.2% NIST Traceable	09/15/2017, 09/22/2017
CARBON MONOXIDE	500.0 PPM	505.5 PPM	G1	+/- 0.6% NIST Traceable	09/20/2017
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	103107A	KAL004222	5.08 PPM NITRIC OXIDE/NITROGEN	+/- 1.0%	Jun 02, 2018
NTRM	103107A	KAL004222-NOx	5.08 PPM NOx/NITROGEN	+/- 1.0%	Jun 02, 2018
NTRM	12062427	CC366878	487.1 PPM CARBON MONOXIDE/NITROGEN	+/- 0.6%	Jun 22, 2018

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS 6E CO HIGH	NDIR	Sep 14, 2017
Thermo 42-iLS 1115848421 NO	Chemiluminescence	Aug 31, 2017
Thermo 42-iLS 1115848421 NOx	Chemiluminescence	Aug 31, 2017

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

UNIT 1

CV 7

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A73F4	Reference Number:	153-401144293-1
Cylinder Number:	EB0061551	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72018	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Mar 13, 2018

Expiration Date: Mar 13, 2021

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	2.500 PPM	2.404 PPM	G1	+/- 1.4% NIST Traceable	03/06/2018, 03/13/2018
NITRIC OXIDE	2.500 PPM	2.397 PPM	G1	+/- 1.4% NIST Traceable	03/06/2018, 03/13/2018
CARBON MONOXIDE	4.750 PPM	4.653 PPM	G1	+/- 0.6% NIST Traceable	03/06/2018
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	08012121A	KAL004278	5.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Jun 02, 2018
NTRM	08012121A	KAL004278-NOX	5.08 PPM NOx/NITROGEN	1.0%	Jun 02, 2018
NTRM	1	CC401502	9.766 PPM CARBON MONOXIDE/NITROGEN	0.3	Sep 07, 2018

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Feb 13, 2018
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Feb 22, 2018
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Feb 22, 2018

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

IN SERVICE: 09 Jul 19

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

UNIT #1
CV-8

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI87E15A0080	Reference Number:	153-124604208-1
Cylinder Number:	CC25033	Cylinder Volume:	145.5 CF
Laboratory:	124 - Tooele - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72017	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Feb 20, 2017

Expiration Date: Feb 20, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	13.00 %	13.05 %	G1	+/- 0.7% NIST Traceable	02/20/2017
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	98051014	SG9162888BAL	12.05 % OXYGEN/NITROGEN	0.7%	Dec 02, 2017

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 X9A4UGL8 O2	O2 Paramagnetic (Dixon)	Feb 17, 2017

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

IN SERVICE 13 JAN 2020

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

UNIT #1
CV9

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI94E15AC040	Reference Number:	153-401555373-1
Cylinder Number:	EB0090548	Cylinder Volume:	144.8 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72019	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Jul 26, 2019

Expiration Date: Jul 26, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	5.500 %	5.514 %	G1	+/- 0.4% NIST Traceable	07/26/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	11060717	CC338451	4.861 % OXYGEN/NITROGEN	0.4%	Dec 13, 2022

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Jul 10, 2019

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

Approved for Release

Linearity Report

ORIS Code: 56298
EDR Site ID: CT2
Instrument Name: CT2_O2D_P_Instrument
Performance Spec: 5 %

Facility Name: COLUSA GENERATION
Component ID: A22
Component Type: O2D
Test End Date/Time: 04/06/2020
Test No.: 95
Status (Pass/Fail): **Passed**

ReasonForTest: QA
Grace Period: 0
Scale: High
Highest Error: 0.0

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
04/06/2020	0839	L	25.0	5.5	5.5		22.0 %
04/06/2020	0845	M	25.0	13.0	13.0		52.0 %
04/06/2020	0851	H	25.0	21.0	21.0		84.0 %
04/06/2020	0900	L	25.0	5.5	5.5		22.0 %
04/06/2020	0906	M	25.0	13.0	13.0		52.0 %
04/06/2020	0912	H	25.0	21.0	21.0		84.0 %
04/06/2020	0920	L	25.0	5.5	5.5		22.0 %
04/06/2020	0926	M	25.0	13.0	13.0		52.0 %
04/06/2020	0932	H	25.0	21.0	21.0		84.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.500	No	**0.0**
M	13.000	13.000	No	**0.0**
H	21.000	21.000	No	**0.0**

Linearity Report

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT2	Component ID:	A21	ReasonForTest:	QA
		Component Type:	NOXA	Grace Period:	0
Instrument Name:	CT2_NOXDualRg_P_Instrume	Test End Date/Time:	04/06/2020	Scale:	High
Performance Spec:	5 %	Test No.:	94	Highest Error:	1.6
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
04/06/2020	0726	L	200.0	51.2	50.2		25.6 %
04/06/2020	0732	M	200.0	110.4	109.7		55.2 %
04/06/2020	0738	H	200.0	178.6	178.5		89.3 %
04/06/2020	0747	L	200.0	51.2	50.5		25.6 %
04/06/2020	0753	M	200.0	110.4	109.7		55.2 %
04/06/2020	0759	H	200.0	178.6	178.1		89.3 %
04/06/2020	0807	L	200.0	51.2	50.4		25.6 %
04/06/2020	0813	M	200.0	110.4	109.9		55.2 %
04/06/2020	0819	H	200.0	178.6	178.1		89.3 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.200	50.367	No	**1.6**
M	110.400	109.767	No	**0.6**
H	178.600	178.233	No	**0.2**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: CO / High
Test Date: 04/06/2020
Test Result: **Pass**
Instrument Name: CT2_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
04/06/2020	11:30	L	2000	500.500	496.900	25.0 %
04/06/2020	11:36	M	2000	1140.000	1152.500	57.0 %
04/06/2020	11:45	L	2000	500.500	497.200	25.0 %
04/06/2020	11:51	M	2000	1140.000	1151.900	57.0 %
04/06/2020	11:59	L	2000	500.500	497.200	25.0 %
04/06/2020	12:05	M	2000	1140.000	1151.900	57.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	500.500	497.100	Std	**0.7**
M	1140.000	1152.100	Std	**1.1**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: NOX / Low
Test Date: 04/06/2020
Test Result: **Pass**
Instrument Name: CT2_NOXDualRg_P_Instru
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
04/06/2020	12:25	L	10	2.500	2.200	25.0 %
04/06/2020	12:31	M	10	5.200	4.700	52.0 %
04/06/2020	12:40	L	10	2.500	2.200	25.0 %
04/06/2020	12:46	M	10	5.200	4.800	52.0 %
04/06/2020	12:54	L	10	2.500	2.200	25.0 %
04/06/2020	13:00	M	10	5.200	4.800	52.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.500	2.200	Std	**12.0**
M	5.200	4.767	Std	**8.3**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: NOX / High
Test Date: 04/06/2020
Test Result: **Pass**
Instrument Name: CT2_NOXInlet_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
04/06/2020	13:24	L	200	51.200	50.000	25.6 %
04/06/2020	13:30	M	200	110.400	109.500	55.2 %
04/06/2020	13:39	L	200	51.200	50.300	25.6 %
04/06/2020	13:45	M	200	110.400	109.600	55.2 %
04/06/2020	13:53	L	200	51.200	50.400	25.6 %
04/06/2020	13:59	M	200	110.400	109.600	55.2 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	51.200	50.233	Std	**1.9**
M	110.400	109.567	Std	**0.8**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: O2D / High
Test Date: 04/06/2020
Test Result: **Pass**
Instrument Name: CT2_O2DInlet_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 0 Pct

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
04/06/2020	14:25	L	25	5.500	5.500	22.0 %
04/06/2020	14:31	M	25	13.000	13.000	52.0 %
04/06/2020	14:40	L	25	5.500	5.500	22.0 %
04/06/2020	14:46	M	25	13.000	13.000	52.0 %
04/06/2020	14:54	L	25	5.500	5.500	22.0 %
04/06/2020	15:00	M	25	13.000	13.000	52.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	5.500	5.500	Std	**0.0**
M	13.000	13.000	Std	**0.0**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: CO / Low
Test Date: 04/06/2020
Test Result: **Pass**
Instrument Name: CT2_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
04/06/2020	10:24	L	20	4.600	4.100	23.0 %
04/06/2020	10:30	M	20	11.000	10.900	55.0 %
04/06/2020	10:39	L	20	4.600	4.100	23.0 %
04/06/2020	10:45	M	20	11.000	10.900	55.0 %
04/06/2020	10:53	L	20	4.600	4.100	23.0 %
04/06/2020	10:59	M	20	11.000	10.900	55.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	4.600	4.100	Std	**10.9**
M	11.000	10.900	Std	**0.9**

Airgas
an Air Liquide company

IN SERVICE: 19 MAR 2020

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT-2
CV-1

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A42D0	Reference Number:	153-401616319-1
Cylinder Number:	ALM056901	Cylinder Volume:	144.4 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72019	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Oct 22, 2019

Expiration Date: Oct 22, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	180.0 PPM	178.6 PPM	G1	+/- 0.7% NIST Traceable	10/15/2019, 10/22/2019
NITRIC OXIDE	180.0 PPM	178.5 PPM	G1	+/- 0.7% NIST Traceable	10/15/2019, 10/22/2019
CARBON MONOXIDE	1150 PPM	1140 PPM	G1	+/- 1.1% NIST Traceable	10/15/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	18060119	KAL004212	249.9 PPM NITRIC OXIDE/NITROGEN	0.4%	Nov 08, 2023
PRM	12376	D562879	10.01 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Aug 17, 2018
GMIS	7302017111	CC511391	4.634 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Aug 15, 2021
NTRM	14060144	CC436645	990.9 PPM CARBON MONOXIDE/NITROGEN	0.6%	Nov 18, 2019

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 CO HCO	FTIR	Sep 26, 2019
Nicolet 6700 AHR0801550 NO MNO	FTIR	Oct 16, 2019
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Oct 17, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

IN SERVICE 30 MAR 20 8

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT 2
CV 2

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI79E15AC046	Reference Number:	153-401617761-1
Cylinder Number:	CC708674	Cylinder Volume:	146.2 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72019	Valve Outlet:	590
		Certification Date:	Oct 08, 2019

Expiration Date: Oct 08, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	21.00 %	21.00 %	G1	+/- 0.2% NIST Traceable	10/08/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12062019	CC367606	22.883 % OXYGEN/NITROGEN	0.050%	May 14, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Oct 03, 2019

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

mlmd

Approved for Release

Airgas
an Air Liquide company

IN SERVICE: 05 MAR 2020

Airgas Specialty Gases
Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT-2
CV-3

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A7635	Reference Number:	153-401438611-1
Cylinder Number:	CC465063	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72019	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Mar 12, 2019

Expiration Date: Mar 12, 2022

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	9.149 PPM	G1	+/- 1.3% NIST Traceable	03/05/2019, 03/12/2019
NITRIC OXIDE	9.000 PPM	9.121 PPM	G1	+/- 1.3% NIST Traceable	03/05/2019, 03/12/2019
CARBON MONOXIDE	11.00 PPM	11.03 PPM	G1	+/- 1.0% NIST Traceable	03/05/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060733	CC465060	10.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Oct 16, 2022
PRM	12376	D562879	10.01 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Aug 17, 2018
GMIS	7301017103	CC506597	4.451 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Dec 18, 2020
NTRM	08011130	KAL004049	9.855 PPM CARBON MONOXIDE/NITROGEN	0.5%	Jun 05, 2024

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 CO LCO	FTIR	Feb 28, 2019
Nicolet 6700 AHR0801550 NO LNO	FTIR	Feb 20, 2019
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Mar 06, 2019

Triad Data Available Upon Request

Approved for Release

IN SERVICE 03 APR 2020

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT2 - CV4

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0093	Reference Number:	153-400996726-1
Cylinder Number:	CC205834	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72017	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Sep 19, 2017

Expiration Date: Sep 19, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	110.0 PPM	110.4 PPM	G1	+/- 1.0% NIST Traceable	09/12/2017, 09/19/2017
NITRIC OXIDE	110.0 PPM	110.2 PPM	G1	+/- 1.0% NIST Traceable	09/12/2017, 09/19/2017
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	13010428	KAL004053	97.6 PPM NITRIC OXIDE/NITROGEN	0.8	May 09, 2019
PRM	12367	APEX1099237	10.00 PPM NITROGEN DIOXIDE/NITROGEN	1.6%	May 29, 2016
GMIS	1114201604	CC507567	4.955 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Nov 14, 2019

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 NO LNO	FTIR	Sep 07, 2017
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Sep 07, 2017

Triad Data Available Upon Request

Approved for Release

IN SERVICE 07/01/19

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT2

CV5

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0147	Reference Number:	153-400996727-1
Cylinder Number:	CC254020	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72017	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Sep 19, 2017

Expiration Date: Sep 19, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	50.00 PPM	51.16 PPM	G1	+/- 1.2% NIST Traceable	09/12/2017, 09/19/2017
NITRIC OXIDE	50.00 PPM	51.12 PPM	G1	+/- 1.2% NIST Traceable	09/12/2017, 09/19/2017
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060632	CC442611	50.42 PPM NITRIC OXIDE/NITROGEN	0.8%	May 27, 2020
PRM	12367	APEX1099237	10.00 PPM NITROGEN DIOXIDE/NITROGEN	1.6%	May 29, 2016
GMIS	1114201604	CC507567	4.955 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Nov 14, 2019

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 NO LNO	FTIR	Sep 07, 2017
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Sep 07, 2017

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

Airgas USA, LLC
11711 S. Alameda Street
Los Angeles, CA 90059
Airgas.com

CT 2
CV Le

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A42C9	Reference Number:	48-401198488-1
Cylinder Number:	CC437300	Cylinder Volume:	128.9 CF
Laboratory:	124 - Los Angeles (SAP) - CA	Cylinder Pressure:	1800 PSIG
PGVP Number:	B32018	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	May 18, 2018

Expiration Date: May 18, 2021

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	5.500 PPM	5.207 PPM	G1	+/- 1.4% NIST Traceable	05/18/2018
NITRIC OXIDE	5.500 PPM	4.934 PPM	G1	+/- 1.2% NIST Traceable	05/18/2018
CARBON MONOXIDE	500.0 PPM	500.5 PPM	G1	+/- 0.7% NIST Traceable	05/10/2018
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	103107A	KAL004222	5.08 PPM NITRIC OXIDE/NITROGEN	+/- 1.0%	Jun 02, 2018
NTRM	103107A	KAL004222-NOx	5.08 PPM NOx/NITROGEN	+/- 1.0%	Jun 02, 2018
NTRM	12062427	CC366878	487.1 PPM CARBON MONOXIDE/NITROGEN	+/- 0.6%	Jun 22, 2018

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS 6E CO HIGH	NDIR	Apr 23, 2018
Thermo 42-iLS 1115848421 NO	Chemiluminescence	Apr 24, 2018
Thermo 42-iLS 1115848421 NOx	Chemiluminescence	Apr 24, 2018

Triad Data Available Upon Request

Approved for Release

IN SERVICE: 03 APR 2020

Airgas
an Air Liquide company

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

< T 2
< V 7

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A73F4	Reference Number:	153-401707981-1
Cylinder Number:	CC472917	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72020	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Jan 28, 2020

Expiration Date: Jan 28, 2023

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	2.500 PPM	2.507 PPM	G1	+/- 1.3% NIST Traceable	01/21/2020, 01/28/2020
NITRIC OXIDE	2.500 PPM	2.502 PPM	G1	+/- 1.4% NIST Traceable	01/21/2020, 01/28/2020
CARBON MONOXIDE	4.750 PPM	4.637 PPM	G1	+/- 0.6% NIST Traceable	01/21/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	08012121A	KAL004278	5.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Jun 05, 2021
NTRM	08012126	KAL004291	5.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Jul 05, 2021
NTRM	08012121A	KAL004278-NOX	5.08 PPM NOx/NITROGEN	1.0%	Jun 05, 2021
NTRM	08012126	KAL004291-NOX	5.08 PPM NOx/NITROGEN	1.0%	Jul 05, 2021
NTRM	08011130	KAL004049	9.855 PPM CARBON MONOXIDE/NITROGEN	0.5%	Jun 05, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Jan 06, 2020
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Jan 16, 2020
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Jan 16, 2020

Triad Data Available Upon Request

Approved for Release

In Service: 9 April 19

Airgas
an Air Liquide company

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT 2
CV 8

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI87E15A0080	Reference Number:	153-124618307-1
Cylinder Number:	CC420243	Cylinder Volume:	145.5 CF
Laboratory:	124 - Tooele - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72017	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	May 09, 2017

Expiration Date: May 09, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	13.00 %	13.04 %	G1	+/- 0.7% NIST Traceable	05/09/2017
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	98051014	SG9162888BAL	12.05 % OXYGEN/NITROGEN	0.7%	Dec 02, 2017

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 X9A4UGL8 O2	O2 Paramagnetic (Dixon)	Apr 12, 2017

Triad Data Available Upon Request

Approved for Release

IN SERVICE 03 APR 2020

Airgas
an Air Liquide company

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT.2
CV.9

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI94E15AC040	Reference Number:	153-401707983-1
Cylinder Number:	CC54718	Cylinder Volume:	144.8 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72020	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Jan 21, 2020

Expiration Date: Jan 21, 2028

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	5.500 %	5.507 %	G1	+/- 0.6% NIST Traceable	01/21/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	11060717	CC338451	4.861 % OXYGEN/NITROGEN	0.4%	Dec 13, 2022

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Dec 30, 2019

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

NOTES:NO: 0.001 PPM
CO: 0.001 PPM
CO2: 0.001 PPM

Approved for Release

ATTACHMENT 12
Startup/Shutdown Emissions

FCD: AQ-22
Title V: #13, #14

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 671.97 Hours

Non-Operating Time: 1,512.03 Hours Report Time: 2,184.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
04/01/2020 03:43 04/01/2020 04:54 Warm Start - Gas	72	128.9		
04/02/2020 21:22 04/02/2020 21:27 Shut Down - Gas	6	1.4		
04/04/2020 01:04 04/04/2020 02:38 Warm Start - Gas	95	158.8		
04/17/2020 23:23 04/17/2020 23:28 Shut Down - Gas	6	1.8		
04/20/2020 02:03 04/20/2020 03:42 Warm Start - Gas	100	176.1		
04/20/2020 23:08 04/20/2020 23:13 Shut Down - Gas	6	1.3		
04/22/2020 07:37 04/22/2020 09:16 Warm Start - Gas	100	170.9		
04/22/2020 11:02 04/22/2020 11:07 Shut Down - Gas	6	1.7		
04/24/2020 14:18 04/24/2020 16:04 Warm Start - Gas	107	188.3		
04/24/2020 22:07 04/24/2020 22:13 Shut Down - Gas	7	2.4		
04/28/2020 13:20 04/28/2020 15:01 Cold Start - Gas	102	176.7		
04/28/2020 21:54 04/28/2020 21:59 Shut Down - Gas	6	1.3		
05/26/2020 10:08 05/26/2020 10:29 Cold Start - Gas	22	120.9		

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 671.97 Hours

Non-Operating Time: 1,512.03 Hours Report Time: 2,184.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
05/26/2020 10:30 05/26/2020 10:35 Shut Down - Gas	6	32.9		
05/26/2020 11:53 05/26/2020 15:12 Cold Start - Gas	200	1,112.6		
05/26/2020 15:14 05/26/2020 15:19 Shut Down - Gas	6	33.5		
05/28/2020 12:38 05/28/2020 15:23 Cold Start - Gas	166	930.1		
05/29/2020 01:38 05/29/2020 01:43 Shut Down - Gas	6	33.6		
06/01/2020 12:48 06/01/2020 13:37 Cold Start - Gas	50	274.8		
06/01/2020 13:38 06/01/2020 13:43 Shut Down - Gas	6	33.0		
06/01/2020 14:22 06/01/2020 14:57 Cold Start - Gas	36	200.6		
06/04/2020 00:23 06/04/2020 00:28 Shut Down - Gas	6	33.6		
06/04/2020 06:41 06/04/2020 07:54 Hot Start - Gas	74	415.5		
06/05/2020 00:26 06/05/2020 00:31 Shut Down - Gas	6	32.7		
06/08/2020 15:29 06/08/2020 17:00 Cold Start - Gas	92	514.1		
06/08/2020 17:02 06/08/2020 17:07 Shut Down - Gas	6	33.6		
06/08/2020 17:45 06/08/2020 18:24 Hot Start - Gas	40	247.5		

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 671.97 Hours

Non-Operating Time: 1,512.03 Hours Report Time: 2,184.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
06/08/2020 23:54 06/08/2020 23:58 Shut Down - Gas	5	28.0		
06/09/2020 12:36 06/09/2020 13:16 Warm Start - Gas	41	223.1		
06/09/2020 13:18 06/09/2020 13:23 Shut Down - Gas	6	32.6		
06/09/2020 14:09 06/09/2020 15:02 Warm Start - Gas	54	316.1		
06/09/2020 23:22 06/09/2020 23:27 Shut Down - Gas	6	33.6		
06/10/2020 10:18 06/10/2020 12:14 Warm Start - Gas	117	686.6		
06/11/2020 23:23 06/11/2020 23:28 Shut Down - Gas	6	33.6		
06/17/2020 12:38 06/17/2020 15:52 Cold Start - Gas	195	1,119.0		
06/17/2020 23:24 06/17/2020 23:29 Shut Down - Gas	6	33.6		
06/18/2020 11:33 06/18/2020 12:40 Warm Start - Gas	68	374.8		
06/18/2020 23:09 06/18/2020 23:14 Shut Down - Gas	6	33.6		
06/22/2020 09:24 06/22/2020 10:01 Cold Start - Gas	38	207.8		
06/22/2020 10:02 06/22/2020 10:07 Shut Down - Gas	6	33.1		
06/22/2020 10:49 06/22/2020 12:13 Cold Start - Gas	85	474.4		

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 671.97 Hours

Non-Operating Time: 1,512.03 Hours Report Time: 2,184.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
06/23/2020 00:23 06/23/2020 00:28 Shut Down - Gas	6	38.7		
06/23/2020 07:52 06/23/2020 09:06 Hot Start - Gas	75	140.3		
06/25/2020 00:31 06/25/2020 00:36 Shut Down - Gas	6	1.3		
06/25/2020 12:47 06/25/2020 13:40 Warm Start - Gas	54	99.7		
06/25/2020 22:38 06/25/2020 22:43 Shut Down - Gas	6	2.1		
06/26/2020 10:48 06/26/2020 11:46 Warm Start - Gas	59	110.8		
06/26/2020 12:01 06/26/2020 12:07 Shut Down - Gas	7	2.2		
06/26/2020 16:22 06/26/2020 17:16 Hot Start - Gas	55	95.9		
06/27/2020 00:39 06/27/2020 00:44 Shut Down - Gas	6	1.8		
06/30/2020 14:28 06/30/2020 15:59 Cold Start - Gas	92	158.6		
06/30/2020 22:23 06/30/2020 22:28 Shut Down - Gas	6	2.1		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 671.97 Hours

Non-Operating Time: 1,512.03 Hours Report Time: 2,184.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 671.97 Hours

Non-Operating Time: 1,512.03 Hours Report Time: 2,184.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/01/2020 00:00	0.0	0	0	0	0	0
04/01/2020 01:00	0.0	0	0	0	0	0
04/01/2020 02:00	0.0	0	0	0	0	0
04/01/2020 03:00	34.7	0	1	0	0	0
04/01/2020 04:00	44.7	0	1	0	0	0
04/01/2020 05:00	0.0	0	0	0	0	1
04/01/2020 06:00	0.0	0	0	0	0	1
04/01/2020 07:00	0.0	0	0	0	0	1
04/01/2020 08:00	0.0	0	0	0	0	1
04/01/2020 09:00	0.0	0	0	0	0	1
04/01/2020 10:00	0.0	0	0	0	0	1
04/01/2020 11:00	0.0	0	0	0	0	1
04/01/2020 12:00	0.0	0	0	0	0	1
04/01/2020 13:00	0.0	0	0	0	0	1
04/01/2020 14:00	0.0	0	0	0	0	1
04/01/2020 15:00	0.0	0	0	0	0	1
04/01/2020 16:00	0.0	0	0	0	0	1
04/01/2020 17:00	0.0	0	0	0	0	1
04/01/2020 18:00	0.0	0	0	0	0	1
04/01/2020 19:00	0.0	0	0	0	0	1
04/01/2020 20:00	0.0	0	0	0	0	1
04/01/2020 21:00	0.0	0	0	0	0	1
04/01/2020 22:00	0.0	0	0	0	0	1
04/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	79.4 #	0 #	2 #	0 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	44.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/02/2020 00:00	0.0	0	0	0	0	1
04/02/2020 01:00	0.0	0	0	0	0	1
04/02/2020 02:00	0.0	0	0	0	0	1
04/02/2020 03:00	0.0	0	0	0	0	1
04/02/2020 04:00	0.0	0	0	0	0	1
04/02/2020 05:00	0.0	0	0	0	0	1
04/02/2020 06:00	0.0	0	0	0	0	1
04/02/2020 07:00	0.0	0	0	0	0	1
04/02/2020 08:00	0.0	0	0	0	0	1
04/02/2020 09:00	0.0	0	0	0	0	1
04/02/2020 10:00	0.0	0	0	0	0	1
04/02/2020 11:00	0.0	0	0	0	0	1
04/02/2020 12:00	0.0	0	0	0	0	1
04/02/2020 13:00	0.0	0	0	0	0	1
04/02/2020 14:00	0.0	0	0	0	0	1
04/02/2020 15:00	0.0	0	0	0	0	1
04/02/2020 16:00	0.0	0	0	0	0	1
04/02/2020 17:00	0.0	0	0	0	0	1
04/02/2020 18:00	0.0	0	0	0	0	1
04/02/2020 19:00	0.0	0	0	0	0	1
04/02/2020 20:00	0.0	0	0	0	0	1
04/02/2020 21:00	1.5	0	0	0	1	0
04/02/2020 22:00	0.0	0	0	0	0	0
04/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.5 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/03/2020 00:00	0.0	0	0	0	0	0
04/03/2020 01:00	0.0	0	0	0	0	0
04/03/2020 02:00	0.0	0	0	0	0	0
04/03/2020 03:00	0.0	0	0	0	0	0
04/03/2020 04:00	0.0	0	0	0	0	0
04/03/2020 05:00	0.0	0	0	0	0	0
04/03/2020 06:00	0.0	0	0	0	0	0
04/03/2020 07:00	0.0	0	0	0	0	0
04/03/2020 08:00	0.0	0	0	0	0	0
04/03/2020 09:00	0.0	0	0	0	0	0
04/03/2020 10:00	0.0	0	0	0	0	0
04/03/2020 11:00	0.0	0	0	0	0	0
04/03/2020 12:00	0.0	0	0	0	0	0
04/03/2020 13:00	0.0	0	0	0	0	0
04/03/2020 14:00	0.0	0	0	0	0	0
04/03/2020 15:00	0.0	0	0	0	0	0
04/03/2020 16:00	0.0	0	0	0	0	0
04/03/2020 17:00	0.0	0	0	0	0	0
04/03/2020 18:00	0.0	0	0	0	0	0
04/03/2020 19:00	0.0	0	0	0	0	0
04/03/2020 20:00	0.0	0	0	0	0	0
04/03/2020 21:00	0.0	0	0	0	0	0
04/03/2020 22:00	0.0	0	0	0	0	0
04/03/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/04/2020 00:00	0.0	0	0	0	0	0
04/04/2020 01:00	66.4	0	1	0	0	0
04/04/2020 02:00	22.8	0	1	0	0	0
04/04/2020 03:00	0.0	0	0	0	0	1
04/04/2020 04:00	0.0	0	0	0	0	1
04/04/2020 05:00	0.0	0	0	0	0	1
04/04/2020 06:00	0.0	0	0	0	0	1
04/04/2020 07:00	0.0	0	0	0	0	1
04/04/2020 08:00	0.0	0	0	0	0	1
04/04/2020 09:00	0.0	0	0	0	0	1
04/04/2020 10:00	0.0	0	0	0	0	1
04/04/2020 11:00	0.0	0	0	0	0	1
04/04/2020 12:00	0.0	0	0	0	0	1
04/04/2020 13:00	0.0	0	0	0	0	1
04/04/2020 14:00	0.0	0	0	0	0	1
04/04/2020 15:00	0.0	0	0	0	0	1
04/04/2020 16:00	0.0	0	0	0	0	1
04/04/2020 17:00	0.0	0	0	0	0	1
04/04/2020 18:00	0.0	0	0	0	0	1
04/04/2020 19:00	0.0	0	0	0	0	1
04/04/2020 20:00	0.0	0	0	0	0	1
04/04/2020 21:00	0.0	0	0	0	0	1
04/04/2020 22:00	0.0	0	0	0	0	1
04/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	89.2 #	0 #	2 #	0 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	66.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/05/2020 00:00	0.0	0	0	0	0	1
04/05/2020 01:00	0.0	0	0	0	0	1
04/05/2020 02:00	0.0	0	0	0	0	1
04/05/2020 03:00	0.0	0	0	0	0	1
04/05/2020 04:00	0.0	0	0	0	0	1
04/05/2020 05:00	0.0	0	0	0	0	1
04/05/2020 06:00	0.0	0	0	0	0	1
04/05/2020 07:00	0.0	0	0	0	0	1
04/05/2020 08:00	0.0	0	0	0	0	1
04/05/2020 09:00	0.0	0	0	0	0	1
04/05/2020 10:00	0.0	0	0	0	0	1
04/05/2020 11:00	0.0	0	0	0	0	1
04/05/2020 12:00	0.0	0	0	0	0	1
04/05/2020 13:00	0.0	0	0	0	0	1
04/05/2020 14:00	0.0	0	0	0	0	1
04/05/2020 15:00	0.0	0	0	0	0	1
04/05/2020 16:00	0.0	0	0	0	0	1
04/05/2020 17:00	0.0	0	0	0	0	1
04/05/2020 18:00	0.0	0	0	0	0	1
04/05/2020 19:00	0.0	0	0	0	0	1
04/05/2020 20:00	0.0	0	0	0	0	1
04/05/2020 21:00	0.0	0	0	0	0	1
04/05/2020 22:00	0.0	0	0	0	0	1
04/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/06/2020 00:00	0.0	0	0	0	0	1
04/06/2020 01:00	0.0	0	0	0	0	1
04/06/2020 02:00	0.0	0	0	0	0	1
04/06/2020 03:00	0.0	0	0	0	0	1
04/06/2020 04:00	0.0	0	0	0	0	1
04/06/2020 05:00	0.0	0	0	0	0	1
04/06/2020 06:00	0.0	0	0	0	0	1
04/06/2020 07:00	0.0	0	0	0	0	1
04/06/2020 08:00	0.0	0	0	0	0	1
04/06/2020 09:00	0.0	0	0	0	0	1
04/06/2020 10:00	0.0	0	0	0	0	1
04/06/2020 11:00	0.0	0	0	0	0	1
04/06/2020 12:00	0.0	0	0	0	0	1
04/06/2020 13:00	0.0	0	0	0	0	1
04/06/2020 14:00	0.0	0	0	0	0	1
04/06/2020 15:00	0.0	0	0	0	0	1
04/06/2020 16:00	0.0	0	0	0	0	1
04/06/2020 17:00	0.0	0	0	0	0	1
04/06/2020 18:00	0.0	0	0	0	0	1
04/06/2020 19:00	0.0	0	0	0	0	1
04/06/2020 20:00	0.0	0	0	0	0	1
04/06/2020 21:00	0.0	0	0	0	0	1
04/06/2020 22:00	0.0	0	0	0	0	1
04/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/07/2020 00:00	0.0	0	0	0	0	1
04/07/2020 01:00	0.0	0	0	0	0	1
04/07/2020 02:00	0.0	0	0	0	0	1
04/07/2020 03:00	0.0	0	0	0	0	1
04/07/2020 04:00	0.0	0	0	0	0	1
04/07/2020 05:00	0.0	0	0	0	0	1
04/07/2020 06:00	0.0	0	0	0	0	1
04/07/2020 07:00	0.0	0	0	0	0	1
04/07/2020 08:00	0.0	0	0	0	0	1
04/07/2020 09:00	0.0	0	0	0	0	1
04/07/2020 10:00	0.0	0	0	0	0	1
04/07/2020 11:00	0.0	0	0	0	0	1
04/07/2020 12:00	0.0	0	0	0	0	1
04/07/2020 13:00	0.0	0	0	0	0	1
04/07/2020 14:00	0.0	0	0	0	0	1
04/07/2020 15:00	0.0	0	0	0	0	1
04/07/2020 16:00	0.0	0	0	0	0	1
04/07/2020 17:00	0.0	0	0	0	0	1
04/07/2020 18:00	0.0	0	0	0	0	1
04/07/2020 19:00	0.0	0	0	0	0	1
04/07/2020 20:00	0.0	0	0	0	0	1
04/07/2020 21:00	0.0	0	0	0	0	1
04/07/2020 22:00	0.0	0	0	0	0	1
04/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/08/2020 00:00	0.0	0	0	0	0	1
04/08/2020 01:00	0.0	0	0	0	0	1
04/08/2020 02:00	0.0	0	0	0	0	1
04/08/2020 03:00	0.0	0	0	0	0	1
04/08/2020 04:00	0.0	0	0	0	0	1
04/08/2020 05:00	0.0	0	0	0	0	1
04/08/2020 06:00	0.0	0	0	0	0	1
04/08/2020 07:00	0.0	0	0	0	0	1
04/08/2020 08:00	0.0	0	0	0	0	1
04/08/2020 09:00	0.0	0	0	0	0	1
04/08/2020 10:00	0.0	0	0	0	0	1
04/08/2020 11:00	0.0	0	0	0	0	1
04/08/2020 12:00	0.0	0	0	0	0	1
04/08/2020 13:00	0.0	0	0	0	0	1
04/08/2020 14:00	0.0	0	0	0	0	1
04/08/2020 15:00	0.0	0	0	0	0	1
04/08/2020 16:00	0.0	0	0	0	0	1
04/08/2020 17:00	0.0	0	0	0	0	1
04/08/2020 18:00	0.0	0	0	0	0	1
04/08/2020 19:00	0.0	0	0	0	0	1
04/08/2020 20:00	0.0	0	0	0	0	1
04/08/2020 21:00	0.0	0	0	0	0	1
04/08/2020 22:00	0.0	0	0	0	0	1
04/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/09/2020 00:00	0.0	0	0	0	0	1
04/09/2020 01:00	0.0	0	0	0	0	1
04/09/2020 02:00	0.0	0	0	0	0	1
04/09/2020 03:00	0.0	0	0	0	0	1
04/09/2020 04:00	0.0	0	0	0	0	1
04/09/2020 05:00	0.0	0	0	0	0	1
04/09/2020 06:00	0.0	0	0	0	0	1
04/09/2020 07:00	0.0	0	0	0	0	1
04/09/2020 08:00	0.0	0	0	0	0	1
04/09/2020 09:00	0.0	0	0	0	0	1
04/09/2020 10:00	0.0	0	0	0	0	1
04/09/2020 11:00	0.0	0	0	0	0	1
04/09/2020 12:00	0.0	0	0	0	0	1
04/09/2020 13:00	0.0	0	0	0	0	1
04/09/2020 14:00	0.0	0	0	0	0	1
04/09/2020 15:00	0.0	0	0	0	0	1
04/09/2020 16:00	0.0	0	0	0	0	1
04/09/2020 17:00	0.0	0	0	0	0	1
04/09/2020 18:00	0.0	0	0	0	0	1
04/09/2020 19:00	0.0	0	0	0	0	1
04/09/2020 20:00	0.0	0	0	0	0	1
04/09/2020 21:00	0.0	0	0	0	0	1
04/09/2020 22:00	0.0	0	0	0	0	1
04/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/10/2020 00:00	0.0	0	0	0	0	1
04/10/2020 01:00	0.0	0	0	0	0	1
04/10/2020 02:00	0.0	0	0	0	0	1
04/10/2020 03:00	0.0	0	0	0	0	1
04/10/2020 04:00	0.0	0	0	0	0	1
04/10/2020 05:00	0.0	0	0	0	0	1
04/10/2020 06:00	0.0	0	0	0	0	1
04/10/2020 07:00	0.0	0	0	0	0	1
04/10/2020 08:00	0.0	0	0	0	0	1
04/10/2020 09:00	0.0	0	0	0	0	1
04/10/2020 10:00	0.0	0	0	0	0	1
04/10/2020 11:00	0.0	0	0	0	0	1
04/10/2020 12:00	0.0	0	0	0	0	1
04/10/2020 13:00	0.0	0	0	0	0	1
04/10/2020 14:00	0.0	0	0	0	0	1
04/10/2020 15:00	0.0	0	0	0	0	1
04/10/2020 16:00	0.0	0	0	0	0	1
04/10/2020 17:00	0.0	0	0	0	0	1
04/10/2020 18:00	0.0	0	0	0	0	1
04/10/2020 19:00	0.0	0	0	0	0	1
04/10/2020 20:00	0.0	0	0	0	0	1
04/10/2020 21:00	0.0	0	0	0	0	1
04/10/2020 22:00	0.0	0	0	0	0	1
04/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/11/2020 00:00	0.0	0	0	0	0	1
04/11/2020 01:00	0.0	0	0	0	0	1
04/11/2020 02:00	0.0	0	0	0	0	1
04/11/2020 03:00	0.0	0	0	0	0	1
04/11/2020 04:00	0.0	0	0	0	0	1
04/11/2020 05:00	0.0	0	0	0	0	1
04/11/2020 06:00	0.0	0	0	0	0	1
04/11/2020 07:00	0.0	0	0	0	0	1
04/11/2020 08:00	0.0	0	0	0	0	1
04/11/2020 09:00	0.0	0	0	0	0	1
04/11/2020 10:00	0.0	0	0	0	0	1
04/11/2020 11:00	0.0	0	0	0	0	1
04/11/2020 12:00	0.0	0	0	0	0	1
04/11/2020 13:00	0.0	0	0	0	0	1
04/11/2020 14:00	0.0	0	0	0	0	1
04/11/2020 15:00	0.0	0	0	0	0	1
04/11/2020 16:00	0.0	0	0	0	0	1
04/11/2020 17:00	0.0	0	0	0	0	1
04/11/2020 18:00	0.0	0	0	0	0	1
04/11/2020 19:00	0.0	0	0	0	0	1
04/11/2020 20:00	0.0	0	0	0	0	1
04/11/2020 21:00	0.0	0	0	0	0	1
04/11/2020 22:00	0.0	0	0	0	0	1
04/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/12/2020 00:00	0.0	0	0	0	0	1
04/12/2020 01:00	0.0	0	0	0	0	1
04/12/2020 02:00	0.0	0	0	0	0	1
04/12/2020 03:00	0.0	0	0	0	0	1
04/12/2020 04:00	0.0	0	0	0	0	1
04/12/2020 05:00	0.0	0	0	0	0	1
04/12/2020 06:00	0.0	0	0	0	0	1
04/12/2020 07:00	0.0	0	0	0	0	1
04/12/2020 08:00	0.0	0	0	0	0	1
04/12/2020 09:00	0.0	0	0	0	0	1
04/12/2020 10:00	0.0	0	0	0	0	1
04/12/2020 11:00	0.0	0	0	0	0	1
04/12/2020 12:00	0.0	0	0	0	0	1
04/12/2020 13:00	0.0	0	0	0	0	1
04/12/2020 14:00	0.0	0	0	0	0	1
04/12/2020 15:00	0.0	0	0	0	0	1
04/12/2020 16:00	0.0	0	0	0	0	1
04/12/2020 17:00	0.0	0	0	0	0	1
04/12/2020 18:00	0.0	0	0	0	0	1
04/12/2020 19:00	0.0	0	0	0	0	1
04/12/2020 20:00	0.0	0	0	0	0	1
04/12/2020 21:00	0.0	0	0	0	0	1
04/12/2020 22:00	0.0	0	0	0	0	1
04/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/13/2020 00:00	0.0	0	0	0	0	1
04/13/2020 01:00	0.0	0	0	0	0	1
04/13/2020 02:00	0.0	0	0	0	0	1
04/13/2020 03:00	0.0	0	0	0	0	1
04/13/2020 04:00	0.0	0	0	0	0	1
04/13/2020 05:00	0.0	0	0	0	0	1
04/13/2020 06:00	0.0	0	0	0	0	1
04/13/2020 07:00	0.0	0	0	0	0	1
04/13/2020 08:00	0.0	0	0	0	0	1
04/13/2020 09:00	0.0	0	0	0	0	1
04/13/2020 10:00	0.0	0	0	0	0	1
04/13/2020 11:00	0.0	0	0	0	0	1
04/13/2020 12:00	0.0	0	0	0	0	1
04/13/2020 13:00	0.0	0	0	0	0	1
04/13/2020 14:00	0.0	0	0	0	0	1
04/13/2020 15:00	0.0	0	0	0	0	1
04/13/2020 16:00	0.0	0	0	0	0	1
04/13/2020 17:00	0.0	0	0	0	0	1
04/13/2020 18:00	0.0	0	0	0	0	1
04/13/2020 19:00	0.0	0	0	0	0	1
04/13/2020 20:00	0.0	0	0	0	0	1
04/13/2020 21:00	0.0	0	0	0	0	1
04/13/2020 22:00	0.0	0	0	0	0	1
04/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/14/2020 00:00	0.0	0	0	0	0	1
04/14/2020 01:00	0.0	0	0	0	0	1
04/14/2020 02:00	0.0	0	0	0	0	1
04/14/2020 03:00	0.0	0	0	0	0	1
04/14/2020 04:00	0.0	0	0	0	0	1
04/14/2020 05:00	0.0	0	0	0	0	1
04/14/2020 06:00	0.0	0	0	0	0	1
04/14/2020 07:00	0.0	0	0	0	0	1
04/14/2020 08:00	0.0	0	0	0	0	1
04/14/2020 09:00	0.0	0	0	0	0	1
04/14/2020 10:00	0.0	0	0	0	0	1
04/14/2020 11:00	0.0	0	0	0	0	1
04/14/2020 12:00	0.0	0	0	0	0	1
04/14/2020 13:00	0.0	0	0	0	0	1
04/14/2020 14:00	0.0	0	0	0	0	1
04/14/2020 15:00	0.0	0	0	0	0	1
04/14/2020 16:00	0.0	0	0	0	0	1
04/14/2020 17:00	0.0	0	0	0	0	1
04/14/2020 18:00	0.0	0	0	0	0	1
04/14/2020 19:00	0.0	0	0	0	0	1
04/14/2020 20:00	0.0	0	0	0	0	1
04/14/2020 21:00	0.0	0	0	0	0	1
04/14/2020 22:00	0.0	0	0	0	0	1
04/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/15/2020 00:00	0.0	0	0	0	0	1
04/15/2020 01:00	0.0	0	0	0	0	1
04/15/2020 02:00	0.0	0	0	0	0	1
04/15/2020 03:00	0.0	0	0	0	0	1
04/15/2020 04:00	0.0	0	0	0	0	1
04/15/2020 05:00	0.0	0	0	0	0	1
04/15/2020 06:00	0.0	0	0	0	0	1
04/15/2020 07:00	0.0	0	0	0	0	1
04/15/2020 08:00	0.0	0	0	0	0	1
04/15/2020 09:00	0.0	0	0	0	0	1
04/15/2020 10:00	0.0	0	0	0	0	1
04/15/2020 11:00	0.0	0	0	0	0	1
04/15/2020 12:00	0.0	0	0	0	0	1
04/15/2020 13:00	0.0	0	0	0	0	1
04/15/2020 14:00	0.0	0	0	0	0	1
04/15/2020 15:00	0.0	0	0	0	0	1
04/15/2020 16:00	0.0	0	0	0	0	1
04/15/2020 17:00	0.0	0	0	0	0	1
04/15/2020 18:00	0.0	0	0	0	0	1
04/15/2020 19:00	0.0	0	0	0	0	1
04/15/2020 20:00	0.0	0	0	0	0	1
04/15/2020 21:00	0.0	0	0	0	0	1
04/15/2020 22:00	0.0	0	0	0	0	1
04/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/16/2020 00:00	0.0	0	0	0	0	1
04/16/2020 01:00	0.0	0	0	0	0	1
04/16/2020 02:00	0.0	0	0	0	0	1
04/16/2020 03:00	0.0	0	0	0	0	1
04/16/2020 04:00	0.0	0	0	0	0	1
04/16/2020 05:00	0.0	0	0	0	0	1
04/16/2020 06:00	0.0	0	0	0	0	1
04/16/2020 07:00	0.0	0	0	0	0	1
04/16/2020 08:00	0.0	0	0	0	0	1
04/16/2020 09:00	0.0	0	0	0	0	1
04/16/2020 10:00	0.0	0	0	0	0	1
04/16/2020 11:00	0.0	0	0	0	0	1
04/16/2020 12:00	0.0	0	0	0	0	1
04/16/2020 13:00	0.0	0	0	0	0	1
04/16/2020 14:00	0.0	0	0	0	0	1
04/16/2020 15:00	0.0	0	0	0	0	1
04/16/2020 16:00	0.0	0	0	0	0	1
04/16/2020 17:00	0.0	0	0	0	0	1
04/16/2020 18:00	0.0	0	0	0	0	1
04/16/2020 19:00	0.0	0	0	0	0	1
04/16/2020 20:00	0.0	0	0	0	0	1
04/16/2020 21:00	0.0	0	0	0	0	1
04/16/2020 22:00	0.0	0	0	0	0	1
04/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/17/2020 00:00	0.0	0	0	0	0	1
04/17/2020 01:00	0.0	0	0	0	0	1
04/17/2020 02:00	0.0	0	0	0	0	1
04/17/2020 03:00	0.0	0	0	0	0	1
04/17/2020 04:00	0.0	0	0	0	0	1
04/17/2020 05:00	0.0	0	0	0	0	1
04/17/2020 06:00	0.0	0	0	0	0	1
04/17/2020 07:00	0.0	0	0	0	0	1
04/17/2020 08:00	0.0	0	0	0	0	1
04/17/2020 09:00	0.0	0	0	0	0	1
04/17/2020 10:00	0.0	0	0	0	0	1
04/17/2020 11:00	0.0	0	0	0	0	1
04/17/2020 12:00	0.0	0	0	0	0	1
04/17/2020 13:00	0.0	0	0	0	0	1
04/17/2020 14:00	0.0	0	0	0	0	1
04/17/2020 15:00	0.0	0	0	0	0	1
04/17/2020 16:00	0.0	0	0	0	0	1
04/17/2020 17:00	0.0	0	0	0	0	1
04/17/2020 18:00	0.0	0	0	0	0	1
04/17/2020 19:00	0.0	0	0	0	0	1
04/17/2020 20:00	0.0	0	0	0	0	1
04/17/2020 21:00	0.0	0	0	0	0	1
04/17/2020 22:00	0.0	0	0	0	0	1
04/17/2020 23:00	1.6	0	0	0	1	0
Average/Sum#:	1.6 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/18/2020 00:00	0.0	0	0	0	0	0
04/18/2020 01:00	0.0	0	0	0	0	0
04/18/2020 02:00	0.0	0	0	0	0	0
04/18/2020 03:00	0.0	0	0	0	0	0
04/18/2020 04:00	0.0	0	0	0	0	0
04/18/2020 05:00	0.0	0	0	0	0	0
04/18/2020 06:00	0.0	0	0	0	0	0
04/18/2020 07:00	0.0	0	0	0	0	0
04/18/2020 08:00	0.0	0	0	0	0	0
04/18/2020 09:00	0.0	0	0	0	0	0
04/18/2020 10:00	0.0	0	0	0	0	0
04/18/2020 11:00	0.0	0	0	0	0	0
04/18/2020 12:00	0.0	0	0	0	0	0
04/18/2020 13:00	0.0	0	0	0	0	0
04/18/2020 14:00	0.0	0	0	0	0	0
04/18/2020 15:00	0.0	0	0	0	0	0
04/18/2020 16:00	0.0	0	0	0	0	0
04/18/2020 17:00	0.0	0	0	0	0	0
04/18/2020 18:00	0.0	0	0	0	0	0
04/18/2020 19:00	0.0	0	0	0	0	0
04/18/2020 20:00	0.0	0	0	0	0	0
04/18/2020 21:00	0.0	0	0	0	0	0
04/18/2020 22:00	0.0	0	0	0	0	0
04/18/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/19/2020 00:00	0.0	0	0	0	0	0
04/19/2020 01:00	0.0	0	0	0	0	0
04/19/2020 02:00	0.0	0	0	0	0	0
04/19/2020 03:00	0.0	0	0	0	0	0
04/19/2020 04:00	0.0	0	0	0	0	0
04/19/2020 05:00	0.0	0	0	0	0	0
04/19/2020 06:00	0.0	0	0	0	0	0
04/19/2020 07:00	0.0	0	0	0	0	0
04/19/2020 08:00	0.0	0	0	0	0	0
04/19/2020 09:00	0.0	0	0	0	0	0
04/19/2020 10:00	0.0	0	0	0	0	0
04/19/2020 11:00	0.0	0	0	0	0	0
04/19/2020 12:00	0.0	0	0	0	0	0
04/19/2020 13:00	0.0	0	0	0	0	0
04/19/2020 14:00	0.0	0	0	0	0	0
04/19/2020 15:00	0.0	0	0	0	0	0
04/19/2020 16:00	0.0	0	0	0	0	0
04/19/2020 17:00	0.0	0	0	0	0	0
04/19/2020 18:00	0.0	0	0	0	0	0
04/19/2020 19:00	0.0	0	0	0	0	0
04/19/2020 20:00	0.0	0	0	0	0	0
04/19/2020 21:00	0.0	0	0	0	0	0
04/19/2020 22:00	0.0	0	0	0	0	0
04/19/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/20/2020 00:00	0.0	0	0	0	0	0
04/20/2020 01:00	0.0	0	0	0	0	0
04/20/2020 02:00	94.1	0	1	0	0	0
04/20/2020 03:00	31.8	0	1	0	0	0
04/20/2020 04:00	0.0	0	0	0	0	1
04/20/2020 05:00	0.0	0	0	0	0	1
04/20/2020 06:00	0.0	0	0	0	0	1
04/20/2020 07:00	0.0	0	0	0	0	1
04/20/2020 08:00	0.0	0	0	0	0	1
04/20/2020 09:00	0.0	0	0	0	0	1
04/20/2020 10:00	0.0	0	0	0	0	1
04/20/2020 11:00	0.0	0	0	0	0	1
04/20/2020 12:00	0.0	0	0	0	0	1
04/20/2020 13:00	0.0	0	0	0	0	1
04/20/2020 14:00	0.0	0	0	0	0	1
04/20/2020 15:00	0.0	0	0	0	0	1
04/20/2020 16:00	0.0	0	0	0	0	1
04/20/2020 17:00	0.0	0	0	0	0	1
04/20/2020 18:00	0.0	0	0	0	0	1
04/20/2020 19:00	0.0	0	0	0	0	1
04/20/2020 20:00	0.0	0	0	0	0	1
04/20/2020 21:00	0.0	0	0	0	0	1
04/20/2020 22:00	0.0	0	0	0	0	1
04/20/2020 23:00	1.9	0	0	0	1	0
Average/Sum#:	127.8 #	0 #	2 #	0 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	94.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/21/2020 00:00	0.0	0	0	0	0	0
04/21/2020 01:00	0.0	0	0	0	0	0
04/21/2020 02:00	0.0	0	0	0	0	0
04/21/2020 03:00	0.0	0	0	0	0	0
04/21/2020 04:00	0.0	0	0	0	0	0
04/21/2020 05:00	0.0	0	0	0	0	0
04/21/2020 06:00	0.0	0	0	0	0	0
04/21/2020 07:00	0.0	0	0	0	0	0
04/21/2020 08:00	0.0	0	0	0	0	0
04/21/2020 09:00	0.0	0	0	0	0	0
04/21/2020 10:00	0.0	0	0	0	0	0
04/21/2020 11:00	0.0	0	0	0	0	0
04/21/2020 12:00	0.0	0	0	0	0	0
04/21/2020 13:00	0.0	0	0	0	0	0
04/21/2020 14:00	0.0	0	0	0	0	0
04/21/2020 15:00	0.0	0	0	0	0	0
04/21/2020 16:00	0.0	0	0	0	0	0
04/21/2020 17:00	0.0	0	0	0	0	0
04/21/2020 18:00	0.0	0	0	0	0	0
04/21/2020 19:00	0.0	0	0	0	0	0
04/21/2020 20:00	0.0	0	0	0	0	0
04/21/2020 21:00	0.0	0	0	0	0	0
04/21/2020 22:00	0.0	0	0	0	0	0
04/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/22/2020 00:00	0.0	0	0	0	0	0
04/22/2020 01:00	0.0	0	0	0	0	0
04/22/2020 02:00	0.0	0	0	0	0	0
04/22/2020 03:00	0.0	0	0	0	0	0
04/22/2020 04:00	0.0	0	0	0	0	0
04/22/2020 05:00	0.0	0	0	0	0	0
04/22/2020 06:00	0.0	0	0	0	0	0
04/22/2020 07:00	60.5	0	1	0	0	0
04/22/2020 08:00	44.6	0	1	0	0	0
04/22/2020 09:00	4.1	0	1	0	0	0
04/22/2020 10:00	0.0	0	0	0	0	1
04/22/2020 11:00	1.9	0	0	0	1	0
04/22/2020 12:00	0.0	0	0	0	0	0
04/22/2020 13:00	0.0	0	0	0	0	0
04/22/2020 14:00	0.0	0	0	0	0	0
04/22/2020 15:00	0.0	0	0	0	0	0
04/22/2020 16:00	0.0	0	0	0	0	0
04/22/2020 17:00	0.0	0	0	0	0	0
04/22/2020 18:00	0.0	0	0	0	0	0
04/22/2020 19:00	0.0	0	0	0	0	0
04/22/2020 20:00	0.0	0	0	0	0	0
04/22/2020 21:00	0.0	0	0	0	0	0
04/22/2020 22:00	0.0	0	0	0	0	0
04/22/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	111.1 #	0 #	3 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	60.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/23/2020 00:00	0.0	0	0	0	0	0
04/23/2020 01:00	0.0	0	0	0	0	0
04/23/2020 02:00	0.0	0	0	0	0	0
04/23/2020 03:00	0.0	0	0	0	0	0
04/23/2020 04:00	0.0	0	0	0	0	0
04/23/2020 05:00	0.0	0	0	0	0	0
04/23/2020 06:00	0.0	0	0	0	0	0
04/23/2020 07:00	0.0	0	0	0	0	0
04/23/2020 08:00	0.0	0	0	0	0	0
04/23/2020 09:00	0.0	0	0	0	0	0
04/23/2020 10:00	0.0	0	0	0	0	0
04/23/2020 11:00	0.0	0	0	0	0	0
04/23/2020 12:00	0.0	0	0	0	0	0
04/23/2020 13:00	0.0	0	0	0	0	0
04/23/2020 14:00	0.0	0	0	0	0	0
04/23/2020 15:00	0.0	0	0	0	0	0
04/23/2020 16:00	0.0	0	0	0	0	0
04/23/2020 17:00	0.0	0	0	0	0	0
04/23/2020 18:00	0.0	0	0	0	0	0
04/23/2020 19:00	0.0	0	0	0	0	0
04/23/2020 20:00	0.0	0	0	0	0	0
04/23/2020 21:00	0.0	0	0	0	0	0
04/23/2020 22:00	0.0	0	0	0	0	0
04/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/24/2020 00:00	0.0	0	0	0	0	0
04/24/2020 01:00	0.0	0	0	0	0	0
04/24/2020 02:00	0.0	0	0	0	0	0
04/24/2020 03:00	0.0	0	0	0	0	0
04/24/2020 04:00	0.0	0	0	0	0	0
04/24/2020 05:00	0.0	0	0	0	0	0
04/24/2020 06:00	0.0	0	0	0	0	0
04/24/2020 07:00	0.0	0	0	0	0	0
04/24/2020 08:00	0.0	0	0	0	0	0
04/24/2020 09:00	0.0	0	0	0	0	0
04/24/2020 10:00	0.0	0	0	0	0	0
04/24/2020 11:00	0.0	0	0	0	0	0
04/24/2020 12:00	0.0	0	0	0	0	0
04/24/2020 13:00	0.0	0	0	0	0	0
04/24/2020 14:00	9.7	0	1	0	0	0
04/24/2020 15:00	10.3	0	1	0	0	0
04/24/2020 16:00	0.0	0	1	0	0	0
04/24/2020 17:00	0.0	0	0	0	0	1
04/24/2020 18:00	0.0	0	0	0	0	1
04/24/2020 19:00	0.0	0	0	0	0	1
04/24/2020 20:00	0.0	0	0	0	0	1
04/24/2020 21:00	0.0	0	0	0	0	1
04/24/2020 22:00	2.0	0	0	0	1	0
04/24/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	22.0 #	0 #	3 #	0 #	1 #	5 #
Minimum:	0.0	0	0	0	0	0
Maximum:	10.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/25/2020 00:00	0.0	0	0	0	0	0
04/25/2020 01:00	0.0	0	0	0	0	0
04/25/2020 02:00	0.0	0	0	0	0	0
04/25/2020 03:00	0.0	0	0	0	0	0
04/25/2020 04:00	0.0	0	0	0	0	0
04/25/2020 05:00	0.0	0	0	0	0	0
04/25/2020 06:00	0.0	0	0	0	0	0
04/25/2020 07:00	0.0	0	0	0	0	0
04/25/2020 08:00	0.0	0	0	0	0	0
04/25/2020 09:00	0.0	0	0	0	0	0
04/25/2020 10:00	0.0	0	0	0	0	0
04/25/2020 11:00	0.0	0	0	0	0	0
04/25/2020 12:00	0.0	0	0	0	0	0
04/25/2020 13:00	0.0	0	0	0	0	0
04/25/2020 14:00	0.0	0	0	0	0	0
04/25/2020 15:00	0.0	0	0	0	0	0
04/25/2020 16:00	0.0	0	0	0	0	0
04/25/2020 17:00	0.0	0	0	0	0	0
04/25/2020 18:00	0.0	0	0	0	0	0
04/25/2020 19:00	0.0	0	0	0	0	0
04/25/2020 20:00	0.0	0	0	0	0	0
04/25/2020 21:00	0.0	0	0	0	0	0
04/25/2020 22:00	0.0	0	0	0	0	0
04/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/26/2020 00:00	0.0	0	0	0	0	0
04/26/2020 01:00	0.0	0	0	0	0	0
04/26/2020 02:00	0.0	0	0	0	0	0
04/26/2020 03:00	0.0	0	0	0	0	0
04/26/2020 04:00	0.0	0	0	0	0	0
04/26/2020 05:00	0.0	0	0	0	0	0
04/26/2020 06:00	0.0	0	0	0	0	0
04/26/2020 07:00	0.0	0	0	0	0	0
04/26/2020 08:00	0.0	0	0	0	0	0
04/26/2020 09:00	0.0	0	0	0	0	0
04/26/2020 10:00	0.0	0	0	0	0	0
04/26/2020 11:00	0.0	0	0	0	0	0
04/26/2020 12:00	0.0	0	0	0	0	0
04/26/2020 13:00	0.0	0	0	0	0	0
04/26/2020 14:00	0.0	0	0	0	0	0
04/26/2020 15:00	0.0	0	0	0	0	0
04/26/2020 16:00	0.0	0	0	0	0	0
04/26/2020 17:00	0.0	0	0	0	0	0
04/26/2020 18:00	0.0	0	0	0	0	0
04/26/2020 19:00	0.0	0	0	0	0	0
04/26/2020 20:00	0.0	0	0	0	0	0
04/26/2020 21:00	0.0	0	0	0	0	0
04/26/2020 22:00	0.0	0	0	0	0	0
04/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/27/2020 00:00	0.0	0	0	0	0	0
04/27/2020 01:00	0.0	0	0	0	0	0
04/27/2020 02:00	0.0	0	0	0	0	0
04/27/2020 03:00	0.0	0	0	0	0	0
04/27/2020 04:00	0.0	0	0	0	0	0
04/27/2020 05:00	0.0	0	0	0	0	0
04/27/2020 06:00	0.0	0	0	0	0	0
04/27/2020 07:00	0.0	0	0	0	0	0
04/27/2020 08:00	0.0	0	0	0	0	0
04/27/2020 09:00	0.0	0	0	0	0	0
04/27/2020 10:00	0.0	0	0	0	0	0
04/27/2020 11:00	0.0	0	0	0	0	0
04/27/2020 12:00	0.0	0	0	0	0	0
04/27/2020 13:00	0.0	0	0	0	0	0
04/27/2020 14:00	0.0	0	0	0	0	0
04/27/2020 15:00	0.0	0	0	0	0	0
04/27/2020 16:00	0.0	0	0	0	0	0
04/27/2020 17:00	0.0	0	0	0	0	0
04/27/2020 18:00	0.0	0	0	0	0	0
04/27/2020 19:00	0.0	0	0	0	0	0
04/27/2020 20:00	0.0	0	0	0	0	0
04/27/2020 21:00	0.0	0	0	0	0	0
04/27/2020 22:00	0.0	0	0	0	0	0
04/27/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/28/2020 00:00	0.0	0	0	0	0	0
04/28/2020 01:00	0.0	0	0	0	0	0
04/28/2020 02:00	0.0	0	0	0	0	0
04/28/2020 03:00	0.0	0	0	0	0	0
04/28/2020 04:00	0.0	0	0	0	0	0
04/28/2020 05:00	0.0	0	0	0	0	0
04/28/2020 06:00	0.0	0	0	0	0	0
04/28/2020 07:00	0.0	0	0	0	0	0
04/28/2020 08:00	0.0	0	0	0	0	0
04/28/2020 09:00	0.0	0	0	0	0	0
04/28/2020 10:00	0.0	0	0	0	0	0
04/28/2020 11:00	0.0	0	0	0	0	0
04/28/2020 12:00	0.0	0	0	0	0	0
04/28/2020 13:00	68.1	1	0	0	0	0
04/28/2020 14:00	41.6	1	0	0	0	0
04/28/2020 15:00	0.0	1	0	0	0	0
04/28/2020 16:00	0.0	0	0	0	0	1
04/28/2020 17:00	0.0	0	0	0	0	1
04/28/2020 18:00	0.0	0	0	0	0	1
04/28/2020 19:00	0.0	0	0	0	0	1
04/28/2020 20:00	0.0	0	0	0	0	1
04/28/2020 21:00	0.9	0	0	0	1	0
04/28/2020 22:00	0.0	0	0	0	0	0
04/28/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	110.6 #	3 #	0 #	0 #	1 #	5 #
Minimum:	0.0	0	0	0	0	0
Maximum:	68.1	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/29/2020 00:00	0.0	0	0	0	0	0
04/29/2020 01:00	0.0	0	0	0	0	0
04/29/2020 02:00	0.0	0	0	0	0	0
04/29/2020 03:00	0.0	0	0	0	0	0
04/29/2020 04:00	0.0	0	0	0	0	0
04/29/2020 05:00	0.0	0	0	0	0	0
04/29/2020 06:00	0.0	0	0	0	0	0
04/29/2020 07:00	0.0	0	0	0	0	0
04/29/2020 08:00	0.0	0	0	0	0	0
04/29/2020 09:00	0.0	0	0	0	0	0
04/29/2020 10:00	0.0	0	0	0	0	0
04/29/2020 11:00	0.0	0	0	0	0	0
04/29/2020 12:00	0.0	0	0	0	0	0
04/29/2020 13:00	0.0	0	0	0	0	0
04/29/2020 14:00	0.0	0	0	0	0	0
04/29/2020 15:00	0.0	0	0	0	0	0
04/29/2020 16:00	0.0	0	0	0	0	0
04/29/2020 17:00	0.0	0	0	0	0	0
04/29/2020 18:00	0.0	0	0	0	0	0
04/29/2020 19:00	0.0	0	0	0	0	0
04/29/2020 20:00	0.0	0	0	0	0	0
04/29/2020 21:00	0.0	0	0	0	0	0
04/29/2020 22:00	0.0	0	0	0	0	0
04/29/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/30/2020 00:00	0.0	0	0	0	0	0
04/30/2020 01:00	0.0	0	0	0	0	0
04/30/2020 02:00	0.0	0	0	0	0	0
04/30/2020 03:00	0.0	0	0	0	0	0
04/30/2020 04:00	0.0	0	0	0	0	0
04/30/2020 05:00	0.0	0	0	0	0	0
04/30/2020 06:00	0.0	0	0	0	0	0
04/30/2020 07:00	0.0	0	0	0	0	0
04/30/2020 08:00	0.0	0	0	0	0	0
04/30/2020 09:00	0.0	0	0	0	0	0
04/30/2020 10:00	0.0	0	0	0	0	0
04/30/2020 11:00	0.0	0	0	0	0	0
04/30/2020 12:00	0.0	0	0	0	0	0
04/30/2020 13:00	0.0	0	0	0	0	0
04/30/2020 14:00	0.0	0	0	0	0	0
04/30/2020 15:00	0.0	0	0	0	0	0
04/30/2020 16:00	0.0	0	0	0	0	0
04/30/2020 17:00	0.0	0	0	0	0	0
04/30/2020 18:00	0.0	0	0	0	0	0
04/30/2020 19:00	0.0	0	0	0	0	0
04/30/2020 20:00	0.0	0	0	0	0	0
04/30/2020 21:00	0.0	0	0	0	0	0
04/30/2020 22:00	0.0	0	0	0	0	0
04/30/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/01/2020 00:00	0.0	0	0	0	0	0
05/01/2020 01:00	0.0	0	0	0	0	0
05/01/2020 02:00	0.0	0	0	0	0	0
05/01/2020 03:00	0.0	0	0	0	0	0
05/01/2020 04:00	0.0	0	0	0	0	0
05/01/2020 05:00	0.0	0	0	0	0	0
05/01/2020 06:00	0.0	0	0	0	0	0
05/01/2020 07:00	0.0	0	0	0	0	0
05/01/2020 08:00	0.0	0	0	0	0	0
05/01/2020 09:00	0.0	0	0	0	0	0
05/01/2020 10:00	0.0	0	0	0	0	0
05/01/2020 11:00	0.0	0	0	0	0	0
05/01/2020 12:00	0.0	0	0	0	0	0
05/01/2020 13:00	0.0	0	0	0	0	0
05/01/2020 14:00	0.0	0	0	0	0	0
05/01/2020 15:00	0.0	0	0	0	0	0
05/01/2020 16:00	0.0	0	0	0	0	0
05/01/2020 17:00	0.0	0	0	0	0	0
05/01/2020 18:00	0.0	0	0	0	0	0
05/01/2020 19:00	0.0	0	0	0	0	0
05/01/2020 20:00	0.0	0	0	0	0	0
05/01/2020 21:00	0.0	0	0	0	0	0
05/01/2020 22:00	0.0	0	0	0	0	0
05/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/02/2020 00:00	0.0	0	0	0	0	0
05/02/2020 01:00	0.0	0	0	0	0	0
05/02/2020 02:00	0.0	0	0	0	0	0
05/02/2020 03:00	0.0	0	0	0	0	0
05/02/2020 04:00	0.0	0	0	0	0	0
05/02/2020 05:00	0.0	0	0	0	0	0
05/02/2020 06:00	0.0	0	0	0	0	0
05/02/2020 07:00	0.0	0	0	0	0	0
05/02/2020 08:00	0.0	0	0	0	0	0
05/02/2020 09:00	0.0	0	0	0	0	0
05/02/2020 10:00	0.0	0	0	0	0	0
05/02/2020 11:00	0.0	0	0	0	0	0
05/02/2020 12:00	0.0	0	0	0	0	0
05/02/2020 13:00	0.0	0	0	0	0	0
05/02/2020 14:00	0.0	0	0	0	0	0
05/02/2020 15:00	0.0	0	0	0	0	0
05/02/2020 16:00	0.0	0	0	0	0	0
05/02/2020 17:00	0.0	0	0	0	0	0
05/02/2020 18:00	0.0	0	0	0	0	0
05/02/2020 19:00	0.0	0	0	0	0	0
05/02/2020 20:00	0.0	0	0	0	0	0
05/02/2020 21:00	0.0	0	0	0	0	0
05/02/2020 22:00	0.0	0	0	0	0	0
05/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/03/2020 00:00	0.0	0	0	0	0	0
05/03/2020 01:00	0.0	0	0	0	0	0
05/03/2020 02:00	0.0	0	0	0	0	0
05/03/2020 03:00	0.0	0	0	0	0	0
05/03/2020 04:00	0.0	0	0	0	0	0
05/03/2020 05:00	0.0	0	0	0	0	0
05/03/2020 06:00	0.0	0	0	0	0	0
05/03/2020 07:00	0.0	0	0	0	0	0
05/03/2020 08:00	0.0	0	0	0	0	0
05/03/2020 09:00	0.0	0	0	0	0	0
05/03/2020 10:00	0.0	0	0	0	0	0
05/03/2020 11:00	0.0	0	0	0	0	0
05/03/2020 12:00	0.0	0	0	0	0	0
05/03/2020 13:00	0.0	0	0	0	0	0
05/03/2020 14:00	0.0	0	0	0	0	0
05/03/2020 15:00	0.0	0	0	0	0	0
05/03/2020 16:00	0.0	0	0	0	0	0
05/03/2020 17:00	0.0	0	0	0	0	0
05/03/2020 18:00	0.0	0	0	0	0	0
05/03/2020 19:00	0.0	0	0	0	0	0
05/03/2020 20:00	0.0	0	0	0	0	0
05/03/2020 21:00	0.0	0	0	0	0	0
05/03/2020 22:00	0.0	0	0	0	0	0
05/03/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/04/2020 00:00	0.0	0	0	0	0	0
05/04/2020 01:00	0.0	0	0	0	0	0
05/04/2020 02:00	0.0	0	0	0	0	0
05/04/2020 03:00	0.0	0	0	0	0	0
05/04/2020 04:00	0.0	0	0	0	0	0
05/04/2020 05:00	0.0	0	0	0	0	0
05/04/2020 06:00	0.0	0	0	0	0	0
05/04/2020 07:00	0.0	0	0	0	0	0
05/04/2020 08:00	0.0	0	0	0	0	0
05/04/2020 09:00	0.0	0	0	0	0	0
05/04/2020 10:00	0.0	0	0	0	0	0
05/04/2020 11:00	0.0	0	0	0	0	0
05/04/2020 12:00	0.0	0	0	0	0	0
05/04/2020 13:00	0.0	0	0	0	0	0
05/04/2020 14:00	0.0	0	0	0	0	0
05/04/2020 15:00	0.0	0	0	0	0	0
05/04/2020 16:00	0.0	0	0	0	0	0
05/04/2020 17:00	0.0	0	0	0	0	0
05/04/2020 18:00	0.0	0	0	0	0	0
05/04/2020 19:00	0.0	0	0	0	0	0
05/04/2020 20:00	0.0	0	0	0	0	0
05/04/2020 21:00	0.0	0	0	0	0	0
05/04/2020 22:00	0.0	0	0	0	0	0
05/04/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/05/2020 00:00	0.0	0	0	0	0	0
05/05/2020 01:00	0.0	0	0	0	0	0
05/05/2020 02:00	0.0	0	0	0	0	0
05/05/2020 03:00	0.0	0	0	0	0	0
05/05/2020 04:00	0.0	0	0	0	0	0
05/05/2020 05:00	0.0	0	0	0	0	0
05/05/2020 06:00	0.0	0	0	0	0	0
05/05/2020 07:00	0.0	0	0	0	0	0
05/05/2020 08:00	0.0	0	0	0	0	0
05/05/2020 09:00	0.0	0	0	0	0	0
05/05/2020 10:00	0.0	0	0	0	0	0
05/05/2020 11:00	0.0	0	0	0	0	0
05/05/2020 12:00	0.0	0	0	0	0	0
05/05/2020 13:00	0.0	0	0	0	0	0
05/05/2020 14:00	0.0	0	0	0	0	0
05/05/2020 15:00	0.0	0	0	0	0	0
05/05/2020 16:00	0.0	0	0	0	0	0
05/05/2020 17:00	0.0	0	0	0	0	0
05/05/2020 18:00	0.0	0	0	0	0	0
05/05/2020 19:00	0.0	0	0	0	0	0
05/05/2020 20:00	0.0	0	0	0	0	0
05/05/2020 21:00	0.0	0	0	0	0	0
05/05/2020 22:00	0.0	0	0	0	0	0
05/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/06/2020 00:00	0.0	0	0	0	0	0
05/06/2020 01:00	0.0	0	0	0	0	0
05/06/2020 02:00	0.0	0	0	0	0	0
05/06/2020 03:00	0.0	0	0	0	0	0
05/06/2020 04:00	0.0	0	0	0	0	0
05/06/2020 05:00	0.0	0	0	0	0	0
05/06/2020 06:00	0.0	0	0	0	0	0
05/06/2020 07:00	0.0	0	0	0	0	0
05/06/2020 08:00	0.0	0	0	0	0	0
05/06/2020 09:00	0.0	0	0	0	0	0
05/06/2020 10:00	0.0	0	0	0	0	0
05/06/2020 11:00	0.0	0	0	0	0	0
05/06/2020 12:00	0.0	0	0	0	0	0
05/06/2020 13:00	0.0	0	0	0	0	0
05/06/2020 14:00	0.0	0	0	0	0	0
05/06/2020 15:00	0.0	0	0	0	0	0
05/06/2020 16:00	0.0	0	0	0	0	0
05/06/2020 17:00	0.0	0	0	0	0	0
05/06/2020 18:00	0.0	0	0	0	0	0
05/06/2020 19:00	0.0	0	0	0	0	0
05/06/2020 20:00	0.0	0	0	0	0	0
05/06/2020 21:00	0.0	0	0	0	0	0
05/06/2020 22:00	0.0	0	0	0	0	0
05/06/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/07/2020 00:00	0.0	0	0	0	0	0
05/07/2020 01:00	0.0	0	0	0	0	0
05/07/2020 02:00	0.0	0	0	0	0	0
05/07/2020 03:00	0.0	0	0	0	0	0
05/07/2020 04:00	0.0	0	0	0	0	0
05/07/2020 05:00	0.0	0	0	0	0	0
05/07/2020 06:00	0.0	0	0	0	0	0
05/07/2020 07:00	0.0	0	0	0	0	0
05/07/2020 08:00	0.0	0	0	0	0	0
05/07/2020 09:00	0.0	0	0	0	0	0
05/07/2020 10:00	0.0	0	0	0	0	0
05/07/2020 11:00	0.0	0	0	0	0	0
05/07/2020 12:00	0.0	0	0	0	0	0
05/07/2020 13:00	0.0	0	0	0	0	0
05/07/2020 14:00	0.0	0	0	0	0	0
05/07/2020 15:00	0.0	0	0	0	0	0
05/07/2020 16:00	0.0	0	0	0	0	0
05/07/2020 17:00	0.0	0	0	0	0	0
05/07/2020 18:00	0.0	0	0	0	0	0
05/07/2020 19:00	0.0	0	0	0	0	0
05/07/2020 20:00	0.0	0	0	0	0	0
05/07/2020 21:00	0.0	0	0	0	0	0
05/07/2020 22:00	0.0	0	0	0	0	0
05/07/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/08/2020 00:00	0.0	0	0	0	0	0
05/08/2020 01:00	0.0	0	0	0	0	0
05/08/2020 02:00	0.0	0	0	0	0	0
05/08/2020 03:00	0.0	0	0	0	0	0
05/08/2020 04:00	0.0	0	0	0	0	0
05/08/2020 05:00	0.0	0	0	0	0	0
05/08/2020 06:00	0.0	0	0	0	0	0
05/08/2020 07:00	0.0	0	0	0	0	0
05/08/2020 08:00	0.0	0	0	0	0	0
05/08/2020 09:00	0.0	0	0	0	0	0
05/08/2020 10:00	0.0	0	0	0	0	0
05/08/2020 11:00	0.0	0	0	0	0	0
05/08/2020 12:00	0.0	0	0	0	0	0
05/08/2020 13:00	0.0	0	0	0	0	0
05/08/2020 14:00	0.0	0	0	0	0	0
05/08/2020 15:00	0.0	0	0	0	0	0
05/08/2020 16:00	0.0	0	0	0	0	0
05/08/2020 17:00	0.0	0	0	0	0	0
05/08/2020 18:00	0.0	0	0	0	0	0
05/08/2020 19:00	0.0	0	0	0	0	0
05/08/2020 20:00	0.0	0	0	0	0	0
05/08/2020 21:00	0.0	0	0	0	0	0
05/08/2020 22:00	0.0	0	0	0	0	0
05/08/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/09/2020 00:00	0.0	0	0	0	0	0
05/09/2020 01:00	0.0	0	0	0	0	0
05/09/2020 02:00	0.0	0	0	0	0	0
05/09/2020 03:00	0.0	0	0	0	0	0
05/09/2020 04:00	0.0	0	0	0	0	0
05/09/2020 05:00	0.0	0	0	0	0	0
05/09/2020 06:00	0.0	0	0	0	0	0
05/09/2020 07:00	0.0	0	0	0	0	0
05/09/2020 08:00	0.0	0	0	0	0	0
05/09/2020 09:00	0.0	0	0	0	0	0
05/09/2020 10:00	0.0	0	0	0	0	0
05/09/2020 11:00	0.0	0	0	0	0	0
05/09/2020 12:00	0.0	0	0	0	0	0
05/09/2020 13:00	0.0	0	0	0	0	0
05/09/2020 14:00	0.0	0	0	0	0	0
05/09/2020 15:00	0.0	0	0	0	0	0
05/09/2020 16:00	0.0	0	0	0	0	0
05/09/2020 17:00	0.0	0	0	0	0	0
05/09/2020 18:00	0.0	0	0	0	0	0
05/09/2020 19:00	0.0	0	0	0	0	0
05/09/2020 20:00	0.0	0	0	0	0	0
05/09/2020 21:00	0.0	0	0	0	0	0
05/09/2020 22:00	0.0	0	0	0	0	0
05/09/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/10/2020 00:00	0.0	0	0	0	0	0
05/10/2020 01:00	0.0	0	0	0	0	0
05/10/2020 02:00	0.0	0	0	0	0	0
05/10/2020 03:00	0.0	0	0	0	0	0
05/10/2020 04:00	0.0	0	0	0	0	0
05/10/2020 05:00	0.0	0	0	0	0	0
05/10/2020 06:00	0.0	0	0	0	0	0
05/10/2020 07:00	0.0	0	0	0	0	0
05/10/2020 08:00	0.0	0	0	0	0	0
05/10/2020 09:00	0.0	0	0	0	0	0
05/10/2020 10:00	0.0	0	0	0	0	0
05/10/2020 11:00	0.0	0	0	0	0	0
05/10/2020 12:00	0.0	0	0	0	0	0
05/10/2020 13:00	0.0	0	0	0	0	0
05/10/2020 14:00	0.0	0	0	0	0	0
05/10/2020 15:00	0.0	0	0	0	0	0
05/10/2020 16:00	0.0	0	0	0	0	0
05/10/2020 17:00	0.0	0	0	0	0	0
05/10/2020 18:00	0.0	0	0	0	0	0
05/10/2020 19:00	0.0	0	0	0	0	0
05/10/2020 20:00	0.0	0	0	0	0	0
05/10/2020 21:00	0.0	0	0	0	0	0
05/10/2020 22:00	0.0	0	0	0	0	0
05/10/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/11/2020 00:00	0.0	0	0	0	0	0
05/11/2020 01:00	0.0	0	0	0	0	0
05/11/2020 02:00	0.0	0	0	0	0	0
05/11/2020 03:00	0.0	0	0	0	0	0
05/11/2020 04:00	0.0	0	0	0	0	0
05/11/2020 05:00	0.0	0	0	0	0	0
05/11/2020 06:00	0.0	0	0	0	0	0
05/11/2020 07:00	0.0	0	0	0	0	0
05/11/2020 08:00	0.0	0	0	0	0	0
05/11/2020 09:00	0.0	0	0	0	0	0
05/11/2020 10:00	0.0	0	0	0	0	0
05/11/2020 11:00	0.0	0	0	0	0	0
05/11/2020 12:00	0.0	0	0	0	0	0
05/11/2020 13:00	0.0	0	0	0	0	0
05/11/2020 14:00	0.0	0	0	0	0	0
05/11/2020 15:00	0.0	0	0	0	0	0
05/11/2020 16:00	0.0	0	0	0	0	0
05/11/2020 17:00	0.0	0	0	0	0	0
05/11/2020 18:00	0.0	0	0	0	0	0
05/11/2020 19:00	0.0	0	0	0	0	0
05/11/2020 20:00	0.0	0	0	0	0	0
05/11/2020 21:00	0.0	0	0	0	0	0
05/11/2020 22:00	0.0	0	0	0	0	0
05/11/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/12/2020 00:00	0.0	0	0	0	0	0
05/12/2020 01:00	0.0	0	0	0	0	0
05/12/2020 02:00	0.0	0	0	0	0	0
05/12/2020 03:00	0.0	0	0	0	0	0
05/12/2020 04:00	0.0	0	0	0	0	0
05/12/2020 05:00	0.0	0	0	0	0	0
05/12/2020 06:00	0.0	0	0	0	0	0
05/12/2020 07:00	0.0	0	0	0	0	0
05/12/2020 08:00	0.0	0	0	0	0	0
05/12/2020 09:00	0.0	0	0	0	0	0
05/12/2020 10:00	0.0	0	0	0	0	0
05/12/2020 11:00	0.0	0	0	0	0	0
05/12/2020 12:00	0.0	0	0	0	0	0
05/12/2020 13:00	0.0	0	0	0	0	0
05/12/2020 14:00	0.0	0	0	0	0	0
05/12/2020 15:00	0.0	0	0	0	0	0
05/12/2020 16:00	0.0	0	0	0	0	0
05/12/2020 17:00	0.0	0	0	0	0	0
05/12/2020 18:00	0.0	0	0	0	0	0
05/12/2020 19:00	0.0	0	0	0	0	0
05/12/2020 20:00	0.0	0	0	0	0	0
05/12/2020 21:00	0.0	0	0	0	0	0
05/12/2020 22:00	0.0	0	0	0	0	0
05/12/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/13/2020 00:00	0.0	0	0	0	0	0
05/13/2020 01:00	0.0	0	0	0	0	0
05/13/2020 02:00	0.0	0	0	0	0	0
05/13/2020 03:00	0.0	0	0	0	0	0
05/13/2020 04:00	0.0	0	0	0	0	0
05/13/2020 05:00	0.0	0	0	0	0	0
05/13/2020 06:00	0.0	0	0	0	0	0
05/13/2020 07:00	0.0	0	0	0	0	0
05/13/2020 08:00	0.0	0	0	0	0	0
05/13/2020 09:00	0.0	0	0	0	0	0
05/13/2020 10:00	0.0	0	0	0	0	0
05/13/2020 11:00	0.0	0	0	0	0	0
05/13/2020 12:00	0.0	0	0	0	0	0
05/13/2020 13:00	0.0	0	0	0	0	0
05/13/2020 14:00	0.0	0	0	0	0	0
05/13/2020 15:00	0.0	0	0	0	0	0
05/13/2020 16:00	0.0	0	0	0	0	0
05/13/2020 17:00	0.0	0	0	0	0	0
05/13/2020 18:00	0.0	0	0	0	0	0
05/13/2020 19:00	0.0	0	0	0	0	0
05/13/2020 20:00	0.0	0	0	0	0	0
05/13/2020 21:00	0.0	0	0	0	0	0
05/13/2020 22:00	0.0	0	0	0	0	0
05/13/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/14/2020 00:00	0.0	0	0	0	0	0
05/14/2020 01:00	0.0	0	0	0	0	0
05/14/2020 02:00	0.0	0	0	0	0	0
05/14/2020 03:00	0.0	0	0	0	0	0
05/14/2020 04:00	0.0	0	0	0	0	0
05/14/2020 05:00	0.0	0	0	0	0	0
05/14/2020 06:00	0.0	0	0	0	0	0
05/14/2020 07:00	0.0	0	0	0	0	0
05/14/2020 08:00	0.0	0	0	0	0	0
05/14/2020 09:00	0.0	0	0	0	0	0
05/14/2020 10:00	0.0	0	0	0	0	0
05/14/2020 11:00	0.0	0	0	0	0	0
05/14/2020 12:00	0.0	0	0	0	0	0
05/14/2020 13:00	0.0	0	0	0	0	0
05/14/2020 14:00	0.0	0	0	0	0	0
05/14/2020 15:00	0.0	0	0	0	0	0
05/14/2020 16:00	0.0	0	0	0	0	0
05/14/2020 17:00	0.0	0	0	0	0	0
05/14/2020 18:00	0.0	0	0	0	0	0
05/14/2020 19:00	0.0	0	0	0	0	0
05/14/2020 20:00	0.0	0	0	0	0	0
05/14/2020 21:00	0.0	0	0	0	0	0
05/14/2020 22:00	0.0	0	0	0	0	0
05/14/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/15/2020 00:00	0.0	0	0	0	0	0
05/15/2020 01:00	0.0	0	0	0	0	0
05/15/2020 02:00	0.0	0	0	0	0	0
05/15/2020 03:00	0.0	0	0	0	0	0
05/15/2020 04:00	0.0	0	0	0	0	0
05/15/2020 05:00	0.0	0	0	0	0	0
05/15/2020 06:00	0.0	0	0	0	0	0
05/15/2020 07:00	0.0	0	0	0	0	0
05/15/2020 08:00	0.0	0	0	0	0	0
05/15/2020 09:00	0.0	0	0	0	0	0
05/15/2020 10:00	0.0	0	0	0	0	0
05/15/2020 11:00	0.0	0	0	0	0	0
05/15/2020 12:00	0.0	0	0	0	0	0
05/15/2020 13:00	0.0	0	0	0	0	0
05/15/2020 14:00	0.0	0	0	0	0	0
05/15/2020 15:00	0.0	0	0	0	0	0
05/15/2020 16:00	0.0	0	0	0	0	0
05/15/2020 17:00	0.0	0	0	0	0	0
05/15/2020 18:00	0.0	0	0	0	0	0
05/15/2020 19:00	0.0	0	0	0	0	0
05/15/2020 20:00	0.0	0	0	0	0	0
05/15/2020 21:00	0.0	0	0	0	0	0
05/15/2020 22:00	0.0	0	0	0	0	0
05/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/16/2020 00:00	0.0	0	0	0	0	0
05/16/2020 01:00	0.0	0	0	0	0	0
05/16/2020 02:00	0.0	0	0	0	0	0
05/16/2020 03:00	0.0	0	0	0	0	0
05/16/2020 04:00	0.0	0	0	0	0	0
05/16/2020 05:00	0.0	0	0	0	0	0
05/16/2020 06:00	0.0	0	0	0	0	0
05/16/2020 07:00	0.0	0	0	0	0	0
05/16/2020 08:00	0.0	0	0	0	0	0
05/16/2020 09:00	0.0	0	0	0	0	0
05/16/2020 10:00	0.0	0	0	0	0	0
05/16/2020 11:00	0.0	0	0	0	0	0
05/16/2020 12:00	0.0	0	0	0	0	0
05/16/2020 13:00	0.0	0	0	0	0	0
05/16/2020 14:00	0.0	0	0	0	0	0
05/16/2020 15:00	0.0	0	0	0	0	0
05/16/2020 16:00	0.0	0	0	0	0	0
05/16/2020 17:00	0.0	0	0	0	0	0
05/16/2020 18:00	0.0	0	0	0	0	0
05/16/2020 19:00	0.0	0	0	0	0	0
05/16/2020 20:00	0.0	0	0	0	0	0
05/16/2020 21:00	0.0	0	0	0	0	0
05/16/2020 22:00	0.0	0	0	0	0	0
05/16/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/17/2020 00:00	0.0	0	0	0	0	0
05/17/2020 01:00	0.0	0	0	0	0	0
05/17/2020 02:00	0.0	0	0	0	0	0
05/17/2020 03:00	0.0	0	0	0	0	0
05/17/2020 04:00	0.0	0	0	0	0	0
05/17/2020 05:00	0.0	0	0	0	0	0
05/17/2020 06:00	0.0	0	0	0	0	0
05/17/2020 07:00	0.0	0	0	0	0	0
05/17/2020 08:00	0.0	0	0	0	0	0
05/17/2020 09:00	0.0	0	0	0	0	0
05/17/2020 10:00	0.0	0	0	0	0	0
05/17/2020 11:00	0.0	0	0	0	0	0
05/17/2020 12:00	0.0	0	0	0	0	0
05/17/2020 13:00	0.0	0	0	0	0	0
05/17/2020 14:00	0.0	0	0	0	0	0
05/17/2020 15:00	0.0	0	0	0	0	0
05/17/2020 16:00	0.0	0	0	0	0	0
05/17/2020 17:00	0.0	0	0	0	0	0
05/17/2020 18:00	0.0	0	0	0	0	0
05/17/2020 19:00	0.0	0	0	0	0	0
05/17/2020 20:00	0.0	0	0	0	0	0
05/17/2020 21:00	0.0	0	0	0	0	0
05/17/2020 22:00	0.0	0	0	0	0	0
05/17/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/18/2020 00:00	0.0	0	0	0	0	0
05/18/2020 01:00	0.0	0	0	0	0	0
05/18/2020 02:00	0.0	0	0	0	0	0
05/18/2020 03:00	0.0	0	0	0	0	0
05/18/2020 04:00	0.0	0	0	0	0	0
05/18/2020 05:00	0.0	0	0	0	0	0
05/18/2020 06:00	0.0	0	0	0	0	0
05/18/2020 07:00	0.0	0	0	0	0	0
05/18/2020 08:00	0.0	0	0	0	0	0
05/18/2020 09:00	0.0	0	0	0	0	0
05/18/2020 10:00	0.0	0	0	0	0	0
05/18/2020 11:00	0.0	0	0	0	0	0
05/18/2020 12:00	0.0	0	0	0	0	0
05/18/2020 13:00	0.0	0	0	0	0	0
05/18/2020 14:00	0.0	0	0	0	0	0
05/18/2020 15:00	0.0	0	0	0	0	0
05/18/2020 16:00	0.0	0	0	0	0	0
05/18/2020 17:00	0.0	0	0	0	0	0
05/18/2020 18:00	0.0	0	0	0	0	0
05/18/2020 19:00	0.0	0	0	0	0	0
05/18/2020 20:00	0.0	0	0	0	0	0
05/18/2020 21:00	0.0	0	0	0	0	0
05/18/2020 22:00	0.0	0	0	0	0	0
05/18/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/19/2020 00:00	0.0	0	0	0	0	0
05/19/2020 01:00	0.0	0	0	0	0	0
05/19/2020 02:00	0.0	0	0	0	0	0
05/19/2020 03:00	0.0	0	0	0	0	0
05/19/2020 04:00	0.0	0	0	0	0	0
05/19/2020 05:00	0.0	0	0	0	0	0
05/19/2020 06:00	0.0	0	0	0	0	0
05/19/2020 07:00	0.0	0	0	0	0	0
05/19/2020 08:00	0.0	0	0	0	0	0
05/19/2020 09:00	0.0	0	0	0	0	0
05/19/2020 10:00	0.0	0	0	0	0	0
05/19/2020 11:00	0.0	0	0	0	0	0
05/19/2020 12:00	0.0	0	0	0	0	0
05/19/2020 13:00	0.0	0	0	0	0	0
05/19/2020 14:00	0.0	0	0	0	0	0
05/19/2020 15:00	0.0	0	0	0	0	0
05/19/2020 16:00	0.0	0	0	0	0	0
05/19/2020 17:00	0.0	0	0	0	0	0
05/19/2020 18:00	0.0	0	0	0	0	0
05/19/2020 19:00	0.0	0	0	0	0	0
05/19/2020 20:00	0.0	0	0	0	0	0
05/19/2020 21:00	0.0	0	0	0	0	0
05/19/2020 22:00	0.0	0	0	0	0	0
05/19/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/20/2020 00:00	0.0	0	0	0	0	0
05/20/2020 01:00	0.0	0	0	0	0	0
05/20/2020 02:00	0.0	0	0	0	0	0
05/20/2020 03:00	0.0	0	0	0	0	0
05/20/2020 04:00	0.0	0	0	0	0	0
05/20/2020 05:00	0.0	0	0	0	0	0
05/20/2020 06:00	0.0	0	0	0	0	0
05/20/2020 07:00	0.0	0	0	0	0	0
05/20/2020 08:00	0.0	0	0	0	0	0
05/20/2020 09:00	0.0	0	0	0	0	0
05/20/2020 10:00	0.0	0	0	0	0	0
05/20/2020 11:00	0.0	0	0	0	0	0
05/20/2020 12:00	0.0	0	0	0	0	0
05/20/2020 13:00	0.0	0	0	0	0	0
05/20/2020 14:00	0.0	0	0	0	0	0
05/20/2020 15:00	0.0	0	0	0	0	0
05/20/2020 16:00	0.0	0	0	0	0	0
05/20/2020 17:00	0.0	0	0	0	0	0
05/20/2020 18:00	0.0	0	0	0	0	0
05/20/2020 19:00	0.0	0	0	0	0	0
05/20/2020 20:00	0.0	0	0	0	0	0
05/20/2020 21:00	0.0	0	0	0	0	0
05/20/2020 22:00	0.0	0	0	0	0	0
05/20/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/21/2020 00:00	0.0	0	0	0	0	0
05/21/2020 01:00	0.0	0	0	0	0	0
05/21/2020 02:00	0.0	0	0	0	0	0
05/21/2020 03:00	0.0	0	0	0	0	0
05/21/2020 04:00	0.0	0	0	0	0	0
05/21/2020 05:00	0.0	0	0	0	0	0
05/21/2020 06:00	0.0	0	0	0	0	0
05/21/2020 07:00	0.0	0	0	0	0	0
05/21/2020 08:00	0.0	0	0	0	0	0
05/21/2020 09:00	0.0	0	0	0	0	0
05/21/2020 10:00	0.0	0	0	0	0	0
05/21/2020 11:00	0.0	0	0	0	0	0
05/21/2020 12:00	0.0	0	0	0	0	0
05/21/2020 13:00	0.0	0	0	0	0	0
05/21/2020 14:00	0.0	0	0	0	0	0
05/21/2020 15:00	0.0	0	0	0	0	0
05/21/2020 16:00	0.0	0	0	0	0	0
05/21/2020 17:00	0.0	0	0	0	0	0
05/21/2020 18:00	0.0	0	0	0	0	0
05/21/2020 19:00	0.0	0	0	0	0	0
05/21/2020 20:00	0.0	0	0	0	0	0
05/21/2020 21:00	0.0	0	0	0	0	0
05/21/2020 22:00	0.0	0	0	0	0	0
05/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/22/2020 00:00	0.0	0	0	0	0	0
05/22/2020 01:00	0.0	0	0	0	0	0
05/22/2020 02:00	0.0	0	0	0	0	0
05/22/2020 03:00	0.0	0	0	0	0	0
05/22/2020 04:00	0.0	0	0	0	0	0
05/22/2020 05:00	0.0	0	0	0	0	0
05/22/2020 06:00	0.0	0	0	0	0	0
05/22/2020 07:00	0.0	0	0	0	0	0
05/22/2020 08:00	0.0	0	0	0	0	0
05/22/2020 09:00	0.0	0	0	0	0	0
05/22/2020 10:00	0.0	0	0	0	0	0
05/22/2020 11:00	0.0	0	0	0	0	0
05/22/2020 12:00	0.0	0	0	0	0	0
05/22/2020 13:00	0.0	0	0	0	0	0
05/22/2020 14:00	0.0	0	0	0	0	0
05/22/2020 15:00	0.0	0	0	0	0	0
05/22/2020 16:00	0.0	0	0	0	0	0
05/22/2020 17:00	0.0	0	0	0	0	0
05/22/2020 18:00	0.0	0	0	0	0	0
05/22/2020 19:00	0.0	0	0	0	0	0
05/22/2020 20:00	0.0	0	0	0	0	0
05/22/2020 21:00	0.0	0	0	0	0	0
05/22/2020 22:00	0.0	0	0	0	0	0
05/22/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/23/2020 00:00	0.0	0	0	0	0	0
05/23/2020 01:00	0.0	0	0	0	0	0
05/23/2020 02:00	0.0	0	0	0	0	0
05/23/2020 03:00	0.0	0	0	0	0	0
05/23/2020 04:00	0.0	0	0	0	0	0
05/23/2020 05:00	0.0	0	0	0	0	0
05/23/2020 06:00	0.0	0	0	0	0	0
05/23/2020 07:00	0.0	0	0	0	0	0
05/23/2020 08:00	0.0	0	0	0	0	0
05/23/2020 09:00	0.0	0	0	0	0	0
05/23/2020 10:00	0.0	0	0	0	0	0
05/23/2020 11:00	0.0	0	0	0	0	0
05/23/2020 12:00	0.0	0	0	0	0	0
05/23/2020 13:00	0.0	0	0	0	0	0
05/23/2020 14:00	0.0	0	0	0	0	0
05/23/2020 15:00	0.0	0	0	0	0	0
05/23/2020 16:00	0.0	0	0	0	0	0
05/23/2020 17:00	0.0	0	0	0	0	0
05/23/2020 18:00	0.0	0	0	0	0	0
05/23/2020 19:00	0.0	0	0	0	0	0
05/23/2020 20:00	0.0	0	0	0	0	0
05/23/2020 21:00	0.0	0	0	0	0	0
05/23/2020 22:00	0.0	0	0	0	0	0
05/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/24/2020 00:00	0.0	0	0	0	0	0
05/24/2020 01:00	0.0	0	0	0	0	0
05/24/2020 02:00	0.0	0	0	0	0	0
05/24/2020 03:00	0.0	0	0	0	0	0
05/24/2020 04:00	0.0	0	0	0	0	0
05/24/2020 05:00	0.0	0	0	0	0	0
05/24/2020 06:00	0.0	0	0	0	0	0
05/24/2020 07:00	0.0	0	0	0	0	0
05/24/2020 08:00	0.0	0	0	0	0	0
05/24/2020 09:00	0.0	0	0	0	0	0
05/24/2020 10:00	0.0	0	0	0	0	0
05/24/2020 11:00	0.0	0	0	0	0	0
05/24/2020 12:00	0.0	0	0	0	0	0
05/24/2020 13:00	0.0	0	0	0	0	0
05/24/2020 14:00	0.0	0	0	0	0	0
05/24/2020 15:00	0.0	0	0	0	0	0
05/24/2020 16:00	0.0	0	0	0	0	0
05/24/2020 17:00	0.0	0	0	0	0	0
05/24/2020 18:00	0.0	0	0	0	0	0
05/24/2020 19:00	0.0	0	0	0	0	0
05/24/2020 20:00	0.0	0	0	0	0	0
05/24/2020 21:00	0.0	0	0	0	0	0
05/24/2020 22:00	0.0	0	0	0	0	0
05/24/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/25/2020 00:00	0.0	0	0	0	0	0
05/25/2020 01:00	0.0	0	0	0	0	0
05/25/2020 02:00	0.0	0	0	0	0	0
05/25/2020 03:00	0.0	0	0	0	0	0
05/25/2020 04:00	0.0	0	0	0	0	0
05/25/2020 05:00	0.0	0	0	0	0	0
05/25/2020 06:00	0.0	0	0	0	0	0
05/25/2020 07:00	0.0	0	0	0	0	0
05/25/2020 08:00	0.0	0	0	0	0	0
05/25/2020 09:00	0.0	0	0	0	0	0
05/25/2020 10:00	0.0	0	0	0	0	0
05/25/2020 11:00	0.0	0	0	0	0	0
05/25/2020 12:00	0.0	0	0	0	0	0
05/25/2020 13:00	0.0	0	0	0	0	0
05/25/2020 14:00	0.0	0	0	0	0	0
05/25/2020 15:00	0.0	0	0	0	0	0
05/25/2020 16:00	0.0	0	0	0	0	0
05/25/2020 17:00	0.0	0	0	0	0	0
05/25/2020 18:00	0.0	0	0	0	0	0
05/25/2020 19:00	0.0	0	0	0	0	0
05/25/2020 20:00	0.0	0	0	0	0	0
05/25/2020 21:00	0.0	0	0	0	0	0
05/25/2020 22:00	0.0	0	0	0	0	0
05/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/26/2020 00:00	0.0	0	0	0	0	0
05/26/2020 01:00	0.0	0	0	0	0	0
05/26/2020 02:00	0.0	0	0	0	0	0
05/26/2020 03:00	0.0	0	0	0	0	0
05/26/2020 04:00	0.0	0	0	0	0	0
05/26/2020 05:00	0.0	0	0	0	0	0
05/26/2020 06:00	0.0	0	0	0	0	0
05/26/2020 07:00	0.0	0	0	0	0	0
05/26/2020 08:00	0.0	0	0	0	0	0
05/26/2020 09:00	0.0	0	0	0	0	0
05/26/2020 10:00	165.3	1	0	0	1	0
05/26/2020 11:00	135.5	1	0	0	0	0
05/26/2020 12:00	110.7	1	0	0	0	0
05/26/2020 13:00	91.1	1	0	0	0	0
05/26/2020 14:00	147.3	1	0	0	0	0
05/26/2020 15:00	16.4	1	0	0	1	0
05/26/2020 16:00	0.0	0	0	0	0	0
05/26/2020 17:00	0.0	0	0	0	0	0
05/26/2020 18:00	0.0	0	0	0	0	0
05/26/2020 19:00	0.0	0	0	0	0	0
05/26/2020 20:00	0.0	0	0	0	0	0
05/26/2020 21:00	0.0	0	0	0	0	0
05/26/2020 22:00	0.0	0	0	0	0	0
05/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	666.3 #	6 #	0 #	0 #	2 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	165.3	1	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/27/2020 00:00	0.0	0	0	0	0	0
05/27/2020 01:00	0.0	0	0	0	0	0
05/27/2020 02:00	0.0	0	0	0	0	0
05/27/2020 03:00	0.0	0	0	0	0	0
05/27/2020 04:00	0.0	0	0	0	0	0
05/27/2020 05:00	0.0	0	0	0	0	0
05/27/2020 06:00	0.0	0	0	0	0	0
05/27/2020 07:00	0.0	0	0	0	0	0
05/27/2020 08:00	0.0	0	0	0	0	0
05/27/2020 09:00	0.0	0	0	0	0	0
05/27/2020 10:00	0.0	0	0	0	0	0
05/27/2020 11:00	0.0	0	0	0	0	0
05/27/2020 12:00	0.0	0	0	0	0	0
05/27/2020 13:00	0.0	0	0	0	0	0
05/27/2020 14:00	0.0	0	0	0	0	0
05/27/2020 15:00	0.0	0	0	0	0	0
05/27/2020 16:00	0.0	0	0	0	0	0
05/27/2020 17:00	0.0	0	0	0	0	0
05/27/2020 18:00	0.0	0	0	0	0	0
05/27/2020 19:00	0.0	0	0	0	0	0
05/27/2020 20:00	0.0	0	0	0	0	0
05/27/2020 21:00	0.0	0	0	0	0	0
05/27/2020 22:00	0.0	0	0	0	0	0
05/27/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/28/2020 00:00	0.0	0	0	0	0	0
05/28/2020 01:00	0.0	0	0	0	0	0
05/28/2020 02:00	0.0	0	0	0	0	0
05/28/2020 03:00	0.0	0	0	0	0	0
05/28/2020 04:00	0.0	0	0	0	0	0
05/28/2020 05:00	0.0	0	0	0	0	0
05/28/2020 06:00	0.0	0	0	0	0	0
05/28/2020 07:00	0.0	0	0	0	0	0
05/28/2020 08:00	0.0	0	0	0	0	0
05/28/2020 09:00	0.0	0	0	0	0	0
05/28/2020 10:00	0.0	0	0	0	0	0
05/28/2020 11:00	0.0	0	0	0	0	0
05/28/2020 12:00	47.9	1	0	0	0	0
05/28/2020 13:00	30.9	1	0	0	0	0
05/28/2020 14:00	40.6	1	0	0	0	0
05/28/2020 15:00	7.8	1	0	0	0	0
05/28/2020 16:00	0.0	0	0	0	0	1
05/28/2020 17:00	0.0	0	0	0	0	1
05/28/2020 18:00	0.0	0	0	0	0	1
05/28/2020 19:00	0.0	0	0	0	0	1
05/28/2020 20:00	0.0	0	0	0	0	1
05/28/2020 21:00	0.0	0	0	0	0	1
05/28/2020 22:00	0.0	0	0	0	0	1
05/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	127.2 #	4 #	0 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	47.9	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/29/2020 00:00	0.0	0	0	0	0	1
05/29/2020 01:00	2.1	0	0	0	1	0
05/29/2020 02:00	0.0	0	0	0	0	0
05/29/2020 03:00	0.0	0	0	0	0	0
05/29/2020 04:00	0.0	0	0	0	0	0
05/29/2020 05:00	0.0	0	0	0	0	0
05/29/2020 06:00	0.0	0	0	0	0	0
05/29/2020 07:00	0.0	0	0	0	0	0
05/29/2020 08:00	0.0	0	0	0	0	0
05/29/2020 09:00	0.0	0	0	0	0	0
05/29/2020 10:00	0.0	0	0	0	0	0
05/29/2020 11:00	0.0	0	0	0	0	0
05/29/2020 12:00	0.0	0	0	0	0	0
05/29/2020 13:00	0.0	0	0	0	0	0
05/29/2020 14:00	0.0	0	0	0	0	0
05/29/2020 15:00	0.0	0	0	0	0	0
05/29/2020 16:00	0.0	0	0	0	0	0
05/29/2020 17:00	0.0	0	0	0	0	0
05/29/2020 18:00	0.0	0	0	0	0	0
05/29/2020 19:00	0.0	0	0	0	0	0
05/29/2020 20:00	0.0	0	0	0	0	0
05/29/2020 21:00	0.0	0	0	0	0	0
05/29/2020 22:00	0.0	0	0	0	0	0
05/29/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.1 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/30/2020 00:00	0.0	0	0	0	0	0
05/30/2020 01:00	0.0	0	0	0	0	0
05/30/2020 02:00	0.0	0	0	0	0	0
05/30/2020 03:00	0.0	0	0	0	0	0
05/30/2020 04:00	0.0	0	0	0	0	0
05/30/2020 05:00	0.0	0	0	0	0	0
05/30/2020 06:00	0.0	0	0	0	0	0
05/30/2020 07:00	0.0	0	0	0	0	0
05/30/2020 08:00	0.0	0	0	0	0	0
05/30/2020 09:00	0.0	0	0	0	0	0
05/30/2020 10:00	0.0	0	0	0	0	0
05/30/2020 11:00	0.0	0	0	0	0	0
05/30/2020 12:00	0.0	0	0	0	0	0
05/30/2020 13:00	0.0	0	0	0	0	0
05/30/2020 14:00	0.0	0	0	0	0	0
05/30/2020 15:00	0.0	0	0	0	0	0
05/30/2020 16:00	0.0	0	0	0	0	0
05/30/2020 17:00	0.0	0	0	0	0	0
05/30/2020 18:00	0.0	0	0	0	0	0
05/30/2020 19:00	0.0	0	0	0	0	0
05/30/2020 20:00	0.0	0	0	0	0	0
05/30/2020 21:00	0.0	0	0	0	0	0
05/30/2020 22:00	0.0	0	0	0	0	0
05/30/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/31/2020 00:00	0.0	0	0	0	0	0
05/31/2020 01:00	0.0	0	0	0	0	0
05/31/2020 02:00	0.0	0	0	0	0	0
05/31/2020 03:00	0.0	0	0	0	0	0
05/31/2020 04:00	0.0	0	0	0	0	0
05/31/2020 05:00	0.0	0	0	0	0	0
05/31/2020 06:00	0.0	0	0	0	0	0
05/31/2020 07:00	0.0	0	0	0	0	0
05/31/2020 08:00	0.0	0	0	0	0	0
05/31/2020 09:00	0.0	0	0	0	0	0
05/31/2020 10:00	0.0	0	0	0	0	0
05/31/2020 11:00	0.0	0	0	0	0	0
05/31/2020 12:00	0.0	0	0	0	0	0
05/31/2020 13:00	0.0	0	0	0	0	0
05/31/2020 14:00	0.0	0	0	0	0	0
05/31/2020 15:00	0.0	0	0	0	0	0
05/31/2020 16:00	0.0	0	0	0	0	0
05/31/2020 17:00	0.0	0	0	0	0	0
05/31/2020 18:00	0.0	0	0	0	0	0
05/31/2020 19:00	0.0	0	0	0	0	0
05/31/2020 20:00	0.0	0	0	0	0	0
05/31/2020 21:00	0.0	0	0	0	0	0
05/31/2020 22:00	0.0	0	0	0	0	0
05/31/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/01/2020 00:00	0.0	0	0	0	0	0
06/01/2020 01:00	0.0	0	0	0	0	0
06/01/2020 02:00	0.0	0	0	0	0	0
06/01/2020 03:00	0.0	0	0	0	0	0
06/01/2020 04:00	0.0	0	0	0	0	0
06/01/2020 05:00	0.0	0	0	0	0	0
06/01/2020 06:00	0.0	0	0	0	0	0
06/01/2020 07:00	0.0	0	0	0	0	0
06/01/2020 08:00	0.0	0	0	0	0	0
06/01/2020 09:00	0.0	0	0	0	0	0
06/01/2020 10:00	0.0	0	0	0	0	0
06/01/2020 11:00	0.0	0	0	0	0	0
06/01/2020 12:00	331.7	1	0	0	0	0
06/01/2020 13:00	27.8	1	0	0	1	0
06/01/2020 14:00	56.6	1	0	0	0	0
06/01/2020 15:00	0.0	0	0	0	0	1
06/01/2020 16:00	0.0	0	0	0	0	1
06/01/2020 17:00	0.0	0	0	0	0	1
06/01/2020 18:00	0.0	0	0	0	0	1
06/01/2020 19:00	0.0	0	0	0	0	1
06/01/2020 20:00	0.0	0	0	0	0	1
06/01/2020 21:00	0.0	0	0	0	0	1
06/01/2020 22:00	0.0	0	0	0	0	1
06/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	416.1 #	3 #	0 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	331.7	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/02/2020 00:00	0.0	0	0	0	0	1
06/02/2020 01:00	0.0	0	0	0	0	1
06/02/2020 02:00	0.0	0	0	0	0	1
06/02/2020 03:00	0.0	0	0	0	0	1
06/02/2020 04:00	0.0	0	0	0	0	1
06/02/2020 05:00	0.0	0	0	0	0	1
06/02/2020 06:00	0.0	0	0	0	0	1
06/02/2020 07:00	0.0	0	0	0	0	1
06/02/2020 08:00	0.0	0	0	0	0	1
06/02/2020 09:00	0.0	0	0	0	0	1
06/02/2020 10:00	0.0	0	0	0	0	1
06/02/2020 11:00	0.0	0	0	0	0	1
06/02/2020 12:00	0.0	0	0	0	0	1
06/02/2020 13:00	0.0	0	0	0	0	1
06/02/2020 14:00	0.0	0	0	0	0	1
06/02/2020 15:00	0.0	0	0	0	0	1
06/02/2020 16:00	0.0	0	0	0	0	1
06/02/2020 17:00	0.0	0	0	0	0	1
06/02/2020 18:00	0.0	0	0	0	0	1
06/02/2020 19:00	0.0	0	0	0	0	1
06/02/2020 20:00	0.0	0	0	0	0	1
06/02/2020 21:00	0.0	0	0	0	0	1
06/02/2020 22:00	0.0	0	0	0	0	1
06/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/03/2020 00:00	0.0	0	0	0	0	1
06/03/2020 01:00	0.0	0	0	0	0	1
06/03/2020 02:00	0.0	0	0	0	0	1
06/03/2020 03:00	0.0	0	0	0	0	1
06/03/2020 04:00	0.0	0	0	0	0	1
06/03/2020 05:00	0.0	0	0	0	0	1
06/03/2020 06:00	0.0	0	0	0	0	1
06/03/2020 07:00	0.0	0	0	0	0	1
06/03/2020 08:00	0.0	0	0	0	0	1
06/03/2020 09:00	0.0	0	0	0	0	1
06/03/2020 10:00	0.0	0	0	0	0	1
06/03/2020 11:00	0.0	0	0	0	0	1
06/03/2020 12:00	0.0	0	0	0	0	1
06/03/2020 13:00	0.0	0	0	0	0	1
06/03/2020 14:00	0.0	0	0	0	0	1
06/03/2020 15:00	0.0	0	0	0	0	1
06/03/2020 16:00	0.0	0	0	0	0	1
06/03/2020 17:00	0.0	0	0	0	0	1
06/03/2020 18:00	0.0	0	0	0	0	1
06/03/2020 19:00	0.0	0	0	0	0	1
06/03/2020 20:00	0.0	0	0	0	0	1
06/03/2020 21:00	0.0	0	0	0	0	1
06/03/2020 22:00	0.0	0	0	0	0	1
06/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/04/2020 00:00	2.8	0	0	0	1	0
06/04/2020 01:00	0.0	0	0	0	0	0
06/04/2020 02:00	0.0	0	0	0	0	0
06/04/2020 03:00	0.0	0	0	0	0	0
06/04/2020 04:00	0.0	0	0	0	0	0
06/04/2020 05:00	0.0	0	0	0	0	0
06/04/2020 06:00	43.3	0	0	1	0	0
06/04/2020 07:00	104.1	0	0	1	0	0
06/04/2020 08:00	0.0	0	0	0	0	1
06/04/2020 09:00	0.0	0	0	0	0	1
06/04/2020 10:00	0.0	0	0	0	0	1
06/04/2020 11:00	0.0	0	0	0	0	1
06/04/2020 12:00	0.0	0	0	0	0	1
06/04/2020 13:00	0.0	0	0	0	0	1
06/04/2020 14:00	0.0	0	0	0	0	1
06/04/2020 15:00	0.0	0	0	0	0	1
06/04/2020 16:00	0.0	0	0	0	0	1
06/04/2020 17:00	0.0	0	0	0	0	1
06/04/2020 18:00	0.0	0	0	0	0	1
06/04/2020 19:00	0.0	0	0	0	0	1
06/04/2020 20:00	0.0	0	0	0	0	1
06/04/2020 21:00	0.0	0	0	0	0	1
06/04/2020 22:00	0.0	0	0	0	0	1
06/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	150.2 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	104.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/05/2020 00:00	2.8	0	0	0	1	0
06/05/2020 01:00	0.0	0	0	0	0	0
06/05/2020 02:00	0.0	0	0	0	0	0
06/05/2020 03:00	0.0	0	0	0	0	0
06/05/2020 04:00	0.0	0	0	0	0	0
06/05/2020 05:00	0.0	0	0	0	0	0
06/05/2020 06:00	0.0	0	0	0	0	0
06/05/2020 07:00	0.0	0	0	0	0	0
06/05/2020 08:00	0.0	0	0	0	0	0
06/05/2020 09:00	0.0	0	0	0	0	0
06/05/2020 10:00	0.0	0	0	0	0	0
06/05/2020 11:00	0.0	0	0	0	0	0
06/05/2020 12:00	0.0	0	0	0	0	0
06/05/2020 13:00	0.0	0	0	0	0	0
06/05/2020 14:00	0.0	0	0	0	0	0
06/05/2020 15:00	0.0	0	0	0	0	0
06/05/2020 16:00	0.0	0	0	0	0	0
06/05/2020 17:00	0.0	0	0	0	0	0
06/05/2020 18:00	0.0	0	0	0	0	0
06/05/2020 19:00	0.0	0	0	0	0	0
06/05/2020 20:00	0.0	0	0	0	0	0
06/05/2020 21:00	0.0	0	0	0	0	0
06/05/2020 22:00	0.0	0	0	0	0	0
06/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.8 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.8	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/06/2020 00:00	0.0	0	0	0	0	0
06/06/2020 01:00	0.0	0	0	0	0	0
06/06/2020 02:00	0.0	0	0	0	0	0
06/06/2020 03:00	0.0	0	0	0	0	0
06/06/2020 04:00	0.0	0	0	0	0	0
06/06/2020 05:00	0.0	0	0	0	0	0
06/06/2020 06:00	0.0	0	0	0	0	0
06/06/2020 07:00	0.0	0	0	0	0	0
06/06/2020 08:00	0.0	0	0	0	0	0
06/06/2020 09:00	0.0	0	0	0	0	0
06/06/2020 10:00	0.0	0	0	0	0	0
06/06/2020 11:00	0.0	0	0	0	0	0
06/06/2020 12:00	0.0	0	0	0	0	0
06/06/2020 13:00	0.0	0	0	0	0	0
06/06/2020 14:00	0.0	0	0	0	0	0
06/06/2020 15:00	0.0	0	0	0	0	0
06/06/2020 16:00	0.0	0	0	0	0	0
06/06/2020 17:00	0.0	0	0	0	0	0
06/06/2020 18:00	0.0	0	0	0	0	0
06/06/2020 19:00	0.0	0	0	0	0	0
06/06/2020 20:00	0.0	0	0	0	0	0
06/06/2020 21:00	0.0	0	0	0	0	0
06/06/2020 22:00	0.0	0	0	0	0	0
06/06/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/07/2020 00:00	0.0	0	0	0	0	0
06/07/2020 01:00	0.0	0	0	0	0	0
06/07/2020 02:00	0.0	0	0	0	0	0
06/07/2020 03:00	0.0	0	0	0	0	0
06/07/2020 04:00	0.0	0	0	0	0	0
06/07/2020 05:00	0.0	0	0	0	0	0
06/07/2020 06:00	0.0	0	0	0	0	0
06/07/2020 07:00	0.0	0	0	0	0	0
06/07/2020 08:00	0.0	0	0	0	0	0
06/07/2020 09:00	0.0	0	0	0	0	0
06/07/2020 10:00	0.0	0	0	0	0	0
06/07/2020 11:00	0.0	0	0	0	0	0
06/07/2020 12:00	0.0	0	0	0	0	0
06/07/2020 13:00	0.0	0	0	0	0	0
06/07/2020 14:00	0.0	0	0	0	0	0
06/07/2020 15:00	0.0	0	0	0	0	0
06/07/2020 16:00	0.0	0	0	0	0	0
06/07/2020 17:00	0.0	0	0	0	0	0
06/07/2020 18:00	0.0	0	0	0	0	0
06/07/2020 19:00	0.0	0	0	0	0	0
06/07/2020 20:00	0.0	0	0	0	0	0
06/07/2020 21:00	0.0	0	0	0	0	0
06/07/2020 22:00	0.0	0	0	0	0	0
06/07/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/08/2020 00:00	0.0	0	0	0	0	0
06/08/2020 01:00	0.0	0	0	0	0	0
06/08/2020 02:00	0.0	0	0	0	0	0
06/08/2020 03:00	0.0	0	0	0	0	0
06/08/2020 04:00	0.0	0	0	0	0	0
06/08/2020 05:00	0.0	0	0	0	0	0
06/08/2020 06:00	0.0	0	0	0	0	0
06/08/2020 07:00	0.0	0	0	0	0	0
06/08/2020 08:00	0.0	0	0	0	0	0
06/08/2020 09:00	0.0	0	0	0	0	0
06/08/2020 10:00	0.0	0	0	0	0	0
06/08/2020 11:00	0.0	0	0	0	0	0
06/08/2020 12:00	0.0	0	0	0	0	0
06/08/2020 13:00	0.0	0	0	0	0	0
06/08/2020 14:00	0.0	0	0	0	0	0
06/08/2020 15:00	326.6	1	0	0	0	0
06/08/2020 16:00	122.6	1	0	0	0	0
06/08/2020 17:00	12.1	1	0	1	1	0
06/08/2020 18:00	15.9	0	0	1	0	0
06/08/2020 19:00	0.0	0	0	0	0	1
06/08/2020 20:00	0.0	0	0	0	0	1
06/08/2020 21:00	0.0	0	0	0	0	1
06/08/2020 22:00	0.0	0	0	0	0	1
06/08/2020 23:00	1.2	0	0	0	1	0
Average/Sum#:	478.4 #	3 #	0 #	2 #	2 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	326.6	1	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/09/2020 00:00	0.0	0	0	0	0	0
06/09/2020 01:00	0.0	0	0	0	0	0
06/09/2020 02:00	0.0	0	0	0	0	0
06/09/2020 03:00	0.0	0	0	0	0	0
06/09/2020 04:00	0.0	0	0	0	0	0
06/09/2020 05:00	0.0	0	0	0	0	0
06/09/2020 06:00	0.0	0	0	0	0	0
06/09/2020 07:00	0.0	0	0	0	0	0
06/09/2020 08:00	0.0	0	0	0	0	0
06/09/2020 09:00	0.0	0	0	0	0	0
06/09/2020 10:00	0.0	0	0	0	0	0
06/09/2020 11:00	0.0	0	0	0	0	0
06/09/2020 12:00	66.5	0	1	0	0	0
06/09/2020 13:00	12.0	0	1	0	1	0
06/09/2020 14:00	94.4	0	1	0	0	0
06/09/2020 15:00	0.0	0	1	0	0	0
06/09/2020 16:00	0.0	0	0	0	0	1
06/09/2020 17:00	0.0	0	0	0	0	1
06/09/2020 18:00	0.0	0	0	0	0	1
06/09/2020 19:00	0.0	0	0	0	0	1
06/09/2020 20:00	0.0	0	0	0	0	1
06/09/2020 21:00	0.0	0	0	0	0	1
06/09/2020 22:00	0.0	0	0	0	0	1
06/09/2020 23:00	3.2	0	0	0	1	0
Average/Sum#:	176.1 #	0 #	4 #	0 #	2 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	94.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/10/2020 00:00	0.0	0	0	0	0	0
06/10/2020 01:00	0.0	0	0	0	0	0
06/10/2020 02:00	0.0	0	0	0	0	0
06/10/2020 03:00	0.0	0	0	0	0	0
06/10/2020 04:00	0.0	0	0	0	0	0
06/10/2020 05:00	0.0	0	0	0	0	0
06/10/2020 06:00	0.0	0	0	0	0	0
06/10/2020 07:00	0.0	0	0	0	0	0
06/10/2020 08:00	0.0	0	0	0	0	0
06/10/2020 09:00	0.0	0	0	0	0	0
06/10/2020 10:00	96.3	0	1	0	0	0
06/10/2020 11:00	248.8	0	1	0	0	0
06/10/2020 12:00	5.1	0	1	0	0	0
06/10/2020 13:00	0.0	0	0	0	0	1
06/10/2020 14:00	0.0	0	0	0	0	1
06/10/2020 15:00	0.0	0	0	0	0	1
06/10/2020 16:00	0.0	0	0	0	0	1
06/10/2020 17:00	0.0	0	0	0	0	1
06/10/2020 18:00	0.0	0	0	0	0	1
06/10/2020 19:00	0.0	0	0	0	0	1
06/10/2020 20:00	0.0	0	0	0	0	1
06/10/2020 21:00	0.0	0	0	0	0	1
06/10/2020 22:00	0.0	0	0	0	0	1
06/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	350.2 #	0 #	3 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	248.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/11/2020 00:00	0.0	0	0	0	0	1
06/11/2020 01:00	0.0	0	0	0	0	1
06/11/2020 02:00	0.0	0	0	0	0	1
06/11/2020 03:00	0.0	0	0	0	0	1
06/11/2020 04:00	0.0	0	0	0	0	1
06/11/2020 05:00	0.0	0	0	0	0	1
06/11/2020 06:00	0.0	0	0	0	0	1
06/11/2020 07:00	0.0	0	0	0	0	1
06/11/2020 08:00	0.0	0	0	0	0	1
06/11/2020 09:00	0.0	0	0	0	0	1
06/11/2020 10:00	0.0	0	0	0	0	1
06/11/2020 11:00	0.0	0	0	0	0	1
06/11/2020 12:00	0.0	0	0	0	0	1
06/11/2020 13:00	0.0	0	0	0	0	1
06/11/2020 14:00	0.0	0	0	0	0	1
06/11/2020 15:00	0.0	0	0	0	0	1
06/11/2020 16:00	0.0	0	0	0	0	1
06/11/2020 17:00	0.0	0	0	0	0	1
06/11/2020 18:00	0.0	0	0	0	0	1
06/11/2020 19:00	0.0	0	0	0	0	1
06/11/2020 20:00	0.0	0	0	0	0	1
06/11/2020 21:00	0.0	0	0	0	0	1
06/11/2020 22:00	0.0	0	0	0	0	1
06/11/2020 23:00	3.2	0	0	0	1	0
Average/Sum#:	3.2 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/12/2020 00:00	0.0	0	0	0	0	0
06/12/2020 01:00	0.0	0	0	0	0	0
06/12/2020 02:00	0.0	0	0	0	0	0
06/12/2020 03:00	0.0	0	0	0	0	0
06/12/2020 04:00	0.0	0	0	0	0	0
06/12/2020 05:00	0.0	0	0	0	0	0
06/12/2020 06:00	0.0	0	0	0	0	0
06/12/2020 07:00	0.0	0	0	0	0	0
06/12/2020 08:00	0.0	0	0	0	0	0
06/12/2020 09:00	0.0	0	0	0	0	0
06/12/2020 10:00	0.0	0	0	0	0	0
06/12/2020 11:00	0.0	0	0	0	0	0
06/12/2020 12:00	0.0	0	0	0	0	0
06/12/2020 13:00	0.0	0	0	0	0	0
06/12/2020 14:00	0.0	0	0	0	0	0
06/12/2020 15:00	0.0	0	0	0	0	0
06/12/2020 16:00	0.0	0	0	0	0	0
06/12/2020 17:00	0.0	0	0	0	0	0
06/12/2020 18:00	0.0	0	0	0	0	0
06/12/2020 19:00	0.0	0	0	0	0	0
06/12/2020 20:00	0.0	0	0	0	0	0
06/12/2020 21:00	0.0	0	0	0	0	0
06/12/2020 22:00	0.0	0	0	0	0	0
06/12/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/13/2020 00:00	0.0	0	0	0	0	0
06/13/2020 01:00	0.0	0	0	0	0	0
06/13/2020 02:00	0.0	0	0	0	0	0
06/13/2020 03:00	0.0	0	0	0	0	0
06/13/2020 04:00	0.0	0	0	0	0	0
06/13/2020 05:00	0.0	0	0	0	0	0
06/13/2020 06:00	0.0	0	0	0	0	0
06/13/2020 07:00	0.0	0	0	0	0	0
06/13/2020 08:00	0.0	0	0	0	0	0
06/13/2020 09:00	0.0	0	0	0	0	0
06/13/2020 10:00	0.0	0	0	0	0	0
06/13/2020 11:00	0.0	0	0	0	0	0
06/13/2020 12:00	0.0	0	0	0	0	0
06/13/2020 13:00	0.0	0	0	0	0	0
06/13/2020 14:00	0.0	0	0	0	0	0
06/13/2020 15:00	0.0	0	0	0	0	0
06/13/2020 16:00	0.0	0	0	0	0	0
06/13/2020 17:00	0.0	0	0	0	0	0
06/13/2020 18:00	0.0	0	0	0	0	0
06/13/2020 19:00	0.0	0	0	0	0	0
06/13/2020 20:00	0.0	0	0	0	0	0
06/13/2020 21:00	0.0	0	0	0	0	0
06/13/2020 22:00	0.0	0	0	0	0	0
06/13/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/14/2020 00:00	0.0	0	0	0	0	0
06/14/2020 01:00	0.0	0	0	0	0	0
06/14/2020 02:00	0.0	0	0	0	0	0
06/14/2020 03:00	0.0	0	0	0	0	0
06/14/2020 04:00	0.0	0	0	0	0	0
06/14/2020 05:00	0.0	0	0	0	0	0
06/14/2020 06:00	0.0	0	0	0	0	0
06/14/2020 07:00	0.0	0	0	0	0	0
06/14/2020 08:00	0.0	0	0	0	0	0
06/14/2020 09:00	0.0	0	0	0	0	0
06/14/2020 10:00	0.0	0	0	0	0	0
06/14/2020 11:00	0.0	0	0	0	0	0
06/14/2020 12:00	0.0	0	0	0	0	0
06/14/2020 13:00	0.0	0	0	0	0	0
06/14/2020 14:00	0.0	0	0	0	0	0
06/14/2020 15:00	0.0	0	0	0	0	0
06/14/2020 16:00	0.0	0	0	0	0	0
06/14/2020 17:00	0.0	0	0	0	0	0
06/14/2020 18:00	0.0	0	0	0	0	0
06/14/2020 19:00	0.0	0	0	0	0	0
06/14/2020 20:00	0.0	0	0	0	0	0
06/14/2020 21:00	0.0	0	0	0	0	0
06/14/2020 22:00	0.0	0	0	0	0	0
06/14/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/15/2020 00:00	0.0	0	0	0	0	0
06/15/2020 01:00	0.0	0	0	0	0	0
06/15/2020 02:00	0.0	0	0	0	0	0
06/15/2020 03:00	0.0	0	0	0	0	0
06/15/2020 04:00	0.0	0	0	0	0	0
06/15/2020 05:00	0.0	0	0	0	0	0
06/15/2020 06:00	0.0	0	0	0	0	0
06/15/2020 07:00	0.0	0	0	0	0	0
06/15/2020 08:00	0.0	0	0	0	0	0
06/15/2020 09:00	0.0	0	0	0	0	0
06/15/2020 10:00	0.0	0	0	0	0	0
06/15/2020 11:00	0.0	0	0	0	0	0
06/15/2020 12:00	0.0	0	0	0	0	0
06/15/2020 13:00	0.0	0	0	0	0	0
06/15/2020 14:00	0.0	0	0	0	0	0
06/15/2020 15:00	0.0	0	0	0	0	0
06/15/2020 16:00	0.0	0	0	0	0	0
06/15/2020 17:00	0.0	0	0	0	0	0
06/15/2020 18:00	0.0	0	0	0	0	0
06/15/2020 19:00	0.0	0	0	0	0	0
06/15/2020 20:00	0.0	0	0	0	0	0
06/15/2020 21:00	0.0	0	0	0	0	0
06/15/2020 22:00	0.0	0	0	0	0	0
06/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/16/2020 00:00	0.0	0	0	0	0	0
06/16/2020 01:00	0.0	0	0	0	0	0
06/16/2020 02:00	0.0	0	0	0	0	0
06/16/2020 03:00	0.0	0	0	0	0	0
06/16/2020 04:00	0.0	0	0	0	0	0
06/16/2020 05:00	0.0	0	0	0	0	0
06/16/2020 06:00	0.0	0	0	0	0	0
06/16/2020 07:00	0.0	0	0	0	0	0
06/16/2020 08:00	0.0	0	0	0	0	0
06/16/2020 09:00	0.0	0	0	0	0	0
06/16/2020 10:00	0.0	0	0	0	0	0
06/16/2020 11:00	0.0	0	0	0	0	0
06/16/2020 12:00	0.0	0	0	0	0	0
06/16/2020 13:00	0.0	0	0	0	0	0
06/16/2020 14:00	0.0	0	0	0	0	0
06/16/2020 15:00	0.0	0	0	0	0	0
06/16/2020 16:00	0.0	0	0	0	0	0
06/16/2020 17:00	0.0	0	0	0	0	0
06/16/2020 18:00	0.0	0	0	0	0	0
06/16/2020 19:00	0.0	0	0	0	0	0
06/16/2020 20:00	0.0	0	0	0	0	0
06/16/2020 21:00	0.0	0	0	0	0	0
06/16/2020 22:00	0.0	0	0	0	0	0
06/16/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/17/2020 00:00	0.0	0	0	0	0	0
06/17/2020 01:00	0.0	0	0	0	0	0
06/17/2020 02:00	0.0	0	0	0	0	0
06/17/2020 03:00	0.0	0	0	0	0	0
06/17/2020 04:00	0.0	0	0	0	0	0
06/17/2020 05:00	0.0	0	0	0	0	0
06/17/2020 06:00	0.0	0	0	0	0	0
06/17/2020 07:00	0.0	0	0	0	0	0
06/17/2020 08:00	0.0	0	0	0	0	0
06/17/2020 09:00	0.0	0	0	0	0	0
06/17/2020 10:00	0.0	0	0	0	0	0
06/17/2020 11:00	0.0	0	0	0	0	0
06/17/2020 12:00	337.7	1	0	0	0	0
06/17/2020 13:00	122.4	1	0	0	0	0
06/17/2020 14:00	88.5	1	0	0	0	0
06/17/2020 15:00	67.8	1	0	0	0	0
06/17/2020 16:00	0.0	0	0	0	0	1
06/17/2020 17:00	0.0	0	0	0	0	1
06/17/2020 18:00	0.0	0	0	0	0	1
06/17/2020 19:00	0.0	0	0	0	0	1
06/17/2020 20:00	0.0	0	0	0	0	1
06/17/2020 21:00	0.0	0	0	0	0	1
06/17/2020 22:00	0.0	0	0	0	0	1
06/17/2020 23:00	2.9	0	0	0	1	0
Average/Sum#:	619.3 #	4 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	337.7	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/18/2020 00:00	0.0	0	0	0	0	0
06/18/2020 01:00	0.0	0	0	0	0	0
06/18/2020 02:00	0.0	0	0	0	0	0
06/18/2020 03:00	0.0	0	0	0	0	0
06/18/2020 04:00	0.0	0	0	0	0	0
06/18/2020 05:00	0.0	0	0	0	0	0
06/18/2020 06:00	0.0	0	0	0	0	0
06/18/2020 07:00	0.0	0	0	0	0	0
06/18/2020 08:00	0.0	0	0	0	0	0
06/18/2020 09:00	0.0	0	0	0	0	0
06/18/2020 10:00	0.0	0	0	0	0	0
06/18/2020 11:00	57.8	0	1	0	0	0
06/18/2020 12:00	36.4	0	1	0	0	0
06/18/2020 13:00	0.0	0	0	0	0	1
06/18/2020 14:00	0.0	0	0	0	0	1
06/18/2020 15:00	0.0	0	0	0	0	1
06/18/2020 16:00	0.0	0	0	0	0	1
06/18/2020 17:00	0.0	0	0	0	0	1
06/18/2020 18:00	0.0	0	0	0	0	1
06/18/2020 19:00	0.0	0	0	0	0	1
06/18/2020 20:00	0.0	0	0	0	0	1
06/18/2020 21:00	0.0	0	0	0	0	1
06/18/2020 22:00	0.0	0	0	0	0	1
06/18/2020 23:00	6.7	0	0	0	1	0
Average/Sum#:	100.9 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	57.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/19/2020 00:00	0.0	0	0	0	0	0
06/19/2020 01:00	0.0	0	0	0	0	0
06/19/2020 02:00	0.0	0	0	0	0	0
06/19/2020 03:00	0.0	0	0	0	0	0
06/19/2020 04:00	0.0	0	0	0	0	0
06/19/2020 05:00	0.0	0	0	0	0	0
06/19/2020 06:00	0.0	0	0	0	0	0
06/19/2020 07:00	0.0	0	0	0	0	0
06/19/2020 08:00	0.0	0	0	0	0	0
06/19/2020 09:00	0.0	0	0	0	0	0
06/19/2020 10:00	0.0	0	0	0	0	0
06/19/2020 11:00	0.0	0	0	0	0	0
06/19/2020 12:00	0.0	0	0	0	0	0
06/19/2020 13:00	0.0	0	0	0	0	0
06/19/2020 14:00	0.0	0	0	0	0	0
06/19/2020 15:00	0.0	0	0	0	0	0
06/19/2020 16:00	0.0	0	0	0	0	0
06/19/2020 17:00	0.0	0	0	0	0	0
06/19/2020 18:00	0.0	0	0	0	0	0
06/19/2020 19:00	0.0	0	0	0	0	0
06/19/2020 20:00	0.0	0	0	0	0	0
06/19/2020 21:00	0.0	0	0	0	0	0
06/19/2020 22:00	0.0	0	0	0	0	0
06/19/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/20/2020 00:00	0.0	0	0	0	0	0
06/20/2020 01:00	0.0	0	0	0	0	0
06/20/2020 02:00	0.0	0	0	0	0	0
06/20/2020 03:00	0.0	0	0	0	0	0
06/20/2020 04:00	0.0	0	0	0	0	0
06/20/2020 05:00	0.0	0	0	0	0	0
06/20/2020 06:00	0.0	0	0	0	0	0
06/20/2020 07:00	0.0	0	0	0	0	0
06/20/2020 08:00	0.0	0	0	0	0	0
06/20/2020 09:00	0.0	0	0	0	0	0
06/20/2020 10:00	0.0	0	0	0	0	0
06/20/2020 11:00	0.0	0	0	0	0	0
06/20/2020 12:00	0.0	0	0	0	0	0
06/20/2020 13:00	0.0	0	0	0	0	0
06/20/2020 14:00	0.0	0	0	0	0	0
06/20/2020 15:00	0.0	0	0	0	0	0
06/20/2020 16:00	0.0	0	0	0	0	0
06/20/2020 17:00	0.0	0	0	0	0	0
06/20/2020 18:00	0.0	0	0	0	0	0
06/20/2020 19:00	0.0	0	0	0	0	0
06/20/2020 20:00	0.0	0	0	0	0	0
06/20/2020 21:00	0.0	0	0	0	0	0
06/20/2020 22:00	0.0	0	0	0	0	0
06/20/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/21/2020 00:00	0.0	0	0	0	0	0
06/21/2020 01:00	0.0	0	0	0	0	0
06/21/2020 02:00	0.0	0	0	0	0	0
06/21/2020 03:00	0.0	0	0	0	0	0
06/21/2020 04:00	0.0	0	0	0	0	0
06/21/2020 05:00	0.0	0	0	0	0	0
06/21/2020 06:00	0.0	0	0	0	0	0
06/21/2020 07:00	0.0	0	0	0	0	0
06/21/2020 08:00	0.0	0	0	0	0	0
06/21/2020 09:00	0.0	0	0	0	0	0
06/21/2020 10:00	0.0	0	0	0	0	0
06/21/2020 11:00	0.0	0	0	0	0	0
06/21/2020 12:00	0.0	0	0	0	0	0
06/21/2020 13:00	0.0	0	0	0	0	0
06/21/2020 14:00	0.0	0	0	0	0	0
06/21/2020 15:00	0.0	0	0	0	0	0
06/21/2020 16:00	0.0	0	0	0	0	0
06/21/2020 17:00	0.0	0	0	0	0	0
06/21/2020 18:00	0.0	0	0	0	0	0
06/21/2020 19:00	0.0	0	0	0	0	0
06/21/2020 20:00	0.0	0	0	0	0	0
06/21/2020 21:00	0.0	0	0	0	0	0
06/21/2020 22:00	0.0	0	0	0	0	0
06/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/22/2020 00:00	0.0	0	0	0	0	0
06/22/2020 01:00	0.0	0	0	0	0	0
06/22/2020 02:00	0.0	0	0	0	0	0
06/22/2020 03:00	0.0	0	0	0	0	0
06/22/2020 04:00	0.0	0	0	0	0	0
06/22/2020 05:00	0.0	0	0	0	0	0
06/22/2020 06:00	0.0	0	0	0	0	0
06/22/2020 07:00	0.0	0	0	0	0	0
06/22/2020 08:00	0.0	0	0	0	0	0
06/22/2020 09:00	444.0	1	0	0	0	0
06/22/2020 10:00	12.9	1	0	0	1	0
06/22/2020 11:00	187.4	1	0	0	0	0
06/22/2020 12:00	4.4	1	0	0	0	0
06/22/2020 13:00	0.0	0	0	0	0	1
06/22/2020 14:00	0.0	0	0	0	0	1
06/22/2020 15:00	0.0	0	0	0	0	1
06/22/2020 16:00	0.0	0	0	0	0	1
06/22/2020 17:00	0.0	0	0	0	0	1
06/22/2020 18:00	0.0	0	0	0	0	1
06/22/2020 19:00	0.0	0	0	0	0	1
06/22/2020 20:00	0.0	0	0	0	0	1
06/22/2020 21:00	0.0	0	0	0	0	1
06/22/2020 22:00	0.0	0	0	0	0	1
06/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	648.7 #	4 #	0 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	444.0	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/23/2020 00:00	4.2	0	0	0	1	0
06/23/2020 01:00	0.0	0	0	0	0	0
06/23/2020 02:00	0.0	0	0	0	0	0
06/23/2020 03:00	0.0	0	0	0	0	0
06/23/2020 04:00	0.0	0	0	0	0	0
06/23/2020 05:00	0.0	0	0	0	0	0
06/23/2020 06:00	0.0	0	0	0	0	0
06/23/2020 07:00	1.0	0	0	1	0	0
06/23/2020 08:00	85.6	0	0	1	0	0
06/23/2020 09:00	0.1	0	0	1	0	0
06/23/2020 10:00	0.0	0	0	0	0	1
06/23/2020 11:00	0.0	0	0	0	0	1
06/23/2020 12:00	0.0	0	0	0	0	1
06/23/2020 13:00	0.0	0	0	0	0	1
06/23/2020 14:00	0.0	0	0	0	0	1
06/23/2020 15:00	0.0	0	0	0	0	1
06/23/2020 16:00	0.0	0	0	0	0	1
06/23/2020 17:00	0.0	0	0	0	0	1
06/23/2020 18:00	0.0	0	0	0	0	1
06/23/2020 19:00	0.0	0	0	0	0	1
06/23/2020 20:00	0.0	0	0	0	0	1
06/23/2020 21:00	0.0	0	0	0	0	1
06/23/2020 22:00	0.0	0	0	0	0	1
06/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	90.9 #	0 #	0 #	3 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	85.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/24/2020 00:00	0.0	0	0	0	0	1
06/24/2020 01:00	0.0	0	0	0	0	1
06/24/2020 02:00	0.0	0	0	0	0	1
06/24/2020 03:00	0.0	0	0	0	0	1
06/24/2020 04:00	0.0	0	0	0	0	1
06/24/2020 05:00	0.0	0	0	0	0	1
06/24/2020 06:00	0.0	0	0	0	0	1
06/24/2020 07:00	0.0	0	0	0	0	1
06/24/2020 08:00	0.0	0	0	0	0	1
06/24/2020 09:00	0.0	0	0	0	0	1
06/24/2020 10:00	0.0	0	0	0	0	1
06/24/2020 11:00	0.0	0	0	0	0	1
06/24/2020 12:00	0.0	0	0	0	0	1
06/24/2020 13:00	0.0	0	0	0	0	1
06/24/2020 14:00	0.0	0	0	0	0	1
06/24/2020 15:00	0.0	0	0	0	0	1
06/24/2020 16:00	0.0	0	0	0	0	1
06/24/2020 17:00	0.0	0	0	0	0	1
06/24/2020 18:00	0.0	0	0	0	0	1
06/24/2020 19:00	0.0	0	0	0	0	1
06/24/2020 20:00	0.0	0	0	0	0	1
06/24/2020 21:00	0.0	0	0	0	0	1
06/24/2020 22:00	0.0	0	0	0	0	1
06/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/25/2020 00:00	2.1	0	0	0	1	0
06/25/2020 01:00	0.0	0	0	0	0	0
06/25/2020 02:00	0.0	0	0	0	0	0
06/25/2020 03:00	0.0	0	0	0	0	0
06/25/2020 04:00	0.0	0	0	0	0	0
06/25/2020 05:00	0.0	0	0	0	0	0
06/25/2020 06:00	0.0	0	0	0	0	0
06/25/2020 07:00	0.0	0	0	0	0	0
06/25/2020 08:00	0.0	0	0	0	0	0
06/25/2020 09:00	0.0	0	0	0	0	0
06/25/2020 10:00	0.0	0	0	0	0	0
06/25/2020 11:00	0.0	0	0	0	0	0
06/25/2020 12:00	9.6	0	1	0	0	0
06/25/2020 13:00	26.2	0	1	0	0	0
06/25/2020 14:00	0.0	0	0	0	0	1
06/25/2020 15:00	0.0	0	0	0	0	1
06/25/2020 16:00	0.0	0	0	0	0	1
06/25/2020 17:00	0.0	0	0	0	0	1
06/25/2020 18:00	0.0	0	0	0	0	1
06/25/2020 19:00	0.0	0	0	0	0	1
06/25/2020 20:00	0.0	0	0	0	0	1
06/25/2020 21:00	0.0	0	0	0	0	1
06/25/2020 22:00	1.7	0	0	0	1	0
06/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	39.6 #	0 #	2 #	0 #	2 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	26.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/26/2020 00:00	0.0	0	0	0	0	0
06/26/2020 01:00	0.0	0	0	0	0	0
06/26/2020 02:00	0.0	0	0	0	0	0
06/26/2020 03:00	0.0	0	0	0	0	0
06/26/2020 04:00	0.0	0	0	0	0	0
06/26/2020 05:00	0.0	0	0	0	0	0
06/26/2020 06:00	0.0	0	0	0	0	0
06/26/2020 07:00	0.0	0	0	0	0	0
06/26/2020 08:00	0.0	0	0	0	0	0
06/26/2020 09:00	0.0	0	0	0	0	0
06/26/2020 10:00	8.1	0	1	0	0	0
06/26/2020 11:00	36.3	0	1	0	0	0
06/26/2020 12:00	2.7	0	0	0	1	0
06/26/2020 13:00	0.0	0	0	0	0	0
06/26/2020 14:00	0.0	0	0	0	0	0
06/26/2020 15:00	0.0	0	0	0	0	0
06/26/2020 16:00	20.7	0	0	1	0	0
06/26/2020 17:00	4.8	0	0	1	0	0
06/26/2020 18:00	0.0	0	0	0	0	1
06/26/2020 19:00	0.0	0	0	0	0	1
06/26/2020 20:00	0.0	0	0	0	0	1
06/26/2020 21:00	0.0	0	0	0	0	1
06/26/2020 22:00	0.0	0	0	0	0	1
06/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	72.6 #	0 #	2 #	2 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	36.3	0	1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/27/2020 00:00	1.0	0	0	0	1	0
06/27/2020 01:00	0.0	0	0	0	0	0
06/27/2020 02:00	0.0	0	0	0	0	0
06/27/2020 03:00	0.0	0	0	0	0	0
06/27/2020 04:00	0.0	0	0	0	0	0
06/27/2020 05:00	0.0	0	0	0	0	0
06/27/2020 06:00	0.0	0	0	0	0	0
06/27/2020 07:00	0.0	0	0	0	0	0
06/27/2020 08:00	0.0	0	0	0	0	0
06/27/2020 09:00	0.0	0	0	0	0	0
06/27/2020 10:00	0.0	0	0	0	0	0
06/27/2020 11:00	0.0	0	0	0	0	0
06/27/2020 12:00	0.0	0	0	0	0	0
06/27/2020 13:00	0.0	0	0	0	0	0
06/27/2020 14:00	0.0	0	0	0	0	0
06/27/2020 15:00	0.0	0	0	0	0	0
06/27/2020 16:00	0.0	0	0	0	0	0
06/27/2020 17:00	0.0	0	0	0	0	0
06/27/2020 18:00	0.0	0	0	0	0	0
06/27/2020 19:00	0.0	0	0	0	0	0
06/27/2020 20:00	0.0	0	0	0	0	0
06/27/2020 21:00	0.0	0	0	0	0	0
06/27/2020 22:00	0.0	0	0	0	0	0
06/27/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.0 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.0	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/28/2020 00:00	0.0	0	0	0	0	0
06/28/2020 01:00	0.0	0	0	0	0	0
06/28/2020 02:00	0.0	0	0	0	0	0
06/28/2020 03:00	0.0	0	0	0	0	0
06/28/2020 04:00	0.0	0	0	0	0	0
06/28/2020 05:00	0.0	0	0	0	0	0
06/28/2020 06:00	0.0	0	0	0	0	0
06/28/2020 07:00	0.0	0	0	0	0	0
06/28/2020 08:00	0.0	0	0	0	0	0
06/28/2020 09:00	0.0	0	0	0	0	0
06/28/2020 10:00	0.0	0	0	0	0	0
06/28/2020 11:00	0.0	0	0	0	0	0
06/28/2020 12:00	0.0	0	0	0	0	0
06/28/2020 13:00	0.0	0	0	0	0	0
06/28/2020 14:00	0.0	0	0	0	0	0
06/28/2020 15:00	0.0	0	0	0	0	0
06/28/2020 16:00	0.0	0	0	0	0	0
06/28/2020 17:00	0.0	0	0	0	0	0
06/28/2020 18:00	0.0	0	0	0	0	0
06/28/2020 19:00	0.0	0	0	0	0	0
06/28/2020 20:00	0.0	0	0	0	0	0
06/28/2020 21:00	0.0	0	0	0	0	0
06/28/2020 22:00	0.0	0	0	0	0	0
06/28/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/29/2020 00:00	0.0	0	0	0	0	0
06/29/2020 01:00	0.0	0	0	0	0	0
06/29/2020 02:00	0.0	0	0	0	0	0
06/29/2020 03:00	0.0	0	0	0	0	0
06/29/2020 04:00	0.0	0	0	0	0	0
06/29/2020 05:00	0.0	0	0	0	0	0
06/29/2020 06:00	0.0	0	0	0	0	0
06/29/2020 07:00	0.0	0	0	0	0	0
06/29/2020 08:00	0.0	0	0	0	0	0
06/29/2020 09:00	0.0	0	0	0	0	0
06/29/2020 10:00	0.0	0	0	0	0	0
06/29/2020 11:00	0.0	0	0	0	0	0
06/29/2020 12:00	0.0	0	0	0	0	0
06/29/2020 13:00	0.0	0	0	0	0	0
06/29/2020 14:00	0.0	0	0	0	0	0
06/29/2020 15:00	0.0	0	0	0	0	0
06/29/2020 16:00	0.0	0	0	0	0	0
06/29/2020 17:00	0.0	0	0	0	0	0
06/29/2020 18:00	0.0	0	0	0	0	0
06/29/2020 19:00	0.0	0	0	0	0	0
06/29/2020 20:00	0.0	0	0	0	0	0
06/29/2020 21:00	0.0	0	0	0	0	0
06/29/2020 22:00	0.0	0	0	0	0	0
06/29/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/30/2020 00:00	0.0	0	0	0	0	0
06/30/2020 01:00	0.0	0	0	0	0	0
06/30/2020 02:00	0.0	0	0	0	0	0
06/30/2020 03:00	0.0	0	0	0	0	0
06/30/2020 04:00	0.0	0	0	0	0	0
06/30/2020 05:00	0.0	0	0	0	0	0
06/30/2020 06:00	0.0	0	0	0	0	0
06/30/2020 07:00	0.0	0	0	0	0	0
06/30/2020 08:00	0.0	0	0	0	0	0
06/30/2020 09:00	0.0	0	0	0	0	0
06/30/2020 10:00	0.0	0	0	0	0	0
06/30/2020 11:00	0.0	0	0	0	0	0
06/30/2020 12:00	0.0	0	0	0	0	0
06/30/2020 13:00	0.0	0	0	0	0	0
06/30/2020 14:00	59.5	1	0	0	0	0
06/30/2020 15:00	40.9	1	0	0	0	0
06/30/2020 16:00	0.0	0	0	0	0	1
06/30/2020 17:00	0.0	0	0	0	0	1
06/30/2020 18:00	0.0	0	0	0	0	1
06/30/2020 19:00	0.0	0	0	0	0	1
06/30/2020 20:00	0.0	0	0	0	0	1
06/30/2020 21:00	0.0	0	0	0	0	1
06/30/2020 22:00	1.7	0	0	0	1	0
06/30/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	102.1 #	2 #	0 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	59.5	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/01/2020 00:00	0.0	0	0	0	0	0
04/01/2020 01:00	0.0	0	0	0	0	0
04/01/2020 02:00	0.0	0	0	0	0	0
04/01/2020 03:00	987.3	0	1	0	0	0
04/01/2020 04:00	6,748.9	0	1	0	0	0
04/01/2020 05:00	0.0	0	0	0	0	1
04/01/2020 06:00	0.0	0	0	0	0	1
04/01/2020 07:00	0.0	0	0	0	0	1
04/01/2020 08:00	0.0	0	0	0	0	1
04/01/2020 09:00	0.0	0	0	0	0	1
04/01/2020 10:00	0.0	0	0	0	0	1
04/01/2020 11:00	0.0	0	0	0	0	1
04/01/2020 12:00	0.0	0	0	0	0	1
04/01/2020 13:00	0.0	0	0	0	0	1
04/01/2020 14:00	0.0	0	0	0	0	1
04/01/2020 15:00	0.0	0	0	0	0	1
04/01/2020 16:00	0.0	0	0	0	0	1
04/01/2020 17:00	0.0	0	0	0	0	1
04/01/2020 18:00	0.0	0	0	0	0	1
04/01/2020 19:00	0.0	0	0	0	0	1
04/01/2020 20:00	0.0	0	0	0	0	1
04/01/2020 21:00	0.0	0	0	0	0	1
04/01/2020 22:00	0.0	0	0	0	0	1
04/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,736.2 #	0 #	2 #	0 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,748.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/02/2020 00:00	0.0	0	0	0	0	1
04/02/2020 01:00	0.0	0	0	0	0	1
04/02/2020 02:00	0.0	0	0	0	0	1
04/02/2020 03:00	0.0	0	0	0	0	1
04/02/2020 04:00	0.0	0	0	0	0	1
04/02/2020 05:00	0.0	0	0	0	0	1
04/02/2020 06:00	0.0	0	0	0	0	1
04/02/2020 07:00	0.0	0	0	0	0	1
04/02/2020 08:00	0.0	0	0	0	0	1
04/02/2020 09:00	0.0	0	0	0	0	1
04/02/2020 10:00	0.0	0	0	0	0	1
04/02/2020 11:00	0.0	0	0	0	0	1
04/02/2020 12:00	0.0	0	0	0	0	1
04/02/2020 13:00	0.0	0	0	0	0	1
04/02/2020 14:00	0.0	0	0	0	0	1
04/02/2020 15:00	0.0	0	0	0	0	1
04/02/2020 16:00	0.0	0	0	0	0	1
04/02/2020 17:00	0.0	0	0	0	0	1
04/02/2020 18:00	0.0	0	0	0	0	1
04/02/2020 19:00	0.0	0	0	0	0	1
04/02/2020 20:00	0.0	0	0	0	0	1
04/02/2020 21:00	84.0	0	0	0	1	0
04/02/2020 22:00	0.0	0	0	0	0	0
04/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	84.0 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	84.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/03/2020 00:00	0.0	0	0	0	0	0
04/03/2020 01:00	0.0	0	0	0	0	0
04/03/2020 02:00	0.0	0	0	0	0	0
04/03/2020 03:00	0.0	0	0	0	0	0
04/03/2020 04:00	0.0	0	0	0	0	0
04/03/2020 05:00	0.0	0	0	0	0	0
04/03/2020 06:00	0.0	0	0	0	0	0
04/03/2020 07:00	0.0	0	0	0	0	0
04/03/2020 08:00	0.0	0	0	0	0	0
04/03/2020 09:00	0.0	0	0	0	0	0
04/03/2020 10:00	0.0	0	0	0	0	0
04/03/2020 11:00	0.0	0	0	0	0	0
04/03/2020 12:00	0.0	0	0	0	0	0
04/03/2020 13:00	0.0	0	0	0	0	0
04/03/2020 14:00	0.0	0	0	0	0	0
04/03/2020 15:00	0.0	0	0	0	0	0
04/03/2020 16:00	0.0	0	0	0	0	0
04/03/2020 17:00	0.0	0	0	0	0	0
04/03/2020 18:00	0.0	0	0	0	0	0
04/03/2020 19:00	0.0	0	0	0	0	0
04/03/2020 20:00	0.0	0	0	0	0	0
04/03/2020 21:00	0.0	0	0	0	0	0
04/03/2020 22:00	0.0	0	0	0	0	0
04/03/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/04/2020 00:00	0.0	0	0	0	0	0
04/04/2020 01:00	4,256.3	0	1	0	0	0
04/04/2020 02:00	5,274.5	0	1	0	0	0
04/04/2020 03:00	0.0	0	0	0	0	1
04/04/2020 04:00	0.0	0	0	0	0	1
04/04/2020 05:00	0.0	0	0	0	0	1
04/04/2020 06:00	0.0	0	0	0	0	1
04/04/2020 07:00	0.0	0	0	0	0	1
04/04/2020 08:00	0.0	0	0	0	0	1
04/04/2020 09:00	0.0	0	0	0	0	1
04/04/2020 10:00	0.0	0	0	0	0	1
04/04/2020 11:00	0.0	0	0	0	0	1
04/04/2020 12:00	0.0	0	0	0	0	1
04/04/2020 13:00	0.0	0	0	0	0	1
04/04/2020 14:00	0.0	0	0	0	0	1
04/04/2020 15:00	0.0	0	0	0	0	1
04/04/2020 16:00	0.0	0	0	0	0	1
04/04/2020 17:00	0.0	0	0	0	0	1
04/04/2020 18:00	0.0	0	0	0	0	1
04/04/2020 19:00	0.0	0	0	0	0	1
04/04/2020 20:00	0.0	0	0	0	0	1
04/04/2020 21:00	0.0	0	0	0	0	1
04/04/2020 22:00	0.0	0	0	0	0	1
04/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,530.8 #	0 #	2 #	0 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,274.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/05/2020 00:00	0.0	0	0	0	0	1
04/05/2020 01:00	0.0	0	0	0	0	1
04/05/2020 02:00	0.0	0	0	0	0	1
04/05/2020 03:00	0.0	0	0	0	0	1
04/05/2020 04:00	0.0	0	0	0	0	1
04/05/2020 05:00	0.0	0	0	0	0	1
04/05/2020 06:00	0.0	0	0	0	0	1
04/05/2020 07:00	0.0	0	0	0	0	1
04/05/2020 08:00	0.0	0	0	0	0	1
04/05/2020 09:00	0.0	0	0	0	0	1
04/05/2020 10:00	0.0	0	0	0	0	1
04/05/2020 11:00	0.0	0	0	0	0	1
04/05/2020 12:00	0.0	0	0	0	0	1
04/05/2020 13:00	0.0	0	0	0	0	1
04/05/2020 14:00	0.0	0	0	0	0	1
04/05/2020 15:00	0.0	0	0	0	0	1
04/05/2020 16:00	0.0	0	0	0	0	1
04/05/2020 17:00	0.0	0	0	0	0	1
04/05/2020 18:00	0.0	0	0	0	0	1
04/05/2020 19:00	0.0	0	0	0	0	1
04/05/2020 20:00	0.0	0	0	0	0	1
04/05/2020 21:00	0.0	0	0	0	0	1
04/05/2020 22:00	0.0	0	0	0	0	1
04/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/06/2020 00:00	0.0	0	0	0	0	1
04/06/2020 01:00	0.0	0	0	0	0	1
04/06/2020 02:00	0.0	0	0	0	0	1
04/06/2020 03:00	0.0	0	0	0	0	1
04/06/2020 04:00	0.0	0	0	0	0	1
04/06/2020 05:00	0.0	0	0	0	0	1
04/06/2020 06:00	0.0	0	0	0	0	1
04/06/2020 07:00	0.0	0	0	0	0	1
04/06/2020 08:00	0.0	0	0	0	0	1
04/06/2020 09:00	0.0	0	0	0	0	1
04/06/2020 10:00	0.0	0	0	0	0	1
04/06/2020 11:00	0.0	0	0	0	0	1
04/06/2020 12:00	0.0	0	0	0	0	1
04/06/2020 13:00	0.0	0	0	0	0	1
04/06/2020 14:00	0.0	0	0	0	0	1
04/06/2020 15:00	0.0	0	0	0	0	1
04/06/2020 16:00	0.0	0	0	0	0	1
04/06/2020 17:00	0.0	0	0	0	0	1
04/06/2020 18:00	0.0	0	0	0	0	1
04/06/2020 19:00	0.0	0	0	0	0	1
04/06/2020 20:00	0.0	0	0	0	0	1
04/06/2020 21:00	0.0	0	0	0	0	1
04/06/2020 22:00	0.0	0	0	0	0	1
04/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/07/2020 00:00	0.0	0	0	0	0	1
04/07/2020 01:00	0.0	0	0	0	0	1
04/07/2020 02:00	0.0	0	0	0	0	1
04/07/2020 03:00	0.0	0	0	0	0	1
04/07/2020 04:00	0.0	0	0	0	0	1
04/07/2020 05:00	0.0	0	0	0	0	1
04/07/2020 06:00	0.0	0	0	0	0	1
04/07/2020 07:00	0.0	0	0	0	0	1
04/07/2020 08:00	0.0	0	0	0	0	1
04/07/2020 09:00	0.0	0	0	0	0	1
04/07/2020 10:00	0.0	0	0	0	0	1
04/07/2020 11:00	0.0	0	0	0	0	1
04/07/2020 12:00	0.0	0	0	0	0	1
04/07/2020 13:00	0.0	0	0	0	0	1
04/07/2020 14:00	0.0	0	0	0	0	1
04/07/2020 15:00	0.0	0	0	0	0	1
04/07/2020 16:00	0.0	0	0	0	0	1
04/07/2020 17:00	0.0	0	0	0	0	1
04/07/2020 18:00	0.0	0	0	0	0	1
04/07/2020 19:00	0.0	0	0	0	0	1
04/07/2020 20:00	0.0	0	0	0	0	1
04/07/2020 21:00	0.0	0	0	0	0	1
04/07/2020 22:00	0.0	0	0	0	0	1
04/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/08/2020 00:00	0.0	0	0	0	0	1
04/08/2020 01:00	0.0	0	0	0	0	1
04/08/2020 02:00	0.0	0	0	0	0	1
04/08/2020 03:00	0.0	0	0	0	0	1
04/08/2020 04:00	0.0	0	0	0	0	1
04/08/2020 05:00	0.0	0	0	0	0	1
04/08/2020 06:00	0.0	0	0	0	0	1
04/08/2020 07:00	0.0	0	0	0	0	1
04/08/2020 08:00	0.0	0	0	0	0	1
04/08/2020 09:00	0.0	0	0	0	0	1
04/08/2020 10:00	0.0	0	0	0	0	1
04/08/2020 11:00	0.0	0	0	0	0	1
04/08/2020 12:00	0.0	0	0	0	0	1
04/08/2020 13:00	0.0	0	0	0	0	1
04/08/2020 14:00	0.0	0	0	0	0	1
04/08/2020 15:00	0.0	0	0	0	0	1
04/08/2020 16:00	0.0	0	0	0	0	1
04/08/2020 17:00	0.0	0	0	0	0	1
04/08/2020 18:00	0.0	0	0	0	0	1
04/08/2020 19:00	0.0	0	0	0	0	1
04/08/2020 20:00	0.0	0	0	0	0	1
04/08/2020 21:00	0.0	0	0	0	0	1
04/08/2020 22:00	0.0	0	0	0	0	1
04/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/09/2020 00:00	0.0	0	0	0	0	1
04/09/2020 01:00	0.0	0	0	0	0	1
04/09/2020 02:00	0.0	0	0	0	0	1
04/09/2020 03:00	0.0	0	0	0	0	1
04/09/2020 04:00	0.0	0	0	0	0	1
04/09/2020 05:00	0.0	0	0	0	0	1
04/09/2020 06:00	0.0	0	0	0	0	1
04/09/2020 07:00	0.0	0	0	0	0	1
04/09/2020 08:00	0.0	0	0	0	0	1
04/09/2020 09:00	0.0	0	0	0	0	1
04/09/2020 10:00	0.0	0	0	0	0	1
04/09/2020 11:00	0.0	0	0	0	0	1
04/09/2020 12:00	0.0	0	0	0	0	1
04/09/2020 13:00	0.0	0	0	0	0	1
04/09/2020 14:00	0.0	0	0	0	0	1
04/09/2020 15:00	0.0	0	0	0	0	1
04/09/2020 16:00	0.0	0	0	0	0	1
04/09/2020 17:00	0.0	0	0	0	0	1
04/09/2020 18:00	0.0	0	0	0	0	1
04/09/2020 19:00	0.0	0	0	0	0	1
04/09/2020 20:00	0.0	0	0	0	0	1
04/09/2020 21:00	0.0	0	0	0	0	1
04/09/2020 22:00	0.0	0	0	0	0	1
04/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/10/2020 00:00	0.0	0	0	0	0	1
04/10/2020 01:00	0.0	0	0	0	0	1
04/10/2020 02:00	0.0	0	0	0	0	1
04/10/2020 03:00	0.0	0	0	0	0	1
04/10/2020 04:00	0.0	0	0	0	0	1
04/10/2020 05:00	0.0	0	0	0	0	1
04/10/2020 06:00	0.0	0	0	0	0	1
04/10/2020 07:00	0.0	0	0	0	0	1
04/10/2020 08:00	0.0	0	0	0	0	1
04/10/2020 09:00	0.0	0	0	0	0	1
04/10/2020 10:00	0.0	0	0	0	0	1
04/10/2020 11:00	0.0	0	0	0	0	1
04/10/2020 12:00	0.0	0	0	0	0	1
04/10/2020 13:00	0.0	0	0	0	0	1
04/10/2020 14:00	0.0	0	0	0	0	1
04/10/2020 15:00	0.0	0	0	0	0	1
04/10/2020 16:00	0.0	0	0	0	0	1
04/10/2020 17:00	0.0	0	0	0	0	1
04/10/2020 18:00	0.0	0	0	0	0	1
04/10/2020 19:00	0.0	0	0	0	0	1
04/10/2020 20:00	0.0	0	0	0	0	1
04/10/2020 21:00	0.0	0	0	0	0	1
04/10/2020 22:00	0.0	0	0	0	0	1
04/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/11/2020 00:00	0.0	0	0	0	0	1
04/11/2020 01:00	0.0	0	0	0	0	1
04/11/2020 02:00	0.0	0	0	0	0	1
04/11/2020 03:00	0.0	0	0	0	0	1
04/11/2020 04:00	0.0	0	0	0	0	1
04/11/2020 05:00	0.0	0	0	0	0	1
04/11/2020 06:00	0.0	0	0	0	0	1
04/11/2020 07:00	0.0	0	0	0	0	1
04/11/2020 08:00	0.0	0	0	0	0	1
04/11/2020 09:00	0.0	0	0	0	0	1
04/11/2020 10:00	0.0	0	0	0	0	1
04/11/2020 11:00	0.0	0	0	0	0	1
04/11/2020 12:00	0.0	0	0	0	0	1
04/11/2020 13:00	0.0	0	0	0	0	1
04/11/2020 14:00	0.0	0	0	0	0	1
04/11/2020 15:00	0.0	0	0	0	0	1
04/11/2020 16:00	0.0	0	0	0	0	1
04/11/2020 17:00	0.0	0	0	0	0	1
04/11/2020 18:00	0.0	0	0	0	0	1
04/11/2020 19:00	0.0	0	0	0	0	1
04/11/2020 20:00	0.0	0	0	0	0	1
04/11/2020 21:00	0.0	0	0	0	0	1
04/11/2020 22:00	0.0	0	0	0	0	1
04/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/12/2020 00:00	0.0	0	0	0	0	1
04/12/2020 01:00	0.0	0	0	0	0	1
04/12/2020 02:00	0.0	0	0	0	0	1
04/12/2020 03:00	0.0	0	0	0	0	1
04/12/2020 04:00	0.0	0	0	0	0	1
04/12/2020 05:00	0.0	0	0	0	0	1
04/12/2020 06:00	0.0	0	0	0	0	1
04/12/2020 07:00	0.0	0	0	0	0	1
04/12/2020 08:00	0.0	0	0	0	0	1
04/12/2020 09:00	0.0	0	0	0	0	1
04/12/2020 10:00	0.0	0	0	0	0	1
04/12/2020 11:00	0.0	0	0	0	0	1
04/12/2020 12:00	0.0	0	0	0	0	1
04/12/2020 13:00	0.0	0	0	0	0	1
04/12/2020 14:00	0.0	0	0	0	0	1
04/12/2020 15:00	0.0	0	0	0	0	1
04/12/2020 16:00	0.0	0	0	0	0	1
04/12/2020 17:00	0.0	0	0	0	0	1
04/12/2020 18:00	0.0	0	0	0	0	1
04/12/2020 19:00	0.0	0	0	0	0	1
04/12/2020 20:00	0.0	0	0	0	0	1
04/12/2020 21:00	0.0	0	0	0	0	1
04/12/2020 22:00	0.0	0	0	0	0	1
04/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/13/2020 00:00	0.0	0	0	0	0	1
04/13/2020 01:00	0.0	0	0	0	0	1
04/13/2020 02:00	0.0	0	0	0	0	1
04/13/2020 03:00	0.0	0	0	0	0	1
04/13/2020 04:00	0.0	0	0	0	0	1
04/13/2020 05:00	0.0	0	0	0	0	1
04/13/2020 06:00	0.0	0	0	0	0	1
04/13/2020 07:00	0.0	0	0	0	0	1
04/13/2020 08:00	0.0	0	0	0	0	1
04/13/2020 09:00	0.0	0	0	0	0	1
04/13/2020 10:00	0.0	0	0	0	0	1
04/13/2020 11:00	0.0	0	0	0	0	1
04/13/2020 12:00	0.0	0	0	0	0	1
04/13/2020 13:00	0.0	0	0	0	0	1
04/13/2020 14:00	0.0	0	0	0	0	1
04/13/2020 15:00	0.0	0	0	0	0	1
04/13/2020 16:00	0.0	0	0	0	0	1
04/13/2020 17:00	0.0	0	0	0	0	1
04/13/2020 18:00	0.0	0	0	0	0	1
04/13/2020 19:00	0.0	0	0	0	0	1
04/13/2020 20:00	0.0	0	0	0	0	1
04/13/2020 21:00	0.0	0	0	0	0	1
04/13/2020 22:00	0.0	0	0	0	0	1
04/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/14/2020 00:00	0.0	0	0	0	0	1
04/14/2020 01:00	0.0	0	0	0	0	1
04/14/2020 02:00	0.0	0	0	0	0	1
04/14/2020 03:00	0.0	0	0	0	0	1
04/14/2020 04:00	0.0	0	0	0	0	1
04/14/2020 05:00	0.0	0	0	0	0	1
04/14/2020 06:00	0.0	0	0	0	0	1
04/14/2020 07:00	0.0	0	0	0	0	1
04/14/2020 08:00	0.0	0	0	0	0	1
04/14/2020 09:00	0.0	0	0	0	0	1
04/14/2020 10:00	0.0	0	0	0	0	1
04/14/2020 11:00	0.0	0	0	0	0	1
04/14/2020 12:00	0.0	0	0	0	0	1
04/14/2020 13:00	0.0	0	0	0	0	1
04/14/2020 14:00	0.0	0	0	0	0	1
04/14/2020 15:00	0.0	0	0	0	0	1
04/14/2020 16:00	0.0	0	0	0	0	1
04/14/2020 17:00	0.0	0	0	0	0	1
04/14/2020 18:00	0.0	0	0	0	0	1
04/14/2020 19:00	0.0	0	0	0	0	1
04/14/2020 20:00	0.0	0	0	0	0	1
04/14/2020 21:00	0.0	0	0	0	0	1
04/14/2020 22:00	0.0	0	0	0	0	1
04/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/15/2020 00:00	0.0	0	0	0	0	1
04/15/2020 01:00	0.0	0	0	0	0	1
04/15/2020 02:00	0.0	0	0	0	0	1
04/15/2020 03:00	0.0	0	0	0	0	1
04/15/2020 04:00	0.0	0	0	0	0	1
04/15/2020 05:00	0.0	0	0	0	0	1
04/15/2020 06:00	0.0	0	0	0	0	1
04/15/2020 07:00	0.0	0	0	0	0	1
04/15/2020 08:00	0.0	0	0	0	0	1
04/15/2020 09:00	0.0	0	0	0	0	1
04/15/2020 10:00	0.0	0	0	0	0	1
04/15/2020 11:00	0.0	0	0	0	0	1
04/15/2020 12:00	0.0	0	0	0	0	1
04/15/2020 13:00	0.0	0	0	0	0	1
04/15/2020 14:00	0.0	0	0	0	0	1
04/15/2020 15:00	0.0	0	0	0	0	1
04/15/2020 16:00	0.0	0	0	0	0	1
04/15/2020 17:00	0.0	0	0	0	0	1
04/15/2020 18:00	0.0	0	0	0	0	1
04/15/2020 19:00	0.0	0	0	0	0	1
04/15/2020 20:00	0.0	0	0	0	0	1
04/15/2020 21:00	0.0	0	0	0	0	1
04/15/2020 22:00	0.0	0	0	0	0	1
04/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/16/2020 00:00	0.0	0	0	0	0	1
04/16/2020 01:00	0.0	0	0	0	0	1
04/16/2020 02:00	0.0	0	0	0	0	1
04/16/2020 03:00	0.0	0	0	0	0	1
04/16/2020 04:00	0.0	0	0	0	0	1
04/16/2020 05:00	0.0	0	0	0	0	1
04/16/2020 06:00	0.0	0	0	0	0	1
04/16/2020 07:00	0.0	0	0	0	0	1
04/16/2020 08:00	0.0	0	0	0	0	1
04/16/2020 09:00	0.0	0	0	0	0	1
04/16/2020 10:00	0.0	0	0	0	0	1
04/16/2020 11:00	0.0	0	0	0	0	1
04/16/2020 12:00	0.0	0	0	0	0	1
04/16/2020 13:00	0.0	0	0	0	0	1
04/16/2020 14:00	0.0	0	0	0	0	1
04/16/2020 15:00	0.0	0	0	0	0	1
04/16/2020 16:00	0.0	0	0	0	0	1
04/16/2020 17:00	0.0	0	0	0	0	1
04/16/2020 18:00	0.0	0	0	0	0	1
04/16/2020 19:00	0.0	0	0	0	0	1
04/16/2020 20:00	0.0	0	0	0	0	1
04/16/2020 21:00	0.0	0	0	0	0	1
04/16/2020 22:00	0.0	0	0	0	0	1
04/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/17/2020 00:00	0.0	0	0	0	0	1
04/17/2020 01:00	0.0	0	0	0	0	1
04/17/2020 02:00	0.0	0	0	0	0	1
04/17/2020 03:00	0.0	0	0	0	0	1
04/17/2020 04:00	0.0	0	0	0	0	1
04/17/2020 05:00	0.0	0	0	0	0	1
04/17/2020 06:00	0.0	0	0	0	0	1
04/17/2020 07:00	0.0	0	0	0	0	1
04/17/2020 08:00	0.0	0	0	0	0	1
04/17/2020 09:00	0.0	0	0	0	0	1
04/17/2020 10:00	0.0	0	0	0	0	1
04/17/2020 11:00	0.0	0	0	0	0	1
04/17/2020 12:00	0.0	0	0	0	0	1
04/17/2020 13:00	0.0	0	0	0	0	1
04/17/2020 14:00	0.0	0	0	0	0	1
04/17/2020 15:00	0.0	0	0	0	0	1
04/17/2020 16:00	0.0	0	0	0	0	1
04/17/2020 17:00	0.0	0	0	0	0	1
04/17/2020 18:00	0.0	0	0	0	0	1
04/17/2020 19:00	0.0	0	0	0	0	1
04/17/2020 20:00	0.0	0	0	0	0	1
04/17/2020 21:00	0.0	0	0	0	0	1
04/17/2020 22:00	0.0	0	0	0	0	1
04/17/2020 23:00	107.3	0	0	0	1	0
Average/Sum#:	107.3 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	107.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/18/2020 00:00	0.0	0	0	0	0	0
04/18/2020 01:00	0.0	0	0	0	0	0
04/18/2020 02:00	0.0	0	0	0	0	0
04/18/2020 03:00	0.0	0	0	0	0	0
04/18/2020 04:00	0.0	0	0	0	0	0
04/18/2020 05:00	0.0	0	0	0	0	0
04/18/2020 06:00	0.0	0	0	0	0	0
04/18/2020 07:00	0.0	0	0	0	0	0
04/18/2020 08:00	0.0	0	0	0	0	0
04/18/2020 09:00	0.0	0	0	0	0	0
04/18/2020 10:00	0.0	0	0	0	0	0
04/18/2020 11:00	0.0	0	0	0	0	0
04/18/2020 12:00	0.0	0	0	0	0	0
04/18/2020 13:00	0.0	0	0	0	0	0
04/18/2020 14:00	0.0	0	0	0	0	0
04/18/2020 15:00	0.0	0	0	0	0	0
04/18/2020 16:00	0.0	0	0	0	0	0
04/18/2020 17:00	0.0	0	0	0	0	0
04/18/2020 18:00	0.0	0	0	0	0	0
04/18/2020 19:00	0.0	0	0	0	0	0
04/18/2020 20:00	0.0	0	0	0	0	0
04/18/2020 21:00	0.0	0	0	0	0	0
04/18/2020 22:00	0.0	0	0	0	0	0
04/18/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/19/2020 00:00	0.0	0	0	0	0	0
04/19/2020 01:00	0.0	0	0	0	0	0
04/19/2020 02:00	0.0	0	0	0	0	0
04/19/2020 03:00	0.0	0	0	0	0	0
04/19/2020 04:00	0.0	0	0	0	0	0
04/19/2020 05:00	0.0	0	0	0	0	0
04/19/2020 06:00	0.0	0	0	0	0	0
04/19/2020 07:00	0.0	0	0	0	0	0
04/19/2020 08:00	0.0	0	0	0	0	0
04/19/2020 09:00	0.0	0	0	0	0	0
04/19/2020 10:00	0.0	0	0	0	0	0
04/19/2020 11:00	0.0	0	0	0	0	0
04/19/2020 12:00	0.0	0	0	0	0	0
04/19/2020 13:00	0.0	0	0	0	0	0
04/19/2020 14:00	0.0	0	0	0	0	0
04/19/2020 15:00	0.0	0	0	0	0	0
04/19/2020 16:00	0.0	0	0	0	0	0
04/19/2020 17:00	0.0	0	0	0	0	0
04/19/2020 18:00	0.0	0	0	0	0	0
04/19/2020 19:00	0.0	0	0	0	0	0
04/19/2020 20:00	0.0	0	0	0	0	0
04/19/2020 21:00	0.0	0	0	0	0	0
04/19/2020 22:00	0.0	0	0	0	0	0
04/19/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/20/2020 00:00	0.0	0	0	0	0	0
04/20/2020 01:00	0.0	0	0	0	0	0
04/20/2020 02:00	4,603.3	0	1	0	0	0
04/20/2020 03:00	5,962.7	0	1	0	0	0
04/20/2020 04:00	0.0	0	0	0	0	1
04/20/2020 05:00	0.0	0	0	0	0	1
04/20/2020 06:00	0.0	0	0	0	0	1
04/20/2020 07:00	0.0	0	0	0	0	1
04/20/2020 08:00	0.0	0	0	0	0	1
04/20/2020 09:00	0.0	0	0	0	0	1
04/20/2020 10:00	0.0	0	0	0	0	1
04/20/2020 11:00	0.0	0	0	0	0	1
04/20/2020 12:00	0.0	0	0	0	0	1
04/20/2020 13:00	0.0	0	0	0	0	1
04/20/2020 14:00	0.0	0	0	0	0	1
04/20/2020 15:00	0.0	0	0	0	0	1
04/20/2020 16:00	0.0	0	0	0	0	1
04/20/2020 17:00	0.0	0	0	0	0	1
04/20/2020 18:00	0.0	0	0	0	0	1
04/20/2020 19:00	0.0	0	0	0	0	1
04/20/2020 20:00	0.0	0	0	0	0	1
04/20/2020 21:00	0.0	0	0	0	0	1
04/20/2020 22:00	0.0	0	0	0	0	1
04/20/2020 23:00	78.3	0	0	0	1	0
Average/Sum#:	10,644.3 #	0 #	2 #	0 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,962.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/21/2020 00:00	0.0	0	0	0	0	0
04/21/2020 01:00	0.0	0	0	0	0	0
04/21/2020 02:00	0.0	0	0	0	0	0
04/21/2020 03:00	0.0	0	0	0	0	0
04/21/2020 04:00	0.0	0	0	0	0	0
04/21/2020 05:00	0.0	0	0	0	0	0
04/21/2020 06:00	0.0	0	0	0	0	0
04/21/2020 07:00	0.0	0	0	0	0	0
04/21/2020 08:00	0.0	0	0	0	0	0
04/21/2020 09:00	0.0	0	0	0	0	0
04/21/2020 10:00	0.0	0	0	0	0	0
04/21/2020 11:00	0.0	0	0	0	0	0
04/21/2020 12:00	0.0	0	0	0	0	0
04/21/2020 13:00	0.0	0	0	0	0	0
04/21/2020 14:00	0.0	0	0	0	0	0
04/21/2020 15:00	0.0	0	0	0	0	0
04/21/2020 16:00	0.0	0	0	0	0	0
04/21/2020 17:00	0.0	0	0	0	0	0
04/21/2020 18:00	0.0	0	0	0	0	0
04/21/2020 19:00	0.0	0	0	0	0	0
04/21/2020 20:00	0.0	0	0	0	0	0
04/21/2020 21:00	0.0	0	0	0	0	0
04/21/2020 22:00	0.0	0	0	0	0	0
04/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/22/2020 00:00	0.0	0	0	0	0	0
04/22/2020 01:00	0.0	0	0	0	0	0
04/22/2020 02:00	0.0	0	0	0	0	0
04/22/2020 03:00	0.0	0	0	0	0	0
04/22/2020 04:00	0.0	0	0	0	0	0
04/22/2020 05:00	0.0	0	0	0	0	0
04/22/2020 06:00	0.0	0	0	0	0	0
04/22/2020 07:00	1,513.0	0	1	0	0	0
04/22/2020 08:00	5,908.2	0	1	0	0	0
04/22/2020 09:00	2,833.2	0	1	0	0	0
04/22/2020 10:00	0.0	0	0	0	0	1
04/22/2020 11:00	99.7	0	0	0	1	0
04/22/2020 12:00	0.0	0	0	0	0	0
04/22/2020 13:00	0.0	0	0	0	0	0
04/22/2020 14:00	0.0	0	0	0	0	0
04/22/2020 15:00	0.0	0	0	0	0	0
04/22/2020 16:00	0.0	0	0	0	0	0
04/22/2020 17:00	0.0	0	0	0	0	0
04/22/2020 18:00	0.0	0	0	0	0	0
04/22/2020 19:00	0.0	0	0	0	0	0
04/22/2020 20:00	0.0	0	0	0	0	0
04/22/2020 21:00	0.0	0	0	0	0	0
04/22/2020 22:00	0.0	0	0	0	0	0
04/22/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	10,354.1 #	0 #	3 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,908.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/23/2020 00:00	0.0	0	0	0	0	0
04/23/2020 01:00	0.0	0	0	0	0	0
04/23/2020 02:00	0.0	0	0	0	0	0
04/23/2020 03:00	0.0	0	0	0	0	0
04/23/2020 04:00	0.0	0	0	0	0	0
04/23/2020 05:00	0.0	0	0	0	0	0
04/23/2020 06:00	0.0	0	0	0	0	0
04/23/2020 07:00	0.0	0	0	0	0	0
04/23/2020 08:00	0.0	0	0	0	0	0
04/23/2020 09:00	0.0	0	0	0	0	0
04/23/2020 10:00	0.0	0	0	0	0	0
04/23/2020 11:00	0.0	0	0	0	0	0
04/23/2020 12:00	0.0	0	0	0	0	0
04/23/2020 13:00	0.0	0	0	0	0	0
04/23/2020 14:00	0.0	0	0	0	0	0
04/23/2020 15:00	0.0	0	0	0	0	0
04/23/2020 16:00	0.0	0	0	0	0	0
04/23/2020 17:00	0.0	0	0	0	0	0
04/23/2020 18:00	0.0	0	0	0	0	0
04/23/2020 19:00	0.0	0	0	0	0	0
04/23/2020 20:00	0.0	0	0	0	0	0
04/23/2020 21:00	0.0	0	0	0	0	0
04/23/2020 22:00	0.0	0	0	0	0	0
04/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/24/2020 00:00	0.0	0	0	0	0	0
04/24/2020 01:00	0.0	0	0	0	0	0
04/24/2020 02:00	0.0	0	0	0	0	0
04/24/2020 03:00	0.0	0	0	0	0	0
04/24/2020 04:00	0.0	0	0	0	0	0
04/24/2020 05:00	0.0	0	0	0	0	0
04/24/2020 06:00	0.0	0	0	0	0	0
04/24/2020 07:00	0.0	0	0	0	0	0
04/24/2020 08:00	0.0	0	0	0	0	0
04/24/2020 09:00	0.0	0	0	0	0	0
04/24/2020 10:00	0.0	0	0	0	0	0
04/24/2020 11:00	0.0	0	0	0	0	0
04/24/2020 12:00	0.0	0	0	0	0	0
04/24/2020 13:00	0.0	0	0	0	0	0
04/24/2020 14:00	3,137.6	0	1	0	0	0
04/24/2020 15:00	7,085.0	0	1	0	0	0
04/24/2020 16:00	1,072.4	0	1	0	0	0
04/24/2020 17:00	0.0	0	0	0	0	1
04/24/2020 18:00	0.0	0	0	0	0	1
04/24/2020 19:00	0.0	0	0	0	0	1
04/24/2020 20:00	0.0	0	0	0	0	1
04/24/2020 21:00	0.0	0	0	0	0	1
04/24/2020 22:00	146.9	0	0	0	1	0
04/24/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	11,441.9 #	0 #	3 #	0 #	1 #	5 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,085.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/25/2020 00:00	0.0	0	0	0	0	0
04/25/2020 01:00	0.0	0	0	0	0	0
04/25/2020 02:00	0.0	0	0	0	0	0
04/25/2020 03:00	0.0	0	0	0	0	0
04/25/2020 04:00	0.0	0	0	0	0	0
04/25/2020 05:00	0.0	0	0	0	0	0
04/25/2020 06:00	0.0	0	0	0	0	0
04/25/2020 07:00	0.0	0	0	0	0	0
04/25/2020 08:00	0.0	0	0	0	0	0
04/25/2020 09:00	0.0	0	0	0	0	0
04/25/2020 10:00	0.0	0	0	0	0	0
04/25/2020 11:00	0.0	0	0	0	0	0
04/25/2020 12:00	0.0	0	0	0	0	0
04/25/2020 13:00	0.0	0	0	0	0	0
04/25/2020 14:00	0.0	0	0	0	0	0
04/25/2020 15:00	0.0	0	0	0	0	0
04/25/2020 16:00	0.0	0	0	0	0	0
04/25/2020 17:00	0.0	0	0	0	0	0
04/25/2020 18:00	0.0	0	0	0	0	0
04/25/2020 19:00	0.0	0	0	0	0	0
04/25/2020 20:00	0.0	0	0	0	0	0
04/25/2020 21:00	0.0	0	0	0	0	0
04/25/2020 22:00	0.0	0	0	0	0	0
04/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/26/2020 00:00	0.0	0	0	0	0	0
04/26/2020 01:00	0.0	0	0	0	0	0
04/26/2020 02:00	0.0	0	0	0	0	0
04/26/2020 03:00	0.0	0	0	0	0	0
04/26/2020 04:00	0.0	0	0	0	0	0
04/26/2020 05:00	0.0	0	0	0	0	0
04/26/2020 06:00	0.0	0	0	0	0	0
04/26/2020 07:00	0.0	0	0	0	0	0
04/26/2020 08:00	0.0	0	0	0	0	0
04/26/2020 09:00	0.0	0	0	0	0	0
04/26/2020 10:00	0.0	0	0	0	0	0
04/26/2020 11:00	0.0	0	0	0	0	0
04/26/2020 12:00	0.0	0	0	0	0	0
04/26/2020 13:00	0.0	0	0	0	0	0
04/26/2020 14:00	0.0	0	0	0	0	0
04/26/2020 15:00	0.0	0	0	0	0	0
04/26/2020 16:00	0.0	0	0	0	0	0
04/26/2020 17:00	0.0	0	0	0	0	0
04/26/2020 18:00	0.0	0	0	0	0	0
04/26/2020 19:00	0.0	0	0	0	0	0
04/26/2020 20:00	0.0	0	0	0	0	0
04/26/2020 21:00	0.0	0	0	0	0	0
04/26/2020 22:00	0.0	0	0	0	0	0
04/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/27/2020 00:00	0.0	0	0	0	0	0
04/27/2020 01:00	0.0	0	0	0	0	0
04/27/2020 02:00	0.0	0	0	0	0	0
04/27/2020 03:00	0.0	0	0	0	0	0
04/27/2020 04:00	0.0	0	0	0	0	0
04/27/2020 05:00	0.0	0	0	0	0	0
04/27/2020 06:00	0.0	0	0	0	0	0
04/27/2020 07:00	0.0	0	0	0	0	0
04/27/2020 08:00	0.0	0	0	0	0	0
04/27/2020 09:00	0.0	0	0	0	0	0
04/27/2020 10:00	0.0	0	0	0	0	0
04/27/2020 11:00	0.0	0	0	0	0	0
04/27/2020 12:00	0.0	0	0	0	0	0
04/27/2020 13:00	0.0	0	0	0	0	0
04/27/2020 14:00	0.0	0	0	0	0	0
04/27/2020 15:00	0.0	0	0	0	0	0
04/27/2020 16:00	0.0	0	0	0	0	0
04/27/2020 17:00	0.0	0	0	0	0	0
04/27/2020 18:00	0.0	0	0	0	0	0
04/27/2020 19:00	0.0	0	0	0	0	0
04/27/2020 20:00	0.0	0	0	0	0	0
04/27/2020 21:00	0.0	0	0	0	0	0
04/27/2020 22:00	0.0	0	0	0	0	0
04/27/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/28/2020 00:00	0.0	0	0	0	0	0
04/28/2020 01:00	0.0	0	0	0	0	0
04/28/2020 02:00	0.0	0	0	0	0	0
04/28/2020 03:00	0.0	0	0	0	0	0
04/28/2020 04:00	0.0	0	0	0	0	0
04/28/2020 05:00	0.0	0	0	0	0	0
04/28/2020 06:00	0.0	0	0	0	0	0
04/28/2020 07:00	0.0	0	0	0	0	0
04/28/2020 08:00	0.0	0	0	0	0	0
04/28/2020 09:00	0.0	0	0	0	0	0
04/28/2020 10:00	0.0	0	0	0	0	0
04/28/2020 11:00	0.0	0	0	0	0	0
04/28/2020 12:00	0.0	0	0	0	0	0
04/28/2020 13:00	2,885.8	1	0	0	0	0
04/28/2020 14:00	7,281.5	1	0	0	0	0
04/28/2020 15:00	434.7	1	0	0	0	0
04/28/2020 16:00	0.0	0	0	0	0	1
04/28/2020 17:00	0.0	0	0	0	0	1
04/28/2020 18:00	0.0	0	0	0	0	1
04/28/2020 19:00	0.0	0	0	0	0	1
04/28/2020 20:00	0.0	0	0	0	0	1
04/28/2020 21:00	80.6	0	0	0	1	0
04/28/2020 22:00	0.0	0	0	0	0	0
04/28/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	10,682.6 #	3 #	0 #	0 #	1 #	5 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,281.5	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/29/2020 00:00	0.0	0	0	0	0	0
04/29/2020 01:00	0.0	0	0	0	0	0
04/29/2020 02:00	0.0	0	0	0	0	0
04/29/2020 03:00	0.0	0	0	0	0	0
04/29/2020 04:00	0.0	0	0	0	0	0
04/29/2020 05:00	0.0	0	0	0	0	0
04/29/2020 06:00	0.0	0	0	0	0	0
04/29/2020 07:00	0.0	0	0	0	0	0
04/29/2020 08:00	0.0	0	0	0	0	0
04/29/2020 09:00	0.0	0	0	0	0	0
04/29/2020 10:00	0.0	0	0	0	0	0
04/29/2020 11:00	0.0	0	0	0	0	0
04/29/2020 12:00	0.0	0	0	0	0	0
04/29/2020 13:00	0.0	0	0	0	0	0
04/29/2020 14:00	0.0	0	0	0	0	0
04/29/2020 15:00	0.0	0	0	0	0	0
04/29/2020 16:00	0.0	0	0	0	0	0
04/29/2020 17:00	0.0	0	0	0	0	0
04/29/2020 18:00	0.0	0	0	0	0	0
04/29/2020 19:00	0.0	0	0	0	0	0
04/29/2020 20:00	0.0	0	0	0	0	0
04/29/2020 21:00	0.0	0	0	0	0	0
04/29/2020 22:00	0.0	0	0	0	0	0
04/29/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/30/2020 00:00	0.0	0	0	0	0	0
04/30/2020 01:00	0.0	0	0	0	0	0
04/30/2020 02:00	0.0	0	0	0	0	0
04/30/2020 03:00	0.0	0	0	0	0	0
04/30/2020 04:00	0.0	0	0	0	0	0
04/30/2020 05:00	0.0	0	0	0	0	0
04/30/2020 06:00	0.0	0	0	0	0	0
04/30/2020 07:00	0.0	0	0	0	0	0
04/30/2020 08:00	0.0	0	0	0	0	0
04/30/2020 09:00	0.0	0	0	0	0	0
04/30/2020 10:00	0.0	0	0	0	0	0
04/30/2020 11:00	0.0	0	0	0	0	0
04/30/2020 12:00	0.0	0	0	0	0	0
04/30/2020 13:00	0.0	0	0	0	0	0
04/30/2020 14:00	0.0	0	0	0	0	0
04/30/2020 15:00	0.0	0	0	0	0	0
04/30/2020 16:00	0.0	0	0	0	0	0
04/30/2020 17:00	0.0	0	0	0	0	0
04/30/2020 18:00	0.0	0	0	0	0	0
04/30/2020 19:00	0.0	0	0	0	0	0
04/30/2020 20:00	0.0	0	0	0	0	0
04/30/2020 21:00	0.0	0	0	0	0	0
04/30/2020 22:00	0.0	0	0	0	0	0
04/30/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/01/2020 00:00	0.0	0	0	0	0	0
05/01/2020 01:00	0.0	0	0	0	0	0
05/01/2020 02:00	0.0	0	0	0	0	0
05/01/2020 03:00	0.0	0	0	0	0	0
05/01/2020 04:00	0.0	0	0	0	0	0
05/01/2020 05:00	0.0	0	0	0	0	0
05/01/2020 06:00	0.0	0	0	0	0	0
05/01/2020 07:00	0.0	0	0	0	0	0
05/01/2020 08:00	0.0	0	0	0	0	0
05/01/2020 09:00	0.0	0	0	0	0	0
05/01/2020 10:00	0.0	0	0	0	0	0
05/01/2020 11:00	0.0	0	0	0	0	0
05/01/2020 12:00	0.0	0	0	0	0	0
05/01/2020 13:00	0.0	0	0	0	0	0
05/01/2020 14:00	0.0	0	0	0	0	0
05/01/2020 15:00	0.0	0	0	0	0	0
05/01/2020 16:00	0.0	0	0	0	0	0
05/01/2020 17:00	0.0	0	0	0	0	0
05/01/2020 18:00	0.0	0	0	0	0	0
05/01/2020 19:00	0.0	0	0	0	0	0
05/01/2020 20:00	0.0	0	0	0	0	0
05/01/2020 21:00	0.0	0	0	0	0	0
05/01/2020 22:00	0.0	0	0	0	0	0
05/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/02/2020 00:00	0.0	0	0	0	0	0
05/02/2020 01:00	0.0	0	0	0	0	0
05/02/2020 02:00	0.0	0	0	0	0	0
05/02/2020 03:00	0.0	0	0	0	0	0
05/02/2020 04:00	0.0	0	0	0	0	0
05/02/2020 05:00	0.0	0	0	0	0	0
05/02/2020 06:00	0.0	0	0	0	0	0
05/02/2020 07:00	0.0	0	0	0	0	0
05/02/2020 08:00	0.0	0	0	0	0	0
05/02/2020 09:00	0.0	0	0	0	0	0
05/02/2020 10:00	0.0	0	0	0	0	0
05/02/2020 11:00	0.0	0	0	0	0	0
05/02/2020 12:00	0.0	0	0	0	0	0
05/02/2020 13:00	0.0	0	0	0	0	0
05/02/2020 14:00	0.0	0	0	0	0	0
05/02/2020 15:00	0.0	0	0	0	0	0
05/02/2020 16:00	0.0	0	0	0	0	0
05/02/2020 17:00	0.0	0	0	0	0	0
05/02/2020 18:00	0.0	0	0	0	0	0
05/02/2020 19:00	0.0	0	0	0	0	0
05/02/2020 20:00	0.0	0	0	0	0	0
05/02/2020 21:00	0.0	0	0	0	0	0
05/02/2020 22:00	0.0	0	0	0	0	0
05/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/03/2020 00:00	0.0	0	0	0	0	0
05/03/2020 01:00	0.0	0	0	0	0	0
05/03/2020 02:00	0.0	0	0	0	0	0
05/03/2020 03:00	0.0	0	0	0	0	0
05/03/2020 04:00	0.0	0	0	0	0	0
05/03/2020 05:00	0.0	0	0	0	0	0
05/03/2020 06:00	0.0	0	0	0	0	0
05/03/2020 07:00	0.0	0	0	0	0	0
05/03/2020 08:00	0.0	0	0	0	0	0
05/03/2020 09:00	0.0	0	0	0	0	0
05/03/2020 10:00	0.0	0	0	0	0	0
05/03/2020 11:00	0.0	0	0	0	0	0
05/03/2020 12:00	0.0	0	0	0	0	0
05/03/2020 13:00	0.0	0	0	0	0	0
05/03/2020 14:00	0.0	0	0	0	0	0
05/03/2020 15:00	0.0	0	0	0	0	0
05/03/2020 16:00	0.0	0	0	0	0	0
05/03/2020 17:00	0.0	0	0	0	0	0
05/03/2020 18:00	0.0	0	0	0	0	0
05/03/2020 19:00	0.0	0	0	0	0	0
05/03/2020 20:00	0.0	0	0	0	0	0
05/03/2020 21:00	0.0	0	0	0	0	0
05/03/2020 22:00	0.0	0	0	0	0	0
05/03/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/04/2020 00:00	0.0	0	0	0	0	0
05/04/2020 01:00	0.0	0	0	0	0	0
05/04/2020 02:00	0.0	0	0	0	0	0
05/04/2020 03:00	0.0	0	0	0	0	0
05/04/2020 04:00	0.0	0	0	0	0	0
05/04/2020 05:00	0.0	0	0	0	0	0
05/04/2020 06:00	0.0	0	0	0	0	0
05/04/2020 07:00	0.0	0	0	0	0	0
05/04/2020 08:00	0.0	0	0	0	0	0
05/04/2020 09:00	0.0	0	0	0	0	0
05/04/2020 10:00	0.0	0	0	0	0	0
05/04/2020 11:00	0.0	0	0	0	0	0
05/04/2020 12:00	0.0	0	0	0	0	0
05/04/2020 13:00	0.0	0	0	0	0	0
05/04/2020 14:00	0.0	0	0	0	0	0
05/04/2020 15:00	0.0	0	0	0	0	0
05/04/2020 16:00	0.0	0	0	0	0	0
05/04/2020 17:00	0.0	0	0	0	0	0
05/04/2020 18:00	0.0	0	0	0	0	0
05/04/2020 19:00	0.0	0	0	0	0	0
05/04/2020 20:00	0.0	0	0	0	0	0
05/04/2020 21:00	0.0	0	0	0	0	0
05/04/2020 22:00	0.0	0	0	0	0	0
05/04/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/05/2020 00:00	0.0	0	0	0	0	0
05/05/2020 01:00	0.0	0	0	0	0	0
05/05/2020 02:00	0.0	0	0	0	0	0
05/05/2020 03:00	0.0	0	0	0	0	0
05/05/2020 04:00	0.0	0	0	0	0	0
05/05/2020 05:00	0.0	0	0	0	0	0
05/05/2020 06:00	0.0	0	0	0	0	0
05/05/2020 07:00	0.0	0	0	0	0	0
05/05/2020 08:00	0.0	0	0	0	0	0
05/05/2020 09:00	0.0	0	0	0	0	0
05/05/2020 10:00	0.0	0	0	0	0	0
05/05/2020 11:00	0.0	0	0	0	0	0
05/05/2020 12:00	0.0	0	0	0	0	0
05/05/2020 13:00	0.0	0	0	0	0	0
05/05/2020 14:00	0.0	0	0	0	0	0
05/05/2020 15:00	0.0	0	0	0	0	0
05/05/2020 16:00	0.0	0	0	0	0	0
05/05/2020 17:00	0.0	0	0	0	0	0
05/05/2020 18:00	0.0	0	0	0	0	0
05/05/2020 19:00	0.0	0	0	0	0	0
05/05/2020 20:00	0.0	0	0	0	0	0
05/05/2020 21:00	0.0	0	0	0	0	0
05/05/2020 22:00	0.0	0	0	0	0	0
05/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/06/2020 00:00	0.0	0	0	0	0	0
05/06/2020 01:00	0.0	0	0	0	0	0
05/06/2020 02:00	0.0	0	0	0	0	0
05/06/2020 03:00	0.0	0	0	0	0	0
05/06/2020 04:00	0.0	0	0	0	0	0
05/06/2020 05:00	0.0	0	0	0	0	0
05/06/2020 06:00	0.0	0	0	0	0	0
05/06/2020 07:00	0.0	0	0	0	0	0
05/06/2020 08:00	0.0	0	0	0	0	0
05/06/2020 09:00	0.0	0	0	0	0	0
05/06/2020 10:00	0.0	0	0	0	0	0
05/06/2020 11:00	0.0	0	0	0	0	0
05/06/2020 12:00	0.0	0	0	0	0	0
05/06/2020 13:00	0.0	0	0	0	0	0
05/06/2020 14:00	0.0	0	0	0	0	0
05/06/2020 15:00	0.0	0	0	0	0	0
05/06/2020 16:00	0.0	0	0	0	0	0
05/06/2020 17:00	0.0	0	0	0	0	0
05/06/2020 18:00	0.0	0	0	0	0	0
05/06/2020 19:00	0.0	0	0	0	0	0
05/06/2020 20:00	0.0	0	0	0	0	0
05/06/2020 21:00	0.0	0	0	0	0	0
05/06/2020 22:00	0.0	0	0	0	0	0
05/06/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/07/2020 00:00	0.0	0	0	0	0	0
05/07/2020 01:00	0.0	0	0	0	0	0
05/07/2020 02:00	0.0	0	0	0	0	0
05/07/2020 03:00	0.0	0	0	0	0	0
05/07/2020 04:00	0.0	0	0	0	0	0
05/07/2020 05:00	0.0	0	0	0	0	0
05/07/2020 06:00	0.0	0	0	0	0	0
05/07/2020 07:00	0.0	0	0	0	0	0
05/07/2020 08:00	0.0	0	0	0	0	0
05/07/2020 09:00	0.0	0	0	0	0	0
05/07/2020 10:00	0.0	0	0	0	0	0
05/07/2020 11:00	0.0	0	0	0	0	0
05/07/2020 12:00	0.0	0	0	0	0	0
05/07/2020 13:00	0.0	0	0	0	0	0
05/07/2020 14:00	0.0	0	0	0	0	0
05/07/2020 15:00	0.0	0	0	0	0	0
05/07/2020 16:00	0.0	0	0	0	0	0
05/07/2020 17:00	0.0	0	0	0	0	0
05/07/2020 18:00	0.0	0	0	0	0	0
05/07/2020 19:00	0.0	0	0	0	0	0
05/07/2020 20:00	0.0	0	0	0	0	0
05/07/2020 21:00	0.0	0	0	0	0	0
05/07/2020 22:00	0.0	0	0	0	0	0
05/07/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/08/2020 00:00	0.0	0	0	0	0	0
05/08/2020 01:00	0.0	0	0	0	0	0
05/08/2020 02:00	0.0	0	0	0	0	0
05/08/2020 03:00	0.0	0	0	0	0	0
05/08/2020 04:00	0.0	0	0	0	0	0
05/08/2020 05:00	0.0	0	0	0	0	0
05/08/2020 06:00	0.0	0	0	0	0	0
05/08/2020 07:00	0.0	0	0	0	0	0
05/08/2020 08:00	0.0	0	0	0	0	0
05/08/2020 09:00	0.0	0	0	0	0	0
05/08/2020 10:00	0.0	0	0	0	0	0
05/08/2020 11:00	0.0	0	0	0	0	0
05/08/2020 12:00	0.0	0	0	0	0	0
05/08/2020 13:00	0.0	0	0	0	0	0
05/08/2020 14:00	0.0	0	0	0	0	0
05/08/2020 15:00	0.0	0	0	0	0	0
05/08/2020 16:00	0.0	0	0	0	0	0
05/08/2020 17:00	0.0	0	0	0	0	0
05/08/2020 18:00	0.0	0	0	0	0	0
05/08/2020 19:00	0.0	0	0	0	0	0
05/08/2020 20:00	0.0	0	0	0	0	0
05/08/2020 21:00	0.0	0	0	0	0	0
05/08/2020 22:00	0.0	0	0	0	0	0
05/08/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/09/2020 00:00	0.0	0	0	0	0	0
05/09/2020 01:00	0.0	0	0	0	0	0
05/09/2020 02:00	0.0	0	0	0	0	0
05/09/2020 03:00	0.0	0	0	0	0	0
05/09/2020 04:00	0.0	0	0	0	0	0
05/09/2020 05:00	0.0	0	0	0	0	0
05/09/2020 06:00	0.0	0	0	0	0	0
05/09/2020 07:00	0.0	0	0	0	0	0
05/09/2020 08:00	0.0	0	0	0	0	0
05/09/2020 09:00	0.0	0	0	0	0	0
05/09/2020 10:00	0.0	0	0	0	0	0
05/09/2020 11:00	0.0	0	0	0	0	0
05/09/2020 12:00	0.0	0	0	0	0	0
05/09/2020 13:00	0.0	0	0	0	0	0
05/09/2020 14:00	0.0	0	0	0	0	0
05/09/2020 15:00	0.0	0	0	0	0	0
05/09/2020 16:00	0.0	0	0	0	0	0
05/09/2020 17:00	0.0	0	0	0	0	0
05/09/2020 18:00	0.0	0	0	0	0	0
05/09/2020 19:00	0.0	0	0	0	0	0
05/09/2020 20:00	0.0	0	0	0	0	0
05/09/2020 21:00	0.0	0	0	0	0	0
05/09/2020 22:00	0.0	0	0	0	0	0
05/09/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/10/2020 00:00	0.0	0	0	0	0	0
05/10/2020 01:00	0.0	0	0	0	0	0
05/10/2020 02:00	0.0	0	0	0	0	0
05/10/2020 03:00	0.0	0	0	0	0	0
05/10/2020 04:00	0.0	0	0	0	0	0
05/10/2020 05:00	0.0	0	0	0	0	0
05/10/2020 06:00	0.0	0	0	0	0	0
05/10/2020 07:00	0.0	0	0	0	0	0
05/10/2020 08:00	0.0	0	0	0	0	0
05/10/2020 09:00	0.0	0	0	0	0	0
05/10/2020 10:00	0.0	0	0	0	0	0
05/10/2020 11:00	0.0	0	0	0	0	0
05/10/2020 12:00	0.0	0	0	0	0	0
05/10/2020 13:00	0.0	0	0	0	0	0
05/10/2020 14:00	0.0	0	0	0	0	0
05/10/2020 15:00	0.0	0	0	0	0	0
05/10/2020 16:00	0.0	0	0	0	0	0
05/10/2020 17:00	0.0	0	0	0	0	0
05/10/2020 18:00	0.0	0	0	0	0	0
05/10/2020 19:00	0.0	0	0	0	0	0
05/10/2020 20:00	0.0	0	0	0	0	0
05/10/2020 21:00	0.0	0	0	0	0	0
05/10/2020 22:00	0.0	0	0	0	0	0
05/10/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/11/2020 00:00	0.0	0	0	0	0	0
05/11/2020 01:00	0.0	0	0	0	0	0
05/11/2020 02:00	0.0	0	0	0	0	0
05/11/2020 03:00	0.0	0	0	0	0	0
05/11/2020 04:00	0.0	0	0	0	0	0
05/11/2020 05:00	0.0	0	0	0	0	0
05/11/2020 06:00	0.0	0	0	0	0	0
05/11/2020 07:00	0.0	0	0	0	0	0
05/11/2020 08:00	0.0	0	0	0	0	0
05/11/2020 09:00	0.0	0	0	0	0	0
05/11/2020 10:00	0.0	0	0	0	0	0
05/11/2020 11:00	0.0	0	0	0	0	0
05/11/2020 12:00	0.0	0	0	0	0	0
05/11/2020 13:00	0.0	0	0	0	0	0
05/11/2020 14:00	0.0	0	0	0	0	0
05/11/2020 15:00	0.0	0	0	0	0	0
05/11/2020 16:00	0.0	0	0	0	0	0
05/11/2020 17:00	0.0	0	0	0	0	0
05/11/2020 18:00	0.0	0	0	0	0	0
05/11/2020 19:00	0.0	0	0	0	0	0
05/11/2020 20:00	0.0	0	0	0	0	0
05/11/2020 21:00	0.0	0	0	0	0	0
05/11/2020 22:00	0.0	0	0	0	0	0
05/11/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/12/2020 00:00	0.0	0	0	0	0	0
05/12/2020 01:00	0.0	0	0	0	0	0
05/12/2020 02:00	0.0	0	0	0	0	0
05/12/2020 03:00	0.0	0	0	0	0	0
05/12/2020 04:00	0.0	0	0	0	0	0
05/12/2020 05:00	0.0	0	0	0	0	0
05/12/2020 06:00	0.0	0	0	0	0	0
05/12/2020 07:00	0.0	0	0	0	0	0
05/12/2020 08:00	0.0	0	0	0	0	0
05/12/2020 09:00	0.0	0	0	0	0	0
05/12/2020 10:00	0.0	0	0	0	0	0
05/12/2020 11:00	0.0	0	0	0	0	0
05/12/2020 12:00	0.0	0	0	0	0	0
05/12/2020 13:00	0.0	0	0	0	0	0
05/12/2020 14:00	0.0	0	0	0	0	0
05/12/2020 15:00	0.0	0	0	0	0	0
05/12/2020 16:00	0.0	0	0	0	0	0
05/12/2020 17:00	0.0	0	0	0	0	0
05/12/2020 18:00	0.0	0	0	0	0	0
05/12/2020 19:00	0.0	0	0	0	0	0
05/12/2020 20:00	0.0	0	0	0	0	0
05/12/2020 21:00	0.0	0	0	0	0	0
05/12/2020 22:00	0.0	0	0	0	0	0
05/12/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/13/2020 00:00	0.0	0	0	0	0	0
05/13/2020 01:00	0.0	0	0	0	0	0
05/13/2020 02:00	0.0	0	0	0	0	0
05/13/2020 03:00	0.0	0	0	0	0	0
05/13/2020 04:00	0.0	0	0	0	0	0
05/13/2020 05:00	0.0	0	0	0	0	0
05/13/2020 06:00	0.0	0	0	0	0	0
05/13/2020 07:00	0.0	0	0	0	0	0
05/13/2020 08:00	0.0	0	0	0	0	0
05/13/2020 09:00	0.0	0	0	0	0	0
05/13/2020 10:00	0.0	0	0	0	0	0
05/13/2020 11:00	0.0	0	0	0	0	0
05/13/2020 12:00	0.0	0	0	0	0	0
05/13/2020 13:00	0.0	0	0	0	0	0
05/13/2020 14:00	0.0	0	0	0	0	0
05/13/2020 15:00	0.0	0	0	0	0	0
05/13/2020 16:00	0.0	0	0	0	0	0
05/13/2020 17:00	0.0	0	0	0	0	0
05/13/2020 18:00	0.0	0	0	0	0	0
05/13/2020 19:00	0.0	0	0	0	0	0
05/13/2020 20:00	0.0	0	0	0	0	0
05/13/2020 21:00	0.0	0	0	0	0	0
05/13/2020 22:00	0.0	0	0	0	0	0
05/13/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/14/2020 00:00	0.0	0	0	0	0	0
05/14/2020 01:00	0.0	0	0	0	0	0
05/14/2020 02:00	0.0	0	0	0	0	0
05/14/2020 03:00	0.0	0	0	0	0	0
05/14/2020 04:00	0.0	0	0	0	0	0
05/14/2020 05:00	0.0	0	0	0	0	0
05/14/2020 06:00	0.0	0	0	0	0	0
05/14/2020 07:00	0.0	0	0	0	0	0
05/14/2020 08:00	0.0	0	0	0	0	0
05/14/2020 09:00	0.0	0	0	0	0	0
05/14/2020 10:00	0.0	0	0	0	0	0
05/14/2020 11:00	0.0	0	0	0	0	0
05/14/2020 12:00	0.0	0	0	0	0	0
05/14/2020 13:00	0.0	0	0	0	0	0
05/14/2020 14:00	0.0	0	0	0	0	0
05/14/2020 15:00	0.0	0	0	0	0	0
05/14/2020 16:00	0.0	0	0	0	0	0
05/14/2020 17:00	0.0	0	0	0	0	0
05/14/2020 18:00	0.0	0	0	0	0	0
05/14/2020 19:00	0.0	0	0	0	0	0
05/14/2020 20:00	0.0	0	0	0	0	0
05/14/2020 21:00	0.0	0	0	0	0	0
05/14/2020 22:00	0.0	0	0	0	0	0
05/14/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/15/2020 00:00	0.0	0	0	0	0	0
05/15/2020 01:00	0.0	0	0	0	0	0
05/15/2020 02:00	0.0	0	0	0	0	0
05/15/2020 03:00	0.0	0	0	0	0	0
05/15/2020 04:00	0.0	0	0	0	0	0
05/15/2020 05:00	0.0	0	0	0	0	0
05/15/2020 06:00	0.0	0	0	0	0	0
05/15/2020 07:00	0.0	0	0	0	0	0
05/15/2020 08:00	0.0	0	0	0	0	0
05/15/2020 09:00	0.0	0	0	0	0	0
05/15/2020 10:00	0.0	0	0	0	0	0
05/15/2020 11:00	0.0	0	0	0	0	0
05/15/2020 12:00	0.0	0	0	0	0	0
05/15/2020 13:00	0.0	0	0	0	0	0
05/15/2020 14:00	0.0	0	0	0	0	0
05/15/2020 15:00	0.0	0	0	0	0	0
05/15/2020 16:00	0.0	0	0	0	0	0
05/15/2020 17:00	0.0	0	0	0	0	0
05/15/2020 18:00	0.0	0	0	0	0	0
05/15/2020 19:00	0.0	0	0	0	0	0
05/15/2020 20:00	0.0	0	0	0	0	0
05/15/2020 21:00	0.0	0	0	0	0	0
05/15/2020 22:00	0.0	0	0	0	0	0
05/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/16/2020 00:00	0.0	0	0	0	0	0
05/16/2020 01:00	0.0	0	0	0	0	0
05/16/2020 02:00	0.0	0	0	0	0	0
05/16/2020 03:00	0.0	0	0	0	0	0
05/16/2020 04:00	0.0	0	0	0	0	0
05/16/2020 05:00	0.0	0	0	0	0	0
05/16/2020 06:00	0.0	0	0	0	0	0
05/16/2020 07:00	0.0	0	0	0	0	0
05/16/2020 08:00	0.0	0	0	0	0	0
05/16/2020 09:00	0.0	0	0	0	0	0
05/16/2020 10:00	0.0	0	0	0	0	0
05/16/2020 11:00	0.0	0	0	0	0	0
05/16/2020 12:00	0.0	0	0	0	0	0
05/16/2020 13:00	0.0	0	0	0	0	0
05/16/2020 14:00	0.0	0	0	0	0	0
05/16/2020 15:00	0.0	0	0	0	0	0
05/16/2020 16:00	0.0	0	0	0	0	0
05/16/2020 17:00	0.0	0	0	0	0	0
05/16/2020 18:00	0.0	0	0	0	0	0
05/16/2020 19:00	0.0	0	0	0	0	0
05/16/2020 20:00	0.0	0	0	0	0	0
05/16/2020 21:00	0.0	0	0	0	0	0
05/16/2020 22:00	0.0	0	0	0	0	0
05/16/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/17/2020 00:00	0.0	0	0	0	0	0
05/17/2020 01:00	0.0	0	0	0	0	0
05/17/2020 02:00	0.0	0	0	0	0	0
05/17/2020 03:00	0.0	0	0	0	0	0
05/17/2020 04:00	0.0	0	0	0	0	0
05/17/2020 05:00	0.0	0	0	0	0	0
05/17/2020 06:00	0.0	0	0	0	0	0
05/17/2020 07:00	0.0	0	0	0	0	0
05/17/2020 08:00	0.0	0	0	0	0	0
05/17/2020 09:00	0.0	0	0	0	0	0
05/17/2020 10:00	0.0	0	0	0	0	0
05/17/2020 11:00	0.0	0	0	0	0	0
05/17/2020 12:00	0.0	0	0	0	0	0
05/17/2020 13:00	0.0	0	0	0	0	0
05/17/2020 14:00	0.0	0	0	0	0	0
05/17/2020 15:00	0.0	0	0	0	0	0
05/17/2020 16:00	0.0	0	0	0	0	0
05/17/2020 17:00	0.0	0	0	0	0	0
05/17/2020 18:00	0.0	0	0	0	0	0
05/17/2020 19:00	0.0	0	0	0	0	0
05/17/2020 20:00	0.0	0	0	0	0	0
05/17/2020 21:00	0.0	0	0	0	0	0
05/17/2020 22:00	0.0	0	0	0	0	0
05/17/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/18/2020 00:00	0.0	0	0	0	0	0
05/18/2020 01:00	0.0	0	0	0	0	0
05/18/2020 02:00	0.0	0	0	0	0	0
05/18/2020 03:00	0.0	0	0	0	0	0
05/18/2020 04:00	0.0	0	0	0	0	0
05/18/2020 05:00	0.0	0	0	0	0	0
05/18/2020 06:00	0.0	0	0	0	0	0
05/18/2020 07:00	0.0	0	0	0	0	0
05/18/2020 08:00	0.0	0	0	0	0	0
05/18/2020 09:00	0.0	0	0	0	0	0
05/18/2020 10:00	0.0	0	0	0	0	0
05/18/2020 11:00	0.0	0	0	0	0	0
05/18/2020 12:00	0.0	0	0	0	0	0
05/18/2020 13:00	0.0	0	0	0	0	0
05/18/2020 14:00	0.0	0	0	0	0	0
05/18/2020 15:00	0.0	0	0	0	0	0
05/18/2020 16:00	0.0	0	0	0	0	0
05/18/2020 17:00	0.0	0	0	0	0	0
05/18/2020 18:00	0.0	0	0	0	0	0
05/18/2020 19:00	0.0	0	0	0	0	0
05/18/2020 20:00	0.0	0	0	0	0	0
05/18/2020 21:00	0.0	0	0	0	0	0
05/18/2020 22:00	0.0	0	0	0	0	0
05/18/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/19/2020 00:00	0.0	0	0	0	0	0
05/19/2020 01:00	0.0	0	0	0	0	0
05/19/2020 02:00	0.0	0	0	0	0	0
05/19/2020 03:00	0.0	0	0	0	0	0
05/19/2020 04:00	0.0	0	0	0	0	0
05/19/2020 05:00	0.0	0	0	0	0	0
05/19/2020 06:00	0.0	0	0	0	0	0
05/19/2020 07:00	0.0	0	0	0	0	0
05/19/2020 08:00	0.0	0	0	0	0	0
05/19/2020 09:00	0.0	0	0	0	0	0
05/19/2020 10:00	0.0	0	0	0	0	0
05/19/2020 11:00	0.0	0	0	0	0	0
05/19/2020 12:00	0.0	0	0	0	0	0
05/19/2020 13:00	0.0	0	0	0	0	0
05/19/2020 14:00	0.0	0	0	0	0	0
05/19/2020 15:00	0.0	0	0	0	0	0
05/19/2020 16:00	0.0	0	0	0	0	0
05/19/2020 17:00	0.0	0	0	0	0	0
05/19/2020 18:00	0.0	0	0	0	0	0
05/19/2020 19:00	0.0	0	0	0	0	0
05/19/2020 20:00	0.0	0	0	0	0	0
05/19/2020 21:00	0.0	0	0	0	0	0
05/19/2020 22:00	0.0	0	0	0	0	0
05/19/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/20/2020 00:00	0.0	0	0	0	0	0
05/20/2020 01:00	0.0	0	0	0	0	0
05/20/2020 02:00	0.0	0	0	0	0	0
05/20/2020 03:00	0.0	0	0	0	0	0
05/20/2020 04:00	0.0	0	0	0	0	0
05/20/2020 05:00	0.0	0	0	0	0	0
05/20/2020 06:00	0.0	0	0	0	0	0
05/20/2020 07:00	0.0	0	0	0	0	0
05/20/2020 08:00	0.0	0	0	0	0	0
05/20/2020 09:00	0.0	0	0	0	0	0
05/20/2020 10:00	0.0	0	0	0	0	0
05/20/2020 11:00	0.0	0	0	0	0	0
05/20/2020 12:00	0.0	0	0	0	0	0
05/20/2020 13:00	0.0	0	0	0	0	0
05/20/2020 14:00	0.0	0	0	0	0	0
05/20/2020 15:00	0.0	0	0	0	0	0
05/20/2020 16:00	0.0	0	0	0	0	0
05/20/2020 17:00	0.0	0	0	0	0	0
05/20/2020 18:00	0.0	0	0	0	0	0
05/20/2020 19:00	0.0	0	0	0	0	0
05/20/2020 20:00	0.0	0	0	0	0	0
05/20/2020 21:00	0.0	0	0	0	0	0
05/20/2020 22:00	0.0	0	0	0	0	0
05/20/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/21/2020 00:00	0.0	0	0	0	0	0
05/21/2020 01:00	0.0	0	0	0	0	0
05/21/2020 02:00	0.0	0	0	0	0	0
05/21/2020 03:00	0.0	0	0	0	0	0
05/21/2020 04:00	0.0	0	0	0	0	0
05/21/2020 05:00	0.0	0	0	0	0	0
05/21/2020 06:00	0.0	0	0	0	0	0
05/21/2020 07:00	0.0	0	0	0	0	0
05/21/2020 08:00	0.0	0	0	0	0	0
05/21/2020 09:00	0.0	0	0	0	0	0
05/21/2020 10:00	0.0	0	0	0	0	0
05/21/2020 11:00	0.0	0	0	0	0	0
05/21/2020 12:00	0.0	0	0	0	0	0
05/21/2020 13:00	0.0	0	0	0	0	0
05/21/2020 14:00	0.0	0	0	0	0	0
05/21/2020 15:00	0.0	0	0	0	0	0
05/21/2020 16:00	0.0	0	0	0	0	0
05/21/2020 17:00	0.0	0	0	0	0	0
05/21/2020 18:00	0.0	0	0	0	0	0
05/21/2020 19:00	0.0	0	0	0	0	0
05/21/2020 20:00	0.0	0	0	0	0	0
05/21/2020 21:00	0.0	0	0	0	0	0
05/21/2020 22:00	0.0	0	0	0	0	0
05/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/22/2020 00:00	0.0	0	0	0	0	0
05/22/2020 01:00	0.0	0	0	0	0	0
05/22/2020 02:00	0.0	0	0	0	0	0
05/22/2020 03:00	0.0	0	0	0	0	0
05/22/2020 04:00	0.0	0	0	0	0	0
05/22/2020 05:00	0.0	0	0	0	0	0
05/22/2020 06:00	0.0	0	0	0	0	0
05/22/2020 07:00	0.0	0	0	0	0	0
05/22/2020 08:00	0.0	0	0	0	0	0
05/22/2020 09:00	0.0	0	0	0	0	0
05/22/2020 10:00	0.0	0	0	0	0	0
05/22/2020 11:00	0.0	0	0	0	0	0
05/22/2020 12:00	0.0	0	0	0	0	0
05/22/2020 13:00	0.0	0	0	0	0	0
05/22/2020 14:00	0.0	0	0	0	0	0
05/22/2020 15:00	0.0	0	0	0	0	0
05/22/2020 16:00	0.0	0	0	0	0	0
05/22/2020 17:00	0.0	0	0	0	0	0
05/22/2020 18:00	0.0	0	0	0	0	0
05/22/2020 19:00	0.0	0	0	0	0	0
05/22/2020 20:00	0.0	0	0	0	0	0
05/22/2020 21:00	0.0	0	0	0	0	0
05/22/2020 22:00	0.0	0	0	0	0	0
05/22/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/23/2020 00:00	0.0	0	0	0	0	0
05/23/2020 01:00	0.0	0	0	0	0	0
05/23/2020 02:00	0.0	0	0	0	0	0
05/23/2020 03:00	0.0	0	0	0	0	0
05/23/2020 04:00	0.0	0	0	0	0	0
05/23/2020 05:00	0.0	0	0	0	0	0
05/23/2020 06:00	0.0	0	0	0	0	0
05/23/2020 07:00	0.0	0	0	0	0	0
05/23/2020 08:00	0.0	0	0	0	0	0
05/23/2020 09:00	0.0	0	0	0	0	0
05/23/2020 10:00	0.0	0	0	0	0	0
05/23/2020 11:00	0.0	0	0	0	0	0
05/23/2020 12:00	0.0	0	0	0	0	0
05/23/2020 13:00	0.0	0	0	0	0	0
05/23/2020 14:00	0.0	0	0	0	0	0
05/23/2020 15:00	0.0	0	0	0	0	0
05/23/2020 16:00	0.0	0	0	0	0	0
05/23/2020 17:00	0.0	0	0	0	0	0
05/23/2020 18:00	0.0	0	0	0	0	0
05/23/2020 19:00	0.0	0	0	0	0	0
05/23/2020 20:00	0.0	0	0	0	0	0
05/23/2020 21:00	0.0	0	0	0	0	0
05/23/2020 22:00	0.0	0	0	0	0	0
05/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/24/2020 00:00	0.0	0	0	0	0	0
05/24/2020 01:00	0.0	0	0	0	0	0
05/24/2020 02:00	0.0	0	0	0	0	0
05/24/2020 03:00	0.0	0	0	0	0	0
05/24/2020 04:00	0.0	0	0	0	0	0
05/24/2020 05:00	0.0	0	0	0	0	0
05/24/2020 06:00	0.0	0	0	0	0	0
05/24/2020 07:00	0.0	0	0	0	0	0
05/24/2020 08:00	0.0	0	0	0	0	0
05/24/2020 09:00	0.0	0	0	0	0	0
05/24/2020 10:00	0.0	0	0	0	0	0
05/24/2020 11:00	0.0	0	0	0	0	0
05/24/2020 12:00	0.0	0	0	0	0	0
05/24/2020 13:00	0.0	0	0	0	0	0
05/24/2020 14:00	0.0	0	0	0	0	0
05/24/2020 15:00	0.0	0	0	0	0	0
05/24/2020 16:00	0.0	0	0	0	0	0
05/24/2020 17:00	0.0	0	0	0	0	0
05/24/2020 18:00	0.0	0	0	0	0	0
05/24/2020 19:00	0.0	0	0	0	0	0
05/24/2020 20:00	0.0	0	0	0	0	0
05/24/2020 21:00	0.0	0	0	0	0	0
05/24/2020 22:00	0.0	0	0	0	0	0
05/24/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/25/2020 00:00	0.0	0	0	0	0	0
05/25/2020 01:00	0.0	0	0	0	0	0
05/25/2020 02:00	0.0	0	0	0	0	0
05/25/2020 03:00	0.0	0	0	0	0	0
05/25/2020 04:00	0.0	0	0	0	0	0
05/25/2020 05:00	0.0	0	0	0	0	0
05/25/2020 06:00	0.0	0	0	0	0	0
05/25/2020 07:00	0.0	0	0	0	0	0
05/25/2020 08:00	0.0	0	0	0	0	0
05/25/2020 09:00	0.0	0	0	0	0	0
05/25/2020 10:00	0.0	0	0	0	0	0
05/25/2020 11:00	0.0	0	0	0	0	0
05/25/2020 12:00	0.0	0	0	0	0	0
05/25/2020 13:00	0.0	0	0	0	0	0
05/25/2020 14:00	0.0	0	0	0	0	0
05/25/2020 15:00	0.0	0	0	0	0	0
05/25/2020 16:00	0.0	0	0	0	0	0
05/25/2020 17:00	0.0	0	0	0	0	0
05/25/2020 18:00	0.0	0	0	0	0	0
05/25/2020 19:00	0.0	0	0	0	0	0
05/25/2020 20:00	0.0	0	0	0	0	0
05/25/2020 21:00	0.0	0	0	0	0	0
05/25/2020 22:00	0.0	0	0	0	0	0
05/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/26/2020 00:00	0.0	0	0	0	0	0
05/26/2020 01:00	0.0	0	0	0	0	0
05/26/2020 02:00	0.0	0	0	0	0	0
05/26/2020 03:00	0.0	0	0	0	0	0
05/26/2020 04:00	0.0	0	0	0	0	0
05/26/2020 05:00	0.0	0	0	0	0	0
05/26/2020 06:00	0.0	0	0	0	0	0
05/26/2020 07:00	0.0	0	0	0	0	0
05/26/2020 08:00	0.0	0	0	0	0	0
05/26/2020 09:00	0.0	0	0	0	0	0
05/26/2020 10:00	9,227.7	1	0	0	1	0
05/26/2020 11:00	2,297.1	1	0	0	0	0
05/26/2020 12:00	19,799.6	1	0	0	0	0
05/26/2020 13:00	19,802.6	1	0	0	0	0
05/26/2020 14:00	20,413.0	1	0	0	0	0
05/26/2020 15:00	6,458.6	1	0	0	1	0
05/26/2020 16:00	0.0	0	0	0	0	0
05/26/2020 17:00	0.0	0	0	0	0	0
05/26/2020 18:00	0.0	0	0	0	0	0
05/26/2020 19:00	0.0	0	0	0	0	0
05/26/2020 20:00	0.0	0	0	0	0	0
05/26/2020 21:00	0.0	0	0	0	0	0
05/26/2020 22:00	0.0	0	0	0	0	0
05/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	77,998.6 #	6 #	0 #	0 #	2 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	20,413.0	1	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/27/2020 00:00	0.0	0	0	0	0	0
05/27/2020 01:00	0.0	0	0	0	0	0
05/27/2020 02:00	0.0	0	0	0	0	0
05/27/2020 03:00	0.0	0	0	0	0	0
05/27/2020 04:00	0.0	0	0	0	0	0
05/27/2020 05:00	0.0	0	0	0	0	0
05/27/2020 06:00	0.0	0	0	0	0	0
05/27/2020 07:00	0.0	0	0	0	0	0
05/27/2020 08:00	0.0	0	0	0	0	0
05/27/2020 09:00	0.0	0	0	0	0	0
05/27/2020 10:00	0.0	0	0	0	0	0
05/27/2020 11:00	0.0	0	0	0	0	0
05/27/2020 12:00	0.0	0	0	0	0	0
05/27/2020 13:00	0.0	0	0	0	0	0
05/27/2020 14:00	0.0	0	0	0	0	0
05/27/2020 15:00	0.0	0	0	0	0	0
05/27/2020 16:00	0.0	0	0	0	0	0
05/27/2020 17:00	0.0	0	0	0	0	0
05/27/2020 18:00	0.0	0	0	0	0	0
05/27/2020 19:00	0.0	0	0	0	0	0
05/27/2020 20:00	0.0	0	0	0	0	0
05/27/2020 21:00	0.0	0	0	0	0	0
05/27/2020 22:00	0.0	0	0	0	0	0
05/27/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/28/2020 00:00	0.0	0	0	0	0	0
05/28/2020 01:00	0.0	0	0	0	0	0
05/28/2020 02:00	0.0	0	0	0	0	0
05/28/2020 03:00	0.0	0	0	0	0	0
05/28/2020 04:00	0.0	0	0	0	0	0
05/28/2020 05:00	0.0	0	0	0	0	0
05/28/2020 06:00	0.0	0	0	0	0	0
05/28/2020 07:00	0.0	0	0	0	0	0
05/28/2020 08:00	0.0	0	0	0	0	0
05/28/2020 09:00	0.0	0	0	0	0	0
05/28/2020 10:00	0.0	0	0	0	0	0
05/28/2020 11:00	0.0	0	0	0	0	0
05/28/2020 12:00	7,287.4	1	0	0	0	0
05/28/2020 13:00	19,914.2	1	0	0	0	0
05/28/2020 14:00	20,465.7	1	0	0	0	0
05/28/2020 15:00	8,138.1	1	0	0	0	0
05/28/2020 16:00	0.0	0	0	0	0	1
05/28/2020 17:00	0.0	0	0	0	0	1
05/28/2020 18:00	0.0	0	0	0	0	1
05/28/2020 19:00	0.0	0	0	0	0	1
05/28/2020 20:00	0.0	0	0	0	0	1
05/28/2020 21:00	0.0	0	0	0	0	1
05/28/2020 22:00	0.0	0	0	0	0	1
05/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	55,805.4 #	4 #	0 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	20,465.7	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/29/2020 00:00	0.0	0	0	0	0	1
05/29/2020 01:00	2,017.1	0	0	0	1	0
05/29/2020 02:00	0.0	0	0	0	0	0
05/29/2020 03:00	0.0	0	0	0	0	0
05/29/2020 04:00	0.0	0	0	0	0	0
05/29/2020 05:00	0.0	0	0	0	0	0
05/29/2020 06:00	0.0	0	0	0	0	0
05/29/2020 07:00	0.0	0	0	0	0	0
05/29/2020 08:00	0.0	0	0	0	0	0
05/29/2020 09:00	0.0	0	0	0	0	0
05/29/2020 10:00	0.0	0	0	0	0	0
05/29/2020 11:00	0.0	0	0	0	0	0
05/29/2020 12:00	0.0	0	0	0	0	0
05/29/2020 13:00	0.0	0	0	0	0	0
05/29/2020 14:00	0.0	0	0	0	0	0
05/29/2020 15:00	0.0	0	0	0	0	0
05/29/2020 16:00	0.0	0	0	0	0	0
05/29/2020 17:00	0.0	0	0	0	0	0
05/29/2020 18:00	0.0	0	0	0	0	0
05/29/2020 19:00	0.0	0	0	0	0	0
05/29/2020 20:00	0.0	0	0	0	0	0
05/29/2020 21:00	0.0	0	0	0	0	0
05/29/2020 22:00	0.0	0	0	0	0	0
05/29/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	2,017.1 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2,017.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/30/2020 00:00	0.0	0	0	0	0	0
05/30/2020 01:00	0.0	0	0	0	0	0
05/30/2020 02:00	0.0	0	0	0	0	0
05/30/2020 03:00	0.0	0	0	0	0	0
05/30/2020 04:00	0.0	0	0	0	0	0
05/30/2020 05:00	0.0	0	0	0	0	0
05/30/2020 06:00	0.0	0	0	0	0	0
05/30/2020 07:00	0.0	0	0	0	0	0
05/30/2020 08:00	0.0	0	0	0	0	0
05/30/2020 09:00	0.0	0	0	0	0	0
05/30/2020 10:00	0.0	0	0	0	0	0
05/30/2020 11:00	0.0	0	0	0	0	0
05/30/2020 12:00	0.0	0	0	0	0	0
05/30/2020 13:00	0.0	0	0	0	0	0
05/30/2020 14:00	0.0	0	0	0	0	0
05/30/2020 15:00	0.0	0	0	0	0	0
05/30/2020 16:00	0.0	0	0	0	0	0
05/30/2020 17:00	0.0	0	0	0	0	0
05/30/2020 18:00	0.0	0	0	0	0	0
05/30/2020 19:00	0.0	0	0	0	0	0
05/30/2020 20:00	0.0	0	0	0	0	0
05/30/2020 21:00	0.0	0	0	0	0	0
05/30/2020 22:00	0.0	0	0	0	0	0
05/30/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/31/2020 00:00	0.0	0	0	0	0	0
05/31/2020 01:00	0.0	0	0	0	0	0
05/31/2020 02:00	0.0	0	0	0	0	0
05/31/2020 03:00	0.0	0	0	0	0	0
05/31/2020 04:00	0.0	0	0	0	0	0
05/31/2020 05:00	0.0	0	0	0	0	0
05/31/2020 06:00	0.0	0	0	0	0	0
05/31/2020 07:00	0.0	0	0	0	0	0
05/31/2020 08:00	0.0	0	0	0	0	0
05/31/2020 09:00	0.0	0	0	0	0	0
05/31/2020 10:00	0.0	0	0	0	0	0
05/31/2020 11:00	0.0	0	0	0	0	0
05/31/2020 12:00	0.0	0	0	0	0	0
05/31/2020 13:00	0.0	0	0	0	0	0
05/31/2020 14:00	0.0	0	0	0	0	0
05/31/2020 15:00	0.0	0	0	0	0	0
05/31/2020 16:00	0.0	0	0	0	0	0
05/31/2020 17:00	0.0	0	0	0	0	0
05/31/2020 18:00	0.0	0	0	0	0	0
05/31/2020 19:00	0.0	0	0	0	0	0
05/31/2020 20:00	0.0	0	0	0	0	0
05/31/2020 21:00	0.0	0	0	0	0	0
05/31/2020 22:00	0.0	0	0	0	0	0
05/31/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/01/2020 00:00	0.0	0	0	0	0	0
06/01/2020 01:00	0.0	0	0	0	0	0
06/01/2020 02:00	0.0	0	0	0	0	0
06/01/2020 03:00	0.0	0	0	0	0	0
06/01/2020 04:00	0.0	0	0	0	0	0
06/01/2020 05:00	0.0	0	0	0	0	0
06/01/2020 06:00	0.0	0	0	0	0	0
06/01/2020 07:00	0.0	0	0	0	0	0
06/01/2020 08:00	0.0	0	0	0	0	0
06/01/2020 09:00	0.0	0	0	0	0	0
06/01/2020 10:00	0.0	0	0	0	0	0
06/01/2020 11:00	0.0	0	0	0	0	0
06/01/2020 12:00	3,943.6	1	0	0	0	0
06/01/2020 13:00	14,525.4	1	0	0	1	0
06/01/2020 14:00	12,033.0	1	0	0	0	0
06/01/2020 15:00	0.0	0	0	0	0	1
06/01/2020 16:00	0.0	0	0	0	0	1
06/01/2020 17:00	0.0	0	0	0	0	1
06/01/2020 18:00	0.0	0	0	0	0	1
06/01/2020 19:00	0.0	0	0	0	0	1
06/01/2020 20:00	0.0	0	0	0	0	1
06/01/2020 21:00	0.0	0	0	0	0	1
06/01/2020 22:00	0.0	0	0	0	0	1
06/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	30,502.0 #	3 #	0 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	14,525.4	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/02/2020 00:00	0.0	0	0	0	0	1
06/02/2020 01:00	0.0	0	0	0	0	1
06/02/2020 02:00	0.0	0	0	0	0	1
06/02/2020 03:00	0.0	0	0	0	0	1
06/02/2020 04:00	0.0	0	0	0	0	1
06/02/2020 05:00	0.0	0	0	0	0	1
06/02/2020 06:00	0.0	0	0	0	0	1
06/02/2020 07:00	0.0	0	0	0	0	1
06/02/2020 08:00	0.0	0	0	0	0	1
06/02/2020 09:00	0.0	0	0	0	0	1
06/02/2020 10:00	0.0	0	0	0	0	1
06/02/2020 11:00	0.0	0	0	0	0	1
06/02/2020 12:00	0.0	0	0	0	0	1
06/02/2020 13:00	0.0	0	0	0	0	1
06/02/2020 14:00	0.0	0	0	0	0	1
06/02/2020 15:00	0.0	0	0	0	0	1
06/02/2020 16:00	0.0	0	0	0	0	1
06/02/2020 17:00	0.0	0	0	0	0	1
06/02/2020 18:00	0.0	0	0	0	0	1
06/02/2020 19:00	0.0	0	0	0	0	1
06/02/2020 20:00	0.0	0	0	0	0	1
06/02/2020 21:00	0.0	0	0	0	0	1
06/02/2020 22:00	0.0	0	0	0	0	1
06/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/03/2020 00:00	0.0	0	0	0	0	1
06/03/2020 01:00	0.0	0	0	0	0	1
06/03/2020 02:00	0.0	0	0	0	0	1
06/03/2020 03:00	0.0	0	0	0	0	1
06/03/2020 04:00	0.0	0	0	0	0	1
06/03/2020 05:00	0.0	0	0	0	0	1
06/03/2020 06:00	0.0	0	0	0	0	1
06/03/2020 07:00	0.0	0	0	0	0	1
06/03/2020 08:00	0.0	0	0	0	0	1
06/03/2020 09:00	0.0	0	0	0	0	1
06/03/2020 10:00	0.0	0	0	0	0	1
06/03/2020 11:00	0.0	0	0	0	0	1
06/03/2020 12:00	0.0	0	0	0	0	1
06/03/2020 13:00	0.0	0	0	0	0	1
06/03/2020 14:00	0.0	0	0	0	0	1
06/03/2020 15:00	0.0	0	0	0	0	1
06/03/2020 16:00	0.0	0	0	0	0	1
06/03/2020 17:00	0.0	0	0	0	0	1
06/03/2020 18:00	0.0	0	0	0	0	1
06/03/2020 19:00	0.0	0	0	0	0	1
06/03/2020 20:00	0.0	0	0	0	0	1
06/03/2020 21:00	0.0	0	0	0	0	1
06/03/2020 22:00	0.0	0	0	0	0	1
06/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/04/2020 00:00	2,016.6	0	0	0	1	0
06/04/2020 01:00	0.0	0	0	0	0	0
06/04/2020 02:00	0.0	0	0	0	0	0
06/04/2020 03:00	0.0	0	0	0	0	0
06/04/2020 04:00	0.0	0	0	0	0	0
06/04/2020 05:00	0.0	0	0	0	0	0
06/04/2020 06:00	6,296.5	0	0	1	0	0
06/04/2020 07:00	18,635.9	0	0	1	0	0
06/04/2020 08:00	0.0	0	0	0	0	1
06/04/2020 09:00	0.0	0	0	0	0	1
06/04/2020 10:00	0.0	0	0	0	0	1
06/04/2020 11:00	0.0	0	0	0	0	1
06/04/2020 12:00	0.0	0	0	0	0	1
06/04/2020 13:00	0.0	0	0	0	0	1
06/04/2020 14:00	0.0	0	0	0	0	1
06/04/2020 15:00	0.0	0	0	0	0	1
06/04/2020 16:00	0.0	0	0	0	0	1
06/04/2020 17:00	0.0	0	0	0	0	1
06/04/2020 18:00	0.0	0	0	0	0	1
06/04/2020 19:00	0.0	0	0	0	0	1
06/04/2020 20:00	0.0	0	0	0	0	1
06/04/2020 21:00	0.0	0	0	0	0	1
06/04/2020 22:00	0.0	0	0	0	0	1
06/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	26,949.0 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	18,635.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/05/2020 00:00	1,961.6	0	0	0	1	0
06/05/2020 01:00	0.0	0	0	0	0	0
06/05/2020 02:00	0.0	0	0	0	0	0
06/05/2020 03:00	0.0	0	0	0	0	0
06/05/2020 04:00	0.0	0	0	0	0	0
06/05/2020 05:00	0.0	0	0	0	0	0
06/05/2020 06:00	0.0	0	0	0	0	0
06/05/2020 07:00	0.0	0	0	0	0	0
06/05/2020 08:00	0.0	0	0	0	0	0
06/05/2020 09:00	0.0	0	0	0	0	0
06/05/2020 10:00	0.0	0	0	0	0	0
06/05/2020 11:00	0.0	0	0	0	0	0
06/05/2020 12:00	0.0	0	0	0	0	0
06/05/2020 13:00	0.0	0	0	0	0	0
06/05/2020 14:00	0.0	0	0	0	0	0
06/05/2020 15:00	0.0	0	0	0	0	0
06/05/2020 16:00	0.0	0	0	0	0	0
06/05/2020 17:00	0.0	0	0	0	0	0
06/05/2020 18:00	0.0	0	0	0	0	0
06/05/2020 19:00	0.0	0	0	0	0	0
06/05/2020 20:00	0.0	0	0	0	0	0
06/05/2020 21:00	0.0	0	0	0	0	0
06/05/2020 22:00	0.0	0	0	0	0	0
06/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1,961.6 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1,961.6	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/06/2020 00:00	0.0	0	0	0	0	0
06/06/2020 01:00	0.0	0	0	0	0	0
06/06/2020 02:00	0.0	0	0	0	0	0
06/06/2020 03:00	0.0	0	0	0	0	0
06/06/2020 04:00	0.0	0	0	0	0	0
06/06/2020 05:00	0.0	0	0	0	0	0
06/06/2020 06:00	0.0	0	0	0	0	0
06/06/2020 07:00	0.0	0	0	0	0	0
06/06/2020 08:00	0.0	0	0	0	0	0
06/06/2020 09:00	0.0	0	0	0	0	0
06/06/2020 10:00	0.0	0	0	0	0	0
06/06/2020 11:00	0.0	0	0	0	0	0
06/06/2020 12:00	0.0	0	0	0	0	0
06/06/2020 13:00	0.0	0	0	0	0	0
06/06/2020 14:00	0.0	0	0	0	0	0
06/06/2020 15:00	0.0	0	0	0	0	0
06/06/2020 16:00	0.0	0	0	0	0	0
06/06/2020 17:00	0.0	0	0	0	0	0
06/06/2020 18:00	0.0	0	0	0	0	0
06/06/2020 19:00	0.0	0	0	0	0	0
06/06/2020 20:00	0.0	0	0	0	0	0
06/06/2020 21:00	0.0	0	0	0	0	0
06/06/2020 22:00	0.0	0	0	0	0	0
06/06/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/07/2020 00:00	0.0	0	0	0	0	0
06/07/2020 01:00	0.0	0	0	0	0	0
06/07/2020 02:00	0.0	0	0	0	0	0
06/07/2020 03:00	0.0	0	0	0	0	0
06/07/2020 04:00	0.0	0	0	0	0	0
06/07/2020 05:00	0.0	0	0	0	0	0
06/07/2020 06:00	0.0	0	0	0	0	0
06/07/2020 07:00	0.0	0	0	0	0	0
06/07/2020 08:00	0.0	0	0	0	0	0
06/07/2020 09:00	0.0	0	0	0	0	0
06/07/2020 10:00	0.0	0	0	0	0	0
06/07/2020 11:00	0.0	0	0	0	0	0
06/07/2020 12:00	0.0	0	0	0	0	0
06/07/2020 13:00	0.0	0	0	0	0	0
06/07/2020 14:00	0.0	0	0	0	0	0
06/07/2020 15:00	0.0	0	0	0	0	0
06/07/2020 16:00	0.0	0	0	0	0	0
06/07/2020 17:00	0.0	0	0	0	0	0
06/07/2020 18:00	0.0	0	0	0	0	0
06/07/2020 19:00	0.0	0	0	0	0	0
06/07/2020 20:00	0.0	0	0	0	0	0
06/07/2020 21:00	0.0	0	0	0	0	0
06/07/2020 22:00	0.0	0	0	0	0	0
06/07/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/08/2020 00:00	0.0	0	0	0	0	0
06/08/2020 01:00	0.0	0	0	0	0	0
06/08/2020 02:00	0.0	0	0	0	0	0
06/08/2020 03:00	0.0	0	0	0	0	0
06/08/2020 04:00	0.0	0	0	0	0	0
06/08/2020 05:00	0.0	0	0	0	0	0
06/08/2020 06:00	0.0	0	0	0	0	0
06/08/2020 07:00	0.0	0	0	0	0	0
06/08/2020 08:00	0.0	0	0	0	0	0
06/08/2020 09:00	0.0	0	0	0	0	0
06/08/2020 10:00	0.0	0	0	0	0	0
06/08/2020 11:00	0.0	0	0	0	0	0
06/08/2020 12:00	0.0	0	0	0	0	0
06/08/2020 13:00	0.0	0	0	0	0	0
06/08/2020 14:00	0.0	0	0	0	0	0
06/08/2020 15:00	10,723.8	1	0	0	0	0
06/08/2020 16:00	19,787.1	1	0	0	0	0
06/08/2020 17:00	7,507.7	1	0	1	1	0
06/08/2020 18:00	9,696.3	0	0	1	0	0
06/08/2020 19:00	0.0	0	0	0	0	1
06/08/2020 20:00	0.0	0	0	0	0	1
06/08/2020 21:00	0.0	0	0	0	0	1
06/08/2020 22:00	0.0	0	0	0	0	1
06/08/2020 23:00	1,677.0	0	0	0	1	0
Average/Sum#:	49,391.9 #	3 #	0 #	2 #	2 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	19,787.1	1	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/09/2020 00:00	0.0	0	0	0	0	0
06/09/2020 01:00	0.0	0	0	0	0	0
06/09/2020 02:00	0.0	0	0	0	0	0
06/09/2020 03:00	0.0	0	0	0	0	0
06/09/2020 04:00	0.0	0	0	0	0	0
06/09/2020 05:00	0.0	0	0	0	0	0
06/09/2020 06:00	0.0	0	0	0	0	0
06/09/2020 07:00	0.0	0	0	0	0	0
06/09/2020 08:00	0.0	0	0	0	0	0
06/09/2020 09:00	0.0	0	0	0	0	0
06/09/2020 10:00	0.0	0	0	0	0	0
06/09/2020 11:00	0.0	0	0	0	0	0
06/09/2020 12:00	7,846.4	0	1	0	0	0
06/09/2020 13:00	7,494.4	0	1	0	1	0
06/09/2020 14:00	17,786.2	0	1	0	0	0
06/09/2020 15:00	1,177.3	0	1	0	0	0
06/09/2020 16:00	0.0	0	0	0	0	1
06/09/2020 17:00	0.0	0	0	0	0	1
06/09/2020 18:00	0.0	0	0	0	0	1
06/09/2020 19:00	0.0	0	0	0	0	1
06/09/2020 20:00	0.0	0	0	0	0	1
06/09/2020 21:00	0.0	0	0	0	0	1
06/09/2020 22:00	0.0	0	0	0	0	1
06/09/2020 23:00	2,013.7	0	0	0	1	0
Average/Sum#:	36,318.0 #	0 #	4 #	0 #	2 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	17,786.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/10/2020 00:00	0.0	0	0	0	0	0
06/10/2020 01:00	0.0	0	0	0	0	0
06/10/2020 02:00	0.0	0	0	0	0	0
06/10/2020 03:00	0.0	0	0	0	0	0
06/10/2020 04:00	0.0	0	0	0	0	0
06/10/2020 05:00	0.0	0	0	0	0	0
06/10/2020 06:00	0.0	0	0	0	0	0
06/10/2020 07:00	0.0	0	0	0	0	0
06/10/2020 08:00	0.0	0	0	0	0	0
06/10/2020 09:00	0.0	0	0	0	0	0
06/10/2020 10:00	13,743.9	0	1	0	0	0
06/10/2020 11:00	22,374.6	0	1	0	0	0
06/10/2020 12:00	5,080.2	0	1	0	0	0
06/10/2020 13:00	0.0	0	0	0	0	1
06/10/2020 14:00	0.0	0	0	0	0	1
06/10/2020 15:00	0.0	0	0	0	0	1
06/10/2020 16:00	0.0	0	0	0	0	1
06/10/2020 17:00	0.0	0	0	0	0	1
06/10/2020 18:00	0.0	0	0	0	0	1
06/10/2020 19:00	0.0	0	0	0	0	1
06/10/2020 20:00	0.0	0	0	0	0	1
06/10/2020 21:00	0.0	0	0	0	0	1
06/10/2020 22:00	0.0	0	0	0	0	1
06/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	41,198.7 #	0 #	3 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	22,374.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/11/2020 00:00	0.0	0	0	0	0	1
06/11/2020 01:00	0.0	0	0	0	0	1
06/11/2020 02:00	0.0	0	0	0	0	1
06/11/2020 03:00	0.0	0	0	0	0	1
06/11/2020 04:00	0.0	0	0	0	0	1
06/11/2020 05:00	0.0	0	0	0	0	1
06/11/2020 06:00	0.0	0	0	0	0	1
06/11/2020 07:00	0.0	0	0	0	0	1
06/11/2020 08:00	0.0	0	0	0	0	1
06/11/2020 09:00	0.0	0	0	0	0	1
06/11/2020 10:00	0.0	0	0	0	0	1
06/11/2020 11:00	0.0	0	0	0	0	1
06/11/2020 12:00	0.0	0	0	0	0	1
06/11/2020 13:00	0.0	0	0	0	0	1
06/11/2020 14:00	0.0	0	0	0	0	1
06/11/2020 15:00	0.0	0	0	0	0	1
06/11/2020 16:00	0.0	0	0	0	0	1
06/11/2020 17:00	0.0	0	0	0	0	1
06/11/2020 18:00	0.0	0	0	0	0	1
06/11/2020 19:00	0.0	0	0	0	0	1
06/11/2020 20:00	0.0	0	0	0	0	1
06/11/2020 21:00	0.0	0	0	0	0	1
06/11/2020 22:00	0.0	0	0	0	0	1
06/11/2020 23:00	2,016.7	0	0	0	1	0
Average/Sum#:	2,016.7 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2,016.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/12/2020 00:00	0.0	0	0	0	0	0
06/12/2020 01:00	0.0	0	0	0	0	0
06/12/2020 02:00	0.0	0	0	0	0	0
06/12/2020 03:00	0.0	0	0	0	0	0
06/12/2020 04:00	0.0	0	0	0	0	0
06/12/2020 05:00	0.0	0	0	0	0	0
06/12/2020 06:00	0.0	0	0	0	0	0
06/12/2020 07:00	0.0	0	0	0	0	0
06/12/2020 08:00	0.0	0	0	0	0	0
06/12/2020 09:00	0.0	0	0	0	0	0
06/12/2020 10:00	0.0	0	0	0	0	0
06/12/2020 11:00	0.0	0	0	0	0	0
06/12/2020 12:00	0.0	0	0	0	0	0
06/12/2020 13:00	0.0	0	0	0	0	0
06/12/2020 14:00	0.0	0	0	0	0	0
06/12/2020 15:00	0.0	0	0	0	0	0
06/12/2020 16:00	0.0	0	0	0	0	0
06/12/2020 17:00	0.0	0	0	0	0	0
06/12/2020 18:00	0.0	0	0	0	0	0
06/12/2020 19:00	0.0	0	0	0	0	0
06/12/2020 20:00	0.0	0	0	0	0	0
06/12/2020 21:00	0.0	0	0	0	0	0
06/12/2020 22:00	0.0	0	0	0	0	0
06/12/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/13/2020 00:00	0.0	0	0	0	0	0
06/13/2020 01:00	0.0	0	0	0	0	0
06/13/2020 02:00	0.0	0	0	0	0	0
06/13/2020 03:00	0.0	0	0	0	0	0
06/13/2020 04:00	0.0	0	0	0	0	0
06/13/2020 05:00	0.0	0	0	0	0	0
06/13/2020 06:00	0.0	0	0	0	0	0
06/13/2020 07:00	0.0	0	0	0	0	0
06/13/2020 08:00	0.0	0	0	0	0	0
06/13/2020 09:00	0.0	0	0	0	0	0
06/13/2020 10:00	0.0	0	0	0	0	0
06/13/2020 11:00	0.0	0	0	0	0	0
06/13/2020 12:00	0.0	0	0	0	0	0
06/13/2020 13:00	0.0	0	0	0	0	0
06/13/2020 14:00	0.0	0	0	0	0	0
06/13/2020 15:00	0.0	0	0	0	0	0
06/13/2020 16:00	0.0	0	0	0	0	0
06/13/2020 17:00	0.0	0	0	0	0	0
06/13/2020 18:00	0.0	0	0	0	0	0
06/13/2020 19:00	0.0	0	0	0	0	0
06/13/2020 20:00	0.0	0	0	0	0	0
06/13/2020 21:00	0.0	0	0	0	0	0
06/13/2020 22:00	0.0	0	0	0	0	0
06/13/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/14/2020 00:00	0.0	0	0	0	0	0
06/14/2020 01:00	0.0	0	0	0	0	0
06/14/2020 02:00	0.0	0	0	0	0	0
06/14/2020 03:00	0.0	0	0	0	0	0
06/14/2020 04:00	0.0	0	0	0	0	0
06/14/2020 05:00	0.0	0	0	0	0	0
06/14/2020 06:00	0.0	0	0	0	0	0
06/14/2020 07:00	0.0	0	0	0	0	0
06/14/2020 08:00	0.0	0	0	0	0	0
06/14/2020 09:00	0.0	0	0	0	0	0
06/14/2020 10:00	0.0	0	0	0	0	0
06/14/2020 11:00	0.0	0	0	0	0	0
06/14/2020 12:00	0.0	0	0	0	0	0
06/14/2020 13:00	0.0	0	0	0	0	0
06/14/2020 14:00	0.0	0	0	0	0	0
06/14/2020 15:00	0.0	0	0	0	0	0
06/14/2020 16:00	0.0	0	0	0	0	0
06/14/2020 17:00	0.0	0	0	0	0	0
06/14/2020 18:00	0.0	0	0	0	0	0
06/14/2020 19:00	0.0	0	0	0	0	0
06/14/2020 20:00	0.0	0	0	0	0	0
06/14/2020 21:00	0.0	0	0	0	0	0
06/14/2020 22:00	0.0	0	0	0	0	0
06/14/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/15/2020 00:00	0.0	0	0	0	0	0
06/15/2020 01:00	0.0	0	0	0	0	0
06/15/2020 02:00	0.0	0	0	0	0	0
06/15/2020 03:00	0.0	0	0	0	0	0
06/15/2020 04:00	0.0	0	0	0	0	0
06/15/2020 05:00	0.0	0	0	0	0	0
06/15/2020 06:00	0.0	0	0	0	0	0
06/15/2020 07:00	0.0	0	0	0	0	0
06/15/2020 08:00	0.0	0	0	0	0	0
06/15/2020 09:00	0.0	0	0	0	0	0
06/15/2020 10:00	0.0	0	0	0	0	0
06/15/2020 11:00	0.0	0	0	0	0	0
06/15/2020 12:00	0.0	0	0	0	0	0
06/15/2020 13:00	0.0	0	0	0	0	0
06/15/2020 14:00	0.0	0	0	0	0	0
06/15/2020 15:00	0.0	0	0	0	0	0
06/15/2020 16:00	0.0	0	0	0	0	0
06/15/2020 17:00	0.0	0	0	0	0	0
06/15/2020 18:00	0.0	0	0	0	0	0
06/15/2020 19:00	0.0	0	0	0	0	0
06/15/2020 20:00	0.0	0	0	0	0	0
06/15/2020 21:00	0.0	0	0	0	0	0
06/15/2020 22:00	0.0	0	0	0	0	0
06/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/16/2020 00:00	0.0	0	0	0	0	0
06/16/2020 01:00	0.0	0	0	0	0	0
06/16/2020 02:00	0.0	0	0	0	0	0
06/16/2020 03:00	0.0	0	0	0	0	0
06/16/2020 04:00	0.0	0	0	0	0	0
06/16/2020 05:00	0.0	0	0	0	0	0
06/16/2020 06:00	0.0	0	0	0	0	0
06/16/2020 07:00	0.0	0	0	0	0	0
06/16/2020 08:00	0.0	0	0	0	0	0
06/16/2020 09:00	0.0	0	0	0	0	0
06/16/2020 10:00	0.0	0	0	0	0	0
06/16/2020 11:00	0.0	0	0	0	0	0
06/16/2020 12:00	0.0	0	0	0	0	0
06/16/2020 13:00	0.0	0	0	0	0	0
06/16/2020 14:00	0.0	0	0	0	0	0
06/16/2020 15:00	0.0	0	0	0	0	0
06/16/2020 16:00	0.0	0	0	0	0	0
06/16/2020 17:00	0.0	0	0	0	0	0
06/16/2020 18:00	0.0	0	0	0	0	0
06/16/2020 19:00	0.0	0	0	0	0	0
06/16/2020 20:00	0.0	0	0	0	0	0
06/16/2020 21:00	0.0	0	0	0	0	0
06/16/2020 22:00	0.0	0	0	0	0	0
06/16/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/17/2020 00:00	0.0	0	0	0	0	0
06/17/2020 01:00	0.0	0	0	0	0	0
06/17/2020 02:00	0.0	0	0	0	0	0
06/17/2020 03:00	0.0	0	0	0	0	0
06/17/2020 04:00	0.0	0	0	0	0	0
06/17/2020 05:00	0.0	0	0	0	0	0
06/17/2020 06:00	0.0	0	0	0	0	0
06/17/2020 07:00	0.0	0	0	0	0	0
06/17/2020 08:00	0.0	0	0	0	0	0
06/17/2020 09:00	0.0	0	0	0	0	0
06/17/2020 10:00	0.0	0	0	0	0	0
06/17/2020 11:00	0.0	0	0	0	0	0
06/17/2020 12:00	7,168.5	1	0	0	0	0
06/17/2020 13:00	19,606.8	1	0	0	0	0
06/17/2020 14:00	21,335.3	1	0	0	0	0
06/17/2020 15:00	19,029.7	1	0	0	0	0
06/17/2020 16:00	0.0	0	0	0	0	1
06/17/2020 17:00	0.0	0	0	0	0	1
06/17/2020 18:00	0.0	0	0	0	0	1
06/17/2020 19:00	0.0	0	0	0	0	1
06/17/2020 20:00	0.0	0	0	0	0	1
06/17/2020 21:00	0.0	0	0	0	0	1
06/17/2020 22:00	0.0	0	0	0	0	1
06/17/2020 23:00	2,018.3	0	0	0	1	0
Average/Sum#:	69,158.6 #	4 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	21,335.3	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/18/2020 00:00	0.0	0	0	0	0	0
06/18/2020 01:00	0.0	0	0	0	0	0
06/18/2020 02:00	0.0	0	0	0	0	0
06/18/2020 03:00	0.0	0	0	0	0	0
06/18/2020 04:00	0.0	0	0	0	0	0
06/18/2020 05:00	0.0	0	0	0	0	0
06/18/2020 06:00	0.0	0	0	0	0	0
06/18/2020 07:00	0.0	0	0	0	0	0
06/18/2020 08:00	0.0	0	0	0	0	0
06/18/2020 09:00	0.0	0	0	0	0	0
06/18/2020 10:00	0.0	0	0	0	0	0
06/18/2020 11:00	8,917.5	0	1	0	0	0
06/18/2020 12:00	13,571.9	0	1	0	0	0
06/18/2020 13:00	0.0	0	0	0	0	1
06/18/2020 14:00	0.0	0	0	0	0	1
06/18/2020 15:00	0.0	0	0	0	0	1
06/18/2020 16:00	0.0	0	0	0	0	1
06/18/2020 17:00	0.0	0	0	0	0	1
06/18/2020 18:00	0.0	0	0	0	0	1
06/18/2020 19:00	0.0	0	0	0	0	1
06/18/2020 20:00	0.0	0	0	0	0	1
06/18/2020 21:00	0.0	0	0	0	0	1
06/18/2020 22:00	0.0	0	0	0	0	1
06/18/2020 23:00	2,016.9	0	0	0	1	0
Average/Sum#:	24,506.3 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	13,571.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/19/2020 00:00	0.0	0	0	0	0	0
06/19/2020 01:00	0.0	0	0	0	0	0
06/19/2020 02:00	0.0	0	0	0	0	0
06/19/2020 03:00	0.0	0	0	0	0	0
06/19/2020 04:00	0.0	0	0	0	0	0
06/19/2020 05:00	0.0	0	0	0	0	0
06/19/2020 06:00	0.0	0	0	0	0	0
06/19/2020 07:00	0.0	0	0	0	0	0
06/19/2020 08:00	0.0	0	0	0	0	0
06/19/2020 09:00	0.0	0	0	0	0	0
06/19/2020 10:00	0.0	0	0	0	0	0
06/19/2020 11:00	0.0	0	0	0	0	0
06/19/2020 12:00	0.0	0	0	0	0	0
06/19/2020 13:00	0.0	0	0	0	0	0
06/19/2020 14:00	0.0	0	0	0	0	0
06/19/2020 15:00	0.0	0	0	0	0	0
06/19/2020 16:00	0.0	0	0	0	0	0
06/19/2020 17:00	0.0	0	0	0	0	0
06/19/2020 18:00	0.0	0	0	0	0	0
06/19/2020 19:00	0.0	0	0	0	0	0
06/19/2020 20:00	0.0	0	0	0	0	0
06/19/2020 21:00	0.0	0	0	0	0	0
06/19/2020 22:00	0.0	0	0	0	0	0
06/19/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/20/2020 00:00	0.0	0	0	0	0	0
06/20/2020 01:00	0.0	0	0	0	0	0
06/20/2020 02:00	0.0	0	0	0	0	0
06/20/2020 03:00	0.0	0	0	0	0	0
06/20/2020 04:00	0.0	0	0	0	0	0
06/20/2020 05:00	0.0	0	0	0	0	0
06/20/2020 06:00	0.0	0	0	0	0	0
06/20/2020 07:00	0.0	0	0	0	0	0
06/20/2020 08:00	0.0	0	0	0	0	0
06/20/2020 09:00	0.0	0	0	0	0	0
06/20/2020 10:00	0.0	0	0	0	0	0
06/20/2020 11:00	0.0	0	0	0	0	0
06/20/2020 12:00	0.0	0	0	0	0	0
06/20/2020 13:00	0.0	0	0	0	0	0
06/20/2020 14:00	0.0	0	0	0	0	0
06/20/2020 15:00	0.0	0	0	0	0	0
06/20/2020 16:00	0.0	0	0	0	0	0
06/20/2020 17:00	0.0	0	0	0	0	0
06/20/2020 18:00	0.0	0	0	0	0	0
06/20/2020 19:00	0.0	0	0	0	0	0
06/20/2020 20:00	0.0	0	0	0	0	0
06/20/2020 21:00	0.0	0	0	0	0	0
06/20/2020 22:00	0.0	0	0	0	0	0
06/20/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/21/2020 00:00	0.0	0	0	0	0	0
06/21/2020 01:00	0.0	0	0	0	0	0
06/21/2020 02:00	0.0	0	0	0	0	0
06/21/2020 03:00	0.0	0	0	0	0	0
06/21/2020 04:00	0.0	0	0	0	0	0
06/21/2020 05:00	0.0	0	0	0	0	0
06/21/2020 06:00	0.0	0	0	0	0	0
06/21/2020 07:00	0.0	0	0	0	0	0
06/21/2020 08:00	0.0	0	0	0	0	0
06/21/2020 09:00	0.0	0	0	0	0	0
06/21/2020 10:00	0.0	0	0	0	0	0
06/21/2020 11:00	0.0	0	0	0	0	0
06/21/2020 12:00	0.0	0	0	0	0	0
06/21/2020 13:00	0.0	0	0	0	0	0
06/21/2020 14:00	0.0	0	0	0	0	0
06/21/2020 15:00	0.0	0	0	0	0	0
06/21/2020 16:00	0.0	0	0	0	0	0
06/21/2020 17:00	0.0	0	0	0	0	0
06/21/2020 18:00	0.0	0	0	0	0	0
06/21/2020 19:00	0.0	0	0	0	0	0
06/21/2020 20:00	0.0	0	0	0	0	0
06/21/2020 21:00	0.0	0	0	0	0	0
06/21/2020 22:00	0.0	0	0	0	0	0
06/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/22/2020 00:00	0.0	0	0	0	0	0
06/22/2020 01:00	0.0	0	0	0	0	0
06/22/2020 02:00	0.0	0	0	0	0	0
06/22/2020 03:00	0.0	0	0	0	0	0
06/22/2020 04:00	0.0	0	0	0	0	0
06/22/2020 05:00	0.0	0	0	0	0	0
06/22/2020 06:00	0.0	0	0	0	0	0
06/22/2020 07:00	0.0	0	0	0	0	0
06/22/2020 08:00	0.0	0	0	0	0	0
06/22/2020 09:00	11,801.3	1	0	0	0	0
06/22/2020 10:00	6,200.0	1	0	0	1	0
06/22/2020 11:00	20,030.2	1	0	0	0	0
06/22/2020 12:00	4,884.4	1	0	0	0	0
06/22/2020 13:00	0.0	0	0	0	0	1
06/22/2020 14:00	0.0	0	0	0	0	1
06/22/2020 15:00	0.0	0	0	0	0	1
06/22/2020 16:00	0.0	0	0	0	0	1
06/22/2020 17:00	0.0	0	0	0	0	1
06/22/2020 18:00	0.0	0	0	0	0	1
06/22/2020 19:00	0.0	0	0	0	0	1
06/22/2020 20:00	0.0	0	0	0	0	1
06/22/2020 21:00	0.0	0	0	0	0	1
06/22/2020 22:00	0.0	0	0	0	0	1
06/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	42,915.9 #	4 #	0 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	20,030.2	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/23/2020 00:00	2,323.2	0	0	0	1	0
06/23/2020 01:00	0.0	0	0	0	0	0
06/23/2020 02:00	0.0	0	0	0	0	0
06/23/2020 03:00	0.0	0	0	0	0	0
06/23/2020 04:00	0.0	0	0	0	0	0
06/23/2020 05:00	0.0	0	0	0	0	0
06/23/2020 06:00	0.0	0	0	0	0	0
06/23/2020 07:00	230.1	0	0	1	0	0
06/23/2020 08:00	6,653.4	0	0	1	0	0
06/23/2020 09:00	1,535.3	0	0	1	0	0
06/23/2020 10:00	0.0	0	0	0	0	1
06/23/2020 11:00	0.0	0	0	0	0	1
06/23/2020 12:00	0.0	0	0	0	0	1
06/23/2020 13:00	0.0	0	0	0	0	1
06/23/2020 14:00	0.0	0	0	0	0	1
06/23/2020 15:00	0.0	0	0	0	0	1
06/23/2020 16:00	0.0	0	0	0	0	1
06/23/2020 17:00	0.0	0	0	0	0	1
06/23/2020 18:00	0.0	0	0	0	0	1
06/23/2020 19:00	0.0	0	0	0	0	1
06/23/2020 20:00	0.0	0	0	0	0	1
06/23/2020 21:00	0.0	0	0	0	0	1
06/23/2020 22:00	0.0	0	0	0	0	1
06/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	10,742.0 #	0 #	0 #	3 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,653.4	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/24/2020 00:00	0.0	0	0	0	0	1
06/24/2020 01:00	0.0	0	0	0	0	1
06/24/2020 02:00	0.0	0	0	0	0	1
06/24/2020 03:00	0.0	0	0	0	0	1
06/24/2020 04:00	0.0	0	0	0	0	1
06/24/2020 05:00	0.0	0	0	0	0	1
06/24/2020 06:00	0.0	0	0	0	0	1
06/24/2020 07:00	0.0	0	0	0	0	1
06/24/2020 08:00	0.0	0	0	0	0	1
06/24/2020 09:00	0.0	0	0	0	0	1
06/24/2020 10:00	0.0	0	0	0	0	1
06/24/2020 11:00	0.0	0	0	0	0	1
06/24/2020 12:00	0.0	0	0	0	0	1
06/24/2020 13:00	0.0	0	0	0	0	1
06/24/2020 14:00	0.0	0	0	0	0	1
06/24/2020 15:00	0.0	0	0	0	0	1
06/24/2020 16:00	0.0	0	0	0	0	1
06/24/2020 17:00	0.0	0	0	0	0	1
06/24/2020 18:00	0.0	0	0	0	0	1
06/24/2020 19:00	0.0	0	0	0	0	1
06/24/2020 20:00	0.0	0	0	0	0	1
06/24/2020 21:00	0.0	0	0	0	0	1
06/24/2020 22:00	0.0	0	0	0	0	1
06/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/25/2020 00:00	76.9	0	0	0	1	0
06/25/2020 01:00	0.0	0	0	0	0	0
06/25/2020 02:00	0.0	0	0	0	0	0
06/25/2020 03:00	0.0	0	0	0	0	0
06/25/2020 04:00	0.0	0	0	0	0	0
06/25/2020 05:00	0.0	0	0	0	0	0
06/25/2020 06:00	0.0	0	0	0	0	0
06/25/2020 07:00	0.0	0	0	0	0	0
06/25/2020 08:00	0.0	0	0	0	0	0
06/25/2020 09:00	0.0	0	0	0	0	0
06/25/2020 10:00	0.0	0	0	0	0	0
06/25/2020 11:00	0.0	0	0	0	0	0
06/25/2020 12:00	630.8	0	1	0	0	0
06/25/2020 13:00	5,350.4	0	1	0	0	0
06/25/2020 14:00	0.0	0	0	0	0	1
06/25/2020 15:00	0.0	0	0	0	0	1
06/25/2020 16:00	0.0	0	0	0	0	1
06/25/2020 17:00	0.0	0	0	0	0	1
06/25/2020 18:00	0.0	0	0	0	0	1
06/25/2020 19:00	0.0	0	0	0	0	1
06/25/2020 20:00	0.0	0	0	0	0	1
06/25/2020 21:00	0.0	0	0	0	0	1
06/25/2020 22:00	123.6	0	0	0	1	0
06/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	6,181.7 #	0 #	2 #	0 #	2 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,350.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/26/2020 00:00	0.0	0	0	0	0	0
06/26/2020 01:00	0.0	0	0	0	0	0
06/26/2020 02:00	0.0	0	0	0	0	0
06/26/2020 03:00	0.0	0	0	0	0	0
06/26/2020 04:00	0.0	0	0	0	0	0
06/26/2020 05:00	0.0	0	0	0	0	0
06/26/2020 06:00	0.0	0	0	0	0	0
06/26/2020 07:00	0.0	0	0	0	0	0
06/26/2020 08:00	0.0	0	0	0	0	0
06/26/2020 09:00	0.0	0	0	0	0	0
06/26/2020 10:00	580.3	0	1	0	0	0
06/26/2020 11:00	6,067.9	0	1	0	0	0
06/26/2020 12:00	133.7	0	0	0	1	0
06/26/2020 13:00	0.0	0	0	0	0	0
06/26/2020 14:00	0.0	0	0	0	0	0
06/26/2020 15:00	0.0	0	0	0	0	0
06/26/2020 16:00	2,946.5	0	0	1	0	0
06/26/2020 17:00	2,806.4	0	0	1	0	0
06/26/2020 18:00	0.0	0	0	0	0	1
06/26/2020 19:00	0.0	0	0	0	0	1
06/26/2020 20:00	0.0	0	0	0	0	1
06/26/2020 21:00	0.0	0	0	0	0	1
06/26/2020 22:00	0.0	0	0	0	0	1
06/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	12,534.8 #	0 #	2 #	2 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,067.9	0	1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/27/2020 00:00	106.1	0	0	0	1	0
06/27/2020 01:00	0.0	0	0	0	0	0
06/27/2020 02:00	0.0	0	0	0	0	0
06/27/2020 03:00	0.0	0	0	0	0	0
06/27/2020 04:00	0.0	0	0	0	0	0
06/27/2020 05:00	0.0	0	0	0	0	0
06/27/2020 06:00	0.0	0	0	0	0	0
06/27/2020 07:00	0.0	0	0	0	0	0
06/27/2020 08:00	0.0	0	0	0	0	0
06/27/2020 09:00	0.0	0	0	0	0	0
06/27/2020 10:00	0.0	0	0	0	0	0
06/27/2020 11:00	0.0	0	0	0	0	0
06/27/2020 12:00	0.0	0	0	0	0	0
06/27/2020 13:00	0.0	0	0	0	0	0
06/27/2020 14:00	0.0	0	0	0	0	0
06/27/2020 15:00	0.0	0	0	0	0	0
06/27/2020 16:00	0.0	0	0	0	0	0
06/27/2020 17:00	0.0	0	0	0	0	0
06/27/2020 18:00	0.0	0	0	0	0	0
06/27/2020 19:00	0.0	0	0	0	0	0
06/27/2020 20:00	0.0	0	0	0	0	0
06/27/2020 21:00	0.0	0	0	0	0	0
06/27/2020 22:00	0.0	0	0	0	0	0
06/27/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	106.1 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	106.1	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/28/2020 00:00	0.0	0	0	0	0	0
06/28/2020 01:00	0.0	0	0	0	0	0
06/28/2020 02:00	0.0	0	0	0	0	0
06/28/2020 03:00	0.0	0	0	0	0	0
06/28/2020 04:00	0.0	0	0	0	0	0
06/28/2020 05:00	0.0	0	0	0	0	0
06/28/2020 06:00	0.0	0	0	0	0	0
06/28/2020 07:00	0.0	0	0	0	0	0
06/28/2020 08:00	0.0	0	0	0	0	0
06/28/2020 09:00	0.0	0	0	0	0	0
06/28/2020 10:00	0.0	0	0	0	0	0
06/28/2020 11:00	0.0	0	0	0	0	0
06/28/2020 12:00	0.0	0	0	0	0	0
06/28/2020 13:00	0.0	0	0	0	0	0
06/28/2020 14:00	0.0	0	0	0	0	0
06/28/2020 15:00	0.0	0	0	0	0	0
06/28/2020 16:00	0.0	0	0	0	0	0
06/28/2020 17:00	0.0	0	0	0	0	0
06/28/2020 18:00	0.0	0	0	0	0	0
06/28/2020 19:00	0.0	0	0	0	0	0
06/28/2020 20:00	0.0	0	0	0	0	0
06/28/2020 21:00	0.0	0	0	0	0	0
06/28/2020 22:00	0.0	0	0	0	0	0
06/28/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/29/2020 00:00	0.0	0	0	0	0	0
06/29/2020 01:00	0.0	0	0	0	0	0
06/29/2020 02:00	0.0	0	0	0	0	0
06/29/2020 03:00	0.0	0	0	0	0	0
06/29/2020 04:00	0.0	0	0	0	0	0
06/29/2020 05:00	0.0	0	0	0	0	0
06/29/2020 06:00	0.0	0	0	0	0	0
06/29/2020 07:00	0.0	0	0	0	0	0
06/29/2020 08:00	0.0	0	0	0	0	0
06/29/2020 09:00	0.0	0	0	0	0	0
06/29/2020 10:00	0.0	0	0	0	0	0
06/29/2020 11:00	0.0	0	0	0	0	0
06/29/2020 12:00	0.0	0	0	0	0	0
06/29/2020 13:00	0.0	0	0	0	0	0
06/29/2020 14:00	0.0	0	0	0	0	0
06/29/2020 15:00	0.0	0	0	0	0	0
06/29/2020 16:00	0.0	0	0	0	0	0
06/29/2020 17:00	0.0	0	0	0	0	0
06/29/2020 18:00	0.0	0	0	0	0	0
06/29/2020 19:00	0.0	0	0	0	0	0
06/29/2020 20:00	0.0	0	0	0	0	0
06/29/2020 21:00	0.0	0	0	0	0	0
06/29/2020 22:00	0.0	0	0	0	0	0
06/29/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:17 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/30/2020 00:00	0.0	0	0	0	0	0
06/30/2020 01:00	0.0	0	0	0	0	0
06/30/2020 02:00	0.0	0	0	0	0	0
06/30/2020 03:00	0.0	0	0	0	0	0
06/30/2020 04:00	0.0	0	0	0	0	0
06/30/2020 05:00	0.0	0	0	0	0	0
06/30/2020 06:00	0.0	0	0	0	0	0
06/30/2020 07:00	0.0	0	0	0	0	0
06/30/2020 08:00	0.0	0	0	0	0	0
06/30/2020 09:00	0.0	0	0	0	0	0
06/30/2020 10:00	0.0	0	0	0	0	0
06/30/2020 11:00	0.0	0	0	0	0	0
06/30/2020 12:00	0.0	0	0	0	0	0
06/30/2020 13:00	0.0	0	0	0	0	0
06/30/2020 14:00	2,206.9	1	0	0	0	0
06/30/2020 15:00	7,306.2	1	0	0	0	0
06/30/2020 16:00	0.0	0	0	0	0	1
06/30/2020 17:00	0.0	0	0	0	0	1
06/30/2020 18:00	0.0	0	0	0	0	1
06/30/2020 19:00	0.0	0	0	0	0	1
06/30/2020 20:00	0.0	0	0	0	0	1
06/30/2020 21:00	0.0	0	0	0	0	1
06/30/2020 22:00	127.0	0	0	0	1	0
06/30/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	9,640.1 #	2 #	0 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,306.2	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/01/2020 00:00	0.0	0	0	0	0	0
04/01/2020 01:00	0.0	0	0	0	0	0
04/01/2020 02:00	0.0	0	0	0	0	0
04/01/2020 03:00	16.8	0	1	0	0	0
04/01/2020 04:00	88.9	0	1	0	0	0
04/01/2020 05:00	0.0	0	0	0	0	1
04/01/2020 06:00	0.0	0	0	0	0	1
04/01/2020 07:00	0.0	0	0	0	0	1
04/01/2020 08:00	0.0	0	0	0	0	1
04/01/2020 09:00	0.0	0	0	0	0	1
04/01/2020 10:00	0.0	0	0	0	0	1
04/01/2020 11:00	0.0	0	0	0	0	1
04/01/2020 12:00	0.0	0	0	0	0	1
04/01/2020 13:00	0.0	0	0	0	0	1
04/01/2020 14:00	0.0	0	0	0	0	1
04/01/2020 15:00	0.0	0	0	0	0	1
04/01/2020 16:00	0.0	0	0	0	0	1
04/01/2020 17:00	0.0	0	0	0	0	1
04/01/2020 18:00	0.0	0	0	0	0	1
04/01/2020 19:00	0.0	0	0	0	0	1
04/01/2020 20:00	0.0	0	0	0	0	1
04/01/2020 21:00	0.0	0	0	0	0	1
04/01/2020 22:00	0.0	0	0	0	0	1
04/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	105.7 #	0 #	2 #	0 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	88.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/02/2020 00:00	0.0	0	0	0	0	1
04/02/2020 01:00	0.0	0	0	0	0	1
04/02/2020 02:00	0.0	0	0	0	0	1
04/02/2020 03:00	0.0	0	0	0	0	1
04/02/2020 04:00	0.0	0	0	0	0	1
04/02/2020 05:00	0.0	0	0	0	0	1
04/02/2020 06:00	0.0	0	0	0	0	1
04/02/2020 07:00	0.0	0	0	0	0	1
04/02/2020 08:00	0.0	0	0	0	0	1
04/02/2020 09:00	0.0	0	0	0	0	1
04/02/2020 10:00	0.0	0	0	0	0	1
04/02/2020 11:00	0.0	0	0	0	0	1
04/02/2020 12:00	0.0	0	0	0	0	1
04/02/2020 13:00	0.0	0	0	0	0	1
04/02/2020 14:00	0.0	0	0	0	0	1
04/02/2020 15:00	0.0	0	0	0	0	1
04/02/2020 16:00	0.0	0	0	0	0	1
04/02/2020 17:00	0.0	0	0	0	0	1
04/02/2020 18:00	0.0	0	0	0	0	1
04/02/2020 19:00	0.0	0	0	0	0	1
04/02/2020 20:00	0.0	0	0	0	0	1
04/02/2020 21:00	1.0	0	0	0	1	0
04/02/2020 22:00	0.0	0	0	0	0	0
04/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.0 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/03/2020 00:00	0.0	0	0	0	0	0
04/03/2020 01:00	0.0	0	0	0	0	0
04/03/2020 02:00	0.0	0	0	0	0	0
04/03/2020 03:00	0.0	0	0	0	0	0
04/03/2020 04:00	0.0	0	0	0	0	0
04/03/2020 05:00	0.0	0	0	0	0	0
04/03/2020 06:00	0.0	0	0	0	0	0
04/03/2020 07:00	0.0	0	0	0	0	0
04/03/2020 08:00	0.0	0	0	0	0	0
04/03/2020 09:00	0.0	0	0	0	0	0
04/03/2020 10:00	0.0	0	0	0	0	0
04/03/2020 11:00	0.0	0	0	0	0	0
04/03/2020 12:00	0.0	0	0	0	0	0
04/03/2020 13:00	0.0	0	0	0	0	0
04/03/2020 14:00	0.0	0	0	0	0	0
04/03/2020 15:00	0.0	0	0	0	0	0
04/03/2020 16:00	0.0	0	0	0	0	0
04/03/2020 17:00	0.0	0	0	0	0	0
04/03/2020 18:00	0.0	0	0	0	0	0
04/03/2020 19:00	0.0	0	0	0	0	0
04/03/2020 20:00	0.0	0	0	0	0	0
04/03/2020 21:00	0.0	0	0	0	0	0
04/03/2020 22:00	0.0	0	0	0	0	0
04/03/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/04/2020 00:00	0.0	0	0	0	0	0
04/04/2020 01:00	80.4	0	1	0	0	0
04/04/2020 02:00	27.6	0	1	0	0	0
04/04/2020 03:00	0.0	0	0	0	0	1
04/04/2020 04:00	0.0	0	0	0	0	1
04/04/2020 05:00	0.0	0	0	0	0	1
04/04/2020 06:00	0.0	0	0	0	0	1
04/04/2020 07:00	0.0	0	0	0	0	1
04/04/2020 08:00	0.0	0	0	0	0	1
04/04/2020 09:00	0.0	0	0	0	0	1
04/04/2020 10:00	0.0	0	0	0	0	1
04/04/2020 11:00	0.0	0	0	0	0	1
04/04/2020 12:00	0.0	0	0	0	0	1
04/04/2020 13:00	0.0	0	0	0	0	1
04/04/2020 14:00	0.0	0	0	0	0	1
04/04/2020 15:00	0.0	0	0	0	0	1
04/04/2020 16:00	0.0	0	0	0	0	1
04/04/2020 17:00	0.0	0	0	0	0	1
04/04/2020 18:00	0.0	0	0	0	0	1
04/04/2020 19:00	0.0	0	0	0	0	1
04/04/2020 20:00	0.0	0	0	0	0	1
04/04/2020 21:00	0.0	0	0	0	0	1
04/04/2020 22:00	0.0	0	0	0	0	1
04/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	108.0 #	0 #	2 #	0 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	80.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/05/2020 00:00	0.0	0	0	0	0	1
04/05/2020 01:00	0.0	0	0	0	0	1
04/05/2020 02:00	0.0	0	0	0	0	1
04/05/2020 03:00	0.0	0	0	0	0	1
04/05/2020 04:00	0.0	0	0	0	0	1
04/05/2020 05:00	0.0	0	0	0	0	1
04/05/2020 06:00	0.0	0	0	0	0	1
04/05/2020 07:00	0.0	0	0	0	0	1
04/05/2020 08:00	0.0	0	0	0	0	1
04/05/2020 09:00	0.0	0	0	0	0	1
04/05/2020 10:00	0.0	0	0	0	0	1
04/05/2020 11:00	0.0	0	0	0	0	1
04/05/2020 12:00	0.0	0	0	0	0	1
04/05/2020 13:00	0.0	0	0	0	0	1
04/05/2020 14:00	0.0	0	0	0	0	1
04/05/2020 15:00	0.0	0	0	0	0	1
04/05/2020 16:00	0.0	0	0	0	0	1
04/05/2020 17:00	0.0	0	0	0	0	1
04/05/2020 18:00	0.0	0	0	0	0	1
04/05/2020 19:00	0.0	0	0	0	0	1
04/05/2020 20:00	0.0	0	0	0	0	1
04/05/2020 21:00	0.0	0	0	0	0	1
04/05/2020 22:00	0.0	0	0	0	0	1
04/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/06/2020 00:00	0.0	0	0	0	0	1
04/06/2020 01:00	0.0	0	0	0	0	1
04/06/2020 02:00	0.0	0	0	0	0	1
04/06/2020 03:00	0.0	0	0	0	0	1
04/06/2020 04:00	0.0	0	0	0	0	1
04/06/2020 05:00	0.0	0	0	0	0	1
04/06/2020 06:00	0.0	0	0	0	0	1
04/06/2020 07:00	0.0	0	0	0	0	1
04/06/2020 08:00	0.0	0	0	0	0	1
04/06/2020 09:00	0.0	0	0	0	0	1
04/06/2020 10:00	0.0	0	0	0	0	1
04/06/2020 11:00	0.0	0	0	0	0	1
04/06/2020 12:00	0.0	0	0	0	0	1
04/06/2020 13:00	0.0	0	0	0	0	1
04/06/2020 14:00	0.0	0	0	0	0	1
04/06/2020 15:00	0.0	0	0	0	0	1
04/06/2020 16:00	0.0	0	0	0	0	1
04/06/2020 17:00	0.0	0	0	0	0	1
04/06/2020 18:00	0.0	0	0	0	0	1
04/06/2020 19:00	0.0	0	0	0	0	1
04/06/2020 20:00	0.0	0	0	0	0	1
04/06/2020 21:00	0.0	0	0	0	0	1
04/06/2020 22:00	0.0	0	0	0	0	1
04/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/07/2020 00:00	0.0	0	0	0	0	1
04/07/2020 01:00	0.0	0	0	0	0	1
04/07/2020 02:00	0.0	0	0	0	0	1
04/07/2020 03:00	0.0	0	0	0	0	1
04/07/2020 04:00	0.0	0	0	0	0	1
04/07/2020 05:00	0.0	0	0	0	0	1
04/07/2020 06:00	0.0	0	0	0	0	1
04/07/2020 07:00	0.0	0	0	0	0	1
04/07/2020 08:00	0.0	0	0	0	0	1
04/07/2020 09:00	0.0	0	0	0	0	1
04/07/2020 10:00	0.0	0	0	0	0	1
04/07/2020 11:00	0.0	0	0	0	0	1
04/07/2020 12:00	0.0	0	0	0	0	1
04/07/2020 13:00	0.0	0	0	0	0	1
04/07/2020 14:00	0.0	0	0	0	0	1
04/07/2020 15:00	0.0	0	0	0	0	1
04/07/2020 16:00	0.0	0	0	0	0	1
04/07/2020 17:00	0.0	0	0	0	0	1
04/07/2020 18:00	0.0	0	0	0	0	1
04/07/2020 19:00	0.0	0	0	0	0	1
04/07/2020 20:00	0.0	0	0	0	0	1
04/07/2020 21:00	0.0	0	0	0	0	1
04/07/2020 22:00	0.0	0	0	0	0	1
04/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/08/2020 00:00	0.0	0	0	0	0	1
04/08/2020 01:00	0.0	0	0	0	0	1
04/08/2020 02:00	0.0	0	0	0	0	1
04/08/2020 03:00	0.0	0	0	0	0	1
04/08/2020 04:00	0.0	0	0	0	0	1
04/08/2020 05:00	0.0	0	0	0	0	1
04/08/2020 06:00	0.0	0	0	0	0	1
04/08/2020 07:00	0.0	0	0	0	0	1
04/08/2020 08:00	0.0	0	0	0	0	1
04/08/2020 09:00	0.0	0	0	0	0	1
04/08/2020 10:00	0.0	0	0	0	0	1
04/08/2020 11:00	0.0	0	0	0	0	1
04/08/2020 12:00	0.0	0	0	0	0	1
04/08/2020 13:00	0.0	0	0	0	0	1
04/08/2020 14:00	0.0	0	0	0	0	1
04/08/2020 15:00	0.0	0	0	0	0	1
04/08/2020 16:00	0.0	0	0	0	0	1
04/08/2020 17:00	0.0	0	0	0	0	1
04/08/2020 18:00	0.0	0	0	0	0	1
04/08/2020 19:00	0.0	0	0	0	0	1
04/08/2020 20:00	0.0	0	0	0	0	1
04/08/2020 21:00	0.0	0	0	0	0	1
04/08/2020 22:00	0.0	0	0	0	0	1
04/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/09/2020 00:00	0.0	0	0	0	0	1
04/09/2020 01:00	0.0	0	0	0	0	1
04/09/2020 02:00	0.0	0	0	0	0	1
04/09/2020 03:00	0.0	0	0	0	0	1
04/09/2020 04:00	0.0	0	0	0	0	1
04/09/2020 05:00	0.0	0	0	0	0	1
04/09/2020 06:00	0.0	0	0	0	0	1
04/09/2020 07:00	0.0	0	0	0	0	1
04/09/2020 08:00	0.0	0	0	0	0	1
04/09/2020 09:00	0.0	0	0	0	0	1
04/09/2020 10:00	0.0	0	0	0	0	1
04/09/2020 11:00	0.0	0	0	0	0	1
04/09/2020 12:00	0.0	0	0	0	0	1
04/09/2020 13:00	0.0	0	0	0	0	1
04/09/2020 14:00	0.0	0	0	0	0	1
04/09/2020 15:00	0.0	0	0	0	0	1
04/09/2020 16:00	0.0	0	0	0	0	1
04/09/2020 17:00	0.0	0	0	0	0	1
04/09/2020 18:00	0.0	0	0	0	0	1
04/09/2020 19:00	0.0	0	0	0	0	1
04/09/2020 20:00	0.0	0	0	0	0	1
04/09/2020 21:00	0.0	0	0	0	0	1
04/09/2020 22:00	0.0	0	0	0	0	1
04/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/10/2020 00:00	0.0	0	0	0	0	1
04/10/2020 01:00	0.0	0	0	0	0	1
04/10/2020 02:00	0.0	0	0	0	0	1
04/10/2020 03:00	0.0	0	0	0	0	1
04/10/2020 04:00	0.0	0	0	0	0	1
04/10/2020 05:00	0.0	0	0	0	0	1
04/10/2020 06:00	0.0	0	0	0	0	1
04/10/2020 07:00	0.0	0	0	0	0	1
04/10/2020 08:00	0.0	0	0	0	0	1
04/10/2020 09:00	0.0	0	0	0	0	1
04/10/2020 10:00	0.0	0	0	0	0	1
04/10/2020 11:00	0.0	0	0	0	0	1
04/10/2020 12:00	0.0	0	0	0	0	1
04/10/2020 13:00	0.0	0	0	0	0	1
04/10/2020 14:00	0.0	0	0	0	0	1
04/10/2020 15:00	0.0	0	0	0	0	1
04/10/2020 16:00	0.0	0	0	0	0	1
04/10/2020 17:00	0.0	0	0	0	0	1
04/10/2020 18:00	0.0	0	0	0	0	1
04/10/2020 19:00	0.0	0	0	0	0	1
04/10/2020 20:00	0.0	0	0	0	0	1
04/10/2020 21:00	0.0	0	0	0	0	1
04/10/2020 22:00	0.0	0	0	0	0	1
04/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/11/2020 00:00	0.0	0	0	0	0	1
04/11/2020 01:00	0.0	0	0	0	0	1
04/11/2020 02:00	0.0	0	0	0	0	1
04/11/2020 03:00	0.0	0	0	0	0	1
04/11/2020 04:00	0.0	0	0	0	0	1
04/11/2020 05:00	0.0	0	0	0	0	1
04/11/2020 06:00	0.0	0	0	0	0	1
04/11/2020 07:00	0.0	0	0	0	0	1
04/11/2020 08:00	0.0	0	0	0	0	1
04/11/2020 09:00	0.0	0	0	0	0	1
04/11/2020 10:00	0.0	0	0	0	0	1
04/11/2020 11:00	0.0	0	0	0	0	1
04/11/2020 12:00	0.0	0	0	0	0	1
04/11/2020 13:00	0.0	0	0	0	0	1
04/11/2020 14:00	0.0	0	0	0	0	1
04/11/2020 15:00	0.0	0	0	0	0	1
04/11/2020 16:00	0.0	0	0	0	0	1
04/11/2020 17:00	0.0	0	0	0	0	1
04/11/2020 18:00	0.0	0	0	0	0	1
04/11/2020 19:00	0.0	0	0	0	0	1
04/11/2020 20:00	0.0	0	0	0	0	1
04/11/2020 21:00	0.0	0	0	0	0	1
04/11/2020 22:00	0.0	0	0	0	0	1
04/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/12/2020 00:00	0.0	0	0	0	0	1
04/12/2020 01:00	0.0	0	0	0	0	1
04/12/2020 02:00	0.0	0	0	0	0	1
04/12/2020 03:00	0.0	0	0	0	0	1
04/12/2020 04:00	0.0	0	0	0	0	1
04/12/2020 05:00	0.0	0	0	0	0	1
04/12/2020 06:00	0.0	0	0	0	0	1
04/12/2020 07:00	0.0	0	0	0	0	1
04/12/2020 08:00	0.0	0	0	0	0	1
04/12/2020 09:00	0.0	0	0	0	0	1
04/12/2020 10:00	0.0	0	0	0	0	1
04/12/2020 11:00	0.0	0	0	0	0	1
04/12/2020 12:00	0.0	0	0	0	0	1
04/12/2020 13:00	0.0	0	0	0	0	1
04/12/2020 14:00	0.0	0	0	0	0	1
04/12/2020 15:00	0.0	0	0	0	0	1
04/12/2020 16:00	0.0	0	0	0	0	1
04/12/2020 17:00	0.0	0	0	0	0	1
04/12/2020 18:00	0.0	0	0	0	0	1
04/12/2020 19:00	0.0	0	0	0	0	1
04/12/2020 20:00	0.0	0	0	0	0	1
04/12/2020 21:00	0.0	0	0	0	0	1
04/12/2020 22:00	0.0	0	0	0	0	1
04/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/13/2020 00:00	0.0	0	0	0	0	1
04/13/2020 01:00	0.0	0	0	0	0	1
04/13/2020 02:00	0.0	0	0	0	0	1
04/13/2020 03:00	0.0	0	0	0	0	1
04/13/2020 04:00	0.0	0	0	0	0	1
04/13/2020 05:00	0.0	0	0	0	0	1
04/13/2020 06:00	0.0	0	0	0	0	1
04/13/2020 07:00	0.0	0	0	0	0	1
04/13/2020 08:00	0.0	0	0	0	0	1
04/13/2020 09:00	0.0	0	0	0	0	1
04/13/2020 10:00	0.0	0	0	0	0	1
04/13/2020 11:00	0.0	0	0	0	0	1
04/13/2020 12:00	0.0	0	0	0	0	1
04/13/2020 13:00	0.0	0	0	0	0	1
04/13/2020 14:00	0.0	0	0	0	0	1
04/13/2020 15:00	0.0	0	0	0	0	1
04/13/2020 16:00	0.0	0	0	0	0	1
04/13/2020 17:00	0.0	0	0	0	0	1
04/13/2020 18:00	0.0	0	0	0	0	1
04/13/2020 19:00	0.0	0	0	0	0	1
04/13/2020 20:00	0.0	0	0	0	0	1
04/13/2020 21:00	0.0	0	0	0	0	1
04/13/2020 22:00	0.0	0	0	0	0	1
04/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/14/2020 00:00	0.0	0	0	0	0	1
04/14/2020 01:00	0.0	0	0	0	0	1
04/14/2020 02:00	0.0	0	0	0	0	1
04/14/2020 03:00	0.0	0	0	0	0	1
04/14/2020 04:00	0.0	0	0	0	0	1
04/14/2020 05:00	0.0	0	0	0	0	1
04/14/2020 06:00	0.0	0	0	0	0	1
04/14/2020 07:00	0.0	0	0	0	0	1
04/14/2020 08:00	0.0	0	0	0	0	1
04/14/2020 09:00	0.0	0	0	0	0	1
04/14/2020 10:00	0.0	0	0	0	0	1
04/14/2020 11:00	0.0	0	0	0	0	1
04/14/2020 12:00	0.0	0	0	0	0	1
04/14/2020 13:00	0.0	0	0	0	0	1
04/14/2020 14:00	0.0	0	0	0	0	1
04/14/2020 15:00	0.0	0	0	0	0	1
04/14/2020 16:00	0.0	0	0	0	0	1
04/14/2020 17:00	0.0	0	0	0	0	1
04/14/2020 18:00	0.0	0	0	0	0	1
04/14/2020 19:00	0.0	0	0	0	0	1
04/14/2020 20:00	0.0	0	0	0	0	1
04/14/2020 21:00	0.0	0	0	0	0	1
04/14/2020 22:00	0.0	0	0	0	0	1
04/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/15/2020 00:00	0.0	0	0	0	0	1
04/15/2020 01:00	0.0	0	0	0	0	1
04/15/2020 02:00	0.0	0	0	0	0	1
04/15/2020 03:00	0.0	0	0	0	0	1
04/15/2020 04:00	0.0	0	0	0	0	1
04/15/2020 05:00	0.0	0	0	0	0	1
04/15/2020 06:00	0.0	0	0	0	0	1
04/15/2020 07:00	0.0	0	0	0	0	1
04/15/2020 08:00	0.0	0	0	0	0	1
04/15/2020 09:00	0.0	0	0	0	0	1
04/15/2020 10:00	0.0	0	0	0	0	1
04/15/2020 11:00	0.0	0	0	0	0	1
04/15/2020 12:00	0.0	0	0	0	0	1
04/15/2020 13:00	0.0	0	0	0	0	1
04/15/2020 14:00	0.0	0	0	0	0	1
04/15/2020 15:00	0.0	0	0	0	0	1
04/15/2020 16:00	0.0	0	0	0	0	1
04/15/2020 17:00	0.0	0	0	0	0	1
04/15/2020 18:00	0.0	0	0	0	0	1
04/15/2020 19:00	0.0	0	0	0	0	1
04/15/2020 20:00	0.0	0	0	0	0	1
04/15/2020 21:00	0.0	0	0	0	0	1
04/15/2020 22:00	0.0	0	0	0	0	1
04/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/16/2020 00:00	0.0	0	0	0	0	1
04/16/2020 01:00	0.0	0	0	0	0	1
04/16/2020 02:00	0.0	0	0	0	0	1
04/16/2020 03:00	0.0	0	0	0	0	1
04/16/2020 04:00	0.0	0	0	0	0	1
04/16/2020 05:00	0.0	0	0	0	0	1
04/16/2020 06:00	0.0	0	0	0	0	1
04/16/2020 07:00	0.0	0	0	0	0	1
04/16/2020 08:00	0.0	0	0	0	0	1
04/16/2020 09:00	0.0	0	0	0	0	1
04/16/2020 10:00	0.0	0	0	0	0	1
04/16/2020 11:00	0.0	0	0	0	0	1
04/16/2020 12:00	0.0	0	0	0	0	1
04/16/2020 13:00	0.0	0	0	0	0	1
04/16/2020 14:00	0.0	0	0	0	0	1
04/16/2020 15:00	0.0	0	0	0	0	1
04/16/2020 16:00	0.0	0	0	0	0	1
04/16/2020 17:00	0.0	0	0	0	0	1
04/16/2020 18:00	0.0	0	0	0	0	1
04/16/2020 19:00	0.0	0	0	0	0	1
04/16/2020 20:00	0.0	0	0	0	0	1
04/16/2020 21:00	0.0	0	0	0	0	1
04/16/2020 22:00	0.0	0	0	0	0	1
04/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/17/2020 00:00	0.0	0	0	0	0	1
04/17/2020 01:00	0.0	0	0	0	0	1
04/17/2020 02:00	0.0	0	0	0	0	1
04/17/2020 03:00	0.0	0	0	0	0	1
04/17/2020 04:00	0.0	0	0	0	0	1
04/17/2020 05:00	0.0	0	0	0	0	1
04/17/2020 06:00	0.0	0	0	0	0	1
04/17/2020 07:00	0.0	0	0	0	0	1
04/17/2020 08:00	0.0	0	0	0	0	1
04/17/2020 09:00	0.0	0	0	0	0	1
04/17/2020 10:00	0.0	0	0	0	0	1
04/17/2020 11:00	0.0	0	0	0	0	1
04/17/2020 12:00	0.0	0	0	0	0	1
04/17/2020 13:00	0.0	0	0	0	0	1
04/17/2020 14:00	0.0	0	0	0	0	1
04/17/2020 15:00	0.0	0	0	0	0	1
04/17/2020 16:00	0.0	0	0	0	0	1
04/17/2020 17:00	0.0	0	0	0	0	1
04/17/2020 18:00	0.0	0	0	0	0	1
04/17/2020 19:00	0.0	0	0	0	0	1
04/17/2020 20:00	0.0	0	0	0	0	1
04/17/2020 21:00	0.0	0	0	0	0	1
04/17/2020 22:00	0.0	0	0	0	0	1
04/17/2020 23:00	1.0	0	0	0	1	0
Average/Sum#:	1.0 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/18/2020 00:00	0.0	0	0	0	0	0
04/18/2020 01:00	0.0	0	0	0	0	0
04/18/2020 02:00	0.0	0	0	0	0	0
04/18/2020 03:00	0.0	0	0	0	0	0
04/18/2020 04:00	0.0	0	0	0	0	0
04/18/2020 05:00	0.0	0	0	0	0	0
04/18/2020 06:00	0.0	0	0	0	0	0
04/18/2020 07:00	0.0	0	0	0	0	0
04/18/2020 08:00	0.0	0	0	0	0	0
04/18/2020 09:00	0.0	0	0	0	0	0
04/18/2020 10:00	0.0	0	0	0	0	0
04/18/2020 11:00	0.0	0	0	0	0	0
04/18/2020 12:00	0.0	0	0	0	0	0
04/18/2020 13:00	0.0	0	0	0	0	0
04/18/2020 14:00	0.0	0	0	0	0	0
04/18/2020 15:00	0.0	0	0	0	0	0
04/18/2020 16:00	0.0	0	0	0	0	0
04/18/2020 17:00	0.0	0	0	0	0	0
04/18/2020 18:00	0.0	0	0	0	0	0
04/18/2020 19:00	0.0	0	0	0	0	0
04/18/2020 20:00	0.0	0	0	0	0	0
04/18/2020 21:00	0.0	0	0	0	0	0
04/18/2020 22:00	0.0	0	0	0	0	0
04/18/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/19/2020 00:00	0.0	0	0	0	0	0
04/19/2020 01:00	0.0	0	0	0	0	0
04/19/2020 02:00	0.0	0	0	0	0	0
04/19/2020 03:00	0.0	0	0	0	0	0
04/19/2020 04:00	0.0	0	0	0	0	0
04/19/2020 05:00	0.0	0	0	0	0	0
04/19/2020 06:00	0.0	0	0	0	0	0
04/19/2020 07:00	0.0	0	0	0	0	0
04/19/2020 08:00	0.0	0	0	0	0	0
04/19/2020 09:00	0.0	0	0	0	0	0
04/19/2020 10:00	0.0	0	0	0	0	0
04/19/2020 11:00	0.0	0	0	0	0	0
04/19/2020 12:00	0.0	0	0	0	0	0
04/19/2020 13:00	0.0	0	0	0	0	0
04/19/2020 14:00	0.0	0	0	0	0	0
04/19/2020 15:00	0.0	0	0	0	0	0
04/19/2020 16:00	0.0	0	0	0	0	0
04/19/2020 17:00	0.0	0	0	0	0	0
04/19/2020 18:00	0.0	0	0	0	0	0
04/19/2020 19:00	0.0	0	0	0	0	0
04/19/2020 20:00	0.0	0	0	0	0	0
04/19/2020 21:00	0.0	0	0	0	0	0
04/19/2020 22:00	0.0	0	0	0	0	0
04/19/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/20/2020 00:00	0.0	0	0	0	0	0
04/20/2020 01:00	0.0	0	0	0	0	0
04/20/2020 02:00	93.8	0	1	0	0	0
04/20/2020 03:00	39.1	0	1	0	0	0
04/20/2020 04:00	0.0	0	0	0	0	1
04/20/2020 05:00	0.0	0	0	0	0	1
04/20/2020 06:00	0.0	0	0	0	0	1
04/20/2020 07:00	0.0	0	0	0	0	1
04/20/2020 08:00	0.0	0	0	0	0	1
04/20/2020 09:00	0.0	0	0	0	0	1
04/20/2020 10:00	0.0	0	0	0	0	1
04/20/2020 11:00	0.0	0	0	0	0	1
04/20/2020 12:00	0.0	0	0	0	0	1
04/20/2020 13:00	0.0	0	0	0	0	1
04/20/2020 14:00	0.0	0	0	0	0	1
04/20/2020 15:00	0.0	0	0	0	0	1
04/20/2020 16:00	0.0	0	0	0	0	1
04/20/2020 17:00	0.0	0	0	0	0	1
04/20/2020 18:00	0.0	0	0	0	0	1
04/20/2020 19:00	0.0	0	0	0	0	1
04/20/2020 20:00	0.0	0	0	0	0	1
04/20/2020 21:00	0.0	0	0	0	0	1
04/20/2020 22:00	0.0	0	0	0	0	1
04/20/2020 23:00	1.0	0	0	0	1	0
Average/Sum#:	133.9 #	0 #	2 #	0 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	93.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/21/2020 00:00	0.0	0	0	0	0	0
04/21/2020 01:00	0.0	0	0	0	0	0
04/21/2020 02:00	0.0	0	0	0	0	0
04/21/2020 03:00	0.0	0	0	0	0	0
04/21/2020 04:00	0.0	0	0	0	0	0
04/21/2020 05:00	0.0	0	0	0	0	0
04/21/2020 06:00	0.0	0	0	0	0	0
04/21/2020 07:00	0.0	0	0	0	0	0
04/21/2020 08:00	0.0	0	0	0	0	0
04/21/2020 09:00	0.0	0	0	0	0	0
04/21/2020 10:00	0.0	0	0	0	0	0
04/21/2020 11:00	0.0	0	0	0	0	0
04/21/2020 12:00	0.0	0	0	0	0	0
04/21/2020 13:00	0.0	0	0	0	0	0
04/21/2020 14:00	0.0	0	0	0	0	0
04/21/2020 15:00	0.0	0	0	0	0	0
04/21/2020 16:00	0.0	0	0	0	0	0
04/21/2020 17:00	0.0	0	0	0	0	0
04/21/2020 18:00	0.0	0	0	0	0	0
04/21/2020 19:00	0.0	0	0	0	0	0
04/21/2020 20:00	0.0	0	0	0	0	0
04/21/2020 21:00	0.0	0	0	0	0	0
04/21/2020 22:00	0.0	0	0	0	0	0
04/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/22/2020 00:00	0.0	0	0	0	0	0
04/22/2020 01:00	0.0	0	0	0	0	0
04/22/2020 02:00	0.0	0	0	0	0	0
04/22/2020 03:00	0.0	0	0	0	0	0
04/22/2020 04:00	0.0	0	0	0	0	0
04/22/2020 05:00	0.0	0	0	0	0	0
04/22/2020 06:00	0.0	0	0	0	0	0
04/22/2020 07:00	27.5	0	1	0	0	0
04/22/2020 08:00	70.0	0	1	0	0	0
04/22/2020 09:00	6.0	0	1	0	0	0
04/22/2020 10:00	0.0	0	0	0	0	1
04/22/2020 11:00	0.7	0	0	0	1	0
04/22/2020 12:00	0.0	0	0	0	0	0
04/22/2020 13:00	0.0	0	0	0	0	0
04/22/2020 14:00	0.0	0	0	0	0	0
04/22/2020 15:00	0.0	0	0	0	0	0
04/22/2020 16:00	0.0	0	0	0	0	0
04/22/2020 17:00	0.0	0	0	0	0	0
04/22/2020 18:00	0.0	0	0	0	0	0
04/22/2020 19:00	0.0	0	0	0	0	0
04/22/2020 20:00	0.0	0	0	0	0	0
04/22/2020 21:00	0.0	0	0	0	0	0
04/22/2020 22:00	0.0	0	0	0	0	0
04/22/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	104.2 #	0 #	3 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	70.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/23/2020 00:00	0.0	0	0	0	0	0
04/23/2020 01:00	0.0	0	0	0	0	0
04/23/2020 02:00	0.0	0	0	0	0	0
04/23/2020 03:00	0.0	0	0	0	0	0
04/23/2020 04:00	0.0	0	0	0	0	0
04/23/2020 05:00	0.0	0	0	0	0	0
04/23/2020 06:00	0.0	0	0	0	0	0
04/23/2020 07:00	0.0	0	0	0	0	0
04/23/2020 08:00	0.0	0	0	0	0	0
04/23/2020 09:00	0.0	0	0	0	0	0
04/23/2020 10:00	0.0	0	0	0	0	0
04/23/2020 11:00	0.0	0	0	0	0	0
04/23/2020 12:00	0.0	0	0	0	0	0
04/23/2020 13:00	0.0	0	0	0	0	0
04/23/2020 14:00	0.0	0	0	0	0	0
04/23/2020 15:00	0.0	0	0	0	0	0
04/23/2020 16:00	0.0	0	0	0	0	0
04/23/2020 17:00	0.0	0	0	0	0	0
04/23/2020 18:00	0.0	0	0	0	0	0
04/23/2020 19:00	0.0	0	0	0	0	0
04/23/2020 20:00	0.0	0	0	0	0	0
04/23/2020 21:00	0.0	0	0	0	0	0
04/23/2020 22:00	0.0	0	0	0	0	0
04/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/24/2020 00:00	0.0	0	0	0	0	0
04/24/2020 01:00	0.0	0	0	0	0	0
04/24/2020 02:00	0.0	0	0	0	0	0
04/24/2020 03:00	0.0	0	0	0	0	0
04/24/2020 04:00	0.0	0	0	0	0	0
04/24/2020 05:00	0.0	0	0	0	0	0
04/24/2020 06:00	0.0	0	0	0	0	0
04/24/2020 07:00	0.0	0	0	0	0	0
04/24/2020 08:00	0.0	0	0	0	0	0
04/24/2020 09:00	0.0	0	0	0	0	0
04/24/2020 10:00	0.0	0	0	0	0	0
04/24/2020 11:00	0.0	0	0	0	0	0
04/24/2020 12:00	0.0	0	0	0	0	0
04/24/2020 13:00	0.0	0	0	0	0	0
04/24/2020 14:00	0.0	0	1	0	0	0
04/24/2020 15:00	0.0	0	1	0	0	0
04/24/2020 16:00	0.0	0	1	0	0	0
04/24/2020 17:00	0.0	0	0	0	0	1
04/24/2020 18:00	0.0	0	0	0	0	1
04/24/2020 19:00	0.0	0	0	0	0	1
04/24/2020 20:00	0.0	0	0	0	0	1
04/24/2020 21:00	0.0	0	0	0	0	1
04/24/2020 22:00	1.2	0	0	0	1	0
04/24/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.2 #	0 #	3 #	0 #	1 #	5 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/25/2020 00:00	0.0	0	0	0	0	0
04/25/2020 01:00	0.0	0	0	0	0	0
04/25/2020 02:00	0.0	0	0	0	0	0
04/25/2020 03:00	0.0	0	0	0	0	0
04/25/2020 04:00	0.0	0	0	0	0	0
04/25/2020 05:00	0.0	0	0	0	0	0
04/25/2020 06:00	0.0	0	0	0	0	0
04/25/2020 07:00	0.0	0	0	0	0	0
04/25/2020 08:00	0.0	0	0	0	0	0
04/25/2020 09:00	0.0	0	0	0	0	0
04/25/2020 10:00	0.0	0	0	0	0	0
04/25/2020 11:00	0.0	0	0	0	0	0
04/25/2020 12:00	0.0	0	0	0	0	0
04/25/2020 13:00	0.0	0	0	0	0	0
04/25/2020 14:00	0.0	0	0	0	0	0
04/25/2020 15:00	0.0	0	0	0	0	0
04/25/2020 16:00	0.0	0	0	0	0	0
04/25/2020 17:00	0.0	0	0	0	0	0
04/25/2020 18:00	0.0	0	0	0	0	0
04/25/2020 19:00	0.0	0	0	0	0	0
04/25/2020 20:00	0.0	0	0	0	0	0
04/25/2020 21:00	0.0	0	0	0	0	0
04/25/2020 22:00	0.0	0	0	0	0	0
04/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/26/2020 00:00	0.0	0	0	0	0	0
04/26/2020 01:00	0.0	0	0	0	0	0
04/26/2020 02:00	0.0	0	0	0	0	0
04/26/2020 03:00	0.0	0	0	0	0	0
04/26/2020 04:00	0.0	0	0	0	0	0
04/26/2020 05:00	0.0	0	0	0	0	0
04/26/2020 06:00	0.0	0	0	0	0	0
04/26/2020 07:00	0.0	0	0	0	0	0
04/26/2020 08:00	0.0	0	0	0	0	0
04/26/2020 09:00	0.0	0	0	0	0	0
04/26/2020 10:00	0.0	0	0	0	0	0
04/26/2020 11:00	0.0	0	0	0	0	0
04/26/2020 12:00	0.0	0	0	0	0	0
04/26/2020 13:00	0.0	0	0	0	0	0
04/26/2020 14:00	0.0	0	0	0	0	0
04/26/2020 15:00	0.0	0	0	0	0	0
04/26/2020 16:00	0.0	0	0	0	0	0
04/26/2020 17:00	0.0	0	0	0	0	0
04/26/2020 18:00	0.0	0	0	0	0	0
04/26/2020 19:00	0.0	0	0	0	0	0
04/26/2020 20:00	0.0	0	0	0	0	0
04/26/2020 21:00	0.0	0	0	0	0	0
04/26/2020 22:00	0.0	0	0	0	0	0
04/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/27/2020 00:00	0.0	0	0	0	0	0
04/27/2020 01:00	0.0	0	0	0	0	0
04/27/2020 02:00	0.0	0	0	0	0	0
04/27/2020 03:00	0.0	0	0	0	0	0
04/27/2020 04:00	0.0	0	0	0	0	0
04/27/2020 05:00	0.0	0	0	0	0	0
04/27/2020 06:00	0.0	0	0	0	0	0
04/27/2020 07:00	0.0	0	0	0	0	0
04/27/2020 08:00	0.0	0	0	0	0	0
04/27/2020 09:00	0.0	0	0	0	0	0
04/27/2020 10:00	0.0	0	0	0	0	0
04/27/2020 11:00	0.0	0	0	0	0	0
04/27/2020 12:00	0.0	0	0	0	0	0
04/27/2020 13:00	0.0	0	0	0	0	0
04/27/2020 14:00	0.0	0	0	0	0	0
04/27/2020 15:00	0.0	0	0	0	0	0
04/27/2020 16:00	0.0	0	0	0	0	0
04/27/2020 17:00	0.0	0	0	0	0	0
04/27/2020 18:00	0.0	0	0	0	0	0
04/27/2020 19:00	0.0	0	0	0	0	0
04/27/2020 20:00	0.0	0	0	0	0	0
04/27/2020 21:00	0.0	0	0	0	0	0
04/27/2020 22:00	0.0	0	0	0	0	0
04/27/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/28/2020 00:00	0.0	0	0	0	0	0
04/28/2020 01:00	0.0	0	0	0	0	0
04/28/2020 02:00	0.0	0	0	0	0	0
04/28/2020 03:00	0.0	0	0	0	0	0
04/28/2020 04:00	0.0	0	0	0	0	0
04/28/2020 05:00	0.0	0	0	0	0	0
04/28/2020 06:00	0.0	0	0	0	0	0
04/28/2020 07:00	0.0	0	0	0	0	0
04/28/2020 08:00	0.0	0	0	0	0	0
04/28/2020 09:00	0.0	0	0	0	0	0
04/28/2020 10:00	0.0	0	0	0	0	0
04/28/2020 11:00	0.0	0	0	0	0	0
04/28/2020 12:00	0.0	0	0	0	0	0
04/28/2020 13:00	65.8	1	0	0	0	0
04/28/2020 14:00	81.9	1	0	0	0	0
04/28/2020 15:00	0.1	1	0	0	0	0
04/28/2020 16:00	0.0	0	0	0	0	1
04/28/2020 17:00	0.0	0	0	0	0	1
04/28/2020 18:00	0.0	0	0	0	0	1
04/28/2020 19:00	0.0	0	0	0	0	1
04/28/2020 20:00	0.0	0	0	0	0	1
04/28/2020 21:00	0.8	0	0	0	1	0
04/28/2020 22:00	0.0	0	0	0	0	0
04/28/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	148.6 #	3 #	0 #	0 #	1 #	5 #
Minimum:	0.0	0	0	0	0	0
Maximum:	81.9	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/29/2020 00:00	0.0	0	0	0	0	0
04/29/2020 01:00	0.0	0	0	0	0	0
04/29/2020 02:00	0.0	0	0	0	0	0
04/29/2020 03:00	0.0	0	0	0	0	0
04/29/2020 04:00	0.0	0	0	0	0	0
04/29/2020 05:00	0.0	0	0	0	0	0
04/29/2020 06:00	0.0	0	0	0	0	0
04/29/2020 07:00	0.0	0	0	0	0	0
04/29/2020 08:00	0.0	0	0	0	0	0
04/29/2020 09:00	0.0	0	0	0	0	0
04/29/2020 10:00	0.0	0	0	0	0	0
04/29/2020 11:00	0.0	0	0	0	0	0
04/29/2020 12:00	0.0	0	0	0	0	0
04/29/2020 13:00	0.0	0	0	0	0	0
04/29/2020 14:00	0.0	0	0	0	0	0
04/29/2020 15:00	0.0	0	0	0	0	0
04/29/2020 16:00	0.0	0	0	0	0	0
04/29/2020 17:00	0.0	0	0	0	0	0
04/29/2020 18:00	0.0	0	0	0	0	0
04/29/2020 19:00	0.0	0	0	0	0	0
04/29/2020 20:00	0.0	0	0	0	0	0
04/29/2020 21:00	0.0	0	0	0	0	0
04/29/2020 22:00	0.0	0	0	0	0	0
04/29/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
04/30/2020 00:00	0.0	0	0	0	0	0
04/30/2020 01:00	0.0	0	0	0	0	0
04/30/2020 02:00	0.0	0	0	0	0	0
04/30/2020 03:00	0.0	0	0	0	0	0
04/30/2020 04:00	0.0	0	0	0	0	0
04/30/2020 05:00	0.0	0	0	0	0	0
04/30/2020 06:00	0.0	0	0	0	0	0
04/30/2020 07:00	0.0	0	0	0	0	0
04/30/2020 08:00	0.0	0	0	0	0	0
04/30/2020 09:00	0.0	0	0	0	0	0
04/30/2020 10:00	0.0	0	0	0	0	0
04/30/2020 11:00	0.0	0	0	0	0	0
04/30/2020 12:00	0.0	0	0	0	0	0
04/30/2020 13:00	0.0	0	0	0	0	0
04/30/2020 14:00	0.0	0	0	0	0	0
04/30/2020 15:00	0.0	0	0	0	0	0
04/30/2020 16:00	0.0	0	0	0	0	0
04/30/2020 17:00	0.0	0	0	0	0	0
04/30/2020 18:00	0.0	0	0	0	0	0
04/30/2020 19:00	0.0	0	0	0	0	0
04/30/2020 20:00	0.0	0	0	0	0	0
04/30/2020 21:00	0.0	0	0	0	0	0
04/30/2020 22:00	0.0	0	0	0	0	0
04/30/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/01/2020 00:00	0.0	0	0	0	0	0
05/01/2020 01:00	0.0	0	0	0	0	0
05/01/2020 02:00	0.0	0	0	0	0	0
05/01/2020 03:00	0.0	0	0	0	0	0
05/01/2020 04:00	0.0	0	0	0	0	0
05/01/2020 05:00	0.0	0	0	0	0	0
05/01/2020 06:00	0.0	0	0	0	0	0
05/01/2020 07:00	0.0	0	0	0	0	0
05/01/2020 08:00	0.0	0	0	0	0	0
05/01/2020 09:00	0.0	0	0	0	0	0
05/01/2020 10:00	0.0	0	0	0	0	0
05/01/2020 11:00	0.0	0	0	0	0	0
05/01/2020 12:00	0.0	0	0	0	0	0
05/01/2020 13:00	0.0	0	0	0	0	0
05/01/2020 14:00	0.0	0	0	0	0	0
05/01/2020 15:00	0.0	0	0	0	0	0
05/01/2020 16:00	0.0	0	0	0	0	0
05/01/2020 17:00	0.0	0	0	0	0	0
05/01/2020 18:00	0.0	0	0	0	0	0
05/01/2020 19:00	0.0	0	0	0	0	0
05/01/2020 20:00	0.0	0	0	0	0	0
05/01/2020 21:00	0.0	0	0	0	0	0
05/01/2020 22:00	0.0	0	0	0	0	0
05/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/02/2020 00:00	0.0	0	0	0	0	0
05/02/2020 01:00	0.0	0	0	0	0	0
05/02/2020 02:00	0.0	0	0	0	0	0
05/02/2020 03:00	0.0	0	0	0	0	0
05/02/2020 04:00	0.0	0	0	0	0	0
05/02/2020 05:00	0.0	0	0	0	0	0
05/02/2020 06:00	0.0	0	0	0	0	0
05/02/2020 07:00	0.0	0	0	0	0	0
05/02/2020 08:00	0.0	0	0	0	0	0
05/02/2020 09:00	0.0	0	0	0	0	0
05/02/2020 10:00	0.0	0	0	0	0	0
05/02/2020 11:00	0.0	0	0	0	0	0
05/02/2020 12:00	0.0	0	0	0	0	0
05/02/2020 13:00	0.0	0	0	0	0	0
05/02/2020 14:00	0.0	0	0	0	0	0
05/02/2020 15:00	0.0	0	0	0	0	0
05/02/2020 16:00	0.0	0	0	0	0	0
05/02/2020 17:00	0.0	0	0	0	0	0
05/02/2020 18:00	0.0	0	0	0	0	0
05/02/2020 19:00	0.0	0	0	0	0	0
05/02/2020 20:00	0.0	0	0	0	0	0
05/02/2020 21:00	0.0	0	0	0	0	0
05/02/2020 22:00	0.0	0	0	0	0	0
05/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/03/2020 00:00	0.0	0	0	0	0	0
05/03/2020 01:00	0.0	0	0	0	0	0
05/03/2020 02:00	0.0	0	0	0	0	0
05/03/2020 03:00	0.0	0	0	0	0	0
05/03/2020 04:00	0.0	0	0	0	0	0
05/03/2020 05:00	0.0	0	0	0	0	0
05/03/2020 06:00	0.0	0	0	0	0	0
05/03/2020 07:00	0.0	0	0	0	0	0
05/03/2020 08:00	0.0	0	0	0	0	0
05/03/2020 09:00	0.0	0	0	0	0	0
05/03/2020 10:00	0.0	0	0	0	0	0
05/03/2020 11:00	0.0	0	0	0	0	0
05/03/2020 12:00	0.0	0	0	0	0	0
05/03/2020 13:00	0.0	0	0	0	0	0
05/03/2020 14:00	0.0	0	0	0	0	0
05/03/2020 15:00	0.0	0	0	0	0	0
05/03/2020 16:00	0.0	0	0	0	0	0
05/03/2020 17:00	0.0	0	0	0	0	0
05/03/2020 18:00	0.0	0	0	0	0	0
05/03/2020 19:00	0.0	0	0	0	0	0
05/03/2020 20:00	0.0	0	0	0	0	0
05/03/2020 21:00	0.0	0	0	0	0	0
05/03/2020 22:00	0.0	0	0	0	0	0
05/03/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/04/2020 00:00	0.0	0	0	0	0	0
05/04/2020 01:00	0.0	0	0	0	0	0
05/04/2020 02:00	0.0	0	0	0	0	0
05/04/2020 03:00	0.0	0	0	0	0	0
05/04/2020 04:00	0.0	0	0	0	0	0
05/04/2020 05:00	0.0	0	0	0	0	0
05/04/2020 06:00	0.0	0	0	0	0	0
05/04/2020 07:00	0.0	0	0	0	0	0
05/04/2020 08:00	0.0	0	0	0	0	0
05/04/2020 09:00	0.0	0	0	0	0	0
05/04/2020 10:00	0.0	0	0	0	0	0
05/04/2020 11:00	0.0	0	0	0	0	0
05/04/2020 12:00	0.0	0	0	0	0	0
05/04/2020 13:00	0.0	0	0	0	0	0
05/04/2020 14:00	0.0	0	0	0	0	0
05/04/2020 15:00	0.0	0	0	0	0	0
05/04/2020 16:00	0.0	0	0	0	0	0
05/04/2020 17:00	0.0	0	0	0	0	0
05/04/2020 18:00	0.0	0	0	0	0	0
05/04/2020 19:00	0.0	0	0	0	0	0
05/04/2020 20:00	0.0	0	0	0	0	0
05/04/2020 21:00	0.0	0	0	0	0	0
05/04/2020 22:00	0.0	0	0	0	0	0
05/04/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/05/2020 00:00	0.0	0	0	0	0	0
05/05/2020 01:00	0.0	0	0	0	0	0
05/05/2020 02:00	0.0	0	0	0	0	0
05/05/2020 03:00	0.0	0	0	0	0	0
05/05/2020 04:00	0.0	0	0	0	0	0
05/05/2020 05:00	0.0	0	0	0	0	0
05/05/2020 06:00	0.0	0	0	0	0	0
05/05/2020 07:00	0.0	0	0	0	0	0
05/05/2020 08:00	0.0	0	0	0	0	0
05/05/2020 09:00	0.0	0	0	0	0	0
05/05/2020 10:00	0.0	0	0	0	0	0
05/05/2020 11:00	0.0	0	0	0	0	0
05/05/2020 12:00	0.0	0	0	0	0	0
05/05/2020 13:00	0.0	0	0	0	0	0
05/05/2020 14:00	0.0	0	0	0	0	0
05/05/2020 15:00	0.0	0	0	0	0	0
05/05/2020 16:00	0.0	0	0	0	0	0
05/05/2020 17:00	0.0	0	0	0	0	0
05/05/2020 18:00	0.0	0	0	0	0	0
05/05/2020 19:00	0.0	0	0	0	0	0
05/05/2020 20:00	0.0	0	0	0	0	0
05/05/2020 21:00	0.0	0	0	0	0	0
05/05/2020 22:00	0.0	0	0	0	0	0
05/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/06/2020 00:00	0.0	0	0	0	0	0
05/06/2020 01:00	0.0	0	0	0	0	0
05/06/2020 02:00	0.0	0	0	0	0	0
05/06/2020 03:00	0.0	0	0	0	0	0
05/06/2020 04:00	0.0	0	0	0	0	0
05/06/2020 05:00	0.0	0	0	0	0	0
05/06/2020 06:00	0.0	0	0	0	0	0
05/06/2020 07:00	0.0	0	0	0	0	0
05/06/2020 08:00	0.0	0	0	0	0	0
05/06/2020 09:00	0.0	0	0	0	0	0
05/06/2020 10:00	0.0	0	0	0	0	0
05/06/2020 11:00	0.0	0	0	0	0	0
05/06/2020 12:00	0.0	0	0	0	0	0
05/06/2020 13:00	0.0	0	0	0	0	0
05/06/2020 14:00	0.0	0	0	0	0	0
05/06/2020 15:00	0.0	0	0	0	0	0
05/06/2020 16:00	0.0	0	0	0	0	0
05/06/2020 17:00	0.0	0	0	0	0	0
05/06/2020 18:00	0.0	0	0	0	0	0
05/06/2020 19:00	0.0	0	0	0	0	0
05/06/2020 20:00	0.0	0	0	0	0	0
05/06/2020 21:00	0.0	0	0	0	0	0
05/06/2020 22:00	0.0	0	0	0	0	0
05/06/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/07/2020 00:00	0.0	0	0	0	0	0
05/07/2020 01:00	0.0	0	0	0	0	0
05/07/2020 02:00	0.0	0	0	0	0	0
05/07/2020 03:00	0.0	0	0	0	0	0
05/07/2020 04:00	0.0	0	0	0	0	0
05/07/2020 05:00	0.0	0	0	0	0	0
05/07/2020 06:00	0.0	0	0	0	0	0
05/07/2020 07:00	0.0	0	0	0	0	0
05/07/2020 08:00	0.0	0	0	0	0	0
05/07/2020 09:00	0.0	0	0	0	0	0
05/07/2020 10:00	0.0	0	0	0	0	0
05/07/2020 11:00	0.0	0	0	0	0	0
05/07/2020 12:00	0.0	0	0	0	0	0
05/07/2020 13:00	0.0	0	0	0	0	0
05/07/2020 14:00	0.0	0	0	0	0	0
05/07/2020 15:00	0.0	0	0	0	0	0
05/07/2020 16:00	0.0	0	0	0	0	0
05/07/2020 17:00	0.0	0	0	0	0	0
05/07/2020 18:00	0.0	0	0	0	0	0
05/07/2020 19:00	0.0	0	0	0	0	0
05/07/2020 20:00	0.0	0	0	0	0	0
05/07/2020 21:00	0.0	0	0	0	0	0
05/07/2020 22:00	0.0	0	0	0	0	0
05/07/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/08/2020 00:00	0.0	0	0	0	0	0
05/08/2020 01:00	0.0	0	0	0	0	0
05/08/2020 02:00	0.0	0	0	0	0	0
05/08/2020 03:00	0.0	0	0	0	0	0
05/08/2020 04:00	0.0	0	0	0	0	0
05/08/2020 05:00	0.0	0	0	0	0	0
05/08/2020 06:00	0.0	0	0	0	0	0
05/08/2020 07:00	0.0	0	0	0	0	0
05/08/2020 08:00	0.0	0	0	0	0	0
05/08/2020 09:00	0.0	0	0	0	0	0
05/08/2020 10:00	0.0	0	0	0	0	0
05/08/2020 11:00	0.0	0	0	0	0	0
05/08/2020 12:00	0.0	0	0	0	0	0
05/08/2020 13:00	0.0	0	0	0	0	0
05/08/2020 14:00	0.0	0	0	0	0	0
05/08/2020 15:00	0.0	0	0	0	0	0
05/08/2020 16:00	0.0	0	0	0	0	0
05/08/2020 17:00	0.0	0	0	0	0	0
05/08/2020 18:00	0.0	0	0	0	0	0
05/08/2020 19:00	0.0	0	0	0	0	0
05/08/2020 20:00	0.0	0	0	0	0	0
05/08/2020 21:00	0.0	0	0	0	0	0
05/08/2020 22:00	0.0	0	0	0	0	0
05/08/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/09/2020 00:00	0.0	0	0	0	0	0
05/09/2020 01:00	0.0	0	0	0	0	0
05/09/2020 02:00	0.0	0	0	0	0	0
05/09/2020 03:00	0.0	0	0	0	0	0
05/09/2020 04:00	0.0	0	0	0	0	0
05/09/2020 05:00	0.0	0	0	0	0	0
05/09/2020 06:00	0.0	0	0	0	0	0
05/09/2020 07:00	0.0	0	0	0	0	0
05/09/2020 08:00	0.0	0	0	0	0	0
05/09/2020 09:00	0.0	0	0	0	0	0
05/09/2020 10:00	0.0	0	0	0	0	0
05/09/2020 11:00	0.0	0	0	0	0	0
05/09/2020 12:00	0.0	0	0	0	0	0
05/09/2020 13:00	0.0	0	0	0	0	0
05/09/2020 14:00	0.0	0	0	0	0	0
05/09/2020 15:00	0.0	0	0	0	0	0
05/09/2020 16:00	0.0	0	0	0	0	0
05/09/2020 17:00	0.0	0	0	0	0	0
05/09/2020 18:00	0.0	0	0	0	0	0
05/09/2020 19:00	0.0	0	0	0	0	0
05/09/2020 20:00	0.0	0	0	0	0	0
05/09/2020 21:00	0.0	0	0	0	0	0
05/09/2020 22:00	0.0	0	0	0	0	0
05/09/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/10/2020 00:00	0.0	0	0	0	0	0
05/10/2020 01:00	0.0	0	0	0	0	0
05/10/2020 02:00	0.0	0	0	0	0	0
05/10/2020 03:00	0.0	0	0	0	0	0
05/10/2020 04:00	0.0	0	0	0	0	0
05/10/2020 05:00	0.0	0	0	0	0	0
05/10/2020 06:00	0.0	0	0	0	0	0
05/10/2020 07:00	0.0	0	0	0	0	0
05/10/2020 08:00	0.0	0	0	0	0	0
05/10/2020 09:00	0.0	0	0	0	0	0
05/10/2020 10:00	0.0	0	0	0	0	0
05/10/2020 11:00	0.0	0	0	0	0	0
05/10/2020 12:00	0.0	0	0	0	0	0
05/10/2020 13:00	0.0	0	0	0	0	0
05/10/2020 14:00	0.0	0	0	0	0	0
05/10/2020 15:00	0.0	0	0	0	0	0
05/10/2020 16:00	0.0	0	0	0	0	0
05/10/2020 17:00	0.0	0	0	0	0	0
05/10/2020 18:00	0.0	0	0	0	0	0
05/10/2020 19:00	0.0	0	0	0	0	0
05/10/2020 20:00	0.0	0	0	0	0	0
05/10/2020 21:00	0.0	0	0	0	0	0
05/10/2020 22:00	0.0	0	0	0	0	0
05/10/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/11/2020 00:00	0.0	0	0	0	0	0
05/11/2020 01:00	0.0	0	0	0	0	0
05/11/2020 02:00	0.0	0	0	0	0	0
05/11/2020 03:00	0.0	0	0	0	0	0
05/11/2020 04:00	0.0	0	0	0	0	0
05/11/2020 05:00	0.0	0	0	0	0	0
05/11/2020 06:00	0.0	0	0	0	0	0
05/11/2020 07:00	0.0	0	0	0	0	0
05/11/2020 08:00	0.0	0	0	0	0	0
05/11/2020 09:00	0.0	0	0	0	0	0
05/11/2020 10:00	0.0	0	0	0	0	0
05/11/2020 11:00	0.0	0	0	0	0	0
05/11/2020 12:00	0.0	0	0	0	0	0
05/11/2020 13:00	0.0	0	0	0	0	0
05/11/2020 14:00	0.0	0	0	0	0	0
05/11/2020 15:00	0.0	0	0	0	0	0
05/11/2020 16:00	0.0	0	0	0	0	0
05/11/2020 17:00	0.0	0	0	0	0	0
05/11/2020 18:00	0.0	0	0	0	0	0
05/11/2020 19:00	0.0	0	0	0	0	0
05/11/2020 20:00	0.0	0	0	0	0	0
05/11/2020 21:00	0.0	0	0	0	0	0
05/11/2020 22:00	0.0	0	0	0	0	0
05/11/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/12/2020 00:00	0.0	0	0	0	0	0
05/12/2020 01:00	0.0	0	0	0	0	0
05/12/2020 02:00	0.0	0	0	0	0	0
05/12/2020 03:00	0.0	0	0	0	0	0
05/12/2020 04:00	0.0	0	0	0	0	0
05/12/2020 05:00	0.0	0	0	0	0	0
05/12/2020 06:00	0.0	0	0	0	0	0
05/12/2020 07:00	0.0	0	0	0	0	0
05/12/2020 08:00	0.0	0	0	0	0	0
05/12/2020 09:00	0.0	0	0	0	0	0
05/12/2020 10:00	0.0	0	0	0	0	0
05/12/2020 11:00	0.0	0	0	0	0	0
05/12/2020 12:00	0.0	0	0	0	0	0
05/12/2020 13:00	0.0	0	0	0	0	0
05/12/2020 14:00	0.0	0	0	0	0	0
05/12/2020 15:00	0.0	0	0	0	0	0
05/12/2020 16:00	0.0	0	0	0	0	0
05/12/2020 17:00	0.0	0	0	0	0	0
05/12/2020 18:00	0.0	0	0	0	0	0
05/12/2020 19:00	0.0	0	0	0	0	0
05/12/2020 20:00	0.0	0	0	0	0	0
05/12/2020 21:00	0.0	0	0	0	0	0
05/12/2020 22:00	0.0	0	0	0	0	0
05/12/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/13/2020 00:00	0.0	0	0	0	0	0
05/13/2020 01:00	0.0	0	0	0	0	0
05/13/2020 02:00	0.0	0	0	0	0	0
05/13/2020 03:00	0.0	0	0	0	0	0
05/13/2020 04:00	0.0	0	0	0	0	0
05/13/2020 05:00	0.0	0	0	0	0	0
05/13/2020 06:00	0.0	0	0	0	0	0
05/13/2020 07:00	0.0	0	0	0	0	0
05/13/2020 08:00	0.0	0	0	0	0	0
05/13/2020 09:00	0.0	0	0	0	0	0
05/13/2020 10:00	0.0	0	0	0	0	0
05/13/2020 11:00	0.0	0	0	0	0	0
05/13/2020 12:00	0.0	0	0	0	0	0
05/13/2020 13:00	0.0	0	0	0	0	0
05/13/2020 14:00	0.0	0	0	0	0	0
05/13/2020 15:00	0.0	0	0	0	0	0
05/13/2020 16:00	0.0	0	0	0	0	0
05/13/2020 17:00	0.0	0	0	0	0	0
05/13/2020 18:00	0.0	0	0	0	0	0
05/13/2020 19:00	0.0	0	0	0	0	0
05/13/2020 20:00	0.0	0	0	0	0	0
05/13/2020 21:00	0.0	0	0	0	0	0
05/13/2020 22:00	0.0	0	0	0	0	0
05/13/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/14/2020 00:00	0.0	0	0	0	0	0
05/14/2020 01:00	0.0	0	0	0	0	0
05/14/2020 02:00	0.0	0	0	0	0	0
05/14/2020 03:00	0.0	0	0	0	0	0
05/14/2020 04:00	0.0	0	0	0	0	0
05/14/2020 05:00	0.0	0	0	0	0	0
05/14/2020 06:00	0.0	0	0	0	0	0
05/14/2020 07:00	0.0	0	0	0	0	0
05/14/2020 08:00	0.0	0	0	0	0	0
05/14/2020 09:00	0.0	0	0	0	0	0
05/14/2020 10:00	0.0	0	0	0	0	0
05/14/2020 11:00	0.0	0	0	0	0	0
05/14/2020 12:00	0.0	0	0	0	0	0
05/14/2020 13:00	0.0	0	0	0	0	0
05/14/2020 14:00	0.0	0	0	0	0	0
05/14/2020 15:00	0.0	0	0	0	0	0
05/14/2020 16:00	0.0	0	0	0	0	0
05/14/2020 17:00	0.0	0	0	0	0	0
05/14/2020 18:00	0.0	0	0	0	0	0
05/14/2020 19:00	0.0	0	0	0	0	0
05/14/2020 20:00	0.0	0	0	0	0	0
05/14/2020 21:00	0.0	0	0	0	0	0
05/14/2020 22:00	0.0	0	0	0	0	0
05/14/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/15/2020 00:00	0.0	0	0	0	0	0
05/15/2020 01:00	0.0	0	0	0	0	0
05/15/2020 02:00	0.0	0	0	0	0	0
05/15/2020 03:00	0.0	0	0	0	0	0
05/15/2020 04:00	0.0	0	0	0	0	0
05/15/2020 05:00	0.0	0	0	0	0	0
05/15/2020 06:00	0.0	0	0	0	0	0
05/15/2020 07:00	0.0	0	0	0	0	0
05/15/2020 08:00	0.0	0	0	0	0	0
05/15/2020 09:00	0.0	0	0	0	0	0
05/15/2020 10:00	0.0	0	0	0	0	0
05/15/2020 11:00	0.0	0	0	0	0	0
05/15/2020 12:00	0.0	0	0	0	0	0
05/15/2020 13:00	0.0	0	0	0	0	0
05/15/2020 14:00	0.0	0	0	0	0	0
05/15/2020 15:00	0.0	0	0	0	0	0
05/15/2020 16:00	0.0	0	0	0	0	0
05/15/2020 17:00	0.0	0	0	0	0	0
05/15/2020 18:00	0.0	0	0	0	0	0
05/15/2020 19:00	0.0	0	0	0	0	0
05/15/2020 20:00	0.0	0	0	0	0	0
05/15/2020 21:00	0.0	0	0	0	0	0
05/15/2020 22:00	0.0	0	0	0	0	0
05/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/16/2020 00:00	0.0	0	0	0	0	0
05/16/2020 01:00	0.0	0	0	0	0	0
05/16/2020 02:00	0.0	0	0	0	0	0
05/16/2020 03:00	0.0	0	0	0	0	0
05/16/2020 04:00	0.0	0	0	0	0	0
05/16/2020 05:00	0.0	0	0	0	0	0
05/16/2020 06:00	0.0	0	0	0	0	0
05/16/2020 07:00	0.0	0	0	0	0	0
05/16/2020 08:00	0.0	0	0	0	0	0
05/16/2020 09:00	0.0	0	0	0	0	0
05/16/2020 10:00	0.0	0	0	0	0	0
05/16/2020 11:00	0.0	0	0	0	0	0
05/16/2020 12:00	0.0	0	0	0	0	0
05/16/2020 13:00	0.0	0	0	0	0	0
05/16/2020 14:00	0.0	0	0	0	0	0
05/16/2020 15:00	0.0	0	0	0	0	0
05/16/2020 16:00	0.0	0	0	0	0	0
05/16/2020 17:00	0.0	0	0	0	0	0
05/16/2020 18:00	0.0	0	0	0	0	0
05/16/2020 19:00	0.0	0	0	0	0	0
05/16/2020 20:00	0.0	0	0	0	0	0
05/16/2020 21:00	0.0	0	0	0	0	0
05/16/2020 22:00	0.0	0	0	0	0	0
05/16/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/17/2020 00:00	0.0	0	0	0	0	0
05/17/2020 01:00	0.0	0	0	0	0	0
05/17/2020 02:00	0.0	0	0	0	0	0
05/17/2020 03:00	0.0	0	0	0	0	0
05/17/2020 04:00	0.0	0	0	0	0	0
05/17/2020 05:00	0.0	0	0	0	0	0
05/17/2020 06:00	0.0	0	0	0	0	0
05/17/2020 07:00	0.0	0	0	0	0	0
05/17/2020 08:00	0.0	0	0	0	0	0
05/17/2020 09:00	0.0	0	0	0	0	0
05/17/2020 10:00	0.0	0	0	0	0	0
05/17/2020 11:00	0.0	0	0	0	0	0
05/17/2020 12:00	0.0	0	0	0	0	0
05/17/2020 13:00	0.0	0	0	0	0	0
05/17/2020 14:00	0.0	0	0	0	0	0
05/17/2020 15:00	0.0	0	0	0	0	0
05/17/2020 16:00	0.0	0	0	0	0	0
05/17/2020 17:00	0.0	0	0	0	0	0
05/17/2020 18:00	0.0	0	0	0	0	0
05/17/2020 19:00	0.0	0	0	0	0	0
05/17/2020 20:00	0.0	0	0	0	0	0
05/17/2020 21:00	0.0	0	0	0	0	0
05/17/2020 22:00	0.0	0	0	0	0	0
05/17/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/18/2020 00:00	0.0	0	0	0	0	0
05/18/2020 01:00	0.0	0	0	0	0	0
05/18/2020 02:00	0.0	0	0	0	0	0
05/18/2020 03:00	0.0	0	0	0	0	0
05/18/2020 04:00	0.0	0	0	0	0	0
05/18/2020 05:00	0.0	0	0	0	0	0
05/18/2020 06:00	0.0	0	0	0	0	0
05/18/2020 07:00	0.0	0	0	0	0	0
05/18/2020 08:00	0.0	0	0	0	0	0
05/18/2020 09:00	0.0	0	0	0	0	0
05/18/2020 10:00	0.0	0	0	0	0	0
05/18/2020 11:00	0.0	0	0	0	0	0
05/18/2020 12:00	0.0	0	0	0	0	0
05/18/2020 13:00	0.0	0	0	0	0	0
05/18/2020 14:00	0.0	0	0	0	0	0
05/18/2020 15:00	0.0	0	0	0	0	0
05/18/2020 16:00	0.0	0	0	0	0	0
05/18/2020 17:00	0.0	0	0	0	0	0
05/18/2020 18:00	0.0	0	0	0	0	0
05/18/2020 19:00	0.0	0	0	0	0	0
05/18/2020 20:00	0.0	0	0	0	0	0
05/18/2020 21:00	0.0	0	0	0	0	0
05/18/2020 22:00	0.0	0	0	0	0	0
05/18/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/19/2020 00:00	0.0	0	0	0	0	0
05/19/2020 01:00	0.0	0	0	0	0	0
05/19/2020 02:00	0.0	0	0	0	0	0
05/19/2020 03:00	0.0	0	0	0	0	0
05/19/2020 04:00	0.0	0	0	0	0	0
05/19/2020 05:00	0.0	0	0	0	0	0
05/19/2020 06:00	0.0	0	0	0	0	0
05/19/2020 07:00	0.0	0	0	0	0	0
05/19/2020 08:00	0.0	0	0	0	0	0
05/19/2020 09:00	0.0	0	0	0	0	0
05/19/2020 10:00	0.0	0	0	0	0	0
05/19/2020 11:00	0.0	0	0	0	0	0
05/19/2020 12:00	0.0	0	0	0	0	0
05/19/2020 13:00	0.0	0	0	0	0	0
05/19/2020 14:00	0.0	0	0	0	0	0
05/19/2020 15:00	0.0	0	0	0	0	0
05/19/2020 16:00	0.0	0	0	0	0	0
05/19/2020 17:00	0.0	0	0	0	0	0
05/19/2020 18:00	0.0	0	0	0	0	0
05/19/2020 19:00	0.0	0	0	0	0	0
05/19/2020 20:00	0.0	0	0	0	0	0
05/19/2020 21:00	0.0	0	0	0	0	0
05/19/2020 22:00	0.0	0	0	0	0	0
05/19/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/20/2020 00:00	0.0	0	0	0	0	0
05/20/2020 01:00	0.0	0	0	0	0	0
05/20/2020 02:00	0.0	0	0	0	0	0
05/20/2020 03:00	0.0	0	0	0	0	0
05/20/2020 04:00	0.0	0	0	0	0	0
05/20/2020 05:00	0.0	0	0	0	0	0
05/20/2020 06:00	0.0	0	0	0	0	0
05/20/2020 07:00	0.0	0	0	0	0	0
05/20/2020 08:00	0.0	0	0	0	0	0
05/20/2020 09:00	0.0	0	0	0	0	0
05/20/2020 10:00	0.0	0	0	0	0	0
05/20/2020 11:00	0.0	0	0	0	0	0
05/20/2020 12:00	0.0	0	0	0	0	0
05/20/2020 13:00	0.0	0	0	0	0	0
05/20/2020 14:00	0.0	0	0	0	0	0
05/20/2020 15:00	0.0	0	0	0	0	0
05/20/2020 16:00	0.0	0	0	0	0	0
05/20/2020 17:00	0.0	0	0	0	0	0
05/20/2020 18:00	0.0	0	0	0	0	0
05/20/2020 19:00	0.0	0	0	0	0	0
05/20/2020 20:00	0.0	0	0	0	0	0
05/20/2020 21:00	0.0	0	0	0	0	0
05/20/2020 22:00	0.0	0	0	0	0	0
05/20/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/21/2020 00:00	0.0	0	0	0	0	0
05/21/2020 01:00	0.0	0	0	0	0	0
05/21/2020 02:00	0.0	0	0	0	0	0
05/21/2020 03:00	0.0	0	0	0	0	0
05/21/2020 04:00	0.0	0	0	0	0	0
05/21/2020 05:00	0.0	0	0	0	0	0
05/21/2020 06:00	0.0	0	0	0	0	0
05/21/2020 07:00	0.0	0	0	0	0	0
05/21/2020 08:00	0.0	0	0	0	0	0
05/21/2020 09:00	0.0	0	0	0	0	0
05/21/2020 10:00	0.0	0	0	0	0	0
05/21/2020 11:00	0.0	0	0	0	0	0
05/21/2020 12:00	0.0	0	0	0	0	0
05/21/2020 13:00	0.0	0	0	0	0	0
05/21/2020 14:00	0.0	0	0	0	0	0
05/21/2020 15:00	0.0	0	0	0	0	0
05/21/2020 16:00	0.0	0	0	0	0	0
05/21/2020 17:00	0.0	0	0	0	0	0
05/21/2020 18:00	0.0	0	0	0	0	0
05/21/2020 19:00	0.0	0	0	0	0	0
05/21/2020 20:00	0.0	0	0	0	0	0
05/21/2020 21:00	0.0	0	0	0	0	0
05/21/2020 22:00	0.0	0	0	0	0	0
05/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/22/2020 00:00	0.0	0	0	0	0	0
05/22/2020 01:00	0.0	0	0	0	0	0
05/22/2020 02:00	0.0	0	0	0	0	0
05/22/2020 03:00	0.0	0	0	0	0	0
05/22/2020 04:00	0.0	0	0	0	0	0
05/22/2020 05:00	0.0	0	0	0	0	0
05/22/2020 06:00	0.0	0	0	0	0	0
05/22/2020 07:00	0.0	0	0	0	0	0
05/22/2020 08:00	0.0	0	0	0	0	0
05/22/2020 09:00	0.0	0	0	0	0	0
05/22/2020 10:00	0.0	0	0	0	0	0
05/22/2020 11:00	0.0	0	0	0	0	0
05/22/2020 12:00	0.0	0	0	0	0	0
05/22/2020 13:00	0.0	0	0	0	0	0
05/22/2020 14:00	0.0	0	0	0	0	0
05/22/2020 15:00	0.0	0	0	0	0	0
05/22/2020 16:00	0.0	0	0	0	0	0
05/22/2020 17:00	0.0	0	0	0	0	0
05/22/2020 18:00	0.0	0	0	0	0	0
05/22/2020 19:00	0.0	0	0	0	0	0
05/22/2020 20:00	0.0	0	0	0	0	0
05/22/2020 21:00	0.0	0	0	0	0	0
05/22/2020 22:00	0.0	0	0	0	0	0
05/22/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/23/2020 00:00	0.0	0	0	0	0	0
05/23/2020 01:00	0.0	0	0	0	0	0
05/23/2020 02:00	0.0	0	0	0	0	0
05/23/2020 03:00	0.0	0	0	0	0	0
05/23/2020 04:00	0.0	0	0	0	0	0
05/23/2020 05:00	0.0	0	0	0	0	0
05/23/2020 06:00	0.0	0	0	0	0	0
05/23/2020 07:00	0.0	0	0	0	0	0
05/23/2020 08:00	0.0	0	0	0	0	0
05/23/2020 09:00	0.0	0	0	0	0	0
05/23/2020 10:00	0.0	0	0	0	0	0
05/23/2020 11:00	0.0	0	0	0	0	0
05/23/2020 12:00	0.0	0	0	0	0	0
05/23/2020 13:00	0.0	0	0	0	0	0
05/23/2020 14:00	0.0	0	0	0	0	0
05/23/2020 15:00	0.0	0	0	0	0	0
05/23/2020 16:00	0.0	0	0	0	0	0
05/23/2020 17:00	0.0	0	0	0	0	0
05/23/2020 18:00	0.0	0	0	0	0	0
05/23/2020 19:00	0.0	0	0	0	0	0
05/23/2020 20:00	0.0	0	0	0	0	0
05/23/2020 21:00	0.0	0	0	0	0	0
05/23/2020 22:00	0.0	0	0	0	0	0
05/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/24/2020 00:00	0.0	0	0	0	0	0
05/24/2020 01:00	0.0	0	0	0	0	0
05/24/2020 02:00	0.0	0	0	0	0	0
05/24/2020 03:00	0.0	0	0	0	0	0
05/24/2020 04:00	0.0	0	0	0	0	0
05/24/2020 05:00	0.0	0	0	0	0	0
05/24/2020 06:00	0.0	0	0	0	0	0
05/24/2020 07:00	0.0	0	0	0	0	0
05/24/2020 08:00	0.0	0	0	0	0	0
05/24/2020 09:00	0.0	0	0	0	0	0
05/24/2020 10:00	0.0	0	0	0	0	0
05/24/2020 11:00	0.0	0	0	0	0	0
05/24/2020 12:00	0.0	0	0	0	0	0
05/24/2020 13:00	0.0	0	0	0	0	0
05/24/2020 14:00	0.0	0	0	0	0	0
05/24/2020 15:00	0.0	0	0	0	0	0
05/24/2020 16:00	0.0	0	0	0	0	0
05/24/2020 17:00	0.0	0	0	0	0	0
05/24/2020 18:00	0.0	0	0	0	0	0
05/24/2020 19:00	0.0	0	0	0	0	0
05/24/2020 20:00	0.0	0	0	0	0	0
05/24/2020 21:00	0.0	0	0	0	0	0
05/24/2020 22:00	0.0	0	0	0	0	0
05/24/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/25/2020 00:00	0.0	0	0	0	0	0
05/25/2020 01:00	0.0	0	0	0	0	0
05/25/2020 02:00	0.0	0	0	0	0	0
05/25/2020 03:00	0.0	0	0	0	0	0
05/25/2020 04:00	0.0	0	0	0	0	0
05/25/2020 05:00	0.0	0	0	0	0	0
05/25/2020 06:00	0.0	0	0	0	0	0
05/25/2020 07:00	0.0	0	0	0	0	0
05/25/2020 08:00	0.0	0	0	0	0	0
05/25/2020 09:00	0.0	0	0	0	0	0
05/25/2020 10:00	0.0	0	0	0	0	0
05/25/2020 11:00	0.0	0	0	0	0	0
05/25/2020 12:00	0.0	0	0	0	0	0
05/25/2020 13:00	0.0	0	0	0	0	0
05/25/2020 14:00	0.0	0	0	0	0	0
05/25/2020 15:00	0.0	0	0	0	0	0
05/25/2020 16:00	0.0	0	0	0	0	0
05/25/2020 17:00	0.0	0	0	0	0	0
05/25/2020 18:00	0.0	0	0	0	0	0
05/25/2020 19:00	0.0	0	0	0	0	0
05/25/2020 20:00	0.0	0	0	0	0	0
05/25/2020 21:00	0.0	0	0	0	0	0
05/25/2020 22:00	0.0	0	0	0	0	0
05/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/26/2020 00:00	0.0	0	0	0	0	0
05/26/2020 01:00	0.0	0	0	0	0	0
05/26/2020 02:00	0.0	0	0	0	0	0
05/26/2020 03:00	0.0	0	0	0	0	0
05/26/2020 04:00	0.0	0	0	0	0	0
05/26/2020 05:00	0.0	0	0	0	0	0
05/26/2020 06:00	0.0	0	0	0	0	0
05/26/2020 07:00	0.0	0	0	0	0	0
05/26/2020 08:00	0.0	0	0	0	0	0
05/26/2020 09:00	0.0	0	0	0	0	0
05/26/2020 10:00	37.8	1	0	0	1	0
05/26/2020 11:00	11.4	1	0	0	0	0
05/26/2020 12:00	320.0	1	0	0	0	0
05/26/2020 13:00	87.1	1	0	0	0	0
05/26/2020 14:00	89.8	1	0	0	0	0
05/26/2020 15:00	7.9	1	0	0	1	0
05/26/2020 16:00	0.0	0	0	0	0	0
05/26/2020 17:00	0.0	0	0	0	0	0
05/26/2020 18:00	0.0	0	0	0	0	0
05/26/2020 19:00	0.0	0	0	0	0	0
05/26/2020 20:00	0.0	0	0	0	0	0
05/26/2020 21:00	0.0	0	0	0	0	0
05/26/2020 22:00	0.0	0	0	0	0	0
05/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	554.0 #	6 #	0 #	0 #	2 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	320.0	1	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/27/2020 00:00	0.0	0	0	0	0	0
05/27/2020 01:00	0.0	0	0	0	0	0
05/27/2020 02:00	0.0	0	0	0	0	0
05/27/2020 03:00	0.0	0	0	0	0	0
05/27/2020 04:00	0.0	0	0	0	0	0
05/27/2020 05:00	0.0	0	0	0	0	0
05/27/2020 06:00	0.0	0	0	0	0	0
05/27/2020 07:00	0.0	0	0	0	0	0
05/27/2020 08:00	0.0	0	0	0	0	0
05/27/2020 09:00	0.0	0	0	0	0	0
05/27/2020 10:00	0.0	0	0	0	0	0
05/27/2020 11:00	0.0	0	0	0	0	0
05/27/2020 12:00	0.0	0	0	0	0	0
05/27/2020 13:00	0.0	0	0	0	0	0
05/27/2020 14:00	0.0	0	0	0	0	0
05/27/2020 15:00	0.0	0	0	0	0	0
05/27/2020 16:00	0.0	0	0	0	0	0
05/27/2020 17:00	0.0	0	0	0	0	0
05/27/2020 18:00	0.0	0	0	0	0	0
05/27/2020 19:00	0.0	0	0	0	0	0
05/27/2020 20:00	0.0	0	0	0	0	0
05/27/2020 21:00	0.0	0	0	0	0	0
05/27/2020 22:00	0.0	0	0	0	0	0
05/27/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/28/2020 00:00	0.0	0	0	0	0	0
05/28/2020 01:00	0.0	0	0	0	0	0
05/28/2020 02:00	0.0	0	0	0	0	0
05/28/2020 03:00	0.0	0	0	0	0	0
05/28/2020 04:00	0.0	0	0	0	0	0
05/28/2020 05:00	0.0	0	0	0	0	0
05/28/2020 06:00	0.0	0	0	0	0	0
05/28/2020 07:00	0.0	0	0	0	0	0
05/28/2020 08:00	0.0	0	0	0	0	0
05/28/2020 09:00	0.0	0	0	0	0	0
05/28/2020 10:00	0.0	0	0	0	0	0
05/28/2020 11:00	0.0	0	0	0	0	0
05/28/2020 12:00	0.0	1	0	0	0	0
05/28/2020 13:00	0.0	1	0	0	0	0
05/28/2020 14:00	0.0	1	0	0	0	0
05/28/2020 15:00	0.0	1	0	0	0	0
05/28/2020 16:00	0.0	0	0	0	0	1
05/28/2020 17:00	0.0	0	0	0	0	1
05/28/2020 18:00	0.0	0	0	0	0	1
05/28/2020 19:00	0.0	0	0	0	0	1
05/28/2020 20:00	0.0	0	0	0	0	1
05/28/2020 21:00	0.0	0	0	0	0	1
05/28/2020 22:00	0.0	0	0	0	0	1
05/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	4 #	0 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/29/2020 00:00	0.0	0	0	0	0	1
05/29/2020 01:00	1.0	0	0	0	1	0
05/29/2020 02:00	0.0	0	0	0	0	0
05/29/2020 03:00	0.0	0	0	0	0	0
05/29/2020 04:00	0.0	0	0	0	0	0
05/29/2020 05:00	0.0	0	0	0	0	0
05/29/2020 06:00	0.0	0	0	0	0	0
05/29/2020 07:00	0.0	0	0	0	0	0
05/29/2020 08:00	0.0	0	0	0	0	0
05/29/2020 09:00	0.0	0	0	0	0	0
05/29/2020 10:00	0.0	0	0	0	0	0
05/29/2020 11:00	0.0	0	0	0	0	0
05/29/2020 12:00	0.0	0	0	0	0	0
05/29/2020 13:00	0.0	0	0	0	0	0
05/29/2020 14:00	0.0	0	0	0	0	0
05/29/2020 15:00	0.0	0	0	0	0	0
05/29/2020 16:00	0.0	0	0	0	0	0
05/29/2020 17:00	0.0	0	0	0	0	0
05/29/2020 18:00	0.0	0	0	0	0	0
05/29/2020 19:00	0.0	0	0	0	0	0
05/29/2020 20:00	0.0	0	0	0	0	0
05/29/2020 21:00	0.0	0	0	0	0	0
05/29/2020 22:00	0.0	0	0	0	0	0
05/29/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.0 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/30/2020 00:00	0.0	0	0	0	0	0
05/30/2020 01:00	0.0	0	0	0	0	0
05/30/2020 02:00	0.0	0	0	0	0	0
05/30/2020 03:00	0.0	0	0	0	0	0
05/30/2020 04:00	0.0	0	0	0	0	0
05/30/2020 05:00	0.0	0	0	0	0	0
05/30/2020 06:00	0.0	0	0	0	0	0
05/30/2020 07:00	0.0	0	0	0	0	0
05/30/2020 08:00	0.0	0	0	0	0	0
05/30/2020 09:00	0.0	0	0	0	0	0
05/30/2020 10:00	0.0	0	0	0	0	0
05/30/2020 11:00	0.0	0	0	0	0	0
05/30/2020 12:00	0.0	0	0	0	0	0
05/30/2020 13:00	0.0	0	0	0	0	0
05/30/2020 14:00	0.0	0	0	0	0	0
05/30/2020 15:00	0.0	0	0	0	0	0
05/30/2020 16:00	0.0	0	0	0	0	0
05/30/2020 17:00	0.0	0	0	0	0	0
05/30/2020 18:00	0.0	0	0	0	0	0
05/30/2020 19:00	0.0	0	0	0	0	0
05/30/2020 20:00	0.0	0	0	0	0	0
05/30/2020 21:00	0.0	0	0	0	0	0
05/30/2020 22:00	0.0	0	0	0	0	0
05/30/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
05/31/2020 00:00	0.0	0	0	0	0	0
05/31/2020 01:00	0.0	0	0	0	0	0
05/31/2020 02:00	0.0	0	0	0	0	0
05/31/2020 03:00	0.0	0	0	0	0	0
05/31/2020 04:00	0.0	0	0	0	0	0
05/31/2020 05:00	0.0	0	0	0	0	0
05/31/2020 06:00	0.0	0	0	0	0	0
05/31/2020 07:00	0.0	0	0	0	0	0
05/31/2020 08:00	0.0	0	0	0	0	0
05/31/2020 09:00	0.0	0	0	0	0	0
05/31/2020 10:00	0.0	0	0	0	0	0
05/31/2020 11:00	0.0	0	0	0	0	0
05/31/2020 12:00	0.0	0	0	0	0	0
05/31/2020 13:00	0.0	0	0	0	0	0
05/31/2020 14:00	0.0	0	0	0	0	0
05/31/2020 15:00	0.0	0	0	0	0	0
05/31/2020 16:00	0.0	0	0	0	0	0
05/31/2020 17:00	0.0	0	0	0	0	0
05/31/2020 18:00	0.0	0	0	0	0	0
05/31/2020 19:00	0.0	0	0	0	0	0
05/31/2020 20:00	0.0	0	0	0	0	0
05/31/2020 21:00	0.0	0	0	0	0	0
05/31/2020 22:00	0.0	0	0	0	0	0
05/31/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/01/2020 00:00	0.0	0	0	0	0	0
06/01/2020 01:00	0.0	0	0	0	0	0
06/01/2020 02:00	0.0	0	0	0	0	0
06/01/2020 03:00	0.0	0	0	0	0	0
06/01/2020 04:00	0.0	0	0	0	0	0
06/01/2020 05:00	0.0	0	0	0	0	0
06/01/2020 06:00	0.0	0	0	0	0	0
06/01/2020 07:00	0.0	0	0	0	0	0
06/01/2020 08:00	0.0	0	0	0	0	0
06/01/2020 09:00	0.0	0	0	0	0	0
06/01/2020 10:00	0.0	0	0	0	0	0
06/01/2020 11:00	0.0	0	0	0	0	0
06/01/2020 12:00	57.7	1	0	0	0	0
06/01/2020 13:00	44.0	1	0	0	1	0
06/01/2020 14:00	35.7	1	0	0	0	0
06/01/2020 15:00	0.0	0	0	0	0	1
06/01/2020 16:00	0.0	0	0	0	0	1
06/01/2020 17:00	0.0	0	0	0	0	1
06/01/2020 18:00	0.0	0	0	0	0	1
06/01/2020 19:00	0.0	0	0	0	0	1
06/01/2020 20:00	0.0	0	0	0	0	1
06/01/2020 21:00	0.0	0	0	0	0	1
06/01/2020 22:00	0.0	0	0	0	0	1
06/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	137.4 #	3 #	0 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	57.7	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/02/2020 00:00	0.0	0	0	0	0	1
06/02/2020 01:00	0.0	0	0	0	0	1
06/02/2020 02:00	0.0	0	0	0	0	1
06/02/2020 03:00	0.0	0	0	0	0	1
06/02/2020 04:00	0.0	0	0	0	0	1
06/02/2020 05:00	0.0	0	0	0	0	1
06/02/2020 06:00	0.0	0	0	0	0	1
06/02/2020 07:00	0.0	0	0	0	0	1
06/02/2020 08:00	0.0	0	0	0	0	1
06/02/2020 09:00	0.0	0	0	0	0	1
06/02/2020 10:00	0.0	0	0	0	0	1
06/02/2020 11:00	0.0	0	0	0	0	1
06/02/2020 12:00	0.0	0	0	0	0	1
06/02/2020 13:00	0.0	0	0	0	0	1
06/02/2020 14:00	0.0	0	0	0	0	1
06/02/2020 15:00	0.0	0	0	0	0	1
06/02/2020 16:00	0.0	0	0	0	0	1
06/02/2020 17:00	0.0	0	0	0	0	1
06/02/2020 18:00	0.0	0	0	0	0	1
06/02/2020 19:00	0.0	0	0	0	0	1
06/02/2020 20:00	0.0	0	0	0	0	1
06/02/2020 21:00	0.0	0	0	0	0	1
06/02/2020 22:00	0.0	0	0	0	0	1
06/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/03/2020 00:00	0.0	0	0	0	0	1
06/03/2020 01:00	0.0	0	0	0	0	1
06/03/2020 02:00	0.0	0	0	0	0	1
06/03/2020 03:00	0.0	0	0	0	0	1
06/03/2020 04:00	0.0	0	0	0	0	1
06/03/2020 05:00	0.0	0	0	0	0	1
06/03/2020 06:00	0.0	0	0	0	0	1
06/03/2020 07:00	0.0	0	0	0	0	1
06/03/2020 08:00	0.0	0	0	0	0	1
06/03/2020 09:00	0.0	0	0	0	0	1
06/03/2020 10:00	0.0	0	0	0	0	1
06/03/2020 11:00	0.0	0	0	0	0	1
06/03/2020 12:00	0.0	0	0	0	0	1
06/03/2020 13:00	0.0	0	0	0	0	1
06/03/2020 14:00	0.0	0	0	0	0	1
06/03/2020 15:00	0.0	0	0	0	0	1
06/03/2020 16:00	0.0	0	0	0	0	1
06/03/2020 17:00	0.0	0	0	0	0	1
06/03/2020 18:00	0.0	0	0	0	0	1
06/03/2020 19:00	0.0	0	0	0	0	1
06/03/2020 20:00	0.0	0	0	0	0	1
06/03/2020 21:00	0.0	0	0	0	0	1
06/03/2020 22:00	0.0	0	0	0	0	1
06/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/04/2020 00:00	2.1	0	0	0	1	0
06/04/2020 01:00	0.0	0	0	0	0	0
06/04/2020 02:00	0.0	0	0	0	0	0
06/04/2020 03:00	0.0	0	0	0	0	0
06/04/2020 04:00	0.0	0	0	0	0	0
06/04/2020 05:00	0.0	0	0	0	0	0
06/04/2020 06:00	11.7	0	0	1	0	0
06/04/2020 07:00	84.2	0	0	1	0	0
06/04/2020 08:00	0.0	0	0	0	0	1
06/04/2020 09:00	0.0	0	0	0	0	1
06/04/2020 10:00	0.0	0	0	0	0	1
06/04/2020 11:00	0.0	0	0	0	0	1
06/04/2020 12:00	0.0	0	0	0	0	1
06/04/2020 13:00	0.0	0	0	0	0	1
06/04/2020 14:00	0.0	0	0	0	0	1
06/04/2020 15:00	0.0	0	0	0	0	1
06/04/2020 16:00	0.0	0	0	0	0	1
06/04/2020 17:00	0.0	0	0	0	0	1
06/04/2020 18:00	0.0	0	0	0	0	1
06/04/2020 19:00	0.0	0	0	0	0	1
06/04/2020 20:00	0.0	0	0	0	0	1
06/04/2020 21:00	0.0	0	0	0	0	1
06/04/2020 22:00	0.0	0	0	0	0	1
06/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	98.0 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	84.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/05/2020 00:00	1.3	0	0	0	1	0
06/05/2020 01:00	0.0	0	0	0	0	0
06/05/2020 02:00	0.0	0	0	0	0	0
06/05/2020 03:00	0.0	0	0	0	0	0
06/05/2020 04:00	0.0	0	0	0	0	0
06/05/2020 05:00	0.0	0	0	0	0	0
06/05/2020 06:00	0.0	0	0	0	0	0
06/05/2020 07:00	0.0	0	0	0	0	0
06/05/2020 08:00	0.0	0	0	0	0	0
06/05/2020 09:00	0.0	0	0	0	0	0
06/05/2020 10:00	0.0	0	0	0	0	0
06/05/2020 11:00	0.0	0	0	0	0	0
06/05/2020 12:00	0.0	0	0	0	0	0
06/05/2020 13:00	0.0	0	0	0	0	0
06/05/2020 14:00	0.0	0	0	0	0	0
06/05/2020 15:00	0.0	0	0	0	0	0
06/05/2020 16:00	0.0	0	0	0	0	0
06/05/2020 17:00	0.0	0	0	0	0	0
06/05/2020 18:00	0.0	0	0	0	0	0
06/05/2020 19:00	0.0	0	0	0	0	0
06/05/2020 20:00	0.0	0	0	0	0	0
06/05/2020 21:00	0.0	0	0	0	0	0
06/05/2020 22:00	0.0	0	0	0	0	0
06/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.3 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.3	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/06/2020 00:00	0.0	0	0	0	0	0
06/06/2020 01:00	0.0	0	0	0	0	0
06/06/2020 02:00	0.0	0	0	0	0	0
06/06/2020 03:00	0.0	0	0	0	0	0
06/06/2020 04:00	0.0	0	0	0	0	0
06/06/2020 05:00	0.0	0	0	0	0	0
06/06/2020 06:00	0.0	0	0	0	0	0
06/06/2020 07:00	0.0	0	0	0	0	0
06/06/2020 08:00	0.0	0	0	0	0	0
06/06/2020 09:00	0.0	0	0	0	0	0
06/06/2020 10:00	0.0	0	0	0	0	0
06/06/2020 11:00	0.0	0	0	0	0	0
06/06/2020 12:00	0.0	0	0	0	0	0
06/06/2020 13:00	0.0	0	0	0	0	0
06/06/2020 14:00	0.0	0	0	0	0	0
06/06/2020 15:00	0.0	0	0	0	0	0
06/06/2020 16:00	0.0	0	0	0	0	0
06/06/2020 17:00	0.0	0	0	0	0	0
06/06/2020 18:00	0.0	0	0	0	0	0
06/06/2020 19:00	0.0	0	0	0	0	0
06/06/2020 20:00	0.0	0	0	0	0	0
06/06/2020 21:00	0.0	0	0	0	0	0
06/06/2020 22:00	0.0	0	0	0	0	0
06/06/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/07/2020 00:00	0.0	0	0	0	0	0
06/07/2020 01:00	0.0	0	0	0	0	0
06/07/2020 02:00	0.0	0	0	0	0	0
06/07/2020 03:00	0.0	0	0	0	0	0
06/07/2020 04:00	0.0	0	0	0	0	0
06/07/2020 05:00	0.0	0	0	0	0	0
06/07/2020 06:00	0.0	0	0	0	0	0
06/07/2020 07:00	0.0	0	0	0	0	0
06/07/2020 08:00	0.0	0	0	0	0	0
06/07/2020 09:00	0.0	0	0	0	0	0
06/07/2020 10:00	0.0	0	0	0	0	0
06/07/2020 11:00	0.0	0	0	0	0	0
06/07/2020 12:00	0.0	0	0	0	0	0
06/07/2020 13:00	0.0	0	0	0	0	0
06/07/2020 14:00	0.0	0	0	0	0	0
06/07/2020 15:00	0.0	0	0	0	0	0
06/07/2020 16:00	0.0	0	0	0	0	0
06/07/2020 17:00	0.0	0	0	0	0	0
06/07/2020 18:00	0.0	0	0	0	0	0
06/07/2020 19:00	0.0	0	0	0	0	0
06/07/2020 20:00	0.0	0	0	0	0	0
06/07/2020 21:00	0.0	0	0	0	0	0
06/07/2020 22:00	0.0	0	0	0	0	0
06/07/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/08/2020 00:00	0.0	0	0	0	0	0
06/08/2020 01:00	0.0	0	0	0	0	0
06/08/2020 02:00	0.0	0	0	0	0	0
06/08/2020 03:00	0.0	0	0	0	0	0
06/08/2020 04:00	0.0	0	0	0	0	0
06/08/2020 05:00	0.0	0	0	0	0	0
06/08/2020 06:00	0.0	0	0	0	0	0
06/08/2020 07:00	0.0	0	0	0	0	0
06/08/2020 08:00	0.0	0	0	0	0	0
06/08/2020 09:00	0.0	0	0	0	0	0
06/08/2020 10:00	0.0	0	0	0	0	0
06/08/2020 11:00	0.0	0	0	0	0	0
06/08/2020 12:00	0.0	0	0	0	0	0
06/08/2020 13:00	0.0	0	0	0	0	0
06/08/2020 14:00	0.0	0	0	0	0	0
06/08/2020 15:00	259.5	1	0	0	0	0
06/08/2020 16:00	305.7	1	0	0	0	0
06/08/2020 17:00	6.3	1	0	1	1	0
06/08/2020 18:00	22.7	0	0	1	0	0
06/08/2020 19:00	0.0	0	0	0	0	1
06/08/2020 20:00	0.0	0	0	0	0	1
06/08/2020 21:00	0.0	0	0	0	0	1
06/08/2020 22:00	0.0	0	0	0	0	1
06/08/2020 23:00	0.8	0	0	0	1	0
Average/Sum#:	595.0 #	3 #	0 #	2 #	2 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	305.7	1	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/09/2020 00:00	0.0	0	0	0	0	0
06/09/2020 01:00	0.0	0	0	0	0	0
06/09/2020 02:00	0.0	0	0	0	0	0
06/09/2020 03:00	0.0	0	0	0	0	0
06/09/2020 04:00	0.0	0	0	0	0	0
06/09/2020 05:00	0.0	0	0	0	0	0
06/09/2020 06:00	0.0	0	0	0	0	0
06/09/2020 07:00	0.0	0	0	0	0	0
06/09/2020 08:00	0.0	0	0	0	0	0
06/09/2020 09:00	0.0	0	0	0	0	0
06/09/2020 10:00	0.0	0	0	0	0	0
06/09/2020 11:00	0.0	0	0	0	0	0
06/09/2020 12:00	131.6	0	1	0	0	0
06/09/2020 13:00	22.1	0	1	0	1	0
06/09/2020 14:00	40.0	0	1	0	0	0
06/09/2020 15:00	0.2	0	1	0	0	0
06/09/2020 16:00	0.0	0	0	0	0	1
06/09/2020 17:00	0.0	0	0	0	0	1
06/09/2020 18:00	0.0	0	0	0	0	1
06/09/2020 19:00	0.0	0	0	0	0	1
06/09/2020 20:00	0.0	0	0	0	0	1
06/09/2020 21:00	0.0	0	0	0	0	1
06/09/2020 22:00	0.0	0	0	0	0	1
06/09/2020 23:00	1.5	0	0	0	1	0
Average/Sum#:	195.4 #	0 #	4 #	0 #	2 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	131.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/10/2020 00:00	0.0	0	0	0	0	0
06/10/2020 01:00	0.0	0	0	0	0	0
06/10/2020 02:00	0.0	0	0	0	0	0
06/10/2020 03:00	0.0	0	0	0	0	0
06/10/2020 04:00	0.0	0	0	0	0	0
06/10/2020 05:00	0.0	0	0	0	0	0
06/10/2020 06:00	0.0	0	0	0	0	0
06/10/2020 07:00	0.0	0	0	0	0	0
06/10/2020 08:00	0.0	0	0	0	0	0
06/10/2020 09:00	0.0	0	0	0	0	0
06/10/2020 10:00	154.6	0	1	0	0	0
06/10/2020 11:00	93.8	0	1	0	0	0
06/10/2020 12:00	3.1	0	1	0	0	0
06/10/2020 13:00	0.0	0	0	0	0	1
06/10/2020 14:00	0.0	0	0	0	0	1
06/10/2020 15:00	0.0	0	0	0	0	1
06/10/2020 16:00	0.0	0	0	0	0	1
06/10/2020 17:00	0.0	0	0	0	0	1
06/10/2020 18:00	0.0	0	0	0	0	1
06/10/2020 19:00	0.0	0	0	0	0	1
06/10/2020 20:00	0.0	0	0	0	0	1
06/10/2020 21:00	0.0	0	0	0	0	1
06/10/2020 22:00	0.0	0	0	0	0	1
06/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	251.5 #	0 #	3 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	154.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/11/2020 00:00	0.0	0	0	0	0	1
06/11/2020 01:00	0.0	0	0	0	0	1
06/11/2020 02:00	0.0	0	0	0	0	1
06/11/2020 03:00	0.0	0	0	0	0	1
06/11/2020 04:00	0.0	0	0	0	0	1
06/11/2020 05:00	0.0	0	0	0	0	1
06/11/2020 06:00	0.0	0	0	0	0	1
06/11/2020 07:00	0.0	0	0	0	0	1
06/11/2020 08:00	0.0	0	0	0	0	1
06/11/2020 09:00	0.0	0	0	0	0	1
06/11/2020 10:00	0.0	0	0	0	0	1
06/11/2020 11:00	0.0	0	0	0	0	1
06/11/2020 12:00	0.0	0	0	0	0	1
06/11/2020 13:00	0.0	0	0	0	0	1
06/11/2020 14:00	0.0	0	0	0	0	1
06/11/2020 15:00	0.0	0	0	0	0	1
06/11/2020 16:00	0.0	0	0	0	0	1
06/11/2020 17:00	0.0	0	0	0	0	1
06/11/2020 18:00	0.0	0	0	0	0	1
06/11/2020 19:00	0.0	0	0	0	0	1
06/11/2020 20:00	0.0	0	0	0	0	1
06/11/2020 21:00	0.0	0	0	0	0	1
06/11/2020 22:00	0.0	0	0	0	0	1
06/11/2020 23:00	1.0	0	0	0	1	0
Average/Sum#:	1.0 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/12/2020 00:00	0.0	0	0	0	0	0
06/12/2020 01:00	0.0	0	0	0	0	0
06/12/2020 02:00	0.0	0	0	0	0	0
06/12/2020 03:00	0.0	0	0	0	0	0
06/12/2020 04:00	0.0	0	0	0	0	0
06/12/2020 05:00	0.0	0	0	0	0	0
06/12/2020 06:00	0.0	0	0	0	0	0
06/12/2020 07:00	0.0	0	0	0	0	0
06/12/2020 08:00	0.0	0	0	0	0	0
06/12/2020 09:00	0.0	0	0	0	0	0
06/12/2020 10:00	0.0	0	0	0	0	0
06/12/2020 11:00	0.0	0	0	0	0	0
06/12/2020 12:00	0.0	0	0	0	0	0
06/12/2020 13:00	0.0	0	0	0	0	0
06/12/2020 14:00	0.0	0	0	0	0	0
06/12/2020 15:00	0.0	0	0	0	0	0
06/12/2020 16:00	0.0	0	0	0	0	0
06/12/2020 17:00	0.0	0	0	0	0	0
06/12/2020 18:00	0.0	0	0	0	0	0
06/12/2020 19:00	0.0	0	0	0	0	0
06/12/2020 20:00	0.0	0	0	0	0	0
06/12/2020 21:00	0.0	0	0	0	0	0
06/12/2020 22:00	0.0	0	0	0	0	0
06/12/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/13/2020 00:00	0.0	0	0	0	0	0
06/13/2020 01:00	0.0	0	0	0	0	0
06/13/2020 02:00	0.0	0	0	0	0	0
06/13/2020 03:00	0.0	0	0	0	0	0
06/13/2020 04:00	0.0	0	0	0	0	0
06/13/2020 05:00	0.0	0	0	0	0	0
06/13/2020 06:00	0.0	0	0	0	0	0
06/13/2020 07:00	0.0	0	0	0	0	0
06/13/2020 08:00	0.0	0	0	0	0	0
06/13/2020 09:00	0.0	0	0	0	0	0
06/13/2020 10:00	0.0	0	0	0	0	0
06/13/2020 11:00	0.0	0	0	0	0	0
06/13/2020 12:00	0.0	0	0	0	0	0
06/13/2020 13:00	0.0	0	0	0	0	0
06/13/2020 14:00	0.0	0	0	0	0	0
06/13/2020 15:00	0.0	0	0	0	0	0
06/13/2020 16:00	0.0	0	0	0	0	0
06/13/2020 17:00	0.0	0	0	0	0	0
06/13/2020 18:00	0.0	0	0	0	0	0
06/13/2020 19:00	0.0	0	0	0	0	0
06/13/2020 20:00	0.0	0	0	0	0	0
06/13/2020 21:00	0.0	0	0	0	0	0
06/13/2020 22:00	0.0	0	0	0	0	0
06/13/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/14/2020 00:00	0.0	0	0	0	0	0
06/14/2020 01:00	0.0	0	0	0	0	0
06/14/2020 02:00	0.0	0	0	0	0	0
06/14/2020 03:00	0.0	0	0	0	0	0
06/14/2020 04:00	0.0	0	0	0	0	0
06/14/2020 05:00	0.0	0	0	0	0	0
06/14/2020 06:00	0.0	0	0	0	0	0
06/14/2020 07:00	0.0	0	0	0	0	0
06/14/2020 08:00	0.0	0	0	0	0	0
06/14/2020 09:00	0.0	0	0	0	0	0
06/14/2020 10:00	0.0	0	0	0	0	0
06/14/2020 11:00	0.0	0	0	0	0	0
06/14/2020 12:00	0.0	0	0	0	0	0
06/14/2020 13:00	0.0	0	0	0	0	0
06/14/2020 14:00	0.0	0	0	0	0	0
06/14/2020 15:00	0.0	0	0	0	0	0
06/14/2020 16:00	0.0	0	0	0	0	0
06/14/2020 17:00	0.0	0	0	0	0	0
06/14/2020 18:00	0.0	0	0	0	0	0
06/14/2020 19:00	0.0	0	0	0	0	0
06/14/2020 20:00	0.0	0	0	0	0	0
06/14/2020 21:00	0.0	0	0	0	0	0
06/14/2020 22:00	0.0	0	0	0	0	0
06/14/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/15/2020 00:00	0.0	0	0	0	0	0
06/15/2020 01:00	0.0	0	0	0	0	0
06/15/2020 02:00	0.0	0	0	0	0	0
06/15/2020 03:00	0.0	0	0	0	0	0
06/15/2020 04:00	0.0	0	0	0	0	0
06/15/2020 05:00	0.0	0	0	0	0	0
06/15/2020 06:00	0.0	0	0	0	0	0
06/15/2020 07:00	0.0	0	0	0	0	0
06/15/2020 08:00	0.0	0	0	0	0	0
06/15/2020 09:00	0.0	0	0	0	0	0
06/15/2020 10:00	0.0	0	0	0	0	0
06/15/2020 11:00	0.0	0	0	0	0	0
06/15/2020 12:00	0.0	0	0	0	0	0
06/15/2020 13:00	0.0	0	0	0	0	0
06/15/2020 14:00	0.0	0	0	0	0	0
06/15/2020 15:00	0.0	0	0	0	0	0
06/15/2020 16:00	0.0	0	0	0	0	0
06/15/2020 17:00	0.0	0	0	0	0	0
06/15/2020 18:00	0.0	0	0	0	0	0
06/15/2020 19:00	0.0	0	0	0	0	0
06/15/2020 20:00	0.0	0	0	0	0	0
06/15/2020 21:00	0.0	0	0	0	0	0
06/15/2020 22:00	0.0	0	0	0	0	0
06/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/16/2020 00:00	0.0	0	0	0	0	0
06/16/2020 01:00	0.0	0	0	0	0	0
06/16/2020 02:00	0.0	0	0	0	0	0
06/16/2020 03:00	0.0	0	0	0	0	0
06/16/2020 04:00	0.0	0	0	0	0	0
06/16/2020 05:00	0.0	0	0	0	0	0
06/16/2020 06:00	0.0	0	0	0	0	0
06/16/2020 07:00	0.0	0	0	0	0	0
06/16/2020 08:00	0.0	0	0	0	0	0
06/16/2020 09:00	0.0	0	0	0	0	0
06/16/2020 10:00	0.0	0	0	0	0	0
06/16/2020 11:00	0.0	0	0	0	0	0
06/16/2020 12:00	0.0	0	0	0	0	0
06/16/2020 13:00	0.0	0	0	0	0	0
06/16/2020 14:00	0.0	0	0	0	0	0
06/16/2020 15:00	0.0	0	0	0	0	0
06/16/2020 16:00	0.0	0	0	0	0	0
06/16/2020 17:00	0.0	0	0	0	0	0
06/16/2020 18:00	0.0	0	0	0	0	0
06/16/2020 19:00	0.0	0	0	0	0	0
06/16/2020 20:00	0.0	0	0	0	0	0
06/16/2020 21:00	0.0	0	0	0	0	0
06/16/2020 22:00	0.0	0	0	0	0	0
06/16/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/17/2020 00:00	0.0	0	0	0	0	0
06/17/2020 01:00	0.0	0	0	0	0	0
06/17/2020 02:00	0.0	0	0	0	0	0
06/17/2020 03:00	0.0	0	0	0	0	0
06/17/2020 04:00	0.0	0	0	0	0	0
06/17/2020 05:00	0.0	0	0	0	0	0
06/17/2020 06:00	0.0	0	0	0	0	0
06/17/2020 07:00	0.0	0	0	0	0	0
06/17/2020 08:00	0.0	0	0	0	0	0
06/17/2020 09:00	0.0	0	0	0	0	0
06/17/2020 10:00	0.0	0	0	0	0	0
06/17/2020 11:00	0.0	0	0	0	0	0
06/17/2020 12:00	147.4	1	0	0	0	0
06/17/2020 13:00	280.9	1	0	0	0	0
06/17/2020 14:00	73.2	1	0	0	0	0
06/17/2020 15:00	46.3	1	0	0	0	0
06/17/2020 16:00	0.0	0	0	0	0	1
06/17/2020 17:00	0.0	0	0	0	0	1
06/17/2020 18:00	0.0	0	0	0	0	1
06/17/2020 19:00	0.0	0	0	0	0	1
06/17/2020 20:00	0.0	0	0	0	0	1
06/17/2020 21:00	0.0	0	0	0	0	1
06/17/2020 22:00	0.0	0	0	0	0	1
06/17/2020 23:00	1.3	0	0	0	1	0
Average/Sum#:	549.1 #	4 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	280.9	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/18/2020 00:00	0.0	0	0	0	0	0
06/18/2020 01:00	0.0	0	0	0	0	0
06/18/2020 02:00	0.0	0	0	0	0	0
06/18/2020 03:00	0.0	0	0	0	0	0
06/18/2020 04:00	0.0	0	0	0	0	0
06/18/2020 05:00	0.0	0	0	0	0	0
06/18/2020 06:00	0.0	0	0	0	0	0
06/18/2020 07:00	0.0	0	0	0	0	0
06/18/2020 08:00	0.0	0	0	0	0	0
06/18/2020 09:00	0.0	0	0	0	0	0
06/18/2020 10:00	0.0	0	0	0	0	0
06/18/2020 11:00	165.6	0	1	0	0	0
06/18/2020 12:00	49.2	0	1	0	0	0
06/18/2020 13:00	0.0	0	0	0	0	1
06/18/2020 14:00	0.0	0	0	0	0	1
06/18/2020 15:00	0.0	0	0	0	0	1
06/18/2020 16:00	0.0	0	0	0	0	1
06/18/2020 17:00	0.0	0	0	0	0	1
06/18/2020 18:00	0.0	0	0	0	0	1
06/18/2020 19:00	0.0	0	0	0	0	1
06/18/2020 20:00	0.0	0	0	0	0	1
06/18/2020 21:00	0.0	0	0	0	0	1
06/18/2020 22:00	0.0	0	0	0	0	1
06/18/2020 23:00	2.0	0	0	0	1	0
Average/Sum#:	216.8 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	165.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/19/2020 00:00	0.0	0	0	0	0	0
06/19/2020 01:00	0.0	0	0	0	0	0
06/19/2020 02:00	0.0	0	0	0	0	0
06/19/2020 03:00	0.0	0	0	0	0	0
06/19/2020 04:00	0.0	0	0	0	0	0
06/19/2020 05:00	0.0	0	0	0	0	0
06/19/2020 06:00	0.0	0	0	0	0	0
06/19/2020 07:00	0.0	0	0	0	0	0
06/19/2020 08:00	0.0	0	0	0	0	0
06/19/2020 09:00	0.0	0	0	0	0	0
06/19/2020 10:00	0.0	0	0	0	0	0
06/19/2020 11:00	0.0	0	0	0	0	0
06/19/2020 12:00	0.0	0	0	0	0	0
06/19/2020 13:00	0.0	0	0	0	0	0
06/19/2020 14:00	0.0	0	0	0	0	0
06/19/2020 15:00	0.0	0	0	0	0	0
06/19/2020 16:00	0.0	0	0	0	0	0
06/19/2020 17:00	0.0	0	0	0	0	0
06/19/2020 18:00	0.0	0	0	0	0	0
06/19/2020 19:00	0.0	0	0	0	0	0
06/19/2020 20:00	0.0	0	0	0	0	0
06/19/2020 21:00	0.0	0	0	0	0	0
06/19/2020 22:00	0.0	0	0	0	0	0
06/19/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/20/2020 00:00	0.0	0	0	0	0	0
06/20/2020 01:00	0.0	0	0	0	0	0
06/20/2020 02:00	0.0	0	0	0	0	0
06/20/2020 03:00	0.0	0	0	0	0	0
06/20/2020 04:00	0.0	0	0	0	0	0
06/20/2020 05:00	0.0	0	0	0	0	0
06/20/2020 06:00	0.0	0	0	0	0	0
06/20/2020 07:00	0.0	0	0	0	0	0
06/20/2020 08:00	0.0	0	0	0	0	0
06/20/2020 09:00	0.0	0	0	0	0	0
06/20/2020 10:00	0.0	0	0	0	0	0
06/20/2020 11:00	0.0	0	0	0	0	0
06/20/2020 12:00	0.0	0	0	0	0	0
06/20/2020 13:00	0.0	0	0	0	0	0
06/20/2020 14:00	0.0	0	0	0	0	0
06/20/2020 15:00	0.0	0	0	0	0	0
06/20/2020 16:00	0.0	0	0	0	0	0
06/20/2020 17:00	0.0	0	0	0	0	0
06/20/2020 18:00	0.0	0	0	0	0	0
06/20/2020 19:00	0.0	0	0	0	0	0
06/20/2020 20:00	0.0	0	0	0	0	0
06/20/2020 21:00	0.0	0	0	0	0	0
06/20/2020 22:00	0.0	0	0	0	0	0
06/20/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/21/2020 00:00	0.0	0	0	0	0	0
06/21/2020 01:00	0.0	0	0	0	0	0
06/21/2020 02:00	0.0	0	0	0	0	0
06/21/2020 03:00	0.0	0	0	0	0	0
06/21/2020 04:00	0.0	0	0	0	0	0
06/21/2020 05:00	0.0	0	0	0	0	0
06/21/2020 06:00	0.0	0	0	0	0	0
06/21/2020 07:00	0.0	0	0	0	0	0
06/21/2020 08:00	0.0	0	0	0	0	0
06/21/2020 09:00	0.0	0	0	0	0	0
06/21/2020 10:00	0.0	0	0	0	0	0
06/21/2020 11:00	0.0	0	0	0	0	0
06/21/2020 12:00	0.0	0	0	0	0	0
06/21/2020 13:00	0.0	0	0	0	0	0
06/21/2020 14:00	0.0	0	0	0	0	0
06/21/2020 15:00	0.0	0	0	0	0	0
06/21/2020 16:00	0.0	0	0	0	0	0
06/21/2020 17:00	0.0	0	0	0	0	0
06/21/2020 18:00	0.0	0	0	0	0	0
06/21/2020 19:00	0.0	0	0	0	0	0
06/21/2020 20:00	0.0	0	0	0	0	0
06/21/2020 21:00	0.0	0	0	0	0	0
06/21/2020 22:00	0.0	0	0	0	0	0
06/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/22/2020 00:00	0.0	0	0	0	0	0
06/22/2020 01:00	0.0	0	0	0	0	0
06/22/2020 02:00	0.0	0	0	0	0	0
06/22/2020 03:00	0.0	0	0	0	0	0
06/22/2020 04:00	0.0	0	0	0	0	0
06/22/2020 05:00	0.0	0	0	0	0	0
06/22/2020 06:00	0.0	0	0	0	0	0
06/22/2020 07:00	0.0	0	0	0	0	0
06/22/2020 08:00	0.0	0	0	0	0	0
06/22/2020 09:00	204.8	1	0	0	0	0
06/22/2020 10:00	30.0	1	0	0	1	0
06/22/2020 11:00	125.3	1	0	0	0	0
06/22/2020 12:00	3.6	1	0	0	0	0
06/22/2020 13:00	0.0	0	0	0	0	1
06/22/2020 14:00	0.0	0	0	0	0	1
06/22/2020 15:00	0.0	0	0	0	0	1
06/22/2020 16:00	0.0	0	0	0	0	1
06/22/2020 17:00	0.0	0	0	0	0	1
06/22/2020 18:00	0.0	0	0	0	0	1
06/22/2020 19:00	0.0	0	0	0	0	1
06/22/2020 20:00	0.0	0	0	0	0	1
06/22/2020 21:00	0.0	0	0	0	0	1
06/22/2020 22:00	0.0	0	0	0	0	1
06/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	363.7 #	4 #	0 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	204.8	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/23/2020 00:00	1.2	0	0	0	1	0
06/23/2020 01:00	0.0	0	0	0	0	0
06/23/2020 02:00	0.0	0	0	0	0	0
06/23/2020 03:00	0.0	0	0	0	0	0
06/23/2020 04:00	0.0	0	0	0	0	0
06/23/2020 05:00	0.0	0	0	0	0	0
06/23/2020 06:00	0.0	0	0	0	0	0
06/23/2020 07:00	0.0	0	0	1	0	0
06/23/2020 08:00	20.1	0	0	1	0	0
06/23/2020 09:00	0.6	0	0	1	0	0
06/23/2020 10:00	0.0	0	0	0	0	1
06/23/2020 11:00	0.0	0	0	0	0	1
06/23/2020 12:00	0.0	0	0	0	0	1
06/23/2020 13:00	0.0	0	0	0	0	1
06/23/2020 14:00	0.0	0	0	0	0	1
06/23/2020 15:00	0.0	0	0	0	0	1
06/23/2020 16:00	0.0	0	0	0	0	1
06/23/2020 17:00	0.0	0	0	0	0	1
06/23/2020 18:00	0.0	0	0	0	0	1
06/23/2020 19:00	0.0	0	0	0	0	1
06/23/2020 20:00	0.0	0	0	0	0	1
06/23/2020 21:00	0.0	0	0	0	0	1
06/23/2020 22:00	0.0	0	0	0	0	1
06/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	21.9 #	0 #	0 #	3 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	20.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/24/2020 00:00	0.0	0	0	0	0	1
06/24/2020 01:00	0.0	0	0	0	0	1
06/24/2020 02:00	0.0	0	0	0	0	1
06/24/2020 03:00	0.0	0	0	0	0	1
06/24/2020 04:00	0.0	0	0	0	0	1
06/24/2020 05:00	0.0	0	0	0	0	1
06/24/2020 06:00	0.0	0	0	0	0	1
06/24/2020 07:00	0.0	0	0	0	0	1
06/24/2020 08:00	0.0	0	0	0	0	1
06/24/2020 09:00	0.0	0	0	0	0	1
06/24/2020 10:00	0.0	0	0	0	0	1
06/24/2020 11:00	0.0	0	0	0	0	1
06/24/2020 12:00	0.0	0	0	0	0	1
06/24/2020 13:00	0.0	0	0	0	0	1
06/24/2020 14:00	0.0	0	0	0	0	1
06/24/2020 15:00	0.0	0	0	0	0	1
06/24/2020 16:00	0.0	0	0	0	0	1
06/24/2020 17:00	0.0	0	0	0	0	1
06/24/2020 18:00	0.0	0	0	0	0	1
06/24/2020 19:00	0.0	0	0	0	0	1
06/24/2020 20:00	0.0	0	0	0	0	1
06/24/2020 21:00	0.0	0	0	0	0	1
06/24/2020 22:00	0.0	0	0	0	0	1
06/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/25/2020 00:00	0.6	0	0	0	1	0
06/25/2020 01:00	0.0	0	0	0	0	0
06/25/2020 02:00	0.0	0	0	0	0	0
06/25/2020 03:00	0.0	0	0	0	0	0
06/25/2020 04:00	0.0	0	0	0	0	0
06/25/2020 05:00	0.0	0	0	0	0	0
06/25/2020 06:00	0.0	0	0	0	0	0
06/25/2020 07:00	0.0	0	0	0	0	0
06/25/2020 08:00	0.0	0	0	0	0	0
06/25/2020 09:00	0.0	0	0	0	0	0
06/25/2020 10:00	0.0	0	0	0	0	0
06/25/2020 11:00	0.0	0	0	0	0	0
06/25/2020 12:00	3.6	0	1	0	0	0
06/25/2020 13:00	27.6	0	1	0	0	0
06/25/2020 14:00	0.0	0	0	0	0	1
06/25/2020 15:00	0.0	0	0	0	0	1
06/25/2020 16:00	0.0	0	0	0	0	1
06/25/2020 17:00	0.0	0	0	0	0	1
06/25/2020 18:00	0.0	0	0	0	0	1
06/25/2020 19:00	0.0	0	0	0	0	1
06/25/2020 20:00	0.0	0	0	0	0	1
06/25/2020 21:00	0.0	0	0	0	0	1
06/25/2020 22:00	0.6	0	0	0	1	0
06/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	32.4 #	0 #	2 #	0 #	2 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	27.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/26/2020 00:00	0.0	0	0	0	0	0
06/26/2020 01:00	0.0	0	0	0	0	0
06/26/2020 02:00	0.0	0	0	0	0	0
06/26/2020 03:00	0.0	0	0	0	0	0
06/26/2020 04:00	0.0	0	0	0	0	0
06/26/2020 05:00	0.0	0	0	0	0	0
06/26/2020 06:00	0.0	0	0	0	0	0
06/26/2020 07:00	0.0	0	0	0	0	0
06/26/2020 08:00	0.0	0	0	0	0	0
06/26/2020 09:00	0.0	0	0	0	0	0
06/26/2020 10:00	2.5	0	1	0	0	0
06/26/2020 11:00	28.5	0	1	0	0	0
06/26/2020 12:00	0.1	0	0	0	1	0
06/26/2020 13:00	0.0	0	0	0	0	0
06/26/2020 14:00	0.0	0	0	0	0	0
06/26/2020 15:00	0.0	0	0	0	0	0
06/26/2020 16:00	1.4	0	0	1	0	0
06/26/2020 17:00	2.5	0	0	1	0	0
06/26/2020 18:00	0.0	0	0	0	0	1
06/26/2020 19:00	0.0	0	0	0	0	1
06/26/2020 20:00	0.0	0	0	0	0	1
06/26/2020 21:00	0.0	0	0	0	0	1
06/26/2020 22:00	0.0	0	0	0	0	1
06/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	35.0 #	0 #	2 #	2 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	28.5	0	1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/27/2020 00:00	0.3	0	0	0	1	0
06/27/2020 01:00	0.0	0	0	0	0	0
06/27/2020 02:00	0.0	0	0	0	0	0
06/27/2020 03:00	0.0	0	0	0	0	0
06/27/2020 04:00	0.0	0	0	0	0	0
06/27/2020 05:00	0.0	0	0	0	0	0
06/27/2020 06:00	0.0	0	0	0	0	0
06/27/2020 07:00	0.0	0	0	0	0	0
06/27/2020 08:00	0.0	0	0	0	0	0
06/27/2020 09:00	0.0	0	0	0	0	0
06/27/2020 10:00	0.0	0	0	0	0	0
06/27/2020 11:00	0.0	0	0	0	0	0
06/27/2020 12:00	0.0	0	0	0	0	0
06/27/2020 13:00	0.0	0	0	0	0	0
06/27/2020 14:00	0.0	0	0	0	0	0
06/27/2020 15:00	0.0	0	0	0	0	0
06/27/2020 16:00	0.0	0	0	0	0	0
06/27/2020 17:00	0.0	0	0	0	0	0
06/27/2020 18:00	0.0	0	0	0	0	0
06/27/2020 19:00	0.0	0	0	0	0	0
06/27/2020 20:00	0.0	0	0	0	0	0
06/27/2020 21:00	0.0	0	0	0	0	0
06/27/2020 22:00	0.0	0	0	0	0	0
06/27/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.3 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.3	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/28/2020 00:00	0.0	0	0	0	0	0
06/28/2020 01:00	0.0	0	0	0	0	0
06/28/2020 02:00	0.0	0	0	0	0	0
06/28/2020 03:00	0.0	0	0	0	0	0
06/28/2020 04:00	0.0	0	0	0	0	0
06/28/2020 05:00	0.0	0	0	0	0	0
06/28/2020 06:00	0.0	0	0	0	0	0
06/28/2020 07:00	0.0	0	0	0	0	0
06/28/2020 08:00	0.0	0	0	0	0	0
06/28/2020 09:00	0.0	0	0	0	0	0
06/28/2020 10:00	0.0	0	0	0	0	0
06/28/2020 11:00	0.0	0	0	0	0	0
06/28/2020 12:00	0.0	0	0	0	0	0
06/28/2020 13:00	0.0	0	0	0	0	0
06/28/2020 14:00	0.0	0	0	0	0	0
06/28/2020 15:00	0.0	0	0	0	0	0
06/28/2020 16:00	0.0	0	0	0	0	0
06/28/2020 17:00	0.0	0	0	0	0	0
06/28/2020 18:00	0.0	0	0	0	0	0
06/28/2020 19:00	0.0	0	0	0	0	0
06/28/2020 20:00	0.0	0	0	0	0	0
06/28/2020 21:00	0.0	0	0	0	0	0
06/28/2020 22:00	0.0	0	0	0	0	0
06/28/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/29/2020 00:00	0.0	0	0	0	0	0
06/29/2020 01:00	0.0	0	0	0	0	0
06/29/2020 02:00	0.0	0	0	0	0	0
06/29/2020 03:00	0.0	0	0	0	0	0
06/29/2020 04:00	0.0	0	0	0	0	0
06/29/2020 05:00	0.0	0	0	0	0	0
06/29/2020 06:00	0.0	0	0	0	0	0
06/29/2020 07:00	0.0	0	0	0	0	0
06/29/2020 08:00	0.0	0	0	0	0	0
06/29/2020 09:00	0.0	0	0	0	0	0
06/29/2020 10:00	0.0	0	0	0	0	0
06/29/2020 11:00	0.0	0	0	0	0	0
06/29/2020 12:00	0.0	0	0	0	0	0
06/29/2020 13:00	0.0	0	0	0	0	0
06/29/2020 14:00	0.0	0	0	0	0	0
06/29/2020 15:00	0.0	0	0	0	0	0
06/29/2020 16:00	0.0	0	0	0	0	0
06/29/2020 17:00	0.0	0	0	0	0	0
06/29/2020 18:00	0.0	0	0	0	0	0
06/29/2020 19:00	0.0	0	0	0	0	0
06/29/2020 20:00	0.0	0	0	0	0	0
06/29/2020 21:00	0.0	0	0	0	0	0
06/29/2020 22:00	0.0	0	0	0	0	0
06/29/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
06/30/2020 00:00	0.0	0	0	0	0	0
06/30/2020 01:00	0.0	0	0	0	0	0
06/30/2020 02:00	0.0	0	0	0	0	0
06/30/2020 03:00	0.0	0	0	0	0	0
06/30/2020 04:00	0.0	0	0	0	0	0
06/30/2020 05:00	0.0	0	0	0	0	0
06/30/2020 06:00	0.0	0	0	0	0	0
06/30/2020 07:00	0.0	0	0	0	0	0
06/30/2020 08:00	0.0	0	0	0	0	0
06/30/2020 09:00	0.0	0	0	0	0	0
06/30/2020 10:00	0.0	0	0	0	0	0
06/30/2020 11:00	0.0	0	0	0	0	0
06/30/2020 12:00	0.0	0	0	0	0	0
06/30/2020 13:00	0.0	0	0	0	0	0
06/30/2020 14:00	48.0	1	0	0	0	0
06/30/2020 15:00	68.6	1	0	0	0	0
06/30/2020 16:00	0.0	0	0	0	0	1
06/30/2020 17:00	0.0	0	0	0	0	1
06/30/2020 18:00	0.0	0	0	0	0	1
06/30/2020 19:00	0.0	0	0	0	0	1
06/30/2020 20:00	0.0	0	0	0	0	1
06/30/2020 21:00	0.0	0	0	0	0	1
06/30/2020 22:00	0.6	0	0	0	1	0
06/30/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	117.2 #	2 #	0 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	68.6	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Pound Per Hr Per Event Report

CT1 - CO LbPerHr

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:20 **Location:** Maxwell, CA

Tag Name: CT1_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 671.97 Hours

Non-Operating Time: 1,512.03 Hours Report Time: 2,184.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
04/01/2020 03:43 04/01/2020 04:54 Warm Start - Gas	72	74.9	373.6		
04/02/2020 21:22 04/02/2020 21:27 Shut Down - Gas	6	0.8	483.5		
04/04/2020 01:04 04/04/2020 02:38 Warm Start - Gas	95	90.3	373.6		
04/17/2020 23:23 04/17/2020 23:28 Shut Down - Gas	6	1.0	483.5		
04/20/2020 02:03 04/20/2020 03:42 Warm Start - Gas	100	120.4	373.6		
04/20/2020 23:08 04/20/2020 23:13 Shut Down - Gas	6	0.8	483.5		
04/22/2020 07:37 04/22/2020 09:16 Warm Start - Gas	100	111.8	373.6		
04/22/2020 11:02 04/22/2020 11:07 Shut Down - Gas	6	1.2	483.5		
04/24/2020 14:18 04/24/2020 16:04 Warm Start - Gas	107	0.0 SI	373.6		
04/24/2020 22:07 04/24/2020 22:13 Shut Down - Gas	7	1.2	483.5		
04/28/2020 13:20 04/28/2020 15:01 Cold Start - Gas	102	98.3	429.6		
04/28/2020 21:54 04/28/2020 21:59 Shut Down - Gas	6	0.8	483.5		
05/26/2020 10:08 05/26/2020 10:29 Cold Start - Gas	22	414.2	429.6		

Pound Per Hr Per Event Report

CT1 - CO LbPerHr

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:20 **Location:** Maxwell, CA

Tag Name: CT1_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 671.97 Hours

Non-Operating Time: 1,512.03 Hours Report Time: 2,184.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
05/26/2020 10:30 05/26/2020 10:35 Shut Down - Gas	6	482.0	483.5		
05/26/2020 11:53 05/26/2020 15:12 Cold Start - Gas	200	425.2	429.6		
05/26/2020 15:14 05/26/2020 15:19 Shut Down - Gas	6	20.6	483.5		
05/28/2020 12:38 05/28/2020 15:23 Cold Start - Gas	166	0.0 SI	429.6		
05/29/2020 01:38 05/29/2020 01:43 Shut Down - Gas	6	20.2	483.5		
06/01/2020 12:48 06/01/2020 13:37 Cold Start - Gas	50	389.2	429.6		
06/01/2020 13:38 06/01/2020 13:43 Shut Down - Gas	6	16.4	483.5		
06/01/2020 14:22 06/01/2020 14:57 Cold Start - Gas	36	55.1	429.6		
06/04/2020 00:23 06/04/2020 00:28 Shut Down - Gas	6	19.1	483.5		
06/04/2020 06:41 06/04/2020 07:54 Hot Start - Gas	74	151.4	370.3		
06/05/2020 00:26 06/05/2020 00:31 Shut Down - Gas	6	20.9	483.5		
06/08/2020 15:29 06/08/2020 17:00 Cold Start - Gas	92	400.6	429.6		
06/08/2020 17:02 06/08/2020 17:07 Shut Down - Gas	6	17.4	483.5		
06/08/2020 17:45 06/08/2020 18:24 Hot Start - Gas	40	60.0	370.3		

Pound Per Hr Per Event Report

CT1 - CO LbPerHr

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:20 **Location:** Maxwell, CA
Tag Name: CT1_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 671.97 Hours
Non-Operating Time: 1,512.03 Hours Report Time: 2,184.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
06/08/2020 23:54 06/08/2020 23:58 Shut Down - Gas	5	17.5	483.5		
06/09/2020 12:36 06/09/2020 13:16 Warm Start - Gas	41	83.8	373.6		
06/09/2020 13:18 06/09/2020 13:23 Shut Down - Gas	6	16.4	483.5		
06/09/2020 14:09 06/09/2020 15:02 Warm Start - Gas	54	88.3	373.6		
06/09/2020 23:22 06/09/2020 23:27 Shut Down - Gas	6	20.3	483.5		
06/10/2020 10:18 06/10/2020 12:14 Warm Start - Gas	117	358.8	373.6		
06/11/2020 23:23 06/11/2020 23:28 Shut Down - Gas	6	19.7	483.5		
06/17/2020 12:38 06/17/2020 15:52 Cold Start - Gas	195	575.4 *	429.6		
06/17/2020 23:24 06/17/2020 23:29 Shut Down - Gas	6	18.2	483.5		
06/18/2020 11:33 06/18/2020 12:40 Warm Start - Gas	68	109.1	373.6		
06/18/2020 23:09 06/18/2020 23:14 Shut Down - Gas	6	18.7	483.5		
06/22/2020 09:24 06/22/2020 10:01 Cold Start - Gas	38	401.2	429.6		
06/22/2020 10:02 06/22/2020 10:07 Shut Down - Gas	6	21.1	483.5		
06/22/2020 10:49 06/22/2020 12:13 Cold Start - Gas	85	212.0	429.6		

Pound Per Hr Per Event Report

CT1 - CO LbPerHr

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:20 **Location:** Maxwell, CA

Tag Name: CT1_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 671.97 Hours

Non-Operating Time: 1,512.03 Hours Report Time: 2,184.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
06/23/2020 00:23 06/23/2020 00:28 Shut Down - Gas	6	25.0	483.5		
06/23/2020 07:52 06/23/2020 09:06 Hot Start - Gas	75	87.0	370.3		
06/25/2020 00:31 06/25/2020 00:36 Shut Down - Gas	6	1.3	483.5		
06/25/2020 12:47 06/25/2020 13:40 Warm Start - Gas	54	39.3	373.6		
06/25/2020 22:38 06/25/2020 22:43 Shut Down - Gas	6	1.9	483.5		
06/26/2020 10:48 06/26/2020 11:46 Warm Start - Gas	59	46.4	373.6		
06/26/2020 12:01 06/26/2020 12:07 Shut Down - Gas	7	2.4	483.5		
06/26/2020 16:22 06/26/2020 17:16 Hot Start - Gas	55	32.5	370.3		
06/27/2020 00:39 06/27/2020 00:44 Shut Down - Gas	6	1.2	483.5		
06/30/2020 14:28 06/30/2020 15:59 Cold Start - Gas	92	92.7	429.6		
06/30/2020 22:23 06/30/2020 22:28 Shut Down - Gas	6	1.4	483.5		

Total Duration of Excess Emission	**195**	**Minute(s)**
Time of Excess Emission as a percentage of operating time	**0.48**	**%**
Time in compliance as percentage of operating time	**99.52**	**%**

Pound Per Hr Per Event Report

CT1 - CO LbPerHr

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:20 **Location:** Maxwell, CA
Tag Name: CT1_CO_LbPerHr_1M
SI = SampleInvalid, * = Excess Emission

Total Operating Time: 671.97 Hours
Non-Operating Time: 1,512.03 Hours Report Time: 2,184.00 Hours

Event Invalid Information

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
04/24/2020 14:18 04/24/2020 16:04	107		
05/28/2020 12:38 05/28/2020 15:23	166		

Total CMS Downtime	273	Minute(s)
Total Downtime as a percentage of operating time	0.68	%
Total Availability as a percentage of operating time	99.32	%

Pound Per Hr Per Event Report

CT1 - CO LbPerHr

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:20 **Location:** Maxwell, CA

Tag Name: CT1_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 671.97 Hours

Non-Operating Time: 1,512.03 Hours Report Time: 2,184.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	195
2. Total Duration of Excess Emission in Minute(s)	195
3. Time of Excess Emission as a percentage of operating time	0.48
4. Time in compliance as percentage of operating time	99.52

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	273
2. Total CMS Downtime in Minute(s)	273
3. Total Downtime as a percentage of operating time	0.68
4. Total Availability as a percentage of operating time	99.32

Pound Per Event Report

CT1 - NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:22 **Location:** Maxwell, CA
Tag Name: CT1_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 671.97 Hours
Non-Operating Time: 1,512.03 Hours Report Time: 2,184.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
04/01/2020 03:43 04/01/2020 04:54 Warm Start - Gas	72	103.50	456.20		
04/02/2020 21:22 04/02/2020 21:27 Shut Down - Gas	6	0.35	115.00		
04/04/2020 01:04 04/04/2020 02:38 Warm Start - Gas	95	114.28	456.20		
04/17/2020 23:23 04/17/2020 23:28 Shut Down - Gas	6	0.48	115.00		
04/20/2020 02:03 04/20/2020 03:42 Warm Start - Gas	100	136.78	456.20		
04/20/2020 23:08 04/20/2020 23:13 Shut Down - Gas	6	0.29	115.00		
04/22/2020 07:37 04/22/2020 09:16 Warm Start - Gas	100	114.74	456.20		
04/22/2020 11:02 04/22/2020 11:07 Shut Down - Gas	6	0.33	115.00		
04/24/2020 14:18 04/24/2020 16:04 Warm Start - Gas	107	0.00 SI	456.20		
04/24/2020 22:07 04/24/2020 22:13 Shut Down - Gas	7	0.64	115.00		
04/28/2020 13:20 04/28/2020 15:01 Cold Start - Gas	102	144.33	779.10		
04/28/2020 21:54 04/28/2020 21:59 Shut Down - Gas	6	0.22	115.00		
05/26/2020 10:08 05/26/2020 10:29 Cold Start - Gas	22	98.48	779.10		

Pound Per Event Report

CT1 - NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:22 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 671.97 Hours

Non-Operating Time: 1,512.03 Hours Report Time: 2,184.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
05/26/2020 10:30 05/26/2020 10:35 Shut Down - Gas	6	37.33	115.00		
05/26/2020 11:53 05/26/2020 15:12 Cold Start - Gas	200	520.56	779.10		
05/26/2020 15:14 05/26/2020 15:19 Shut Down - Gas	6	3.73	115.00		
05/28/2020 12:38 05/28/2020 15:23 Cold Start - Gas	166	0.00 SI	779.10		
05/29/2020 01:38 05/29/2020 01:43 Shut Down - Gas	6	1.42	115.00		
06/01/2020 12:48 06/01/2020 13:37 Cold Start - Gas	50	327.89	779.10		
06/01/2020 13:38 06/01/2020 13:43 Shut Down - Gas	6	17.77	115.00		
06/01/2020 14:22 06/01/2020 14:57 Cold Start - Gas	36	31.42	779.10		
06/04/2020 00:23 06/04/2020 00:28 Shut Down - Gas	6	1.17	115.00		
06/04/2020 06:41 06/04/2020 07:54 Hot Start - Gas	74	98.73	259.90		
06/05/2020 00:26 06/05/2020 00:31 Shut Down - Gas	6	1.67	115.00		
06/08/2020 15:29 06/08/2020 17:00 Cold Start - Gas	92	536.77	779.10		
06/08/2020 17:02 06/08/2020 17:07 Shut Down - Gas	6	6.22	115.00		
06/08/2020 17:45 06/08/2020 18:24 Hot Start - Gas	40	62.06	259.90		

Pound Per Event Report

CT1 - NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:22 **Location:** Maxwell, CA
Tag Name: CT1_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 671.97 Hours
Non-Operating Time: 1,512.03 Hours Report Time: 2,184.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
06/08/2020 23:54 06/08/2020 23:58 Shut Down - Gas	5	1.82	115.00		
06/09/2020 12:36 06/09/2020 13:16 Warm Start - Gas	41	177.53	456.20		
06/09/2020 13:18 06/09/2020 13:23 Shut Down - Gas	6	2.92	115.00		
06/09/2020 14:09 06/09/2020 15:02 Warm Start - Gas	54	32.26	456.20		
06/09/2020 23:22 06/09/2020 23:27 Shut Down - Gas	6	2.47	115.00		
06/10/2020 10:18 06/10/2020 12:14 Warm Start - Gas	117	243.32	456.20		
06/11/2020 23:23 06/11/2020 23:28 Shut Down - Gas	6	1.06	115.00		
06/17/2020 12:38 06/17/2020 15:52 Cold Start - Gas	195	514.98	779.10		
06/17/2020 23:24 06/17/2020 23:29 Shut Down - Gas	6	1.22	115.00		
06/18/2020 11:33 06/18/2020 12:40 Warm Start - Gas	68	218.14	456.20		
06/18/2020 23:09 06/18/2020 23:14 Shut Down - Gas	6	1.29	115.00		
06/22/2020 09:24 06/22/2020 10:01 Cold Start - Gas	38	186.14	779.10		
06/22/2020 10:02 06/22/2020 10:07 Shut Down - Gas	6	25.97	115.00		
06/22/2020 10:49 06/22/2020 12:13 Cold Start - Gas	85	176.62	779.10		

Pound Per Event Report

CT1 - NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:22 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 671.97 Hours

Non-Operating Time: 1,512.03 Hours Report Time: 2,184.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
06/23/2020 00:23 06/23/2020 00:28 Shut Down - Gas	6	1.43	115.00		
06/23/2020 07:52 06/23/2020 09:06 Hot Start - Gas	75	23.87	259.90		
06/25/2020 00:31 06/25/2020 00:36 Shut Down - Gas	6	0.11	115.00		
06/25/2020 12:47 06/25/2020 13:40 Warm Start - Gas	54	37.35	456.20		
06/25/2020 22:38 06/25/2020 22:43 Shut Down - Gas	6	0.21	115.00		
06/26/2020 10:48 06/26/2020 11:46 Warm Start - Gas	59	34.78	456.20		
06/26/2020 12:01 06/26/2020 12:07 Shut Down - Gas	7	0.13	115.00		
06/26/2020 16:22 06/26/2020 17:16 Hot Start - Gas	55	6.76	259.90		
06/27/2020 00:39 06/27/2020 00:44 Shut Down - Gas	6	0.16	115.00		
06/30/2020 14:28 06/30/2020 15:59 Cold Start - Gas	92	113.90	779.10		
06/30/2020 22:23 06/30/2020 22:28 Shut Down - Gas	6	0.24	115.00		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT1 - NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:22 **Location:** Maxwell, CA
Tag Name: CT1_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 671.97 Hours
Non-Operating Time: 1,512.03 Hours Report Time: 2,184.00 Hours

Event Invalid Information

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
04/24/2020 14:18 04/24/2020 16:04	107		
05/28/2020 12:38 05/28/2020 15:23	166		

Total CMS Downtime	273	Minute(s)
Total Downtime as a percentage of operating time	0.68	%
Total Availability as a percentage of operating time	99.32	%

Pound Per Event Report

CT1 - NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:22 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 671.97 Hours

Non-Operating Time: 1,512.03 Hours Report Time: 2,184.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	273
2. Total CMS Downtime in Minute(s)	273
3. Total Downtime as a percentage of operating time	0.68
4. Total Availability as a percentage of operating time	99.32

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:23 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 876.73 Hours

Non-Operating Time: 1,307.27 Hours Report Time: 2,184.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
04/02/2020 21:22 04/02/2020 21:27 Shut Down - Gas	6	1.7		
04/03/2020 20:17 04/03/2020 22:50 Warm Start - Gas	154	244.8		
04/17/2020 23:23 04/17/2020 23:28 Shut Down - Gas	6	2.0		
04/19/2020 17:18 04/19/2020 19:51 Warm Start - Gas	154	246.3		
04/20/2020 23:08 04/20/2020 23:13 Shut Down - Gas	6	1.5		
04/22/2020 04:19 04/22/2020 06:51 Warm Start - Gas	153	240.9		
04/22/2020 13:05 04/22/2020 13:10 Shut Down - Gas	6	1.6		
04/22/2020 18:47 04/22/2020 19:51 Hot Start - Gas	65	114.5		
04/23/2020 02:04 04/23/2020 02:09 Shut Down - Gas	6	1.5		
04/24/2020 09:18 04/24/2020 11:50 Warm Start - Gas	153	248.2		
04/24/2020 22:30 04/24/2020 22:35 Shut Down - Gas	6	1.7		
04/27/2020 13:20 04/27/2020 15:43 Warm Start - Gas	144	255.3		
04/28/2020 21:54 04/28/2020 21:59 Shut Down - Gas	6	1.5		

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:23 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 876.73 Hours

Non-Operating Time: 1,307.27 Hours Report Time: 2,184.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
04/29/2020 13:19 04/29/2020 15:18 Warm Start - Gas	120	220.7		
04/30/2020 07:04 04/30/2020 07:09 Shut Down - Gas	6	1.7		
05/11/2020 16:30 05/11/2020 16:32 Shut Down - Gas	3	0.0		
05/27/2020 08:40 05/27/2020 11:54 Cold Start - Gas	195	310.9		
05/27/2020 14:11 05/27/2020 14:16 Shut Down - Gas	6	1.4		
05/28/2020 18:50 05/28/2020 20:16 Warm Start - Gas	87	149.7		
05/29/2020 01:38 05/29/2020 01:43 Shut Down - Gas	6	1.4		
05/29/2020 20:28 05/29/2020 22:43 Warm Start - Gas	136	252.5		
05/30/2020 08:04 05/30/2020 08:09 Shut Down - Gas	6	2.3		
05/30/2020 13:53 05/30/2020 15:06 Hot Start - Gas	74	136.9		
05/31/2020 06:04 05/31/2020 06:09 Shut Down - Gas	6	2.2		
05/31/2020 14:18 05/31/2020 15:40 Warm Start - Gas	83	140.2		
06/04/2020 00:22 06/04/2020 00:28 Shut Down - Gas	7	2.5		
06/04/2020 10:34 06/04/2020 11:54 Warm Start - Gas	81	150.0		

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:23 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 876.73 Hours

Non-Operating Time: 1,307.27 Hours Report Time: 2,184.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
06/05/2020 00:26 06/05/2020 00:31 Shut Down - Gas	6	1.6		
06/08/2020 09:34 06/08/2020 12:48 Cold Start - Gas	195	315.7		
06/08/2020 23:54 06/08/2020 23:59 Shut Down - Gas	6	1.5		
06/09/2020 08:28 06/09/2020 10:50 Warm Start - Gas	143	238.3		
06/09/2020 23:23 06/09/2020 23:28 Shut Down - Gas	6	1.3		
06/10/2020 07:38 06/10/2020 08:42 Warm Start - Gas	65	122.5		
06/11/2020 23:23 06/11/2020 23:28 Shut Down - Gas	6	1.5		
06/14/2020 12:18 06/14/2020 14:58 Warm Start - Gas	161	293.9		
06/14/2020 23:05 06/14/2020 23:10 Shut Down - Gas	6	1.6		
06/17/2020 09:08 06/17/2020 11:41 Warm Start - Gas	154	241.0		
06/17/2020 23:24 06/17/2020 23:29 Shut Down - Gas	6	1.4		
06/18/2020 07:38 06/18/2020 08:51 Warm Start - Gas	74	128.9		
06/18/2020 23:09 06/18/2020 23:14 Shut Down - Gas	6	1.5		
06/20/2020 20:03 06/20/2020 22:42 Warm Start - Gas	160	252.3		

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:23 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 876.73 Hours

Non-Operating Time: 1,307.27 Hours Report Time: 2,184.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
06/23/2020 00:23 06/23/2020 00:29 Shut Down - Gas	7	2.5		
06/23/2020 12:43 06/23/2020 14:10 Warm Start - Gas	88	160.3		
06/25/2020 00:31 06/25/2020 00:36 Shut Down - Gas	6	1.4		
06/25/2020 08:47 06/25/2020 09:45 Warm Start - Gas	59	106.2		
06/25/2020 22:38 06/25/2020 22:43 Shut Down - Gas	6	2.2		
06/26/2020 05:47 06/26/2020 06:56 Hot Start - Gas	70	123.6		
06/27/2020 00:39 06/27/2020 00:44 Shut Down - Gas	6	2.0		
06/30/2020 08:33 06/30/2020 11:52 Cold Start - Gas	200	323.4		
06/30/2020 22:23 06/30/2020 22:28 Shut Down - Gas	6	2.2		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:23 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 876.73 Hours

Non-Operating Time: 1,307.27 Hours Report Time: 2,184.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:23 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 876.73 Hours

Non-Operating Time: 1,307.27 Hours Report Time: 2,184.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/01/2020 00:00	0.0	0	0	0	0	1
04/01/2020 01:00	0.0	0	0	0	0	1
04/01/2020 02:00	0.0	0	0	0	0	1
04/01/2020 03:00	0.0	0	0	0	0	1
04/01/2020 04:00	0.0	0	0	0	0	1
04/01/2020 05:00	0.0	0	0	0	0	1
04/01/2020 06:00	0.0	0	0	0	0	1
04/01/2020 07:00	0.0	0	0	0	0	1
04/01/2020 08:00	0.0	0	0	0	0	1
04/01/2020 09:00	0.0	0	0	0	0	1
04/01/2020 10:00	0.0	0	0	0	0	1
04/01/2020 11:00	0.0	0	0	0	0	1
04/01/2020 12:00	0.0	0	0	0	0	1
04/01/2020 13:00	0.0	0	0	0	0	1
04/01/2020 14:00	0.0	0	0	0	0	1
04/01/2020 15:00	0.0	0	0	0	0	1
04/01/2020 16:00	0.0	0	0	0	0	1
04/01/2020 17:00	0.0	0	0	0	0	1
04/01/2020 18:00	0.0	0	0	0	0	1
04/01/2020 19:00	0.0	0	0	0	0	1
04/01/2020 20:00	0.0	0	0	0	0	1
04/01/2020 21:00	0.0	0	0	0	0	1
04/01/2020 22:00	0.0	0	0	0	0	1
04/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/02/2020 00:00	0.0	0	0	0	0	1
04/02/2020 01:00	0.0	0	0	0	0	1
04/02/2020 02:00	0.0	0	0	0	0	1
04/02/2020 03:00	0.0	0	0	0	0	1
04/02/2020 04:00	0.0	0	0	0	0	1
04/02/2020 05:00	0.0	0	0	0	0	1
04/02/2020 06:00	0.0	0	0	0	0	1
04/02/2020 07:00	0.0	0	0	0	0	1
04/02/2020 08:00	0.0	0	0	0	0	1
04/02/2020 09:00	0.0	0	0	0	0	1
04/02/2020 10:00	0.0	0	0	0	0	1
04/02/2020 11:00	0.0	0	0	0	0	1
04/02/2020 12:00	0.0	0	0	0	0	1
04/02/2020 13:00	0.0	0	0	0	0	1
04/02/2020 14:00	0.0	0	0	0	0	1
04/02/2020 15:00	0.0	0	0	0	0	1
04/02/2020 16:00	0.0	0	0	0	0	1
04/02/2020 17:00	0.0	0	0	0	0	1
04/02/2020 18:00	0.0	0	0	0	0	1
04/02/2020 19:00	0.0	0	0	0	0	1
04/02/2020 20:00	0.0	0	0	0	0	1
04/02/2020 21:00	1.3	0	0	0	1	0
04/02/2020 22:00	0.0	0	0	0	0	0
04/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.3 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/03/2020 00:00	0.0	0	0	0	0	0
04/03/2020 01:00	0.0	0	0	0	0	0
04/03/2020 02:00	0.0	0	0	0	0	0
04/03/2020 03:00	0.0	0	0	0	0	0
04/03/2020 04:00	0.0	0	0	0	0	0
04/03/2020 05:00	0.0	0	0	0	0	0
04/03/2020 06:00	0.0	0	0	0	0	0
04/03/2020 07:00	0.0	0	0	0	0	0
04/03/2020 08:00	0.0	0	0	0	0	0
04/03/2020 09:00	0.0	0	0	0	0	0
04/03/2020 10:00	0.0	0	0	0	0	0
04/03/2020 11:00	0.0	0	0	0	0	0
04/03/2020 12:00	0.0	0	0	0	0	0
04/03/2020 13:00	0.0	0	0	0	0	0
04/03/2020 14:00	0.0	0	0	0	0	0
04/03/2020 15:00	0.0	0	0	0	0	0
04/03/2020 16:00	0.0	0	0	0	0	0
04/03/2020 17:00	0.0	0	0	0	0	0
04/03/2020 18:00	0.0	0	0	0	0	0
04/03/2020 19:00	0.0	0	0	0	0	0
04/03/2020 20:00	49.3	0	1	0	0	0
04/03/2020 21:00	16.5	0	1	0	0	0
04/03/2020 22:00	30.0	0	1	0	0	0
04/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	95.8 #	0 #	3 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	49.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/04/2020 00:00	0.0	0	0	0	0	1
04/04/2020 01:00	0.0	0	0	0	0	1
04/04/2020 02:00	0.0	0	0	0	0	1
04/04/2020 03:00	0.0	0	0	0	0	1
04/04/2020 04:00	0.0	0	0	0	0	1
04/04/2020 05:00	0.0	0	0	0	0	1
04/04/2020 06:00	0.0	0	0	0	0	1
04/04/2020 07:00	0.0	0	0	0	0	1
04/04/2020 08:00	0.0	0	0	0	0	1
04/04/2020 09:00	0.0	0	0	0	0	1
04/04/2020 10:00	0.0	0	0	0	0	1
04/04/2020 11:00	0.0	0	0	0	0	1
04/04/2020 12:00	0.0	0	0	0	0	1
04/04/2020 13:00	0.0	0	0	0	0	1
04/04/2020 14:00	0.0	0	0	0	0	1
04/04/2020 15:00	0.0	0	0	0	0	1
04/04/2020 16:00	0.0	0	0	0	0	1
04/04/2020 17:00	0.0	0	0	0	0	1
04/04/2020 18:00	0.0	0	0	0	0	1
04/04/2020 19:00	0.0	0	0	0	0	1
04/04/2020 20:00	0.0	0	0	0	0	1
04/04/2020 21:00	0.0	0	0	0	0	1
04/04/2020 22:00	0.0	0	0	0	0	1
04/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/05/2020 00:00	0.0	0	0	0	0	1
04/05/2020 01:00	0.0	0	0	0	0	1
04/05/2020 02:00	0.0	0	0	0	0	1
04/05/2020 03:00	0.0	0	0	0	0	1
04/05/2020 04:00	0.0	0	0	0	0	1
04/05/2020 05:00	0.0	0	0	0	0	1
04/05/2020 06:00	0.0	0	0	0	0	1
04/05/2020 07:00	0.0	0	0	0	0	1
04/05/2020 08:00	0.0	0	0	0	0	1
04/05/2020 09:00	0.0	0	0	0	0	1
04/05/2020 10:00	0.0	0	0	0	0	1
04/05/2020 11:00	0.0	0	0	0	0	1
04/05/2020 12:00	0.0	0	0	0	0	1
04/05/2020 13:00	0.0	0	0	0	0	1
04/05/2020 14:00	0.0	0	0	0	0	1
04/05/2020 15:00	0.0	0	0	0	0	1
04/05/2020 16:00	0.0	0	0	0	0	1
04/05/2020 17:00	0.0	0	0	0	0	1
04/05/2020 18:00	0.0	0	0	0	0	1
04/05/2020 19:00	0.0	0	0	0	0	1
04/05/2020 20:00	0.0	0	0	0	0	1
04/05/2020 21:00	0.0	0	0	0	0	1
04/05/2020 22:00	0.0	0	0	0	0	1
04/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/06/2020 00:00	0.0	0	0	0	0	1
04/06/2020 01:00	0.0	0	0	0	0	1
04/06/2020 02:00	0.0	0	0	0	0	1
04/06/2020 03:00	0.0	0	0	0	0	1
04/06/2020 04:00	0.0	0	0	0	0	1
04/06/2020 05:00	0.0	0	0	0	0	1
04/06/2020 06:00	0.0	0	0	0	0	1
04/06/2020 07:00	0.0	0	0	0	0	1
04/06/2020 08:00	0.0	0	0	0	0	1
04/06/2020 09:00	0.0	0	0	0	0	1
04/06/2020 10:00	0.0	0	0	0	0	1
04/06/2020 11:00	0.0	0	0	0	0	1
04/06/2020 12:00	0.0	0	0	0	0	1
04/06/2020 13:00	0.0	0	0	0	0	1
04/06/2020 14:00	0.0	0	0	0	0	1
04/06/2020 15:00	0.0	0	0	0	0	1
04/06/2020 16:00	0.0	0	0	0	0	1
04/06/2020 17:00	0.0	0	0	0	0	1
04/06/2020 18:00	0.0	0	0	0	0	1
04/06/2020 19:00	0.0	0	0	0	0	1
04/06/2020 20:00	0.0	0	0	0	0	1
04/06/2020 21:00	0.0	0	0	0	0	1
04/06/2020 22:00	0.0	0	0	0	0	1
04/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/07/2020 00:00	0.0	0	0	0	0	1
04/07/2020 01:00	0.0	0	0	0	0	1
04/07/2020 02:00	0.0	0	0	0	0	1
04/07/2020 03:00	0.0	0	0	0	0	1
04/07/2020 04:00	0.0	0	0	0	0	1
04/07/2020 05:00	0.0	0	0	0	0	1
04/07/2020 06:00	0.0	0	0	0	0	1
04/07/2020 07:00	0.0	0	0	0	0	1
04/07/2020 08:00	0.0	0	0	0	0	1
04/07/2020 09:00	0.0	0	0	0	0	1
04/07/2020 10:00	0.0	0	0	0	0	1
04/07/2020 11:00	0.0	0	0	0	0	1
04/07/2020 12:00	0.0	0	0	0	0	1
04/07/2020 13:00	0.0	0	0	0	0	1
04/07/2020 14:00	0.0	0	0	0	0	1
04/07/2020 15:00	0.0	0	0	0	0	1
04/07/2020 16:00	0.0	0	0	0	0	1
04/07/2020 17:00	0.0	0	0	0	0	1
04/07/2020 18:00	0.0	0	0	0	0	1
04/07/2020 19:00	0.0	0	0	0	0	1
04/07/2020 20:00	0.0	0	0	0	0	1
04/07/2020 21:00	0.0	0	0	0	0	1
04/07/2020 22:00	0.0	0	0	0	0	1
04/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/08/2020 00:00	0.0	0	0	0	0	1
04/08/2020 01:00	0.0	0	0	0	0	1
04/08/2020 02:00	0.0	0	0	0	0	1
04/08/2020 03:00	0.0	0	0	0	0	1
04/08/2020 04:00	0.0	0	0	0	0	1
04/08/2020 05:00	0.0	0	0	0	0	1
04/08/2020 06:00	0.0	0	0	0	0	1
04/08/2020 07:00	0.0	0	0	0	0	1
04/08/2020 08:00	0.0	0	0	0	0	1
04/08/2020 09:00	0.0	0	0	0	0	1
04/08/2020 10:00	0.0	0	0	0	0	1
04/08/2020 11:00	0.0	0	0	0	0	1
04/08/2020 12:00	0.0	0	0	0	0	1
04/08/2020 13:00	0.0	0	0	0	0	1
04/08/2020 14:00	0.0	0	0	0	0	1
04/08/2020 15:00	0.0	0	0	0	0	1
04/08/2020 16:00	0.0	0	0	0	0	1
04/08/2020 17:00	0.0	0	0	0	0	1
04/08/2020 18:00	0.0	0	0	0	0	1
04/08/2020 19:00	0.0	0	0	0	0	1
04/08/2020 20:00	0.0	0	0	0	0	1
04/08/2020 21:00	0.0	0	0	0	0	1
04/08/2020 22:00	0.0	0	0	0	0	1
04/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/09/2020 00:00	0.0	0	0	0	0	1
04/09/2020 01:00	0.0	0	0	0	0	1
04/09/2020 02:00	0.0	0	0	0	0	1
04/09/2020 03:00	0.0	0	0	0	0	1
04/09/2020 04:00	0.0	0	0	0	0	1
04/09/2020 05:00	0.0	0	0	0	0	1
04/09/2020 06:00	0.0	0	0	0	0	1
04/09/2020 07:00	0.0	0	0	0	0	1
04/09/2020 08:00	0.0	0	0	0	0	1
04/09/2020 09:00	0.0	0	0	0	0	1
04/09/2020 10:00	0.0	0	0	0	0	1
04/09/2020 11:00	0.0	0	0	0	0	1
04/09/2020 12:00	0.0	0	0	0	0	1
04/09/2020 13:00	0.0	0	0	0	0	1
04/09/2020 14:00	0.0	0	0	0	0	1
04/09/2020 15:00	0.0	0	0	0	0	1
04/09/2020 16:00	0.0	0	0	0	0	1
04/09/2020 17:00	0.0	0	0	0	0	1
04/09/2020 18:00	0.0	0	0	0	0	1
04/09/2020 19:00	0.0	0	0	0	0	1
04/09/2020 20:00	0.0	0	0	0	0	1
04/09/2020 21:00	0.0	0	0	0	0	1
04/09/2020 22:00	0.0	0	0	0	0	1
04/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/10/2020 00:00	0.0	0	0	0	0	1
04/10/2020 01:00	0.0	0	0	0	0	1
04/10/2020 02:00	0.0	0	0	0	0	1
04/10/2020 03:00	0.0	0	0	0	0	1
04/10/2020 04:00	0.0	0	0	0	0	1
04/10/2020 05:00	0.0	0	0	0	0	1
04/10/2020 06:00	0.0	0	0	0	0	1
04/10/2020 07:00	0.0	0	0	0	0	1
04/10/2020 08:00	0.0	0	0	0	0	1
04/10/2020 09:00	0.0	0	0	0	0	1
04/10/2020 10:00	0.0	0	0	0	0	1
04/10/2020 11:00	0.0	0	0	0	0	1
04/10/2020 12:00	0.0	0	0	0	0	1
04/10/2020 13:00	0.0	0	0	0	0	1
04/10/2020 14:00	0.0	0	0	0	0	1
04/10/2020 15:00	0.0	0	0	0	0	1
04/10/2020 16:00	0.0	0	0	0	0	1
04/10/2020 17:00	0.0	0	0	0	0	1
04/10/2020 18:00	0.0	0	0	0	0	1
04/10/2020 19:00	0.0	0	0	0	0	1
04/10/2020 20:00	0.0	0	0	0	0	1
04/10/2020 21:00	0.0	0	0	0	0	1
04/10/2020 22:00	0.0	0	0	0	0	1
04/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/11/2020 00:00	0.0	0	0	0	0	1
04/11/2020 01:00	0.0	0	0	0	0	1
04/11/2020 02:00	0.0	0	0	0	0	1
04/11/2020 03:00	0.0	0	0	0	0	1
04/11/2020 04:00	0.0	0	0	0	0	1
04/11/2020 05:00	0.0	0	0	0	0	1
04/11/2020 06:00	0.0	0	0	0	0	1
04/11/2020 07:00	0.0	0	0	0	0	1
04/11/2020 08:00	0.0	0	0	0	0	1
04/11/2020 09:00	0.0	0	0	0	0	1
04/11/2020 10:00	0.0	0	0	0	0	1
04/11/2020 11:00	0.0	0	0	0	0	1
04/11/2020 12:00	0.0	0	0	0	0	1
04/11/2020 13:00	0.0	0	0	0	0	1
04/11/2020 14:00	0.0	0	0	0	0	1
04/11/2020 15:00	0.0	0	0	0	0	1
04/11/2020 16:00	0.0	0	0	0	0	1
04/11/2020 17:00	0.0	0	0	0	0	1
04/11/2020 18:00	0.0	0	0	0	0	1
04/11/2020 19:00	0.0	0	0	0	0	1
04/11/2020 20:00	0.0	0	0	0	0	1
04/11/2020 21:00	0.0	0	0	0	0	1
04/11/2020 22:00	0.0	0	0	0	0	1
04/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/12/2020 00:00	0.0	0	0	0	0	1
04/12/2020 01:00	0.0	0	0	0	0	1
04/12/2020 02:00	0.0	0	0	0	0	1
04/12/2020 03:00	0.0	0	0	0	0	1
04/12/2020 04:00	0.0	0	0	0	0	1
04/12/2020 05:00	0.0	0	0	0	0	1
04/12/2020 06:00	0.0	0	0	0	0	1
04/12/2020 07:00	0.0	0	0	0	0	1
04/12/2020 08:00	0.0	0	0	0	0	1
04/12/2020 09:00	0.0	0	0	0	0	1
04/12/2020 10:00	0.0	0	0	0	0	1
04/12/2020 11:00	0.0	0	0	0	0	1
04/12/2020 12:00	0.0	0	0	0	0	1
04/12/2020 13:00	0.0	0	0	0	0	1
04/12/2020 14:00	0.0	0	0	0	0	1
04/12/2020 15:00	0.0	0	0	0	0	1
04/12/2020 16:00	0.0	0	0	0	0	1
04/12/2020 17:00	0.0	0	0	0	0	1
04/12/2020 18:00	0.0	0	0	0	0	1
04/12/2020 19:00	0.0	0	0	0	0	1
04/12/2020 20:00	0.0	0	0	0	0	1
04/12/2020 21:00	0.0	0	0	0	0	1
04/12/2020 22:00	0.0	0	0	0	0	1
04/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/13/2020 00:00	0.0	0	0	0	0	1
04/13/2020 01:00	0.0	0	0	0	0	1
04/13/2020 02:00	0.0	0	0	0	0	1
04/13/2020 03:00	0.0	0	0	0	0	1
04/13/2020 04:00	0.0	0	0	0	0	1
04/13/2020 05:00	0.0	0	0	0	0	1
04/13/2020 06:00	0.0	0	0	0	0	1
04/13/2020 07:00	0.0	0	0	0	0	1
04/13/2020 08:00	0.0	0	0	0	0	1
04/13/2020 09:00	0.0	0	0	0	0	1
04/13/2020 10:00	0.0	0	0	0	0	1
04/13/2020 11:00	0.0	0	0	0	0	1
04/13/2020 12:00	0.0	0	0	0	0	1
04/13/2020 13:00	0.0	0	0	0	0	1
04/13/2020 14:00	0.0	0	0	0	0	1
04/13/2020 15:00	0.0	0	0	0	0	1
04/13/2020 16:00	0.0	0	0	0	0	1
04/13/2020 17:00	0.0	0	0	0	0	1
04/13/2020 18:00	0.0	0	0	0	0	1
04/13/2020 19:00	0.0	0	0	0	0	1
04/13/2020 20:00	0.0	0	0	0	0	1
04/13/2020 21:00	0.0	0	0	0	0	1
04/13/2020 22:00	0.0	0	0	0	0	1
04/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/14/2020 00:00	0.0	0	0	0	0	1
04/14/2020 01:00	0.0	0	0	0	0	1
04/14/2020 02:00	0.0	0	0	0	0	1
04/14/2020 03:00	0.0	0	0	0	0	1
04/14/2020 04:00	0.0	0	0	0	0	1
04/14/2020 05:00	0.0	0	0	0	0	1
04/14/2020 06:00	0.0	0	0	0	0	1
04/14/2020 07:00	0.0	0	0	0	0	1
04/14/2020 08:00	0.0	0	0	0	0	1
04/14/2020 09:00	0.0	0	0	0	0	1
04/14/2020 10:00	0.0	0	0	0	0	1
04/14/2020 11:00	0.0	0	0	0	0	1
04/14/2020 12:00	0.0	0	0	0	0	1
04/14/2020 13:00	0.0	0	0	0	0	1
04/14/2020 14:00	0.0	0	0	0	0	1
04/14/2020 15:00	0.0	0	0	0	0	1
04/14/2020 16:00	0.0	0	0	0	0	1
04/14/2020 17:00	0.0	0	0	0	0	1
04/14/2020 18:00	0.0	0	0	0	0	1
04/14/2020 19:00	0.0	0	0	0	0	1
04/14/2020 20:00	0.0	0	0	0	0	1
04/14/2020 21:00	0.0	0	0	0	0	1
04/14/2020 22:00	0.0	0	0	0	0	1
04/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/15/2020 00:00	0.0	0	0	0	0	1
04/15/2020 01:00	0.0	0	0	0	0	1
04/15/2020 02:00	0.0	0	0	0	0	1
04/15/2020 03:00	0.0	0	0	0	0	1
04/15/2020 04:00	0.0	0	0	0	0	1
04/15/2020 05:00	0.0	0	0	0	0	1
04/15/2020 06:00	0.0	0	0	0	0	1
04/15/2020 07:00	0.0	0	0	0	0	1
04/15/2020 08:00	0.0	0	0	0	0	1
04/15/2020 09:00	0.0	0	0	0	0	1
04/15/2020 10:00	0.0	0	0	0	0	1
04/15/2020 11:00	0.0	0	0	0	0	1
04/15/2020 12:00	0.0	0	0	0	0	1
04/15/2020 13:00	0.0	0	0	0	0	1
04/15/2020 14:00	0.0	0	0	0	0	1
04/15/2020 15:00	0.0	0	0	0	0	1
04/15/2020 16:00	0.0	0	0	0	0	1
04/15/2020 17:00	0.0	0	0	0	0	1
04/15/2020 18:00	0.0	0	0	0	0	1
04/15/2020 19:00	0.0	0	0	0	0	1
04/15/2020 20:00	0.0	0	0	0	0	1
04/15/2020 21:00	0.0	0	0	0	0	1
04/15/2020 22:00	0.0	0	0	0	0	1
04/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/16/2020 00:00	0.0	0	0	0	0	1
04/16/2020 01:00	0.0	0	0	0	0	1
04/16/2020 02:00	0.0	0	0	0	0	1
04/16/2020 03:00	0.0	0	0	0	0	1
04/16/2020 04:00	0.0	0	0	0	0	1
04/16/2020 05:00	0.0	0	0	0	0	1
04/16/2020 06:00	0.0	0	0	0	0	1
04/16/2020 07:00	0.0	0	0	0	0	1
04/16/2020 08:00	0.0	0	0	0	0	1
04/16/2020 09:00	0.0	0	0	0	0	1
04/16/2020 10:00	0.0	0	0	0	0	1
04/16/2020 11:00	0.0	0	0	0	0	1
04/16/2020 12:00	0.0	0	0	0	0	1
04/16/2020 13:00	0.0	0	0	0	0	1
04/16/2020 14:00	0.0	0	0	0	0	1
04/16/2020 15:00	0.0	0	0	0	0	1
04/16/2020 16:00	0.0	0	0	0	0	1
04/16/2020 17:00	0.0	0	0	0	0	1
04/16/2020 18:00	0.0	0	0	0	0	1
04/16/2020 19:00	0.0	0	0	0	0	1
04/16/2020 20:00	0.0	0	0	0	0	1
04/16/2020 21:00	0.0	0	0	0	0	1
04/16/2020 22:00	0.0	0	0	0	0	1
04/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/17/2020 00:00	0.0	0	0	0	0	1
04/17/2020 01:00	0.0	0	0	0	0	1
04/17/2020 02:00	0.0	0	0	0	0	1
04/17/2020 03:00	0.0	0	0	0	0	1
04/17/2020 04:00	0.0	0	0	0	0	1
04/17/2020 05:00	0.0	0	0	0	0	1
04/17/2020 06:00	0.0	0	0	0	0	1
04/17/2020 07:00	0.0	0	0	0	0	1
04/17/2020 08:00	0.0	0	0	0	0	1
04/17/2020 09:00	0.0	0	0	0	0	1
04/17/2020 10:00	0.0	0	0	0	0	1
04/17/2020 11:00	0.0	0	0	0	0	1
04/17/2020 12:00	0.0	0	0	0	0	1
04/17/2020 13:00	0.0	0	0	0	0	1
04/17/2020 14:00	0.0	0	0	0	0	1
04/17/2020 15:00	0.0	0	0	0	0	1
04/17/2020 16:00	0.0	0	0	0	0	1
04/17/2020 17:00	0.0	0	0	0	0	1
04/17/2020 18:00	0.0	0	0	0	0	1
04/17/2020 19:00	0.0	0	0	0	0	1
04/17/2020 20:00	0.0	0	0	0	0	1
04/17/2020 21:00	0.0	0	0	0	0	1
04/17/2020 22:00	0.0	0	0	0	0	1
04/17/2020 23:00	1.2	0	0	0	1	0
Average/Sum#:	1.2 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/18/2020 00:00	0.0	0	0	0	0	0
04/18/2020 01:00	0.0	0	0	0	0	0
04/18/2020 02:00	0.0	0	0	0	0	0
04/18/2020 03:00	0.0	0	0	0	0	0
04/18/2020 04:00	0.0	0	0	0	0	0
04/18/2020 05:00	0.0	0	0	0	0	0
04/18/2020 06:00	0.0	0	0	0	0	0
04/18/2020 07:00	0.0	0	0	0	0	0
04/18/2020 08:00	0.0	0	0	0	0	0
04/18/2020 09:00	0.0	0	0	0	0	0
04/18/2020 10:00	0.0	0	0	0	0	0
04/18/2020 11:00	0.0	0	0	0	0	0
04/18/2020 12:00	0.0	0	0	0	0	0
04/18/2020 13:00	0.0	0	0	0	0	0
04/18/2020 14:00	0.0	0	0	0	0	0
04/18/2020 15:00	0.0	0	0	0	0	0
04/18/2020 16:00	0.0	0	0	0	0	0
04/18/2020 17:00	0.0	0	0	0	0	0
04/18/2020 18:00	0.0	0	0	0	0	0
04/18/2020 19:00	0.0	0	0	0	0	0
04/18/2020 20:00	0.0	0	0	0	0	0
04/18/2020 21:00	0.0	0	0	0	0	0
04/18/2020 22:00	0.0	0	0	0	0	0
04/18/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/19/2020 00:00	0.0	0	0	0	0	0
04/19/2020 01:00	0.0	0	0	0	0	0
04/19/2020 02:00	0.0	0	0	0	0	0
04/19/2020 03:00	0.0	0	0	0	0	0
04/19/2020 04:00	0.0	0	0	0	0	0
04/19/2020 05:00	0.0	0	0	0	0	0
04/19/2020 06:00	0.0	0	0	0	0	0
04/19/2020 07:00	0.0	0	0	0	0	0
04/19/2020 08:00	0.0	0	0	0	0	0
04/19/2020 09:00	0.0	0	0	0	0	0
04/19/2020 10:00	0.0	0	0	0	0	0
04/19/2020 11:00	0.0	0	0	0	0	0
04/19/2020 12:00	0.0	0	0	0	0	0
04/19/2020 13:00	0.0	0	0	0	0	0
04/19/2020 14:00	0.0	0	0	0	0	0
04/19/2020 15:00	0.0	0	0	0	0	0
04/19/2020 16:00	0.0	0	0	0	0	0
04/19/2020 17:00	77.0	0	1	0	0	0
04/19/2020 18:00	18.8	0	1	0	0	0
04/19/2020 19:00	29.9	0	1	0	0	0
04/19/2020 20:00	0.0	0	0	0	0	1
04/19/2020 21:00	0.0	0	0	0	0	1
04/19/2020 22:00	0.0	0	0	0	0	1
04/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	125.7 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	77.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/20/2020 00:00	0.0	0	0	0	0	1
04/20/2020 01:00	0.0	0	0	0	0	1
04/20/2020 02:00	0.0	0	0	0	0	1
04/20/2020 03:00	0.0	0	0	0	0	1
04/20/2020 04:00	0.0	0	0	0	0	1
04/20/2020 05:00	0.0	0	0	0	0	1
04/20/2020 06:00	0.0	0	0	0	0	1
04/20/2020 07:00	0.0	0	0	0	0	1
04/20/2020 08:00	0.0	0	0	0	0	1
04/20/2020 09:00	0.0	0	0	0	0	1
04/20/2020 10:00	0.0	0	0	0	0	1
04/20/2020 11:00	0.0	0	0	0	0	1
04/20/2020 12:00	0.0	0	0	0	0	1
04/20/2020 13:00	0.0	0	0	0	0	1
04/20/2020 14:00	0.0	0	0	0	0	1
04/20/2020 15:00	0.0	0	0	0	0	1
04/20/2020 16:00	0.0	0	0	0	0	1
04/20/2020 17:00	0.0	0	0	0	0	1
04/20/2020 18:00	0.0	0	0	0	0	1
04/20/2020 19:00	0.0	0	0	0	0	1
04/20/2020 20:00	0.0	0	0	0	0	1
04/20/2020 21:00	0.0	0	0	0	0	1
04/20/2020 22:00	0.0	0	0	0	0	1
04/20/2020 23:00	1.8	0	0	0	1	0
Average/Sum#:	1.8 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/21/2020 00:00	0.0	0	0	0	0	0
04/21/2020 01:00	0.0	0	0	0	0	0
04/21/2020 02:00	0.0	0	0	0	0	0
04/21/2020 03:00	0.0	0	0	0	0	0
04/21/2020 04:00	0.0	0	0	0	0	0
04/21/2020 05:00	0.0	0	0	0	0	0
04/21/2020 06:00	0.0	0	0	0	0	0
04/21/2020 07:00	0.0	0	0	0	0	0
04/21/2020 08:00	0.0	0	0	0	0	0
04/21/2020 09:00	0.0	0	0	0	0	0
04/21/2020 10:00	0.0	0	0	0	0	0
04/21/2020 11:00	0.0	0	0	0	0	0
04/21/2020 12:00	0.0	0	0	0	0	0
04/21/2020 13:00	0.0	0	0	0	0	0
04/21/2020 14:00	0.0	0	0	0	0	0
04/21/2020 15:00	0.0	0	0	0	0	0
04/21/2020 16:00	0.0	0	0	0	0	0
04/21/2020 17:00	0.0	0	0	0	0	0
04/21/2020 18:00	0.0	0	0	0	0	0
04/21/2020 19:00	0.0	0	0	0	0	0
04/21/2020 20:00	0.0	0	0	0	0	0
04/21/2020 21:00	0.0	0	0	0	0	0
04/21/2020 22:00	0.0	0	0	0	0	0
04/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/22/2020 00:00	0.0	0	0	0	0	0
04/22/2020 01:00	0.0	0	0	0	0	0
04/22/2020 02:00	0.0	0	0	0	0	0
04/22/2020 03:00	0.0	0	0	0	0	0
04/22/2020 04:00	66.4	0	1	0	0	0
04/22/2020 05:00	23.0	0	1	0	0	0
04/22/2020 06:00	27.7	0	1	0	0	0
04/22/2020 07:00	0.0	0	0	0	0	1
04/22/2020 08:00	0.0	0	0	0	0	1
04/22/2020 09:00	0.0	0	0	0	0	1
04/22/2020 10:00	0.0	0	0	0	0	1
04/22/2020 11:00	0.0	0	0	0	0	1
04/22/2020 12:00	0.0	0	0	0	0	1
04/22/2020 13:00	1.8	0	0	0	1	0
04/22/2020 14:00	0.0	0	0	0	0	0
04/22/2020 15:00	0.0	0	0	0	0	0
04/22/2020 16:00	0.0	0	0	0	0	0
04/22/2020 17:00	0.0	0	0	0	0	0
04/22/2020 18:00	2.7	0	0	1	0	0
04/22/2020 19:00	32.1	0	0	1	0	0
04/22/2020 20:00	0.0	0	0	0	0	1
04/22/2020 21:00	0.0	0	0	0	0	1
04/22/2020 22:00	0.0	0	0	0	0	1
04/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	153.7 #	0 #	3 #	2 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	66.4	0	1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/23/2020 00:00	0.0	0	0	0	0	1
04/23/2020 01:00	0.0	0	0	0	0	1
04/23/2020 02:00	1.6	0	0	0	1	0
04/23/2020 03:00	0.0	0	0	0	0	0
04/23/2020 04:00	0.0	0	0	0	0	0
04/23/2020 05:00	0.0	0	0	0	0	0
04/23/2020 06:00	0.0	0	0	0	0	0
04/23/2020 07:00	0.0	0	0	0	0	0
04/23/2020 08:00	0.0	0	0	0	0	0
04/23/2020 09:00	0.0	0	0	0	0	0
04/23/2020 10:00	0.0	0	0	0	0	0
04/23/2020 11:00	0.0	0	0	0	0	0
04/23/2020 12:00	0.0	0	0	0	0	0
04/23/2020 13:00	0.0	0	0	0	0	0
04/23/2020 14:00	0.0	0	0	0	0	0
04/23/2020 15:00	0.0	0	0	0	0	0
04/23/2020 16:00	0.0	0	0	0	0	0
04/23/2020 17:00	0.0	0	0	0	0	0
04/23/2020 18:00	0.0	0	0	0	0	0
04/23/2020 19:00	0.0	0	0	0	0	0
04/23/2020 20:00	0.0	0	0	0	0	0
04/23/2020 21:00	0.0	0	0	0	0	0
04/23/2020 22:00	0.0	0	0	0	0	0
04/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.6 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/24/2020 00:00	0.0	0	0	0	0	0
04/24/2020 01:00	0.0	0	0	0	0	0
04/24/2020 02:00	0.0	0	0	0	0	0
04/24/2020 03:00	0.0	0	0	0	0	0
04/24/2020 04:00	0.0	0	0	0	0	0
04/24/2020 05:00	0.0	0	0	0	0	0
04/24/2020 06:00	0.0	0	0	0	0	0
04/24/2020 07:00	0.0	0	0	0	0	0
04/24/2020 08:00	0.0	0	0	0	0	0
04/24/2020 09:00	63.1	0	1	0	0	0
04/24/2020 10:00	17.4	0	1	0	0	0
04/24/2020 11:00	29.8	0	1	0	0	0
04/24/2020 12:00	0.0	0	0	0	0	1
04/24/2020 13:00	0.0	0	0	0	0	1
04/24/2020 14:00	0.0	0	0	0	0	1
04/24/2020 15:00	0.0	0	0	0	0	1
04/24/2020 16:00	0.0	0	0	0	0	1
04/24/2020 17:00	0.0	0	0	0	0	1
04/24/2020 18:00	0.0	0	0	0	0	1
04/24/2020 19:00	0.0	0	0	0	0	1
04/24/2020 20:00	0.0	0	0	0	0	1
04/24/2020 21:00	0.0	0	0	0	0	1
04/24/2020 22:00	0.7	0	0	0	1	0
04/24/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	111.0 #	0 #	3 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	63.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/25/2020 00:00	0.0	0	0	0	0	0
04/25/2020 01:00	0.0	0	0	0	0	0
04/25/2020 02:00	0.0	0	0	0	0	0
04/25/2020 03:00	0.0	0	0	0	0	0
04/25/2020 04:00	0.0	0	0	0	0	0
04/25/2020 05:00	0.0	0	0	0	0	0
04/25/2020 06:00	0.0	0	0	0	0	0
04/25/2020 07:00	0.0	0	0	0	0	0
04/25/2020 08:00	0.0	0	0	0	0	0
04/25/2020 09:00	0.0	0	0	0	0	0
04/25/2020 10:00	0.0	0	0	0	0	0
04/25/2020 11:00	0.0	0	0	0	0	0
04/25/2020 12:00	0.0	0	0	0	0	0
04/25/2020 13:00	0.0	0	0	0	0	0
04/25/2020 14:00	0.0	0	0	0	0	0
04/25/2020 15:00	0.0	0	0	0	0	0
04/25/2020 16:00	0.0	0	0	0	0	0
04/25/2020 17:00	0.0	0	0	0	0	0
04/25/2020 18:00	0.0	0	0	0	0	0
04/25/2020 19:00	0.0	0	0	0	0	0
04/25/2020 20:00	0.0	0	0	0	0	0
04/25/2020 21:00	0.0	0	0	0	0	0
04/25/2020 22:00	0.0	0	0	0	0	0
04/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/26/2020 00:00	0.0	0	0	0	0	0
04/26/2020 01:00	0.0	0	0	0	0	0
04/26/2020 02:00	0.0	0	0	0	0	0
04/26/2020 03:00	0.0	0	0	0	0	0
04/26/2020 04:00	0.0	0	0	0	0	0
04/26/2020 05:00	0.0	0	0	0	0	0
04/26/2020 06:00	0.0	0	0	0	0	0
04/26/2020 07:00	0.0	0	0	0	0	0
04/26/2020 08:00	0.0	0	0	0	0	0
04/26/2020 09:00	0.0	0	0	0	0	0
04/26/2020 10:00	0.0	0	0	0	0	0
04/26/2020 11:00	0.0	0	0	0	0	0
04/26/2020 12:00	0.0	0	0	0	0	0
04/26/2020 13:00	0.0	0	0	0	0	0
04/26/2020 14:00	0.0	0	0	0	0	0
04/26/2020 15:00	0.0	0	0	0	0	0
04/26/2020 16:00	0.0	0	0	0	0	0
04/26/2020 17:00	0.0	0	0	0	0	0
04/26/2020 18:00	0.0	0	0	0	0	0
04/26/2020 19:00	0.0	0	0	0	0	0
04/26/2020 20:00	0.0	0	0	0	0	0
04/26/2020 21:00	0.0	0	0	0	0	0
04/26/2020 22:00	0.0	0	0	0	0	0
04/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/27/2020 00:00	0.0	0	0	0	0	0
04/27/2020 01:00	0.0	0	0	0	0	0
04/27/2020 02:00	0.0	0	0	0	0	0
04/27/2020 03:00	0.0	0	0	0	0	0
04/27/2020 04:00	0.0	0	0	0	0	0
04/27/2020 05:00	0.0	0	0	0	0	0
04/27/2020 06:00	0.0	0	0	0	0	0
04/27/2020 07:00	0.0	0	0	0	0	0
04/27/2020 08:00	0.0	0	0	0	0	0
04/27/2020 09:00	0.0	0	0	0	0	0
04/27/2020 10:00	0.0	0	0	0	0	0
04/27/2020 11:00	0.0	0	0	0	0	0
04/27/2020 12:00	0.0	0	0	0	0	0
04/27/2020 13:00	64.8	0	1	0	0	0
04/27/2020 14:00	33.2	0	1	0	0	0
04/27/2020 15:00	24.2	0	1	0	0	0
04/27/2020 16:00	0.0	0	0	0	0	1
04/27/2020 17:00	0.0	0	0	0	0	1
04/27/2020 18:00	0.0	0	0	0	0	1
04/27/2020 19:00	0.0	0	0	0	0	1
04/27/2020 20:00	0.0	0	0	0	0	1
04/27/2020 21:00	0.0	0	0	0	0	1
04/27/2020 22:00	0.0	0	0	0	0	1
04/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	122.2 #	0 #	3 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	64.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/28/2020 00:00	0.0	0	0	0	0	1
04/28/2020 01:00	0.0	0	0	0	0	1
04/28/2020 02:00	0.0	0	0	0	0	1
04/28/2020 03:00	0.0	0	0	0	0	1
04/28/2020 04:00	0.0	0	0	0	0	1
04/28/2020 05:00	0.0	0	0	0	0	1
04/28/2020 06:00	0.0	0	0	0	0	1
04/28/2020 07:00	0.0	0	0	0	0	1
04/28/2020 08:00	0.0	0	0	0	0	1
04/28/2020 09:00	0.0	0	0	0	0	1
04/28/2020 10:00	0.0	0	0	0	0	1
04/28/2020 11:00	0.0	0	0	0	0	1
04/28/2020 12:00	0.0	0	0	0	0	1
04/28/2020 13:00	0.0	0	0	0	0	1
04/28/2020 14:00	0.0	0	0	0	0	1
04/28/2020 15:00	0.0	0	0	0	0	1
04/28/2020 16:00	0.0	0	0	0	0	1
04/28/2020 17:00	0.0	0	0	0	0	1
04/28/2020 18:00	0.0	0	0	0	0	1
04/28/2020 19:00	0.0	0	0	0	0	1
04/28/2020 20:00	0.0	0	0	0	0	1
04/28/2020 21:00	0.8	0	0	0	1	0
04/28/2020 22:00	0.0	0	0	0	0	0
04/28/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/29/2020 00:00	0.0	0	0	0	0	0
04/29/2020 01:00	0.0	0	0	0	0	0
04/29/2020 02:00	0.0	0	0	0	0	0
04/29/2020 03:00	0.0	0	0	0	0	0
04/29/2020 04:00	0.0	0	0	0	0	0
04/29/2020 05:00	0.0	0	0	0	0	0
04/29/2020 06:00	0.0	0	0	0	0	0
04/29/2020 07:00	0.0	0	0	0	0	0
04/29/2020 08:00	0.0	0	0	0	0	0
04/29/2020 09:00	0.0	0	0	0	0	0
04/29/2020 10:00	0.0	0	0	0	0	0
04/29/2020 11:00	0.0	0	0	0	0	0
04/29/2020 12:00	0.0	0	0	0	0	0
04/29/2020 13:00	43.2	0	1	0	0	0
04/29/2020 14:00	51.4	0	1	0	0	0
04/29/2020 15:00	5.0	0	1	0	0	0
04/29/2020 16:00	0.0	0	0	0	0	1
04/29/2020 17:00	0.0	0	0	0	0	1
04/29/2020 18:00	0.0	0	0	0	0	1
04/29/2020 19:00	0.0	0	0	0	0	1
04/29/2020 20:00	0.0	0	0	0	0	1
04/29/2020 21:00	0.0	0	0	0	0	1
04/29/2020 22:00	0.0	0	0	0	0	1
04/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	99.6 #	0 #	3 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	51.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/30/2020 00:00	0.0	0	0	0	0	1
04/30/2020 01:00	0.0	0	0	0	0	1
04/30/2020 02:00	0.0	0	0	0	0	1
04/30/2020 03:00	0.0	0	0	0	0	1
04/30/2020 04:00	0.0	0	0	0	0	1
04/30/2020 05:00	0.0	0	0	0	0	1
04/30/2020 06:00	0.0	0	0	0	0	1
04/30/2020 07:00	2.3	0	0	0	1	0
04/30/2020 08:00	0.0	0	0	0	0	0
04/30/2020 09:00	0.0	0	0	0	0	0
04/30/2020 10:00	0.0	0	0	0	0	0
04/30/2020 11:00	0.0	0	0	0	0	0
04/30/2020 12:00	0.0	0	0	0	0	0
04/30/2020 13:00	0.0	0	0	0	0	0
04/30/2020 14:00	0.0	0	0	0	0	0
04/30/2020 15:00	0.0	0	0	0	0	0
04/30/2020 16:00	0.0	0	0	0	0	0
04/30/2020 17:00	0.0	0	0	0	0	0
04/30/2020 18:00	0.0	0	0	0	0	0
04/30/2020 19:00	0.0	0	0	0	0	0
04/30/2020 20:00	0.0	0	0	0	0	0
04/30/2020 21:00	0.0	0	0	0	0	0
04/30/2020 22:00	0.0	0	0	0	0	0
04/30/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.3 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/01/2020 00:00	0.0	0	0	0	0	0
05/01/2020 01:00	0.0	0	0	0	0	0
05/01/2020 02:00	0.0	0	0	0	0	0
05/01/2020 03:00	0.0	0	0	0	0	0
05/01/2020 04:00	0.0	0	0	0	0	0
05/01/2020 05:00	0.0	0	0	0	0	0
05/01/2020 06:00	0.0	0	0	0	0	0
05/01/2020 07:00	0.0	0	0	0	0	0
05/01/2020 08:00	0.0	0	0	0	0	0
05/01/2020 09:00	0.0	0	0	0	0	0
05/01/2020 10:00	0.0	0	0	0	0	0
05/01/2020 11:00	0.0	0	0	0	0	0
05/01/2020 12:00	0.0	0	0	0	0	0
05/01/2020 13:00	0.0	0	0	0	0	0
05/01/2020 14:00	0.0	0	0	0	0	0
05/01/2020 15:00	0.0	0	0	0	0	0
05/01/2020 16:00	0.0	0	0	0	0	0
05/01/2020 17:00	0.0	0	0	0	0	0
05/01/2020 18:00	0.0	0	0	0	0	0
05/01/2020 19:00	0.0	0	0	0	0	0
05/01/2020 20:00	0.0	0	0	0	0	0
05/01/2020 21:00	0.0	0	0	0	0	0
05/01/2020 22:00	0.0	0	0	0	0	0
05/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/02/2020 00:00	0.0	0	0	0	0	0
05/02/2020 01:00	0.0	0	0	0	0	0
05/02/2020 02:00	0.0	0	0	0	0	0
05/02/2020 03:00	0.0	0	0	0	0	0
05/02/2020 04:00	0.0	0	0	0	0	0
05/02/2020 05:00	0.0	0	0	0	0	0
05/02/2020 06:00	0.0	0	0	0	0	0
05/02/2020 07:00	0.0	0	0	0	0	0
05/02/2020 08:00	0.0	0	0	0	0	0
05/02/2020 09:00	0.0	0	0	0	0	0
05/02/2020 10:00	0.0	0	0	0	0	0
05/02/2020 11:00	0.0	0	0	0	0	0
05/02/2020 12:00	0.0	0	0	0	0	0
05/02/2020 13:00	0.0	0	0	0	0	0
05/02/2020 14:00	0.0	0	0	0	0	0
05/02/2020 15:00	0.0	0	0	0	0	0
05/02/2020 16:00	0.0	0	0	0	0	0
05/02/2020 17:00	0.0	0	0	0	0	0
05/02/2020 18:00	0.0	0	0	0	0	0
05/02/2020 19:00	0.0	0	0	0	0	0
05/02/2020 20:00	0.0	0	0	0	0	0
05/02/2020 21:00	0.0	0	0	0	0	0
05/02/2020 22:00	0.0	0	0	0	0	0
05/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/03/2020 00:00	0.0	0	0	0	0	0
05/03/2020 01:00	0.0	0	0	0	0	0
05/03/2020 02:00	0.0	0	0	0	0	0
05/03/2020 03:00	0.0	0	0	0	0	0
05/03/2020 04:00	0.0	0	0	0	0	0
05/03/2020 05:00	0.0	0	0	0	0	0
05/03/2020 06:00	0.0	0	0	0	0	0
05/03/2020 07:00	0.0	0	0	0	0	0
05/03/2020 08:00	0.0	0	0	0	0	0
05/03/2020 09:00	0.0	0	0	0	0	0
05/03/2020 10:00	0.0	0	0	0	0	0
05/03/2020 11:00	0.0	0	0	0	0	0
05/03/2020 12:00	0.0	0	0	0	0	0
05/03/2020 13:00	0.0	0	0	0	0	0
05/03/2020 14:00	0.0	0	0	0	0	0
05/03/2020 15:00	0.0	0	0	0	0	0
05/03/2020 16:00	0.0	0	0	0	0	0
05/03/2020 17:00	0.0	0	0	0	0	0
05/03/2020 18:00	0.0	0	0	0	0	0
05/03/2020 19:00	0.0	0	0	0	0	0
05/03/2020 20:00	0.0	0	0	0	0	0
05/03/2020 21:00	0.0	0	0	0	0	0
05/03/2020 22:00	0.0	0	0	0	0	0
05/03/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/04/2020 00:00	0.0	0	0	0	0	0
05/04/2020 01:00	0.0	0	0	0	0	0
05/04/2020 02:00	0.0	0	0	0	0	0
05/04/2020 03:00	0.0	0	0	0	0	0
05/04/2020 04:00	0.0	0	0	0	0	0
05/04/2020 05:00	0.0	0	0	0	0	0
05/04/2020 06:00	0.0	0	0	0	0	0
05/04/2020 07:00	0.0	0	0	0	0	0
05/04/2020 08:00	0.0	0	0	0	0	0
05/04/2020 09:00	0.0	0	0	0	0	0
05/04/2020 10:00	0.0	0	0	0	0	0
05/04/2020 11:00	0.0	0	0	0	0	0
05/04/2020 12:00	0.0	0	0	0	0	0
05/04/2020 13:00	0.0	0	0	0	0	0
05/04/2020 14:00	0.0	0	0	0	0	0
05/04/2020 15:00	0.0	0	0	0	0	0
05/04/2020 16:00	0.0	0	0	0	0	0
05/04/2020 17:00	0.0	0	0	0	0	0
05/04/2020 18:00	0.0	0	0	0	0	0
05/04/2020 19:00	0.0	0	0	0	0	0
05/04/2020 20:00	0.0	0	0	0	0	0
05/04/2020 21:00	0.0	0	0	0	0	0
05/04/2020 22:00	0.0	0	0	0	0	0
05/04/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/05/2020 00:00	0.0	0	0	0	0	0
05/05/2020 01:00	0.0	0	0	0	0	0
05/05/2020 02:00	0.0	0	0	0	0	0
05/05/2020 03:00	0.0	0	0	0	0	0
05/05/2020 04:00	0.0	0	0	0	0	0
05/05/2020 05:00	0.0	0	0	0	0	0
05/05/2020 06:00	0.0	0	0	0	0	0
05/05/2020 07:00	0.0	0	0	0	0	0
05/05/2020 08:00	0.0	0	0	0	0	0
05/05/2020 09:00	0.0	0	0	0	0	0
05/05/2020 10:00	0.0	0	0	0	0	0
05/05/2020 11:00	0.0	0	0	0	0	0
05/05/2020 12:00	0.0	0	0	0	0	0
05/05/2020 13:00	0.0	0	0	0	0	0
05/05/2020 14:00	0.0	0	0	0	0	0
05/05/2020 15:00	0.0	0	0	0	0	0
05/05/2020 16:00	0.0	0	0	0	0	0
05/05/2020 17:00	0.0	0	0	0	0	0
05/05/2020 18:00	0.0	0	0	0	0	0
05/05/2020 19:00	0.0	0	0	0	0	0
05/05/2020 20:00	0.0	0	0	0	0	0
05/05/2020 21:00	0.0	0	0	0	0	0
05/05/2020 22:00	0.0	0	0	0	0	0
05/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/06/2020 00:00	0.0	0	0	0	0	0
05/06/2020 01:00	0.0	0	0	0	0	0
05/06/2020 02:00	0.0	0	0	0	0	0
05/06/2020 03:00	0.0	0	0	0	0	0
05/06/2020 04:00	0.0	0	0	0	0	0
05/06/2020 05:00	0.0	0	0	0	0	0
05/06/2020 06:00	0.0	0	0	0	0	0
05/06/2020 07:00	0.0	0	0	0	0	0
05/06/2020 08:00	0.0	0	0	0	0	0
05/06/2020 09:00	0.0	0	0	0	0	0
05/06/2020 10:00	0.0	0	0	0	0	0
05/06/2020 11:00	0.0	0	0	0	0	0
05/06/2020 12:00	0.0	0	0	0	0	0
05/06/2020 13:00	0.0	0	0	0	0	0
05/06/2020 14:00	0.0	0	0	0	0	0
05/06/2020 15:00	0.0	0	0	0	0	0
05/06/2020 16:00	0.0	0	0	0	0	0
05/06/2020 17:00	0.0	0	0	0	0	0
05/06/2020 18:00	0.0	0	0	0	0	0
05/06/2020 19:00	0.0	0	0	0	0	0
05/06/2020 20:00	0.0	0	0	0	0	0
05/06/2020 21:00	0.0	0	0	0	0	0
05/06/2020 22:00	0.0	0	0	0	0	0
05/06/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/07/2020 00:00	0.0	0	0	0	0	0
05/07/2020 01:00	0.0	0	0	0	0	0
05/07/2020 02:00	0.0	0	0	0	0	0
05/07/2020 03:00	0.0	0	0	0	0	0
05/07/2020 04:00	0.0	0	0	0	0	0
05/07/2020 05:00	0.0	0	0	0	0	0
05/07/2020 06:00	0.0	0	0	0	0	0
05/07/2020 07:00	0.0	0	0	0	0	0
05/07/2020 08:00	0.0	0	0	0	0	0
05/07/2020 09:00	0.0	0	0	0	0	0
05/07/2020 10:00	0.0	0	0	0	0	0
05/07/2020 11:00	0.0	0	0	0	0	0
05/07/2020 12:00	0.0	0	0	0	0	0
05/07/2020 13:00	0.0	0	0	0	0	0
05/07/2020 14:00	0.0	0	0	0	0	0
05/07/2020 15:00	0.0	0	0	0	0	0
05/07/2020 16:00	0.0	0	0	0	0	0
05/07/2020 17:00	0.0	0	0	0	0	0
05/07/2020 18:00	0.0	0	0	0	0	0
05/07/2020 19:00	0.0	0	0	0	0	0
05/07/2020 20:00	0.0	0	0	0	0	0
05/07/2020 21:00	0.0	0	0	0	0	0
05/07/2020 22:00	0.0	0	0	0	0	0
05/07/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/08/2020 00:00	0.0	0	0	0	0	0
05/08/2020 01:00	0.0	0	0	0	0	0
05/08/2020 02:00	0.0	0	0	0	0	0
05/08/2020 03:00	0.0	0	0	0	0	0
05/08/2020 04:00	0.0	0	0	0	0	0
05/08/2020 05:00	0.0	0	0	0	0	0
05/08/2020 06:00	0.0	0	0	0	0	0
05/08/2020 07:00	0.0	0	0	0	0	0
05/08/2020 08:00	0.0	0	0	0	0	0
05/08/2020 09:00	0.0	0	0	0	0	0
05/08/2020 10:00	0.0	0	0	0	0	0
05/08/2020 11:00	0.0	0	0	0	0	0
05/08/2020 12:00	0.0	0	0	0	0	0
05/08/2020 13:00	0.0	0	0	0	0	0
05/08/2020 14:00	0.0	0	0	0	0	0
05/08/2020 15:00	0.0	0	0	0	0	0
05/08/2020 16:00	0.0	0	0	0	0	0
05/08/2020 17:00	0.0	0	0	0	0	0
05/08/2020 18:00	0.0	0	0	0	0	0
05/08/2020 19:00	0.0	0	0	0	0	0
05/08/2020 20:00	0.0	0	0	0	0	0
05/08/2020 21:00	0.0	0	0	0	0	0
05/08/2020 22:00	0.0	0	0	0	0	0
05/08/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/09/2020 00:00	0.0	0	0	0	0	0
05/09/2020 01:00	0.0	0	0	0	0	0
05/09/2020 02:00	0.0	0	0	0	0	0
05/09/2020 03:00	0.0	0	0	0	0	0
05/09/2020 04:00	0.0	0	0	0	0	0
05/09/2020 05:00	0.0	0	0	0	0	0
05/09/2020 06:00	0.0	0	0	0	0	0
05/09/2020 07:00	0.0	0	0	0	0	0
05/09/2020 08:00	0.0	0	0	0	0	0
05/09/2020 09:00	0.0	0	0	0	0	0
05/09/2020 10:00	0.0	0	0	0	0	0
05/09/2020 11:00	0.0	0	0	0	0	0
05/09/2020 12:00	0.0	0	0	0	0	0
05/09/2020 13:00	0.0	0	0	0	0	0
05/09/2020 14:00	0.0	0	0	0	0	0
05/09/2020 15:00	0.0	0	0	0	0	0
05/09/2020 16:00	0.0	0	0	0	0	0
05/09/2020 17:00	0.0	0	0	0	0	0
05/09/2020 18:00	0.0	0	0	0	0	0
05/09/2020 19:00	0.0	0	0	0	0	0
05/09/2020 20:00	0.0	0	0	0	0	0
05/09/2020 21:00	0.0	0	0	0	0	0
05/09/2020 22:00	0.0	0	0	0	0	0
05/09/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/10/2020 00:00	0.0	0	0	0	0	0
05/10/2020 01:00	0.0	0	0	0	0	0
05/10/2020 02:00	0.0	0	0	0	0	0
05/10/2020 03:00	0.0	0	0	0	0	0
05/10/2020 04:00	0.0	0	0	0	0	0
05/10/2020 05:00	0.0	0	0	0	0	0
05/10/2020 06:00	0.0	0	0	0	0	0
05/10/2020 07:00	0.0	0	0	0	0	0
05/10/2020 08:00	0.0	0	0	0	0	0
05/10/2020 09:00	0.0	0	0	0	0	0
05/10/2020 10:00	0.0	0	0	0	0	0
05/10/2020 11:00	0.0	0	0	0	0	0
05/10/2020 12:00	0.0	0	0	0	0	0
05/10/2020 13:00	0.0	0	0	0	0	0
05/10/2020 14:00	0.0	0	0	0	0	0
05/10/2020 15:00	0.0	0	0	0	0	0
05/10/2020 16:00	0.0	0	0	0	0	0
05/10/2020 17:00	0.0	0	0	0	0	0
05/10/2020 18:00	0.0	0	0	0	0	0
05/10/2020 19:00	0.0	0	0	0	0	0
05/10/2020 20:00	0.0	0	0	0	0	0
05/10/2020 21:00	0.0	0	0	0	0	0
05/10/2020 22:00	0.0	0	0	0	0	0
05/10/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/11/2020 00:00	0.0	0	0	0	0	0
05/11/2020 01:00	0.0	0	0	0	0	0
05/11/2020 02:00	0.0	0	0	0	0	0
05/11/2020 03:00	0.0	0	0	0	0	0
05/11/2020 04:00	0.0	0	0	0	0	0
05/11/2020 05:00	0.0	0	0	0	0	0
05/11/2020 06:00	0.0	0	0	0	0	0
05/11/2020 07:00	0.0	0	0	0	0	0
05/11/2020 08:00	0.0	0	0	0	0	0
05/11/2020 09:00	0.0	0	0	0	0	0
05/11/2020 10:00	0.0	0	0	0	0	0
05/11/2020 11:00	0.0	0	0	0	0	0
05/11/2020 12:00	0.0	0	0	0	0	0
05/11/2020 13:00	0.0	0	0	0	0	0
05/11/2020 14:00	0.0	0	0	0	0	0
05/11/2020 15:00	0.0	0	0	0	0	0
05/11/2020 16:00	0.0	0	0	0	1	0
05/11/2020 17:00	0.0	0	0	0	0	0
05/11/2020 18:00	0.0	0	0	0	0	0
05/11/2020 19:00	0.0	0	0	0	0	0
05/11/2020 20:00	0.0	0	0	0	0	0
05/11/2020 21:00	0.0	0	0	0	0	0
05/11/2020 22:00	0.0	0	0	0	0	0
05/11/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/12/2020 00:00	0.0	0	0	0	0	0
05/12/2020 01:00	0.0	0	0	0	0	0
05/12/2020 02:00	0.0	0	0	0	0	0
05/12/2020 03:00	0.0	0	0	0	0	0
05/12/2020 04:00	0.0	0	0	0	0	0
05/12/2020 05:00	0.0	0	0	0	0	0
05/12/2020 06:00	0.0	0	0	0	0	0
05/12/2020 07:00	0.0	0	0	0	0	0
05/12/2020 08:00	0.0	0	0	0	0	0
05/12/2020 09:00	0.0	0	0	0	0	0
05/12/2020 10:00	0.0	0	0	0	0	0
05/12/2020 11:00	0.0	0	0	0	0	0
05/12/2020 12:00	0.0	0	0	0	0	0
05/12/2020 13:00	0.0	0	0	0	0	0
05/12/2020 14:00	0.0	0	0	0	0	0
05/12/2020 15:00	0.0	0	0	0	0	0
05/12/2020 16:00	0.0	0	0	0	0	0
05/12/2020 17:00	0.0	0	0	0	0	0
05/12/2020 18:00	0.0	0	0	0	0	0
05/12/2020 19:00	0.0	0	0	0	0	0
05/12/2020 20:00	0.0	0	0	0	0	0
05/12/2020 21:00	0.0	0	0	0	0	0
05/12/2020 22:00	0.0	0	0	0	0	0
05/12/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/13/2020 00:00	0.0	0	0	0	0	0
05/13/2020 01:00	0.0	0	0	0	0	0
05/13/2020 02:00	0.0	0	0	0	0	0
05/13/2020 03:00	0.0	0	0	0	0	0
05/13/2020 04:00	0.0	0	0	0	0	0
05/13/2020 05:00	0.0	0	0	0	0	0
05/13/2020 06:00	0.0	0	0	0	0	0
05/13/2020 07:00	0.0	0	0	0	0	0
05/13/2020 08:00	0.0	0	0	0	0	0
05/13/2020 09:00	0.0	0	0	0	0	0
05/13/2020 10:00	0.0	0	0	0	0	0
05/13/2020 11:00	0.0	0	0	0	0	0
05/13/2020 12:00	0.0	0	0	0	0	0
05/13/2020 13:00	0.0	0	0	0	0	0
05/13/2020 14:00	0.0	0	0	0	0	0
05/13/2020 15:00	0.0	0	0	0	0	0
05/13/2020 16:00	0.0	0	0	0	0	0
05/13/2020 17:00	0.0	0	0	0	0	0
05/13/2020 18:00	0.0	0	0	0	0	0
05/13/2020 19:00	0.0	0	0	0	0	0
05/13/2020 20:00	0.0	0	0	0	0	0
05/13/2020 21:00	0.0	0	0	0	0	0
05/13/2020 22:00	0.0	0	0	0	0	0
05/13/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/14/2020 00:00	0.0	0	0	0	0	0
05/14/2020 01:00	0.0	0	0	0	0	0
05/14/2020 02:00	0.0	0	0	0	0	0
05/14/2020 03:00	0.0	0	0	0	0	0
05/14/2020 04:00	0.0	0	0	0	0	0
05/14/2020 05:00	0.0	0	0	0	0	0
05/14/2020 06:00	0.0	0	0	0	0	0
05/14/2020 07:00	0.0	0	0	0	0	0
05/14/2020 08:00	0.0	0	0	0	0	0
05/14/2020 09:00	0.0	0	0	0	0	0
05/14/2020 10:00	0.0	0	0	0	0	0
05/14/2020 11:00	0.0	0	0	0	0	0
05/14/2020 12:00	0.0	0	0	0	0	0
05/14/2020 13:00	0.0	0	0	0	0	0
05/14/2020 14:00	0.0	0	0	0	0	0
05/14/2020 15:00	0.0	0	0	0	0	0
05/14/2020 16:00	0.0	0	0	0	0	0
05/14/2020 17:00	0.0	0	0	0	0	0
05/14/2020 18:00	0.0	0	0	0	0	0
05/14/2020 19:00	0.0	0	0	0	0	0
05/14/2020 20:00	0.0	0	0	0	0	0
05/14/2020 21:00	0.0	0	0	0	0	0
05/14/2020 22:00	0.0	0	0	0	0	0
05/14/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/15/2020 00:00	0.0	0	0	0	0	0
05/15/2020 01:00	0.0	0	0	0	0	0
05/15/2020 02:00	0.0	0	0	0	0	0
05/15/2020 03:00	0.0	0	0	0	0	0
05/15/2020 04:00	0.0	0	0	0	0	0
05/15/2020 05:00	0.0	0	0	0	0	0
05/15/2020 06:00	0.0	0	0	0	0	0
05/15/2020 07:00	0.0	0	0	0	0	0
05/15/2020 08:00	0.0	0	0	0	0	0
05/15/2020 09:00	0.0	0	0	0	0	0
05/15/2020 10:00	0.0	0	0	0	0	0
05/15/2020 11:00	0.0	0	0	0	0	0
05/15/2020 12:00	0.0	0	0	0	0	0
05/15/2020 13:00	0.0	0	0	0	0	0
05/15/2020 14:00	0.0	0	0	0	0	0
05/15/2020 15:00	0.0	0	0	0	0	0
05/15/2020 16:00	0.0	0	0	0	0	0
05/15/2020 17:00	0.0	0	0	0	0	0
05/15/2020 18:00	0.0	0	0	0	0	0
05/15/2020 19:00	0.0	0	0	0	0	0
05/15/2020 20:00	0.0	0	0	0	0	0
05/15/2020 21:00	0.0	0	0	0	0	0
05/15/2020 22:00	0.0	0	0	0	0	0
05/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/16/2020 00:00	0.0	0	0	0	0	0
05/16/2020 01:00	0.0	0	0	0	0	0
05/16/2020 02:00	0.0	0	0	0	0	0
05/16/2020 03:00	0.0	0	0	0	0	0
05/16/2020 04:00	0.0	0	0	0	0	0
05/16/2020 05:00	0.0	0	0	0	0	0
05/16/2020 06:00	0.0	0	0	0	0	0
05/16/2020 07:00	0.0	0	0	0	0	0
05/16/2020 08:00	0.0	0	0	0	0	0
05/16/2020 09:00	0.0	0	0	0	0	0
05/16/2020 10:00	0.0	0	0	0	0	0
05/16/2020 11:00	0.0	0	0	0	0	0
05/16/2020 12:00	0.0	0	0	0	0	0
05/16/2020 13:00	0.0	0	0	0	0	0
05/16/2020 14:00	0.0	0	0	0	0	0
05/16/2020 15:00	0.0	0	0	0	0	0
05/16/2020 16:00	0.0	0	0	0	0	0
05/16/2020 17:00	0.0	0	0	0	0	0
05/16/2020 18:00	0.0	0	0	0	0	0
05/16/2020 19:00	0.0	0	0	0	0	0
05/16/2020 20:00	0.0	0	0	0	0	0
05/16/2020 21:00	0.0	0	0	0	0	0
05/16/2020 22:00	0.0	0	0	0	0	0
05/16/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/17/2020 00:00	0.0	0	0	0	0	0
05/17/2020 01:00	0.0	0	0	0	0	0
05/17/2020 02:00	0.0	0	0	0	0	0
05/17/2020 03:00	0.0	0	0	0	0	0
05/17/2020 04:00	0.0	0	0	0	0	0
05/17/2020 05:00	0.0	0	0	0	0	0
05/17/2020 06:00	0.0	0	0	0	0	0
05/17/2020 07:00	0.0	0	0	0	0	0
05/17/2020 08:00	0.0	0	0	0	0	0
05/17/2020 09:00	0.0	0	0	0	0	0
05/17/2020 10:00	0.0	0	0	0	0	0
05/17/2020 11:00	0.0	0	0	0	0	0
05/17/2020 12:00	0.0	0	0	0	0	0
05/17/2020 13:00	0.0	0	0	0	0	0
05/17/2020 14:00	0.0	0	0	0	0	0
05/17/2020 15:00	0.0	0	0	0	0	0
05/17/2020 16:00	0.0	0	0	0	0	0
05/17/2020 17:00	0.0	0	0	0	0	0
05/17/2020 18:00	0.0	0	0	0	0	0
05/17/2020 19:00	0.0	0	0	0	0	0
05/17/2020 20:00	0.0	0	0	0	0	0
05/17/2020 21:00	0.0	0	0	0	0	0
05/17/2020 22:00	0.0	0	0	0	0	0
05/17/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/18/2020 00:00	0.0	0	0	0	0	0
05/18/2020 01:00	0.0	0	0	0	0	0
05/18/2020 02:00	0.0	0	0	0	0	0
05/18/2020 03:00	0.0	0	0	0	0	0
05/18/2020 04:00	0.0	0	0	0	0	0
05/18/2020 05:00	0.0	0	0	0	0	0
05/18/2020 06:00	0.0	0	0	0	0	0
05/18/2020 07:00	0.0	0	0	0	0	0
05/18/2020 08:00	0.0	0	0	0	0	0
05/18/2020 09:00	0.0	0	0	0	0	0
05/18/2020 10:00	0.0	0	0	0	0	0
05/18/2020 11:00	0.0	0	0	0	0	0
05/18/2020 12:00	0.0	0	0	0	0	0
05/18/2020 13:00	0.0	0	0	0	0	0
05/18/2020 14:00	0.0	0	0	0	0	0
05/18/2020 15:00	0.0	0	0	0	0	0
05/18/2020 16:00	0.0	0	0	0	0	0
05/18/2020 17:00	0.0	0	0	0	0	0
05/18/2020 18:00	0.0	0	0	0	0	0
05/18/2020 19:00	0.0	0	0	0	0	0
05/18/2020 20:00	0.0	0	0	0	0	0
05/18/2020 21:00	0.0	0	0	0	0	0
05/18/2020 22:00	0.0	0	0	0	0	0
05/18/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/19/2020 00:00	0.0	0	0	0	0	0
05/19/2020 01:00	0.0	0	0	0	0	0
05/19/2020 02:00	0.0	0	0	0	0	0
05/19/2020 03:00	0.0	0	0	0	0	0
05/19/2020 04:00	0.0	0	0	0	0	0
05/19/2020 05:00	0.0	0	0	0	0	0
05/19/2020 06:00	0.0	0	0	0	0	0
05/19/2020 07:00	0.0	0	0	0	0	0
05/19/2020 08:00	0.0	0	0	0	0	0
05/19/2020 09:00	0.0	0	0	0	0	0
05/19/2020 10:00	0.0	0	0	0	0	0
05/19/2020 11:00	0.0	0	0	0	0	0
05/19/2020 12:00	0.0	0	0	0	0	0
05/19/2020 13:00	0.0	0	0	0	0	0
05/19/2020 14:00	0.0	0	0	0	0	0
05/19/2020 15:00	0.0	0	0	0	0	0
05/19/2020 16:00	0.0	0	0	0	0	0
05/19/2020 17:00	0.0	0	0	0	0	0
05/19/2020 18:00	0.0	0	0	0	0	0
05/19/2020 19:00	0.0	0	0	0	0	0
05/19/2020 20:00	0.0	0	0	0	0	0
05/19/2020 21:00	0.0	0	0	0	0	0
05/19/2020 22:00	0.0	0	0	0	0	0
05/19/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/20/2020 00:00	0.0	0	0	0	0	0
05/20/2020 01:00	0.0	0	0	0	0	0
05/20/2020 02:00	0.0	0	0	0	0	0
05/20/2020 03:00	0.0	0	0	0	0	0
05/20/2020 04:00	0.0	0	0	0	0	0
05/20/2020 05:00	0.0	0	0	0	0	0
05/20/2020 06:00	0.0	0	0	0	0	0
05/20/2020 07:00	0.0	0	0	0	0	0
05/20/2020 08:00	0.0	0	0	0	0	0
05/20/2020 09:00	0.0	0	0	0	0	0
05/20/2020 10:00	0.0	0	0	0	0	0
05/20/2020 11:00	0.0	0	0	0	0	0
05/20/2020 12:00	0.0	0	0	0	0	0
05/20/2020 13:00	0.0	0	0	0	0	0
05/20/2020 14:00	0.0	0	0	0	0	0
05/20/2020 15:00	0.0	0	0	0	0	0
05/20/2020 16:00	0.0	0	0	0	0	0
05/20/2020 17:00	0.0	0	0	0	0	0
05/20/2020 18:00	0.0	0	0	0	0	0
05/20/2020 19:00	0.0	0	0	0	0	0
05/20/2020 20:00	0.0	0	0	0	0	0
05/20/2020 21:00	0.0	0	0	0	0	0
05/20/2020 22:00	0.0	0	0	0	0	0
05/20/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/21/2020 00:00	0.0	0	0	0	0	0
05/21/2020 01:00	0.0	0	0	0	0	0
05/21/2020 02:00	0.0	0	0	0	0	0
05/21/2020 03:00	0.0	0	0	0	0	0
05/21/2020 04:00	0.0	0	0	0	0	0
05/21/2020 05:00	0.0	0	0	0	0	0
05/21/2020 06:00	0.0	0	0	0	0	0
05/21/2020 07:00	0.0	0	0	0	0	0
05/21/2020 08:00	0.0	0	0	0	0	0
05/21/2020 09:00	0.0	0	0	0	0	0
05/21/2020 10:00	0.0	0	0	0	0	0
05/21/2020 11:00	0.0	0	0	0	0	0
05/21/2020 12:00	0.0	0	0	0	0	0
05/21/2020 13:00	0.0	0	0	0	0	0
05/21/2020 14:00	0.0	0	0	0	0	0
05/21/2020 15:00	0.0	0	0	0	0	0
05/21/2020 16:00	0.0	0	0	0	0	0
05/21/2020 17:00	0.0	0	0	0	0	0
05/21/2020 18:00	0.0	0	0	0	0	0
05/21/2020 19:00	0.0	0	0	0	0	0
05/21/2020 20:00	0.0	0	0	0	0	0
05/21/2020 21:00	0.0	0	0	0	0	0
05/21/2020 22:00	0.0	0	0	0	0	0
05/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/22/2020 00:00	0.0	0	0	0	0	0
05/22/2020 01:00	0.0	0	0	0	0	0
05/22/2020 02:00	0.0	0	0	0	0	0
05/22/2020 03:00	0.0	0	0	0	0	0
05/22/2020 04:00	0.0	0	0	0	0	0
05/22/2020 05:00	0.0	0	0	0	0	0
05/22/2020 06:00	0.0	0	0	0	0	0
05/22/2020 07:00	0.0	0	0	0	0	0
05/22/2020 08:00	0.0	0	0	0	0	0
05/22/2020 09:00	0.0	0	0	0	0	0
05/22/2020 10:00	0.0	0	0	0	0	0
05/22/2020 11:00	0.0	0	0	0	0	0
05/22/2020 12:00	0.0	0	0	0	0	0
05/22/2020 13:00	0.0	0	0	0	0	0
05/22/2020 14:00	0.0	0	0	0	0	0
05/22/2020 15:00	0.0	0	0	0	0	0
05/22/2020 16:00	0.0	0	0	0	0	0
05/22/2020 17:00	0.0	0	0	0	0	0
05/22/2020 18:00	0.0	0	0	0	0	0
05/22/2020 19:00	0.0	0	0	0	0	0
05/22/2020 20:00	0.0	0	0	0	0	0
05/22/2020 21:00	0.0	0	0	0	0	0
05/22/2020 22:00	0.0	0	0	0	0	0
05/22/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/23/2020 00:00	0.0	0	0	0	0	0
05/23/2020 01:00	0.0	0	0	0	0	0
05/23/2020 02:00	0.0	0	0	0	0	0
05/23/2020 03:00	0.0	0	0	0	0	0
05/23/2020 04:00	0.0	0	0	0	0	0
05/23/2020 05:00	0.0	0	0	0	0	0
05/23/2020 06:00	0.0	0	0	0	0	0
05/23/2020 07:00	0.0	0	0	0	0	0
05/23/2020 08:00	0.0	0	0	0	0	0
05/23/2020 09:00	0.0	0	0	0	0	0
05/23/2020 10:00	0.0	0	0	0	0	0
05/23/2020 11:00	0.0	0	0	0	0	0
05/23/2020 12:00	0.0	0	0	0	0	0
05/23/2020 13:00	0.0	0	0	0	0	0
05/23/2020 14:00	0.0	0	0	0	0	0
05/23/2020 15:00	0.0	0	0	0	0	0
05/23/2020 16:00	0.0	0	0	0	0	0
05/23/2020 17:00	0.0	0	0	0	0	0
05/23/2020 18:00	0.0	0	0	0	0	0
05/23/2020 19:00	0.0	0	0	0	0	0
05/23/2020 20:00	0.0	0	0	0	0	0
05/23/2020 21:00	0.0	0	0	0	0	0
05/23/2020 22:00	0.0	0	0	0	0	0
05/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/24/2020 00:00	0.0	0	0	0	0	0
05/24/2020 01:00	0.0	0	0	0	0	0
05/24/2020 02:00	0.0	0	0	0	0	0
05/24/2020 03:00	0.0	0	0	0	0	0
05/24/2020 04:00	0.0	0	0	0	0	0
05/24/2020 05:00	0.0	0	0	0	0	0
05/24/2020 06:00	0.0	0	0	0	0	0
05/24/2020 07:00	0.0	0	0	0	0	0
05/24/2020 08:00	0.0	0	0	0	0	0
05/24/2020 09:00	0.0	0	0	0	0	0
05/24/2020 10:00	0.0	0	0	0	0	0
05/24/2020 11:00	0.0	0	0	0	0	0
05/24/2020 12:00	0.0	0	0	0	0	0
05/24/2020 13:00	0.0	0	0	0	0	0
05/24/2020 14:00	0.0	0	0	0	0	0
05/24/2020 15:00	0.0	0	0	0	0	0
05/24/2020 16:00	0.0	0	0	0	0	0
05/24/2020 17:00	0.0	0	0	0	0	0
05/24/2020 18:00	0.0	0	0	0	0	0
05/24/2020 19:00	0.0	0	0	0	0	0
05/24/2020 20:00	0.0	0	0	0	0	0
05/24/2020 21:00	0.0	0	0	0	0	0
05/24/2020 22:00	0.0	0	0	0	0	0
05/24/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/25/2020 00:00	0.0	0	0	0	0	0
05/25/2020 01:00	0.0	0	0	0	0	0
05/25/2020 02:00	0.0	0	0	0	0	0
05/25/2020 03:00	0.0	0	0	0	0	0
05/25/2020 04:00	0.0	0	0	0	0	0
05/25/2020 05:00	0.0	0	0	0	0	0
05/25/2020 06:00	0.0	0	0	0	0	0
05/25/2020 07:00	0.0	0	0	0	0	0
05/25/2020 08:00	0.0	0	0	0	0	0
05/25/2020 09:00	0.0	0	0	0	0	0
05/25/2020 10:00	0.0	0	0	0	0	0
05/25/2020 11:00	0.0	0	0	0	0	0
05/25/2020 12:00	0.0	0	0	0	0	0
05/25/2020 13:00	0.0	0	0	0	0	0
05/25/2020 14:00	0.0	0	0	0	0	0
05/25/2020 15:00	0.0	0	0	0	0	0
05/25/2020 16:00	0.0	0	0	0	0	0
05/25/2020 17:00	0.0	0	0	0	0	0
05/25/2020 18:00	0.0	0	0	0	0	0
05/25/2020 19:00	0.0	0	0	0	0	0
05/25/2020 20:00	0.0	0	0	0	0	0
05/25/2020 21:00	0.0	0	0	0	0	0
05/25/2020 22:00	0.0	0	0	0	0	0
05/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/26/2020 00:00	0.0	0	0	0	0	0
05/26/2020 01:00	0.0	0	0	0	0	0
05/26/2020 02:00	0.0	0	0	0	0	0
05/26/2020 03:00	0.0	0	0	0	0	0
05/26/2020 04:00	0.0	0	0	0	0	0
05/26/2020 05:00	0.0	0	0	0	0	0
05/26/2020 06:00	0.0	0	0	0	0	0
05/26/2020 07:00	0.0	0	0	0	0	0
05/26/2020 08:00	0.0	0	0	0	0	0
05/26/2020 09:00	0.0	0	0	0	0	0
05/26/2020 10:00	0.0	0	0	0	0	0
05/26/2020 11:00	0.0	0	0	0	0	0
05/26/2020 12:00	0.0	0	0	0	0	0
05/26/2020 13:00	0.0	0	0	0	0	0
05/26/2020 14:00	0.0	0	0	0	0	0
05/26/2020 15:00	0.0	0	0	0	0	0
05/26/2020 16:00	0.0	0	0	0	0	0
05/26/2020 17:00	0.0	0	0	0	0	0
05/26/2020 18:00	0.0	0	0	0	0	0
05/26/2020 19:00	0.0	0	0	0	0	0
05/26/2020 20:00	0.0	0	0	0	0	0
05/26/2020 21:00	0.0	0	0	0	0	0
05/26/2020 22:00	0.0	0	0	0	0	0
05/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/27/2020 00:00	0.0	0	0	0	0	0
05/27/2020 01:00	0.0	0	0	0	0	0
05/27/2020 02:00	0.0	0	0	0	0	0
05/27/2020 03:00	0.0	0	0	0	0	0
05/27/2020 04:00	0.0	0	0	0	0	0
05/27/2020 05:00	0.0	0	0	0	0	0
05/27/2020 06:00	0.0	0	0	0	0	0
05/27/2020 07:00	0.0	0	0	0	0	0
05/27/2020 08:00	10.5	1	0	0	0	0
05/27/2020 09:00	6.1	1	0	0	0	0
05/27/2020 10:00	3.1	1	0	0	0	0
05/27/2020 11:00	13.3	1	0	0	0	0
05/27/2020 12:00	0.0	0	0	0	0	1
05/27/2020 13:00	0.0	0	0	0	0	1
05/27/2020 14:00	1.9	0	0	0	1	0
05/27/2020 15:00	0.0	0	0	0	0	0
05/27/2020 16:00	0.0	0	0	0	0	0
05/27/2020 17:00	0.0	0	0	0	0	0
05/27/2020 18:00	0.0	0	0	0	0	0
05/27/2020 19:00	0.0	0	0	0	0	0
05/27/2020 20:00	0.0	0	0	0	0	0
05/27/2020 21:00	0.0	0	0	0	0	0
05/27/2020 22:00	0.0	0	0	0	0	0
05/27/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	34.9 #	4 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	13.3	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/28/2020 00:00	0.0	0	0	0	0	0
05/28/2020 01:00	0.0	0	0	0	0	0
05/28/2020 02:00	0.0	0	0	0	0	0
05/28/2020 03:00	0.0	0	0	0	0	0
05/28/2020 04:00	0.0	0	0	0	0	0
05/28/2020 05:00	0.0	0	0	0	0	0
05/28/2020 06:00	0.0	0	0	0	0	0
05/28/2020 07:00	0.0	0	0	0	0	0
05/28/2020 08:00	0.0	0	0	0	0	0
05/28/2020 09:00	0.0	0	0	0	0	0
05/28/2020 10:00	0.0	0	0	0	0	0
05/28/2020 11:00	0.0	0	0	0	0	0
05/28/2020 12:00	0.0	0	0	0	0	0
05/28/2020 13:00	0.0	0	0	0	0	0
05/28/2020 14:00	0.0	0	0	0	0	0
05/28/2020 15:00	0.0	0	0	0	0	0
05/28/2020 16:00	0.0	0	0	0	0	0
05/28/2020 17:00	0.0	0	0	0	0	0
05/28/2020 18:00	31.4	0	1	0	0	0
05/28/2020 19:00	59.1	0	1	0	0	0
05/28/2020 20:00	2.9	0	1	0	0	0
05/28/2020 21:00	0.0	0	0	0	0	1
05/28/2020 22:00	0.0	0	0	0	0	1
05/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	93.4 #	0 #	3 #	0 #	0 #	3 #
Minimum:	0.0	0	0	0	0	0
Maximum:	59.1	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/29/2020 00:00	0.0	0	0	0	0	1
05/29/2020 01:00	1.1	0	0	0	1	0
05/29/2020 02:00	0.0	0	0	0	0	0
05/29/2020 03:00	0.0	0	0	0	0	0
05/29/2020 04:00	0.0	0	0	0	0	0
05/29/2020 05:00	0.0	0	0	0	0	0
05/29/2020 06:00	0.0	0	0	0	0	0
05/29/2020 07:00	0.0	0	0	0	0	0
05/29/2020 08:00	0.0	0	0	0	0	0
05/29/2020 09:00	0.0	0	0	0	0	0
05/29/2020 10:00	0.0	0	0	0	0	0
05/29/2020 11:00	0.0	0	0	0	0	0
05/29/2020 12:00	0.0	0	0	0	0	0
05/29/2020 13:00	0.0	0	0	0	0	0
05/29/2020 14:00	0.0	0	0	0	0	0
05/29/2020 15:00	0.0	0	0	0	0	0
05/29/2020 16:00	0.0	0	0	0	0	0
05/29/2020 17:00	0.0	0	0	0	0	0
05/29/2020 18:00	0.0	0	0	0	0	0
05/29/2020 19:00	0.0	0	0	0	0	0
05/29/2020 20:00	39.4	0	1	0	0	0
05/29/2020 21:00	57.7	0	1	0	0	0
05/29/2020 22:00	35.3	0	1	0	0	0
05/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	133.5 #	0 #	3 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	57.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/30/2020 00:00	0.0	0	0	0	0	1
05/30/2020 01:00	0.0	0	0	0	0	1
05/30/2020 02:00	0.0	0	0	0	0	1
05/30/2020 03:00	0.0	0	0	0	0	1
05/30/2020 04:00	0.0	0	0	0	0	1
05/30/2020 05:00	0.0	0	0	0	0	1
05/30/2020 06:00	0.0	0	0	0	0	1
05/30/2020 07:00	0.0	0	0	0	0	1
05/30/2020 08:00	1.6	0	0	0	1	0
05/30/2020 09:00	0.0	0	0	0	0	0
05/30/2020 10:00	0.0	0	0	0	0	0
05/30/2020 11:00	0.0	0	0	0	0	0
05/30/2020 12:00	0.0	0	0	0	0	0
05/30/2020 13:00	0.3	0	0	1	0	0
05/30/2020 14:00	54.2	0	0	1	0	0
05/30/2020 15:00	0.0	0	0	1	0	0
05/30/2020 16:00	0.0	0	0	0	0	1
05/30/2020 17:00	0.0	0	0	0	0	1
05/30/2020 18:00	0.0	0	0	0	0	1
05/30/2020 19:00	0.0	0	0	0	0	1
05/30/2020 20:00	0.0	0	0	0	0	1
05/30/2020 21:00	0.0	0	0	0	0	1
05/30/2020 22:00	0.0	0	0	0	0	1
05/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	56.1 #	0 #	0 #	3 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	54.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/31/2020 00:00	0.0	0	0	0	0	1
05/31/2020 01:00	0.0	0	0	0	0	1
05/31/2020 02:00	0.0	0	0	0	0	1
05/31/2020 03:00	0.0	0	0	0	0	1
05/31/2020 04:00	0.0	0	0	0	0	1
05/31/2020 05:00	0.0	0	0	0	0	1
05/31/2020 06:00	0.0	0	0	0	1	0
05/31/2020 07:00	0.0	0	0	0	0	0
05/31/2020 08:00	0.0	0	0	0	0	0
05/31/2020 09:00	0.0	0	0	0	0	0
05/31/2020 10:00	0.0	0	0	0	0	0
05/31/2020 11:00	0.0	0	0	0	0	0
05/31/2020 12:00	0.0	0	0	0	0	0
05/31/2020 13:00	0.0	0	0	0	0	0
05/31/2020 14:00	19.7	0	1	0	0	0
05/31/2020 15:00	21.4	0	1	0	0	0
05/31/2020 16:00	0.0	0	0	0	0	1
05/31/2020 17:00	0.0	0	0	0	0	1
05/31/2020 18:00	0.0	0	0	0	0	1
05/31/2020 19:00	0.0	0	0	0	0	1
05/31/2020 20:00	0.0	0	0	0	0	1
05/31/2020 21:00	0.0	0	0	0	0	1
05/31/2020 22:00	0.0	0	0	0	0	1
05/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	41.1 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	21.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/01/2020 00:00	0.0	0	0	0	0	1
06/01/2020 01:00	0.0	0	0	0	0	1
06/01/2020 02:00	0.0	0	0	0	0	1
06/01/2020 03:00	0.0	0	0	0	0	1
06/01/2020 04:00	0.0	0	0	0	0	1
06/01/2020 05:00	0.0	0	0	0	0	1
06/01/2020 06:00	0.0	0	0	0	0	1
06/01/2020 07:00	0.0	0	0	0	0	1
06/01/2020 08:00	0.0	0	0	0	0	1
06/01/2020 09:00	0.0	0	0	0	0	1
06/01/2020 10:00	0.0	0	0	0	0	1
06/01/2020 11:00	0.0	0	0	0	0	1
06/01/2020 12:00	0.0	0	0	0	0	1
06/01/2020 13:00	0.0	0	0	0	0	1
06/01/2020 14:00	0.0	0	0	0	0	1
06/01/2020 15:00	0.0	0	0	0	0	1
06/01/2020 16:00	0.0	0	0	0	0	1
06/01/2020 17:00	0.0	0	0	0	0	1
06/01/2020 18:00	0.0	0	0	0	0	1
06/01/2020 19:00	0.0	0	0	0	0	1
06/01/2020 20:00	0.0	0	0	0	0	1
06/01/2020 21:00	0.0	0	0	0	0	1
06/01/2020 22:00	0.0	0	0	0	0	1
06/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/02/2020 00:00	0.0	0	0	0	0	1
06/02/2020 01:00	0.0	0	0	0	0	1
06/02/2020 02:00	0.0	0	0	0	0	1
06/02/2020 03:00	0.0	0	0	0	0	1
06/02/2020 04:00	0.0	0	0	0	0	1
06/02/2020 05:00	0.0	0	0	0	0	1
06/02/2020 06:00	0.0	0	0	0	0	1
06/02/2020 07:00	0.0	0	0	0	0	1
06/02/2020 08:00	0.0	0	0	0	0	1
06/02/2020 09:00	0.0	0	0	0	0	1
06/02/2020 10:00	0.0	0	0	0	0	1
06/02/2020 11:00	0.0	0	0	0	0	1
06/02/2020 12:00	0.0	0	0	0	0	1
06/02/2020 13:00	0.0	0	0	0	0	1
06/02/2020 14:00	0.0	0	0	0	0	1
06/02/2020 15:00	0.0	0	0	0	0	1
06/02/2020 16:00	0.0	0	0	0	0	1
06/02/2020 17:00	0.0	0	0	0	0	1
06/02/2020 18:00	0.0	0	0	0	0	1
06/02/2020 19:00	0.0	0	0	0	0	1
06/02/2020 20:00	0.0	0	0	0	0	1
06/02/2020 21:00	0.0	0	0	0	0	1
06/02/2020 22:00	0.0	0	0	0	0	1
06/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/03/2020 00:00	0.0	0	0	0	0	1
06/03/2020 01:00	0.0	0	0	0	0	1
06/03/2020 02:00	0.0	0	0	0	0	1
06/03/2020 03:00	0.0	0	0	0	0	1
06/03/2020 04:00	0.0	0	0	0	0	1
06/03/2020 05:00	0.0	0	0	0	0	1
06/03/2020 06:00	0.0	0	0	0	0	1
06/03/2020 07:00	0.0	0	0	0	0	1
06/03/2020 08:00	0.0	0	0	0	0	1
06/03/2020 09:00	0.0	0	0	0	0	1
06/03/2020 10:00	0.0	0	0	0	0	1
06/03/2020 11:00	0.0	0	0	0	0	1
06/03/2020 12:00	0.0	0	0	0	0	1
06/03/2020 13:00	0.0	0	0	0	0	1
06/03/2020 14:00	0.0	0	0	0	0	1
06/03/2020 15:00	0.0	0	0	0	0	1
06/03/2020 16:00	0.0	0	0	0	0	1
06/03/2020 17:00	0.0	0	0	0	0	1
06/03/2020 18:00	0.0	0	0	0	0	1
06/03/2020 19:00	0.0	0	0	0	0	1
06/03/2020 20:00	0.0	0	0	0	0	1
06/03/2020 21:00	0.0	0	0	0	0	1
06/03/2020 22:00	0.0	0	0	0	0	1
06/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/04/2020 00:00	1.5	0	0	0	1	0
06/04/2020 01:00	0.0	0	0	0	0	0
06/04/2020 02:00	0.0	0	0	0	0	0
06/04/2020 03:00	0.0	0	0	0	0	0
06/04/2020 04:00	0.0	0	0	0	0	0
06/04/2020 05:00	0.0	0	0	0	0	0
06/04/2020 06:00	0.0	0	0	0	0	0
06/04/2020 07:00	0.0	0	0	0	0	0
06/04/2020 08:00	0.0	0	0	0	0	0
06/04/2020 09:00	0.0	0	0	0	0	0
06/04/2020 10:00	10.2	0	1	0	0	0
06/04/2020 11:00	34.7	0	1	0	0	0
06/04/2020 12:00	0.0	0	0	0	0	1
06/04/2020 13:00	0.0	0	0	0	0	1
06/04/2020 14:00	0.0	0	0	0	0	1
06/04/2020 15:00	0.0	0	0	0	0	1
06/04/2020 16:00	0.0	0	0	0	0	1
06/04/2020 17:00	0.0	0	0	0	0	1
06/04/2020 18:00	0.0	0	0	0	0	1
06/04/2020 19:00	0.0	0	0	0	0	1
06/04/2020 20:00	0.0	0	0	0	0	1
06/04/2020 21:00	0.0	0	0	0	0	1
06/04/2020 22:00	0.0	0	0	0	0	1
06/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	46.4 #	0 #	2 #	0 #	1 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	34.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/05/2020 00:00	1.4	0	0	0	1	0
06/05/2020 01:00	0.0	0	0	0	0	0
06/05/2020 02:00	0.0	0	0	0	0	0
06/05/2020 03:00	0.0	0	0	0	0	0
06/05/2020 04:00	0.0	0	0	0	0	0
06/05/2020 05:00	0.0	0	0	0	0	0
06/05/2020 06:00	0.0	0	0	0	0	0
06/05/2020 07:00	0.0	0	0	0	0	0
06/05/2020 08:00	0.0	0	0	0	0	0
06/05/2020 09:00	0.0	0	0	0	0	0
06/05/2020 10:00	0.0	0	0	0	0	0
06/05/2020 11:00	0.0	0	0	0	0	0
06/05/2020 12:00	0.0	0	0	0	0	0
06/05/2020 13:00	0.0	0	0	0	0	0
06/05/2020 14:00	0.0	0	0	0	0	0
06/05/2020 15:00	0.0	0	0	0	0	0
06/05/2020 16:00	0.0	0	0	0	0	0
06/05/2020 17:00	0.0	0	0	0	0	0
06/05/2020 18:00	0.0	0	0	0	0	0
06/05/2020 19:00	0.0	0	0	0	0	0
06/05/2020 20:00	0.0	0	0	0	0	0
06/05/2020 21:00	0.0	0	0	0	0	0
06/05/2020 22:00	0.0	0	0	0	0	0
06/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.4 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.4	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/06/2020 00:00	0.0	0	0	0	0	0
06/06/2020 01:00	0.0	0	0	0	0	0
06/06/2020 02:00	0.0	0	0	0	0	0
06/06/2020 03:00	0.0	0	0	0	0	0
06/06/2020 04:00	0.0	0	0	0	0	0
06/06/2020 05:00	0.0	0	0	0	0	0
06/06/2020 06:00	0.0	0	0	0	0	0
06/06/2020 07:00	0.0	0	0	0	0	0
06/06/2020 08:00	0.0	0	0	0	0	0
06/06/2020 09:00	0.0	0	0	0	0	0
06/06/2020 10:00	0.0	0	0	0	0	0
06/06/2020 11:00	0.0	0	0	0	0	0
06/06/2020 12:00	0.0	0	0	0	0	0
06/06/2020 13:00	0.0	0	0	0	0	0
06/06/2020 14:00	0.0	0	0	0	0	0
06/06/2020 15:00	0.0	0	0	0	0	0
06/06/2020 16:00	0.0	0	0	0	0	0
06/06/2020 17:00	0.0	0	0	0	0	0
06/06/2020 18:00	0.0	0	0	0	0	0
06/06/2020 19:00	0.0	0	0	0	0	0
06/06/2020 20:00	0.0	0	0	0	0	0
06/06/2020 21:00	0.0	0	0	0	0	0
06/06/2020 22:00	0.0	0	0	0	0	0
06/06/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/07/2020 00:00	0.0	0	0	0	0	0
06/07/2020 01:00	0.0	0	0	0	0	0
06/07/2020 02:00	0.0	0	0	0	0	0
06/07/2020 03:00	0.0	0	0	0	0	0
06/07/2020 04:00	0.0	0	0	0	0	0
06/07/2020 05:00	0.0	0	0	0	0	0
06/07/2020 06:00	0.0	0	0	0	0	0
06/07/2020 07:00	0.0	0	0	0	0	0
06/07/2020 08:00	0.0	0	0	0	0	0
06/07/2020 09:00	0.0	0	0	0	0	0
06/07/2020 10:00	0.0	0	0	0	0	0
06/07/2020 11:00	0.0	0	0	0	0	0
06/07/2020 12:00	0.0	0	0	0	0	0
06/07/2020 13:00	0.0	0	0	0	0	0
06/07/2020 14:00	0.0	0	0	0	0	0
06/07/2020 15:00	0.0	0	0	0	0	0
06/07/2020 16:00	0.0	0	0	0	0	0
06/07/2020 17:00	0.0	0	0	0	0	0
06/07/2020 18:00	0.0	0	0	0	0	0
06/07/2020 19:00	0.0	0	0	0	0	0
06/07/2020 20:00	0.0	0	0	0	0	0
06/07/2020 21:00	0.0	0	0	0	0	0
06/07/2020 22:00	0.0	0	0	0	0	0
06/07/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/08/2020 00:00	0.0	0	0	0	0	0
06/08/2020 01:00	0.0	0	0	0	0	0
06/08/2020 02:00	0.0	0	0	0	0	0
06/08/2020 03:00	0.0	0	0	0	0	0
06/08/2020 04:00	0.0	0	0	0	0	0
06/08/2020 05:00	0.0	0	0	0	0	0
06/08/2020 06:00	0.0	0	0	0	0	0
06/08/2020 07:00	0.0	0	0	0	0	0
06/08/2020 08:00	0.0	0	0	0	0	0
06/08/2020 09:00	74.3	1	0	0	0	0
06/08/2020 10:00	19.8	1	0	0	0	0
06/08/2020 11:00	20.6	1	0	0	0	0
06/08/2020 12:00	53.1	1	0	0	0	0
06/08/2020 13:00	0.0	0	0	0	0	1
06/08/2020 14:00	0.0	0	0	0	0	1
06/08/2020 15:00	0.0	0	0	0	0	1
06/08/2020 16:00	0.0	0	0	0	0	1
06/08/2020 17:00	0.0	0	0	0	0	1
06/08/2020 18:00	0.0	0	0	0	0	1
06/08/2020 19:00	0.0	0	0	0	0	1
06/08/2020 20:00	0.0	0	0	0	0	1
06/08/2020 21:00	0.0	0	0	0	0	1
06/08/2020 22:00	0.0	0	0	0	0	1
06/08/2020 23:00	1.0	0	0	0	1	0
Average/Sum#:	168.8 #	4 #	0 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	74.3	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/09/2020 00:00	0.0	0	0	0	0	0
06/09/2020 01:00	0.0	0	0	0	0	0
06/09/2020 02:00	0.0	0	0	0	0	0
06/09/2020 03:00	0.0	0	0	0	0	0
06/09/2020 04:00	0.0	0	0	0	0	0
06/09/2020 05:00	0.0	0	0	0	0	0
06/09/2020 06:00	0.0	0	0	0	0	0
06/09/2020 07:00	0.0	0	0	0	0	0
06/09/2020 08:00	12.2	0	1	0	0	0
06/09/2020 09:00	22.6	0	1	0	0	0
06/09/2020 10:00	37.0	0	1	0	0	0
06/09/2020 11:00	0.0	0	0	0	0	1
06/09/2020 12:00	0.0	0	0	0	0	1
06/09/2020 13:00	0.0	0	0	0	0	1
06/09/2020 14:00	0.0	0	0	0	0	1
06/09/2020 15:00	0.0	0	0	0	0	1
06/09/2020 16:00	0.0	0	0	0	0	1
06/09/2020 17:00	0.0	0	0	0	0	1
06/09/2020 18:00	0.0	0	0	0	0	1
06/09/2020 19:00	0.0	0	0	0	0	1
06/09/2020 20:00	0.0	0	0	0	0	1
06/09/2020 21:00	0.0	0	0	0	0	1
06/09/2020 22:00	0.0	0	0	0	0	1
06/09/2020 23:00	1.5	0	0	0	1	0
Average/Sum#:	73.3 #	0 #	3 #	0 #	1 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	37.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/10/2020 00:00	0.0	0	0	0	0	0
06/10/2020 01:00	0.0	0	0	0	0	0
06/10/2020 02:00	0.0	0	0	0	0	0
06/10/2020 03:00	0.0	0	0	0	0	0
06/10/2020 04:00	0.0	0	0	0	0	0
06/10/2020 05:00	0.0	0	0	0	0	0
06/10/2020 06:00	0.0	0	0	0	0	0
06/10/2020 07:00	9.0	0	1	0	0	0
06/10/2020 08:00	34.7	0	1	0	0	0
06/10/2020 09:00	0.0	0	0	0	0	1
06/10/2020 10:00	0.0	0	0	0	0	1
06/10/2020 11:00	0.0	0	0	0	0	1
06/10/2020 12:00	0.0	0	0	0	0	1
06/10/2020 13:00	0.0	0	0	0	0	1
06/10/2020 14:00	0.0	0	0	0	0	1
06/10/2020 15:00	0.0	0	0	0	0	1
06/10/2020 16:00	0.0	0	0	0	0	1
06/10/2020 17:00	0.0	0	0	0	0	1
06/10/2020 18:00	0.0	0	0	0	0	1
06/10/2020 19:00	0.0	0	0	0	0	1
06/10/2020 20:00	0.0	0	0	0	0	1
06/10/2020 21:00	0.0	0	0	0	0	1
06/10/2020 22:00	0.0	0	0	0	0	1
06/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	43.7 #	0 #	2 #	0 #	0 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	34.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/11/2020 00:00	0.0	0	0	0	0	1
06/11/2020 01:00	0.0	0	0	0	0	1
06/11/2020 02:00	0.0	0	0	0	0	1
06/11/2020 03:00	0.0	0	0	0	0	1
06/11/2020 04:00	0.0	0	0	0	0	1
06/11/2020 05:00	0.0	0	0	0	0	1
06/11/2020 06:00	0.0	0	0	0	0	1
06/11/2020 07:00	0.0	0	0	0	0	1
06/11/2020 08:00	0.0	0	0	0	0	1
06/11/2020 09:00	0.0	0	0	0	0	1
06/11/2020 10:00	0.0	0	0	0	0	1
06/11/2020 11:00	0.0	0	0	0	0	1
06/11/2020 12:00	0.0	0	0	0	0	1
06/11/2020 13:00	0.0	0	0	0	0	1
06/11/2020 14:00	0.0	0	0	0	0	1
06/11/2020 15:00	0.0	0	0	0	0	1
06/11/2020 16:00	0.0	0	0	0	0	1
06/11/2020 17:00	0.0	0	0	0	0	1
06/11/2020 18:00	0.0	0	0	0	0	1
06/11/2020 19:00	0.0	0	0	0	0	1
06/11/2020 20:00	0.0	0	0	0	0	1
06/11/2020 21:00	0.0	0	0	0	0	1
06/11/2020 22:00	0.0	0	0	0	0	1
06/11/2020 23:00	1.6	0	0	0	1	0
Average/Sum#:	1.6 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/12/2020 00:00	0.0	0	0	0	0	0
06/12/2020 01:00	0.0	0	0	0	0	0
06/12/2020 02:00	0.0	0	0	0	0	0
06/12/2020 03:00	0.0	0	0	0	0	0
06/12/2020 04:00	0.0	0	0	0	0	0
06/12/2020 05:00	0.0	0	0	0	0	0
06/12/2020 06:00	0.0	0	0	0	0	0
06/12/2020 07:00	0.0	0	0	0	0	0
06/12/2020 08:00	0.0	0	0	0	0	0
06/12/2020 09:00	0.0	0	0	0	0	0
06/12/2020 10:00	0.0	0	0	0	0	0
06/12/2020 11:00	0.0	0	0	0	0	0
06/12/2020 12:00	0.0	0	0	0	0	0
06/12/2020 13:00	0.0	0	0	0	0	0
06/12/2020 14:00	0.0	0	0	0	0	0
06/12/2020 15:00	0.0	0	0	0	0	0
06/12/2020 16:00	0.0	0	0	0	0	0
06/12/2020 17:00	0.0	0	0	0	0	0
06/12/2020 18:00	0.0	0	0	0	0	0
06/12/2020 19:00	0.0	0	0	0	0	0
06/12/2020 20:00	0.0	0	0	0	0	0
06/12/2020 21:00	0.0	0	0	0	0	0
06/12/2020 22:00	0.0	0	0	0	0	0
06/12/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/13/2020 00:00	0.0	0	0	0	0	0
06/13/2020 01:00	0.0	0	0	0	0	0
06/13/2020 02:00	0.0	0	0	0	0	0
06/13/2020 03:00	0.0	0	0	0	0	0
06/13/2020 04:00	0.0	0	0	0	0	0
06/13/2020 05:00	0.0	0	0	0	0	0
06/13/2020 06:00	0.0	0	0	0	0	0
06/13/2020 07:00	0.0	0	0	0	0	0
06/13/2020 08:00	0.0	0	0	0	0	0
06/13/2020 09:00	0.0	0	0	0	0	0
06/13/2020 10:00	0.0	0	0	0	0	0
06/13/2020 11:00	0.0	0	0	0	0	0
06/13/2020 12:00	0.0	0	0	0	0	0
06/13/2020 13:00	0.0	0	0	0	0	0
06/13/2020 14:00	0.0	0	0	0	0	0
06/13/2020 15:00	0.0	0	0	0	0	0
06/13/2020 16:00	0.0	0	0	0	0	0
06/13/2020 17:00	0.0	0	0	0	0	0
06/13/2020 18:00	0.0	0	0	0	0	0
06/13/2020 19:00	0.0	0	0	0	0	0
06/13/2020 20:00	0.0	0	0	0	0	0
06/13/2020 21:00	0.0	0	0	0	0	0
06/13/2020 22:00	0.0	0	0	0	0	0
06/13/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/14/2020 00:00	0.0	0	0	0	0	0
06/14/2020 01:00	0.0	0	0	0	0	0
06/14/2020 02:00	0.0	0	0	0	0	0
06/14/2020 03:00	0.0	0	0	0	0	0
06/14/2020 04:00	0.0	0	0	0	0	0
06/14/2020 05:00	0.0	0	0	0	0	0
06/14/2020 06:00	0.0	0	0	0	0	0
06/14/2020 07:00	0.0	0	0	0	0	0
06/14/2020 08:00	0.0	0	0	0	0	0
06/14/2020 09:00	0.0	0	0	0	0	0
06/14/2020 10:00	0.0	0	0	0	0	0
06/14/2020 11:00	0.0	0	0	0	0	0
06/14/2020 12:00	89.2	0	1	0	0	0
06/14/2020 13:00	42.1	0	1	0	0	0
06/14/2020 14:00	80.1	0	1	0	0	0
06/14/2020 15:00	0.0	0	0	0	0	1
06/14/2020 16:00	0.0	0	0	0	0	1
06/14/2020 17:00	0.0	0	0	0	0	1
06/14/2020 18:00	0.0	0	0	0	0	1
06/14/2020 19:00	0.0	0	0	0	0	1
06/14/2020 20:00	0.0	0	0	0	0	1
06/14/2020 21:00	0.0	0	0	0	0	1
06/14/2020 22:00	0.0	0	0	0	0	1
06/14/2020 23:00	2.0	0	0	0	1	0
Average/Sum#:	213.4 #	0 #	3 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	89.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/15/2020 00:00	0.0	0	0	0	0	0
06/15/2020 01:00	0.0	0	0	0	0	0
06/15/2020 02:00	0.0	0	0	0	0	0
06/15/2020 03:00	0.0	0	0	0	0	0
06/15/2020 04:00	0.0	0	0	0	0	0
06/15/2020 05:00	0.0	0	0	0	0	0
06/15/2020 06:00	0.0	0	0	0	0	0
06/15/2020 07:00	0.0	0	0	0	0	0
06/15/2020 08:00	0.0	0	0	0	0	0
06/15/2020 09:00	0.0	0	0	0	0	0
06/15/2020 10:00	0.0	0	0	0	0	0
06/15/2020 11:00	0.0	0	0	0	0	0
06/15/2020 12:00	0.0	0	0	0	0	0
06/15/2020 13:00	0.0	0	0	0	0	0
06/15/2020 14:00	0.0	0	0	0	0	0
06/15/2020 15:00	0.0	0	0	0	0	0
06/15/2020 16:00	0.0	0	0	0	0	0
06/15/2020 17:00	0.0	0	0	0	0	0
06/15/2020 18:00	0.0	0	0	0	0	0
06/15/2020 19:00	0.0	0	0	0	0	0
06/15/2020 20:00	0.0	0	0	0	0	0
06/15/2020 21:00	0.0	0	0	0	0	0
06/15/2020 22:00	0.0	0	0	0	0	0
06/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/16/2020 00:00	0.0	0	0	0	0	0
06/16/2020 01:00	0.0	0	0	0	0	0
06/16/2020 02:00	0.0	0	0	0	0	0
06/16/2020 03:00	0.0	0	0	0	0	0
06/16/2020 04:00	0.0	0	0	0	0	0
06/16/2020 05:00	0.0	0	0	0	0	0
06/16/2020 06:00	0.0	0	0	0	0	0
06/16/2020 07:00	0.0	0	0	0	0	0
06/16/2020 08:00	0.0	0	0	0	0	0
06/16/2020 09:00	0.0	0	0	0	0	0
06/16/2020 10:00	0.0	0	0	0	0	0
06/16/2020 11:00	0.0	0	0	0	0	0
06/16/2020 12:00	0.0	0	0	0	0	0
06/16/2020 13:00	0.0	0	0	0	0	0
06/16/2020 14:00	0.0	0	0	0	0	0
06/16/2020 15:00	0.0	0	0	0	0	0
06/16/2020 16:00	0.0	0	0	0	0	0
06/16/2020 17:00	0.0	0	0	0	0	0
06/16/2020 18:00	0.0	0	0	0	0	0
06/16/2020 19:00	0.0	0	0	0	0	0
06/16/2020 20:00	0.0	0	0	0	0	0
06/16/2020 21:00	0.0	0	0	0	0	0
06/16/2020 22:00	0.0	0	0	0	0	0
06/16/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/17/2020 00:00	0.0	0	0	0	0	0
06/17/2020 01:00	0.0	0	0	0	0	0
06/17/2020 02:00	0.0	0	0	0	0	0
06/17/2020 03:00	0.0	0	0	0	0	0
06/17/2020 04:00	0.0	0	0	0	0	0
06/17/2020 05:00	0.0	0	0	0	0	0
06/17/2020 06:00	0.0	0	0	0	0	0
06/17/2020 07:00	0.0	0	0	0	0	0
06/17/2020 08:00	0.0	0	0	0	0	0
06/17/2020 09:00	77.8	0	1	0	0	0
06/17/2020 10:00	20.4	0	1	0	0	0
06/17/2020 11:00	17.9	0	1	0	0	0
06/17/2020 12:00	0.0	0	0	0	0	1
06/17/2020 13:00	0.0	0	0	0	0	1
06/17/2020 14:00	0.0	0	0	0	0	1
06/17/2020 15:00	0.0	0	0	0	0	1
06/17/2020 16:00	0.0	0	0	0	0	1
06/17/2020 17:00	0.0	0	0	0	0	1
06/17/2020 18:00	0.0	0	0	0	0	1
06/17/2020 19:00	0.0	0	0	0	0	1
06/17/2020 20:00	0.0	0	0	0	0	1
06/17/2020 21:00	0.0	0	0	0	0	1
06/17/2020 22:00	0.0	0	0	0	0	1
06/17/2020 23:00	1.4	0	0	0	1	0
Average/Sum#:	117.5 #	0 #	3 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	77.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/18/2020 00:00	0.0	0	0	0	0	0
06/18/2020 01:00	0.0	0	0	0	0	0
06/18/2020 02:00	0.0	0	0	0	0	0
06/18/2020 03:00	0.0	0	0	0	0	0
06/18/2020 04:00	0.0	0	0	0	0	0
06/18/2020 05:00	0.0	0	0	0	0	0
06/18/2020 06:00	0.0	0	0	0	0	0
06/18/2020 07:00	8.1	0	1	0	0	0
06/18/2020 08:00	23.4	0	1	0	0	0
06/18/2020 09:00	0.0	0	0	0	0	1
06/18/2020 10:00	0.0	0	0	0	0	1
06/18/2020 11:00	0.0	0	0	0	0	1
06/18/2020 12:00	0.0	0	0	0	0	1
06/18/2020 13:00	0.0	0	0	0	0	1
06/18/2020 14:00	0.0	0	0	0	0	1
06/18/2020 15:00	0.0	0	0	0	0	1
06/18/2020 16:00	0.0	0	0	0	0	1
06/18/2020 17:00	0.0	0	0	0	0	1
06/18/2020 18:00	0.0	0	0	0	0	1
06/18/2020 19:00	0.0	0	0	0	0	1
06/18/2020 20:00	0.0	0	0	0	0	1
06/18/2020 21:00	0.0	0	0	0	0	1
06/18/2020 22:00	0.0	0	0	0	0	1
06/18/2020 23:00	1.9	0	0	0	1	0
Average/Sum#:	33.4 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	23.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/19/2020 00:00	0.0	0	0	0	0	0
06/19/2020 01:00	0.0	0	0	0	0	0
06/19/2020 02:00	0.0	0	0	0	0	0
06/19/2020 03:00	0.0	0	0	0	0	0
06/19/2020 04:00	0.0	0	0	0	0	0
06/19/2020 05:00	0.0	0	0	0	0	0
06/19/2020 06:00	0.0	0	0	0	0	0
06/19/2020 07:00	0.0	0	0	0	0	0
06/19/2020 08:00	0.0	0	0	0	0	0
06/19/2020 09:00	0.0	0	0	0	0	0
06/19/2020 10:00	0.0	0	0	0	0	0
06/19/2020 11:00	0.0	0	0	0	0	0
06/19/2020 12:00	0.0	0	0	0	0	0
06/19/2020 13:00	0.0	0	0	0	0	0
06/19/2020 14:00	0.0	0	0	0	0	0
06/19/2020 15:00	0.0	0	0	0	0	0
06/19/2020 16:00	0.0	0	0	0	0	0
06/19/2020 17:00	0.0	0	0	0	0	0
06/19/2020 18:00	0.0	0	0	0	0	0
06/19/2020 19:00	0.0	0	0	0	0	0
06/19/2020 20:00	0.0	0	0	0	0	0
06/19/2020 21:00	0.0	0	0	0	0	0
06/19/2020 22:00	0.0	0	0	0	0	0
06/19/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/20/2020 00:00	0.0	0	0	0	0	0
06/20/2020 01:00	0.0	0	0	0	0	0
06/20/2020 02:00	0.0	0	0	0	0	0
06/20/2020 03:00	0.0	0	0	0	0	0
06/20/2020 04:00	0.0	0	0	0	0	0
06/20/2020 05:00	0.0	0	0	0	0	0
06/20/2020 06:00	0.0	0	0	0	0	0
06/20/2020 07:00	0.0	0	0	0	0	0
06/20/2020 08:00	0.0	0	0	0	0	0
06/20/2020 09:00	0.0	0	0	0	0	0
06/20/2020 10:00	0.0	0	0	0	0	0
06/20/2020 11:00	0.0	0	0	0	0	0
06/20/2020 12:00	0.0	0	0	0	0	0
06/20/2020 13:00	0.0	0	0	0	0	0
06/20/2020 14:00	0.0	0	0	0	0	0
06/20/2020 15:00	0.0	0	0	0	0	0
06/20/2020 16:00	0.0	0	0	0	0	0
06/20/2020 17:00	0.0	0	0	0	0	0
06/20/2020 18:00	0.0	0	0	0	0	0
06/20/2020 19:00	0.0	0	0	0	0	0
06/20/2020 20:00	88.5	0	1	0	0	0
06/20/2020 21:00	27.9	0	1	0	0	0
06/20/2020 22:00	36.0	0	1	0	0	0
06/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	152.4 #	0 #	3 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	88.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/21/2020 00:00	0.0	0	0	0	0	1
06/21/2020 01:00	0.0	0	0	0	0	1
06/21/2020 02:00	0.0	0	0	0	0	1
06/21/2020 03:00	0.0	0	0	0	0	1
06/21/2020 04:00	0.0	0	0	0	0	1
06/21/2020 05:00	0.0	0	0	0	0	1
06/21/2020 06:00	0.0	0	0	0	0	1
06/21/2020 07:00	0.0	0	0	0	0	1
06/21/2020 08:00	0.0	0	0	0	0	1
06/21/2020 09:00	0.0	0	0	0	0	1
06/21/2020 10:00	0.0	0	0	0	0	1
06/21/2020 11:00	0.0	0	0	0	0	1
06/21/2020 12:00	0.0	0	0	0	0	1
06/21/2020 13:00	0.0	0	0	0	0	1
06/21/2020 14:00	0.0	0	0	0	0	1
06/21/2020 15:00	0.0	0	0	0	0	1
06/21/2020 16:00	0.0	0	0	0	0	1
06/21/2020 17:00	0.0	0	0	0	0	1
06/21/2020 18:00	0.0	0	0	0	0	1
06/21/2020 19:00	0.0	0	0	0	0	1
06/21/2020 20:00	0.0	0	0	0	0	1
06/21/2020 21:00	0.0	0	0	0	0	1
06/21/2020 22:00	0.0	0	0	0	0	1
06/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/22/2020 00:00	0.0	0	0	0	0	1
06/22/2020 01:00	0.0	0	0	0	0	1
06/22/2020 02:00	0.0	0	0	0	0	1
06/22/2020 03:00	0.0	0	0	0	0	1
06/22/2020 04:00	0.0	0	0	0	0	1
06/22/2020 05:00	0.0	0	0	0	0	1
06/22/2020 06:00	0.0	0	0	0	0	1
06/22/2020 07:00	0.0	0	0	0	0	1
06/22/2020 08:00	0.0	0	0	0	0	1
06/22/2020 09:00	0.0	0	0	0	0	1
06/22/2020 10:00	0.0	0	0	0	0	1
06/22/2020 11:00	0.0	0	0	0	0	1
06/22/2020 12:00	0.0	0	0	0	0	1
06/22/2020 13:00	0.0	0	0	0	0	1
06/22/2020 14:00	0.0	0	0	0	0	1
06/22/2020 15:00	0.0	0	0	0	0	1
06/22/2020 16:00	0.0	0	0	0	0	1
06/22/2020 17:00	0.0	0	0	0	0	1
06/22/2020 18:00	0.0	0	0	0	0	1
06/22/2020 19:00	0.0	0	0	0	0	1
06/22/2020 20:00	0.0	0	0	0	0	1
06/22/2020 21:00	0.0	0	0	0	0	1
06/22/2020 22:00	0.0	0	0	0	0	1
06/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/23/2020 00:00	2.1	0	0	0	1	0
06/23/2020 01:00	0.0	0	0	0	0	0
06/23/2020 02:00	0.0	0	0	0	0	0
06/23/2020 03:00	0.0	0	0	0	0	0
06/23/2020 04:00	0.0	0	0	0	0	0
06/23/2020 05:00	0.0	0	0	0	0	0
06/23/2020 06:00	0.0	0	0	0	0	0
06/23/2020 07:00	0.0	0	0	0	0	0
06/23/2020 08:00	0.0	0	0	0	0	0
06/23/2020 09:00	0.0	0	0	0	0	0
06/23/2020 10:00	0.0	0	0	0	0	0
06/23/2020 11:00	0.0	0	0	0	0	0
06/23/2020 12:00	7.3	0	1	0	0	0
06/23/2020 13:00	52.1	0	1	0	0	0
06/23/2020 14:00	1.0	0	1	0	0	0
06/23/2020 15:00	0.0	0	0	0	0	1
06/23/2020 16:00	0.0	0	0	0	0	1
06/23/2020 17:00	0.0	0	0	0	0	1
06/23/2020 18:00	0.0	0	0	0	0	1
06/23/2020 19:00	0.0	0	0	0	0	1
06/23/2020 20:00	0.0	0	0	0	0	1
06/23/2020 21:00	0.0	0	0	0	0	1
06/23/2020 22:00	0.0	0	0	0	0	1
06/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	62.5 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	52.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/24/2020 00:00	0.0	0	0	0	0	1
06/24/2020 01:00	0.0	0	0	0	0	1
06/24/2020 02:00	0.0	0	0	0	0	1
06/24/2020 03:00	0.0	0	0	0	0	1
06/24/2020 04:00	0.0	0	0	0	0	1
06/24/2020 05:00	0.0	0	0	0	0	1
06/24/2020 06:00	0.0	0	0	0	0	1
06/24/2020 07:00	0.0	0	0	0	0	1
06/24/2020 08:00	0.0	0	0	0	0	1
06/24/2020 09:00	0.0	0	0	0	0	1
06/24/2020 10:00	0.0	0	0	0	0	1
06/24/2020 11:00	0.0	0	0	0	0	1
06/24/2020 12:00	0.0	0	0	0	0	1
06/24/2020 13:00	0.0	0	0	0	0	1
06/24/2020 14:00	0.0	0	0	0	0	1
06/24/2020 15:00	0.0	0	0	0	0	1
06/24/2020 16:00	0.0	0	0	0	0	1
06/24/2020 17:00	0.0	0	0	0	0	1
06/24/2020 18:00	0.0	0	0	0	0	1
06/24/2020 19:00	0.0	0	0	0	0	1
06/24/2020 20:00	0.0	0	0	0	0	1
06/24/2020 21:00	0.0	0	0	0	0	1
06/24/2020 22:00	0.0	0	0	0	0	1
06/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/25/2020 00:00	1.7	0	0	0	1	0
06/25/2020 01:00	0.0	0	0	0	0	0
06/25/2020 02:00	0.0	0	0	0	0	0
06/25/2020 03:00	0.0	0	0	0	0	0
06/25/2020 04:00	0.0	0	0	0	0	0
06/25/2020 05:00	0.0	0	0	0	0	0
06/25/2020 06:00	0.0	0	0	0	0	0
06/25/2020 07:00	0.0	0	0	0	0	0
06/25/2020 08:00	4.5	0	1	0	0	0
06/25/2020 09:00	29.3	0	1	0	0	0
06/25/2020 10:00	0.0	0	0	0	0	1
06/25/2020 11:00	0.0	0	0	0	0	1
06/25/2020 12:00	0.0	0	0	0	0	1
06/25/2020 13:00	0.0	0	0	0	0	1
06/25/2020 14:00	0.0	0	0	0	0	1
06/25/2020 15:00	0.0	0	0	0	0	1
06/25/2020 16:00	0.0	0	0	0	0	1
06/25/2020 17:00	0.0	0	0	0	0	1
06/25/2020 18:00	0.0	0	0	0	0	1
06/25/2020 19:00	0.0	0	0	0	0	1
06/25/2020 20:00	0.0	0	0	0	0	1
06/25/2020 21:00	0.0	0	0	0	0	1
06/25/2020 22:00	1.3	0	0	0	1	0
06/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	36.8 #	0 #	2 #	0 #	2 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	29.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/26/2020 00:00	0.0	0	0	0	0	0
06/26/2020 01:00	0.0	0	0	0	0	0
06/26/2020 02:00	0.0	0	0	0	0	0
06/26/2020 03:00	0.0	0	0	0	0	0
06/26/2020 04:00	0.0	0	0	0	0	0
06/26/2020 05:00	3.9	0	0	1	0	0
06/26/2020 06:00	41.3	0	0	1	0	0
06/26/2020 07:00	0.0	0	0	0	0	1
06/26/2020 08:00	0.0	0	0	0	0	1
06/26/2020 09:00	0.0	0	0	0	0	1
06/26/2020 10:00	0.0	0	0	0	0	1
06/26/2020 11:00	0.0	0	0	0	0	1
06/26/2020 12:00	0.0	0	0	0	0	1
06/26/2020 13:00	0.0	0	0	0	0	1
06/26/2020 14:00	0.0	0	0	0	0	1
06/26/2020 15:00	0.0	0	0	0	0	1
06/26/2020 16:00	0.0	0	0	0	0	1
06/26/2020 17:00	0.0	0	0	0	0	1
06/26/2020 18:00	0.0	0	0	0	0	1
06/26/2020 19:00	0.0	0	0	0	0	1
06/26/2020 20:00	0.0	0	0	0	0	1
06/26/2020 21:00	0.0	0	0	0	0	1
06/26/2020 22:00	0.0	0	0	0	0	1
06/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	45.2 #	0 #	0 #	2 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	41.3	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/27/2020 00:00	0.9	0	0	0	1	0
06/27/2020 01:00	0.0	0	0	0	0	0
06/27/2020 02:00	0.0	0	0	0	0	0
06/27/2020 03:00	0.0	0	0	0	0	0
06/27/2020 04:00	0.0	0	0	0	0	0
06/27/2020 05:00	0.0	0	0	0	0	0
06/27/2020 06:00	0.0	0	0	0	0	0
06/27/2020 07:00	0.0	0	0	0	0	0
06/27/2020 08:00	0.0	0	0	0	0	0
06/27/2020 09:00	0.0	0	0	0	0	0
06/27/2020 10:00	0.0	0	0	0	0	0
06/27/2020 11:00	0.0	0	0	0	0	0
06/27/2020 12:00	0.0	0	0	0	0	0
06/27/2020 13:00	0.0	0	0	0	0	0
06/27/2020 14:00	0.0	0	0	0	0	0
06/27/2020 15:00	0.0	0	0	0	0	0
06/27/2020 16:00	0.0	0	0	0	0	0
06/27/2020 17:00	0.0	0	0	0	0	0
06/27/2020 18:00	0.0	0	0	0	0	0
06/27/2020 19:00	0.0	0	0	0	0	0
06/27/2020 20:00	0.0	0	0	0	0	0
06/27/2020 21:00	0.0	0	0	0	0	0
06/27/2020 22:00	0.0	0	0	0	0	0
06/27/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.9 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/28/2020 00:00	0.0	0	0	0	0	0
06/28/2020 01:00	0.0	0	0	0	0	0
06/28/2020 02:00	0.0	0	0	0	0	0
06/28/2020 03:00	0.0	0	0	0	0	0
06/28/2020 04:00	0.0	0	0	0	0	0
06/28/2020 05:00	0.0	0	0	0	0	0
06/28/2020 06:00	0.0	0	0	0	0	0
06/28/2020 07:00	0.0	0	0	0	0	0
06/28/2020 08:00	0.0	0	0	0	0	0
06/28/2020 09:00	0.0	0	0	0	0	0
06/28/2020 10:00	0.0	0	0	0	0	0
06/28/2020 11:00	0.0	0	0	0	0	0
06/28/2020 12:00	0.0	0	0	0	0	0
06/28/2020 13:00	0.0	0	0	0	0	0
06/28/2020 14:00	0.0	0	0	0	0	0
06/28/2020 15:00	0.0	0	0	0	0	0
06/28/2020 16:00	0.0	0	0	0	0	0
06/28/2020 17:00	0.0	0	0	0	0	0
06/28/2020 18:00	0.0	0	0	0	0	0
06/28/2020 19:00	0.0	0	0	0	0	0
06/28/2020 20:00	0.0	0	0	0	0	0
06/28/2020 21:00	0.0	0	0	0	0	0
06/28/2020 22:00	0.0	0	0	0	0	0
06/28/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/29/2020 00:00	0.0	0	0	0	0	0
06/29/2020 01:00	0.0	0	0	0	0	0
06/29/2020 02:00	0.0	0	0	0	0	0
06/29/2020 03:00	0.0	0	0	0	0	0
06/29/2020 04:00	0.0	0	0	0	0	0
06/29/2020 05:00	0.0	0	0	0	0	0
06/29/2020 06:00	0.0	0	0	0	0	0
06/29/2020 07:00	0.0	0	0	0	0	0
06/29/2020 08:00	0.0	0	0	0	0	0
06/29/2020 09:00	0.0	0	0	0	0	0
06/29/2020 10:00	0.0	0	0	0	0	0
06/29/2020 11:00	0.0	0	0	0	0	0
06/29/2020 12:00	0.0	0	0	0	0	0
06/29/2020 13:00	0.0	0	0	0	0	0
06/29/2020 14:00	0.0	0	0	0	0	0
06/29/2020 15:00	0.0	0	0	0	0	0
06/29/2020 16:00	0.0	0	0	0	0	0
06/29/2020 17:00	0.0	0	0	0	0	0
06/29/2020 18:00	0.0	0	0	0	0	0
06/29/2020 19:00	0.0	0	0	0	0	0
06/29/2020 20:00	0.0	0	0	0	0	0
06/29/2020 21:00	0.0	0	0	0	0	0
06/29/2020 22:00	0.0	0	0	0	0	0
06/29/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/30/2020 00:00	0.0	0	0	0	0	0
06/30/2020 01:00	0.0	0	0	0	0	0
06/30/2020 02:00	0.0	0	0	0	0	0
06/30/2020 03:00	0.0	0	0	0	0	0
06/30/2020 04:00	0.0	0	0	0	0	0
06/30/2020 05:00	0.0	0	0	0	0	0
06/30/2020 06:00	0.0	0	0	0	0	0
06/30/2020 07:00	0.0	0	0	0	0	0
06/30/2020 08:00	70.2	1	0	0	0	0
06/30/2020 09:00	24.5	1	0	0	0	0
06/30/2020 10:00	30.8	1	0	0	0	0
06/30/2020 11:00	69.3	1	0	0	0	0
06/30/2020 12:00	0.0	0	0	0	0	1
06/30/2020 13:00	0.0	0	0	0	0	1
06/30/2020 14:00	0.0	0	0	0	0	1
06/30/2020 15:00	0.0	0	0	0	0	1
06/30/2020 16:00	0.0	0	0	0	0	1
06/30/2020 17:00	0.0	0	0	0	0	1
06/30/2020 18:00	0.0	0	0	0	0	1
06/30/2020 19:00	0.0	0	0	0	0	1
06/30/2020 20:00	0.0	0	0	0	0	1
06/30/2020 21:00	0.0	0	0	0	0	1
06/30/2020 22:00	1.5	0	0	0	1	0
06/30/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	196.3 #	4 #	0 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	70.2	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/01/2020 00:00	0.0	0	0	0	0	1
04/01/2020 01:00	0.0	0	0	0	0	1
04/01/2020 02:00	0.0	0	0	0	0	1
04/01/2020 03:00	0.0	0	0	0	0	1
04/01/2020 04:00	0.0	0	0	0	0	1
04/01/2020 05:00	0.0	0	0	0	0	1
04/01/2020 06:00	0.0	0	0	0	0	1
04/01/2020 07:00	0.0	0	0	0	0	1
04/01/2020 08:00	0.0	0	0	0	0	1
04/01/2020 09:00	0.0	0	0	0	0	1
04/01/2020 10:00	0.0	0	0	0	0	1
04/01/2020 11:00	0.0	0	0	0	0	1
04/01/2020 12:00	0.0	0	0	0	0	1
04/01/2020 13:00	0.0	0	0	0	0	1
04/01/2020 14:00	0.0	0	0	0	0	1
04/01/2020 15:00	0.0	0	0	0	0	1
04/01/2020 16:00	0.0	0	0	0	0	1
04/01/2020 17:00	0.0	0	0	0	0	1
04/01/2020 18:00	0.0	0	0	0	0	1
04/01/2020 19:00	0.0	0	0	0	0	1
04/01/2020 20:00	0.0	0	0	0	0	1
04/01/2020 21:00	0.0	0	0	0	0	1
04/01/2020 22:00	0.0	0	0	0	0	1
04/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/02/2020 00:00	0.0	0	0	0	0	1
04/02/2020 01:00	0.0	0	0	0	0	1
04/02/2020 02:00	0.0	0	0	0	0	1
04/02/2020 03:00	0.0	0	0	0	0	1
04/02/2020 04:00	0.0	0	0	0	0	1
04/02/2020 05:00	0.0	0	0	0	0	1
04/02/2020 06:00	0.0	0	0	0	0	1
04/02/2020 07:00	0.0	0	0	0	0	1
04/02/2020 08:00	0.0	0	0	0	0	1
04/02/2020 09:00	0.0	0	0	0	0	1
04/02/2020 10:00	0.0	0	0	0	0	1
04/02/2020 11:00	0.0	0	0	0	0	1
04/02/2020 12:00	0.0	0	0	0	0	1
04/02/2020 13:00	0.0	0	0	0	0	1
04/02/2020 14:00	0.0	0	0	0	0	1
04/02/2020 15:00	0.0	0	0	0	0	1
04/02/2020 16:00	0.0	0	0	0	0	1
04/02/2020 17:00	0.0	0	0	0	0	1
04/02/2020 18:00	0.0	0	0	0	0	1
04/02/2020 19:00	0.0	0	0	0	0	1
04/02/2020 20:00	0.0	0	0	0	0	1
04/02/2020 21:00	102.2	0	0	0	1	0
04/02/2020 22:00	0.0	0	0	0	0	0
04/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	102.2 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	102.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/03/2020 00:00	0.0	0	0	0	0	0
04/03/2020 01:00	0.0	0	0	0	0	0
04/03/2020 02:00	0.0	0	0	0	0	0
04/03/2020 03:00	0.0	0	0	0	0	0
04/03/2020 04:00	0.0	0	0	0	0	0
04/03/2020 05:00	0.0	0	0	0	0	0
04/03/2020 06:00	0.0	0	0	0	0	0
04/03/2020 07:00	0.0	0	0	0	0	0
04/03/2020 08:00	0.0	0	0	0	0	0
04/03/2020 09:00	0.0	0	0	0	0	0
04/03/2020 10:00	0.0	0	0	0	0	0
04/03/2020 11:00	0.0	0	0	0	0	0
04/03/2020 12:00	0.0	0	0	0	0	0
04/03/2020 13:00	0.0	0	0	0	0	0
04/03/2020 14:00	0.0	0	0	0	0	0
04/03/2020 15:00	0.0	0	0	0	0	0
04/03/2020 16:00	0.0	0	0	0	0	0
04/03/2020 17:00	0.0	0	0	0	0	0
04/03/2020 18:00	0.0	0	0	0	0	0
04/03/2020 19:00	0.0	0	0	0	0	0
04/03/2020 20:00	3,190.6	0	1	0	0	0
04/03/2020 21:00	5,064.0	0	1	0	0	0
04/03/2020 22:00	6,434.7	0	1	0	0	0
04/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	14,689.3 #	0 #	3 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,434.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/04/2020 00:00	0.0	0	0	0	0	1
04/04/2020 01:00	0.0	0	0	0	0	1
04/04/2020 02:00	0.0	0	0	0	0	1
04/04/2020 03:00	0.0	0	0	0	0	1
04/04/2020 04:00	0.0	0	0	0	0	1
04/04/2020 05:00	0.0	0	0	0	0	1
04/04/2020 06:00	0.0	0	0	0	0	1
04/04/2020 07:00	0.0	0	0	0	0	1
04/04/2020 08:00	0.0	0	0	0	0	1
04/04/2020 09:00	0.0	0	0	0	0	1
04/04/2020 10:00	0.0	0	0	0	0	1
04/04/2020 11:00	0.0	0	0	0	0	1
04/04/2020 12:00	0.0	0	0	0	0	1
04/04/2020 13:00	0.0	0	0	0	0	1
04/04/2020 14:00	0.0	0	0	0	0	1
04/04/2020 15:00	0.0	0	0	0	0	1
04/04/2020 16:00	0.0	0	0	0	0	1
04/04/2020 17:00	0.0	0	0	0	0	1
04/04/2020 18:00	0.0	0	0	0	0	1
04/04/2020 19:00	0.0	0	0	0	0	1
04/04/2020 20:00	0.0	0	0	0	0	1
04/04/2020 21:00	0.0	0	0	0	0	1
04/04/2020 22:00	0.0	0	0	0	0	1
04/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/05/2020 00:00	0.0	0	0	0	0	1
04/05/2020 01:00	0.0	0	0	0	0	1
04/05/2020 02:00	0.0	0	0	0	0	1
04/05/2020 03:00	0.0	0	0	0	0	1
04/05/2020 04:00	0.0	0	0	0	0	1
04/05/2020 05:00	0.0	0	0	0	0	1
04/05/2020 06:00	0.0	0	0	0	0	1
04/05/2020 07:00	0.0	0	0	0	0	1
04/05/2020 08:00	0.0	0	0	0	0	1
04/05/2020 09:00	0.0	0	0	0	0	1
04/05/2020 10:00	0.0	0	0	0	0	1
04/05/2020 11:00	0.0	0	0	0	0	1
04/05/2020 12:00	0.0	0	0	0	0	1
04/05/2020 13:00	0.0	0	0	0	0	1
04/05/2020 14:00	0.0	0	0	0	0	1
04/05/2020 15:00	0.0	0	0	0	0	1
04/05/2020 16:00	0.0	0	0	0	0	1
04/05/2020 17:00	0.0	0	0	0	0	1
04/05/2020 18:00	0.0	0	0	0	0	1
04/05/2020 19:00	0.0	0	0	0	0	1
04/05/2020 20:00	0.0	0	0	0	0	1
04/05/2020 21:00	0.0	0	0	0	0	1
04/05/2020 22:00	0.0	0	0	0	0	1
04/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/06/2020 00:00	0.0	0	0	0	0	1
04/06/2020 01:00	0.0	0	0	0	0	1
04/06/2020 02:00	0.0	0	0	0	0	1
04/06/2020 03:00	0.0	0	0	0	0	1
04/06/2020 04:00	0.0	0	0	0	0	1
04/06/2020 05:00	0.0	0	0	0	0	1
04/06/2020 06:00	0.0	0	0	0	0	1
04/06/2020 07:00	0.0	0	0	0	0	1
04/06/2020 08:00	0.0	0	0	0	0	1
04/06/2020 09:00	0.0	0	0	0	0	1
04/06/2020 10:00	0.0	0	0	0	0	1
04/06/2020 11:00	0.0	0	0	0	0	1
04/06/2020 12:00	0.0	0	0	0	0	1
04/06/2020 13:00	0.0	0	0	0	0	1
04/06/2020 14:00	0.0	0	0	0	0	1
04/06/2020 15:00	0.0	0	0	0	0	1
04/06/2020 16:00	0.0	0	0	0	0	1
04/06/2020 17:00	0.0	0	0	0	0	1
04/06/2020 18:00	0.0	0	0	0	0	1
04/06/2020 19:00	0.0	0	0	0	0	1
04/06/2020 20:00	0.0	0	0	0	0	1
04/06/2020 21:00	0.0	0	0	0	0	1
04/06/2020 22:00	0.0	0	0	0	0	1
04/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/07/2020 00:00	0.0	0	0	0	0	1
04/07/2020 01:00	0.0	0	0	0	0	1
04/07/2020 02:00	0.0	0	0	0	0	1
04/07/2020 03:00	0.0	0	0	0	0	1
04/07/2020 04:00	0.0	0	0	0	0	1
04/07/2020 05:00	0.0	0	0	0	0	1
04/07/2020 06:00	0.0	0	0	0	0	1
04/07/2020 07:00	0.0	0	0	0	0	1
04/07/2020 08:00	0.0	0	0	0	0	1
04/07/2020 09:00	0.0	0	0	0	0	1
04/07/2020 10:00	0.0	0	0	0	0	1
04/07/2020 11:00	0.0	0	0	0	0	1
04/07/2020 12:00	0.0	0	0	0	0	1
04/07/2020 13:00	0.0	0	0	0	0	1
04/07/2020 14:00	0.0	0	0	0	0	1
04/07/2020 15:00	0.0	0	0	0	0	1
04/07/2020 16:00	0.0	0	0	0	0	1
04/07/2020 17:00	0.0	0	0	0	0	1
04/07/2020 18:00	0.0	0	0	0	0	1
04/07/2020 19:00	0.0	0	0	0	0	1
04/07/2020 20:00	0.0	0	0	0	0	1
04/07/2020 21:00	0.0	0	0	0	0	1
04/07/2020 22:00	0.0	0	0	0	0	1
04/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/08/2020 00:00	0.0	0	0	0	0	1
04/08/2020 01:00	0.0	0	0	0	0	1
04/08/2020 02:00	0.0	0	0	0	0	1
04/08/2020 03:00	0.0	0	0	0	0	1
04/08/2020 04:00	0.0	0	0	0	0	1
04/08/2020 05:00	0.0	0	0	0	0	1
04/08/2020 06:00	0.0	0	0	0	0	1
04/08/2020 07:00	0.0	0	0	0	0	1
04/08/2020 08:00	0.0	0	0	0	0	1
04/08/2020 09:00	0.0	0	0	0	0	1
04/08/2020 10:00	0.0	0	0	0	0	1
04/08/2020 11:00	0.0	0	0	0	0	1
04/08/2020 12:00	0.0	0	0	0	0	1
04/08/2020 13:00	0.0	0	0	0	0	1
04/08/2020 14:00	0.0	0	0	0	0	1
04/08/2020 15:00	0.0	0	0	0	0	1
04/08/2020 16:00	0.0	0	0	0	0	1
04/08/2020 17:00	0.0	0	0	0	0	1
04/08/2020 18:00	0.0	0	0	0	0	1
04/08/2020 19:00	0.0	0	0	0	0	1
04/08/2020 20:00	0.0	0	0	0	0	1
04/08/2020 21:00	0.0	0	0	0	0	1
04/08/2020 22:00	0.0	0	0	0	0	1
04/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/09/2020 00:00	0.0	0	0	0	0	1
04/09/2020 01:00	0.0	0	0	0	0	1
04/09/2020 02:00	0.0	0	0	0	0	1
04/09/2020 03:00	0.0	0	0	0	0	1
04/09/2020 04:00	0.0	0	0	0	0	1
04/09/2020 05:00	0.0	0	0	0	0	1
04/09/2020 06:00	0.0	0	0	0	0	1
04/09/2020 07:00	0.0	0	0	0	0	1
04/09/2020 08:00	0.0	0	0	0	0	1
04/09/2020 09:00	0.0	0	0	0	0	1
04/09/2020 10:00	0.0	0	0	0	0	1
04/09/2020 11:00	0.0	0	0	0	0	1
04/09/2020 12:00	0.0	0	0	0	0	1
04/09/2020 13:00	0.0	0	0	0	0	1
04/09/2020 14:00	0.0	0	0	0	0	1
04/09/2020 15:00	0.0	0	0	0	0	1
04/09/2020 16:00	0.0	0	0	0	0	1
04/09/2020 17:00	0.0	0	0	0	0	1
04/09/2020 18:00	0.0	0	0	0	0	1
04/09/2020 19:00	0.0	0	0	0	0	1
04/09/2020 20:00	0.0	0	0	0	0	1
04/09/2020 21:00	0.0	0	0	0	0	1
04/09/2020 22:00	0.0	0	0	0	0	1
04/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/10/2020 00:00	0.0	0	0	0	0	1
04/10/2020 01:00	0.0	0	0	0	0	1
04/10/2020 02:00	0.0	0	0	0	0	1
04/10/2020 03:00	0.0	0	0	0	0	1
04/10/2020 04:00	0.0	0	0	0	0	1
04/10/2020 05:00	0.0	0	0	0	0	1
04/10/2020 06:00	0.0	0	0	0	0	1
04/10/2020 07:00	0.0	0	0	0	0	1
04/10/2020 08:00	0.0	0	0	0	0	1
04/10/2020 09:00	0.0	0	0	0	0	1
04/10/2020 10:00	0.0	0	0	0	0	1
04/10/2020 11:00	0.0	0	0	0	0	1
04/10/2020 12:00	0.0	0	0	0	0	1
04/10/2020 13:00	0.0	0	0	0	0	1
04/10/2020 14:00	0.0	0	0	0	0	1
04/10/2020 15:00	0.0	0	0	0	0	1
04/10/2020 16:00	0.0	0	0	0	0	1
04/10/2020 17:00	0.0	0	0	0	0	1
04/10/2020 18:00	0.0	0	0	0	0	1
04/10/2020 19:00	0.0	0	0	0	0	1
04/10/2020 20:00	0.0	0	0	0	0	1
04/10/2020 21:00	0.0	0	0	0	0	1
04/10/2020 22:00	0.0	0	0	0	0	1
04/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/11/2020 00:00	0.0	0	0	0	0	1
04/11/2020 01:00	0.0	0	0	0	0	1
04/11/2020 02:00	0.0	0	0	0	0	1
04/11/2020 03:00	0.0	0	0	0	0	1
04/11/2020 04:00	0.0	0	0	0	0	1
04/11/2020 05:00	0.0	0	0	0	0	1
04/11/2020 06:00	0.0	0	0	0	0	1
04/11/2020 07:00	0.0	0	0	0	0	1
04/11/2020 08:00	0.0	0	0	0	0	1
04/11/2020 09:00	0.0	0	0	0	0	1
04/11/2020 10:00	0.0	0	0	0	0	1
04/11/2020 11:00	0.0	0	0	0	0	1
04/11/2020 12:00	0.0	0	0	0	0	1
04/11/2020 13:00	0.0	0	0	0	0	1
04/11/2020 14:00	0.0	0	0	0	0	1
04/11/2020 15:00	0.0	0	0	0	0	1
04/11/2020 16:00	0.0	0	0	0	0	1
04/11/2020 17:00	0.0	0	0	0	0	1
04/11/2020 18:00	0.0	0	0	0	0	1
04/11/2020 19:00	0.0	0	0	0	0	1
04/11/2020 20:00	0.0	0	0	0	0	1
04/11/2020 21:00	0.0	0	0	0	0	1
04/11/2020 22:00	0.0	0	0	0	0	1
04/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/12/2020 00:00	0.0	0	0	0	0	1
04/12/2020 01:00	0.0	0	0	0	0	1
04/12/2020 02:00	0.0	0	0	0	0	1
04/12/2020 03:00	0.0	0	0	0	0	1
04/12/2020 04:00	0.0	0	0	0	0	1
04/12/2020 05:00	0.0	0	0	0	0	1
04/12/2020 06:00	0.0	0	0	0	0	1
04/12/2020 07:00	0.0	0	0	0	0	1
04/12/2020 08:00	0.0	0	0	0	0	1
04/12/2020 09:00	0.0	0	0	0	0	1
04/12/2020 10:00	0.0	0	0	0	0	1
04/12/2020 11:00	0.0	0	0	0	0	1
04/12/2020 12:00	0.0	0	0	0	0	1
04/12/2020 13:00	0.0	0	0	0	0	1
04/12/2020 14:00	0.0	0	0	0	0	1
04/12/2020 15:00	0.0	0	0	0	0	1
04/12/2020 16:00	0.0	0	0	0	0	1
04/12/2020 17:00	0.0	0	0	0	0	1
04/12/2020 18:00	0.0	0	0	0	0	1
04/12/2020 19:00	0.0	0	0	0	0	1
04/12/2020 20:00	0.0	0	0	0	0	1
04/12/2020 21:00	0.0	0	0	0	0	1
04/12/2020 22:00	0.0	0	0	0	0	1
04/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/13/2020 00:00	0.0	0	0	0	0	1
04/13/2020 01:00	0.0	0	0	0	0	1
04/13/2020 02:00	0.0	0	0	0	0	1
04/13/2020 03:00	0.0	0	0	0	0	1
04/13/2020 04:00	0.0	0	0	0	0	1
04/13/2020 05:00	0.0	0	0	0	0	1
04/13/2020 06:00	0.0	0	0	0	0	1
04/13/2020 07:00	0.0	0	0	0	0	1
04/13/2020 08:00	0.0	0	0	0	0	1
04/13/2020 09:00	0.0	0	0	0	0	1
04/13/2020 10:00	0.0	0	0	0	0	1
04/13/2020 11:00	0.0	0	0	0	0	1
04/13/2020 12:00	0.0	0	0	0	0	1
04/13/2020 13:00	0.0	0	0	0	0	1
04/13/2020 14:00	0.0	0	0	0	0	1
04/13/2020 15:00	0.0	0	0	0	0	1
04/13/2020 16:00	0.0	0	0	0	0	1
04/13/2020 17:00	0.0	0	0	0	0	1
04/13/2020 18:00	0.0	0	0	0	0	1
04/13/2020 19:00	0.0	0	0	0	0	1
04/13/2020 20:00	0.0	0	0	0	0	1
04/13/2020 21:00	0.0	0	0	0	0	1
04/13/2020 22:00	0.0	0	0	0	0	1
04/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/14/2020 00:00	0.0	0	0	0	0	1
04/14/2020 01:00	0.0	0	0	0	0	1
04/14/2020 02:00	0.0	0	0	0	0	1
04/14/2020 03:00	0.0	0	0	0	0	1
04/14/2020 04:00	0.0	0	0	0	0	1
04/14/2020 05:00	0.0	0	0	0	0	1
04/14/2020 06:00	0.0	0	0	0	0	1
04/14/2020 07:00	0.0	0	0	0	0	1
04/14/2020 08:00	0.0	0	0	0	0	1
04/14/2020 09:00	0.0	0	0	0	0	1
04/14/2020 10:00	0.0	0	0	0	0	1
04/14/2020 11:00	0.0	0	0	0	0	1
04/14/2020 12:00	0.0	0	0	0	0	1
04/14/2020 13:00	0.0	0	0	0	0	1
04/14/2020 14:00	0.0	0	0	0	0	1
04/14/2020 15:00	0.0	0	0	0	0	1
04/14/2020 16:00	0.0	0	0	0	0	1
04/14/2020 17:00	0.0	0	0	0	0	1
04/14/2020 18:00	0.0	0	0	0	0	1
04/14/2020 19:00	0.0	0	0	0	0	1
04/14/2020 20:00	0.0	0	0	0	0	1
04/14/2020 21:00	0.0	0	0	0	0	1
04/14/2020 22:00	0.0	0	0	0	0	1
04/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/15/2020 00:00	0.0	0	0	0	0	1
04/15/2020 01:00	0.0	0	0	0	0	1
04/15/2020 02:00	0.0	0	0	0	0	1
04/15/2020 03:00	0.0	0	0	0	0	1
04/15/2020 04:00	0.0	0	0	0	0	1
04/15/2020 05:00	0.0	0	0	0	0	1
04/15/2020 06:00	0.0	0	0	0	0	1
04/15/2020 07:00	0.0	0	0	0	0	1
04/15/2020 08:00	0.0	0	0	0	0	1
04/15/2020 09:00	0.0	0	0	0	0	1
04/15/2020 10:00	0.0	0	0	0	0	1
04/15/2020 11:00	0.0	0	0	0	0	1
04/15/2020 12:00	0.0	0	0	0	0	1
04/15/2020 13:00	0.0	0	0	0	0	1
04/15/2020 14:00	0.0	0	0	0	0	1
04/15/2020 15:00	0.0	0	0	0	0	1
04/15/2020 16:00	0.0	0	0	0	0	1
04/15/2020 17:00	0.0	0	0	0	0	1
04/15/2020 18:00	0.0	0	0	0	0	1
04/15/2020 19:00	0.0	0	0	0	0	1
04/15/2020 20:00	0.0	0	0	0	0	1
04/15/2020 21:00	0.0	0	0	0	0	1
04/15/2020 22:00	0.0	0	0	0	0	1
04/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/16/2020 00:00	0.0	0	0	0	0	1
04/16/2020 01:00	0.0	0	0	0	0	1
04/16/2020 02:00	0.0	0	0	0	0	1
04/16/2020 03:00	0.0	0	0	0	0	1
04/16/2020 04:00	0.0	0	0	0	0	1
04/16/2020 05:00	0.0	0	0	0	0	1
04/16/2020 06:00	0.0	0	0	0	0	1
04/16/2020 07:00	0.0	0	0	0	0	1
04/16/2020 08:00	0.0	0	0	0	0	1
04/16/2020 09:00	0.0	0	0	0	0	1
04/16/2020 10:00	0.0	0	0	0	0	1
04/16/2020 11:00	0.0	0	0	0	0	1
04/16/2020 12:00	0.0	0	0	0	0	1
04/16/2020 13:00	0.0	0	0	0	0	1
04/16/2020 14:00	0.0	0	0	0	0	1
04/16/2020 15:00	0.0	0	0	0	0	1
04/16/2020 16:00	0.0	0	0	0	0	1
04/16/2020 17:00	0.0	0	0	0	0	1
04/16/2020 18:00	0.0	0	0	0	0	1
04/16/2020 19:00	0.0	0	0	0	0	1
04/16/2020 20:00	0.0	0	0	0	0	1
04/16/2020 21:00	0.0	0	0	0	0	1
04/16/2020 22:00	0.0	0	0	0	0	1
04/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/17/2020 00:00	0.0	0	0	0	0	1
04/17/2020 01:00	0.0	0	0	0	0	1
04/17/2020 02:00	0.0	0	0	0	0	1
04/17/2020 03:00	0.0	0	0	0	0	1
04/17/2020 04:00	0.0	0	0	0	0	1
04/17/2020 05:00	0.0	0	0	0	0	1
04/17/2020 06:00	0.0	0	0	0	0	1
04/17/2020 07:00	0.0	0	0	0	0	1
04/17/2020 08:00	0.0	0	0	0	0	1
04/17/2020 09:00	0.0	0	0	0	0	1
04/17/2020 10:00	0.0	0	0	0	0	1
04/17/2020 11:00	0.0	0	0	0	0	1
04/17/2020 12:00	0.0	0	0	0	0	1
04/17/2020 13:00	0.0	0	0	0	0	1
04/17/2020 14:00	0.0	0	0	0	0	1
04/17/2020 15:00	0.0	0	0	0	0	1
04/17/2020 16:00	0.0	0	0	0	0	1
04/17/2020 17:00	0.0	0	0	0	0	1
04/17/2020 18:00	0.0	0	0	0	0	1
04/17/2020 19:00	0.0	0	0	0	0	1
04/17/2020 20:00	0.0	0	0	0	0	1
04/17/2020 21:00	0.0	0	0	0	0	1
04/17/2020 22:00	0.0	0	0	0	0	1
04/17/2020 23:00	122.8	0	0	0	1	0
Average/Sum#:	122.8 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	122.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/18/2020 00:00	0.0	0	0	0	0	0
04/18/2020 01:00	0.0	0	0	0	0	0
04/18/2020 02:00	0.0	0	0	0	0	0
04/18/2020 03:00	0.0	0	0	0	0	0
04/18/2020 04:00	0.0	0	0	0	0	0
04/18/2020 05:00	0.0	0	0	0	0	0
04/18/2020 06:00	0.0	0	0	0	0	0
04/18/2020 07:00	0.0	0	0	0	0	0
04/18/2020 08:00	0.0	0	0	0	0	0
04/18/2020 09:00	0.0	0	0	0	0	0
04/18/2020 10:00	0.0	0	0	0	0	0
04/18/2020 11:00	0.0	0	0	0	0	0
04/18/2020 12:00	0.0	0	0	0	0	0
04/18/2020 13:00	0.0	0	0	0	0	0
04/18/2020 14:00	0.0	0	0	0	0	0
04/18/2020 15:00	0.0	0	0	0	0	0
04/18/2020 16:00	0.0	0	0	0	0	0
04/18/2020 17:00	0.0	0	0	0	0	0
04/18/2020 18:00	0.0	0	0	0	0	0
04/18/2020 19:00	0.0	0	0	0	0	0
04/18/2020 20:00	0.0	0	0	0	0	0
04/18/2020 21:00	0.0	0	0	0	0	0
04/18/2020 22:00	0.0	0	0	0	0	0
04/18/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/19/2020 00:00	0.0	0	0	0	0	0
04/19/2020 01:00	0.0	0	0	0	0	0
04/19/2020 02:00	0.0	0	0	0	0	0
04/19/2020 03:00	0.0	0	0	0	0	0
04/19/2020 04:00	0.0	0	0	0	0	0
04/19/2020 05:00	0.0	0	0	0	0	0
04/19/2020 06:00	0.0	0	0	0	0	0
04/19/2020 07:00	0.0	0	0	0	0	0
04/19/2020 08:00	0.0	0	0	0	0	0
04/19/2020 09:00	0.0	0	0	0	0	0
04/19/2020 10:00	0.0	0	0	0	0	0
04/19/2020 11:00	0.0	0	0	0	0	0
04/19/2020 12:00	0.0	0	0	0	0	0
04/19/2020 13:00	0.0	0	0	0	0	0
04/19/2020 14:00	0.0	0	0	0	0	0
04/19/2020 15:00	0.0	0	0	0	0	0
04/19/2020 16:00	0.0	0	0	0	0	0
04/19/2020 17:00	3,139.0	0	1	0	0	0
04/19/2020 18:00	5,071.4	0	1	0	0	0
04/19/2020 19:00	6,566.3	0	1	0	0	0
04/19/2020 20:00	0.0	0	0	0	0	1
04/19/2020 21:00	0.0	0	0	0	0	1
04/19/2020 22:00	0.0	0	0	0	0	1
04/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	14,776.7 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,566.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/20/2020 00:00	0.0	0	0	0	0	1
04/20/2020 01:00	0.0	0	0	0	0	1
04/20/2020 02:00	0.0	0	0	0	0	1
04/20/2020 03:00	0.0	0	0	0	0	1
04/20/2020 04:00	0.0	0	0	0	0	1
04/20/2020 05:00	0.0	0	0	0	0	1
04/20/2020 06:00	0.0	0	0	0	0	1
04/20/2020 07:00	0.0	0	0	0	0	1
04/20/2020 08:00	0.0	0	0	0	0	1
04/20/2020 09:00	0.0	0	0	0	0	1
04/20/2020 10:00	0.0	0	0	0	0	1
04/20/2020 11:00	0.0	0	0	0	0	1
04/20/2020 12:00	0.0	0	0	0	0	1
04/20/2020 13:00	0.0	0	0	0	0	1
04/20/2020 14:00	0.0	0	0	0	0	1
04/20/2020 15:00	0.0	0	0	0	0	1
04/20/2020 16:00	0.0	0	0	0	0	1
04/20/2020 17:00	0.0	0	0	0	0	1
04/20/2020 18:00	0.0	0	0	0	0	1
04/20/2020 19:00	0.0	0	0	0	0	1
04/20/2020 20:00	0.0	0	0	0	0	1
04/20/2020 21:00	0.0	0	0	0	0	1
04/20/2020 22:00	0.0	0	0	0	0	1
04/20/2020 23:00	91.6	0	0	0	1	0
Average/Sum#:	91.6 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	91.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/21/2020 00:00	0.0	0	0	0	0	0
04/21/2020 01:00	0.0	0	0	0	0	0
04/21/2020 02:00	0.0	0	0	0	0	0
04/21/2020 03:00	0.0	0	0	0	0	0
04/21/2020 04:00	0.0	0	0	0	0	0
04/21/2020 05:00	0.0	0	0	0	0	0
04/21/2020 06:00	0.0	0	0	0	0	0
04/21/2020 07:00	0.0	0	0	0	0	0
04/21/2020 08:00	0.0	0	0	0	0	0
04/21/2020 09:00	0.0	0	0	0	0	0
04/21/2020 10:00	0.0	0	0	0	0	0
04/21/2020 11:00	0.0	0	0	0	0	0
04/21/2020 12:00	0.0	0	0	0	0	0
04/21/2020 13:00	0.0	0	0	0	0	0
04/21/2020 14:00	0.0	0	0	0	0	0
04/21/2020 15:00	0.0	0	0	0	0	0
04/21/2020 16:00	0.0	0	0	0	0	0
04/21/2020 17:00	0.0	0	0	0	0	0
04/21/2020 18:00	0.0	0	0	0	0	0
04/21/2020 19:00	0.0	0	0	0	0	0
04/21/2020 20:00	0.0	0	0	0	0	0
04/21/2020 21:00	0.0	0	0	0	0	0
04/21/2020 22:00	0.0	0	0	0	0	0
04/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/22/2020 00:00	0.0	0	0	0	0	0
04/22/2020 01:00	0.0	0	0	0	0	0
04/22/2020 02:00	0.0	0	0	0	0	0
04/22/2020 03:00	0.0	0	0	0	0	0
04/22/2020 04:00	3,104.1	0	1	0	0	0
04/22/2020 05:00	5,107.0	0	1	0	0	0
04/22/2020 06:00	6,243.2	0	1	0	0	0
04/22/2020 07:00	0.0	0	0	0	0	1
04/22/2020 08:00	0.0	0	0	0	0	1
04/22/2020 09:00	0.0	0	0	0	0	1
04/22/2020 10:00	0.0	0	0	0	0	1
04/22/2020 11:00	0.0	0	0	0	0	1
04/22/2020 12:00	0.0	0	0	0	0	1
04/22/2020 13:00	97.0	0	0	0	1	0
04/22/2020 14:00	0.0	0	0	0	0	0
04/22/2020 15:00	0.0	0	0	0	0	0
04/22/2020 16:00	0.0	0	0	0	0	0
04/22/2020 17:00	0.0	0	0	0	0	0
04/22/2020 18:00	629.4	0	0	1	0	0
04/22/2020 19:00	6,241.5	0	0	1	0	0
04/22/2020 20:00	0.0	0	0	0	0	1
04/22/2020 21:00	0.0	0	0	0	0	1
04/22/2020 22:00	0.0	0	0	0	0	1
04/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	21,422.2 #	0 #	3 #	2 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,243.2	0	1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/23/2020 00:00	0.0	0	0	0	0	1
04/23/2020 01:00	0.0	0	0	0	0	1
04/23/2020 02:00	87.1	0	0	0	1	0
04/23/2020 03:00	0.0	0	0	0	0	0
04/23/2020 04:00	0.0	0	0	0	0	0
04/23/2020 05:00	0.0	0	0	0	0	0
04/23/2020 06:00	0.0	0	0	0	0	0
04/23/2020 07:00	0.0	0	0	0	0	0
04/23/2020 08:00	0.0	0	0	0	0	0
04/23/2020 09:00	0.0	0	0	0	0	0
04/23/2020 10:00	0.0	0	0	0	0	0
04/23/2020 11:00	0.0	0	0	0	0	0
04/23/2020 12:00	0.0	0	0	0	0	0
04/23/2020 13:00	0.0	0	0	0	0	0
04/23/2020 14:00	0.0	0	0	0	0	0
04/23/2020 15:00	0.0	0	0	0	0	0
04/23/2020 16:00	0.0	0	0	0	0	0
04/23/2020 17:00	0.0	0	0	0	0	0
04/23/2020 18:00	0.0	0	0	0	0	0
04/23/2020 19:00	0.0	0	0	0	0	0
04/23/2020 20:00	0.0	0	0	0	0	0
04/23/2020 21:00	0.0	0	0	0	0	0
04/23/2020 22:00	0.0	0	0	0	0	0
04/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	87.1 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	87.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/24/2020 00:00	0.0	0	0	0	0	0
04/24/2020 01:00	0.0	0	0	0	0	0
04/24/2020 02:00	0.0	0	0	0	0	0
04/24/2020 03:00	0.0	0	0	0	0	0
04/24/2020 04:00	0.0	0	0	0	0	0
04/24/2020 05:00	0.0	0	0	0	0	0
04/24/2020 06:00	0.0	0	0	0	0	0
04/24/2020 07:00	0.0	0	0	0	0	0
04/24/2020 08:00	0.0	0	0	0	0	0
04/24/2020 09:00	3,112.7	0	1	0	0	0
04/24/2020 10:00	5,082.4	0	1	0	0	0
04/24/2020 11:00	6,698.2	0	1	0	0	0
04/24/2020 12:00	0.0	0	0	0	0	1
04/24/2020 13:00	0.0	0	0	0	0	1
04/24/2020 14:00	0.0	0	0	0	0	1
04/24/2020 15:00	0.0	0	0	0	0	1
04/24/2020 16:00	0.0	0	0	0	0	1
04/24/2020 17:00	0.0	0	0	0	0	1
04/24/2020 18:00	0.0	0	0	0	0	1
04/24/2020 19:00	0.0	0	0	0	0	1
04/24/2020 20:00	0.0	0	0	0	0	1
04/24/2020 21:00	0.0	0	0	0	0	1
04/24/2020 22:00	100.2	0	0	0	1	0
04/24/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	14,993.5 #	0 #	3 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,698.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/25/2020 00:00	0.0	0	0	0	0	0
04/25/2020 01:00	0.0	0	0	0	0	0
04/25/2020 02:00	0.0	0	0	0	0	0
04/25/2020 03:00	0.0	0	0	0	0	0
04/25/2020 04:00	0.0	0	0	0	0	0
04/25/2020 05:00	0.0	0	0	0	0	0
04/25/2020 06:00	0.0	0	0	0	0	0
04/25/2020 07:00	0.0	0	0	0	0	0
04/25/2020 08:00	0.0	0	0	0	0	0
04/25/2020 09:00	0.0	0	0	0	0	0
04/25/2020 10:00	0.0	0	0	0	0	0
04/25/2020 11:00	0.0	0	0	0	0	0
04/25/2020 12:00	0.0	0	0	0	0	0
04/25/2020 13:00	0.0	0	0	0	0	0
04/25/2020 14:00	0.0	0	0	0	0	0
04/25/2020 15:00	0.0	0	0	0	0	0
04/25/2020 16:00	0.0	0	0	0	0	0
04/25/2020 17:00	0.0	0	0	0	0	0
04/25/2020 18:00	0.0	0	0	0	0	0
04/25/2020 19:00	0.0	0	0	0	0	0
04/25/2020 20:00	0.0	0	0	0	0	0
04/25/2020 21:00	0.0	0	0	0	0	0
04/25/2020 22:00	0.0	0	0	0	0	0
04/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/26/2020 00:00	0.0	0	0	0	0	0
04/26/2020 01:00	0.0	0	0	0	0	0
04/26/2020 02:00	0.0	0	0	0	0	0
04/26/2020 03:00	0.0	0	0	0	0	0
04/26/2020 04:00	0.0	0	0	0	0	0
04/26/2020 05:00	0.0	0	0	0	0	0
04/26/2020 06:00	0.0	0	0	0	0	0
04/26/2020 07:00	0.0	0	0	0	0	0
04/26/2020 08:00	0.0	0	0	0	0	0
04/26/2020 09:00	0.0	0	0	0	0	0
04/26/2020 10:00	0.0	0	0	0	0	0
04/26/2020 11:00	0.0	0	0	0	0	0
04/26/2020 12:00	0.0	0	0	0	0	0
04/26/2020 13:00	0.0	0	0	0	0	0
04/26/2020 14:00	0.0	0	0	0	0	0
04/26/2020 15:00	0.0	0	0	0	0	0
04/26/2020 16:00	0.0	0	0	0	0	0
04/26/2020 17:00	0.0	0	0	0	0	0
04/26/2020 18:00	0.0	0	0	0	0	0
04/26/2020 19:00	0.0	0	0	0	0	0
04/26/2020 20:00	0.0	0	0	0	0	0
04/26/2020 21:00	0.0	0	0	0	0	0
04/26/2020 22:00	0.0	0	0	0	0	0
04/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/27/2020 00:00	0.0	0	0	0	0	0
04/27/2020 01:00	0.0	0	0	0	0	0
04/27/2020 02:00	0.0	0	0	0	0	0
04/27/2020 03:00	0.0	0	0	0	0	0
04/27/2020 04:00	0.0	0	0	0	0	0
04/27/2020 05:00	0.0	0	0	0	0	0
04/27/2020 06:00	0.0	0	0	0	0	0
04/27/2020 07:00	0.0	0	0	0	0	0
04/27/2020 08:00	0.0	0	0	0	0	0
04/27/2020 09:00	0.0	0	0	0	0	0
04/27/2020 10:00	0.0	0	0	0	0	0
04/27/2020 11:00	0.0	0	0	0	0	0
04/27/2020 12:00	0.0	0	0	0	0	0
04/27/2020 13:00	2,957.3	0	1	0	0	0
04/27/2020 14:00	6,179.5	0	1	0	0	0
04/27/2020 15:00	6,183.6	0	1	0	0	0
04/27/2020 16:00	0.0	0	0	0	0	1
04/27/2020 17:00	0.0	0	0	0	0	1
04/27/2020 18:00	0.0	0	0	0	0	1
04/27/2020 19:00	0.0	0	0	0	0	1
04/27/2020 20:00	0.0	0	0	0	0	1
04/27/2020 21:00	0.0	0	0	0	0	1
04/27/2020 22:00	0.0	0	0	0	0	1
04/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	15,320.4 #	0 #	3 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,183.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/28/2020 00:00	0.0	0	0	0	0	1
04/28/2020 01:00	0.0	0	0	0	0	1
04/28/2020 02:00	0.0	0	0	0	0	1
04/28/2020 03:00	0.0	0	0	0	0	1
04/28/2020 04:00	0.0	0	0	0	0	1
04/28/2020 05:00	0.0	0	0	0	0	1
04/28/2020 06:00	0.0	0	0	0	0	1
04/28/2020 07:00	0.0	0	0	0	0	1
04/28/2020 08:00	0.0	0	0	0	0	1
04/28/2020 09:00	0.0	0	0	0	0	1
04/28/2020 10:00	0.0	0	0	0	0	1
04/28/2020 11:00	0.0	0	0	0	0	1
04/28/2020 12:00	0.0	0	0	0	0	1
04/28/2020 13:00	0.0	0	0	0	0	1
04/28/2020 14:00	0.0	0	0	0	0	1
04/28/2020 15:00	0.0	0	0	0	0	1
04/28/2020 16:00	0.0	0	0	0	0	1
04/28/2020 17:00	0.0	0	0	0	0	1
04/28/2020 18:00	0.0	0	0	0	0	1
04/28/2020 19:00	0.0	0	0	0	0	1
04/28/2020 20:00	0.0	0	0	0	0	1
04/28/2020 21:00	91.6	0	0	0	1	0
04/28/2020 22:00	0.0	0	0	0	0	0
04/28/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	91.6 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	91.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/29/2020 00:00	0.0	0	0	0	0	0
04/29/2020 01:00	0.0	0	0	0	0	0
04/29/2020 02:00	0.0	0	0	0	0	0
04/29/2020 03:00	0.0	0	0	0	0	0
04/29/2020 04:00	0.0	0	0	0	0	0
04/29/2020 05:00	0.0	0	0	0	0	0
04/29/2020 06:00	0.0	0	0	0	0	0
04/29/2020 07:00	0.0	0	0	0	0	0
04/29/2020 08:00	0.0	0	0	0	0	0
04/29/2020 09:00	0.0	0	0	0	0	0
04/29/2020 10:00	0.0	0	0	0	0	0
04/29/2020 11:00	0.0	0	0	0	0	0
04/29/2020 12:00	0.0	0	0	0	0	0
04/29/2020 13:00	3,063.7	0	1	0	0	0
04/29/2020 14:00	7,067.8	0	1	0	0	0
04/29/2020 15:00	3,109.8	0	1	0	0	0
04/29/2020 16:00	0.0	0	0	0	0	1
04/29/2020 17:00	0.0	0	0	0	0	1
04/29/2020 18:00	0.0	0	0	0	0	1
04/29/2020 19:00	0.0	0	0	0	0	1
04/29/2020 20:00	0.0	0	0	0	0	1
04/29/2020 21:00	0.0	0	0	0	0	1
04/29/2020 22:00	0.0	0	0	0	0	1
04/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	13,241.3 #	0 #	3 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,067.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/30/2020 00:00	0.0	0	0	0	0	1
04/30/2020 01:00	0.0	0	0	0	0	1
04/30/2020 02:00	0.0	0	0	0	0	1
04/30/2020 03:00	0.0	0	0	0	0	1
04/30/2020 04:00	0.0	0	0	0	0	1
04/30/2020 05:00	0.0	0	0	0	0	1
04/30/2020 06:00	0.0	0	0	0	0	1
04/30/2020 07:00	99.1	0	0	0	1	0
04/30/2020 08:00	0.0	0	0	0	0	0
04/30/2020 09:00	0.0	0	0	0	0	0
04/30/2020 10:00	0.0	0	0	0	0	0
04/30/2020 11:00	0.0	0	0	0	0	0
04/30/2020 12:00	0.0	0	0	0	0	0
04/30/2020 13:00	0.0	0	0	0	0	0
04/30/2020 14:00	0.0	0	0	0	0	0
04/30/2020 15:00	0.0	0	0	0	0	0
04/30/2020 16:00	0.0	0	0	0	0	0
04/30/2020 17:00	0.0	0	0	0	0	0
04/30/2020 18:00	0.0	0	0	0	0	0
04/30/2020 19:00	0.0	0	0	0	0	0
04/30/2020 20:00	0.0	0	0	0	0	0
04/30/2020 21:00	0.0	0	0	0	0	0
04/30/2020 22:00	0.0	0	0	0	0	0
04/30/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	99.1 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	99.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/01/2020 00:00	0.0	0	0	0	0	0
05/01/2020 01:00	0.0	0	0	0	0	0
05/01/2020 02:00	0.0	0	0	0	0	0
05/01/2020 03:00	0.0	0	0	0	0	0
05/01/2020 04:00	0.0	0	0	0	0	0
05/01/2020 05:00	0.0	0	0	0	0	0
05/01/2020 06:00	0.0	0	0	0	0	0
05/01/2020 07:00	0.0	0	0	0	0	0
05/01/2020 08:00	0.0	0	0	0	0	0
05/01/2020 09:00	0.0	0	0	0	0	0
05/01/2020 10:00	0.0	0	0	0	0	0
05/01/2020 11:00	0.0	0	0	0	0	0
05/01/2020 12:00	0.0	0	0	0	0	0
05/01/2020 13:00	0.0	0	0	0	0	0
05/01/2020 14:00	0.0	0	0	0	0	0
05/01/2020 15:00	0.0	0	0	0	0	0
05/01/2020 16:00	0.0	0	0	0	0	0
05/01/2020 17:00	0.0	0	0	0	0	0
05/01/2020 18:00	0.0	0	0	0	0	0
05/01/2020 19:00	0.0	0	0	0	0	0
05/01/2020 20:00	0.0	0	0	0	0	0
05/01/2020 21:00	0.0	0	0	0	0	0
05/01/2020 22:00	0.0	0	0	0	0	0
05/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/02/2020 00:00	0.0	0	0	0	0	0
05/02/2020 01:00	0.0	0	0	0	0	0
05/02/2020 02:00	0.0	0	0	0	0	0
05/02/2020 03:00	0.0	0	0	0	0	0
05/02/2020 04:00	0.0	0	0	0	0	0
05/02/2020 05:00	0.0	0	0	0	0	0
05/02/2020 06:00	0.0	0	0	0	0	0
05/02/2020 07:00	0.0	0	0	0	0	0
05/02/2020 08:00	0.0	0	0	0	0	0
05/02/2020 09:00	0.0	0	0	0	0	0
05/02/2020 10:00	0.0	0	0	0	0	0
05/02/2020 11:00	0.0	0	0	0	0	0
05/02/2020 12:00	0.0	0	0	0	0	0
05/02/2020 13:00	0.0	0	0	0	0	0
05/02/2020 14:00	0.0	0	0	0	0	0
05/02/2020 15:00	0.0	0	0	0	0	0
05/02/2020 16:00	0.0	0	0	0	0	0
05/02/2020 17:00	0.0	0	0	0	0	0
05/02/2020 18:00	0.0	0	0	0	0	0
05/02/2020 19:00	0.0	0	0	0	0	0
05/02/2020 20:00	0.0	0	0	0	0	0
05/02/2020 21:00	0.0	0	0	0	0	0
05/02/2020 22:00	0.0	0	0	0	0	0
05/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/03/2020 00:00	0.0	0	0	0	0	0
05/03/2020 01:00	0.0	0	0	0	0	0
05/03/2020 02:00	0.0	0	0	0	0	0
05/03/2020 03:00	0.0	0	0	0	0	0
05/03/2020 04:00	0.0	0	0	0	0	0
05/03/2020 05:00	0.0	0	0	0	0	0
05/03/2020 06:00	0.0	0	0	0	0	0
05/03/2020 07:00	0.0	0	0	0	0	0
05/03/2020 08:00	0.0	0	0	0	0	0
05/03/2020 09:00	0.0	0	0	0	0	0
05/03/2020 10:00	0.0	0	0	0	0	0
05/03/2020 11:00	0.0	0	0	0	0	0
05/03/2020 12:00	0.0	0	0	0	0	0
05/03/2020 13:00	0.0	0	0	0	0	0
05/03/2020 14:00	0.0	0	0	0	0	0
05/03/2020 15:00	0.0	0	0	0	0	0
05/03/2020 16:00	0.0	0	0	0	0	0
05/03/2020 17:00	0.0	0	0	0	0	0
05/03/2020 18:00	0.0	0	0	0	0	0
05/03/2020 19:00	0.0	0	0	0	0	0
05/03/2020 20:00	0.0	0	0	0	0	0
05/03/2020 21:00	0.0	0	0	0	0	0
05/03/2020 22:00	0.0	0	0	0	0	0
05/03/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/04/2020 00:00	0.0	0	0	0	0	0
05/04/2020 01:00	0.0	0	0	0	0	0
05/04/2020 02:00	0.0	0	0	0	0	0
05/04/2020 03:00	0.0	0	0	0	0	0
05/04/2020 04:00	0.0	0	0	0	0	0
05/04/2020 05:00	0.0	0	0	0	0	0
05/04/2020 06:00	0.0	0	0	0	0	0
05/04/2020 07:00	0.0	0	0	0	0	0
05/04/2020 08:00	0.0	0	0	0	0	0
05/04/2020 09:00	0.0	0	0	0	0	0
05/04/2020 10:00	0.0	0	0	0	0	0
05/04/2020 11:00	0.0	0	0	0	0	0
05/04/2020 12:00	0.0	0	0	0	0	0
05/04/2020 13:00	0.0	0	0	0	0	0
05/04/2020 14:00	0.0	0	0	0	0	0
05/04/2020 15:00	0.0	0	0	0	0	0
05/04/2020 16:00	0.0	0	0	0	0	0
05/04/2020 17:00	0.0	0	0	0	0	0
05/04/2020 18:00	0.0	0	0	0	0	0
05/04/2020 19:00	0.0	0	0	0	0	0
05/04/2020 20:00	0.0	0	0	0	0	0
05/04/2020 21:00	0.0	0	0	0	0	0
05/04/2020 22:00	0.0	0	0	0	0	0
05/04/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/05/2020 00:00	0.0	0	0	0	0	0
05/05/2020 01:00	0.0	0	0	0	0	0
05/05/2020 02:00	0.0	0	0	0	0	0
05/05/2020 03:00	0.0	0	0	0	0	0
05/05/2020 04:00	0.0	0	0	0	0	0
05/05/2020 05:00	0.0	0	0	0	0	0
05/05/2020 06:00	0.0	0	0	0	0	0
05/05/2020 07:00	0.0	0	0	0	0	0
05/05/2020 08:00	0.0	0	0	0	0	0
05/05/2020 09:00	0.0	0	0	0	0	0
05/05/2020 10:00	0.0	0	0	0	0	0
05/05/2020 11:00	0.0	0	0	0	0	0
05/05/2020 12:00	0.0	0	0	0	0	0
05/05/2020 13:00	0.0	0	0	0	0	0
05/05/2020 14:00	0.0	0	0	0	0	0
05/05/2020 15:00	0.0	0	0	0	0	0
05/05/2020 16:00	0.0	0	0	0	0	0
05/05/2020 17:00	0.0	0	0	0	0	0
05/05/2020 18:00	0.0	0	0	0	0	0
05/05/2020 19:00	0.0	0	0	0	0	0
05/05/2020 20:00	0.0	0	0	0	0	0
05/05/2020 21:00	0.0	0	0	0	0	0
05/05/2020 22:00	0.0	0	0	0	0	0
05/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/06/2020 00:00	0.0	0	0	0	0	0
05/06/2020 01:00	0.0	0	0	0	0	0
05/06/2020 02:00	0.0	0	0	0	0	0
05/06/2020 03:00	0.0	0	0	0	0	0
05/06/2020 04:00	0.0	0	0	0	0	0
05/06/2020 05:00	0.0	0	0	0	0	0
05/06/2020 06:00	0.0	0	0	0	0	0
05/06/2020 07:00	0.0	0	0	0	0	0
05/06/2020 08:00	0.0	0	0	0	0	0
05/06/2020 09:00	0.0	0	0	0	0	0
05/06/2020 10:00	0.0	0	0	0	0	0
05/06/2020 11:00	0.0	0	0	0	0	0
05/06/2020 12:00	0.0	0	0	0	0	0
05/06/2020 13:00	0.0	0	0	0	0	0
05/06/2020 14:00	0.0	0	0	0	0	0
05/06/2020 15:00	0.0	0	0	0	0	0
05/06/2020 16:00	0.0	0	0	0	0	0
05/06/2020 17:00	0.0	0	0	0	0	0
05/06/2020 18:00	0.0	0	0	0	0	0
05/06/2020 19:00	0.0	0	0	0	0	0
05/06/2020 20:00	0.0	0	0	0	0	0
05/06/2020 21:00	0.0	0	0	0	0	0
05/06/2020 22:00	0.0	0	0	0	0	0
05/06/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/07/2020 00:00	0.0	0	0	0	0	0
05/07/2020 01:00	0.0	0	0	0	0	0
05/07/2020 02:00	0.0	0	0	0	0	0
05/07/2020 03:00	0.0	0	0	0	0	0
05/07/2020 04:00	0.0	0	0	0	0	0
05/07/2020 05:00	0.0	0	0	0	0	0
05/07/2020 06:00	0.0	0	0	0	0	0
05/07/2020 07:00	0.0	0	0	0	0	0
05/07/2020 08:00	0.0	0	0	0	0	0
05/07/2020 09:00	0.0	0	0	0	0	0
05/07/2020 10:00	0.0	0	0	0	0	0
05/07/2020 11:00	0.0	0	0	0	0	0
05/07/2020 12:00	0.0	0	0	0	0	0
05/07/2020 13:00	0.0	0	0	0	0	0
05/07/2020 14:00	0.0	0	0	0	0	0
05/07/2020 15:00	0.0	0	0	0	0	0
05/07/2020 16:00	0.0	0	0	0	0	0
05/07/2020 17:00	0.0	0	0	0	0	0
05/07/2020 18:00	0.0	0	0	0	0	0
05/07/2020 19:00	0.0	0	0	0	0	0
05/07/2020 20:00	0.0	0	0	0	0	0
05/07/2020 21:00	0.0	0	0	0	0	0
05/07/2020 22:00	0.0	0	0	0	0	0
05/07/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/08/2020 00:00	0.0	0	0	0	0	0
05/08/2020 01:00	0.0	0	0	0	0	0
05/08/2020 02:00	0.0	0	0	0	0	0
05/08/2020 03:00	0.0	0	0	0	0	0
05/08/2020 04:00	0.0	0	0	0	0	0
05/08/2020 05:00	0.0	0	0	0	0	0
05/08/2020 06:00	0.0	0	0	0	0	0
05/08/2020 07:00	0.0	0	0	0	0	0
05/08/2020 08:00	0.0	0	0	0	0	0
05/08/2020 09:00	0.0	0	0	0	0	0
05/08/2020 10:00	0.0	0	0	0	0	0
05/08/2020 11:00	0.0	0	0	0	0	0
05/08/2020 12:00	0.0	0	0	0	0	0
05/08/2020 13:00	0.0	0	0	0	0	0
05/08/2020 14:00	0.0	0	0	0	0	0
05/08/2020 15:00	0.0	0	0	0	0	0
05/08/2020 16:00	0.0	0	0	0	0	0
05/08/2020 17:00	0.0	0	0	0	0	0
05/08/2020 18:00	0.0	0	0	0	0	0
05/08/2020 19:00	0.0	0	0	0	0	0
05/08/2020 20:00	0.0	0	0	0	0	0
05/08/2020 21:00	0.0	0	0	0	0	0
05/08/2020 22:00	0.0	0	0	0	0	0
05/08/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/09/2020 00:00	0.0	0	0	0	0	0
05/09/2020 01:00	0.0	0	0	0	0	0
05/09/2020 02:00	0.0	0	0	0	0	0
05/09/2020 03:00	0.0	0	0	0	0	0
05/09/2020 04:00	0.0	0	0	0	0	0
05/09/2020 05:00	0.0	0	0	0	0	0
05/09/2020 06:00	0.0	0	0	0	0	0
05/09/2020 07:00	0.0	0	0	0	0	0
05/09/2020 08:00	0.0	0	0	0	0	0
05/09/2020 09:00	0.0	0	0	0	0	0
05/09/2020 10:00	0.0	0	0	0	0	0
05/09/2020 11:00	0.0	0	0	0	0	0
05/09/2020 12:00	0.0	0	0	0	0	0
05/09/2020 13:00	0.0	0	0	0	0	0
05/09/2020 14:00	0.0	0	0	0	0	0
05/09/2020 15:00	0.0	0	0	0	0	0
05/09/2020 16:00	0.0	0	0	0	0	0
05/09/2020 17:00	0.0	0	0	0	0	0
05/09/2020 18:00	0.0	0	0	0	0	0
05/09/2020 19:00	0.0	0	0	0	0	0
05/09/2020 20:00	0.0	0	0	0	0	0
05/09/2020 21:00	0.0	0	0	0	0	0
05/09/2020 22:00	0.0	0	0	0	0	0
05/09/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/10/2020 00:00	0.0	0	0	0	0	0
05/10/2020 01:00	0.0	0	0	0	0	0
05/10/2020 02:00	0.0	0	0	0	0	0
05/10/2020 03:00	0.0	0	0	0	0	0
05/10/2020 04:00	0.0	0	0	0	0	0
05/10/2020 05:00	0.0	0	0	0	0	0
05/10/2020 06:00	0.0	0	0	0	0	0
05/10/2020 07:00	0.0	0	0	0	0	0
05/10/2020 08:00	0.0	0	0	0	0	0
05/10/2020 09:00	0.0	0	0	0	0	0
05/10/2020 10:00	0.0	0	0	0	0	0
05/10/2020 11:00	0.0	0	0	0	0	0
05/10/2020 12:00	0.0	0	0	0	0	0
05/10/2020 13:00	0.0	0	0	0	0	0
05/10/2020 14:00	0.0	0	0	0	0	0
05/10/2020 15:00	0.0	0	0	0	0	0
05/10/2020 16:00	0.0	0	0	0	0	0
05/10/2020 17:00	0.0	0	0	0	0	0
05/10/2020 18:00	0.0	0	0	0	0	0
05/10/2020 19:00	0.0	0	0	0	0	0
05/10/2020 20:00	0.0	0	0	0	0	0
05/10/2020 21:00	0.0	0	0	0	0	0
05/10/2020 22:00	0.0	0	0	0	0	0
05/10/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/11/2020 00:00	0.0	0	0	0	0	0
05/11/2020 01:00	0.0	0	0	0	0	0
05/11/2020 02:00	0.0	0	0	0	0	0
05/11/2020 03:00	0.0	0	0	0	0	0
05/11/2020 04:00	0.0	0	0	0	0	0
05/11/2020 05:00	0.0	0	0	0	0	0
05/11/2020 06:00	0.0	0	0	0	0	0
05/11/2020 07:00	0.0	0	0	0	0	0
05/11/2020 08:00	0.0	0	0	0	0	0
05/11/2020 09:00	0.0	0	0	0	0	0
05/11/2020 10:00	0.0	0	0	0	0	0
05/11/2020 11:00	0.0	0	0	0	0	0
05/11/2020 12:00	0.0	0	0	0	0	0
05/11/2020 13:00	0.0	0	0	0	0	0
05/11/2020 14:00	0.0	0	0	0	0	0
05/11/2020 15:00	0.0	0	0	0	0	0
05/11/2020 16:00	0.0	0	0	0	1	0
05/11/2020 17:00	0.0	0	0	0	0	0
05/11/2020 18:00	0.0	0	0	0	0	0
05/11/2020 19:00	0.0	0	0	0	0	0
05/11/2020 20:00	0.0	0	0	0	0	0
05/11/2020 21:00	0.0	0	0	0	0	0
05/11/2020 22:00	0.0	0	0	0	0	0
05/11/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/12/2020 00:00	0.0	0	0	0	0	0
05/12/2020 01:00	0.0	0	0	0	0	0
05/12/2020 02:00	0.0	0	0	0	0	0
05/12/2020 03:00	0.0	0	0	0	0	0
05/12/2020 04:00	0.0	0	0	0	0	0
05/12/2020 05:00	0.0	0	0	0	0	0
05/12/2020 06:00	0.0	0	0	0	0	0
05/12/2020 07:00	0.0	0	0	0	0	0
05/12/2020 08:00	0.0	0	0	0	0	0
05/12/2020 09:00	0.0	0	0	0	0	0
05/12/2020 10:00	0.0	0	0	0	0	0
05/12/2020 11:00	0.0	0	0	0	0	0
05/12/2020 12:00	0.0	0	0	0	0	0
05/12/2020 13:00	0.0	0	0	0	0	0
05/12/2020 14:00	0.0	0	0	0	0	0
05/12/2020 15:00	0.0	0	0	0	0	0
05/12/2020 16:00	0.0	0	0	0	0	0
05/12/2020 17:00	0.0	0	0	0	0	0
05/12/2020 18:00	0.0	0	0	0	0	0
05/12/2020 19:00	0.0	0	0	0	0	0
05/12/2020 20:00	0.0	0	0	0	0	0
05/12/2020 21:00	0.0	0	0	0	0	0
05/12/2020 22:00	0.0	0	0	0	0	0
05/12/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/13/2020 00:00	0.0	0	0	0	0	0
05/13/2020 01:00	0.0	0	0	0	0	0
05/13/2020 02:00	0.0	0	0	0	0	0
05/13/2020 03:00	0.0	0	0	0	0	0
05/13/2020 04:00	0.0	0	0	0	0	0
05/13/2020 05:00	0.0	0	0	0	0	0
05/13/2020 06:00	0.0	0	0	0	0	0
05/13/2020 07:00	0.0	0	0	0	0	0
05/13/2020 08:00	0.0	0	0	0	0	0
05/13/2020 09:00	0.0	0	0	0	0	0
05/13/2020 10:00	0.0	0	0	0	0	0
05/13/2020 11:00	0.0	0	0	0	0	0
05/13/2020 12:00	0.0	0	0	0	0	0
05/13/2020 13:00	0.0	0	0	0	0	0
05/13/2020 14:00	0.0	0	0	0	0	0
05/13/2020 15:00	0.0	0	0	0	0	0
05/13/2020 16:00	0.0	0	0	0	0	0
05/13/2020 17:00	0.0	0	0	0	0	0
05/13/2020 18:00	0.0	0	0	0	0	0
05/13/2020 19:00	0.0	0	0	0	0	0
05/13/2020 20:00	0.0	0	0	0	0	0
05/13/2020 21:00	0.0	0	0	0	0	0
05/13/2020 22:00	0.0	0	0	0	0	0
05/13/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/14/2020 00:00	0.0	0	0	0	0	0
05/14/2020 01:00	0.0	0	0	0	0	0
05/14/2020 02:00	0.0	0	0	0	0	0
05/14/2020 03:00	0.0	0	0	0	0	0
05/14/2020 04:00	0.0	0	0	0	0	0
05/14/2020 05:00	0.0	0	0	0	0	0
05/14/2020 06:00	0.0	0	0	0	0	0
05/14/2020 07:00	0.0	0	0	0	0	0
05/14/2020 08:00	0.0	0	0	0	0	0
05/14/2020 09:00	0.0	0	0	0	0	0
05/14/2020 10:00	0.0	0	0	0	0	0
05/14/2020 11:00	0.0	0	0	0	0	0
05/14/2020 12:00	0.0	0	0	0	0	0
05/14/2020 13:00	0.0	0	0	0	0	0
05/14/2020 14:00	0.0	0	0	0	0	0
05/14/2020 15:00	0.0	0	0	0	0	0
05/14/2020 16:00	0.0	0	0	0	0	0
05/14/2020 17:00	0.0	0	0	0	0	0
05/14/2020 18:00	0.0	0	0	0	0	0
05/14/2020 19:00	0.0	0	0	0	0	0
05/14/2020 20:00	0.0	0	0	0	0	0
05/14/2020 21:00	0.0	0	0	0	0	0
05/14/2020 22:00	0.0	0	0	0	0	0
05/14/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/15/2020 00:00	0.0	0	0	0	0	0
05/15/2020 01:00	0.0	0	0	0	0	0
05/15/2020 02:00	0.0	0	0	0	0	0
05/15/2020 03:00	0.0	0	0	0	0	0
05/15/2020 04:00	0.0	0	0	0	0	0
05/15/2020 05:00	0.0	0	0	0	0	0
05/15/2020 06:00	0.0	0	0	0	0	0
05/15/2020 07:00	0.0	0	0	0	0	0
05/15/2020 08:00	0.0	0	0	0	0	0
05/15/2020 09:00	0.0	0	0	0	0	0
05/15/2020 10:00	0.0	0	0	0	0	0
05/15/2020 11:00	0.0	0	0	0	0	0
05/15/2020 12:00	0.0	0	0	0	0	0
05/15/2020 13:00	0.0	0	0	0	0	0
05/15/2020 14:00	0.0	0	0	0	0	0
05/15/2020 15:00	0.0	0	0	0	0	0
05/15/2020 16:00	0.0	0	0	0	0	0
05/15/2020 17:00	0.0	0	0	0	0	0
05/15/2020 18:00	0.0	0	0	0	0	0
05/15/2020 19:00	0.0	0	0	0	0	0
05/15/2020 20:00	0.0	0	0	0	0	0
05/15/2020 21:00	0.0	0	0	0	0	0
05/15/2020 22:00	0.0	0	0	0	0	0
05/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/16/2020 00:00	0.0	0	0	0	0	0
05/16/2020 01:00	0.0	0	0	0	0	0
05/16/2020 02:00	0.0	0	0	0	0	0
05/16/2020 03:00	0.0	0	0	0	0	0
05/16/2020 04:00	0.0	0	0	0	0	0
05/16/2020 05:00	0.0	0	0	0	0	0
05/16/2020 06:00	0.0	0	0	0	0	0
05/16/2020 07:00	0.0	0	0	0	0	0
05/16/2020 08:00	0.0	0	0	0	0	0
05/16/2020 09:00	0.0	0	0	0	0	0
05/16/2020 10:00	0.0	0	0	0	0	0
05/16/2020 11:00	0.0	0	0	0	0	0
05/16/2020 12:00	0.0	0	0	0	0	0
05/16/2020 13:00	0.0	0	0	0	0	0
05/16/2020 14:00	0.0	0	0	0	0	0
05/16/2020 15:00	0.0	0	0	0	0	0
05/16/2020 16:00	0.0	0	0	0	0	0
05/16/2020 17:00	0.0	0	0	0	0	0
05/16/2020 18:00	0.0	0	0	0	0	0
05/16/2020 19:00	0.0	0	0	0	0	0
05/16/2020 20:00	0.0	0	0	0	0	0
05/16/2020 21:00	0.0	0	0	0	0	0
05/16/2020 22:00	0.0	0	0	0	0	0
05/16/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/17/2020 00:00	0.0	0	0	0	0	0
05/17/2020 01:00	0.0	0	0	0	0	0
05/17/2020 02:00	0.0	0	0	0	0	0
05/17/2020 03:00	0.0	0	0	0	0	0
05/17/2020 04:00	0.0	0	0	0	0	0
05/17/2020 05:00	0.0	0	0	0	0	0
05/17/2020 06:00	0.0	0	0	0	0	0
05/17/2020 07:00	0.0	0	0	0	0	0
05/17/2020 08:00	0.0	0	0	0	0	0
05/17/2020 09:00	0.0	0	0	0	0	0
05/17/2020 10:00	0.0	0	0	0	0	0
05/17/2020 11:00	0.0	0	0	0	0	0
05/17/2020 12:00	0.0	0	0	0	0	0
05/17/2020 13:00	0.0	0	0	0	0	0
05/17/2020 14:00	0.0	0	0	0	0	0
05/17/2020 15:00	0.0	0	0	0	0	0
05/17/2020 16:00	0.0	0	0	0	0	0
05/17/2020 17:00	0.0	0	0	0	0	0
05/17/2020 18:00	0.0	0	0	0	0	0
05/17/2020 19:00	0.0	0	0	0	0	0
05/17/2020 20:00	0.0	0	0	0	0	0
05/17/2020 21:00	0.0	0	0	0	0	0
05/17/2020 22:00	0.0	0	0	0	0	0
05/17/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/18/2020 00:00	0.0	0	0	0	0	0
05/18/2020 01:00	0.0	0	0	0	0	0
05/18/2020 02:00	0.0	0	0	0	0	0
05/18/2020 03:00	0.0	0	0	0	0	0
05/18/2020 04:00	0.0	0	0	0	0	0
05/18/2020 05:00	0.0	0	0	0	0	0
05/18/2020 06:00	0.0	0	0	0	0	0
05/18/2020 07:00	0.0	0	0	0	0	0
05/18/2020 08:00	0.0	0	0	0	0	0
05/18/2020 09:00	0.0	0	0	0	0	0
05/18/2020 10:00	0.0	0	0	0	0	0
05/18/2020 11:00	0.0	0	0	0	0	0
05/18/2020 12:00	0.0	0	0	0	0	0
05/18/2020 13:00	0.0	0	0	0	0	0
05/18/2020 14:00	0.0	0	0	0	0	0
05/18/2020 15:00	0.0	0	0	0	0	0
05/18/2020 16:00	0.0	0	0	0	0	0
05/18/2020 17:00	0.0	0	0	0	0	0
05/18/2020 18:00	0.0	0	0	0	0	0
05/18/2020 19:00	0.0	0	0	0	0	0
05/18/2020 20:00	0.0	0	0	0	0	0
05/18/2020 21:00	0.0	0	0	0	0	0
05/18/2020 22:00	0.0	0	0	0	0	0
05/18/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/19/2020 00:00	0.0	0	0	0	0	0
05/19/2020 01:00	0.0	0	0	0	0	0
05/19/2020 02:00	0.0	0	0	0	0	0
05/19/2020 03:00	0.0	0	0	0	0	0
05/19/2020 04:00	0.0	0	0	0	0	0
05/19/2020 05:00	0.0	0	0	0	0	0
05/19/2020 06:00	0.0	0	0	0	0	0
05/19/2020 07:00	0.0	0	0	0	0	0
05/19/2020 08:00	0.0	0	0	0	0	0
05/19/2020 09:00	0.0	0	0	0	0	0
05/19/2020 10:00	0.0	0	0	0	0	0
05/19/2020 11:00	0.0	0	0	0	0	0
05/19/2020 12:00	0.0	0	0	0	0	0
05/19/2020 13:00	0.0	0	0	0	0	0
05/19/2020 14:00	0.0	0	0	0	0	0
05/19/2020 15:00	0.0	0	0	0	0	0
05/19/2020 16:00	0.0	0	0	0	0	0
05/19/2020 17:00	0.0	0	0	0	0	0
05/19/2020 18:00	0.0	0	0	0	0	0
05/19/2020 19:00	0.0	0	0	0	0	0
05/19/2020 20:00	0.0	0	0	0	0	0
05/19/2020 21:00	0.0	0	0	0	0	0
05/19/2020 22:00	0.0	0	0	0	0	0
05/19/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/20/2020 00:00	0.0	0	0	0	0	0
05/20/2020 01:00	0.0	0	0	0	0	0
05/20/2020 02:00	0.0	0	0	0	0	0
05/20/2020 03:00	0.0	0	0	0	0	0
05/20/2020 04:00	0.0	0	0	0	0	0
05/20/2020 05:00	0.0	0	0	0	0	0
05/20/2020 06:00	0.0	0	0	0	0	0
05/20/2020 07:00	0.0	0	0	0	0	0
05/20/2020 08:00	0.0	0	0	0	0	0
05/20/2020 09:00	0.0	0	0	0	0	0
05/20/2020 10:00	0.0	0	0	0	0	0
05/20/2020 11:00	0.0	0	0	0	0	0
05/20/2020 12:00	0.0	0	0	0	0	0
05/20/2020 13:00	0.0	0	0	0	0	0
05/20/2020 14:00	0.0	0	0	0	0	0
05/20/2020 15:00	0.0	0	0	0	0	0
05/20/2020 16:00	0.0	0	0	0	0	0
05/20/2020 17:00	0.0	0	0	0	0	0
05/20/2020 18:00	0.0	0	0	0	0	0
05/20/2020 19:00	0.0	0	0	0	0	0
05/20/2020 20:00	0.0	0	0	0	0	0
05/20/2020 21:00	0.0	0	0	0	0	0
05/20/2020 22:00	0.0	0	0	0	0	0
05/20/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/21/2020 00:00	0.0	0	0	0	0	0
05/21/2020 01:00	0.0	0	0	0	0	0
05/21/2020 02:00	0.0	0	0	0	0	0
05/21/2020 03:00	0.0	0	0	0	0	0
05/21/2020 04:00	0.0	0	0	0	0	0
05/21/2020 05:00	0.0	0	0	0	0	0
05/21/2020 06:00	0.0	0	0	0	0	0
05/21/2020 07:00	0.0	0	0	0	0	0
05/21/2020 08:00	0.0	0	0	0	0	0
05/21/2020 09:00	0.0	0	0	0	0	0
05/21/2020 10:00	0.0	0	0	0	0	0
05/21/2020 11:00	0.0	0	0	0	0	0
05/21/2020 12:00	0.0	0	0	0	0	0
05/21/2020 13:00	0.0	0	0	0	0	0
05/21/2020 14:00	0.0	0	0	0	0	0
05/21/2020 15:00	0.0	0	0	0	0	0
05/21/2020 16:00	0.0	0	0	0	0	0
05/21/2020 17:00	0.0	0	0	0	0	0
05/21/2020 18:00	0.0	0	0	0	0	0
05/21/2020 19:00	0.0	0	0	0	0	0
05/21/2020 20:00	0.0	0	0	0	0	0
05/21/2020 21:00	0.0	0	0	0	0	0
05/21/2020 22:00	0.0	0	0	0	0	0
05/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/22/2020 00:00	0.0	0	0	0	0	0
05/22/2020 01:00	0.0	0	0	0	0	0
05/22/2020 02:00	0.0	0	0	0	0	0
05/22/2020 03:00	0.0	0	0	0	0	0
05/22/2020 04:00	0.0	0	0	0	0	0
05/22/2020 05:00	0.0	0	0	0	0	0
05/22/2020 06:00	0.0	0	0	0	0	0
05/22/2020 07:00	0.0	0	0	0	0	0
05/22/2020 08:00	0.0	0	0	0	0	0
05/22/2020 09:00	0.0	0	0	0	0	0
05/22/2020 10:00	0.0	0	0	0	0	0
05/22/2020 11:00	0.0	0	0	0	0	0
05/22/2020 12:00	0.0	0	0	0	0	0
05/22/2020 13:00	0.0	0	0	0	0	0
05/22/2020 14:00	0.0	0	0	0	0	0
05/22/2020 15:00	0.0	0	0	0	0	0
05/22/2020 16:00	0.0	0	0	0	0	0
05/22/2020 17:00	0.0	0	0	0	0	0
05/22/2020 18:00	0.0	0	0	0	0	0
05/22/2020 19:00	0.0	0	0	0	0	0
05/22/2020 20:00	0.0	0	0	0	0	0
05/22/2020 21:00	0.0	0	0	0	0	0
05/22/2020 22:00	0.0	0	0	0	0	0
05/22/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/23/2020 00:00	0.0	0	0	0	0	0
05/23/2020 01:00	0.0	0	0	0	0	0
05/23/2020 02:00	0.0	0	0	0	0	0
05/23/2020 03:00	0.0	0	0	0	0	0
05/23/2020 04:00	0.0	0	0	0	0	0
05/23/2020 05:00	0.0	0	0	0	0	0
05/23/2020 06:00	0.0	0	0	0	0	0
05/23/2020 07:00	0.0	0	0	0	0	0
05/23/2020 08:00	0.0	0	0	0	0	0
05/23/2020 09:00	0.0	0	0	0	0	0
05/23/2020 10:00	0.0	0	0	0	0	0
05/23/2020 11:00	0.0	0	0	0	0	0
05/23/2020 12:00	0.0	0	0	0	0	0
05/23/2020 13:00	0.0	0	0	0	0	0
05/23/2020 14:00	0.0	0	0	0	0	0
05/23/2020 15:00	0.0	0	0	0	0	0
05/23/2020 16:00	0.0	0	0	0	0	0
05/23/2020 17:00	0.0	0	0	0	0	0
05/23/2020 18:00	0.0	0	0	0	0	0
05/23/2020 19:00	0.0	0	0	0	0	0
05/23/2020 20:00	0.0	0	0	0	0	0
05/23/2020 21:00	0.0	0	0	0	0	0
05/23/2020 22:00	0.0	0	0	0	0	0
05/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/24/2020 00:00	0.0	0	0	0	0	0
05/24/2020 01:00	0.0	0	0	0	0	0
05/24/2020 02:00	0.0	0	0	0	0	0
05/24/2020 03:00	0.0	0	0	0	0	0
05/24/2020 04:00	0.0	0	0	0	0	0
05/24/2020 05:00	0.0	0	0	0	0	0
05/24/2020 06:00	0.0	0	0	0	0	0
05/24/2020 07:00	0.0	0	0	0	0	0
05/24/2020 08:00	0.0	0	0	0	0	0
05/24/2020 09:00	0.0	0	0	0	0	0
05/24/2020 10:00	0.0	0	0	0	0	0
05/24/2020 11:00	0.0	0	0	0	0	0
05/24/2020 12:00	0.0	0	0	0	0	0
05/24/2020 13:00	0.0	0	0	0	0	0
05/24/2020 14:00	0.0	0	0	0	0	0
05/24/2020 15:00	0.0	0	0	0	0	0
05/24/2020 16:00	0.0	0	0	0	0	0
05/24/2020 17:00	0.0	0	0	0	0	0
05/24/2020 18:00	0.0	0	0	0	0	0
05/24/2020 19:00	0.0	0	0	0	0	0
05/24/2020 20:00	0.0	0	0	0	0	0
05/24/2020 21:00	0.0	0	0	0	0	0
05/24/2020 22:00	0.0	0	0	0	0	0
05/24/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/25/2020 00:00	0.0	0	0	0	0	0
05/25/2020 01:00	0.0	0	0	0	0	0
05/25/2020 02:00	0.0	0	0	0	0	0
05/25/2020 03:00	0.0	0	0	0	0	0
05/25/2020 04:00	0.0	0	0	0	0	0
05/25/2020 05:00	0.0	0	0	0	0	0
05/25/2020 06:00	0.0	0	0	0	0	0
05/25/2020 07:00	0.0	0	0	0	0	0
05/25/2020 08:00	0.0	0	0	0	0	0
05/25/2020 09:00	0.0	0	0	0	0	0
05/25/2020 10:00	0.0	0	0	0	0	0
05/25/2020 11:00	0.0	0	0	0	0	0
05/25/2020 12:00	0.0	0	0	0	0	0
05/25/2020 13:00	0.0	0	0	0	0	0
05/25/2020 14:00	0.0	0	0	0	0	0
05/25/2020 15:00	0.0	0	0	0	0	0
05/25/2020 16:00	0.0	0	0	0	0	0
05/25/2020 17:00	0.0	0	0	0	0	0
05/25/2020 18:00	0.0	0	0	0	0	0
05/25/2020 19:00	0.0	0	0	0	0	0
05/25/2020 20:00	0.0	0	0	0	0	0
05/25/2020 21:00	0.0	0	0	0	0	0
05/25/2020 22:00	0.0	0	0	0	0	0
05/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/26/2020 00:00	0.0	0	0	0	0	0
05/26/2020 01:00	0.0	0	0	0	0	0
05/26/2020 02:00	0.0	0	0	0	0	0
05/26/2020 03:00	0.0	0	0	0	0	0
05/26/2020 04:00	0.0	0	0	0	0	0
05/26/2020 05:00	0.0	0	0	0	0	0
05/26/2020 06:00	0.0	0	0	0	0	0
05/26/2020 07:00	0.0	0	0	0	0	0
05/26/2020 08:00	0.0	0	0	0	0	0
05/26/2020 09:00	0.0	0	0	0	0	0
05/26/2020 10:00	0.0	0	0	0	0	0
05/26/2020 11:00	0.0	0	0	0	0	0
05/26/2020 12:00	0.0	0	0	0	0	0
05/26/2020 13:00	0.0	0	0	0	0	0
05/26/2020 14:00	0.0	0	0	0	0	0
05/26/2020 15:00	0.0	0	0	0	0	0
05/26/2020 16:00	0.0	0	0	0	0	0
05/26/2020 17:00	0.0	0	0	0	0	0
05/26/2020 18:00	0.0	0	0	0	0	0
05/26/2020 19:00	0.0	0	0	0	0	0
05/26/2020 20:00	0.0	0	0	0	0	0
05/26/2020 21:00	0.0	0	0	0	0	0
05/26/2020 22:00	0.0	0	0	0	0	0
05/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/27/2020 00:00	0.0	0	0	0	0	0
05/27/2020 01:00	0.0	0	0	0	0	0
05/27/2020 02:00	0.0	0	0	0	0	0
05/27/2020 03:00	0.0	0	0	0	0	0
05/27/2020 04:00	0.0	0	0	0	0	0
05/27/2020 05:00	0.0	0	0	0	0	0
05/27/2020 06:00	0.0	0	0	0	0	0
05/27/2020 07:00	0.0	0	0	0	0	0
05/27/2020 08:00	1,261.6	1	0	0	0	0
05/27/2020 09:00	5,086.0	1	0	0	0	0
05/27/2020 10:00	5,051.6	1	0	0	0	0
05/27/2020 11:00	7,257.5	1	0	0	0	0
05/27/2020 12:00	0.0	0	0	0	0	1
05/27/2020 13:00	0.0	0	0	0	0	1
05/27/2020 14:00	81.9	0	0	0	1	0
05/27/2020 15:00	0.0	0	0	0	0	0
05/27/2020 16:00	0.0	0	0	0	0	0
05/27/2020 17:00	0.0	0	0	0	0	0
05/27/2020 18:00	0.0	0	0	0	0	0
05/27/2020 19:00	0.0	0	0	0	0	0
05/27/2020 20:00	0.0	0	0	0	0	0
05/27/2020 21:00	0.0	0	0	0	0	0
05/27/2020 22:00	0.0	0	0	0	0	0
05/27/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	18,738.6 #	4 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,257.5	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/28/2020 00:00	0.0	0	0	0	0	0
05/28/2020 01:00	0.0	0	0	0	0	0
05/28/2020 02:00	0.0	0	0	0	0	0
05/28/2020 03:00	0.0	0	0	0	0	0
05/28/2020 04:00	0.0	0	0	0	0	0
05/28/2020 05:00	0.0	0	0	0	0	0
05/28/2020 06:00	0.0	0	0	0	0	0
05/28/2020 07:00	0.0	0	0	0	0	0
05/28/2020 08:00	0.0	0	0	0	0	0
05/28/2020 09:00	0.0	0	0	0	0	0
05/28/2020 10:00	0.0	0	0	0	0	0
05/28/2020 11:00	0.0	0	0	0	0	0
05/28/2020 12:00	0.0	0	0	0	0	0
05/28/2020 13:00	0.0	0	0	0	0	0
05/28/2020 14:00	0.0	0	0	0	0	0
05/28/2020 15:00	0.0	0	0	0	0	0
05/28/2020 16:00	0.0	0	0	0	0	0
05/28/2020 17:00	0.0	0	0	0	0	0
05/28/2020 18:00	325.9	0	1	0	0	0
05/28/2020 19:00	5,775.1	0	1	0	0	0
05/28/2020 20:00	2,878.1	0	1	0	0	0
05/28/2020 21:00	0.0	0	0	0	0	1
05/28/2020 22:00	0.0	0	0	0	0	1
05/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,979.1 #	0 #	3 #	0 #	0 #	3 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,775.1	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/29/2020 00:00	0.0	0	0	0	0	1
05/29/2020 01:00	82.9	0	0	0	1	0
05/29/2020 02:00	0.0	0	0	0	0	0
05/29/2020 03:00	0.0	0	0	0	0	0
05/29/2020 04:00	0.0	0	0	0	0	0
05/29/2020 05:00	0.0	0	0	0	0	0
05/29/2020 06:00	0.0	0	0	0	0	0
05/29/2020 07:00	0.0	0	0	0	0	0
05/29/2020 08:00	0.0	0	0	0	0	0
05/29/2020 09:00	0.0	0	0	0	0	0
05/29/2020 10:00	0.0	0	0	0	0	0
05/29/2020 11:00	0.0	0	0	0	0	0
05/29/2020 12:00	0.0	0	0	0	0	0
05/29/2020 13:00	0.0	0	0	0	0	0
05/29/2020 14:00	0.0	0	0	0	0	0
05/29/2020 15:00	0.0	0	0	0	0	0
05/29/2020 16:00	0.0	0	0	0	0	0
05/29/2020 17:00	0.0	0	0	0	0	0
05/29/2020 18:00	0.0	0	0	0	0	0
05/29/2020 19:00	0.0	0	0	0	0	0
05/29/2020 20:00	2,244.1	0	1	0	0	0
05/29/2020 21:00	6,807.9	0	1	0	0	0
05/29/2020 22:00	6,099.5	0	1	0	0	0
05/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	15,234.4 #	0 #	3 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,807.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/30/2020 00:00	0.0	0	0	0	0	1
05/30/2020 01:00	0.0	0	0	0	0	1
05/30/2020 02:00	0.0	0	0	0	0	1
05/30/2020 03:00	0.0	0	0	0	0	1
05/30/2020 04:00	0.0	0	0	0	0	1
05/30/2020 05:00	0.0	0	0	0	0	1
05/30/2020 06:00	0.0	0	0	0	0	1
05/30/2020 07:00	0.0	0	0	0	0	1
05/30/2020 08:00	136.9	0	0	0	1	0
05/30/2020 09:00	0.0	0	0	0	0	0
05/30/2020 10:00	0.0	0	0	0	0	0
05/30/2020 11:00	0.0	0	0	0	0	0
05/30/2020 12:00	0.0	0	0	0	0	0
05/30/2020 13:00	132.9	0	0	1	0	0
05/30/2020 14:00	6,531.7	0	0	1	0	0
05/30/2020 15:00	1,549.7	0	0	1	0	0
05/30/2020 16:00	0.0	0	0	0	0	1
05/30/2020 17:00	0.0	0	0	0	0	1
05/30/2020 18:00	0.0	0	0	0	0	1
05/30/2020 19:00	0.0	0	0	0	0	1
05/30/2020 20:00	0.0	0	0	0	0	1
05/30/2020 21:00	0.0	0	0	0	0	1
05/30/2020 22:00	0.0	0	0	0	0	1
05/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,351.2 #	0 #	0 #	3 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,531.7	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/31/2020 00:00	0.0	0	0	0	0	1
05/31/2020 01:00	0.0	0	0	0	0	1
05/31/2020 02:00	0.0	0	0	0	0	1
05/31/2020 03:00	0.0	0	0	0	0	1
05/31/2020 04:00	0.0	0	0	0	0	1
05/31/2020 05:00	0.0	0	0	0	0	1
05/31/2020 06:00	130.9	0	0	0	1	0
05/31/2020 07:00	0.0	0	0	0	0	0
05/31/2020 08:00	0.0	0	0	0	0	0
05/31/2020 09:00	0.0	0	0	0	0	0
05/31/2020 10:00	0.0	0	0	0	0	0
05/31/2020 11:00	0.0	0	0	0	0	0
05/31/2020 12:00	0.0	0	0	0	0	0
05/31/2020 13:00	0.0	0	0	0	0	0
05/31/2020 14:00	3,052.6	0	1	0	0	0
05/31/2020 15:00	5,359.7	0	1	0	0	0
05/31/2020 16:00	0.0	0	0	0	0	1
05/31/2020 17:00	0.0	0	0	0	0	1
05/31/2020 18:00	0.0	0	0	0	0	1
05/31/2020 19:00	0.0	0	0	0	0	1
05/31/2020 20:00	0.0	0	0	0	0	1
05/31/2020 21:00	0.0	0	0	0	0	1
05/31/2020 22:00	0.0	0	0	0	0	1
05/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,543.2 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,359.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/01/2020 00:00	0.0	0	0	0	0	1
06/01/2020 01:00	0.0	0	0	0	0	1
06/01/2020 02:00	0.0	0	0	0	0	1
06/01/2020 03:00	0.0	0	0	0	0	1
06/01/2020 04:00	0.0	0	0	0	0	1
06/01/2020 05:00	0.0	0	0	0	0	1
06/01/2020 06:00	0.0	0	0	0	0	1
06/01/2020 07:00	0.0	0	0	0	0	1
06/01/2020 08:00	0.0	0	0	0	0	1
06/01/2020 09:00	0.0	0	0	0	0	1
06/01/2020 10:00	0.0	0	0	0	0	1
06/01/2020 11:00	0.0	0	0	0	0	1
06/01/2020 12:00	0.0	0	0	0	0	1
06/01/2020 13:00	0.0	0	0	0	0	1
06/01/2020 14:00	0.0	0	0	0	0	1
06/01/2020 15:00	0.0	0	0	0	0	1
06/01/2020 16:00	0.0	0	0	0	0	1
06/01/2020 17:00	0.0	0	0	0	0	1
06/01/2020 18:00	0.0	0	0	0	0	1
06/01/2020 19:00	0.0	0	0	0	0	1
06/01/2020 20:00	0.0	0	0	0	0	1
06/01/2020 21:00	0.0	0	0	0	0	1
06/01/2020 22:00	0.0	0	0	0	0	1
06/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/02/2020 00:00	0.0	0	0	0	0	1
06/02/2020 01:00	0.0	0	0	0	0	1
06/02/2020 02:00	0.0	0	0	0	0	1
06/02/2020 03:00	0.0	0	0	0	0	1
06/02/2020 04:00	0.0	0	0	0	0	1
06/02/2020 05:00	0.0	0	0	0	0	1
06/02/2020 06:00	0.0	0	0	0	0	1
06/02/2020 07:00	0.0	0	0	0	0	1
06/02/2020 08:00	0.0	0	0	0	0	1
06/02/2020 09:00	0.0	0	0	0	0	1
06/02/2020 10:00	0.0	0	0	0	0	1
06/02/2020 11:00	0.0	0	0	0	0	1
06/02/2020 12:00	0.0	0	0	0	0	1
06/02/2020 13:00	0.0	0	0	0	0	1
06/02/2020 14:00	0.0	0	0	0	0	1
06/02/2020 15:00	0.0	0	0	0	0	1
06/02/2020 16:00	0.0	0	0	0	0	1
06/02/2020 17:00	0.0	0	0	0	0	1
06/02/2020 18:00	0.0	0	0	0	0	1
06/02/2020 19:00	0.0	0	0	0	0	1
06/02/2020 20:00	0.0	0	0	0	0	1
06/02/2020 21:00	0.0	0	0	0	0	1
06/02/2020 22:00	0.0	0	0	0	0	1
06/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/03/2020 00:00	0.0	0	0	0	0	1
06/03/2020 01:00	0.0	0	0	0	0	1
06/03/2020 02:00	0.0	0	0	0	0	1
06/03/2020 03:00	0.0	0	0	0	0	1
06/03/2020 04:00	0.0	0	0	0	0	1
06/03/2020 05:00	0.0	0	0	0	0	1
06/03/2020 06:00	0.0	0	0	0	0	1
06/03/2020 07:00	0.0	0	0	0	0	1
06/03/2020 08:00	0.0	0	0	0	0	1
06/03/2020 09:00	0.0	0	0	0	0	1
06/03/2020 10:00	0.0	0	0	0	0	1
06/03/2020 11:00	0.0	0	0	0	0	1
06/03/2020 12:00	0.0	0	0	0	0	1
06/03/2020 13:00	0.0	0	0	0	0	1
06/03/2020 14:00	0.0	0	0	0	0	1
06/03/2020 15:00	0.0	0	0	0	0	1
06/03/2020 16:00	0.0	0	0	0	0	1
06/03/2020 17:00	0.0	0	0	0	0	1
06/03/2020 18:00	0.0	0	0	0	0	1
06/03/2020 19:00	0.0	0	0	0	0	1
06/03/2020 20:00	0.0	0	0	0	0	1
06/03/2020 21:00	0.0	0	0	0	0	1
06/03/2020 22:00	0.0	0	0	0	0	1
06/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/04/2020 00:00	149.6	0	0	0	1	0
06/04/2020 01:00	0.0	0	0	0	0	0
06/04/2020 02:00	0.0	0	0	0	0	0
06/04/2020 03:00	0.0	0	0	0	0	0
06/04/2020 04:00	0.0	0	0	0	0	0
06/04/2020 05:00	0.0	0	0	0	0	0
06/04/2020 06:00	0.0	0	0	0	0	0
06/04/2020 07:00	0.0	0	0	0	0	0
06/04/2020 08:00	0.0	0	0	0	0	0
06/04/2020 09:00	0.0	0	0	0	0	0
06/04/2020 10:00	1,726.0	0	1	0	0	0
06/04/2020 11:00	7,273.0	0	1	0	0	0
06/04/2020 12:00	0.0	0	0	0	0	1
06/04/2020 13:00	0.0	0	0	0	0	1
06/04/2020 14:00	0.0	0	0	0	0	1
06/04/2020 15:00	0.0	0	0	0	0	1
06/04/2020 16:00	0.0	0	0	0	0	1
06/04/2020 17:00	0.0	0	0	0	0	1
06/04/2020 18:00	0.0	0	0	0	0	1
06/04/2020 19:00	0.0	0	0	0	0	1
06/04/2020 20:00	0.0	0	0	0	0	1
06/04/2020 21:00	0.0	0	0	0	0	1
06/04/2020 22:00	0.0	0	0	0	0	1
06/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,148.6 #	0 #	2 #	0 #	1 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,273.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/05/2020 00:00	95.3	0	0	0	1	0
06/05/2020 01:00	0.0	0	0	0	0	0
06/05/2020 02:00	0.0	0	0	0	0	0
06/05/2020 03:00	0.0	0	0	0	0	0
06/05/2020 04:00	0.0	0	0	0	0	0
06/05/2020 05:00	0.0	0	0	0	0	0
06/05/2020 06:00	0.0	0	0	0	0	0
06/05/2020 07:00	0.0	0	0	0	0	0
06/05/2020 08:00	0.0	0	0	0	0	0
06/05/2020 09:00	0.0	0	0	0	0	0
06/05/2020 10:00	0.0	0	0	0	0	0
06/05/2020 11:00	0.0	0	0	0	0	0
06/05/2020 12:00	0.0	0	0	0	0	0
06/05/2020 13:00	0.0	0	0	0	0	0
06/05/2020 14:00	0.0	0	0	0	0	0
06/05/2020 15:00	0.0	0	0	0	0	0
06/05/2020 16:00	0.0	0	0	0	0	0
06/05/2020 17:00	0.0	0	0	0	0	0
06/05/2020 18:00	0.0	0	0	0	0	0
06/05/2020 19:00	0.0	0	0	0	0	0
06/05/2020 20:00	0.0	0	0	0	0	0
06/05/2020 21:00	0.0	0	0	0	0	0
06/05/2020 22:00	0.0	0	0	0	0	0
06/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	95.3 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	95.3	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/06/2020 00:00	0.0	0	0	0	0	0
06/06/2020 01:00	0.0	0	0	0	0	0
06/06/2020 02:00	0.0	0	0	0	0	0
06/06/2020 03:00	0.0	0	0	0	0	0
06/06/2020 04:00	0.0	0	0	0	0	0
06/06/2020 05:00	0.0	0	0	0	0	0
06/06/2020 06:00	0.0	0	0	0	0	0
06/06/2020 07:00	0.0	0	0	0	0	0
06/06/2020 08:00	0.0	0	0	0	0	0
06/06/2020 09:00	0.0	0	0	0	0	0
06/06/2020 10:00	0.0	0	0	0	0	0
06/06/2020 11:00	0.0	0	0	0	0	0
06/06/2020 12:00	0.0	0	0	0	0	0
06/06/2020 13:00	0.0	0	0	0	0	0
06/06/2020 14:00	0.0	0	0	0	0	0
06/06/2020 15:00	0.0	0	0	0	0	0
06/06/2020 16:00	0.0	0	0	0	0	0
06/06/2020 17:00	0.0	0	0	0	0	0
06/06/2020 18:00	0.0	0	0	0	0	0
06/06/2020 19:00	0.0	0	0	0	0	0
06/06/2020 20:00	0.0	0	0	0	0	0
06/06/2020 21:00	0.0	0	0	0	0	0
06/06/2020 22:00	0.0	0	0	0	0	0
06/06/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/07/2020 00:00	0.0	0	0	0	0	0
06/07/2020 01:00	0.0	0	0	0	0	0
06/07/2020 02:00	0.0	0	0	0	0	0
06/07/2020 03:00	0.0	0	0	0	0	0
06/07/2020 04:00	0.0	0	0	0	0	0
06/07/2020 05:00	0.0	0	0	0	0	0
06/07/2020 06:00	0.0	0	0	0	0	0
06/07/2020 07:00	0.0	0	0	0	0	0
06/07/2020 08:00	0.0	0	0	0	0	0
06/07/2020 09:00	0.0	0	0	0	0	0
06/07/2020 10:00	0.0	0	0	0	0	0
06/07/2020 11:00	0.0	0	0	0	0	0
06/07/2020 12:00	0.0	0	0	0	0	0
06/07/2020 13:00	0.0	0	0	0	0	0
06/07/2020 14:00	0.0	0	0	0	0	0
06/07/2020 15:00	0.0	0	0	0	0	0
06/07/2020 16:00	0.0	0	0	0	0	0
06/07/2020 17:00	0.0	0	0	0	0	0
06/07/2020 18:00	0.0	0	0	0	0	0
06/07/2020 19:00	0.0	0	0	0	0	0
06/07/2020 20:00	0.0	0	0	0	0	0
06/07/2020 21:00	0.0	0	0	0	0	0
06/07/2020 22:00	0.0	0	0	0	0	0
06/07/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/08/2020 00:00	0.0	0	0	0	0	0
06/08/2020 01:00	0.0	0	0	0	0	0
06/08/2020 02:00	0.0	0	0	0	0	0
06/08/2020 03:00	0.0	0	0	0	0	0
06/08/2020 04:00	0.0	0	0	0	0	0
06/08/2020 05:00	0.0	0	0	0	0	0
06/08/2020 06:00	0.0	0	0	0	0	0
06/08/2020 07:00	0.0	0	0	0	0	0
06/08/2020 08:00	0.0	0	0	0	0	0
06/08/2020 09:00	1,771.6	1	0	0	0	0
06/08/2020 10:00	5,145.8	1	0	0	0	0
06/08/2020 11:00	5,434.8	1	0	0	0	0
06/08/2020 12:00	6,591.5	1	0	0	0	0
06/08/2020 13:00	0.0	0	0	0	0	1
06/08/2020 14:00	0.0	0	0	0	0	1
06/08/2020 15:00	0.0	0	0	0	0	1
06/08/2020 16:00	0.0	0	0	0	0	1
06/08/2020 17:00	0.0	0	0	0	0	1
06/08/2020 18:00	0.0	0	0	0	0	1
06/08/2020 19:00	0.0	0	0	0	0	1
06/08/2020 20:00	0.0	0	0	0	0	1
06/08/2020 21:00	0.0	0	0	0	0	1
06/08/2020 22:00	0.0	0	0	0	0	1
06/08/2020 23:00	89.8	0	0	0	1	0
Average/Sum#:	19,033.5 #	4 #	0 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,591.5	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/09/2020 00:00	0.0	0	0	0	0	0
06/09/2020 01:00	0.0	0	0	0	0	0
06/09/2020 02:00	0.0	0	0	0	0	0
06/09/2020 03:00	0.0	0	0	0	0	0
06/09/2020 04:00	0.0	0	0	0	0	0
06/09/2020 05:00	0.0	0	0	0	0	0
06/09/2020 06:00	0.0	0	0	0	0	0
06/09/2020 07:00	0.0	0	0	0	0	0
06/09/2020 08:00	2,240.4	0	1	0	0	0
06/09/2020 09:00	5,114.8	0	1	0	0	0
06/09/2020 10:00	6,943.2	0	1	0	0	0
06/09/2020 11:00	0.0	0	0	0	0	1
06/09/2020 12:00	0.0	0	0	0	0	1
06/09/2020 13:00	0.0	0	0	0	0	1
06/09/2020 14:00	0.0	0	0	0	0	1
06/09/2020 15:00	0.0	0	0	0	0	1
06/09/2020 16:00	0.0	0	0	0	0	1
06/09/2020 17:00	0.0	0	0	0	0	1
06/09/2020 18:00	0.0	0	0	0	0	1
06/09/2020 19:00	0.0	0	0	0	0	1
06/09/2020 20:00	0.0	0	0	0	0	1
06/09/2020 21:00	0.0	0	0	0	0	1
06/09/2020 22:00	0.0	0	0	0	0	1
06/09/2020 23:00	78.7	0	0	0	1	0
Average/Sum#:	14,377.1 #	0 #	3 #	0 #	1 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,943.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/10/2020 00:00	0.0	0	0	0	0	0
06/10/2020 01:00	0.0	0	0	0	0	0
06/10/2020 02:00	0.0	0	0	0	0	0
06/10/2020 03:00	0.0	0	0	0	0	0
06/10/2020 04:00	0.0	0	0	0	0	0
06/10/2020 05:00	0.0	0	0	0	0	0
06/10/2020 06:00	0.0	0	0	0	0	0
06/10/2020 07:00	1,414.6	0	1	0	0	0
06/10/2020 08:00	5,935.8	0	1	0	0	0
06/10/2020 09:00	0.0	0	0	0	0	1
06/10/2020 10:00	0.0	0	0	0	0	1
06/10/2020 11:00	0.0	0	0	0	0	1
06/10/2020 12:00	0.0	0	0	0	0	1
06/10/2020 13:00	0.0	0	0	0	0	1
06/10/2020 14:00	0.0	0	0	0	0	1
06/10/2020 15:00	0.0	0	0	0	0	1
06/10/2020 16:00	0.0	0	0	0	0	1
06/10/2020 17:00	0.0	0	0	0	0	1
06/10/2020 18:00	0.0	0	0	0	0	1
06/10/2020 19:00	0.0	0	0	0	0	1
06/10/2020 20:00	0.0	0	0	0	0	1
06/10/2020 21:00	0.0	0	0	0	0	1
06/10/2020 22:00	0.0	0	0	0	0	1
06/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,350.4 #	0 #	2 #	0 #	0 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,935.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/11/2020 00:00	0.0	0	0	0	0	1
06/11/2020 01:00	0.0	0	0	0	0	1
06/11/2020 02:00	0.0	0	0	0	0	1
06/11/2020 03:00	0.0	0	0	0	0	1
06/11/2020 04:00	0.0	0	0	0	0	1
06/11/2020 05:00	0.0	0	0	0	0	1
06/11/2020 06:00	0.0	0	0	0	0	1
06/11/2020 07:00	0.0	0	0	0	0	1
06/11/2020 08:00	0.0	0	0	0	0	1
06/11/2020 09:00	0.0	0	0	0	0	1
06/11/2020 10:00	0.0	0	0	0	0	1
06/11/2020 11:00	0.0	0	0	0	0	1
06/11/2020 12:00	0.0	0	0	0	0	1
06/11/2020 13:00	0.0	0	0	0	0	1
06/11/2020 14:00	0.0	0	0	0	0	1
06/11/2020 15:00	0.0	0	0	0	0	1
06/11/2020 16:00	0.0	0	0	0	0	1
06/11/2020 17:00	0.0	0	0	0	0	1
06/11/2020 18:00	0.0	0	0	0	0	1
06/11/2020 19:00	0.0	0	0	0	0	1
06/11/2020 20:00	0.0	0	0	0	0	1
06/11/2020 21:00	0.0	0	0	0	0	1
06/11/2020 22:00	0.0	0	0	0	0	1
06/11/2020 23:00	88.1	0	0	0	1	0
Average/Sum#:	88.1 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	88.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/12/2020 00:00	0.0	0	0	0	0	0
06/12/2020 01:00	0.0	0	0	0	0	0
06/12/2020 02:00	0.0	0	0	0	0	0
06/12/2020 03:00	0.0	0	0	0	0	0
06/12/2020 04:00	0.0	0	0	0	0	0
06/12/2020 05:00	0.0	0	0	0	0	0
06/12/2020 06:00	0.0	0	0	0	0	0
06/12/2020 07:00	0.0	0	0	0	0	0
06/12/2020 08:00	0.0	0	0	0	0	0
06/12/2020 09:00	0.0	0	0	0	0	0
06/12/2020 10:00	0.0	0	0	0	0	0
06/12/2020 11:00	0.0	0	0	0	0	0
06/12/2020 12:00	0.0	0	0	0	0	0
06/12/2020 13:00	0.0	0	0	0	0	0
06/12/2020 14:00	0.0	0	0	0	0	0
06/12/2020 15:00	0.0	0	0	0	0	0
06/12/2020 16:00	0.0	0	0	0	0	0
06/12/2020 17:00	0.0	0	0	0	0	0
06/12/2020 18:00	0.0	0	0	0	0	0
06/12/2020 19:00	0.0	0	0	0	0	0
06/12/2020 20:00	0.0	0	0	0	0	0
06/12/2020 21:00	0.0	0	0	0	0	0
06/12/2020 22:00	0.0	0	0	0	0	0
06/12/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/13/2020 00:00	0.0	0	0	0	0	0
06/13/2020 01:00	0.0	0	0	0	0	0
06/13/2020 02:00	0.0	0	0	0	0	0
06/13/2020 03:00	0.0	0	0	0	0	0
06/13/2020 04:00	0.0	0	0	0	0	0
06/13/2020 05:00	0.0	0	0	0	0	0
06/13/2020 06:00	0.0	0	0	0	0	0
06/13/2020 07:00	0.0	0	0	0	0	0
06/13/2020 08:00	0.0	0	0	0	0	0
06/13/2020 09:00	0.0	0	0	0	0	0
06/13/2020 10:00	0.0	0	0	0	0	0
06/13/2020 11:00	0.0	0	0	0	0	0
06/13/2020 12:00	0.0	0	0	0	0	0
06/13/2020 13:00	0.0	0	0	0	0	0
06/13/2020 14:00	0.0	0	0	0	0	0
06/13/2020 15:00	0.0	0	0	0	0	0
06/13/2020 16:00	0.0	0	0	0	0	0
06/13/2020 17:00	0.0	0	0	0	0	0
06/13/2020 18:00	0.0	0	0	0	0	0
06/13/2020 19:00	0.0	0	0	0	0	0
06/13/2020 20:00	0.0	0	0	0	0	0
06/13/2020 21:00	0.0	0	0	0	0	0
06/13/2020 22:00	0.0	0	0	0	0	0
06/13/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/14/2020 00:00	0.0	0	0	0	0	0
06/14/2020 01:00	0.0	0	0	0	0	0
06/14/2020 02:00	0.0	0	0	0	0	0
06/14/2020 03:00	0.0	0	0	0	0	0
06/14/2020 04:00	0.0	0	0	0	0	0
06/14/2020 05:00	0.0	0	0	0	0	0
06/14/2020 06:00	0.0	0	0	0	0	0
06/14/2020 07:00	0.0	0	0	0	0	0
06/14/2020 08:00	0.0	0	0	0	0	0
06/14/2020 09:00	0.0	0	0	0	0	0
06/14/2020 10:00	0.0	0	0	0	0	0
06/14/2020 11:00	0.0	0	0	0	0	0
06/14/2020 12:00	3,170.1	0	1	0	0	0
06/14/2020 13:00	6,496.0	0	1	0	0	0
06/14/2020 14:00	7,967.9	0	1	0	0	0
06/14/2020 15:00	0.0	0	0	0	0	1
06/14/2020 16:00	0.0	0	0	0	0	1
06/14/2020 17:00	0.0	0	0	0	0	1
06/14/2020 18:00	0.0	0	0	0	0	1
06/14/2020 19:00	0.0	0	0	0	0	1
06/14/2020 20:00	0.0	0	0	0	0	1
06/14/2020 21:00	0.0	0	0	0	0	1
06/14/2020 22:00	0.0	0	0	0	0	1
06/14/2020 23:00	98.2	0	0	0	1	0
Average/Sum#:	17,732.2 #	0 #	3 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,967.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/15/2020 00:00	0.0	0	0	0	0	0
06/15/2020 01:00	0.0	0	0	0	0	0
06/15/2020 02:00	0.0	0	0	0	0	0
06/15/2020 03:00	0.0	0	0	0	0	0
06/15/2020 04:00	0.0	0	0	0	0	0
06/15/2020 05:00	0.0	0	0	0	0	0
06/15/2020 06:00	0.0	0	0	0	0	0
06/15/2020 07:00	0.0	0	0	0	0	0
06/15/2020 08:00	0.0	0	0	0	0	0
06/15/2020 09:00	0.0	0	0	0	0	0
06/15/2020 10:00	0.0	0	0	0	0	0
06/15/2020 11:00	0.0	0	0	0	0	0
06/15/2020 12:00	0.0	0	0	0	0	0
06/15/2020 13:00	0.0	0	0	0	0	0
06/15/2020 14:00	0.0	0	0	0	0	0
06/15/2020 15:00	0.0	0	0	0	0	0
06/15/2020 16:00	0.0	0	0	0	0	0
06/15/2020 17:00	0.0	0	0	0	0	0
06/15/2020 18:00	0.0	0	0	0	0	0
06/15/2020 19:00	0.0	0	0	0	0	0
06/15/2020 20:00	0.0	0	0	0	0	0
06/15/2020 21:00	0.0	0	0	0	0	0
06/15/2020 22:00	0.0	0	0	0	0	0
06/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/16/2020 00:00	0.0	0	0	0	0	0
06/16/2020 01:00	0.0	0	0	0	0	0
06/16/2020 02:00	0.0	0	0	0	0	0
06/16/2020 03:00	0.0	0	0	0	0	0
06/16/2020 04:00	0.0	0	0	0	0	0
06/16/2020 05:00	0.0	0	0	0	0	0
06/16/2020 06:00	0.0	0	0	0	0	0
06/16/2020 07:00	0.0	0	0	0	0	0
06/16/2020 08:00	0.0	0	0	0	0	0
06/16/2020 09:00	0.0	0	0	0	0	0
06/16/2020 10:00	0.0	0	0	0	0	0
06/16/2020 11:00	0.0	0	0	0	0	0
06/16/2020 12:00	0.0	0	0	0	0	0
06/16/2020 13:00	0.0	0	0	0	0	0
06/16/2020 14:00	0.0	0	0	0	0	0
06/16/2020 15:00	0.0	0	0	0	0	0
06/16/2020 16:00	0.0	0	0	0	0	0
06/16/2020 17:00	0.0	0	0	0	0	0
06/16/2020 18:00	0.0	0	0	0	0	0
06/16/2020 19:00	0.0	0	0	0	0	0
06/16/2020 20:00	0.0	0	0	0	0	0
06/16/2020 21:00	0.0	0	0	0	0	0
06/16/2020 22:00	0.0	0	0	0	0	0
06/16/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/17/2020 00:00	0.0	0	0	0	0	0
06/17/2020 01:00	0.0	0	0	0	0	0
06/17/2020 02:00	0.0	0	0	0	0	0
06/17/2020 03:00	0.0	0	0	0	0	0
06/17/2020 04:00	0.0	0	0	0	0	0
06/17/2020 05:00	0.0	0	0	0	0	0
06/17/2020 06:00	0.0	0	0	0	0	0
06/17/2020 07:00	0.0	0	0	0	0	0
06/17/2020 08:00	0.0	0	0	0	0	0
06/17/2020 09:00	3,998.2	0	1	0	0	0
06/17/2020 10:00	5,112.5	0	1	0	0	0
06/17/2020 11:00	5,346.7	0	1	0	0	0
06/17/2020 12:00	0.0	0	0	0	0	1
06/17/2020 13:00	0.0	0	0	0	0	1
06/17/2020 14:00	0.0	0	0	0	0	1
06/17/2020 15:00	0.0	0	0	0	0	1
06/17/2020 16:00	0.0	0	0	0	0	1
06/17/2020 17:00	0.0	0	0	0	0	1
06/17/2020 18:00	0.0	0	0	0	0	1
06/17/2020 19:00	0.0	0	0	0	0	1
06/17/2020 20:00	0.0	0	0	0	0	1
06/17/2020 21:00	0.0	0	0	0	0	1
06/17/2020 22:00	0.0	0	0	0	0	1
06/17/2020 23:00	84.6	0	0	0	1	0
Average/Sum#:	14,542.0 #	0 #	3 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,346.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/18/2020 00:00	0.0	0	0	0	0	0
06/18/2020 01:00	0.0	0	0	0	0	0
06/18/2020 02:00	0.0	0	0	0	0	0
06/18/2020 03:00	0.0	0	0	0	0	0
06/18/2020 04:00	0.0	0	0	0	0	0
06/18/2020 05:00	0.0	0	0	0	0	0
06/18/2020 06:00	0.0	0	0	0	0	0
06/18/2020 07:00	1,432.5	0	1	0	0	0
06/18/2020 08:00	6,298.8	0	1	0	0	0
06/18/2020 09:00	0.0	0	0	0	0	1
06/18/2020 10:00	0.0	0	0	0	0	1
06/18/2020 11:00	0.0	0	0	0	0	1
06/18/2020 12:00	0.0	0	0	0	0	1
06/18/2020 13:00	0.0	0	0	0	0	1
06/18/2020 14:00	0.0	0	0	0	0	1
06/18/2020 15:00	0.0	0	0	0	0	1
06/18/2020 16:00	0.0	0	0	0	0	1
06/18/2020 17:00	0.0	0	0	0	0	1
06/18/2020 18:00	0.0	0	0	0	0	1
06/18/2020 19:00	0.0	0	0	0	0	1
06/18/2020 20:00	0.0	0	0	0	0	1
06/18/2020 21:00	0.0	0	0	0	0	1
06/18/2020 22:00	0.0	0	0	0	0	1
06/18/2020 23:00	92.7	0	0	0	1	0
Average/Sum#:	7,824.0 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,298.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/19/2020 00:00	0.0	0	0	0	0	0
06/19/2020 01:00	0.0	0	0	0	0	0
06/19/2020 02:00	0.0	0	0	0	0	0
06/19/2020 03:00	0.0	0	0	0	0	0
06/19/2020 04:00	0.0	0	0	0	0	0
06/19/2020 05:00	0.0	0	0	0	0	0
06/19/2020 06:00	0.0	0	0	0	0	0
06/19/2020 07:00	0.0	0	0	0	0	0
06/19/2020 08:00	0.0	0	0	0	0	0
06/19/2020 09:00	0.0	0	0	0	0	0
06/19/2020 10:00	0.0	0	0	0	0	0
06/19/2020 11:00	0.0	0	0	0	0	0
06/19/2020 12:00	0.0	0	0	0	0	0
06/19/2020 13:00	0.0	0	0	0	0	0
06/19/2020 14:00	0.0	0	0	0	0	0
06/19/2020 15:00	0.0	0	0	0	0	0
06/19/2020 16:00	0.0	0	0	0	0	0
06/19/2020 17:00	0.0	0	0	0	0	0
06/19/2020 18:00	0.0	0	0	0	0	0
06/19/2020 19:00	0.0	0	0	0	0	0
06/19/2020 20:00	0.0	0	0	0	0	0
06/19/2020 21:00	0.0	0	0	0	0	0
06/19/2020 22:00	0.0	0	0	0	0	0
06/19/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/20/2020 00:00	0.0	0	0	0	0	0
06/20/2020 01:00	0.0	0	0	0	0	0
06/20/2020 02:00	0.0	0	0	0	0	0
06/20/2020 03:00	0.0	0	0	0	0	0
06/20/2020 04:00	0.0	0	0	0	0	0
06/20/2020 05:00	0.0	0	0	0	0	0
06/20/2020 06:00	0.0	0	0	0	0	0
06/20/2020 07:00	0.0	0	0	0	0	0
06/20/2020 08:00	0.0	0	0	0	0	0
06/20/2020 09:00	0.0	0	0	0	0	0
06/20/2020 10:00	0.0	0	0	0	0	0
06/20/2020 11:00	0.0	0	0	0	0	0
06/20/2020 12:00	0.0	0	0	0	0	0
06/20/2020 13:00	0.0	0	0	0	0	0
06/20/2020 14:00	0.0	0	0	0	0	0
06/20/2020 15:00	0.0	0	0	0	0	0
06/20/2020 16:00	0.0	0	0	0	0	0
06/20/2020 17:00	0.0	0	0	0	0	0
06/20/2020 18:00	0.0	0	0	0	0	0
06/20/2020 19:00	0.0	0	0	0	0	0
06/20/2020 20:00	4,336.4	0	1	0	0	0
06/20/2020 21:00	5,026.0	0	1	0	0	0
06/20/2020 22:00	5,774.8	0	1	0	0	0
06/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	15,137.2 #	0 #	3 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,774.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/21/2020 00:00	0.0	0	0	0	0	1
06/21/2020 01:00	0.0	0	0	0	0	1
06/21/2020 02:00	0.0	0	0	0	0	1
06/21/2020 03:00	0.0	0	0	0	0	1
06/21/2020 04:00	0.0	0	0	0	0	1
06/21/2020 05:00	0.0	0	0	0	0	1
06/21/2020 06:00	0.0	0	0	0	0	1
06/21/2020 07:00	0.0	0	0	0	0	1
06/21/2020 08:00	0.0	0	0	0	0	1
06/21/2020 09:00	0.0	0	0	0	0	1
06/21/2020 10:00	0.0	0	0	0	0	1
06/21/2020 11:00	0.0	0	0	0	0	1
06/21/2020 12:00	0.0	0	0	0	0	1
06/21/2020 13:00	0.0	0	0	0	0	1
06/21/2020 14:00	0.0	0	0	0	0	1
06/21/2020 15:00	0.0	0	0	0	0	1
06/21/2020 16:00	0.0	0	0	0	0	1
06/21/2020 17:00	0.0	0	0	0	0	1
06/21/2020 18:00	0.0	0	0	0	0	1
06/21/2020 19:00	0.0	0	0	0	0	1
06/21/2020 20:00	0.0	0	0	0	0	1
06/21/2020 21:00	0.0	0	0	0	0	1
06/21/2020 22:00	0.0	0	0	0	0	1
06/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/22/2020 00:00	0.0	0	0	0	0	1
06/22/2020 01:00	0.0	0	0	0	0	1
06/22/2020 02:00	0.0	0	0	0	0	1
06/22/2020 03:00	0.0	0	0	0	0	1
06/22/2020 04:00	0.0	0	0	0	0	1
06/22/2020 05:00	0.0	0	0	0	0	1
06/22/2020 06:00	0.0	0	0	0	0	1
06/22/2020 07:00	0.0	0	0	0	0	1
06/22/2020 08:00	0.0	0	0	0	0	1
06/22/2020 09:00	0.0	0	0	0	0	1
06/22/2020 10:00	0.0	0	0	0	0	1
06/22/2020 11:00	0.0	0	0	0	0	1
06/22/2020 12:00	0.0	0	0	0	0	1
06/22/2020 13:00	0.0	0	0	0	0	1
06/22/2020 14:00	0.0	0	0	0	0	1
06/22/2020 15:00	0.0	0	0	0	0	1
06/22/2020 16:00	0.0	0	0	0	0	1
06/22/2020 17:00	0.0	0	0	0	0	1
06/22/2020 18:00	0.0	0	0	0	0	1
06/22/2020 19:00	0.0	0	0	0	0	1
06/22/2020 20:00	0.0	0	0	0	0	1
06/22/2020 21:00	0.0	0	0	0	0	1
06/22/2020 22:00	0.0	0	0	0	0	1
06/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/23/2020 00:00	149.7	0	0	0	1	0
06/23/2020 01:00	0.0	0	0	0	0	0
06/23/2020 02:00	0.0	0	0	0	0	0
06/23/2020 03:00	0.0	0	0	0	0	0
06/23/2020 04:00	0.0	0	0	0	0	0
06/23/2020 05:00	0.0	0	0	0	0	0
06/23/2020 06:00	0.0	0	0	0	0	0
06/23/2020 07:00	0.0	0	0	0	0	0
06/23/2020 08:00	0.0	0	0	0	0	0
06/23/2020 09:00	0.0	0	0	0	0	0
06/23/2020 10:00	0.0	0	0	0	0	0
06/23/2020 11:00	0.0	0	0	0	0	0
06/23/2020 12:00	985.1	0	1	0	0	0
06/23/2020 13:00	6,468.6	0	1	0	0	0
06/23/2020 14:00	2,164.5	0	1	0	0	0
06/23/2020 15:00	0.0	0	0	0	0	1
06/23/2020 16:00	0.0	0	0	0	0	1
06/23/2020 17:00	0.0	0	0	0	0	1
06/23/2020 18:00	0.0	0	0	0	0	1
06/23/2020 19:00	0.0	0	0	0	0	1
06/23/2020 20:00	0.0	0	0	0	0	1
06/23/2020 21:00	0.0	0	0	0	0	1
06/23/2020 22:00	0.0	0	0	0	0	1
06/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,767.9 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,468.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/24/2020 00:00	0.0	0	0	0	0	1
06/24/2020 01:00	0.0	0	0	0	0	1
06/24/2020 02:00	0.0	0	0	0	0	1
06/24/2020 03:00	0.0	0	0	0	0	1
06/24/2020 04:00	0.0	0	0	0	0	1
06/24/2020 05:00	0.0	0	0	0	0	1
06/24/2020 06:00	0.0	0	0	0	0	1
06/24/2020 07:00	0.0	0	0	0	0	1
06/24/2020 08:00	0.0	0	0	0	0	1
06/24/2020 09:00	0.0	0	0	0	0	1
06/24/2020 10:00	0.0	0	0	0	0	1
06/24/2020 11:00	0.0	0	0	0	0	1
06/24/2020 12:00	0.0	0	0	0	0	1
06/24/2020 13:00	0.0	0	0	0	0	1
06/24/2020 14:00	0.0	0	0	0	0	1
06/24/2020 15:00	0.0	0	0	0	0	1
06/24/2020 16:00	0.0	0	0	0	0	1
06/24/2020 17:00	0.0	0	0	0	0	1
06/24/2020 18:00	0.0	0	0	0	0	1
06/24/2020 19:00	0.0	0	0	0	0	1
06/24/2020 20:00	0.0	0	0	0	0	1
06/24/2020 21:00	0.0	0	0	0	0	1
06/24/2020 22:00	0.0	0	0	0	0	1
06/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/25/2020 00:00	83.8	0	0	0	1	0
06/25/2020 01:00	0.0	0	0	0	0	0
06/25/2020 02:00	0.0	0	0	0	0	0
06/25/2020 03:00	0.0	0	0	0	0	0
06/25/2020 04:00	0.0	0	0	0	0	0
06/25/2020 05:00	0.0	0	0	0	0	0
06/25/2020 06:00	0.0	0	0	0	0	0
06/25/2020 07:00	0.0	0	0	0	0	0
06/25/2020 08:00	611.6	0	1	0	0	0
06/25/2020 09:00	5,762.9	0	1	0	0	0
06/25/2020 10:00	0.0	0	0	0	0	1
06/25/2020 11:00	0.0	0	0	0	0	1
06/25/2020 12:00	0.0	0	0	0	0	1
06/25/2020 13:00	0.0	0	0	0	0	1
06/25/2020 14:00	0.0	0	0	0	0	1
06/25/2020 15:00	0.0	0	0	0	0	1
06/25/2020 16:00	0.0	0	0	0	0	1
06/25/2020 17:00	0.0	0	0	0	0	1
06/25/2020 18:00	0.0	0	0	0	0	1
06/25/2020 19:00	0.0	0	0	0	0	1
06/25/2020 20:00	0.0	0	0	0	0	1
06/25/2020 21:00	0.0	0	0	0	0	1
06/25/2020 22:00	132.9	0	0	0	1	0
06/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	6,591.2 #	0 #	2 #	0 #	2 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,762.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/26/2020 00:00	0.0	0	0	0	0	0
06/26/2020 01:00	0.0	0	0	0	0	0
06/26/2020 02:00	0.0	0	0	0	0	0
06/26/2020 03:00	0.0	0	0	0	0	0
06/26/2020 04:00	0.0	0	0	0	0	0
06/26/2020 05:00	633.7	0	0	1	0	0
06/26/2020 06:00	6,784.7	0	0	1	0	0
06/26/2020 07:00	0.0	0	0	0	0	1
06/26/2020 08:00	0.0	0	0	0	0	1
06/26/2020 09:00	0.0	0	0	0	0	1
06/26/2020 10:00	0.0	0	0	0	0	1
06/26/2020 11:00	0.0	0	0	0	0	1
06/26/2020 12:00	0.0	0	0	0	0	1
06/26/2020 13:00	0.0	0	0	0	0	1
06/26/2020 14:00	0.0	0	0	0	0	1
06/26/2020 15:00	0.0	0	0	0	0	1
06/26/2020 16:00	0.0	0	0	0	0	1
06/26/2020 17:00	0.0	0	0	0	0	1
06/26/2020 18:00	0.0	0	0	0	0	1
06/26/2020 19:00	0.0	0	0	0	0	1
06/26/2020 20:00	0.0	0	0	0	0	1
06/26/2020 21:00	0.0	0	0	0	0	1
06/26/2020 22:00	0.0	0	0	0	0	1
06/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,418.4 #	0 #	0 #	2 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,784.7	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/27/2020 00:00	118.0	0	0	0	1	0
06/27/2020 01:00	0.0	0	0	0	0	0
06/27/2020 02:00	0.0	0	0	0	0	0
06/27/2020 03:00	0.0	0	0	0	0	0
06/27/2020 04:00	0.0	0	0	0	0	0
06/27/2020 05:00	0.0	0	0	0	0	0
06/27/2020 06:00	0.0	0	0	0	0	0
06/27/2020 07:00	0.0	0	0	0	0	0
06/27/2020 08:00	0.0	0	0	0	0	0
06/27/2020 09:00	0.0	0	0	0	0	0
06/27/2020 10:00	0.0	0	0	0	0	0
06/27/2020 11:00	0.0	0	0	0	0	0
06/27/2020 12:00	0.0	0	0	0	0	0
06/27/2020 13:00	0.0	0	0	0	0	0
06/27/2020 14:00	0.0	0	0	0	0	0
06/27/2020 15:00	0.0	0	0	0	0	0
06/27/2020 16:00	0.0	0	0	0	0	0
06/27/2020 17:00	0.0	0	0	0	0	0
06/27/2020 18:00	0.0	0	0	0	0	0
06/27/2020 19:00	0.0	0	0	0	0	0
06/27/2020 20:00	0.0	0	0	0	0	0
06/27/2020 21:00	0.0	0	0	0	0	0
06/27/2020 22:00	0.0	0	0	0	0	0
06/27/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	118.0 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	118.0	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/28/2020 00:00	0.0	0	0	0	0	0
06/28/2020 01:00	0.0	0	0	0	0	0
06/28/2020 02:00	0.0	0	0	0	0	0
06/28/2020 03:00	0.0	0	0	0	0	0
06/28/2020 04:00	0.0	0	0	0	0	0
06/28/2020 05:00	0.0	0	0	0	0	0
06/28/2020 06:00	0.0	0	0	0	0	0
06/28/2020 07:00	0.0	0	0	0	0	0
06/28/2020 08:00	0.0	0	0	0	0	0
06/28/2020 09:00	0.0	0	0	0	0	0
06/28/2020 10:00	0.0	0	0	0	0	0
06/28/2020 11:00	0.0	0	0	0	0	0
06/28/2020 12:00	0.0	0	0	0	0	0
06/28/2020 13:00	0.0	0	0	0	0	0
06/28/2020 14:00	0.0	0	0	0	0	0
06/28/2020 15:00	0.0	0	0	0	0	0
06/28/2020 16:00	0.0	0	0	0	0	0
06/28/2020 17:00	0.0	0	0	0	0	0
06/28/2020 18:00	0.0	0	0	0	0	0
06/28/2020 19:00	0.0	0	0	0	0	0
06/28/2020 20:00	0.0	0	0	0	0	0
06/28/2020 21:00	0.0	0	0	0	0	0
06/28/2020 22:00	0.0	0	0	0	0	0
06/28/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/29/2020 00:00	0.0	0	0	0	0	0
06/29/2020 01:00	0.0	0	0	0	0	0
06/29/2020 02:00	0.0	0	0	0	0	0
06/29/2020 03:00	0.0	0	0	0	0	0
06/29/2020 04:00	0.0	0	0	0	0	0
06/29/2020 05:00	0.0	0	0	0	0	0
06/29/2020 06:00	0.0	0	0	0	0	0
06/29/2020 07:00	0.0	0	0	0	0	0
06/29/2020 08:00	0.0	0	0	0	0	0
06/29/2020 09:00	0.0	0	0	0	0	0
06/29/2020 10:00	0.0	0	0	0	0	0
06/29/2020 11:00	0.0	0	0	0	0	0
06/29/2020 12:00	0.0	0	0	0	0	0
06/29/2020 13:00	0.0	0	0	0	0	0
06/29/2020 14:00	0.0	0	0	0	0	0
06/29/2020 15:00	0.0	0	0	0	0	0
06/29/2020 16:00	0.0	0	0	0	0	0
06/29/2020 17:00	0.0	0	0	0	0	0
06/29/2020 18:00	0.0	0	0	0	0	0
06/29/2020 19:00	0.0	0	0	0	0	0
06/29/2020 20:00	0.0	0	0	0	0	0
06/29/2020 21:00	0.0	0	0	0	0	0
06/29/2020 22:00	0.0	0	0	0	0	0
06/29/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/30/2020 00:00	0.0	0	0	0	0	0
06/30/2020 01:00	0.0	0	0	0	0	0
06/30/2020 02:00	0.0	0	0	0	0	0
06/30/2020 03:00	0.0	0	0	0	0	0
06/30/2020 04:00	0.0	0	0	0	0	0
06/30/2020 05:00	0.0	0	0	0	0	0
06/30/2020 06:00	0.0	0	0	0	0	0
06/30/2020 07:00	0.0	0	0	0	0	0
06/30/2020 08:00	1,809.0	1	0	0	0	0
06/30/2020 09:00	5,038.3	1	0	0	0	0
06/30/2020 10:00	5,535.9	1	0	0	0	0
06/30/2020 11:00	7,020.7	1	0	0	0	0
06/30/2020 12:00	0.0	0	0	0	0	1
06/30/2020 13:00	0.0	0	0	0	0	1
06/30/2020 14:00	0.0	0	0	0	0	1
06/30/2020 15:00	0.0	0	0	0	0	1
06/30/2020 16:00	0.0	0	0	0	0	1
06/30/2020 17:00	0.0	0	0	0	0	1
06/30/2020 18:00	0.0	0	0	0	0	1
06/30/2020 19:00	0.0	0	0	0	0	1
06/30/2020 20:00	0.0	0	0	0	0	1
06/30/2020 21:00	0.0	0	0	0	0	1
06/30/2020 22:00	134.0	0	0	0	1	0
06/30/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	19,537.9 #	4 #	0 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,020.7	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/01/2020 00:00	0.0	0	0	0	0	1
04/01/2020 01:00	0.0	0	0	0	0	1
04/01/2020 02:00	0.0	0	0	0	0	1
04/01/2020 03:00	0.0	0	0	0	0	1
04/01/2020 04:00	0.0	0	0	0	0	1
04/01/2020 05:00	0.0	0	0	0	0	1
04/01/2020 06:00	0.0	0	0	0	0	1
04/01/2020 07:00	0.0	0	0	0	0	1
04/01/2020 08:00	0.0	0	0	0	0	1
04/01/2020 09:00	0.0	0	0	0	0	1
04/01/2020 10:00	0.0	0	0	0	0	1
04/01/2020 11:00	0.0	0	0	0	0	1
04/01/2020 12:00	0.0	0	0	0	0	1
04/01/2020 13:00	0.0	0	0	0	0	1
04/01/2020 14:00	0.0	0	0	0	0	1
04/01/2020 15:00	0.0	0	0	0	0	1
04/01/2020 16:00	0.0	0	0	0	0	1
04/01/2020 17:00	0.0	0	0	0	0	1
04/01/2020 18:00	0.0	0	0	0	0	1
04/01/2020 19:00	0.0	0	0	0	0	1
04/01/2020 20:00	0.0	0	0	0	0	1
04/01/2020 21:00	0.0	0	0	0	0	1
04/01/2020 22:00	0.0	0	0	0	0	1
04/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/02/2020 00:00	0.0	0	0	0	0	1
04/02/2020 01:00	0.0	0	0	0	0	1
04/02/2020 02:00	0.0	0	0	0	0	1
04/02/2020 03:00	0.0	0	0	0	0	1
04/02/2020 04:00	0.0	0	0	0	0	1
04/02/2020 05:00	0.0	0	0	0	0	1
04/02/2020 06:00	0.0	0	0	0	0	1
04/02/2020 07:00	0.0	0	0	0	0	1
04/02/2020 08:00	0.0	0	0	0	0	1
04/02/2020 09:00	0.0	0	0	0	0	1
04/02/2020 10:00	0.0	0	0	0	0	1
04/02/2020 11:00	0.0	0	0	0	0	1
04/02/2020 12:00	0.0	0	0	0	0	1
04/02/2020 13:00	0.0	0	0	0	0	1
04/02/2020 14:00	0.0	0	0	0	0	1
04/02/2020 15:00	0.0	0	0	0	0	1
04/02/2020 16:00	0.0	0	0	0	0	1
04/02/2020 17:00	0.0	0	0	0	0	1
04/02/2020 18:00	0.0	0	0	0	0	1
04/02/2020 19:00	0.0	0	0	0	0	1
04/02/2020 20:00	0.0	0	0	0	0	1
04/02/2020 21:00	2.1	0	0	0	1	0
04/02/2020 22:00	0.0	0	0	0	0	0
04/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.1 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/03/2020 00:00	0.0	0	0	0	0	0
04/03/2020 01:00	0.0	0	0	0	0	0
04/03/2020 02:00	0.0	0	0	0	0	0
04/03/2020 03:00	0.0	0	0	0	0	0
04/03/2020 04:00	0.0	0	0	0	0	0
04/03/2020 05:00	0.0	0	0	0	0	0
04/03/2020 06:00	0.0	0	0	0	0	0
04/03/2020 07:00	0.0	0	0	0	0	0
04/03/2020 08:00	0.0	0	0	0	0	0
04/03/2020 09:00	0.0	0	0	0	0	0
04/03/2020 10:00	0.0	0	0	0	0	0
04/03/2020 11:00	0.0	0	0	0	0	0
04/03/2020 12:00	0.0	0	0	0	0	0
04/03/2020 13:00	0.0	0	0	0	0	0
04/03/2020 14:00	0.0	0	0	0	0	0
04/03/2020 15:00	0.0	0	0	0	0	0
04/03/2020 16:00	0.0	0	0	0	0	0
04/03/2020 17:00	0.0	0	0	0	0	0
04/03/2020 18:00	0.0	0	0	0	0	0
04/03/2020 19:00	0.0	0	0	0	0	0
04/03/2020 20:00	73.5	0	1	0	0	0
04/03/2020 21:00	32.8	0	1	0	0	0
04/03/2020 22:00	40.9	0	1	0	0	0
04/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	147.2 #	0 #	3 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	73.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/04/2020 00:00	0.0	0	0	0	0	1
04/04/2020 01:00	0.0	0	0	0	0	1
04/04/2020 02:00	0.0	0	0	0	0	1
04/04/2020 03:00	0.0	0	0	0	0	1
04/04/2020 04:00	0.0	0	0	0	0	1
04/04/2020 05:00	0.0	0	0	0	0	1
04/04/2020 06:00	0.0	0	0	0	0	1
04/04/2020 07:00	0.0	0	0	0	0	1
04/04/2020 08:00	0.0	0	0	0	0	1
04/04/2020 09:00	0.0	0	0	0	0	1
04/04/2020 10:00	0.0	0	0	0	0	1
04/04/2020 11:00	0.0	0	0	0	0	1
04/04/2020 12:00	0.0	0	0	0	0	1
04/04/2020 13:00	0.0	0	0	0	0	1
04/04/2020 14:00	0.0	0	0	0	0	1
04/04/2020 15:00	0.0	0	0	0	0	1
04/04/2020 16:00	0.0	0	0	0	0	1
04/04/2020 17:00	0.0	0	0	0	0	1
04/04/2020 18:00	0.0	0	0	0	0	1
04/04/2020 19:00	0.0	0	0	0	0	1
04/04/2020 20:00	0.0	0	0	0	0	1
04/04/2020 21:00	0.0	0	0	0	0	1
04/04/2020 22:00	0.0	0	0	0	0	1
04/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/05/2020 00:00	0.0	0	0	0	0	1
04/05/2020 01:00	0.0	0	0	0	0	1
04/05/2020 02:00	0.0	0	0	0	0	1
04/05/2020 03:00	0.0	0	0	0	0	1
04/05/2020 04:00	0.0	0	0	0	0	1
04/05/2020 05:00	0.0	0	0	0	0	1
04/05/2020 06:00	0.0	0	0	0	0	1
04/05/2020 07:00	0.0	0	0	0	0	1
04/05/2020 08:00	0.0	0	0	0	0	1
04/05/2020 09:00	0.0	0	0	0	0	1
04/05/2020 10:00	0.0	0	0	0	0	1
04/05/2020 11:00	0.0	0	0	0	0	1
04/05/2020 12:00	0.0	0	0	0	0	1
04/05/2020 13:00	0.0	0	0	0	0	1
04/05/2020 14:00	0.0	0	0	0	0	1
04/05/2020 15:00	0.0	0	0	0	0	1
04/05/2020 16:00	0.0	0	0	0	0	1
04/05/2020 17:00	0.0	0	0	0	0	1
04/05/2020 18:00	0.0	0	0	0	0	1
04/05/2020 19:00	0.0	0	0	0	0	1
04/05/2020 20:00	0.0	0	0	0	0	1
04/05/2020 21:00	0.0	0	0	0	0	1
04/05/2020 22:00	0.0	0	0	0	0	1
04/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/06/2020 00:00	0.0	0	0	0	0	1
04/06/2020 01:00	0.0	0	0	0	0	1
04/06/2020 02:00	0.0	0	0	0	0	1
04/06/2020 03:00	0.0	0	0	0	0	1
04/06/2020 04:00	0.0	0	0	0	0	1
04/06/2020 05:00	0.0	0	0	0	0	1
04/06/2020 06:00	0.0	0	0	0	0	1
04/06/2020 07:00	0.0	0	0	0	0	1
04/06/2020 08:00	0.0	0	0	0	0	1
04/06/2020 09:00	0.0	0	0	0	0	1
04/06/2020 10:00	0.0	0	0	0	0	1
04/06/2020 11:00	0.0	0	0	0	0	1
04/06/2020 12:00	0.0	0	0	0	0	1
04/06/2020 13:00	0.0	0	0	0	0	1
04/06/2020 14:00	0.0	0	0	0	0	1
04/06/2020 15:00	0.0	0	0	0	0	1
04/06/2020 16:00	0.0	0	0	0	0	1
04/06/2020 17:00	0.0	0	0	0	0	1
04/06/2020 18:00	0.0	0	0	0	0	1
04/06/2020 19:00	0.0	0	0	0	0	1
04/06/2020 20:00	0.0	0	0	0	0	1
04/06/2020 21:00	0.0	0	0	0	0	1
04/06/2020 22:00	0.0	0	0	0	0	1
04/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/07/2020 00:00	0.0	0	0	0	0	1
04/07/2020 01:00	0.0	0	0	0	0	1
04/07/2020 02:00	0.0	0	0	0	0	1
04/07/2020 03:00	0.0	0	0	0	0	1
04/07/2020 04:00	0.0	0	0	0	0	1
04/07/2020 05:00	0.0	0	0	0	0	1
04/07/2020 06:00	0.0	0	0	0	0	1
04/07/2020 07:00	0.0	0	0	0	0	1
04/07/2020 08:00	0.0	0	0	0	0	1
04/07/2020 09:00	0.0	0	0	0	0	1
04/07/2020 10:00	0.0	0	0	0	0	1
04/07/2020 11:00	0.0	0	0	0	0	1
04/07/2020 12:00	0.0	0	0	0	0	1
04/07/2020 13:00	0.0	0	0	0	0	1
04/07/2020 14:00	0.0	0	0	0	0	1
04/07/2020 15:00	0.0	0	0	0	0	1
04/07/2020 16:00	0.0	0	0	0	0	1
04/07/2020 17:00	0.0	0	0	0	0	1
04/07/2020 18:00	0.0	0	0	0	0	1
04/07/2020 19:00	0.0	0	0	0	0	1
04/07/2020 20:00	0.0	0	0	0	0	1
04/07/2020 21:00	0.0	0	0	0	0	1
04/07/2020 22:00	0.0	0	0	0	0	1
04/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/08/2020 00:00	0.0	0	0	0	0	1
04/08/2020 01:00	0.0	0	0	0	0	1
04/08/2020 02:00	0.0	0	0	0	0	1
04/08/2020 03:00	0.0	0	0	0	0	1
04/08/2020 04:00	0.0	0	0	0	0	1
04/08/2020 05:00	0.0	0	0	0	0	1
04/08/2020 06:00	0.0	0	0	0	0	1
04/08/2020 07:00	0.0	0	0	0	0	1
04/08/2020 08:00	0.0	0	0	0	0	1
04/08/2020 09:00	0.0	0	0	0	0	1
04/08/2020 10:00	0.0	0	0	0	0	1
04/08/2020 11:00	0.0	0	0	0	0	1
04/08/2020 12:00	0.0	0	0	0	0	1
04/08/2020 13:00	0.0	0	0	0	0	1
04/08/2020 14:00	0.0	0	0	0	0	1
04/08/2020 15:00	0.0	0	0	0	0	1
04/08/2020 16:00	0.0	0	0	0	0	1
04/08/2020 17:00	0.0	0	0	0	0	1
04/08/2020 18:00	0.0	0	0	0	0	1
04/08/2020 19:00	0.0	0	0	0	0	1
04/08/2020 20:00	0.0	0	0	0	0	1
04/08/2020 21:00	0.0	0	0	0	0	1
04/08/2020 22:00	0.0	0	0	0	0	1
04/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/09/2020 00:00	0.0	0	0	0	0	1
04/09/2020 01:00	0.0	0	0	0	0	1
04/09/2020 02:00	0.0	0	0	0	0	1
04/09/2020 03:00	0.0	0	0	0	0	1
04/09/2020 04:00	0.0	0	0	0	0	1
04/09/2020 05:00	0.0	0	0	0	0	1
04/09/2020 06:00	0.0	0	0	0	0	1
04/09/2020 07:00	0.0	0	0	0	0	1
04/09/2020 08:00	0.0	0	0	0	0	1
04/09/2020 09:00	0.0	0	0	0	0	1
04/09/2020 10:00	0.0	0	0	0	0	1
04/09/2020 11:00	0.0	0	0	0	0	1
04/09/2020 12:00	0.0	0	0	0	0	1
04/09/2020 13:00	0.0	0	0	0	0	1
04/09/2020 14:00	0.0	0	0	0	0	1
04/09/2020 15:00	0.0	0	0	0	0	1
04/09/2020 16:00	0.0	0	0	0	0	1
04/09/2020 17:00	0.0	0	0	0	0	1
04/09/2020 18:00	0.0	0	0	0	0	1
04/09/2020 19:00	0.0	0	0	0	0	1
04/09/2020 20:00	0.0	0	0	0	0	1
04/09/2020 21:00	0.0	0	0	0	0	1
04/09/2020 22:00	0.0	0	0	0	0	1
04/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/10/2020 00:00	0.0	0	0	0	0	1
04/10/2020 01:00	0.0	0	0	0	0	1
04/10/2020 02:00	0.0	0	0	0	0	1
04/10/2020 03:00	0.0	0	0	0	0	1
04/10/2020 04:00	0.0	0	0	0	0	1
04/10/2020 05:00	0.0	0	0	0	0	1
04/10/2020 06:00	0.0	0	0	0	0	1
04/10/2020 07:00	0.0	0	0	0	0	1
04/10/2020 08:00	0.0	0	0	0	0	1
04/10/2020 09:00	0.0	0	0	0	0	1
04/10/2020 10:00	0.0	0	0	0	0	1
04/10/2020 11:00	0.0	0	0	0	0	1
04/10/2020 12:00	0.0	0	0	0	0	1
04/10/2020 13:00	0.0	0	0	0	0	1
04/10/2020 14:00	0.0	0	0	0	0	1
04/10/2020 15:00	0.0	0	0	0	0	1
04/10/2020 16:00	0.0	0	0	0	0	1
04/10/2020 17:00	0.0	0	0	0	0	1
04/10/2020 18:00	0.0	0	0	0	0	1
04/10/2020 19:00	0.0	0	0	0	0	1
04/10/2020 20:00	0.0	0	0	0	0	1
04/10/2020 21:00	0.0	0	0	0	0	1
04/10/2020 22:00	0.0	0	0	0	0	1
04/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/11/2020 00:00	0.0	0	0	0	0	1
04/11/2020 01:00	0.0	0	0	0	0	1
04/11/2020 02:00	0.0	0	0	0	0	1
04/11/2020 03:00	0.0	0	0	0	0	1
04/11/2020 04:00	0.0	0	0	0	0	1
04/11/2020 05:00	0.0	0	0	0	0	1
04/11/2020 06:00	0.0	0	0	0	0	1
04/11/2020 07:00	0.0	0	0	0	0	1
04/11/2020 08:00	0.0	0	0	0	0	1
04/11/2020 09:00	0.0	0	0	0	0	1
04/11/2020 10:00	0.0	0	0	0	0	1
04/11/2020 11:00	0.0	0	0	0	0	1
04/11/2020 12:00	0.0	0	0	0	0	1
04/11/2020 13:00	0.0	0	0	0	0	1
04/11/2020 14:00	0.0	0	0	0	0	1
04/11/2020 15:00	0.0	0	0	0	0	1
04/11/2020 16:00	0.0	0	0	0	0	1
04/11/2020 17:00	0.0	0	0	0	0	1
04/11/2020 18:00	0.0	0	0	0	0	1
04/11/2020 19:00	0.0	0	0	0	0	1
04/11/2020 20:00	0.0	0	0	0	0	1
04/11/2020 21:00	0.0	0	0	0	0	1
04/11/2020 22:00	0.0	0	0	0	0	1
04/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/12/2020 00:00	0.0	0	0	0	0	1
04/12/2020 01:00	0.0	0	0	0	0	1
04/12/2020 02:00	0.0	0	0	0	0	1
04/12/2020 03:00	0.0	0	0	0	0	1
04/12/2020 04:00	0.0	0	0	0	0	1
04/12/2020 05:00	0.0	0	0	0	0	1
04/12/2020 06:00	0.0	0	0	0	0	1
04/12/2020 07:00	0.0	0	0	0	0	1
04/12/2020 08:00	0.0	0	0	0	0	1
04/12/2020 09:00	0.0	0	0	0	0	1
04/12/2020 10:00	0.0	0	0	0	0	1
04/12/2020 11:00	0.0	0	0	0	0	1
04/12/2020 12:00	0.0	0	0	0	0	1
04/12/2020 13:00	0.0	0	0	0	0	1
04/12/2020 14:00	0.0	0	0	0	0	1
04/12/2020 15:00	0.0	0	0	0	0	1
04/12/2020 16:00	0.0	0	0	0	0	1
04/12/2020 17:00	0.0	0	0	0	0	1
04/12/2020 18:00	0.0	0	0	0	0	1
04/12/2020 19:00	0.0	0	0	0	0	1
04/12/2020 20:00	0.0	0	0	0	0	1
04/12/2020 21:00	0.0	0	0	0	0	1
04/12/2020 22:00	0.0	0	0	0	0	1
04/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/13/2020 00:00	0.0	0	0	0	0	1
04/13/2020 01:00	0.0	0	0	0	0	1
04/13/2020 02:00	0.0	0	0	0	0	1
04/13/2020 03:00	0.0	0	0	0	0	1
04/13/2020 04:00	0.0	0	0	0	0	1
04/13/2020 05:00	0.0	0	0	0	0	1
04/13/2020 06:00	0.0	0	0	0	0	1
04/13/2020 07:00	0.0	0	0	0	0	1
04/13/2020 08:00	0.0	0	0	0	0	1
04/13/2020 09:00	0.0	0	0	0	0	1
04/13/2020 10:00	0.0	0	0	0	0	1
04/13/2020 11:00	0.0	0	0	0	0	1
04/13/2020 12:00	0.0	0	0	0	0	1
04/13/2020 13:00	0.0	0	0	0	0	1
04/13/2020 14:00	0.0	0	0	0	0	1
04/13/2020 15:00	0.0	0	0	0	0	1
04/13/2020 16:00	0.0	0	0	0	0	1
04/13/2020 17:00	0.0	0	0	0	0	1
04/13/2020 18:00	0.0	0	0	0	0	1
04/13/2020 19:00	0.0	0	0	0	0	1
04/13/2020 20:00	0.0	0	0	0	0	1
04/13/2020 21:00	0.0	0	0	0	0	1
04/13/2020 22:00	0.0	0	0	0	0	1
04/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/14/2020 00:00	0.0	0	0	0	0	1
04/14/2020 01:00	0.0	0	0	0	0	1
04/14/2020 02:00	0.0	0	0	0	0	1
04/14/2020 03:00	0.0	0	0	0	0	1
04/14/2020 04:00	0.0	0	0	0	0	1
04/14/2020 05:00	0.0	0	0	0	0	1
04/14/2020 06:00	0.0	0	0	0	0	1
04/14/2020 07:00	0.0	0	0	0	0	1
04/14/2020 08:00	0.0	0	0	0	0	1
04/14/2020 09:00	0.0	0	0	0	0	1
04/14/2020 10:00	0.0	0	0	0	0	1
04/14/2020 11:00	0.0	0	0	0	0	1
04/14/2020 12:00	0.0	0	0	0	0	1
04/14/2020 13:00	0.0	0	0	0	0	1
04/14/2020 14:00	0.0	0	0	0	0	1
04/14/2020 15:00	0.0	0	0	0	0	1
04/14/2020 16:00	0.0	0	0	0	0	1
04/14/2020 17:00	0.0	0	0	0	0	1
04/14/2020 18:00	0.0	0	0	0	0	1
04/14/2020 19:00	0.0	0	0	0	0	1
04/14/2020 20:00	0.0	0	0	0	0	1
04/14/2020 21:00	0.0	0	0	0	0	1
04/14/2020 22:00	0.0	0	0	0	0	1
04/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/15/2020 00:00	0.0	0	0	0	0	1
04/15/2020 01:00	0.0	0	0	0	0	1
04/15/2020 02:00	0.0	0	0	0	0	1
04/15/2020 03:00	0.0	0	0	0	0	1
04/15/2020 04:00	0.0	0	0	0	0	1
04/15/2020 05:00	0.0	0	0	0	0	1
04/15/2020 06:00	0.0	0	0	0	0	1
04/15/2020 07:00	0.0	0	0	0	0	1
04/15/2020 08:00	0.0	0	0	0	0	1
04/15/2020 09:00	0.0	0	0	0	0	1
04/15/2020 10:00	0.0	0	0	0	0	1
04/15/2020 11:00	0.0	0	0	0	0	1
04/15/2020 12:00	0.0	0	0	0	0	1
04/15/2020 13:00	0.0	0	0	0	0	1
04/15/2020 14:00	0.0	0	0	0	0	1
04/15/2020 15:00	0.0	0	0	0	0	1
04/15/2020 16:00	0.0	0	0	0	0	1
04/15/2020 17:00	0.0	0	0	0	0	1
04/15/2020 18:00	0.0	0	0	0	0	1
04/15/2020 19:00	0.0	0	0	0	0	1
04/15/2020 20:00	0.0	0	0	0	0	1
04/15/2020 21:00	0.0	0	0	0	0	1
04/15/2020 22:00	0.0	0	0	0	0	1
04/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/16/2020 00:00	0.0	0	0	0	0	1
04/16/2020 01:00	0.0	0	0	0	0	1
04/16/2020 02:00	0.0	0	0	0	0	1
04/16/2020 03:00	0.0	0	0	0	0	1
04/16/2020 04:00	0.0	0	0	0	0	1
04/16/2020 05:00	0.0	0	0	0	0	1
04/16/2020 06:00	0.0	0	0	0	0	1
04/16/2020 07:00	0.0	0	0	0	0	1
04/16/2020 08:00	0.0	0	0	0	0	1
04/16/2020 09:00	0.0	0	0	0	0	1
04/16/2020 10:00	0.0	0	0	0	0	1
04/16/2020 11:00	0.0	0	0	0	0	1
04/16/2020 12:00	0.0	0	0	0	0	1
04/16/2020 13:00	0.0	0	0	0	0	1
04/16/2020 14:00	0.0	0	0	0	0	1
04/16/2020 15:00	0.0	0	0	0	0	1
04/16/2020 16:00	0.0	0	0	0	0	1
04/16/2020 17:00	0.0	0	0	0	0	1
04/16/2020 18:00	0.0	0	0	0	0	1
04/16/2020 19:00	0.0	0	0	0	0	1
04/16/2020 20:00	0.0	0	0	0	0	1
04/16/2020 21:00	0.0	0	0	0	0	1
04/16/2020 22:00	0.0	0	0	0	0	1
04/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/17/2020 00:00	0.0	0	0	0	0	1
04/17/2020 01:00	0.0	0	0	0	0	1
04/17/2020 02:00	0.0	0	0	0	0	1
04/17/2020 03:00	0.0	0	0	0	0	1
04/17/2020 04:00	0.0	0	0	0	0	1
04/17/2020 05:00	0.0	0	0	0	0	1
04/17/2020 06:00	0.0	0	0	0	0	1
04/17/2020 07:00	0.0	0	0	0	0	1
04/17/2020 08:00	0.0	0	0	0	0	1
04/17/2020 09:00	0.0	0	0	0	0	1
04/17/2020 10:00	0.0	0	0	0	0	1
04/17/2020 11:00	0.0	0	0	0	0	1
04/17/2020 12:00	0.0	0	0	0	0	1
04/17/2020 13:00	0.0	0	0	0	0	1
04/17/2020 14:00	0.0	0	0	0	0	1
04/17/2020 15:00	0.0	0	0	0	0	1
04/17/2020 16:00	0.0	0	0	0	0	1
04/17/2020 17:00	0.0	0	0	0	0	1
04/17/2020 18:00	0.0	0	0	0	0	1
04/17/2020 19:00	0.0	0	0	0	0	1
04/17/2020 20:00	0.0	0	0	0	0	1
04/17/2020 21:00	0.0	0	0	0	0	1
04/17/2020 22:00	0.0	0	0	0	0	1
04/17/2020 23:00	1.4	0	0	0	1	0
Average/Sum#:	1.4 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/18/2020 00:00	0.0	0	0	0	0	0
04/18/2020 01:00	0.0	0	0	0	0	0
04/18/2020 02:00	0.0	0	0	0	0	0
04/18/2020 03:00	0.0	0	0	0	0	0
04/18/2020 04:00	0.0	0	0	0	0	0
04/18/2020 05:00	0.0	0	0	0	0	0
04/18/2020 06:00	0.0	0	0	0	0	0
04/18/2020 07:00	0.0	0	0	0	0	0
04/18/2020 08:00	0.0	0	0	0	0	0
04/18/2020 09:00	0.0	0	0	0	0	0
04/18/2020 10:00	0.0	0	0	0	0	0
04/18/2020 11:00	0.0	0	0	0	0	0
04/18/2020 12:00	0.0	0	0	0	0	0
04/18/2020 13:00	0.0	0	0	0	0	0
04/18/2020 14:00	0.0	0	0	0	0	0
04/18/2020 15:00	0.0	0	0	0	0	0
04/18/2020 16:00	0.0	0	0	0	0	0
04/18/2020 17:00	0.0	0	0	0	0	0
04/18/2020 18:00	0.0	0	0	0	0	0
04/18/2020 19:00	0.0	0	0	0	0	0
04/18/2020 20:00	0.0	0	0	0	0	0
04/18/2020 21:00	0.0	0	0	0	0	0
04/18/2020 22:00	0.0	0	0	0	0	0
04/18/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/19/2020 00:00	0.0	0	0	0	0	0
04/19/2020 01:00	0.0	0	0	0	0	0
04/19/2020 02:00	0.0	0	0	0	0	0
04/19/2020 03:00	0.0	0	0	0	0	0
04/19/2020 04:00	0.0	0	0	0	0	0
04/19/2020 05:00	0.0	0	0	0	0	0
04/19/2020 06:00	0.0	0	0	0	0	0
04/19/2020 07:00	0.0	0	0	0	0	0
04/19/2020 08:00	0.0	0	0	0	0	0
04/19/2020 09:00	0.0	0	0	0	0	0
04/19/2020 10:00	0.0	0	0	0	0	0
04/19/2020 11:00	0.0	0	0	0	0	0
04/19/2020 12:00	0.0	0	0	0	0	0
04/19/2020 13:00	0.0	0	0	0	0	0
04/19/2020 14:00	0.0	0	0	0	0	0
04/19/2020 15:00	0.0	0	0	0	0	0
04/19/2020 16:00	0.0	0	0	0	0	0
04/19/2020 17:00	67.4	0	1	0	0	0
04/19/2020 18:00	48.5	0	1	0	0	0
04/19/2020 19:00	41.1	0	1	0	0	0
04/19/2020 20:00	0.0	0	0	0	0	1
04/19/2020 21:00	0.0	0	0	0	0	1
04/19/2020 22:00	0.0	0	0	0	0	1
04/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	157.0 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	67.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/20/2020 00:00	0.0	0	0	0	0	1
04/20/2020 01:00	0.0	0	0	0	0	1
04/20/2020 02:00	0.0	0	0	0	0	1
04/20/2020 03:00	0.0	0	0	0	0	1
04/20/2020 04:00	0.0	0	0	0	0	1
04/20/2020 05:00	0.0	0	0	0	0	1
04/20/2020 06:00	0.0	0	0	0	0	1
04/20/2020 07:00	0.0	0	0	0	0	1
04/20/2020 08:00	0.0	0	0	0	0	1
04/20/2020 09:00	0.0	0	0	0	0	1
04/20/2020 10:00	0.0	0	0	0	0	1
04/20/2020 11:00	0.0	0	0	0	0	1
04/20/2020 12:00	0.0	0	0	0	0	1
04/20/2020 13:00	0.0	0	0	0	0	1
04/20/2020 14:00	0.0	0	0	0	0	1
04/20/2020 15:00	0.0	0	0	0	0	1
04/20/2020 16:00	0.0	0	0	0	0	1
04/20/2020 17:00	0.0	0	0	0	0	1
04/20/2020 18:00	0.0	0	0	0	0	1
04/20/2020 19:00	0.0	0	0	0	0	1
04/20/2020 20:00	0.0	0	0	0	0	1
04/20/2020 21:00	0.0	0	0	0	0	1
04/20/2020 22:00	0.0	0	0	0	0	1
04/20/2020 23:00	1.3	0	0	0	1	0
Average/Sum#:	1.3 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/21/2020 00:00	0.0	0	0	0	0	0
04/21/2020 01:00	0.0	0	0	0	0	0
04/21/2020 02:00	0.0	0	0	0	0	0
04/21/2020 03:00	0.0	0	0	0	0	0
04/21/2020 04:00	0.0	0	0	0	0	0
04/21/2020 05:00	0.0	0	0	0	0	0
04/21/2020 06:00	0.0	0	0	0	0	0
04/21/2020 07:00	0.0	0	0	0	0	0
04/21/2020 08:00	0.0	0	0	0	0	0
04/21/2020 09:00	0.0	0	0	0	0	0
04/21/2020 10:00	0.0	0	0	0	0	0
04/21/2020 11:00	0.0	0	0	0	0	0
04/21/2020 12:00	0.0	0	0	0	0	0
04/21/2020 13:00	0.0	0	0	0	0	0
04/21/2020 14:00	0.0	0	0	0	0	0
04/21/2020 15:00	0.0	0	0	0	0	0
04/21/2020 16:00	0.0	0	0	0	0	0
04/21/2020 17:00	0.0	0	0	0	0	0
04/21/2020 18:00	0.0	0	0	0	0	0
04/21/2020 19:00	0.0	0	0	0	0	0
04/21/2020 20:00	0.0	0	0	0	0	0
04/21/2020 21:00	0.0	0	0	0	0	0
04/21/2020 22:00	0.0	0	0	0	0	0
04/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/22/2020 00:00	0.0	0	0	0	0	0
04/22/2020 01:00	0.0	0	0	0	0	0
04/22/2020 02:00	0.0	0	0	0	0	0
04/22/2020 03:00	0.0	0	0	0	0	0
04/22/2020 04:00	62.6	0	1	0	0	0
04/22/2020 05:00	24.7	0	1	0	0	0
04/22/2020 06:00	20.4	0	1	0	0	0
04/22/2020 07:00	0.0	0	0	0	0	1
04/22/2020 08:00	0.0	0	0	0	0	1
04/22/2020 09:00	0.0	0	0	0	0	1
04/22/2020 10:00	0.0	0	0	0	0	1
04/22/2020 11:00	0.0	0	0	0	0	1
04/22/2020 12:00	0.0	0	0	0	0	1
04/22/2020 13:00	1.0	0	0	0	1	0
04/22/2020 14:00	0.0	0	0	0	0	0
04/22/2020 15:00	0.0	0	0	0	0	0
04/22/2020 16:00	0.0	0	0	0	0	0
04/22/2020 17:00	0.0	0	0	0	0	0
04/22/2020 18:00	2.3	0	0	1	0	0
04/22/2020 19:00	42.5	0	0	1	0	0
04/22/2020 20:00	0.0	0	0	0	0	1
04/22/2020 21:00	0.0	0	0	0	0	1
04/22/2020 22:00	0.0	0	0	0	0	1
04/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	153.5 #	0 #	3 #	2 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	62.6	0	1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/23/2020 00:00	0.0	0	0	0	0	1
04/23/2020 01:00	0.0	0	0	0	0	1
04/23/2020 02:00	0.8	0	0	0	1	0
04/23/2020 03:00	0.0	0	0	0	0	0
04/23/2020 04:00	0.0	0	0	0	0	0
04/23/2020 05:00	0.0	0	0	0	0	0
04/23/2020 06:00	0.0	0	0	0	0	0
04/23/2020 07:00	0.0	0	0	0	0	0
04/23/2020 08:00	0.0	0	0	0	0	0
04/23/2020 09:00	0.0	0	0	0	0	0
04/23/2020 10:00	0.0	0	0	0	0	0
04/23/2020 11:00	0.0	0	0	0	0	0
04/23/2020 12:00	0.0	0	0	0	0	0
04/23/2020 13:00	0.0	0	0	0	0	0
04/23/2020 14:00	0.0	0	0	0	0	0
04/23/2020 15:00	0.0	0	0	0	0	0
04/23/2020 16:00	0.0	0	0	0	0	0
04/23/2020 17:00	0.0	0	0	0	0	0
04/23/2020 18:00	0.0	0	0	0	0	0
04/23/2020 19:00	0.0	0	0	0	0	0
04/23/2020 20:00	0.0	0	0	0	0	0
04/23/2020 21:00	0.0	0	0	0	0	0
04/23/2020 22:00	0.0	0	0	0	0	0
04/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/24/2020 00:00	0.0	0	0	0	0	0
04/24/2020 01:00	0.0	0	0	0	0	0
04/24/2020 02:00	0.0	0	0	0	0	0
04/24/2020 03:00	0.0	0	0	0	0	0
04/24/2020 04:00	0.0	0	0	0	0	0
04/24/2020 05:00	0.0	0	0	0	0	0
04/24/2020 06:00	0.0	0	0	0	0	0
04/24/2020 07:00	0.0	0	0	0	0	0
04/24/2020 08:00	0.0	0	0	0	0	0
04/24/2020 09:00	67.2	0	1	0	0	0
04/24/2020 10:00	37.6	0	1	0	0	0
04/24/2020 11:00	48.1	0	1	0	0	0
04/24/2020 12:00	0.0	0	0	0	0	1
04/24/2020 13:00	0.0	0	0	0	0	1
04/24/2020 14:00	0.0	0	0	0	0	1
04/24/2020 15:00	0.0	0	0	0	0	1
04/24/2020 16:00	0.0	0	0	0	0	1
04/24/2020 17:00	0.0	0	0	0	0	1
04/24/2020 18:00	0.0	0	0	0	0	1
04/24/2020 19:00	0.0	0	0	0	0	1
04/24/2020 20:00	0.0	0	0	0	0	1
04/24/2020 21:00	0.0	0	0	0	0	1
04/24/2020 22:00	0.7	0	0	0	1	0
04/24/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	153.6 #	0 #	3 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	67.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/25/2020 00:00	0.0	0	0	0	0	0
04/25/2020 01:00	0.0	0	0	0	0	0
04/25/2020 02:00	0.0	0	0	0	0	0
04/25/2020 03:00	0.0	0	0	0	0	0
04/25/2020 04:00	0.0	0	0	0	0	0
04/25/2020 05:00	0.0	0	0	0	0	0
04/25/2020 06:00	0.0	0	0	0	0	0
04/25/2020 07:00	0.0	0	0	0	0	0
04/25/2020 08:00	0.0	0	0	0	0	0
04/25/2020 09:00	0.0	0	0	0	0	0
04/25/2020 10:00	0.0	0	0	0	0	0
04/25/2020 11:00	0.0	0	0	0	0	0
04/25/2020 12:00	0.0	0	0	0	0	0
04/25/2020 13:00	0.0	0	0	0	0	0
04/25/2020 14:00	0.0	0	0	0	0	0
04/25/2020 15:00	0.0	0	0	0	0	0
04/25/2020 16:00	0.0	0	0	0	0	0
04/25/2020 17:00	0.0	0	0	0	0	0
04/25/2020 18:00	0.0	0	0	0	0	0
04/25/2020 19:00	0.0	0	0	0	0	0
04/25/2020 20:00	0.0	0	0	0	0	0
04/25/2020 21:00	0.0	0	0	0	0	0
04/25/2020 22:00	0.0	0	0	0	0	0
04/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/26/2020 00:00	0.0	0	0	0	0	0
04/26/2020 01:00	0.0	0	0	0	0	0
04/26/2020 02:00	0.0	0	0	0	0	0
04/26/2020 03:00	0.0	0	0	0	0	0
04/26/2020 04:00	0.0	0	0	0	0	0
04/26/2020 05:00	0.0	0	0	0	0	0
04/26/2020 06:00	0.0	0	0	0	0	0
04/26/2020 07:00	0.0	0	0	0	0	0
04/26/2020 08:00	0.0	0	0	0	0	0
04/26/2020 09:00	0.0	0	0	0	0	0
04/26/2020 10:00	0.0	0	0	0	0	0
04/26/2020 11:00	0.0	0	0	0	0	0
04/26/2020 12:00	0.0	0	0	0	0	0
04/26/2020 13:00	0.0	0	0	0	0	0
04/26/2020 14:00	0.0	0	0	0	0	0
04/26/2020 15:00	0.0	0	0	0	0	0
04/26/2020 16:00	0.0	0	0	0	0	0
04/26/2020 17:00	0.0	0	0	0	0	0
04/26/2020 18:00	0.0	0	0	0	0	0
04/26/2020 19:00	0.0	0	0	0	0	0
04/26/2020 20:00	0.0	0	0	0	0	0
04/26/2020 21:00	0.0	0	0	0	0	0
04/26/2020 22:00	0.0	0	0	0	0	0
04/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/27/2020 00:00	0.0	0	0	0	0	0
04/27/2020 01:00	0.0	0	0	0	0	0
04/27/2020 02:00	0.0	0	0	0	0	0
04/27/2020 03:00	0.0	0	0	0	0	0
04/27/2020 04:00	0.0	0	0	0	0	0
04/27/2020 05:00	0.0	0	0	0	0	0
04/27/2020 06:00	0.0	0	0	0	0	0
04/27/2020 07:00	0.0	0	0	0	0	0
04/27/2020 08:00	0.0	0	0	0	0	0
04/27/2020 09:00	0.0	0	0	0	0	0
04/27/2020 10:00	0.0	0	0	0	0	0
04/27/2020 11:00	0.0	0	0	0	0	0
04/27/2020 12:00	0.0	0	0	0	0	0
04/27/2020 13:00	66.0	0	1	0	0	0
04/27/2020 14:00	71.2	0	1	0	0	0
04/27/2020 15:00	34.5	0	1	0	0	0
04/27/2020 16:00	0.0	0	0	0	0	1
04/27/2020 17:00	0.0	0	0	0	0	1
04/27/2020 18:00	0.0	0	0	0	0	1
04/27/2020 19:00	0.0	0	0	0	0	1
04/27/2020 20:00	0.0	0	0	0	0	1
04/27/2020 21:00	0.0	0	0	0	0	1
04/27/2020 22:00	0.0	0	0	0	0	1
04/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	171.7 #	0 #	3 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	71.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/28/2020 00:00	0.0	0	0	0	0	1
04/28/2020 01:00	0.0	0	0	0	0	1
04/28/2020 02:00	0.0	0	0	0	0	1
04/28/2020 03:00	0.0	0	0	0	0	1
04/28/2020 04:00	0.0	0	0	0	0	1
04/28/2020 05:00	0.0	0	0	0	0	1
04/28/2020 06:00	0.0	0	0	0	0	1
04/28/2020 07:00	0.0	0	0	0	0	1
04/28/2020 08:00	0.0	0	0	0	0	1
04/28/2020 09:00	0.0	0	0	0	0	1
04/28/2020 10:00	0.0	0	0	0	0	1
04/28/2020 11:00	0.0	0	0	0	0	1
04/28/2020 12:00	0.0	0	0	0	0	1
04/28/2020 13:00	0.0	0	0	0	0	1
04/28/2020 14:00	0.0	0	0	0	0	1
04/28/2020 15:00	0.0	0	0	0	0	1
04/28/2020 16:00	0.0	0	0	0	0	1
04/28/2020 17:00	0.0	0	0	0	0	1
04/28/2020 18:00	0.0	0	0	0	0	1
04/28/2020 19:00	0.0	0	0	0	0	1
04/28/2020 20:00	0.0	0	0	0	0	1
04/28/2020 21:00	1.0	0	0	0	1	0
04/28/2020 22:00	0.0	0	0	0	0	0
04/28/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.0 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/29/2020 00:00	0.0	0	0	0	0	0
04/29/2020 01:00	0.0	0	0	0	0	0
04/29/2020 02:00	0.0	0	0	0	0	0
04/29/2020 03:00	0.0	0	0	0	0	0
04/29/2020 04:00	0.0	0	0	0	0	0
04/29/2020 05:00	0.0	0	0	0	0	0
04/29/2020 06:00	0.0	0	0	0	0	0
04/29/2020 07:00	0.0	0	0	0	0	0
04/29/2020 08:00	0.0	0	0	0	0	0
04/29/2020 09:00	0.0	0	0	0	0	0
04/29/2020 10:00	0.0	0	0	0	0	0
04/29/2020 11:00	0.0	0	0	0	0	0
04/29/2020 12:00	0.0	0	0	0	0	0
04/29/2020 13:00	51.4	0	1	0	0	0
04/29/2020 14:00	47.2	0	1	0	0	0
04/29/2020 15:00	4.5	0	1	0	0	0
04/29/2020 16:00	0.0	0	0	0	0	1
04/29/2020 17:00	0.0	0	0	0	0	1
04/29/2020 18:00	0.0	0	0	0	0	1
04/29/2020 19:00	0.0	0	0	0	0	1
04/29/2020 20:00	0.0	0	0	0	0	1
04/29/2020 21:00	0.0	0	0	0	0	1
04/29/2020 22:00	0.0	0	0	0	0	1
04/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	103.1 #	0 #	3 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	51.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
04/30/2020 00:00	0.0	0	0	0	0	1
04/30/2020 01:00	0.0	0	0	0	0	1
04/30/2020 02:00	0.0	0	0	0	0	1
04/30/2020 03:00	0.0	0	0	0	0	1
04/30/2020 04:00	0.0	0	0	0	0	1
04/30/2020 05:00	0.0	0	0	0	0	1
04/30/2020 06:00	0.0	0	0	0	0	1
04/30/2020 07:00	0.8	0	0	0	1	0
04/30/2020 08:00	0.0	0	0	0	0	0
04/30/2020 09:00	0.0	0	0	0	0	0
04/30/2020 10:00	0.0	0	0	0	0	0
04/30/2020 11:00	0.0	0	0	0	0	0
04/30/2020 12:00	0.0	0	0	0	0	0
04/30/2020 13:00	0.0	0	0	0	0	0
04/30/2020 14:00	0.0	0	0	0	0	0
04/30/2020 15:00	0.0	0	0	0	0	0
04/30/2020 16:00	0.0	0	0	0	0	0
04/30/2020 17:00	0.0	0	0	0	0	0
04/30/2020 18:00	0.0	0	0	0	0	0
04/30/2020 19:00	0.0	0	0	0	0	0
04/30/2020 20:00	0.0	0	0	0	0	0
04/30/2020 21:00	0.0	0	0	0	0	0
04/30/2020 22:00	0.0	0	0	0	0	0
04/30/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/01/2020 00:00	0.0	0	0	0	0	0
05/01/2020 01:00	0.0	0	0	0	0	0
05/01/2020 02:00	0.0	0	0	0	0	0
05/01/2020 03:00	0.0	0	0	0	0	0
05/01/2020 04:00	0.0	0	0	0	0	0
05/01/2020 05:00	0.0	0	0	0	0	0
05/01/2020 06:00	0.0	0	0	0	0	0
05/01/2020 07:00	0.0	0	0	0	0	0
05/01/2020 08:00	0.0	0	0	0	0	0
05/01/2020 09:00	0.0	0	0	0	0	0
05/01/2020 10:00	0.0	0	0	0	0	0
05/01/2020 11:00	0.0	0	0	0	0	0
05/01/2020 12:00	0.0	0	0	0	0	0
05/01/2020 13:00	0.0	0	0	0	0	0
05/01/2020 14:00	0.0	0	0	0	0	0
05/01/2020 15:00	0.0	0	0	0	0	0
05/01/2020 16:00	0.0	0	0	0	0	0
05/01/2020 17:00	0.0	0	0	0	0	0
05/01/2020 18:00	0.0	0	0	0	0	0
05/01/2020 19:00	0.0	0	0	0	0	0
05/01/2020 20:00	0.0	0	0	0	0	0
05/01/2020 21:00	0.0	0	0	0	0	0
05/01/2020 22:00	0.0	0	0	0	0	0
05/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/02/2020 00:00	0.0	0	0	0	0	0
05/02/2020 01:00	0.0	0	0	0	0	0
05/02/2020 02:00	0.0	0	0	0	0	0
05/02/2020 03:00	0.0	0	0	0	0	0
05/02/2020 04:00	0.0	0	0	0	0	0
05/02/2020 05:00	0.0	0	0	0	0	0
05/02/2020 06:00	0.0	0	0	0	0	0
05/02/2020 07:00	0.0	0	0	0	0	0
05/02/2020 08:00	0.0	0	0	0	0	0
05/02/2020 09:00	0.0	0	0	0	0	0
05/02/2020 10:00	0.0	0	0	0	0	0
05/02/2020 11:00	0.0	0	0	0	0	0
05/02/2020 12:00	0.0	0	0	0	0	0
05/02/2020 13:00	0.0	0	0	0	0	0
05/02/2020 14:00	0.0	0	0	0	0	0
05/02/2020 15:00	0.0	0	0	0	0	0
05/02/2020 16:00	0.0	0	0	0	0	0
05/02/2020 17:00	0.0	0	0	0	0	0
05/02/2020 18:00	0.0	0	0	0	0	0
05/02/2020 19:00	0.0	0	0	0	0	0
05/02/2020 20:00	0.0	0	0	0	0	0
05/02/2020 21:00	0.0	0	0	0	0	0
05/02/2020 22:00	0.0	0	0	0	0	0
05/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/03/2020 00:00	0.0	0	0	0	0	0
05/03/2020 01:00	0.0	0	0	0	0	0
05/03/2020 02:00	0.0	0	0	0	0	0
05/03/2020 03:00	0.0	0	0	0	0	0
05/03/2020 04:00	0.0	0	0	0	0	0
05/03/2020 05:00	0.0	0	0	0	0	0
05/03/2020 06:00	0.0	0	0	0	0	0
05/03/2020 07:00	0.0	0	0	0	0	0
05/03/2020 08:00	0.0	0	0	0	0	0
05/03/2020 09:00	0.0	0	0	0	0	0
05/03/2020 10:00	0.0	0	0	0	0	0
05/03/2020 11:00	0.0	0	0	0	0	0
05/03/2020 12:00	0.0	0	0	0	0	0
05/03/2020 13:00	0.0	0	0	0	0	0
05/03/2020 14:00	0.0	0	0	0	0	0
05/03/2020 15:00	0.0	0	0	0	0	0
05/03/2020 16:00	0.0	0	0	0	0	0
05/03/2020 17:00	0.0	0	0	0	0	0
05/03/2020 18:00	0.0	0	0	0	0	0
05/03/2020 19:00	0.0	0	0	0	0	0
05/03/2020 20:00	0.0	0	0	0	0	0
05/03/2020 21:00	0.0	0	0	0	0	0
05/03/2020 22:00	0.0	0	0	0	0	0
05/03/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/04/2020 00:00	0.0	0	0	0	0	0
05/04/2020 01:00	0.0	0	0	0	0	0
05/04/2020 02:00	0.0	0	0	0	0	0
05/04/2020 03:00	0.0	0	0	0	0	0
05/04/2020 04:00	0.0	0	0	0	0	0
05/04/2020 05:00	0.0	0	0	0	0	0
05/04/2020 06:00	0.0	0	0	0	0	0
05/04/2020 07:00	0.0	0	0	0	0	0
05/04/2020 08:00	0.0	0	0	0	0	0
05/04/2020 09:00	0.0	0	0	0	0	0
05/04/2020 10:00	0.0	0	0	0	0	0
05/04/2020 11:00	0.0	0	0	0	0	0
05/04/2020 12:00	0.0	0	0	0	0	0
05/04/2020 13:00	0.0	0	0	0	0	0
05/04/2020 14:00	0.0	0	0	0	0	0
05/04/2020 15:00	0.0	0	0	0	0	0
05/04/2020 16:00	0.0	0	0	0	0	0
05/04/2020 17:00	0.0	0	0	0	0	0
05/04/2020 18:00	0.0	0	0	0	0	0
05/04/2020 19:00	0.0	0	0	0	0	0
05/04/2020 20:00	0.0	0	0	0	0	0
05/04/2020 21:00	0.0	0	0	0	0	0
05/04/2020 22:00	0.0	0	0	0	0	0
05/04/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/05/2020 00:00	0.0	0	0	0	0	0
05/05/2020 01:00	0.0	0	0	0	0	0
05/05/2020 02:00	0.0	0	0	0	0	0
05/05/2020 03:00	0.0	0	0	0	0	0
05/05/2020 04:00	0.0	0	0	0	0	0
05/05/2020 05:00	0.0	0	0	0	0	0
05/05/2020 06:00	0.0	0	0	0	0	0
05/05/2020 07:00	0.0	0	0	0	0	0
05/05/2020 08:00	0.0	0	0	0	0	0
05/05/2020 09:00	0.0	0	0	0	0	0
05/05/2020 10:00	0.0	0	0	0	0	0
05/05/2020 11:00	0.0	0	0	0	0	0
05/05/2020 12:00	0.0	0	0	0	0	0
05/05/2020 13:00	0.0	0	0	0	0	0
05/05/2020 14:00	0.0	0	0	0	0	0
05/05/2020 15:00	0.0	0	0	0	0	0
05/05/2020 16:00	0.0	0	0	0	0	0
05/05/2020 17:00	0.0	0	0	0	0	0
05/05/2020 18:00	0.0	0	0	0	0	0
05/05/2020 19:00	0.0	0	0	0	0	0
05/05/2020 20:00	0.0	0	0	0	0	0
05/05/2020 21:00	0.0	0	0	0	0	0
05/05/2020 22:00	0.0	0	0	0	0	0
05/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/06/2020 00:00	0.0	0	0	0	0	0
05/06/2020 01:00	0.0	0	0	0	0	0
05/06/2020 02:00	0.0	0	0	0	0	0
05/06/2020 03:00	0.0	0	0	0	0	0
05/06/2020 04:00	0.0	0	0	0	0	0
05/06/2020 05:00	0.0	0	0	0	0	0
05/06/2020 06:00	0.0	0	0	0	0	0
05/06/2020 07:00	0.0	0	0	0	0	0
05/06/2020 08:00	0.0	0	0	0	0	0
05/06/2020 09:00	0.0	0	0	0	0	0
05/06/2020 10:00	0.0	0	0	0	0	0
05/06/2020 11:00	0.0	0	0	0	0	0
05/06/2020 12:00	0.0	0	0	0	0	0
05/06/2020 13:00	0.0	0	0	0	0	0
05/06/2020 14:00	0.0	0	0	0	0	0
05/06/2020 15:00	0.0	0	0	0	0	0
05/06/2020 16:00	0.0	0	0	0	0	0
05/06/2020 17:00	0.0	0	0	0	0	0
05/06/2020 18:00	0.0	0	0	0	0	0
05/06/2020 19:00	0.0	0	0	0	0	0
05/06/2020 20:00	0.0	0	0	0	0	0
05/06/2020 21:00	0.0	0	0	0	0	0
05/06/2020 22:00	0.0	0	0	0	0	0
05/06/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/07/2020 00:00	0.0	0	0	0	0	0
05/07/2020 01:00	0.0	0	0	0	0	0
05/07/2020 02:00	0.0	0	0	0	0	0
05/07/2020 03:00	0.0	0	0	0	0	0
05/07/2020 04:00	0.0	0	0	0	0	0
05/07/2020 05:00	0.0	0	0	0	0	0
05/07/2020 06:00	0.0	0	0	0	0	0
05/07/2020 07:00	0.0	0	0	0	0	0
05/07/2020 08:00	0.0	0	0	0	0	0
05/07/2020 09:00	0.0	0	0	0	0	0
05/07/2020 10:00	0.0	0	0	0	0	0
05/07/2020 11:00	0.0	0	0	0	0	0
05/07/2020 12:00	0.0	0	0	0	0	0
05/07/2020 13:00	0.0	0	0	0	0	0
05/07/2020 14:00	0.0	0	0	0	0	0
05/07/2020 15:00	0.0	0	0	0	0	0
05/07/2020 16:00	0.0	0	0	0	0	0
05/07/2020 17:00	0.0	0	0	0	0	0
05/07/2020 18:00	0.0	0	0	0	0	0
05/07/2020 19:00	0.0	0	0	0	0	0
05/07/2020 20:00	0.0	0	0	0	0	0
05/07/2020 21:00	0.0	0	0	0	0	0
05/07/2020 22:00	0.0	0	0	0	0	0
05/07/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/08/2020 00:00	0.0	0	0	0	0	0
05/08/2020 01:00	0.0	0	0	0	0	0
05/08/2020 02:00	0.0	0	0	0	0	0
05/08/2020 03:00	0.0	0	0	0	0	0
05/08/2020 04:00	0.0	0	0	0	0	0
05/08/2020 05:00	0.0	0	0	0	0	0
05/08/2020 06:00	0.0	0	0	0	0	0
05/08/2020 07:00	0.0	0	0	0	0	0
05/08/2020 08:00	0.0	0	0	0	0	0
05/08/2020 09:00	0.0	0	0	0	0	0
05/08/2020 10:00	0.0	0	0	0	0	0
05/08/2020 11:00	0.0	0	0	0	0	0
05/08/2020 12:00	0.0	0	0	0	0	0
05/08/2020 13:00	0.0	0	0	0	0	0
05/08/2020 14:00	0.0	0	0	0	0	0
05/08/2020 15:00	0.0	0	0	0	0	0
05/08/2020 16:00	0.0	0	0	0	0	0
05/08/2020 17:00	0.0	0	0	0	0	0
05/08/2020 18:00	0.0	0	0	0	0	0
05/08/2020 19:00	0.0	0	0	0	0	0
05/08/2020 20:00	0.0	0	0	0	0	0
05/08/2020 21:00	0.0	0	0	0	0	0
05/08/2020 22:00	0.0	0	0	0	0	0
05/08/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/09/2020 00:00	0.0	0	0	0	0	0
05/09/2020 01:00	0.0	0	0	0	0	0
05/09/2020 02:00	0.0	0	0	0	0	0
05/09/2020 03:00	0.0	0	0	0	0	0
05/09/2020 04:00	0.0	0	0	0	0	0
05/09/2020 05:00	0.0	0	0	0	0	0
05/09/2020 06:00	0.0	0	0	0	0	0
05/09/2020 07:00	0.0	0	0	0	0	0
05/09/2020 08:00	0.0	0	0	0	0	0
05/09/2020 09:00	0.0	0	0	0	0	0
05/09/2020 10:00	0.0	0	0	0	0	0
05/09/2020 11:00	0.0	0	0	0	0	0
05/09/2020 12:00	0.0	0	0	0	0	0
05/09/2020 13:00	0.0	0	0	0	0	0
05/09/2020 14:00	0.0	0	0	0	0	0
05/09/2020 15:00	0.0	0	0	0	0	0
05/09/2020 16:00	0.0	0	0	0	0	0
05/09/2020 17:00	0.0	0	0	0	0	0
05/09/2020 18:00	0.0	0	0	0	0	0
05/09/2020 19:00	0.0	0	0	0	0	0
05/09/2020 20:00	0.0	0	0	0	0	0
05/09/2020 21:00	0.0	0	0	0	0	0
05/09/2020 22:00	0.0	0	0	0	0	0
05/09/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/10/2020 00:00	0.0	0	0	0	0	0
05/10/2020 01:00	0.0	0	0	0	0	0
05/10/2020 02:00	0.0	0	0	0	0	0
05/10/2020 03:00	0.0	0	0	0	0	0
05/10/2020 04:00	0.0	0	0	0	0	0
05/10/2020 05:00	0.0	0	0	0	0	0
05/10/2020 06:00	0.0	0	0	0	0	0
05/10/2020 07:00	0.0	0	0	0	0	0
05/10/2020 08:00	0.0	0	0	0	0	0
05/10/2020 09:00	0.0	0	0	0	0	0
05/10/2020 10:00	0.0	0	0	0	0	0
05/10/2020 11:00	0.0	0	0	0	0	0
05/10/2020 12:00	0.0	0	0	0	0	0
05/10/2020 13:00	0.0	0	0	0	0	0
05/10/2020 14:00	0.0	0	0	0	0	0
05/10/2020 15:00	0.0	0	0	0	0	0
05/10/2020 16:00	0.0	0	0	0	0	0
05/10/2020 17:00	0.0	0	0	0	0	0
05/10/2020 18:00	0.0	0	0	0	0	0
05/10/2020 19:00	0.0	0	0	0	0	0
05/10/2020 20:00	0.0	0	0	0	0	0
05/10/2020 21:00	0.0	0	0	0	0	0
05/10/2020 22:00	0.0	0	0	0	0	0
05/10/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/11/2020 00:00	0.0	0	0	0	0	0
05/11/2020 01:00	0.0	0	0	0	0	0
05/11/2020 02:00	0.0	0	0	0	0	0
05/11/2020 03:00	0.0	0	0	0	0	0
05/11/2020 04:00	0.0	0	0	0	0	0
05/11/2020 05:00	0.0	0	0	0	0	0
05/11/2020 06:00	0.0	0	0	0	0	0
05/11/2020 07:00	0.0	0	0	0	0	0
05/11/2020 08:00	0.0	0	0	0	0	0
05/11/2020 09:00	0.0	0	0	0	0	0
05/11/2020 10:00	0.0	0	0	0	0	0
05/11/2020 11:00	0.0	0	0	0	0	0
05/11/2020 12:00	0.0	0	0	0	0	0
05/11/2020 13:00	0.0	0	0	0	0	0
05/11/2020 14:00	0.0	0	0	0	0	0
05/11/2020 15:00	0.0	0	0	0	0	0
05/11/2020 16:00	0.0	0	0	0	1	0
05/11/2020 17:00	0.0	0	0	0	0	0
05/11/2020 18:00	0.0	0	0	0	0	0
05/11/2020 19:00	0.0	0	0	0	0	0
05/11/2020 20:00	0.0	0	0	0	0	0
05/11/2020 21:00	0.0	0	0	0	0	0
05/11/2020 22:00	0.0	0	0	0	0	0
05/11/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/12/2020 00:00	0.0	0	0	0	0	0
05/12/2020 01:00	0.0	0	0	0	0	0
05/12/2020 02:00	0.0	0	0	0	0	0
05/12/2020 03:00	0.0	0	0	0	0	0
05/12/2020 04:00	0.0	0	0	0	0	0
05/12/2020 05:00	0.0	0	0	0	0	0
05/12/2020 06:00	0.0	0	0	0	0	0
05/12/2020 07:00	0.0	0	0	0	0	0
05/12/2020 08:00	0.0	0	0	0	0	0
05/12/2020 09:00	0.0	0	0	0	0	0
05/12/2020 10:00	0.0	0	0	0	0	0
05/12/2020 11:00	0.0	0	0	0	0	0
05/12/2020 12:00	0.0	0	0	0	0	0
05/12/2020 13:00	0.0	0	0	0	0	0
05/12/2020 14:00	0.0	0	0	0	0	0
05/12/2020 15:00	0.0	0	0	0	0	0
05/12/2020 16:00	0.0	0	0	0	0	0
05/12/2020 17:00	0.0	0	0	0	0	0
05/12/2020 18:00	0.0	0	0	0	0	0
05/12/2020 19:00	0.0	0	0	0	0	0
05/12/2020 20:00	0.0	0	0	0	0	0
05/12/2020 21:00	0.0	0	0	0	0	0
05/12/2020 22:00	0.0	0	0	0	0	0
05/12/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/13/2020 00:00	0.0	0	0	0	0	0
05/13/2020 01:00	0.0	0	0	0	0	0
05/13/2020 02:00	0.0	0	0	0	0	0
05/13/2020 03:00	0.0	0	0	0	0	0
05/13/2020 04:00	0.0	0	0	0	0	0
05/13/2020 05:00	0.0	0	0	0	0	0
05/13/2020 06:00	0.0	0	0	0	0	0
05/13/2020 07:00	0.0	0	0	0	0	0
05/13/2020 08:00	0.0	0	0	0	0	0
05/13/2020 09:00	0.0	0	0	0	0	0
05/13/2020 10:00	0.0	0	0	0	0	0
05/13/2020 11:00	0.0	0	0	0	0	0
05/13/2020 12:00	0.0	0	0	0	0	0
05/13/2020 13:00	0.0	0	0	0	0	0
05/13/2020 14:00	0.0	0	0	0	0	0
05/13/2020 15:00	0.0	0	0	0	0	0
05/13/2020 16:00	0.0	0	0	0	0	0
05/13/2020 17:00	0.0	0	0	0	0	0
05/13/2020 18:00	0.0	0	0	0	0	0
05/13/2020 19:00	0.0	0	0	0	0	0
05/13/2020 20:00	0.0	0	0	0	0	0
05/13/2020 21:00	0.0	0	0	0	0	0
05/13/2020 22:00	0.0	0	0	0	0	0
05/13/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/14/2020 00:00	0.0	0	0	0	0	0
05/14/2020 01:00	0.0	0	0	0	0	0
05/14/2020 02:00	0.0	0	0	0	0	0
05/14/2020 03:00	0.0	0	0	0	0	0
05/14/2020 04:00	0.0	0	0	0	0	0
05/14/2020 05:00	0.0	0	0	0	0	0
05/14/2020 06:00	0.0	0	0	0	0	0
05/14/2020 07:00	0.0	0	0	0	0	0
05/14/2020 08:00	0.0	0	0	0	0	0
05/14/2020 09:00	0.0	0	0	0	0	0
05/14/2020 10:00	0.0	0	0	0	0	0
05/14/2020 11:00	0.0	0	0	0	0	0
05/14/2020 12:00	0.0	0	0	0	0	0
05/14/2020 13:00	0.0	0	0	0	0	0
05/14/2020 14:00	0.0	0	0	0	0	0
05/14/2020 15:00	0.0	0	0	0	0	0
05/14/2020 16:00	0.0	0	0	0	0	0
05/14/2020 17:00	0.0	0	0	0	0	0
05/14/2020 18:00	0.0	0	0	0	0	0
05/14/2020 19:00	0.0	0	0	0	0	0
05/14/2020 20:00	0.0	0	0	0	0	0
05/14/2020 21:00	0.0	0	0	0	0	0
05/14/2020 22:00	0.0	0	0	0	0	0
05/14/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/15/2020 00:00	0.0	0	0	0	0	0
05/15/2020 01:00	0.0	0	0	0	0	0
05/15/2020 02:00	0.0	0	0	0	0	0
05/15/2020 03:00	0.0	0	0	0	0	0
05/15/2020 04:00	0.0	0	0	0	0	0
05/15/2020 05:00	0.0	0	0	0	0	0
05/15/2020 06:00	0.0	0	0	0	0	0
05/15/2020 07:00	0.0	0	0	0	0	0
05/15/2020 08:00	0.0	0	0	0	0	0
05/15/2020 09:00	0.0	0	0	0	0	0
05/15/2020 10:00	0.0	0	0	0	0	0
05/15/2020 11:00	0.0	0	0	0	0	0
05/15/2020 12:00	0.0	0	0	0	0	0
05/15/2020 13:00	0.0	0	0	0	0	0
05/15/2020 14:00	0.0	0	0	0	0	0
05/15/2020 15:00	0.0	0	0	0	0	0
05/15/2020 16:00	0.0	0	0	0	0	0
05/15/2020 17:00	0.0	0	0	0	0	0
05/15/2020 18:00	0.0	0	0	0	0	0
05/15/2020 19:00	0.0	0	0	0	0	0
05/15/2020 20:00	0.0	0	0	0	0	0
05/15/2020 21:00	0.0	0	0	0	0	0
05/15/2020 22:00	0.0	0	0	0	0	0
05/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/16/2020 00:00	0.0	0	0	0	0	0
05/16/2020 01:00	0.0	0	0	0	0	0
05/16/2020 02:00	0.0	0	0	0	0	0
05/16/2020 03:00	0.0	0	0	0	0	0
05/16/2020 04:00	0.0	0	0	0	0	0
05/16/2020 05:00	0.0	0	0	0	0	0
05/16/2020 06:00	0.0	0	0	0	0	0
05/16/2020 07:00	0.0	0	0	0	0	0
05/16/2020 08:00	0.0	0	0	0	0	0
05/16/2020 09:00	0.0	0	0	0	0	0
05/16/2020 10:00	0.0	0	0	0	0	0
05/16/2020 11:00	0.0	0	0	0	0	0
05/16/2020 12:00	0.0	0	0	0	0	0
05/16/2020 13:00	0.0	0	0	0	0	0
05/16/2020 14:00	0.0	0	0	0	0	0
05/16/2020 15:00	0.0	0	0	0	0	0
05/16/2020 16:00	0.0	0	0	0	0	0
05/16/2020 17:00	0.0	0	0	0	0	0
05/16/2020 18:00	0.0	0	0	0	0	0
05/16/2020 19:00	0.0	0	0	0	0	0
05/16/2020 20:00	0.0	0	0	0	0	0
05/16/2020 21:00	0.0	0	0	0	0	0
05/16/2020 22:00	0.0	0	0	0	0	0
05/16/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/17/2020 00:00	0.0	0	0	0	0	0
05/17/2020 01:00	0.0	0	0	0	0	0
05/17/2020 02:00	0.0	0	0	0	0	0
05/17/2020 03:00	0.0	0	0	0	0	0
05/17/2020 04:00	0.0	0	0	0	0	0
05/17/2020 05:00	0.0	0	0	0	0	0
05/17/2020 06:00	0.0	0	0	0	0	0
05/17/2020 07:00	0.0	0	0	0	0	0
05/17/2020 08:00	0.0	0	0	0	0	0
05/17/2020 09:00	0.0	0	0	0	0	0
05/17/2020 10:00	0.0	0	0	0	0	0
05/17/2020 11:00	0.0	0	0	0	0	0
05/17/2020 12:00	0.0	0	0	0	0	0
05/17/2020 13:00	0.0	0	0	0	0	0
05/17/2020 14:00	0.0	0	0	0	0	0
05/17/2020 15:00	0.0	0	0	0	0	0
05/17/2020 16:00	0.0	0	0	0	0	0
05/17/2020 17:00	0.0	0	0	0	0	0
05/17/2020 18:00	0.0	0	0	0	0	0
05/17/2020 19:00	0.0	0	0	0	0	0
05/17/2020 20:00	0.0	0	0	0	0	0
05/17/2020 21:00	0.0	0	0	0	0	0
05/17/2020 22:00	0.0	0	0	0	0	0
05/17/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/18/2020 00:00	0.0	0	0	0	0	0
05/18/2020 01:00	0.0	0	0	0	0	0
05/18/2020 02:00	0.0	0	0	0	0	0
05/18/2020 03:00	0.0	0	0	0	0	0
05/18/2020 04:00	0.0	0	0	0	0	0
05/18/2020 05:00	0.0	0	0	0	0	0
05/18/2020 06:00	0.0	0	0	0	0	0
05/18/2020 07:00	0.0	0	0	0	0	0
05/18/2020 08:00	0.0	0	0	0	0	0
05/18/2020 09:00	0.0	0	0	0	0	0
05/18/2020 10:00	0.0	0	0	0	0	0
05/18/2020 11:00	0.0	0	0	0	0	0
05/18/2020 12:00	0.0	0	0	0	0	0
05/18/2020 13:00	0.0	0	0	0	0	0
05/18/2020 14:00	0.0	0	0	0	0	0
05/18/2020 15:00	0.0	0	0	0	0	0
05/18/2020 16:00	0.0	0	0	0	0	0
05/18/2020 17:00	0.0	0	0	0	0	0
05/18/2020 18:00	0.0	0	0	0	0	0
05/18/2020 19:00	0.0	0	0	0	0	0
05/18/2020 20:00	0.0	0	0	0	0	0
05/18/2020 21:00	0.0	0	0	0	0	0
05/18/2020 22:00	0.0	0	0	0	0	0
05/18/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/19/2020 00:00	0.0	0	0	0	0	0
05/19/2020 01:00	0.0	0	0	0	0	0
05/19/2020 02:00	0.0	0	0	0	0	0
05/19/2020 03:00	0.0	0	0	0	0	0
05/19/2020 04:00	0.0	0	0	0	0	0
05/19/2020 05:00	0.0	0	0	0	0	0
05/19/2020 06:00	0.0	0	0	0	0	0
05/19/2020 07:00	0.0	0	0	0	0	0
05/19/2020 08:00	0.0	0	0	0	0	0
05/19/2020 09:00	0.0	0	0	0	0	0
05/19/2020 10:00	0.0	0	0	0	0	0
05/19/2020 11:00	0.0	0	0	0	0	0
05/19/2020 12:00	0.0	0	0	0	0	0
05/19/2020 13:00	0.0	0	0	0	0	0
05/19/2020 14:00	0.0	0	0	0	0	0
05/19/2020 15:00	0.0	0	0	0	0	0
05/19/2020 16:00	0.0	0	0	0	0	0
05/19/2020 17:00	0.0	0	0	0	0	0
05/19/2020 18:00	0.0	0	0	0	0	0
05/19/2020 19:00	0.0	0	0	0	0	0
05/19/2020 20:00	0.0	0	0	0	0	0
05/19/2020 21:00	0.0	0	0	0	0	0
05/19/2020 22:00	0.0	0	0	0	0	0
05/19/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/20/2020 00:00	0.0	0	0	0	0	0
05/20/2020 01:00	0.0	0	0	0	0	0
05/20/2020 02:00	0.0	0	0	0	0	0
05/20/2020 03:00	0.0	0	0	0	0	0
05/20/2020 04:00	0.0	0	0	0	0	0
05/20/2020 05:00	0.0	0	0	0	0	0
05/20/2020 06:00	0.0	0	0	0	0	0
05/20/2020 07:00	0.0	0	0	0	0	0
05/20/2020 08:00	0.0	0	0	0	0	0
05/20/2020 09:00	0.0	0	0	0	0	0
05/20/2020 10:00	0.0	0	0	0	0	0
05/20/2020 11:00	0.0	0	0	0	0	0
05/20/2020 12:00	0.0	0	0	0	0	0
05/20/2020 13:00	0.0	0	0	0	0	0
05/20/2020 14:00	0.0	0	0	0	0	0
05/20/2020 15:00	0.0	0	0	0	0	0
05/20/2020 16:00	0.0	0	0	0	0	0
05/20/2020 17:00	0.0	0	0	0	0	0
05/20/2020 18:00	0.0	0	0	0	0	0
05/20/2020 19:00	0.0	0	0	0	0	0
05/20/2020 20:00	0.0	0	0	0	0	0
05/20/2020 21:00	0.0	0	0	0	0	0
05/20/2020 22:00	0.0	0	0	0	0	0
05/20/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/21/2020 00:00	0.0	0	0	0	0	0
05/21/2020 01:00	0.0	0	0	0	0	0
05/21/2020 02:00	0.0	0	0	0	0	0
05/21/2020 03:00	0.0	0	0	0	0	0
05/21/2020 04:00	0.0	0	0	0	0	0
05/21/2020 05:00	0.0	0	0	0	0	0
05/21/2020 06:00	0.0	0	0	0	0	0
05/21/2020 07:00	0.0	0	0	0	0	0
05/21/2020 08:00	0.0	0	0	0	0	0
05/21/2020 09:00	0.0	0	0	0	0	0
05/21/2020 10:00	0.0	0	0	0	0	0
05/21/2020 11:00	0.0	0	0	0	0	0
05/21/2020 12:00	0.0	0	0	0	0	0
05/21/2020 13:00	0.0	0	0	0	0	0
05/21/2020 14:00	0.0	0	0	0	0	0
05/21/2020 15:00	0.0	0	0	0	0	0
05/21/2020 16:00	0.0	0	0	0	0	0
05/21/2020 17:00	0.0	0	0	0	0	0
05/21/2020 18:00	0.0	0	0	0	0	0
05/21/2020 19:00	0.0	0	0	0	0	0
05/21/2020 20:00	0.0	0	0	0	0	0
05/21/2020 21:00	0.0	0	0	0	0	0
05/21/2020 22:00	0.0	0	0	0	0	0
05/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/22/2020 00:00	0.0	0	0	0	0	0
05/22/2020 01:00	0.0	0	0	0	0	0
05/22/2020 02:00	0.0	0	0	0	0	0
05/22/2020 03:00	0.0	0	0	0	0	0
05/22/2020 04:00	0.0	0	0	0	0	0
05/22/2020 05:00	0.0	0	0	0	0	0
05/22/2020 06:00	0.0	0	0	0	0	0
05/22/2020 07:00	0.0	0	0	0	0	0
05/22/2020 08:00	0.0	0	0	0	0	0
05/22/2020 09:00	0.0	0	0	0	0	0
05/22/2020 10:00	0.0	0	0	0	0	0
05/22/2020 11:00	0.0	0	0	0	0	0
05/22/2020 12:00	0.0	0	0	0	0	0
05/22/2020 13:00	0.0	0	0	0	0	0
05/22/2020 14:00	0.0	0	0	0	0	0
05/22/2020 15:00	0.0	0	0	0	0	0
05/22/2020 16:00	0.0	0	0	0	0	0
05/22/2020 17:00	0.0	0	0	0	0	0
05/22/2020 18:00	0.0	0	0	0	0	0
05/22/2020 19:00	0.0	0	0	0	0	0
05/22/2020 20:00	0.0	0	0	0	0	0
05/22/2020 21:00	0.0	0	0	0	0	0
05/22/2020 22:00	0.0	0	0	0	0	0
05/22/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/23/2020 00:00	0.0	0	0	0	0	0
05/23/2020 01:00	0.0	0	0	0	0	0
05/23/2020 02:00	0.0	0	0	0	0	0
05/23/2020 03:00	0.0	0	0	0	0	0
05/23/2020 04:00	0.0	0	0	0	0	0
05/23/2020 05:00	0.0	0	0	0	0	0
05/23/2020 06:00	0.0	0	0	0	0	0
05/23/2020 07:00	0.0	0	0	0	0	0
05/23/2020 08:00	0.0	0	0	0	0	0
05/23/2020 09:00	0.0	0	0	0	0	0
05/23/2020 10:00	0.0	0	0	0	0	0
05/23/2020 11:00	0.0	0	0	0	0	0
05/23/2020 12:00	0.0	0	0	0	0	0
05/23/2020 13:00	0.0	0	0	0	0	0
05/23/2020 14:00	0.0	0	0	0	0	0
05/23/2020 15:00	0.0	0	0	0	0	0
05/23/2020 16:00	0.0	0	0	0	0	0
05/23/2020 17:00	0.0	0	0	0	0	0
05/23/2020 18:00	0.0	0	0	0	0	0
05/23/2020 19:00	0.0	0	0	0	0	0
05/23/2020 20:00	0.0	0	0	0	0	0
05/23/2020 21:00	0.0	0	0	0	0	0
05/23/2020 22:00	0.0	0	0	0	0	0
05/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/24/2020 00:00	0.0	0	0	0	0	0
05/24/2020 01:00	0.0	0	0	0	0	0
05/24/2020 02:00	0.0	0	0	0	0	0
05/24/2020 03:00	0.0	0	0	0	0	0
05/24/2020 04:00	0.0	0	0	0	0	0
05/24/2020 05:00	0.0	0	0	0	0	0
05/24/2020 06:00	0.0	0	0	0	0	0
05/24/2020 07:00	0.0	0	0	0	0	0
05/24/2020 08:00	0.0	0	0	0	0	0
05/24/2020 09:00	0.0	0	0	0	0	0
05/24/2020 10:00	0.0	0	0	0	0	0
05/24/2020 11:00	0.0	0	0	0	0	0
05/24/2020 12:00	0.0	0	0	0	0	0
05/24/2020 13:00	0.0	0	0	0	0	0
05/24/2020 14:00	0.0	0	0	0	0	0
05/24/2020 15:00	0.0	0	0	0	0	0
05/24/2020 16:00	0.0	0	0	0	0	0
05/24/2020 17:00	0.0	0	0	0	0	0
05/24/2020 18:00	0.0	0	0	0	0	0
05/24/2020 19:00	0.0	0	0	0	0	0
05/24/2020 20:00	0.0	0	0	0	0	0
05/24/2020 21:00	0.0	0	0	0	0	0
05/24/2020 22:00	0.0	0	0	0	0	0
05/24/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/25/2020 00:00	0.0	0	0	0	0	0
05/25/2020 01:00	0.0	0	0	0	0	0
05/25/2020 02:00	0.0	0	0	0	0	0
05/25/2020 03:00	0.0	0	0	0	0	0
05/25/2020 04:00	0.0	0	0	0	0	0
05/25/2020 05:00	0.0	0	0	0	0	0
05/25/2020 06:00	0.0	0	0	0	0	0
05/25/2020 07:00	0.0	0	0	0	0	0
05/25/2020 08:00	0.0	0	0	0	0	0
05/25/2020 09:00	0.0	0	0	0	0	0
05/25/2020 10:00	0.0	0	0	0	0	0
05/25/2020 11:00	0.0	0	0	0	0	0
05/25/2020 12:00	0.0	0	0	0	0	0
05/25/2020 13:00	0.0	0	0	0	0	0
05/25/2020 14:00	0.0	0	0	0	0	0
05/25/2020 15:00	0.0	0	0	0	0	0
05/25/2020 16:00	0.0	0	0	0	0	0
05/25/2020 17:00	0.0	0	0	0	0	0
05/25/2020 18:00	0.0	0	0	0	0	0
05/25/2020 19:00	0.0	0	0	0	0	0
05/25/2020 20:00	0.0	0	0	0	0	0
05/25/2020 21:00	0.0	0	0	0	0	0
05/25/2020 22:00	0.0	0	0	0	0	0
05/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/26/2020 00:00	0.0	0	0	0	0	0
05/26/2020 01:00	0.0	0	0	0	0	0
05/26/2020 02:00	0.0	0	0	0	0	0
05/26/2020 03:00	0.0	0	0	0	0	0
05/26/2020 04:00	0.0	0	0	0	0	0
05/26/2020 05:00	0.0	0	0	0	0	0
05/26/2020 06:00	0.0	0	0	0	0	0
05/26/2020 07:00	0.0	0	0	0	0	0
05/26/2020 08:00	0.0	0	0	0	0	0
05/26/2020 09:00	0.0	0	0	0	0	0
05/26/2020 10:00	0.0	0	0	0	0	0
05/26/2020 11:00	0.0	0	0	0	0	0
05/26/2020 12:00	0.0	0	0	0	0	0
05/26/2020 13:00	0.0	0	0	0	0	0
05/26/2020 14:00	0.0	0	0	0	0	0
05/26/2020 15:00	0.0	0	0	0	0	0
05/26/2020 16:00	0.0	0	0	0	0	0
05/26/2020 17:00	0.0	0	0	0	0	0
05/26/2020 18:00	0.0	0	0	0	0	0
05/26/2020 19:00	0.0	0	0	0	0	0
05/26/2020 20:00	0.0	0	0	0	0	0
05/26/2020 21:00	0.0	0	0	0	0	0
05/26/2020 22:00	0.0	0	0	0	0	0
05/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/27/2020 00:00	0.0	0	0	0	0	0
05/27/2020 01:00	0.0	0	0	0	0	0
05/27/2020 02:00	0.0	0	0	0	0	0
05/27/2020 03:00	0.0	0	0	0	0	0
05/27/2020 04:00	0.0	0	0	0	0	0
05/27/2020 05:00	0.0	0	0	0	0	0
05/27/2020 06:00	0.0	0	0	0	0	0
05/27/2020 07:00	0.0	0	0	0	0	0
05/27/2020 08:00	0.0	1	0	0	0	0
05/27/2020 09:00	0.0	1	0	0	0	0
05/27/2020 10:00	0.0	1	0	0	0	0
05/27/2020 11:00	0.0	1	0	0	0	0
05/27/2020 12:00	0.0	0	0	0	0	1
05/27/2020 13:00	0.0	0	0	0	0	1
05/27/2020 14:00	1.0	0	0	0	1	0
05/27/2020 15:00	0.0	0	0	0	0	0
05/27/2020 16:00	0.0	0	0	0	0	0
05/27/2020 17:00	0.0	0	0	0	0	0
05/27/2020 18:00	0.0	0	0	0	0	0
05/27/2020 19:00	0.0	0	0	0	0	0
05/27/2020 20:00	0.0	0	0	0	0	0
05/27/2020 21:00	0.0	0	0	0	0	0
05/27/2020 22:00	0.0	0	0	0	0	0
05/27/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.0 #	4 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.0	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/28/2020 00:00	0.0	0	0	0	0	0
05/28/2020 01:00	0.0	0	0	0	0	0
05/28/2020 02:00	0.0	0	0	0	0	0
05/28/2020 03:00	0.0	0	0	0	0	0
05/28/2020 04:00	0.0	0	0	0	0	0
05/28/2020 05:00	0.0	0	0	0	0	0
05/28/2020 06:00	0.0	0	0	0	0	0
05/28/2020 07:00	0.0	0	0	0	0	0
05/28/2020 08:00	0.0	0	0	0	0	0
05/28/2020 09:00	0.0	0	0	0	0	0
05/28/2020 10:00	0.0	0	0	0	0	0
05/28/2020 11:00	0.0	0	0	0	0	0
05/28/2020 12:00	0.0	0	0	0	0	0
05/28/2020 13:00	0.0	0	0	0	0	0
05/28/2020 14:00	0.0	0	0	0	0	0
05/28/2020 15:00	0.0	0	0	0	0	0
05/28/2020 16:00	0.0	0	0	0	0	0
05/28/2020 17:00	0.0	0	0	0	0	0
05/28/2020 18:00	2.4	0	1	0	0	0
05/28/2020 19:00	70.3	0	1	0	0	0
05/28/2020 20:00	3.2	0	1	0	0	0
05/28/2020 21:00	0.0	0	0	0	0	1
05/28/2020 22:00	0.0	0	0	0	0	1
05/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	75.9 #	0 #	3 #	0 #	0 #	3 #
Minimum:	0.0	0	0	0	0	0
Maximum:	70.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/29/2020 00:00	0.0	0	0	0	0	1
05/29/2020 01:00	0.6	0	0	0	1	0
05/29/2020 02:00	0.0	0	0	0	0	0
05/29/2020 03:00	0.0	0	0	0	0	0
05/29/2020 04:00	0.0	0	0	0	0	0
05/29/2020 05:00	0.0	0	0	0	0	0
05/29/2020 06:00	0.0	0	0	0	0	0
05/29/2020 07:00	0.0	0	0	0	0	0
05/29/2020 08:00	0.0	0	0	0	0	0
05/29/2020 09:00	0.0	0	0	0	0	0
05/29/2020 10:00	0.0	0	0	0	0	0
05/29/2020 11:00	0.0	0	0	0	0	0
05/29/2020 12:00	0.0	0	0	0	0	0
05/29/2020 13:00	0.0	0	0	0	0	0
05/29/2020 14:00	0.0	0	0	0	0	0
05/29/2020 15:00	0.0	0	0	0	0	0
05/29/2020 16:00	0.0	0	0	0	0	0
05/29/2020 17:00	0.0	0	0	0	0	0
05/29/2020 18:00	0.0	0	0	0	0	0
05/29/2020 19:00	0.0	0	0	0	0	0
05/29/2020 20:00	42.2	0	1	0	0	0
05/29/2020 21:00	63.4	0	1	0	0	0
05/29/2020 22:00	33.4	0	1	0	0	0
05/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	139.6 #	0 #	3 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	63.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/30/2020 00:00	0.0	0	0	0	0	1
05/30/2020 01:00	0.0	0	0	0	0	1
05/30/2020 02:00	0.0	0	0	0	0	1
05/30/2020 03:00	0.0	0	0	0	0	1
05/30/2020 04:00	0.0	0	0	0	0	1
05/30/2020 05:00	0.0	0	0	0	0	1
05/30/2020 06:00	0.0	0	0	0	0	1
05/30/2020 07:00	0.0	0	0	0	0	1
05/30/2020 08:00	0.6	0	0	0	1	0
05/30/2020 09:00	0.0	0	0	0	0	0
05/30/2020 10:00	0.0	0	0	0	0	0
05/30/2020 11:00	0.0	0	0	0	0	0
05/30/2020 12:00	0.0	0	0	0	0	0
05/30/2020 13:00	0.0	0	0	1	0	0
05/30/2020 14:00	64.8	0	0	1	0	0
05/30/2020 15:00	0.3	0	0	1	0	0
05/30/2020 16:00	0.0	0	0	0	0	1
05/30/2020 17:00	0.0	0	0	0	0	1
05/30/2020 18:00	0.0	0	0	0	0	1
05/30/2020 19:00	0.0	0	0	0	0	1
05/30/2020 20:00	0.0	0	0	0	0	1
05/30/2020 21:00	0.0	0	0	0	0	1
05/30/2020 22:00	0.0	0	0	0	0	1
05/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	65.7 #	0 #	0 #	3 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	64.8	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
05/31/2020 00:00	0.0	0	0	0	0	1
05/31/2020 01:00	0.0	0	0	0	0	1
05/31/2020 02:00	0.0	0	0	0	0	1
05/31/2020 03:00	0.0	0	0	0	0	1
05/31/2020 04:00	0.0	0	0	0	0	1
05/31/2020 05:00	0.0	0	0	0	0	1
05/31/2020 06:00	0.0	0	0	0	1	0
05/31/2020 07:00	0.0	0	0	0	0	0
05/31/2020 08:00	0.0	0	0	0	0	0
05/31/2020 09:00	0.0	0	0	0	0	0
05/31/2020 10:00	0.0	0	0	0	0	0
05/31/2020 11:00	0.0	0	0	0	0	0
05/31/2020 12:00	0.0	0	0	0	0	0
05/31/2020 13:00	0.0	0	0	0	0	0
05/31/2020 14:00	52.4	0	1	0	0	0
05/31/2020 15:00	25.4	0	1	0	0	0
05/31/2020 16:00	0.0	0	0	0	0	1
05/31/2020 17:00	0.0	0	0	0	0	1
05/31/2020 18:00	0.0	0	0	0	0	1
05/31/2020 19:00	0.0	0	0	0	0	1
05/31/2020 20:00	0.0	0	0	0	0	1
05/31/2020 21:00	0.0	0	0	0	0	1
05/31/2020 22:00	0.0	0	0	0	0	1
05/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	77.8 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	52.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/01/2020 00:00	0.0	0	0	0	0	1
06/01/2020 01:00	0.0	0	0	0	0	1
06/01/2020 02:00	0.0	0	0	0	0	1
06/01/2020 03:00	0.0	0	0	0	0	1
06/01/2020 04:00	0.0	0	0	0	0	1
06/01/2020 05:00	0.0	0	0	0	0	1
06/01/2020 06:00	0.0	0	0	0	0	1
06/01/2020 07:00	0.0	0	0	0	0	1
06/01/2020 08:00	0.0	0	0	0	0	1
06/01/2020 09:00	0.0	0	0	0	0	1
06/01/2020 10:00	0.0	0	0	0	0	1
06/01/2020 11:00	0.0	0	0	0	0	1
06/01/2020 12:00	0.0	0	0	0	0	1
06/01/2020 13:00	0.0	0	0	0	0	1
06/01/2020 14:00	0.0	0	0	0	0	1
06/01/2020 15:00	0.0	0	0	0	0	1
06/01/2020 16:00	0.0	0	0	0	0	1
06/01/2020 17:00	0.0	0	0	0	0	1
06/01/2020 18:00	0.0	0	0	0	0	1
06/01/2020 19:00	0.0	0	0	0	0	1
06/01/2020 20:00	0.0	0	0	0	0	1
06/01/2020 21:00	0.0	0	0	0	0	1
06/01/2020 22:00	0.0	0	0	0	0	1
06/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/02/2020 00:00	0.0	0	0	0	0	1
06/02/2020 01:00	0.0	0	0	0	0	1
06/02/2020 02:00	0.0	0	0	0	0	1
06/02/2020 03:00	0.0	0	0	0	0	1
06/02/2020 04:00	0.0	0	0	0	0	1
06/02/2020 05:00	0.0	0	0	0	0	1
06/02/2020 06:00	0.0	0	0	0	0	1
06/02/2020 07:00	0.0	0	0	0	0	1
06/02/2020 08:00	0.0	0	0	0	0	1
06/02/2020 09:00	0.0	0	0	0	0	1
06/02/2020 10:00	0.0	0	0	0	0	1
06/02/2020 11:00	0.0	0	0	0	0	1
06/02/2020 12:00	0.0	0	0	0	0	1
06/02/2020 13:00	0.0	0	0	0	0	1
06/02/2020 14:00	0.0	0	0	0	0	1
06/02/2020 15:00	0.0	0	0	0	0	1
06/02/2020 16:00	0.0	0	0	0	0	1
06/02/2020 17:00	0.0	0	0	0	0	1
06/02/2020 18:00	0.0	0	0	0	0	1
06/02/2020 19:00	0.0	0	0	0	0	1
06/02/2020 20:00	0.0	0	0	0	0	1
06/02/2020 21:00	0.0	0	0	0	0	1
06/02/2020 22:00	0.0	0	0	0	0	1
06/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/03/2020 00:00	0.0	0	0	0	0	1
06/03/2020 01:00	0.0	0	0	0	0	1
06/03/2020 02:00	0.0	0	0	0	0	1
06/03/2020 03:00	0.0	0	0	0	0	1
06/03/2020 04:00	0.0	0	0	0	0	1
06/03/2020 05:00	0.0	0	0	0	0	1
06/03/2020 06:00	0.0	0	0	0	0	1
06/03/2020 07:00	0.0	0	0	0	0	1
06/03/2020 08:00	0.0	0	0	0	0	1
06/03/2020 09:00	0.0	0	0	0	0	1
06/03/2020 10:00	0.0	0	0	0	0	1
06/03/2020 11:00	0.0	0	0	0	0	1
06/03/2020 12:00	0.0	0	0	0	0	1
06/03/2020 13:00	0.0	0	0	0	0	1
06/03/2020 14:00	0.0	0	0	0	0	1
06/03/2020 15:00	0.0	0	0	0	0	1
06/03/2020 16:00	0.0	0	0	0	0	1
06/03/2020 17:00	0.0	0	0	0	0	1
06/03/2020 18:00	0.0	0	0	0	0	1
06/03/2020 19:00	0.0	0	0	0	0	1
06/03/2020 20:00	0.0	0	0	0	0	1
06/03/2020 21:00	0.0	0	0	0	0	1
06/03/2020 22:00	0.0	0	0	0	0	1
06/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/04/2020 00:00	1.1	0	0	0	1	0
06/04/2020 01:00	0.0	0	0	0	0	0
06/04/2020 02:00	0.0	0	0	0	0	0
06/04/2020 03:00	0.0	0	0	0	0	0
06/04/2020 04:00	0.0	0	0	0	0	0
06/04/2020 05:00	0.0	0	0	0	0	0
06/04/2020 06:00	0.0	0	0	0	0	0
06/04/2020 07:00	0.0	0	0	0	0	0
06/04/2020 08:00	0.0	0	0	0	0	0
06/04/2020 09:00	0.0	0	0	0	0	0
06/04/2020 10:00	26.4	0	1	0	0	0
06/04/2020 11:00	40.0	0	1	0	0	0
06/04/2020 12:00	0.0	0	0	0	0	1
06/04/2020 13:00	0.0	0	0	0	0	1
06/04/2020 14:00	0.0	0	0	0	0	1
06/04/2020 15:00	0.0	0	0	0	0	1
06/04/2020 16:00	0.0	0	0	0	0	1
06/04/2020 17:00	0.0	0	0	0	0	1
06/04/2020 18:00	0.0	0	0	0	0	1
06/04/2020 19:00	0.0	0	0	0	0	1
06/04/2020 20:00	0.0	0	0	0	0	1
06/04/2020 21:00	0.0	0	0	0	0	1
06/04/2020 22:00	0.0	0	0	0	0	1
06/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	67.5 #	0 #	2 #	0 #	1 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	40.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/05/2020 00:00	1.0	0	0	0	1	0
06/05/2020 01:00	0.0	0	0	0	0	0
06/05/2020 02:00	0.0	0	0	0	0	0
06/05/2020 03:00	0.0	0	0	0	0	0
06/05/2020 04:00	0.0	0	0	0	0	0
06/05/2020 05:00	0.0	0	0	0	0	0
06/05/2020 06:00	0.0	0	0	0	0	0
06/05/2020 07:00	0.0	0	0	0	0	0
06/05/2020 08:00	0.0	0	0	0	0	0
06/05/2020 09:00	0.0	0	0	0	0	0
06/05/2020 10:00	0.0	0	0	0	0	0
06/05/2020 11:00	0.0	0	0	0	0	0
06/05/2020 12:00	0.0	0	0	0	0	0
06/05/2020 13:00	0.0	0	0	0	0	0
06/05/2020 14:00	0.0	0	0	0	0	0
06/05/2020 15:00	0.0	0	0	0	0	0
06/05/2020 16:00	0.0	0	0	0	0	0
06/05/2020 17:00	0.0	0	0	0	0	0
06/05/2020 18:00	0.0	0	0	0	0	0
06/05/2020 19:00	0.0	0	0	0	0	0
06/05/2020 20:00	0.0	0	0	0	0	0
06/05/2020 21:00	0.0	0	0	0	0	0
06/05/2020 22:00	0.0	0	0	0	0	0
06/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.0 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.0	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/06/2020 00:00	0.0	0	0	0	0	0
06/06/2020 01:00	0.0	0	0	0	0	0
06/06/2020 02:00	0.0	0	0	0	0	0
06/06/2020 03:00	0.0	0	0	0	0	0
06/06/2020 04:00	0.0	0	0	0	0	0
06/06/2020 05:00	0.0	0	0	0	0	0
06/06/2020 06:00	0.0	0	0	0	0	0
06/06/2020 07:00	0.0	0	0	0	0	0
06/06/2020 08:00	0.0	0	0	0	0	0
06/06/2020 09:00	0.0	0	0	0	0	0
06/06/2020 10:00	0.0	0	0	0	0	0
06/06/2020 11:00	0.0	0	0	0	0	0
06/06/2020 12:00	0.0	0	0	0	0	0
06/06/2020 13:00	0.0	0	0	0	0	0
06/06/2020 14:00	0.0	0	0	0	0	0
06/06/2020 15:00	0.0	0	0	0	0	0
06/06/2020 16:00	0.0	0	0	0	0	0
06/06/2020 17:00	0.0	0	0	0	0	0
06/06/2020 18:00	0.0	0	0	0	0	0
06/06/2020 19:00	0.0	0	0	0	0	0
06/06/2020 20:00	0.0	0	0	0	0	0
06/06/2020 21:00	0.0	0	0	0	0	0
06/06/2020 22:00	0.0	0	0	0	0	0
06/06/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/07/2020 00:00	0.0	0	0	0	0	0
06/07/2020 01:00	0.0	0	0	0	0	0
06/07/2020 02:00	0.0	0	0	0	0	0
06/07/2020 03:00	0.0	0	0	0	0	0
06/07/2020 04:00	0.0	0	0	0	0	0
06/07/2020 05:00	0.0	0	0	0	0	0
06/07/2020 06:00	0.0	0	0	0	0	0
06/07/2020 07:00	0.0	0	0	0	0	0
06/07/2020 08:00	0.0	0	0	0	0	0
06/07/2020 09:00	0.0	0	0	0	0	0
06/07/2020 10:00	0.0	0	0	0	0	0
06/07/2020 11:00	0.0	0	0	0	0	0
06/07/2020 12:00	0.0	0	0	0	0	0
06/07/2020 13:00	0.0	0	0	0	0	0
06/07/2020 14:00	0.0	0	0	0	0	0
06/07/2020 15:00	0.0	0	0	0	0	0
06/07/2020 16:00	0.0	0	0	0	0	0
06/07/2020 17:00	0.0	0	0	0	0	0
06/07/2020 18:00	0.0	0	0	0	0	0
06/07/2020 19:00	0.0	0	0	0	0	0
06/07/2020 20:00	0.0	0	0	0	0	0
06/07/2020 21:00	0.0	0	0	0	0	0
06/07/2020 22:00	0.0	0	0	0	0	0
06/07/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/08/2020 00:00	0.0	0	0	0	0	0
06/08/2020 01:00	0.0	0	0	0	0	0
06/08/2020 02:00	0.0	0	0	0	0	0
06/08/2020 03:00	0.0	0	0	0	0	0
06/08/2020 04:00	0.0	0	0	0	0	0
06/08/2020 05:00	0.0	0	0	0	0	0
06/08/2020 06:00	0.0	0	0	0	0	0
06/08/2020 07:00	0.0	0	0	0	0	0
06/08/2020 08:00	0.0	0	0	0	0	0
06/08/2020 09:00	31.6	1	0	0	0	0
06/08/2020 10:00	72.6	1	0	0	0	0
06/08/2020 11:00	30.0	1	0	0	0	0
06/08/2020 12:00	44.9	1	0	0	0	0
06/08/2020 13:00	0.0	0	0	0	0	1
06/08/2020 14:00	0.0	0	0	0	0	1
06/08/2020 15:00	0.0	0	0	0	0	1
06/08/2020 16:00	0.0	0	0	0	0	1
06/08/2020 17:00	0.0	0	0	0	0	1
06/08/2020 18:00	0.0	0	0	0	0	1
06/08/2020 19:00	0.0	0	0	0	0	1
06/08/2020 20:00	0.0	0	0	0	0	1
06/08/2020 21:00	0.0	0	0	0	0	1
06/08/2020 22:00	0.0	0	0	0	0	1
06/08/2020 23:00	1.1	0	0	0	1	0
Average/Sum#:	180.2 #	4 #	0 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	72.6	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/09/2020 00:00	0.0	0	0	0	0	0
06/09/2020 01:00	0.0	0	0	0	0	0
06/09/2020 02:00	0.0	0	0	0	0	0
06/09/2020 03:00	0.0	0	0	0	0	0
06/09/2020 04:00	0.0	0	0	0	0	0
06/09/2020 05:00	0.0	0	0	0	0	0
06/09/2020 06:00	0.0	0	0	0	0	0
06/09/2020 07:00	0.0	0	0	0	0	0
06/09/2020 08:00	31.2	0	1	0	0	0
06/09/2020 09:00	28.3	0	1	0	0	0
06/09/2020 10:00	51.7	0	1	0	0	0
06/09/2020 11:00	0.0	0	0	0	0	1
06/09/2020 12:00	0.0	0	0	0	0	1
06/09/2020 13:00	0.0	0	0	0	0	1
06/09/2020 14:00	0.0	0	0	0	0	1
06/09/2020 15:00	0.0	0	0	0	0	1
06/09/2020 16:00	0.0	0	0	0	0	1
06/09/2020 17:00	0.0	0	0	0	0	1
06/09/2020 18:00	0.0	0	0	0	0	1
06/09/2020 19:00	0.0	0	0	0	0	1
06/09/2020 20:00	0.0	0	0	0	0	1
06/09/2020 21:00	0.0	0	0	0	0	1
06/09/2020 22:00	0.0	0	0	0	0	1
06/09/2020 23:00	1.1	0	0	0	1	0
Average/Sum#:	112.3 #	0 #	3 #	0 #	1 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	51.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/10/2020 00:00	0.0	0	0	0	0	0
06/10/2020 01:00	0.0	0	0	0	0	0
06/10/2020 02:00	0.0	0	0	0	0	0
06/10/2020 03:00	0.0	0	0	0	0	0
06/10/2020 04:00	0.0	0	0	0	0	0
06/10/2020 05:00	0.0	0	0	0	0	0
06/10/2020 06:00	0.0	0	0	0	0	0
06/10/2020 07:00	17.1	0	1	0	0	0
06/10/2020 08:00	36.6	0	1	0	0	0
06/10/2020 09:00	0.0	0	0	0	0	1
06/10/2020 10:00	0.0	0	0	0	0	1
06/10/2020 11:00	0.0	0	0	0	0	1
06/10/2020 12:00	0.0	0	0	0	0	1
06/10/2020 13:00	0.0	0	0	0	0	1
06/10/2020 14:00	0.0	0	0	0	0	1
06/10/2020 15:00	0.0	0	0	0	0	1
06/10/2020 16:00	0.0	0	0	0	0	1
06/10/2020 17:00	0.0	0	0	0	0	1
06/10/2020 18:00	0.0	0	0	0	0	1
06/10/2020 19:00	0.0	0	0	0	0	1
06/10/2020 20:00	0.0	0	0	0	0	1
06/10/2020 21:00	0.0	0	0	0	0	1
06/10/2020 22:00	0.0	0	0	0	0	1
06/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	53.7 #	0 #	2 #	0 #	0 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	36.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/11/2020 00:00	0.0	0	0	0	0	1
06/11/2020 01:00	0.0	0	0	0	0	1
06/11/2020 02:00	0.0	0	0	0	0	1
06/11/2020 03:00	0.0	0	0	0	0	1
06/11/2020 04:00	0.0	0	0	0	0	1
06/11/2020 05:00	0.0	0	0	0	0	1
06/11/2020 06:00	0.0	0	0	0	0	1
06/11/2020 07:00	0.0	0	0	0	0	1
06/11/2020 08:00	0.0	0	0	0	0	1
06/11/2020 09:00	0.0	0	0	0	0	1
06/11/2020 10:00	0.0	0	0	0	0	1
06/11/2020 11:00	0.0	0	0	0	0	1
06/11/2020 12:00	0.0	0	0	0	0	1
06/11/2020 13:00	0.0	0	0	0	0	1
06/11/2020 14:00	0.0	0	0	0	0	1
06/11/2020 15:00	0.0	0	0	0	0	1
06/11/2020 16:00	0.0	0	0	0	0	1
06/11/2020 17:00	0.0	0	0	0	0	1
06/11/2020 18:00	0.0	0	0	0	0	1
06/11/2020 19:00	0.0	0	0	0	0	1
06/11/2020 20:00	0.0	0	0	0	0	1
06/11/2020 21:00	0.0	0	0	0	0	1
06/11/2020 22:00	0.0	0	0	0	0	1
06/11/2020 23:00	1.1	0	0	0	1	0
Average/Sum#:	1.1 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/12/2020 00:00	0.0	0	0	0	0	0
06/12/2020 01:00	0.0	0	0	0	0	0
06/12/2020 02:00	0.0	0	0	0	0	0
06/12/2020 03:00	0.0	0	0	0	0	0
06/12/2020 04:00	0.0	0	0	0	0	0
06/12/2020 05:00	0.0	0	0	0	0	0
06/12/2020 06:00	0.0	0	0	0	0	0
06/12/2020 07:00	0.0	0	0	0	0	0
06/12/2020 08:00	0.0	0	0	0	0	0
06/12/2020 09:00	0.0	0	0	0	0	0
06/12/2020 10:00	0.0	0	0	0	0	0
06/12/2020 11:00	0.0	0	0	0	0	0
06/12/2020 12:00	0.0	0	0	0	0	0
06/12/2020 13:00	0.0	0	0	0	0	0
06/12/2020 14:00	0.0	0	0	0	0	0
06/12/2020 15:00	0.0	0	0	0	0	0
06/12/2020 16:00	0.0	0	0	0	0	0
06/12/2020 17:00	0.0	0	0	0	0	0
06/12/2020 18:00	0.0	0	0	0	0	0
06/12/2020 19:00	0.0	0	0	0	0	0
06/12/2020 20:00	0.0	0	0	0	0	0
06/12/2020 21:00	0.0	0	0	0	0	0
06/12/2020 22:00	0.0	0	0	0	0	0
06/12/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/13/2020 00:00	0.0	0	0	0	0	0
06/13/2020 01:00	0.0	0	0	0	0	0
06/13/2020 02:00	0.0	0	0	0	0	0
06/13/2020 03:00	0.0	0	0	0	0	0
06/13/2020 04:00	0.0	0	0	0	0	0
06/13/2020 05:00	0.0	0	0	0	0	0
06/13/2020 06:00	0.0	0	0	0	0	0
06/13/2020 07:00	0.0	0	0	0	0	0
06/13/2020 08:00	0.0	0	0	0	0	0
06/13/2020 09:00	0.0	0	0	0	0	0
06/13/2020 10:00	0.0	0	0	0	0	0
06/13/2020 11:00	0.0	0	0	0	0	0
06/13/2020 12:00	0.0	0	0	0	0	0
06/13/2020 13:00	0.0	0	0	0	0	0
06/13/2020 14:00	0.0	0	0	0	0	0
06/13/2020 15:00	0.0	0	0	0	0	0
06/13/2020 16:00	0.0	0	0	0	0	0
06/13/2020 17:00	0.0	0	0	0	0	0
06/13/2020 18:00	0.0	0	0	0	0	0
06/13/2020 19:00	0.0	0	0	0	0	0
06/13/2020 20:00	0.0	0	0	0	0	0
06/13/2020 21:00	0.0	0	0	0	0	0
06/13/2020 22:00	0.0	0	0	0	0	0
06/13/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/14/2020 00:00	0.0	0	0	0	0	0
06/14/2020 01:00	0.0	0	0	0	0	0
06/14/2020 02:00	0.0	0	0	0	0	0
06/14/2020 03:00	0.0	0	0	0	0	0
06/14/2020 04:00	0.0	0	0	0	0	0
06/14/2020 05:00	0.0	0	0	0	0	0
06/14/2020 06:00	0.0	0	0	0	0	0
06/14/2020 07:00	0.0	0	0	0	0	0
06/14/2020 08:00	0.0	0	0	0	0	0
06/14/2020 09:00	0.0	0	0	0	0	0
06/14/2020 10:00	0.0	0	0	0	0	0
06/14/2020 11:00	0.0	0	0	0	0	0
06/14/2020 12:00	61.0	0	1	0	0	0
06/14/2020 13:00	63.1	0	1	0	0	0
06/14/2020 14:00	57.9	0	1	0	0	0
06/14/2020 15:00	0.0	0	0	0	0	1
06/14/2020 16:00	0.0	0	0	0	0	1
06/14/2020 17:00	0.0	0	0	0	0	1
06/14/2020 18:00	0.0	0	0	0	0	1
06/14/2020 19:00	0.0	0	0	0	0	1
06/14/2020 20:00	0.0	0	0	0	0	1
06/14/2020 21:00	0.0	0	0	0	0	1
06/14/2020 22:00	0.0	0	0	0	0	1
06/14/2020 23:00	0.8	0	0	0	1	0
Average/Sum#:	182.8 #	0 #	3 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	63.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/15/2020 00:00	0.0	0	0	0	0	0
06/15/2020 01:00	0.0	0	0	0	0	0
06/15/2020 02:00	0.0	0	0	0	0	0
06/15/2020 03:00	0.0	0	0	0	0	0
06/15/2020 04:00	0.0	0	0	0	0	0
06/15/2020 05:00	0.0	0	0	0	0	0
06/15/2020 06:00	0.0	0	0	0	0	0
06/15/2020 07:00	0.0	0	0	0	0	0
06/15/2020 08:00	0.0	0	0	0	0	0
06/15/2020 09:00	0.0	0	0	0	0	0
06/15/2020 10:00	0.0	0	0	0	0	0
06/15/2020 11:00	0.0	0	0	0	0	0
06/15/2020 12:00	0.0	0	0	0	0	0
06/15/2020 13:00	0.0	0	0	0	0	0
06/15/2020 14:00	0.0	0	0	0	0	0
06/15/2020 15:00	0.0	0	0	0	0	0
06/15/2020 16:00	0.0	0	0	0	0	0
06/15/2020 17:00	0.0	0	0	0	0	0
06/15/2020 18:00	0.0	0	0	0	0	0
06/15/2020 19:00	0.0	0	0	0	0	0
06/15/2020 20:00	0.0	0	0	0	0	0
06/15/2020 21:00	0.0	0	0	0	0	0
06/15/2020 22:00	0.0	0	0	0	0	0
06/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/16/2020 00:00	0.0	0	0	0	0	0
06/16/2020 01:00	0.0	0	0	0	0	0
06/16/2020 02:00	0.0	0	0	0	0	0
06/16/2020 03:00	0.0	0	0	0	0	0
06/16/2020 04:00	0.0	0	0	0	0	0
06/16/2020 05:00	0.0	0	0	0	0	0
06/16/2020 06:00	0.0	0	0	0	0	0
06/16/2020 07:00	0.0	0	0	0	0	0
06/16/2020 08:00	0.0	0	0	0	0	0
06/16/2020 09:00	0.0	0	0	0	0	0
06/16/2020 10:00	0.0	0	0	0	0	0
06/16/2020 11:00	0.0	0	0	0	0	0
06/16/2020 12:00	0.0	0	0	0	0	0
06/16/2020 13:00	0.0	0	0	0	0	0
06/16/2020 14:00	0.0	0	0	0	0	0
06/16/2020 15:00	0.0	0	0	0	0	0
06/16/2020 16:00	0.0	0	0	0	0	0
06/16/2020 17:00	0.0	0	0	0	0	0
06/16/2020 18:00	0.0	0	0	0	0	0
06/16/2020 19:00	0.0	0	0	0	0	0
06/16/2020 20:00	0.0	0	0	0	0	0
06/16/2020 21:00	0.0	0	0	0	0	0
06/16/2020 22:00	0.0	0	0	0	0	0
06/16/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/17/2020 00:00	0.0	0	0	0	0	0
06/17/2020 01:00	0.0	0	0	0	0	0
06/17/2020 02:00	0.0	0	0	0	0	0
06/17/2020 03:00	0.0	0	0	0	0	0
06/17/2020 04:00	0.0	0	0	0	0	0
06/17/2020 05:00	0.0	0	0	0	0	0
06/17/2020 06:00	0.0	0	0	0	0	0
06/17/2020 07:00	0.0	0	0	0	0	0
06/17/2020 08:00	0.0	0	0	0	0	0
06/17/2020 09:00	82.6	0	1	0	0	0
06/17/2020 10:00	32.4	0	1	0	0	0
06/17/2020 11:00	29.3	0	1	0	0	0
06/17/2020 12:00	0.0	0	0	0	0	1
06/17/2020 13:00	0.0	0	0	0	0	1
06/17/2020 14:00	0.0	0	0	0	0	1
06/17/2020 15:00	0.0	0	0	0	0	1
06/17/2020 16:00	0.0	0	0	0	0	1
06/17/2020 17:00	0.0	0	0	0	0	1
06/17/2020 18:00	0.0	0	0	0	0	1
06/17/2020 19:00	0.0	0	0	0	0	1
06/17/2020 20:00	0.0	0	0	0	0	1
06/17/2020 21:00	0.0	0	0	0	0	1
06/17/2020 22:00	0.0	0	0	0	0	1
06/17/2020 23:00	1.2	0	0	0	1	0
Average/Sum#:	145.5 #	0 #	3 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	82.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/18/2020 00:00	0.0	0	0	0	0	0
06/18/2020 01:00	0.0	0	0	0	0	0
06/18/2020 02:00	0.0	0	0	0	0	0
06/18/2020 03:00	0.0	0	0	0	0	0
06/18/2020 04:00	0.0	0	0	0	0	0
06/18/2020 05:00	0.0	0	0	0	0	0
06/18/2020 06:00	0.0	0	0	0	0	0
06/18/2020 07:00	22.1	0	1	0	0	0
06/18/2020 08:00	46.5	0	1	0	0	0
06/18/2020 09:00	0.0	0	0	0	0	1
06/18/2020 10:00	0.0	0	0	0	0	1
06/18/2020 11:00	0.0	0	0	0	0	1
06/18/2020 12:00	0.0	0	0	0	0	1
06/18/2020 13:00	0.0	0	0	0	0	1
06/18/2020 14:00	0.0	0	0	0	0	1
06/18/2020 15:00	0.0	0	0	0	0	1
06/18/2020 16:00	0.0	0	0	0	0	1
06/18/2020 17:00	0.0	0	0	0	0	1
06/18/2020 18:00	0.0	0	0	0	0	1
06/18/2020 19:00	0.0	0	0	0	0	1
06/18/2020 20:00	0.0	0	0	0	0	1
06/18/2020 21:00	0.0	0	0	0	0	1
06/18/2020 22:00	0.0	0	0	0	0	1
06/18/2020 23:00	1.3	0	0	0	1	0
Average/Sum#:	69.9 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	46.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/19/2020 00:00	0.0	0	0	0	0	0
06/19/2020 01:00	0.0	0	0	0	0	0
06/19/2020 02:00	0.0	0	0	0	0	0
06/19/2020 03:00	0.0	0	0	0	0	0
06/19/2020 04:00	0.0	0	0	0	0	0
06/19/2020 05:00	0.0	0	0	0	0	0
06/19/2020 06:00	0.0	0	0	0	0	0
06/19/2020 07:00	0.0	0	0	0	0	0
06/19/2020 08:00	0.0	0	0	0	0	0
06/19/2020 09:00	0.0	0	0	0	0	0
06/19/2020 10:00	0.0	0	0	0	0	0
06/19/2020 11:00	0.0	0	0	0	0	0
06/19/2020 12:00	0.0	0	0	0	0	0
06/19/2020 13:00	0.0	0	0	0	0	0
06/19/2020 14:00	0.0	0	0	0	0	0
06/19/2020 15:00	0.0	0	0	0	0	0
06/19/2020 16:00	0.0	0	0	0	0	0
06/19/2020 17:00	0.0	0	0	0	0	0
06/19/2020 18:00	0.0	0	0	0	0	0
06/19/2020 19:00	0.0	0	0	0	0	0
06/19/2020 20:00	0.0	0	0	0	0	0
06/19/2020 21:00	0.0	0	0	0	0	0
06/19/2020 22:00	0.0	0	0	0	0	0
06/19/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/20/2020 00:00	0.0	0	0	0	0	0
06/20/2020 01:00	0.0	0	0	0	0	0
06/20/2020 02:00	0.0	0	0	0	0	0
06/20/2020 03:00	0.0	0	0	0	0	0
06/20/2020 04:00	0.0	0	0	0	0	0
06/20/2020 05:00	0.0	0	0	0	0	0
06/20/2020 06:00	0.0	0	0	0	0	0
06/20/2020 07:00	0.0	0	0	0	0	0
06/20/2020 08:00	0.0	0	0	0	0	0
06/20/2020 09:00	0.0	0	0	0	0	0
06/20/2020 10:00	0.0	0	0	0	0	0
06/20/2020 11:00	0.0	0	0	0	0	0
06/20/2020 12:00	0.0	0	0	0	0	0
06/20/2020 13:00	0.0	0	0	0	0	0
06/20/2020 14:00	0.0	0	0	0	0	0
06/20/2020 15:00	0.0	0	0	0	0	0
06/20/2020 16:00	0.0	0	0	0	0	0
06/20/2020 17:00	0.0	0	0	0	0	0
06/20/2020 18:00	0.0	0	0	0	0	0
06/20/2020 19:00	0.0	0	0	0	0	0
06/20/2020 20:00	68.8	0	1	0	0	0
06/20/2020 21:00	11.3	0	1	0	0	0
06/20/2020 22:00	21.6	0	1	0	0	0
06/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	101.7 #	0 #	3 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	68.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/21/2020 00:00	0.0	0	0	0	0	1
06/21/2020 01:00	0.0	0	0	0	0	1
06/21/2020 02:00	0.0	0	0	0	0	1
06/21/2020 03:00	0.0	0	0	0	0	1
06/21/2020 04:00	0.0	0	0	0	0	1
06/21/2020 05:00	0.0	0	0	0	0	1
06/21/2020 06:00	0.0	0	0	0	0	1
06/21/2020 07:00	0.0	0	0	0	0	1
06/21/2020 08:00	0.0	0	0	0	0	1
06/21/2020 09:00	0.0	0	0	0	0	1
06/21/2020 10:00	0.0	0	0	0	0	1
06/21/2020 11:00	0.0	0	0	0	0	1
06/21/2020 12:00	0.0	0	0	0	0	1
06/21/2020 13:00	0.0	0	0	0	0	1
06/21/2020 14:00	0.0	0	0	0	0	1
06/21/2020 15:00	0.0	0	0	0	0	1
06/21/2020 16:00	0.0	0	0	0	0	1
06/21/2020 17:00	0.0	0	0	0	0	1
06/21/2020 18:00	0.0	0	0	0	0	1
06/21/2020 19:00	0.0	0	0	0	0	1
06/21/2020 20:00	0.0	0	0	0	0	1
06/21/2020 21:00	0.0	0	0	0	0	1
06/21/2020 22:00	0.0	0	0	0	0	1
06/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/22/2020 00:00	0.0	0	0	0	0	1
06/22/2020 01:00	0.0	0	0	0	0	1
06/22/2020 02:00	0.0	0	0	0	0	1
06/22/2020 03:00	0.0	0	0	0	0	1
06/22/2020 04:00	0.0	0	0	0	0	1
06/22/2020 05:00	0.0	0	0	0	0	1
06/22/2020 06:00	0.0	0	0	0	0	1
06/22/2020 07:00	0.0	0	0	0	0	1
06/22/2020 08:00	0.0	0	0	0	0	1
06/22/2020 09:00	0.0	0	0	0	0	1
06/22/2020 10:00	0.0	0	0	0	0	1
06/22/2020 11:00	0.0	0	0	0	0	1
06/22/2020 12:00	0.0	0	0	0	0	1
06/22/2020 13:00	0.0	0	0	0	0	1
06/22/2020 14:00	0.0	0	0	0	0	1
06/22/2020 15:00	0.0	0	0	0	0	1
06/22/2020 16:00	0.0	0	0	0	0	1
06/22/2020 17:00	0.0	0	0	0	0	1
06/22/2020 18:00	0.0	0	0	0	0	1
06/22/2020 19:00	0.0	0	0	0	0	1
06/22/2020 20:00	0.0	0	0	0	0	1
06/22/2020 21:00	0.0	0	0	0	0	1
06/22/2020 22:00	0.0	0	0	0	0	1
06/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/23/2020 00:00	1.0	0	0	0	1	0
06/23/2020 01:00	0.0	0	0	0	0	0
06/23/2020 02:00	0.0	0	0	0	0	0
06/23/2020 03:00	0.0	0	0	0	0	0
06/23/2020 04:00	0.0	0	0	0	0	0
06/23/2020 05:00	0.0	0	0	0	0	0
06/23/2020 06:00	0.0	0	0	0	0	0
06/23/2020 07:00	0.0	0	0	0	0	0
06/23/2020 08:00	0.0	0	0	0	0	0
06/23/2020 09:00	0.0	0	0	0	0	0
06/23/2020 10:00	0.0	0	0	0	0	0
06/23/2020 11:00	0.0	0	0	0	0	0
06/23/2020 12:00	10.1	0	1	0	0	0
06/23/2020 13:00	34.4	0	1	0	0	0
06/23/2020 14:00	1.5	0	1	0	0	0
06/23/2020 15:00	0.0	0	0	0	0	1
06/23/2020 16:00	0.0	0	0	0	0	1
06/23/2020 17:00	0.0	0	0	0	0	1
06/23/2020 18:00	0.0	0	0	0	0	1
06/23/2020 19:00	0.0	0	0	0	0	1
06/23/2020 20:00	0.0	0	0	0	0	1
06/23/2020 21:00	0.0	0	0	0	0	1
06/23/2020 22:00	0.0	0	0	0	0	1
06/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	47.0 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	34.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/24/2020 00:00	0.0	0	0	0	0	1
06/24/2020 01:00	0.0	0	0	0	0	1
06/24/2020 02:00	0.0	0	0	0	0	1
06/24/2020 03:00	0.0	0	0	0	0	1
06/24/2020 04:00	0.0	0	0	0	0	1
06/24/2020 05:00	0.0	0	0	0	0	1
06/24/2020 06:00	0.0	0	0	0	0	1
06/24/2020 07:00	0.0	0	0	0	0	1
06/24/2020 08:00	0.0	0	0	0	0	1
06/24/2020 09:00	0.0	0	0	0	0	1
06/24/2020 10:00	0.0	0	0	0	0	1
06/24/2020 11:00	0.0	0	0	0	0	1
06/24/2020 12:00	0.0	0	0	0	0	1
06/24/2020 13:00	0.0	0	0	0	0	1
06/24/2020 14:00	0.0	0	0	0	0	1
06/24/2020 15:00	0.0	0	0	0	0	1
06/24/2020 16:00	0.0	0	0	0	0	1
06/24/2020 17:00	0.0	0	0	0	0	1
06/24/2020 18:00	0.0	0	0	0	0	1
06/24/2020 19:00	0.0	0	0	0	0	1
06/24/2020 20:00	0.0	0	0	0	0	1
06/24/2020 21:00	0.0	0	0	0	0	1
06/24/2020 22:00	0.0	0	0	0	0	1
06/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/25/2020 00:00	0.9	0	0	0	1	0
06/25/2020 01:00	0.0	0	0	0	0	0
06/25/2020 02:00	0.0	0	0	0	0	0
06/25/2020 03:00	0.0	0	0	0	0	0
06/25/2020 04:00	0.0	0	0	0	0	0
06/25/2020 05:00	0.0	0	0	0	0	0
06/25/2020 06:00	0.0	0	0	0	0	0
06/25/2020 07:00	0.0	0	0	0	0	0
06/25/2020 08:00	3.1	0	1	0	0	0
06/25/2020 09:00	41.9	0	1	0	0	0
06/25/2020 10:00	0.0	0	0	0	0	1
06/25/2020 11:00	0.0	0	0	0	0	1
06/25/2020 12:00	0.0	0	0	0	0	1
06/25/2020 13:00	0.0	0	0	0	0	1
06/25/2020 14:00	0.0	0	0	0	0	1
06/25/2020 15:00	0.0	0	0	0	0	1
06/25/2020 16:00	0.0	0	0	0	0	1
06/25/2020 17:00	0.0	0	0	0	0	1
06/25/2020 18:00	0.0	0	0	0	0	1
06/25/2020 19:00	0.0	0	0	0	0	1
06/25/2020 20:00	0.0	0	0	0	0	1
06/25/2020 21:00	0.0	0	0	0	0	1
06/25/2020 22:00	0.9	0	0	0	1	0
06/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	46.8 #	0 #	2 #	0 #	2 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	41.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/26/2020 00:00	0.0	0	0	0	0	0
06/26/2020 01:00	0.0	0	0	0	0	0
06/26/2020 02:00	0.0	0	0	0	0	0
06/26/2020 03:00	0.0	0	0	0	0	0
06/26/2020 04:00	0.0	0	0	0	0	0
06/26/2020 05:00	3.2	0	0	1	0	0
06/26/2020 06:00	35.5	0	0	1	0	0
06/26/2020 07:00	0.0	0	0	0	0	1
06/26/2020 08:00	0.0	0	0	0	0	1
06/26/2020 09:00	0.0	0	0	0	0	1
06/26/2020 10:00	0.0	0	0	0	0	1
06/26/2020 11:00	0.0	0	0	0	0	1
06/26/2020 12:00	0.0	0	0	0	0	1
06/26/2020 13:00	0.0	0	0	0	0	1
06/26/2020 14:00	0.0	0	0	0	0	1
06/26/2020 15:00	0.0	0	0	0	0	1
06/26/2020 16:00	0.0	0	0	0	0	1
06/26/2020 17:00	0.0	0	0	0	0	1
06/26/2020 18:00	0.0	0	0	0	0	1
06/26/2020 19:00	0.0	0	0	0	0	1
06/26/2020 20:00	0.0	0	0	0	0	1
06/26/2020 21:00	0.0	0	0	0	0	1
06/26/2020 22:00	0.0	0	0	0	0	1
06/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	38.7 #	0 #	0 #	2 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	35.5	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/27/2020 00:00	0.4	0	0	0	1	0
06/27/2020 01:00	0.0	0	0	0	0	0
06/27/2020 02:00	0.0	0	0	0	0	0
06/27/2020 03:00	0.0	0	0	0	0	0
06/27/2020 04:00	0.0	0	0	0	0	0
06/27/2020 05:00	0.0	0	0	0	0	0
06/27/2020 06:00	0.0	0	0	0	0	0
06/27/2020 07:00	0.0	0	0	0	0	0
06/27/2020 08:00	0.0	0	0	0	0	0
06/27/2020 09:00	0.0	0	0	0	0	0
06/27/2020 10:00	0.0	0	0	0	0	0
06/27/2020 11:00	0.0	0	0	0	0	0
06/27/2020 12:00	0.0	0	0	0	0	0
06/27/2020 13:00	0.0	0	0	0	0	0
06/27/2020 14:00	0.0	0	0	0	0	0
06/27/2020 15:00	0.0	0	0	0	0	0
06/27/2020 16:00	0.0	0	0	0	0	0
06/27/2020 17:00	0.0	0	0	0	0	0
06/27/2020 18:00	0.0	0	0	0	0	0
06/27/2020 19:00	0.0	0	0	0	0	0
06/27/2020 20:00	0.0	0	0	0	0	0
06/27/2020 21:00	0.0	0	0	0	0	0
06/27/2020 22:00	0.0	0	0	0	0	0
06/27/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.4 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.4	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/28/2020 00:00	0.0	0	0	0	0	0
06/28/2020 01:00	0.0	0	0	0	0	0
06/28/2020 02:00	0.0	0	0	0	0	0
06/28/2020 03:00	0.0	0	0	0	0	0
06/28/2020 04:00	0.0	0	0	0	0	0
06/28/2020 05:00	0.0	0	0	0	0	0
06/28/2020 06:00	0.0	0	0	0	0	0
06/28/2020 07:00	0.0	0	0	0	0	0
06/28/2020 08:00	0.0	0	0	0	0	0
06/28/2020 09:00	0.0	0	0	0	0	0
06/28/2020 10:00	0.0	0	0	0	0	0
06/28/2020 11:00	0.0	0	0	0	0	0
06/28/2020 12:00	0.0	0	0	0	0	0
06/28/2020 13:00	0.0	0	0	0	0	0
06/28/2020 14:00	0.0	0	0	0	0	0
06/28/2020 15:00	0.0	0	0	0	0	0
06/28/2020 16:00	0.0	0	0	0	0	0
06/28/2020 17:00	0.0	0	0	0	0	0
06/28/2020 18:00	0.0	0	0	0	0	0
06/28/2020 19:00	0.0	0	0	0	0	0
06/28/2020 20:00	0.0	0	0	0	0	0
06/28/2020 21:00	0.0	0	0	0	0	0
06/28/2020 22:00	0.0	0	0	0	0	0
06/28/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/29/2020 00:00	0.0	0	0	0	0	0
06/29/2020 01:00	0.0	0	0	0	0	0
06/29/2020 02:00	0.0	0	0	0	0	0
06/29/2020 03:00	0.0	0	0	0	0	0
06/29/2020 04:00	0.0	0	0	0	0	0
06/29/2020 05:00	0.0	0	0	0	0	0
06/29/2020 06:00	0.0	0	0	0	0	0
06/29/2020 07:00	0.0	0	0	0	0	0
06/29/2020 08:00	0.0	0	0	0	0	0
06/29/2020 09:00	0.0	0	0	0	0	0
06/29/2020 10:00	0.0	0	0	0	0	0
06/29/2020 11:00	0.0	0	0	0	0	0
06/29/2020 12:00	0.0	0	0	0	0	0
06/29/2020 13:00	0.0	0	0	0	0	0
06/29/2020 14:00	0.0	0	0	0	0	0
06/29/2020 15:00	0.0	0	0	0	0	0
06/29/2020 16:00	0.0	0	0	0	0	0
06/29/2020 17:00	0.0	0	0	0	0	0
06/29/2020 18:00	0.0	0	0	0	0	0
06/29/2020 19:00	0.0	0	0	0	0	0
06/29/2020 20:00	0.0	0	0	0	0	0
06/29/2020 21:00	0.0	0	0	0	0	0
06/29/2020 22:00	0.0	0	0	0	0	0
06/29/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
06/30/2020 00:00	0.0	0	0	0	0	0
06/30/2020 01:00	0.0	0	0	0	0	0
06/30/2020 02:00	0.0	0	0	0	0	0
06/30/2020 03:00	0.0	0	0	0	0	0
06/30/2020 04:00	0.0	0	0	0	0	0
06/30/2020 05:00	0.0	0	0	0	0	0
06/30/2020 06:00	0.0	0	0	0	0	0
06/30/2020 07:00	0.0	0	0	0	0	0
06/30/2020 08:00	30.2	1	0	0	0	0
06/30/2020 09:00	66.0	1	0	0	0	0
06/30/2020 10:00	26.0	1	0	0	0	0
06/30/2020 11:00	45.7	1	0	0	0	0
06/30/2020 12:00	0.0	0	0	0	0	1
06/30/2020 13:00	0.0	0	0	0	0	1
06/30/2020 14:00	0.0	0	0	0	0	1
06/30/2020 15:00	0.0	0	0	0	0	1
06/30/2020 16:00	0.0	0	0	0	0	1
06/30/2020 17:00	0.0	0	0	0	0	1
06/30/2020 18:00	0.0	0	0	0	0	1
06/30/2020 19:00	0.0	0	0	0	0	1
06/30/2020 20:00	0.0	0	0	0	0	1
06/30/2020 21:00	0.0	0	0	0	0	1
06/30/2020 22:00	1.0	0	0	0	1	0
06/30/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	168.9 #	4 #	0 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	66.0	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Pound Per Event Report

CT2 - CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 671.97 Hours

Non-Operating Time: 1,512.03 Hours Report Time: 2,184.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
04/02/2020 21:22 04/02/2020 21:27 Shut Down - Gas	6	0.9	483.5		
04/03/2020 20:17 04/03/2020 22:50 Warm Start - Gas	154	95.7	790.5		
04/17/2020 23:23 04/17/2020 23:28 Shut Down - Gas	6	0.9	483.5		
04/19/2020 17:18 04/19/2020 19:51 Warm Start - Gas	154	127.2	790.5		
04/20/2020 23:08 04/20/2020 23:13 Shut Down - Gas	6	0.8	483.5		
04/22/2020 04:19 04/22/2020 06:51 Warm Start - Gas	153	111.7	790.5		
04/22/2020 13:05 04/22/2020 13:10 Shut Down - Gas	6	0.9	483.5		
04/22/2020 18:47 04/22/2020 19:51 Hot Start - Gas	65	34.8	679.6		
04/23/2020 02:04 04/23/2020 02:09 Shut Down - Gas	6	0.4	483.5		
04/24/2020 09:18 04/24/2020 11:50 Warm Start - Gas	153	115.5	790.5		
04/24/2020 22:30 04/24/2020 22:35 Shut Down - Gas	6	0.8	483.5		
04/27/2020 13:20 04/27/2020 15:43 Warm Start - Gas	144	125.9	790.5		
04/28/2020 21:54 04/28/2020 21:59 Shut Down - Gas	6	0.9	483.5		

Pound Per Event Report

CT2 - CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 671.97 Hours

Non-Operating Time: 1,512.03 Hours Report Time: 2,184.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
04/29/2020 13:19 04/29/2020 15:18 Warm Start - Gas	120	100.2	790.5		
04/30/2020 07:04 04/30/2020 07:09 Shut Down - Gas	6	1.1	483.5		
05/11/2020 16:30 05/11/2020 16:32 Shut Down - Gas	3	0.0	483.5		
05/27/2020 08:40 05/27/2020 11:54 Cold Start - Gas	195	0.0 SI	1,355.6		
05/27/2020 14:11 05/27/2020 14:16 Shut Down - Gas	6	0.7	483.5		
05/28/2020 18:50 05/28/2020 20:16 Warm Start - Gas	87	95.3	790.5		
05/29/2020 01:38 05/29/2020 01:43 Shut Down - Gas	6	0.7	483.5		
05/29/2020 20:28 05/29/2020 22:43 Warm Start - Gas	136	128.0	790.5		
05/30/2020 08:04 05/30/2020 08:09 Shut Down - Gas	6	1.1	483.5		
05/30/2020 13:53 05/30/2020 15:06 Hot Start - Gas	74	53.8	679.6		
05/31/2020 06:04 05/31/2020 06:09 Shut Down - Gas	6	0.0 SI	483.5		
05/31/2020 14:18 05/31/2020 15:40 Warm Start - Gas	83	44.1	790.5		
06/04/2020 00:22 06/04/2020 00:28 Shut Down - Gas	7	0.9	483.5		
06/04/2020 10:34 06/04/2020 11:54 Warm Start - Gas	81	42.9	790.5		

Pound Per Event Report

CT2 - CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 671.97 Hours

Non-Operating Time: 1,512.03 Hours Report Time: 2,184.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
06/05/2020 00:26 06/05/2020 00:31 Shut Down - Gas	6	0.8	483.5		
06/08/2020 09:34 06/08/2020 12:48 Cold Start - Gas	195	182.1	1,355.6		
06/08/2020 23:54 06/08/2020 23:59 Shut Down - Gas	6	0.8	483.5		
06/09/2020 08:28 06/09/2020 10:50 Warm Start - Gas	143	75.0	790.5		
06/09/2020 23:23 06/09/2020 23:28 Shut Down - Gas	6	0.4	483.5		
06/10/2020 07:38 06/10/2020 08:42 Warm Start - Gas	65	48.4	790.5		
06/11/2020 23:23 06/11/2020 23:28 Shut Down - Gas	6	0.8	483.5		
06/14/2020 12:18 06/14/2020 14:58 Warm Start - Gas	161	208.2	790.5		
06/14/2020 23:05 06/14/2020 23:10 Shut Down - Gas	6	1.0	483.5		
06/17/2020 09:08 06/17/2020 11:41 Warm Start - Gas	154	115.4	790.5		
06/17/2020 23:24 06/17/2020 23:29 Shut Down - Gas	6	0.4	483.5		
06/18/2020 07:38 06/18/2020 08:51 Warm Start - Gas	74	30.6	790.5		
06/18/2020 23:09 06/18/2020 23:14 Shut Down - Gas	6	0.9	483.5		
06/20/2020 20:03 06/20/2020 22:42 Warm Start - Gas	160	149.2	790.5		

Pound Per Event Report

CT2 - CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 671.97 Hours

Non-Operating Time: 1,512.03 Hours Report Time: 2,184.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
06/23/2020 00:23 06/23/2020 00:29 Shut Down - Gas	7	1.4	483.5		
06/23/2020 12:43 06/23/2020 14:10 Warm Start - Gas	88	63.6	790.5		
06/25/2020 00:31 06/25/2020 00:36 Shut Down - Gas	6	0.9	483.5		
06/25/2020 08:47 06/25/2020 09:45 Warm Start - Gas	59	35.9	790.5		
06/25/2020 22:38 06/25/2020 22:43 Shut Down - Gas	6	1.2	483.5		
06/26/2020 05:47 06/26/2020 06:56 Hot Start - Gas	70	43.0	679.6		
06/27/2020 00:39 06/27/2020 00:44 Shut Down - Gas	6	1.1	483.5		
06/30/2020 08:33 06/30/2020 11:52 Cold Start - Gas	200	199.6	1,355.6		
06/30/2020 22:23 06/30/2020 22:28 Shut Down - Gas	6	1.1	483.5		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT2 - CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 671.97 Hours

Non-Operating Time: 1,512.03 Hours Report Time: 2,184.00 Hours

Event Invalid Information

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
05/27/2020 08:40 05/27/2020 11:54	195		
05/31/2020 06:04 05/31/2020 06:09	6		

Total CMS Downtime	201	Minute(s)
Total Downtime as a percentage of operating time	0.50	%
Total Availability as a percentage of operating time	99.50	%

Pound Per Event Report

CT2 - CO Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:26 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 671.97 Hours

Non-Operating Time: 1,512.03 Hours Report Time: 2,184.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	201
2. Total CMS Downtime in Minute(s)	201
3. Total Downtime as a percentage of operating time	0.50
4. Total Availability as a percentage of operating time	99.50

Pound Per Event Report

CT2 - NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:27 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 876.73 Hours

Non-Operating Time: 1,307.27 Hours Report Time: 2,184.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
04/02/2020 21:22 04/02/2020 21:27 Shut Down - Gas	6	0.52	115.00		
04/03/2020 20:17 04/03/2020 22:50 Warm Start - Gas	154	150.35	456.20		
04/17/2020 23:23 04/17/2020 23:28 Shut Down - Gas	6	0.66	115.00		
04/19/2020 17:18 04/19/2020 19:51 Warm Start - Gas	154	157.75	456.20		
04/20/2020 23:08 04/20/2020 23:13 Shut Down - Gas	6	0.34	115.00		
04/22/2020 04:19 04/22/2020 06:51 Warm Start - Gas	153	106.88	456.20		
04/22/2020 13:05 04/22/2020 13:10 Shut Down - Gas	6	0.34	115.00		
04/22/2020 18:47 04/22/2020 19:51 Hot Start - Gas	65	45.83	259.90		
04/23/2020 02:04 04/23/2020 02:09 Shut Down - Gas	6	0.18	115.00		
04/24/2020 09:18 04/24/2020 11:50 Warm Start - Gas	153	154.45	456.20		
04/24/2020 22:30 04/24/2020 22:35 Shut Down - Gas	6	0.32	115.00		
04/27/2020 13:20 04/27/2020 15:43 Warm Start - Gas	144	177.06	456.20		
04/28/2020 21:54 04/28/2020 21:59 Shut Down - Gas	6	0.36	115.00		

Pound Per Event Report

CT2 - NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:27 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 876.73 Hours

Non-Operating Time: 1,307.27 Hours Report Time: 2,184.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
04/29/2020 13:19 04/29/2020 15:18 Warm Start - Gas	120	108.72	456.20		
04/30/2020 07:04 04/30/2020 07:09 Shut Down - Gas	6	0.22	115.00		
05/11/2020 16:30 05/11/2020 16:32 Shut Down - Gas	3	0.00	115.00		
05/27/2020 08:40 05/27/2020 11:54 Cold Start - Gas	195	0.00 SI	779.10		
05/27/2020 14:11 05/27/2020 14:16 Shut Down - Gas	6	0.21	115.00		
05/28/2020 18:50 05/28/2020 20:16 Warm Start - Gas	87	81.43	456.20		
05/29/2020 01:38 05/29/2020 01:43 Shut Down - Gas	6	0.16	115.00		
05/29/2020 20:28 05/29/2020 22:43 Warm Start - Gas	136	144.57	456.20		
05/30/2020 08:04 05/30/2020 08:09 Shut Down - Gas	6	0.21	115.00		
05/30/2020 13:53 05/30/2020 15:06 Hot Start - Gas	74	67.81	259.90		
05/31/2020 06:04 05/31/2020 06:09 Shut Down - Gas	6	0.00 SI	115.00		
05/31/2020 14:18 05/31/2020 15:40 Warm Start - Gas	83	83.34	456.20		
06/04/2020 00:22 06/04/2020 00:28 Shut Down - Gas	7	0.43	115.00		
06/04/2020 10:34 06/04/2020 11:54 Warm Start - Gas	81	67.11	456.20		

Pound Per Event Report

CT2 - NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:27 **Location:** Maxwell, CA
Tag Name: CT2_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 876.73 Hours
Non-Operating Time: 1,307.27 Hours Report Time: 2,184.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
06/05/2020 00:26 06/05/2020 00:31 Shut Down - Gas	6	0.28	115.00		
06/08/2020 09:34 06/08/2020 12:48 Cold Start - Gas	195	185.21	779.10		
06/08/2020 23:54 06/08/2020 23:59 Shut Down - Gas	6	0.34	115.00		
06/09/2020 08:28 06/09/2020 10:50 Warm Start - Gas	143	114.62	456.20		
06/09/2020 23:23 06/09/2020 23:28 Shut Down - Gas	6	0.26	115.00		
06/10/2020 07:38 06/10/2020 08:42 Warm Start - Gas	65	59.92	456.20		
06/11/2020 23:23 06/11/2020 23:28 Shut Down - Gas	6	0.31	115.00		
06/14/2020 12:18 06/14/2020 14:58 Warm Start - Gas	161	178.42	456.20		
06/14/2020 23:05 06/14/2020 23:10 Shut Down - Gas	6	0.20	115.00		
06/17/2020 09:08 06/17/2020 11:41 Warm Start - Gas	154	152.24	456.20		
06/17/2020 23:24 06/17/2020 23:29 Shut Down - Gas	6	0.32	115.00		
06/18/2020 07:38 06/18/2020 08:51 Warm Start - Gas	74	69.72	456.20		
06/18/2020 23:09 06/18/2020 23:14 Shut Down - Gas	6	0.50	115.00		
06/20/2020 20:03 06/20/2020 22:42 Warm Start - Gas	160	105.01	456.20		

Pound Per Event Report

CT2 - NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:27 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 876.73 Hours

Non-Operating Time: 1,307.27 Hours Report Time: 2,184.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
06/23/2020 00:23 06/23/2020 00:29 Shut Down - Gas	7	0.41	115.00		
06/23/2020 12:43 06/23/2020 14:10 Warm Start - Gas	88	51.80	456.20		
06/25/2020 00:31 06/25/2020 00:36 Shut Down - Gas	6	0.18	115.00		
06/25/2020 08:47 06/25/2020 09:45 Warm Start - Gas	59	49.03	456.20		
06/25/2020 22:38 06/25/2020 22:43 Shut Down - Gas	6	0.40	115.00		
06/26/2020 05:47 06/26/2020 06:56 Hot Start - Gas	70	38.68	259.90		
06/27/2020 00:39 06/27/2020 00:44 Shut Down - Gas	6	0.23	115.00		
06/30/2020 08:33 06/30/2020 11:52 Cold Start - Gas	200	169.93	779.10		
06/30/2020 22:23 06/30/2020 22:28 Shut Down - Gas	6	0.45	115.00		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT2 - NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:27 **Location:** Maxwell, CA
Tag Name: CT2_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 876.73 Hours
Non-Operating Time: 1,307.27 Hours Report Time: 2,184.00 Hours

Event Invalid Information

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
05/27/2020 08:40 05/27/2020 11:54	195		
05/31/2020 06:04 05/31/2020 06:09	6		

Total CMS Downtime	201	Minute(s)
Total Downtime as a percentage of operating time	0.38	%
Total Availability as a percentage of operating time	99.62	%

Pound Per Event Report

CT2 - NOx Lbs

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 07/10/2020 09:27 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 876.73 Hours

Non-Operating Time: 1,307.27 Hours Report Time: 2,184.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	201
2. Total CMS Downtime in Minute(s)	201
3. Total Downtime as a percentage of operating time	0.38
4. Total Availability as a percentage of operating time	99.62

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:28 **Location:** Maxwell, CA

Unit Offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	**End Time**	**Duration in Hour(s)**
04/01/2020 00:00	04/01/2020 02:00	3
04/02/2020 22:00	04/04/2020 00:00	27
04/18/2020 00:00	04/20/2020 01:00	50
04/21/2020 00:00	04/22/2020 06:00	31
04/22/2020 12:00	04/24/2020 13:00	50
04/24/2020 23:00	04/28/2020 12:00	86
04/28/2020 22:00	05/26/2020 09:00	660
05/26/2020 16:00	05/28/2020 11:00	44
05/29/2020 02:00	06/01/2020 11:00	82
06/04/2020 01:00	06/04/2020 05:00	5
06/05/2020 01:00	06/08/2020 14:00	86
06/09/2020 00:00	06/09/2020 11:00	12
06/10/2020 00:00	06/10/2020 09:00	10
06/12/2020 00:00	06/17/2020 11:00	132
06/18/2020 00:00	06/18/2020 10:00	11
06/19/2020 00:00	06/22/2020 08:00	81
06/23/2020 01:00	06/23/2020 06:00	6
06/25/2020 01:00	06/25/2020 11:00	11
06/25/2020 23:00	06/26/2020 09:00	11
06/26/2020 13:00	06/26/2020 15:00	3
06/27/2020 01:00	06/30/2020 13:00	85
06/30/2020 23:00	06/30/2020 23:00	1

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:28 **Location:** Maxwell, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,184.00 Hour(s)
Total Offline:	1,487.00 Hour(s)
Offline Percentage:	68.09 %
Total Online:	697.00 Hour(s)
Online Percentage:	31.91 %

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:28 **Location:** Maxwell, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	04/01/2020 03:00	04/01/2020 04:00	Warm Startup	2
2	04/04/2020 01:00	04/04/2020 02:00	Warm Startup	2
3	04/20/2020 02:00	04/20/2020 03:00	Warm Startup	2
4	04/22/2020 07:00	04/22/2020 09:00	Warm Startup	3
5	04/24/2020 14:00	04/24/2020 16:00	Warm Startup	3
6	04/28/2020 13:00	04/28/2020 15:00	Cold Startup	3
7	05/26/2020 10:00	05/26/2020 15:00	Cold Startup	6
8	05/28/2020 12:00	05/28/2020 15:00	Cold Startup	4
9	06/01/2020 12:00	06/01/2020 14:00	Cold Startup	3
10	06/04/2020 06:00	06/04/2020 07:00	Hot Startup	2
11	06/08/2020 15:00	06/08/2020 17:00	Cold Startup	3
12	06/08/2020 17:00	06/08/2020 18:00	Hot Startup	2
13	06/09/2020 12:00	06/09/2020 15:00	Warm Startup	4
14	06/10/2020 10:00	06/10/2020 12:00	Warm Startup	3
15	06/17/2020 12:00	06/17/2020 15:00	Cold Startup	4
16	06/18/2020 11:00	06/18/2020 12:00	Warm Startup	2
17	06/22/2020 09:00	06/22/2020 12:00	Cold Startup	4
18	06/23/2020 07:00	06/23/2020 09:00	Hot Startup	3
19	06/25/2020 12:00	06/25/2020 13:00	Warm Startup	2
20	06/26/2020 10:00	06/26/2020 11:00	Warm Startup	2
21	06/26/2020 16:00	06/26/2020 17:00	Hot Startup	2
22	06/30/2020 14:00	06/30/2020 15:00	Cold Startup	2

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:28 **Location:** Maxwell, CA

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:28 **Location:** Maxwell, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	8	29	4.16
Hot Startup/Startup Shutdown Event Text 02 Add	4	9	1.29
Warm Startup	10	25	3.59
Total Process Events:	22	63	9.04

Total Report Time:	2,184 Hour(s)
Total Operating Time:	697 Hour(s)
Total Startup Time:	63 Hour(s)
Total Shutdown Time:	0 Hour(s)
Total Startup/Shutdown Time:	63 Hour(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	9.04 %

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:28 **Location:** Maxwell, CA

Unit Offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
04/02/2020 22:00	04/03/2020 19:00	22
04/18/2020 00:00	04/19/2020 16:00	41
04/21/2020 00:00	04/22/2020 03:00	28
04/22/2020 14:00	04/22/2020 17:00	4
04/23/2020 03:00	04/24/2020 08:00	30
04/24/2020 23:00	04/27/2020 12:00	62
04/28/2020 22:00	04/29/2020 12:00	15
04/30/2020 08:00	05/11/2020 15:00	272
05/11/2020 17:00	05/27/2020 07:00	375
05/27/2020 15:00	05/28/2020 17:00	27
05/29/2020 02:00	05/29/2020 19:00	18
05/30/2020 09:00	05/30/2020 12:00	4
05/31/2020 07:00	05/31/2020 13:00	7
06/04/2020 01:00	06/04/2020 09:00	9
06/05/2020 01:00	06/08/2020 08:00	80
06/09/2020 00:00	06/09/2020 07:00	8
06/10/2020 00:00	06/10/2020 06:00	7
06/12/2020 00:00	06/14/2020 11:00	60
06/15/2020 00:00	06/17/2020 08:00	57
06/18/2020 00:00	06/18/2020 06:00	7
06/19/2020 00:00	06/20/2020 19:00	44
06/23/2020 01:00	06/23/2020 11:00	11
06/25/2020 01:00	06/25/2020 07:00	7
06/25/2020 23:00	06/26/2020 04:00	6
06/27/2020 01:00	06/30/2020 07:00	79
06/30/2020 23:00	06/30/2020 23:00	1

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:28 **Location:** Maxwell, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,184.00 Hour(s)
Total Offline:	1,281.00 Hour(s)
Offline Percentage:	58.65 %
Total Online:	903.00 Hour(s)
Online Percentage:	41.35 %

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:28 **Location:** Maxwell, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	04/03/2020 20:00	04/03/2020 22:00	Warm startup	3
2	04/19/2020 17:00	04/19/2020 19:00	Warm startup	3
3	04/22/2020 04:00	04/22/2020 06:00	Warm startup	3
4	04/22/2020 18:00	04/22/2020 19:00	Hot Startup	2
5	04/24/2020 09:00	04/24/2020 11:00	Warm startup	3
6	04/27/2020 13:00	04/27/2020 15:00	Warm startup	3
7	04/29/2020 13:00	04/29/2020 15:00	Warm startup	3
8	05/27/2020 08:00	05/27/2020 11:00	Cold Startup	4
9	05/28/2020 18:00	05/28/2020 20:00	Warm startup	3
10	05/29/2020 20:00	05/29/2020 22:00	Warm startup	3
11	05/30/2020 13:00	05/30/2020 15:00	Hot Startup	3
12	05/31/2020 14:00	05/31/2020 15:00	Warm startup	2
13	06/04/2020 10:00	06/04/2020 11:00	Warm startup	2
14	06/08/2020 09:00	06/08/2020 12:00	Cold Startup	4
15	06/09/2020 08:00	06/09/2020 10:00	Warm startup	3
16	06/10/2020 07:00	06/10/2020 08:00	Warm startup	2
17	06/14/2020 12:00	06/14/2020 14:00	Warm startup	3
18	06/17/2020 09:00	06/17/2020 11:00	Warm startup	3
19	06/18/2020 07:00	06/18/2020 08:00	Warm startup	2
20	06/20/2020 20:00	06/20/2020 22:00	Warm startup	3
21	06/23/2020 12:00	06/23/2020 14:00	Warm startup	3
22	06/25/2020 08:00	06/25/2020 09:00	Warm startup	2

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:28 **Location:** Maxwell, CA

Number	Start Time	End Time	Event Type	Duration
23	06/26/2020 05:00	06/26/2020 06:00	Hot Startup	2
24	06/30/2020 08:00	06/30/2020 11:00	Cold Startup	4

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 04/01/2020 00:00 **To:** 06/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 07/10/2020 09:28 **Location:** Maxwell, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	3	12	1.33
Hot Startup	3	7	0.78
Warm startup	18	49	5.43
Total Process Events:	24	68	7.53

Total Report Time:	2,184 Hour(s)
Total Operating Time:	903 Hour(s)
Total Startup Time:	68 Hour(s)
Total Shutdown Time:	0 Hour(s)
Total Startup/Shutdown Time:	68 Hour(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	7.53 %

ATTACHMENT 13
Water Bath Heater Operations
FCD: AQ-17
Title V: #6

The Natural Gas Fired Water Bath Heater did not operate in the 2nd Quarter of 2020.

ATTACHMENT 14
Certification Report

FCD: AQ-22
Title V: #13

CERTIFICATION REPORT
(FORM 3.17-K1)

DISTRICT:	▸ DISTRICT USE ONLY ◂
Colusa County Air Pollution Control District	DISTRICT ID:
COMPANY NAME: Pacific Gas and Electric	FACILITY NAME: Colusa Generating Station

I. FACILITY INFORMATION

1. Company Name: Pacif ic Gas and Electric
2. Facility Name (if different than Company Name): Colusa Generating Station
3. Mailing Address: 4780 Dirks Rd , Maxwell CA 95955
4. Street Address or Source Location: Same
5. Facility Permit Number: 21006-0259

II. GENERAL INFORMATION

1. Reporting period (specify dates): April 1 - June 30, 2020
2. Due date for submittal of report: July 30, 2020

3. Type of submittal: [X] Monitoring Report (complete Section III below)
   [ ] Compliance Schedule Progress Report (complete Section IV of Form 3.17-K2)
   [ ] Compliance Certification (complete Section V of Form 3.17-K2)

III. MONITORING REPORT INFORMATION

1. Were deviations from monitoring requirements encountered during the reporting period?[X] No [ ] Yes (If Yes, complete Form 3.17-L)