

DOCKETED

Docket Number:	19-BSTD-03
Project Title:	2022 Energy Code Pre-Rulemaking
TN #:	234968
Document Title:	Compressed Air System Monitoring
Description:	N/A
Filer:	System
Organization:	Nicolas De Deken
Submitter Role:	Public
Submission Date:	9/30/2020 3:33:40 PM
Docketed Date:	9/30/2020

Comment Received From: Nicolas De Deken
Submitted On: 9/30/2020
Docket Number: 19-BSTD-03

Compressed Air System Monitoring

Remote monitoring of compressed air systems is the only solution to continuous savings.

Most compressed air systems are energy efficient by design and at start-up but quite often turn inefficient within a few months of operation. Energy is typically wasted because of an increase in leaks, compressors no longer being properly synchronized, increase in pressure differentials, etc.

Only by continuously monitoring Power (or Amps), Flow and Efficiency (kW/100CFM) can compressed air system energy savings persist.

E.g. An increase in flow which can not be linked to additional demand in production is most of the time due to increased leaks and a decrease in efficiency (=increase of kW/100CFM) is typically a consequence of compressors no longer be properly synchronized

But if you don't get alerted by these important energy efficiency KPIs, you can't act on it and you'll miss out on a lot of energy savings!