

DOCKETED

Docket Number:	19-BSTD-03
Project Title:	2022 Energy Code Pre-Rulemaking
TN #:	235011
Document Title:	AlaJor Engineering, Inc Comments - Data Center Economizer Concerns
Description:	N/A
Filer:	System
Organization:	AlaJor Engineering, Inc
Submitter Role:	Public
Submission Date:	10/5/2020 9:37:46 AM
Docketed Date:	10/5/2020

Comment Received From: AlaJor Engineering, Inc
Submitted On: 10/5/2020
Docket Number: 19-BSTD-03

Data Center Economizer Concerns

I have the following technical concerns with the CASE Report on Nonresidential Computer Room Efficiency. First, air economizers have a 10Â°F increase in economizer temperature while all other technologies have a 25Â°F increase. Standard redundancy, structural, and system design considerations may be challenging to uphold and also meet the new requirements. Secondly, if evaporatively-cooled technology needs to be applied to meet these requirements where a basic "dry" system would have been able to be applied, water consumption will go from zero to millions of gallons per year in some cases. And finally, all of the analysis assumes 100% of the economization hours are available for an airside economizer. Unfortunately in California unsatisfactory environmental factors exist such as ocean saltwater spray, smog, and most recently smoke from fires which would decrease the hours airside economization would be viable for a data center or computer room that requires clean air for sensitive servers. Please consider these comments during your evaluation of the CASE proposal. Thank you.