| DOCKETED         |  |
|------------------|--|
| Docket Number:   | 19-BSTD-03   |
| Project Title:   | 2022 Energy Code Pre-Rulemaking  |
| TN #:            | 235085   |
| Document Title:  | Curtis Korpash - Jacobs Comments - 2022 Energy Code<br>Computer Rooms, Compressed Air Systems, and Refrigeration |
| Description:     | N/A  |
| Filer:           | System   |
| Organization:    | Curtis Korpash - Jacobs  |
| Submitter Role:  | Public   |
| Submission Date: | 10/6/2020 1:20:57 PM   |
| Docketed Date:   | 10/6/2020  |

Comment Received From: Curtis Korpash - Jacobs

Submitted On: 10/6/2020 Docket Number: 19-BSTD-03

## 2022 Energy Code Computer Rooms, Compressed Air Systems, and Refrigeration

Additional submitted attachment is included below.

From: Korpash, Curtis A.

To: <u>Energy - Docket Optical System</u>

**Subject:** docket number 19-BSTD-03 and "2022 Energy Code Computer Rooms, Compressed Air Systems, and

Refrigeration

**Date:** Tuesday, October 6, 2020 1:15:41 PM

**CAUTION:** This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

I have the following technical concerns with the CASE Report on Nonresidential Computer Room Efficiency. First, air economizers have a 10°F increase in economizer temperature while all other technologies have a 25°F increase. Standard redundancy, structural, and system design considerations may be challenging to uphold and also meet the new requirements. Secondly, if evaporatively-cooled technology needs to be applied to meet these requirements where a basic "dry" system would have been able to be applied, water consumption will go from zero to millions of gallons per year in some cases. And finally, all of the analysis assumes 100% of the economization hours are available for an airside economizer. Unfortunately in California unsatisfactory environmental factors exist such as ocean saltwater spray, smog, and most recently smoke from fires which would decrease the hours airside economization would be viable for a data center or computer room that requires clean air for sensitive servers. Please consider these comments during your evaluation of the CASE proposal.

Curtis Korpash, PE, LEED AP | Jacobs | Senior Mechanical Engineer | O:+949 224 7615 | M:+949 614 9081 | Curtis.Korpash@jacobs.com | 2600 Michelson | Irvine, Ca 92656 | USA

NOTICE - This communication may contain confidential and privileged information that is for the sole use of the intended recipient. Any viewing, copying or distribution of, or reliance on this message by unintended recipients is strictly prohibited. If you have received this message in error, please notify us immediately by replying to the message and deleting it from your computer.