DOCKETED	
Docket Number:	19-BSTD-03
Project Title:	2022 Energy Code Pre-Rulemaking
TN #:	235313
Document Title:	Daikin Applied Comments - Energy recovery
Description:	N/A
Filer:	System
Organization:	Daikin Applied
Submitter Role:	Public
Submission Date:	10/19/2020 1:02:56 PM
Docketed Date:	10/19/2020

Comment Received From: Daikin Applied Submitted On: 10/19/2020 Docket Number: 19-BSTD-03

Energy recovery

Additional submitted attachment is included below.

Daikin Applied Comments; Non-residential HVAC Controls

- Dedicated Outdoor Air Systems
- Exhaust Air Heat Recovery

These comments are submitted by Daikin Applied in response to California's proposed non-residential, HVAC controls regulations. Daikin Applied is head quartered in Plymouth, Minnesota, employs over 9000 people, and is a division of Daikin Industries.

- Harmonization or at least good alignment with ASHRAE 90.1 is very important.
- The new proposal specifies minimum recovery ratio at "full flow cooling design conditions." We assume that full flow cooling design airflow is not the same as "150% of the sum of the outdoor airflow rate to each zone as specified in Section 120.1c3" because the 150% airflow should only occur during economizer operation.

Thank you for considering Daikin Applied comments. Please contact me if you have any questions.

Henry [Skip] Ernst

Trade Association and Regulations ManagerDaikin Applied13600 Industrial Park Blvd.Plymouth, Mn. 55441763-553-5017henry.ernst@daikinapplied.com