

DOCKETED

Docket Number:	06-AFC-09C
Project Title:	Colusa Generating Station - Compliance
TN #:	235635-2
Document Title:	2020 3rd QTR QOR
Description:	Quarterly Operating Report
Filer:	Anthony TJ Gomez
Organization:	Pacific Gas and Electric
Submitter Role:	Applicant
Submission Date:	11/17/2020 9:35:20 AM
Docketed Date:	11/17/2020

ATTACHMENT 1

Complaints


FCD: AQ-5

Title V: #5

During the third quarter of 2020, there were no complaints issued from the public for the Colusa Generating Station. The site continues to be available for inspection by representatives of the CCAPCD and the CEC.

ATTACHMENT 2
Fuel Quality Data

FCD: AQ-10 & 11
Title V: #16



Atmospheric Analysis & Consulting, Inc.

CLIENT : PG&E
PROJECT NAME : Natural Gas Sampling
AAC PROJECT NO. : 201246
REPORT DATE : 07/20/2020

On July 16, 2020, Atmospheric Analysis & Consulting, Inc. received one (1) 1.4-Liter Silonite Canister for Total Reduced Sulfur analysis by ASTM D-5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:


Client ID	Lab No.	Return Pressure (mmHg)
HBPP-GS-JUL-A	201246-10111	675.0

This analysis is performed in accordance with AAC's Quality Manual. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample.


The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.


Sucha Parmar, Ph.D.
Technical Director

This report consists of 5 pages.





Atmospheric Analysis & Consulting, Inc.

LABORATORY ANALYSIS REPORT


CLIENT : PG&E
PROJECT NO. : 201246
MATRIX : AIR
UNITS : ppmV

SAMPLING DATE : 07/15/2020
RECEIVING DATE : 07/16/2020
ANALYSIS DATE : 07/16/2020
REPORT DATE : 07/20/2020


Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	HBPP-GS-JUL-A
AAC ID	201246-10111
Canister Dil. Fac.	2.3
Analyte	Result
Hydrogen Sulfide	1.09
COS / SO ₂	0.995
Methyl Mercaptan	< 0.114
Ethyl Mercaptan	< 0.114
Dimethyl Sulfide	0.308
Carbon Disulfide	< 0.114
Isopropyl Mercaptan	< 0.114
tert-Butyl Mercaptan	0.766
n-Propyl Mercaptan	< 0.114
Methylethylsulfide	< 0.114
sec-Butyl Mercaptan / Thiophene	< 0.114
iso-Butyl Mercaptan	< 0.114
Diethyl Sulfide	< 0.114
n-Butyl Mercaptan	< 0.114
Dimethyl Disulfide	< 0.114
2-Methylthiophene	< 0.114
3-Methylthiophene	< 0.114
Tetrahydrothiophene	0.989
Bromothiophene	< 0.114
Thiophenol	< 0.114
Diethyl Disulfide	< 0.114
Total Unidentified Sulfur	0.170
Total Reduced Sulfurs	3.32
Total Sulfurs	4.32

All unidentified compound's concentrations expressed in terms of H₂S (TRS does not include COS and SO₂)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.


Sucha Parmar, Ph.D.
Technical Director





Atmospheric Analysis & Consulting, Inc.

LABORATORY ANALYSIS REPORT


CLIENT : PG&E
PROJECT NO. : 201246
MATRIX : AIR
UNITS : grains/100 dscf

SAMPLING DATE : 07/15/2020
RECEIVING DATE : 07/16/2020
ANALYSIS DATE : 07/16/2020
REPORT DATE : 07/20/2020


Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	HBPP-GS-JUL-A
AAC ID	201246-10111
Canister Dil. Fac.	2.3
Analyte	Result
Hydrogen Sulfide	0.06644
COS / SO ₂	0.06060
Methyl Mercaptan	< 0.00694
Ethyl Mercaptan	< 0.00694
Dimethyl Sulfide	0.01874
Carbon Disulfide	< 0.00694
Isopropyl Mercaptan	< 0.00694
tert-Butyl Mercaptan	0.04667
n-Propyl Mercaptan	< 0.00694
Methylethylsulfide	< 0.00694
sec-Butyl Mercaptan / Thiophene	< 0.00694
iso-Butyl Mercaptan	< 0.00694
Diethyl Sulfide	< 0.00694
n-Butyl Mercaptan	< 0.00694
Dimethyl Disulfide	< 0.00694
2-Methylthiophene	< 0.00694
3-Methylthiophene	< 0.00694
Tetrahydrothiophene	0.06024
Bromothiophene	< 0.00694
Thiophenol	< 0.00694
Diethyl Disulfide	< 0.00694
Total Unidentified Sulfur	0.01038
Total Reduced Sulfurs	0.20248
Total Sulfurs	0.26308

All unidentified compound's concentrations expressed in terms of H₂S (TRS does not include COS and SO₂)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.


Sucha Parmar, Ph.D.
Technical Director





Atmospheric Analysis & Consulting, Inc.

Quality Control/Quality Assurance Report ASTM D-5504

Date Analyzed: 7/16/2020
Analyst: DL
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 7/1/2020

Opening Calibration Verification Standard

523.0 ppbV H₂S (SSI192)

H ₂ S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	5362	513	98.1	0.3
Duplicate	5437	520	99.5	1.7
Triplicate	5235	501	95.8	2.1

547.5 ppbV H₂S (SSI192)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	6493	548	100.2	0.7
Duplicate	6476	547	99.9	0.5
Triplicate	6370	538	98.3	1.2

535.8 ppbV H₂S (SSI192)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	7089	545	101.8	0.8
Duplicate	7129	548	102.4	1.4
Triplicate	6872	529	98.7	2.2

Method Blank

Analyte	Result
H ₂ S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis

Sample ID 201223-10026

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H ₂ S	<PQL	<PQL	0.0	0.0
MeSH	<PQL	<PQL	0.0	0.0
DMS	<PQL	<PQL	0.0	0.0

Matrix Spike & Duplicate

Sample ID 201223-10026 x10

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H ₂ S	<PQL	261.5	248.2	246.1	94.9	94.1	0.8
MeSH	<PQL	273.8	262.1	258.8	95.7	94.5	1.3
DMS	<PQL	267.9	273.2	271.3	102.0	101.3	0.7

Closing Calibration Verification Standard


Analyte	Std. Conc.	Result	% Rec **
H ₂ S	523.0	499.3	95.5
MeSH	547.5	530.6	96.9
DMS	535.8	521.0	97.2

* Must be 95-105%, ** Must be 90-110%, *** Must be <10%, **** Must be <5% RPD from Mean result.

H₂S: PQL = 10.0 ppbV, MDL = 1.60 ppbV

MeSH: PQL = 10.0 ppbV, MDL = 1.60 ppbV

DMS: PQL = 10.0 ppbV, MDL = 1.60 ppbV


 Sucha Parmar, Ph.D.
 Technical Director



201246

Colusa Fuel Gas Sampling

Client PG&E Environmental Services	Project Manager Surrinder Sidhu	Date 7/15/20	Preparation and Analysis
Address 3400 Crow Canyon Road	Telephone Number 925-866-5245	Laboratory AAC Labs	
City San Ramon	State CA	Laboratory Phone 805-650-1642	
Project Number/Name Natural Gas Sampling	Site Contact Steve North	Laboratory/Fax 94583	

Contract Number: PO Number: Laboratory Contact: Eric Grosjean - 1594 Eastman Ave. Suite A Ventura, CA 93003

PG&E Sample ID	SAMI-ID#	Date	Time	Sample Type	Containers			Preservative	Condition on Receipt/Comments	Sulfur ASTM D-5504
					Volume	Type	No.			
HBPP-GS-JUL-A	10111	7/15/20	1500	Gas	1 liter	cyl	1	None		X
CPP-GS-JUL-A	10111									

Special Instruction: Email results to Surrinder Sidhu (SKSG@PGE.COM), Eyan Cavalli (EMCM@PGE.COM), A.J. Gomez (AJGU@PGE.COM)

Turn Around Time Required

Normal Rush Other


QC Level: I, II, III

1. Relinquished By Steve North	Date 7/15/20	Time 17:15	1. Received By	Date	Time
2. Relinquished By VP5	Date	Time	2. Received By	Date	Time
3. Relinquished By	Date	Time	3. Received By	Date	Time

Project Specific Requirements (Specify)

Sample collected in 3L Tedlar bag and immediately field transferred to evacuated 1L mini-can onsite.

* Sample ID was changed from HBPP-GS-JUL-A to CPP-GS-JUL-A
 VP5 1x 1.14 L
 8/8 07/22/2020



Atmospheric Analysis & Consulting, Inc.

CLIENT : PG&E
PROJECT NAME : Natural Gas Sampling
AAC PROJECT NO. : 201414
REPORT DATE : 08/12/2020

On August 7, 2020, Atmospheric Analysis & Consulting, Inc. received one (1) 1.0-Liter Silonite Canister for Total Reduced Sulfur analysis by ASTM D-5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:


Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-AUG-A	201414-10975	688.2

This analysis is performed in accordance with AAC's Quality Manual. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample.


The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.


Sucha Parmar, Ph.D.
Technical Director

This report consists of 5 pages.





Atmospheric Analysis & Consulting, Inc.

LABORATORY ANALYSIS REPORT


CLIENT : PG&E
PROJECT NO. : 201414
MATRIX : AIR
UNITS : ppmV

SAMPLING DATE : 08/05/2020
RECEIVING DATE : 08/07/2020
ANALYSIS DATE : 08/11/2020
REPORT DATE : 08/12/2020


Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-AUG-A
AAC ID	201414-10975
Canister Dil. Fac.	2.2
Analyte	Result
Hydrogen Sulfide	0.812
COS / SO ₂	0.686
Methyl Mercaptan	0.116
Ethyl Mercaptan	< 0.112
Dimethyl Sulfide	< 0.112
Carbon Disulfide	< 0.112
Isopropyl Mercaptan	< 0.112
tert-Butyl Mercaptan	0.989
n-Propyl Mercaptan	< 0.112
Methylethylsulfide	< 0.112
sec-Butyl Mercaptan / Thiophene	< 0.112
iso-Butyl Mercaptan	< 0.112
Diethyl Sulfide	< 0.112
n-Butyl Mercaptan	< 0.112
Dimethyl Disulfide	< 0.112
2-Methylthiophene	< 0.112
3-Methylthiophene	< 0.112
Tetrahydrothiophene	1.13
Bromothiophene	< 0.112
Thiophenol	< 0.112
Diethyl Disulfide	< 0.112
Total Unidentified Sulfur	< 0.112
Total Reduced Sulfurs	3.05
Total Sulfurs	3.74

All unidentified compound's concentrations expressed in terms of H₂S (TRS does not include COS and SO₂)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.


Sucha Parmar, Ph.D.
Technical Director





Atmospheric Analysis & Consulting, Inc.

LABORATORY ANALYSIS REPORT


CLIENT : PG&E
PROJECT NO. : 201414
MATRIX : AIR
UNITS : grains/100 dscf

SAMPLING DATE : 08/05/2020
RECEIVING DATE : 08/07/2020
ANALYSIS DATE : 08/11/2020
REPORT DATE : 08/12/2020


Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-AUG-A
AAC ID	201414-10975
Canister Dil. Fac.	2.2
Analyte	Result
Hydrogen Sulfide	0.04948
COS / SO ₂	0.04177
Methyl Mercaptan	0.00706
Ethyl Mercaptan	< 0.00681
Dimethyl Sulfide	< 0.00681
Carbon Disulfide	< 0.00681
Isopropyl Mercaptan	< 0.00681
tert-Butyl Mercaptan	0.06022
n-Propyl Mercaptan	< 0.00681
Methylethylsulfide	< 0.00681
sec-Butyl Mercaptan / Thiophene	< 0.00681
iso-Butyl Mercaptan	< 0.00681
Diethyl Sulfide	< 0.00681
n-Butyl Mercaptan	< 0.00681
Dimethyl Disulfide	< 0.00681
2-Methylthiophene	< 0.00681
3-Methylthiophene	< 0.00681
Tetrahydrothiophene	0.06913
Bromothiophene	< 0.00681
Thiophenol	< 0.00681
Diethyl Disulfide	< 0.00681
Total Unidentified Sulfur	< 0.00681
Total Reduced Sulfurs	0.18590
Total Sulfurs	0.22767

All unidentified compound's concentrations expressed in terms of H₂S (TRS does not include COS and SO₂)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.


Sucha Parmar, Ph.D.
Technical Director





Atmospheric Analysis & Consulting, Inc.

Quality Control/Quality Assurance Report ASTM D-5504

Date Analyzed: 8/11/2020
Analyst: DL
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 7/1/2020

Opening Calibration Verification Standard

523.0 ppbV H₂S (SSI192)

H ₂ S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	5269	504	96.4	0.9
Duplicate	5208	498	95.3	0.3
Triplicate	5194	497	95.1	0.6

547.3 ppbV H₂S (SSI192)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	6279	530	96.9	0.5
Duplicate	6248	528	96.4	0.0
Triplicate	6223	526	96.0	0.4

535.8 ppbV H₂S (SSI192)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	6809	524	97.8	0.9
Duplicate	6699	515	96.2	0.8
Triplicate	6741	519	96.8	0.1

Method Blank

Analyte	Result
H ₂ S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis

Sample ID 201414-10975

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H ₂ S	360.5	366.0	363.3	1.5
MeSH	51.6	52.1	51.9	1.0
DMS	<PQL	<PQL	0.0	0.0

Matrix Spike & Duplicate

Sample ID 201414-10975 x10

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H ₂ S	36.3	261.5	278.4	288.4	93.5	96.8	3.5
MeSH	5.2	273.8	253.1	252.9	90.7	90.7	0.0
DMS	<PQL	267.9	251.2	254.6	93.8	95.1	1.3

Closing Calibration Verification Standard


Analyte	Std. Conc.	Result	% Rec **
H ₂ S	523.0	546.1	104.4
MeSH	547.5	526.9	96.2
DMS	535.8	510.2	95.2

* Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.

H₂S: PQL = 10.0 ppbV, MDL = 1.60 ppbV

MeSH: PQL = 10.0 ppbV, MDL = 1.60 ppbV

DMS: PQL = 10.0 ppbV, MDL = 1.60 ppbV


 Sucha Parmar, Ph.D.
 Technical Director



201414

Colusa Fuel Gas Sampling

Client: PG&E Environmental Services

Address: 3400 Crow Canyon Road

City: San Ramon State: CA Zip: 94583

Project Number/Name: Natural Gas Sampling

Contract Number, PO Number: Eric Grosjean - 1534 Eastman Ave. Suite A Ventura CA 93003

Project Manager: Surinder Sidhu

Telephone Number: 925-866-5245

Site Contact: Steve North

Site Contact: Steve North 925-785-3039

Site Contact: Email: SKSG@pge.com

Laboratory: AAC Labs

Laboratory Phone: 805-650-1642

Laboratory Fax: 805-650-1642

Preparation and Analysis

PG&E Sample ID: CPP-GS-ANK6-A

SAM#-ID#

Date: 8/5/20

Time: 1530

Sample Type: Gas

Volume: 1 liter

Type: cyl

No.: 1

Preservative: None

Condition on Receipt/Comments: 10975

Sulfur ASTM D-5504

Special Instruction: Email results to Surinder Sidhu (SKSG@PGE.COM), Evan Cavalli (EMCM@PGE.COM), A.J. Gomez (AJGU@PGE.COM)

Turn Around Time Required

Normal Rush Other

QC Level: I, II, III

Project Specific Requirements (Specify)

1. Relinquished By: Steve North

Date: 8/5/20

Time: 1730

Received By: [Signature]

Date: 8/11/20

Time: 0919

2. Relinquished By

Date

Time

3. Relinquished By


Date

Time

Comments

Sample collected in 3L Tedlar bag and immediately field transferred to evacuated 1L mini-can onsite.

Client returned 1.0L siliconite can



Atmospheric Analysis & Consulting, Inc.

CLIENT : PG&E
PROJECT NAME : Natural Gas Sampling
AAC PROJECT NO. : 201630
REPORT DATE : 09/16/2020

On September 10, 2020, Atmospheric Analysis & Consulting, Inc. received one (1) 1.0-Liter Silonite Canister for Total Reduced Sulfur analysis by ASTM D-5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:


Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-SEP-A	201630-12225	717.6

This analysis is performed in accordance with AAC's Quality Manual. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample.


The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.


Sucha Parmar, Ph.D.
Technical Director

This report consists of 5 pages.





Atmospheric Analysis & Consulting, Inc.

LABORATORY ANALYSIS REPORT


CLIENT : PG&E
PROJECT NO. : 201630
MATRIX : AIR
UNITS : ppmV

SAMPLING DATE : 09/08/2020
RECEIVING DATE : 09/10/2020
ANALYSIS DATE : 09/10/2020
REPORT DATE : 09/16/2020


Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-SEP-A
AAC ID	201630-12225
Canister Dil. Fac.	2.2
Analyte	Result
Hydrogen Sulfide	0.703
COS / SO ₂	0.398
Methyl Mercaptan	< 0.109
Ethyl Mercaptan	< 0.109
Dimethyl Sulfide	< 0.109
Carbon Disulfide	< 0.109
Isopropyl Mercaptan	< 0.109
tert-Butyl Mercaptan	0.781
n-Propyl Mercaptan	< 0.109
Methylethylsulfide	< 0.109
sec-Butyl Mercaptan / Thiophene	< 0.109
iso-Butyl Mercaptan	< 0.109
Diethyl Sulfide	< 0.109
n-Butyl Mercaptan	< 0.109
Dimethyl Disulfide	< 0.109
2-Methylthiophene	< 0.109
3-Methylthiophene	< 0.109
Tetrahydrothiophene	0.805
Bromothiophene	< 0.109
Thiophenol	< 0.109
Diethyl Disulfide	< 0.109
Total Unidentified Sulfur	< 0.109
Total Reduced Sulfurs	2.29
Total Sulfurs	2.69

All unidentified compound's concentrations expressed in terms of H₂S (TRS does not include COS and SO₂)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.


Sucha Parmar, Ph.D.
Technical Director





Atmospheric Analysis & Consulting, Inc.

LABORATORY ANALYSIS REPORT


CLIENT : PG&E
PROJECT NO. : 201630
MATRIX : AIR
UNITS : grains/100 dscf

SAMPLING DATE : 09/08/2020
RECEIVING DATE : 09/10/2020
ANALYSIS DATE : 09/10/2020
REPORT DATE : 09/16/2020


Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-SEP-A
AAC ID	201630-12225
Canister Dil. Fac.	2.2
Analyte	Result
Hydrogen Sulfide	0.04280
COS / SO ₂	0.02421
Methyl Mercaptan	< 0.00663
Ethyl Mercaptan	< 0.00663
Dimethyl Sulfide	< 0.00663
Carbon Disulfide	< 0.00663
Isopropyl Mercaptan	< 0.00663
tert-Butyl Mercaptan	0.04756
n-Propyl Mercaptan	< 0.00663
Methylethylsulfide	< 0.00663
sec-Butyl Mercaptan / Thiophene	< 0.00663
iso-Butyl Mercaptan	< 0.00663
Diethyl Sulfide	< 0.00663
n-Butyl Mercaptan	< 0.00663
Dimethyl Disulfide	< 0.00663
2-Methylthiophene	< 0.00663
3-Methylthiophene	< 0.00663
Tetrahydrothiophene	0.04900
Bromothiophene	< 0.00663
Thiophenol	< 0.00663
Diethyl Disulfide	< 0.00663
Total Unidentified Sulfur	< 0.00663
Total Reduced Sulfurs	0.13936
Total Sulfurs	0.16357

All unidentified compound's concentrations expressed in terms of H₂S (TRS does not include COS and SO₂)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.


Sucha Parmar, Ph.D.
Technical Director





Atmospheric Analysis & Consulting, Inc.

Quality Control/Quality Assurance Report ASTM D-5504

Date Analyzed: 9/10/2020
Analyst: DL
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 9/9/2020

Opening Calibration Verification Standard

576.8 ppbV H₂S (SS1227)

H ₂ S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	5753	548	95.1	1.0
Duplicate	5868	559	97.0	1.0
Triplicate	5817	555	96.2	0.1

573.3 ppbV H₂S (SS1227)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	6700	575	100.4	0.2
Duplicate	6864	590	102.8	2.2
Triplicate	6584	566	98.6	2.0

509.8 ppbV H₂S (SS1227)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	7101	522	102.4	0.4
Duplicate	7153	526	103.2	1.2
Triplicate	6956	512	100.3	1.6

Method Blank

Analyte	Result
H ₂ S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis

Sample ID 201573-11924

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H ₂ S	<PQL	<PQL	0.0	0.0
MeSH	<PQL	<PQL	0.0	0.0
DMS	<PQL	<PQL	0.0	0.0

Matrix Spike & Duplicate

Sample ID 201573-11924 x10

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H ₂ S	<PQL	288.4	276.5	282.4	95.9	97.9	2.1
MeSH	<PQL	286.6	275.9	280.5	96.3	97.8	1.6
DMS	<PQL	254.9	247.9	254.9	97.3	100.0	2.8

Closing Calibration Verification Standard


Analyte	Std. Conc.	Result	% Rec **
H ₂ S	576.8	561.5	97.4
MeSH	573.3	569.4	99.3
DMS	509.8	510.0	100.0

* Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.

H₂S: PQL = 10.0 ppbV, MDL = 1.60 ppbV

MeSH: PQL = 10.0 ppbV, MDL = 1.60 ppbV

DMS: PQL = 10.0 ppbV, MDL = 1.60 ppbV


 Sucha Parmar, Ph.D.
 Technical Director



2020 Monthly Sulfur Content - Colusa Generating Station

All Units in Grains of Sulfur per 100 Standard Cubic Foot

Month	Jan-20	Feb-20	Mar-20	Apr-20	May-20	Jun-20	Jul-20	Aug-20	Sep-20	Oct-20	Nov-20	Dec-20	Avg
Gr/100SCF	0.296	0.377	0.316	0.141	0.316	0.248	0.263	0.227	0.163				0.261

Permit Limits:

0.75 Grains/100SCF per Month (PSD Condition X.I.4); 0.3 Grains/100SCF Annual Average (Title V # 16)

ATTACHMENT 3
40 CFR 60 Section KKKK

FCD: AQ-13
Title V: #8, 9, 25, 25, 30

40 CFR 60 KKKK Emission Limits:

Natural Gas Fired Combustion Turbine > 850 MMBtu

15 ppmvdc @ 15% O₂; 4 Hour Rolling Average

During Normal Operations

96 ppmvdc @ 15% O₂; 4 Hour Rolling Average

Turbines operating at less than 75% of Peak Load
(Startup/Shutdown)

KKKK Compliance (Colusa Generating Station)

40 CFR Part 60 Subpart KKKK applies to all stationary gas turbines rated at greater than or equal to 10 MMBtu/hr that commence construction, modification, or reconstruction after February 18, 2005. The gas turbines involved in this project have a rating of 1612 MMBtu/hr and were installed after February 18, 2005, therefore, this subpart applies.

Compliance with the applicable provisions of NSPS KKKK are summarized below. Specific data to support the compliance determinations listed below are included as attachments. The non-applicable portions of KKKK are not listed in the compliance summary:

Section	Requirement	Compliance Status
60.4305	CGS Turbines/HRSGs rated at larger than 10 MMBtu/hr and construction commenced after February 18, 2005. Subpart KKKK applies.	IN COMPLIANCE
60.4310	No exemptions apply.	No exemptions apply.
60.4315	Pollutants regulated under Subpart KKKK: NO _x and SO ₂ .	IN COMPLIANCE
60.4320	NO _x emissions limit: 15 ppmv @15% O ₂	IN COMPLIANCE
60.4330	SO ₂ emissions limit: 0.90 lbs SO ₂ /MWh (gross output), or cannot burn any fuel which contains total potential sulfur emissions in excess of 0.060 lbs SO ₂ /MMBtu (heat input).	IN COMPLIANCE Based on monthly fuel sampling.
60.4333	Operate turbine/HRSG, APC systems, and monitoring equipment to minimize emissions at all times including during startup, shutdown, and malfunction.	IN COMPLIANCE
60.4340(b)(1)	For units with SCR, install a NO _x CEMS per 60.4335(b) or 60.4345. If Part 75 applies, NO _x can be monitored per Appendix E of Part 75. (CGS QAP applies here)	IN COMPLIANCE CT1 and CT2 utilize SCR and NO _x CEMS per 60.4335(b) or 60.4345. Part 75 applies and NO _x is monitored per Appendix E of Part 75.
60.4345	Meet all CEMS Performance Specs and develop a QA Plan for the CEMS. (CGS QAP applies here)	IN COMPLIANCE
60.4350	All CEMS data must be reduced to hourly averages per 60.13(h). (CGS QAP applies here)	IN COMPLIANCE

60.4355	If applicable, develop and insure all parametric monitoring and monitoring plans comply with this section. (CGS QAP applies here)	IN COMPLIANCE
60.4360	Monitor fuel sulfur content, or invoke exemption per 60.4365.	Exemption per 60.4365
60.4365	Exemption for fuel sulfur monitoring if fuel is demonstrated not to exceed potential sulfur emissions of 0.060 lb SO ₂ /MMBtu. Use PG&E gas quality data to show that exemption applies per 60.4365 (a) or (b).	IN COMPLIANCE Pipeline quality natural gas used with sulfur content less than 0.30 gr/100 SCF (0.0008 lb/MMBtu as SO ₂). Annual compliance based on PG&E supplied fuel analysis data. See Attachment 2.
60.4375	Submit excess emissions reports per 60.7(c). Within 30 days following the end of each 6 month period (see 60.4395).	IN COMPLIANCE
60.4380(b)	Determine excess emissions and monitor downtime per (b) (1-3)	IN COMPLIANCE See Attachment 4.
60.4400	Initial and annual NO _x performance tests not required if CEMS used per 60.4340(b)(1)	IN COMPLIANCE NO _x CEMS used per 60.4340(b)(1). NO _x , CO, and VOC tested annually.
60.4415	Perform initial SO ₂ performance test per 60.4415 (2) or (3). This test must be conducted even if the 60.4365 exemption is invoked.	IN COMPLIANCE Initial SO ₂ source test performed in 2010; results available upon request. Ongoing compliance determined by fuel sampling (60.4415(a)(1)(ii)).

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/01/2020 00:00	1	1
07/01/2020 01:00	1	1
07/01/2020 02:00	1	1
07/01/2020 03:00	1	1
07/01/2020 04:00	1	1
07/01/2020 05:00	1	1
07/01/2020 06:00	1	1
07/01/2020 07:00	1	1
07/01/2020 08:00	1	1
07/01/2020 09:00	1	1
07/01/2020 10:00	1	1
07/01/2020 11:00	1	1
07/01/2020 12:00	1	1
07/01/2020 13:00	1	1
07/01/2020 14:00	1	1
07/01/2020 15:00	1	1
07/01/2020 16:00	1	1
07/01/2020 17:00	1	1
07/01/2020 18:00	1	1
07/01/2020 19:00	1	1
07/01/2020 20:00	1	1
07/01/2020 21:00	1	1
07/01/2020 22:00	1	1
07/01/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/02/2020 00:00	1	1
07/02/2020 01:00	1	1
07/02/2020 02:00	1	1
07/02/2020 03:00	1	1
07/02/2020 04:00	1	1
07/02/2020 05:00	1	1
07/02/2020 06:00	1	1
07/02/2020 07:00	1	1
07/02/2020 08:00	1	1
07/02/2020 09:00	1	1
07/02/2020 10:00	1	1
07/02/2020 11:00	1	1
07/02/2020 12:00	1	1
07/02/2020 13:00	1	1
07/02/2020 14:00	1	1
07/02/2020 15:00	1	1
07/02/2020 16:00	1	1
07/02/2020 17:00	1	1
07/02/2020 18:00	1	1
07/02/2020 19:00	1	1
07/02/2020 20:00	1	1
07/02/2020 21:00	1	1
07/02/2020 22:00	1	1
07/02/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/03/2020 00:00	1	1
07/03/2020 01:00	1	1
07/03/2020 02:00	1	1
07/03/2020 03:00	1	1
07/03/2020 04:00	1	1
07/03/2020 05:00	1	1
07/03/2020 06:00	1	1
07/03/2020 07:00	1	1
07/03/2020 08:00	1	13
07/03/2020 09:00	1	17
07/03/2020 10:00	1	19
07/03/2020 11:00	1	19
07/03/2020 12:00	1	7
07/03/2020 13:00	14	2
07/03/2020 14:00	17	1
07/03/2020 15:00	17	1
07/03/2020 16:00	17	1
07/03/2020 17:00	4	1
07/03/2020 18:00	1	1
07/03/2020 19:00	1	1
07/03/2020 20:00	1	1
07/03/2020 21:00	1	1
07/03/2020 22:00	1	1
07/03/2020 23:00	1	1
Average/Sum#:	4	4
Minimum:	1	1
Maximum:	17	19
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/04/2020 00:00	1	1
07/04/2020 01:00	1	1
07/04/2020 02:00	1	1
07/04/2020 03:00	1	1
07/04/2020 04:00	1	1
07/04/2020 05:00	1	1
07/04/2020 06:00	1	1
07/04/2020 07:00	1	1
07/04/2020 08:00	1	1
07/04/2020 09:00	1	1
07/04/2020 10:00	1	1
07/04/2020 11:00	1	1
07/04/2020 12:00	1	1
07/04/2020 13:00	1	1
07/04/2020 14:00	1	1
07/04/2020 15:00	1	1
07/04/2020 16:00	1	1
07/04/2020 17:00	1	1
07/04/2020 18:00	1	1
07/04/2020 19:00	1	1
07/04/2020 20:00	1	1
07/04/2020 21:00	1	1
07/04/2020 22:00	1	1
07/04/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/05/2020 00:00	1	1
07/05/2020 01:00	1	1
07/05/2020 02:00	1	1
07/05/2020 03:00	1	1
07/05/2020 04:00	1	1
07/05/2020 05:00	1	1
07/05/2020 06:00	1	1
07/05/2020 07:00	1	1
07/05/2020 08:00	1	1
07/05/2020 09:00	1	15
07/05/2020 10:00	1	19
07/05/2020 11:00	1	23
07/05/2020 12:00	1	23
07/05/2020 13:00	1	9
07/05/2020 14:00	15	5
07/05/2020 15:00	19	1
07/05/2020 16:00	19	1
07/05/2020 17:00	19	1
07/05/2020 18:00	4	1
07/05/2020 19:00	1	1
07/05/2020 20:00	1	1
07/05/2020 21:00	1	1
07/05/2020 22:00	1	1
07/05/2020 23:00	1	1
Average/Sum#:	4	5
Minimum:	1	1
Maximum:	19	23
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/06/2020 00:00	1	1
07/06/2020 01:00	1	1
07/06/2020 02:00	1	2
07/06/2020 03:00	1	3
07/06/2020 04:00	1	3
07/06/2020 05:00	1	2
07/06/2020 06:00	1	2
07/06/2020 07:00	1	1
07/06/2020 08:00	1	1
07/06/2020 09:00	1	1
07/06/2020 10:00	1	1
07/06/2020 11:00	10	1
07/06/2020 12:00	14	1
07/06/2020 13:00	14	1
07/06/2020 14:00	13	1
07/06/2020 15:00	4	1
07/06/2020 16:00	1	1
07/06/2020 17:00	1	1
07/06/2020 18:00	1	1
07/06/2020 19:00	1	1
07/06/2020 20:00	1	1
07/06/2020 21:00	1	1
07/06/2020 22:00	1	1
07/06/2020 23:00	1	1
Average/Sum#:	3	1
Minimum:	1	1
Maximum:	14	3
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/07/2020 00:00	1	1
07/07/2020 01:00	1	1
07/07/2020 02:00	1	1
07/07/2020 03:00	1	1
07/07/2020 04:00	1	1
07/07/2020 05:00	1	1
07/07/2020 06:00	1	1
07/07/2020 07:00	1	1
07/07/2020 08:00	1	1
07/07/2020 09:00	1	1
07/07/2020 10:00	1	1
07/07/2020 11:00	1	1
07/07/2020 12:00	1	1
07/07/2020 13:00	1	1
07/07/2020 14:00	1	1
07/07/2020 15:00	1	1
07/07/2020 16:00	1	1
07/07/2020 17:00	1	1
07/07/2020 18:00	1	1
07/07/2020 19:00	1	1
07/07/2020 20:00	1	1
07/07/2020 21:00	1	1
07/07/2020 22:00	1	1
07/07/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/08/2020 00:00	1	1
07/08/2020 01:00	1	1
07/08/2020 02:00	1	1
07/08/2020 03:00	1	1
07/08/2020 04:00	1	1
07/08/2020 05:00	1	1
07/08/2020 06:00	1	1
07/08/2020 07:00	1	1
07/08/2020 08:00	1	1
07/08/2020 09:00	1	1
07/08/2020 10:00	1	1
07/08/2020 11:00	1	1
07/08/2020 12:00	1	1
07/08/2020 13:00	1	1
07/08/2020 14:00	1	1
07/08/2020 15:00	1	1
07/08/2020 16:00	1	1
07/08/2020 17:00	1	1
07/08/2020 18:00	1	1
07/08/2020 19:00	1	1
07/08/2020 20:00	1	1
07/08/2020 21:00	1	1
07/08/2020 22:00	1	1
07/08/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc 1 Hour(s)	NOx_4Hr, Ppmvdc 1 Hour(s)
07/09/2020 00:00	1	1
07/09/2020 01:00	1	1
07/09/2020 02:00	1	1
07/09/2020 03:00	1	1
07/09/2020 04:00	1	1
07/09/2020 05:00	1	1
07/09/2020 06:00	1	1
07/09/2020 07:00	1	1
07/09/2020 08:00	1	1
07/09/2020 09:00	1	1
07/09/2020 10:00	1	1
07/09/2020 11:00	1	1
07/09/2020 12:00	1	1
07/09/2020 13:00	1	1
07/09/2020 14:00	1	1
07/09/2020 15:00	1	1
07/09/2020 16:00	1	1
07/09/2020 17:00	1	1
07/09/2020 18:00	1	1
07/09/2020 19:00	1	1
07/09/2020 20:00	1	1
07/09/2020 21:00	1	1
07/09/2020 22:00	1	1
07/09/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/10/2020 00:00	1	1
07/10/2020 01:00	1	1
07/10/2020 02:00	1	1
07/10/2020 03:00	1	1
07/10/2020 04:00	1	1
07/10/2020 05:00	1	1
07/10/2020 06:00	1	1
07/10/2020 07:00	1	1
07/10/2020 08:00	1	1
07/10/2020 09:00	1	1
07/10/2020 10:00	1	1
07/10/2020 11:00	1	1
07/10/2020 12:00	1	1
07/10/2020 13:00	1	1
07/10/2020 14:00	1	1
07/10/2020 15:00	1	1
07/10/2020 16:00	1	1
07/10/2020 17:00	1	1
07/10/2020 18:00	1	1
07/10/2020 19:00	1	1
07/10/2020 20:00	1	1
07/10/2020 21:00	1	1
07/10/2020 22:00	1	1
07/10/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/11/2020 00:00	1	1
07/11/2020 01:00	1	1
07/11/2020 02:00	1	1
07/11/2020 03:00	1	1
07/11/2020 04:00	1	1
07/11/2020 05:00	1	1
07/11/2020 06:00	1	1
07/11/2020 07:00	1	1
07/11/2020 08:00	1	1
07/11/2020 09:00	1	1
07/11/2020 10:00	1	1
07/11/2020 11:00	1	1
07/11/2020 12:00	1	1
07/11/2020 13:00	1	1
07/11/2020 14:00	1	1
07/11/2020 15:00	1	1
07/11/2020 16:00	1	1
07/11/2020 17:00	1	1
07/11/2020 18:00	1	1
07/11/2020 19:00	1	1
07/11/2020 20:00	1	1
07/11/2020 21:00	1	1
07/11/2020 22:00	1	1
07/11/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/12/2020 00:00	1	1
07/12/2020 01:00	1	1
07/12/2020 02:00	1	1
07/12/2020 03:00	1	1
07/12/2020 04:00	1	1
07/12/2020 05:00	1	1
07/12/2020 06:00	1	1
07/12/2020 07:00	1	1
07/12/2020 08:00	1	1
07/12/2020 09:00	1	1
07/12/2020 10:00	1	1
07/12/2020 11:00	1	1
07/12/2020 12:00	1	1
07/12/2020 13:00	1	1
07/12/2020 14:00	1	1
07/12/2020 15:00	1	1
07/12/2020 16:00	1	1
07/12/2020 17:00	1	1
07/12/2020 18:00	1	1
07/12/2020 19:00	1	1
07/12/2020 20:00	1	1
07/12/2020 21:00	1	1
07/12/2020 22:00	1	1
07/12/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/13/2020 00:00	1	1
07/13/2020 01:00	1	1
07/13/2020 02:00	1	1
07/13/2020 03:00	1	1
07/13/2020 04:00	1	1
07/13/2020 05:00	1	1
07/13/2020 06:00	1	1
07/13/2020 07:00	1	1
07/13/2020 08:00	1	1
07/13/2020 09:00	1	1
07/13/2020 10:00	1	1
07/13/2020 11:00	1	1
07/13/2020 12:00	1	1
07/13/2020 13:00	1	1
07/13/2020 14:00	1	1
07/13/2020 15:00	1	1
07/13/2020 16:00	1	1
07/13/2020 17:00	1	1
07/13/2020 18:00	1	1
07/13/2020 19:00	1	1
07/13/2020 20:00	1	1
07/13/2020 21:00	1	1
07/13/2020 22:00	1	1
07/13/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/14/2020 00:00	1	1
07/14/2020 01:00	1	1
07/14/2020 02:00	1	1
07/14/2020 03:00	1	1
07/14/2020 04:00	1	1
07/14/2020 05:00	1	1
07/14/2020 06:00	1	1
07/14/2020 07:00	1	1
07/14/2020 08:00	1	1
07/14/2020 09:00	1	1
07/14/2020 10:00	1	1
07/14/2020 11:00	1	1
07/14/2020 12:00	1	1
07/14/2020 13:00	1	1
07/14/2020 14:00	1	1
07/14/2020 15:00	1	1
07/14/2020 16:00	1	1
07/14/2020 17:00	1	1
07/14/2020 18:00	1	1
07/14/2020 19:00	1	1
07/14/2020 20:00	1	1
07/14/2020 21:00	1	1
07/14/2020 22:00	1	1
07/14/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/15/2020 00:00	1	1
07/15/2020 01:00	1	1
07/15/2020 02:00	1	1
07/15/2020 03:00	1	1
07/15/2020 04:00	1	1
07/15/2020 05:00	1	1
07/15/2020 06:00	1	1
07/15/2020 07:00	1	1
07/15/2020 08:00	1	1
07/15/2020 09:00	1	1
07/15/2020 10:00	1	1
07/15/2020 11:00	1	1
07/15/2020 12:00	1	1
07/15/2020 13:00	1	1
07/15/2020 14:00	1	1
07/15/2020 15:00	1	1
07/15/2020 16:00	1	1
07/15/2020 17:00	1	1
07/15/2020 18:00	1	1
07/15/2020 19:00	1	1
07/15/2020 20:00	1	1
07/15/2020 21:00	1	1
07/15/2020 22:00	1	1
07/15/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/16/2020 00:00	1	1
07/16/2020 01:00	1	1
07/16/2020 02:00	1	1
07/16/2020 03:00	1	1
07/16/2020 04:00	1	1
07/16/2020 05:00	1	1
07/16/2020 06:00	1	1
07/16/2020 07:00	1	1
07/16/2020 08:00	1	1
07/16/2020 09:00	1	1
07/16/2020 10:00	1	1
07/16/2020 11:00	1	1
07/16/2020 12:00	1	1
07/16/2020 13:00	1	1
07/16/2020 14:00	1	1
07/16/2020 15:00	1	1
07/16/2020 16:00	1	1
07/16/2020 17:00	1	1
07/16/2020 18:00	1	1
07/16/2020 19:00	1	1
07/16/2020 20:00	1	1
07/16/2020 21:00	1	1
07/16/2020 22:00	1	1
07/16/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/17/2020 00:00	1	1
07/17/2020 01:00	1	1
07/17/2020 02:00	1	1
07/17/2020 03:00	1	1
07/17/2020 04:00	1	1
07/17/2020 05:00	1	1
07/17/2020 06:00	1	1
07/17/2020 07:00	1	1
07/17/2020 08:00	1	1
07/17/2020 09:00	1	1
07/17/2020 10:00	1	1
07/17/2020 11:00	1	1
07/17/2020 12:00	1	1
07/17/2020 13:00	1	1
07/17/2020 14:00	1	1
07/17/2020 15:00	1	1
07/17/2020 16:00	1	1
07/17/2020 17:00	1	1
07/17/2020 18:00	1	1
07/17/2020 19:00	1	1
07/17/2020 20:00	1	1
07/17/2020 21:00	1	1
07/17/2020 22:00	1	1
07/17/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/18/2020 00:00	1	1
07/18/2020 01:00	1	1
07/18/2020 02:00	1	1
07/18/2020 03:00	1	1
07/18/2020 04:00	1	1
07/18/2020 05:00	1	1
07/18/2020 06:00	1	1
07/18/2020 07:00	1	1
07/18/2020 08:00	1	1
07/18/2020 09:00	1	1
07/18/2020 10:00	1	1
07/18/2020 11:00	1	1
07/18/2020 12:00	1	1
07/18/2020 13:00	1	1
07/18/2020 14:00	1	1
07/18/2020 15:00	1	1
07/18/2020 16:00	1	1
07/18/2020 17:00	1	1
07/18/2020 18:00	1	1
07/18/2020 19:00	1	1
07/18/2020 20:00	1	1
07/18/2020 21:00	1	1
07/18/2020 22:00	1	1
07/18/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/19/2020 00:00	1	1
07/19/2020 01:00	1	1
07/19/2020 02:00	1	1
07/19/2020 03:00	1	1
07/19/2020 04:00	1	1
07/19/2020 05:00	1	1
07/19/2020 06:00	1	1
07/19/2020 07:00	1	1
07/19/2020 08:00	1	1
07/19/2020 09:00	1	1
07/19/2020 10:00	1	1
07/19/2020 11:00	1	1
07/19/2020 12:00	1	1
07/19/2020 13:00	1	1
07/19/2020 14:00	1	1
07/19/2020 15:00	1	1
07/19/2020 16:00	1	1
07/19/2020 17:00	1	1
07/19/2020 18:00	1	1
07/19/2020 19:00	1	1
07/19/2020 20:00	1	1
07/19/2020 21:00	1	1
07/19/2020 22:00	1	1
07/19/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/20/2020 00:00	1	1
07/20/2020 01:00	1	1
07/20/2020 02:00	1	1
07/20/2020 03:00	1	1
07/20/2020 04:00	1	1
07/20/2020 05:00	1	1
07/20/2020 06:00	1	1
07/20/2020 07:00	1	1
07/20/2020 08:00	1	1
07/20/2020 09:00	1	1
07/20/2020 10:00	1	1
07/20/2020 11:00	1	1
07/20/2020 12:00	1	1
07/20/2020 13:00	1	1
07/20/2020 14:00	1	1
07/20/2020 15:00	1	1
07/20/2020 16:00	1	1
07/20/2020 17:00	1	1
07/20/2020 18:00	1	1
07/20/2020 19:00	1	1
07/20/2020 20:00	1	1
07/20/2020 21:00	1	1
07/20/2020 22:00	1	1
07/20/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/21/2020 00:00	1	1
07/21/2020 01:00	1	1
07/21/2020 02:00	1	1
07/21/2020 03:00	1	1
07/21/2020 04:00	1	1
07/21/2020 05:00	1	1
07/21/2020 06:00	1	1
07/21/2020 07:00	1	1
07/21/2020 08:00	1	1
07/21/2020 09:00	1	1
07/21/2020 10:00	1	1
07/21/2020 11:00	1	1
07/21/2020 12:00	1	1
07/21/2020 13:00	1	1
07/21/2020 14:00	1	1
07/21/2020 15:00	1	1
07/21/2020 16:00	1	1
07/21/2020 17:00	1	1
07/21/2020 18:00	1	1
07/21/2020 19:00	1	1
07/21/2020 20:00	1	1
07/21/2020 21:00	1	1
07/21/2020 22:00	1	1
07/21/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/22/2020 00:00	1	1
07/22/2020 01:00	1	1
07/22/2020 02:00	1	1
07/22/2020 03:00	1	1
07/22/2020 04:00	1	1
07/22/2020 05:00	1	1
07/22/2020 06:00	1	1
07/22/2020 07:00	1	1
07/22/2020 08:00	1	1
07/22/2020 09:00	1	1
07/22/2020 10:00	1	1
07/22/2020 11:00	1	1
07/22/2020 12:00	1	1
07/22/2020 13:00	1	1
07/22/2020 14:00	1	1
07/22/2020 15:00	1	1
07/22/2020 16:00	1	1
07/22/2020 17:00	1	1
07/22/2020 18:00	1	1
07/22/2020 19:00	1	1
07/22/2020 20:00	1	1
07/22/2020 21:00	1	1
07/22/2020 22:00	1	1
07/22/2020 23:00	1	1
<hr/>		
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/23/2020 00:00	1	1
07/23/2020 01:00	1	1
07/23/2020 02:00	1	1
07/23/2020 03:00	1	1
07/23/2020 04:00	1	1
07/23/2020 05:00	1	1
07/23/2020 06:00	1	1
07/23/2020 07:00	1	1
07/23/2020 08:00	1	1
07/23/2020 09:00	1	1
07/23/2020 10:00	1	1
07/23/2020 11:00	1	1
07/23/2020 12:00	1	1
07/23/2020 13:00	1	1
07/23/2020 14:00	1	1
07/23/2020 15:00	1	1
07/23/2020 16:00	1	1
07/23/2020 17:00	1	1
07/23/2020 18:00	1	1
07/23/2020 19:00	1	1
07/23/2020 20:00	1	1
07/23/2020 21:00	1	1
07/23/2020 22:00	1	1
07/23/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/24/2020 00:00	1	1
07/24/2020 01:00	1	1
07/24/2020 02:00	1	1
07/24/2020 03:00	1	1
07/24/2020 04:00	1	1
07/24/2020 05:00	1	1
07/24/2020 06:00	1	1
07/24/2020 07:00	1	1
07/24/2020 08:00	1	1
07/24/2020 09:00	1	1
07/24/2020 10:00	1	1
07/24/2020 11:00	1	1
07/24/2020 12:00	1	1
07/24/2020 13:00	1	1
07/24/2020 14:00	1	1
07/24/2020 15:00	1	1
07/24/2020 16:00	1	1
07/24/2020 17:00	1	1
07/24/2020 18:00	1	1
07/24/2020 19:00	1	1
07/24/2020 20:00	1	1
07/24/2020 21:00	1	1
07/24/2020 22:00	1	1
07/24/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/25/2020 00:00	1	1
07/25/2020 01:00	1	1
07/25/2020 02:00	1	1
07/25/2020 03:00	1	1
07/25/2020 04:00	1	1
07/25/2020 05:00	1	1
07/25/2020 06:00	1	1
07/25/2020 07:00	1	1
07/25/2020 08:00	1	1
07/25/2020 09:00	1	1
07/25/2020 10:00	1	1
07/25/2020 11:00	1	1
07/25/2020 12:00	1	1
07/25/2020 13:00	1	13
07/25/2020 14:00	1	18
07/25/2020 15:00	1	18
07/25/2020 16:00	1	18
07/25/2020 17:00	1	5
07/25/2020 18:00	1	1
07/25/2020 19:00	1	1
07/25/2020 20:00	1	1
07/25/2020 21:00	1	1
07/25/2020 22:00	1	1
07/25/2020 23:00	1	1
Average/Sum#:	1	4
Minimum:	1	1
Maximum:	1	18
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/26/2020 00:00	1	1
07/26/2020 01:00	1	1
07/26/2020 02:00	1	1
07/26/2020 03:00	1	1
07/26/2020 04:00	1	1
07/26/2020 05:00	1	1
07/26/2020 06:00	1	1
07/26/2020 07:00	1	1
07/26/2020 08:00	1	1
07/26/2020 09:00	1	1
07/26/2020 10:00	1	1
07/26/2020 11:00	1	1
07/26/2020 12:00	1	1
07/26/2020 13:00	1	1
07/26/2020 14:00	1	1
07/26/2020 15:00	1	1
07/26/2020 16:00	1	1
07/26/2020 17:00	1	1
07/26/2020 18:00	1	1
07/26/2020 19:00	1	1
07/26/2020 20:00	1	1
07/26/2020 21:00	1	1
07/26/2020 22:00	1	1
07/26/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/27/2020 00:00	1	1
07/27/2020 01:00	1	1
07/27/2020 02:00	1	1
07/27/2020 03:00	1	1
07/27/2020 04:00	1	1
07/27/2020 05:00	1	1
07/27/2020 06:00	1	1
07/27/2020 07:00	1	1
07/27/2020 08:00	1	1
07/27/2020 09:00	1	1
07/27/2020 10:00	1	1
07/27/2020 11:00	1	1
07/27/2020 12:00	1	1
07/27/2020 13:00	1	1
07/27/2020 14:00	1	1
07/27/2020 15:00	1	1
07/27/2020 16:00	1	1
07/27/2020 17:00	1	1
07/27/2020 18:00	1	1
07/27/2020 19:00	1	1
07/27/2020 20:00	1	1
07/27/2020 21:00	1	1
07/27/2020 22:00	1	1
07/27/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/28/2020 00:00	1	1
07/28/2020 01:00	1	1
07/28/2020 02:00	1	1
07/28/2020 03:00	1	1
07/28/2020 04:00	1	1
07/28/2020 05:00	1	1
07/28/2020 06:00	1	1
07/28/2020 07:00	1	1
07/28/2020 08:00	1	1
07/28/2020 09:00	1	1
07/28/2020 10:00	1	1
07/28/2020 11:00	1	1
07/28/2020 12:00	1	1
07/28/2020 13:00	1	1
07/28/2020 14:00	1	1
07/28/2020 15:00	1	1
07/28/2020 16:00	1	1
07/28/2020 17:00	1	1
07/28/2020 18:00	1	1
07/28/2020 19:00	1	1
07/28/2020 20:00	1	1
07/28/2020 21:00	1	1
07/28/2020 22:00	1	1
07/28/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/29/2020 00:00	1	1
07/29/2020 01:00	1	1
07/29/2020 02:00	1	1
07/29/2020 03:00	1	1
07/29/2020 04:00	1	1
07/29/2020 05:00	1	1
07/29/2020 06:00	1	1
07/29/2020 07:00	1	1
07/29/2020 08:00	1	1
07/29/2020 09:00	1	1
07/29/2020 10:00	1	1
07/29/2020 11:00	1	1
07/29/2020 12:00	1	1
07/29/2020 13:00	1	1
07/29/2020 14:00	1	1
07/29/2020 15:00	1	1
07/29/2020 16:00	1	1
07/29/2020 17:00	1	1
07/29/2020 18:00	1	1
07/29/2020 19:00	1	1
07/29/2020 20:00	1	1
07/29/2020 21:00	1	1
07/29/2020 22:00	1	1
07/29/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc 1 Hour(s)	NOx_4Hr, Ppmvdc 1 Hour(s)
07/30/2020 00:00	1	1
07/30/2020 01:00	1	1
07/30/2020 02:00	1	1
07/30/2020 03:00	1	1
07/30/2020 04:00	1	1
07/30/2020 05:00	1	1
07/30/2020 06:00	1	1
07/30/2020 07:00	1	1
07/30/2020 08:00	1	1
07/30/2020 09:00	1	1
07/30/2020 10:00	1	1
07/30/2020 11:00	1	1
07/30/2020 12:00	1	1
07/30/2020 13:00	1	1
07/30/2020 14:00	1	1
07/30/2020 15:00	1	1
07/30/2020 16:00	1	1
07/30/2020 17:00	1	1
07/30/2020 18:00	1	1
07/30/2020 19:00	1	1
07/30/2020 20:00	1	1
07/30/2020 21:00	1	1
07/30/2020 22:00	1	1
07/30/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
07/31/2020 00:00	1	1
07/31/2020 01:00	1	1
07/31/2020 02:00	1	1
07/31/2020 03:00	1	1
07/31/2020 04:00	1	1
07/31/2020 05:00	1	1
07/31/2020 06:00	1	1
07/31/2020 07:00	1	1
07/31/2020 08:00	1	1
07/31/2020 09:00	1	1
07/31/2020 10:00	1	1
07/31/2020 11:00	1	1
07/31/2020 12:00	1	1
07/31/2020 13:00	1	1
07/31/2020 14:00	1	1
07/31/2020 15:00	1	1
07/31/2020 16:00	1	1
07/31/2020 17:00	1	1
07/31/2020 18:00	1	1
07/31/2020 19:00	1	1
07/31/2020 20:00	1	1
07/31/2020 21:00	1	1
07/31/2020 22:00	1	1
07/31/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/01/2020 00:00	1	1
08/01/2020 01:00	1	1
08/01/2020 02:00	1	1
08/01/2020 03:00	1	1
08/01/2020 04:00	1	1
08/01/2020 05:00	1	1
08/01/2020 06:00	1	1
08/01/2020 07:00	1	1
08/01/2020 08:00	1	1
08/01/2020 09:00	1	1
08/01/2020 10:00	1	1
08/01/2020 11:00	1	1
08/01/2020 12:00	1	1
08/01/2020 13:00	1	1
08/01/2020 14:00	1	1
08/01/2020 15:00	1	1
08/01/2020 16:00	1	1
08/01/2020 17:00	1	1
08/01/2020 18:00	1	1
08/01/2020 19:00	1	1
08/01/2020 20:00	1	1
08/01/2020 21:00	1	1
08/01/2020 22:00	1	1
08/01/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/02/2020 00:00	1	1
08/02/2020 01:00	1	1
08/02/2020 02:00	1	1
08/02/2020 03:00	1	1
08/02/2020 04:00	1	1
08/02/2020 05:00	1	1
08/02/2020 06:00	1	1
08/02/2020 07:00	1	1
08/02/2020 08:00	1	1
08/02/2020 09:00	1	1
08/02/2020 10:00	1	1
08/02/2020 11:00	1	1
08/02/2020 12:00	1	1
08/02/2020 13:00	1	1
08/02/2020 14:00	1	1
08/02/2020 15:00	1	1
08/02/2020 16:00	1	1
08/02/2020 17:00	1	1
08/02/2020 18:00	1	1
08/02/2020 19:00	1	1
08/02/2020 20:00	1	1
08/02/2020 21:00	1	1
08/02/2020 22:00	1	1
08/02/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc 1 Hour(s)	NOx_4Hr, Ppmvdc 1 Hour(s)
08/03/2020 00:00	1	1
08/03/2020 01:00	1	1
08/03/2020 02:00	1	1
08/03/2020 03:00	1	1
08/03/2020 04:00	1	1
08/03/2020 05:00	1	1
08/03/2020 06:00	1	1
08/03/2020 07:00	1	1
08/03/2020 08:00	1	1
08/03/2020 09:00	1	1
08/03/2020 10:00	1	1
08/03/2020 11:00	1	1
08/03/2020 12:00	1	1
08/03/2020 13:00	1	1
08/03/2020 14:00	1	1
08/03/2020 15:00	1	1
08/03/2020 16:00	1	1
08/03/2020 17:00	1	1
08/03/2020 18:00	1	1
08/03/2020 19:00	1	1
08/03/2020 20:00	1	1
08/03/2020 21:00	1	1
08/03/2020 22:00	1	1
08/03/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/04/2020 00:00	1	1
08/04/2020 01:00	1	1
08/04/2020 02:00	1	1
08/04/2020 03:00	1	1
08/04/2020 04:00	1	1
08/04/2020 05:00	1	1
08/04/2020 06:00	1	1
08/04/2020 07:00	1	1
08/04/2020 08:00	1	1
08/04/2020 09:00	1	1
08/04/2020 10:00	1	1
08/04/2020 11:00	1	1
08/04/2020 12:00	1	1
08/04/2020 13:00	1	1
08/04/2020 14:00	1	1
08/04/2020 15:00	1	1
08/04/2020 16:00	1	1
08/04/2020 17:00	1	1
08/04/2020 18:00	1	1
08/04/2020 19:00	1	1
08/04/2020 20:00	1	1
08/04/2020 21:00	1	1
08/04/2020 22:00	1	1
08/04/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc 1 Hour(s)	NOx_4Hr, Ppmvdc 1 Hour(s)
08/05/2020 00:00	1	1
08/05/2020 01:00	1	1
08/05/2020 02:00	1	1
08/05/2020 03:00	1	1
08/05/2020 04:00	1	1
08/05/2020 05:00	1	1
08/05/2020 06:00	1	1
08/05/2020 07:00	1	1
08/05/2020 08:00	1	1
08/05/2020 09:00	1	1
08/05/2020 10:00	1	1
08/05/2020 11:00	1	1
08/05/2020 12:00	1	1
08/05/2020 13:00	1	1
08/05/2020 14:00	1	1
08/05/2020 15:00	1	1
08/05/2020 16:00	1	1
08/05/2020 17:00	1	1
08/05/2020 18:00	1	1
08/05/2020 19:00	1	1
08/05/2020 20:00	1	1
08/05/2020 21:00	1	1
08/05/2020 22:00	1	1
08/05/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/06/2020 00:00	1	1
08/06/2020 01:00	1	1
08/06/2020 02:00	1	1
08/06/2020 03:00	1	1
08/06/2020 04:00	1	1
08/06/2020 05:00	1	1
08/06/2020 06:00	1	1
08/06/2020 07:00	1	1
08/06/2020 08:00	1	1
08/06/2020 09:00	1	1
08/06/2020 10:00	1	1
08/06/2020 11:00	1	1
08/06/2020 12:00	1	1
08/06/2020 13:00	1	1
08/06/2020 14:00	1	1
08/06/2020 15:00	1	1
08/06/2020 16:00	1	1
08/06/2020 17:00	1	1
08/06/2020 18:00	1	1
08/06/2020 19:00	1	1
08/06/2020 20:00	1	1
08/06/2020 21:00	1	1
08/06/2020 22:00	1	1
08/06/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/07/2020 00:00	1	1
08/07/2020 01:00	1	1
08/07/2020 02:00	1	1
08/07/2020 03:00	1	1
08/07/2020 04:00	1	1
08/07/2020 05:00	1	1
08/07/2020 06:00	1	1
08/07/2020 07:00	1	1
08/07/2020 08:00	1	1
08/07/2020 09:00	1	1
08/07/2020 10:00	1	1
08/07/2020 11:00	1	1
08/07/2020 12:00	1	1
08/07/2020 13:00	1	1
08/07/2020 14:00	1	1
08/07/2020 15:00	1	1
08/07/2020 16:00	1	1
08/07/2020 17:00	1	1
08/07/2020 18:00	1	1
08/07/2020 19:00	1	1
08/07/2020 20:00	1	1
08/07/2020 21:00	1	1
08/07/2020 22:00	1	1
08/07/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/08/2020 00:00	1	1
08/08/2020 01:00	1	1
08/08/2020 02:00	1	1
08/08/2020 03:00	1	1
08/08/2020 04:00	1	1
08/08/2020 05:00	1	1
08/08/2020 06:00	1	1
08/08/2020 07:00	1	1
08/08/2020 08:00	1	1
08/08/2020 09:00	1	1
08/08/2020 10:00	1	1
08/08/2020 11:00	1	1
08/08/2020 12:00	1	1
08/08/2020 13:00	1	1
08/08/2020 14:00	1	1
08/08/2020 15:00	1	1
08/08/2020 16:00	1	1
08/08/2020 17:00	1	1
08/08/2020 18:00	1	1
08/08/2020 19:00	1	1
08/08/2020 20:00	1	1
08/08/2020 21:00	1	1
08/08/2020 22:00	1	1
08/08/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/09/2020 00:00	1	1
08/09/2020 01:00	1	1
08/09/2020 02:00	1	1
08/09/2020 03:00	1	1
08/09/2020 04:00	1	1
08/09/2020 05:00	1	1
08/09/2020 06:00	1	1
08/09/2020 07:00	1	1
08/09/2020 08:00	1	1
08/09/2020 09:00	1	1
08/09/2020 10:00	1	1
08/09/2020 11:00	1	1
08/09/2020 12:00	1	1
08/09/2020 13:00	1	1
08/09/2020 14:00	1	1
08/09/2020 15:00	1	1
08/09/2020 16:00	1	1
08/09/2020 17:00	1	1
08/09/2020 18:00	1	1
08/09/2020 19:00	1	1
08/09/2020 20:00	1	1
08/09/2020 21:00	1	1
08/09/2020 22:00	1	1
08/09/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/10/2020 00:00	1	1
08/10/2020 01:00	1	1
08/10/2020 02:00	1	1
08/10/2020 03:00	1	1
08/10/2020 04:00	1	1
08/10/2020 05:00	1	1
08/10/2020 06:00	1	1
08/10/2020 07:00	1	1
08/10/2020 08:00	1	1
08/10/2020 09:00	1	1
08/10/2020 10:00	1	1
08/10/2020 11:00	1	1
08/10/2020 12:00	1	1
08/10/2020 13:00	1	1
08/10/2020 14:00	1	1
08/10/2020 15:00	1	1
08/10/2020 16:00	1	1
08/10/2020 17:00	1	1
08/10/2020 18:00	1	1
08/10/2020 19:00	1	1
08/10/2020 20:00	1	1
08/10/2020 21:00	1	1
08/10/2020 22:00	1	1
08/10/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/11/2020 00:00	1	1
08/11/2020 01:00	1	1
08/11/2020 02:00	1	1
08/11/2020 03:00	1	1
08/11/2020 04:00	1	1
08/11/2020 05:00	1	1
08/11/2020 06:00	1	1
08/11/2020 07:00	1	1
08/11/2020 08:00	1	1
08/11/2020 09:00	1	1
08/11/2020 10:00	1	1
08/11/2020 11:00	1	1
08/11/2020 12:00	1	1
08/11/2020 13:00	1	1
08/11/2020 14:00	1	1
08/11/2020 15:00	1	1
08/11/2020 16:00	1	1
08/11/2020 17:00	1	1
08/11/2020 18:00	1	1
08/11/2020 19:00	1	1
08/11/2020 20:00	1	1
08/11/2020 21:00	1	1
08/11/2020 22:00	1	1
08/11/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/12/2020 00:00	1	1
08/12/2020 01:00	1	1
08/12/2020 02:00	1	1
08/12/2020 03:00	1	1
08/12/2020 04:00	1	1
08/12/2020 05:00	1	1
08/12/2020 06:00	1	1
08/12/2020 07:00	1	1
08/12/2020 08:00	1	1
08/12/2020 09:00	1	1
08/12/2020 10:00	1	1
08/12/2020 11:00	1	1
08/12/2020 12:00	1	1
08/12/2020 13:00	1	1
08/12/2020 14:00	1	1
08/12/2020 15:00	1	1
08/12/2020 16:00	1	1
08/12/2020 17:00	1	1
08/12/2020 18:00	1	1
08/12/2020 19:00	1	1
08/12/2020 20:00	1	1
08/12/2020 21:00	1	1
08/12/2020 22:00	1	1
08/12/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/13/2020 00:00	1	1
08/13/2020 01:00	1	1
08/13/2020 02:00	1	1
08/13/2020 03:00	1	1
08/13/2020 04:00	1	1
08/13/2020 05:00	1	1
08/13/2020 06:00	1	1
08/13/2020 07:00	1	1
08/13/2020 08:00	1	1
08/13/2020 09:00	1	1
08/13/2020 10:00	1	1
08/13/2020 11:00	1	1
08/13/2020 12:00	1	1
08/13/2020 13:00	1	1
08/13/2020 14:00	1	1
08/13/2020 15:00	1	1
08/13/2020 16:00	1	1
08/13/2020 17:00	1	1
08/13/2020 18:00	1	1
08/13/2020 19:00	1	1
08/13/2020 20:00	1	1
08/13/2020 21:00	1	1
08/13/2020 22:00	1	1
08/13/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/14/2020 00:00	1	1
08/14/2020 01:00	1	1
08/14/2020 02:00	1	1
08/14/2020 03:00	1	1
08/14/2020 04:00	1	1
08/14/2020 05:00	1	1
08/14/2020 06:00	1	1
08/14/2020 07:00	1	1
08/14/2020 08:00	1	1
08/14/2020 09:00	1	1
08/14/2020 10:00	1	1
08/14/2020 11:00	1	1
08/14/2020 12:00	1	1
08/14/2020 13:00	1	1
08/14/2020 14:00	1	1
08/14/2020 15:00	1	1
08/14/2020 16:00	1	1
08/14/2020 17:00	1	1
08/14/2020 18:00	1	1
08/14/2020 19:00	1	1
08/14/2020 20:00	1	1
08/14/2020 21:00	1	1
08/14/2020 22:00	1	1
08/14/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/15/2020 00:00	1	1
08/15/2020 01:00	1	1
08/15/2020 02:00	1	1
08/15/2020 03:00	1	1
08/15/2020 04:00	1	1
08/15/2020 05:00	1	1
08/15/2020 06:00	1	1
08/15/2020 07:00	1	1
08/15/2020 08:00	1	1
08/15/2020 09:00	1	1
08/15/2020 10:00	1	1
08/15/2020 11:00	1	1
08/15/2020 12:00	1	1
08/15/2020 13:00	1	1
08/15/2020 14:00	1	1
08/15/2020 15:00	1	1
08/15/2020 16:00	1	1
08/15/2020 17:00	1	1
08/15/2020 18:00	1	1
08/15/2020 19:00	1	1
08/15/2020 20:00	1	1
08/15/2020 21:00	1	1
08/15/2020 22:00	1	1
08/15/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/16/2020 00:00	1	1
08/16/2020 01:00	1	1
08/16/2020 02:00	1	1
08/16/2020 03:00	1	1
08/16/2020 04:00	1	1
08/16/2020 05:00	1	1
08/16/2020 06:00	1	1
08/16/2020 07:00	1	1
08/16/2020 08:00	1	1
08/16/2020 09:00	1	1
08/16/2020 10:00	1	1
08/16/2020 11:00	1	1
08/16/2020 12:00	1	1
08/16/2020 13:00	1	1
08/16/2020 14:00	1	1
08/16/2020 15:00	1	1
08/16/2020 16:00	1	1
08/16/2020 17:00	1	1
08/16/2020 18:00	1	1
08/16/2020 19:00	1	1
08/16/2020 20:00	1	1
08/16/2020 21:00	1	1
08/16/2020 22:00	1	1
08/16/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/17/2020 00:00	1	1
08/17/2020 01:00	1	1
08/17/2020 02:00	1	1
08/17/2020 03:00	1	1
08/17/2020 04:00	1	1
08/17/2020 05:00	1	1
08/17/2020 06:00	1	1
08/17/2020 07:00	1	1
08/17/2020 08:00	1	1
08/17/2020 09:00	1	1
08/17/2020 10:00	1	1
08/17/2020 11:00	1	1
08/17/2020 12:00	1	1
08/17/2020 13:00	1	1
08/17/2020 14:00	1	1
08/17/2020 15:00	1	1
08/17/2020 16:00	1	1
08/17/2020 17:00	1	1
08/17/2020 18:00	1	1
08/17/2020 19:00	1	1
08/17/2020 20:00	1	1
08/17/2020 21:00	1	1
08/17/2020 22:00	1	1
08/17/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/18/2020 00:00	1	1
08/18/2020 01:00	1	1
08/18/2020 02:00	1	1
08/18/2020 03:00	1	1
08/18/2020 04:00	1	1
08/18/2020 05:00	1	1
08/18/2020 06:00	1	1
08/18/2020 07:00	1	1
08/18/2020 08:00	1	1
08/18/2020 09:00	1	1
08/18/2020 10:00	1	1
08/18/2020 11:00	1	1
08/18/2020 12:00	1	1
08/18/2020 13:00	1	1
08/18/2020 14:00	1	1
08/18/2020 15:00	1	1
08/18/2020 16:00	1	1
08/18/2020 17:00	1	1
08/18/2020 18:00	1	1
08/18/2020 19:00	1	1
08/18/2020 20:00	1	1
08/18/2020 21:00	1	1
08/18/2020 22:00	1	1
08/18/2020 23:00	1	1
<hr/>		
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/19/2020 00:00	1	1
08/19/2020 01:00	1	1
08/19/2020 02:00	1	1
08/19/2020 03:00	1	1
08/19/2020 04:00	1	1
08/19/2020 05:00	1	1
08/19/2020 06:00	1	1
08/19/2020 07:00	1	1
08/19/2020 08:00	1	1
08/19/2020 09:00	1	1
08/19/2020 10:00	1	1
08/19/2020 11:00	1	1
08/19/2020 12:00	1	1
08/19/2020 13:00	1	1
08/19/2020 14:00	1	1
08/19/2020 15:00	1	1
08/19/2020 16:00	1	1
08/19/2020 17:00	1	1
08/19/2020 18:00	1	1
08/19/2020 19:00	1	1
08/19/2020 20:00	1	1
08/19/2020 21:00	1	1
08/19/2020 22:00	1	1
08/19/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/20/2020 00:00	1	1
08/20/2020 01:00	1	1
08/20/2020 02:00	1	1
08/20/2020 03:00	1	1
08/20/2020 04:00	1	1
08/20/2020 05:00	1	1
08/20/2020 06:00	1	1
08/20/2020 07:00	1	1
08/20/2020 08:00	1	1
08/20/2020 09:00	1	1
08/20/2020 10:00	1	1
08/20/2020 11:00	1	1
08/20/2020 12:00	1	1
08/20/2020 13:00	1	1
08/20/2020 14:00	1	1
08/20/2020 15:00	1	1
08/20/2020 16:00	1	1
08/20/2020 17:00	1	1
08/20/2020 18:00	1	1
08/20/2020 19:00	1	1
08/20/2020 20:00	1	1
08/20/2020 21:00	1	1
08/20/2020 22:00	1	1
08/20/2020 23:00	1	1
<hr/>		
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/21/2020 00:00	1	1
08/21/2020 01:00	1	1
08/21/2020 02:00	1	1
08/21/2020 03:00	1	1
08/21/2020 04:00	1	1
08/21/2020 05:00	1	1
08/21/2020 06:00	0	1
08/21/2020 07:00	0	1
08/21/2020 08:00	0	1
08/21/2020 09:00	0	1
08/21/2020 10:00	0	1
08/21/2020 11:00	0	1
08/21/2020 12:00	0	1
08/21/2020 13:00	0	1
08/21/2020 14:00	1	1
08/21/2020 15:00	1	1
08/21/2020 16:00	1	1
08/21/2020 17:00	1	1
08/21/2020 18:00	1	1
08/21/2020 19:00	1	1
08/21/2020 20:00	1	1
08/21/2020 21:00	1	1
08/21/2020 22:00	1	1
08/21/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	33.33	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/22/2020 00:00	1	1
08/22/2020 01:00	1	1
08/22/2020 02:00	1	1
08/22/2020 03:00	1	1
08/22/2020 04:00	1	1
08/22/2020 05:00	1	1
08/22/2020 06:00	1	1
08/22/2020 07:00	1	1
08/22/2020 08:00	1	1
08/22/2020 09:00	1	1
08/22/2020 10:00	1	1
08/22/2020 11:00	1	1
08/22/2020 12:00	1	1
08/22/2020 13:00	1	1
08/22/2020 14:00	1	1
08/22/2020 15:00	1	1
08/22/2020 16:00	1	1
08/22/2020 17:00	1	1
08/22/2020 18:00	1	1
08/22/2020 19:00	1	1
08/22/2020 20:00	1	1
08/22/2020 21:00	1	1
08/22/2020 22:00	1	1
08/22/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/23/2020 00:00	1	1
08/23/2020 01:00	1	1
08/23/2020 02:00	1	1
08/23/2020 03:00	1	1
08/23/2020 04:00	1	1
08/23/2020 05:00	1	1
08/23/2020 06:00	1	1
08/23/2020 07:00	1	1
08/23/2020 08:00	1	1
08/23/2020 09:00	1	1
08/23/2020 10:00	1	1
08/23/2020 11:00	1	1
08/23/2020 12:00	1	1
08/23/2020 13:00	1	1
08/23/2020 14:00	1	1
08/23/2020 15:00	1	1
08/23/2020 16:00	1	1
08/23/2020 17:00	1	1
08/23/2020 18:00	1	1
08/23/2020 19:00	1	1
08/23/2020 20:00	1	1
08/23/2020 21:00	1	1
08/23/2020 22:00	1	1
08/23/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/24/2020 00:00	1	1
08/24/2020 01:00	1	1
08/24/2020 02:00	1	1
08/24/2020 03:00	1	1
08/24/2020 04:00	1	1
08/24/2020 05:00	1	1
08/24/2020 06:00	1	1
08/24/2020 07:00	1	1
08/24/2020 08:00	1	1
08/24/2020 09:00	1	1
08/24/2020 10:00	1	1
08/24/2020 11:00	1	1
08/24/2020 12:00	1	1
08/24/2020 13:00	1	1
08/24/2020 14:00	1	1
08/24/2020 15:00	1	1
08/24/2020 16:00	1	1
08/24/2020 17:00	1	1
08/24/2020 18:00	1	1
08/24/2020 19:00	1	1
08/24/2020 20:00	1	1
08/24/2020 21:00	1	1
08/24/2020 22:00	1	1
08/24/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/25/2020 00:00	1	1
08/25/2020 01:00	1	1
08/25/2020 02:00	1	1
08/25/2020 03:00	1	1
08/25/2020 04:00	1	1
08/25/2020 05:00	1	1
08/25/2020 06:00	1	1
08/25/2020 07:00	1	1
08/25/2020 08:00	1	1
08/25/2020 09:00	1	1
08/25/2020 10:00	1	1
08/25/2020 11:00	1	1
08/25/2020 12:00	1	1
08/25/2020 13:00	1	1
08/25/2020 14:00	1	1
08/25/2020 15:00	1	1
08/25/2020 16:00	1	1
08/25/2020 17:00	1	1
08/25/2020 18:00	1	1
08/25/2020 19:00	1	1
08/25/2020 20:00	1	1
08/25/2020 21:00	1	1
08/25/2020 22:00	1	1
08/25/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/26/2020 00:00	1	1
08/26/2020 01:00	1	1
08/26/2020 02:00	1	1
08/26/2020 03:00	1	1
08/26/2020 04:00	1	1
08/26/2020 05:00	1	1
08/26/2020 06:00	1	1
08/26/2020 07:00	1	1
08/26/2020 08:00	1	1
08/26/2020 09:00	1	1
08/26/2020 10:00	1	1
08/26/2020 11:00	1	1
08/26/2020 12:00	1	1
08/26/2020 13:00	1	1
08/26/2020 14:00	1	1
08/26/2020 15:00	1	1
08/26/2020 16:00	1	1
08/26/2020 17:00	1	1
08/26/2020 18:00	1	1
08/26/2020 19:00	1	1
08/26/2020 20:00	1	1
08/26/2020 21:00	1	1
08/26/2020 22:00	1	1
08/26/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/27/2020 00:00	1	1
08/27/2020 01:00	1	1
08/27/2020 02:00	1	1
08/27/2020 03:00	1	1
08/27/2020 04:00	1	1
08/27/2020 05:00	1	1
08/27/2020 06:00	1	1
08/27/2020 07:00	1	1
08/27/2020 08:00	1	1
08/27/2020 09:00	1	1
08/27/2020 10:00	1	1
08/27/2020 11:00	1	1
08/27/2020 12:00	1	1
08/27/2020 13:00	1	1
08/27/2020 14:00	1	1
08/27/2020 15:00	1	1
08/27/2020 16:00	1	1
08/27/2020 17:00	1	1
08/27/2020 18:00	1	1
08/27/2020 19:00	1	1
08/27/2020 20:00	1	1
08/27/2020 21:00	1	1
08/27/2020 22:00	1	1
08/27/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/28/2020 00:00	1	1
08/28/2020 01:00	1	1
08/28/2020 02:00	1	1
08/28/2020 03:00	1	1
08/28/2020 04:00	1	1
08/28/2020 05:00	1	1
08/28/2020 06:00	1	1
08/28/2020 07:00	1	1
08/28/2020 08:00	1	1
08/28/2020 09:00	1	1
08/28/2020 10:00	1	1
08/28/2020 11:00	1	1
08/28/2020 12:00	1	1
08/28/2020 13:00	1	1
08/28/2020 14:00	1	1
08/28/2020 15:00	1	1
08/28/2020 16:00	1	1
08/28/2020 17:00	1	1
08/28/2020 18:00	1	1
08/28/2020 19:00	1	1
08/28/2020 20:00	1	1
08/28/2020 21:00	1	1
08/28/2020 22:00	1	1
08/28/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/29/2020 00:00	1	1
08/29/2020 01:00	1	1
08/29/2020 02:00	1	1
08/29/2020 03:00	1	1
08/29/2020 04:00	1	1
08/29/2020 05:00	1	1
08/29/2020 06:00	1	1
08/29/2020 07:00	1	1
08/29/2020 08:00	1	1
08/29/2020 09:00	1	1
08/29/2020 10:00	1	1
08/29/2020 11:00	1	1
08/29/2020 12:00	1	1
08/29/2020 13:00	1	1
08/29/2020 14:00	1	1
08/29/2020 15:00	1	1
08/29/2020 16:00	1	1
08/29/2020 17:00	1	1
08/29/2020 18:00	1	1
08/29/2020 19:00	1	1
08/29/2020 20:00	1	1
08/29/2020 21:00	1	1
08/29/2020 22:00	1	1
08/29/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/30/2020 00:00	1	1
08/30/2020 01:00	1	1
08/30/2020 02:00	1	1
08/30/2020 03:00	1	1
08/30/2020 04:00	1	1
08/30/2020 05:00	1	1
08/30/2020 06:00	1	1
08/30/2020 07:00	1	1
08/30/2020 08:00	1	1
08/30/2020 09:00	1	1
08/30/2020 10:00	1	1
08/30/2020 11:00	1	1
08/30/2020 12:00	1	1
08/30/2020 13:00	1	1
08/30/2020 14:00	1	1
08/30/2020 15:00	1	1
08/30/2020 16:00	1	1
08/30/2020 17:00	1	1
08/30/2020 18:00	1	1
08/30/2020 19:00	1	1
08/30/2020 20:00	1	1
08/30/2020 21:00	1	1
08/30/2020 22:00	1	1
08/30/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
08/31/2020 00:00	1	1
08/31/2020 01:00	1	1
08/31/2020 02:00	1	1
08/31/2020 03:00	1	1
08/31/2020 04:00	1	1
08/31/2020 05:00	1	1
08/31/2020 06:00	1	1
08/31/2020 07:00	1	1
08/31/2020 08:00	1	1
08/31/2020 09:00	1	1
08/31/2020 10:00	1	1
08/31/2020 11:00	1	1
08/31/2020 12:00	1	1
08/31/2020 13:00	1	1
08/31/2020 14:00	1	1
08/31/2020 15:00	1	1
08/31/2020 16:00	1	1
08/31/2020 17:00	1	1
08/31/2020 18:00	1	1
08/31/2020 19:00	1	1
08/31/2020 20:00	1	1
08/31/2020 21:00	1	1
08/31/2020 22:00	1	1
08/31/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/01/2020 00:00	1	1
09/01/2020 01:00	1	1
09/01/2020 02:00	1	1
09/01/2020 03:00	1	1
09/01/2020 04:00	1	1
09/01/2020 05:00	1	1
09/01/2020 06:00	1	1
09/01/2020 07:00	1	1
09/01/2020 08:00	1	1
09/01/2020 09:00	1	1
09/01/2020 10:00	1	1
09/01/2020 11:00	1	1
09/01/2020 12:00	1	1
09/01/2020 13:00	1	1
09/01/2020 14:00	1	1
09/01/2020 15:00	1	1
09/01/2020 16:00	1	1
09/01/2020 17:00	1	1
09/01/2020 18:00	1	1
09/01/2020 19:00	1	1
09/01/2020 20:00	1	1
09/01/2020 21:00	1	1
09/01/2020 22:00	1	1
09/01/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/02/2020 00:00	1	1
09/02/2020 01:00	1	1
09/02/2020 02:00	1	1
09/02/2020 03:00	1	1
09/02/2020 04:00	1	1
09/02/2020 05:00	1	1
09/02/2020 06:00	1	1
09/02/2020 07:00	1	1
09/02/2020 08:00	1	1
09/02/2020 09:00	1	1
09/02/2020 10:00	1	1
09/02/2020 11:00	1	1
09/02/2020 12:00	1	1
09/02/2020 13:00	1	1
09/02/2020 14:00	1	1
09/02/2020 15:00	1	1
09/02/2020 16:00	1	1
09/02/2020 17:00	1	1
09/02/2020 18:00	1	1
09/02/2020 19:00	1	1
09/02/2020 20:00	1	1
09/02/2020 21:00	1	1
09/02/2020 22:00	1	1
09/02/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/03/2020 00:00	1	1
09/03/2020 01:00	1	1
09/03/2020 02:00	1	1
09/03/2020 03:00	1	11
09/03/2020 04:00	1	15
09/03/2020 05:00	1	15
09/03/2020 06:00	1	15
09/03/2020 07:00	1	5
09/03/2020 08:00	1	1
09/03/2020 09:00	1	1
09/03/2020 10:00	1	1
09/03/2020 11:00	1	1
09/03/2020 12:00	1	1
09/03/2020 13:00	1	1
09/03/2020 14:00	1	1
09/03/2020 15:00	1	1
09/03/2020 16:00	1	1
09/03/2020 17:00	1	1
09/03/2020 18:00	1	1
09/03/2020 19:00	1	1
09/03/2020 20:00	1	1
09/03/2020 21:00	1	1
09/03/2020 22:00	1	1
09/03/2020 23:00	1	1
Average/Sum#:	1	3
Minimum:	1	1
Maximum:	1	15
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/04/2020 00:00	1	1
09/04/2020 01:00	1	1
09/04/2020 02:00	1	1
09/04/2020 03:00	1	1
09/04/2020 04:00	1	1
09/04/2020 05:00	1	1
09/04/2020 06:00	1	1
09/04/2020 07:00	1	1
09/04/2020 08:00	1	1
09/04/2020 09:00	1	1
09/04/2020 10:00	1	1
09/04/2020 11:00	1	1
09/04/2020 12:00	1	1
09/04/2020 13:00	1	1
09/04/2020 14:00	1	1
09/04/2020 15:00	1	1
09/04/2020 16:00	1	1
09/04/2020 17:00	1	1
09/04/2020 18:00	1	1
09/04/2020 19:00	1	1
09/04/2020 20:00	1	1
09/04/2020 21:00	1	1
09/04/2020 22:00	1	1
09/04/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/05/2020 00:00	1	1
09/05/2020 01:00	1	1
09/05/2020 02:00	1	1
09/05/2020 03:00	1	1
09/05/2020 04:00	1	1
09/05/2020 05:00	1	1
09/05/2020 06:00	1	1
09/05/2020 07:00	1	1
09/05/2020 08:00	1	1
09/05/2020 09:00	1	1
09/05/2020 10:00	1	1
09/05/2020 11:00	1	1
09/05/2020 12:00	1	1
09/05/2020 13:00	1	1
09/05/2020 14:00	1	1
09/05/2020 15:00	1	1
09/05/2020 16:00	1	1
09/05/2020 17:00	1	1
09/05/2020 18:00	1	1
09/05/2020 19:00	1	1
09/05/2020 20:00	1	1
09/05/2020 21:00	1	1
09/05/2020 22:00	1	1
09/05/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/06/2020 00:00	1	1
09/06/2020 01:00	1	1
09/06/2020 02:00	1	1
09/06/2020 03:00	1	1
09/06/2020 04:00	1	1
09/06/2020 05:00	1	1
09/06/2020 06:00	1	1
09/06/2020 07:00	1	1
09/06/2020 08:00	1	1
09/06/2020 09:00	1	1
09/06/2020 10:00	1	1
09/06/2020 11:00	1	1
09/06/2020 12:00	1	1
09/06/2020 13:00	1	1
09/06/2020 14:00	1	1
09/06/2020 15:00	1	1
09/06/2020 16:00	1	1
09/06/2020 17:00	1	1
09/06/2020 18:00	1	1
09/06/2020 19:00	1	1
09/06/2020 20:00	1	1
09/06/2020 21:00	1	1
09/06/2020 22:00	1	1
09/06/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/07/2020 00:00	1	1
09/07/2020 01:00	1	1
09/07/2020 02:00	1	1
09/07/2020 03:00	1	1
09/07/2020 04:00	1	1
09/07/2020 05:00	1	1
09/07/2020 06:00	1	1
09/07/2020 07:00	1	1
09/07/2020 08:00	1	1
09/07/2020 09:00	1	1
09/07/2020 10:00	1	1
09/07/2020 11:00	1	1
09/07/2020 12:00	1	1
09/07/2020 13:00	1	1
09/07/2020 14:00	1	1
09/07/2020 15:00	1	1
09/07/2020 16:00	1	1
09/07/2020 17:00	1	1
09/07/2020 18:00	1	1
09/07/2020 19:00	1	1
09/07/2020 20:00	1	1
09/07/2020 21:00	1	1
09/07/2020 22:00	1	1
09/07/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/08/2020 00:00	1	1
09/08/2020 01:00	1	1
09/08/2020 02:00	1	1
09/08/2020 03:00	1	1
09/08/2020 04:00	1	1
09/08/2020 05:00	1	1
09/08/2020 06:00	1	1
09/08/2020 07:00	1	1
09/08/2020 08:00	1	1
09/08/2020 09:00	1	1
09/08/2020 10:00	1	1
09/08/2020 11:00	1	1
09/08/2020 12:00	1	1
09/08/2020 13:00	1	1
09/08/2020 14:00	1	1
09/08/2020 15:00	1	1
09/08/2020 16:00	1	1
09/08/2020 17:00	1	1
09/08/2020 18:00	1	1
09/08/2020 19:00	1	1
09/08/2020 20:00	1	1
09/08/2020 21:00	1	1
09/08/2020 22:00	1	1
09/08/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/09/2020 00:00	1	1
09/09/2020 01:00	1	1
09/09/2020 02:00	1	1
09/09/2020 03:00	1	1
09/09/2020 04:00	1	1
09/09/2020 05:00	1	1
09/09/2020 06:00	1	1
09/09/2020 07:00	1	1
09/09/2020 08:00	1	1
09/09/2020 09:00	1	1
09/09/2020 10:00	1	1
09/09/2020 11:00	1	1
09/09/2020 12:00	1	1
09/09/2020 13:00	1	1
09/09/2020 14:00	1	1
09/09/2020 15:00	1	1
09/09/2020 16:00	1	1
09/09/2020 17:00	1	1
09/09/2020 18:00	1	1
09/09/2020 19:00	1	1
09/09/2020 20:00	1	1
09/09/2020 21:00	1	1
09/09/2020 22:00	1	1
09/09/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/10/2020 00:00	1	1
09/10/2020 01:00	1	1
09/10/2020 02:00	1	1
09/10/2020 03:00	1	1
09/10/2020 04:00	1	1
09/10/2020 05:00	1	1
09/10/2020 06:00	1	1
09/10/2020 07:00	1	1
09/10/2020 08:00	1	1
09/10/2020 09:00	1	1
09/10/2020 10:00	1	1
09/10/2020 11:00	1	1
09/10/2020 12:00	1	1
09/10/2020 13:00	1	1
09/10/2020 14:00	1	1
09/10/2020 15:00	1	1
09/10/2020 16:00	1	1
09/10/2020 17:00	1	1
09/10/2020 18:00	1	1
09/10/2020 19:00	1	1
09/10/2020 20:00	1	1
09/10/2020 21:00	1	1
09/10/2020 22:00	1	1
09/10/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/11/2020 00:00	1	1
09/11/2020 01:00	1	1
09/11/2020 02:00	1	1
09/11/2020 03:00	1	1
09/11/2020 04:00	1	1
09/11/2020 05:00	1	1
09/11/2020 06:00	1	1
09/11/2020 07:00	1	1
09/11/2020 08:00	1	1
09/11/2020 09:00	1	1
09/11/2020 10:00	1	1
09/11/2020 11:00	1	1
09/11/2020 12:00	1	1
09/11/2020 13:00	1	1
09/11/2020 14:00	1	1
09/11/2020 15:00	1	1
09/11/2020 16:00	1	1
09/11/2020 17:00	1	1
09/11/2020 18:00	1	1
09/11/2020 19:00	1	1
09/11/2020 20:00	1	1
09/11/2020 21:00	1	1
09/11/2020 22:00	1	1
09/11/2020 23:00	2	2
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	2	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/12/2020 00:00	2	2
09/12/2020 01:00	2	2
09/12/2020 02:00	2	2
09/12/2020 03:00	2	2
09/12/2020 04:00	2	2
09/12/2020 05:00	2	2
09/12/2020 06:00	2	2
09/12/2020 07:00	2	2
09/12/2020 08:00	2	2
09/12/2020 09:00	2	2
09/12/2020 10:00	2	2
09/12/2020 11:00	2	2
09/12/2020 12:00	2	2
09/12/2020 13:00	2	2
09/12/2020 14:00	2	2
09/12/2020 15:00	2	2
09/12/2020 16:00	2	2
09/12/2020 17:00	2	14
09/12/2020 18:00	2	16
09/12/2020 19:00	2	19
09/12/2020 20:00	2	17
09/12/2020 21:00	2	6
09/12/2020 22:00	2	3
09/12/2020 23:00	2	1
Average/Sum#:	2	5
Minimum:	2	1
Maximum:	2	19
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/13/2020 00:00	2	1
09/13/2020 01:00	2	1
09/13/2020 02:00	2	2
09/13/2020 03:00	2	2
09/13/2020 04:00	2	2
09/13/2020 05:00	2	2
09/13/2020 06:00	2	2
09/13/2020 07:00	2	2
09/13/2020 08:00	2	2
09/13/2020 09:00	2	2
09/13/2020 10:00	2	2
09/13/2020 11:00	2	2
09/13/2020 12:00	2	2
09/13/2020 13:00	2	2
09/13/2020 14:00	2	2
09/13/2020 15:00	2	2
09/13/2020 16:00	2	2
09/13/2020 17:00	2	12
09/13/2020 18:00	2	15
09/13/2020 19:00	2	18
09/13/2020 20:00	2	16
09/13/2020 21:00	2	6
09/13/2020 22:00	2	3
09/13/2020 23:00	2	1
Average/Sum#:	2	4
Minimum:	2	1
Maximum:	2	18
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/14/2020 00:00	2	1
09/14/2020 01:00	2	1
09/14/2020 02:00	2	2
09/14/2020 03:00	2	2
09/14/2020 04:00	2	2
09/14/2020 05:00	2	2
09/14/2020 06:00	2	2
09/14/2020 07:00	2	2
09/14/2020 08:00	2	2
09/14/2020 09:00	2	2
09/14/2020 10:00	2	10
09/14/2020 11:00	2	11
09/14/2020 12:00	2	10
09/14/2020 13:00	16	9
09/14/2020 14:00	23	1
09/14/2020 15:00	23	1
09/14/2020 16:00	22	1
09/14/2020 17:00	8	1
09/14/2020 18:00	1	1
09/14/2020 19:00	1	1
09/14/2020 20:00	1	1
09/14/2020 21:00	1	1
09/14/2020 22:00	1	1
09/14/2020 23:00	1	1
Average/Sum#:	5	3
Minimum:	1	1
Maximum:	23	11
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/15/2020 00:00	1	1
09/15/2020 01:00	1	1
09/15/2020 02:00	1	1
09/15/2020 03:00	1	1
09/15/2020 04:00	1	1
09/15/2020 05:00	1	1
09/15/2020 06:00	1	1
09/15/2020 07:00	1	1
09/15/2020 08:00	1	1
09/15/2020 09:00	1	1
09/15/2020 10:00	1	1
09/15/2020 11:00	1	1
09/15/2020 12:00	1	1
09/15/2020 13:00	1	1
09/15/2020 14:00	1	1
09/15/2020 15:00	1	1
09/15/2020 16:00	1	1
09/15/2020 17:00	1	1
09/15/2020 18:00	1	1
09/15/2020 19:00	1	1
09/15/2020 20:00	1	1
09/15/2020 21:00	1	1
09/15/2020 22:00	1	1
09/15/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/16/2020 00:00	1	1
09/16/2020 01:00	1	1
09/16/2020 02:00	1	1
09/16/2020 03:00	1	1
09/16/2020 04:00	1	1
09/16/2020 05:00	1	1
09/16/2020 06:00	4	1
09/16/2020 07:00	6	1
09/16/2020 08:00	6	1
09/16/2020 09:00	6	1
09/16/2020 10:00	3	1
09/16/2020 11:00	1	12
09/16/2020 12:00	1	14
09/16/2020 13:00	1	14
09/16/2020 14:00	1	13
09/16/2020 15:00	1	3
09/16/2020 16:00	1	1
09/16/2020 17:00	1	1
09/16/2020 18:00	1	1
09/16/2020 19:00	1	1
09/16/2020 20:00	1	1
09/16/2020 21:00	1	1
09/16/2020 22:00	1	1
09/16/2020 23:00	1	1
Average/Sum#:	2	3
Minimum:	1	1
Maximum:	6	14
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc 1 Hour(s)	NOx_4Hr, Ppmvdc 1 Hour(s)
09/17/2020 00:00	1	1
09/17/2020 01:00	1	1
09/17/2020 02:00	1	1
09/17/2020 03:00	1	1
09/17/2020 04:00	1	1
09/17/2020 05:00	1	1
09/17/2020 06:00	1	1
09/17/2020 07:00	1	1
09/17/2020 08:00	1	1
09/17/2020 09:00	1	1
09/17/2020 10:00	1	1
09/17/2020 11:00	1	1
09/17/2020 12:00	1	1
09/17/2020 13:00	1	1
09/17/2020 14:00	1	1
09/17/2020 15:00	1	1
09/17/2020 16:00	1	1
09/17/2020 17:00	1	1
09/17/2020 18:00	1	1
09/17/2020 19:00	1	1
09/17/2020 20:00	1	1
09/17/2020 21:00	1	1
09/17/2020 22:00	1	1
09/17/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/18/2020 00:00	1	1
09/18/2020 01:00	1	1
09/18/2020 02:00	1	1
09/18/2020 03:00	1	1
09/18/2020 04:00	1	1
09/18/2020 05:00	1	1
09/18/2020 06:00	2	1
09/18/2020 07:00	3	1
09/18/2020 08:00	3	1
09/18/2020 09:00	3	1
09/18/2020 10:00	2	7
09/18/2020 11:00	1	13
09/18/2020 12:00	1	12
09/18/2020 13:00	1	12
09/18/2020 14:00	1	7
09/18/2020 15:00	1	1
09/18/2020 16:00	1	1
09/18/2020 17:00	1	1
09/18/2020 18:00	1	1
09/18/2020 19:00	1	1
09/18/2020 20:00	1	1
09/18/2020 21:00	1	1
09/18/2020 22:00	1	1
09/18/2020 23:00	1	1
Average/Sum#:	1	3
Minimum:	1	1
Maximum:	3	13
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/19/2020 00:00	1	1
09/19/2020 01:00	1	1
09/19/2020 02:00	1	1
09/19/2020 03:00	1	1
09/19/2020 04:00	2	1
09/19/2020 05:00	3	1
09/19/2020 06:00	3	1
09/19/2020 07:00	3	1
09/19/2020 08:00	2	1
09/19/2020 09:00	1	1
09/19/2020 10:00	1	1
09/19/2020 11:00	1	1
09/19/2020 12:00	1	1
09/19/2020 13:00	1	13
09/19/2020 14:00	1	18
09/19/2020 15:00	1	18
09/19/2020 16:00	1	17
09/19/2020 17:00	1	6
09/19/2020 18:00	1	1
09/19/2020 19:00	1	1
09/19/2020 20:00	1	1
09/19/2020 21:00	1	1
09/19/2020 22:00	1	1
09/19/2020 23:00	1	1
Average/Sum#:	1	4
Minimum:	1	1
Maximum:	3	18
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/20/2020 00:00	1	1
09/20/2020 01:00	1	1
09/20/2020 02:00	1	1
09/20/2020 03:00	1	1
09/20/2020 04:00	1	1
09/20/2020 05:00	1	1
09/20/2020 06:00	1	1
09/20/2020 07:00	1	1
09/20/2020 08:00	1	1
09/20/2020 09:00	1	1
09/20/2020 10:00	2	1
09/20/2020 11:00	3	1
09/20/2020 12:00	3	1
09/20/2020 13:00	3	1
09/20/2020 14:00	2	12
09/20/2020 15:00	1	15
09/20/2020 16:00	1	14
09/20/2020 17:00	1	11
09/20/2020 18:00	1	3
09/20/2020 19:00	1	1
09/20/2020 20:00	1	1
09/20/2020 21:00	1	1
09/20/2020 22:00	1	2
09/20/2020 23:00	1	2
Average/Sum#:	1	3
Minimum:	1	1
Maximum:	3	15
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/21/2020 00:00	1	2
09/21/2020 01:00	1	2
09/21/2020 02:00	1	2
09/21/2020 03:00	1	2
09/21/2020 04:00	1	2
09/21/2020 05:00	1	2
09/21/2020 06:00	1	2
09/21/2020 07:00	1	2
09/21/2020 08:00	1	13
09/21/2020 09:00	1	17
09/21/2020 10:00	1	20
09/21/2020 11:00	1	19
09/21/2020 12:00	1	8
09/21/2020 13:00	14	4
09/21/2020 14:00	18	1
09/21/2020 15:00	18	1
09/21/2020 16:00	17	1
09/21/2020 17:00	5	1
09/21/2020 18:00	1	1
09/21/2020 19:00	1	1
09/21/2020 20:00	1	1
09/21/2020 21:00	1	1
09/21/2020 22:00	1	2
09/21/2020 23:00	1	2
Average/Sum#:	4	5
Minimum:	1	1
Maximum:	18	20
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/22/2020 00:00	1	2
09/22/2020 01:00	1	2
09/22/2020 02:00	1	2
09/22/2020 03:00	1	2
09/22/2020 04:00	1	2
09/22/2020 05:00	1	2
09/22/2020 06:00	1	2
09/22/2020 07:00	1	2
09/22/2020 08:00	1	13
09/22/2020 09:00	1	18
09/22/2020 10:00	1	20
09/22/2020 11:00	1	19
09/22/2020 12:00	1	9
09/22/2020 13:00	1	4
09/22/2020 14:00	13	1
09/22/2020 15:00	18	1
09/22/2020 16:00	18	1
09/22/2020 17:00	18	1
09/22/2020 18:00	6	1
09/22/2020 19:00	1	1
09/22/2020 20:00	1	1
09/22/2020 21:00	1	1
09/22/2020 22:00	1	1
09/22/2020 23:00	1	1
Average/Sum#:	4	5
Minimum:	1	1
Maximum:	18	20
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/23/2020 00:00	1	1
09/23/2020 01:00	1	1
09/23/2020 02:00	1	1
09/23/2020 03:00	1	1
09/23/2020 04:00	1	1
09/23/2020 05:00	1	1
09/23/2020 06:00	1	1
09/23/2020 07:00	1	1
09/23/2020 08:00	1	14
09/23/2020 09:00	1	17
09/23/2020 10:00	1	20
09/23/2020 11:00	1	20
09/23/2020 12:00	1	7
09/23/2020 13:00	13	4
09/23/2020 14:00	19	1
09/23/2020 15:00	19	1
09/23/2020 16:00	19	1
09/23/2020 17:00	7	1
09/23/2020 18:00	1	1
09/23/2020 19:00	1	1
09/23/2020 20:00	1	1
09/23/2020 21:00	1	3
09/23/2020 22:00	1	3
09/23/2020 23:00	1	3
Average/Sum#:	4	4
Minimum:	1	1
Maximum:	19	20
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/24/2020 00:00	1	3
09/24/2020 01:00	1	3
09/24/2020 02:00	1	3
09/24/2020 03:00	1	3
09/24/2020 04:00	1	3
09/24/2020 05:00	1	3
09/24/2020 06:00	1	3
09/24/2020 07:00	1	3
09/24/2020 08:00	12	3
09/24/2020 09:00	17	3
09/24/2020 10:00	19	3
09/24/2020 11:00	18	3
09/24/2020 12:00	7	3
09/24/2020 13:00	2	15
09/24/2020 14:00	1	18
09/24/2020 15:00	1	18
09/24/2020 16:00	1	17
09/24/2020 17:00	1	4
09/24/2020 18:00	1	1
09/24/2020 19:00	1	1
09/24/2020 20:00	1	2
09/24/2020 21:00	1	2
09/24/2020 22:00	1	2
09/24/2020 23:00	1	2
Average/Sum#:	4	5
Minimum:	1	1
Maximum:	19	18
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc 1 Hour(s)	NOx_4Hr, Ppmvdc 1 Hour(s)
09/25/2020 00:00	1	2
09/25/2020 01:00	1	2
09/25/2020 02:00	1	2
09/25/2020 03:00	1	2
09/25/2020 04:00	1	2
09/25/2020 05:00	1	2
09/25/2020 06:00	1	2
09/25/2020 07:00	1	2
09/25/2020 08:00	1	2
09/25/2020 09:00	1	2
09/25/2020 10:00	1	2
09/25/2020 11:00	1	2
09/25/2020 12:00	1	2
09/25/2020 13:00	1	2
09/25/2020 14:00	1	2
09/25/2020 15:00	1	2
09/25/2020 16:00	1	2
09/25/2020 17:00	1	2
09/25/2020 18:00	1	2
09/25/2020 19:00	1	2
09/25/2020 20:00	1	2
09/25/2020 21:00	1	2
09/25/2020 22:00	1	2
09/25/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/26/2020 00:00	1	2
09/26/2020 01:00	1	2
09/26/2020 02:00	1	2
09/26/2020 03:00	1	2
09/26/2020 04:00	1	2
09/26/2020 05:00	1	2
09/26/2020 06:00	1	2
09/26/2020 07:00	1	2
09/26/2020 08:00	1	2
09/26/2020 09:00	1	2
09/26/2020 10:00	1	2
09/26/2020 11:00	1	2
09/26/2020 12:00	1	2
09/26/2020 13:00	1	2
09/26/2020 14:00	1	2
09/26/2020 15:00	1	2
09/26/2020 16:00	1	2
09/26/2020 17:00	1	2
09/26/2020 18:00	1	2
09/26/2020 19:00	1	2
09/26/2020 20:00	1	2
09/26/2020 21:00	1	2
09/26/2020 22:00	1	2
09/26/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/27/2020 00:00	1	2
09/27/2020 01:00	1	2
09/27/2020 02:00	1	2
09/27/2020 03:00	1	2
09/27/2020 04:00	1	2
09/27/2020 05:00	1	2
09/27/2020 06:00	1	2
09/27/2020 07:00	1	2
09/27/2020 08:00	7	1
09/27/2020 09:00	7	15
09/27/2020 10:00	7	19
09/27/2020 11:00	7	18
09/27/2020 12:00	7	18
09/27/2020 13:00	16	5
09/27/2020 14:00	29	1
09/27/2020 15:00	29	1
09/27/2020 16:00	31	1
09/27/2020 17:00	19	1
09/27/2020 18:00	2	1
09/27/2020 19:00	1	1
09/27/2020 20:00	1	1
09/27/2020 21:00	1	1
09/27/2020 22:00	1	2
09/27/2020 23:00	1	2
Average/Sum#:	7	4
Minimum:	1	1
Maximum:	31	19
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/28/2020 00:00	1	2
09/28/2020 01:00	1	2
09/28/2020 02:00	1	2
09/28/2020 03:00	1	2
09/28/2020 04:00	1	2
09/28/2020 05:00	1	2
09/28/2020 06:00	14	2
09/28/2020 07:00	18	2
09/28/2020 08:00	18	2
09/28/2020 09:00	18	2
09/28/2020 10:00	5	14
09/28/2020 11:00	1	17
09/28/2020 12:00	1	17
09/28/2020 13:00	1	17
09/28/2020 14:00	1	4
09/28/2020 15:00	1	1
09/28/2020 16:00	1	1
09/28/2020 17:00	1	1
09/28/2020 18:00	1	1
09/28/2020 19:00	1	1
09/28/2020 20:00	1	1
09/28/2020 21:00	1	1
09/28/2020 22:00	1	2
09/28/2020 23:00	1	2
Average/Sum#:	4	4
Minimum:	1	1
Maximum:	18	17
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/29/2020 00:00	1	2
09/29/2020 01:00	1	2
09/29/2020 02:00	1	2
09/29/2020 03:00	1	2
09/29/2020 04:00	1	2
09/29/2020 05:00	1	2
09/29/2020 06:00	12	2
09/29/2020 07:00	16	2
09/29/2020 08:00	16	2
09/29/2020 09:00	16	2
09/29/2020 10:00	5	12
09/29/2020 11:00	1	15
09/29/2020 12:00	1	14
09/29/2020 13:00	1	14
09/29/2020 14:00	1	4
09/29/2020 15:00	1	1
09/29/2020 16:00	1	1
09/29/2020 17:00	1	1
09/29/2020 18:00	1	1
09/29/2020 19:00	1	1
09/29/2020 20:00	1	1
09/29/2020 21:00	1	1
09/29/2020 22:00	1	1
09/29/2020 23:00	1	1
Average/Sum#:	4	4
Minimum:	1	1
Maximum:	16	15
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 07:55 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
09/30/2020 00:00	1	1
09/30/2020 01:00	1	1
09/30/2020 02:00	1	1
09/30/2020 03:00	1	1
09/30/2020 04:00	1	1
09/30/2020 05:00	1	1
09/30/2020 06:00	1	1
09/30/2020 07:00	1	1
09/30/2020 08:00	1	1
09/30/2020 09:00	1	1
09/30/2020 10:00	1	1
09/30/2020 11:00	1	1
09/30/2020 12:00	1	1
09/30/2020 13:00	1	1
09/30/2020 14:00	1	1
09/30/2020 15:00	1	1
09/30/2020 16:00	1	1
09/30/2020 17:00	1	1
09/30/2020 18:00	1	1
09/30/2020 19:00	1	1
09/30/2020 20:00	1	1
09/30/2020 21:00	1	1
09/30/2020 22:00	1	1
09/30/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Excess Emission Report



CT1 NOx 30 Day Rolling Average (K K K K)

From: 07/01/2020 00:00 To: 09/30/2020 23:59
Generated: 10/06/2020 08:20

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA

Tag Name: CT1_NOx_30D_Ppmvdc_1D

Total Operating Time: 85.00 Day(s)

No Exclusions Allowed

Non-Operating Time: 7.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	85.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT2 NOx 30 Day Rolling Average (K K K K)

From: 07/01/2020 00:00 To: 09/30/2020 23:59
Generated: 10/06/2020 08:21

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA

Tag Name: CT2_NOx_30D_Ppmvdc_1D

Total Operating Time: 87.00 Day(s)

No Exclusions Allowed

Non-Operating Time: 5.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	87.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

ATTACHMENT 4
Excess Emission/Downtime Report

FCD: AQ-4
Title V: #29

EDS-CMS Reports

EDS/CMS Summary Report

CT1 - CO LbPerHr



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:22 Location: Maxwell, CA
 Description: Electric Utility

CMS Data from: CT1_CO_LbPerHr_1H
 EDS Data from: CT1_CONormalOp_LbPerHr_1H
 Emission Limitation: CT1_COLimit_LbPerHr_1H
 No Value Exclusions Allowed
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
 Date of Latest CMS Certification or Audit: 12/01/2009 00:00
 Process Unit(s) Description:
 Operating time for EDS: 1,885.00 Hour(s)
 Operating time for CMS: 1,885.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	10
e. Unknown causes	0
2. Total CMS Downtime	10
3. Total Downtime as a percentage of operating time	0.53
4. Total Availability as a percentage of operating time	99.47

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - CO Ppmvdc



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 10/06/2020 08:23 Location: Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_CO_Ppmvdc_1H
EDS Data from: CT1_CO_3Hr_Ppmvdc_1H
Emission Limitation: CT1_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:
Operating time for EDS: 1,885.00 Hour(s)
Operating time for CMS: 1,885.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	10
e. Unknown causes	0
2. Total CMS Downtime	10
3. Total Downtime as a percentage of operating time	0.53
4. Total Availability as a percentage of operating time	99.47

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx LbPerHr



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 08:23 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_NOx_LbPerHr_1H
EDS Data from: CT1_NOxNormalOp_LbPerHr_1H
Emission Limitation: CT1_NOxLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:
Operating time for EDS: 1,885.00 Hour(s)
Operating time for CMS: 1,885.00 Hour(s)

Emission Data Summary	
-----------------------	--

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
-------------------------	--

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	10
e. Unknown causes	0
2. Total CMS Downtime	10
3. Total Downtime as a percentage of operating time	0.53
4. Total Availability as a percentage of operating time	99.47

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx Ppmvdc



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 08:24 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Ppmvdc_1H
EDS Data from: CT1_NOx_Ppmvdc_1H
Emission Limitation: CT1_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:
Operating time for EDS: 1,885.00 Hour(s)
Operating time for CMS: 1,885.00 Hour(s)

Emission Data Summary	
-----------------------	--

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
-------------------------	--

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	10
e. Unknown causes	0
2. Total CMS Downtime	10
3. Total Downtime as a percentage of operating time	0.53
4. Total Availability as a percentage of operating time	99.47

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO LbPerHr



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:25 Location: Maxwell, CA
 Description: Electric Utility

CMS Data from: CT2_CO_LbPerHr_1H
 EDS Data from: CT2_CONormalOp_LbPerHr_1H
 Emission Limitation: CT2_COLimit_LbPerHr_1H
 No Value Exclusions Allowed
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
 Date of Latest CMS Certification or Audit: 12/01/2009 00:00
 Process Unit(s) Description:
 Operating time for EDS: 1,865.00 Hour(s)
 Operating time for CMS: 1,865.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	1
e. Unknown causes	0
2. Total CMS Downtime	1
3. Total Downtime as a percentage of operating time	0.05
4. Total Availability as a percentage of operating time	99.95

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO Ppmvdc



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:25 Location: Maxwell, CA
 Description: Electric Utility

CMS Data from: CT2_CO_Ppmvdc_1H
 EDS Data from: CT2_CO_3Hr_Ppmvdc_1H
 Emission Limitation: CT2_COLimit_3Hr_Ppmvdc_1H
 No Value Exclusions Allowed
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
 Date of Latest CMS Certification or Audit: 12/01/2009 00:00
 Process Unit(s) Description:
 Operating time for EDS: 1,865.00 Hour(s)
 Operating time for CMS: 1,865.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	1
e. Unknown causes	0
2. Total CMS Downtime	1
3. Total Downtime as a percentage of operating time	0.05
4. Total Availability as a percentage of operating time	99.95

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - NOx LbPerHr



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 08:26 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_NOx_LbPerHr_1H
EDS Data from: CT2_NOxNormalOp_LbPerHr_1H
Emission Limitation: CT2_NOxLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:
Operating time for EDS: 1,865.00 Hour(s)
Operating time for CMS: 1,865.00 Hour(s)

Emission Data Summary	
-----------------------	--

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
-------------------------	--

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	1
e. Unknown causes	0
2. Total CMS Downtime	1
3. Total Downtime as a percentage of operating time	0.05
4. Total Availability as a percentage of operating time	99.95

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - NOx Ppmvdc



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 08:26 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_NOx_Ppmvdc_1H
EDS Data from: CT2_NOx_Ppmvdc_1H
Emission Limitation: CT2_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:
Operating time for EDS: 1,865.00 Hour(s)
Operating time for CMS: 1,865.00 Hour(s)

Emission Data Summary	
-----------------------	--

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
-------------------------	--

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	1
e. Unknown causes	0
2. Total CMS Downtime	1
3. Total Downtime as a percentage of operating time	0.05
4. Total Availability as a percentage of operating time	99.95

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

Excess Emission Report



CT1 - CO LbPerHr Normal Operating 1-Hour Block Average

From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 10/06/2020 08:27 Location: Maxwell, CA

Tag Name: CT1_CONormalOp_LbPerHr_1H

Total Operating Time: 1,885.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 323.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,885.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 - CO Ppmvdc 3-Hour Rolling Average

From: 07/01/2020 00:00 To: 09/30/2020 23:59
Generated: 10/06/2020 08:28

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA

Tag Name: CT1_CO_3Hr_Ppmvdc_1H

Total Operating Time: 1,885.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 323.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,885.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 - NOx LbPerHr Normal Operating 1-Hour Block Average

From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 10/06/2020 08:28 Location: Maxwell, CA

Tag Name: CT1_NOxNormalOp_LbPerHr_1H

Total Operating Time: 1,885.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 323.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,885.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 - NOx Ppmvdc 1-Hour Block Average

From: 07/01/2020 00:00 To: 09/30/2020 23:59
Generated: 10/06/2020 08:29

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA

Tag Name: CT1_NOx_Ppmvdc_1H

Total Operating Time: 1,885.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 323.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,885.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT2 - CO LbPerHr Normal Operating 1-Hour Block Average

From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 10/06/2020 08:29 Location: Maxwell, CA

Tag Name: CT2_CONormalOp_LbPerHr_1H

Total Operating Time: 1,865.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 343.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,865.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT2 - CO Ppmvdc 3-Hour Rolling Average

From: 07/01/2020 00:00 To: 09/30/2020 23:59
Generated: 10/06/2020 08:30

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA

Tag Name: CT2_CO_3Hr_Ppmvdc_1H

Total Operating Time: 1,865.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 343.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,865.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT2 - NOx LbPerHr Normal Operating 1-Hour Block Average

From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 10/06/2020 08:31 Location: Maxwell, CA

Tag Name: CT2_NOxNormalOp_LbPerHr_1H

Total Operating Time: 1,865.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 343.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,865.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT2 - NOx Ppmvdc 1-Hour Block Average

From: 07/01/2020 00:00 To: 09/30/2020 23:59
Generated: 10/06/2020 08:32

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA

Tag Name: CT2_NOx_Ppmvdc_1H

Total Operating Time: 1,865.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 343.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,865.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Invalid Data Report

CT1 - Stack CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 10/06/2020 08:33 Location: Maxwell, CA

Tag Name: CT1_CO_LbPerHr_1H
Total Operating Time: 1,885.00 Hour(s)
Non-Operating Time: 323.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/07/2020 15:00	07/07/2020 15:59	1	4 - Other known causes	10 - Performed Linearity
2	08/21/2020 05:00	08/21/2020 11:59	7	4 - Other known causes	8 - Quarterly Maintenance
3	09/01/2020 08:00	09/01/2020 08:59	1	4 - Other known causes	3 - Performed manual calibration
4	09/27/2020 16:00	09/27/2020 16:59	1	4 - Other known causes	3 - Performed manual calibration

Total Operating Time:	1,885.00 Hour(s)
Total Monitor Downtime (Online only):	10.00 Hour(s)
Percent Monitor Availability:	99.47 %
Percent Monitor Downtime:	0.53 %

Report Code	Type	Text	Duration	Duration Percent
4	Reason	Other known causes	10	100.00
10	Action	Performed Linearity	1	10.00
3	Action	Performed manual calibration	2	20.00
8	Action	Quarterly Maintenance	7	70.00

Invalid Data Report



CT1 - Stack NOx

From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:33 Location: Maxwell, CA

Tag Name: CT1_NOx_LbPerHr_1H
 Total Operating Time: 1,885.00 Hour(s)
 Non-Operating Time: 323.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/07/2020 15:00	07/07/2020 15:59	1	4 - Other known causes	10 - Performed Linearity
2	08/21/2020 05:00	08/21/2020 11:59	7	4 - Other known causes	8 - Replaced malfunctioning component, performed calibration sequence
3	09/01/2020 08:00	09/01/2020 08:59	1	4 - Other known causes	3 - Performed manual calibration
4	09/27/2020 16:00	09/27/2020 16:59	1	4 - Other known causes	3 - Performed manual calibration

Total Operating Time:	1,885.00 Hour(s)
Total Monitor Downtime (Online only):	10.00 Hour(s)
Percent Monitor Availability:	99.47 %
Percent Monitor Downtime:	0.53 %

Report Code	Type	Text	Duration	Duration Percent
4	Reason	Other known causes	10	100.00
10	Action	Performed Linearity	1	10.00
3	Action	Performed manual calibration	2	20.00
8	Action	Replaced malfunctioning component, performed calibration sequence	7	70.00

Invalid Data Report



CT2 - Stack CO

From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:34 Location: Maxwell, CA

Tag Name: CT2_CO_LbPerHr_1H
 Total Operating Time: 1,865.00 Hour(s)
 Non-Operating Time: 343.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	09/20/2020 06:00	09/20/2020 06:59	1	4 - other known causes	3 - Performed manual calibration

Total Operating Time:	1,865.00 Hour(s)
Total Monitor Downtime (Online only):	1.00 Hour(s)
Percent Monitor Availability:	99.95 %
Percent Monitor Downtime:	0.05 %

Report Code	Type	Text	Duration	Duration Percent
4	Reason	Other known causes	1	100.00
3	Action	Performed manual calibration	1	100.00

Invalid Data Report

CT2 - Stack NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 10/06/2020 08:35 Location: Maxwell, CA

Tag Name: CT2_NOx_LbPerHr_1H
Total Operating Time: 1,865.00 Hour(s)
Non-Operating Time: 343.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	09/20/2020 06:00	09/20/2020 06:59	1	4 - other known causes	3 - Performed manual calibration

Total Operating Time:	1,865.00 Hour(s)
Total Monitor Downtime (Online only):	1.00 Hour(s)
Percent Monitor Availability:	99.95 %
Percent Monitor Downtime:	0.05 %

Report Code	Type	Text	Duration	Duration Percent
4	Reason	Other known causes	1	100.00
3	Action	Performed manual calibration	1	100.00

ATTACHMENT 5
Hourly Emissions – VOC

FCD: AQ-14
Title V: #6

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 13:00	0.0	17.6	440.0	0.0	0.3	1	0	0
07/03/2020 14:00	0.0	15.0	1,031.2	0.0	0.7	1	0	0
07/03/2020 15:00	0.6	13.9	1,652.8	0.6	1.2	1	1	0
07/03/2020 16:00	0.7	13.9	1,611.1	0.7	1.1	1	1	1
07/03/2020 17:00	-0.5	12.3	2,011.2	-0.1	1.4	1	1	1
07/03/2020 18:00	-0.2	11.6	2,116.1	0.1	1.5	1	1	1
07/03/2020 19:00	-0.2	11.8	2,094.2	0.1	1.5	1	1	1
07/03/2020 20:00	-0.2	11.6	2,130.8	0.1	1.5	1	1	1
07/03/2020 21:00	-0.4	12.2	2,025.1	-0.1	1.4	1	1	1
07/03/2020 22:00	-0.4	12.1	2,048.1	-0.1	1.4	1	1	1
07/03/2020 23:00	0.0	13.9	1,231.3	0.0	0.9	1	0	1
Average/Sum#:	-0.1	13.3	1,672.0	0.1	1.2	11 #	8 #	8 #
Minimum:	-0.5	11.6	440.0	-0.1	0.3	0	0	0
Maximum:	0.7	17.6	2,130.8	0.7	1.5	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/04/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/05/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 14:00	0.0	17.7	423.1	0.0	0.3	1	0	0
07/05/2020 15:00	0.0	15.1	952.5	0.0	0.7	1	0	0
07/05/2020 16:00	0.6	13.9	1,572.4	0.6	1.1	1	1	0
07/05/2020 17:00	-0.1	12.9	1,789.5	0.1	1.3	1	1	1
07/05/2020 18:00	-0.4	11.6	2,104.3	0.1	1.5	1	1	1
07/05/2020 19:00	-0.4	11.7	2,078.1	0.1	1.5	1	1	1
07/05/2020 20:00	-0.4	11.7	2,105.4	0.1	1.5	1	1	1
07/05/2020 21:00	-0.4	11.9	2,083.7	-0.1	1.5	1	1	1
07/05/2020 22:00	0.0	13.5	1,360.8	0.0	1.0	1	0	1
07/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	-0.1	13.3	1,607.8	0.1	1.2	9 #	6 #	6 #
Minimum:	-0.4	11.6	423.1	-0.1	0.3	0	0	0
Maximum:	0.6	17.7	2,105.4	0.6	1.5	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2020 11:00	0.0	18.0	379.4	0.0	0.3	1	0	0
07/06/2020 12:00	0.0	15.5	891.9	0.0	0.6	1	0	0
07/06/2020 13:00	0.6	13.9	1,665.8	0.6	1.2	1	1	0
07/06/2020 14:00	0.4	13.9	1,595.1	0.4	1.1	1	1	0
07/06/2020 15:00	-0.2	13.9	1,524.3	-0.1	1.1	1	1	1
07/06/2020 16:00	-1.4	12.2	2,035.3	-0.7	1.4	1	1	1
07/06/2020 17:00	-1.2	11.9	2,099.2	-0.7	1.5	1	1	1
07/06/2020 18:00	-1.1	11.8	2,114.2	-0.5	1.5	1	1	1
07/06/2020 19:00	-1.2	12.0	2,086.2	-0.7	1.5	1	1	1
07/06/2020 20:00	-1.4	12.2	2,059.5	-0.7	1.4	1	1	1
07/06/2020 21:00	-1.4	12.3	2,026.6	-0.8	1.4	1	1	1
07/06/2020 22:00	-1.2	12.8	1,924.2	-0.7	1.3	1	1	1
07/06/2020 23:00	-1.1	13.2	1,764.1	-0.7	1.2	1	1	1
Average/Sum#:	-0.7	13.4	1,705.1	-0.4	1.2	13 #	11 #	9 #
Minimum:	-1.4	11.8	379.4	-0.8	0.3	0	0	0
Maximum:	0.6	18.0	2,114.2	0.6	1.5	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/07/2020 00:00	0.1	14.0	1,266.8	0.1	0.9	1	1	0
07/07/2020 01:00	0.1	14.0	1,318.2	0.2	0.9	1	1	0
07/07/2020 02:00	0.1	14.0	1,276.7	0.2	0.9	1	1	0
07/07/2020 03:00	0.1	14.0	1,267.0	0.2	0.9	1	1	0
07/07/2020 04:00	0.1	14.0	1,258.2	0.2	0.9	1	1	0
07/07/2020 05:00	0.1	14.0	1,279.5	0.2	0.9	1	1	0
07/07/2020 06:00	0.1	14.0	1,266.6	0.2	0.9	1	1	0
07/07/2020 07:00	0.2	14.0	1,284.4	0.3	0.9	1	1	0
07/07/2020 08:00	0.2	14.0	1,302.6	0.3	0.9	1	1	0
07/07/2020 09:00	0.2	14.0	1,277.3	0.3	0.9	1	1	0
07/07/2020 10:00	0.2	14.0	1,266.6	0.3	0.9	1	1	0
07/07/2020 11:00	0.2	14.1	1,270.9	0.3	0.9	1	1	0
07/07/2020 12:00	0.3	14.1	1,272.5	0.4	0.9	1	1	0
07/07/2020 13:00	0.1	14.0	1,372.0	0.1	1.0	1	1	0
07/07/2020 14:00	0.1	14.0	1,344.6	0.2	0.9	1	1	0
07/07/2020 15:00	0.7	0.0	1,482.0	0.7	1.0	1	1	1
07/07/2020 16:00	-1.5	12.3	2,028.5	-0.8	1.4	1	1	1
07/07/2020 17:00	-1.2	11.8	2,115.5	-0.5	1.5	1	1	1
07/07/2020 18:00	-1.2	12.0	2,077.4	-0.7	1.5	1	1	1
07/07/2020 19:00	-1.2	12.0	2,065.7	-0.7	1.4	1	1	1
07/07/2020 20:00	-1.2	12.0	2,063.7	-0.7	1.4	1	1	1
07/07/2020 21:00	-1.2	12.1	2,052.5	-0.7	1.4	1	1	1
07/07/2020 22:00	-1.4	12.7	1,936.7	-0.8	1.4	1	1	1
07/07/2020 23:00	-1.1	12.9	1,818.2	-0.7	1.3	1	1	1
Average/Sum#:	-0.3	13.4	1,540.2	-0.1	1.1	24 #	24 #	9 #
Minimum:	-1.5	11.8	1,258.2	-0.8	0.9	1	1	0
Maximum:	0.3	14.1	2,115.5	0.4	1.5	1	1	1
%SI	4.17	4.17	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/08/2020 00:00	0.1	14.0	1,288.8	0.2	0.9	1	1	0
07/08/2020 01:00	0.1	14.0	1,255.5	0.2	0.9	1	1	0
07/08/2020 02:00	0.2	14.0	1,255.4	0.3	0.9	1	1	0
07/08/2020 03:00	0.2	14.1	1,254.9	0.3	0.9	1	1	0
07/08/2020 04:00	0.2	14.1	1,257.1	0.3	0.9	1	1	0
07/08/2020 05:00	0.2	14.0	1,268.0	0.3	0.9	1	1	0
07/08/2020 06:00	0.2	14.1	1,259.1	0.3	0.9	1	1	0
07/08/2020 07:00	0.2	14.0	1,263.0	0.3	0.9	1	1	0
07/08/2020 08:00	0.2	14.0	1,261.3	0.3	0.9	1	1	0
07/08/2020 09:00	0.1	14.0	1,261.6	0.2	0.9	1	1	0
07/08/2020 10:00	0.2	14.1	1,263.6	0.3	0.9	1	1	0
07/08/2020 11:00	0.2	14.1	1,279.9	0.3	0.9	1	1	0
07/08/2020 12:00	0.2	14.0	1,336.2	0.3	0.9	1	1	0
07/08/2020 13:00	0.1	14.1	1,287.4	0.2	0.9	1	1	0
07/08/2020 14:00	0.2	14.1	1,336.3	0.3	0.9	1	1	0
07/08/2020 15:00	-0.1	14.0	1,424.2	0.1	1.0	1	1	1
07/08/2020 16:00	-1.5	12.1	2,027.1	-0.8	1.4	1	1	1
07/08/2020 17:00	-1.2	11.8	2,070.5	-0.5	1.4	1	1	1
07/08/2020 18:00	-1.2	11.8	2,088.0	-0.5	1.5	1	1	1
07/08/2020 19:00	-1.4	11.8	2,084.1	-0.7	1.5	1	1	1
07/08/2020 20:00	-1.2	11.8	2,084.8	-0.5	1.5	1	1	1
07/08/2020 21:00	-1.4	12.2	2,007.9	-0.7	1.4	1	1	1
07/08/2020 22:00	-1.4	12.5	1,955.0	-0.8	1.4	1	1	1
07/08/2020 23:00	-1.1	12.9	1,782.9	-0.7	1.2	1	1	1
Average/Sum#:	-0.3	13.4	1,527.2	0.0	1.1	24 #	24 #	9 #
Minimum:	-1.5	11.8	1,254.9	-0.8	0.9	1	1	0
Maximum:	0.2	14.1	2,088.0	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/09/2020 00:00	0.0	14.0	1,274.2	0.1	0.9	1	1	0
07/09/2020 01:00	0.0	14.0	1,271.2	0.1	0.9	1	1	0
07/09/2020 02:00	0.1	14.0	1,253.3	0.1	0.9	1	1	0
07/09/2020 03:00	0.1	14.0	1,314.5	0.1	0.9	1	1	0
07/09/2020 04:00	0.0	14.0	1,284.5	0.1	0.9	1	1	0
07/09/2020 05:00	0.1	14.0	1,339.3	0.1	0.9	1	1	0
07/09/2020 06:00	0.1	14.0	1,268.0	0.1	0.9	1	1	0
07/09/2020 07:00	0.1	14.0	1,257.2	0.1	0.9	1	1	0
07/09/2020 08:00	0.1	14.0	1,259.5	0.2	0.9	1	1	0
07/09/2020 09:00	0.1	14.0	1,267.0	0.2	0.9	1	1	0
07/09/2020 10:00	0.1	14.0	1,266.4	0.2	0.9	1	1	0
07/09/2020 11:00	0.2	14.1	1,266.7	0.3	0.9	1	1	0
07/09/2020 12:00	0.2	14.0	1,511.9	0.3	1.1	1	1	0
07/09/2020 13:00	0.2	13.9	1,629.0	0.3	1.1	1	1	0
07/09/2020 14:00	-0.2	13.9	1,501.0	-0.1	1.1	1	1	1
07/09/2020 15:00	-1.4	12.1	2,021.6	-0.7	1.4	1	1	1
07/09/2020 16:00	-1.2	11.8	2,068.6	-0.5	1.4	1	1	1
07/09/2020 17:00	-1.1	11.7	2,100.2	-0.5	1.5	1	1	1
07/09/2020 18:00	-1.1	11.5	2,127.9	-0.5	1.5	1	1	1
07/09/2020 19:00	-1.1	11.6	2,122.3	-0.5	1.5	1	1	1
07/09/2020 20:00	-1.1	11.8	2,076.6	-0.5	1.5	1	1	1
07/09/2020 21:00	-1.2	11.9	2,074.2	-0.7	1.5	1	1	1
07/09/2020 22:00	-1.2	12.5	1,959.7	-0.7	1.4	1	1	1
07/09/2020 23:00	-1.4	12.8	1,900.4	-0.8	1.3	1	1	1
Average/Sum#:	-0.4	13.2	1,600.6	-0.1	1.1	24 #	24 #	10 #
Minimum:	-1.4	11.5	1,253.3	-0.8	0.9	1	1	0
Maximum:	0.2	14.1	2,127.9	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/10/2020 00:00	0.2	14.0	1,360.6	0.3	1.0	1	1	0
07/10/2020 01:00	0.3	14.1	1,258.3	0.4	0.9	1	1	0
07/10/2020 02:00	0.3	14.1	1,257.3	0.4	0.9	1	1	0
07/10/2020 03:00	0.3	14.1	1,254.8	0.4	0.9	1	1	0
07/10/2020 04:00	0.3	14.1	1,265.3	0.4	0.9	1	1	0
07/10/2020 05:00	0.3	14.0	1,530.4	0.4	1.1	1	1	0
07/10/2020 06:00	0.2	14.0	1,670.6	0.3	1.2	1	1	0
07/10/2020 07:00	0.3	14.0	1,668.0	0.4	1.2	1	1	0
07/10/2020 08:00	0.3	14.0	1,578.2	0.4	1.1	1	1	0
07/10/2020 09:00	0.3	14.0	1,447.8	0.4	1.0	1	1	0
07/10/2020 10:00	0.3	14.0	1,483.2	0.4	1.0	1	1	0
07/10/2020 11:00	0.3	14.1	1,373.7	0.4	1.0	1	1	0
07/10/2020 12:00	0.2	14.0	1,542.6	0.3	1.1	1	1	0
07/10/2020 13:00	-1.4	12.2	2,047.2	-0.7	1.4	1	1	1
07/10/2020 14:00	-1.2	11.9	2,108.3	-0.7	1.5	1	1	1
07/10/2020 15:00	-1.1	11.9	2,113.7	-0.5	1.5	1	1	1
07/10/2020 16:00	-1.1	11.7	2,149.4	-0.5	1.5	1	1	1
07/10/2020 17:00	-0.9	11.5	2,182.9	-0.4	1.5	1	1	1
07/10/2020 18:00	-0.9	11.4	2,197.2	-0.4	1.5	1	1	1
07/10/2020 19:00	-0.9	11.5	2,198.8	-0.4	1.5	1	1	1
07/10/2020 20:00	-0.9	11.5	2,190.3	-0.4	1.5	1	1	1
07/10/2020 21:00	-1.2	12.0	2,091.3	-0.7	1.5	1	1	1
07/10/2020 22:00	-1.2	12.0	2,106.0	-0.7	1.5	1	1	1
07/10/2020 23:00	-0.9	12.9	1,809.6	-0.5	1.3	1	1	1
Average/Sum#:	-0.3	13.0	1,745.2	0.0	1.2	24 #	24 #	11 #
Minimum:	-1.4	11.4	1,254.8	-0.7	0.9	1	1	0
Maximum:	0.3	14.1	2,198.8	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/11/2020 00:00	-0.1	14.0	1,298.4	0.0	0.9	1	1	0
07/11/2020 01:00	0.0	14.0	1,345.5	0.1	0.9	1	1	0
07/11/2020 02:00	0.1	14.0	1,352.3	0.1	0.9	1	1	0
07/11/2020 03:00	0.1	14.0	1,368.3	0.1	1.0	1	1	0
07/11/2020 04:00	0.1	14.0	1,333.5	0.2	0.9	1	1	0
07/11/2020 05:00	0.1	14.0	1,654.7	0.2	1.2	1	1	0
07/11/2020 06:00	0.1	14.0	1,589.2	0.1	1.1	1	1	0
07/11/2020 07:00	0.1	14.0	1,362.1	0.2	1.0	1	1	0
07/11/2020 08:00	0.2	14.0	1,583.8	0.3	1.1	1	1	0
07/11/2020 09:00	0.1	14.0	1,309.6	0.2	0.9	1	1	0
07/11/2020 10:00	0.2	14.0	1,480.9	0.3	1.0	1	1	0
07/11/2020 11:00	0.2	13.9	1,613.9	0.3	1.1	1	1	0
07/11/2020 12:00	0.2	14.0	1,617.0	0.3	1.1	1	1	0
07/11/2020 13:00	0.2	14.1	1,365.0	0.3	1.0	1	1	0
07/11/2020 14:00	0.2	14.0	1,363.0	0.3	1.0	1	1	0
07/11/2020 15:00	-0.9	13.0	1,816.3	-0.5	1.3	1	1	1
07/11/2020 16:00	-1.2	11.8	2,135.4	-0.5	1.5	1	1	1
07/11/2020 17:00	-1.1	11.5	2,177.4	-0.5	1.5	1	1	1
07/11/2020 18:00	-0.9	11.5	2,188.6	-0.4	1.5	1	1	1
07/11/2020 19:00	-0.9	11.5	2,199.7	-0.4	1.5	1	1	1
07/11/2020 20:00	-1.1	11.8	2,144.8	-0.5	1.5	1	1	1
07/11/2020 21:00	-1.2	12.0	2,097.6	-0.7	1.5	1	1	1
07/11/2020 22:00	-1.2	12.0	2,112.8	-0.7	1.5	1	1	1
07/11/2020 23:00	-1.1	12.9	1,826.2	-0.7	1.3	1	1	1
Average/Sum#:	-0.3	13.3	1,680.7	-0.1	1.2	24 #	24 #	9 #
Minimum:	-1.2	11.5	1,298.4	-0.7	0.9	1	1	0
Maximum:	0.2	14.1	2,199.7	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/12/2020 00:00	0.1	14.0	1,296.8	0.1	0.9	1	1	0
07/12/2020 01:00	0.1	14.0	1,288.6	0.2	0.9	1	1	0
07/12/2020 02:00	0.0	14.0	1,287.3	0.1	0.9	1	1	0
07/12/2020 03:00	0.1	14.0	1,287.2	0.1	0.9	1	1	0
07/12/2020 04:00	0.1	14.0	1,288.3	0.2	0.9	1	1	0
07/12/2020 05:00	0.1	14.0	1,286.8	0.1	0.9	1	1	0
07/12/2020 06:00	0.1	14.0	1,291.7	0.1	0.9	1	1	0
07/12/2020 07:00	0.2	14.0	1,290.0	0.3	0.9	1	1	0
07/12/2020 08:00	0.2	14.1	1,291.8	0.3	0.9	1	1	0
07/12/2020 09:00	0.2	14.1	1,302.2	0.3	0.9	1	1	0
07/12/2020 10:00	0.2	14.1	1,404.8	0.3	1.0	1	1	0
07/12/2020 11:00	0.1	14.0	1,371.8	0.2	1.0	1	1	0
07/12/2020 12:00	0.1	14.0	1,428.8	0.2	1.0	1	1	0
07/12/2020 13:00	0.2	14.1	1,365.6	0.3	1.0	1	1	0
07/12/2020 14:00	0.2	14.1	1,313.3	0.3	0.9	1	1	0
07/12/2020 15:00	-0.1	13.9	1,643.0	0.1	1.2	1	1	1
07/12/2020 16:00	-1.4	11.9	2,097.6	-0.7	1.5	1	1	1
07/12/2020 17:00	-0.9	11.4	2,178.4	-0.4	1.5	1	1	1
07/12/2020 18:00	-1.1	11.4	2,170.1	-0.4	1.5	1	1	1
07/12/2020 19:00	-1.1	11.5	2,153.6	-0.5	1.5	1	1	1
07/12/2020 20:00	-1.2	11.9	2,097.4	-0.7	1.5	1	1	1
07/12/2020 21:00	-1.4	12.1	2,065.8	-0.7	1.4	1	1	1
07/12/2020 22:00	-1.2	11.9	2,112.3	-0.7	1.5	1	1	1
07/12/2020 23:00	-1.4	12.5	1,966.2	-0.8	1.4	1	1	1
Average/Sum#:	-0.3	13.3	1,595.0	-0.1	1.1	24 #	24 #	9 #
Minimum:	-1.4	11.4	1,286.8	-0.8	0.9	1	1	0
Maximum:	0.2	14.1	2,178.4	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/13/2020 00:00	0.1	13.9	1,583.2	0.1	1.1	1	1	0
07/13/2020 01:00	0.1	13.9	1,443.0	0.1	1.0	1	1	0
07/13/2020 02:00	0.0	14.0	1,322.5	0.1	0.9	1	1	0
07/13/2020 03:00	0.0	14.0	1,291.4	0.1	0.9	1	1	0
07/13/2020 04:00	0.1	14.0	1,292.8	0.1	0.9	1	1	0
07/13/2020 05:00	0.1	13.9	1,629.1	0.2	1.1	1	1	0
07/13/2020 06:00	0.1	13.9	1,493.1	0.1	1.0	1	1	0
07/13/2020 07:00	0.1	13.9	1,394.0	0.1	1.0	1	1	0
07/13/2020 08:00	0.1	13.9	1,526.5	0.2	1.1	1	1	0
07/13/2020 09:00	0.1	14.0	1,307.3	0.1	0.9	1	1	0
07/13/2020 10:00	0.2	14.0	1,483.2	0.3	1.0	1	1	0
07/13/2020 11:00	-0.1	13.9	1,621.6	0.1	1.1	1	1	1
07/13/2020 12:00	-1.5	12.3	2,042.9	-0.8	1.4	1	1	1
07/13/2020 13:00	-1.4	11.9	2,098.4	-0.7	1.5	1	1	1
07/13/2020 14:00	-1.2	11.8	2,117.1	-0.5	1.5	1	1	1
07/13/2020 15:00	-1.1	11.7	2,119.4	-0.5	1.5	1	1	1
07/13/2020 16:00	-1.1	11.6	2,140.3	-0.5	1.5	1	1	1
07/13/2020 17:00	-1.1	11.5	2,165.0	-0.5	1.5	1	1	1
07/13/2020 18:00	-0.9	11.5	2,163.0	-0.4	1.5	1	1	1
07/13/2020 19:00	-1.1	11.6	2,146.9	-0.5	1.5	1	1	1
07/13/2020 20:00	-1.1	11.8	2,120.6	-0.5	1.5	1	1	1
07/13/2020 21:00	-1.2	11.9	2,103.0	-0.7	1.5	1	1	1
07/13/2020 22:00	-1.2	12.0	2,098.0	-0.7	1.5	1	1	1
07/13/2020 23:00	-1.2	12.7	1,965.5	-0.7	1.4	1	1	1
Average/Sum#:	-0.6	12.9	1,777.8	-0.2	1.2	24 #	24 #	13 #
Minimum:	-1.5	11.5	1,291.4	-0.8	0.9	1	1	0
Maximum:	0.2	14.0	2,165.0	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/14/2020 00:00	-0.9	13.1	1,788.3	-0.5	1.3	1	1	1
07/14/2020 01:00	-0.1	13.9	1,296.1	0.0	0.9	1	1	0
07/14/2020 02:00	0.1	13.9	1,354.6	0.1	0.9	1	1	0
07/14/2020 03:00	0.0	14.0	1,295.9	0.1	0.9	1	1	0
07/14/2020 04:00	0.0	14.0	1,292.0	0.1	0.9	1	1	0
07/14/2020 05:00	0.1	13.9	1,629.2	0.1	1.1	1	1	0
07/14/2020 06:00	0.1	13.9	1,662.5	0.1	1.2	1	1	0
07/14/2020 07:00	0.1	13.9	1,676.8	0.2	1.2	1	1	0
07/14/2020 08:00	0.2	13.9	1,552.4	0.3	1.1	1	1	0
07/14/2020 09:00	0.1	14.0	1,299.1	0.1	0.9	1	1	0
07/14/2020 10:00	0.1	14.0	1,314.4	0.1	0.9	1	1	0
07/14/2020 11:00	0.1	14.0	1,361.5	0.1	1.0	1	1	0
07/14/2020 12:00	0.1	13.9	1,531.6	0.2	1.1	1	1	0
07/14/2020 13:00	-0.4	14.0	1,346.7	-0.2	0.9	1	1	1
07/14/2020 14:00	-1.5	12.3	2,026.7	-0.8	1.4	1	1	1
07/14/2020 15:00	-1.4	11.9	2,076.4	-0.7	1.5	1	1	1
07/14/2020 16:00	-1.2	11.8	2,099.9	-0.5	1.5	1	1	1
07/14/2020 17:00	-1.2	11.8	2,109.9	-0.5	1.5	1	1	1
07/14/2020 18:00	-1.2	11.7	2,135.2	-0.5	1.5	1	1	1
07/14/2020 19:00	-1.2	11.6	2,131.9	-0.5	1.5	1	1	1
07/14/2020 20:00	-1.2	11.8	2,119.8	-0.5	1.5	1	1	1
07/14/2020 21:00	-1.2	11.8	2,125.8	-0.5	1.5	1	1	1
07/14/2020 22:00	-1.4	12.5	1,981.5	-0.8	1.4	1	1	1
07/14/2020 23:00	-1.1	13.0	1,795.1	-0.7	1.3	1	1	1
Average/Sum#:	-0.5	13.1	1,708.5	-0.2	1.2	24 #	24 #	12 #
Minimum:	-1.5	11.6	1,292.0	-0.8	0.9	1	1	0
Maximum:	0.2	14.0	2,135.2	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/15/2020 00:00	-0.2	13.9	1,292.8	-0.1	0.9	1	1	0
07/15/2020 01:00	-0.1	14.0	1,288.0	0.0	0.9	1	1	0
07/15/2020 02:00	0.0	14.0	1,291.6	0.1	0.9	1	1	0
07/15/2020 03:00	0.0	14.0	1,293.1	0.1	0.9	1	1	0
07/15/2020 04:00	0.0	14.0	1,293.8	0.1	0.9	1	1	0
07/15/2020 05:00	-0.1	13.9	1,319.3	0.0	0.9	1	1	0
07/15/2020 06:00	-0.1	13.9	1,305.0	0.0	0.9	1	1	0
07/15/2020 07:00	0.0	14.0	1,289.2	0.1	0.9	1	1	0
07/15/2020 08:00	0.0	14.0	1,290.7	0.1	0.9	1	1	0
07/15/2020 09:00	0.0	14.0	1,294.0	0.1	0.9	1	1	0
07/15/2020 10:00	0.0	14.0	1,295.0	0.1	0.9	1	1	0
07/15/2020 11:00	0.1	14.0	1,297.5	0.1	0.9	1	1	0
07/15/2020 12:00	0.1	14.0	1,296.0	0.1	0.9	1	1	0
07/15/2020 13:00	0.1	14.0	1,299.5	0.1	0.9	1	1	0
07/15/2020 14:00	0.1	14.0	1,307.4	0.1	0.9	1	1	0
07/15/2020 15:00	0.1	14.0	1,302.6	0.1	0.9	1	1	0
07/15/2020 16:00	0.1	14.0	1,307.9	0.1	0.9	1	1	0
07/15/2020 17:00	0.1	14.0	1,308.4	0.1	0.9	1	1	0
07/15/2020 18:00	0.1	13.9	1,392.0	0.1	1.0	1	1	0
07/15/2020 19:00	0.1	13.9	1,462.8	0.2	1.0	1	1	0
07/15/2020 20:00	0.1	14.0	1,358.8	0.1	1.0	1	1	0
07/15/2020 21:00	0.0	14.0	1,288.7	0.1	0.9	1	1	0
07/15/2020 22:00	-0.2	13.9	1,285.1	0.0	0.9	1	1	0
07/15/2020 23:00	0.0	14.0	1,323.4	0.1	0.9	1	1	0
Average/Sum#:	0.0	14.0	1,311.8	0.1	0.9	24 #	24 #	0 #
Minimum:	-0.2	13.9	1,285.1	-0.1	0.9	1	1	0
Maximum:	0.1	14.0	1,462.8	0.2	1.0	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/16/2020 00:00	0.0	14.0	1,288.8	0.1	0.9	1	1	0
07/16/2020 01:00	-0.1	14.0	1,288.2	0.0	0.9	1	1	0
07/16/2020 02:00	-0.1	14.0	1,286.5	0.0	0.9	1	1	0
07/16/2020 03:00	-0.2	13.9	1,286.3	0.0	0.9	1	1	0
07/16/2020 04:00	-0.2	13.9	1,287.1	0.0	0.9	1	1	0
07/16/2020 05:00	-0.2	13.9	1,287.0	0.0	0.9	1	1	0
07/16/2020 06:00	-0.1	14.0	1,287.8	0.0	0.9	1	1	0
07/16/2020 07:00	-0.1	14.0	1,288.1	0.0	0.9	1	1	0
07/16/2020 08:00	0.0	14.0	1,291.1	0.1	0.9	1	1	0
07/16/2020 09:00	0.0	14.0	1,293.9	0.1	0.9	1	1	0
07/16/2020 10:00	0.1	14.0	1,298.6	0.1	0.9	1	1	0
07/16/2020 11:00	0.1	14.0	1,297.0	0.1	0.9	1	1	0
07/16/2020 12:00	0.0	14.0	1,295.0	0.1	0.9	1	1	0
07/16/2020 13:00	0.1	14.0	1,297.3	0.1	0.9	1	1	0
07/16/2020 14:00	0.1	13.9	1,463.7	0.2	1.0	1	1	0
07/16/2020 15:00	-0.4	13.9	1,504.0	-0.2	1.1	1	1	1
07/16/2020 16:00	-1.5	11.9	2,067.7	-0.8	1.4	1	1	1
07/16/2020 17:00	-1.4	11.7	2,107.8	-0.7	1.5	1	1	1
07/16/2020 18:00	-1.4	11.8	2,094.6	-0.7	1.5	1	1	1
07/16/2020 19:00	-1.2	11.7	2,128.9	-0.5	1.5	1	1	1
07/16/2020 20:00	-1.2	11.7	2,126.3	-0.5	1.5	1	1	1
07/16/2020 21:00	-1.4	11.9	2,111.6	-0.7	1.5	1	1	1
07/16/2020 22:00	-1.4	12.6	1,974.7	-0.8	1.4	1	1	1
07/16/2020 23:00	-1.1	13.1	1,789.3	-0.7	1.3	1	1	1
Average/Sum#:	-0.5	13.3	1,560.1	-0.2	1.1	24 #	24 #	9 #
Minimum:	-1.5	11.7	1,286.3	-0.8	0.9	1	1	0
Maximum:	0.1	14.0	2,128.9	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/17/2020 00:00	-0.2	13.9	1,292.7	-0.1	0.9	1	1	0
07/17/2020 01:00	0.0	13.9	1,297.8	0.1	0.9	1	1	0
07/17/2020 02:00	0.0	14.0	1,293.2	0.1	0.9	1	1	0
07/17/2020 03:00	0.0	14.0	1,300.9	0.1	0.9	1	1	0
07/17/2020 04:00	0.0	14.0	1,298.0	0.1	0.9	1	1	0
07/17/2020 05:00	-0.1	13.9	1,304.6	0.0	0.9	1	1	0
07/17/2020 06:00	0.0	13.9	1,304.4	0.1	0.9	1	1	0
07/17/2020 07:00	0.1	14.0	1,298.6	0.1	0.9	1	1	0
07/17/2020 08:00	0.1	14.0	1,300.4	0.2	0.9	1	1	0
07/17/2020 09:00	0.1	14.0	1,312.8	0.2	0.9	1	1	0
07/17/2020 10:00	0.1	14.0	1,305.3	0.1	0.9	1	1	0
07/17/2020 11:00	0.1	14.0	1,308.2	0.1	0.9	1	1	0
07/17/2020 12:00	0.1	14.0	1,317.9	0.1	0.9	1	1	0
07/17/2020 13:00	0.1	14.0	1,327.9	0.1	0.9	1	1	0
07/17/2020 14:00	0.1	14.0	1,300.6	0.1	0.9	1	1	0
07/17/2020 15:00	0.1	14.0	1,303.4	0.1	0.9	1	1	0
07/17/2020 16:00	-0.4	13.9	1,505.4	-0.2	1.1	1	1	1
07/17/2020 17:00	-1.5	12.0	2,071.3	-0.8	1.4	1	1	1
07/17/2020 18:00	-1.4	11.8	2,107.8	-0.7	1.5	1	1	1
07/17/2020 19:00	-1.4	11.8	2,119.7	-0.7	1.5	1	1	1
07/17/2020 20:00	-1.4	11.8	2,123.3	-0.7	1.5	1	1	1
07/17/2020 21:00	-1.4	11.9	2,108.4	-0.7	1.5	1	1	1
07/17/2020 22:00	-1.4	12.6	1,985.7	-0.8	1.4	1	1	1
07/17/2020 23:00	-1.1	13.0	1,865.4	-0.7	1.3	1	1	1
Average/Sum#:	-0.4	13.4	1,531.4	-0.2	1.1	24 #	24 #	8 #
Minimum:	-1.5	11.8	1,292.7	-0.8	0.9	1	1	0
Maximum:	0.1	14.0	2,123.3	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/18/2020 00:00	0.1	13.7	1,757.5	0.2	1.2	1	1	0
07/18/2020 01:00	0.1	13.8	1,599.1	0.1	1.1	1	1	0
07/18/2020 02:00	-0.2	13.9	1,308.4	-0.1	0.9	1	1	0
07/18/2020 03:00	0.0	13.9	1,310.0	0.1	0.9	1	1	0
07/18/2020 04:00	0.0	13.9	1,319.9	0.1	0.9	1	1	0
07/18/2020 05:00	0.1	13.9	1,355.7	0.1	0.9	1	1	0
07/18/2020 06:00	0.0	13.9	1,294.4	0.1	0.9	1	1	0
07/18/2020 07:00	0.1	14.0	1,294.7	0.1	0.9	1	1	0
07/18/2020 08:00	0.1	14.0	1,294.6	0.1	0.9	1	1	0
07/18/2020 09:00	0.1	14.0	1,301.1	0.1	0.9	1	1	0
07/18/2020 10:00	0.1	14.0	1,301.4	0.1	0.9	1	1	0
07/18/2020 11:00	0.1	14.0	1,392.7	0.2	1.0	1	1	0
07/18/2020 12:00	0.1	13.9	1,407.3	0.2	1.0	1	1	0
07/18/2020 13:00	-0.2	13.9	1,587.2	-0.1	1.1	1	1	1
07/18/2020 14:00	-1.7	12.4	2,007.4	-0.9	1.4	1	1	1
07/18/2020 15:00	-0.5	13.5	1,515.8	-0.2	1.1	1	1	1
07/18/2020 16:00	-0.2	13.9	1,599.3	-0.1	1.1	1	1	1
07/18/2020 17:00	-1.4	12.0	2,074.1	-0.7	1.5	1	1	1
07/18/2020 18:00	-1.1	11.5	2,149.9	-0.5	1.5	1	1	1
07/18/2020 19:00	-1.1	11.4	2,177.7	-0.4	1.5	1	1	1
07/18/2020 20:00	-1.2	11.6	2,134.0	-0.5	1.5	1	1	1
07/18/2020 21:00	-1.4	12.3	2,006.8	-0.8	1.4	1	1	1
07/18/2020 22:00	-1.5	12.4	1,990.9	-0.8	1.4	1	1	1
07/18/2020 23:00	-1.2	12.8	1,867.6	-0.7	1.3	1	1	1
Average/Sum#:	-0.5	13.3	1,627.0	-0.2	1.1	24 #	24 #	11 #
Minimum:	-1.7	11.4	1,294.4	-0.9	0.9	1	1	0
Maximum:	0.1	14.0	2,177.7	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/19/2020 00:00	0.0	13.6	1,759.1	0.1	1.2	1	1	0
07/19/2020 01:00	-0.3	13.9	1,313.6	-0.2	0.9	1	1	0
07/19/2020 02:00	-0.2	13.9	1,289.2	-0.1	0.9	1	1	0
07/19/2020 03:00	-0.2	13.9	1,293.5	-0.1	0.9	1	1	0
07/19/2020 04:00	-0.1	13.9	1,289.8	0.0	0.9	1	1	0
07/19/2020 05:00	-0.1	13.9	1,290.7	0.0	0.9	1	1	0
07/19/2020 06:00	-0.1	13.9	1,289.1	0.0	0.9	1	1	0
07/19/2020 07:00	0.0	14.0	1,292.4	0.1	0.9	1	1	0
07/19/2020 08:00	0.1	14.0	1,300.6	0.1	0.9	1	1	0
07/19/2020 09:00	0.1	14.0	1,300.7	0.1	0.9	1	1	0
07/19/2020 10:00	0.1	14.0	1,301.4	0.1	0.9	1	1	0
07/19/2020 11:00	0.1	14.0	1,300.7	0.1	0.9	1	1	0
07/19/2020 12:00	0.1	14.0	1,301.3	0.1	0.9	1	1	0
07/19/2020 13:00	0.1	14.0	1,304.0	0.1	0.9	1	1	0
07/19/2020 14:00	0.1	14.0	1,309.0	0.2	0.9	1	1	0
07/19/2020 15:00	0.1	14.0	1,306.8	0.2	0.9	1	1	0
07/19/2020 16:00	-0.2	13.9	1,498.4	-0.1	1.0	1	1	1
07/19/2020 17:00	-1.5	12.0	2,048.3	-0.8	1.4	1	1	1
07/19/2020 18:00	-1.1	11.6	2,130.2	-0.5	1.5	1	1	1
07/19/2020 19:00	-1.1	11.7	2,124.6	-0.5	1.5	1	1	1
07/19/2020 20:00	-1.2	11.8	2,110.5	-0.5	1.5	1	1	1
07/19/2020 21:00	-1.4	12.0	2,091.8	-0.7	1.5	1	1	1
07/19/2020 22:00	-1.4	12.6	1,970.3	-0.8	1.4	1	1	1
07/19/2020 23:00	-1.1	13.1	1,786.8	-0.7	1.3	1	1	1
Average/Sum#:	-0.4	13.4	1,541.8	-0.2	1.1	24 #	24 #	8 #
Minimum:	-1.5	11.6	1,289.1	-0.8	0.9	1	1	0
Maximum:	0.1	14.0	2,130.2	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/20/2020 00:00	-0.2	13.9	1,291.9	0.0	0.9	1	1	0
07/20/2020 01:00	0.0	13.9	1,284.9	0.1	0.9	1	1	0
07/20/2020 02:00	0.0	13.9	1,283.5	0.1	0.9	1	1	0
07/20/2020 03:00	0.0	13.9	1,283.1	0.1	0.9	1	1	0
07/20/2020 04:00	0.0	13.9	1,284.7	0.1	0.9	1	1	0
07/20/2020 05:00	-0.1	13.9	1,300.2	0.0	0.9	1	1	0
07/20/2020 06:00	0.1	13.9	1,661.5	0.2	1.2	1	1	0
07/20/2020 07:00	0.2	13.9	1,634.1	0.3	1.1	1	1	0
07/20/2020 08:00	0.2	13.9	1,676.7	0.3	1.2	1	1	0
07/20/2020 09:00	0.1	13.9	1,385.1	0.2	1.0	1	1	0
07/20/2020 10:00	0.2	13.9	1,530.8	0.3	1.1	1	1	0
07/20/2020 11:00	0.2	13.9	1,543.3	0.3	1.1	1	1	0
07/20/2020 12:00	-0.2	13.8	1,523.7	-0.1	1.1	1	1	1
07/20/2020 13:00	-1.5	12.2	2,029.1	-0.8	1.4	1	1	1
07/20/2020 14:00	-1.4	12.3	1,999.1	-0.8	1.4	1	1	1
07/20/2020 15:00	-1.2	11.9	2,072.1	-0.7	1.5	1	1	1
07/20/2020 16:00	-1.2	11.9	2,076.3	-0.7	1.5	1	1	1
07/20/2020 17:00	-1.2	11.8	2,084.5	-0.5	1.5	1	1	1
07/20/2020 18:00	-1.1	11.6	2,124.9	-0.5	1.5	1	1	1
07/20/2020 19:00	-1.2	11.7	2,122.1	-0.5	1.5	1	1	1
07/20/2020 20:00	-1.2	11.8	2,110.2	-0.5	1.5	1	1	1
07/20/2020 21:00	-1.4	12.0	2,089.5	-0.7	1.5	1	1	1
07/20/2020 22:00	-1.2	12.4	2,003.9	-0.7	1.4	1	1	1
07/20/2020 23:00	-0.7	13.0	1,777.5	-0.4	1.2	1	1	1
Average/Sum#:	-0.5	13.1	1,715.5	-0.2	1.2	24 #	24 #	12 #
Minimum:	-1.5	11.6	1,283.1	-0.8	0.9	1	1	0
Maximum:	0.2	13.9	2,124.9	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/21/2020 00:00	0.1	13.9	1,284.2	0.1	0.9	1	1	0
07/21/2020 01:00	0.1	13.9	1,285.2	0.1	0.9	1	1	0
07/21/2020 02:00	0.0	13.9	1,285.0	0.1	0.9	1	1	0
07/21/2020 03:00	0.0	13.9	1,283.1	0.1	0.9	1	1	0
07/21/2020 04:00	0.0	13.9	1,283.6	0.1	0.9	1	1	0
07/21/2020 05:00	-0.1	13.9	1,296.0	0.0	0.9	1	1	0
07/21/2020 06:00	0.1	13.9	1,652.7	0.2	1.2	1	1	0
07/21/2020 07:00	0.1	13.9	1,529.9	0.2	1.1	1	1	0
07/21/2020 08:00	0.1	13.9	1,526.6	0.2	1.1	1	1	0
07/21/2020 09:00	0.1	13.9	1,371.1	0.1	1.0	1	1	0
07/21/2020 10:00	0.2	13.9	1,507.4	0.3	1.1	1	1	0
07/21/2020 11:00	0.1	13.9	1,369.6	0.2	1.0	1	1	0
07/21/2020 12:00	0.1	13.9	1,383.2	0.1	1.0	1	1	0
07/21/2020 13:00	-1.1	12.9	1,810.3	-0.7	1.3	1	1	1
07/21/2020 14:00	-1.4	11.8	2,078.6	-0.7	1.5	1	1	1
07/21/2020 15:00	-1.2	11.7	2,090.3	-0.5	1.5	1	1	1
07/21/2020 16:00	-1.2	11.6	2,122.9	-0.5	1.5	1	1	1
07/21/2020 17:00	-1.1	11.5	2,161.6	-0.5	1.5	1	1	1
07/21/2020 18:00	-1.1	11.5	2,152.9	-0.5	1.5	1	1	1
07/21/2020 19:00	-1.1	11.7	2,123.4	-0.5	1.5	1	1	1
07/21/2020 20:00	-1.2	11.8	2,120.7	-0.5	1.5	1	1	1
07/21/2020 21:00	-1.2	12.0	2,091.9	-0.7	1.5	1	1	1
07/21/2020 22:00	-1.4	12.5	1,984.9	-0.8	1.4	1	1	1
07/21/2020 23:00	-0.7	13.0	1,838.6	-0.4	1.3	1	1	1
Average/Sum#:	-0.5	13.0	1,693.1	-0.2	1.2	24 #	24 #	11 #
Minimum:	-1.4	11.5	1,283.1	-0.8	0.9	1	1	0
Maximum:	0.2	13.9	2,161.6	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/22/2020 00:00	0.1	13.9	1,394.0	0.1	1.0	1	1	0
07/22/2020 01:00	0.1	13.9	1,283.5	0.1	0.9	1	1	0
07/22/2020 02:00	0.0	13.9	1,284.0	0.1	0.9	1	1	0
07/22/2020 03:00	-0.1	13.9	1,284.0	0.0	0.9	1	1	0
07/22/2020 04:00	-0.1	13.9	1,297.4	0.0	0.9	1	1	0
07/22/2020 05:00	-0.2	13.9	1,377.5	0.0	1.0	1	1	0
07/22/2020 06:00	0.1	13.8	1,661.4	0.2	1.2	1	1	0
07/22/2020 07:00	0.0	13.9	1,360.4	0.1	1.0	1	1	0
07/22/2020 08:00	0.0	13.9	1,297.1	0.1	0.9	1	1	0
07/22/2020 09:00	0.1	13.9	1,299.4	0.1	0.9	1	1	0
07/22/2020 10:00	0.1	13.9	1,301.1	0.1	0.9	1	1	0
07/22/2020 11:00	0.1	14.0	1,301.5	0.2	0.9	1	1	0
07/22/2020 12:00	0.1	14.0	1,294.0	0.1	0.9	1	1	0
07/22/2020 13:00	0.1	14.0	1,292.3	0.1	0.9	1	1	0
07/22/2020 14:00	0.1	14.0	1,293.2	0.1	0.9	1	1	0
07/22/2020 15:00	0.1	14.0	1,301.2	0.1	0.9	1	1	0
07/22/2020 16:00	-0.2	13.9	1,629.3	-0.1	1.1	1	1	1
07/22/2020 17:00	-1.5	12.1	2,047.5	-0.8	1.4	1	1	1
07/22/2020 18:00	-1.2	11.9	2,102.4	-0.7	1.5	1	1	1
07/22/2020 19:00	-1.4	11.9	2,097.8	-0.7	1.5	1	1	1
07/22/2020 20:00	-1.4	12.0	2,098.2	-0.7	1.5	1	1	1
07/22/2020 21:00	-1.4	12.0	2,092.7	-0.7	1.5	1	1	1
07/22/2020 22:00	-1.4	12.6	1,971.0	-0.8	1.4	1	1	1
07/22/2020 23:00	-1.1	13.1	1,778.2	-0.7	1.2	1	1	1
Average/Sum#:	-0.4	13.4	1,547.5	-0.2	1.1	24 #	24 #	8 #
Minimum:	-1.5	11.9	1,283.5	-0.8	0.9	1	1	0
Maximum:	0.1	14.0	2,102.4	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/23/2020 00:00	-0.2	13.9	1,288.7	0.0	0.9	1	1	0
07/23/2020 01:00	-0.1	13.9	1,283.7	0.0	0.9	1	1	0
07/23/2020 02:00	-0.1	13.9	1,282.6	0.0	0.9	1	1	0
07/23/2020 03:00	-0.1	13.9	1,282.1	0.0	0.9	1	1	0
07/23/2020 04:00	-0.1	13.9	1,283.1	0.0	0.9	1	1	0
07/23/2020 05:00	-0.2	13.9	1,287.5	0.0	0.9	1	1	0
07/23/2020 06:00	-0.2	13.9	1,293.0	0.0	0.9	1	1	0
07/23/2020 07:00	-0.1	13.9	1,296.0	0.0	0.9	1	1	0
07/23/2020 08:00	0.0	13.9	1,298.4	0.1	0.9	1	1	0
07/23/2020 09:00	0.1	13.9	1,297.5	0.1	0.9	1	1	0
07/23/2020 10:00	0.1	13.9	1,298.5	0.1	0.9	1	1	0
07/23/2020 11:00	0.1	13.9	1,288.6	0.1	0.9	1	1	0
07/23/2020 12:00	0.1	14.0	1,296.9	0.1	0.9	1	1	0
07/23/2020 13:00	0.1	14.0	1,288.4	0.1	0.9	1	1	0
07/23/2020 14:00	0.1	14.0	1,292.5	0.2	0.9	1	1	0
07/23/2020 15:00	0.1	14.0	1,295.6	0.2	0.9	1	1	0
07/23/2020 16:00	0.1	14.0	1,293.9	0.2	0.9	1	1	0
07/23/2020 17:00	0.1	13.9	1,409.0	0.2	1.0	1	1	0
07/23/2020 18:00	0.1	13.8	1,628.4	0.2	1.1	1	1	0
07/23/2020 19:00	0.1	13.8	1,612.2	0.2	1.1	1	1	0
07/23/2020 20:00	-0.1	13.8	1,431.3	0.1	1.0	1	1	0
07/23/2020 21:00	0.0	13.9	1,336.6	0.1	0.9	1	1	0
07/23/2020 22:00	-0.1	13.9	1,288.1	0.0	0.9	1	1	0
07/23/2020 23:00	-0.1	13.9	1,325.9	0.0	0.9	1	1	0
Average/Sum#:	0.0	13.9	1,332.4	0.1	0.9	24 #	24 #	0 #
Minimum:	-0.2	13.8	1,282.1	0.0	0.9	1	1	0
Maximum:	0.1	14.0	1,628.4	0.2	1.1	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/24/2020 00:00	-0.1	13.9	1,283.6	0.0	0.9	1	1	0
07/24/2020 01:00	-0.1	13.9	1,285.1	0.0	0.9	1	1	0
07/24/2020 02:00	-0.1	13.9	1,281.4	0.0	0.9	1	1	0
07/24/2020 03:00	-0.2	13.9	1,281.9	0.0	0.9	1	1	0
07/24/2020 04:00	-0.2	13.9	1,287.1	0.0	0.9	1	1	0
07/24/2020 05:00	-0.2	13.9	1,292.4	-0.1	0.9	1	1	0
07/24/2020 06:00	-0.2	13.9	1,323.8	-0.1	0.9	1	1	0
07/24/2020 07:00	0.1	13.8	1,555.6	0.1	1.1	1	1	0
07/24/2020 08:00	0.1	13.8	1,472.3	0.1	1.0	1	1	0
07/24/2020 09:00	0.1	13.9	1,375.7	0.1	1.0	1	1	0
07/24/2020 10:00	0.1	13.9	1,380.6	0.1	1.0	1	1	0
07/24/2020 11:00	0.1	13.9	1,388.3	0.2	1.0	1	1	0
07/24/2020 12:00	0.1	13.9	1,391.0	0.2	1.0	1	1	0
07/24/2020 13:00	0.1	13.9	1,393.8	0.2	1.0	1	1	0
07/24/2020 14:00	0.1	13.9	1,396.5	0.2	1.0	1	1	0
07/24/2020 15:00	0.1	14.0	1,396.5	0.2	1.0	1	1	0
07/24/2020 16:00	-0.2	13.9	1,418.4	-0.1	1.0	1	1	1
07/24/2020 17:00	-2.1	12.5	1,951.8	-1.2	1.4	1	1	1
07/24/2020 18:00	-2.1	12.4	1,975.1	-1.2	1.4	1	1	1
07/24/2020 19:00	-2.1	12.5	1,969.8	-1.2	1.4	1	1	1
07/24/2020 20:00	-2.1	12.5	1,930.2	-1.2	1.4	1	1	1
07/24/2020 21:00	0.0	13.9	1,387.5	0.1	1.0	1	1	0
07/24/2020 22:00	0.1	13.9	1,373.4	0.1	1.0	1	1	0
07/24/2020 23:00	0.0	13.9	1,373.1	0.1	1.0	1	1	0
Average/Sum#:	-0.4	13.7	1,465.2	-0.1	1.0	24 #	24 #	5 #
Minimum:	-2.1	12.4	1,281.4	-1.2	0.9	1	1	0
Maximum:	0.1	14.0	1,975.1	0.2	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/25/2020 00:00	0.0	13.9	1,374.7	0.1	1.0	1	1	0
07/25/2020 01:00	-0.1	13.9	1,377.2	0.0	1.0	1	1	0
07/25/2020 02:00	-0.1	13.9	1,376.3	0.0	1.0	1	1	0
07/25/2020 03:00	-0.1	13.9	1,374.2	0.0	1.0	1	1	0
07/25/2020 04:00	-0.2	13.9	1,373.5	0.0	1.0	1	1	0
07/25/2020 05:00	-0.2	13.9	1,373.9	0.0	1.0	1	1	0
07/25/2020 06:00	-0.2	13.9	1,378.8	0.0	1.0	1	1	0
07/25/2020 07:00	0.0	13.9	1,386.9	0.1	1.0	1	1	0
07/25/2020 08:00	0.1	13.9	1,390.1	0.1	1.0	1	1	0
07/25/2020 09:00	0.1	13.9	1,390.3	0.1	1.0	1	1	0
07/25/2020 10:00	0.1	13.9	1,393.8	0.2	1.0	1	1	0
07/25/2020 11:00	0.1	13.9	1,393.4	0.2	1.0	1	1	0
07/25/2020 12:00	0.1	13.9	1,394.1	0.2	1.0	1	1	0
07/25/2020 13:00	0.1	13.9	1,546.5	0.2	1.1	1	1	0
07/25/2020 14:00	0.1	13.9	1,494.7	0.1	1.0	1	1	0
07/25/2020 15:00	0.2	13.9	1,555.1	0.3	1.1	1	1	0
07/25/2020 16:00	-0.2	13.9	1,543.5	-0.1	1.1	1	1	1
07/25/2020 17:00	-1.5	12.1	2,050.1	-0.8	1.4	1	1	1
07/25/2020 18:00	-1.1	11.7	2,123.1	-0.5	1.5	1	1	1
07/25/2020 19:00	-1.1	11.7	2,128.3	-0.5	1.5	1	1	1
07/25/2020 20:00	-1.1	11.8	2,123.7	-0.5	1.5	1	1	1
07/25/2020 21:00	-1.2	11.9	2,104.6	-0.7	1.5	1	1	1
07/25/2020 22:00	-1.4	12.2	2,043.3	-0.7	1.4	1	1	1
07/25/2020 23:00	-1.2	12.0	2,056.7	-0.7	1.4	1	1	1
Average/Sum#:	-0.4	13.3	1,614.5	-0.1	1.1	24 #	24 #	8 #
Minimum:	-1.5	11.7	1,373.5	-0.8	1.0	1	1	0
Maximum:	0.2	13.9	2,128.3	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/26/2020 00:00	0.1	13.9	1,446.6	0.1	1.0	1	1	0
07/26/2020 01:00	0.1	13.9	1,600.8	0.2	1.1	1	1	0
07/26/2020 02:00	0.1	13.9	1,545.7	0.2	1.1	1	1	0
07/26/2020 03:00	0.1	13.9	1,502.5	0.1	1.1	1	1	0
07/26/2020 04:00	0.1	13.9	1,533.0	0.2	1.1	1	1	0
07/26/2020 05:00	0.0	13.9	1,412.1	0.1	1.0	1	1	0
07/26/2020 06:00	-0.1	13.9	1,284.0	0.0	0.9	1	1	0
07/26/2020 07:00	0.0	13.9	1,284.6	0.1	0.9	1	1	0
07/26/2020 08:00	0.1	13.9	1,286.0	0.1	0.9	1	1	0
07/26/2020 09:00	0.0	13.9	1,290.0	0.1	0.9	1	1	0
07/26/2020 10:00	0.1	13.9	1,380.2	0.1	1.0	1	1	0
07/26/2020 11:00	0.1	13.9	1,535.8	0.2	1.1	1	1	0
07/26/2020 12:00	0.2	13.9	1,549.6	0.3	1.1	1	1	0
07/26/2020 13:00	-0.2	13.8	1,700.5	-0.1	1.2	1	1	1
07/26/2020 14:00	-1.5	12.1	2,034.1	-0.8	1.4	1	1	1
07/26/2020 15:00	-0.5	13.4	1,629.4	-0.2	1.1	1	1	1
07/26/2020 16:00	-0.9	12.9	1,790.6	-0.5	1.3	1	1	1
07/26/2020 17:00	-1.2	11.4	2,168.3	-0.5	1.5	1	1	1
07/26/2020 18:00	-1.1	11.4	2,165.2	-0.4	1.5	1	1	1
07/26/2020 19:00	-0.9	11.3	2,175.3	-0.4	1.5	1	1	1
07/26/2020 20:00	-1.1	11.6	2,131.5	-0.5	1.5	1	1	1
07/26/2020 21:00	-1.1	11.7	2,119.2	-0.5	1.5	1	1	1
07/26/2020 22:00	-1.4	12.4	1,988.7	-0.8	1.4	1	1	1
07/26/2020 23:00	-1.1	12.8	1,795.9	-0.7	1.3	1	1	1
Average/Sum#:	-0.4	13.1	1,681.2	-0.2	1.2	24 #	24 #	11 #
Minimum:	-1.5	11.3	1,284.0	-0.8	0.9	1	1	0
Maximum:	0.2	13.9	2,175.3	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/27/2020 00:00	-0.2	13.9	1,288.5	0.0	0.9	1	1	0
07/27/2020 01:00	-0.2	13.9	1,284.7	0.0	0.9	1	1	0
07/27/2020 02:00	0.0	13.9	1,285.9	0.1	0.9	1	1	0
07/27/2020 03:00	0.1	13.9	1,288.4	0.1	0.9	1	1	0
07/27/2020 04:00	-0.1	13.9	1,297.2	0.0	0.9	1	1	0
07/27/2020 05:00	0.1	13.8	1,645.4	0.2	1.2	1	1	0
07/27/2020 06:00	0.1	13.9	1,674.0	0.2	1.2	1	1	0
07/27/2020 07:00	0.2	13.9	1,681.9	0.3	1.2	1	1	0
07/27/2020 08:00	0.2	13.9	1,646.3	0.3	1.2	1	1	0
07/27/2020 09:00	0.1	13.9	1,345.5	0.2	0.9	1	1	0
07/27/2020 10:00	0.2	13.9	1,572.6	0.3	1.1	1	1	0
07/27/2020 11:00	-0.2	13.8	1,545.0	-0.1	1.1	1	1	1
07/27/2020 12:00	-1.5	12.0	2,071.9	-0.8	1.5	1	1	1
07/27/2020 13:00	-1.2	11.5	2,140.3	-0.5	1.5	1	1	1
07/27/2020 14:00	-1.2	11.6	2,107.6	-0.5	1.5	1	1	1
07/27/2020 15:00	-1.2	11.4	2,149.8	-0.5	1.5	1	1	1
07/27/2020 16:00	-1.2	11.3	2,155.5	-0.5	1.5	1	1	1
07/27/2020 17:00	-1.2	11.3	2,161.2	-0.5	1.5	1	1	1
07/27/2020 18:00	-1.1	11.4	2,144.7	-0.4	1.5	1	1	1
07/27/2020 19:00	-1.1	11.5	2,130.7	-0.5	1.5	1	1	1
07/27/2020 20:00	-1.1	11.3	2,174.2	-0.4	1.5	1	1	1
07/27/2020 21:00	-1.1	11.5	2,134.4	-0.5	1.5	1	1	1
07/27/2020 22:00	-1.1	11.6	2,129.7	-0.5	1.5	1	1	1
07/27/2020 23:00	-1.2	12.3	1,962.6	-0.7	1.4	1	1	1
Average/Sum#:	-0.6	12.7	1,792.4	-0.2	1.3	24 #	24 #	13 #
Minimum:	-1.5	11.3	1,284.7	-0.8	0.9	1	1	0
Maximum:	0.2	13.9	2,174.2	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/28/2020 00:00	0.1	13.8	1,545.8	0.2	1.1	1	1	0
07/28/2020 01:00	0.0	13.8	1,507.2	0.1	1.1	1	1	0
07/28/2020 02:00	0.1	13.8	1,427.7	0.1	1.0	1	1	0
07/28/2020 03:00	0.1	13.8	1,505.6	0.2	1.1	1	1	0
07/28/2020 04:00	0.1	13.8	1,541.3	0.2	1.1	1	1	0
07/28/2020 05:00	0.1	13.8	1,600.3	0.2	1.1	1	1	0
07/28/2020 06:00	0.1	13.8	1,690.1	0.2	1.2	1	1	0
07/28/2020 07:00	0.2	13.8	1,674.4	0.3	1.2	1	1	0
07/28/2020 08:00	0.1	13.8	1,524.7	0.2	1.1	1	1	0
07/28/2020 09:00	0.0	13.9	1,314.4	0.1	0.9	1	1	0
07/28/2020 10:00	0.2	13.9	1,519.9	0.3	1.1	1	1	0
07/28/2020 11:00	-0.2	13.8	1,511.6	-0.1	1.1	1	1	1
07/28/2020 12:00	-1.5	12.0	2,070.1	-0.8	1.4	1	1	1
07/28/2020 13:00	-1.2	11.7	2,115.1	-0.5	1.5	1	1	1
07/28/2020 14:00	-1.2	11.5	2,123.5	-0.5	1.5	1	1	1
07/28/2020 15:00	-1.2	11.3	2,159.6	-0.5	1.5	1	1	1
07/28/2020 16:00	-1.2	11.3	2,162.5	-0.5	1.5	1	1	1
07/28/2020 17:00	-1.2	11.3	2,159.1	-0.5	1.5	1	1	1
07/28/2020 18:00	-1.1	11.3	2,163.8	-0.4	1.5	1	1	1
07/28/2020 19:00	-1.1	11.5	2,123.5	-0.5	1.5	1	1	1
07/28/2020 20:00	-0.9	11.7	2,144.0	-0.4	1.5	1	1	1
07/28/2020 21:00	-1.1	11.7	2,146.5	-0.5	1.5	1	1	1
07/28/2020 22:00	-1.1	11.8	2,119.2	-0.5	1.5	1	1	1
07/28/2020 23:00	-1.4	11.9	2,093.8	-0.7	1.5	1	1	1
Average/Sum#:	-0.6	12.7	1,831.0	-0.2	1.3	24 #	24 #	13 #
Minimum:	-1.5	11.3	1,314.4	-0.8	0.9	1	1	0
Maximum:	0.2	13.9	2,163.8	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/29/2020 00:00	-1.4	12.5	1,974.7	-0.8	1.4	1	1	1
07/29/2020 01:00	-1.4	12.7	1,946.8	-0.8	1.4	1	1	1
07/29/2020 02:00	-1.4	12.7	1,945.1	-0.8	1.4	1	1	1
07/29/2020 03:00	-1.4	12.7	1,955.6	-0.8	1.4	1	1	1
07/29/2020 04:00	-1.4	12.2	2,066.8	-0.7	1.4	1	1	1
07/29/2020 05:00	-1.4	12.1	2,085.2	-0.7	1.5	1	1	1
07/29/2020 06:00	-1.4	12.2	2,070.4	-0.7	1.4	1	1	1
07/29/2020 07:00	-1.4	12.7	1,955.9	-0.8	1.4	1	1	1
07/29/2020 08:00	-1.4	12.7	1,952.9	-0.8	1.4	1	1	1
07/29/2020 09:00	-1.4	12.6	1,969.4	-0.8	1.4	1	1	1
07/29/2020 10:00	-1.2	12.0	2,090.0	-0.7	1.5	1	1	1
07/29/2020 11:00	-1.2	11.8	2,107.2	-0.5	1.5	1	1	1
07/29/2020 12:00	-1.2	11.8	2,122.6	-0.5	1.5	1	1	1
07/29/2020 13:00	-1.2	11.7	2,114.3	-0.5	1.5	1	1	1
07/29/2020 14:00	-1.2	11.4	2,160.3	-0.5	1.5	1	1	1
07/29/2020 15:00	-1.1	11.3	2,173.9	-0.4	1.5	1	1	1
07/29/2020 16:00	-1.1	11.4	2,165.9	-0.4	1.5	1	1	1
07/29/2020 17:00	-1.1	11.4	2,164.1	-0.4	1.5	1	1	1
07/29/2020 18:00	-1.1	11.4	2,157.9	-0.4	1.5	1	1	1
07/29/2020 19:00	-0.9	11.4	2,176.3	-0.4	1.5	1	1	1
07/29/2020 20:00	-0.9	11.5	2,164.4	-0.4	1.5	1	1	1
07/29/2020 21:00	-1.1	11.8	2,113.1	-0.5	1.5	1	1	1
07/29/2020 22:00	-1.1	11.7	2,136.9	-0.5	1.5	1	1	1
07/29/2020 23:00	-1.1	11.8	2,114.2	-0.5	1.5	1	1	1
Average/Sum#:	-1.2	12.0	2,078.5	-0.6	1.5	24 #	24 #	24 #
Minimum:	-1.4	11.3	1,945.1	-0.8	1.4	1	1	1
Maximum:	-0.9	12.7	2,176.3	-0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/30/2020 00:00	-1.2	12.0	2,084.3	-0.7	1.5	1	1	1
07/30/2020 01:00	-1.2	12.6	1,963.5	-0.7	1.4	1	1	1
07/30/2020 02:00	-1.4	12.7	1,947.6	-0.8	1.4	1	1	1
07/30/2020 03:00	-1.4	12.8	1,942.8	-0.8	1.4	1	1	1
07/30/2020 04:00	-1.4	12.8	1,954.0	-0.8	1.4	1	1	1
07/30/2020 05:00	-1.4	12.1	2,080.0	-0.7	1.5	1	1	1
07/30/2020 06:00	-1.4	12.2	2,065.9	-0.7	1.4	1	1	1
07/30/2020 07:00	-1.2	12.7	1,951.1	-0.7	1.4	1	1	1
07/30/2020 08:00	-1.2	12.7	1,947.5	-0.7	1.4	1	1	1
07/30/2020 09:00	-1.2	12.6	1,966.1	-0.7	1.4	1	1	1
07/30/2020 10:00	-1.1	12.0	2,087.4	-0.5	1.5	1	1	1
07/30/2020 11:00	-1.1	11.8	2,121.5	-0.5	1.5	1	1	1
07/30/2020 12:00	-1.1	11.9	2,110.1	-0.5	1.5	1	1	1
07/30/2020 13:00	-1.1	11.8	2,112.2	-0.5	1.5	1	1	1
07/30/2020 14:00	-1.1	11.7	2,121.2	-0.5	1.5	1	1	1
07/30/2020 15:00	-1.1	11.4	2,151.8	-0.4	1.5	1	1	1
07/30/2020 16:00	-1.1	11.4	2,159.8	-0.4	1.5	1	1	1
07/30/2020 17:00	-1.1	11.3	2,173.8	-0.4	1.5	1	1	1
07/30/2020 18:00	-1.1	11.3	2,169.5	-0.4	1.5	1	1	1
07/30/2020 19:00	-1.1	11.9	2,066.4	-0.5	1.4	1	1	1
07/30/2020 20:00	-1.1	11.9	2,081.1	-0.5	1.5	1	1	1
07/30/2020 21:00	-1.2	12.0	2,068.3	-0.7	1.4	1	1	1
07/30/2020 22:00	-1.1	11.8	2,113.9	-0.5	1.5	1	1	1
07/30/2020 23:00	-1.1	12.1	2,056.0	-0.5	1.4	1	1	1
Average/Sum#:	-1.2	12.1	2,062.3	-0.6	1.5	24 #	24 #	24 #
Minimum:	-1.4	11.3	1,942.8	-0.8	1.4	1	1	1
Maximum:	-1.1	12.8	2,173.8	-0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/31/2020 00:00	-1.4	12.5	1,975.4	-0.8	1.4	1	1	1
07/31/2020 01:00	-1.4	12.7	1,939.8	-0.8	1.4	1	1	1
07/31/2020 02:00	-1.4	12.8	1,936.5	-0.8	1.4	1	1	1
07/31/2020 03:00	-1.4	12.8	1,935.9	-0.8	1.4	1	1	1
07/31/2020 04:00	-1.4	12.8	1,944.4	-0.8	1.4	1	1	1
07/31/2020 05:00	-1.5	12.2	2,042.6	-0.8	1.4	1	1	1
07/31/2020 06:00	-1.5	12.2	2,052.4	-0.8	1.4	1	1	1
07/31/2020 07:00	-1.4	12.6	1,963.0	-0.8	1.4	1	1	1
07/31/2020 08:00	-1.4	12.7	1,938.8	-0.8	1.4	1	1	1
07/31/2020 09:00	-1.2	12.4	2,004.3	-0.7	1.4	1	1	1
07/31/2020 10:00	-1.1	12.0	2,080.2	-0.5	1.5	1	1	1
07/31/2020 11:00	-1.2	11.8	2,104.9	-0.5	1.5	1	1	1
07/31/2020 12:00	-1.2	11.8	2,105.7	-0.5	1.5	1	1	1
07/31/2020 13:00	-1.2	11.7	2,115.5	-0.5	1.5	1	1	1
07/31/2020 14:00	-1.2	11.6	2,120.0	-0.5	1.5	1	1	1
07/31/2020 15:00	-1.2	11.5	2,131.8	-0.5	1.5	1	1	1
07/31/2020 16:00	-1.2	11.5	2,132.0	-0.5	1.5	1	1	1
07/31/2020 17:00	-1.2	11.5	2,123.0	-0.5	1.5	1	1	1
07/31/2020 18:00	-1.1	11.3	2,165.2	-0.4	1.5	1	1	1
07/31/2020 19:00	-1.1	11.6	2,114.5	-0.5	1.5	1	1	1
07/31/2020 20:00	-1.2	11.7	2,118.4	-0.5	1.5	1	1	1
07/31/2020 21:00	-1.1	11.8	2,093.8	-0.5	1.5	1	1	1
07/31/2020 22:00	-1.2	11.9	2,084.6	-0.7	1.5	1	1	1
07/31/2020 23:00	-1.4	12.0	2,063.1	-0.7	1.4	1	1	1
Average/Sum#:	-1.3	12.1	2,053.6	-0.6	1.5	24 #	24 #	24 #
Minimum:	-1.5	11.3	1,935.9	-0.8	1.4	1	1	1
Maximum:	-1.1	12.8	2,165.2	-0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/01/2020 00:00	-1.2	12.2	2,048.4	-0.7	1.4	1	1	1
08/01/2020 01:00	-1.4	12.7	1,949.3	-0.8	1.4	1	1	1
08/01/2020 02:00	-1.4	12.8	1,909.8	-0.8	1.3	1	1	1
08/01/2020 03:00	0.0	13.8	1,435.4	0.1	1.0	1	1	0
08/01/2020 04:00	0.2	13.8	1,527.8	0.3	1.1	1	1	0
08/01/2020 05:00	0.1	13.8	1,543.4	0.2	1.1	1	1	0
08/01/2020 06:00	0.1	13.9	1,302.0	0.1	0.9	1	1	0
08/01/2020 07:00	0.1	13.9	1,290.5	0.1	0.9	1	1	0
08/01/2020 08:00	0.1	13.9	1,292.1	0.2	0.9	1	1	0
08/01/2020 09:00	0.1	13.9	1,297.1	0.2	0.9	1	1	0
08/01/2020 10:00	0.2	13.8	1,436.9	0.3	1.0	1	1	0
08/01/2020 11:00	-0.2	13.8	1,511.6	-0.1	1.1	1	1	1
08/01/2020 12:00	-1.5	12.1	2,052.7	-0.8	1.4	1	1	1
08/01/2020 13:00	-1.4	11.8	2,103.4	-0.7	1.5	1	1	1
08/01/2020 14:00	-1.4	11.7	2,108.3	-0.7	1.5	1	1	1
08/01/2020 15:00	-1.4	11.7	2,129.4	-0.7	1.5	1	1	1
08/01/2020 16:00	-1.4	11.6	2,149.5	-0.7	1.5	1	1	1
08/01/2020 17:00	-1.2	11.6	2,161.5	-0.5	1.5	1	1	1
08/01/2020 18:00	-1.2	11.6	2,154.9	-0.5	1.5	1	1	1
08/01/2020 19:00	-1.2	11.6	2,155.9	-0.5	1.5	1	1	1
08/01/2020 20:00	-1.2	11.6	2,149.8	-0.5	1.5	1	1	1
08/01/2020 21:00	-1.2	11.8	2,093.4	-0.5	1.5	1	1	1
08/01/2020 22:00	-1.2	11.9	2,087.7	-0.7	1.5	1	1	1
08/01/2020 23:00	-1.2	12.5	1,932.0	-0.7	1.4	1	1	1
Average/Sum#:	-0.8	12.7	1,826.0	-0.4	1.3	24 #	24 #	16 #
Minimum:	-1.5	11.6	1,290.5	-0.8	0.9	1	1	0
Maximum:	0.2	13.9	2,161.5	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/02/2020 00:00	0.0	13.8	1,427.2	0.1	1.0	1	1	0
08/02/2020 01:00	-0.1	13.9	1,285.3	0.0	0.9	1	1	0
08/02/2020 02:00	0.0	13.9	1,288.3	0.1	0.9	1	1	0
08/02/2020 03:00	0.1	13.9	1,292.4	0.1	0.9	1	1	0
08/02/2020 04:00	0.1	13.8	1,497.1	0.2	1.0	1	1	0
08/02/2020 05:00	0.1	13.9	1,383.8	0.1	1.0	1	1	0
08/02/2020 06:00	0.1	13.9	1,295.7	0.2	0.9	1	1	0
08/02/2020 07:00	0.1	13.9	1,293.1	0.2	0.9	1	1	0
08/02/2020 08:00	0.1	13.9	1,294.2	0.2	0.9	1	1	0
08/02/2020 09:00	0.1	13.9	1,298.7	0.2	0.9	1	1	0
08/02/2020 10:00	0.1	13.9	1,302.2	0.2	0.9	1	1	0
08/02/2020 11:00	0.1	13.9	1,304.3	0.2	0.9	1	1	0
08/02/2020 12:00	0.1	13.9	1,301.4	0.1	0.9	1	1	0
08/02/2020 13:00	0.1	13.9	1,313.6	0.1	0.9	1	1	0
08/02/2020 14:00	0.1	13.9	1,365.4	0.2	1.0	1	1	0
08/02/2020 15:00	-0.2	13.8	1,520.5	-0.1	1.1	1	1	1
08/02/2020 16:00	-1.7	12.2	2,010.3	-0.9	1.4	1	1	1
08/02/2020 17:00	-1.5	11.8	2,090.9	-0.8	1.5	1	1	1
08/02/2020 18:00	-1.4	11.8	2,093.1	-0.7	1.5	1	1	1
08/02/2020 19:00	-1.4	11.6	2,123.9	-0.7	1.5	1	1	1
08/02/2020 20:00	-1.4	11.8	2,100.9	-0.7	1.5	1	1	1
08/02/2020 21:00	-1.4	11.7	2,115.0	-0.7	1.5	1	1	1
08/02/2020 22:00	-1.4	11.8	2,094.1	-0.7	1.5	1	1	1
08/02/2020 23:00	-1.4	12.5	1,947.4	-0.8	1.4	1	1	1
Average/Sum#:	-0.4	13.2	1,585.0	-0.2	1.1	24 #	24 #	9 #
Minimum:	-1.7	11.6	1,285.3	-0.9	0.9	1	1	0
Maximum:	0.1	13.9	2,123.9	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/03/2020 00:00	-0.1	13.8	1,436.0	0.1	1.0	1	1	0
08/03/2020 01:00	-0.1	13.8	1,320.2	0.1	0.9	1	1	0
08/03/2020 02:00	-0.1	13.9	1,284.0	0.0	0.9	1	1	0
08/03/2020 03:00	0.0	13.9	1,292.9	0.1	0.9	1	1	0
08/03/2020 04:00	0.1	13.8	1,509.6	0.2	1.1	1	1	0
08/03/2020 05:00	0.1	13.8	1,490.3	0.1	1.0	1	1	0
08/03/2020 06:00	0.1	13.8	1,577.3	0.1	1.1	1	1	0
08/03/2020 07:00	0.1	13.8	1,539.3	0.2	1.1	1	1	0
08/03/2020 08:00	0.1	13.8	1,485.5	0.2	1.0	1	1	0
08/03/2020 09:00	0.0	13.8	1,375.4	0.1	1.0	1	1	0
08/03/2020 10:00	0.1	13.9	1,301.4	0.2	0.9	1	1	0
08/03/2020 11:00	0.1	13.9	1,363.0	0.2	1.0	1	1	0
08/03/2020 12:00	-0.2	13.8	1,501.1	-0.1	1.1	1	1	1
08/03/2020 13:00	-1.5	12.0	2,057.8	-0.8	1.4	1	1	1
08/03/2020 14:00	-1.4	11.8	2,097.3	-0.7	1.5	1	1	1
08/03/2020 15:00	-1.4	11.8	2,088.5	-0.7	1.5	1	1	1
08/03/2020 16:00	-1.4	11.7	2,090.2	-0.7	1.5	1	1	1
08/03/2020 17:00	-1.4	11.6	2,101.4	-0.7	1.5	1	1	1
08/03/2020 18:00	-1.4	11.6	2,094.0	-0.7	1.5	1	1	1
08/03/2020 19:00	-1.4	11.6	2,118.2	-0.7	1.5	1	1	1
08/03/2020 20:00	-1.4	11.7	2,103.1	-0.7	1.5	1	1	1
08/03/2020 21:00	-1.4	11.7	2,108.6	-0.7	1.5	1	1	1
08/03/2020 22:00	-1.4	11.8	2,095.8	-0.7	1.5	1	1	1
08/03/2020 23:00	-1.1	12.8	1,799.3	-0.7	1.3	1	1	1
Average/Sum#:	-0.6	12.9	1,717.9	-0.3	1.2	24 #	24 #	12 #
Minimum:	-1.5	11.6	1,284.0	-0.8	0.9	1	1	0
Maximum:	0.1	13.9	2,118.2	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/04/2020 00:00	-0.1	13.8	1,288.2	0.1	0.9	1	1	0
08/04/2020 01:00	0.0	13.8	1,284.7	0.1	0.9	1	1	0
08/04/2020 02:00	0.1	13.8	1,294.4	0.1	0.9	1	1	0
08/04/2020 03:00	0.0	13.8	1,290.2	0.1	0.9	1	1	0
08/04/2020 04:00	0.0	13.8	1,293.1	0.1	0.9	1	1	0
08/04/2020 05:00	0.0	13.8	1,407.2	0.1	1.0	1	1	0
08/04/2020 06:00	-0.1	13.8	1,303.5	0.1	0.9	1	1	0
08/04/2020 07:00	0.0	13.8	1,290.6	0.1	0.9	1	1	0
08/04/2020 08:00	0.1	13.8	1,291.4	0.1	0.9	1	1	0
08/04/2020 09:00	0.1	13.9	1,293.8	0.1	0.9	1	1	0
08/04/2020 10:00	0.1	13.9	1,301.9	0.2	0.9	1	1	0
08/04/2020 11:00	0.1	13.9	1,300.3	0.2	0.9	1	1	0
08/04/2020 12:00	0.1	13.9	1,438.4	0.2	1.0	1	1	0
08/04/2020 13:00	0.1	13.8	1,476.4	0.2	1.0	1	1	0
08/04/2020 14:00	0.1	13.9	1,319.8	0.1	0.9	1	1	0
08/04/2020 15:00	0.1	13.8	1,529.7	0.2	1.1	1	1	0
08/04/2020 16:00	-0.4	13.8	1,506.0	-0.2	1.1	1	1	1
08/04/2020 17:00	-1.5	11.8	2,065.6	-0.8	1.4	1	1	1
08/04/2020 18:00	-1.4	11.5	2,118.0	-0.7	1.5	1	1	1
08/04/2020 19:00	-1.4	11.5	2,121.8	-0.7	1.5	1	1	1
08/04/2020 20:00	-1.4	11.7	2,104.5	-0.7	1.5	1	1	1
08/04/2020 21:00	-1.4	11.8	2,095.2	-0.7	1.5	1	1	1
08/04/2020 22:00	-1.2	12.4	1,975.2	-0.7	1.4	1	1	1
08/04/2020 23:00	-0.8	13.0	1,784.8	-0.4	1.2	1	1	1
Average/Sum#:	-0.4	13.3	1,548.9	-0.1	1.1	24 #	24 #	8 #
Minimum:	-1.5	11.5	1,284.7	-0.8	0.9	1	1	0
Maximum:	0.1	13.9	2,121.8	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/05/2020 00:00	0.0	13.8	1,287.7	0.1	0.9	1	1	0
08/05/2020 01:00	0.1	13.8	1,288.6	0.1	0.9	1	1	0
08/05/2020 02:00	0.1	13.8	1,283.8	0.1	0.9	1	1	0
08/05/2020 03:00	0.0	13.8	1,284.0	0.1	0.9	1	1	0
08/05/2020 04:00	-0.1	13.8	1,286.1	0.1	0.9	1	1	0
08/05/2020 05:00	-0.1	13.8	1,319.3	0.1	0.9	1	1	0
08/05/2020 06:00	-0.1	13.8	1,283.7	0.1	0.9	1	1	0
08/05/2020 07:00	0.0	13.8	1,284.1	0.1	0.9	1	1	0
08/05/2020 08:00	0.1	13.8	1,286.4	0.1	0.9	1	1	0
08/05/2020 09:00	0.1	13.8	1,288.3	0.2	0.9	1	1	0
08/05/2020 10:00	0.1	13.8	1,291.1	0.2	0.9	1	1	0
08/05/2020 11:00	0.1	13.8	1,293.9	0.2	0.9	1	1	0
08/05/2020 12:00	0.1	13.9	1,293.9	0.2	0.9	1	1	0
08/05/2020 13:00	0.1	13.9	1,294.5	0.2	0.9	1	1	0
08/05/2020 14:00	0.1	13.8	1,292.5	0.1	0.9	1	1	0
08/05/2020 15:00	0.1	13.8	1,290.9	0.1	0.9	1	1	0
08/05/2020 16:00	0.1	13.8	1,299.8	0.1	0.9	1	1	0
08/05/2020 17:00	-0.9	13.1	1,762.6	-0.5	1.2	1	1	1
08/05/2020 18:00	-1.5	11.9	2,085.8	-0.8	1.5	1	1	1
08/05/2020 19:00	-1.4	12.1	2,011.9	-0.7	1.4	1	1	1
08/05/2020 20:00	0.2	13.8	1,582.2	0.3	1.1	1	1	0
08/05/2020 21:00	0.1	13.8	1,405.7	0.2	1.0	1	1	0
08/05/2020 22:00	0.1	13.8	1,386.0	0.2	1.0	1	1	0
08/05/2020 23:00	0.0	13.8	1,284.9	0.1	0.9	1	1	0
Average/Sum#:	-0.1	13.6	1,394.5	0.0	1.0	24 #	24 #	3 #
Minimum:	-1.5	11.9	1,283.7	-0.8	0.9	1	1	0
Maximum:	0.2	13.9	2,085.8	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/06/2020 00:00	0.0	13.8	1,283.5	0.1	0.9	1	1	0
08/06/2020 01:00	0.0	13.8	1,283.2	0.1	0.9	1	1	0
08/06/2020 02:00	0.0	13.8	1,283.6	0.1	0.9	1	1	0
08/06/2020 03:00	0.0	13.8	1,286.8	0.1	0.9	1	1	0
08/06/2020 04:00	0.0	13.8	1,303.4	0.1	0.9	1	1	0
08/06/2020 05:00	-0.1	13.8	1,326.8	0.1	0.9	1	1	0
08/06/2020 06:00	-0.1	13.8	1,290.6	0.1	0.9	1	1	0
08/06/2020 07:00	0.1	13.8	1,296.8	0.1	0.9	1	1	0
08/06/2020 08:00	0.1	13.8	1,298.4	0.1	0.9	1	1	0
08/06/2020 09:00	0.1	13.8	1,297.9	0.2	0.9	1	1	0
08/06/2020 10:00	0.1	13.8	1,296.8	0.2	0.9	1	1	0
08/06/2020 11:00	0.1	13.8	1,296.1	0.2	0.9	1	1	0
08/06/2020 12:00	0.1	13.9	1,296.0	0.2	0.9	1	1	0
08/06/2020 13:00	0.1	13.9	1,291.5	0.2	0.9	1	1	0
08/06/2020 14:00	0.1	13.9	1,290.9	0.1	0.9	1	1	0
08/06/2020 15:00	0.1	13.9	1,292.1	0.1	0.9	1	1	0
08/06/2020 16:00	0.1	13.9	1,289.8	0.1	0.9	1	1	0
08/06/2020 17:00	0.1	13.9	1,400.8	0.2	1.0	1	1	0
08/06/2020 18:00	0.1	13.8	1,401.5	0.2	1.0	1	1	0
08/06/2020 19:00	0.0	13.8	1,308.2	0.1	0.9	1	1	0
08/06/2020 20:00	0.0	13.8	1,284.3	0.1	0.9	1	1	0
08/06/2020 21:00	0.0	13.8	1,280.5	0.1	0.9	1	1	0
08/06/2020 22:00	-0.1	13.8	1,279.5	0.1	0.9	1	1	0
08/06/2020 23:00	-0.1	13.8	1,276.5	0.1	0.9	1	1	0
Average/Sum#:	0.0	13.8	1,301.5	0.1	0.9	24 #	24 #	0 #
Minimum:	-0.1	13.8	1,276.5	0.1	0.9	1	1	0
Maximum:	0.1	13.9	1,401.5	0.2	1.0	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/07/2020 00:00	0.0	13.8	1,283.3	0.1	0.9	1	1	0
08/07/2020 01:00	0.0	13.8	1,282.3	0.1	0.9	1	1	0
08/07/2020 02:00	0.1	13.8	1,282.5	0.1	0.9	1	1	0
08/07/2020 03:00	0.1	13.8	1,283.2	0.1	0.9	1	1	0
08/07/2020 04:00	0.0	13.8	1,327.8	0.1	0.9	1	1	0
08/07/2020 05:00	-0.2	13.8	1,317.6	0.0	0.9	1	1	0
08/07/2020 06:00	0.0	13.8	1,283.4	0.1	0.9	1	1	0
08/07/2020 07:00	0.0	13.8	1,287.6	0.1	0.9	1	1	0
08/07/2020 08:00	0.1	13.8	1,294.2	0.1	0.9	1	1	0
08/07/2020 09:00	0.1	13.9	1,297.4	0.2	0.9	1	1	0
08/07/2020 10:00	0.1	13.9	1,295.5	0.2	0.9	1	1	0
08/07/2020 11:00	0.1	13.9	1,295.8	0.2	0.9	1	1	0
08/07/2020 12:00	0.1	13.9	1,291.2	0.1	0.9	1	1	0
08/07/2020 13:00	0.1	13.9	1,347.5	0.2	0.9	1	1	0
08/07/2020 14:00	0.1	13.9	1,357.5	0.2	1.0	1	1	0
08/07/2020 15:00	0.1	13.9	1,295.0	0.1	0.9	1	1	0
08/07/2020 16:00	0.1	13.9	1,399.1	0.1	1.0	1	1	0
08/07/2020 17:00	0.1	13.8	1,464.7	0.2	1.0	1	1	0
08/07/2020 18:00	0.1	13.7	1,681.6	0.1	1.2	1	1	0
08/07/2020 19:00	0.1	13.7	1,643.7	0.1	1.2	1	1	0
08/07/2020 20:00	0.0	13.8	1,483.6	0.1	1.0	1	1	0
08/07/2020 21:00	-0.1	13.8	1,338.2	0.1	0.9	1	1	0
08/07/2020 22:00	0.1	13.8	1,391.2	0.1	1.0	1	1	0
08/07/2020 23:00	0.1	13.8	1,445.2	0.1	1.0	1	1	0
Average/Sum#:	0.1	13.8	1,361.2	0.1	1.0	24 #	24 #	0 #
Minimum:	-0.2	13.7	1,282.3	0.0	0.9	1	1	0
Maximum:	0.1	13.9	1,681.6	0.2	1.2	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/08/2020 00:00	0.0	13.8	1,350.6	0.1	0.9	1	1	0
08/08/2020 01:00	-0.1	13.8	1,283.4	0.1	0.9	1	1	0
08/08/2020 02:00	-0.1	13.8	1,280.7	0.1	0.9	1	1	0
08/08/2020 03:00	-0.1	13.8	1,284.7	0.1	0.9	1	1	0
08/08/2020 04:00	0.0	13.8	1,288.0	0.1	0.9	1	1	0
08/08/2020 05:00	-0.2	13.8	1,283.6	0.0	0.9	1	1	0
08/08/2020 06:00	-0.2	13.8	1,284.2	0.0	0.9	1	1	0
08/08/2020 07:00	0.0	13.8	1,291.8	0.1	0.9	1	1	0
08/08/2020 08:00	0.1	13.8	1,290.4	0.1	0.9	1	1	0
08/08/2020 09:00	0.1	13.8	1,292.5	0.1	0.9	1	1	0
08/08/2020 10:00	0.0	13.8	1,295.0	0.1	0.9	1	1	0
08/08/2020 11:00	0.0	13.9	1,293.2	0.1	0.9	1	1	0
08/08/2020 12:00	0.1	13.9	1,292.2	0.1	0.9	1	1	0
08/08/2020 13:00	0.1	13.9	1,415.5	0.2	1.0	1	1	0
08/08/2020 14:00	0.1	13.9	1,325.3	0.1	0.9	1	1	0
08/08/2020 15:00	0.1	13.9	1,370.9	0.2	1.0	1	1	0
08/08/2020 16:00	-0.4	13.8	1,446.5	-0.2	1.0	1	1	1
08/08/2020 17:00	-1.7	11.8	2,070.2	-0.8	1.4	1	1	1
08/08/2020 18:00	-1.2	11.4	2,149.9	-0.5	1.5	1	1	1
08/08/2020 19:00	-1.2	11.3	2,153.3	-0.5	1.5	1	1	1
08/08/2020 20:00	-1.4	11.6	2,109.5	-0.7	1.5	1	1	1
08/08/2020 21:00	-1.4	11.7	2,098.2	-0.7	1.5	1	1	1
08/08/2020 22:00	-1.4	12.2	2,002.8	-0.7	1.4	1	1	1
08/08/2020 23:00	-1.5	12.5	1,935.2	-0.9	1.4	1	1	1
Average/Sum#:	-0.4	13.2	1,537.0	-0.1	1.1	24 #	24 #	8 #
Minimum:	-1.7	11.3	1,280.7	-0.9	0.9	1	1	0
Maximum:	0.1	13.9	2,153.3	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/09/2020 00:00	-0.1	13.7	1,543.1	0.1	1.1	1	1	0
08/09/2020 01:00	-0.2	13.8	1,303.9	-0.1	0.9	1	1	0
08/09/2020 02:00	-0.2	13.8	1,279.4	0.0	0.9	1	1	0
08/09/2020 03:00	-0.1	13.8	1,285.1	0.1	0.9	1	1	0
08/09/2020 04:00	0.0	13.8	1,286.9	0.1	0.9	1	1	0
08/09/2020 05:00	0.0	13.8	1,287.5	0.1	0.9	1	1	0
08/09/2020 06:00	0.0	13.8	1,291.3	0.1	0.9	1	1	0
08/09/2020 07:00	0.1	13.8	1,294.1	0.1	0.9	1	1	0
08/09/2020 08:00	0.1	13.8	1,296.8	0.1	0.9	1	1	0
08/09/2020 09:00	0.1	13.8	1,294.8	0.1	0.9	1	1	0
08/09/2020 10:00	0.1	13.8	1,293.0	0.1	0.9	1	1	0
08/09/2020 11:00	0.1	13.9	1,295.2	0.2	0.9	1	1	0
08/09/2020 12:00	0.1	13.8	1,440.5	0.2	1.0	1	1	0
08/09/2020 13:00	0.0	13.8	1,511.7	0.1	1.1	1	1	0
08/09/2020 14:00	0.1	13.9	1,382.5	0.1	1.0	1	1	0
08/09/2020 15:00	-0.5	13.6	1,599.8	-0.2	1.1	1	1	1
08/09/2020 16:00	-1.4	11.7	2,074.2	-0.7	1.5	1	1	1
08/09/2020 17:00	-1.2	11.3	2,135.8	-0.5	1.5	1	1	1
08/09/2020 18:00	-1.1	11.3	2,143.8	-0.4	1.5	1	1	1
08/09/2020 19:00	-1.1	11.5	2,105.2	-0.5	1.5	1	1	1
08/09/2020 20:00	-1.2	11.6	2,083.6	-0.5	1.5	1	1	1
08/09/2020 21:00	-1.2	11.6	2,110.4	-0.5	1.5	1	1	1
08/09/2020 22:00	-1.2	12.1	2,009.5	-0.7	1.4	1	1	1
08/09/2020 23:00	-1.4	12.4	1,931.7	-0.8	1.4	1	1	1
Average/Sum#:	-0.4	13.1	1,595.0	-0.1	1.1	24 #	24 #	9 #
Minimum:	-1.4	11.3	1,279.4	-0.8	0.9	1	1	0
Maximum:	0.1	13.9	2,143.8	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/10/2020 00:00	0.0	13.7	1,416.0	0.1	1.0	1	1	0
08/10/2020 01:00	0.0	13.8	1,285.9	0.1	0.9	1	1	0
08/10/2020 02:00	0.0	13.8	1,293.1	0.1	0.9	1	1	0
08/10/2020 03:00	0.1	13.8	1,499.2	0.2	1.0	1	1	0
08/10/2020 04:00	0.1	13.8	1,528.1	0.2	1.1	1	1	0
08/10/2020 05:00	0.1	13.8	1,519.4	0.1	1.1	1	1	0
08/10/2020 06:00	0.1	13.7	1,614.1	0.1	1.1	1	1	0
08/10/2020 07:00	0.1	13.8	1,368.8	0.1	1.0	1	1	0
08/10/2020 08:00	0.1	13.8	1,499.3	0.2	1.0	1	1	0
08/10/2020 09:00	0.1	13.8	1,310.5	0.1	0.9	1	1	0
08/10/2020 10:00	0.1	13.8	1,523.8	0.2	1.1	1	1	0
08/10/2020 11:00	0.1	13.8	1,521.1	0.2	1.1	1	1	0
08/10/2020 12:00	0.1	13.9	1,306.0	0.1	0.9	1	1	0
08/10/2020 13:00	0.1	13.9	1,325.3	0.1	0.9	1	1	0
08/10/2020 14:00	0.1	13.9	1,332.1	0.2	0.9	1	1	0
08/10/2020 15:00	-0.4	13.6	1,639.8	-0.2	1.1	1	1	1
08/10/2020 16:00	-1.5	11.6	2,082.7	-0.8	1.5	1	1	1
08/10/2020 17:00	-1.2	11.2	2,149.8	-0.5	1.5	1	1	1
08/10/2020 18:00	-1.2	11.5	2,089.6	-0.5	1.5	1	1	1
08/10/2020 19:00	-1.4	11.8	2,051.2	-0.7	1.4	1	1	1
08/10/2020 20:00	-1.4	11.9	2,037.5	-0.7	1.4	1	1	1
08/10/2020 21:00	-1.4	12.0	2,027.7	-0.7	1.4	1	1	1
08/10/2020 22:00	-1.5	12.3	1,975.4	-0.8	1.4	1	1	1
08/10/2020 23:00	-1.1	12.9	1,778.1	-0.7	1.2	1	1	1
Average/Sum#:	-0.4	13.2	1,632.3	-0.1	1.1	24 #	24 #	9 #
Minimum:	-1.5	11.2	1,285.9	-0.8	0.9	1	1	0
Maximum:	0.1	13.9	2,149.8	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/11/2020 00:00	-0.2	13.8	1,285.0	0.0	0.9	1	1	0
08/11/2020 01:00	0.0	13.8	1,284.5	0.1	0.9	1	1	0
08/11/2020 02:00	0.0	13.8	1,287.0	0.1	0.9	1	1	0
08/11/2020 03:00	0.0	13.8	1,288.2	0.1	0.9	1	1	0
08/11/2020 04:00	0.0	13.8	1,296.4	0.1	0.9	1	1	0
08/11/2020 05:00	-0.1	13.8	1,305.9	0.1	0.9	1	1	0
08/11/2020 06:00	0.0	13.8	1,340.9	0.1	0.9	1	1	0
08/11/2020 07:00	0.0	13.8	1,290.2	0.1	0.9	1	1	0
08/11/2020 08:00	0.1	13.8	1,292.4	0.1	0.9	1	1	0
08/11/2020 09:00	0.1	13.8	1,294.6	0.1	0.9	1	1	0
08/11/2020 10:00	0.1	13.8	1,297.6	0.1	0.9	1	1	0
08/11/2020 11:00	0.1	13.8	1,300.1	0.1	0.9	1	1	0
08/11/2020 12:00	0.0	13.8	1,297.5	0.1	0.9	1	1	0
08/11/2020 13:00	0.0	13.8	1,298.2	0.1	0.9	1	1	0
08/11/2020 14:00	0.1	13.8	1,317.1	0.1	0.9	1	1	0
08/11/2020 15:00	0.1	13.8	1,332.3	0.1	0.9	1	1	0
08/11/2020 16:00	0.1	13.8	1,427.9	0.2	1.0	1	1	0
08/11/2020 17:00	0.1	13.8	1,568.3	0.2	1.1	1	1	0
08/11/2020 18:00	0.1	13.8	1,521.0	0.2	1.1	1	1	0
08/11/2020 19:00	0.1	13.8	1,377.6	0.1	1.0	1	1	0
08/11/2020 20:00	0.0	13.8	1,359.2	0.1	1.0	1	1	0
08/11/2020 21:00	0.0	13.8	1,306.5	0.1	0.9	1	1	0
08/11/2020 22:00	0.1	13.8	1,394.4	0.1	1.0	1	1	0
08/11/2020 23:00	0.0	13.8	1,300.7	0.1	0.9	1	1	0
Average/Sum#:	0.0	13.8	1,336.0	0.1	0.9	24 #	24 #	0 #
Minimum:	-0.2	13.8	1,284.5	0.0	0.9	1	1	0
Maximum:	0.1	13.8	1,568.3	0.2	1.1	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/12/2020 00:00	0.0	13.8	1,288.7	0.1	0.9	1	1	0
08/12/2020 01:00	0.0	13.8	1,311.8	0.1	0.9	1	1	0
08/12/2020 02:00	-0.1	13.8	1,288.9	0.1	0.9	1	1	0
08/12/2020 03:00	-0.1	13.8	1,292.7	0.1	0.9	1	1	0
08/12/2020 04:00	-0.2	13.8	1,312.3	0.0	0.9	1	1	0
08/12/2020 05:00	-0.2	13.8	1,304.8	0.0	0.9	1	1	0
08/12/2020 06:00	-0.2	13.8	1,299.1	0.0	0.9	1	1	0
08/12/2020 07:00	-0.1	13.8	1,313.4	0.1	0.9	1	1	0
08/12/2020 08:00	0.1	13.8	1,385.8	0.1	1.0	1	1	0
08/12/2020 09:00	0.1	13.8	1,334.8	0.1	0.9	1	1	0
08/12/2020 10:00	0.1	13.8	1,342.3	0.1	0.9	1	1	0
08/12/2020 11:00	0.1	13.8	1,386.2	0.2	1.0	1	1	0
08/12/2020 12:00	-0.2	13.7	1,644.1	-0.1	1.2	1	1	1
08/12/2020 13:00	-1.7	12.0	2,040.5	-0.9	1.4	1	1	1
08/12/2020 14:00	-1.4	11.6	2,096.4	-0.7	1.5	1	1	1
08/12/2020 15:00	-1.2	11.4	2,138.8	-0.5	1.5	1	1	1
08/12/2020 16:00	-1.2	11.4	2,135.0	-0.5	1.5	1	1	1
08/12/2020 17:00	-1.2	11.5	2,117.9	-0.5	1.5	1	1	1
08/12/2020 18:00	-1.2	11.6	2,104.3	-0.5	1.5	1	1	1
08/12/2020 19:00	-1.2	11.7	2,098.7	-0.5	1.5	1	1	1
08/12/2020 20:00	-1.4	11.9	2,061.5	-0.7	1.4	1	1	1
08/12/2020 21:00	-1.4	12.0	2,052.1	-0.7	1.4	1	1	1
08/12/2020 22:00	-1.5	12.0	2,068.1	-0.8	1.4	1	1	1
08/12/2020 23:00	-1.4	12.5	1,943.7	-0.8	1.4	1	1	1
Average/Sum#:	-0.6	12.9	1,681.7	-0.3	1.2	24 #	24 #	12 #
Minimum:	-1.7	11.4	1,288.7	-0.9	0.9	1	1	0
Maximum:	0.1	13.8	2,138.8	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/13/2020 00:00	0.1	13.8	1,680.1	0.2	1.2	1	1	0
08/13/2020 01:00	0.1	13.8	1,618.5	0.1	1.1	1	1	0
08/13/2020 02:00	0.1	13.8	1,551.6	0.2	1.1	1	1	0
08/13/2020 03:00	0.2	13.8	1,584.1	0.3	1.1	1	1	0
08/13/2020 04:00	0.2	13.8	1,590.2	0.3	1.1	1	1	0
08/13/2020 05:00	0.1	13.8	1,610.2	0.2	1.1	1	1	0
08/13/2020 06:00	0.2	13.9	1,697.3	0.3	1.2	1	1	0
08/13/2020 07:00	0.2	13.8	1,599.5	0.3	1.1	1	1	0
08/13/2020 08:00	0.2	13.8	1,679.6	0.3	1.2	1	1	0
08/13/2020 09:00	-0.2	13.8	1,603.7	-0.1	1.1	1	1	1
08/13/2020 10:00	-1.7	12.4	2,006.5	-0.9	1.4	1	1	1
08/13/2020 11:00	-1.4	11.8	2,120.2	-0.7	1.5	1	1	1
08/13/2020 12:00	-1.4	11.7	2,114.4	-0.7	1.5	1	1	1
08/13/2020 13:00	-1.4	11.8	2,097.7	-0.7	1.5	1	1	1
08/13/2020 14:00	-1.2	11.8	2,087.1	-0.5	1.5	1	1	1
08/13/2020 15:00	-1.1	11.6	2,116.5	-0.5	1.5	1	1	1
08/13/2020 16:00	-1.2	11.6	2,105.9	-0.5	1.5	1	1	1
08/13/2020 17:00	-1.1	11.6	2,118.3	-0.5	1.5	1	1	1
08/13/2020 18:00	-1.1	11.6	2,115.0	-0.5	1.5	1	1	1
08/13/2020 19:00	-1.1	11.6	2,117.0	-0.5	1.5	1	1	1
08/13/2020 20:00	-1.2	11.9	2,082.8	-0.7	1.5	1	1	1
08/13/2020 21:00	-1.4	12.0	2,063.7	-0.7	1.4	1	1	1
08/13/2020 22:00	-1.2	11.8	2,112.7	-0.5	1.5	1	1	1
08/13/2020 23:00	-1.1	11.5	2,179.2	-0.5	1.5	1	1	1
Average/Sum#:	-0.7	12.6	1,902.2	-0.3	1.3	24 #	24 #	15 #
Minimum:	-1.7	11.5	1,551.6	-0.9	1.1	1	1	0
Maximum:	0.2	13.9	2,179.2	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/14/2020 00:00	-1.1	11.5	2,187.9	-0.5	1.5	1	1	1
08/14/2020 01:00	-1.2	11.6	2,166.9	-0.5	1.5	1	1	1
08/14/2020 02:00	-1.2	11.8	2,128.4	-0.5	1.5	1	1	1
08/14/2020 03:00	-1.4	11.9	2,108.6	-0.7	1.5	1	1	1
08/14/2020 04:00	-1.1	11.6	2,168.6	-0.5	1.5	1	1	1
08/14/2020 05:00	-1.4	12.0	2,103.8	-0.7	1.5	1	1	1
08/14/2020 06:00	-1.5	12.1	2,075.3	-0.8	1.5	1	1	1
08/14/2020 07:00	-1.4	12.1	2,068.8	-0.7	1.4	1	1	1
08/14/2020 08:00	-1.4	11.9	2,097.3	-0.7	1.5	1	1	1
08/14/2020 09:00	-1.2	11.7	2,119.8	-0.5	1.5	1	1	1
08/14/2020 10:00	-1.1	11.4	2,169.8	-0.4	1.5	1	1	1
08/14/2020 11:00	-1.1	11.6	2,136.3	-0.5	1.5	1	1	1
08/14/2020 12:00	-1.1	11.5	2,151.6	-0.5	1.5	1	1	1
08/14/2020 13:00	-1.1	11.6	2,131.5	-0.5	1.5	1	1	1
08/14/2020 14:00	-1.1	11.6	2,115.3	-0.5	1.5	1	1	1
08/14/2020 15:00	-1.1	11.6	2,104.3	-0.5	1.5	1	1	1
08/14/2020 16:00	-1.2	11.7	2,081.0	-0.5	1.5	1	1	1
08/14/2020 17:00	-1.1	11.6	2,102.1	-0.5	1.5	1	1	1
08/14/2020 18:00	-1.1	11.6	2,105.7	-0.5	1.5	1	1	1
08/14/2020 19:00	-1.1	11.5	2,135.2	-0.5	1.5	1	1	1
08/14/2020 20:00	-1.1	11.4	2,155.8	-0.4	1.5	1	1	1
08/14/2020 21:00	-1.1	11.5	2,144.6	-0.5	1.5	1	1	1
08/14/2020 22:00	-1.1	11.4	2,172.8	-0.4	1.5	1	1	1
08/14/2020 23:00	-1.1	11.4	2,179.0	-0.4	1.5	1	1	1
Average/Sum#:	-1.2	11.7	2,129.6	-0.5	1.5	24 #	24 #	24 #
Minimum:	-1.5	11.4	2,068.8	-0.8	1.4	1	1	1
Maximum:	-1.1	12.1	2,187.9	-0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/15/2020 00:00	-0.9	11.4	2,183.5	-0.4	1.5	1	1	1
08/15/2020 01:00	-0.9	11.4	2,182.7	-0.4	1.5	1	1	1
08/15/2020 02:00	-1.1	11.6	2,139.3	-0.5	1.5	1	1	1
08/15/2020 03:00	-1.1	11.7	2,124.0	-0.5	1.5	1	1	1
08/15/2020 04:00	-1.2	11.9	2,108.2	-0.7	1.5	1	1	1
08/15/2020 05:00	-1.2	11.9	2,098.6	-0.7	1.5	1	1	1
08/15/2020 06:00	-1.4	11.9	2,101.5	-0.7	1.5	1	1	1
08/15/2020 07:00	-1.4	11.9	2,099.7	-0.7	1.5	1	1	1
08/15/2020 08:00	-1.4	12.3	2,011.5	-0.8	1.4	1	1	1
08/15/2020 09:00	-1.2	11.8	2,098.5	-0.5	1.5	1	1	1
08/15/2020 10:00	-1.2	11.7	2,106.4	-0.5	1.5	1	1	1
08/15/2020 11:00	-1.1	11.5	2,149.6	-0.5	1.5	1	1	1
08/15/2020 12:00	-1.1	11.3	2,171.3	-0.4	1.5	1	1	1
08/15/2020 13:00	-1.1	11.3	2,160.8	-0.4	1.5	1	1	1
08/15/2020 14:00	-0.9	11.3	2,152.7	-0.4	1.5	1	1	1
08/15/2020 15:00	-0.9	11.3	2,144.8	-0.4	1.5	1	1	1
08/15/2020 16:00	-1.1	11.3	2,143.1	-0.4	1.5	1	1	1
08/15/2020 17:00	-1.1	11.2	2,140.8	-0.4	1.5	1	1	1
08/15/2020 18:00	-0.9	11.3	2,137.6	-0.4	1.5	1	1	1
08/15/2020 19:00	-0.9	11.3	2,144.9	-0.4	1.5	1	1	1
08/15/2020 20:00	-0.9	11.3	2,165.2	-0.4	1.5	1	1	1
08/15/2020 21:00	-0.9	11.5	2,139.8	-0.4	1.5	1	1	1
08/15/2020 22:00	-0.9	11.7	2,111.9	-0.4	1.5	1	1	1
08/15/2020 23:00	-0.9	11.4	2,178.8	-0.4	1.5	1	1	1
Average/Sum#:	-1.1	11.6	2,133.1	-0.5	1.5	24 #	24 #	24 #
Minimum:	-1.4	11.2	2,011.5	-0.8	1.4	1	1	1
Maximum:	-0.9	12.3	2,183.5	-0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/16/2020 00:00	-0.8	11.3	2,187.2	-0.2	1.5	1	1	1
08/16/2020 01:00	-0.8	11.4	2,186.4	-0.2	1.5	1	1	1
08/16/2020 02:00	-0.8	11.4	2,185.3	-0.2	1.5	1	1	1
08/16/2020 03:00	-0.8	11.6	2,153.8	-0.2	1.5	1	1	1
08/16/2020 04:00	-0.8	11.4	2,182.7	-0.2	1.5	1	1	1
08/16/2020 05:00	-0.9	11.5	2,164.7	-0.4	1.5	1	1	1
08/16/2020 06:00	-0.9	11.6	2,146.0	-0.4	1.5	1	1	1
08/16/2020 07:00	-1.1	12.1	2,037.3	-0.5	1.4	1	1	1
08/16/2020 08:00	-1.2	12.4	1,982.1	-0.7	1.4	1	1	1
08/16/2020 09:00	-1.2	12.0	2,049.4	-0.7	1.4	1	1	1
08/16/2020 10:00	-1.1	12.0	2,058.1	-0.5	1.4	1	1	1
08/16/2020 11:00	-1.1	12.0	2,052.7	-0.5	1.4	1	1	1
08/16/2020 12:00	-1.1	11.8	2,081.4	-0.5	1.5	1	1	1
08/16/2020 13:00	-0.9	11.7	2,103.1	-0.4	1.5	1	1	1
08/16/2020 14:00	-0.9	11.5	2,146.6	-0.4	1.5	1	1	1
08/16/2020 15:00	-0.9	11.4	2,150.1	-0.4	1.5	1	1	1
08/16/2020 16:00	-0.9	11.3	2,162.3	-0.4	1.5	1	1	1
08/16/2020 17:00	-0.9	11.3	2,161.3	-0.4	1.5	1	1	1
08/16/2020 18:00	-0.9	11.3	2,153.3	-0.4	1.5	1	1	1
08/16/2020 19:00	-1.1	11.3	2,145.7	-0.4	1.5	1	1	1
08/16/2020 20:00	-1.1	11.4	2,146.2	-0.4	1.5	1	1	1
08/16/2020 21:00	-1.1	11.5	2,127.8	-0.5	1.5	1	1	1
08/16/2020 22:00	-1.1	11.5	2,126.3	-0.5	1.5	1	1	1
08/16/2020 23:00	-0.9	11.5	2,136.4	-0.4	1.5	1	1	1
Average/Sum#:	-1.0	11.6	2,126.1	-0.4	1.5	24 #	24 #	24 #
Minimum:	-1.2	11.3	1,982.1	-0.7	1.4	1	1	1
Maximum:	-0.8	12.4	2,187.2	-0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/17/2020 00:00	-0.9	11.5	2,147.9	-0.4	1.5	1	1	1
08/17/2020 01:00	-1.1	11.6	2,132.9	-0.5	1.5	1	1	1
08/17/2020 02:00	-1.1	11.6	2,129.3	-0.5	1.5	1	1	1
08/17/2020 03:00	-1.1	11.6	2,144.1	-0.5	1.5	1	1	1
08/17/2020 04:00	-1.1	11.6	2,142.1	-0.5	1.5	1	1	1
08/17/2020 05:00	-1.2	11.7	2,129.3	-0.5	1.5	1	1	1
08/17/2020 06:00	-1.1	11.6	2,157.3	-0.5	1.5	1	1	1
08/17/2020 07:00	-1.1	11.5	2,163.1	-0.5	1.5	1	1	1
08/17/2020 08:00	-0.9	11.6	2,147.0	-0.4	1.5	1	1	1
08/17/2020 09:00	-0.9	11.4	2,175.3	-0.4	1.5	1	1	1
08/17/2020 10:00	-0.9	11.3	2,178.6	-0.4	1.5	1	1	1
08/17/2020 11:00	-0.9	11.5	2,135.8	-0.4	1.5	1	1	1
08/17/2020 12:00	-0.9	11.5	2,152.4	-0.4	1.5	1	1	1
08/17/2020 13:00	-0.9	11.6	2,107.7	-0.4	1.5	1	1	1
08/17/2020 14:00	-0.9	11.6	2,116.7	-0.4	1.5	1	1	1
08/17/2020 15:00	-0.8	11.3	2,166.6	-0.2	1.5	1	1	1
08/17/2020 16:00	-0.8	11.3	2,170.8	-0.2	1.5	1	1	1
08/17/2020 17:00	-0.9	11.6	2,121.9	-0.4	1.5	1	1	1
08/17/2020 18:00	-1.1	11.8	2,089.1	-0.5	1.5	1	1	1
08/17/2020 19:00	-1.1	11.8	2,089.4	-0.5	1.5	1	1	1
08/17/2020 20:00	-1.1	11.7	2,120.7	-0.5	1.5	1	1	1
08/17/2020 21:00	-0.9	11.4	2,167.2	-0.4	1.5	1	1	1
08/17/2020 22:00	-0.9	11.5	2,150.3	-0.4	1.5	1	1	1
08/17/2020 23:00	-0.9	11.6	2,148.8	-0.4	1.5	1	1	1
Average/Sum#:	-1.0	11.6	2,141.0	-0.4	1.5	24 #	24 #	24 #
Minimum:	-1.2	11.3	2,089.1	-0.5	1.5	1	1	1
Maximum:	-0.8	11.8	2,178.6	-0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	VOC, Ppm 1 Hour(s)	O2, Dry, Pct 1 Hour(s)	HI, MBtuPerHr 1 Hour(s)	VOC, Ppmvdc 1 Hour(s)	VOC, LbPerHr 1 Hour(s)	UnitOn, TF 1 Hour(s)	NormalOp, TF 1 Hour(s)	DBOn, TF 1 Hour(s)
08/18/2020 00:00	-1.1	11.8	2,098.0	-0.5	1.5	1	1	1
08/18/2020 01:00	-0.9	11.6	2,135.2	-0.4	1.5	1	1	1
08/18/2020 02:00	-0.9	11.5	2,153.5	-0.4	1.5	1	1	1
08/18/2020 03:00	-1.1	11.8	2,116.8	-0.5	1.5	1	1	1
08/18/2020 04:00	-1.1	11.6	2,133.5	-0.5	1.5	1	1	1
08/18/2020 05:00	-1.1	11.7	2,124.5	-0.5	1.5	1	1	1
08/18/2020 06:00	-1.1	11.5	2,157.1	-0.5	1.5	1	1	1
08/18/2020 07:00	-1.1	11.7	2,125.3	-0.5	1.5	1	1	1
08/18/2020 08:00	-1.1	11.8	2,101.0	-0.5	1.5	1	1	1
08/18/2020 09:00	-1.1	11.7	2,093.7	-0.5	1.5	1	1	1
08/18/2020 10:00	-1.1	11.6	2,110.9	-0.5	1.5	1	1	1
08/18/2020 11:00	-1.1	11.7	2,069.5	-0.5	1.4	1	1	1
08/18/2020 12:00	-0.9	11.4	2,134.0	-0.4	1.5	1	1	1
08/18/2020 13:00	-0.9	11.3	2,143.3	-0.4	1.5	1	1	1
08/18/2020 14:00	-0.8	11.3	2,150.8	-0.2	1.5	1	1	1
08/18/2020 15:00	-0.8	11.3	2,142.5	-0.2	1.5	1	1	1
08/18/2020 16:00	-0.9	11.2	2,141.8	-0.4	1.5	1	1	1
08/18/2020 17:00	-0.8	11.2	2,146.7	-0.2	1.5	1	1	1
08/18/2020 18:00	-0.9	11.2	2,151.6	-0.4	1.5	1	1	1
08/18/2020 19:00	-0.8	11.2	2,160.3	-0.2	1.5	1	1	1
08/18/2020 20:00	-0.8	11.3	2,169.4	-0.2	1.5	1	1	1
08/18/2020 21:00	-0.8	11.5	2,150.8	-0.2	1.5	1	1	1
08/18/2020 22:00	-0.8	11.4	2,174.2	-0.2	1.5	1	1	1
08/18/2020 23:00	-0.8	11.5	2,181.3	-0.2	1.5	1	1	1
Average/Sum#:	-1.0	11.5	2,136.1	-0.4	1.5	24 #	24 #	24 #
Minimum:	-1.1	11.2	2,069.5	-0.5	1.4	1	1	1
Maximum:	-0.8	11.8	2,181.3	-0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/19/2020 00:00	-0.8	11.6	2,141.3	-0.2	1.5	1	1	1
08/19/2020 01:00	-0.8	11.6	2,137.3	-0.2	1.5	1	1	1
08/19/2020 02:00	-0.8	11.6	2,137.9	-0.2	1.5	1	1	1
08/19/2020 03:00	-1.1	11.8	2,110.3	-0.5	1.5	1	1	1
08/19/2020 04:00	-1.1	11.8	2,124.0	-0.5	1.5	1	1	1
08/19/2020 05:00	-1.2	11.8	2,114.3	-0.5	1.5	1	1	1
08/19/2020 06:00	-1.2	11.9	2,108.5	-0.7	1.5	1	1	1
08/19/2020 07:00	-1.1	11.6	2,161.1	-0.5	1.5	1	1	1
08/19/2020 08:00	-1.2	11.9	2,097.6	-0.7	1.5	1	1	1
08/19/2020 09:00	-1.1	11.5	2,163.5	-0.5	1.5	1	1	1
08/19/2020 10:00	-0.9	11.4	2,176.1	-0.4	1.5	1	1	1
08/19/2020 11:00	-0.9	11.3	2,162.9	-0.4	1.5	1	1	1
08/19/2020 12:00	-0.9	11.4	2,130.8	-0.4	1.5	1	1	1
08/19/2020 13:00	-0.9	11.4	2,157.3	-0.4	1.5	1	1	1
08/19/2020 14:00	-0.8	11.3	2,154.6	-0.2	1.5	1	1	1
08/19/2020 15:00	-0.8	11.2	2,144.5	-0.2	1.5	1	1	1
08/19/2020 16:00	-0.8	11.3	2,146.0	-0.2	1.5	1	1	1
08/19/2020 17:00	-0.9	11.4	2,153.3	-0.4	1.5	1	1	1
08/19/2020 18:00	-0.8	11.4	2,173.5	-0.2	1.5	1	1	1
08/19/2020 19:00	-0.9	11.6	2,149.7	-0.4	1.5	1	1	1
08/19/2020 20:00	-0.9	11.6	2,149.0	-0.4	1.5	1	1	1
08/19/2020 21:00	-1.1	11.8	2,118.7	-0.5	1.5	1	1	1
08/19/2020 22:00	-1.1	12.0	2,097.9	-0.5	1.5	1	1	1
08/19/2020 23:00	-1.1	12.1	2,073.4	-0.5	1.5	1	1	1
Average/Sum#:	-1.0	11.6	2,136.8	-0.4	1.5	24 #	24 #	24 #
Minimum:	-1.2	11.2	2,073.4	-0.7	1.5	1	1	1
Maximum:	-0.8	12.1	2,176.1	-0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/20/2020 00:00	-1.2	12.1	2,075.8	-0.7	1.5	1	1	1
08/20/2020 01:00	-1.2	12.2	2,064.4	-0.7	1.4	1	1	1
08/20/2020 02:00	-1.2	12.2	2,047.5	-0.7	1.4	1	1	1
08/20/2020 03:00	-1.2	12.2	2,052.8	-0.7	1.4	1	1	1
08/20/2020 04:00	-1.2	12.1	2,059.3	-0.7	1.4	1	1	1
08/20/2020 05:00	-1.4	12.1	2,067.5	-0.7	1.4	1	1	1
08/20/2020 06:00	-1.4	12.2	2,050.6	-0.7	1.4	1	1	1
08/20/2020 07:00	-1.4	12.2	2,048.8	-0.7	1.4	1	1	1
08/20/2020 08:00	-1.4	12.1	2,053.6	-0.7	1.4	1	1	1
08/20/2020 09:00	-1.2	12.0	2,069.7	-0.7	1.4	1	1	1
08/20/2020 10:00	-1.2	11.9	2,082.6	-0.7	1.5	1	1	1
08/20/2020 11:00	-1.2	12.0	2,075.5	-0.7	1.5	1	1	1
08/20/2020 12:00	-1.2	11.9	2,089.7	-0.7	1.5	1	1	1
08/20/2020 13:00	-1.2	11.9	2,088.4	-0.7	1.5	1	1	1
08/20/2020 14:00	-1.4	12.0	2,072.1	-0.7	1.5	1	1	1
08/20/2020 15:00	-1.4	12.0	2,064.1	-0.7	1.4	1	1	1
08/20/2020 16:00	-1.4	11.9	2,061.1	-0.7	1.4	1	1	1
08/20/2020 17:00	-1.5	11.8	2,085.0	-0.8	1.5	1	1	1
08/20/2020 18:00	-1.4	11.8	2,086.6	-0.7	1.5	1	1	1
08/20/2020 19:00	-1.5	11.8	2,088.7	-0.8	1.5	1	1	1
08/20/2020 20:00	-1.4	11.7	2,092.7	-0.7	1.5	1	1	1
08/20/2020 21:00	-1.4	11.8	2,082.3	-0.7	1.5	1	1	1
08/20/2020 22:00	-1.4	11.8	2,069.2	-0.7	1.4	1	1	1
08/20/2020 23:00	-0.9	11.7	2,084.0	-0.4	1.5	1	1	1
Average/Sum#:	-1.3	12.0	2,071.3	-0.7	1.5	24 #	24 #	24 #
Minimum:	-1.5	11.7	2,047.5	-0.8	1.4	1	1	1
Maximum:	-0.9	12.2	2,092.7	-0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/21/2020 00:00	-0.7	11.6	2,099.4	-0.2	1.5	1	1	1
08/21/2020 01:00	-0.8	11.7	2,080.3	-0.2	1.5	1	1	1
08/21/2020 02:00	-0.8	12.2	1,980.8	-0.4	1.4	1	1	1
08/21/2020 03:00	-0.8	11.7	2,081.2	-0.2	1.5	1	1	1
08/21/2020 04:00	-0.7	11.6	2,093.4	-0.2	1.5	1	1	1
08/21/2020 05:00	-0.8	0.0	2,083.6	0.2	1.5	1	1	1
08/21/2020 06:00	-0.8	0.0	2,116.1	0.2	1.5	1	1	1
08/21/2020 07:00	-0.7	0.0	2,109.1	0.2	1.5	1	1	1
08/21/2020 08:00	-0.7	0.0	2,088.0	0.2	1.5	1	1	1
08/21/2020 09:00	-0.7	0.0	2,119.9	0.2	1.5	1	1	1
08/21/2020 10:00	-0.7	0.0	2,126.5	0.2	1.5	1	1	1
08/21/2020 11:00	-0.4	0.0	2,131.5	0.4	1.5	1	1	1
08/21/2020 12:00	-0.8	12.0	2,086.6	-0.4	1.5	1	1	1
08/21/2020 13:00	-0.4	11.7	2,086.3	0.1	1.5	1	1	1
08/21/2020 14:00	-0.4	11.9	2,034.2	-0.1	1.4	1	1	1
08/21/2020 15:00	-0.8	11.9	2,071.7	-0.4	1.5	1	1	1
08/21/2020 16:00	-0.9	11.7	2,132.2	-0.4	1.5	1	1	1
08/21/2020 17:00	-0.9	11.6	2,143.3	-0.4	1.5	1	1	1
08/21/2020 18:00	-0.9	11.7	2,118.4	-0.4	1.5	1	1	1
08/21/2020 19:00	-1.1	11.9	2,087.5	-0.5	1.5	1	1	1
08/21/2020 20:00	-1.1	11.8	2,102.3	-0.5	1.5	1	1	1
08/21/2020 21:00	-1.1	12.0	2,081.8	-0.5	1.5	1	1	1
08/21/2020 22:00	-1.1	11.9	2,098.9	-0.5	1.5	1	1	1
08/21/2020 23:00	-1.1	11.8	2,111.5	-0.5	1.5	1	1	1
Average/Sum#:	-0.8	11.8	2,094.4	-0.3	1.5	24 #	24 #	24 #
Minimum:	-1.1	11.6	1,980.8	-0.5	1.4	1	1	1
Maximum:	-0.4	12.2	2,143.3	0.1	1.5	1	1	1
%SI	0.00	29.17	0.00	29.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/22/2020 00:00	-0.9	11.8	2,116.8	-0.4	1.5	1	1	1
08/22/2020 01:00	-0.9	12.5	1,942.8	-0.5	1.4	1	1	1
08/22/2020 02:00	0.4	13.8	1,670.8	0.4	1.2	1	1	0
08/22/2020 03:00	0.3	13.9	1,539.8	0.4	1.1	1	1	0
08/22/2020 04:00	0.2	13.8	1,663.0	0.3	1.2	1	1	0
08/22/2020 05:00	0.1	13.8	1,689.1	0.2	1.2	1	1	0
08/22/2020 06:00	0.2	13.8	1,688.3	0.3	1.2	1	1	0
08/22/2020 07:00	0.3	13.8	1,680.0	0.4	1.2	1	1	0
08/22/2020 08:00	0.3	13.8	1,673.5	0.4	1.2	1	1	0
08/22/2020 09:00	0.3	13.8	1,653.0	0.4	1.2	1	1	0
08/22/2020 10:00	-0.2	13.8	1,568.2	-0.1	1.1	1	1	1
08/22/2020 11:00	-1.5	12.1	2,044.5	-0.8	1.4	1	1	1
08/22/2020 12:00	-1.2	11.5	2,130.6	-0.5	1.5	1	1	1
08/22/2020 13:00	-1.1	11.4	2,145.7	-0.4	1.5	1	1	1
08/22/2020 14:00	-1.2	11.6	2,099.0	-0.5	1.5	1	1	1
08/22/2020 15:00	-1.1	11.3	2,152.1	-0.4	1.5	1	1	1
08/22/2020 16:00	-1.1	11.2	2,161.3	-0.4	1.5	1	1	1
08/22/2020 17:00	-1.1	11.3	2,124.6	-0.4	1.5	1	1	1
08/22/2020 18:00	-1.1	11.5	2,106.9	-0.5	1.5	1	1	1
08/22/2020 19:00	-1.1	11.6	2,098.7	-0.5	1.5	1	1	1
08/22/2020 20:00	-1.1	11.6	2,085.6	-0.5	1.5	1	1	1
08/22/2020 21:00	-0.9	11.4	2,132.2	-0.4	1.5	1	1	1
08/22/2020 22:00	-0.9	11.6	2,106.8	-0.4	1.5	1	1	1
08/22/2020 23:00	-0.9	11.4	2,137.4	-0.4	1.5	1	1	1
Average/Sum#:	-0.6	12.4	1,933.8	-0.2	1.4	24 #	24 #	16 #
Minimum:	-1.5	11.2	1,539.8	-0.8	1.1	1	1	0
Maximum:	0.4	13.9	2,161.3	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/23/2020 00:00	-1.1	11.7	2,096.8	-0.5	1.5	1	1	1
08/23/2020 01:00	-1.1	11.9	2,059.8	-0.5	1.4	1	1	1
08/23/2020 02:00	-1.1	11.8	2,081.4	-0.5	1.5	1	1	1
08/23/2020 03:00	-1.1	11.9	2,065.7	-0.5	1.4	1	1	1
08/23/2020 04:00	-1.1	12.4	1,949.8	-0.5	1.4	1	1	1
08/23/2020 05:00	0.3	13.7	1,688.4	0.4	1.2	1	1	0
08/23/2020 06:00	0.3	13.7	1,637.8	0.4	1.1	1	1	0
08/23/2020 07:00	0.3	13.7	1,584.7	0.4	1.1	1	1	0
08/23/2020 08:00	0.3	13.6	1,649.5	0.4	1.2	1	1	0
08/23/2020 09:00	0.4	13.6	1,616.9	0.4	1.1	1	1	0
08/23/2020 10:00	0.1	13.7	1,536.0	0.2	1.1	1	1	1
08/23/2020 11:00	-1.2	11.9	2,043.9	-0.7	1.4	1	1	1
08/23/2020 12:00	-0.9	11.5	2,127.5	-0.4	1.5	1	1	1
08/23/2020 13:00	-0.9	11.4	2,125.7	-0.4	1.5	1	1	1
08/23/2020 14:00	-0.9	11.4	2,118.2	-0.4	1.5	1	1	1
08/23/2020 15:00	-0.9	11.2	2,155.8	-0.4	1.5	1	1	1
08/23/2020 16:00	-0.8	11.1	2,157.6	-0.2	1.5	1	1	1
08/23/2020 17:00	-0.8	11.0	2,162.2	-0.2	1.5	1	1	1
08/23/2020 18:00	-0.8	11.0	2,163.3	-0.2	1.5	1	1	1
08/23/2020 19:00	-0.8	11.1	2,168.1	-0.2	1.5	1	1	1
08/23/2020 20:00	-0.9	11.1	2,178.8	-0.4	1.5	1	1	1
08/23/2020 21:00	-0.9	11.4	2,137.0	-0.4	1.5	1	1	1
08/23/2020 22:00	-1.1	11.5	2,118.5	-0.5	1.5	1	1	1
08/23/2020 23:00	-1.2	11.5	2,116.4	-0.5	1.5	1	1	1
Average/Sum#:	-0.7	12.0	1,989.2	-0.2	1.4	24 #	24 #	19 #
Minimum:	-1.2	11.0	1,536.0	-0.7	1.1	1	1	0
Maximum:	0.4	13.7	2,178.8	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/24/2020 00:00	-1.1	11.5	2,125.6	-0.5	1.5	1	1	1
08/24/2020 01:00	-1.1	11.5	2,119.2	-0.5	1.5	1	1	1
08/24/2020 02:00	-1.1	11.4	2,139.1	-0.4	1.5	1	1	1
08/24/2020 03:00	-1.1	11.3	2,162.5	-0.4	1.5	1	1	1
08/24/2020 04:00	-0.9	11.4	2,146.4	-0.4	1.5	1	1	1
08/24/2020 05:00	-1.1	11.4	2,137.3	-0.4	1.5	1	1	1
08/24/2020 06:00	-1.1	11.5	2,126.2	-0.5	1.5	1	1	1
08/24/2020 07:00	-1.2	11.7	2,095.1	-0.5	1.5	1	1	1
08/24/2020 08:00	-1.2	11.7	2,086.9	-0.5	1.5	1	1	1
08/24/2020 09:00	-1.1	11.5	2,106.7	-0.5	1.5	1	1	1
08/24/2020 10:00	-0.9	11.4	2,149.2	-0.4	1.5	1	1	1
08/24/2020 11:00	-0.9	11.9	2,162.0	-0.4	1.5	1	1	1
08/24/2020 12:00	-0.9	12.1	2,138.3	-0.4	1.5	1	1	1
08/24/2020 13:00	-0.9	11.9	2,145.0	-0.4	1.5	1	1	1
08/24/2020 14:00	-0.9	12.0	2,116.6	-0.4	1.5	1	1	1
08/24/2020 15:00	-0.8	11.9	2,132.6	-0.4	1.5	1	1	1
08/24/2020 16:00	-0.9	11.8	2,150.9	-0.4	1.5	1	1	1
08/24/2020 17:00	-0.9	11.8	2,147.6	-0.4	1.5	1	1	1
08/24/2020 18:00	-0.9	11.8	2,152.1	-0.4	1.5	1	1	1
08/24/2020 19:00	-0.9	12.0	2,110.0	-0.4	1.5	1	1	1
08/24/2020 20:00	-0.9	12.0	2,130.4	-0.4	1.5	1	1	1
08/24/2020 21:00	-1.1	12.0	2,126.5	-0.5	1.5	1	1	1
08/24/2020 22:00	-1.1	12.1	2,130.9	-0.5	1.5	1	1	1
08/24/2020 23:00	-1.1	12.1	2,125.4	-0.5	1.5	1	1	1
Average/Sum#:	-1.0	11.7	2,131.8	-0.4	1.5	24 #	24 #	24 #
Minimum:	-1.2	11.3	2,086.9	-0.5	1.5	1	1	1
Maximum:	-0.8	12.1	2,162.5	-0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/25/2020 00:00	-1.1	12.2	2,096.7	-0.5	1.5	1	1	1
08/25/2020 01:00	-1.1	12.2	2,088.1	-0.5	1.5	1	1	1
08/25/2020 02:00	-1.1	12.3	2,079.2	-0.5	1.5	1	1	1
08/25/2020 03:00	-1.2	12.7	2,021.9	-0.7	1.4	1	1	1
08/25/2020 04:00	-1.2	12.4	2,067.9	-0.7	1.4	1	1	1
08/25/2020 05:00	-1.2	12.4	2,074.6	-0.7	1.5	1	1	1
08/25/2020 06:00	-1.2	12.4	2,079.3	-0.7	1.5	1	1	1
08/25/2020 07:00	-1.2	12.5	2,062.8	-0.7	1.4	1	1	1
08/25/2020 08:00	-1.1	12.5	2,066.0	-0.5	1.4	1	1	1
08/25/2020 09:00	-1.1	12.3	2,086.6	-0.5	1.5	1	1	1
08/25/2020 10:00	-0.9	12.3	2,096.1	-0.5	1.5	1	1	1
08/25/2020 11:00	-0.9	12.3	2,088.2	-0.5	1.5	1	1	1
08/25/2020 12:00	-0.9	12.2	2,084.5	-0.4	1.5	1	1	1
08/25/2020 13:00	-0.9	12.2	2,087.7	-0.4	1.5	1	1	1
08/25/2020 14:00	-0.9	12.1	2,090.9	-0.4	1.5	1	1	1
08/25/2020 15:00	-0.9	12.0	2,097.9	-0.4	1.5	1	1	1
08/25/2020 16:00	-0.9	11.9	2,120.9	-0.4	1.5	1	1	1
08/25/2020 17:00	-0.9	11.8	2,151.1	-0.4	1.5	1	1	1
08/25/2020 18:00	-0.8	11.7	2,164.3	-0.2	1.5	1	1	1
08/25/2020 19:00	-0.8	11.7	2,162.3	-0.2	1.5	1	1	1
08/25/2020 20:00	-0.9	12.0	2,120.9	-0.4	1.5	1	1	1
08/25/2020 21:00	-0.9	12.0	2,107.4	-0.4	1.5	1	1	1
08/25/2020 22:00	-1.1	12.1	2,097.1	-0.5	1.5	1	1	1
08/25/2020 23:00	-1.1	12.1	2,096.9	-0.5	1.5	1	1	1
Average/Sum#:	-1.0	12.2	2,095.4	-0.5	1.5	24 #	24 #	24 #
Minimum:	-1.2	11.7	2,021.9	-0.7	1.4	1	1	1
Maximum:	-0.8	12.7	2,164.3	-0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/26/2020 00:00	-1.1	12.4	2,060.4	-0.5	1.4	1	1	1
08/26/2020 01:00	-1.2	12.9	1,955.0	-0.8	1.4	1	1	1
08/26/2020 02:00	-1.2	13.0	1,956.7	-0.8	1.4	1	1	1
08/26/2020 03:00	-1.2	12.5	2,053.0	-0.7	1.4	1	1	1
08/26/2020 04:00	-1.2	12.5	2,064.3	-0.7	1.4	1	1	1
08/26/2020 05:00	-1.1	12.5	2,067.7	-0.5	1.4	1	1	1
08/26/2020 06:00	-1.2	12.5	2,067.5	-0.7	1.4	1	1	1
08/26/2020 07:00	-1.1	13.0	1,955.3	-0.7	1.4	1	1	1
08/26/2020 08:00	-1.2	13.0	1,958.9	-0.8	1.4	1	1	1
08/26/2020 09:00	-1.1	12.4	2,071.7	-0.5	1.5	1	1	1
08/26/2020 10:00	-1.1	12.3	2,099.5	-0.5	1.5	1	1	1
08/26/2020 11:00	-0.9	12.2	2,095.0	-0.4	1.5	1	1	1
08/26/2020 12:00	-0.9	12.1	2,105.0	-0.4	1.5	1	1	1
08/26/2020 13:00	-0.9	12.1	2,102.9	-0.4	1.5	1	1	1
08/26/2020 14:00	-0.8	11.9	2,126.4	-0.4	1.5	1	1	1
08/26/2020 15:00	-0.8	11.7	2,154.4	-0.2	1.5	1	1	1
08/26/2020 16:00	-0.9	12.1	2,079.4	-0.4	1.5	1	1	1
08/26/2020 17:00	-0.9	12.2	2,059.5	-0.4	1.4	1	1	1
08/26/2020 18:00	-0.9	12.2	2,060.7	-0.4	1.4	1	1	1
08/26/2020 19:00	-0.9	12.3	2,052.0	-0.5	1.4	1	1	1
08/26/2020 20:00	-1.1	12.5	2,035.7	-0.5	1.4	1	1	1
08/26/2020 21:00	-1.1	12.6	2,021.4	-0.7	1.4	1	1	1
08/26/2020 22:00	-1.1	12.9	1,960.4	-0.7	1.4	1	1	1
08/26/2020 23:00	-1.1	13.0	1,948.0	-0.7	1.4	1	1	1
Average/Sum#:	-1.0	12.5	2,046.3	-0.6	1.4	24 #	24 #	24 #
Minimum:	-1.2	11.7	1,948.0	-0.8	1.4	1	1	1
Maximum:	-0.8	13.0	2,154.4	-0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/27/2020 00:00	-1.1	13.1	1,941.9	-0.7	1.4	1	1	1
08/27/2020 01:00	-1.1	13.1	1,940.0	-0.7	1.4	1	1	1
08/27/2020 02:00	-0.9	13.1	1,939.9	-0.5	1.4	1	1	1
08/27/2020 03:00	-0.7	13.1	1,954.4	-0.4	1.4	1	1	1
08/27/2020 04:00	-0.8	12.5	2,065.4	-0.4	1.4	1	1	1
08/27/2020 05:00	-0.7	12.5	2,067.8	-0.2	1.4	1	1	1
08/27/2020 06:00	-0.7	12.4	2,086.7	-0.2	1.5	1	1	1
08/27/2020 07:00	-1.1	13.1	1,951.4	-0.7	1.4	1	1	1
08/27/2020 08:00	-1.1	12.7	2,018.3	-0.7	1.4	1	1	1
08/27/2020 09:00	-1.1	12.7	2,017.7	-0.7	1.4	1	1	1
08/27/2020 10:00	-1.1	12.6	2,015.6	-0.7	1.4	1	1	1
08/27/2020 11:00	-0.8	12.0	2,151.9	-0.4	1.5	1	1	1
08/27/2020 12:00	-0.7	11.8	2,177.8	-0.2	1.5	1	1	1
08/27/2020 13:00	-0.7	11.8	2,174.1	-0.2	1.5	1	1	1
08/27/2020 14:00	-0.7	11.5	2,166.7	-0.2	1.5	1	1	1
08/27/2020 15:00	-0.7	11.5	2,173.4	-0.2	1.5	1	1	1
08/27/2020 16:00	-0.9	12.0	2,087.0	-0.4	1.5	1	1	1
08/27/2020 17:00	-0.9	11.9	2,092.6	-0.4	1.5	1	1	1
08/27/2020 18:00	-0.9	11.9	2,099.6	-0.4	1.5	1	1	1
08/27/2020 19:00	-0.8	11.8	2,135.9	-0.2	1.5	1	1	1
08/27/2020 20:00	-0.9	11.7	2,154.5	-0.4	1.5	1	1	1
08/27/2020 21:00	-0.9	11.5	2,184.2	-0.4	1.5	1	1	1
08/27/2020 22:00	-0.9	11.5	2,186.5	-0.4	1.5	1	1	1
08/27/2020 23:00	-1.2	12.3	2,037.7	-0.7	1.4	1	1	1
Average/Sum#:	-0.9	12.3	2,075.9	-0.4	1.5	24 #	24 #	24 #
Minimum:	-1.2	11.5	1,939.9	-0.7	1.4	1	1	1
Maximum:	-0.7	13.1	2,186.5	-0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/28/2020 00:00	-1.2	12.7	1,935.7	-0.7	1.4	1	1	1
08/28/2020 01:00	0.2	13.9	1,524.3	0.3	1.1	1	1	0
08/28/2020 02:00	0.4	14.0	1,449.8	0.4	1.0	1	1	0
08/28/2020 03:00	0.2	14.0	1,288.9	0.3	0.9	1	1	0
08/28/2020 04:00	0.4	14.0	1,473.3	0.4	1.0	1	1	0
08/28/2020 05:00	0.3	14.0	1,595.0	0.4	1.1	1	1	0
08/28/2020 06:00	0.2	14.0	1,454.6	0.3	1.0	1	1	0
08/28/2020 07:00	0.1	14.0	1,375.4	0.2	1.0	1	1	0
08/28/2020 08:00	0.2	14.0	1,396.1	0.3	1.0	1	1	0
08/28/2020 09:00	0.3	14.0	1,426.6	0.4	1.0	1	1	0
08/28/2020 10:00	0.4	14.0	1,461.0	0.4	1.0	1	1	0
08/28/2020 11:00	0.3	13.9	1,514.1	0.4	1.1	1	1	0
08/28/2020 12:00	-1.4	12.0	2,058.2	-0.7	1.4	1	1	1
08/28/2020 13:00	-1.1	11.4	2,176.6	-0.4	1.5	1	1	1
08/28/2020 14:00	-1.1	11.4	2,169.6	-0.4	1.5	1	1	1
08/28/2020 15:00	-1.1	11.4	2,165.3	-0.4	1.5	1	1	1
08/28/2020 16:00	-1.1	11.4	2,173.3	-0.4	1.5	1	1	1
08/28/2020 17:00	-0.9	11.4	2,163.3	-0.4	1.5	1	1	1
08/28/2020 18:00	-1.1	11.5	2,151.2	-0.5	1.5	1	1	1
08/28/2020 19:00	-1.1	12.0	2,059.6	-0.5	1.4	1	1	1
08/28/2020 20:00	-1.2	12.1	2,046.1	-0.7	1.4	1	1	1
08/28/2020 21:00	-1.2	12.2	2,045.5	-0.7	1.4	1	1	1
08/28/2020 22:00	-1.2	12.4	1,994.0	-0.7	1.4	1	1	1
08/28/2020 23:00	-1.2	12.0	2,090.7	-0.7	1.5	1	1	1
Average/Sum#:	-0.5	12.8	1,799.5	-0.1	1.3	24 #	24 #	13 #
Minimum:	-1.4	11.4	1,288.9	-0.7	0.9	1	1	0
Maximum:	0.4	14.0	2,176.6	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/29/2020 00:00	-1.2	11.9	2,100.2	-0.7	1.5	1	1	1
08/29/2020 01:00	-1.2	12.0	2,098.1	-0.7	1.5	1	1	1
08/29/2020 02:00	-1.2	12.2	2,069.6	-0.7	1.4	1	1	1
08/29/2020 03:00	-1.2	12.7	1,949.2	-0.7	1.4	1	1	1
08/29/2020 04:00	0.2	13.9	1,606.0	0.3	1.1	1	1	0
08/29/2020 05:00	0.1	13.9	1,586.5	0.2	1.1	1	1	0
08/29/2020 06:00	0.1	13.9	1,559.4	0.2	1.1	1	1	0
08/29/2020 07:00	0.1	13.9	1,428.6	0.2	1.0	1	1	0
08/29/2020 08:00	0.2	13.9	1,381.1	0.3	1.0	1	1	0
08/29/2020 09:00	0.1	14.0	1,282.5	0.2	0.9	1	1	0
08/29/2020 10:00	0.2	14.0	1,295.9	0.3	0.9	1	1	0
08/29/2020 11:00	0.3	14.0	1,329.1	0.4	0.9	1	1	0
08/29/2020 12:00	0.2	14.0	1,287.9	0.3	0.9	1	1	0
08/29/2020 13:00	0.3	13.9	1,589.9	0.4	1.1	1	1	0
08/29/2020 14:00	0.3	13.9	1,597.3	0.4	1.1	1	1	0
08/29/2020 15:00	0.2	13.8	1,604.5	0.3	1.1	1	1	0
08/29/2020 16:00	-0.1	13.8	1,654.1	0.1	1.2	1	1	1
08/29/2020 17:00	-1.4	11.9	2,065.0	-0.7	1.4	1	1	1
08/29/2020 18:00	-1.1	11.6	2,109.7	-0.5	1.5	1	1	1
08/29/2020 19:00	-1.1	11.7	2,110.7	-0.5	1.5	1	1	1
08/29/2020 20:00	-1.1	11.4	2,172.4	-0.4	1.5	1	1	1
08/29/2020 21:00	-1.1	11.6	2,145.4	-0.5	1.5	1	1	1
08/29/2020 22:00	-1.4	12.3	2,023.0	-0.8	1.4	1	1	1
08/29/2020 23:00	-1.4	12.4	2,018.0	-0.8	1.4	1	1	1
Average/Sum#:	-0.5	13.0	1,752.7	-0.1	1.2	24 #	24 #	12 #
Minimum:	-1.4	11.4	1,282.5	-0.8	0.9	1	1	0
Maximum:	0.3	14.0	2,172.4	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/30/2020 00:00	-1.2	12.7	1,930.6	-0.7	1.4	1	1	1
08/30/2020 01:00	0.2	13.7	1,750.8	0.3	1.2	1	1	0
08/30/2020 02:00	0.2	13.7	1,754.2	0.3	1.2	1	1	0
08/30/2020 03:00	0.2	13.7	1,754.7	0.3	1.2	1	1	0
08/30/2020 04:00	0.2	13.8	1,755.6	0.3	1.2	1	1	0
08/30/2020 05:00	0.2	13.7	1,747.0	0.3	1.2	1	1	0
08/30/2020 06:00	0.2	13.8	1,747.0	0.3	1.2	1	1	0
08/30/2020 07:00	0.3	13.7	1,750.7	0.4	1.2	1	1	0
08/30/2020 08:00	0.2	13.7	1,756.7	0.3	1.2	1	1	0
08/30/2020 09:00	0.2	13.6	1,763.4	0.3	1.2	1	1	0
08/30/2020 10:00	0.2	13.6	1,761.2	0.3	1.2	1	1	0
08/30/2020 11:00	0.2	13.6	1,753.6	0.3	1.2	1	1	0
08/30/2020 12:00	0.2	13.6	1,744.7	0.3	1.2	1	1	0
08/30/2020 13:00	0.2	13.7	1,633.1	0.3	1.1	1	1	0
08/30/2020 14:00	-0.2	13.8	1,540.0	-0.1	1.1	1	1	1
08/30/2020 15:00	-1.2	11.9	2,091.5	-0.7	1.5	1	1	1
08/30/2020 16:00	-0.9	11.3	2,177.6	-0.4	1.5	1	1	1
08/30/2020 17:00	-1.1	11.6	2,126.6	-0.5	1.5	1	1	1
08/30/2020 18:00	-1.1	11.8	2,098.2	-0.5	1.5	1	1	1
08/30/2020 19:00	-1.2	12.1	2,055.0	-0.7	1.4	1	1	1
08/30/2020 20:00	-1.2	12.1	2,048.7	-0.7	1.4	1	1	1
08/30/2020 21:00	-1.4	12.2	2,037.1	-0.7	1.4	1	1	1
08/30/2020 22:00	-1.2	12.2	2,031.9	-0.7	1.4	1	1	1
08/30/2020 23:00	-1.2	12.6	1,944.3	-0.7	1.4	1	1	1
Average/Sum#:	-0.4	13.0	1,864.8	-0.1	1.3	24 #	24 #	11 #
Minimum:	-1.4	11.3	1,540.0	-0.7	1.1	1	1	0
Maximum:	0.3	13.8	2,177.6	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/31/2020 00:00	0.1	13.8	1,614.4	0.2	1.1	1	1	0
08/31/2020 01:00	-0.1	13.9	1,303.1	0.0	0.9	1	1	0
08/31/2020 02:00	0.1	14.0	1,289.4	0.2	0.9	1	1	0
08/31/2020 03:00	0.1	14.0	1,299.9	0.2	0.9	1	1	0
08/31/2020 04:00	0.2	13.8	1,639.1	0.3	1.1	1	1	0
08/31/2020 05:00	0.2	13.8	1,669.3	0.3	1.2	1	1	0
08/31/2020 06:00	0.2	13.8	1,693.4	0.3	1.2	1	1	0
08/31/2020 07:00	0.0	13.9	1,385.4	0.1	1.0	1	1	0
08/31/2020 08:00	0.2	13.9	1,407.3	0.3	1.0	1	1	0
08/31/2020 09:00	0.3	14.0	1,312.4	0.4	0.9	1	1	0
08/31/2020 10:00	0.3	14.0	1,302.1	0.4	0.9	1	1	0
08/31/2020 11:00	0.4	14.0	1,504.4	0.4	1.1	1	1	0
08/31/2020 12:00	0.2	13.9	1,488.2	0.2	1.0	1	1	1
08/31/2020 13:00	-1.2	11.9	2,098.1	-0.7	1.5	1	1	1
08/31/2020 14:00	-1.1	11.4	2,187.6	-0.4	1.5	1	1	1
08/31/2020 15:00	-0.9	11.4	2,181.2	-0.4	1.5	1	1	1
08/31/2020 16:00	-1.1	11.9	2,075.9	-0.5	1.5	1	1	1
08/31/2020 17:00	-1.1	12.1	2,046.7	-0.5	1.4	1	1	1
08/31/2020 18:00	-1.2	12.2	2,042.4	-0.7	1.4	1	1	1
08/31/2020 19:00	-1.2	12.2	2,034.7	-0.7	1.4	1	1	1
08/31/2020 20:00	-1.2	12.2	2,032.1	-0.7	1.4	1	1	1
08/31/2020 21:00	-1.2	12.3	2,028.6	-0.7	1.4	1	1	1
08/31/2020 22:00	-1.2	12.3	2,024.4	-0.7	1.4	1	1	1
08/31/2020 23:00	-0.9	13.0	1,793.4	-0.5	1.3	1	1	1
Average/Sum#:	-0.4	13.1	1,727.2	-0.1	1.2	24 #	24 #	12 #
Minimum:	-1.2	11.4	1,289.4	-0.7	0.9	1	1	0
Maximum:	0.4	14.0	2,187.6	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/01/2020 00:00	0.1	14.0	1,298.4	0.1	0.9	1	1	0
09/01/2020 01:00	0.4	13.9	1,497.3	0.4	1.0	1	1	0
09/01/2020 02:00	0.3	14.0	1,393.5	0.4	1.0	1	1	0
09/01/2020 03:00	0.1	14.0	1,300.4	0.2	0.9	1	1	0
09/01/2020 04:00	0.3	14.0	1,347.1	0.4	0.9	1	1	0
09/01/2020 05:00	0.4	13.8	1,678.7	0.4	1.2	1	1	0
09/01/2020 06:00	0.3	13.9	1,653.2	0.4	1.2	1	1	0
09/01/2020 07:00	0.2	13.8	1,676.8	0.3	1.2	1	1	0
09/01/2020 08:00	0.6	0.0	1,596.3	0.6	1.1	1	1	0
09/01/2020 09:00	0.4	13.9	1,623.2	0.4	1.1	1	1	0
09/01/2020 10:00	0.5	13.9	1,483.8	0.5	1.0	1	1	0
09/01/2020 11:00	0.5	14.1	1,311.8	0.5	0.9	1	1	0
09/01/2020 12:00	0.6	14.1	1,340.5	0.6	0.9	1	1	0
09/01/2020 13:00	0.6	14.1	1,488.6	0.6	1.0	1	1	0
09/01/2020 14:00	0.6	14.0	1,648.6	0.6	1.2	1	1	0
09/01/2020 15:00	0.6	14.0	1,612.3	0.6	1.1	1	1	0
09/01/2020 16:00	0.7	13.9	1,541.1	0.7	1.1	1	1	1
09/01/2020 17:00	-0.7	12.0	2,064.4	-0.2	1.4	1	1	1
09/01/2020 18:00	-0.4	11.6	2,157.9	0.1	1.5	1	1	1
09/01/2020 19:00	-0.4	11.7	2,131.3	0.1	1.5	1	1	1
09/01/2020 20:00	-0.5	12.3	2,027.7	-0.1	1.4	1	1	1
09/01/2020 21:00	-0.7	12.4	2,014.1	-0.2	1.4	1	1	1
09/01/2020 22:00	-0.5	12.8	1,946.1	-0.2	1.4	1	1	1
09/01/2020 23:00	-0.2	13.2	1,783.2	-0.1	1.2	1	1	1
Average/Sum#:	0.1	13.5	1,650.7	0.3	1.1	24 #	24 #	8 #
Minimum:	-0.7	11.6	1,298.4	-0.2	0.9	1	1	0
Maximum:	0.7	14.1	2,157.9	0.7	1.5	1	1	1
%SI	4.17	4.17	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/02/2020 00:00	0.3	14.0	1,287.8	0.4	0.9	1	1	0
09/02/2020 01:00	0.4	14.0	1,284.2	0.4	0.9	1	1	0
09/02/2020 02:00	0.4	14.0	1,301.4	0.4	0.9	1	1	0
09/02/2020 03:00	0.4	14.0	1,294.8	0.4	0.9	1	1	0
09/02/2020 04:00	0.4	14.0	1,318.3	0.4	0.9	1	1	0
09/02/2020 05:00	0.4	14.0	1,285.9	0.4	0.9	1	1	0
09/02/2020 06:00	0.4	14.0	1,292.6	0.4	0.9	1	1	0
09/02/2020 07:00	0.4	14.0	1,408.7	0.4	1.0	1	1	0
09/02/2020 08:00	0.3	14.0	1,367.6	0.4	1.0	1	1	0
09/02/2020 09:00	0.4	14.0	1,374.7	0.4	1.0	1	1	0
09/02/2020 10:00	0.6	14.0	1,383.4	0.6	1.0	1	1	0
09/02/2020 11:00	0.6	14.0	1,392.2	0.6	1.0	1	1	0
09/02/2020 12:00	0.6	14.0	1,394.6	0.6	1.0	1	1	0
09/02/2020 13:00	0.6	14.0	1,394.8	0.6	1.0	1	1	0
09/02/2020 14:00	0.6	14.0	1,394.3	0.6	1.0	1	1	0
09/02/2020 15:00	0.6	14.0	1,419.1	0.6	1.0	1	1	0
09/02/2020 16:00	-1.1	12.8	1,921.0	-0.7	1.3	1	1	1
09/02/2020 17:00	-1.2	12.6	1,963.9	-0.7	1.4	1	1	1
09/02/2020 18:00	-1.1	12.7	1,957.9	-0.7	1.4	1	1	1
09/02/2020 19:00	-1.1	12.8	1,948.7	-0.7	1.4	1	1	1
09/02/2020 20:00	-1.1	12.8	1,911.9	-0.7	1.3	1	1	1
09/02/2020 21:00	0.4	14.0	1,390.6	0.4	1.0	1	1	0
09/02/2020 22:00	0.5	14.0	1,373.7	0.5	1.0	1	1	0
09/02/2020 23:00	0.4	14.0	1,377.5	0.4	1.0	1	1	0
Average/Sum#:	0.1	13.7	1,476.7	0.2	1.0	24 #	24 #	5 #
Minimum:	-1.2	12.6	1,284.2	-0.7	0.9	1	1	0
Maximum:	0.6	14.0	1,963.9	0.6	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/03/2020 00:00	0.4	14.0	1,374.0	0.4	1.0	1	1	0
09/03/2020 01:00	0.4	14.0	1,373.5	0.4	1.0	1	1	0
09/03/2020 02:00	0.4	14.0	1,376.0	0.4	1.0	1	1	0
09/03/2020 03:00	0.5	14.0	1,621.5	0.5	1.1	1	1	0
09/03/2020 04:00	0.4	14.0	1,445.9	0.4	1.0	1	1	0
09/03/2020 05:00	0.5	14.0	1,573.4	0.5	1.1	1	1	0
09/03/2020 06:00	0.6	14.0	1,588.8	0.6	1.1	1	1	0
09/03/2020 07:00	0.6	14.0	1,645.9	0.6	1.2	1	1	0
09/03/2020 08:00	0.6	14.0	1,642.0	0.6	1.1	1	1	0
09/03/2020 09:00	0.6	14.0	1,539.7	0.6	1.1	1	1	0
09/03/2020 10:00	0.6	14.0	1,577.0	0.6	1.1	1	1	0
09/03/2020 11:00	0.7	14.0	1,528.5	0.7	1.1	1	1	1
09/03/2020 12:00	-1.1	12.1	2,093.4	-0.5	1.5	1	1	1
09/03/2020 13:00	-0.4	11.7	2,155.4	0.1	1.5	1	1	1
09/03/2020 14:00	-0.5	11.9	2,109.7	-0.1	1.5	1	1	1
09/03/2020 15:00	-0.4	11.6	2,161.1	0.1	1.5	1	1	1
09/03/2020 16:00	-0.2	11.5	2,166.8	0.1	1.5	1	1	1
09/03/2020 17:00	-0.2	11.5	2,166.4	0.1	1.5	1	1	1
09/03/2020 18:00	-0.2	11.5	2,170.5	0.1	1.5	1	1	1
09/03/2020 19:00	-0.4	11.8	2,114.6	-0.1	1.5	1	1	1
09/03/2020 20:00	-0.5	12.2	2,034.1	-0.1	1.4	1	1	1
09/03/2020 21:00	-0.5	12.3	2,030.5	-0.1	1.4	1	1	1
09/03/2020 22:00	-0.4	12.1	2,068.9	-0.1	1.4	1	1	1
09/03/2020 23:00	-0.2	11.7	2,160.1	0.1	1.5	1	1	1
Average/Sum#:	0.1	12.9	1,821.6	0.2	1.3	24 #	24 #	13 #
Minimum:	-1.1	11.5	1,373.5	-0.5	1.0	1	1	0
Maximum:	0.7	14.0	2,170.5	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/04/2020 00:00	-0.5	12.4	2,044.7	-0.2	1.4	1	1	1
09/04/2020 01:00	-0.5	12.6	2,004.7	-0.2	1.4	1	1	1
09/04/2020 02:00	-0.5	12.6	2,006.5	-0.2	1.4	1	1	1
09/04/2020 03:00	-0.5	12.7	2,008.8	-0.2	1.4	1	1	1
09/04/2020 04:00	-0.4	11.9	2,159.5	-0.1	1.5	1	1	1
09/04/2020 05:00	-0.2	11.7	2,192.1	0.1	1.5	1	1	1
09/04/2020 06:00	-0.2	11.8	2,162.4	0.1	1.5	1	1	1
09/04/2020 07:00	-0.2	11.9	2,144.0	0.1	1.5	1	1	1
09/04/2020 08:00	-0.4	12.4	2,039.1	-0.1	1.4	1	1	1
09/04/2020 09:00	-0.4	12.5	2,004.2	-0.1	1.4	1	1	1
09/04/2020 10:00	-0.4	12.1	2,087.7	-0.1	1.5	1	1	1
09/04/2020 11:00	-0.2	11.9	2,121.9	0.1	1.5	1	1	1
09/04/2020 12:00	-0.2	11.8	2,139.3	0.1	1.5	1	1	1
09/04/2020 13:00	-0.1	11.7	2,143.8	0.2	1.5	1	1	1
09/04/2020 14:00	-0.1	11.7	2,143.4	0.2	1.5	1	1	1
09/04/2020 15:00	-0.1	11.7	2,151.6	0.2	1.5	1	1	1
09/04/2020 16:00	-0.1	11.6	2,155.4	0.2	1.5	1	1	1
09/04/2020 17:00	-0.1	11.6	2,160.4	0.2	1.5	1	1	1
09/04/2020 18:00	-0.2	11.6	2,164.8	0.1	1.5	1	1	1
09/04/2020 19:00	-0.1	11.6	2,169.0	0.2	1.5	1	1	1
09/04/2020 20:00	-0.1	11.6	2,170.4	0.2	1.5	1	1	1
09/04/2020 21:00	-0.1	11.8	2,137.3	0.2	1.5	1	1	1
09/04/2020 22:00	-0.1	11.9	2,137.2	0.2	1.5	1	1	1
09/04/2020 23:00	-0.2	12.4	2,052.0	0.1	1.4	1	1	1
Average/Sum#:	-0.2	12.0	2,112.5	0.1	1.5	24 #	24 #	24 #
Minimum:	-0.5	11.6	2,004.2	-0.2	1.4	1	1	1
Maximum:	-0.1	12.7	2,192.1	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/05/2020 00:00	-0.4	12.5	2,028.9	-0.1	1.4	1	1	1
09/05/2020 01:00	-0.4	12.5	2,033.6	-0.1	1.4	1	1	1
09/05/2020 02:00	-0.4	12.5	2,032.6	-0.1	1.4	1	1	1
09/05/2020 03:00	-0.4	12.5	2,034.7	-0.1	1.4	1	1	1
09/05/2020 04:00	-0.4	12.5	2,047.1	-0.1	1.4	1	1	1
09/05/2020 05:00	-0.5	12.7	1,996.2	-0.2	1.4	1	1	1
09/05/2020 06:00	0.5	14.0	1,646.2	0.5	1.2	1	1	0
09/05/2020 07:00	0.5	14.0	1,575.4	0.5	1.1	1	1	0
09/05/2020 08:00	0.5	14.0	1,619.3	0.5	1.1	1	1	0
09/05/2020 09:00	0.4	14.0	1,596.6	0.4	1.1	1	1	0
09/05/2020 10:00	0.4	14.0	1,628.7	0.4	1.1	1	1	1
09/05/2020 11:00	-0.7	12.2	2,070.4	-0.2	1.4	1	1	1
09/05/2020 12:00	-0.2	11.7	2,146.3	0.1	1.5	1	1	1
09/05/2020 13:00	-0.1	11.6	2,158.0	0.2	1.5	1	1	1
09/05/2020 14:00	-0.1	11.6	2,159.4	0.2	1.5	1	1	1
09/05/2020 15:00	-0.1	11.5	2,156.1	0.2	1.5	1	1	1
09/05/2020 16:00	-0.2	11.5	2,146.5	0.1	1.5	1	1	1
09/05/2020 17:00	-0.1	11.5	2,155.9	0.2	1.5	1	1	1
09/05/2020 18:00	-0.1	11.5	2,162.8	0.2	1.5	1	1	1
09/05/2020 19:00	-0.1	11.5	2,167.9	0.2	1.5	1	1	1
09/05/2020 20:00	-0.1	11.5	2,171.2	0.2	1.5	1	1	1
09/05/2020 21:00	-0.1	11.5	2,177.1	0.2	1.5	1	1	1
09/05/2020 22:00	-0.1	11.6	2,186.6	0.2	1.5	1	1	1
09/05/2020 23:00	-0.1	11.9	2,117.7	0.2	1.5	1	1	1
Average/Sum#:	-0.1	12.3	2,009.0	0.2	1.4	24 #	24 #	20 #
Minimum:	-0.7	11.5	1,575.4	-0.2	1.1	1	1	0
Maximum:	0.5	14.0	2,186.6	0.5	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/06/2020 00:00	-0.1	11.8	2,154.4	0.2	1.5	1	1	1
09/06/2020 01:00	-0.1	12.1	2,086.4	0.2	1.5	1	1	1
09/06/2020 02:00	0.4	11.9	2,082.6	0.5	1.5	1	1	1
09/06/2020 03:00	0.4	11.8	2,105.5	0.5	1.5	1	1	1
09/06/2020 04:00	-0.4	12.3	2,069.1	-0.1	1.4	1	1	1
09/06/2020 05:00	-0.7	12.4	2,055.1	-0.2	1.4	1	1	1
09/06/2020 06:00	-0.7	12.7	1,987.4	-0.2	1.4	1	1	1
09/06/2020 07:00	-0.5	12.1	2,110.9	-0.1	1.5	1	1	1
09/06/2020 08:00	-0.4	11.8	2,133.1	-0.1	1.5	1	1	1
09/06/2020 09:00	-0.2	11.7	2,146.1	0.1	1.5	1	1	1
09/06/2020 10:00	-0.1	11.6	2,144.2	0.2	1.5	1	1	1
09/06/2020 11:00	-0.1	11.6	2,139.2	0.2	1.5	1	1	1
09/06/2020 12:00	-0.1	11.5	2,140.0	0.2	1.5	1	1	1
09/06/2020 13:00	-0.1	11.6	2,145.4	0.2	1.5	1	1	1
09/06/2020 14:00	-0.1	11.6	2,145.7	0.2	1.5	1	1	1
09/06/2020 15:00	0.1	11.5	2,148.3	0.2	1.5	1	1	1
09/06/2020 16:00	-0.1	11.9	2,078.4	0.2	1.5	1	1	1
09/06/2020 17:00	0.1	11.5	2,141.4	0.2	1.5	1	1	1
09/06/2020 18:00	-0.1	11.6	2,121.0	0.2	1.5	1	1	1
09/06/2020 19:00	-0.1	11.8	2,090.2	0.2	1.5	1	1	1
09/06/2020 20:00	-0.1	11.9	2,092.8	0.2	1.5	1	1	1
09/06/2020 21:00	-0.1	11.7	2,146.3	0.2	1.5	1	1	1
09/06/2020 22:00	0.4	11.6	2,142.3	0.5	1.5	1	1	1
09/06/2020 23:00	0.5	11.6	2,099.9	0.5	1.5	1	1	1
Average/Sum#:	-0.1	11.8	2,112.7	0.2	1.5	24 #	24 #	24 #
Minimum:	-0.7	11.5	1,987.4	-0.2	1.4	1	1	1
Maximum:	0.5	12.7	2,154.4	0.5	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/07/2020 00:00	0.5	11.6	2,087.2	0.5	1.5	1	1	1
09/07/2020 01:00	0.5	11.7	2,080.0	0.5	1.5	1	1	1
09/07/2020 02:00	0.5	11.7	2,090.5	0.5	1.5	1	1	1
09/07/2020 03:00	-0.2	12.0	2,105.0	0.1	1.5	1	1	1
09/07/2020 04:00	-0.4	12.3	2,038.4	-0.1	1.4	1	1	1
09/07/2020 05:00	-0.4	12.3	2,045.0	-0.1	1.4	1	1	1
09/07/2020 06:00	0.6	14.0	1,593.0	0.6	1.1	1	1	0
09/07/2020 07:00	0.6	14.1	1,591.9	0.6	1.1	1	1	0
09/07/2020 08:00	0.6	14.1	1,604.2	0.6	1.1	1	1	0
09/07/2020 09:00	0.6	14.1	1,566.2	0.6	1.1	1	1	0
09/07/2020 10:00	0.6	14.0	1,507.6	0.6	1.1	1	1	0
09/07/2020 11:00	0.7	14.0	1,508.2	0.7	1.1	1	1	1
09/07/2020 12:00	-0.8	12.6	1,958.9	-0.4	1.4	1	1	1
09/07/2020 13:00	-0.1	13.4	1,742.4	0.1	1.2	1	1	1
09/07/2020 14:00	0.6	13.8	1,673.7	0.6	1.2	1	1	0
09/07/2020 15:00	0.6	13.7	1,721.1	0.6	1.2	1	1	0
09/07/2020 16:00	0.1	13.1	1,782.9	0.2	1.2	1	1	1
09/07/2020 17:00	-0.5	12.2	2,027.4	-0.1	1.4	1	1	1
09/07/2020 18:00	-0.4	12.2	2,022.2	-0.1	1.4	1	1	1
09/07/2020 19:00	-0.2	11.7	2,124.7	0.1	1.5	1	1	1
09/07/2020 20:00	-0.2	11.7	2,112.8	0.1	1.5	1	1	1
09/07/2020 21:00	-0.4	12.0	2,049.3	-0.1	1.4	1	1	1
09/07/2020 22:00	-0.4	12.0	2,052.9	-0.1	1.4	1	1	1
09/07/2020 23:00	-0.4	12.1	2,052.7	-0.1	1.4	1	1	1
Average/Sum#:	0.1	12.8	1,880.8	0.2	1.3	24 #	24 #	17 #
Minimum:	-0.8	11.6	1,507.6	-0.4	1.1	1	1	0
Maximum:	0.7	14.1	2,124.7	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/08/2020 00:00	-0.4	12.2	2,055.9	-0.1	1.4	1	1	1
09/08/2020 01:00	-0.2	11.9	2,111.0	0.1	1.5	1	1	1
09/08/2020 02:00	-0.2	12.0	2,087.8	0.1	1.5	1	1	1
09/08/2020 03:00	-0.2	11.8	2,152.6	0.1	1.5	1	1	1
09/08/2020 04:00	-0.2	12.2	2,089.1	0.1	1.5	1	1	1
09/08/2020 05:00	-0.4	12.4	2,050.2	-0.1	1.4	1	1	1
09/08/2020 06:00	0.6	14.0	1,636.4	0.6	1.1	1	1	0
09/08/2020 07:00	0.6	14.1	1,637.4	0.6	1.1	1	1	0
09/08/2020 08:00	0.6	14.1	1,515.2	0.6	1.1	1	1	0
09/08/2020 09:00	0.6	14.0	1,642.7	0.6	1.1	1	1	0
09/08/2020 10:00	0.6	14.0	1,583.1	0.6	1.1	1	1	0
09/08/2020 11:00	0.6	13.9	1,688.0	0.6	1.2	1	1	0
09/08/2020 12:00	0.7	14.0	1,538.9	0.7	1.1	1	1	1
09/08/2020 13:00	-0.7	12.3	2,083.3	-0.2	1.5	1	1	1
09/08/2020 14:00	-0.2	11.7	2,176.1	0.1	1.5	1	1	1
09/08/2020 15:00	-0.2	11.6	2,186.3	0.1	1.5	1	1	1
09/08/2020 16:00	-0.2	11.6	2,191.0	0.1	1.5	1	1	1
09/08/2020 17:00	-0.1	11.5	2,198.7	0.2	1.5	1	1	1
09/08/2020 18:00	0.5	11.7	2,084.9	0.5	1.5	1	1	1
09/08/2020 19:00	0.1	12.0	2,091.8	0.2	1.5	1	1	1
09/08/2020 20:00	-0.4	12.2	2,095.8	-0.1	1.5	1	1	1
09/08/2020 21:00	-0.4	12.1	2,103.1	-0.1	1.5	1	1	1
09/08/2020 22:00	-0.4	12.5	2,037.8	-0.1	1.4	1	1	1
09/08/2020 23:00	-0.4	12.4	2,056.6	-0.1	1.4	1	1	1
Average/Sum#:	0.0	12.6	1,962.2	0.2	1.4	24 #	24 #	18 #
Minimum:	-0.7	11.5	1,515.2	-0.2	1.1	1	1	0
Maximum:	0.7	14.1	2,198.7	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/09/2020 00:00	-0.2	12.4	2,003.3	0.1	1.4	1	1	1
09/09/2020 01:00	0.6	14.0	1,665.4	0.6	1.2	1	1	0
09/09/2020 02:00	0.6	14.1	1,398.7	0.6	1.0	1	1	0
09/09/2020 03:00	0.6	14.0	1,657.4	0.6	1.2	1	1	0
09/09/2020 04:00	0.6	14.1	1,507.6	0.6	1.1	1	1	0
09/09/2020 05:00	0.6	14.1	1,580.1	0.6	1.1	1	1	0
09/09/2020 06:00	0.6	14.1	1,583.4	0.6	1.1	1	1	0
09/09/2020 07:00	0.6	14.1	1,560.6	0.6	1.1	1	1	0
09/09/2020 08:00	0.6	14.1	1,517.1	0.6	1.1	1	1	0
09/09/2020 09:00	0.6	14.1	1,437.2	0.6	1.0	1	1	0
09/09/2020 10:00	0.6	14.1	1,423.5	0.6	1.0	1	1	0
09/09/2020 11:00	0.6	14.1	1,496.9	0.6	1.0	1	1	0
09/09/2020 12:00	0.7	14.1	1,521.1	0.7	1.1	1	1	1
09/09/2020 13:00	-0.8	12.3	2,084.9	-0.4	1.5	1	1	1
09/09/2020 14:00	-0.7	12.4	2,045.1	-0.2	1.4	1	1	1
09/09/2020 15:00	-0.7	12.5	2,020.4	-0.2	1.4	1	1	1
09/09/2020 16:00	-0.7	12.5	2,013.2	-0.2	1.4	1	1	1
09/09/2020 17:00	-0.5	12.5	2,010.1	-0.2	1.4	1	1	1
09/09/2020 18:00	-0.7	12.6	2,009.5	-0.2	1.4	1	1	1
09/09/2020 19:00	-0.5	12.6	2,008.5	-0.2	1.4	1	1	1
09/09/2020 20:00	-0.5	12.6	2,009.2	-0.2	1.4	1	1	1
09/09/2020 21:00	-0.7	12.7	2,006.3	-0.2	1.4	1	1	1
09/09/2020 22:00	-0.5	12.7	2,003.5	-0.2	1.4	1	1	1
09/09/2020 23:00	-0.5	13.0	1,921.5	-0.2	1.3	1	1	1
Average/Sum#:	0.0	13.3	1,770.2	0.2	1.2	24 #	24 #	13 #
Minimum:	-0.8	12.3	1,398.7	-0.4	1.0	1	1	0
Maximum:	0.7	14.1	2,084.9	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/10/2020 00:00	0.6	14.0	1,517.9	0.6	1.1	1	1	0
09/10/2020 01:00	0.6	14.0	1,492.0	0.6	1.0	1	1	0
09/10/2020 02:00	0.6	14.1	1,313.6	0.6	0.9	1	1	0
09/10/2020 03:00	0.6	14.0	1,594.4	0.6	1.1	1	1	0
09/10/2020 04:00	0.6	14.0	1,563.7	0.6	1.1	1	1	0
09/10/2020 05:00	0.6	14.0	1,559.1	0.6	1.1	1	1	0
09/10/2020 06:00	0.6	14.0	1,605.5	0.6	1.1	1	1	0
09/10/2020 07:00	0.6	14.0	1,643.9	0.6	1.2	1	1	0
09/10/2020 08:00	0.6	14.0	1,680.9	0.6	1.2	1	1	0
09/10/2020 09:00	0.6	14.0	1,621.3	0.6	1.1	1	1	0
09/10/2020 10:00	0.6	14.0	1,673.5	0.6	1.2	1	1	0
09/10/2020 11:00	0.6	14.0	1,474.6	0.6	1.0	1	1	0
09/10/2020 12:00	0.6	14.0	1,449.0	0.6	1.0	1	1	0
09/10/2020 13:00	0.6	14.0	1,460.1	0.6	1.0	1	1	0
09/10/2020 14:00	0.6	14.0	1,599.9	0.6	1.1	1	1	0
09/10/2020 15:00	0.7	13.9	1,573.5	0.7	1.1	1	1	1
09/10/2020 16:00	-0.9	12.3	2,059.3	-0.5	1.4	1	1	1
09/10/2020 17:00	-0.8	12.4	2,032.5	-0.4	1.4	1	1	1
09/10/2020 18:00	-0.7	12.5	2,011.4	-0.2	1.4	1	1	1
09/10/2020 19:00	-0.7	12.6	2,011.1	-0.2	1.4	1	1	1
09/10/2020 20:00	-0.7	12.6	2,007.6	-0.2	1.4	1	1	1
09/10/2020 21:00	-0.7	12.7	2,000.6	-0.2	1.4	1	1	1
09/10/2020 22:00	-0.7	12.6	2,001.6	-0.2	1.4	1	1	1
09/10/2020 23:00	-0.4	13.2	1,843.3	-0.1	1.3	1	1	1
Average/Sum#:	0.2	13.5	1,699.6	0.3	1.2	24 #	24 #	9 #
Minimum:	-0.9	12.3	1,313.6	-0.5	0.9	1	1	0
Maximum:	0.7	14.1	2,059.3	0.7	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/11/2020 00:00	0.3	13.9	1,416.1	0.4	1.0	1	1	0
09/11/2020 01:00	0.4	14.0	1,292.7	0.4	0.9	1	1	0
09/11/2020 02:00	0.4	14.0	1,292.1	0.4	0.9	1	1	0
09/11/2020 03:00	0.4	14.0	1,291.9	0.4	0.9	1	1	0
09/11/2020 04:00	0.5	14.0	1,291.9	0.5	0.9	1	1	0
09/11/2020 05:00	0.6	14.0	1,484.0	0.6	1.0	1	1	0
09/11/2020 06:00	0.4	14.1	1,297.4	0.4	0.9	1	1	0
09/11/2020 07:00	0.4	14.1	1,323.4	0.4	0.9	1	1	0
09/11/2020 08:00	0.4	14.1	1,345.4	0.4	0.9	1	1	0
09/11/2020 09:00	0.6	14.0	1,569.9	0.6	1.1	1	1	0
09/11/2020 10:00	0.6	14.0	1,553.5	0.6	1.1	1	1	0
09/11/2020 11:00	0.6	14.0	1,540.7	0.6	1.1	1	1	0
09/11/2020 12:00	0.6	14.0	1,587.4	0.6	1.1	1	1	0
09/11/2020 13:00	0.4	14.0	1,298.0	0.4	0.9	1	1	0
09/11/2020 14:00	0.5	14.1	1,300.6	0.5	0.9	1	1	0
09/11/2020 15:00	0.5	14.0	1,335.3	0.5	0.9	1	1	0
09/11/2020 16:00	0.5	13.9	1,647.5	0.5	1.2	1	1	0
09/11/2020 17:00	0.5	13.9	1,641.0	0.5	1.1	1	1	0
09/11/2020 18:00	-0.2	13.3	1,805.5	-0.1	1.3	1	1	1
09/11/2020 19:00	-0.7	12.3	2,053.2	-0.2	1.4	1	1	1
09/11/2020 20:00	-0.8	12.4	2,015.8	-0.4	1.4	1	1	1
09/11/2020 21:00	-0.8	12.7	1,971.8	-0.4	1.4	1	1	1
09/11/2020 22:00	-0.2	13.7	1,484.3	-0.1	1.0	1	1	1
09/11/2020 23:00	0.0	16.6	355.5	0.0	0.2	1	0	0
Average/Sum#:	0.2	13.9	1,466.5	0.3	1.0	24 #	23 #	5 #
Minimum:	-0.8	12.3	355.5	-0.4	0.2	1	0	0
Maximum:	0.6	16.6	2,053.2	0.6	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/13/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/14/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 13:00	0.0	17.7	434.1	0.0	0.3	1	0	0
09/14/2020 14:00	0.0	15.8	688.2	0.0	0.5	1	0	0
09/14/2020 15:00	0.0	13.9	1,567.4	0.0	1.1	1	0	0
09/14/2020 16:00	-0.1	13.1	1,814.4	0.1	1.3	1	1	1
09/14/2020 17:00	-0.2	11.7	2,156.7	0.1	1.5	1	1	1
09/14/2020 18:00	-0.2	11.7	2,159.9	0.1	1.5	1	1	1
09/14/2020 19:00	-0.2	11.8	2,137.7	0.1	1.5	1	1	1
09/14/2020 20:00	-0.2	11.7	2,152.2	0.1	1.5	1	1	1
09/14/2020 21:00	-0.4	12.3	2,034.4	-0.1	1.4	1	1	1
09/14/2020 22:00	-0.4	12.7	1,957.7	-0.1	1.4	1	1	1
09/14/2020 23:00	-0.5	12.7	1,953.4	-0.2	1.4	1	1	1
Average/Sum#:	-0.2	13.2	1,732.4	0.0	1.2	11 #	8 #	8 #
Minimum:	-0.5	11.7	434.1	-0.2	0.3	0	0	0
Maximum:	0.0	17.7	2,159.9	0.1	1.5	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/15/2020 00:00	0.6	13.9	1,447.3	0.6	1.0	1	1	0
09/15/2020 01:00	0.6	14.0	1,330.6	0.6	0.9	1	1	0
09/15/2020 02:00	0.6	14.0	1,288.5	0.6	0.9	1	1	0
09/15/2020 03:00	0.6	14.0	1,289.5	0.6	0.9	1	1	0
09/15/2020 04:00	0.6	14.0	1,317.0	0.6	0.9	1	1	0
09/15/2020 05:00	0.6	13.9	1,573.3	0.6	1.1	1	1	0
09/15/2020 06:00	0.6	13.9	1,611.6	0.6	1.1	1	1	0
09/15/2020 07:00	0.6	14.0	1,434.8	0.6	1.0	1	1	0
09/15/2020 08:00	0.6	14.0	1,422.2	0.6	1.0	1	1	0
09/15/2020 09:00	0.6	14.0	1,289.1	0.6	0.9	1	1	0
09/15/2020 10:00	0.6	14.0	1,588.3	0.6	1.1	1	1	0
09/15/2020 11:00	0.6	14.0	1,614.0	0.6	1.1	1	1	0
09/15/2020 12:00	0.6	14.0	1,606.4	0.6	1.1	1	1	0
09/15/2020 13:00	0.7	13.8	1,674.8	0.7	1.2	1	1	1
09/15/2020 14:00	-0.5	11.9	2,112.3	-0.1	1.5	1	1	1
09/15/2020 15:00	-0.4	11.7	2,134.4	0.1	1.5	1	1	1
09/15/2020 16:00	-0.4	12.1	2,060.6	-0.1	1.4	1	1	1
09/15/2020 17:00	-0.4	12.2	2,054.1	-0.1	1.4	1	1	1
09/15/2020 18:00	-0.4	12.3	2,042.1	-0.1	1.4	1	1	1
09/15/2020 19:00	-0.5	12.2	2,061.5	-0.1	1.4	1	1	1
09/15/2020 20:00	-0.2	11.7	2,153.7	0.1	1.5	1	1	1
09/15/2020 21:00	-0.2	12.1	2,079.8	0.1	1.5	1	1	1
09/15/2020 22:00	0.0	13.4	1,411.0	0.0	1.0	1	0	1
09/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.2	13.3	1,678.1	0.4	1.2	23 #	22 #	10 #
Minimum:	-0.5	11.7	1,288.5	-0.1	0.9	0	0	0
Maximum:	0.7	14.0	2,153.7	0.7	1.5	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 06:00	0.0	17.7	450.7	0.0	0.3	1	0	0
09/16/2020 07:00	0.0	14.6	1,111.1	0.0	0.8	1	0	0
09/16/2020 08:00	0.6	14.0	1,388.7	0.6	1.0	1	1	0
09/16/2020 09:00	0.6	13.9	1,386.8	0.6	1.0	1	1	0
09/16/2020 10:00	0.6	14.0	1,384.2	0.6	1.0	1	1	0
09/16/2020 11:00	0.6	13.9	1,602.5	0.6	1.1	1	1	0
09/16/2020 12:00	0.6	13.9	1,464.2	0.6	1.0	1	1	0
09/16/2020 13:00	0.6	13.8	1,690.5	0.6	1.2	1	1	0
09/16/2020 14:00	0.7	13.8	1,692.8	0.7	1.2	1	1	1
09/16/2020 15:00	-0.5	12.0	2,086.2	-0.1	1.5	1	1	1
09/16/2020 16:00	-0.2	11.7	2,138.3	0.1	1.5	1	1	1
09/16/2020 17:00	-0.1	11.5	2,182.1	0.2	1.5	1	1	1
09/16/2020 18:00	-0.1	11.6	2,163.7	0.2	1.5	1	1	1
09/16/2020 19:00	-0.4	12.3	2,029.2	-0.1	1.4	1	1	1
09/16/2020 20:00	-0.4	12.2	2,047.9	-0.1	1.4	1	1	1
09/16/2020 21:00	-0.4	12.3	2,036.4	-0.1	1.4	1	1	1
09/16/2020 22:00	-0.4	12.4	2,014.8	-0.1	1.4	1	1	1
09/16/2020 23:00	-0.4	12.7	1,944.5	-0.1	1.4	1	1	1
Average/Sum#:	0.1	13.2	1,711.9	0.2	1.2	18 #	16 #	10 #
Minimum:	-0.5	11.5	450.7	-0.1	0.3	0	0	0
Maximum:	0.7	17.7	2,182.1	0.7	1.5	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/17/2020 00:00	0.6	13.9	1,406.6	0.6	1.0	1	1	0
09/17/2020 01:00	0.6	14.0	1,311.3	0.6	0.9	1	1	0
09/17/2020 02:00	0.6	14.0	1,292.7	0.6	0.9	1	1	0
09/17/2020 03:00	0.6	14.0	1,293.5	0.6	0.9	1	1	0
09/17/2020 04:00	0.6	13.9	1,466.9	0.6	1.0	1	1	0
09/17/2020 05:00	0.6	13.9	1,575.1	0.6	1.1	1	1	0
09/17/2020 06:00	0.6	13.9	1,541.3	0.6	1.1	1	1	0
09/17/2020 07:00	0.5	13.9	1,618.7	0.5	1.1	1	1	0
09/17/2020 08:00	0.6	13.9	1,592.2	0.6	1.1	1	1	0
09/17/2020 09:00	0.6	13.9	1,605.5	0.6	1.1	1	1	0
09/17/2020 10:00	0.6	13.9	1,420.9	0.6	1.0	1	1	0
09/17/2020 11:00	0.6	13.9	1,429.0	0.6	1.0	1	1	0
09/17/2020 12:00	0.7	13.9	1,625.5	0.7	1.1	1	1	1
09/17/2020 13:00	-0.5	11.9	2,094.6	-0.1	1.5	1	1	1
09/17/2020 14:00	-0.1	11.5	2,149.9	0.2	1.5	1	1	1
09/17/2020 15:00	0.1	11.5	2,160.6	0.2	1.5	1	1	1
09/17/2020 16:00	0.2	11.4	2,177.0	0.4	1.5	1	1	1
09/17/2020 17:00	0.1	11.6	2,131.3	0.2	1.5	1	1	1
09/17/2020 18:00	-0.1	12.1	2,057.5	0.2	1.4	1	1	1
09/17/2020 19:00	0.1	11.8	2,123.8	0.2	1.5	1	1	1
09/17/2020 20:00	-0.1	12.2	2,055.5	0.2	1.4	1	1	1
09/17/2020 21:00	-0.1	12.2	2,063.7	0.2	1.4	1	1	1
09/17/2020 22:00	-0.1	12.0	2,108.0	0.2	1.5	1	1	1
09/17/2020 23:00	0.0	12.4	1,794.5	0.0	1.3	1	0	1
Average/Sum#:	0.3	13.0	1,754.0	0.4	1.2	24 #	23 #	12 #
Minimum:	-0.5	11.4	1,292.7	-0.1	0.9	1	0	0
Maximum:	0.7	14.0	2,177.0	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/18/2020 00:00	0.0	19.2	0.2	0.0	0.0	1	0	0
09/18/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 06:00	0.0	17.9	413.9	0.0	0.3	1	0	0
09/18/2020 07:00	0.0	15.4	957.2	0.0	0.7	1	0	0
09/18/2020 08:00	0.6	13.9	1,401.3	0.6	1.0	1	1	0
09/18/2020 09:00	0.6	14.0	1,397.2	0.6	1.0	1	1	0
09/18/2020 10:00	0.6	13.9	1,691.6	0.6	1.2	1	1	0
09/18/2020 11:00	0.6	13.9	1,496.5	0.6	1.0	1	1	0
09/18/2020 12:00	0.6	13.9	1,615.5	0.6	1.1	1	1	0
09/18/2020 13:00	0.7	13.9	1,540.2	0.7	1.1	1	1	1
09/18/2020 14:00	-0.7	12.3	2,038.5	-0.2	1.4	1	1	1
09/18/2020 15:00	-0.5	12.1	2,070.8	-0.1	1.4	1	1	1
09/18/2020 16:00	-0.5	12.2	2,053.0	-0.1	1.4	1	1	1
09/18/2020 17:00	-0.4	12.3	2,037.3	-0.1	1.4	1	1	1
09/18/2020 18:00	-0.5	12.3	2,022.3	-0.1	1.4	1	1	1
09/18/2020 19:00	-0.5	12.4	2,017.2	-0.2	1.4	1	1	1
09/18/2020 20:00	-0.4	12.5	2,014.7	-0.1	1.4	1	1	1
09/18/2020 21:00	-0.4	12.5	2,010.1	-0.1	1.4	1	1	1
09/18/2020 22:00	0.0	13.7	1,464.3	0.0	1.0	1	0	1
09/18/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	13.8	1,569.0	0.2	1.1	18 #	14 #	10 #
Minimum:	-0.7	12.1	0.2	-0.2	0.0	0	0	0
Maximum:	0.7	19.2	2,070.8	0.7	1.4	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/19/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 04:00	0.0	18.3	356.8	0.0	0.2	1	0	0
09/19/2020 05:00	0.0	15.2	953.0	0.0	0.7	1	0	0
09/19/2020 06:00	0.6	13.9	1,399.2	0.6	1.0	1	1	0
09/19/2020 07:00	0.6	13.9	1,389.0	0.6	1.0	1	1	0
09/19/2020 08:00	0.6	13.9	1,386.4	0.6	1.0	1	1	0
09/19/2020 09:00	0.6	14.0	1,388.2	0.6	1.0	1	1	0
09/19/2020 10:00	0.6	14.0	1,393.4	0.6	1.0	1	1	0
09/19/2020 11:00	0.6	14.0	1,397.6	0.6	1.0	1	1	0
09/19/2020 12:00	0.6	14.0	1,492.4	0.6	1.0	1	1	0
09/19/2020 13:00	0.6	13.9	1,583.3	0.6	1.1	1	1	0
09/19/2020 14:00	0.6	14.0	1,471.3	0.6	1.0	1	1	0
09/19/2020 15:00	0.7	14.0	1,538.0	0.7	1.1	1	1	1
09/19/2020 16:00	-0.7	12.3	2,051.9	-0.2	1.4	1	1	1
09/19/2020 17:00	-0.2	11.5	2,199.3	0.1	1.5	1	1	1
09/19/2020 18:00	-0.4	11.7	2,169.4	0.1	1.5	1	1	1
09/19/2020 19:00	-0.4	11.7	2,158.4	0.1	1.5	1	1	1
09/19/2020 20:00	-0.4	11.7	2,145.3	0.1	1.5	1	1	1
09/19/2020 21:00	-0.4	12.0	2,100.9	-0.1	1.5	1	1	1
09/19/2020 22:00	-0.5	12.0	2,102.3	-0.1	1.5	1	1	1
09/19/2020 23:00	-0.5	12.7	1,967.5	-0.2	1.4	1	1	1
Average/Sum#:	0.1	13.4	1,632.2	0.3	1.1	20 #	18 #	9 #
Minimum:	-0.7	11.5	356.8	-0.2	0.2	0	0	0
Maximum:	0.7	18.3	2,199.3	0.7	1.5	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/20/2020 00:00	-0.7	12.8	1,954.8	-0.4	1.4	1	1	1
09/20/2020 01:00	-0.7	12.8	1,959.3	-0.4	1.4	1	1	1
09/20/2020 02:00	-0.7	12.8	1,960.4	-0.4	1.4	1	1	1
09/20/2020 03:00	-0.7	12.8	1,958.5	-0.4	1.4	1	1	1
09/20/2020 04:00	-0.7	12.9	1,947.3	-0.4	1.4	1	1	1
09/20/2020 05:00	-0.2	12.9	1,916.4	0.1	1.3	1	1	1
09/20/2020 06:00	0.0	15.6	659.6	0.0	0.5	1	0	0
09/20/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2020 10:00	0.0	17.9	408.1	0.0	0.3	1	0	0
09/20/2020 11:00	0.0	15.3	951.1	0.0	0.7	1	0	0
09/20/2020 12:00	0.6	14.0	1,486.9	0.6	1.0	1	1	0
09/20/2020 13:00	0.6	13.9	1,546.6	0.6	1.1	1	1	0
09/20/2020 14:00	0.6	13.9	1,602.4	0.6	1.1	1	1	0
09/20/2020 15:00	0.6	13.9	1,478.1	0.6	1.0	1	1	0
09/20/2020 16:00	0.7	13.9	1,588.9	0.7	1.1	1	1	1
09/20/2020 17:00	-0.8	12.1	2,077.6	-0.4	1.5	1	1	1
09/20/2020 18:00	-0.4	11.4	2,205.7	0.1	1.5	1	1	1
09/20/2020 19:00	-0.4	11.4	2,198.0	0.1	1.5	1	1	1
09/20/2020 20:00	-0.4	11.7	2,160.0	0.1	1.5	1	1	1
09/20/2020 21:00	-0.5	12.2	2,013.7	-0.1	1.4	1	1	1
09/20/2020 22:00	0.0	15.6	627.8	0.0	0.4	1	0	0
09/20/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	-0.2	13.5	1,635.1	0.1	1.1	20 #	16 #	12 #
Minimum:	-0.8	11.4	408.1	-0.4	0.3	0	0	0
Maximum:	0.7	17.9	2,205.7	0.7	1.5	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/21/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 13:00	0.0	17.8	422.7	0.0	0.3	1	0	0
09/21/2020 14:00	0.0	15.5	809.6	0.0	0.6	1	0	0
09/21/2020 15:00	0.7	13.9	1,520.3	0.7	1.1	1	1	1
09/21/2020 16:00	-0.5	12.4	1,984.3	-0.2	1.4	1	1	1
09/21/2020 17:00	-0.5	12.3	2,014.5	-0.1	1.4	1	1	1
09/21/2020 18:00	-0.5	12.4	1,995.7	-0.2	1.4	1	1	1
09/21/2020 19:00	-0.4	12.1	2,057.6	-0.1	1.4	1	1	1
09/21/2020 20:00	-0.4	11.9	2,104.7	-0.1	1.5	1	1	1
09/21/2020 21:00	-0.4	12.1	2,041.2	-0.1	1.4	1	1	1
09/21/2020 22:00	0.0	15.7	620.1	0.0	0.4	1	0	0
09/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	-0.2	13.6	1,557.1	0.0	1.1	10 #	7 #	7 #
Minimum:	-0.5	11.9	422.7	-0.2	0.3	0	0	0
Maximum:	0.7	17.8	2,104.7	0.7	1.5	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 14:00	0.0	17.9	412.5	0.0	0.3	1	0	0
09/22/2020 15:00	0.0	15.5	828.1	0.0	0.6	1	0	0
09/22/2020 16:00	0.7	13.9	1,522.4	0.7	1.1	1	1	1
09/22/2020 17:00	-0.4	12.6	1,765.3	-0.1	1.2	1	1	1
09/22/2020 18:00	-0.2	12.7	1,775.9	0.1	1.2	1	1	1
09/22/2020 19:00	-0.2	12.7	1,775.9	0.1	1.2	1	1	1
09/22/2020 20:00	-0.2	12.7	1,775.0	0.1	1.2	1	1	1
09/22/2020 21:00	0.0	14.2	1,185.6	0.0	0.8	1	0	1
09/22/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	14.0	1,380.1	0.1	1.0	8 #	5 #	6 #
Minimum:	-0.4	12.6	412.5	-0.1	0.3	0	0	0
Maximum:	0.7	17.9	1,775.9	0.7	1.2	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/23/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 13:00	0.0	17.8	423.1	0.0	0.3	1	0	0
09/23/2020 14:00	0.0	15.7	795.1	0.0	0.6	1	0	0
09/23/2020 15:00	0.7	13.9	1,553.8	0.7	1.1	1	1	1
09/23/2020 16:00	-0.5	12.3	2,024.5	-0.1	1.4	1	1	1
09/23/2020 17:00	-0.5	12.3	2,019.3	-0.1	1.4	1	1	1
09/23/2020 18:00	-0.5	12.6	1,989.1	-0.2	1.4	1	1	1
09/23/2020 19:00	-0.5	12.3	2,062.2	-0.1	1.4	1	1	1
09/23/2020 20:00	-0.5	12.8	1,941.0	-0.2	1.4	1	1	1
09/23/2020 21:00	0.0	15.8	606.2	0.0	0.4	1	0	0
09/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	-0.2	13.9	1,490.5	0.0	1.0	9 #	6 #	6 #
Minimum:	-0.5	12.3	423.1	-0.2	0.3	0	0	0
Maximum:	0.7	17.8	2,062.2	0.7	1.4	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 08:00	0.0	18.0	396.8	0.0	0.3	1	0	0
09/24/2020 09:00	0.0	17.1	515.3	0.0	0.4	1	0	0
09/24/2020 10:00	0.0	15.5	870.0	0.0	0.6	1	0	0
09/24/2020 11:00	0.6	14.0	1,380.6	0.6	1.0	1	1	0
09/24/2020 12:00	0.6	14.0	1,367.0	0.6	1.0	1	1	0
09/24/2020 13:00	0.6	13.9	1,577.5	0.6	1.1	1	1	0
09/24/2020 14:00	0.6	14.0	1,408.9	0.6	1.0	1	1	0
09/24/2020 15:00	0.6	13.9	1,659.9	0.6	1.2	1	1	0
09/24/2020 16:00	-0.1	13.1	1,821.4	0.1	1.3	1	1	1
09/24/2020 17:00	-0.5	11.9	2,104.3	-0.1	1.5	1	1	1
09/24/2020 18:00	-0.5	12.0	2,093.7	-0.1	1.5	1	1	1
09/24/2020 19:00	-0.5	12.1	2,086.4	-0.1	1.5	1	1	1
09/24/2020 20:00	0.0	14.1	1,203.9	0.0	0.8	1	0	1
09/24/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.1	14.1	1,422.0	0.2	1.0	13 #	9 #	5 #
Minimum:	-0.5	11.9	396.8	-0.1	0.3	0	0	0
Maximum:	0.6	18.0	2,104.3	0.6	1.5	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 08:00	0.0	19.8	121.9	0.0	0.1	1	0	0
09/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 13:00	0.0	19.2	216.0	0.0	0.2	1	0	0
09/27/2020 14:00	0.0	16.5	601.3	0.0	0.4	1	0	0
09/27/2020 15:00	0.0	14.0	1,610.3	0.0	1.1	1	0	0
09/27/2020 16:00	0.4	0.0	1,618.6	0.5	1.1	1	1	1
09/27/2020 17:00	-0.7	11.8	2,097.3	-0.2	1.5	1	1	1
09/27/2020 18:00	-0.5	11.9	2,137.0	-0.1	1.5	1	1	1
09/27/2020 19:00	-0.5	11.8	2,148.4	-0.1	1.5	1	1	1
09/27/2020 20:00	-0.5	11.9	2,146.1	-0.1	1.5	1	1	1
09/27/2020 21:00	-0.5	11.9	2,140.9	-0.1	1.5	1	1	1
09/27/2020 22:00	0.0	13.7	1,277.6	0.0	0.9	1	0	1
09/27/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	-0.2	14.3	1,465.0	-0.1	1.0	11 #	6 #	7 #
Minimum:	-0.7	11.8	121.9	-0.2	0.1	0	0	0
Maximum:	0.4	19.8	2,148.4	0.0	1.5	1	1	1
%SI	54.17	58.33	54.17	58.33	54.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/28/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 06:00	0.0	18.0	402.9	0.0	0.3	1	0	0
09/28/2020 07:00	0.0	15.5	897.4	0.0	0.6	1	0	0
09/28/2020 08:00	0.6	14.1	1,383.9	0.6	1.0	1	1	0
09/28/2020 09:00	0.6	14.1	1,368.3	0.6	1.0	1	1	0
09/28/2020 10:00	0.6	13.9	1,641.9	0.6	1.1	1	1	0
09/28/2020 11:00	0.6	14.0	1,465.0	0.6	1.0	1	1	0
09/28/2020 12:00	0.6	13.9	1,731.9	0.6	1.2	1	1	0
09/28/2020 13:00	0.2	13.6	1,690.7	0.4	1.2	1	1	1
09/28/2020 14:00	-0.5	12.0	2,125.5	-0.1	1.5	1	1	1
09/28/2020 15:00	-0.1	11.5	2,208.3	0.2	1.5	1	1	1
09/28/2020 16:00	-0.1	11.5	2,206.8	0.2	1.5	1	1	1
09/28/2020 17:00	-0.2	11.6	2,191.5	0.1	1.5	1	1	1
09/28/2020 18:00	-0.2	11.6	2,187.1	0.1	1.5	1	1	1
09/28/2020 19:00	-0.4	11.9	2,131.0	-0.1	1.5	1	1	1
09/28/2020 20:00	-0.4	11.9	2,141.9	-0.1	1.5	1	1	1
09/28/2020 21:00	-0.5	12.1	2,105.4	-0.1	1.5	1	1	1
09/28/2020 22:00	0.0	14.0	1,261.1	0.0	0.9	1	0	1
09/28/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	13.2	1,714.2	0.2	1.2	17 #	14 #	10 #
Minimum:	-0.5	11.5	402.9	-0.1	0.3	0	0	0
Maximum:	0.6	18.0	2,208.3	0.6	1.5	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 06:00	0.0	18.0	412.2	0.0	0.3	1	0	0
09/29/2020 07:00	0.0	15.6	873.1	0.0	0.6	1	0	0
09/29/2020 08:00	0.6	14.1	1,374.8	0.6	1.0	1	1	0
09/29/2020 09:00	0.6	14.1	1,361.9	0.6	1.0	1	1	0
09/29/2020 10:00	0.6	13.9	1,610.6	0.6	1.1	1	1	0
09/29/2020 11:00	0.6	14.0	1,484.3	0.6	1.0	1	1	0
09/29/2020 12:00	0.6	13.9	1,718.3	0.6	1.2	1	1	0
09/29/2020 13:00	-0.2	13.3	1,794.9	-0.1	1.3	1	1	1
09/29/2020 14:00	-0.7	11.9	2,140.7	-0.2	1.5	1	1	1
09/29/2020 15:00	-0.5	11.7	2,162.4	-0.1	1.5	1	1	1
09/29/2020 16:00	-0.4	11.5	2,198.0	0.1	1.5	1	1	1
09/29/2020 17:00	-0.2	11.5	2,198.4	0.1	1.5	1	1	1
09/29/2020 18:00	-0.4	11.8	2,150.6	-0.1	1.5	1	1	1
09/29/2020 19:00	-0.4	11.7	2,187.4	0.1	1.5	1	1	1
09/29/2020 20:00	-0.4	11.8	2,169.2	-0.1	1.5	1	1	1
09/29/2020 21:00	-0.5	11.9	2,148.6	-0.1	1.5	1	1	1
09/29/2020 22:00	-0.5	12.1	2,114.4	-0.1	1.5	1	1	1
09/29/2020 23:00	-0.5	12.2	2,103.0	-0.1	1.5	1	1	1
Average/Sum#:	-0.1	13.1	1,789.0	0.1	1.3	18 #	16 #	11 #
Minimum:	-0.7	11.5	412.2	-0.2	0.3	0	0	0
Maximum:	0.6	18.0	2,198.4	0.6	1.5	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:36 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/30/2020 00:00	-0.5	12.6	2,012.9	-0.2	1.4	1	1	1
09/30/2020 01:00	0.6	13.9	1,653.9	0.6	1.2	1	1	0
09/30/2020 02:00	0.6	13.9	1,693.5	0.6	1.2	1	1	0
09/30/2020 03:00	0.6	13.9	1,673.6	0.6	1.2	1	1	0
09/30/2020 04:00	0.2	13.7	1,718.6	0.4	1.2	1	1	1
09/30/2020 05:00	-0.8	12.4	2,046.5	-0.4	1.4	1	1	1
09/30/2020 06:00	-0.7	12.4	2,035.4	-0.2	1.4	1	1	1
09/30/2020 07:00	0.6	13.9	1,661.0	0.6	1.2	1	1	0
09/30/2020 08:00	0.5	13.9	1,695.7	0.5	1.2	1	1	0
09/30/2020 09:00	0.6	13.9	1,699.6	0.6	1.2	1	1	0
09/30/2020 10:00	0.2	13.6	1,696.0	0.4	1.2	1	1	1
09/30/2020 11:00	-0.7	12.1	2,112.0	-0.2	1.5	1	1	1
09/30/2020 12:00	-0.5	11.8	2,147.5	-0.1	1.5	1	1	1
09/30/2020 13:00	-0.2	11.6	2,177.0	0.1	1.5	1	1	1
09/30/2020 14:00	-0.2	11.8	2,116.5	0.1	1.5	1	1	1
09/30/2020 15:00	-0.4	11.7	2,151.0	0.1	1.5	1	1	1
09/30/2020 16:00	-0.2	11.7	2,142.2	0.1	1.5	1	1	1
09/30/2020 17:00	-0.4	11.8	2,121.0	-0.1	1.5	1	1	1
09/30/2020 18:00	-0.4	11.8	2,139.7	-0.1	1.5	1	1	1
09/30/2020 19:00	-0.4	11.7	2,163.6	0.1	1.5	1	1	1
09/30/2020 20:00	-0.4	11.8	2,146.1	-0.1	1.5	1	1	1
09/30/2020 21:00	-0.4	11.9	2,128.7	-0.1	1.5	1	1	1
09/30/2020 22:00	-0.4	12.0	2,113.7	-0.1	1.5	1	1	1
09/30/2020 23:00	-0.5	12.5	1,981.1	-0.2	1.4	1	1	1
Average/Sum#:	-0.1	12.6	1,967.8	0.1	1.4	24 #	24 #	18 #
Minimum:	-0.8	11.6	1,653.9	-0.4	1.2	1	1	0
Maximum:	0.6	13.9	2,177.0	0.6	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 08:00	0.0	17.6	451.6	0.0	0.1	1	0	0
07/03/2020 09:00	0.0	17.1	517.8	0.0	0.2	1	0	0
07/03/2020 10:00	0.0	15.8	830.3	0.0	0.2	1	0	0
07/03/2020 11:00	0.4	13.9	1,391.9	0.4	0.4	1	1	0
07/03/2020 12:00	0.4	13.9	1,359.1	0.4	0.4	1	1	0
07/03/2020 13:00	0.4	13.9	1,606.0	0.4	0.5	1	1	0
07/03/2020 14:00	0.4	13.9	1,451.0	0.4	0.4	1	1	0
07/03/2020 15:00	0.4	13.8	1,676.5	0.4	0.5	1	1	0
07/03/2020 16:00	0.2	13.8	1,641.4	0.4	0.5	1	1	1
07/03/2020 17:00	-0.2	12.4	2,019.1	0.1	0.6	1	1	1
07/03/2020 18:00	0.1	12.0	2,108.2	0.2	0.6	1	1	1
07/03/2020 19:00	0.1	12.0	2,089.5	0.2	0.6	1	1	1
07/03/2020 20:00	0.1	11.9	2,117.2	0.2	0.6	1	1	1
07/03/2020 21:00	-0.1	12.3	2,033.4	0.2	0.6	1	1	1
07/03/2020 22:00	-0.1	12.3	2,052.5	0.2	0.6	1	1	1
07/03/2020 23:00	0.0	14.1	1,216.3	0.0	0.4	1	0	1
Average/Sum#:	0.1	13.8	1,535.1	0.2	0.5	16 #	12 #	8 #
Minimum:	-0.2	11.9	451.6	0.0	0.1	0	0	0
Maximum:	0.4	17.6	2,117.2	0.4	0.6	1	1	1
%SI	33.33	33.33	33.33	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/04/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/05/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 09:00	0.0	17.5	455.8	0.0	0.1	1	0	0
07/05/2020 10:00	0.0	17.0	520.2	0.0	0.2	1	0	0
07/05/2020 11:00	0.0	15.4	867.4	0.0	0.3	1	0	0
07/05/2020 12:00	0.4	14.0	1,394.7	0.4	0.4	1	1	0
07/05/2020 13:00	0.4	14.0	1,383.8	0.4	0.4	1	1	0
07/05/2020 14:00	0.4	13.8	1,632.8	0.4	0.5	1	1	0
07/05/2020 15:00	0.4	14.0	1,389.5	0.4	0.4	1	1	0
07/05/2020 16:00	0.3	13.8	1,603.7	0.4	0.5	1	1	0
07/05/2020 17:00	-0.1	13.0	1,813.1	0.1	0.5	1	1	1
07/05/2020 18:00	-0.1	11.9	2,095.0	0.2	0.6	1	1	1
07/05/2020 19:00	-0.1	12.0	2,077.3	0.2	0.6	1	1	1
07/05/2020 20:00	-0.1	12.0	2,095.4	0.2	0.6	1	1	1
07/05/2020 21:00	-0.1	12.2	2,082.0	0.2	0.6	1	1	1
07/05/2020 22:00	0.0	13.6	1,379.2	0.0	0.4	1	0	1
07/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.1	13.9	1,485.0	0.2	0.4	14 #	10 #	6 #
Minimum:	-0.1	11.9	455.8	0.0	0.1	0	0	0
Maximum:	0.4	17.5	2,095.4	0.4	0.6	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2020 02:00	0.0	17.7	448.7	0.0	0.1	1	0	0
07/06/2020 03:00	0.0	14.5	1,146.4	0.0	0.3	1	0	0
07/06/2020 04:00	0.4	13.9	1,375.6	0.4	0.4	1	1	0
07/06/2020 05:00	0.4	13.9	1,375.6	0.4	0.4	1	1	0
07/06/2020 06:00	0.4	13.9	1,378.4	0.4	0.4	1	1	0
07/06/2020 07:00	0.4	13.9	1,379.4	0.4	0.4	1	1	0
07/06/2020 08:00	0.4	14.0	1,382.7	0.4	0.4	1	1	0
07/06/2020 09:00	0.4	13.9	1,384.9	0.4	0.4	1	1	0
07/06/2020 10:00	0.4	13.9	1,389.9	0.4	0.4	1	1	0
07/06/2020 11:00	0.3	13.8	1,637.8	0.4	0.5	1	1	0
07/06/2020 12:00	0.3	13.8	1,507.3	0.4	0.5	1	1	0
07/06/2020 13:00	0.3	13.7	1,697.7	0.4	0.5	1	1	0
07/06/2020 14:00	0.3	13.8	1,627.3	0.4	0.5	1	1	0
07/06/2020 15:00	0.1	13.7	1,556.1	0.2	0.5	1	1	1
07/06/2020 16:00	-0.4	12.3	2,050.3	-0.1	0.6	1	1	1
07/06/2020 17:00	-0.1	12.0	2,098.7	0.2	0.6	1	1	1
07/06/2020 18:00	-0.1	11.9	2,111.2	0.2	0.6	1	1	1
07/06/2020 19:00	-0.1	12.1	2,085.5	0.2	0.6	1	1	1
07/06/2020 20:00	-0.2	12.3	2,065.3	0.1	0.6	1	1	1
07/06/2020 21:00	-0.2	12.4	2,040.8	0.1	0.6	1	1	1
07/06/2020 22:00	-0.2	12.8	1,951.6	0.1	0.6	1	1	1
07/06/2020 23:00	-0.1	13.1	1,794.6	0.1	0.5	1	1	1
Average/Sum#:	0.1	13.5	1,613.0	0.3	0.5	22 #	20 #	9 #
Minimum:	-0.4	11.9	448.7	-0.1	0.1	0	0	0
Maximum:	0.4	17.7	2,111.2	0.4	0.6	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/07/2020 00:00	0.4	13.9	1,294.8	0.4	0.4	1	1	0
07/07/2020 01:00	0.4	13.9	1,344.3	0.4	0.4	1	1	0
07/07/2020 02:00	0.4	13.9	1,301.2	0.4	0.4	1	1	0
07/07/2020 03:00	0.4	13.9	1,292.5	0.4	0.4	1	1	0
07/07/2020 04:00	0.4	13.9	1,283.1	0.4	0.4	1	1	0
07/07/2020 05:00	0.4	13.9	1,306.7	0.4	0.4	1	1	0
07/07/2020 06:00	0.4	13.9	1,293.5	0.4	0.4	1	1	0
07/07/2020 07:00	0.4	13.9	1,310.8	0.4	0.4	1	1	0
07/07/2020 08:00	0.4	14.0	1,329.5	0.4	0.4	1	1	0
07/07/2020 09:00	0.4	13.9	1,305.9	0.4	0.4	1	1	0
07/07/2020 10:00	0.4	13.9	1,295.0	0.4	0.4	1	1	0
07/07/2020 11:00	0.4	14.0	1,299.5	0.4	0.4	1	1	0
07/07/2020 12:00	0.4	14.0	1,301.5	0.4	0.4	1	1	0
07/07/2020 13:00	0.3	13.9	1,403.2	0.4	0.4	1	1	0
07/07/2020 14:00	0.4	13.9	1,374.7	0.4	0.4	1	1	0
07/07/2020 15:00	0.2	13.9	1,514.4	0.2	0.5	1	1	1
07/07/2020 16:00	-0.2	12.3	2,035.3	0.1	0.6	1	1	1
07/07/2020 17:00	0.1	12.0	2,107.7	0.2	0.6	1	1	1
07/07/2020 18:00	0.1	12.1	2,081.0	0.2	0.6	1	1	1
07/07/2020 19:00	0.1	12.2	2,071.5	0.2	0.6	1	1	1
07/07/2020 20:00	0.1	12.2	2,075.5	0.2	0.6	1	1	1
07/07/2020 21:00	0.1	12.3	2,066.0	0.2	0.6	1	1	1
07/07/2020 22:00	-0.2	12.7	1,966.2	0.1	0.6	1	1	1
07/07/2020 23:00	-0.1	13.0	1,849.4	0.1	0.6	1	1	1
Average/Sum#:	0.3	13.4	1,562.6	0.3	0.5	24 #	24 #	9 #
Minimum:	-0.2	12.0	1,283.1	0.1	0.4	1	1	0
Maximum:	0.4	14.0	2,107.7	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/08/2020 00:00	0.5	14.0	1,316.6	0.5	0.4	1	1	0
07/08/2020 01:00	0.4	14.0	1,283.1	0.4	0.4	1	1	0
07/08/2020 02:00	0.4	14.0	1,283.2	0.4	0.4	1	1	0
07/08/2020 03:00	0.5	14.0	1,283.2	0.5	0.4	1	1	0
07/08/2020 04:00	0.5	14.0	1,285.2	0.5	0.4	1	1	0
07/08/2020 05:00	0.5	14.0	1,296.4	0.5	0.4	1	1	0
07/08/2020 06:00	0.5	14.0	1,287.7	0.5	0.4	1	1	0
07/08/2020 07:00	0.6	14.0	1,291.8	0.6	0.4	1	1	0
07/08/2020 08:00	0.5	14.0	1,289.9	0.5	0.4	1	1	0
07/08/2020 09:00	0.5	14.0	1,289.4	0.5	0.4	1	1	0
07/08/2020 10:00	0.5	14.0	1,291.4	0.5	0.4	1	1	0
07/08/2020 11:00	0.4	14.0	1,308.4	0.4	0.4	1	1	0
07/08/2020 12:00	0.4	14.0	1,363.9	0.4	0.4	1	1	0
07/08/2020 13:00	0.4	14.0	1,315.9	0.4	0.4	1	1	0
07/08/2020 14:00	0.4	14.0	1,367.2	0.4	0.4	1	1	0
07/08/2020 15:00	0.4	13.9	1,455.6	0.4	0.4	1	1	1
07/08/2020 16:00	-0.1	12.2	2,035.2	0.2	0.6	1	1	1
07/08/2020 17:00	0.1	12.0	2,067.8	0.2	0.6	1	1	1
07/08/2020 18:00	0.2	12.0	2,077.6	0.4	0.6	1	1	1
07/08/2020 19:00	0.1	12.0	2,075.5	0.2	0.6	1	1	1
07/08/2020 20:00	0.1	12.0	2,077.7	0.2	0.6	1	1	1
07/08/2020 21:00	0.1	12.3	2,016.0	0.2	0.6	1	1	1
07/08/2020 22:00	-0.1	12.6	1,969.5	0.1	0.6	1	1	1
07/08/2020 23:00	0.1	12.9	1,805.0	0.2	0.5	1	1	1
Average/Sum#:	0.3	13.4	1,547.2	0.4	0.5	24 #	24 #	9 #
Minimum:	-0.1	12.0	1,283.1	0.1	0.4	1	1	0
Maximum:	0.6	14.0	2,077.7	0.6	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/09/2020 00:00	0.4	13.9	1,304.7	0.4	0.4	1	1	0
07/09/2020 01:00	0.4	13.9	1,300.1	0.4	0.4	1	1	0
07/09/2020 02:00	0.4	13.9	1,282.4	0.4	0.4	1	1	0
07/09/2020 03:00	0.4	13.9	1,343.4	0.4	0.4	1	1	0
07/09/2020 04:00	0.4	13.9	1,312.4	0.4	0.4	1	1	0
07/09/2020 05:00	0.4	13.9	1,366.0	0.4	0.4	1	1	0
07/09/2020 06:00	0.4	14.0	1,295.6	0.4	0.4	1	1	0
07/09/2020 07:00	0.5	14.0	1,295.1	0.5	0.4	1	1	0
07/09/2020 08:00	0.5	14.0	1,298.9	0.5	0.4	1	1	0
07/09/2020 09:00	0.4	14.0	1,301.3	0.4	0.4	1	1	0
07/09/2020 10:00	0.4	13.9	1,296.7	0.4	0.4	1	1	0
07/09/2020 11:00	0.4	14.0	1,296.8	0.4	0.4	1	1	0
07/09/2020 12:00	0.4	13.9	1,545.2	0.4	0.5	1	1	0
07/09/2020 13:00	0.4	13.8	1,663.7	0.4	0.5	1	1	0
07/09/2020 14:00	0.2	13.8	1,535.0	0.4	0.5	1	1	1
07/09/2020 15:00	-0.2	12.2	2,036.1	0.1	0.6	1	1	1
07/09/2020 16:00	-0.1	12.0	2,070.7	0.2	0.6	1	1	1
07/09/2020 17:00	0.1	11.9	2,086.0	0.2	0.6	1	1	1
07/09/2020 18:00	0.1	11.8	2,106.8	0.2	0.6	1	1	1
07/09/2020 19:00	0.1	11.8	2,104.1	0.2	0.6	1	1	1
07/09/2020 20:00	0.1	12.0	2,070.7	0.2	0.6	1	1	1
07/09/2020 21:00	0.1	12.1	2,069.5	0.2	0.6	1	1	1
07/09/2020 22:00	-0.1	12.6	1,975.0	0.1	0.6	1	1	1
07/09/2020 23:00	-0.2	12.7	1,920.2	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.2	1,619.9	0.3	0.5	24 #	24 #	10 #
Minimum:	-0.2	11.8	1,282.4	0.1	0.4	1	1	0
Maximum:	0.5	14.0	2,106.8	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/10/2020 00:00	0.4	13.9	1,390.8	0.4	0.4	1	1	0
07/10/2020 01:00	0.4	14.0	1,287.0	0.4	0.4	1	1	0
07/10/2020 02:00	0.5	14.0	1,286.1	0.5	0.4	1	1	0
07/10/2020 03:00	0.5	14.0	1,283.4	0.5	0.4	1	1	0
07/10/2020 04:00	0.5	13.9	1,293.4	0.5	0.4	1	1	0
07/10/2020 05:00	0.4	13.9	1,564.4	0.4	0.5	1	1	0
07/10/2020 06:00	0.4	13.9	1,666.7	0.4	0.5	1	1	0
07/10/2020 07:00	0.4	13.8	1,666.7	0.4	0.5	1	1	0
07/10/2020 08:00	0.4	13.9	1,579.1	0.4	0.5	1	1	0
07/10/2020 09:00	0.4	13.9	1,443.5	0.4	0.4	1	1	0
07/10/2020 10:00	0.4	13.9	1,479.8	0.4	0.4	1	1	0
07/10/2020 11:00	0.4	13.9	1,373.5	0.4	0.4	1	1	0
07/10/2020 12:00	0.2	13.8	1,529.8	0.4	0.5	1	1	1
07/10/2020 13:00	-0.2	12.3	2,008.5	0.1	0.6	1	1	1
07/10/2020 14:00	-0.1	12.0	2,064.0	0.2	0.6	1	1	1
07/10/2020 15:00	-0.1	12.0	2,067.6	0.2	0.6	1	1	1
07/10/2020 16:00	0.1	11.8	2,090.1	0.2	0.6	1	1	1
07/10/2020 17:00	0.1	11.7	2,103.5	0.2	0.6	1	1	1
07/10/2020 18:00	0.1	11.7	2,111.5	0.2	0.6	1	1	1
07/10/2020 19:00	0.1	11.7	2,115.1	0.2	0.6	1	1	1
07/10/2020 20:00	0.1	11.7	2,114.5	0.2	0.6	1	1	1
07/10/2020 21:00	-0.1	12.1	2,042.9	0.2	0.6	1	1	1
07/10/2020 22:00	-0.1	12.1	2,059.0	0.2	0.6	1	1	1
07/10/2020 23:00	-0.1	12.9	1,788.6	0.1	0.5	1	1	1
Average/Sum#:	0.2	13.0	1,725.4	0.3	0.5	24 #	24 #	12 #
Minimum:	-0.2	11.7	1,283.4	0.1	0.4	1	1	0
Maximum:	0.5	14.0	2,115.1	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/11/2020 00:00	0.4	13.9	1,296.6	0.4	0.4	1	1	0
07/11/2020 01:00	0.3	13.9	1,344.8	0.4	0.4	1	1	0
07/11/2020 02:00	0.4	13.9	1,352.0	0.4	0.4	1	1	0
07/11/2020 03:00	0.4	13.9	1,368.2	0.4	0.4	1	1	0
07/11/2020 04:00	0.4	13.9	1,333.1	0.4	0.4	1	1	0
07/11/2020 05:00	0.3	13.9	1,655.3	0.4	0.5	1	1	0
07/11/2020 06:00	0.3	13.9	1,585.4	0.4	0.5	1	1	0
07/11/2020 07:00	0.4	13.9	1,360.0	0.4	0.4	1	1	0
07/11/2020 08:00	0.4	13.9	1,577.4	0.4	0.5	1	1	0
07/11/2020 09:00	0.4	13.9	1,308.9	0.4	0.4	1	1	0
07/11/2020 10:00	0.4	13.9	1,479.0	0.4	0.4	1	1	0
07/11/2020 11:00	0.4	13.8	1,610.3	0.4	0.5	1	1	0
07/11/2020 12:00	0.4	13.9	1,619.1	0.4	0.5	1	1	0
07/11/2020 13:00	0.4	13.9	1,364.5	0.4	0.4	1	1	0
07/11/2020 14:00	0.4	13.9	1,363.2	0.4	0.4	1	1	0
07/11/2020 15:00	-0.1	13.0	1,786.6	0.1	0.5	1	1	1
07/11/2020 16:00	0.1	11.9	2,090.2	0.2	0.6	1	1	1
07/11/2020 17:00	0.2	11.8	2,113.8	0.4	0.6	1	1	1
07/11/2020 18:00	0.2	11.8	2,122.3	0.4	0.6	1	1	1
07/11/2020 19:00	0.2	11.8	2,127.3	0.4	0.6	1	1	1
07/11/2020 20:00	0.1	12.0	2,085.5	0.2	0.6	1	1	1
07/11/2020 21:00	0.1	12.2	2,050.1	0.2	0.6	1	1	1
07/11/2020 22:00	-0.1	12.2	2,065.3	0.2	0.6	1	1	1
07/11/2020 23:00	-0.1	12.9	1,805.9	0.1	0.5	1	1	1
Average/Sum#:	0.3	13.3	1,661.0	0.3	0.5	24 #	24 #	9 #
Minimum:	-0.1	11.8	1,296.6	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,127.3	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/12/2020 00:00	0.4	13.9	1,295.6	0.4	0.4	1	1	0
07/12/2020 01:00	0.4	13.9	1,287.2	0.4	0.4	1	1	0
07/12/2020 02:00	0.4	13.9	1,286.0	0.4	0.4	1	1	0
07/12/2020 03:00	0.4	13.9	1,285.9	0.4	0.4	1	1	0
07/12/2020 04:00	0.4	13.9	1,287.1	0.4	0.4	1	1	0
07/12/2020 05:00	0.4	13.9	1,288.6	0.4	0.4	1	1	0
07/12/2020 06:00	0.4	14.0	1,299.8	0.4	0.4	1	1	0
07/12/2020 07:00	0.4	14.0	1,295.9	0.4	0.4	1	1	0
07/12/2020 08:00	0.4	14.0	1,290.6	0.4	0.4	1	1	0
07/12/2020 09:00	0.4	14.0	1,300.9	0.4	0.4	1	1	0
07/12/2020 10:00	0.4	14.0	1,403.5	0.4	0.4	1	1	0
07/12/2020 11:00	0.4	13.9	1,371.6	0.4	0.4	1	1	0
07/12/2020 12:00	0.4	13.9	1,427.6	0.4	0.4	1	1	0
07/12/2020 13:00	0.4	14.0	1,365.6	0.4	0.4	1	1	0
07/12/2020 14:00	0.4	14.0	1,313.3	0.4	0.4	1	1	0
07/12/2020 15:00	0.2	13.7	1,643.7	0.4	0.5	1	1	1
07/12/2020 16:00	-0.1	12.1	2,053.3	0.2	0.6	1	1	1
07/12/2020 17:00	0.1	11.7	2,111.8	0.2	0.6	1	1	1
07/12/2020 18:00	0.1	11.7	2,102.2	0.2	0.6	1	1	1
07/12/2020 19:00	0.1	11.8	2,091.2	0.2	0.6	1	1	1
07/12/2020 20:00	0.1	12.0	2,048.7	0.2	0.6	1	1	1
07/12/2020 21:00	-0.1	12.2	2,022.0	0.2	0.6	1	1	1
07/12/2020 22:00	-0.1	12.0	2,061.4	0.2	0.6	1	1	1
07/12/2020 23:00	-0.2	12.5	1,936.2	0.1	0.6	1	1	1
Average/Sum#:	0.3	13.3	1,577.9	0.3	0.5	24 #	24 #	9 #
Minimum:	-0.2	11.7	1,285.9	0.1	0.4	1	1	0
Maximum:	0.4	14.0	2,111.8	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/13/2020 00:00	0.3	13.8	1,575.8	0.4	0.5	1	1	0
07/13/2020 01:00	0.3	13.8	1,438.5	0.4	0.4	1	1	0
07/13/2020 02:00	0.4	13.9	1,319.9	0.4	0.4	1	1	0
07/13/2020 03:00	0.4	13.9	1,289.0	0.4	0.4	1	1	0
07/13/2020 04:00	0.4	13.9	1,289.2	0.4	0.4	1	1	0
07/13/2020 05:00	0.3	13.8	1,622.3	0.4	0.5	1	1	0
07/13/2020 06:00	0.3	13.8	1,486.7	0.4	0.4	1	1	0
07/13/2020 07:00	0.3	13.9	1,390.0	0.4	0.4	1	1	0
07/13/2020 08:00	0.3	13.9	1,521.8	0.4	0.5	1	1	0
07/13/2020 09:00	0.4	13.9	1,306.4	0.4	0.4	1	1	0
07/13/2020 10:00	0.4	13.9	1,480.7	0.4	0.4	1	1	0
07/13/2020 11:00	0.2	13.8	1,617.5	0.4	0.5	1	1	1
07/13/2020 12:00	-0.2	12.4	2,000.9	0.1	0.6	1	1	1
07/13/2020 13:00	0.1	12.0	2,050.8	0.2	0.6	1	1	1
07/13/2020 14:00	0.1	12.0	2,063.9	0.2	0.6	1	1	1
07/13/2020 15:00	0.1	11.9	2,064.6	0.2	0.6	1	1	1
07/13/2020 16:00	0.1	11.9	2,074.4	0.2	0.6	1	1	1
07/13/2020 17:00	0.1	11.8	2,083.9	0.2	0.6	1	1	1
07/13/2020 18:00	0.2	11.8	2,083.5	0.4	0.6	1	1	1
07/13/2020 19:00	0.2	11.9	2,079.3	0.4	0.6	1	1	1
07/13/2020 20:00	0.1	12.0	2,067.4	0.2	0.6	1	1	1
07/13/2020 21:00	0.1	12.1	2,056.2	0.2	0.6	1	1	1
07/13/2020 22:00	0.1	12.2	2,056.1	0.2	0.6	1	1	1
07/13/2020 23:00	-0.2	12.7	1,946.3	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.0	1,748.5	0.3	0.5	24 #	24 #	13 #
Minimum:	-0.2	11.8	1,289.0	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,083.9	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/14/2020 00:00	-0.1	13.1	1,776.5	0.1	0.5	1	1	1
07/14/2020 01:00	0.4	13.8	1,294.3	0.4	0.4	1	1	0
07/14/2020 02:00	0.4	13.9	1,351.9	0.4	0.4	1	1	0
07/14/2020 03:00	0.4	13.9	1,292.8	0.4	0.4	1	1	0
07/14/2020 04:00	0.4	13.9	1,286.6	0.4	0.4	1	1	0
07/14/2020 05:00	0.3	13.8	1,625.6	0.4	0.5	1	1	0
07/14/2020 06:00	0.3	13.8	1,657.9	0.4	0.5	1	1	0
07/14/2020 07:00	0.4	13.8	1,671.9	0.4	0.5	1	1	0
07/14/2020 08:00	0.4	13.8	1,546.9	0.4	0.5	1	1	0
07/14/2020 09:00	0.4	13.9	1,297.9	0.4	0.4	1	1	0
07/14/2020 10:00	0.4	13.9	1,313.5	0.4	0.4	1	1	0
07/14/2020 11:00	0.4	13.9	1,359.7	0.4	0.4	1	1	0
07/14/2020 12:00	0.4	13.8	1,530.8	0.4	0.5	1	1	0
07/14/2020 13:00	0.4	13.9	1,340.1	0.4	0.4	1	1	0
07/14/2020 14:00	-0.2	12.4	1,959.1	0.1	0.6	1	1	1
07/14/2020 15:00	-0.1	12.0	2,041.4	0.2	0.6	1	1	1
07/14/2020 16:00	-0.1	12.0	2,060.0	0.2	0.6	1	1	1
07/14/2020 17:00	0.1	11.9	2,062.9	0.2	0.6	1	1	1
07/14/2020 18:00	0.1	11.9	2,078.4	0.2	0.6	1	1	1
07/14/2020 19:00	0.1	11.9	2,075.3	0.2	0.6	1	1	1
07/14/2020 20:00	0.1	12.0	2,068.2	0.2	0.6	1	1	1
07/14/2020 21:00	0.1	12.0	2,072.3	0.2	0.6	1	1	1
07/14/2020 22:00	-0.1	12.6	1,952.5	0.1	0.6	1	1	1
07/14/2020 23:00	-0.1	13.0	1,777.5	0.1	0.5	1	1	1
Average/Sum#:	0.2	13.1	1,687.3	0.3	0.5	24 #	24 #	11 #
Minimum:	-0.2	11.9	1,286.6	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,078.4	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/15/2020 00:00	0.4	13.8	1,290.4	0.4	0.4	1	1	0
07/15/2020 01:00	0.4	13.9	1,289.2	0.4	0.4	1	1	0
07/15/2020 02:00	0.4	13.9	1,287.8	0.4	0.4	1	1	0
07/15/2020 03:00	0.4	13.9	1,289.4	0.4	0.4	1	1	0
07/15/2020 04:00	0.4	13.9	1,289.8	0.4	0.4	1	1	0
07/15/2020 05:00	0.4	13.9	1,315.0	0.4	0.4	1	1	0
07/15/2020 06:00	0.4	13.9	1,301.2	0.4	0.4	1	1	0
07/15/2020 07:00	0.4	13.9	1,288.0	0.4	0.4	1	1	0
07/15/2020 08:00	0.4	13.9	1,289.7	0.4	0.4	1	1	0
07/15/2020 09:00	0.4	13.9	1,293.4	0.4	0.4	1	1	0
07/15/2020 10:00	0.4	13.9	1,294.1	0.4	0.4	1	1	0
07/15/2020 11:00	0.4	13.9	1,297.3	0.4	0.4	1	1	0
07/15/2020 12:00	0.4	13.9	1,295.2	0.4	0.4	1	1	0
07/15/2020 13:00	0.4	13.9	1,298.7	0.4	0.4	1	1	0
07/15/2020 14:00	0.4	13.9	1,307.2	0.4	0.4	1	1	0
07/15/2020 15:00	0.4	13.9	1,302.6	0.4	0.4	1	1	0
07/15/2020 16:00	0.3	13.9	1,308.4	0.4	0.4	1	1	0
07/15/2020 17:00	0.4	13.9	1,308.3	0.4	0.4	1	1	0
07/15/2020 18:00	0.4	13.9	1,391.6	0.4	0.4	1	1	0
07/15/2020 19:00	0.3	13.9	1,459.0	0.4	0.4	1	1	0
07/15/2020 20:00	0.4	13.9	1,355.3	0.4	0.4	1	1	0
07/15/2020 21:00	0.4	13.9	1,287.3	0.4	0.4	1	1	0
07/15/2020 22:00	0.4	13.9	1,284.0	0.4	0.4	1	1	0
07/15/2020 23:00	0.4	13.9	1,315.6	0.4	0.4	1	1	0
Average/Sum#:	0.4	13.9	1,309.9	0.4	0.4	24 #	24 #	0 #
Minimum:	0.3	13.8	1,284.0	0.4	0.4	1	1	0
Maximum:	0.4	13.9	1,459.0	0.4	0.4	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/16/2020 00:00	0.4	13.9	1,284.2	0.4	0.4	1	1	0
07/16/2020 01:00	0.4	13.9	1,285.8	0.4	0.4	1	1	0
07/16/2020 02:00	0.4	13.9	1,284.0	0.4	0.4	1	1	0
07/16/2020 03:00	0.4	13.9	1,282.1	0.4	0.4	1	1	0
07/16/2020 04:00	0.3	13.9	1,282.7	0.4	0.4	1	1	0
07/16/2020 05:00	0.3	13.9	1,283.3	0.4	0.4	1	1	0
07/16/2020 06:00	0.4	13.9	1,285.5	0.4	0.4	1	1	0
07/16/2020 07:00	0.4	13.9	1,286.5	0.4	0.4	1	1	0
07/16/2020 08:00	0.3	13.9	1,289.6	0.4	0.4	1	1	0
07/16/2020 09:00	0.4	13.9	1,292.8	0.4	0.4	1	1	0
07/16/2020 10:00	0.4	13.9	1,297.8	0.4	0.4	1	1	0
07/16/2020 11:00	0.4	13.9	1,295.1	0.4	0.4	1	1	0
07/16/2020 12:00	0.4	13.9	1,294.3	0.4	0.4	1	1	0
07/16/2020 13:00	0.4	13.9	1,296.7	0.4	0.4	1	1	0
07/16/2020 14:00	0.4	13.9	1,462.0	0.4	0.4	1	1	0
07/16/2020 15:00	0.1	13.8	1,503.0	0.2	0.5	1	1	1
07/16/2020 16:00	-0.2	12.1	2,030.0	0.1	0.6	1	1	1
07/16/2020 17:00	0.1	11.9	2,061.3	0.2	0.6	1	1	1
07/16/2020 18:00	0.1	12.0	2,051.2	0.2	0.6	1	1	1
07/16/2020 19:00	0.1	11.9	2,075.9	0.2	0.6	1	1	1
07/16/2020 20:00	0.1	11.9	2,075.5	0.2	0.6	1	1	1
07/16/2020 21:00	0.1	12.1	2,069.2	0.2	0.6	1	1	1
07/16/2020 22:00	-0.2	12.7	1,952.5	0.1	0.6	1	1	1
07/16/2020 23:00	-0.1	13.1	1,778.6	0.1	0.5	1	1	1
Average/Sum#:	0.2	13.3	1,545.8	0.3	0.5	24 #	24 #	9 #
Minimum:	-0.2	11.9	1,282.1	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,075.9	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/17/2020 00:00	0.4	13.8	1,294.0	0.4	0.4	1	1	0
07/17/2020 01:00	0.4	13.9	1,295.3	0.4	0.4	1	1	0
07/17/2020 02:00	0.4	13.9	1,290.3	0.4	0.4	1	1	0
07/17/2020 03:00	0.4	13.9	1,297.8	0.4	0.4	1	1	0
07/17/2020 04:00	0.4	13.9	1,292.6	0.4	0.4	1	1	0
07/17/2020 05:00	0.4	13.9	1,300.2	0.4	0.4	1	1	0
07/17/2020 06:00	0.4	13.9	1,300.7	0.4	0.4	1	1	0
07/17/2020 07:00	0.4	13.9	1,295.6	0.4	0.4	1	1	0
07/17/2020 08:00	0.4	13.9	1,298.0	0.4	0.4	1	1	0
07/17/2020 09:00	0.4	13.9	1,311.9	0.4	0.4	1	1	0
07/17/2020 10:00	0.4	13.9	1,305.6	0.4	0.4	1	1	0
07/17/2020 11:00	0.4	13.9	1,308.6	0.4	0.4	1	1	0
07/17/2020 12:00	0.4	13.9	1,317.7	0.4	0.4	1	1	0
07/17/2020 13:00	0.4	13.9	1,327.4	0.4	0.4	1	1	0
07/17/2020 14:00	0.4	13.9	1,300.2	0.4	0.4	1	1	0
07/17/2020 15:00	0.4	13.9	1,303.1	0.4	0.4	1	1	0
07/17/2020 16:00	0.1	13.8	1,502.9	0.2	0.5	1	1	1
07/17/2020 17:00	-0.2	12.1	2,019.1	0.1	0.6	1	1	1
07/17/2020 18:00	-0.1	11.9	2,064.0	0.2	0.6	1	1	1
07/17/2020 19:00	-0.1	12.0	2,071.5	0.2	0.6	1	1	1
07/17/2020 20:00	-0.1	12.0	2,077.0	0.2	0.6	1	1	1
07/17/2020 21:00	-0.1	12.1	2,067.4	0.2	0.6	1	1	1
07/17/2020 22:00	-0.2	12.6	1,961.4	0.1	0.6	1	1	1
07/17/2020 23:00	-0.2	13.0	1,848.1	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.4	1,518.8	0.3	0.5	24 #	24 #	8 #
Minimum:	-0.2	11.9	1,290.3	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,077.0	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/18/2020 00:00	0.4	13.7	1,746.9	0.4	0.5	1	1	0
07/18/2020 01:00	0.3	13.8	1,590.9	0.4	0.5	1	1	0
07/18/2020 02:00	0.4	13.9	1,306.2	0.4	0.4	1	1	0
07/18/2020 03:00	0.4	13.9	1,307.2	0.4	0.4	1	1	0
07/18/2020 04:00	0.4	13.9	1,318.6	0.4	0.4	1	1	0
07/18/2020 05:00	0.4	13.9	1,351.5	0.4	0.4	1	1	0
07/18/2020 06:00	0.4	13.9	1,291.8	0.4	0.4	1	1	0
07/18/2020 07:00	0.4	13.9	1,292.0	0.4	0.4	1	1	0
07/18/2020 08:00	0.4	13.9	1,292.2	0.4	0.4	1	1	0
07/18/2020 09:00	0.4	13.9	1,298.2	0.4	0.4	1	1	0
07/18/2020 10:00	0.4	13.9	1,299.4	0.4	0.4	1	1	0
07/18/2020 11:00	0.4	13.9	1,389.3	0.4	0.4	1	1	0
07/18/2020 12:00	0.4	13.9	1,404.9	0.4	0.4	1	1	0
07/18/2020 13:00	0.1	13.8	1,584.1	0.2	0.5	1	1	1
07/18/2020 14:00	-0.4	12.5	1,978.2	-0.1	0.6	1	1	1
07/18/2020 15:00	0.1	13.5	1,508.7	0.2	0.5	1	1	1
07/18/2020 16:00	0.2	13.8	1,593.0	0.4	0.5	1	1	1
07/18/2020 17:00	-0.1	12.2	2,011.9	0.2	0.6	1	1	1
07/18/2020 18:00	0.1	11.8	2,089.1	0.2	0.6	1	1	1
07/18/2020 19:00	0.1	11.8	2,109.3	0.2	0.6	1	1	1
07/18/2020 20:00	0.1	11.9	2,081.8	0.2	0.6	1	1	1
07/18/2020 21:00	-0.1	12.4	1,980.3	0.2	0.6	1	1	1
07/18/2020 22:00	-0.2	12.5	1,966.0	0.1	0.6	1	1	1
07/18/2020 23:00	-0.2	12.8	1,846.1	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.3	1,609.9	0.3	0.5	24 #	24 #	11 #
Minimum:	-0.4	11.8	1,291.8	-0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,109.3	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/19/2020 00:00	0.2	13.6	1,734.9	0.3	0.5	1	1	0
07/19/2020 01:00	0.3	13.8	1,311.7	0.4	0.4	1	1	0
07/19/2020 02:00	0.3	13.9	1,287.7	0.4	0.4	1	1	0
07/19/2020 03:00	0.3	13.9	1,292.9	0.4	0.4	1	1	0
07/19/2020 04:00	0.3	13.9	1,287.0	0.4	0.4	1	1	0
07/19/2020 05:00	0.4	13.9	1,288.6	0.4	0.4	1	1	0
07/19/2020 06:00	0.4	13.9	1,287.1	0.4	0.4	1	1	0
07/19/2020 07:00	0.4	13.9	1,290.5	0.4	0.4	1	1	0
07/19/2020 08:00	0.4	13.9	1,299.2	0.4	0.4	1	1	0
07/19/2020 09:00	0.4	13.9	1,293.6	0.4	0.4	1	1	0
07/19/2020 10:00	0.4	13.9	1,300.8	0.4	0.4	1	1	0
07/19/2020 11:00	0.4	13.9	1,300.0	0.4	0.4	1	1	0
07/19/2020 12:00	0.4	13.9	1,300.4	0.4	0.4	1	1	0
07/19/2020 13:00	0.4	13.9	1,302.9	0.4	0.4	1	1	0
07/19/2020 14:00	0.4	13.9	1,308.9	0.4	0.4	1	1	0
07/19/2020 15:00	0.4	13.9	1,307.1	0.4	0.4	1	1	0
07/19/2020 16:00	0.4	13.8	1,496.4	0.4	0.4	1	1	0
07/19/2020 17:00	-0.1	12.1	2,012.9	0.2	0.6	1	1	1
07/19/2020 18:00	0.1	11.8	2,080.7	0.2	0.6	1	1	1
07/19/2020 19:00	0.1	11.9	2,077.1	0.2	0.6	1	1	1
07/19/2020 20:00	0.1	12.0	2,068.7	0.2	0.6	1	1	1
07/19/2020 21:00	-0.1	12.1	2,054.1	0.2	0.6	1	1	1
07/19/2020 22:00	-0.2	12.6	1,951.2	0.1	0.6	1	1	1
07/19/2020 23:00	-0.1	13.1	1,772.0	0.1	0.5	1	1	1
Average/Sum#:	0.3	13.4	1,529.4	0.3	0.5	24 #	24 #	7 #
Minimum:	-0.2	11.8	1,287.0	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,080.7	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/20/2020 00:00	0.4	13.9	1,290.5	0.4	0.4	1	1	0
07/20/2020 01:00	0.4	13.9	1,282.2	0.4	0.4	1	1	0
07/20/2020 02:00	0.4	13.9	1,280.9	0.4	0.4	1	1	0
07/20/2020 03:00	0.4	13.9	1,280.1	0.4	0.4	1	1	0
07/20/2020 04:00	0.4	13.9	1,278.7	0.4	0.4	1	1	0
07/20/2020 05:00	0.4	13.9	1,294.2	0.4	0.4	1	1	0
07/20/2020 06:00	0.4	13.8	1,655.8	0.4	0.5	1	1	0
07/20/2020 07:00	0.4	13.8	1,628.1	0.4	0.5	1	1	0
07/20/2020 08:00	0.4	13.8	1,671.1	0.4	0.5	1	1	0
07/20/2020 09:00	0.4	13.9	1,381.4	0.4	0.4	1	1	0
07/20/2020 10:00	0.4	13.9	1,529.3	0.4	0.5	1	1	0
07/20/2020 11:00	0.4	13.8	1,539.5	0.4	0.5	1	1	0
07/20/2020 12:00	0.1	13.8	1,517.4	0.2	0.5	1	1	1
07/20/2020 13:00	-0.2	12.3	1,998.7	0.1	0.6	1	1	1
07/20/2020 14:00	-0.2	12.4	1,977.0	0.1	0.6	1	1	1
07/20/2020 15:00	-0.1	12.0	2,036.8	0.2	0.6	1	1	1
07/20/2020 16:00	0.1	12.0	2,041.7	0.2	0.6	1	1	1
07/20/2020 17:00	0.1	12.0	2,044.4	0.2	0.6	1	1	1
07/20/2020 18:00	0.1	11.9	2,070.5	0.2	0.6	1	1	1
07/20/2020 19:00	0.1	11.9	2,072.5	0.2	0.6	1	1	1
07/20/2020 20:00	0.1	12.0	2,066.0	0.2	0.6	1	1	1
07/20/2020 21:00	-0.1	12.1	2,049.1	0.2	0.6	1	1	1
07/20/2020 22:00	-0.1	12.5	1,977.5	0.1	0.6	1	1	1
07/20/2020 23:00	0.1	13.0	1,759.6	0.2	0.5	1	1	1
Average/Sum#:	0.2	13.1	1,696.8	0.3	0.5	24 #	24 #	12 #
Minimum:	-0.2	11.9	1,278.7	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,072.5	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/21/2020 00:00	0.4	13.9	1,283.2	0.4	0.4	1	1	0
07/21/2020 01:00	0.4	13.9	1,282.2	0.4	0.4	1	1	0
07/21/2020 02:00	0.4	13.9	1,281.7	0.4	0.4	1	1	0
07/21/2020 03:00	0.4	13.9	1,280.8	0.4	0.4	1	1	0
07/21/2020 04:00	0.4	13.9	1,280.5	0.4	0.4	1	1	0
07/21/2020 05:00	0.4	13.9	1,292.2	0.4	0.4	1	1	0
07/21/2020 06:00	0.4	13.8	1,647.1	0.4	0.5	1	1	0
07/21/2020 07:00	0.4	13.8	1,522.9	0.4	0.5	1	1	0
07/21/2020 08:00	0.4	13.9	1,520.4	0.4	0.5	1	1	0
07/21/2020 09:00	0.4	13.9	1,368.6	0.4	0.4	1	1	0
07/21/2020 10:00	0.4	13.8	1,505.2	0.4	0.5	1	1	0
07/21/2020 11:00	0.4	13.9	1,367.2	0.4	0.4	1	1	0
07/21/2020 12:00	0.4	13.9	1,381.4	0.4	0.4	1	1	0
07/21/2020 13:00	-0.2	12.9	1,790.1	0.1	0.5	1	1	1
07/21/2020 14:00	-0.1	12.0	2,044.0	0.2	0.6	1	1	1
07/21/2020 15:00	0.1	11.9	2,051.2	0.2	0.6	1	1	1
07/21/2020 16:00	0.1	11.8	2,068.3	0.2	0.6	1	1	1
07/21/2020 17:00	0.1	11.8	2,089.8	0.2	0.6	1	1	1
07/21/2020 18:00	0.1	11.8	2,086.9	0.2	0.6	1	1	1
07/21/2020 19:00	0.1	11.9	2,074.8	0.2	0.6	1	1	1
07/21/2020 20:00	0.1	12.0	2,076.0	0.2	0.6	1	1	1
07/21/2020 21:00	0.1	12.1	2,060.2	0.2	0.6	1	1	1
07/21/2020 22:00	-0.1	12.6	1,968.2	0.1	0.6	1	1	1
07/21/2020 23:00	0.1	13.0	1,829.4	0.2	0.5	1	1	1
Average/Sum#:	0.2	13.1	1,673.0	0.3	0.5	24 #	24 #	11 #
Minimum:	-0.2	11.8	1,280.5	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,089.8	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/22/2020 00:00	0.4	13.8	1,393.5	0.4	0.4	1	1	0
07/22/2020 01:00	0.4	13.9	1,280.2	0.4	0.4	1	1	0
07/22/2020 02:00	0.4	13.9	1,280.8	0.4	0.4	1	1	0
07/22/2020 03:00	0.4	13.9	1,277.9	0.4	0.4	1	1	0
07/22/2020 04:00	0.4	13.9	1,292.5	0.4	0.4	1	1	0
07/22/2020 05:00	0.4	13.8	1,372.8	0.4	0.4	1	1	0
07/22/2020 06:00	0.4	13.8	1,655.6	0.4	0.5	1	1	0
07/22/2020 07:00	0.4	13.9	1,357.5	0.4	0.4	1	1	0
07/22/2020 08:00	0.4	13.9	1,294.0	0.4	0.4	1	1	0
07/22/2020 09:00	0.4	13.9	1,296.2	0.4	0.4	1	1	0
07/22/2020 10:00	0.4	13.9	1,298.0	0.4	0.4	1	1	0
07/22/2020 11:00	0.4	13.9	1,298.3	0.4	0.4	1	1	0
07/22/2020 12:00	0.4	13.9	1,292.9	0.4	0.4	1	1	0
07/22/2020 13:00	0.4	13.9	1,291.8	0.4	0.4	1	1	0
07/22/2020 14:00	0.4	13.9	1,292.6	0.4	0.4	1	1	0
07/22/2020 15:00	0.4	13.9	1,301.0	0.4	0.4	1	1	0
07/22/2020 16:00	0.2	13.8	1,630.9	0.4	0.5	1	1	1
07/22/2020 17:00	-0.2	12.3	1,997.3	0.1	0.6	1	1	1
07/22/2020 18:00	-0.1	12.1	2,043.0	0.2	0.6	1	1	1
07/22/2020 19:00	0.1	12.2	2,040.0	0.2	0.6	1	1	1
07/22/2020 20:00	-0.1	12.3	2,039.7	0.2	0.6	1	1	1
07/22/2020 21:00	0.1	12.3	2,037.5	0.2	0.6	1	1	1
07/22/2020 22:00	-0.1	12.7	1,948.7	0.1	0.6	1	1	1
07/22/2020 23:00	-0.1	13.1	1,770.4	0.1	0.5	1	1	1
Average/Sum#:	0.3	13.5	1,532.6	0.3	0.5	24 #	24 #	8 #
Minimum:	-0.2	12.1	1,277.9	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,043.0	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/23/2020 00:00	0.4	13.9	1,284.3	0.4	0.4	1	1	0
07/23/2020 01:00	0.4	13.9	1,278.5	0.4	0.4	1	1	0
07/23/2020 02:00	0.4	13.9	1,277.1	0.4	0.4	1	1	0
07/23/2020 03:00	0.4	13.9	1,277.6	0.4	0.4	1	1	0
07/23/2020 04:00	0.4	13.9	1,279.5	0.4	0.4	1	1	0
07/23/2020 05:00	0.4	13.9	1,283.9	0.4	0.4	1	1	0
07/23/2020 06:00	0.4	13.9	1,288.3	0.4	0.4	1	1	0
07/23/2020 07:00	0.4	13.9	1,291.3	0.4	0.4	1	1	0
07/23/2020 08:00	0.4	13.9	1,295.3	0.4	0.4	1	1	0
07/23/2020 09:00	0.4	13.9	1,295.3	0.4	0.4	1	1	0
07/23/2020 10:00	0.4	13.9	1,300.3	0.4	0.4	1	1	0
07/23/2020 11:00	0.4	13.9	1,295.2	0.4	0.4	1	1	0
07/23/2020 12:00	0.4	13.9	1,296.2	0.4	0.4	1	1	0
07/23/2020 13:00	0.4	13.9	1,287.5	0.4	0.4	1	1	0
07/23/2020 14:00	0.4	13.9	1,291.4	0.4	0.4	1	1	0
07/23/2020 15:00	0.4	13.9	1,294.7	0.4	0.4	1	1	0
07/23/2020 16:00	0.4	13.9	1,293.3	0.4	0.4	1	1	0
07/23/2020 17:00	0.4	13.9	1,405.7	0.4	0.4	1	1	0
07/23/2020 18:00	0.3	13.8	1,626.5	0.4	0.5	1	1	0
07/23/2020 19:00	0.3	13.8	1,608.9	0.4	0.5	1	1	0
07/23/2020 20:00	0.3	13.8	1,427.6	0.4	0.4	1	1	0
07/23/2020 21:00	0.4	13.9	1,333.8	0.4	0.4	1	1	0
07/23/2020 22:00	0.3	13.9	1,286.5	0.4	0.4	1	1	0
07/23/2020 23:00	0.3	13.9	1,324.1	0.4	0.4	1	1	0
Average/Sum#:	0.4	13.9	1,330.1	0.4	0.4	24 #	24 #	0 #
Minimum:	0.3	13.8	1,277.1	0.4	0.4	1	1	0
Maximum:	0.4	13.9	1,626.5	0.4	0.5	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/24/2020 00:00	0.3	13.9	1,280.6	0.4	0.4	1	1	0
07/24/2020 01:00	0.4	13.9	1,282.8	0.4	0.4	1	1	0
07/24/2020 02:00	0.4	13.9	1,278.9	0.4	0.4	1	1	0
07/24/2020 03:00	0.4	13.9	1,278.1	0.4	0.4	1	1	0
07/24/2020 04:00	0.3	13.9	1,281.6	0.4	0.4	1	1	0
07/24/2020 05:00	0.3	13.9	1,288.0	0.4	0.4	1	1	0
07/24/2020 06:00	0.3	13.9	1,320.4	0.4	0.4	1	1	0
07/24/2020 07:00	0.4	13.9	1,268.1	0.4	0.4	1	1	0
07/24/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.4	13.9	1,284.8	0.4	0.4	8 #	8 #	0 #
Minimum:	0.3	13.9	1,268.1	0.4	0.4	0	0	0
Maximum:	0.4	13.9	1,320.4	0.4	0.4	1	1	0
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 13:00	0.0	17.7	427.2	0.0	0.1	1	0	0
07/25/2020 14:00	0.0	15.7	797.3	0.0	0.2	1	0	0
07/25/2020 15:00	0.4	13.8	1,548.8	0.4	0.5	1	1	0
07/25/2020 16:00	0.2	13.8	1,536.9	0.4	0.5	1	1	1
07/25/2020 17:00	-0.1	12.3	2,011.5	0.2	0.6	1	1	1
07/25/2020 18:00	0.1	11.9	2,073.0	0.2	0.6	1	1	1
07/25/2020 19:00	0.1	11.9	2,077.3	0.2	0.6	1	1	1
07/25/2020 20:00	0.1	12.0	2,077.8	0.2	0.6	1	1	1
07/25/2020 21:00	0.1	12.1	2,061.6	0.2	0.6	1	1	1
07/25/2020 22:00	-0.1	12.4	2,009.6	0.2	0.6	1	1	1
07/25/2020 23:00	0.1	12.3	2,013.6	0.2	0.6	1	1	1
Average/Sum#:	0.1	13.3	1,694.1	0.2	0.5	11 #	9 #	8 #
Minimum:	-0.1	11.9	427.2	0.0	0.1	0	0	0
Maximum:	0.4	17.7	2,077.8	0.4	0.6	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/26/2020 00:00	0.4	13.9	1,442.7	0.4	0.4	1	1	0
07/26/2020 01:00	0.4	13.9	1,598.1	0.4	0.5	1	1	0
07/26/2020 02:00	0.4	13.9	1,538.2	0.4	0.5	1	1	0
07/26/2020 03:00	0.4	13.9	1,497.6	0.4	0.4	1	1	0
07/26/2020 04:00	0.4	13.9	1,529.1	0.4	0.5	1	1	0
07/26/2020 05:00	0.4	13.9	1,408.7	0.4	0.4	1	1	0
07/26/2020 06:00	0.4	13.9	1,282.0	0.4	0.4	1	1	0
07/26/2020 07:00	0.4	13.9	1,283.8	0.4	0.4	1	1	0
07/26/2020 08:00	0.4	13.9	1,285.7	0.4	0.4	1	1	0
07/26/2020 09:00	0.4	13.9	1,289.3	0.4	0.4	1	1	0
07/26/2020 10:00	0.4	13.9	1,377.9	0.4	0.4	1	1	0
07/26/2020 11:00	0.4	13.9	1,533.2	0.4	0.5	1	1	0
07/26/2020 12:00	0.4	13.9	1,543.7	0.4	0.5	1	1	0
07/26/2020 13:00	0.2	13.7	1,686.1	0.4	0.5	1	1	1
07/26/2020 14:00	-0.1	12.3	2,005.1	0.2	0.6	1	1	1
07/26/2020 15:00	0.1	13.4	1,623.8	0.2	0.5	1	1	1
07/26/2020 16:00	0.1	13.0	1,776.3	0.2	0.5	1	1	1
07/26/2020 17:00	0.1	11.7	2,098.0	0.2	0.6	1	1	1
07/26/2020 18:00	0.2	11.7	2,101.2	0.4	0.6	1	1	1
07/26/2020 19:00	0.2	11.7	2,102.1	0.4	0.6	1	1	1
07/26/2020 20:00	0.1	11.9	2,077.3	0.2	0.6	1	1	1
07/26/2020 21:00	0.1	12.0	2,069.2	0.2	0.6	1	1	1
07/26/2020 22:00	-0.1	12.5	1,960.9	0.1	0.6	1	1	1
07/26/2020 23:00	0.1	12.9	1,774.5	0.2	0.5	1	1	1
Average/Sum#:	0.3	13.2	1,661.9	0.3	0.5	24 #	24 #	11 #
Minimum:	-0.1	11.7	1,282.0	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,102.1	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/27/2020 00:00	0.4	13.9	1,287.3	0.4	0.4	1	1	0
07/27/2020 01:00	0.4	13.9	1,283.4	0.4	0.4	1	1	0
07/27/2020 02:00	0.4	13.9	1,283.0	0.4	0.4	1	1	0
07/27/2020 03:00	0.4	13.9	1,285.6	0.4	0.4	1	1	0
07/27/2020 04:00	0.4	13.9	1,293.1	0.4	0.4	1	1	0
07/27/2020 05:00	0.4	13.8	1,640.1	0.4	0.5	1	1	0
07/27/2020 06:00	0.4	13.9	1,672.1	0.4	0.5	1	1	0
07/27/2020 07:00	0.4	13.8	1,676.8	0.4	0.5	1	1	0
07/27/2020 08:00	0.4	13.9	1,640.1	0.4	0.5	1	1	0
07/27/2020 09:00	0.4	13.9	1,343.5	0.4	0.4	1	1	0
07/27/2020 10:00	0.4	13.9	1,569.2	0.4	0.5	1	1	0
07/27/2020 11:00	0.2	13.8	1,535.7	0.4	0.5	1	1	1
07/27/2020 12:00	-0.2	12.2	2,027.6	0.1	0.6	1	1	1
07/27/2020 13:00	0.1	11.8	2,085.5	0.2	0.6	1	1	1
07/27/2020 14:00	0.1	11.9	2,060.3	0.2	0.6	1	1	1
07/27/2020 15:00	0.1	11.7	2,086.6	0.2	0.6	1	1	1
07/27/2020 16:00	0.1	11.6	2,091.1	0.2	0.6	1	1	1
07/27/2020 17:00	0.1	11.6	2,093.1	0.2	0.6	1	1	1
07/27/2020 18:00	0.2	11.7	2,078.0	0.4	0.6	1	1	1
07/27/2020 19:00	0.1	11.8	2,071.9	0.2	0.6	1	1	1
07/27/2020 20:00	0.2	11.7	2,105.5	0.4	0.6	1	1	1
07/27/2020 21:00	0.2	11.9	2,079.3	0.4	0.6	1	1	1
07/27/2020 22:00	0.2	11.9	2,080.1	0.4	0.6	1	1	1
07/27/2020 23:00	0.1	12.5	1,937.3	0.2	0.6	1	1	1
Average/Sum#:	0.2	12.9	1,762.8	0.3	0.5	24 #	24 #	13 #
Minimum:	-0.2	11.6	1,283.0	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,105.5	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/28/2020 00:00	0.4	13.8	1,538.6	0.4	0.5	1	1	0
07/28/2020 01:00	0.4	13.8	1,499.8	0.4	0.4	1	1	0
07/28/2020 02:00	0.4	13.9	1,422.9	0.4	0.4	1	1	0
07/28/2020 03:00	0.4	13.9	1,497.9	0.4	0.4	1	1	0
07/28/2020 04:00	0.4	13.8	1,536.7	0.4	0.5	1	1	0
07/28/2020 05:00	0.4	13.8	1,594.4	0.4	0.5	1	1	0
07/28/2020 06:00	0.4	13.8	1,688.1	0.4	0.5	1	1	0
07/28/2020 07:00	0.4	13.8	1,668.9	0.4	0.5	1	1	0
07/28/2020 08:00	0.4	13.9	1,518.4	0.4	0.5	1	1	0
07/28/2020 09:00	0.4	13.9	1,313.4	0.4	0.4	1	1	0
07/28/2020 10:00	0.4	13.9	1,518.3	0.4	0.5	1	1	0
07/28/2020 11:00	0.4	13.8	1,493.3	0.4	0.4	1	1	1
07/28/2020 12:00	-0.1	12.2	2,029.0	0.2	0.6	1	1	1
07/28/2020 13:00	0.1	12.0	2,071.3	0.2	0.6	1	1	1
07/28/2020 14:00	0.1	11.9	2,077.8	0.2	0.6	1	1	1
07/28/2020 15:00	0.2	11.7	2,103.0	0.4	0.6	1	1	1
07/28/2020 16:00	0.2	11.7	2,105.9	0.4	0.6	1	1	1
07/28/2020 17:00	0.2	11.7	2,096.4	0.4	0.6	1	1	1
07/28/2020 18:00	0.2	11.7	2,098.7	0.4	0.6	1	1	1
07/28/2020 19:00	0.2	11.9	2,071.0	0.4	0.6	1	1	1
07/28/2020 20:00	0.1	12.0	2,090.5	0.2	0.6	1	1	1
07/28/2020 21:00	0.1	12.0	2,096.2	0.2	0.6	1	1	1
07/28/2020 22:00	0.1	12.1	2,075.7	0.2	0.6	1	1	1
07/28/2020 23:00	-0.1	12.1	2,058.1	0.2	0.6	1	1	1
Average/Sum#:	0.3	12.9	1,802.7	0.3	0.5	24 #	24 #	13 #
Minimum:	-0.1	11.7	1,313.4	0.2	0.4	1	1	0
Maximum:	0.4	13.9	2,105.9	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/29/2020 00:00	-0.2	12.7	1,953.1	0.1	0.6	1	1	1
07/29/2020 01:00	-0.2	12.8	1,935.1	0.1	0.6	1	1	1
07/29/2020 02:00	-0.2	12.8	1,936.4	0.1	0.6	1	1	1
07/29/2020 03:00	-0.2	12.8	1,948.8	0.1	0.6	1	1	1
07/29/2020 04:00	-0.1	12.3	2,052.0	0.2	0.6	1	1	1
07/29/2020 05:00	-0.1	12.3	2,067.7	0.2	0.6	1	1	1
07/29/2020 06:00	0.1	12.3	2,052.8	0.2	0.6	1	1	1
07/29/2020 07:00	-0.1	12.8	1,950.5	0.1	0.6	1	1	1
07/29/2020 08:00	-0.1	12.7	1,943.7	0.1	0.6	1	1	1
07/29/2020 09:00	-0.1	12.7	1,958.0	0.1	0.6	1	1	1
07/29/2020 10:00	0.1	12.2	2,064.2	0.2	0.6	1	1	1
07/29/2020 11:00	0.1	12.1	2,065.3	0.2	0.6	1	1	1
07/29/2020 12:00	0.1	12.0	2,076.1	0.2	0.6	1	1	1
07/29/2020 13:00	0.1	12.0	2,067.9	0.2	0.6	1	1	1
07/29/2020 14:00	0.1	11.8	2,097.9	0.2	0.6	1	1	1
07/29/2020 15:00	0.2	11.7	2,104.7	0.4	0.6	1	1	1
07/29/2020 16:00	0.2	11.8	2,109.2	0.4	0.6	1	1	1
07/29/2020 17:00	0.2	11.8	2,104.8	0.4	0.6	1	1	1
07/29/2020 18:00	0.2	11.8	2,101.5	0.4	0.6	1	1	1
07/29/2020 19:00	0.2	11.8	2,116.9	0.4	0.6	1	1	1
07/29/2020 20:00	0.2	11.9	2,110.0	0.4	0.6	1	1	1
07/29/2020 21:00	0.1	12.1	2,074.6	0.2	0.6	1	1	1
07/29/2020 22:00	0.1	12.0	2,094.1	0.2	0.6	1	1	1
07/29/2020 23:00	0.1	12.1	2,078.4	0.2	0.6	1	1	1
Average/Sum#:	0.0	12.2	2,044.3	0.2	0.6	24 #	24 #	24 #
Minimum:	-0.2	11.7	1,935.1	0.1	0.6	1	1	1
Maximum:	0.2	12.8	2,116.9	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/30/2020 00:00	0.1	12.2	2,058.9	0.2	0.6	1	1	1
07/30/2020 01:00	-0.2	12.7	1,949.2	0.1	0.6	1	1	1
07/30/2020 02:00	-0.2	12.8	1,937.6	0.1	0.6	1	1	1
07/30/2020 03:00	-0.2	12.9	1,935.5	0.1	0.6	1	1	1
07/30/2020 04:00	-0.2	12.9	1,947.5	0.1	0.6	1	1	1
07/30/2020 05:00	-0.1	12.3	2,064.6	0.2	0.6	1	1	1
07/30/2020 06:00	-0.1	12.4	2,050.3	0.2	0.6	1	1	1
07/30/2020 07:00	-0.1	12.8	1,947.2	0.1	0.6	1	1	1
07/30/2020 08:00	-0.1	12.8	1,941.0	0.1	0.6	1	1	1
07/30/2020 09:00	-0.1	12.7	1,951.7	0.1	0.6	1	1	1
07/30/2020 10:00	-0.1	12.2	2,057.9	0.2	0.6	1	1	1
07/30/2020 11:00	0.1	12.1	2,079.2	0.2	0.6	1	1	1
07/30/2020 12:00	0.1	12.1	2,068.6	0.2	0.6	1	1	1
07/30/2020 13:00	0.1	12.0	2,071.7	0.2	0.6	1	1	1
07/30/2020 14:00	0.1	11.9	2,077.8	0.2	0.6	1	1	1
07/30/2020 15:00	0.2	11.8	2,098.6	0.4	0.6	1	1	1
07/30/2020 16:00	0.2	11.7	2,105.1	0.4	0.6	1	1	1
07/30/2020 17:00	0.2	11.7	2,106.1	0.4	0.6	1	1	1
07/30/2020 18:00	0.2	11.7	2,105.0	0.4	0.6	1	1	1
07/30/2020 19:00	0.1	12.1	2,029.4	0.2	0.6	1	1	1
07/30/2020 20:00	0.1	12.1	2,046.5	0.2	0.6	1	1	1
07/30/2020 21:00	0.1	12.2	2,037.9	0.2	0.6	1	1	1
07/30/2020 22:00	0.1	12.1	2,077.1	0.2	0.6	1	1	1
07/30/2020 23:00	0.1	12.3	2,027.2	0.2	0.6	1	1	1
Average/Sum#:	0.0	12.3	2,032.2	0.2	0.6	24 #	24 #	24 #
Minimum:	-0.2	11.7	1,935.5	0.1	0.6	1	1	1
Maximum:	0.2	12.9	2,106.1	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/31/2020 00:00	-0.1	12.7	1,955.0	0.1	0.6	1	1	1
07/31/2020 01:00	-0.2	12.8	1,931.2	0.1	0.6	1	1	1
07/31/2020 02:00	-0.2	12.9	1,931.0	0.1	0.6	1	1	1
07/31/2020 03:00	-0.2	12.9	1,929.8	0.1	0.6	1	1	1
07/31/2020 04:00	-0.2	12.9	1,933.6	0.1	0.6	1	1	1
07/31/2020 05:00	-0.2	12.5	2,031.2	0.1	0.6	1	1	1
07/31/2020 06:00	-0.1	12.4	2,037.4	0.2	0.6	1	1	1
07/31/2020 07:00	-0.1	12.7	1,955.1	0.1	0.6	1	1	1
07/31/2020 08:00	-0.2	12.8	1,931.4	0.1	0.6	1	1	1
07/31/2020 09:00	-0.1	12.5	1,988.5	0.1	0.6	1	1	1
07/31/2020 10:00	0.1	12.2	2,049.5	0.2	0.6	1	1	1
07/31/2020 11:00	0.1	12.1	2,062.5	0.2	0.6	1	1	1
07/31/2020 12:00	0.1	12.0	2,063.9	0.2	0.6	1	1	1
07/31/2020 13:00	0.1	12.0	2,071.5	0.2	0.6	1	1	1
07/31/2020 14:00	0.1	11.9	2,077.1	0.2	0.6	1	1	1
07/31/2020 15:00	0.1	11.9	2,086.0	0.2	0.6	1	1	1
07/31/2020 16:00	0.1	11.8	2,086.3	0.2	0.6	1	1	1
07/31/2020 17:00	0.1	11.9	2,075.8	0.2	0.6	1	1	1
07/31/2020 18:00	0.2	11.7	2,102.4	0.4	0.6	1	1	1
07/31/2020 19:00	0.1	12.0	2,068.0	0.2	0.6	1	1	1
07/31/2020 20:00	0.1	12.0	2,074.9	0.2	0.6	1	1	1
07/31/2020 21:00	0.1	12.1	2,058.3	0.2	0.6	1	1	1
07/31/2020 22:00	-0.1	12.2	2,051.8	0.2	0.6	1	1	1
07/31/2020 23:00	-0.1	12.3	2,043.5	0.2	0.6	1	1	1
Average/Sum#:	0.0	12.3	2,024.8	0.2	0.6	24 #	24 #	24 #
Minimum:	-0.2	11.7	1,929.8	0.1	0.6	1	1	1
Maximum:	0.2	12.9	2,102.4	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/01/2020 00:00	-0.1	12.3	2,032.5	0.2	0.6	1	1	1
08/01/2020 01:00	-0.1	12.8	1,938.5	0.1	0.6	1	1	1
08/01/2020 02:00	-0.2	12.9	1,901.9	0.1	0.6	1	1	1
08/01/2020 03:00	0.4	13.9	1,431.2	0.4	0.4	1	1	0
08/01/2020 04:00	0.4	13.8	1,519.6	0.4	0.5	1	1	0
08/01/2020 05:00	0.4	13.8	1,535.3	0.4	0.5	1	1	0
08/01/2020 06:00	0.4	13.9	1,297.8	0.4	0.4	1	1	0
08/01/2020 07:00	0.4	13.9	1,286.6	0.4	0.4	1	1	0
08/01/2020 08:00	0.4	13.9	1,289.2	0.4	0.4	1	1	0
08/01/2020 09:00	0.4	13.9	1,295.2	0.4	0.4	1	1	0
08/01/2020 10:00	0.4	13.9	1,431.1	0.4	0.4	1	1	0
08/01/2020 11:00	0.2	13.8	1,505.5	0.4	0.5	1	1	1
08/01/2020 12:00	-0.2	12.4	2,017.4	0.1	0.6	1	1	1
08/01/2020 13:00	-0.1	12.1	2,063.3	0.2	0.6	1	1	1
08/01/2020 14:00	-0.1	12.0	2,069.7	0.2	0.6	1	1	1
08/01/2020 15:00	0.1	12.0	2,078.0	0.2	0.6	1	1	1
08/01/2020 16:00	0.1	11.9	2,094.7	0.2	0.6	1	1	1
08/01/2020 17:00	0.1	11.9	2,102.2	0.2	0.6	1	1	1
08/01/2020 18:00	0.1	11.9	2,105.6	0.2	0.6	1	1	1
08/01/2020 19:00	0.1	11.9	2,108.5	0.2	0.6	1	1	1
08/01/2020 20:00	0.1	11.9	2,110.8	0.2	0.6	1	1	1
08/01/2020 21:00	-0.1	12.1	2,068.9	0.2	0.6	1	1	1
08/01/2020 22:00	0.1	12.1	2,061.4	0.2	0.6	1	1	1
08/01/2020 23:00	-0.2	12.7	1,921.6	0.1	0.6	1	1	1
Average/Sum#:	0.1	12.8	1,802.8	0.3	0.5	24 #	24 #	16 #
Minimum:	-0.2	11.9	1,286.6	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,110.8	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/02/2020 00:00	0.4	13.8	1,423.9	0.4	0.4	1	1	0
08/02/2020 01:00	0.4	13.9	1,282.9	0.4	0.4	1	1	0
08/02/2020 02:00	0.4	13.9	1,285.9	0.4	0.4	1	1	0
08/02/2020 03:00	0.4	13.9	1,288.9	0.4	0.4	1	1	0
08/02/2020 04:00	0.4	13.9	1,492.7	0.4	0.4	1	1	0
08/02/2020 05:00	0.4	13.9	1,379.2	0.4	0.4	1	1	0
08/02/2020 06:00	0.4	13.9	1,293.1	0.4	0.4	1	1	0
08/02/2020 07:00	0.4	13.9	1,291.2	0.4	0.4	1	1	0
08/02/2020 08:00	0.4	13.9	1,292.8	0.4	0.4	1	1	0
08/02/2020 09:00	0.4	13.9	1,297.0	0.4	0.4	1	1	0
08/02/2020 10:00	0.4	13.9	1,301.8	0.4	0.4	1	1	0
08/02/2020 11:00	0.4	13.9	1,303.8	0.4	0.4	1	1	0
08/02/2020 12:00	0.4	13.9	1,300.9	0.4	0.4	1	1	0
08/02/2020 13:00	0.4	13.9	1,313.3	0.4	0.4	1	1	0
08/02/2020 14:00	0.4	13.9	1,364.7	0.4	0.4	1	1	0
08/02/2020 15:00	0.4	13.8	1,508.1	0.4	0.5	1	1	0
08/02/2020 16:00	-0.1	12.5	1,927.7	0.1	0.6	1	1	1
08/02/2020 17:00	-0.1	12.1	2,051.9	0.2	0.6	1	1	1
08/02/2020 18:00	-0.1	12.1	2,052.8	0.2	0.6	1	1	1
08/02/2020 19:00	0.1	11.9	2,081.6	0.2	0.6	1	1	1
08/02/2020 20:00	0.1	12.0	2,058.6	0.2	0.6	1	1	1
08/02/2020 21:00	0.1	12.0	2,073.1	0.2	0.6	1	1	1
08/02/2020 22:00	-0.1	12.1	2,056.7	0.2	0.6	1	1	1
08/02/2020 23:00	-0.1	12.6	1,925.6	0.1	0.6	1	1	1
Average/Sum#:	0.3	13.3	1,568.7	0.3	0.5	24 #	24 #	8 #
Minimum:	-0.1	11.9	1,282.9	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,081.6	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/03/2020 00:00	0.4	13.8	1,431.1	0.4	0.4	1	1	0
08/03/2020 01:00	0.4	13.9	1,318.3	0.4	0.4	1	1	0
08/03/2020 02:00	0.4	13.9	1,290.1	0.4	0.4	1	1	0
08/03/2020 03:00	0.4	13.9	1,290.4	0.4	0.4	1	1	0
08/03/2020 04:00	0.4	13.9	1,505.7	0.4	0.5	1	1	0
08/03/2020 05:00	0.4	13.9	1,484.8	0.4	0.4	1	1	0
08/03/2020 06:00	0.4	13.8	1,575.3	0.4	0.5	1	1	0
08/03/2020 07:00	0.4	13.9	1,535.1	0.4	0.5	1	1	0
08/03/2020 08:00	0.4	13.9	1,480.0	0.4	0.4	1	1	0
08/03/2020 09:00	0.4	13.9	1,373.1	0.4	0.4	1	1	0
08/03/2020 10:00	0.4	14.0	1,299.1	0.4	0.4	1	1	0
08/03/2020 11:00	0.4	14.0	1,361.6	0.4	0.4	1	1	0
08/03/2020 12:00	0.2	13.9	1,497.7	0.2	0.4	1	1	1
08/03/2020 13:00	-0.2	12.3	2,021.3	0.1	0.6	1	1	1
08/03/2020 14:00	0.1	12.1	2,054.2	0.2	0.6	1	1	1
08/03/2020 15:00	0.1	12.1	2,052.0	0.2	0.6	1	1	1
08/03/2020 16:00	0.1	12.0	2,059.1	0.2	0.6	1	1	1
08/03/2020 17:00	0.2	12.0	2,062.2	0.4	0.6	1	1	1
08/03/2020 18:00	0.1	12.0	2,057.4	0.2	0.6	1	1	1
08/03/2020 19:00	0.1	12.0	2,076.1	0.2	0.6	1	1	1
08/03/2020 20:00	0.1	12.0	2,062.8	0.2	0.6	1	1	1
08/03/2020 21:00	0.1	12.0	2,066.2	0.2	0.6	1	1	1
08/03/2020 22:00	0.1	12.1	2,059.1	0.2	0.6	1	1	1
08/03/2020 23:00	-0.1	12.9	1,782.2	0.1	0.5	1	1	1
Average/Sum#:	0.2	13.1	1,699.8	0.3	0.5	24 #	24 #	12 #
Minimum:	-0.2	12.0	1,290.1	0.1	0.4	1	1	0
Maximum:	0.4	14.0	2,076.1	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/04/2020 00:00	0.4	13.9	1,285.7	0.4	0.4	1	1	0
08/04/2020 01:00	0.4	13.9	1,282.8	0.4	0.4	1	1	0
08/04/2020 02:00	0.4	13.9	1,291.9	0.4	0.4	1	1	0
08/04/2020 03:00	0.4	13.9	1,285.9	0.4	0.4	1	1	0
08/04/2020 04:00	0.4	13.9	1,288.3	0.4	0.4	1	1	0
08/04/2020 05:00	0.4	13.9	1,402.3	0.4	0.4	1	1	0
08/04/2020 06:00	0.4	13.9	1,299.5	0.4	0.4	1	1	0
08/04/2020 07:00	0.4	13.9	1,287.3	0.4	0.4	1	1	0
08/04/2020 08:00	0.4	13.9	1,288.7	0.4	0.4	1	1	0
08/04/2020 09:00	0.4	13.9	1,291.8	0.4	0.4	1	1	0
08/04/2020 10:00	0.4	13.9	1,298.3	0.4	0.4	1	1	0
08/04/2020 11:00	0.4	13.9	1,299.6	0.4	0.4	1	1	0
08/04/2020 12:00	0.4	13.9	1,435.8	0.4	0.4	1	1	0
08/04/2020 13:00	0.4	13.8	1,472.1	0.4	0.4	1	1	0
08/04/2020 14:00	0.4	13.9	1,319.7	0.4	0.4	1	1	0
08/04/2020 15:00	0.4	13.8	1,528.4	0.4	0.5	1	1	0
08/04/2020 16:00	0.2	13.8	1,503.4	0.4	0.5	1	1	1
08/04/2020 17:00	-0.2	12.1	2,025.5	0.1	0.6	1	1	1
08/04/2020 18:00	0.1	11.9	2,070.5	0.2	0.6	1	1	1
08/04/2020 19:00	0.1	11.9	2,075.1	0.2	0.6	1	1	1
08/04/2020 20:00	0.1	12.0	2,062.1	0.2	0.6	1	1	1
08/04/2020 21:00	0.1	12.1	2,055.7	0.2	0.6	1	1	1
08/04/2020 22:00	-0.1	12.6	1,952.7	0.1	0.6	1	1	1
08/04/2020 23:00	0.1	13.1	1,773.9	0.2	0.5	1	1	1
Average/Sum#:	0.3	13.4	1,536.5	0.3	0.5	24 #	24 #	8 #
Minimum:	-0.2	11.9	1,282.8	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,075.1	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/05/2020 00:00	0.4	13.9	1,284.6	0.4	0.4	1	1	0
08/05/2020 01:00	0.4	13.9	1,283.4	0.4	0.4	1	1	0
08/05/2020 02:00	0.4	13.9	1,277.6	0.4	0.4	1	1	0
08/05/2020 03:00	0.4	13.9	1,277.3	0.4	0.4	1	1	0
08/05/2020 04:00	0.4	13.9	1,280.0	0.4	0.4	1	1	0
08/05/2020 05:00	0.4	13.9	1,313.3	0.4	0.4	1	1	0
08/05/2020 06:00	0.4	13.9	1,277.2	0.4	0.4	1	1	0
08/05/2020 07:00	0.4	13.9	1,277.6	0.4	0.4	1	1	0
08/05/2020 08:00	0.4	13.9	1,281.6	0.4	0.4	1	1	0
08/05/2020 09:00	0.4	13.9	1,285.0	0.4	0.4	1	1	0
08/05/2020 10:00	0.4	13.9	1,288.8	0.4	0.4	1	1	0
08/05/2020 11:00	0.4	13.9	1,291.1	0.4	0.4	1	1	0
08/05/2020 12:00	0.4	13.9	1,292.1	0.4	0.4	1	1	0
08/05/2020 13:00	0.4	13.9	1,292.8	0.4	0.4	1	1	0
08/05/2020 14:00	0.4	13.9	1,291.1	0.4	0.4	1	1	0
08/05/2020 15:00	0.4	13.9	1,290.2	0.4	0.4	1	1	0
08/05/2020 16:00	0.4	13.9	1,299.2	0.4	0.4	1	1	0
08/05/2020 17:00	-0.1	13.2	1,748.8	0.1	0.5	1	1	1
08/05/2020 18:00	-0.1	12.0	2,059.3	0.2	0.6	1	1	1
08/05/2020 19:00	0.1	12.3	1,993.6	0.2	0.6	1	1	1
08/05/2020 20:00	0.4	13.8	1,573.0	0.4	0.5	1	1	0
08/05/2020 21:00	0.4	13.9	1,399.3	0.4	0.4	1	1	0
08/05/2020 22:00	0.4	13.9	1,378.3	0.4	0.4	1	1	0
08/05/2020 23:00	0.4	13.9	1,278.4	0.4	0.4	1	1	0
Average/Sum#:	0.3	13.7	1,388.1	0.4	0.4	24 #	24 #	3 #
Minimum:	-0.1	12.0	1,277.2	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,059.3	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/06/2020 00:00	0.4	13.9	1,277.6	0.4	0.4	1	1	0
08/06/2020 01:00	0.4	13.9	1,276.8	0.4	0.4	1	1	0
08/06/2020 02:00	0.4	13.9	1,277.4	0.4	0.4	1	1	0
08/06/2020 03:00	0.4	13.9	1,281.5	0.4	0.4	1	1	0
08/06/2020 04:00	0.4	13.9	1,298.5	0.4	0.4	1	1	0
08/06/2020 05:00	0.4	13.9	1,322.0	0.4	0.4	1	1	0
08/06/2020 06:00	0.4	13.9	1,286.7	0.4	0.4	1	1	0
08/06/2020 07:00	0.4	13.9	1,292.2	0.4	0.4	1	1	0
08/06/2020 08:00	0.4	13.9	1,293.7	0.4	0.4	1	1	0
08/06/2020 09:00	0.4	13.9	1,294.5	0.4	0.4	1	1	0
08/06/2020 10:00	0.4	13.9	1,294.2	0.4	0.4	1	1	0
08/06/2020 11:00	0.4	13.9	1,294.3	0.4	0.4	1	1	0
08/06/2020 12:00	0.4	13.9	1,294.7	0.4	0.4	1	1	0
08/06/2020 13:00	0.4	13.9	1,290.4	0.4	0.4	1	1	0
08/06/2020 14:00	0.4	13.9	1,290.4	0.4	0.4	1	1	0
08/06/2020 15:00	0.4	13.9	1,292.0	0.4	0.4	1	1	0
08/06/2020 16:00	0.4	13.9	1,289.2	0.4	0.4	1	1	0
08/06/2020 17:00	0.4	13.9	1,398.1	0.4	0.4	1	1	0
08/06/2020 18:00	0.4	13.9	1,398.6	0.4	0.4	1	1	0
08/06/2020 19:00	0.4	13.9	1,306.9	0.4	0.4	1	1	0
08/06/2020 20:00	0.4	13.9	1,282.9	0.4	0.4	1	1	0
08/06/2020 21:00	0.4	13.9	1,279.2	0.4	0.4	1	1	0
08/06/2020 22:00	0.4	13.9	1,278.1	0.4	0.4	1	1	0
08/06/2020 23:00	0.4	13.9	1,280.0	0.4	0.4	1	1	0
Average/Sum#:	0.4	13.9	1,298.7	0.4	0.4	24 #	24 #	0 #
Minimum:	0.4	13.9	1,276.8	0.4	0.4	1	1	0
Maximum:	0.4	13.9	1,398.6	0.4	0.4	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/07/2020 00:00	0.4	13.9	1,279.9	0.4	0.4	1	1	0
08/07/2020 01:00	0.4	13.9	1,278.6	0.4	0.4	1	1	0
08/07/2020 02:00	0.4	13.9	1,278.9	0.4	0.4	1	1	0
08/07/2020 03:00	0.4	13.9	1,279.4	0.4	0.4	1	1	0
08/07/2020 04:00	0.4	13.9	1,324.1	0.4	0.4	1	1	0
08/07/2020 05:00	0.4	13.9	1,314.5	0.4	0.4	1	1	0
08/07/2020 06:00	0.4	13.9	1,280.2	0.4	0.4	1	1	0
08/07/2020 07:00	0.4	13.9	1,284.8	0.4	0.4	1	1	0
08/07/2020 08:00	0.4	13.9	1,291.6	0.4	0.4	1	1	0
08/07/2020 09:00	0.4	13.9	1,294.4	0.4	0.4	1	1	0
08/07/2020 10:00	0.4	13.9	1,293.3	0.4	0.4	1	1	0
08/07/2020 11:00	0.4	14.0	1,293.3	0.4	0.4	1	1	0
08/07/2020 12:00	0.4	14.0	1,289.1	0.4	0.4	1	1	0
08/07/2020 13:00	0.4	13.9	1,344.8	0.4	0.4	1	1	0
08/07/2020 14:00	0.4	14.0	1,355.9	0.4	0.4	1	1	0
08/07/2020 15:00	0.4	14.0	1,294.0	0.4	0.4	1	1	0
08/07/2020 16:00	0.4	13.9	1,399.7	0.4	0.4	1	1	0
08/07/2020 17:00	0.4	13.9	1,462.5	0.4	0.4	1	1	0
08/07/2020 18:00	0.4	13.8	1,667.4	0.4	0.5	1	1	0
08/07/2020 19:00	0.4	13.8	1,637.6	0.4	0.5	1	1	0
08/07/2020 20:00	0.4	13.8	1,479.5	0.4	0.4	1	1	0
08/07/2020 21:00	0.4	13.9	1,334.9	0.4	0.4	1	1	0
08/07/2020 22:00	0.4	13.9	1,387.2	0.4	0.4	1	1	0
08/07/2020 23:00	0.4	13.9	1,441.3	0.4	0.4	1	1	0
Average/Sum#:	0.4	13.9	1,357.8	0.4	0.4	24 #	24 #	0 #
Minimum:	0.4	13.8	1,278.6	0.4	0.4	1	1	0
Maximum:	0.4	14.0	1,667.4	0.4	0.5	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/08/2020 00:00	0.4	13.9	1,346.0	0.4	0.4	1	1	0
08/08/2020 01:00	0.4	13.9	1,280.5	0.4	0.4	1	1	0
08/08/2020 02:00	0.4	13.9	1,278.5	0.4	0.4	1	1	0
08/08/2020 03:00	0.4	13.9	1,281.5	0.4	0.4	1	1	0
08/08/2020 04:00	0.4	13.9	1,284.5	0.4	0.4	1	1	0
08/08/2020 05:00	0.4	13.9	1,280.0	0.4	0.4	1	1	0
08/08/2020 06:00	0.4	13.9	1,281.0	0.4	0.4	1	1	0
08/08/2020 07:00	0.4	13.9	1,289.1	0.4	0.4	1	1	0
08/08/2020 08:00	0.4	13.9	1,288.1	0.4	0.4	1	1	0
08/08/2020 09:00	0.4	13.9	1,290.9	0.4	0.4	1	1	0
08/08/2020 10:00	0.4	13.9	1,293.6	0.4	0.4	1	1	0
08/08/2020 11:00	0.4	13.9	1,291.2	0.4	0.4	1	1	0
08/08/2020 12:00	0.4	13.9	1,290.6	0.4	0.4	1	1	0
08/08/2020 13:00	0.4	13.9	1,411.6	0.4	0.4	1	1	0
08/08/2020 14:00	0.4	13.9	1,324.5	0.4	0.4	1	1	0
08/08/2020 15:00	0.4	13.9	1,370.4	0.4	0.4	1	1	0
08/08/2020 16:00	0.2	13.9	1,443.7	0.2	0.4	1	1	1
08/08/2020 17:00	-0.2	12.2	2,027.0	0.1	0.6	1	1	1
08/08/2020 18:00	0.1	11.8	2,092.8	0.2	0.6	1	1	1
08/08/2020 19:00	0.1	11.8	2,097.0	0.2	0.6	1	1	1
08/08/2020 20:00	0.1	12.0	2,066.4	0.2	0.6	1	1	1
08/08/2020 21:00	-0.1	12.1	2,055.3	0.2	0.6	1	1	1
08/08/2020 22:00	-0.1	12.5	1,975.4	0.1	0.6	1	1	1
08/08/2020 23:00	-0.2	12.7	1,914.0	0.1	0.6	1	1	1
Average/Sum#:	0.3	13.4	1,523.1	0.3	0.5	24 #	24 #	8 #
Minimum:	-0.2	11.8	1,278.5	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,097.0	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/09/2020 00:00	0.3	13.8	1,538.1	0.4	0.5	1	1	0
08/09/2020 01:00	0.4	13.9	1,304.6	0.4	0.4	1	1	0
08/09/2020 02:00	0.4	13.9	1,284.8	0.4	0.4	1	1	0
08/09/2020 03:00	0.4	13.9	1,285.5	0.4	0.4	1	1	0
08/09/2020 04:00	0.4	13.9	1,283.7	0.4	0.4	1	1	0
08/09/2020 05:00	0.4	13.9	1,284.9	0.4	0.4	1	1	0
08/09/2020 06:00	0.4	13.9	1,289.2	0.4	0.4	1	1	0
08/09/2020 07:00	0.4	13.9	1,291.7	0.4	0.4	1	1	0
08/09/2020 08:00	0.4	13.9	1,292.5	0.4	0.4	1	1	0
08/09/2020 09:00	0.4	13.9	1,287.1	0.4	0.4	1	1	0
08/09/2020 10:00	0.4	13.9	1,292.4	0.4	0.4	1	1	0
08/09/2020 11:00	0.4	13.9	1,294.1	0.4	0.4	1	1	0
08/09/2020 12:00	0.4	13.9	1,436.4	0.4	0.4	1	1	0
08/09/2020 13:00	0.4	13.8	1,507.2	0.4	0.5	1	1	0
08/09/2020 14:00	0.4	13.9	1,381.6	0.4	0.4	1	1	0
08/09/2020 15:00	0.1	13.7	1,596.0	0.2	0.5	1	1	1
08/09/2020 16:00	-0.1	12.0	2,037.9	0.2	0.6	1	1	1
08/09/2020 17:00	0.1	11.8	2,079.1	0.2	0.6	1	1	1
08/09/2020 18:00	0.2	11.8	2,089.2	0.4	0.6	1	1	1
08/09/2020 19:00	0.1	11.9	2,058.6	0.2	0.6	1	1	1
08/09/2020 20:00	0.1	12.0	2,041.8	0.2	0.6	1	1	1
08/09/2020 21:00	0.1	11.9	2,062.3	0.2	0.6	1	1	1
08/09/2020 22:00	0.1	12.3	1,981.5	0.2	0.6	1	1	1
08/09/2020 23:00	-0.1	12.6	1,911.2	0.1	0.6	1	1	1
Average/Sum#:	0.3	13.3	1,579.6	0.3	0.5	24 #	24 #	9 #
Minimum:	-0.1	11.8	1,283.7	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,089.2	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/10/2020 00:00	0.4	13.8	1,413.6	0.4	0.4	1	1	0
08/10/2020 01:00	0.4	13.9	1,284.4	0.4	0.4	1	1	0
08/10/2020 02:00	0.4	13.9	1,291.1	0.4	0.4	1	1	0
08/10/2020 03:00	0.4	13.9	1,492.6	0.4	0.4	1	1	0
08/10/2020 04:00	0.4	13.9	1,521.0	0.4	0.5	1	1	0
08/10/2020 05:00	0.4	13.9	1,512.5	0.4	0.5	1	1	0
08/10/2020 06:00	0.4	13.9	1,608.3	0.4	0.5	1	1	0
08/10/2020 07:00	0.4	13.9	1,365.3	0.4	0.4	1	1	0
08/10/2020 08:00	0.4	13.9	1,492.7	0.4	0.4	1	1	0
08/10/2020 09:00	0.4	13.9	1,309.3	0.4	0.4	1	1	0
08/10/2020 10:00	0.4	13.9	1,523.3	0.4	0.5	1	1	0
08/10/2020 11:00	0.4	13.9	1,518.2	0.4	0.5	1	1	0
08/10/2020 12:00	0.4	13.9	1,305.8	0.4	0.4	1	1	0
08/10/2020 13:00	0.4	13.9	1,325.6	0.4	0.4	1	1	0
08/10/2020 14:00	0.4	13.9	1,332.3	0.4	0.4	1	1	0
08/10/2020 15:00	0.2	13.7	1,638.9	0.4	0.5	1	1	1
08/10/2020 16:00	-0.1	12.0	2,038.2	0.2	0.6	1	1	1
08/10/2020 17:00	0.1	11.7	2,089.9	0.2	0.6	1	1	1
08/10/2020 18:00	0.1	11.9	2,046.6	0.2	0.6	1	1	1
08/10/2020 19:00	0.1	12.2	2,016.9	0.2	0.6	1	1	1
08/10/2020 20:00	0.1	12.2	2,002.9	0.2	0.6	1	1	1
08/10/2020 21:00	-0.1	12.3	1,995.2	0.2	0.6	1	1	1
08/10/2020 22:00	-0.1	12.6	1,950.2	0.1	0.6	1	1	1
08/10/2020 23:00	-0.1	13.0	1,763.2	0.1	0.5	1	1	1
Average/Sum#:	0.3	13.3	1,618.3	0.3	0.5	24 #	24 #	9 #
Minimum:	-0.1	11.7	1,284.4	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,089.9	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/11/2020 00:00	0.4	13.9	1,282.3	0.4	0.4	1	1	0
08/11/2020 01:00	0.4	13.9	1,281.7	0.4	0.4	1	1	0
08/11/2020 02:00	0.4	13.9	1,282.8	0.4	0.4	1	1	0
08/11/2020 03:00	0.4	13.9	1,281.9	0.4	0.4	1	1	0
08/11/2020 04:00	0.4	13.9	1,289.8	0.4	0.4	1	1	0
08/11/2020 05:00	0.4	13.9	1,299.2	0.4	0.4	1	1	0
08/11/2020 06:00	0.4	13.9	1,333.4	0.4	0.4	1	1	0
08/11/2020 07:00	0.4	13.9	1,283.8	0.4	0.4	1	1	0
08/11/2020 08:00	0.4	13.9	1,289.0	0.4	0.4	1	1	0
08/11/2020 09:00	0.4	13.9	1,291.7	0.4	0.4	1	1	0
08/11/2020 10:00	0.4	13.9	1,295.2	0.4	0.4	1	1	0
08/11/2020 11:00	0.4	13.9	1,298.4	0.4	0.4	1	1	0
08/11/2020 12:00	0.4	13.9	1,296.0	0.4	0.4	1	1	0
08/11/2020 13:00	0.4	13.9	1,296.8	0.4	0.4	1	1	0
08/11/2020 14:00	0.4	13.9	1,315.4	0.4	0.4	1	1	0
08/11/2020 15:00	0.4	13.9	1,331.2	0.4	0.4	1	1	0
08/11/2020 16:00	0.4	13.9	1,425.6	0.4	0.4	1	1	0
08/11/2020 17:00	0.4	13.9	1,567.4	0.4	0.5	1	1	0
08/11/2020 18:00	0.4	13.9	1,519.2	0.4	0.5	1	1	0
08/11/2020 19:00	0.4	13.9	1,374.5	0.4	0.4	1	1	0
08/11/2020 20:00	0.4	13.9	1,356.4	0.4	0.4	1	1	0
08/11/2020 21:00	0.4	13.9	1,306.4	0.4	0.4	1	1	0
08/11/2020 22:00	0.4	13.9	1,390.3	0.4	0.4	1	1	0
08/11/2020 23:00	0.4	13.9	1,297.8	0.4	0.4	1	1	0
Average/Sum#:	0.4	13.9	1,332.8	0.4	0.4	24 #	24 #	0 #
Minimum:	0.4	13.9	1,281.7	0.4	0.4	1	1	0
Maximum:	0.4	13.9	1,567.4	0.4	0.5	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/12/2020 00:00	0.4	13.9	1,284.9	0.4	0.4	1	1	0
08/12/2020 01:00	0.4	13.9	1,307.3	0.4	0.4	1	1	0
08/12/2020 02:00	0.4	13.9	1,282.6	0.4	0.4	1	1	0
08/12/2020 03:00	0.4	13.9	1,286.3	0.4	0.4	1	1	0
08/12/2020 04:00	0.4	13.9	1,307.4	0.4	0.4	1	1	0
08/12/2020 05:00	0.4	13.9	1,298.2	0.4	0.4	1	1	0
08/12/2020 06:00	0.4	13.9	1,292.9	0.4	0.4	1	1	0
08/12/2020 07:00	0.4	13.9	1,308.0	0.4	0.4	1	1	0
08/12/2020 08:00	0.4	13.9	1,379.6	0.4	0.4	1	1	0
08/12/2020 09:00	0.4	13.9	1,332.9	0.4	0.4	1	1	0
08/12/2020 10:00	0.4	13.9	1,339.6	0.4	0.4	1	1	0
08/12/2020 11:00	0.4	13.9	1,382.5	0.4	0.4	1	1	0
08/12/2020 12:00	0.2	13.8	1,636.7	0.4	0.5	1	1	1
08/12/2020 13:00	-0.2	12.3	2,004.7	0.1	0.6	1	1	1
08/12/2020 14:00	-0.1	12.0	2,053.5	0.2	0.6	1	1	1
08/12/2020 15:00	0.1	11.8	2,078.9	0.2	0.6	1	1	1
08/12/2020 16:00	0.1	11.8	2,078.6	0.2	0.6	1	1	1
08/12/2020 17:00	0.1	11.9	2,073.2	0.2	0.6	1	1	1
08/12/2020 18:00	0.1	12.0	2,059.2	0.2	0.6	1	1	1
08/12/2020 19:00	-0.1	12.0	2,054.2	0.2	0.6	1	1	1
08/12/2020 20:00	-0.1	12.2	2,025.0	0.2	0.6	1	1	1
08/12/2020 21:00	-0.1	12.3	2,017.2	0.2	0.6	1	1	1
08/12/2020 22:00	-0.1	12.3	2,032.1	0.2	0.6	1	1	1
08/12/2020 23:00	-0.2	12.7	1,920.1	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.1	1,659.8	0.3	0.5	24 #	24 #	12 #
Minimum:	-0.2	11.8	1,282.6	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,078.9	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/13/2020 00:00	0.4	13.8	1,672.4	0.4	0.5	1	1	0
08/13/2020 01:00	0.4	13.8	1,611.4	0.4	0.5	1	1	0
08/13/2020 02:00	0.4	13.9	1,543.7	0.4	0.5	1	1	0
08/13/2020 03:00	0.4	13.9	1,577.0	0.4	0.5	1	1	0
08/13/2020 04:00	0.4	13.9	1,586.3	0.4	0.5	1	1	0
08/13/2020 05:00	0.4	13.9	1,608.0	0.4	0.5	1	1	0
08/13/2020 06:00	0.4	13.9	1,696.0	0.4	0.5	1	1	0
08/13/2020 07:00	0.4	13.9	1,598.1	0.4	0.5	1	1	0
08/13/2020 08:00	0.4	13.8	1,672.6	0.4	0.5	1	1	0
08/13/2020 09:00	0.4	13.8	1,595.3	0.4	0.5	1	1	1
08/13/2020 10:00	-0.2	12.6	1,972.3	0.1	0.6	1	1	1
08/13/2020 11:00	-0.1	12.1	2,072.7	0.2	0.6	1	1	1
08/13/2020 12:00	-0.1	12.1	2,065.6	0.2	0.6	1	1	1
08/13/2020 13:00	0.1	12.1	2,052.3	0.2	0.6	1	1	1
08/13/2020 14:00	-0.1	12.1	2,039.5	0.2	0.6	1	1	1
08/13/2020 15:00	0.1	11.9	2,071.2	0.2	0.6	1	1	1
08/13/2020 16:00	0.1	12.0	2,062.8	0.2	0.6	1	1	1
08/13/2020 17:00	0.1	11.9	2,064.0	0.2	0.6	1	1	1
08/13/2020 18:00	0.1	12.0	2,062.5	0.2	0.6	1	1	1
08/13/2020 19:00	0.1	12.0	2,069.0	0.2	0.6	1	1	1
08/13/2020 20:00	0.1	12.1	2,044.2	0.2	0.6	1	1	1
08/13/2020 21:00	0.1	12.3	2,030.4	0.2	0.6	1	1	1
08/13/2020 22:00	0.1	12.1	2,071.5	0.2	0.6	1	1	1
08/13/2020 23:00	0.1	11.9	2,118.2	0.2	0.6	1	1	1
Average/Sum#:	0.2	12.8	1,873.2	0.3	0.6	24 #	24 #	15 #
Minimum:	-0.2	11.9	1,543.7	0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,118.2	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/14/2020 00:00	0.1	11.9	2,127.6	0.2	0.6	1	1	1
08/14/2020 01:00	0.1	11.9	2,114.6	0.2	0.6	1	1	1
08/14/2020 02:00	0.1	12.1	2,094.7	0.2	0.6	1	1	1
08/14/2020 03:00	0.1	12.2	2,084.2	0.2	0.6	1	1	1
08/14/2020 04:00	0.1	12.0	2,126.6	0.2	0.6	1	1	1
08/14/2020 05:00	0.1	12.2	2,079.0	0.2	0.6	1	1	1
08/14/2020 06:00	-0.1	12.3	2,052.6	0.2	0.6	1	1	1
08/14/2020 07:00	-0.1	12.3	2,046.2	0.2	0.6	1	1	1
08/14/2020 08:00	0.1	12.2	2,069.2	0.2	0.6	1	1	1
08/14/2020 09:00	0.1	12.0	2,080.2	0.2	0.6	1	1	1
08/14/2020 10:00	0.2	11.8	2,106.6	0.4	0.6	1	1	1
08/14/2020 11:00	0.2	11.9	2,085.6	0.4	0.6	1	1	1
08/14/2020 12:00	0.1	11.9	2,097.4	0.2	0.6	1	1	1
08/14/2020 13:00	0.1	11.9	2,082.2	0.2	0.6	1	1	1
08/14/2020 14:00	0.1	11.9	2,065.2	0.2	0.6	1	1	1
08/14/2020 15:00	0.1	12.0	2,058.3	0.2	0.6	1	1	1
08/14/2020 16:00	0.1	12.0	2,041.3	0.2	0.6	1	1	1
08/14/2020 17:00	0.1	12.0	2,057.0	0.2	0.6	1	1	1
08/14/2020 18:00	0.1	12.0	2,059.1	0.2	0.6	1	1	1
08/14/2020 19:00	0.1	11.9	2,077.9	0.2	0.6	1	1	1
08/14/2020 20:00	0.1	11.8	2,092.5	0.2	0.6	1	1	1
08/14/2020 21:00	0.1	11.9	2,091.0	0.2	0.6	1	1	1
08/14/2020 22:00	0.2	11.8	2,109.5	0.4	0.6	1	1	1
08/14/2020 23:00	0.2	11.8	2,115.7	0.4	0.6	1	1	1
Average/Sum#:	0.1	12.0	2,083.9	0.2	0.6	24 #	24 #	24 #
Minimum:	-0.1	11.8	2,041.3	0.2	0.6	1	1	1
Maximum:	0.2	12.3	2,127.6	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/15/2020 00:00	0.1	11.8	2,118.3	0.2	0.6	1	1	1
08/15/2020 01:00	0.1	11.8	2,121.3	0.2	0.6	1	1	1
08/15/2020 02:00	0.1	11.9	2,096.5	0.2	0.6	1	1	1
08/15/2020 03:00	0.1	12.0	2,086.7	0.2	0.6	1	1	1
08/15/2020 04:00	0.1	12.1	2,072.4	0.2	0.6	1	1	1
08/15/2020 05:00	0.1	12.2	2,063.2	0.2	0.6	1	1	1
08/15/2020 06:00	0.1	12.2	2,065.6	0.2	0.6	1	1	1
08/15/2020 07:00	-0.1	12.1	2,062.5	0.2	0.6	1	1	1
08/15/2020 08:00	-0.1	12.5	1,983.4	0.1	0.6	1	1	1
08/15/2020 09:00	0.1	12.1	2,053.2	0.2	0.6	1	1	1
08/15/2020 10:00	0.1	12.0	2,057.7	0.2	0.6	1	1	1
08/15/2020 11:00	0.1	11.9	2,084.9	0.2	0.6	1	1	1
08/15/2020 12:00	0.1	11.8	2,094.6	0.2	0.6	1	1	1
08/15/2020 13:00	0.1	11.7	2,089.3	0.2	0.6	1	1	1
08/15/2020 14:00	0.1	11.8	2,085.4	0.2	0.6	1	1	1
08/15/2020 15:00	0.1	11.7	2,080.6	0.2	0.6	1	1	1
08/15/2020 16:00	0.1	11.7	2,079.9	0.2	0.6	1	1	1
08/15/2020 17:00	0.1	11.7	2,077.3	0.2	0.6	1	1	1
08/15/2020 18:00	0.1	11.8	2,074.5	0.2	0.6	1	1	1
08/15/2020 19:00	0.1	11.8	2,077.1	0.2	0.6	1	1	1
08/15/2020 20:00	0.2	11.8	2,094.6	0.4	0.6	1	1	1
08/15/2020 21:00	0.2	11.9	2,079.5	0.4	0.6	1	1	1
08/15/2020 22:00	0.2	12.0	2,063.2	0.4	0.6	1	1	1
08/15/2020 23:00	0.2	11.8	2,111.4	0.4	0.6	1	1	1
Average/Sum#:	0.1	11.9	2,078.0	0.2	0.6	24 #	24 #	24 #
Minimum:	-0.1	11.7	1,983.4	0.1	0.6	1	1	1
Maximum:	0.2	12.5	2,121.3	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/16/2020 00:00	0.2	11.8	2,118.1	0.4	0.6	1	1	1
08/16/2020 01:00	0.2	11.8	2,116.0	0.4	0.6	1	1	1
08/16/2020 02:00	0.2	11.8	2,116.5	0.4	0.6	1	1	1
08/16/2020 03:00	0.2	12.0	2,097.9	0.4	0.6	1	1	1
08/16/2020 04:00	0.2	11.9	2,116.9	0.4	0.6	1	1	1
08/16/2020 05:00	0.2	11.9	2,106.8	0.4	0.6	1	1	1
08/16/2020 06:00	0.2	11.9	2,094.0	0.4	0.6	1	1	1
08/16/2020 07:00	0.1	12.3	2,003.3	0.2	0.6	1	1	1
08/16/2020 08:00	-0.1	12.6	1,954.7	0.1	0.6	1	1	1
08/16/2020 09:00	0.1	12.3	2,011.5	0.2	0.6	1	1	1
08/16/2020 10:00	0.1	12.2	2,018.7	0.2	0.6	1	1	1
08/16/2020 11:00	0.1	12.2	2,013.9	0.2	0.6	1	1	1
08/16/2020 12:00	0.2	12.1	2,038.7	0.4	0.6	1	1	1
08/16/2020 13:00	0.2	12.0	2,054.5	0.4	0.6	1	1	1
08/16/2020 14:00	0.2	11.9	2,092.5	0.4	0.6	1	1	1
08/16/2020 15:00	0.2	11.8	2,095.2	0.4	0.6	1	1	1
08/16/2020 16:00	0.2	11.8	2,101.8	0.4	0.6	1	1	1
08/16/2020 17:00	0.2	11.7	2,096.0	0.4	0.6	1	1	1
08/16/2020 18:00	0.2	11.7	2,089.5	0.4	0.6	1	1	1
08/16/2020 19:00	0.2	11.8	2,082.7	0.4	0.6	1	1	1
08/16/2020 20:00	0.2	11.8	2,087.1	0.4	0.6	1	1	1
08/16/2020 21:00	0.1	11.9	2,076.1	0.2	0.6	1	1	1
08/16/2020 22:00	0.2	11.9	2,073.7	0.4	0.6	1	1	1
08/16/2020 23:00	0.2	11.9	2,081.0	0.4	0.6	1	1	1
Average/Sum#:	0.2	12.0	2,072.4	0.3	0.6	24 #	24 #	24 #
Minimum:	-0.1	11.7	1,954.7	0.1	0.6	1	1	1
Maximum:	0.2	12.6	2,118.1	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/17/2020 00:00	0.2	11.9	2,087.8	0.4	0.6	1	1	1
08/17/2020 01:00	0.2	12.0	2,079.6	0.4	0.6	1	1	1
08/17/2020 02:00	0.2	12.0	2,074.8	0.4	0.6	1	1	1
08/17/2020 03:00	0.2	12.0	2,085.7	0.4	0.6	1	1	1
08/17/2020 04:00	0.2	12.0	2,087.5	0.4	0.6	1	1	1
08/17/2020 05:00	0.2	12.0	2,080.3	0.4	0.6	1	1	1
08/17/2020 06:00	0.2	11.9	2,100.5	0.4	0.6	1	1	1
08/17/2020 07:00	0.2	11.9	2,106.7	0.4	0.6	1	1	1
08/17/2020 08:00	0.2	11.9	2,092.4	0.4	0.6	1	1	1
08/17/2020 09:00	0.2	11.8	2,108.6	0.4	0.6	1	1	1
08/17/2020 10:00	0.2	11.8	2,110.2	0.4	0.6	1	1	1
08/17/2020 11:00	0.2	11.9	2,082.2	0.4	0.6	1	1	1
08/17/2020 12:00	0.2	11.9	2,087.8	0.4	0.6	1	1	1
08/17/2020 13:00	0.2	12.0	2,058.6	0.4	0.6	1	1	1
08/17/2020 14:00	0.2	12.0	2,063.5	0.4	0.6	1	1	1
08/17/2020 15:00	0.2	11.8	2,092.7	0.4	0.6	1	1	1
08/17/2020 16:00	0.4	11.8	2,093.7	0.5	0.6	1	1	1
08/17/2020 17:00	0.2	11.9	2,065.1	0.4	0.6	1	1	1
08/17/2020 18:00	0.2	12.1	2,045.7	0.4	0.6	1	1	1
08/17/2020 19:00	0.2	12.1	2,047.1	0.4	0.6	1	1	1
08/17/2020 20:00	0.2	12.1	2,067.5	0.4	0.6	1	1	1
08/17/2020 21:00	0.2	11.9	2,097.8	0.4	0.6	1	1	1
08/17/2020 22:00	0.2	11.9	2,088.7	0.4	0.6	1	1	1
08/17/2020 23:00	0.2	12.0	2,089.0	0.4	0.6	1	1	1
Average/Sum#:	0.2	11.9	2,083.1	0.4	0.6	24 #	24 #	24 #
Minimum:	0.2	11.8	2,045.7	0.4	0.6	1	1	1
Maximum:	0.4	12.1	2,110.2	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/18/2020 00:00	0.2	12.1	2,055.8	0.4	0.6	1	1	1
08/18/2020 01:00	0.2	12.0	2,079.6	0.4	0.6	1	1	1
08/18/2020 02:00	0.2	11.9	2,093.1	0.4	0.6	1	1	1
08/18/2020 03:00	0.2	12.1	2,069.7	0.4	0.6	1	1	1
08/18/2020 04:00	0.2	12.0	2,085.1	0.4	0.6	1	1	1
08/18/2020 05:00	0.2	12.0	2,077.7	0.4	0.6	1	1	1
08/18/2020 06:00	0.2	11.9	2,099.8	0.4	0.6	1	1	1
08/18/2020 07:00	0.2	12.0	2,079.2	0.4	0.6	1	1	1
08/18/2020 08:00	0.1	12.1	2,056.0	0.2	0.6	1	1	1
08/18/2020 09:00	0.1	12.1	2,049.8	0.2	0.6	1	1	1
08/18/2020 10:00	0.2	12.0	2,063.2	0.4	0.6	1	1	1
08/18/2020 11:00	0.2	12.0	2,028.5	0.4	0.6	1	1	1
08/18/2020 12:00	0.2	11.8	2,071.7	0.4	0.6	1	1	1
08/18/2020 13:00	0.2	11.7	2,078.3	0.4	0.6	1	1	1
08/18/2020 14:00	0.2	11.7	2,083.1	0.4	0.6	1	1	1
08/18/2020 15:00	0.2	11.7	2,077.1	0.4	0.6	1	1	1
08/18/2020 16:00	0.2	11.7	2,077.9	0.4	0.6	1	1	1
08/18/2020 17:00	0.2	11.7	2,080.9	0.4	0.6	1	1	1
08/18/2020 18:00	0.2	11.7	2,080.6	0.4	0.6	1	1	1
08/18/2020 19:00	0.2	11.7	2,084.6	0.4	0.6	1	1	1
08/18/2020 20:00	0.4	11.8	2,098.2	0.5	0.6	1	1	1
08/18/2020 21:00	0.2	12.0	2,098.2	0.4	0.6	1	1	1
08/18/2020 22:00	0.2	11.9	2,109.5	0.4	0.6	1	1	1
08/18/2020 23:00	0.2	11.9	2,116.9	0.4	0.6	1	1	1
Average/Sum#:	0.2	11.9	2,078.9	0.4	0.6	24 #	24 #	24 #
Minimum:	0.1	11.7	2,028.5	0.2	0.6	1	1	1
Maximum:	0.4	12.1	2,116.9	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/19/2020 00:00	0.2	12.0	2,086.1	0.4	0.6	1	1	1
08/19/2020 01:00	0.2	12.0	2,080.9	0.4	0.6	1	1	1
08/19/2020 02:00	0.2	12.0	2,091.8	0.4	0.6	1	1	1
08/19/2020 03:00	0.2	12.1	2,069.2	0.4	0.6	1	1	1
08/19/2020 04:00	0.1	12.1	2,076.8	0.2	0.6	1	1	1
08/19/2020 05:00	0.1	12.2	2,069.1	0.2	0.6	1	1	1
08/19/2020 06:00	0.1	12.2	2,066.5	0.2	0.6	1	1	1
08/19/2020 07:00	0.2	12.0	2,106.3	0.4	0.6	1	1	1
08/19/2020 08:00	0.1	12.2	2,056.1	0.2	0.6	1	1	1
08/19/2020 09:00	0.2	12.0	2,098.4	0.4	0.6	1	1	1
08/19/2020 10:00	0.2	11.8	2,115.1	0.4	0.6	1	1	1
08/19/2020 11:00	0.2	11.8	2,102.4	0.4	0.6	1	1	1
08/19/2020 12:00	0.2	11.9	2,076.7	0.4	0.6	1	1	1
08/19/2020 13:00	0.2	11.8	2,099.7	0.4	0.6	1	1	1
08/19/2020 14:00	0.2	11.8	2,092.0	0.4	0.6	1	1	1
08/19/2020 15:00	0.2	11.7	2,082.8	0.4	0.6	1	1	1
08/19/2020 16:00	0.2	11.8	2,085.0	0.4	0.6	1	1	1
08/19/2020 17:00	0.2	11.9	2,089.1	0.4	0.6	1	1	1
08/19/2020 18:00	0.2	11.9	2,110.1	0.4	0.6	1	1	1
08/19/2020 19:00	0.2	12.0	2,101.6	0.4	0.6	1	1	1
08/19/2020 20:00	0.2	12.0	2,098.1	0.4	0.6	1	1	1
08/19/2020 21:00	0.1	12.2	2,073.9	0.2	0.6	1	1	1
08/19/2020 22:00	0.1	12.3	2,062.5	0.2	0.6	1	1	1
08/19/2020 23:00	0.1	12.4	2,048.7	0.2	0.6	1	1	1
Average/Sum#:	0.2	12.0	2,085.0	0.3	0.6	24 #	24 #	24 #
Minimum:	0.1	11.7	2,048.7	0.2	0.6	1	1	1
Maximum:	0.2	12.4	2,115.1	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/20/2020 00:00	0.1	12.4	2,052.7	0.2	0.6	1	1	1
08/20/2020 01:00	0.1	12.4	2,042.7	0.2	0.6	1	1	1
08/20/2020 02:00	0.1	12.5	2,032.3	0.2	0.6	1	1	1
08/20/2020 03:00	-0.1	12.5	2,033.4	0.1	0.6	1	1	1
08/20/2020 04:00	0.1	12.4	2,041.0	0.2	0.6	1	1	1
08/20/2020 05:00	0.1	12.4	2,043.8	0.2	0.6	1	1	1
08/20/2020 06:00	0.1	12.5	2,031.9	0.2	0.6	1	1	1
08/20/2020 07:00	0.1	12.5	2,028.1	0.2	0.6	1	1	1
08/20/2020 08:00	0.1	12.4	2,034.2	0.2	0.6	1	1	1
08/20/2020 09:00	0.1	12.3	2,049.0	0.2	0.6	1	1	1
08/20/2020 10:00	0.1	12.3	2,053.1	0.2	0.6	1	1	1
08/20/2020 11:00	0.1	12.3	2,049.9	0.2	0.6	1	1	1
08/20/2020 12:00	0.1	12.3	2,054.9	0.2	0.6	1	1	1
08/20/2020 13:00	0.1	12.3	2,056.9	0.2	0.6	1	1	1
08/20/2020 14:00	0.1	12.3	2,054.5	0.2	0.6	1	1	1
08/20/2020 15:00	-0.1	12.3	2,042.9	0.2	0.6	1	1	1
08/20/2020 16:00	-0.1	12.3	2,039.1	0.2	0.6	1	1	1
08/20/2020 17:00	-0.1	12.1	2,051.5	0.2	0.6	1	1	1
08/20/2020 18:00	0.1	12.2	2,048.2	0.2	0.6	1	1	1
08/20/2020 19:00	-0.1	12.2	2,052.3	0.2	0.6	1	1	1
08/20/2020 20:00	-0.1	12.2	2,055.6	0.2	0.6	1	1	1
08/20/2020 21:00	-0.1	12.3	2,050.7	0.2	0.6	1	1	1
08/20/2020 22:00	-0.1	12.3	2,039.5	0.2	0.6	1	1	1
08/20/2020 23:00	0.2	12.2	2,037.1	0.4	0.6	1	1	1
Average/Sum#:	0.0	12.3	2,044.8	0.2	0.6	24 #	24 #	24 #
Minimum:	-0.1	12.1	2,028.1	0.1	0.6	1	1	1
Maximum:	0.2	12.5	2,056.9	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/21/2020 00:00	0.4	12.2	2,053.6	0.5	0.6	1	1	1
08/21/2020 01:00	0.2	12.3	2,026.0	0.4	0.6	1	1	1
08/21/2020 02:00	0.2	12.7	1,948.9	0.4	0.6	1	1	1
08/21/2020 03:00	0.2	12.3	2,030.5	0.4	0.6	1	1	1
08/21/2020 04:00	0.2	12.3	2,039.2	0.4	0.6	1	1	1
08/21/2020 05:00	0.2	12.3	2,033.1	0.4	0.6	1	1	1
08/21/2020 06:00	0.4	12.1	2,065.3	0.5	0.6	1	1	1
08/21/2020 07:00	0.4	12.2	2,062.1	0.5	0.6	1	1	1
08/21/2020 08:00	0.4	12.2	2,044.3	0.5	0.6	1	1	1
08/21/2020 09:00	0.4	12.1	2,068.7	0.5	0.6	1	1	1
08/21/2020 10:00	0.4	12.0	2,069.0	0.5	0.6	1	1	1
08/21/2020 11:00	0.4	12.0	2,062.8	0.5	0.6	1	1	1
08/21/2020 12:00	0.1	12.1	2,073.1	0.2	0.6	1	1	1
08/21/2020 13:00	0.2	11.9	2,092.9	0.4	0.6	1	1	1
08/21/2020 14:00	0.1	12.0	2,061.2	0.2	0.6	1	1	1
08/21/2020 15:00	0.1	12.0	2,058.9	0.2	0.6	1	1	1
08/21/2020 16:00	0.1	11.9	2,076.2	0.2	0.6	1	1	1
08/21/2020 17:00	0.2	11.9	2,080.0	0.4	0.6	1	1	1
08/21/2020 18:00	0.1	12.0	2,063.1	0.2	0.6	1	1	1
08/21/2020 19:00	0.1	12.1	2,047.4	0.2	0.6	1	1	1
08/21/2020 20:00	0.1	12.1	2,059.0	0.2	0.6	1	1	1
08/21/2020 21:00	0.1	12.2	2,042.1	0.2	0.6	1	1	1
08/21/2020 22:00	0.1	12.1	2,053.2	0.2	0.6	1	1	1
08/21/2020 23:00	0.1	12.1	2,058.8	0.2	0.6	1	1	1
Average/Sum#:	0.2	12.1	2,052.9	0.3	0.6	24 #	24 #	24 #
Minimum:	0.1	11.9	1,948.9	0.2	0.6	1	1	1
Maximum:	0.4	12.7	2,092.9	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/22/2020 00:00	0.1	12.1	2,061.8	0.2	0.6	1	1	1
08/22/2020 01:00	0.1	12.6	1,918.4	0.2	0.6	1	1	1
08/22/2020 02:00	0.4	13.8	1,666.9	0.4	0.5	1	1	0
08/22/2020 03:00	0.4	13.9	1,534.7	0.4	0.5	1	1	0
08/22/2020 04:00	0.4	13.9	1,660.7	0.4	0.5	1	1	0
08/22/2020 05:00	0.4	13.8	1,682.1	0.4	0.5	1	1	0
08/22/2020 06:00	0.4	13.9	1,681.6	0.4	0.5	1	1	0
08/22/2020 07:00	0.4	13.9	1,673.1	0.4	0.5	1	1	0
08/22/2020 08:00	0.4	13.8	1,666.4	0.4	0.5	1	1	0
08/22/2020 09:00	0.4	13.8	1,645.9	0.4	0.5	1	1	0
08/22/2020 10:00	0.2	13.9	1,562.6	0.2	0.5	1	1	1
08/22/2020 11:00	-0.2	12.4	2,009.3	0.1	0.6	1	1	1
08/22/2020 12:00	-0.1	11.9	2,074.7	0.2	0.6	1	1	1
08/22/2020 13:00	0.1	11.9	2,082.5	0.2	0.6	1	1	1
08/22/2020 14:00	-0.1	12.0	2,050.3	0.2	0.6	1	1	1
08/22/2020 15:00	0.1	11.8	2,086.1	0.2	0.6	1	1	1
08/22/2020 16:00	0.1	11.7	2,095.1	0.2	0.6	1	1	1
08/22/2020 17:00	0.1	11.9	2,073.7	0.2	0.6	1	1	1
08/22/2020 18:00	0.1	12.0	2,058.8	0.2	0.6	1	1	1
08/22/2020 19:00	0.1	12.0	2,058.1	0.2	0.6	1	1	1
08/22/2020 20:00	0.1	12.0	2,049.9	0.2	0.6	1	1	1
08/22/2020 21:00	0.1	11.9	2,083.8	0.2	0.6	1	1	1
08/22/2020 22:00	0.1	12.0	2,069.1	0.2	0.6	1	1	1
08/22/2020 23:00	0.1	11.9	2,090.1	0.2	0.6	1	1	1
Average/Sum#:	0.2	12.7	1,901.5	0.3	0.6	24 #	24 #	16 #
Minimum:	-0.2	11.7	1,534.7	0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,095.1	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/23/2020 00:00	0.1	12.1	2,060.0	0.2	0.6	1	1	1
08/23/2020 01:00	0.1	12.2	2,031.2	0.2	0.6	1	1	1
08/23/2020 02:00	0.1	12.2	2,048.3	0.2	0.6	1	1	1
08/23/2020 03:00	0.1	12.3	2,034.9	0.2	0.6	1	1	1
08/23/2020 04:00	-0.1	12.7	1,936.3	0.1	0.6	1	1	1
08/23/2020 05:00	0.4	13.8	1,683.3	0.4	0.5	1	1	0
08/23/2020 06:00	0.4	13.9	1,636.0	0.4	0.5	1	1	0
08/23/2020 07:00	0.4	13.9	1,581.3	0.4	0.5	1	1	0
08/23/2020 08:00	0.4	13.8	1,641.8	0.4	0.5	1	1	0
08/23/2020 09:00	0.4	13.8	1,608.6	0.4	0.5	1	1	0
08/23/2020 10:00	0.2	13.9	1,529.4	0.2	0.5	1	1	1
08/23/2020 11:00	-0.1	12.4	2,010.5	0.2	0.6	1	1	1
08/23/2020 12:00	0.1	12.0	2,081.1	0.2	0.6	1	1	1
08/23/2020 13:00	0.1	11.9	2,077.2	0.2	0.6	1	1	1
08/23/2020 14:00	0.1	12.0	2,072.5	0.2	0.6	1	1	1
08/23/2020 15:00	0.2	11.8	2,092.8	0.4	0.6	1	1	1
08/23/2020 16:00	0.2	11.7	2,092.5	0.4	0.6	1	1	1
08/23/2020 17:00	0.2	11.7	2,097.6	0.4	0.6	1	1	1
08/23/2020 18:00	0.2	11.7	2,099.7	0.4	0.6	1	1	1
08/23/2020 19:00	0.2	11.7	2,101.8	0.4	0.6	1	1	1
08/23/2020 20:00	0.2	11.8	2,111.9	0.4	0.6	1	1	1
08/23/2020 21:00	0.1	12.0	2,086.7	0.2	0.6	1	1	1
08/23/2020 22:00	0.1	12.0	2,075.3	0.2	0.6	1	1	1
08/23/2020 23:00	0.1	12.0	2,072.4	0.2	0.6	1	1	1
Average/Sum#:	0.2	12.5	1,952.6	0.3	0.6	24 #	24 #	19 #
Minimum:	-0.1	11.7	1,529.4	0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,111.9	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/24/2020 00:00	0.1	12.0	2,077.3	0.2	0.6	1	1	1
08/24/2020 01:00	0.1	12.1	2,072.8	0.2	0.6	1	1	1
08/24/2020 02:00	0.1	12.0	2,086.4	0.2	0.6	1	1	1
08/24/2020 03:00	0.1	11.9	2,106.5	0.2	0.6	1	1	1
08/24/2020 04:00	0.1	12.0	2,098.2	0.2	0.6	1	1	1
08/24/2020 05:00	0.1	12.0	2,092.4	0.2	0.6	1	1	1
08/24/2020 06:00	0.1	12.0	2,083.2	0.2	0.6	1	1	1
08/24/2020 07:00	0.1	12.2	2,057.4	0.2	0.6	1	1	1
08/24/2020 08:00	0.1	12.2	2,046.8	0.2	0.6	1	1	1
08/24/2020 09:00	0.1	12.1	2,062.3	0.2	0.6	1	1	1
08/24/2020 10:00	0.2	11.9	2,096.5	0.4	0.6	1	1	1
08/24/2020 11:00	0.2	11.8	2,106.9	0.4	0.6	1	1	1
08/24/2020 12:00	0.2	12.0	2,088.4	0.4	0.6	1	1	1
08/24/2020 13:00	0.2	11.9	2,086.5	0.4	0.6	1	1	1
08/24/2020 14:00	0.2	11.9	2,067.3	0.4	0.6	1	1	1
08/24/2020 15:00	0.2	11.8	2,072.7	0.4	0.6	1	1	1
08/24/2020 16:00	0.1	11.8	2,084.1	0.2	0.6	1	1	1
08/24/2020 17:00	0.2	11.8	2,078.3	0.4	0.6	1	1	1
08/24/2020 18:00	0.2	11.8	2,081.4	0.4	0.6	1	1	1
08/24/2020 19:00	0.1	12.0	2,053.6	0.2	0.6	1	1	1
08/24/2020 20:00	0.1	12.0	2,070.3	0.2	0.6	1	1	1
08/24/2020 21:00	0.1	12.0	2,071.0	0.2	0.6	1	1	1
08/24/2020 22:00	0.1	12.0	2,078.3	0.2	0.6	1	1	1
08/24/2020 23:00	0.1	12.0	2,076.6	0.2	0.6	1	1	1
Average/Sum#:	0.1	12.0	2,079.0	0.3	0.6	24 #	24 #	24 #
Minimum:	0.1	11.8	2,046.8	0.2	0.6	1	1	1
Maximum:	0.2	12.2	2,106.9	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/25/2020 00:00	0.1	12.1	2,054.6	0.2	0.6	1	1	1
08/25/2020 01:00	0.1	12.1	2,047.5	0.2	0.6	1	1	1
08/25/2020 02:00	0.1	12.2	2,037.7	0.2	0.6	1	1	1
08/25/2020 03:00	-0.1	12.5	1,990.2	0.1	0.6	1	1	1
08/25/2020 04:00	-0.1	12.3	2,035.3	0.2	0.6	1	1	1
08/25/2020 05:00	0.1	12.2	2,044.2	0.2	0.6	1	1	1
08/25/2020 06:00	-0.1	12.3	2,043.5	0.2	0.6	1	1	1
08/25/2020 07:00	0.1	12.4	2,029.6	0.2	0.6	1	1	1
08/25/2020 08:00	-0.1	12.3	2,027.0	0.2	0.6	1	1	1
08/25/2020 09:00	0.1	12.2	2,047.7	0.2	0.6	1	1	1
08/25/2020 10:00	0.1	12.1	2,049.2	0.2	0.6	1	1	1
08/25/2020 11:00	0.1	12.1	2,043.7	0.2	0.6	1	1	1
08/25/2020 12:00	0.1	12.1	2,039.4	0.2	0.6	1	1	1
08/25/2020 13:00	0.1	12.1	2,037.6	0.2	0.6	1	1	1
08/25/2020 14:00	0.1	12.0	2,040.4	0.2	0.6	1	1	1
08/25/2020 15:00	0.2	12.0	2,047.2	0.4	0.6	1	1	1
08/25/2020 16:00	0.2	11.9	2,062.0	0.4	0.6	1	1	1
08/25/2020 17:00	0.2	11.8	2,079.2	0.4	0.6	1	1	1
08/25/2020 18:00	0.2	11.8	2,087.2	0.4	0.6	1	1	1
08/25/2020 19:00	0.2	11.8	2,090.0	0.4	0.6	1	1	1
08/25/2020 20:00	0.2	11.9	2,069.9	0.4	0.6	1	1	1
08/25/2020 21:00	0.1	12.0	2,055.4	0.2	0.6	1	1	1
08/25/2020 22:00	0.1	12.1	2,050.1	0.2	0.6	1	1	1
08/25/2020 23:00	0.1	12.0	2,054.9	0.2	0.6	1	1	1
Average/Sum#:	0.1	12.1	2,048.5	0.2	0.6	24 #	24 #	24 #
Minimum:	-0.1	11.8	1,990.2	0.1	0.6	1	1	1
Maximum:	0.2	12.5	2,090.0	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/26/2020 00:00	0.1	12.2	2,023.2	0.2	0.6	1	1	1
08/26/2020 01:00	-0.1	12.7	1,929.4	0.1	0.6	1	1	1
08/26/2020 02:00	-0.1	12.8	1,936.0	0.1	0.6	1	1	1
08/26/2020 03:00	-0.1	12.4	2,022.2	0.2	0.6	1	1	1
08/26/2020 04:00	0.1	12.3	2,032.4	0.2	0.6	1	1	1
08/26/2020 05:00	0.1	12.3	2,033.1	0.2	0.6	1	1	1
08/26/2020 06:00	0.1	12.3	2,036.4	0.2	0.6	1	1	1
08/26/2020 07:00	-0.1	12.7	1,940.8	0.1	0.6	1	1	1
08/26/2020 08:00	-0.1	12.7	1,941.9	0.1	0.6	1	1	1
08/26/2020 09:00	0.1	12.2	2,037.0	0.2	0.6	1	1	1
08/26/2020 10:00	0.1	12.1	2,058.3	0.2	0.6	1	1	1
08/26/2020 11:00	0.1	12.1	2,047.6	0.2	0.6	1	1	1
08/26/2020 12:00	0.1	12.0	2,049.7	0.2	0.6	1	1	1
08/26/2020 13:00	0.1	12.0	2,048.1	0.2	0.6	1	1	1
08/26/2020 14:00	0.1	11.9	2,060.9	0.2	0.6	1	1	1
08/26/2020 15:00	0.2	11.8	2,081.2	0.4	0.6	1	1	1
08/26/2020 16:00	0.1	12.0	2,029.7	0.2	0.6	1	1	1
08/26/2020 17:00	0.1	12.1	2,009.6	0.2	0.6	1	1	1
08/26/2020 18:00	0.1	12.1	2,008.2	0.2	0.6	1	1	1
08/26/2020 19:00	0.1	12.2	1,999.6	0.2	0.6	1	1	1
08/26/2020 20:00	0.1	12.3	1,991.8	0.2	0.6	1	1	1
08/26/2020 21:00	0.1	12.4	1,989.2	0.2	0.6	1	1	1
08/26/2020 22:00	-0.1	12.7	1,934.7	0.1	0.6	1	1	1
08/26/2020 23:00	-0.1	12.8	1,926.6	0.1	0.6	1	1	1
Average/Sum#:	0.0	12.3	2,007.0	0.2	0.6	24 #	24 #	24 #
Minimum:	-0.1	11.8	1,926.6	0.1	0.6	1	1	1
Maximum:	0.2	12.8	2,081.2	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/27/2020 00:00	-0.1	12.8	1,929.7	0.1	0.6	1	1	1
08/27/2020 01:00	-0.1	12.9	1,929.8	0.1	0.6	1	1	1
08/27/2020 02:00	-0.2	12.9	1,924.3	0.1	0.6	1	1	1
08/27/2020 03:00	0.1	12.9	1,931.0	0.2	0.6	1	1	1
08/27/2020 04:00	0.1	12.4	2,032.6	0.2	0.6	1	1	1
08/27/2020 05:00	0.1	12.4	2,037.2	0.2	0.6	1	1	1
08/27/2020 06:00	0.1	12.4	2,054.3	0.2	0.6	1	1	1
08/27/2020 07:00	-0.2	12.8	1,939.6	0.1	0.6	1	1	1
08/27/2020 08:00	-0.1	12.5	1,996.3	0.1	0.6	1	1	1
08/27/2020 09:00	0.1	12.5	1,995.3	0.2	0.6	1	1	1
08/27/2020 10:00	0.1	12.5	1,990.3	0.2	0.6	1	1	1
08/27/2020 11:00	0.2	12.0	2,089.5	0.4	0.6	1	1	1
08/27/2020 12:00	0.2	11.9	2,101.6	0.4	0.6	1	1	1
08/27/2020 13:00	0.2	11.8	2,096.2	0.4	0.6	1	1	1
08/27/2020 14:00	0.2	11.8	2,097.0	0.4	0.6	1	1	1
08/27/2020 15:00	0.2	11.8	2,105.0	0.4	0.6	1	1	1
08/27/2020 16:00	0.1	12.1	2,042.6	0.2	0.6	1	1	1
08/27/2020 17:00	0.1	12.1	2,041.8	0.2	0.6	1	1	1
08/27/2020 18:00	0.2	12.1	2,048.4	0.4	0.6	1	1	1
08/27/2020 19:00	0.2	12.0	2,080.0	0.4	0.6	1	1	1
08/27/2020 20:00	0.1	12.0	2,094.5	0.2	0.6	1	1	1
08/27/2020 21:00	0.2	11.9	2,115.9	0.4	0.6	1	1	1
08/27/2020 22:00	0.2	11.9	2,115.0	0.4	0.6	1	1	1
08/27/2020 23:00	-0.1	12.4	2,008.0	0.2	0.6	1	1	1
Average/Sum#:	0.1	12.3	2,033.2	0.3	0.6	24 #	24 #	24 #
Minimum:	-0.2	11.8	1,924.3	0.1	0.6	1	1	1
Maximum:	0.2	12.9	2,115.9	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/28/2020 00:00	-0.2	12.8	1,915.3	0.1	0.6	1	1	1
08/28/2020 01:00	0.4	13.8	1,514.1	0.4	0.5	1	1	0
08/28/2020 02:00	0.4	13.9	1,443.2	0.4	0.4	1	1	0
08/28/2020 03:00	0.4	13.9	1,285.5	0.4	0.4	1	1	0
08/28/2020 04:00	0.4	13.9	1,467.2	0.4	0.4	1	1	0
08/28/2020 05:00	0.4	13.9	1,589.7	0.4	0.5	1	1	0
08/28/2020 06:00	0.4	13.9	1,449.3	0.4	0.4	1	1	0
08/28/2020 07:00	0.4	13.9	1,371.8	0.4	0.4	1	1	0
08/28/2020 08:00	0.4	13.9	1,392.1	0.4	0.4	1	1	0
08/28/2020 09:00	0.4	13.9	1,422.3	0.4	0.4	1	1	0
08/28/2020 10:00	0.4	13.9	1,456.5	0.4	0.4	1	1	0
08/28/2020 11:00	0.4	13.9	1,505.7	0.4	0.5	1	1	1
08/28/2020 12:00	-0.2	12.3	1,993.4	0.1	0.6	1	1	1
08/28/2020 13:00	0.1	11.9	2,066.0	0.2	0.6	1	1	1
08/28/2020 14:00	0.1	11.9	2,061.2	0.2	0.6	1	1	1
08/28/2020 15:00	0.1	11.9	2,060.2	0.2	0.6	1	1	1
08/28/2020 16:00	0.1	11.9	2,062.4	0.2	0.6	1	1	1
08/28/2020 17:00	0.1	11.9	2,051.9	0.2	0.6	1	1	1
08/28/2020 18:00	0.1	12.0	2,051.4	0.2	0.6	1	1	1
08/28/2020 19:00	0.1	12.3	2,002.0	0.2	0.6	1	1	1
08/28/2020 20:00	-0.1	12.3	1,995.3	0.2	0.6	1	1	1
08/28/2020 21:00	-0.1	12.4	1,993.7	0.2	0.6	1	1	1
08/28/2020 22:00	-0.1	12.5	1,963.5	0.1	0.6	1	1	1
08/28/2020 23:00	0.1	12.2	2,034.4	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.0	1,756.2	0.3	0.5	24 #	24 #	14 #
Minimum:	-0.2	11.9	1,285.5	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,066.0	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/29/2020 00:00	0.1	12.2	2,040.2	0.2	0.6	1	1	1
08/29/2020 01:00	0.1	12.3	2,038.1	0.2	0.6	1	1	1
08/29/2020 02:00	0.1	12.4	2,019.7	0.2	0.6	1	1	1
08/29/2020 03:00	-0.1	12.7	1,925.4	0.1	0.6	1	1	1
08/29/2020 04:00	0.4	13.8	1,598.5	0.4	0.5	1	1	0
08/29/2020 05:00	0.4	13.8	1,578.3	0.4	0.5	1	1	0
08/29/2020 06:00	0.4	13.8	1,551.9	0.4	0.5	1	1	0
08/29/2020 07:00	0.4	13.8	1,422.5	0.4	0.4	1	1	0
08/29/2020 08:00	0.4	13.9	1,376.4	0.4	0.4	1	1	0
08/29/2020 09:00	0.4	13.9	1,280.9	0.4	0.4	1	1	0
08/29/2020 10:00	0.4	13.9	1,293.5	0.4	0.4	1	1	0
08/29/2020 11:00	0.4	13.9	1,327.6	0.4	0.4	1	1	0
08/29/2020 12:00	0.4	13.9	1,286.3	0.4	0.4	1	1	0
08/29/2020 13:00	0.4	13.9	1,589.7	0.4	0.5	1	1	0
08/29/2020 14:00	0.3	13.8	1,596.4	0.4	0.5	1	1	0
08/29/2020 15:00	0.3	13.8	1,604.2	0.4	0.5	1	1	0
08/29/2020 16:00	0.1	13.8	1,652.1	0.2	0.5	1	1	1
08/29/2020 17:00	-0.1	12.2	2,022.2	0.2	0.6	1	1	1
08/29/2020 18:00	0.1	11.9	2,060.2	0.2	0.6	1	1	1
08/29/2020 19:00	0.1	12.0	2,061.8	0.2	0.6	1	1	1
08/29/2020 20:00	0.1	11.8	2,106.0	0.2	0.6	1	1	1
08/29/2020 21:00	0.1	11.9	2,083.8	0.2	0.6	1	1	1
08/29/2020 22:00	-0.1	12.4	1,992.5	0.2	0.6	1	1	1
08/29/2020 23:00	-0.1	12.5	1,988.3	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.1	1,729.0	0.3	0.5	24 #	24 #	12 #
Minimum:	-0.1	11.8	1,280.9	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,106.0	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/30/2020 00:00	-0.1	12.8	1,911.7	0.1	0.6	1	1	1
08/30/2020 01:00	0.4	13.7	1,739.2	0.4	0.5	1	1	0
08/30/2020 02:00	0.4	13.7	1,742.8	0.4	0.5	1	1	0
08/30/2020 03:00	0.4	13.7	1,744.6	0.4	0.5	1	1	0
08/30/2020 04:00	0.4	13.7	1,744.5	0.4	0.5	1	1	0
08/30/2020 05:00	0.4	13.7	1,749.0	0.4	0.5	1	1	0
08/30/2020 06:00	0.4	13.7	1,743.9	0.4	0.5	1	1	0
08/30/2020 07:00	0.4	13.7	1,738.2	0.4	0.5	1	1	0
08/30/2020 08:00	0.4	13.7	1,746.3	0.4	0.5	1	1	0
08/30/2020 09:00	0.4	13.6	1,745.0	0.4	0.5	1	1	0
08/30/2020 10:00	0.4	13.6	1,736.1	0.4	0.5	1	1	0
08/30/2020 11:00	0.4	13.6	1,726.9	0.4	0.5	1	1	0
08/30/2020 12:00	0.4	13.6	1,718.3	0.4	0.5	1	1	0
08/30/2020 13:00	0.4	13.7	1,621.7	0.4	0.5	1	1	0
08/30/2020 14:00	0.2	13.8	1,533.0	0.4	0.5	1	1	1
08/30/2020 15:00	-0.1	12.1	2,037.2	0.2	0.6	1	1	1
08/30/2020 16:00	0.1	11.8	2,104.1	0.2	0.6	1	1	1
08/30/2020 17:00	0.1	12.0	2,065.7	0.2	0.6	1	1	1
08/30/2020 18:00	0.1	12.1	2,045.5	0.2	0.6	1	1	1
08/30/2020 19:00	-0.1	12.3	2,013.0	0.2	0.6	1	1	1
08/30/2020 20:00	-0.1	12.3	2,007.3	0.2	0.6	1	1	1
08/30/2020 21:00	-0.1	12.4	2,003.0	0.2	0.6	1	1	1
08/30/2020 22:00	-0.1	12.4	1,998.5	0.2	0.6	1	1	1
08/30/2020 23:00	-0.2	12.7	1,919.1	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.1	1,838.9	0.3	0.5	24 #	24 #	11 #
Minimum:	-0.2	11.8	1,533.0	0.1	0.5	1	1	0
Maximum:	0.4	13.8	2,104.1	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/31/2020 00:00	0.4	13.8	1,609.2	0.4	0.5	1	1	0
08/31/2020 01:00	0.4	13.9	1,299.3	0.4	0.4	1	1	0
08/31/2020 02:00	0.4	13.9	1,285.5	0.4	0.4	1	1	0
08/31/2020 03:00	0.4	13.9	1,296.5	0.4	0.4	1	1	0
08/31/2020 04:00	0.4	13.8	1,632.0	0.4	0.5	1	1	0
08/31/2020 05:00	0.4	13.8	1,662.9	0.4	0.5	1	1	0
08/31/2020 06:00	0.4	13.8	1,685.2	0.4	0.5	1	1	0
08/31/2020 07:00	0.4	13.9	1,381.8	0.4	0.4	1	1	0
08/31/2020 08:00	0.4	13.9	1,404.7	0.4	0.4	1	1	0
08/31/2020 09:00	0.4	14.0	1,310.4	0.4	0.4	1	1	0
08/31/2020 10:00	0.5	14.0	1,299.2	0.5	0.4	1	1	0
08/31/2020 11:00	0.5	14.0	1,500.0	0.5	0.5	1	1	0
08/31/2020 12:00	0.5	13.9	1,474.2	0.5	0.4	1	1	0
08/31/2020 13:00	-0.1	12.3	2,014.8	0.2	0.6	1	1	1
08/31/2020 14:00	0.1	11.9	2,114.8	0.2	0.6	1	1	1
08/31/2020 15:00	0.1	11.8	2,106.2	0.2	0.6	1	1	1
08/31/2020 16:00	0.1	12.2	2,028.6	0.2	0.6	1	1	1
08/31/2020 17:00	-0.1	12.4	2,006.2	0.2	0.6	1	1	1
08/31/2020 18:00	-0.1	12.4	2,003.4	0.2	0.6	1	1	1
08/31/2020 19:00	-0.1	12.4	1,998.8	0.2	0.6	1	1	1
08/31/2020 20:00	-0.1	12.4	1,995.8	0.2	0.6	1	1	1
08/31/2020 21:00	-0.1	12.5	1,993.9	0.1	0.6	1	1	1
08/31/2020 22:00	-0.1	12.5	1,991.8	0.1	0.6	1	1	1
08/31/2020 23:00	-0.1	13.0	1,777.2	0.1	0.5	1	1	1
Average/Sum#:	0.2	13.2	1,703.0	0.3	0.5	24 #	24 #	11 #
Minimum:	-0.1	11.8	1,285.5	0.1	0.4	1	1	0
Maximum:	0.5	14.0	2,114.8	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/01/2020 00:00	0.4	13.9	1,295.3	0.4	0.4	1	1	0
09/01/2020 01:00	0.4	13.9	1,492.9	0.4	0.4	1	1	0
09/01/2020 02:00	0.4	14.0	1,388.5	0.4	0.4	1	1	0
09/01/2020 03:00	0.4	14.0	1,297.5	0.4	0.4	1	1	0
09/01/2020 04:00	0.4	14.0	1,345.1	0.4	0.4	1	1	0
09/01/2020 05:00	0.4	13.8	1,663.8	0.4	0.5	1	1	0
09/01/2020 06:00	0.4	13.8	1,650.7	0.4	0.5	1	1	0
09/01/2020 07:00	0.4	13.8	1,671.7	0.4	0.5	1	1	0
09/01/2020 08:00	0.4	13.8	1,592.9	0.4	0.5	1	1	0
09/01/2020 09:00	0.4	13.8	1,620.6	0.4	0.5	1	1	0
09/01/2020 10:00	0.4	13.8	1,479.3	0.4	0.4	1	1	0
09/01/2020 11:00	0.5	14.0	1,309.3	0.5	0.4	1	1	0
09/01/2020 12:00	0.5	14.0	1,338.3	0.5	0.4	1	1	0
09/01/2020 13:00	0.5	14.0	1,486.0	0.5	0.4	1	1	0
09/01/2020 14:00	0.4	13.8	1,645.6	0.4	0.5	1	1	0
09/01/2020 15:00	0.4	13.8	1,613.3	0.4	0.5	1	1	0
09/01/2020 16:00	0.2	13.8	1,535.0	0.4	0.5	1	1	1
09/01/2020 17:00	-0.1	12.2	2,024.7	0.2	0.6	1	1	1
09/01/2020 18:00	0.1	11.8	2,100.8	0.2	0.6	1	1	1
09/01/2020 19:00	0.1	11.9	2,078.1	0.2	0.6	1	1	1
09/01/2020 20:00	-0.1	12.4	1,995.8	0.2	0.6	1	1	1
09/01/2020 21:00	-0.1	12.5	1,986.9	0.1	0.6	1	1	1
09/01/2020 22:00	-0.2	12.8	1,931.4	0.1	0.6	1	1	1
09/01/2020 23:00	0.1	13.2	1,771.7	0.2	0.5	1	1	1
Average/Sum#:	0.3	13.5	1,638.1	0.3	0.5	24 #	24 #	8 #
Minimum:	-0.2	11.8	1,295.3	0.1	0.4	1	1	0
Maximum:	0.5	14.0	2,100.8	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/02/2020 00:00	0.4	13.9	1,282.2	0.4	0.4	1	1	0
09/02/2020 01:00	0.4	13.9	1,277.4	0.4	0.4	1	1	0
09/02/2020 02:00	0.4	13.9	1,294.5	0.4	0.4	1	1	0
09/02/2020 03:00	0.4	13.9	1,288.3	0.4	0.4	1	1	0
09/02/2020 04:00	0.4	13.9	1,312.6	0.4	0.4	1	1	0
09/02/2020 05:00	0.4	13.9	1,279.0	0.4	0.4	1	1	0
09/02/2020 06:00	0.4	13.9	1,286.2	0.4	0.4	1	1	0
09/02/2020 07:00	0.0	14.8	943.4	0.0	0.3	1	0	0
09/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.4	14.0	1,245.5	0.4	0.4	8 #	7 #	0 #
Minimum:	0.0	13.9	943.4	0.0	0.3	0	0	0
Maximum:	0.4	14.8	1,312.6	0.4	0.4	1	1	0
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2020 03:00	0.0	17.8	416.5	0.0	0.1	1	0	0
09/03/2020 04:00	0.0	15.1	986.1	0.0	0.3	1	0	0
09/03/2020 05:00	0.4	13.8	1,569.2	0.4	0.5	1	1	0
09/03/2020 06:00	0.4	13.8	1,582.8	0.4	0.5	1	1	0
09/03/2020 07:00	0.4	13.8	1,640.8	0.4	0.5	1	1	0
09/03/2020 08:00	0.4	13.8	1,636.3	0.4	0.5	1	1	0
09/03/2020 09:00	0.4	13.9	1,532.0	0.4	0.5	1	1	0
09/03/2020 10:00	0.4	13.9	1,572.1	0.4	0.5	1	1	0
09/03/2020 11:00	0.4	13.8	1,522.4	0.4	0.5	1	1	1
09/03/2020 12:00	-0.4	12.2	2,044.8	-0.1	0.6	1	1	1
09/03/2020 13:00	0.2	11.9	2,092.8	0.4	0.6	1	1	1
09/03/2020 14:00	0.1	12.0	2,057.6	0.2	0.6	1	1	1
09/03/2020 15:00	0.2	11.8	2,089.3	0.4	0.6	1	1	1
09/03/2020 16:00	0.2	11.8	2,089.4	0.4	0.6	1	1	1
09/03/2020 17:00	0.2	11.8	2,093.2	0.4	0.6	1	1	1
09/03/2020 18:00	0.2	11.8	2,096.0	0.4	0.6	1	1	1
09/03/2020 19:00	0.2	12.0	2,054.4	0.4	0.6	1	1	1
09/03/2020 20:00	0.1	12.3	1,995.8	0.2	0.6	1	1	1
09/03/2020 21:00	0.2	12.3	1,997.3	0.4	0.6	1	1	1
09/03/2020 22:00	0.2	12.2	2,029.0	0.4	0.6	1	1	1
09/03/2020 23:00	0.2	11.9	2,096.6	0.4	0.6	1	1	1
Average/Sum#:	0.2	13.0	1,771.2	0.3	0.5	21 #	19 #	13 #
Minimum:	-0.4	11.8	416.5	-0.1	0.1	0	0	0
Maximum:	0.4	17.8	2,096.6	0.4	0.6	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/04/2020 00:00	0.1	12.4	2,011.2	0.2	0.6	1	1	1
09/04/2020 01:00	0.1	12.5	1,980.2	0.2	0.6	1	1	1
09/04/2020 02:00	0.1	12.5	1,981.1	0.2	0.6	1	1	1
09/04/2020 03:00	-0.1	12.6	1,983.8	0.1	0.6	1	1	1
09/04/2020 04:00	0.2	12.0	2,104.0	0.4	0.6	1	1	1
09/04/2020 05:00	0.2	11.9	2,127.7	0.4	0.6	1	1	1
09/04/2020 06:00	0.2	12.0	2,107.3	0.4	0.6	1	1	1
09/04/2020 07:00	0.2	12.0	2,095.1	0.4	0.6	1	1	1
09/04/2020 08:00	0.2	12.4	2,016.9	0.4	0.6	1	1	1
09/04/2020 09:00	0.1	12.5	1,983.2	0.2	0.6	1	1	1
09/04/2020 10:00	0.2	12.1	2,041.7	0.4	0.6	1	1	1
09/04/2020 11:00	0.2	12.0	2,065.9	0.4	0.6	1	1	1
09/04/2020 12:00	0.2	11.9	2,071.3	0.4	0.6	1	1	1
09/04/2020 13:00	0.2	11.9	2,072.3	0.4	0.6	1	1	1
09/04/2020 14:00	0.2	11.9	2,077.4	0.4	0.6	1	1	1
09/04/2020 15:00	0.2	11.8	2,077.0	0.4	0.6	1	1	1
09/04/2020 16:00	0.2	11.8	2,076.8	0.4	0.6	1	1	1
09/04/2020 17:00	0.2	11.8	2,080.4	0.4	0.6	1	1	1
09/04/2020 18:00	0.2	11.8	2,088.3	0.4	0.6	1	1	1
09/04/2020 19:00	0.2	11.8	2,093.8	0.4	0.6	1	1	1
09/04/2020 20:00	0.2	11.8	2,097.4	0.4	0.6	1	1	1
09/04/2020 21:00	0.2	11.9	2,081.3	0.4	0.6	1	1	1
09/04/2020 22:00	0.2	12.0	2,082.2	0.4	0.6	1	1	1
09/04/2020 23:00	0.1	12.3	2,021.0	0.2	0.6	1	1	1
Average/Sum#:	0.2	12.1	2,059.1	0.3	0.6	24 #	24 #	24 #
Minimum:	-0.1	11.8	1,980.2	0.1	0.6	1	1	1
Maximum:	0.2	12.6	2,127.7	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/05/2020 00:00	0.1	12.4	1,996.9	0.2	0.6	1	1	1
09/05/2020 01:00	0.1	12.4	1,996.3	0.2	0.6	1	1	1
09/05/2020 02:00	0.1	12.4	1,996.8	0.2	0.6	1	1	1
09/05/2020 03:00	0.1	12.4	1,997.8	0.2	0.6	1	1	1
09/05/2020 04:00	0.1	12.4	2,010.4	0.2	0.6	1	1	1
09/05/2020 05:00	0.1	12.4	1,978.8	0.2	0.6	1	1	1
09/05/2020 06:00	0.4	13.8	1,639.9	0.4	0.5	1	1	0
09/05/2020 07:00	0.4	13.8	1,568.3	0.4	0.5	1	1	0
09/05/2020 08:00	0.4	13.8	1,612.8	0.4	0.5	1	1	0
09/05/2020 09:00	0.3	13.8	1,592.3	0.4	0.5	1	1	0
09/05/2020 10:00	0.2	13.8	1,621.0	0.4	0.5	1	1	1
09/05/2020 11:00	-0.1	12.2	2,025.4	0.2	0.6	1	1	1
09/05/2020 12:00	0.2	11.8	2,086.7	0.4	0.6	1	1	1
09/05/2020 13:00	0.2	11.8	2,091.8	0.4	0.6	1	1	1
09/05/2020 14:00	0.2	11.8	2,092.9	0.4	0.6	1	1	1
09/05/2020 15:00	0.2	11.7	2,084.3	0.4	0.6	1	1	1
09/05/2020 16:00	0.2	11.7	2,078.5	0.4	0.6	1	1	1
09/05/2020 17:00	0.2	11.7	2,087.3	0.4	0.6	1	1	1
09/05/2020 18:00	0.2	11.8	2,089.9	0.4	0.6	1	1	1
09/05/2020 19:00	0.2	11.8	2,095.1	0.4	0.6	1	1	1
09/05/2020 20:00	0.2	11.8	2,100.4	0.4	0.6	1	1	1
09/05/2020 21:00	0.2	11.8	2,109.4	0.4	0.6	1	1	1
09/05/2020 22:00	0.2	11.8	2,117.7	0.4	0.6	1	1	1
09/05/2020 23:00	0.1	12.0	2,071.7	0.2	0.6	1	1	1
Average/Sum#:	0.2	12.4	1,964.3	0.3	0.6	24 #	24 #	20 #
Minimum:	-0.1	11.7	1,568.3	0.2	0.5	1	1	0
Maximum:	0.4	13.8	2,117.7	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/06/2020 00:00	0.2	12.0	2,093.1	0.4	0.6	1	1	1
09/06/2020 01:00	0.1	12.2	2,049.0	0.2	0.6	1	1	1
09/06/2020 02:00	0.1	12.0	2,098.3	0.2	0.6	1	1	1
09/06/2020 03:00	0.1	11.9	2,113.8	0.2	0.6	1	1	1
09/06/2020 04:00	-0.1	12.3	2,035.4	0.2	0.6	1	1	1
09/06/2020 05:00	-0.1	12.4	2,020.5	0.2	0.6	1	1	1
09/06/2020 06:00	-0.2	12.8	1,965.9	0.1	0.6	1	1	1
09/06/2020 07:00	-0.1	12.2	2,070.9	0.2	0.6	1	1	1
09/06/2020 08:00	0.1	12.0	2,086.9	0.2	0.6	1	1	1
09/06/2020 09:00	0.1	12.0	2,092.4	0.2	0.6	1	1	1
09/06/2020 10:00	0.2	11.9	2,081.9	0.4	0.6	1	1	1
09/06/2020 11:00	0.2	11.9	2,078.0	0.4	0.6	1	1	1
09/06/2020 12:00	0.2	11.8	2,078.3	0.4	0.6	1	1	1
09/06/2020 13:00	0.2	11.8	2,079.9	0.4	0.6	1	1	1
09/06/2020 14:00	0.2	11.8	2,082.4	0.4	0.6	1	1	1
09/06/2020 15:00	0.2	11.8	2,080.6	0.4	0.6	1	1	1
09/06/2020 16:00	0.2	12.0	2,028.6	0.4	0.6	1	1	1
09/06/2020 17:00	0.2	11.8	2,069.5	0.4	0.6	1	1	1
09/06/2020 18:00	0.2	11.9	2,062.2	0.4	0.6	1	1	1
09/06/2020 19:00	0.2	12.0	2,043.3	0.4	0.6	1	1	1
09/06/2020 20:00	0.2	12.1	2,044.6	0.4	0.6	1	1	1
09/06/2020 21:00	0.2	12.0	2,081.7	0.4	0.6	1	1	1
09/06/2020 22:00	0.2	11.9	2,104.0	0.4	0.6	1	1	1
09/06/2020 23:00	0.2	11.8	2,102.0	0.4	0.6	1	1	1
Average/Sum#:	0.1	12.0	2,068.5	0.3	0.6	24 #	24 #	24 #
Minimum:	-0.2	11.8	1,965.9	0.1	0.6	1	1	1
Maximum:	0.2	12.8	2,113.8	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/07/2020 00:00	0.2	11.8	2,102.5	0.4	0.6	1	1	1
09/07/2020 01:00	0.2	11.9	2,111.4	0.4	0.6	1	1	1
09/07/2020 02:00	0.2	11.9	2,111.5	0.4	0.6	1	1	1
09/07/2020 03:00	0.1	12.1	2,059.3	0.2	0.6	1	1	1
09/07/2020 04:00	-0.1	12.4	2,009.9	0.2	0.6	1	1	1
09/07/2020 05:00	0.1	12.3	2,008.6	0.2	0.6	1	1	1
09/07/2020 06:00	0.4	13.9	1,585.5	0.4	0.5	1	1	0
09/07/2020 07:00	0.4	14.0	1,586.7	0.4	0.5	1	1	0
09/07/2020 08:00	0.4	14.0	1,603.4	0.4	0.5	1	1	0
09/07/2020 09:00	0.4	14.0	1,564.5	0.4	0.5	1	1	0
09/07/2020 10:00	0.4	13.9	1,503.8	0.4	0.5	1	1	0
09/07/2020 11:00	0.4	13.9	1,500.8	0.4	0.5	1	1	1
09/07/2020 12:00	-0.2	12.7	1,930.7	0.1	0.6	1	1	1
09/07/2020 13:00	-0.1	13.3	1,727.3	0.1	0.5	1	1	1
09/07/2020 14:00	0.4	13.7	1,656.1	0.4	0.5	1	1	0
09/07/2020 15:00	0.4	13.6	1,695.7	0.4	0.5	1	1	0
09/07/2020 16:00	0.1	13.1	1,754.8	0.2	0.5	1	1	1
09/07/2020 17:00	-0.1	12.3	1,991.8	0.2	0.6	1	1	1
09/07/2020 18:00	-0.1	12.3	1,985.5	0.2	0.6	1	1	1
09/07/2020 19:00	0.1	12.0	2,066.3	0.2	0.6	1	1	1
09/07/2020 20:00	0.1	12.0	2,056.8	0.2	0.6	1	1	1
09/07/2020 21:00	0.1	12.2	2,005.7	0.2	0.6	1	1	1
09/07/2020 22:00	0.1	12.2	2,009.0	0.2	0.6	1	1	1
09/07/2020 23:00	0.1	12.3	2,009.5	0.2	0.6	1	1	1
Average/Sum#:	0.2	12.8	1,859.9	0.3	0.6	24 #	24 #	17 #
Minimum:	-0.2	11.8	1,500.8	0.1	0.5	1	1	0
Maximum:	0.4	14.0	2,111.5	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/08/2020 00:00	-0.1	12.3	2,013.9	0.2	0.6	1	1	1
09/08/2020 01:00	0.1	12.2	2,058.6	0.2	0.6	1	1	1
09/08/2020 02:00	0.1	12.2	2,046.0	0.2	0.6	1	1	1
09/08/2020 03:00	0.1	12.0	2,099.6	0.2	0.6	1	1	1
09/08/2020 04:00	0.1	12.3	2,054.2	0.2	0.6	1	1	1
09/08/2020 05:00	-0.1	12.4	2,022.9	0.2	0.6	1	1	1
09/08/2020 06:00	0.4	13.9	1,627.5	0.4	0.5	1	1	0
09/08/2020 07:00	0.4	14.0	1,629.4	0.4	0.5	1	1	0
09/08/2020 08:00	0.5	14.0	1,506.0	0.5	0.5	1	1	0
09/08/2020 09:00	0.5	13.9	1,624.4	0.5	0.5	1	1	0
09/08/2020 10:00	0.5	14.0	1,567.9	0.5	0.5	1	1	0
09/08/2020 11:00	0.4	13.9	1,679.8	0.4	0.5	1	1	0
09/08/2020 12:00	0.2	13.9	1,531.8	0.2	0.5	1	1	1
09/08/2020 13:00	-0.2	12.4	2,040.3	0.1	0.6	1	1	1
09/08/2020 14:00	0.1	12.0	2,116.2	0.2	0.6	1	1	1
09/08/2020 15:00	0.1	11.9	2,119.9	0.2	0.6	1	1	1
09/08/2020 16:00	0.1	11.9	2,121.3	0.2	0.6	1	1	1
09/08/2020 17:00	0.2	11.9	2,127.9	0.4	0.6	1	1	1
09/08/2020 18:00	0.2	11.9	2,133.9	0.4	0.6	1	1	1
09/08/2020 19:00	0.1	12.2	2,075.5	0.2	0.6	1	1	1
09/08/2020 20:00	0.1	12.3	2,061.0	0.2	0.6	1	1	1
09/08/2020 21:00	0.1	12.3	2,069.6	0.2	0.6	1	1	1
09/08/2020 22:00	-0.1	12.6	2,016.3	0.1	0.6	1	1	1
09/08/2020 23:00	-0.1	12.5	2,019.1	0.1	0.6	1	1	1
Average/Sum#:	0.2	12.7	1,931.8	0.3	0.6	24 #	24 #	18 #
Minimum:	-0.2	11.9	1,506.0	0.1	0.5	1	1	0
Maximum:	0.5	14.0	2,133.9	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/09/2020 00:00	0.2	12.6	1,928.1	0.4	0.6	1	1	1
09/09/2020 01:00	0.5	13.9	1,662.9	0.5	0.5	1	1	0
09/09/2020 02:00	0.5	14.1	1,392.9	0.5	0.4	1	1	0
09/09/2020 03:00	0.5	14.0	1,656.6	0.5	0.5	1	1	0
09/09/2020 04:00	0.5	14.0	1,498.8	0.5	0.4	1	1	0
09/09/2020 05:00	0.5	14.0	1,572.3	0.5	0.5	1	1	0
09/09/2020 06:00	0.5	14.0	1,574.7	0.5	0.5	1	1	0
09/09/2020 07:00	0.5	14.0	1,551.0	0.5	0.5	1	1	0
09/09/2020 08:00	0.5	14.0	1,507.7	0.5	0.5	1	1	0
09/09/2020 09:00	0.5	14.1	1,430.9	0.5	0.4	1	1	0
09/09/2020 10:00	0.5	14.1	1,418.0	0.5	0.4	1	1	0
09/09/2020 11:00	0.5	14.0	1,490.1	0.5	0.4	1	1	0
09/09/2020 12:00	0.4	14.0	1,512.7	0.4	0.5	1	1	1
09/09/2020 13:00	-0.2	12.5	2,054.2	0.1	0.6	1	1	1
09/09/2020 14:00	-0.1	12.5	2,024.4	0.1	0.6	1	1	1
09/09/2020 15:00	-0.1	12.6	1,999.6	0.1	0.6	1	1	1
09/09/2020 16:00	-0.1	12.6	1,991.4	0.1	0.6	1	1	1
09/09/2020 17:00	-0.1	12.6	1,989.7	0.1	0.6	1	1	1
09/09/2020 18:00	-0.1	12.7	1,989.7	0.1	0.6	1	1	1
09/09/2020 19:00	-0.1	12.7	1,992.4	0.1	0.6	1	1	1
09/09/2020 20:00	-0.1	12.7	1,995.2	0.1	0.6	1	1	1
09/09/2020 21:00	-0.1	12.8	1,990.1	0.1	0.6	1	1	1
09/09/2020 22:00	-0.1	12.8	1,990.6	0.1	0.6	1	1	1
09/09/2020 23:00	-0.1	13.0	1,919.1	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.3	1,755.5	0.3	0.5	24 #	24 #	13 #
Minimum:	-0.2	12.5	1,392.9	0.1	0.4	1	1	0
Maximum:	0.5	14.1	2,054.2	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/10/2020 00:00	0.4	13.9	1,511.8	0.4	0.5	1	1	0
09/10/2020 01:00	0.4	13.9	1,485.8	0.4	0.4	1	1	0
09/10/2020 02:00	0.5	14.0	1,308.9	0.5	0.4	1	1	0
09/10/2020 03:00	0.4	13.9	1,587.5	0.4	0.5	1	1	0
09/10/2020 04:00	0.4	13.9	1,557.7	0.4	0.5	1	1	0
09/10/2020 05:00	0.4	13.9	1,551.4	0.4	0.5	1	1	0
09/10/2020 06:00	0.4	13.9	1,600.0	0.4	0.5	1	1	0
09/10/2020 07:00	0.4	13.9	1,637.2	0.4	0.5	1	1	0
09/10/2020 08:00	0.4	13.9	1,672.9	0.4	0.5	1	1	0
09/10/2020 09:00	0.4	14.0	1,617.4	0.4	0.5	1	1	0
09/10/2020 10:00	0.4	13.9	1,673.4	0.4	0.5	1	1	0
09/10/2020 11:00	0.4	14.0	1,468.0	0.4	0.4	1	1	0
09/10/2020 12:00	0.4	14.0	1,444.0	0.4	0.4	1	1	0
09/10/2020 13:00	0.4	14.0	1,453.9	0.4	0.4	1	1	0
09/10/2020 14:00	0.4	13.9	1,596.3	0.4	0.5	1	1	0
09/10/2020 15:00	0.2	13.9	1,565.1	0.2	0.5	1	1	1
09/10/2020 16:00	-0.2	12.4	2,032.2	0.1	0.6	1	1	1
09/10/2020 17:00	-0.1	12.5	2,014.2	0.1	0.6	1	1	1
09/10/2020 18:00	-0.1	12.6	1,992.7	0.1	0.6	1	1	1
09/10/2020 19:00	-0.1	12.6	1,990.1	0.1	0.6	1	1	1
09/10/2020 20:00	-0.1	12.7	1,987.7	0.1	0.6	1	1	1
09/10/2020 21:00	-0.1	12.8	1,984.7	0.1	0.6	1	1	1
09/10/2020 22:00	-0.1	12.7	1,982.2	0.1	0.6	1	1	1
09/10/2020 23:00	-0.1	13.2	1,831.4	0.1	0.5	1	1	1
Average/Sum#:	0.2	13.5	1,689.4	0.3	0.5	24 #	24 #	9 #
Minimum:	-0.2	12.4	1,308.9	0.1	0.4	1	1	0
Maximum:	0.5	14.0	2,032.2	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/11/2020 00:00	0.4	13.9	1,409.2	0.4	0.4	1	1	0
09/11/2020 01:00	0.4	13.9	1,287.7	0.4	0.4	1	1	0
09/11/2020 02:00	0.4	13.9	1,286.4	0.4	0.4	1	1	0
09/11/2020 03:00	0.4	13.9	1,285.5	0.4	0.4	1	1	0
09/11/2020 04:00	0.4	13.9	1,286.7	0.4	0.4	1	1	0
09/11/2020 05:00	0.4	13.9	1,479.1	0.4	0.4	1	1	0
09/11/2020 06:00	0.4	14.0	1,292.3	0.4	0.4	1	1	0
09/11/2020 07:00	0.4	14.0	1,318.9	0.4	0.4	1	1	0
09/11/2020 08:00	0.4	14.0	1,342.0	0.4	0.4	1	1	0
09/11/2020 09:00	0.4	13.9	1,566.1	0.4	0.5	1	1	0
09/11/2020 10:00	0.4	13.9	1,548.5	0.4	0.5	1	1	0
09/11/2020 11:00	0.4	13.9	1,534.6	0.4	0.5	1	1	0
09/11/2020 12:00	0.4	13.9	1,581.7	0.4	0.5	1	1	0
09/11/2020 13:00	0.4	14.0	1,295.7	0.4	0.4	1	1	0
09/11/2020 14:00	0.4	14.0	1,299.3	0.4	0.4	1	1	0
09/11/2020 15:00	0.4	14.0	1,334.2	0.4	0.4	1	1	0
09/11/2020 16:00	0.3	13.8	1,646.7	0.4	0.5	1	1	0
09/11/2020 17:00	0.4	13.8	1,635.4	0.4	0.5	1	1	0
09/11/2020 18:00	-0.1	13.3	1,786.5	0.1	0.5	1	1	1
09/11/2020 19:00	-0.1	12.4	2,023.3	0.2	0.6	1	1	1
09/11/2020 20:00	-0.1	12.6	1,994.5	0.1	0.6	1	1	1
09/11/2020 21:00	-0.2	12.8	1,954.8	0.1	0.6	1	1	1
09/11/2020 22:00	0.2	13.6	1,477.3	0.4	0.4	1	1	1
09/11/2020 23:00	0.0	16.5	368.3	0.0	0.1	1	0	0
Average/Sum#:	0.3	13.8	1,459.8	0.3	0.4	24 #	23 #	5 #
Minimum:	-0.2	12.4	368.3	0.0	0.1	1	0	0
Maximum:	0.4	16.5	2,023.3	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 17:00	0.0	17.5	450.7	0.0	0.1	1	0	0
09/12/2020 18:00	0.0	17.1	512.4	0.0	0.2	1	0	0
09/12/2020 19:00	0.0	15.5	927.2	0.0	0.3	1	0	0
09/12/2020 20:00	0.4	13.9	1,478.5	0.4	0.4	1	1	0
09/12/2020 21:00	0.4	14.0	1,493.7	0.4	0.4	1	1	0
09/12/2020 22:00	0.4	13.9	1,456.6	0.4	0.4	1	1	0
09/12/2020 23:00	0.4	13.9	1,354.2	0.4	0.4	1	1	0
Average/Sum#:	0.2	15.1	1,096.2	0.2	0.3	7 #	4 #	0 #
Minimum:	0.0	13.9	450.7	0.0	0.1	0	0	0
Maximum:	0.4	17.5	1,493.7	0.4	0.4	1	1	0
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/13/2020 00:00	0.4	13.9	1,351.9	0.4	0.4	1	1	0
09/13/2020 01:00	0.4	14.0	1,334.7	0.4	0.4	1	1	0
09/13/2020 02:00	0.0	16.8	311.5	0.0	0.1	1	0	0
09/13/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 17:00	0.0	17.4	461.3	0.0	0.1	1	0	0
09/13/2020 18:00	0.0	17.1	514.6	0.0	0.2	1	0	0
09/13/2020 19:00	0.0	15.1	1,019.4	0.0	0.3	1	0	0
09/13/2020 20:00	0.4	13.9	1,474.7	0.4	0.4	1	1	0
09/13/2020 21:00	0.4	13.9	1,382.1	0.4	0.4	1	1	0
09/13/2020 22:00	0.4	13.9	1,377.7	0.4	0.4	1	1	0
09/13/2020 23:00	0.4	13.9	1,342.7	0.4	0.4	1	1	0
Average/Sum#:	0.2	15.0	1,057.1	0.2	0.3	10 #	6 #	0 #
Minimum:	0.0	13.9	311.5	0.0	0.1	0	0	0
Maximum:	0.4	17.4	1,474.7	0.4	0.4	1	1	0
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/14/2020 00:00	0.4	13.9	1,341.7	0.4	0.4	1	1	0
09/14/2020 01:00	0.4	13.9	1,326.0	0.4	0.4	1	1	0
09/14/2020 02:00	0.0	16.8	309.0	0.0	0.1	1	0	0
09/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 09:00	0.0	19.4	181.0	0.0	0.1	1	0	0
09/14/2020 10:00	0.0	16.3	627.1	0.0	0.2	1	0	0
09/14/2020 11:00	0.0	14.1	1,326.1	0.0	0.4	1	0	0
09/14/2020 12:00	0.4	14.0	1,346.6	0.4	0.4	1	1	0
09/14/2020 13:00	0.4	13.9	1,599.4	0.4	0.5	1	1	0
09/14/2020 14:00	0.4	14.0	1,524.2	0.4	0.5	1	1	0
09/14/2020 15:00	0.4	13.9	1,580.1	0.4	0.5	1	1	0
09/14/2020 16:00	0.1	13.2	1,785.1	0.2	0.5	1	1	1
09/14/2020 17:00	0.2	12.0	2,103.7	0.4	0.6	1	1	1
09/14/2020 18:00	0.2	12.0	2,106.2	0.4	0.6	1	1	1
09/14/2020 19:00	0.2	12.1	2,085.4	0.4	0.6	1	1	1
09/14/2020 20:00	0.2	12.0	2,098.9	0.4	0.6	1	1	1
09/14/2020 21:00	0.1	12.4	2,012.9	0.2	0.6	1	1	1
09/14/2020 22:00	0.1	12.8	1,947.3	0.2	0.6	1	1	1
09/14/2020 23:00	0.1	12.8	1,942.6	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.9	1,513.5	0.3	0.5	18 #	14 #	8 #
Minimum:	0.0	12.0	181.0	0.0	0.1	0	0	0
Maximum:	0.4	19.4	2,106.2	0.4	0.6	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/15/2020 00:00	0.4	13.9	1,442.8	0.4	0.4	1	1	0
09/15/2020 01:00	0.4	13.9	1,325.8	0.4	0.4	1	1	0
09/15/2020 02:00	0.4	14.0	1,283.9	0.4	0.4	1	1	0
09/15/2020 03:00	0.4	14.0	1,285.0	0.4	0.4	1	1	0
09/15/2020 04:00	0.4	14.0	1,311.6	0.4	0.4	1	1	0
09/15/2020 05:00	0.4	13.9	1,565.6	0.4	0.5	1	1	0
09/15/2020 06:00	0.4	13.9	1,605.4	0.4	0.5	1	1	0
09/15/2020 07:00	0.4	13.9	1,427.6	0.4	0.4	1	1	0
09/15/2020 08:00	0.4	13.9	1,417.1	0.4	0.4	1	1	0
09/15/2020 09:00	0.4	14.0	1,289.6	0.4	0.4	1	1	0
09/15/2020 10:00	0.4	14.0	1,585.9	0.4	0.5	1	1	0
09/15/2020 11:00	0.4	14.0	1,611.7	0.4	0.5	1	1	0
09/15/2020 12:00	0.4	14.0	1,603.2	0.4	0.5	1	1	0
09/15/2020 13:00	0.2	13.8	1,662.7	0.4	0.5	1	1	1
09/15/2020 14:00	0.1	12.2	2,067.7	0.2	0.6	1	1	1
09/15/2020 15:00	0.2	12.1	2,087.9	0.4	0.6	1	1	1
09/15/2020 16:00	0.1	12.4	2,028.3	0.2	0.6	1	1	1
09/15/2020 17:00	0.1	12.4	2,021.6	0.2	0.6	1	1	1
09/15/2020 18:00	0.1	12.4	2,010.5	0.2	0.6	1	1	1
09/15/2020 19:00	0.1	12.4	2,026.9	0.2	0.6	1	1	1
09/15/2020 20:00	0.2	12.0	2,104.4	0.4	0.6	1	1	1
09/15/2020 21:00	0.1	12.3	2,046.6	0.2	0.6	1	1	1
09/15/2020 22:00	0.0	14.1	1,224.9	0.0	0.4	1	0	1
09/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.3	13.4	1,653.8	0.3	0.5	23 #	22 #	10 #
Minimum:	0.0	12.0	1,224.9	0.0	0.4	0	0	0
Maximum:	0.4	14.1	2,104.4	0.4	0.6	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 11:00	0.0	17.3	492.4	0.0	0.1	1	0	0
09/16/2020 12:00	0.0	14.4	1,209.8	0.0	0.4	1	0	0
09/16/2020 13:00	0.4	13.8	1,665.4	0.4	0.5	1	1	0
09/16/2020 14:00	0.4	13.8	1,665.2	0.4	0.5	1	1	1
09/16/2020 15:00	0.1	12.4	2,040.2	0.2	0.6	1	1	1
09/16/2020 16:00	0.2	12.0	2,089.5	0.4	0.6	1	1	1
09/16/2020 17:00	0.4	11.9	2,121.2	0.5	0.6	1	1	1
09/16/2020 18:00	0.4	12.0	2,108.5	0.5	0.6	1	1	1
09/16/2020 19:00	0.1	12.5	1,998.9	0.2	0.6	1	1	1
09/16/2020 20:00	0.1	12.4	2,015.2	0.2	0.6	1	1	1
09/16/2020 21:00	0.1	12.5	2,008.7	0.2	0.6	1	1	1
09/16/2020 22:00	0.1	12.6	1,991.1	0.2	0.6	1	1	1
09/16/2020 23:00	0.1	12.8	1,932.9	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.1	1,795.3	0.3	0.5	13 #	11 #	10 #
Minimum:	0.0	11.9	492.4	0.0	0.1	0	0	0
Maximum:	0.4	17.3	2,121.2	0.5	0.6	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/17/2020 00:00	0.5	13.9	1,401.0	0.5	0.4	1	1	0
09/17/2020 01:00	0.5	13.9	1,307.6	0.5	0.4	1	1	0
09/17/2020 02:00	0.5	13.9	1,288.0	0.5	0.4	1	1	0
09/17/2020 03:00	0.4	13.9	1,288.8	0.4	0.4	1	1	0
09/17/2020 04:00	0.4	13.9	1,458.7	0.4	0.4	1	1	0
09/17/2020 05:00	0.4	13.9	1,568.9	0.4	0.5	1	1	0
09/17/2020 06:00	0.4	13.9	1,535.0	0.4	0.5	1	1	0
09/17/2020 07:00	0.4	13.8	1,613.9	0.4	0.5	1	1	0
09/17/2020 08:00	0.4	13.8	1,587.1	0.4	0.5	1	1	0
09/17/2020 09:00	0.4	13.9	1,601.9	0.4	0.5	1	1	0
09/17/2020 10:00	0.4	13.9	1,416.0	0.4	0.4	1	1	0
09/17/2020 11:00	0.4	13.9	1,423.0	0.4	0.4	1	1	0
09/17/2020 12:00	0.2	13.9	1,616.6	0.2	0.5	1	1	1
09/17/2020 13:00	0.1	12.2	2,068.0	0.2	0.6	1	1	1
09/17/2020 14:00	0.2	11.8	2,118.9	0.4	0.6	1	1	1
09/17/2020 15:00	0.4	11.8	2,114.4	0.5	0.6	1	1	1
09/17/2020 16:00	0.4	11.8	2,109.3	0.5	0.6	1	1	1
09/17/2020 17:00	0.2	12.0	2,077.6	0.4	0.6	1	1	1
09/17/2020 18:00	0.2	12.3	2,022.5	0.4	0.6	1	1	1
09/17/2020 19:00	0.2	12.1	2,079.4	0.4	0.6	1	1	1
09/17/2020 20:00	0.1	12.4	2,023.4	0.2	0.6	1	1	1
09/17/2020 21:00	0.1	12.4	2,033.9	0.2	0.6	1	1	1
09/17/2020 22:00	0.2	12.2	2,071.3	0.4	0.6	1	1	1
09/17/2020 23:00	0.0	12.6	1,769.1	0.0	0.5	1	0	1
Average/Sum#:	0.3	13.1	1,733.1	0.4	0.5	24 #	23 #	12 #
Minimum:	0.0	11.8	1,288.0	0.0	0.4	1	0	0
Maximum:	0.5	13.9	2,118.9	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/18/2020 00:00	0.0	19.0	0.2	0.0	0.0	1	0	0
09/18/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 10:00	0.0	18.5	329.7	0.0	0.1	1	0	0
09/18/2020 11:00	0.0	15.5	834.3	0.0	0.3	1	0	0
09/18/2020 12:00	0.4	13.8	1,606.4	0.4	0.5	1	1	0
09/18/2020 13:00	0.4	13.8	1,530.2	0.4	0.5	1	1	1
09/18/2020 14:00	-0.1	12.5	2,003.3	0.1	0.6	1	1	1
09/18/2020 15:00	0.1	12.3	2,043.1	0.2	0.6	1	1	1
09/18/2020 16:00	0.2	12.4	2,030.4	0.4	0.6	1	1	1
09/18/2020 17:00	0.1	12.5	2,012.8	0.2	0.6	1	1	1
09/18/2020 18:00	0.1	12.5	2,008.6	0.2	0.6	1	1	1
09/18/2020 19:00	0.1	12.6	1,999.6	0.2	0.6	1	1	1
09/18/2020 20:00	0.1	12.6	1,996.1	0.2	0.6	1	1	1
09/18/2020 21:00	0.1	12.6	1,993.1	0.2	0.6	1	1	1
09/18/2020 22:00	0.0	13.7	1,457.5	0.0	0.4	1	0	1
09/18/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.1	13.9	1,560.4	0.2	0.5	14 #	10 #	10 #
Minimum:	-0.1	12.3	0.2	0.0	0.0	0	0	0
Maximum:	0.4	19.0	2,043.1	0.4	0.6	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/19/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 13:00	0.0	17.9	411.0	0.0	0.1	1	0	0
09/19/2020 14:00	0.0	15.5	857.3	0.0	0.3	1	0	0
09/19/2020 15:00	0.5	13.9	1,530.7	0.5	0.5	1	1	1
09/19/2020 16:00	0.1	12.5	2,012.4	0.2	0.6	1	1	1
09/19/2020 17:00	0.2	11.9	2,132.9	0.4	0.6	1	1	1
09/19/2020 18:00	0.2	12.1	2,113.5	0.4	0.6	1	1	1
09/19/2020 19:00	0.2	12.1	2,109.2	0.4	0.6	1	1	1
09/19/2020 20:00	0.2	12.1	2,101.4	0.4	0.6	1	1	1
09/19/2020 21:00	0.1	12.2	2,069.2	0.2	0.6	1	1	1
09/19/2020 22:00	0.1	12.2	2,071.7	0.2	0.6	1	1	1
09/19/2020 23:00	-0.1	12.8	1,954.3	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.2	1,760.3	0.3	0.5	11 #	9 #	9 #
Minimum:	-0.1	11.9	411.0	0.0	0.1	0	0	0
Maximum:	0.5	17.9	2,132.9	0.5	0.6	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/20/2020 00:00	-0.1	12.9	1,941.4	0.1	0.6	1	1	1
09/20/2020 01:00	-0.1	12.9	1,945.9	0.1	0.6	1	1	1
09/20/2020 02:00	-0.1	12.9	1,947.9	0.1	0.6	1	1	1
09/20/2020 03:00	-0.1	12.9	1,944.9	0.1	0.6	1	1	1
09/20/2020 04:00	-0.1	13.0	1,935.4	0.1	0.6	1	1	1
09/20/2020 05:00	0.1	13.0	1,901.8	0.2	0.6	1	1	1
09/20/2020 06:00	0.0	0.0	666.9	0.0	0.2	1	0	0
09/20/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2020 14:00	0.0	17.7	433.1	0.0	0.1	1	0	0
09/20/2020 15:00	0.0	15.3	940.3	0.0	0.3	1	0	0
09/20/2020 16:00	0.4	13.8	1,583.1	0.4	0.5	1	1	0
09/20/2020 17:00	-0.1	12.4	2,017.5	0.2	0.6	1	1	1
09/20/2020 18:00	0.1	11.8	2,137.7	0.2	0.6	1	1	1
09/20/2020 19:00	0.2	11.8	2,134.1	0.4	0.6	1	1	1
09/20/2020 20:00	0.2	12.0	2,104.1	0.4	0.6	1	1	1
09/20/2020 21:00	0.1	12.4	1,981.5	0.2	0.6	1	1	1
09/20/2020 22:00	0.0	15.6	632.2	0.0	0.2	1	0	0
09/20/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	13.4	1,640.5	0.2	0.5	16 #	12 #	11 #
Minimum:	-0.1	11.8	433.1	0.0	0.1	0	0	0
Maximum:	0.4	17.7	2,137.7	0.4	0.6	1	1	1
%SI	37.50	37.50	33.33	37.50	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/21/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 08:00	0.0	18.0	391.1	0.0	0.1	1	0	0
09/21/2020 09:00	0.0	17.1	517.4	0.0	0.2	1	0	0
09/21/2020 10:00	0.0	15.5	870.6	0.0	0.3	1	0	0
09/21/2020 11:00	0.5	13.9	1,486.4	0.5	0.4	1	1	0
09/21/2020 12:00	0.4	13.8	1,664.1	0.4	0.5	1	1	0
09/21/2020 13:00	0.4	13.9	1,575.1	0.4	0.5	1	1	0
09/21/2020 14:00	0.4	13.9	1,458.3	0.4	0.4	1	1	0
09/21/2020 15:00	0.4	13.9	1,510.1	0.4	0.5	1	1	1
09/21/2020 16:00	-0.1	12.6	1,957.1	0.1	0.6	1	1	1
09/21/2020 17:00	0.1	12.4	1,984.2	0.2	0.6	1	1	1
09/21/2020 18:00	-0.1	12.6	1,965.9	0.1	0.6	1	1	1
09/21/2020 19:00	0.1	12.5	2,019.7	0.2	0.6	1	1	1
09/21/2020 20:00	0.1	12.2	2,059.0	0.2	0.6	1	1	1
09/21/2020 21:00	0.2	12.3	2,000.9	0.4	0.6	1	1	1
09/21/2020 22:00	0.0	15.6	628.4	0.0	0.2	1	0	0
09/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.2	14.0	1,472.6	0.2	0.4	15 #	11 #	7 #
Minimum:	-0.1	12.2	391.1	0.0	0.1	0	0	0
Maximum:	0.5	18.0	2,059.0	0.5	0.6	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 08:00	0.0	18.0	393.7	0.0	0.1	1	0	0
09/22/2020 09:00	0.0	17.1	521.6	0.0	0.2	1	0	0
09/22/2020 10:00	0.0	15.5	855.1	0.0	0.3	1	0	0
09/22/2020 11:00	0.5	13.9	1,500.8	0.5	0.5	1	1	0
09/22/2020 12:00	-0.1	13.2	1,817.2	0.1	0.5	1	1	1
09/22/2020 13:00	-0.2	12.6	1,947.6	0.1	0.6	1	1	1
09/22/2020 14:00	0.4	13.9	1,540.5	0.4	0.5	1	1	0
09/22/2020 15:00	0.4	14.0	1,449.5	0.4	0.4	1	1	0
09/22/2020 16:00	0.4	13.9	1,512.1	0.4	0.5	1	1	1
09/22/2020 17:00	0.1	12.8	1,946.1	0.2	0.6	1	1	1
09/22/2020 18:00	0.1	12.9	1,936.3	0.2	0.6	1	1	1
09/22/2020 19:00	0.1	12.9	1,933.3	0.2	0.6	1	1	1
09/22/2020 20:00	0.1	12.9	1,935.9	0.2	0.6	1	1	1
09/22/2020 21:00	0.0	14.4	1,179.1	0.0	0.4	1	0	1
09/22/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.1	14.1	1,462.1	0.2	0.5	14 #	10 #	8 #
Minimum:	-0.2	12.6	393.7	0.0	0.1	0	0	0
Maximum:	0.5	18.0	1,947.6	0.5	0.6	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/23/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 08:00	0.0	17.8	431.3	0.0	0.1	1	0	0
09/23/2020 09:00	0.0	17.1	519.6	0.0	0.2	1	0	0
09/23/2020 10:00	0.0	15.3	909.8	0.0	0.3	1	0	0
09/23/2020 11:00	0.5	14.0	1,375.5	0.5	0.4	1	1	0
09/23/2020 12:00	0.4	14.0	1,456.4	0.4	0.4	1	1	0
09/23/2020 13:00	0.4	14.0	1,526.6	0.4	0.5	1	1	0
09/23/2020 14:00	0.4	14.0	1,459.5	0.4	0.4	1	1	0
09/23/2020 15:00	0.4	13.9	1,540.0	0.4	0.5	1	1	1
09/23/2020 16:00	0.1	12.5	1,992.2	0.2	0.6	1	1	1
09/23/2020 17:00	0.1	12.5	1,988.8	0.2	0.6	1	1	1
09/23/2020 18:00	-0.1	12.7	1,959.3	0.1	0.6	1	1	1
09/23/2020 19:00	-0.1	12.5	2,023.9	0.1	0.6	1	1	1
09/23/2020 20:00	-0.1	12.9	1,916.5	0.1	0.6	1	1	1
09/23/2020 21:00	0.0	15.7	610.9	0.0	0.2	1	0	0
09/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.1	14.2	1,407.9	0.2	0.4	14 #	10 #	6 #
Minimum:	-0.1	12.5	431.3	0.0	0.1	0	0	0
Maximum:	0.5	17.8	2,023.9	0.5	0.6	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 13:00	0.0	17.6	445.5	0.0	0.1	1	0	0
09/24/2020 14:00	0.0	14.9	1,026.7	0.0	0.3	1	0	0
09/24/2020 15:00	0.4	13.8	1,651.3	0.4	0.5	1	1	0
09/24/2020 16:00	0.2	13.4	1,757.8	0.4	0.5	1	1	1
09/24/2020 17:00	0.1	12.1	2,081.8	0.2	0.6	1	1	1
09/24/2020 18:00	0.1	12.2	2,071.0	0.2	0.6	1	1	1
09/24/2020 19:00	0.1	12.3	2,061.5	0.2	0.6	1	1	1
09/24/2020 20:00	0.0	14.2	1,199.0	0.0	0.4	1	0	1
09/24/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.1	13.8	1,536.8	0.2	0.5	8 #	5 #	5 #
Minimum:	0.0	12.1	445.5	0.0	0.1	0	0	0
Maximum:	0.4	17.6	2,081.8	0.4	0.6	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 08:00	0.0	21.0	34.5	0.0	0.0	1	0	0
09/27/2020 09:00	0.0	17.2	502.0	0.0	0.2	1	0	0
09/27/2020 10:00	0.0	16.2	706.9	0.0	0.2	1	0	0
09/27/2020 11:00	0.5	14.1	1,404.1	0.5	0.4	1	1	0
09/27/2020 12:00	0.5	14.1	1,374.0	0.5	0.4	1	1	0
09/27/2020 13:00	0.5	14.0	1,585.8	0.5	0.5	1	1	0
09/27/2020 14:00	0.5	13.9	1,601.5	0.5	0.5	1	1	0
09/27/2020 15:00	0.4	13.9	1,622.0	0.4	0.5	1	1	0
09/27/2020 16:00	0.2	13.7	1,602.1	0.4	0.5	1	1	1
09/27/2020 17:00	-0.1	12.3	2,074.7	0.2	0.6	1	1	1
09/27/2020 18:00	0.1	12.1	2,114.4	0.2	0.6	1	1	1
09/27/2020 19:00	0.1	12.1	2,122.4	0.2	0.6	1	1	1
09/27/2020 20:00	0.1	12.1	2,121.0	0.2	0.6	1	1	1
09/27/2020 21:00	0.1	12.1	2,124.8	0.2	0.6	1	1	1
09/27/2020 22:00	0.0	13.9	1,273.5	0.0	0.4	1	0	1
09/27/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.2	14.2	1,484.2	0.3	0.4	15 #	11 #	7 #
Minimum:	-0.1	12.1	34.5	0.0	0.0	0	0	0
Maximum:	0.5	21.0	2,124.8	0.5	0.6	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/28/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 10:00	0.0	17.6	451.6	0.0	0.1	1	0	0
09/28/2020 11:00	0.0	15.1	979.1	0.0	0.3	1	0	0
09/28/2020 12:00	0.4	13.8	1,716.2	0.4	0.5	1	1	0
09/28/2020 13:00	0.1	13.7	1,657.2	0.2	0.5	1	1	1
09/28/2020 14:00	-0.1	12.2	2,089.4	0.2	0.6	1	1	1
09/28/2020 15:00	0.2	11.7	2,170.6	0.4	0.7	1	1	1
09/28/2020 16:00	0.2	11.7	2,167.8	0.4	0.7	1	1	1
09/28/2020 17:00	0.2	11.9	2,152.6	0.4	0.6	1	1	1
09/28/2020 18:00	0.2	11.9	2,146.5	0.4	0.6	1	1	1
09/28/2020 19:00	0.1	12.1	2,096.1	0.2	0.6	1	1	1
09/28/2020 20:00	0.1	12.1	2,105.7	0.2	0.6	1	1	1
09/28/2020 21:00	0.1	12.3	2,076.1	0.2	0.6	1	1	1
09/28/2020 22:00	0.0	14.1	1,250.6	0.0	0.4	1	0	1
09/28/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.1	13.1	1,773.8	0.2	0.5	13 #	10 #	10 #
Minimum:	-0.1	11.7	451.6	0.0	0.1	0	0	0
Maximum:	0.4	17.6	2,170.6	0.4	0.7	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 10:00	0.0	17.5	459.6	0.0	0.1	1	0	0
09/29/2020 11:00	0.0	15.1	1,006.2	0.0	0.3	1	0	0
09/29/2020 12:00	0.4	13.9	1,704.3	0.4	0.5	1	1	0
09/29/2020 13:00	0.1	13.4	1,762.3	0.2	0.5	1	1	1
09/29/2020 14:00	-0.1	12.2	2,089.8	0.2	0.6	1	1	1
09/29/2020 15:00	0.1	12.1	2,105.1	0.2	0.6	1	1	1
09/29/2020 16:00	0.1	12.0	2,127.0	0.2	0.6	1	1	1
09/29/2020 17:00	0.2	12.1	2,126.7	0.4	0.6	1	1	1
09/29/2020 18:00	0.1	12.2	2,091.6	0.2	0.6	1	1	1
09/29/2020 19:00	0.1	12.1	2,119.8	0.2	0.6	1	1	1
09/29/2020 20:00	0.1	12.2	2,104.9	0.2	0.6	1	1	1
09/29/2020 21:00	0.1	12.3	2,091.1	0.2	0.6	1	1	1
09/29/2020 22:00	0.1	12.4	2,068.3	0.2	0.6	1	1	1
09/29/2020 23:00	0.1	12.5	2,062.3	0.2	0.6	1	1	1
Average/Sum#:	0.1	13.0	1,851.4	0.2	0.5	14 #	12 #	11 #
Minimum:	-0.1	12.0	459.6	0.0	0.1	0	0	0
Maximum:	0.4	17.5	2,127.0	0.4	0.6	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/30/2020 00:00	0.1	12.8	1,987.6	0.2	0.6	1	1	1
09/30/2020 01:00	0.4	13.9	1,639.6	0.4	0.5	1	1	0
09/30/2020 02:00	0.4	13.9	1,676.0	0.4	0.5	1	1	0
09/30/2020 03:00	0.4	13.9	1,656.5	0.4	0.5	1	1	0
09/30/2020 04:00	0.1	13.7	1,699.1	0.2	0.5	1	1	1
09/30/2020 05:00	-0.1	12.7	2,024.7	0.1	0.6	1	1	1
09/30/2020 06:00	-0.1	12.7	2,016.1	0.1	0.6	1	1	1
09/30/2020 07:00	0.4	13.9	1,645.5	0.4	0.5	1	1	0
09/30/2020 08:00	0.4	13.9	1,677.7	0.4	0.5	1	1	0
09/30/2020 09:00	0.4	13.9	1,682.6	0.4	0.5	1	1	0
09/30/2020 10:00	0.1	13.6	1,675.8	0.2	0.5	1	1	1
09/30/2020 11:00	-0.1	12.3	2,076.6	0.2	0.6	1	1	1
09/30/2020 12:00	0.1	12.0	2,129.2	0.2	0.6	1	1	1
09/30/2020 13:00	0.2	11.8	2,166.7	0.4	0.7	1	1	1
09/30/2020 14:00	0.2	11.9	2,126.2	0.4	0.6	1	1	1
09/30/2020 15:00	0.2	11.9	2,135.5	0.4	0.6	1	1	1
09/30/2020 16:00	0.2	11.9	2,124.4	0.4	0.6	1	1	1
09/30/2020 17:00	0.1	12.1	2,097.4	0.2	0.6	1	1	1
09/30/2020 18:00	0.1	12.0	2,119.5	0.2	0.6	1	1	1
09/30/2020 19:00	0.2	11.9	2,148.3	0.4	0.6	1	1	1
09/30/2020 20:00	0.2	12.0	2,130.3	0.4	0.6	1	1	1
09/30/2020 21:00	0.1	12.1	2,110.9	0.2	0.6	1	1	1
09/30/2020 22:00	0.1	12.2	2,096.2	0.2	0.6	1	1	1
09/30/2020 23:00	-0.1	12.7	1,959.2	0.1	0.6	1	1	1
Average/Sum#:	0.2	12.7	1,950.1	0.3	0.6	24 #	24 #	18 #
Minimum:	-0.1	11.8	1,639.6	0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,166.7	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Excess Emission Report

CT1 - VOC Lb 1-Day Block Average



From: 07/01/2020 00:00 To: 09/30/2020 23:59
Generated: 10/06/2020 08:37

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA

Tag Name: CT1_VOC_Lb_1D

Total Operating Time: 85.00 Day(s)

No Exclusions Allowed

Non-Operating Time: 7.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	85.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 - VOC LbPerHr 1-Hour Block Average

From: 07/01/2020 00:00 To: 09/30/2020 23:59
Generated: 10/06/2020 08:38

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA

Tag Name: CT1_VOC_LbPerHr_1H

Total Operating Time: 1,836.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 372.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,836.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 - VOC Ppmvdc 1-Hour Block Average

From: 07/01/2020 00:00 To: 09/30/2020 23:59
Generated: 10/06/2020 08:39

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA

Tag Name: CT1_VOC_Ppmvdc_1H

Total Operating Time: 1,836.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 372.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,836.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT2 -VOC Lb 1-Day Block Average

From: 07/01/2020 00:00 To: 09/30/2020 23:59
Generated: 10/06/2020 08:40

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA



Tag Name: CT2_VOC_Lb_1D

Total Operating Time: 87.00 Day(s)

No Exclusions Allowed

Non-Operating Time: 5.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	87.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT2 - VOC LbPerHr 1-Hour Block Average

From: 07/01/2020 00:00 To: 09/30/2020 23:59
Generated: 10/06/2020 08:41

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA

Tag Name: CT2_VOC_LbPerHr_1H

Total Operating Time: 1,800.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 408.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,800.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT2 - VOC Ppmvdc 1-Hour Block Average

From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 10/06/2020 08:41 Location: Maxwell, CA

Tag Name: CT2_VOC_Ppmvdc_1H

Total Operating Time: 1,800.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 408.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,800.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

ATTACHMENT 6
Hourly Emissions – NOx

FCD: AQ-15
Title V: #6

Excess Emission Report



CT1 - NOx Lb 1-Day Block Average

From: 07/01/2020 00:00 To: 09/30/2020 23:59
Generated: 10/06/2020 08:46

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA

Tag Name: CT1_NOx_Lb_1D

Total Operating Time: 1,885.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 323.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,885.00 Hour(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 - NOx Lb 1-Day Block Average

From: 07/01/2020 00:00 To: 09/30/2020 23:59
Generated: 10/06/2020 08:46

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA

Tag Name: CT1_NOx_Lb_1D

Total Operating Time: 1,885.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 323.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,885.00 Hour(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/01/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/02/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/03/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2020 13:00	30.4	17.6	440.0	54.4	61.60	1	0	0
07/03/2020 14:00	12.0	15.0	1,031.2	12.0	45.40	1	0	0
07/03/2020 15:00	0.9	13.9	1,652.8	0.8	5.00	1	1	0
07/03/2020 16:00	1.0	13.9	1,611.1	0.8	4.80	1	1	1
07/03/2020 17:00	1.2	12.3	2,011.2	0.8	6.00	1	1	1
07/03/2020 18:00	1.3	11.6	2,116.1	0.8	6.30	1	1	1
07/03/2020 19:00	1.3	11.8	2,094.2	0.8	6.30	1	1	1
07/03/2020 20:00	1.3	11.6	2,130.8	0.8	6.40	1	1	1
07/03/2020 21:00	1.2	12.2	2,025.1	0.8	6.10	1	1	1
07/03/2020 22:00	1.2	12.1	2,048.1	0.8	6.10	1	1	1
07/03/2020 23:00	1.7	13.9	1,231.3	1.4	3.10	1	0	1
Average/Sum#:	4.9	13.3	1,672.0	6.7	157.10 #	11 #	8 #	8 #
Minimum:	0.9	11.6	440.0	0.8	3.10	0	0	0
Maximum:	30.4	17.6	2,130.8	54.4	61.60	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/04/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/05/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2020 14:00	31.8	17.7	423.1	58.6	54.84	1	0	0
07/05/2020 15:00	13.7	15.1	952.5	13.9	48.60	1	0	0
07/05/2020 16:00	0.8	13.9	1,572.4	0.7	3.10	1	1	0
07/05/2020 17:00	1.2	12.9	1,789.5	0.9	5.40	1	1	1
07/05/2020 18:00	1.3	11.6	2,104.3	0.8	6.30	1	1	1
07/05/2020 19:00	1.2	11.7	2,078.1	0.8	6.20	1	1	1
07/05/2020 20:00	1.3	11.7	2,105.4	0.8	6.30	1	1	1
07/05/2020 21:00	1.2	11.9	2,083.7	0.8	6.30	1	1	1
07/05/2020 22:00	1.5	13.5	1,360.8	1.2	3.24	1	0	1
07/05/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	6.0	13.3	1,607.8	8.7	140.28 #	9 #	6 #	6 #
Minimum:	0.8	11.6	423.1	0.7	3.10	0	0	0
Maximum:	31.8	17.7	2,105.4	58.6	54.84	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/06/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2020 11:00	18.9	18.0	379.4	38.5	20.48	1	0	0
07/06/2020 12:00	12.7	15.5	891.9	13.9	45.50	1	0	0
07/06/2020 13:00	0.8	13.9	1,665.8	0.7	3.30	1	1	0
07/06/2020 14:00	1.0	13.9	1,595.1	0.8	4.80	1	1	0
07/06/2020 15:00	0.9	13.9	1,524.3	0.8	4.60	1	1	1
07/06/2020 16:00	1.2	12.2	2,035.3	0.8	6.10	1	1	1
07/06/2020 17:00	1.3	11.9	2,099.2	0.9	6.30	1	1	1
07/06/2020 18:00	1.3	11.8	2,114.2	0.8	6.30	1	1	1
07/06/2020 19:00	1.2	12.0	2,086.2	0.8	6.30	1	1	1
07/06/2020 20:00	1.2	12.2	2,059.5	0.8	6.20	1	1	1
07/06/2020 21:00	1.2	12.3	2,026.6	0.8	6.10	1	1	1
07/06/2020 22:00	1.1	12.8	1,924.2	0.8	5.80	1	1	1
07/06/2020 23:00	1.1	13.2	1,764.1	0.8	5.30	1	1	1
Average/Sum#:	3.4	13.4	1,705.1	4.7	127.08 #	13 #	11 #	9 #
Minimum:	0.8	11.8	379.4	0.7	3.30	0	0	0
Maximum:	18.9	18.0	2,114.2	38.5	45.50	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/07/2020 00:00	0.7	14.0	1,266.8	0.6	2.50	1	1	0
07/07/2020 01:00	0.8	14.0	1,318.2	0.7	4.00	1	1	0
07/07/2020 02:00	0.7	14.0	1,276.7	0.6	2.60	1	1	0
07/07/2020 03:00	0.7	14.0	1,267.0	0.6	2.50	1	1	0
07/07/2020 04:00	0.7	14.0	1,258.2	0.6	2.50	1	1	0
07/07/2020 05:00	0.7	14.0	1,279.5	0.6	2.60	1	1	0
07/07/2020 06:00	0.7	14.0	1,266.6	0.6	2.50	1	1	0
07/07/2020 07:00	0.7	14.0	1,284.4	0.6	2.60	1	1	0
07/07/2020 08:00	0.8	14.0	1,302.6	0.7	3.90	1	1	0
07/07/2020 09:00	0.8	14.0	1,277.3	0.7	3.80	1	1	0
07/07/2020 10:00	0.8	14.0	1,266.6	0.7	3.80	1	1	0
07/07/2020 11:00	0.8	14.1	1,270.9	0.7	3.80	1	1	0
07/07/2020 12:00	0.8	14.1	1,272.5	0.7	3.80	1	1	0
07/07/2020 13:00	1.0	14.0	1,372.0	0.9	4.10	1	1	0
07/07/2020 14:00	0.9	14.0	1,344.6	0.8	4.00	1	1	0
07/07/2020 15:00	0.0	0.0	1,482.0	0.0	0.00	1	1	1
07/07/2020 16:00	1.3	12.3	2,028.5	0.9	6.10	1	1	1
07/07/2020 17:00	1.3	11.8	2,115.5	0.8	6.30	1	1	1
07/07/2020 18:00	1.2	12.0	2,077.4	0.8	6.20	1	1	1
07/07/2020 19:00	1.2	12.0	2,065.7	0.8	6.20	1	1	1
07/07/2020 20:00	1.2	12.0	2,063.7	0.8	6.20	1	1	1
07/07/2020 21:00	1.2	12.1	2,052.5	0.8	6.20	1	1	1
07/07/2020 22:00	1.1	12.7	1,936.7	0.8	5.80	1	1	1
07/07/2020 23:00	1.1	12.9	1,818.2	0.8	5.50	1	1	1
Average/Sum#:	0.9	13.4	1,540.2	0.7	97.50 #	24 #	24 #	9 #
Minimum:	0.7	11.8	1,258.2	0.6	2.50	1	1	0
Maximum:	1.3	14.1	2,115.5	0.9	6.30	1	1	1
%SI	4.17	4.17	0.00	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/08/2020 00:00	0.7	14.0	1,288.8	0.6	2.60	1	1	0
07/08/2020 01:00	0.7	14.0	1,255.5	0.6	2.50	1	1	0
07/08/2020 02:00	0.7	14.0	1,255.4	0.6	2.50	1	1	0
07/08/2020 03:00	0.7	14.1	1,254.9	0.6	2.50	1	1	0
07/08/2020 04:00	0.7	14.1	1,257.1	0.6	2.50	1	1	0
07/08/2020 05:00	0.7	14.0	1,268.0	0.6	2.50	1	1	0
07/08/2020 06:00	0.7	14.1	1,259.1	0.6	2.50	1	1	0
07/08/2020 07:00	0.7	14.0	1,263.0	0.6	2.50	1	1	0
07/08/2020 08:00	0.7	14.0	1,261.3	0.6	2.50	1	1	0
07/08/2020 09:00	0.7	14.0	1,261.6	0.6	2.50	1	1	0
07/08/2020 10:00	0.8	14.1	1,263.6	0.7	3.80	1	1	0
07/08/2020 11:00	0.8	14.1	1,279.9	0.7	3.80	1	1	0
07/08/2020 12:00	0.9	14.0	1,336.2	0.8	4.00	1	1	0
07/08/2020 13:00	0.8	14.1	1,287.4	0.7	3.90	1	1	0
07/08/2020 14:00	1.0	14.1	1,336.3	0.9	4.00	1	1	0
07/08/2020 15:00	0.9	14.0	1,424.2	0.8	4.30	1	1	1
07/08/2020 16:00	1.3	12.1	2,027.1	0.9	6.10	1	1	1
07/08/2020 17:00	1.3	11.8	2,070.5	0.8	6.20	1	1	1
07/08/2020 18:00	1.3	11.8	2,088.0	0.8	6.30	1	1	1
07/08/2020 19:00	1.3	11.8	2,084.1	0.8	6.30	1	1	1
07/08/2020 20:00	1.3	11.8	2,084.8	0.8	6.30	1	1	1
07/08/2020 21:00	1.2	12.2	2,007.9	0.8	6.00	1	1	1
07/08/2020 22:00	1.2	12.5	1,955.0	0.8	5.90	1	1	1
07/08/2020 23:00	1.1	12.9	1,782.9	0.8	5.30	1	1	1
Average/Sum#:	0.9	13.4	1,527.2	0.7	97.30 #	24 #	24 #	9 #
Minimum:	0.7	11.8	1,254.9	0.6	2.50	1	1	0
Maximum:	1.3	14.1	2,088.0	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/09/2020 00:00	0.7	14.0	1,274.2	0.6	2.50	1	1	0
07/09/2020 01:00	0.8	14.0	1,271.2	0.7	3.80	1	1	0
07/09/2020 02:00	0.8	14.0	1,253.3	0.7	3.80	1	1	0
07/09/2020 03:00	0.8	14.0	1,314.5	0.7	3.90	1	1	0
07/09/2020 04:00	0.8	14.0	1,284.5	0.7	3.90	1	1	0
07/09/2020 05:00	0.8	14.0	1,339.3	0.7	4.00	1	1	0
07/09/2020 06:00	0.8	14.0	1,268.0	0.7	3.80	1	1	0
07/09/2020 07:00	0.8	14.0	1,257.2	0.7	3.80	1	1	0
07/09/2020 08:00	0.8	14.0	1,259.5	0.7	3.80	1	1	0
07/09/2020 09:00	0.8	14.0	1,267.0	0.7	3.80	1	1	0
07/09/2020 10:00	0.8	14.0	1,266.4	0.7	3.80	1	1	0
07/09/2020 11:00	0.8	14.1	1,266.7	0.7	3.80	1	1	0
07/09/2020 12:00	0.9	14.0	1,511.9	0.8	4.50	1	1	0
07/09/2020 13:00	1.0	13.9	1,629.0	0.8	4.90	1	1	0
07/09/2020 14:00	0.9	13.9	1,501.0	0.8	4.50	1	1	1
07/09/2020 15:00	1.2	12.1	2,021.6	0.8	6.10	1	1	1
07/09/2020 16:00	1.3	11.8	2,068.6	0.8	6.20	1	1	1
07/09/2020 17:00	1.3	11.7	2,100.2	0.8	6.30	1	1	1
07/09/2020 18:00	1.3	11.5	2,127.9	0.8	6.40	1	1	1
07/09/2020 19:00	1.3	11.6	2,122.3	0.8	6.40	1	1	1
07/09/2020 20:00	1.3	11.8	2,076.6	0.8	6.20	1	1	1
07/09/2020 21:00	1.2	11.9	2,074.2	0.8	6.20	1	1	1
07/09/2020 22:00	1.2	12.5	1,959.7	0.8	5.90	1	1	1
07/09/2020 23:00	1.2	12.8	1,900.4	0.9	5.70	1	1	1
Average/Sum#:	1.0	13.2	1,600.6	0.8	114.00 #	24 #	24 #	10 #
Minimum:	0.7	11.5	1,253.3	0.6	2.50	1	1	0
Maximum:	1.3	14.1	2,127.9	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/10/2020 00:00	0.7	14.0	1,360.6	0.6	2.70	1	1	0
07/10/2020 01:00	0.6	14.1	1,258.3	0.5	2.50	1	1	0
07/10/2020 02:00	0.6	14.1	1,257.3	0.5	2.50	1	1	0
07/10/2020 03:00	0.6	14.1	1,254.8	0.5	2.50	1	1	0
07/10/2020 04:00	0.6	14.1	1,265.3	0.5	2.50	1	1	0
07/10/2020 05:00	0.9	14.0	1,530.4	0.8	4.60	1	1	0
07/10/2020 06:00	0.9	14.0	1,670.6	0.8	5.00	1	1	0
07/10/2020 07:00	0.9	14.0	1,668.0	0.8	5.00	1	1	0
07/10/2020 08:00	0.9	14.0	1,578.2	0.8	4.70	1	1	0
07/10/2020 09:00	0.9	14.0	1,447.8	0.8	4.30	1	1	0
07/10/2020 10:00	1.0	14.0	1,483.2	0.9	4.40	1	1	0
07/10/2020 11:00	0.9	14.1	1,373.7	0.8	4.10	1	1	0
07/10/2020 12:00	0.9	14.0	1,542.6	0.8	4.60	1	1	0
07/10/2020 13:00	1.2	12.2	2,047.2	0.8	6.10	1	1	1
07/10/2020 14:00	1.3	11.9	2,108.3	0.9	6.30	1	1	1
07/10/2020 15:00	1.3	11.9	2,113.7	0.9	6.30	1	1	1
07/10/2020 16:00	1.3	11.7	2,149.4	0.8	6.40	1	1	1
07/10/2020 17:00	1.3	11.5	2,182.9	0.8	6.50	1	1	1
07/10/2020 18:00	1.4	11.4	2,197.2	0.9	6.60	1	1	1
07/10/2020 19:00	1.4	11.5	2,198.8	0.9	6.60	1	1	1
07/10/2020 20:00	1.4	11.5	2,190.3	0.9	6.60	1	1	1
07/10/2020 21:00	1.4	12.0	2,091.3	0.9	6.30	1	1	1
07/10/2020 22:00	1.4	12.0	2,106.0	0.9	6.30	1	1	1
07/10/2020 23:00	1.2	12.9	1,809.6	0.9	5.40	1	1	1
Average/Sum#:	1.0	13.0	1,745.2	0.8	118.80 #	24 #	24 #	11 #
Minimum:	0.6	11.4	1,254.8	0.5	2.50	1	1	0
Maximum:	1.4	14.1	2,198.8	0.9	6.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/11/2020 00:00	0.8	14.0	1,298.4	0.7	3.90	1	1	0
07/11/2020 01:00	0.9	14.0	1,345.5	0.8	4.00	1	1	0
07/11/2020 02:00	1.0	14.0	1,352.3	0.9	4.10	1	1	0
07/11/2020 03:00	1.0	14.0	1,368.3	0.9	4.10	1	1	0
07/11/2020 04:00	0.9	14.0	1,333.5	0.8	4.00	1	1	0
07/11/2020 05:00	1.0	14.0	1,654.7	0.9	5.00	1	1	0
07/11/2020 06:00	1.1	14.0	1,589.2	0.9	4.80	1	1	0
07/11/2020 07:00	1.0	14.0	1,362.1	0.9	4.10	1	1	0
07/11/2020 08:00	1.0	14.0	1,583.8	0.9	4.80	1	1	0
07/11/2020 09:00	0.8	14.0	1,309.6	0.7	3.90	1	1	0
07/11/2020 10:00	1.0	14.0	1,480.9	0.9	4.40	1	1	0
07/11/2020 11:00	1.1	13.9	1,613.9	0.9	4.80	1	1	0
07/11/2020 12:00	1.1	14.0	1,617.0	0.9	4.90	1	1	0
07/11/2020 13:00	0.9	14.1	1,365.0	0.8	4.10	1	1	0
07/11/2020 14:00	1.0	14.0	1,363.0	0.9	4.10	1	1	0
07/11/2020 15:00	1.3	13.0	1,816.3	1.0	7.30	1	1	1
07/11/2020 16:00	1.4	11.8	2,135.4	0.9	6.40	1	1	1
07/11/2020 17:00	1.4	11.5	2,177.4	0.9	6.50	1	1	1
07/11/2020 18:00	1.4	11.5	2,188.6	0.9	6.60	1	1	1
07/11/2020 19:00	1.4	11.5	2,199.7	0.9	6.60	1	1	1
07/11/2020 20:00	1.4	11.8	2,144.8	0.9	6.40	1	1	1
07/11/2020 21:00	1.4	12.0	2,097.6	0.9	6.30	1	1	1
07/11/2020 22:00	1.4	12.0	2,112.8	0.9	6.30	1	1	1
07/11/2020 23:00	1.2	12.9	1,826.2	0.9	5.50	1	1	1
Average/Sum#:	1.1	13.3	1,680.7	0.9	122.90 #	24 #	24 #	9 #
Minimum:	0.8	11.5	1,298.4	0.7	3.90	1	1	0
Maximum:	1.4	14.1	2,199.7	1.0	7.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOX, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOX, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/12/2020 00:00	0.8	14.0	1,296.8	0.7	3.90	1	1	0
07/12/2020 01:00	0.8	14.0	1,288.6	0.7	3.90	1	1	0
07/12/2020 02:00	0.8	14.0	1,287.3	0.7	3.90	1	1	0
07/12/2020 03:00	0.8	14.0	1,287.2	0.7	3.90	1	1	0
07/12/2020 04:00	0.7	14.0	1,288.3	0.6	2.60	1	1	0
07/12/2020 05:00	0.8	14.0	1,286.8	0.7	3.90	1	1	0
07/12/2020 06:00	0.8	14.0	1,291.7	0.7	3.90	1	1	0
07/12/2020 07:00	0.8	14.0	1,290.0	0.7	3.90	1	1	0
07/12/2020 08:00	0.8	14.1	1,291.8	0.7	3.90	1	1	0
07/12/2020 09:00	0.8	14.1	1,302.2	0.7	3.90	1	1	0
07/12/2020 10:00	0.9	14.1	1,404.8	0.8	4.20	1	1	0
07/12/2020 11:00	0.8	14.0	1,371.8	0.7	4.10	1	1	0
07/12/2020 12:00	0.9	14.0	1,428.8	0.8	4.30	1	1	0
07/12/2020 13:00	0.9	14.1	1,365.6	0.8	4.10	1	1	0
07/12/2020 14:00	0.9	14.1	1,313.3	0.8	3.90	1	1	0
07/12/2020 15:00	1.1	13.9	1,643.0	0.9	4.90	1	1	1
07/12/2020 16:00	1.4	11.9	2,097.6	0.9	6.30	1	1	1
07/12/2020 17:00	1.4	11.4	2,178.4	0.9	6.50	1	1	1
07/12/2020 18:00	1.4	11.4	2,170.1	0.9	6.50	1	1	1
07/12/2020 19:00	1.4	11.5	2,153.6	0.9	6.50	1	1	1
07/12/2020 20:00	1.4	11.9	2,097.4	0.9	6.30	1	1	1
07/12/2020 21:00	1.4	12.1	2,065.8	0.9	6.20	1	1	1
07/12/2020 22:00	1.4	11.9	2,112.3	0.9	6.30	1	1	1
07/12/2020 23:00	1.3	12.5	1,966.2	0.9	5.90	1	1	1
Average/Sum#:	1.0	13.3	1,595.0	0.8	113.70 #	24 #	24 #	9 #
Minimum:	0.7	11.4	1,286.8	0.6	2.60	1	1	0
Maximum:	1.4	14.1	2,178.4	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOX, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOX, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/13/2020 00:00	1.0	13.9	1,583.2	0.8	4.70	1	1	0
07/13/2020 01:00	1.1	13.9	1,443.0	0.9	4.30	1	1	0
07/13/2020 02:00	0.8	14.0	1,322.5	0.7	4.00	1	1	0
07/13/2020 03:00	0.8	14.0	1,291.4	0.7	3.90	1	1	0
07/13/2020 04:00	0.8	14.0	1,292.8	0.7	3.90	1	1	0
07/13/2020 05:00	1.0	13.9	1,629.1	0.8	4.90	1	1	0
07/13/2020 06:00	1.0	13.9	1,493.1	0.8	4.50	1	1	0
07/13/2020 07:00	1.0	13.9	1,394.0	0.8	4.20	1	1	0
07/13/2020 08:00	1.1	13.9	1,526.5	0.9	4.60	1	1	0
07/13/2020 09:00	0.9	14.0	1,307.3	0.8	3.90	1	1	0
07/13/2020 10:00	1.1	14.0	1,483.2	0.9	4.40	1	1	0
07/13/2020 11:00	1.1	13.9	1,621.6	0.9	4.90	1	1	1
07/13/2020 12:00	1.3	12.3	2,042.9	0.9	6.10	1	1	1
07/13/2020 13:00	1.4	11.9	2,098.4	0.9	6.30	1	1	1
07/13/2020 14:00	1.4	11.8	2,117.1	0.9	6.40	1	1	1
07/13/2020 15:00	1.4	11.7	2,119.4	0.9	6.40	1	1	1
07/13/2020 16:00	1.4	11.6	2,140.3	0.9	6.40	1	1	1
07/13/2020 17:00	1.4	11.5	2,165.0	0.9	6.50	1	1	1
07/13/2020 18:00	1.4	11.5	2,163.0	0.9	6.50	1	1	1
07/13/2020 19:00	1.4	11.6	2,146.9	0.9	6.40	1	1	1
07/13/2020 20:00	1.4	11.8	2,120.6	0.9	6.40	1	1	1
07/13/2020 21:00	1.4	11.9	2,103.0	0.9	6.30	1	1	1
07/13/2020 22:00	1.4	12.0	2,098.0	0.9	6.30	1	1	1
07/13/2020 23:00	1.3	12.7	1,965.5	0.9	5.90	1	1	1
Average/Sum#:	1.2	12.9	1,777.8	0.9	128.10 #	24 #	24 #	13 #
Minimum:	0.8	11.5	1,291.4	0.7	3.90	1	1	0
Maximum:	1.4	14.0	2,165.0	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/14/2020 00:00	1.1	13.1	1,788.3	0.8	5.40	1	1	1
07/14/2020 01:00	0.7	13.9	1,296.1	0.6	2.60	1	1	0
07/14/2020 02:00	0.9	13.9	1,354.6	0.8	4.10	1	1	0
07/14/2020 03:00	0.8	14.0	1,295.9	0.7	3.90	1	1	0
07/14/2020 04:00	0.8	14.0	1,292.0	0.7	3.90	1	1	0
07/14/2020 05:00	0.9	13.9	1,629.2	0.8	4.90	1	1	0
07/14/2020 06:00	1.0	13.9	1,662.5	0.8	5.00	1	1	0
07/14/2020 07:00	1.1	13.9	1,676.8	0.9	5.00	1	1	0
07/14/2020 08:00	1.1	13.9	1,552.4	0.9	4.70	1	1	0
07/14/2020 09:00	0.9	14.0	1,299.1	0.8	3.90	1	1	0
07/14/2020 10:00	0.9	14.0	1,314.4	0.8	3.90	1	1	0
07/14/2020 11:00	0.8	14.0	1,361.5	0.7	4.10	1	1	0
07/14/2020 12:00	1.1	13.9	1,531.6	0.9	4.60	1	1	0
07/14/2020 13:00	0.9	14.0	1,346.7	0.8	4.00	1	1	1
07/14/2020 14:00	1.3	12.3	2,026.7	0.9	6.10	1	1	1
07/14/2020 15:00	1.4	11.9	2,076.4	0.9	6.20	1	1	1
07/14/2020 16:00	1.4	11.8	2,099.9	0.9	6.30	1	1	1
07/14/2020 17:00	1.4	11.8	2,109.9	0.9	6.30	1	1	1
07/14/2020 18:00	1.4	11.7	2,135.2	0.9	6.40	1	1	1
07/14/2020 19:00	1.4	11.6	2,131.9	0.9	6.40	1	1	1
07/14/2020 20:00	1.4	11.8	2,119.8	0.9	6.40	1	1	1
07/14/2020 21:00	1.4	11.8	2,125.8	0.9	6.40	1	1	1
07/14/2020 22:00	1.3	12.5	1,981.5	0.9	5.90	1	1	1
07/14/2020 23:00	1.2	13.0	1,795.1	0.9	5.40	1	1	1
Average/Sum#:	1.1	13.1	1,708.5	0.8	121.80 #	24 #	24 #	12 #
Minimum:	0.7	11.6	1,292.0	0.6	2.60	1	1	0
Maximum:	1.4	14.0	2,135.2	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/15/2020 00:00	0.8	13.9	1,292.8	0.7	2.60	1	1	0
07/15/2020 01:00	0.8	14.0	1,288.0	0.7	3.90	1	1	0
07/15/2020 02:00	0.8	14.0	1,291.6	0.7	3.90	1	1	0
07/15/2020 03:00	0.8	14.0	1,293.1	0.7	3.90	1	1	0
07/15/2020 04:00	0.9	14.0	1,293.8	0.8	3.90	1	1	0
07/15/2020 05:00	0.9	13.9	1,319.3	0.8	4.00	1	1	0
07/15/2020 06:00	0.9	13.9	1,305.0	0.8	3.90	1	1	0
07/15/2020 07:00	0.9	14.0	1,289.2	0.8	3.90	1	1	0
07/15/2020 08:00	0.9	14.0	1,290.7	0.8	3.90	1	1	0
07/15/2020 09:00	0.9	14.0	1,294.0	0.8	3.90	1	1	0
07/15/2020 10:00	0.9	14.0	1,295.0	0.8	3.90	1	1	0
07/15/2020 11:00	0.9	14.0	1,297.5	0.8	3.90	1	1	0
07/15/2020 12:00	1.0	14.0	1,296.0	0.9	3.90	1	1	0
07/15/2020 13:00	1.0	14.0	1,299.5	0.9	3.90	1	1	0
07/15/2020 14:00	1.0	14.0	1,307.4	0.9	3.90	1	1	0
07/15/2020 15:00	1.0	14.0	1,302.6	0.9	3.90	1	1	0
07/15/2020 16:00	1.0	14.0	1,307.9	0.9	3.90	1	1	0
07/15/2020 17:00	1.0	14.0	1,308.4	0.9	3.90	1	1	0
07/15/2020 18:00	1.0	13.9	1,392.0	0.8	4.20	1	1	0
07/15/2020 19:00	1.1	13.9	1,462.8	0.9	4.40	1	1	0
07/15/2020 20:00	0.8	14.0	1,358.8	0.7	4.10	1	1	0
07/15/2020 21:00	0.9	14.0	1,288.7	0.8	3.90	1	1	0
07/15/2020 22:00	0.9	13.9	1,285.1	0.8	3.90	1	1	0
07/15/2020 23:00	0.9	14.0	1,323.4	0.8	4.00	1	1	0
Average/Sum#:	0.9	14.0	1,311.8	0.8	93.50 #	24 #	24 #	0 #
Minimum:	0.8	13.9	1,285.1	0.7	2.60	1	1	0
Maximum:	1.1	14.0	1,462.8	0.9	4.40	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/16/2020 00:00	0.8	14.0	1,288.8	0.7	3.90	1	1	0
07/16/2020 01:00	0.8	14.0	1,288.2	0.7	3.90	1	1	0
07/16/2020 02:00	0.8	14.0	1,286.5	0.7	3.90	1	1	0
07/16/2020 03:00	0.8	13.9	1,286.3	0.7	2.60	1	1	0
07/16/2020 04:00	0.8	13.9	1,287.1	0.7	2.60	1	1	0
07/16/2020 05:00	0.8	13.9	1,287.0	0.7	2.60	1	1	0
07/16/2020 06:00	0.8	14.0	1,287.8	0.7	3.90	1	1	0
07/16/2020 07:00	0.9	14.0	1,288.1	0.8	3.90	1	1	0
07/16/2020 08:00	0.9	14.0	1,291.1	0.8	3.90	1	1	0
07/16/2020 09:00	0.9	14.0	1,293.9	0.8	3.90	1	1	0
07/16/2020 10:00	0.9	14.0	1,298.6	0.8	3.90	1	1	0
07/16/2020 11:00	0.9	14.0	1,297.0	0.8	3.90	1	1	0
07/16/2020 12:00	0.9	14.0	1,295.0	0.8	3.90	1	1	0
07/16/2020 13:00	0.9	14.0	1,297.3	0.8	3.90	1	1	0
07/16/2020 14:00	1.1	13.9	1,463.7	0.9	4.40	1	1	0
07/16/2020 15:00	1.0	13.9	1,504.0	0.8	4.50	1	1	1
07/16/2020 16:00	1.4	11.9	2,067.7	0.9	6.20	1	1	1
07/16/2020 17:00	1.4	11.7	2,107.8	0.9	6.30	1	1	1
07/16/2020 18:00	1.4	11.8	2,094.6	0.9	6.30	1	1	1
07/16/2020 19:00	1.4	11.7	2,128.9	0.9	6.40	1	1	1
07/16/2020 20:00	1.4	11.7	2,126.3	0.9	6.40	1	1	1
07/16/2020 21:00	1.4	11.9	2,111.6	0.9	6.30	1	1	1
07/16/2020 22:00	1.3	12.6	1,974.7	0.9	5.90	1	1	1
07/16/2020 23:00	1.2	13.1	1,789.3	0.9	5.40	1	1	1
Average/Sum#:	1.0	13.3	1,560.1	0.8	108.80 #	24 #	24 #	9 #
Minimum:	0.8	11.7	1,286.3	0.7	2.60	1	1	0
Maximum:	1.4	14.0	2,128.9	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/17/2020 00:00	0.7	13.9	1,292.7	0.6	2.60	1	1	0
07/17/2020 01:00	0.8	13.9	1,297.8	0.7	2.60	1	1	0
07/17/2020 02:00	0.8	14.0	1,293.2	0.7	3.90	1	1	0
07/17/2020 03:00	0.8	14.0	1,300.9	0.7	3.90	1	1	0
07/17/2020 04:00	0.8	14.0	1,298.0	0.7	3.90	1	1	0
07/17/2020 05:00	0.8	13.9	1,304.6	0.7	2.60	1	1	0
07/17/2020 06:00	0.8	13.9	1,304.4	0.7	2.60	1	1	0
07/17/2020 07:00	0.8	14.0	1,298.6	0.7	3.90	1	1	0
07/17/2020 08:00	0.8	14.0	1,300.4	0.7	3.90	1	1	0
07/17/2020 09:00	0.9	14.0	1,312.8	0.8	3.90	1	1	0
07/17/2020 10:00	0.9	14.0	1,305.3	0.8	3.90	1	1	0
07/17/2020 11:00	0.9	14.0	1,308.2	0.8	3.90	1	1	0
07/17/2020 12:00	0.9	14.0	1,317.9	0.8	4.00	1	1	0
07/17/2020 13:00	1.0	14.0	1,327.9	0.9	4.00	1	1	0
07/17/2020 14:00	0.9	14.0	1,300.6	0.8	3.90	1	1	0
07/17/2020 15:00	0.9	14.0	1,303.4	0.8	3.90	1	1	0
07/17/2020 16:00	1.0	13.9	1,505.4	0.8	4.50	1	1	1
07/17/2020 17:00	1.4	12.0	2,071.3	0.9	6.20	1	1	1
07/17/2020 18:00	1.4	11.8	2,107.8	0.9	6.30	1	1	1
07/17/2020 19:00	1.4	11.8	2,119.7	0.9	6.40	1	1	1
07/17/2020 20:00	1.4	11.8	2,123.3	0.9	6.40	1	1	1
07/17/2020 21:00	1.4	11.9	2,108.4	0.9	6.30	1	1	1
07/17/2020 22:00	1.3	12.6	1,985.7	0.9	6.00	1	1	1
07/17/2020 23:00	1.3	13.0	1,865.4	1.0	7.50	1	1	1
Average/Sum#:	1.0	13.4	1,531.4	0.8	107.00 #	24 #	24 #	8 #
Minimum:	0.7	11.8	1,292.7	0.6	2.60	1	1	0
Maximum:	1.4	14.0	2,123.3	1.0	7.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/18/2020 00:00	1.1	13.7	1,757.5	0.9	5.30	1	1	0
07/18/2020 01:00	1.1	13.8	1,599.1	0.9	4.80	1	1	0
07/18/2020 02:00	0.8	13.9	1,308.4	0.7	2.60	1	1	0
07/18/2020 03:00	0.8	13.9	1,310.0	0.7	2.60	1	1	0
07/18/2020 04:00	0.8	13.9	1,319.9	0.7	2.60	1	1	0
07/18/2020 05:00	0.9	13.9	1,355.7	0.8	4.10	1	1	0
07/18/2020 06:00	0.8	13.9	1,294.4	0.7	2.60	1	1	0
07/18/2020 07:00	0.8	14.0	1,294.7	0.7	3.90	1	1	0
07/18/2020 08:00	0.8	14.0	1,294.6	0.7	3.90	1	1	0
07/18/2020 09:00	0.9	14.0	1,301.1	0.8	3.90	1	1	0
07/18/2020 10:00	0.9	14.0	1,301.4	0.8	3.90	1	1	0
07/18/2020 11:00	1.0	14.0	1,392.7	0.9	4.20	1	1	0
07/18/2020 12:00	1.1	13.9	1,407.3	0.9	4.20	1	1	0
07/18/2020 13:00	1.2	13.9	1,587.2	1.0	6.30	1	1	1
07/18/2020 14:00	2.2	12.4	2,007.4	1.5	12.00	1	1	1
07/18/2020 15:00	1.5	13.5	1,515.8	1.2	6.10	1	1	1
07/18/2020 16:00	1.4	13.9	1,599.3	1.2	6.40	1	1	1
07/18/2020 17:00	2.3	12.0	2,074.1	1.5	12.40	1	1	1
07/18/2020 18:00	2.8	11.5	2,149.9	1.8	12.90	1	1	1
07/18/2020 19:00	2.1	11.4	2,177.7	1.3	10.90	1	1	1
07/18/2020 20:00	1.2	11.6	2,134.0	0.8	6.40	1	1	1
07/18/2020 21:00	1.2	12.3	2,006.8	0.8	6.00	1	1	1
07/18/2020 22:00	1.2	12.4	1,990.9	0.8	6.00	1	1	1
07/18/2020 23:00	1.2	12.8	1,867.6	0.9	5.60	1	1	1
Average/Sum#:	1.3	13.3	1,627.0	1.0	139.60 #	24 #	24 #	11 #
Minimum:	0.8	11.4	1,294.4	0.7	2.60	1	1	0
Maximum:	2.8	14.0	2,177.7	1.8	12.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOX, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/19/2020 00:00	1.0	13.6	1,759.1	0.8	5.30	1	1	0
07/19/2020 01:00	0.7	13.9	1,313.6	0.6	2.60	1	1	0
07/19/2020 02:00	0.8	13.9	1,289.2	0.7	2.60	1	1	0
07/19/2020 03:00	0.8	13.9	1,293.5	0.7	2.60	1	1	0
07/19/2020 04:00	0.8	13.9	1,289.8	0.7	2.60	1	1	0
07/19/2020 05:00	0.8	13.9	1,290.7	0.7	2.60	1	1	0
07/19/2020 06:00	0.8	13.9	1,289.1	0.7	2.60	1	1	0
07/19/2020 07:00	0.8	14.0	1,292.4	0.7	3.90	1	1	0
07/19/2020 08:00	0.9	14.0	1,300.6	0.8	3.90	1	1	0
07/19/2020 09:00	0.9	14.0	1,300.7	0.8	3.90	1	1	0
07/19/2020 10:00	0.9	14.0	1,301.4	0.8	3.90	1	1	0
07/19/2020 11:00	0.9	14.0	1,300.7	0.8	3.90	1	1	0
07/19/2020 12:00	0.9	14.0	1,301.3	0.8	3.90	1	1	0
07/19/2020 13:00	0.9	14.0	1,304.0	0.8	3.90	1	1	0
07/19/2020 14:00	0.9	14.0	1,309.0	0.8	3.90	1	1	0
07/19/2020 15:00	0.9	14.0	1,306.8	0.8	3.90	1	1	0
07/19/2020 16:00	0.9	13.9	1,498.4	0.8	4.50	1	1	1
07/19/2020 17:00	1.2	12.0	2,048.3	0.8	6.10	1	1	1
07/19/2020 18:00	1.3	11.6	2,130.2	0.8	6.40	1	1	1
07/19/2020 19:00	1.3	11.7	2,124.6	0.8	6.40	1	1	1
07/19/2020 20:00	1.3	11.8	2,110.5	0.8	6.30	1	1	1
07/19/2020 21:00	1.2	12.0	2,091.8	0.8	6.30	1	1	1
07/19/2020 22:00	1.2	12.6	1,970.3	0.9	5.90	1	1	1
07/19/2020 23:00	1.1	13.1	1,786.8	0.8	5.40	1	1	1
Average/Sum#:	1.0	13.4	1,541.8	0.8	103.30 #	24 #	24 #	8 #
Minimum:	0.7	11.6	1,289.1	0.6	2.60	1	1	0
Maximum:	1.3	14.0	2,130.2	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOX, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOX, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/20/2020 00:00	0.8	13.9	1,291.9	0.7	2.60	1	1	0
07/20/2020 01:00	0.8	13.9	1,284.9	0.7	2.60	1	1	0
07/20/2020 02:00	0.7	13.9	1,283.5	0.6	2.60	1	1	0
07/20/2020 03:00	0.7	13.9	1,283.1	0.6	2.60	1	1	0
07/20/2020 04:00	0.7	13.9	1,284.7	0.6	2.60	1	1	0
07/20/2020 05:00	0.7	13.9	1,300.2	0.6	2.60	1	1	0
07/20/2020 06:00	1.0	13.9	1,661.5	0.8	5.00	1	1	0
07/20/2020 07:00	1.0	13.9	1,634.1	0.8	4.90	1	1	0
07/20/2020 08:00	1.0	13.9	1,676.7	0.8	5.00	1	1	0
07/20/2020 09:00	0.9	13.9	1,385.1	0.8	4.20	1	1	0
07/20/2020 10:00	1.0	13.9	1,530.8	0.8	4.60	1	1	0
07/20/2020 11:00	1.0	13.9	1,543.3	0.8	4.60	1	1	0
07/20/2020 12:00	0.9	13.8	1,523.7	0.7	4.60	1	1	1
07/20/2020 13:00	1.2	12.2	2,029.1	0.8	6.10	1	1	1
07/20/2020 14:00	1.2	12.3	1,999.1	0.8	6.00	1	1	1
07/20/2020 15:00	1.3	11.9	2,072.1	0.9	6.20	1	1	1
07/20/2020 16:00	1.3	11.9	2,076.3	0.9	6.20	1	1	1
07/20/2020 17:00	1.3	11.8	2,084.5	0.8	6.30	1	1	1
07/20/2020 18:00	1.3	11.6	2,124.9	0.8	6.40	1	1	1
07/20/2020 19:00	1.3	11.7	2,122.1	0.8	6.40	1	1	1
07/20/2020 20:00	1.3	11.8	2,110.2	0.8	6.30	1	1	1
07/20/2020 21:00	1.2	12.0	2,089.5	0.8	6.30	1	1	1
07/20/2020 22:00	1.2	12.4	2,003.9	0.8	6.00	1	1	1
07/20/2020 23:00	1.0	13.0	1,777.5	0.7	5.30	1	1	1
Average/Sum#:	1.0	13.1	1,715.5	0.8	116.00 #	24 #	24 #	12 #
Minimum:	0.7	11.6	1,283.1	0.6	2.60	1	1	0
Maximum:	1.3	13.9	2,124.9	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/21/2020 00:00	0.7	13.9	1,284.2	0.6	2.60	1	1	0
07/21/2020 01:00	0.7	13.9	1,285.2	0.6	2.60	1	1	0
07/21/2020 02:00	0.7	13.9	1,285.0	0.6	2.60	1	1	0
07/21/2020 03:00	0.7	13.9	1,283.1	0.6	2.60	1	1	0
07/21/2020 04:00	0.7	13.9	1,283.6	0.6	2.60	1	1	0
07/21/2020 05:00	0.8	13.9	1,296.0	0.7	2.60	1	1	0
07/21/2020 06:00	1.0	13.9	1,652.7	0.8	5.00	1	1	0
07/21/2020 07:00	1.0	13.9	1,529.9	0.8	4.60	1	1	0
07/21/2020 08:00	1.0	13.9	1,526.6	0.8	4.60	1	1	0
07/21/2020 09:00	0.9	13.9	1,371.1	0.8	4.10	1	1	0
07/21/2020 10:00	1.0	13.9	1,507.4	0.8	4.50	1	1	0
07/21/2020 11:00	1.0	13.9	1,369.6	0.8	4.10	1	1	0
07/21/2020 12:00	0.9	13.9	1,383.2	0.8	4.10	1	1	0
07/21/2020 13:00	1.1	12.9	1,810.3	0.8	5.40	1	1	1
07/21/2020 14:00	1.3	11.8	2,078.6	0.8	6.20	1	1	1
07/21/2020 15:00	1.3	11.7	2,090.3	0.8	6.30	1	1	1
07/21/2020 16:00	1.3	11.6	2,122.9	0.8	6.40	1	1	1
07/21/2020 17:00	1.3	11.5	2,161.6	0.8	6.50	1	1	1
07/21/2020 18:00	1.3	11.5	2,152.9	0.8	6.50	1	1	1
07/21/2020 19:00	1.3	11.7	2,123.4	0.8	6.40	1	1	1
07/21/2020 20:00	1.3	11.8	2,120.7	0.8	6.40	1	1	1
07/21/2020 21:00	1.3	12.0	2,091.9	0.9	6.30	1	1	1
07/21/2020 22:00	1.2	12.5	1,984.9	0.8	6.00	1	1	1
07/21/2020 23:00	1.1	13.0	1,838.6	0.8	5.50	1	1	1
Average/Sum#:	1.0	13.0	1,693.1	0.8	114.50 #	24 #	24 #	11 #
Minimum:	0.7	11.5	1,283.1	0.6	2.60	1	1	0
Maximum:	1.3	13.9	2,161.6	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOX, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/22/2020 00:00	0.7	13.9	1,394.0	0.6	2.80	1	1	0
07/22/2020 01:00	0.7	13.9	1,283.5	0.6	2.60	1	1	0
07/22/2020 02:00	0.7	13.9	1,284.0	0.6	2.60	1	1	0
07/22/2020 03:00	0.7	13.9	1,284.0	0.6	2.60	1	1	0
07/22/2020 04:00	0.7	13.9	1,297.4	0.6	2.60	1	1	0
07/22/2020 05:00	0.8	13.9	1,377.5	0.7	2.80	1	1	0
07/22/2020 06:00	1.0	13.8	1,661.4	0.8	5.00	1	1	0
07/22/2020 07:00	0.8	13.9	1,360.4	0.7	2.70	1	1	0
07/22/2020 08:00	0.8	13.9	1,297.1	0.7	2.60	1	1	0
07/22/2020 09:00	0.8	13.9	1,299.4	0.7	2.60	1	1	0
07/22/2020 10:00	0.8	13.9	1,301.1	0.7	2.60	1	1	0
07/22/2020 11:00	0.8	14.0	1,301.5	0.7	3.90	1	1	0
07/22/2020 12:00	0.8	14.0	1,294.0	0.7	3.90	1	1	0
07/22/2020 13:00	0.8	14.0	1,292.3	0.7	3.90	1	1	0
07/22/2020 14:00	0.8	14.0	1,293.2	0.7	3.90	1	1	0
07/22/2020 15:00	0.8	14.0	1,301.2	0.7	3.90	1	1	0
07/22/2020 16:00	1.0	13.9	1,629.3	0.8	4.90	1	1	1
07/22/2020 17:00	1.2	12.1	2,047.5	0.8	6.10	1	1	1
07/22/2020 18:00	1.3	11.9	2,102.4	0.9	6.30	1	1	1
07/22/2020 19:00	1.3	11.9	2,097.8	0.9	6.30	1	1	1
07/22/2020 20:00	1.2	12.0	2,098.2	0.8	6.30	1	1	1
07/22/2020 21:00	1.2	12.0	2,092.7	0.8	6.30	1	1	1
07/22/2020 22:00	1.2	12.6	1,971.0	0.9	5.90	1	1	1
07/22/2020 23:00	1.0	13.1	1,778.2	0.8	5.30	1	1	1
Average/Sum#:	0.9	13.4	1,547.5	0.7	98.40 #	24 #	24 #	8 #
Minimum:	0.7	11.9	1,283.5	0.6	2.60	1	1	0
Maximum:	1.3	14.0	2,102.4	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/23/2020 00:00	0.7	13.9	1,288.7	0.6	2.60	1	1	0
07/23/2020 01:00	0.7	13.9	1,283.7	0.6	2.60	1	1	0
07/23/2020 02:00	0.7	13.9	1,282.6	0.6	2.60	1	1	0
07/23/2020 03:00	0.8	13.9	1,282.1	0.7	2.60	1	1	0
07/23/2020 04:00	0.7	13.9	1,283.1	0.6	2.60	1	1	0
07/23/2020 05:00	0.8	13.9	1,287.5	0.7	2.60	1	1	0
07/23/2020 06:00	0.8	13.9	1,293.0	0.7	2.60	1	1	0
07/23/2020 07:00	0.8	13.9	1,296.0	0.7	2.60	1	1	0
07/23/2020 08:00	0.8	13.9	1,298.4	0.7	2.60	1	1	0
07/23/2020 09:00	0.8	13.9	1,297.5	0.7	2.60	1	1	0
07/23/2020 10:00	0.8	13.9	1,298.5	0.7	2.60	1	1	0
07/23/2020 11:00	0.8	13.9	1,288.6	0.7	2.60	1	1	0
07/23/2020 12:00	0.9	14.0	1,296.9	0.8	3.90	1	1	0
07/23/2020 13:00	0.9	14.0	1,288.4	0.8	3.90	1	1	0
07/23/2020 14:00	0.8	14.0	1,292.5	0.7	3.90	1	1	0
07/23/2020 15:00	0.8	14.0	1,295.6	0.7	3.90	1	1	0
07/23/2020 16:00	0.8	14.0	1,293.9	0.7	3.90	1	1	0
07/23/2020 17:00	0.9	13.9	1,409.0	0.8	4.20	1	1	0
07/23/2020 18:00	1.0	13.8	1,628.4	0.8	4.90	1	1	0
07/23/2020 19:00	1.0	13.8	1,612.2	0.8	4.80	1	1	0
07/23/2020 20:00	0.9	13.8	1,431.3	0.7	4.30	1	1	0
07/23/2020 21:00	0.9	13.9	1,336.6	0.8	4.00	1	1	0
07/23/2020 22:00	0.8	13.9	1,288.1	0.7	2.60	1	1	0
07/23/2020 23:00	0.9	13.9	1,325.9	0.8	4.00	1	1	0
Average/Sum#:	0.8	13.9	1,332.4	0.7	79.50 #	24 #	24 #	0 #
Minimum:	0.7	13.8	1,282.1	0.6	2.60	1	1	0
Maximum:	1.0	14.0	1,628.4	0.8	4.90	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOX, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/24/2020 00:00	0.8	13.9	1,283.6	0.7	2.60	1	1	0
07/24/2020 01:00	0.8	13.9	1,285.1	0.7	2.60	1	1	0
07/24/2020 02:00	0.7	13.9	1,281.4	0.6	2.60	1	1	0
07/24/2020 03:00	0.7	13.9	1,281.9	0.6	2.60	1	1	0
07/24/2020 04:00	0.7	13.9	1,287.1	0.6	2.60	1	1	0
07/24/2020 05:00	0.8	13.9	1,292.4	0.7	2.60	1	1	0
07/24/2020 06:00	0.8	13.9	1,323.8	0.7	2.60	1	1	0
07/24/2020 07:00	0.9	13.8	1,555.6	0.7	4.70	1	1	0
07/24/2020 08:00	0.8	13.8	1,472.3	0.7	2.90	1	1	0
07/24/2020 09:00	0.9	13.9	1,375.7	0.8	4.10	1	1	0
07/24/2020 10:00	1.0	13.9	1,380.6	0.8	4.10	1	1	0
07/24/2020 11:00	1.0	13.9	1,388.3	0.8	4.20	1	1	0
07/24/2020 12:00	1.0	13.9	1,391.0	0.8	4.20	1	1	0
07/24/2020 13:00	1.0	13.9	1,393.8	0.8	4.20	1	1	0
07/24/2020 14:00	1.0	13.9	1,396.5	0.8	4.20	1	1	0
07/24/2020 15:00	1.0	14.0	1,396.5	0.9	4.20	1	1	0
07/24/2020 16:00	1.0	13.9	1,418.4	0.8	4.30	1	1	1
07/24/2020 17:00	1.2	12.5	1,951.8	0.8	5.90	1	1	1
07/24/2020 18:00	1.2	12.4	1,975.1	0.8	5.90	1	1	1
07/24/2020 19:00	1.2	12.5	1,969.8	0.8	5.90	1	1	1
07/24/2020 20:00	1.2	12.5	1,930.2	0.8	5.80	1	1	1
07/24/2020 21:00	0.8	13.9	1,387.5	0.7	2.80	1	1	0
07/24/2020 22:00	0.9	13.9	1,373.4	0.8	4.10	1	1	0
07/24/2020 23:00	0.9	13.9	1,373.1	0.8	4.10	1	1	0
Average/Sum#:	0.9	13.7	1,465.2	0.8	93.80 #	24 #	24 #	5 #
Minimum:	0.7	12.4	1,281.4	0.6	2.60	1	1	0
Maximum:	1.2	14.0	1,975.1	0.9	5.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/25/2020 00:00	0.9	13.9	1,374.7	0.8	4.10	1	1	0
07/25/2020 01:00	0.9	13.9	1,377.2	0.8	4.10	1	1	0
07/25/2020 02:00	0.9	13.9	1,376.3	0.8	4.10	1	1	0
07/25/2020 03:00	0.9	13.9	1,374.2	0.8	4.10	1	1	0
07/25/2020 04:00	0.9	13.9	1,373.5	0.8	4.10	1	1	0
07/25/2020 05:00	0.9	13.9	1,373.9	0.8	4.10	1	1	0
07/25/2020 06:00	0.9	13.9	1,378.8	0.8	4.10	1	1	0
07/25/2020 07:00	0.9	13.9	1,386.9	0.8	4.20	1	1	0
07/25/2020 08:00	1.0	13.9	1,390.1	0.8	4.20	1	1	0
07/25/2020 09:00	1.0	13.9	1,390.3	0.8	4.20	1	1	0
07/25/2020 10:00	1.0	13.9	1,393.8	0.8	4.20	1	1	0
07/25/2020 11:00	1.0	13.9	1,393.4	0.8	4.20	1	1	0
07/25/2020 12:00	1.0	13.9	1,394.1	0.8	4.20	1	1	0
07/25/2020 13:00	1.0	13.9	1,546.5	0.8	4.60	1	1	0
07/25/2020 14:00	0.9	13.9	1,494.7	0.8	4.50	1	1	0
07/25/2020 15:00	1.0	13.9	1,555.1	0.8	4.70	1	1	0
07/25/2020 16:00	0.9	13.9	1,543.5	0.8	4.60	1	1	1
07/25/2020 17:00	1.3	12.1	2,050.1	0.9	6.20	1	1	1
07/25/2020 18:00	1.3	11.7	2,123.1	0.8	6.40	1	1	1
07/25/2020 19:00	1.3	11.7	2,128.3	0.8	6.40	1	1	1
07/25/2020 20:00	1.3	11.8	2,123.7	0.8	6.40	1	1	1
07/25/2020 21:00	1.3	11.9	2,104.6	0.9	6.30	1	1	1
07/25/2020 22:00	1.2	12.2	2,043.3	0.8	6.10	1	1	1
07/25/2020 23:00	1.2	12.0	2,056.7	0.8	6.20	1	1	1
Average/Sum#:	1.0	13.3	1,614.5	0.8	116.30 #	24 #	24 #	8 #
Minimum:	0.9	11.7	1,373.5	0.8	4.10	1	1	0
Maximum:	1.3	13.9	2,128.3	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOX, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOX, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/26/2020 00:00	0.8	13.9	1,446.6	0.7	2.90	1	1	0
07/26/2020 01:00	1.0	13.9	1,600.8	0.8	4.80	1	1	0
07/26/2020 02:00	1.0	13.9	1,545.7	0.8	4.60	1	1	0
07/26/2020 03:00	1.0	13.9	1,502.5	0.8	4.50	1	1	0
07/26/2020 04:00	1.0	13.9	1,533.0	0.8	4.60	1	1	0
07/26/2020 05:00	0.8	13.9	1,412.1	0.7	2.80	1	1	0
07/26/2020 06:00	0.7	13.9	1,284.0	0.6	2.60	1	1	0
07/26/2020 07:00	0.8	13.9	1,284.6	0.7	2.60	1	1	0
07/26/2020 08:00	0.8	13.9	1,286.0	0.7	2.60	1	1	0
07/26/2020 09:00	0.8	13.9	1,290.0	0.7	2.60	1	1	0
07/26/2020 10:00	0.9	13.9	1,380.2	0.8	4.10	1	1	0
07/26/2020 11:00	1.0	13.9	1,535.8	0.8	4.60	1	1	0
07/26/2020 12:00	1.0	13.9	1,549.6	0.8	4.60	1	1	0
07/26/2020 13:00	1.0	13.8	1,700.5	0.8	5.10	1	1	1
07/26/2020 14:00	1.2	12.1	2,034.1	0.8	6.10	1	1	1
07/26/2020 15:00	1.1	13.4	1,629.4	0.9	4.90	1	1	1
07/26/2020 16:00	1.1	12.9	1,790.6	0.8	5.40	1	1	1
07/26/2020 17:00	1.3	11.4	2,168.3	0.8	6.50	1	1	1
07/26/2020 18:00	1.3	11.4	2,165.2	0.8	6.50	1	1	1
07/26/2020 19:00	1.3	11.3	2,175.3	0.8	6.50	1	1	1
07/26/2020 20:00	1.3	11.6	2,131.5	0.8	6.40	1	1	1
07/26/2020 21:00	1.3	11.7	2,119.2	0.8	6.40	1	1	1
07/26/2020 22:00	1.2	12.4	1,988.7	0.8	6.00	1	1	1
07/26/2020 23:00	1.1	12.8	1,795.9	0.8	5.40	1	1	1
Average/Sum#:	1.0	13.1	1,681.2	0.8	113.10 #	24 #	24 #	11 #
Minimum:	0.7	11.3	1,284.0	0.6	2.60	1	1	0
Maximum:	1.3	13.9	2,175.3	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/27/2020 00:00	0.8	13.9	1,288.5	0.7	2.60	1	1	0
07/27/2020 01:00	0.8	13.9	1,284.7	0.7	2.60	1	1	0
07/27/2020 02:00	0.8	13.9	1,285.9	0.7	2.60	1	1	0
07/27/2020 03:00	0.8	13.9	1,288.4	0.7	2.60	1	1	0
07/27/2020 04:00	0.8	13.9	1,297.2	0.7	2.60	1	1	0
07/27/2020 05:00	0.8	13.8	1,645.4	0.7	3.30	1	1	0
07/27/2020 06:00	1.0	13.9	1,674.0	0.8	5.00	1	1	0
07/27/2020 07:00	1.0	13.9	1,681.9	0.8	5.00	1	1	0
07/27/2020 08:00	1.0	13.9	1,646.3	0.8	4.90	1	1	0
07/27/2020 09:00	0.8	13.9	1,345.5	0.7	2.70	1	1	0
07/27/2020 10:00	1.0	13.9	1,572.6	0.8	4.70	1	1	0
07/27/2020 11:00	0.9	13.8	1,545.0	0.7	4.60	1	1	1
07/27/2020 12:00	1.4	12.0	2,071.9	0.9	6.20	1	1	1
07/27/2020 13:00	1.4	11.5	2,140.3	0.9	6.40	1	1	1
07/27/2020 14:00	1.4	11.6	2,107.6	0.9	6.30	1	1	1
07/27/2020 15:00	1.5	11.4	2,149.8	0.9	6.40	1	1	1
07/27/2020 16:00	1.5	11.3	2,155.5	0.9	6.50	1	1	1
07/27/2020 17:00	1.5	11.3	2,161.2	0.9	6.50	1	1	1
07/27/2020 18:00	1.4	11.4	2,144.7	0.9	6.40	1	1	1
07/27/2020 19:00	1.4	11.5	2,130.7	0.9	6.40	1	1	1
07/27/2020 20:00	1.5	11.3	2,174.2	0.9	6.50	1	1	1
07/27/2020 21:00	1.4	11.5	2,134.4	0.9	6.40	1	1	1
07/27/2020 22:00	1.4	11.6	2,129.7	0.9	6.40	1	1	1
07/27/2020 23:00	1.3	12.3	1,962.6	0.9	5.90	1	1	1
Average/Sum#:	1.2	12.7	1,792.4	0.8	119.50 #	24 #	24 #	13 #
Minimum:	0.8	11.3	1,284.7	0.7	2.60	1	1	0
Maximum:	1.5	13.9	2,174.2	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/28/2020 00:00	1.1	13.8	1,545.8	0.9	4.60	1	1	0
07/28/2020 01:00	1.1	13.8	1,507.2	0.9	4.50	1	1	0
07/28/2020 02:00	1.0	13.8	1,427.7	0.8	4.30	1	1	0
07/28/2020 03:00	1.1	13.8	1,505.6	0.9	4.50	1	1	0
07/28/2020 04:00	1.0	13.8	1,541.3	0.8	4.60	1	1	0
07/28/2020 05:00	1.1	13.8	1,600.3	0.9	4.80	1	1	0
07/28/2020 06:00	1.1	13.8	1,690.1	0.9	5.10	1	1	0
07/28/2020 07:00	1.1	13.8	1,674.4	0.9	5.00	1	1	0
07/28/2020 08:00	1.1	13.8	1,524.7	0.9	4.60	1	1	0
07/28/2020 09:00	0.8	13.9	1,314.4	0.7	2.60	1	1	0
07/28/2020 10:00	1.1	13.9	1,519.9	0.9	4.60	1	1	0
07/28/2020 11:00	1.0	13.8	1,511.6	0.8	4.50	1	1	1
07/28/2020 12:00	1.4	12.0	2,070.1	0.9	6.20	1	1	1
07/28/2020 13:00	1.4	11.7	2,115.1	0.9	6.30	1	1	1
07/28/2020 14:00	1.4	11.5	2,123.5	0.9	6.40	1	1	1
07/28/2020 15:00	1.4	11.3	2,159.6	0.9	6.50	1	1	1
07/28/2020 16:00	1.5	11.3	2,162.5	0.9	6.50	1	1	1
07/28/2020 17:00	1.5	11.3	2,159.1	0.9	6.50	1	1	1
07/28/2020 18:00	1.5	11.3	2,163.8	0.9	6.50	1	1	1
07/28/2020 19:00	1.4	11.5	2,123.5	0.9	6.40	1	1	1
07/28/2020 20:00	1.4	11.7	2,144.0	0.9	6.40	1	1	1
07/28/2020 21:00	1.4	11.7	2,146.5	0.9	6.40	1	1	1
07/28/2020 22:00	1.4	11.8	2,119.2	0.9	6.40	1	1	1
07/28/2020 23:00	1.4	11.9	2,093.8	0.9	6.30	1	1	1
Average/Sum#:	1.2	12.7	1,831.0	0.9	130.50 #	24 #	24 #	13 #
Minimum:	0.8	11.3	1,314.4	0.7	2.60	1	1	0
Maximum:	1.5	13.9	2,163.8	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/29/2020 00:00	1.3	12.5	1,974.7	0.9	5.90	1	1	1
07/29/2020 01:00	1.3	12.7	1,946.8	0.9	5.80	1	1	1
07/29/2020 02:00	1.3	12.7	1,945.1	0.9	5.80	1	1	1
07/29/2020 03:00	1.3	12.7	1,955.6	0.9	5.90	1	1	1
07/29/2020 04:00	1.4	12.2	2,066.8	0.9	6.20	1	1	1
07/29/2020 05:00	1.6	12.1	2,085.2	1.1	8.30	1	1	1
07/29/2020 06:00	1.3	12.2	2,070.4	0.9	6.20	1	1	1
07/29/2020 07:00	1.3	12.7	1,955.9	0.9	5.90	1	1	1
07/29/2020 08:00	1.3	12.7	1,952.9	0.9	5.90	1	1	1
07/29/2020 09:00	1.3	12.6	1,969.4	0.9	5.90	1	1	1
07/29/2020 10:00	1.4	12.0	2,090.0	0.9	6.30	1	1	1
07/29/2020 11:00	1.4	11.8	2,107.2	0.9	6.30	1	1	1
07/29/2020 12:00	1.4	11.8	2,122.6	0.9	6.40	1	1	1
07/29/2020 13:00	1.4	11.7	2,114.3	0.9	6.30	1	1	1
07/29/2020 14:00	1.5	11.4	2,160.3	0.9	6.50	1	1	1
07/29/2020 15:00	1.5	11.3	2,173.9	0.9	6.50	1	1	1
07/29/2020 16:00	1.5	11.4	2,165.9	0.9	6.50	1	1	1
07/29/2020 17:00	1.5	11.4	2,164.1	0.9	6.50	1	1	1
07/29/2020 18:00	1.4	11.4	2,157.9	0.9	6.50	1	1	1
07/29/2020 19:00	1.4	11.4	2,176.3	0.9	6.50	1	1	1
07/29/2020 20:00	1.4	11.5	2,164.4	0.9	6.50	1	1	1
07/29/2020 21:00	1.4	11.8	2,113.1	0.9	6.30	1	1	1
07/29/2020 22:00	1.4	11.7	2,136.9	0.9	6.40	1	1	1
07/29/2020 23:00	1.4	11.8	2,114.2	0.9	6.30	1	1	1
Average/Sum#:	1.4	12.0	2,078.5	0.9	151.60 #	24 #	24 #	24 #
Minimum:	1.3	11.3	1,945.1	0.9	5.80	1	1	1
Maximum:	1.6	12.7	2,176.3	1.1	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/30/2020 00:00	1.4	12.0	2,084.3	0.9	6.30	1	1	1
07/30/2020 01:00	1.3	12.6	1,963.5	0.9	5.90	1	1	1
07/30/2020 02:00	1.3	12.7	1,947.6	0.9	5.80	1	1	1
07/30/2020 03:00	1.2	12.8	1,942.8	0.9	5.80	1	1	1
07/30/2020 04:00	1.3	12.8	1,954.0	0.9	5.90	1	1	1
07/30/2020 05:00	1.3	12.1	2,080.0	0.9	6.20	1	1	1
07/30/2020 06:00	1.4	12.2	2,065.9	0.9	6.20	1	1	1
07/30/2020 07:00	1.3	12.7	1,951.1	0.9	5.90	1	1	1
07/30/2020 08:00	1.3	12.7	1,947.5	0.9	5.80	1	1	1
07/30/2020 09:00	1.3	12.6	1,966.1	0.9	5.90	1	1	1
07/30/2020 10:00	1.4	12.0	2,087.4	0.9	6.30	1	1	1
07/30/2020 11:00	1.4	11.8	2,121.5	0.9	6.40	1	1	1
07/30/2020 12:00	1.4	11.9	2,110.1	0.9	6.30	1	1	1
07/30/2020 13:00	1.4	11.8	2,112.2	0.9	6.30	1	1	1
07/30/2020 14:00	1.4	11.7	2,121.2	0.9	6.40	1	1	1
07/30/2020 15:00	1.4	11.4	2,151.8	0.9	6.50	1	1	1
07/30/2020 16:00	1.4	11.4	2,159.8	0.9	6.50	1	1	1
07/30/2020 17:00	1.4	11.3	2,173.8	0.9	6.50	1	1	1
07/30/2020 18:00	1.4	11.3	2,169.5	0.9	6.50	1	1	1
07/30/2020 19:00	1.4	11.9	2,066.4	0.9	6.20	1	1	1
07/30/2020 20:00	1.4	11.9	2,081.1	0.9	6.20	1	1	1
07/30/2020 21:00	1.4	12.0	2,068.3	0.9	6.20	1	1	1
07/30/2020 22:00	1.4	11.8	2,113.9	0.9	6.30	1	1	1
07/30/2020 23:00	1.4	12.1	2,056.0	0.9	6.20	1	1	1
Average/Sum#:	1.4	12.1	2,062.3	0.9	148.50 #	24 #	24 #	24 #
Minimum:	1.2	11.3	1,942.8	0.9	5.80	1	1	1
Maximum:	1.4	12.8	2,173.8	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/31/2020 00:00	1.3	12.5	1,975.4	0.9	5.90	1	1	1
07/31/2020 01:00	1.3	12.7	1,939.8	0.9	5.80	1	1	1
07/31/2020 02:00	1.3	12.8	1,936.5	0.9	5.80	1	1	1
07/31/2020 03:00	1.3	12.8	1,935.9	0.9	5.80	1	1	1
07/31/2020 04:00	1.3	12.8	1,944.4	0.9	5.80	1	1	1
07/31/2020 05:00	1.4	12.2	2,042.6	0.9	6.10	1	1	1
07/31/2020 06:00	1.3	12.2	2,052.4	0.9	6.20	1	1	1
07/31/2020 07:00	1.3	12.6	1,963.0	0.9	5.90	1	1	1
07/31/2020 08:00	1.3	12.7	1,938.8	0.9	5.80	1	1	1
07/31/2020 09:00	1.3	12.4	2,004.3	0.9	6.00	1	1	1
07/31/2020 10:00	1.4	12.0	2,080.2	0.9	6.20	1	1	1
07/31/2020 11:00	1.4	11.8	2,104.9	0.9	6.30	1	1	1
07/31/2020 12:00	1.4	11.8	2,105.7	0.9	6.30	1	1	1
07/31/2020 13:00	1.4	11.7	2,115.5	0.9	6.30	1	1	1
07/31/2020 14:00	1.4	11.6	2,120.0	0.9	6.40	1	1	1
07/31/2020 15:00	1.4	11.5	2,131.8	0.9	6.40	1	1	1
07/31/2020 16:00	1.4	11.5	2,132.0	0.9	6.40	1	1	1
07/31/2020 17:00	1.4	11.5	2,123.0	0.9	6.40	1	1	1
07/31/2020 18:00	1.5	11.3	2,165.2	0.9	6.50	1	1	1
07/31/2020 19:00	1.4	11.6	2,114.5	0.9	6.30	1	1	1
07/31/2020 20:00	1.4	11.7	2,118.4	0.9	6.40	1	1	1
07/31/2020 21:00	1.4	11.8	2,093.8	0.9	6.30	1	1	1
07/31/2020 22:00	1.4	11.9	2,084.6	0.9	6.30	1	1	1
07/31/2020 23:00	1.4	12.0	2,063.1	0.9	6.20	1	1	1
Average/Sum#:	1.4	12.1	2,053.6	0.9	147.80 #	24 #	24 #	24 #
Minimum:	1.3	11.3	1,935.9	0.9	5.80	1	1	1
Maximum:	1.5	12.8	2,165.2	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOX, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOX, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/01/2020 00:00	1.4	12.2	2,048.4	0.9	6.10	1	1	1
08/01/2020 01:00	1.3	12.7	1,949.3	0.9	5.80	1	1	1
08/01/2020 02:00	1.3	12.8	1,909.8	0.9	5.70	1	1	1
08/01/2020 03:00	0.9	13.8	1,435.4	0.7	4.30	1	1	0
08/01/2020 04:00	1.1	13.8	1,527.8	0.9	4.60	1	1	0
08/01/2020 05:00	1.1	13.8	1,543.4	0.9	4.60	1	1	0
08/01/2020 06:00	0.8	13.9	1,302.0	0.7	2.60	1	1	0
08/01/2020 07:00	0.9	13.9	1,290.5	0.8	3.90	1	1	0
08/01/2020 08:00	0.9	13.9	1,292.1	0.8	3.90	1	1	0
08/01/2020 09:00	0.9	13.9	1,297.1	0.8	3.90	1	1	0
08/01/2020 10:00	1.1	13.8	1,436.9	0.9	4.30	1	1	0
08/01/2020 11:00	1.0	13.8	1,511.6	0.8	4.50	1	1	1
08/01/2020 12:00	1.4	12.1	2,052.7	0.9	6.20	1	1	1
08/01/2020 13:00	1.4	11.8	2,103.4	0.9	6.30	1	1	1
08/01/2020 14:00	1.4	11.7	2,108.3	0.9	6.30	1	1	1
08/01/2020 15:00	1.4	11.7	2,129.4	0.9	6.40	1	1	1
08/01/2020 16:00	1.4	11.6	2,149.5	0.9	6.40	1	1	1
08/01/2020 17:00	1.4	11.6	2,161.5	0.9	6.50	1	1	1
08/01/2020 18:00	1.4	11.6	2,154.9	0.9	6.50	1	1	1
08/01/2020 19:00	1.4	11.6	2,155.9	0.9	6.50	1	1	1
08/01/2020 20:00	1.4	11.6	2,149.8	0.9	6.40	1	1	1
08/01/2020 21:00	1.4	11.8	2,093.4	0.9	6.30	1	1	1
08/01/2020 22:00	1.4	11.9	2,087.7	0.9	6.30	1	1	1
08/01/2020 23:00	1.3	12.5	1,932.0	0.9	5.80	1	1	1
Average/Sum#:	1.2	12.7	1,826.0	0.9	130.10 #	24 #	24 #	16 #
Minimum:	0.8	11.6	1,290.5	0.7	2.60	1	1	0
Maximum:	1.4	13.9	2,161.5	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOX, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/02/2020 00:00	0.9	13.8	1,427.2	0.7	4.30	1	1	0
08/02/2020 01:00	0.8	13.9	1,285.3	0.7	2.60	1	1	0
08/02/2020 02:00	0.8	13.9	1,288.3	0.7	2.60	1	1	0
08/02/2020 03:00	0.8	13.9	1,292.4	0.7	2.60	1	1	0
08/02/2020 04:00	1.1	13.8	1,497.1	0.9	4.50	1	1	0
08/02/2020 05:00	0.9	13.9	1,383.8	0.8	4.20	1	1	0
08/02/2020 06:00	0.8	13.9	1,295.7	0.7	2.60	1	1	0
08/02/2020 07:00	0.8	13.9	1,293.1	0.7	2.60	1	1	0
08/02/2020 08:00	0.9	13.9	1,294.2	0.8	3.90	1	1	0
08/02/2020 09:00	0.9	13.9	1,298.7	0.8	3.90	1	1	0
08/02/2020 10:00	0.9	13.9	1,302.2	0.8	3.90	1	1	0
08/02/2020 11:00	0.9	13.9	1,304.3	0.8	3.90	1	1	0
08/02/2020 12:00	0.9	13.9	1,301.4	0.8	3.90	1	1	0
08/02/2020 13:00	0.9	13.9	1,313.6	0.8	3.90	1	1	0
08/02/2020 14:00	1.1	13.9	1,365.4	0.9	4.10	1	1	0
08/02/2020 15:00	1.1	13.8	1,520.5	0.9	4.60	1	1	1
08/02/2020 16:00	1.4	12.2	2,010.3	0.9	6.00	1	1	1
08/02/2020 17:00	1.4	11.8	2,090.9	0.9	6.30	1	1	1
08/02/2020 18:00	1.4	11.8	2,093.1	0.9	6.30	1	1	1
08/02/2020 19:00	1.4	11.6	2,123.9	0.9	6.40	1	1	1
08/02/2020 20:00	1.4	11.8	2,100.9	0.9	6.30	1	1	1
08/02/2020 21:00	1.4	11.7	2,115.0	0.9	6.30	1	1	1
08/02/2020 22:00	1.4	11.8	2,094.1	0.9	6.30	1	1	1
08/02/2020 23:00	1.3	12.5	1,947.4	0.9	5.80	1	1	1
Average/Sum#:	1.1	13.2	1,585.0	0.8	107.80 #	24 #	24 #	9 #
Minimum:	0.8	11.6	1,285.3	0.7	2.60	1	1	0
Maximum:	1.4	13.9	2,123.9	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/03/2020 00:00	0.9	13.8	1,436.0	0.7	4.30	1	1	0
08/03/2020 01:00	0.9	13.8	1,320.2	0.7	4.00	1	1	0
08/03/2020 02:00	0.8	13.9	1,284.0	0.7	2.60	1	1	0
08/03/2020 03:00	0.9	13.9	1,292.9	0.8	3.90	1	1	0
08/03/2020 04:00	1.1	13.8	1,509.6	0.9	4.50	1	1	0
08/03/2020 05:00	1.0	13.8	1,490.3	0.8	4.50	1	1	0
08/03/2020 06:00	1.1	13.8	1,577.3	0.9	4.70	1	1	0
08/03/2020 07:00	1.2	13.8	1,539.3	1.0	6.20	1	1	0
08/03/2020 08:00	1.1	13.8	1,485.5	0.9	4.50	1	1	0
08/03/2020 09:00	1.0	13.8	1,375.4	0.8	4.10	1	1	0
08/03/2020 10:00	0.9	13.9	1,301.4	0.8	3.90	1	1	0
08/03/2020 11:00	1.1	13.9	1,363.0	0.9	4.10	1	1	0
08/03/2020 12:00	1.0	13.8	1,501.1	0.8	4.50	1	1	1
08/03/2020 13:00	1.4	12.0	2,057.8	0.9	6.20	1	1	1
08/03/2020 14:00	1.4	11.8	2,097.3	0.9	6.30	1	1	1
08/03/2020 15:00	1.4	11.8	2,088.5	0.9	6.30	1	1	1
08/03/2020 16:00	1.4	11.7	2,090.2	0.9	6.30	1	1	1
08/03/2020 17:00	1.4	11.6	2,101.4	0.9	6.30	1	1	1
08/03/2020 18:00	1.4	11.6	2,094.0	0.9	6.30	1	1	1
08/03/2020 19:00	1.4	11.6	2,118.2	0.9	6.40	1	1	1
08/03/2020 20:00	1.4	11.7	2,103.1	0.9	6.30	1	1	1
08/03/2020 21:00	1.4	11.7	2,108.6	0.9	6.30	1	1	1
08/03/2020 22:00	1.4	11.8	2,095.8	0.9	6.30	1	1	1
08/03/2020 23:00	1.2	12.8	1,799.3	0.9	5.40	1	1	1
Average/Sum#:	1.2	12.9	1,717.9	0.9	124.20 #	24 #	24 #	12 #
Minimum:	0.8	11.6	1,284.0	0.7	2.60	1	1	0
Maximum:	1.4	13.9	2,118.2	1.0	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/04/2020 00:00	0.8	13.8	1,288.2	0.7	2.60	1	1	0
08/04/2020 01:00	0.8	13.8	1,284.7	0.7	2.60	1	1	0
08/04/2020 02:00	0.8	13.8	1,294.4	0.7	2.60	1	1	0
08/04/2020 03:00	0.8	13.8	1,290.2	0.7	2.60	1	1	0
08/04/2020 04:00	0.8	13.8	1,293.1	0.7	2.60	1	1	0
08/04/2020 05:00	1.0	13.8	1,407.2	0.8	4.20	1	1	0
08/04/2020 06:00	0.9	13.8	1,303.5	0.7	3.90	1	1	0
08/04/2020 07:00	0.9	13.8	1,290.6	0.7	3.90	1	1	0
08/04/2020 08:00	0.9	13.8	1,291.4	0.7	3.90	1	1	0
08/04/2020 09:00	0.9	13.9	1,293.8	0.8	3.90	1	1	0
08/04/2020 10:00	0.9	13.9	1,301.9	0.8	3.90	1	1	0
08/04/2020 11:00	0.9	13.9	1,300.3	0.8	3.90	1	1	0
08/04/2020 12:00	1.0	13.9	1,438.4	0.8	4.30	1	1	0
08/04/2020 13:00	1.0	13.8	1,476.4	0.8	4.40	1	1	0
08/04/2020 14:00	0.8	13.9	1,319.8	0.7	2.60	1	1	0
08/04/2020 15:00	1.1	13.8	1,529.7	0.9	4.60	1	1	0
08/04/2020 16:00	1.0	13.8	1,506.0	0.8	4.50	1	1	1
08/04/2020 17:00	1.4	11.8	2,065.6	0.9	6.20	1	1	1
08/04/2020 18:00	1.4	11.5	2,118.0	0.9	6.40	1	1	1
08/04/2020 19:00	1.4	11.5	2,121.8	0.9	6.40	1	1	1
08/04/2020 20:00	1.4	11.7	2,104.5	0.9	6.30	1	1	1
08/04/2020 21:00	1.4	11.8	2,095.2	0.9	6.30	1	1	1
08/04/2020 22:00	1.3	12.4	1,975.2	0.9	5.90	1	1	1
08/04/2020 23:00	1.2	13.0	1,784.8	0.9	5.40	1	1	1
Average/Sum#:	1.0	13.3	1,548.9	0.8	103.90 #	24 #	24 #	8 #
Minimum:	0.8	11.5	1,284.7	0.7	2.60	1	1	0
Maximum:	1.4	13.9	2,121.8	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/05/2020 00:00	0.7	13.8	1,287.7	0.6	2.60	1	1	0
08/05/2020 01:00	0.8	13.8	1,288.6	0.7	2.60	1	1	0
08/05/2020 02:00	0.8	13.8	1,283.8	0.7	2.60	1	1	0
08/05/2020 03:00	0.8	13.8	1,284.0	0.7	2.60	1	1	0
08/05/2020 04:00	0.8	13.8	1,286.1	0.7	2.60	1	1	0
08/05/2020 05:00	0.9	13.8	1,319.3	0.7	4.00	1	1	0
08/05/2020 06:00	0.8	13.8	1,283.7	0.7	2.60	1	1	0
08/05/2020 07:00	0.8	13.8	1,284.1	0.7	2.60	1	1	0
08/05/2020 08:00	0.8	13.8	1,286.4	0.7	2.60	1	1	0
08/05/2020 09:00	0.9	13.8	1,288.3	0.7	3.90	1	1	0
08/05/2020 10:00	0.9	13.8	1,291.1	0.7	3.90	1	1	0
08/05/2020 11:00	0.9	13.8	1,293.9	0.7	3.90	1	1	0
08/05/2020 12:00	0.9	13.9	1,293.9	0.8	3.90	1	1	0
08/05/2020 13:00	0.9	13.9	1,294.5	0.8	3.90	1	1	0
08/05/2020 14:00	0.9	13.8	1,292.5	0.7	3.90	1	1	0
08/05/2020 15:00	0.9	13.8	1,290.9	0.7	3.90	1	1	0
08/05/2020 16:00	0.9	13.8	1,299.8	0.7	3.90	1	1	0
08/05/2020 17:00	1.2	13.1	1,762.6	0.9	5.30	1	1	1
08/05/2020 18:00	1.4	11.9	2,085.8	0.9	6.30	1	1	1
08/05/2020 19:00	1.4	12.1	2,011.9	0.9	6.00	1	1	1
08/05/2020 20:00	1.0	13.8	1,582.2	0.8	4.70	1	1	0
08/05/2020 21:00	0.9	13.8	1,405.7	0.7	4.20	1	1	0
08/05/2020 22:00	0.9	13.8	1,386.0	0.7	4.20	1	1	0
08/05/2020 23:00	0.8	13.8	1,284.9	0.7	2.60	1	1	0
Average/Sum#:	0.9	13.6	1,394.5	0.7	89.30 #	24 #	24 #	3 #
Minimum:	0.7	11.9	1,283.7	0.6	2.60	1	1	0
Maximum:	1.4	13.9	2,085.8	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/06/2020 00:00	0.8	13.8	1,283.5	0.7	2.60	1	1	0
08/06/2020 01:00	0.8	13.8	1,283.2	0.7	2.60	1	1	0
08/06/2020 02:00	0.8	13.8	1,283.6	0.7	2.60	1	1	0
08/06/2020 03:00	0.8	13.8	1,286.8	0.7	2.60	1	1	0
08/06/2020 04:00	0.8	13.8	1,303.4	0.7	2.60	1	1	0
08/06/2020 05:00	0.8	13.8	1,326.8	0.7	2.70	1	1	0
08/06/2020 06:00	0.8	13.8	1,290.6	0.7	2.60	1	1	0
08/06/2020 07:00	0.8	13.8	1,296.8	0.7	2.60	1	1	0
08/06/2020 08:00	0.8	13.8	1,298.4	0.7	2.60	1	1	0
08/06/2020 09:00	0.9	13.8	1,297.9	0.7	3.90	1	1	0
08/06/2020 10:00	0.9	13.8	1,296.8	0.7	3.90	1	1	0
08/06/2020 11:00	0.9	13.8	1,296.1	0.7	3.90	1	1	0
08/06/2020 12:00	0.9	13.9	1,296.0	0.8	3.90	1	1	0
08/06/2020 13:00	0.9	13.9	1,291.5	0.8	3.90	1	1	0
08/06/2020 14:00	0.9	13.9	1,290.9	0.8	3.90	1	1	0
08/06/2020 15:00	0.9	13.9	1,292.1	0.8	3.90	1	1	0
08/06/2020 16:00	0.9	13.9	1,289.8	0.8	3.90	1	1	0
08/06/2020 17:00	1.0	13.9	1,400.8	0.8	4.20	1	1	0
08/06/2020 18:00	1.0	13.8	1,401.5	0.8	4.20	1	1	0
08/06/2020 19:00	0.9	13.8	1,308.2	0.7	3.90	1	1	0
08/06/2020 20:00	0.9	13.8	1,284.3	0.7	3.90	1	1	0
08/06/2020 21:00	0.9	13.8	1,280.5	0.7	3.80	1	1	0
08/06/2020 22:00	0.9	13.8	1,279.5	0.7	3.80	1	1	0
08/06/2020 23:00	0.8	13.8	1,276.5	0.7	2.60	1	1	0
Average/Sum#:	0.9	13.8	1,301.5	0.7	81.10 #	24 #	24 #	0 #
Minimum:	0.8	13.8	1,276.5	0.7	2.60	1	1	0
Maximum:	1.0	13.9	1,401.5	0.8	4.20	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/07/2020 00:00	0.9	13.8	1,283.3	0.7	3.80	1	1	0
08/07/2020 01:00	0.8	13.8	1,282.3	0.7	2.60	1	1	0
08/07/2020 02:00	0.8	13.8	1,282.5	0.7	2.60	1	1	0
08/07/2020 03:00	0.8	13.8	1,283.2	0.7	2.60	1	1	0
08/07/2020 04:00	0.8	13.8	1,327.8	0.7	2.70	1	1	0
08/07/2020 05:00	0.9	13.8	1,317.6	0.7	4.00	1	1	0
08/07/2020 06:00	0.9	13.8	1,283.4	0.7	3.90	1	1	0
08/07/2020 07:00	0.9	13.8	1,287.6	0.7	3.90	1	1	0
08/07/2020 08:00	0.9	13.8	1,294.2	0.7	3.90	1	1	0
08/07/2020 09:00	0.9	13.9	1,297.4	0.8	3.90	1	1	0
08/07/2020 10:00	0.9	13.9	1,295.5	0.8	3.90	1	1	0
08/07/2020 11:00	0.9	13.9	1,295.8	0.8	3.90	1	1	0
08/07/2020 12:00	0.9	13.9	1,291.2	0.8	3.90	1	1	0
08/07/2020 13:00	1.0	13.9	1,347.5	0.8	4.00	1	1	0
08/07/2020 14:00	1.0	13.9	1,357.5	0.8	4.10	1	1	0
08/07/2020 15:00	0.9	13.9	1,295.0	0.8	3.90	1	1	0
08/07/2020 16:00	1.0	13.9	1,399.1	0.8	4.20	1	1	0
08/07/2020 17:00	1.0	13.8	1,464.7	0.8	4.40	1	1	0
08/07/2020 18:00	1.1	13.7	1,681.6	0.9	5.00	1	1	0
08/07/2020 19:00	1.2	13.7	1,643.7	1.0	6.60	1	1	0
08/07/2020 20:00	1.1	13.8	1,483.6	0.9	4.50	1	1	0
08/07/2020 21:00	0.9	13.8	1,338.2	0.7	4.00	1	1	0
08/07/2020 22:00	1.0	13.8	1,391.2	0.8	4.20	1	1	0
08/07/2020 23:00	1.0	13.8	1,445.2	0.8	4.30	1	1	0
Average/Sum#:	0.9	13.8	1,361.2	0.8	94.80 #	24 #	24 #	0 #
Minimum:	0.8	13.7	1,282.3	0.7	2.60	1	1	0
Maximum:	1.2	13.9	1,681.6	1.0	6.60	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/08/2020 00:00	0.9	13.8	1,350.6	0.7	4.10	1	1	0
08/08/2020 01:00	0.8	13.8	1,283.4	0.7	2.60	1	1	0
08/08/2020 02:00	0.8	13.8	1,280.7	0.7	2.60	1	1	0
08/08/2020 03:00	0.8	13.8	1,284.7	0.7	2.60	1	1	0
08/08/2020 04:00	0.8	13.8	1,288.0	0.7	2.60	1	1	0
08/08/2020 05:00	0.9	13.8	1,283.6	0.7	3.90	1	1	0
08/08/2020 06:00	0.9	13.8	1,284.2	0.7	3.90	1	1	0
08/08/2020 07:00	0.9	13.8	1,291.8	0.7	3.90	1	1	0
08/08/2020 08:00	0.9	13.8	1,290.4	0.7	3.90	1	1	0
08/08/2020 09:00	0.9	13.8	1,292.5	0.7	3.90	1	1	0
08/08/2020 10:00	1.0	13.8	1,295.0	0.8	3.90	1	1	0
08/08/2020 11:00	0.9	13.9	1,293.2	0.8	3.90	1	1	0
08/08/2020 12:00	0.9	13.9	1,292.2	0.8	3.90	1	1	0
08/08/2020 13:00	1.0	13.9	1,415.5	0.8	4.20	1	1	0
08/08/2020 14:00	0.7	13.9	1,325.3	0.6	2.70	1	1	0
08/08/2020 15:00	1.1	13.9	1,370.9	0.9	4.10	1	1	0
08/08/2020 16:00	1.1	13.8	1,446.5	0.9	4.30	1	1	1
08/08/2020 17:00	1.4	11.8	2,070.2	0.9	6.20	1	1	1
08/08/2020 18:00	1.5	11.4	2,149.9	0.9	6.40	1	1	1
08/08/2020 19:00	1.5	11.3	2,153.3	0.9	6.50	1	1	1
08/08/2020 20:00	1.4	11.6	2,109.5	0.9	6.30	1	1	1
08/08/2020 21:00	1.4	11.7	2,098.2	0.9	6.30	1	1	1
08/08/2020 22:00	1.4	12.2	2,002.8	0.9	6.00	1	1	1
08/08/2020 23:00	1.3	12.5	1,935.2	0.9	5.80	1	1	1
Average/Sum#:	1.1	13.2	1,537.0	0.8	104.50 #	24 #	24 #	8 #
Minimum:	0.7	11.3	1,280.7	0.6	2.60	1	1	0
Maximum:	1.5	13.9	2,153.3	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/09/2020 00:00	1.2	13.7	1,543.1	1.0	6.20	1	1	0
08/09/2020 01:00	0.9	13.8	1,303.9	0.7	3.90	1	1	0
08/09/2020 02:00	0.8	13.8	1,279.4	0.7	2.60	1	1	0
08/09/2020 03:00	0.8	13.8	1,285.1	0.7	2.60	1	1	0
08/09/2020 04:00	0.8	13.8	1,286.9	0.7	2.60	1	1	0
08/09/2020 05:00	0.8	13.8	1,287.5	0.7	2.60	1	1	0
08/09/2020 06:00	0.8	13.8	1,291.3	0.7	2.60	1	1	0
08/09/2020 07:00	0.9	13.8	1,294.1	0.7	3.90	1	1	0
08/09/2020 08:00	0.9	13.8	1,296.8	0.7	3.90	1	1	0
08/09/2020 09:00	0.9	13.8	1,294.8	0.7	3.90	1	1	0
08/09/2020 10:00	0.9	13.8	1,293.0	0.7	3.90	1	1	0
08/09/2020 11:00	0.9	13.9	1,295.2	0.8	3.90	1	1	0
08/09/2020 12:00	1.0	13.8	1,440.5	0.8	4.30	1	1	0
08/09/2020 13:00	0.9	13.8	1,511.7	0.7	4.50	1	1	0
08/09/2020 14:00	1.0	13.9	1,382.5	0.8	4.10	1	1	0
08/09/2020 15:00	1.1	13.6	1,599.8	0.9	4.80	1	1	1
08/09/2020 16:00	1.4	11.7	2,074.2	0.9	6.20	1	1	1
08/09/2020 17:00	1.5	11.3	2,135.8	0.9	6.40	1	1	1
08/09/2020 18:00	1.5	11.3	2,143.8	0.9	6.40	1	1	1
08/09/2020 19:00	1.4	11.5	2,105.2	0.9	6.30	1	1	1
08/09/2020 20:00	1.4	11.6	2,083.6	0.9	6.30	1	1	1
08/09/2020 21:00	1.4	11.6	2,110.4	0.9	6.30	1	1	1
08/09/2020 22:00	1.4	12.1	2,009.5	0.9	6.00	1	1	1
08/09/2020 23:00	1.3	12.4	1,931.7	0.9	5.80	1	1	1
Average/Sum#:	1.1	13.1	1,595.0	0.8	110.00 #	24 #	24 #	9 #
Minimum:	0.8	11.3	1,279.4	0.7	2.60	1	1	0
Maximum:	1.5	13.9	2,143.8	1.0	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/10/2020 00:00	1.0	13.7	1,416.0	0.8	4.20	1	1	0
08/10/2020 01:00	0.9	13.8	1,285.9	0.7	3.90	1	1	0
08/10/2020 02:00	0.8	13.8	1,293.1	0.7	2.60	1	1	0
08/10/2020 03:00	1.1	13.8	1,499.2	0.9	4.50	1	1	0
08/10/2020 04:00	1.2	13.8	1,528.1	1.0	6.10	1	1	0
08/10/2020 05:00	1.1	13.8	1,519.4	0.9	4.60	1	1	0
08/10/2020 06:00	1.1	13.7	1,614.1	0.9	4.80	1	1	0
08/10/2020 07:00	1.0	13.8	1,368.8	0.8	4.10	1	1	0
08/10/2020 08:00	1.2	13.8	1,499.3	1.0	6.00	1	1	0
08/10/2020 09:00	0.9	13.8	1,310.5	0.7	3.90	1	1	0
08/10/2020 10:00	1.1	13.8	1,523.8	0.9	4.60	1	1	0
08/10/2020 11:00	1.1	13.8	1,521.1	0.9	4.60	1	1	0
08/10/2020 12:00	0.9	13.9	1,306.0	0.8	3.90	1	1	0
08/10/2020 13:00	1.0	13.9	1,325.3	0.8	4.00	1	1	0
08/10/2020 14:00	1.0	13.9	1,332.1	0.8	4.00	1	1	0
08/10/2020 15:00	1.1	13.6	1,639.8	0.9	4.90	1	1	1
08/10/2020 16:00	1.4	11.6	2,082.7	0.9	6.20	1	1	1
08/10/2020 17:00	1.5	11.2	2,149.8	0.9	6.40	1	1	1
08/10/2020 18:00	1.4	11.5	2,089.6	0.9	6.30	1	1	1
08/10/2020 19:00	1.4	11.8	2,051.2	0.9	6.20	1	1	1
08/10/2020 20:00	1.4	11.9	2,037.5	0.9	6.10	1	1	1
08/10/2020 21:00	1.4	12.0	2,027.7	0.9	6.10	1	1	1
08/10/2020 22:00	1.3	12.3	1,975.4	0.9	5.90	1	1	1
08/10/2020 23:00	1.2	12.9	1,778.1	0.9	5.30	1	1	1
Average/Sum#:	1.1	13.2	1,632.3	0.9	119.20 #	24 #	24 #	9 #
Minimum:	0.8	11.2	1,285.9	0.7	2.60	1	1	0
Maximum:	1.5	13.9	2,149.8	1.0	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOX, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/11/2020 00:00	0.8	13.8	1,285.0	0.7	2.60	1	1	0
08/11/2020 01:00	0.8	13.8	1,284.5	0.7	2.60	1	1	0
08/11/2020 02:00	0.8	13.8	1,287.0	0.7	2.60	1	1	0
08/11/2020 03:00	0.8	13.8	1,288.2	0.7	2.60	1	1	0
08/11/2020 04:00	0.8	13.8	1,296.4	0.7	2.60	1	1	0
08/11/2020 05:00	0.8	13.8	1,305.9	0.7	2.60	1	1	0
08/11/2020 06:00	0.9	13.8	1,340.9	0.7	4.00	1	1	0
08/11/2020 07:00	0.8	13.8	1,290.2	0.7	2.60	1	1	0
08/11/2020 08:00	0.9	13.8	1,292.4	0.7	3.90	1	1	0
08/11/2020 09:00	0.9	13.8	1,294.6	0.7	3.90	1	1	0
08/11/2020 10:00	0.9	13.8	1,297.6	0.7	3.90	1	1	0
08/11/2020 11:00	0.9	13.8	1,300.1	0.7	3.90	1	1	0
08/11/2020 12:00	0.9	13.8	1,297.5	0.7	3.90	1	1	0
08/11/2020 13:00	0.9	13.8	1,298.2	0.7	3.90	1	1	0
08/11/2020 14:00	0.9	13.8	1,317.1	0.7	4.00	1	1	0
08/11/2020 15:00	1.0	13.8	1,332.3	0.8	4.00	1	1	0
08/11/2020 16:00	1.0	13.8	1,427.9	0.8	4.30	1	1	0
08/11/2020 17:00	1.1	13.8	1,568.3	0.9	4.70	1	1	0
08/11/2020 18:00	1.1	13.8	1,521.0	0.9	4.60	1	1	0
08/11/2020 19:00	1.0	13.8	1,377.6	0.8	4.10	1	1	0
08/11/2020 20:00	1.0	13.8	1,359.2	0.8	4.10	1	1	0
08/11/2020 21:00	0.9	13.8	1,306.5	0.7	3.90	1	1	0
08/11/2020 22:00	0.9	13.8	1,394.4	0.7	4.20	1	1	0
08/11/2020 23:00	0.8	13.8	1,300.7	0.7	2.60	1	1	0
Average/Sum#:	0.9	13.8	1,336.0	0.7	86.10 #	24 #	24 #	0 #
Minimum:	0.8	13.8	1,284.5	0.7	2.60	1	1	0
Maximum:	1.1	13.8	1,568.3	0.9	4.70	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/12/2020 00:00	0.8	13.8	1,288.7	0.7	2.60	1	1	0
08/12/2020 01:00	0.8	13.8	1,311.8	0.7	2.60	1	1	0
08/12/2020 02:00	0.8	13.8	1,288.9	0.7	2.60	1	1	0
08/12/2020 03:00	0.8	13.8	1,292.7	0.7	2.60	1	1	0
08/12/2020 04:00	0.8	13.8	1,312.3	0.7	2.60	1	1	0
08/12/2020 05:00	0.8	13.8	1,304.8	0.7	2.60	1	1	0
08/12/2020 06:00	0.8	13.8	1,299.1	0.7	2.60	1	1	0
08/12/2020 07:00	0.8	13.8	1,313.4	0.7	2.60	1	1	0
08/12/2020 08:00	1.0	13.8	1,385.8	0.8	4.20	1	1	0
08/12/2020 09:00	0.9	13.8	1,334.8	0.7	4.00	1	1	0
08/12/2020 10:00	0.9	13.8	1,342.3	0.7	4.00	1	1	0
08/12/2020 11:00	1.0	13.8	1,386.2	0.8	4.20	1	1	0
08/12/2020 12:00	1.0	13.7	1,644.1	0.8	4.90	1	1	1
08/12/2020 13:00	1.4	12.0	2,040.5	0.9	6.10	1	1	1
08/12/2020 14:00	1.4	11.6	2,096.4	0.9	6.30	1	1	1
08/12/2020 15:00	1.5	11.4	2,138.8	0.9	6.40	1	1	1
08/12/2020 16:00	1.4	11.4	2,135.0	0.9	6.40	1	1	1
08/12/2020 17:00	1.4	11.5	2,117.9	0.9	6.40	1	1	1
08/12/2020 18:00	1.4	11.6	2,104.3	0.9	6.30	1	1	1
08/12/2020 19:00	1.4	11.7	2,098.7	0.9	6.30	1	1	1
08/12/2020 20:00	1.4	11.9	2,061.5	0.9	6.20	1	1	1
08/12/2020 21:00	1.4	12.0	2,052.1	0.9	6.20	1	1	1
08/12/2020 22:00	1.4	12.0	2,068.1	0.9	6.20	1	1	1
08/12/2020 23:00	1.3	12.5	1,943.7	0.9	5.80	1	1	1
Average/Sum#:	1.1	12.9	1,681.7	0.8	110.70 #	24 #	24 #	12 #
Minimum:	0.8	11.4	1,288.7	0.7	2.60	1	1	0
Maximum:	1.5	13.8	2,138.8	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/13/2020 00:00	1.1	13.8	1,680.1	0.9	5.00	1	1	0
08/13/2020 01:00	1.2	13.8	1,618.5	1.0	6.50	1	1	0
08/13/2020 02:00	1.1	13.8	1,551.6	0.9	4.70	1	1	0
08/13/2020 03:00	1.1	13.8	1,584.1	0.9	4.80	1	1	0
08/13/2020 04:00	1.1	13.8	1,590.2	0.9	4.80	1	1	0
08/13/2020 05:00	1.1	13.8	1,610.2	0.9	4.80	1	1	0
08/13/2020 06:00	1.1	13.9	1,697.3	0.9	5.10	1	1	0
08/13/2020 07:00	1.1	13.8	1,599.5	0.9	4.80	1	1	0
08/13/2020 08:00	1.1	13.8	1,679.6	0.9	5.00	1	1	0
08/13/2020 09:00	0.9	13.8	1,603.7	0.7	4.80	1	1	1
08/13/2020 10:00	1.3	12.4	2,006.5	0.9	6.00	1	1	1
08/13/2020 11:00	1.4	11.8	2,120.2	0.9	6.40	1	1	1
08/13/2020 12:00	1.4	11.7	2,114.4	0.9	6.30	1	1	1
08/13/2020 13:00	1.4	11.8	2,097.7	0.9	6.30	1	1	1
08/13/2020 14:00	1.4	11.8	2,087.1	0.9	6.30	1	1	1
08/13/2020 15:00	1.4	11.6	2,116.5	0.9	6.30	1	1	1
08/13/2020 16:00	1.4	11.6	2,105.9	0.9	6.30	1	1	1
08/13/2020 17:00	1.4	11.6	2,118.3	0.9	6.40	1	1	1
08/13/2020 18:00	1.4	11.6	2,115.0	0.9	6.30	1	1	1
08/13/2020 19:00	1.4	11.6	2,117.0	0.9	6.40	1	1	1
08/13/2020 20:00	1.4	11.9	2,082.8	0.9	6.20	1	1	1
08/13/2020 21:00	1.4	12.0	2,063.7	0.9	6.20	1	1	1
08/13/2020 22:00	1.4	11.8	2,112.7	0.9	6.30	1	1	1
08/13/2020 23:00	1.4	11.5	2,179.2	0.9	6.50	1	1	1
Average/Sum#:	1.3	12.6	1,902.2	0.9	138.50 #	24 #	24 #	15 #
Minimum:	0.9	11.5	1,551.6	0.7	4.70	1	1	0
Maximum:	1.4	13.9	2,179.2	1.0	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/14/2020 00:00	1.4	11.5	2,187.9	0.9	6.60	1	1	1
08/14/2020 01:00	1.4	11.6	2,166.9	0.9	6.50	1	1	1
08/14/2020 02:00	1.4	11.8	2,128.4	0.9	6.40	1	1	1
08/14/2020 03:00	1.4	11.9	2,108.6	0.9	6.30	1	1	1
08/14/2020 04:00	1.4	11.6	2,168.6	0.9	6.50	1	1	1
08/14/2020 05:00	1.2	12.0	2,103.8	0.8	6.30	1	1	1
08/14/2020 06:00	1.4	12.1	2,075.3	0.9	6.20	1	1	1
08/14/2020 07:00	1.4	12.1	2,068.8	0.9	6.20	1	1	1
08/14/2020 08:00	1.4	11.9	2,097.3	0.9	6.30	1	1	1
08/14/2020 09:00	1.4	11.7	2,119.8	0.9	6.40	1	1	1
08/14/2020 10:00	1.5	11.4	2,169.8	0.9	6.50	1	1	1
08/14/2020 11:00	1.4	11.6	2,136.3	0.9	6.40	1	1	1
08/14/2020 12:00	1.4	11.5	2,151.6	0.9	6.50	1	1	1
08/14/2020 13:00	1.4	11.6	2,131.5	0.9	6.40	1	1	1
08/14/2020 14:00	1.4	11.6	2,115.3	0.9	6.30	1	1	1
08/14/2020 15:00	1.4	11.6	2,104.3	0.9	6.30	1	1	1
08/14/2020 16:00	1.4	11.7	2,081.0	0.9	6.20	1	1	1
08/14/2020 17:00	1.4	11.6	2,102.1	0.9	6.30	1	1	1
08/14/2020 18:00	1.4	11.6	2,105.7	0.9	6.30	1	1	1
08/14/2020 19:00	1.5	11.5	2,135.2	0.9	6.40	1	1	1
08/14/2020 20:00	1.5	11.4	2,155.8	0.9	6.50	1	1	1
08/14/2020 21:00	1.4	11.5	2,144.6	0.9	6.40	1	1	1
08/14/2020 22:00	1.5	11.4	2,172.8	0.9	6.50	1	1	1
08/14/2020 23:00	1.5	11.4	2,179.0	0.9	6.50	1	1	1
Average/Sum#:	1.4	11.7	2,129.6	0.9	153.20 #	24 #	24 #	24 #
Minimum:	1.2	11.4	2,068.8	0.8	6.20	1	1	1
Maximum:	1.5	12.1	2,187.9	0.9	6.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOX, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOX, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/15/2020 00:00	1.4	11.4	2,183.5	0.9	6.60	1	1	1
08/15/2020 01:00	1.4	11.4	2,182.7	0.9	6.50	1	1	1
08/15/2020 02:00	1.4	11.6	2,139.3	0.9	6.40	1	1	1
08/15/2020 03:00	1.4	11.7	2,124.0	0.9	6.40	1	1	1
08/15/2020 04:00	1.4	11.9	2,108.2	0.9	6.30	1	1	1
08/15/2020 05:00	1.6	11.9	2,098.6	1.0	8.40	1	1	1
08/15/2020 06:00	1.4	11.9	2,101.5	0.9	6.30	1	1	1
08/15/2020 07:00	1.4	11.9	2,099.7	0.9	6.30	1	1	1
08/15/2020 08:00	1.3	12.3	2,011.5	0.9	6.00	1	1	1
08/15/2020 09:00	1.4	11.8	2,098.5	0.9	6.30	1	1	1
08/15/2020 10:00	1.4	11.7	2,106.4	0.9	6.30	1	1	1
08/15/2020 11:00	1.4	11.5	2,149.6	0.9	6.40	1	1	1
08/15/2020 12:00	1.5	11.3	2,171.3	0.9	6.50	1	1	1
08/15/2020 13:00	1.5	11.3	2,160.8	0.9	6.50	1	1	1
08/15/2020 14:00	1.4	11.3	2,152.7	0.9	6.50	1	1	1
08/15/2020 15:00	1.4	11.3	2,144.8	0.9	6.40	1	1	1
08/15/2020 16:00	1.5	11.3	2,143.1	0.9	6.40	1	1	1
08/15/2020 17:00	1.5	11.2	2,140.8	0.9	6.40	1	1	1
08/15/2020 18:00	1.4	11.3	2,137.6	0.9	6.40	1	1	1
08/15/2020 19:00	1.5	11.3	2,144.9	0.9	6.40	1	1	1
08/15/2020 20:00	1.5	11.3	2,165.2	0.9	6.50	1	1	1
08/15/2020 21:00	1.5	11.5	2,139.8	0.9	6.40	1	1	1
08/15/2020 22:00	1.4	11.7	2,111.9	0.9	6.30	1	1	1
08/15/2020 23:00	1.5	11.4	2,178.8	0.9	6.50	1	1	1
Average/Sum#:	1.4	11.6	2,133.1	0.9	155.40 #	24 #	24 #	24 #
Minimum:	1.3	11.2	2,011.5	0.9	6.00	1	1	1
Maximum:	1.6	12.3	2,183.5	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/16/2020 00:00	1.4	11.3	2,187.2	0.9	6.60	1	1	1
08/16/2020 01:00	1.4	11.4	2,186.4	0.9	6.60	1	1	1
08/16/2020 02:00	1.4	11.4	2,185.3	0.9	6.60	1	1	1
08/16/2020 03:00	1.4	11.6	2,153.8	0.9	6.50	1	1	1
08/16/2020 04:00	1.4	11.4	2,182.7	0.9	6.50	1	1	1
08/16/2020 05:00	1.2	11.5	2,164.7	0.8	6.50	1	1	1
08/16/2020 06:00	1.4	11.6	2,146.0	0.9	6.40	1	1	1
08/16/2020 07:00	1.3	12.1	2,037.3	0.9	6.10	1	1	1
08/16/2020 08:00	1.3	12.4	1,982.1	0.9	5.90	1	1	1
08/16/2020 09:00	1.4	12.0	2,049.4	0.9	6.10	1	1	1
08/16/2020 10:00	1.4	12.0	2,058.1	0.9	6.20	1	1	1
08/16/2020 11:00	1.4	12.0	2,052.7	0.9	6.20	1	1	1
08/16/2020 12:00	1.4	11.8	2,081.4	0.9	6.20	1	1	1
08/16/2020 13:00	1.4	11.7	2,103.1	0.9	6.30	1	1	1
08/16/2020 14:00	1.4	11.5	2,146.6	0.9	6.40	1	1	1
08/16/2020 15:00	1.4	11.4	2,150.1	0.9	6.50	1	1	1
08/16/2020 16:00	1.5	11.3	2,162.3	0.9	6.50	1	1	1
08/16/2020 17:00	1.4	11.3	2,161.3	0.9	6.50	1	1	1
08/16/2020 18:00	1.4	11.3	2,153.3	0.9	6.50	1	1	1
08/16/2020 19:00	1.4	11.3	2,145.7	0.9	6.40	1	1	1
08/16/2020 20:00	1.5	11.4	2,146.2	0.9	6.40	1	1	1
08/16/2020 21:00	1.4	11.5	2,127.8	0.9	6.40	1	1	1
08/16/2020 22:00	1.4	11.5	2,126.3	0.9	6.40	1	1	1
08/16/2020 23:00	1.4	11.5	2,136.4	0.9	6.40	1	1	1
Average/Sum#:	1.4	11.6	2,126.1	0.9	153.10 #	24 #	24 #	24 #
Minimum:	1.2	11.3	1,982.1	0.8	5.90	1	1	1
Maximum:	1.5	12.4	2,187.2	0.9	6.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/17/2020 00:00	1.4	11.5	2,147.9	0.9	6.40	1	1	1
08/17/2020 01:00	1.4	11.6	2,132.9	0.9	6.40	1	1	1
08/17/2020 02:00	1.4	11.6	2,129.3	0.9	6.40	1	1	1
08/17/2020 03:00	1.4	11.6	2,144.1	0.9	6.40	1	1	1
08/17/2020 04:00	1.4	11.6	2,142.1	0.9	6.40	1	1	1
08/17/2020 05:00	1.3	11.7	2,129.3	0.8	6.40	1	1	1
08/17/2020 06:00	1.4	11.6	2,157.3	0.9	6.50	1	1	1
08/17/2020 07:00	1.4	11.5	2,163.1	0.9	6.50	1	1	1
08/17/2020 08:00	1.4	11.6	2,147.0	0.9	6.40	1	1	1
08/17/2020 09:00	1.4	11.4	2,175.3	0.9	6.50	1	1	1
08/17/2020 10:00	1.4	11.3	2,178.6	0.9	6.50	1	1	1
08/17/2020 11:00	1.4	11.5	2,135.8	0.9	6.40	1	1	1
08/17/2020 12:00	1.4	11.5	2,152.4	0.9	6.50	1	1	1
08/17/2020 13:00	1.4	11.6	2,107.7	0.9	6.30	1	1	1
08/17/2020 14:00	1.4	11.6	2,116.7	0.9	6.40	1	1	1
08/17/2020 15:00	1.4	11.3	2,166.6	0.9	6.50	1	1	1
08/17/2020 16:00	1.4	11.3	2,170.8	0.9	6.50	1	1	1
08/17/2020 17:00	1.4	11.6	2,121.9	0.9	6.40	1	1	1
08/17/2020 18:00	1.4	11.8	2,089.1	0.9	6.30	1	1	1
08/17/2020 19:00	1.4	11.8	2,089.4	0.9	6.30	1	1	1
08/17/2020 20:00	1.4	11.7	2,120.7	0.9	6.40	1	1	1
08/17/2020 21:00	1.5	11.4	2,167.2	0.9	6.50	1	1	1
08/17/2020 22:00	1.4	11.5	2,150.3	0.9	6.50	1	1	1
08/17/2020 23:00	1.4	11.6	2,148.8	0.9	6.40	1	1	1
Average/Sum#:	1.4	11.6	2,141.0	0.9	154.20 #	24 #	24 #	24 #
Minimum:	1.3	11.3	2,089.1	0.8	6.30	1	1	1
Maximum:	1.5	11.8	2,178.6	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm 1 Hour(s)	O2, Dry, Pct 1 Hour(s)	HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	UnitOn, TF 1 Hour(s)	NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/18/2020 00:00	1.4	11.8	2,098.0	0.9	6.30	1	1	1
08/18/2020 01:00	1.4	11.6	2,135.2	0.9	6.40	1	1	1
08/18/2020 02:00	1.4	11.5	2,153.5	0.9	6.50	1	1	1
08/18/2020 03:00	1.4	11.8	2,116.8	0.9	6.40	1	1	1
08/18/2020 04:00	1.4	11.6	2,133.5	0.9	6.40	1	1	1
08/18/2020 05:00	1.5	11.7	2,124.5	1.0	8.50	1	1	1
08/18/2020 06:00	1.4	11.5	2,157.1	0.9	6.50	1	1	1
08/18/2020 07:00	1.4	11.7	2,125.3	0.9	6.40	1	1	1
08/18/2020 08:00	1.4	11.8	2,101.0	0.9	6.30	1	1	1
08/18/2020 09:00	1.4	11.7	2,093.7	0.9	6.30	1	1	1
08/18/2020 10:00	1.4	11.6	2,110.9	0.9	6.30	1	1	1
08/18/2020 11:00	1.4	11.7	2,069.5	0.9	6.20	1	1	1
08/18/2020 12:00	1.5	11.4	2,134.0	0.9	6.40	1	1	1
08/18/2020 13:00	1.5	11.3	2,143.3	0.9	6.40	1	1	1
08/18/2020 14:00	1.5	11.3	2,150.8	0.9	6.50	1	1	1
08/18/2020 15:00	1.4	11.3	2,142.5	0.9	6.40	1	1	1
08/18/2020 16:00	1.5	11.2	2,141.8	0.9	6.40	1	1	1
08/18/2020 17:00	1.5	11.2	2,146.7	0.9	6.40	1	1	1
08/18/2020 18:00	1.5	11.2	2,151.6	0.9	6.50	1	1	1
08/18/2020 19:00	1.4	11.2	2,160.3	0.9	6.50	1	1	1
08/18/2020 20:00	1.4	11.3	2,169.4	0.9	6.50	1	1	1
08/18/2020 21:00	1.4	11.5	2,150.8	0.9	6.50	1	1	1
08/18/2020 22:00	1.4	11.4	2,174.2	0.9	6.50	1	1	1
08/18/2020 23:00	1.4	11.5	2,181.3	0.9	6.50	1	1	1
Average/Sum#:	1.4	11.5	2,136.1	0.9	156.00 #	24 #	24 #	24 #
Minimum:	1.4	11.2	2,069.5	0.9	6.20	1	1	1
Maximum:	1.5	11.8	2,181.3	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/19/2020 00:00	1.4	11.6	2,141.3	0.9	6.40	1	1	1
08/19/2020 01:00	1.4	11.6	2,137.3	0.9	6.40	1	1	1
08/19/2020 02:00	1.4	11.6	2,137.9	0.9	6.40	1	1	1
08/19/2020 03:00	1.4	11.8	2,110.3	0.9	6.30	1	1	1
08/19/2020 04:00	1.4	11.8	2,124.0	0.9	6.40	1	1	1
08/19/2020 05:00	1.5	11.8	2,114.3	1.0	8.50	1	1	1
08/19/2020 06:00	1.4	11.9	2,108.5	0.9	6.30	1	1	1
08/19/2020 07:00	1.4	11.6	2,161.1	0.9	6.50	1	1	1
08/19/2020 08:00	1.4	11.9	2,097.6	0.9	6.30	1	1	1
08/19/2020 09:00	1.4	11.5	2,163.5	0.9	6.50	1	1	1
08/19/2020 10:00	1.4	11.4	2,176.1	0.9	6.50	1	1	1
08/19/2020 11:00	1.5	11.3	2,162.9	0.9	6.50	1	1	1
08/19/2020 12:00	1.4	11.4	2,130.8	0.9	6.40	1	1	1
08/19/2020 13:00	1.4	11.4	2,157.3	0.9	6.50	1	1	1
08/19/2020 14:00	1.5	11.3	2,154.6	0.9	6.50	1	1	1
08/19/2020 15:00	1.4	11.2	2,144.5	0.9	6.40	1	1	1
08/19/2020 16:00	1.4	11.3	2,146.0	0.9	6.40	1	1	1
08/19/2020 17:00	1.4	11.4	2,153.3	0.9	6.50	1	1	1
08/19/2020 18:00	1.4	11.4	2,173.5	0.9	6.50	1	1	1
08/19/2020 19:00	1.4	11.6	2,149.7	0.9	6.40	1	1	1
08/19/2020 20:00	1.4	11.6	2,149.0	0.9	6.40	1	1	1
08/19/2020 21:00	1.4	11.8	2,118.7	0.9	6.40	1	1	1
08/19/2020 22:00	1.4	12.0	2,097.9	0.9	6.30	1	1	1
08/19/2020 23:00	1.4	12.1	2,073.4	0.9	6.20	1	1	1
Average/Sum#:	1.4	11.6	2,136.8	0.9	155.90 #	24 #	24 #	24 #
Minimum:	1.4	11.2	2,073.4	0.9	6.20	1	1	1
Maximum:	1.5	12.1	2,176.1	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/20/2020 00:00	1.4	12.1	2,075.8	0.9	6.20	1	1	1
08/20/2020 01:00	1.3	12.2	2,064.4	0.9	6.20	1	1	1
08/20/2020 02:00	1.3	12.2	2,047.5	0.9	6.10	1	1	1
08/20/2020 03:00	1.3	12.2	2,052.8	0.9	6.20	1	1	1
08/20/2020 04:00	1.4	12.1	2,059.3	0.9	6.20	1	1	1
08/20/2020 05:00	1.2	12.1	2,067.5	0.8	6.20	1	1	1
08/20/2020 06:00	1.4	12.2	2,050.6	0.9	6.20	1	1	1
08/20/2020 07:00	1.3	12.2	2,048.8	0.9	6.10	1	1	1
08/20/2020 08:00	1.4	12.1	2,053.6	0.9	6.20	1	1	1
08/20/2020 09:00	1.4	12.0	2,069.7	0.9	6.20	1	1	1
08/20/2020 10:00	1.4	11.9	2,082.6	0.9	6.20	1	1	1
08/20/2020 11:00	1.4	12.0	2,075.5	0.9	6.20	1	1	1
08/20/2020 12:00	1.4	11.9	2,089.7	0.9	6.30	1	1	1
08/20/2020 13:00	1.4	11.9	2,088.4	0.9	6.30	1	1	1
08/20/2020 14:00	1.4	12.0	2,072.1	0.9	6.20	1	1	1
08/20/2020 15:00	1.4	12.0	2,064.1	0.9	6.20	1	1	1
08/20/2020 16:00	1.4	11.9	2,061.1	0.9	6.20	1	1	1
08/20/2020 17:00	1.4	11.8	2,085.0	0.9	6.30	1	1	1
08/20/2020 18:00	1.4	11.8	2,086.6	0.9	6.30	1	1	1
08/20/2020 19:00	1.4	11.8	2,088.7	0.9	6.30	1	1	1
08/20/2020 20:00	1.4	11.7	2,092.7	0.9	6.30	1	1	1
08/20/2020 21:00	1.4	11.8	2,082.3	0.9	6.20	1	1	1
08/20/2020 22:00	1.4	11.8	2,069.2	0.9	6.20	1	1	1
08/20/2020 23:00	1.4	11.7	2,084.0	0.9	6.30	1	1	1
Average/Sum#:	1.4	12.0	2,071.3	0.9	149.30 #	24 #	24 #	24 #
Minimum:	1.2	11.7	2,047.5	0.8	6.10	1	1	1
Maximum:	1.4	12.2	2,092.7	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/21/2020 00:00	1.4	11.6	2,099.4	0.9	6.30	1	1	1
08/21/2020 01:00	1.4	11.7	2,080.3	0.9	6.20	1	1	1
08/21/2020 02:00	1.3	12.2	1,980.8	0.9	5.90	1	1	1
08/21/2020 03:00	1.4	11.7	2,081.2	0.9	6.20	1	1	1
08/21/2020 04:00	1.4	11.6	2,093.4	0.9	6.30	1	1	1
08/21/2020 05:00	1.2	0.0	2,083.6	0.3	2.10	1	1	1
08/21/2020 06:00	1.4	0.0	2,116.1	0.4	2.10	1	1	1
08/21/2020 07:00	1.4	0.0	2,109.1	0.4	2.10	1	1	1
08/21/2020 08:00	1.4	0.0	2,088.0	0.4	2.10	1	1	1
08/21/2020 09:00	1.4	0.0	2,119.9	0.4	2.10	1	1	1
08/21/2020 10:00	1.4	0.0	2,126.5	0.4	2.10	1	1	1
08/21/2020 11:00	1.4	0.0	2,131.5	0.4	2.10	1	1	1
08/21/2020 12:00	1.4	12.0	2,086.6	0.9	6.30	1	1	1
08/21/2020 13:00	1.4	11.7	2,086.3	0.9	6.30	1	1	1
08/21/2020 14:00	1.4	11.9	2,034.2	0.9	6.10	1	1	1
08/21/2020 15:00	1.4	11.9	2,071.7	0.9	6.20	1	1	1
08/21/2020 16:00	1.4	11.7	2,132.2	0.9	6.40	1	1	1
08/21/2020 17:00	1.4	11.6	2,143.3	0.9	6.40	1	1	1
08/21/2020 18:00	1.4	11.7	2,118.4	0.9	6.40	1	1	1
08/21/2020 19:00	1.4	11.9	2,087.5	0.9	6.30	1	1	1
08/21/2020 20:00	1.4	11.8	2,102.3	0.9	6.30	1	1	1
08/21/2020 21:00	1.4	12.0	2,081.8	0.9	6.20	1	1	1
08/21/2020 22:00	1.4	11.9	2,098.9	0.9	6.30	1	1	1
08/21/2020 23:00	1.4	11.8	2,111.5	0.9	6.30	1	1	1
Average/Sum#:	1.4	11.8	2,094.4	0.9	106.40 #	24 #	24 #	24 #
Minimum:	1.2	11.6	1,980.8	0.9	5.90	1	1	1
Maximum:	1.4	12.2	2,143.3	0.9	6.40	1	1	1
%SI	0.00	29.17	0.00	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/22/2020 00:00	1.4	11.8	2,116.8	0.9	6.40	1	1	1
08/22/2020 01:00	1.3	12.5	1,942.8	0.9	5.80	1	1	1
08/22/2020 02:00	1.1	13.8	1,670.8	0.9	5.00	1	1	0
08/22/2020 03:00	1.1	13.9	1,539.8	0.9	4.60	1	1	0
08/22/2020 04:00	1.1	13.8	1,663.0	0.9	5.00	1	1	0
08/22/2020 05:00	1.2	13.8	1,689.1	1.0	6.80	1	1	0
08/22/2020 06:00	1.2	13.8	1,688.3	1.0	6.80	1	1	0
08/22/2020 07:00	1.1	13.8	1,680.0	0.9	5.00	1	1	0
08/22/2020 08:00	1.1	13.8	1,673.5	0.9	5.00	1	1	0
08/22/2020 09:00	1.1	13.8	1,653.0	0.9	5.00	1	1	0
08/22/2020 10:00	1.1	13.8	1,568.2	0.9	4.70	1	1	1
08/22/2020 11:00	1.4	12.1	2,044.5	0.9	6.10	1	1	1
08/22/2020 12:00	1.5	11.5	2,130.6	0.9	6.40	1	1	1
08/22/2020 13:00	1.5	11.4	2,145.7	0.9	6.40	1	1	1
08/22/2020 14:00	1.5	11.6	2,099.0	1.0	8.40	1	1	1
08/22/2020 15:00	1.5	11.3	2,152.1	0.9	6.50	1	1	1
08/22/2020 16:00	1.5	11.2	2,161.3	0.9	6.50	1	1	1
08/22/2020 17:00	1.5	11.3	2,124.6	0.9	6.40	1	1	1
08/22/2020 18:00	1.5	11.5	2,106.9	0.9	6.30	1	1	1
08/22/2020 19:00	1.5	11.6	2,098.7	1.0	8.40	1	1	1
08/22/2020 20:00	1.5	11.6	2,085.6	1.0	8.30	1	1	1
08/22/2020 21:00	1.5	11.4	2,132.2	0.9	6.40	1	1	1
08/22/2020 22:00	1.4	11.6	2,106.8	0.9	6.30	1	1	1
08/22/2020 23:00	1.5	11.4	2,137.4	0.9	6.40	1	1	1
Average/Sum#:	1.3	12.4	1,933.8	0.9	148.90 #	24 #	24 #	16 #
Minimum:	1.1	11.2	1,539.8	0.9	4.60	1	1	0
Maximum:	1.5	13.9	2,161.3	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/23/2020 00:00	1.4	11.7	2,096.8	0.9	6.30	1	1	1
08/23/2020 01:00	1.4	11.9	2,059.8	0.9	6.20	1	1	1
08/23/2020 02:00	1.4	11.8	2,081.4	0.9	6.20	1	1	1
08/23/2020 03:00	1.4	11.9	2,065.7	0.9	6.20	1	1	1
08/23/2020 04:00	1.3	12.4	1,949.8	0.9	5.80	1	1	1
08/23/2020 05:00	1.0	13.7	1,688.4	0.8	5.10	1	1	0
08/23/2020 06:00	1.2	13.7	1,637.8	1.0	6.60	1	1	0
08/23/2020 07:00	1.1	13.7	1,584.7	0.9	4.80	1	1	0
08/23/2020 08:00	1.1	13.6	1,649.5	0.9	4.90	1	1	0
08/23/2020 09:00	1.1	13.6	1,616.9	0.9	4.90	1	1	0
08/23/2020 10:00	1.1	13.7	1,536.0	0.9	4.60	1	1	1
08/23/2020 11:00	1.4	11.9	2,043.9	0.9	6.10	1	1	1
08/23/2020 12:00	1.5	11.5	2,127.5	0.9	6.40	1	1	1
08/23/2020 13:00	1.5	11.4	2,125.7	0.9	6.40	1	1	1
08/23/2020 14:00	1.5	11.4	2,118.2	0.9	6.40	1	1	1
08/23/2020 15:00	1.5	11.2	2,155.8	0.9	6.50	1	1	1
08/23/2020 16:00	1.5	11.1	2,157.6	0.9	6.50	1	1	1
08/23/2020 17:00	1.5	11.0	2,162.2	0.9	6.50	1	1	1
08/23/2020 18:00	1.5	11.0	2,163.3	0.9	6.50	1	1	1
08/23/2020 19:00	1.5	11.1	2,168.1	0.9	6.50	1	1	1
08/23/2020 20:00	1.5	11.1	2,178.8	0.9	6.50	1	1	1
08/23/2020 21:00	1.5	11.4	2,137.0	0.9	6.40	1	1	1
08/23/2020 22:00	1.5	11.5	2,118.5	0.9	6.40	1	1	1
08/23/2020 23:00	1.5	11.5	2,116.4	0.9	6.30	1	1	1
Average/Sum#:	1.4	12.0	1,989.2	0.9	145.00 #	24 #	24 #	19 #
Minimum:	1.0	11.0	1,536.0	0.8	4.60	1	1	0
Maximum:	1.5	13.7	2,178.8	1.0	6.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/24/2020 00:00	1.5	11.5	2,125.6	0.9	6.40	1	1	1
08/24/2020 01:00	1.5	11.5	2,119.2	0.9	6.40	1	1	1
08/24/2020 02:00	1.5	11.4	2,139.1	0.9	6.40	1	1	1
08/24/2020 03:00	1.5	11.3	2,162.5	0.9	6.50	1	1	1
08/24/2020 04:00	1.5	11.4	2,146.4	0.9	6.40	1	1	1
08/24/2020 05:00	1.6	11.4	2,137.3	1.0	8.50	1	1	1
08/24/2020 06:00	1.5	11.5	2,126.2	0.9	6.40	1	1	1
08/24/2020 07:00	1.4	11.7	2,095.1	0.9	6.30	1	1	1
08/24/2020 08:00	1.4	11.7	2,086.9	0.9	6.30	1	1	1
08/24/2020 09:00	1.5	11.5	2,106.7	0.9	6.30	1	1	1
08/24/2020 10:00	1.5	11.4	2,149.2	0.9	6.40	1	1	1
08/24/2020 11:00	1.4	11.9	2,162.0	0.9	6.50	1	1	1
08/24/2020 12:00	1.3	12.1	2,138.3	0.9	6.40	1	1	1
08/24/2020 13:00	1.4	11.9	2,145.0	0.9	6.40	1	1	1
08/24/2020 14:00	1.4	12.0	2,116.6	0.9	6.30	1	1	1
08/24/2020 15:00	1.4	11.9	2,132.6	0.9	6.40	1	1	1
08/24/2020 16:00	1.4	11.8	2,150.9	0.9	6.50	1	1	1
08/24/2020 17:00	1.4	11.8	2,147.6	0.9	6.40	1	1	1
08/24/2020 18:00	1.4	11.8	2,152.1	0.9	6.50	1	1	1
08/24/2020 19:00	1.4	12.0	2,110.0	0.9	6.30	1	1	1
08/24/2020 20:00	1.4	12.0	2,130.4	0.9	6.40	1	1	1
08/24/2020 21:00	1.4	12.0	2,126.5	0.9	6.40	1	1	1
08/24/2020 22:00	1.4	12.1	2,130.9	0.9	6.40	1	1	1
08/24/2020 23:00	1.4	12.1	2,125.4	0.9	6.40	1	1	1
Average/Sum#:	1.4	11.7	2,131.8	0.9	155.60 #	24 #	24 #	24 #
Minimum:	1.3	11.3	2,086.9	0.9	6.30	1	1	1
Maximum:	1.6	12.1	2,162.5	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/25/2020 00:00	1.4	12.2	2,096.7	0.9	6.30	1	1	1
08/25/2020 01:00	1.4	12.2	2,088.1	0.9	6.30	1	1	1
08/25/2020 02:00	1.3	12.3	2,079.2	0.9	6.20	1	1	1
08/25/2020 03:00	1.3	12.7	2,021.9	0.9	6.10	1	1	1
08/25/2020 04:00	1.4	12.4	2,067.9	1.0	8.30	1	1	1
08/25/2020 05:00	1.6	12.4	2,074.6	1.1	8.30	1	1	1
08/25/2020 06:00	1.3	12.4	2,079.3	0.9	6.20	1	1	1
08/25/2020 07:00	1.3	12.5	2,062.8	0.9	6.20	1	1	1
08/25/2020 08:00	1.3	12.5	2,066.0	0.9	6.20	1	1	1
08/25/2020 09:00	1.3	12.3	2,086.6	0.9	6.30	1	1	1
08/25/2020 10:00	1.4	12.3	2,096.1	1.0	8.40	1	1	1
08/25/2020 11:00	1.4	12.3	2,088.2	1.0	8.40	1	1	1
08/25/2020 12:00	1.4	12.2	2,084.5	0.9	6.30	1	1	1
08/25/2020 13:00	1.4	12.2	2,087.7	0.9	6.30	1	1	1
08/25/2020 14:00	1.4	12.1	2,090.9	0.9	6.30	1	1	1
08/25/2020 15:00	1.4	12.0	2,097.9	0.9	6.30	1	1	1
08/25/2020 16:00	1.4	11.9	2,120.9	0.9	6.40	1	1	1
08/25/2020 17:00	1.4	11.8	2,151.1	0.9	6.50	1	1	1
08/25/2020 18:00	1.4	11.7	2,164.3	0.9	6.50	1	1	1
08/25/2020 19:00	1.4	11.7	2,162.3	0.9	6.50	1	1	1
08/25/2020 20:00	1.4	12.0	2,120.9	0.9	6.40	1	1	1
08/25/2020 21:00	1.3	12.0	2,107.4	0.9	6.30	1	1	1
08/25/2020 22:00	1.1	12.1	2,097.1	0.7	6.30	1	1	1
08/25/2020 23:00	1.4	12.1	2,096.9	0.9	6.30	1	1	1
Average/Sum#:	1.4	12.2	2,095.4	0.9	159.60 #	24 #	24 #	24 #
Minimum:	1.1	11.7	2,021.9	0.7	6.10	1	1	1
Maximum:	1.6	12.7	2,164.3	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/26/2020 00:00	1.3	12.4	2,060.4	0.9	6.20	1	1	1
08/26/2020 01:00	1.3	12.9	1,955.0	1.0	7.80	1	1	1
08/26/2020 02:00	1.3	13.0	1,956.7	1.0	7.80	1	1	1
08/26/2020 03:00	1.3	12.5	2,053.0	0.9	6.20	1	1	1
08/26/2020 04:00	1.3	12.5	2,064.3	0.9	6.20	1	1	1
08/26/2020 05:00	1.6	12.5	2,067.7	1.1	8.30	1	1	1
08/26/2020 06:00	1.3	12.5	2,067.5	0.9	6.20	1	1	1
08/26/2020 07:00	1.3	13.0	1,955.3	1.0	7.80	1	1	1
08/26/2020 08:00	1.2	13.0	1,958.9	0.9	5.90	1	1	1
08/26/2020 09:00	1.4	12.4	2,071.7	1.0	8.30	1	1	1
08/26/2020 10:00	1.4	12.3	2,099.5	1.0	8.40	1	1	1
08/26/2020 11:00	1.4	12.2	2,095.0	0.9	6.30	1	1	1
08/26/2020 12:00	1.4	12.1	2,105.0	0.9	6.30	1	1	1
08/26/2020 13:00	1.4	12.1	2,102.9	0.9	6.30	1	1	1
08/26/2020 14:00	1.4	11.9	2,126.4	0.9	6.40	1	1	1
08/26/2020 15:00	1.4	11.7	2,154.4	0.9	6.50	1	1	1
08/26/2020 16:00	1.4	12.1	2,079.4	0.9	6.20	1	1	1
08/26/2020 17:00	1.4	12.2	2,059.5	0.9	6.20	1	1	1
08/26/2020 18:00	1.4	12.2	2,060.7	0.9	6.20	1	1	1
08/26/2020 19:00	1.4	12.3	2,052.0	1.0	8.20	1	1	1
08/26/2020 20:00	1.3	12.5	2,035.7	0.9	6.10	1	1	1
08/26/2020 21:00	1.3	12.6	2,021.4	0.9	6.10	1	1	1
08/26/2020 22:00	1.3	12.9	1,960.4	1.0	7.80	1	1	1
08/26/2020 23:00	1.3	13.0	1,948.0	1.0	7.80	1	1	1
Average/Sum#:	1.4	12.5	2,046.3	0.9	165.50 #	24 #	24 #	24 #
Minimum:	1.2	11.7	1,948.0	0.9	5.90	1	1	1
Maximum:	1.6	13.0	2,154.4	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOX, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOX, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/27/2020 00:00	1.2	13.1	1,941.9	0.9	5.80	1	1	1
08/27/2020 01:00	1.2	13.1	1,940.0	0.9	5.80	1	1	1
08/27/2020 02:00	1.2	13.1	1,939.9	0.9	5.80	1	1	1
08/27/2020 03:00	1.2	13.1	1,954.4	0.9	5.90	1	1	1
08/27/2020 04:00	1.3	12.5	2,065.4	0.9	6.20	1	1	1
08/27/2020 05:00	1.2	12.5	2,067.8	0.8	6.20	1	1	1
08/27/2020 06:00	1.3	12.4	2,086.7	0.9	6.30	1	1	1
08/27/2020 07:00	1.2	13.1	1,951.4	0.9	5.90	1	1	1
08/27/2020 08:00	1.3	12.7	2,018.3	0.9	6.10	1	1	1
08/27/2020 09:00	1.3	12.7	2,017.7	0.9	6.10	1	1	1
08/27/2020 10:00	1.3	12.6	2,015.6	0.9	6.00	1	1	1
08/27/2020 11:00	1.4	12.0	2,151.9	0.9	6.50	1	1	1
08/27/2020 12:00	1.4	11.8	2,177.8	0.9	6.50	1	1	1
08/27/2020 13:00	1.4	11.8	2,174.1	0.9	6.50	1	1	1
08/27/2020 14:00	1.4	11.5	2,166.7	0.9	6.50	1	1	1
08/27/2020 15:00	1.4	11.5	2,173.4	0.9	6.50	1	1	1
08/27/2020 16:00	1.4	12.0	2,087.0	0.9	6.30	1	1	1
08/27/2020 17:00	1.4	11.9	2,092.6	0.9	6.30	1	1	1
08/27/2020 18:00	1.4	11.9	2,099.6	0.9	6.30	1	1	1
08/27/2020 19:00	1.4	11.8	2,135.9	0.9	6.40	1	1	1
08/27/2020 20:00	1.4	11.7	2,154.5	0.9	6.50	1	1	1
08/27/2020 21:00	1.4	11.5	2,184.2	0.9	6.60	1	1	1
08/27/2020 22:00	1.4	11.5	2,186.5	0.9	6.60	1	1	1
08/27/2020 23:00	1.3	12.3	2,037.7	0.9	6.10	1	1	1
Average/Sum#:	1.3	12.3	2,075.9	0.9	149.70 #	24 #	24 #	24 #
Minimum:	1.2	11.5	1,939.9	0.8	5.80	1	1	1
Maximum:	1.4	13.1	2,186.5	0.9	6.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOX, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOX, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/28/2020 00:00	1.3	12.7	1,935.7	0.9	5.80	1	1	1
08/28/2020 01:00	0.9	13.9	1,524.3	0.8	4.60	1	1	0
08/28/2020 02:00	1.1	14.0	1,449.8	0.9	4.30	1	1	0
08/28/2020 03:00	0.8	14.0	1,288.9	0.7	3.90	1	1	0
08/28/2020 04:00	1.1	14.0	1,473.3	0.9	4.40	1	1	0
08/28/2020 05:00	0.9	14.0	1,595.0	0.8	4.80	1	1	0
08/28/2020 06:00	1.0	14.0	1,454.6	0.9	4.40	1	1	0
08/28/2020 07:00	1.1	14.0	1,375.4	0.9	4.10	1	1	0
08/28/2020 08:00	1.1	14.0	1,396.1	0.9	4.20	1	1	0
08/28/2020 09:00	1.1	14.0	1,426.6	0.9	4.30	1	1	0
08/28/2020 10:00	1.1	14.0	1,461.0	0.9	4.40	1	1	0
08/28/2020 11:00	0.9	13.9	1,514.1	0.8	4.50	1	1	0
08/28/2020 12:00	1.4	12.0	2,058.2	0.9	6.20	1	1	1
08/28/2020 13:00	1.5	11.4	2,176.6	0.9	6.50	1	1	1
08/28/2020 14:00	1.5	11.4	2,169.6	0.9	6.50	1	1	1
08/28/2020 15:00	1.5	11.4	2,165.3	0.9	6.50	1	1	1
08/28/2020 16:00	1.4	11.4	2,173.3	0.9	6.50	1	1	1
08/28/2020 17:00	1.5	11.4	2,163.3	0.9	6.50	1	1	1
08/28/2020 18:00	1.5	11.5	2,151.2	0.9	6.50	1	1	1
08/28/2020 19:00	1.4	12.0	2,059.6	0.9	6.20	1	1	1
08/28/2020 20:00	1.4	12.1	2,046.1	0.9	6.10	1	1	1
08/28/2020 21:00	1.4	12.2	2,045.5	0.9	6.10	1	1	1
08/28/2020 22:00	1.3	12.4	1,994.0	0.9	6.00	1	1	1
08/28/2020 23:00	1.4	12.0	2,090.7	0.9	6.30	1	1	1
Average/Sum#:	1.2	12.8	1,799.5	0.9	129.60 #	24 #	24 #	13 #
Minimum:	0.8	11.4	1,288.9	0.7	3.90	1	1	0
Maximum:	1.5	14.0	2,176.6	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/29/2020 00:00	1.4	11.9	2,100.2	0.9	6.30	1	1	1
08/29/2020 01:00	1.4	12.0	2,098.1	0.9	6.30	1	1	1
08/29/2020 02:00	1.4	12.2	2,069.6	0.9	6.20	1	1	1
08/29/2020 03:00	1.3	12.7	1,949.2	0.9	5.80	1	1	1
08/29/2020 04:00	1.1	13.9	1,606.0	0.9	4.80	1	1	0
08/29/2020 05:00	1.0	13.9	1,586.5	0.8	4.80	1	1	0
08/29/2020 06:00	1.1	13.9	1,559.4	0.9	4.70	1	1	0
08/29/2020 07:00	1.1	13.9	1,428.6	0.9	4.30	1	1	0
08/29/2020 08:00	1.1	13.9	1,381.1	0.9	4.10	1	1	0
08/29/2020 09:00	1.0	14.0	1,282.5	0.9	3.80	1	1	0
08/29/2020 10:00	1.1	14.0	1,295.9	0.9	3.90	1	1	0
08/29/2020 11:00	1.0	14.0	1,329.1	0.9	4.00	1	1	0
08/29/2020 12:00	1.0	14.0	1,287.9	0.9	3.90	1	1	0
08/29/2020 13:00	1.1	13.9	1,589.9	0.9	4.80	1	1	0
08/29/2020 14:00	1.1	13.9	1,597.3	0.9	4.80	1	1	0
08/29/2020 15:00	1.1	13.8	1,604.5	0.9	4.80	1	1	0
08/29/2020 16:00	1.1	13.8	1,654.1	0.9	5.00	1	1	1
08/29/2020 17:00	1.4	11.9	2,065.0	0.9	6.20	1	1	1
08/29/2020 18:00	1.4	11.6	2,109.7	0.9	6.30	1	1	1
08/29/2020 19:00	1.4	11.7	2,110.7	0.9	6.30	1	1	1
08/29/2020 20:00	1.5	11.4	2,172.4	0.9	6.50	1	1	1
08/29/2020 21:00	1.4	11.6	2,145.4	0.9	6.40	1	1	1
08/29/2020 22:00	1.4	12.3	2,023.0	1.0	8.10	1	1	1
08/29/2020 23:00	1.3	12.4	2,018.0	0.9	6.10	1	1	1
Average/Sum#:	1.2	13.0	1,752.7	0.9	128.20 #	24 #	24 #	12 #
Minimum:	1.0	11.4	1,282.5	0.8	3.80	1	1	0
Maximum:	1.5	14.0	2,172.4	1.0	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/30/2020 00:00	1.3	12.7	1,930.6	0.9	5.80	1	1	1
08/30/2020 01:00	1.1	13.7	1,750.8	0.9	5.30	1	1	0
08/30/2020 02:00	1.2	13.7	1,754.2	1.0	7.00	1	1	0
08/30/2020 03:00	1.1	13.7	1,754.7	0.9	5.30	1	1	0
08/30/2020 04:00	1.2	13.8	1,755.6	1.0	7.00	1	1	0
08/30/2020 05:00	1.2	13.7	1,747.0	1.0	7.00	1	1	0
08/30/2020 06:00	1.1	13.8	1,747.0	0.9	5.20	1	1	0
08/30/2020 07:00	1.2	13.7	1,750.7	1.0	7.00	1	1	0
08/30/2020 08:00	1.1	13.7	1,756.7	0.9	5.30	1	1	0
08/30/2020 09:00	1.2	13.6	1,763.4	1.0	7.10	1	1	0
08/30/2020 10:00	1.2	13.6	1,761.2	1.0	7.00	1	1	0
08/30/2020 11:00	1.2	13.6	1,753.6	1.0	7.00	1	1	0
08/30/2020 12:00	1.2	13.6	1,744.7	1.0	7.00	1	1	0
08/30/2020 13:00	1.1	13.7	1,633.1	0.9	4.90	1	1	0
08/30/2020 14:00	1.0	13.8	1,540.0	0.8	4.60	1	1	1
08/30/2020 15:00	1.4	11.9	2,091.5	0.9	6.30	1	1	1
08/30/2020 16:00	1.5	11.3	2,177.6	0.9	6.50	1	1	1
08/30/2020 17:00	1.4	11.6	2,126.6	0.9	6.40	1	1	1
08/30/2020 18:00	1.4	11.8	2,098.2	0.9	6.30	1	1	1
08/30/2020 19:00	1.4	12.1	2,055.0	0.9	6.20	1	1	1
08/30/2020 20:00	1.4	12.1	2,048.7	0.9	6.10	1	1	1
08/30/2020 21:00	1.4	12.2	2,037.1	0.9	6.10	1	1	1
08/30/2020 22:00	1.4	12.2	2,031.9	0.9	6.10	1	1	1
08/30/2020 23:00	1.3	12.6	1,944.3	0.9	5.80	1	1	1
Average/Sum#:	1.3	13.0	1,864.8	0.9	148.30 #	24 #	24 #	11 #
Minimum:	1.0	11.3	1,540.0	0.8	4.60	1	1	0
Maximum:	1.5	13.8	2,177.6	1.0	7.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/31/2020 00:00	1.1	13.8	1,614.4	0.9	4.80	1	1	0
08/31/2020 01:00	0.9	13.9	1,303.1	0.8	3.90	1	1	0
08/31/2020 02:00	0.9	14.0	1,289.4	0.8	3.90	1	1	0
08/31/2020 03:00	1.0	14.0	1,299.9	0.9	3.90	1	1	0
08/31/2020 04:00	1.1	13.8	1,639.1	0.9	4.90	1	1	0
08/31/2020 05:00	1.1	13.8	1,669.3	0.9	5.00	1	1	0
08/31/2020 06:00	1.1	13.8	1,693.4	0.9	5.10	1	1	0
08/31/2020 07:00	1.0	13.9	1,385.4	0.8	4.20	1	1	0
08/31/2020 08:00	1.1	13.9	1,407.3	0.9	4.20	1	1	0
08/31/2020 09:00	0.9	14.0	1,312.4	0.8	3.90	1	1	0
08/31/2020 10:00	0.9	14.0	1,302.1	0.8	3.90	1	1	0
08/31/2020 11:00	1.1	14.0	1,504.4	0.9	4.50	1	1	0
08/31/2020 12:00	1.0	13.9	1,488.2	0.8	4.50	1	1	1
08/31/2020 13:00	1.4	11.9	2,098.1	0.9	6.30	1	1	1
08/31/2020 14:00	1.5	11.4	2,187.6	0.9	6.60	1	1	1
08/31/2020 15:00	1.5	11.4	2,181.2	0.9	6.50	1	1	1
08/31/2020 16:00	1.4	11.9	2,075.9	0.9	6.20	1	1	1
08/31/2020 17:00	1.4	12.1	2,046.7	0.9	6.10	1	1	1
08/31/2020 18:00	1.4	12.2	2,042.4	0.9	6.10	1	1	1
08/31/2020 19:00	1.4	12.2	2,034.7	0.9	6.10	1	1	1
08/31/2020 20:00	1.4	12.2	2,032.1	0.9	6.10	1	1	1
08/31/2020 21:00	1.4	12.3	2,028.6	1.0	8.10	1	1	1
08/31/2020 22:00	1.4	12.3	2,024.4	1.0	8.10	1	1	1
08/31/2020 23:00	1.2	13.0	1,793.4	0.9	5.40	1	1	1
Average/Sum#:	1.2	13.1	1,727.2	0.9	128.30 #	24 #	24 #	12 #
Minimum:	0.9	11.4	1,289.4	0.8	3.90	1	1	0
Maximum:	1.5	14.0	2,187.6	1.0	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/01/2020 00:00	0.8	14.0	1,298.4	0.7	3.90	1	1	0
09/01/2020 01:00	1.1	13.9	1,497.3	0.9	4.50	1	1	0
09/01/2020 02:00	1.0	14.0	1,393.5	0.9	4.20	1	1	0
09/01/2020 03:00	0.7	14.0	1,300.4	0.6	2.60	1	1	0
09/01/2020 04:00	0.9	14.0	1,347.1	0.8	4.00	1	1	0
09/01/2020 05:00	1.2	13.8	1,678.7	1.0	6.70	1	1	0
09/01/2020 06:00	1.0	13.9	1,653.2	0.8	5.00	1	1	0
09/01/2020 07:00	1.1	13.8	1,676.8	0.9	5.00	1	1	0
09/01/2020 08:00	0.0	0.0	1,596.3	0.0	0.00	1	1	0
09/01/2020 09:00	0.6	13.9	1,623.2	0.5	3.20	1	1	0
09/01/2020 10:00	0.9	13.9	1,483.8	0.8	4.50	1	1	0
09/01/2020 11:00	0.7	14.1	1,311.8	0.6	2.60	1	1	0
09/01/2020 12:00	0.8	14.1	1,340.5	0.7	4.00	1	1	0
09/01/2020 13:00	1.0	14.1	1,488.6	0.9	4.50	1	1	0
09/01/2020 14:00	1.0	14.0	1,648.6	0.9	4.90	1	1	0
09/01/2020 15:00	1.1	14.0	1,612.3	0.9	4.80	1	1	0
09/01/2020 16:00	1.0	13.9	1,541.1	0.8	4.60	1	1	1
09/01/2020 17:00	1.4	12.0	2,064.4	0.9	6.20	1	1	1
09/01/2020 18:00	1.4	11.6	2,157.9	0.9	6.50	1	1	1
09/01/2020 19:00	1.4	11.7	2,131.3	0.9	6.40	1	1	1
09/01/2020 20:00	1.3	12.3	2,027.7	0.9	6.10	1	1	1
09/01/2020 21:00	1.3	12.4	2,014.1	0.9	6.00	1	1	1
09/01/2020 22:00	1.3	12.8	1,946.1	0.9	5.80	1	1	1
09/01/2020 23:00	1.1	13.2	1,783.2	0.8	5.30	1	1	1
Average/Sum#:	1.0	13.5	1,650.7	0.8	111.30 #	24 #	24 #	8 #
Minimum:	0.6	11.6	1,298.4	0.5	2.60	1	1	0
Maximum:	1.4	14.1	2,157.9	1.0	6.70	1	1	1
%SI	4.17	4.17	0.00	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/02/2020 00:00	0.7	14.0	1,287.8	0.6	2.60	1	1	0
09/02/2020 01:00	0.7	14.0	1,284.2	0.6	2.60	1	1	0
09/02/2020 02:00	0.7	14.0	1,301.4	0.6	2.60	1	1	0
09/02/2020 03:00	0.7	14.0	1,294.8	0.6	2.60	1	1	0
09/02/2020 04:00	0.7	14.0	1,318.3	0.6	2.60	1	1	0
09/02/2020 05:00	0.7	14.0	1,285.9	0.6	2.60	1	1	0
09/02/2020 06:00	0.7	14.0	1,292.6	0.6	2.60	1	1	0
09/02/2020 07:00	0.9	14.0	1,408.7	0.8	4.20	1	1	0
09/02/2020 08:00	0.9	14.0	1,367.6	0.8	4.10	1	1	0
09/02/2020 09:00	1.0	14.0	1,374.7	0.9	4.10	1	1	0
09/02/2020 10:00	1.0	14.0	1,383.4	0.9	4.20	1	1	0
09/02/2020 11:00	1.1	14.0	1,392.2	0.9	4.20	1	1	0
09/02/2020 12:00	1.1	14.0	1,394.6	0.9	4.20	1	1	0
09/02/2020 13:00	1.1	14.0	1,394.8	0.9	4.20	1	1	0
09/02/2020 14:00	1.1	14.0	1,394.3	0.9	4.20	1	1	0
09/02/2020 15:00	1.1	14.0	1,419.1	0.9	4.30	1	1	0
09/02/2020 16:00	1.3	12.8	1,921.0	0.9	5.80	1	1	1
09/02/2020 17:00	1.3	12.6	1,963.9	0.9	5.90	1	1	1
09/02/2020 18:00	1.3	12.7	1,957.9	0.9	5.90	1	1	1
09/02/2020 19:00	1.3	12.8	1,948.7	0.9	5.80	1	1	1
09/02/2020 20:00	1.3	12.8	1,911.9	0.9	5.70	1	1	1
09/02/2020 21:00	0.8	14.0	1,390.6	0.7	4.20	1	1	0
09/02/2020 22:00	1.0	14.0	1,373.7	0.9	4.10	1	1	0
09/02/2020 23:00	1.0	14.0	1,377.5	0.9	4.10	1	1	0
Average/Sum#:	1.0	13.7	1,476.7	0.8	97.40 #	24 #	24 #	5 #
Minimum:	0.7	12.6	1,284.2	0.6	2.60	1	1	0
Maximum:	1.3	14.0	1,963.9	0.9	5.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/03/2020 00:00	1.0	14.0	1,374.0	0.9	4.10	1	1	0
09/03/2020 01:00	1.0	14.0	1,373.5	0.9	4.10	1	1	0
09/03/2020 02:00	1.0	14.0	1,376.0	0.9	4.10	1	1	0
09/03/2020 03:00	1.1	14.0	1,621.5	0.9	4.90	1	1	0
09/03/2020 04:00	0.9	14.0	1,445.9	0.8	4.30	1	1	0
09/03/2020 05:00	0.9	14.0	1,573.4	0.8	4.70	1	1	0
09/03/2020 06:00	1.0	14.0	1,588.8	0.9	4.80	1	1	0
09/03/2020 07:00	1.1	14.0	1,645.9	0.9	4.90	1	1	0
09/03/2020 08:00	1.1	14.0	1,642.0	0.9	4.90	1	1	0
09/03/2020 09:00	1.1	14.0	1,539.7	0.9	4.60	1	1	0
09/03/2020 10:00	1.1	14.0	1,577.0	0.9	4.70	1	1	0
09/03/2020 11:00	1.0	14.0	1,528.5	0.9	4.60	1	1	1
09/03/2020 12:00	1.3	12.1	2,093.4	0.9	6.30	1	1	1
09/03/2020 13:00	1.4	11.7	2,155.4	0.9	6.50	1	1	1
09/03/2020 14:00	1.4	11.9	2,109.7	0.9	6.30	1	1	1
09/03/2020 15:00	1.4	11.6	2,161.1	0.9	6.50	1	1	1
09/03/2020 16:00	1.4	11.5	2,166.8	0.9	6.50	1	1	1
09/03/2020 17:00	1.4	11.5	2,166.4	0.9	6.50	1	1	1
09/03/2020 18:00	1.4	11.5	2,170.5	0.9	6.50	1	1	1
09/03/2020 19:00	1.4	11.8	2,114.6	0.9	6.30	1	1	1
09/03/2020 20:00	1.3	12.2	2,034.1	0.9	6.10	1	1	1
09/03/2020 21:00	1.3	12.3	2,030.5	0.9	6.10	1	1	1
09/03/2020 22:00	1.4	12.1	2,068.9	0.9	6.20	1	1	1
09/03/2020 23:00	1.4	11.7	2,160.1	0.9	6.50	1	1	1
Average/Sum#:	1.2	12.9	1,821.6	0.9	131.00 #	24 #	24 #	13 #
Minimum:	0.9	11.5	1,373.5	0.8	4.10	1	1	0
Maximum:	1.4	14.0	2,170.5	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/04/2020 00:00	1.3	12.4	2,044.7	0.9	6.10	1	1	1
09/04/2020 01:00	1.3	12.6	2,004.7	0.9	6.00	1	1	1
09/04/2020 02:00	1.3	12.6	2,006.5	0.9	6.00	1	1	1
09/04/2020 03:00	1.3	12.7	2,008.8	0.9	6.00	1	1	1
09/04/2020 04:00	1.4	11.9	2,159.5	0.9	6.50	1	1	1
09/04/2020 05:00	1.4	11.7	2,192.1	0.9	6.60	1	1	1
09/04/2020 06:00	1.4	11.8	2,162.4	0.9	6.50	1	1	1
09/04/2020 07:00	1.4	11.9	2,144.0	0.9	6.40	1	1	1
09/04/2020 08:00	1.3	12.4	2,039.1	0.9	6.10	1	1	1
09/04/2020 09:00	1.3	12.5	2,004.2	0.9	6.00	1	1	1
09/04/2020 10:00	1.3	12.1	2,087.7	0.9	6.30	1	1	1
09/04/2020 11:00	1.4	11.9	2,121.9	0.9	6.40	1	1	1
09/04/2020 12:00	1.4	11.8	2,139.3	0.9	6.40	1	1	1
09/04/2020 13:00	1.4	11.7	2,143.8	0.9	6.40	1	1	1
09/04/2020 14:00	1.4	11.7	2,143.4	0.9	6.40	1	1	1
09/04/2020 15:00	1.4	11.7	2,151.6	0.9	6.50	1	1	1
09/04/2020 16:00	1.4	11.6	2,155.4	0.9	6.50	1	1	1
09/04/2020 17:00	1.4	11.6	2,160.4	0.9	6.50	1	1	1
09/04/2020 18:00	1.4	11.6	2,164.8	0.9	6.50	1	1	1
09/04/2020 19:00	1.4	11.6	2,169.0	0.9	6.50	1	1	1
09/04/2020 20:00	1.4	11.6	2,170.4	0.9	6.50	1	1	1
09/04/2020 21:00	1.4	11.8	2,137.3	0.9	6.40	1	1	1
09/04/2020 22:00	1.4	11.9	2,137.2	0.9	6.40	1	1	1
09/04/2020 23:00	1.3	12.4	2,052.0	0.9	6.20	1	1	1
Average/Sum#:	1.4	12.0	2,112.5	0.9	152.10 #	24 #	24 #	24 #
Minimum:	1.3	11.6	2,004.2	0.9	6.00	1	1	1
Maximum:	1.4	12.7	2,192.1	0.9	6.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/05/2020 00:00	1.3	12.5	2,028.9	0.9	6.10	1	1	1
09/05/2020 01:00	1.3	12.5	2,033.6	0.9	6.10	1	1	1
09/05/2020 02:00	1.3	12.5	2,032.6	0.9	6.10	1	1	1
09/05/2020 03:00	1.3	12.5	2,034.7	0.9	6.10	1	1	1
09/05/2020 04:00	1.3	12.5	2,047.1	0.9	6.10	1	1	1
09/05/2020 05:00	1.1	12.7	1,996.2	0.8	6.00	1	1	1
09/05/2020 06:00	1.1	14.0	1,646.2	0.9	4.90	1	1	0
09/05/2020 07:00	1.1	14.0	1,575.4	0.9	4.70	1	1	0
09/05/2020 08:00	1.1	14.0	1,619.3	0.9	4.90	1	1	0
09/05/2020 09:00	1.1	14.0	1,596.6	0.9	4.80	1	1	0
09/05/2020 10:00	1.1	14.0	1,628.7	0.9	4.90	1	1	1
09/05/2020 11:00	1.3	12.2	2,070.4	0.9	6.20	1	1	1
09/05/2020 12:00	1.4	11.7	2,146.3	0.9	6.40	1	1	1
09/05/2020 13:00	1.4	11.6	2,158.0	0.9	6.50	1	1	1
09/05/2020 14:00	1.4	11.6	2,159.4	0.9	6.50	1	1	1
09/05/2020 15:00	1.4	11.5	2,156.1	0.9	6.50	1	1	1
09/05/2020 16:00	1.4	11.5	2,146.5	0.9	6.40	1	1	1
09/05/2020 17:00	1.4	11.5	2,155.9	0.9	6.50	1	1	1
09/05/2020 18:00	1.4	11.5	2,162.8	0.9	6.50	1	1	1
09/05/2020 19:00	1.4	11.5	2,167.9	0.9	6.50	1	1	1
09/05/2020 20:00	1.4	11.5	2,171.2	0.9	6.50	1	1	1
09/05/2020 21:00	1.4	11.5	2,177.1	0.9	6.50	1	1	1
09/05/2020 22:00	1.4	11.6	2,186.6	0.9	6.60	1	1	1
09/05/2020 23:00	1.4	11.9	2,117.7	0.9	6.40	1	1	1
Average/Sum#:	1.3	12.3	2,009.0	0.9	144.70 #	24 #	24 #	20 #
Minimum:	1.1	11.5	1,575.4	0.8	4.70	1	1	0
Maximum:	1.4	14.0	2,186.6	0.9	6.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/06/2020 00:00	1.4	11.8	2,154.4	0.9	6.50	1	1	1
09/06/2020 01:00	1.3	12.1	2,086.4	0.9	6.30	1	1	1
09/06/2020 02:00	1.3	11.9	2,082.6	0.9	6.20	1	1	1
09/06/2020 03:00	1.3	11.8	2,105.5	0.8	6.30	1	1	1
09/06/2020 04:00	1.3	12.3	2,069.1	0.9	6.20	1	1	1
09/06/2020 05:00	1.1	12.4	2,055.1	0.8	6.20	1	1	1
09/06/2020 06:00	1.3	12.7	1,987.4	0.9	6.00	1	1	1
09/06/2020 07:00	1.4	12.1	2,110.9	0.9	6.30	1	1	1
09/06/2020 08:00	1.4	11.8	2,133.1	0.9	6.40	1	1	1
09/06/2020 09:00	1.4	11.7	2,146.1	0.9	6.40	1	1	1
09/06/2020 10:00	1.4	11.6	2,144.2	0.9	6.40	1	1	1
09/06/2020 11:00	1.4	11.6	2,139.2	0.9	6.40	1	1	1
09/06/2020 12:00	1.4	11.5	2,140.0	0.9	6.40	1	1	1
09/06/2020 13:00	1.4	11.6	2,145.4	0.9	6.40	1	1	1
09/06/2020 14:00	1.4	11.6	2,145.7	0.9	6.40	1	1	1
09/06/2020 15:00	1.4	11.5	2,148.3	0.9	6.40	1	1	1
09/06/2020 16:00	1.4	11.9	2,078.4	0.9	6.20	1	1	1
09/06/2020 17:00	1.4	11.5	2,141.4	0.9	6.40	1	1	1
09/06/2020 18:00	1.4	11.6	2,121.0	0.9	6.40	1	1	1
09/06/2020 19:00	1.4	11.8	2,090.2	0.9	6.30	1	1	1
09/06/2020 20:00	1.4	11.9	2,092.8	0.9	6.30	1	1	1
09/06/2020 21:00	1.4	11.7	2,146.3	0.9	6.40	1	1	1
09/06/2020 22:00	1.4	11.6	2,142.3	0.9	6.40	1	1	1
09/06/2020 23:00	1.3	11.6	2,099.9	0.8	6.30	1	1	1
Average/Sum#:	1.4	11.8	2,112.7	0.9	151.90 #	24 #	24 #	24 #
Minimum:	1.1	11.5	1,987.4	0.8	6.00	1	1	1
Maximum:	1.4	12.7	2,154.4	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/07/2020 00:00	1.3	11.6	2,087.2	0.8	6.30	1	1	1
09/07/2020 01:00	1.3	11.7	2,080.0	0.8	6.20	1	1	1
09/07/2020 02:00	1.3	11.7	2,090.5	0.8	6.30	1	1	1
09/07/2020 03:00	1.3	12.0	2,105.0	0.9	6.30	1	1	1
09/07/2020 04:00	1.3	12.3	2,038.4	0.9	6.10	1	1	1
09/07/2020 05:00	1.4	12.3	2,045.0	1.0	8.20	1	1	1
09/07/2020 06:00	0.9	14.0	1,593.0	0.8	4.80	1	1	0
09/07/2020 07:00	1.1	14.1	1,591.9	1.0	6.40	1	1	0
09/07/2020 08:00	1.1	14.1	1,604.2	1.0	6.40	1	1	0
09/07/2020 09:00	1.1	14.1	1,566.2	1.0	6.30	1	1	0
09/07/2020 10:00	1.0	14.0	1,507.6	0.9	4.50	1	1	0
09/07/2020 11:00	0.9	14.0	1,508.2	0.8	4.50	1	1	1
09/07/2020 12:00	1.3	12.6	1,958.9	0.9	5.90	1	1	1
09/07/2020 13:00	1.1	13.4	1,742.4	0.9	5.20	1	1	1
09/07/2020 14:00	1.1	13.8	1,673.7	0.9	5.00	1	1	0
09/07/2020 15:00	1.2	13.7	1,721.1	1.0	6.90	1	1	0
09/07/2020 16:00	1.2	13.1	1,782.9	0.9	5.30	1	1	1
09/07/2020 17:00	1.3	12.2	2,027.4	0.9	6.10	1	1	1
09/07/2020 18:00	1.3	12.2	2,022.2	0.9	6.10	1	1	1
09/07/2020 19:00	1.4	11.7	2,124.7	0.9	6.40	1	1	1
09/07/2020 20:00	1.4	11.7	2,112.8	0.9	6.30	1	1	1
09/07/2020 21:00	1.4	12.0	2,049.3	0.9	6.10	1	1	1
09/07/2020 22:00	1.3	12.0	2,052.9	0.9	6.20	1	1	1
09/07/2020 23:00	1.3	12.1	2,052.7	0.9	6.20	1	1	1
Average/Sum#:	1.2	12.8	1,880.8	0.9	144.00 #	24 #	24 #	17 #
Minimum:	0.9	11.6	1,507.6	0.8	4.50	1	1	0
Maximum:	1.4	14.1	2,124.7	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/08/2020 00:00	1.3	12.2	2,055.9	0.9	6.20	1	1	1
09/08/2020 01:00	1.4	11.9	2,111.0	0.9	6.30	1	1	1
09/08/2020 02:00	1.3	12.0	2,087.8	0.9	6.30	1	1	1
09/08/2020 03:00	1.4	11.8	2,152.6	0.9	6.50	1	1	1
09/08/2020 04:00	1.3	12.2	2,089.1	0.9	6.30	1	1	1
09/08/2020 05:00	1.3	12.4	2,050.2	0.9	6.20	1	1	1
09/08/2020 06:00	1.0	14.0	1,636.4	0.9	4.90	1	1	0
09/08/2020 07:00	1.0	14.1	1,637.4	0.9	4.90	1	1	0
09/08/2020 08:00	1.0	14.1	1,515.2	0.9	4.50	1	1	0
09/08/2020 09:00	1.0	14.0	1,642.7	0.9	4.90	1	1	0
09/08/2020 10:00	0.8	14.0	1,583.1	0.7	4.70	1	1	0
09/08/2020 11:00	1.1	13.9	1,688.0	0.9	5.10	1	1	0
09/08/2020 12:00	0.9	14.0	1,538.9	0.8	4.60	1	1	1
09/08/2020 13:00	1.3	12.3	2,083.3	0.9	6.20	1	1	1
09/08/2020 14:00	1.4	11.7	2,176.1	0.9	6.50	1	1	1
09/08/2020 15:00	1.4	11.6	2,186.3	0.9	6.60	1	1	1
09/08/2020 16:00	1.4	11.6	2,191.0	0.9	6.60	1	1	1
09/08/2020 17:00	1.4	11.5	2,198.7	0.9	6.60	1	1	1
09/08/2020 18:00	1.2	11.7	2,084.9	0.8	6.30	1	1	1
09/08/2020 19:00	1.3	12.0	2,091.8	0.9	6.30	1	1	1
09/08/2020 20:00	1.3	12.2	2,095.8	0.9	6.30	1	1	1
09/08/2020 21:00	1.4	12.1	2,103.1	0.9	6.30	1	1	1
09/08/2020 22:00	1.3	12.5	2,037.8	0.9	6.10	1	1	1
09/08/2020 23:00	1.3	12.4	2,056.6	0.9	6.20	1	1	1
Average/Sum#:	1.2	12.6	1,962.2	0.9	141.40 #	24 #	24 #	18 #
Minimum:	0.8	11.5	1,515.2	0.7	4.50	1	1	0
Maximum:	1.4	14.1	2,198.7	0.9	6.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOX, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOX, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/09/2020 00:00	1.3	12.4	2,003.3	0.9	6.00	1	1	1
09/09/2020 01:00	0.9	14.0	1,665.4	0.8	5.00	1	1	0
09/09/2020 02:00	0.7	14.1	1,398.7	0.6	2.80	1	1	0
09/09/2020 03:00	1.0	14.0	1,657.4	0.9	5.00	1	1	0
09/09/2020 04:00	0.8	14.1	1,507.6	0.7	4.50	1	1	0
09/09/2020 05:00	0.8	14.1	1,580.1	0.7	4.70	1	1	0
09/09/2020 06:00	0.9	14.1	1,583.4	0.8	4.80	1	1	0
09/09/2020 07:00	0.8	14.1	1,560.6	0.7	4.70	1	1	0
09/09/2020 08:00	0.8	14.1	1,517.1	0.7	4.60	1	1	0
09/09/2020 09:00	0.8	14.1	1,437.2	0.7	4.30	1	1	0
09/09/2020 10:00	0.8	14.1	1,423.5	0.7	4.30	1	1	0
09/09/2020 11:00	0.9	14.1	1,496.9	0.8	4.50	1	1	0
09/09/2020 12:00	0.8	14.1	1,521.1	0.7	4.60	1	1	1
09/09/2020 13:00	1.3	12.3	2,084.9	0.9	6.30	1	1	1
09/09/2020 14:00	1.3	12.4	2,045.1	0.9	6.10	1	1	1
09/09/2020 15:00	1.3	12.5	2,020.4	0.9	6.10	1	1	1
09/09/2020 16:00	1.3	12.5	2,013.2	0.9	6.00	1	1	1
09/09/2020 17:00	1.3	12.5	2,010.1	0.9	6.00	1	1	1
09/09/2020 18:00	1.3	12.6	2,009.5	0.9	6.00	1	1	1
09/09/2020 19:00	1.3	12.6	2,008.5	0.9	6.00	1	1	1
09/09/2020 20:00	1.3	12.6	2,009.2	0.9	6.00	1	1	1
09/09/2020 21:00	1.3	12.7	2,006.3	0.9	6.00	1	1	1
09/09/2020 22:00	1.3	12.7	2,003.5	0.9	6.00	1	1	1
09/09/2020 23:00	1.2	13.0	1,921.5	0.9	5.80	1	1	1
Average/Sum#:	1.1	13.3	1,770.2	0.8	126.10 #	24 #	24 #	13 #
Minimum:	0.7	12.3	1,398.7	0.6	2.80	1	1	0
Maximum:	1.3	14.1	2,084.9	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/10/2020 00:00	0.8	14.0	1,517.9	0.7	4.60	1	1	0
09/10/2020 01:00	0.9	14.0	1,492.0	0.8	4.50	1	1	0
09/10/2020 02:00	0.7	14.1	1,313.6	0.6	2.60	1	1	0
09/10/2020 03:00	0.9	14.0	1,594.4	0.8	4.80	1	1	0
09/10/2020 04:00	0.9	14.0	1,563.7	0.8	4.70	1	1	0
09/10/2020 05:00	0.9	14.0	1,559.1	0.8	4.70	1	1	0
09/10/2020 06:00	0.9	14.0	1,605.5	0.8	4.80	1	1	0
09/10/2020 07:00	0.9	14.0	1,643.9	0.8	4.90	1	1	0
09/10/2020 08:00	0.9	14.0	1,680.9	0.8	5.00	1	1	0
09/10/2020 09:00	0.9	14.0	1,621.3	0.8	4.90	1	1	0
09/10/2020 10:00	1.1	14.0	1,673.5	0.9	5.00	1	1	0
09/10/2020 11:00	1.0	14.0	1,474.6	0.9	4.40	1	1	0
09/10/2020 12:00	1.0	14.0	1,449.0	0.9	4.30	1	1	0
09/10/2020 13:00	1.1	14.0	1,460.1	0.9	4.40	1	1	0
09/10/2020 14:00	1.1	14.0	1,599.9	0.9	4.80	1	1	0
09/10/2020 15:00	1.0	13.9	1,573.5	0.8	4.70	1	1	1
09/10/2020 16:00	1.3	12.3	2,059.3	0.9	6.20	1	1	1
09/10/2020 17:00	1.3	12.4	2,032.5	0.9	6.10	1	1	1
09/10/2020 18:00	1.3	12.5	2,011.4	0.9	6.00	1	1	1
09/10/2020 19:00	1.3	12.6	2,011.1	0.9	6.00	1	1	1
09/10/2020 20:00	1.3	12.6	2,007.6	0.9	6.00	1	1	1
09/10/2020 21:00	1.3	12.7	2,000.6	0.9	6.00	1	1	1
09/10/2020 22:00	1.3	12.6	2,001.6	0.9	6.00	1	1	1
09/10/2020 23:00	1.2	13.2	1,843.3	0.9	5.50	1	1	1
Average/Sum#:	1.1	13.5	1,699.6	0.8	120.90 #	24 #	24 #	9 #
Minimum:	0.7	12.3	1,313.6	0.6	2.60	1	1	0
Maximum:	1.3	14.1	2,059.3	0.9	6.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/11/2020 00:00	0.6	13.9	1,416.1	0.5	2.80	1	1	0
09/11/2020 01:00	0.6	14.0	1,292.7	0.5	2.60	1	1	0
09/11/2020 02:00	0.7	14.0	1,292.1	0.6	2.60	1	1	0
09/11/2020 03:00	0.7	14.0	1,291.9	0.6	2.60	1	1	0
09/11/2020 04:00	0.7	14.0	1,291.9	0.6	2.60	1	1	0
09/11/2020 05:00	1.0	14.0	1,484.0	0.9	4.50	1	1	0
09/11/2020 06:00	0.7	14.1	1,297.4	0.6	2.60	1	1	0
09/11/2020 07:00	0.7	14.1	1,323.4	0.6	2.60	1	1	0
09/11/2020 08:00	0.7	14.1	1,345.4	0.6	2.70	1	1	0
09/11/2020 09:00	1.0	14.0	1,569.9	0.9	4.70	1	1	0
09/11/2020 10:00	1.0	14.0	1,553.5	0.9	4.70	1	1	0
09/11/2020 11:00	1.1	14.0	1,540.7	0.9	4.60	1	1	0
09/11/2020 12:00	1.1	14.0	1,587.4	0.9	4.80	1	1	0
09/11/2020 13:00	0.8	14.0	1,298.0	0.7	3.90	1	1	0
09/11/2020 14:00	0.8	14.1	1,300.6	0.7	3.90	1	1	0
09/11/2020 15:00	0.9	14.0	1,335.3	0.8	4.00	1	1	0
09/11/2020 16:00	1.1	13.9	1,647.5	0.9	4.90	1	1	0
09/11/2020 17:00	1.1	13.9	1,641.0	0.9	4.90	1	1	0
09/11/2020 18:00	1.2	13.3	1,805.5	0.9	5.40	1	1	1
09/11/2020 19:00	1.3	12.3	2,053.2	0.9	6.20	1	1	1
09/11/2020 20:00	1.3	12.4	2,015.8	0.9	6.00	1	1	1
09/11/2020 21:00	1.3	12.7	1,971.8	0.9	5.90	1	1	1
09/11/2020 22:00	0.9	13.7	1,484.3	0.7	4.50	1	1	1
09/11/2020 23:00	4.4	16.6	355.5	6.0	1.33	1	0	0
Average/Sum#:	1.1	13.9	1,466.5	1.0	95.33 #	24 #	23 #	5 #
Minimum:	0.6	12.3	355.5	0.5	1.33	1	0	0
Maximum:	4.4	16.6	2,053.2	6.0	6.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/12/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/13/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/14/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2020 13:00	31.2	17.7	434.1	57.5	53.36	1	0	0
09/14/2020 14:00	23.6	15.8	688.2	27.3	69.50	1	0	0
09/14/2020 15:00	3.2	13.9	1,567.4	2.7	15.70	1	0	0
09/14/2020 16:00	1.2	13.1	1,814.4	0.9	5.40	1	1	1
09/14/2020 17:00	1.4	11.7	2,156.7	0.9	6.50	1	1	1
09/14/2020 18:00	1.4	11.7	2,159.9	0.9	6.50	1	1	1
09/14/2020 19:00	1.4	11.8	2,137.7	0.9	6.40	1	1	1
09/14/2020 20:00	1.4	11.7	2,152.2	0.9	6.50	1	1	1
09/14/2020 21:00	1.3	12.3	2,034.4	0.9	6.10	1	1	1
09/14/2020 22:00	1.3	12.7	1,957.7	0.9	5.90	1	1	1
09/14/2020 23:00	1.3	12.7	1,953.4	0.9	5.90	1	1	1
Average/Sum#:	6.2	13.2	1,732.4	8.6	187.76 #	11 #	8 #	8 #
Minimum:	1.2	11.7	434.1	0.9	5.40	0	0	0
Maximum:	31.2	17.7	2,159.9	57.5	69.50	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/15/2020 00:00	0.8	13.9	1,447.3	0.7	2.90	1	1	0
09/15/2020 01:00	0.8	14.0	1,330.6	0.7	4.00	1	1	0
09/15/2020 02:00	0.7	14.0	1,288.5	0.6	2.60	1	1	0
09/15/2020 03:00	0.7	14.0	1,289.5	0.6	2.60	1	1	0
09/15/2020 04:00	0.7	14.0	1,317.0	0.6	2.60	1	1	0
09/15/2020 05:00	0.9	13.9	1,573.3	0.8	4.70	1	1	0
09/15/2020 06:00	0.9	13.9	1,611.6	0.8	4.80	1	1	0
09/15/2020 07:00	0.9	14.0	1,434.8	0.8	4.30	1	1	0
09/15/2020 08:00	1.0	14.0	1,422.2	0.9	4.30	1	1	0
09/15/2020 09:00	0.8	14.0	1,289.1	0.7	3.90	1	1	0
09/15/2020 10:00	1.1	14.0	1,588.3	0.9	4.80	1	1	0
09/15/2020 11:00	1.0	14.0	1,614.0	0.9	4.80	1	1	0
09/15/2020 12:00	1.1	14.0	1,606.4	0.9	4.80	1	1	0
09/15/2020 13:00	1.1	13.8	1,674.8	0.9	5.00	1	1	1
09/15/2020 14:00	1.4	11.9	2,112.3	0.9	6.30	1	1	1
09/15/2020 15:00	1.4	11.7	2,134.4	0.9	6.40	1	1	1
09/15/2020 16:00	1.3	12.1	2,060.6	0.9	6.20	1	1	1
09/15/2020 17:00	1.3	12.2	2,054.1	0.9	6.20	1	1	1
09/15/2020 18:00	1.3	12.3	2,042.1	0.9	6.10	1	1	1
09/15/2020 19:00	1.4	12.2	2,061.5	0.9	6.20	1	1	1
09/15/2020 20:00	1.4	11.7	2,153.7	0.9	6.50	1	1	1
09/15/2020 21:00	1.3	12.1	2,079.8	0.9	6.20	1	1	1
09/15/2020 22:00	2.2	13.4	1,411.0	1.7	3.83	1	0	1
09/15/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.1	13.3	1,678.1	0.9	110.03 #	23 #	22 #	10 #
Minimum:	0.7	11.7	1,288.5	0.6	2.60	0	0	0
Maximum:	2.2	14.0	2,153.7	1.7	6.50	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOX, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOX, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/16/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2020 06:00	7.0	17.7	450.7	12.9	11.23	1	0	0
09/16/2020 07:00	8.6	14.6	1,111.1	8.1	33.30	1	0	0
09/16/2020 08:00	0.7	14.0	1,388.7	0.6	2.80	1	1	0
09/16/2020 09:00	0.9	13.9	1,386.8	0.8	4.20	1	1	0
09/16/2020 10:00	0.9	14.0	1,384.2	0.8	4.20	1	1	0
09/16/2020 11:00	0.9	13.9	1,602.5	0.8	4.80	1	1	0
09/16/2020 12:00	0.9	13.9	1,464.2	0.8	4.40	1	1	0
09/16/2020 13:00	1.1	13.8	1,690.5	0.9	5.10	1	1	0
09/16/2020 14:00	1.0	13.8	1,692.8	0.8	5.10	1	1	1
09/16/2020 15:00	1.4	12.0	2,086.2	0.9	6.30	1	1	1
09/16/2020 16:00	1.4	11.7	2,138.3	0.9	6.40	1	1	1
09/16/2020 17:00	1.4	11.5	2,182.1	0.9	6.50	1	1	1
09/16/2020 18:00	1.4	11.6	2,163.7	0.9	6.50	1	1	1
09/16/2020 19:00	1.3	12.3	2,029.2	0.9	6.10	1	1	1
09/16/2020 20:00	1.4	12.2	2,047.9	0.9	6.10	1	1	1
09/16/2020 21:00	1.3	12.3	2,036.4	0.9	6.10	1	1	1
09/16/2020 22:00	1.3	12.4	2,014.8	0.9	6.00	1	1	1
09/16/2020 23:00	1.3	12.7	1,944.5	0.9	5.80	1	1	1
Average/Sum#:	1.9	13.2	1,711.9	1.9	130.93 #	18 #	16 #	10 #
Minimum:	0.7	11.5	450.7	0.6	2.80	0	0	0
Maximum:	8.6	17.7	2,182.1	12.9	33.30	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/17/2020 00:00	0.8	13.9	1,406.6	0.7	2.80	1	1	0
09/17/2020 01:00	0.7	14.0	1,311.3	0.6	2.60	1	1	0
09/17/2020 02:00	0.7	14.0	1,292.7	0.6	2.60	1	1	0
09/17/2020 03:00	0.6	14.0	1,293.5	0.5	2.60	1	1	0
09/17/2020 04:00	0.8	13.9	1,466.9	0.7	2.90	1	1	0
09/17/2020 05:00	0.9	13.9	1,575.1	0.8	4.70	1	1	0
09/17/2020 06:00	0.9	13.9	1,541.3	0.8	4.60	1	1	0
09/17/2020 07:00	1.0	13.9	1,618.7	0.8	4.90	1	1	0
09/17/2020 08:00	1.0	13.9	1,592.2	0.8	4.80	1	1	0
09/17/2020 09:00	0.9	13.9	1,605.5	0.8	4.80	1	1	0
09/17/2020 10:00	0.9	13.9	1,420.9	0.8	4.30	1	1	0
09/17/2020 11:00	1.1	13.9	1,429.0	0.9	4.30	1	1	0
09/17/2020 12:00	1.1	13.9	1,625.5	0.9	4.90	1	1	1
09/17/2020 13:00	1.3	11.9	2,094.6	0.9	6.30	1	1	1
09/17/2020 14:00	1.4	11.5	2,149.9	0.9	6.40	1	1	1
09/17/2020 15:00	1.4	11.5	2,160.6	0.9	6.50	1	1	1
09/17/2020 16:00	1.4	11.4	2,177.0	0.9	6.50	1	1	1
09/17/2020 17:00	1.4	11.6	2,131.3	0.9	6.40	1	1	1
09/17/2020 18:00	1.3	12.1	2,057.5	0.9	6.20	1	1	1
09/17/2020 19:00	1.4	11.8	2,123.8	0.9	6.40	1	1	1
09/17/2020 20:00	1.3	12.2	2,055.5	0.9	6.20	1	1	1
09/17/2020 21:00	1.3	12.2	2,063.7	0.9	6.20	1	1	1
09/17/2020 22:00	1.3	12.0	2,108.0	0.9	6.30	1	1	1
09/17/2020 23:00	2.4	12.4	1,794.5	1.7	10.80	1	0	1
Average/Sum#:	1.1	13.0	1,754.0	0.9	125.00 #	24 #	23 #	12 #
Minimum:	0.6	11.4	1,292.7	0.5	2.60	1	0	0
Maximum:	2.4	14.0	2,177.0	1.7	10.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/18/2020 00:00	0.1	19.2	0.2	0.3	0.00	1	0	0
09/18/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2020 06:00	2.9	17.9	413.9	5.7	3.92	1	0	0
09/18/2020 07:00	5.2	15.4	957.2	5.6	20.10	1	0	0
09/18/2020 08:00	0.6	13.9	1,401.3	0.5	2.80	1	1	0
09/18/2020 09:00	0.9	14.0	1,397.2	0.8	4.20	1	1	0
09/18/2020 10:00	1.1	13.9	1,691.6	0.9	5.10	1	1	0
09/18/2020 11:00	0.9	13.9	1,496.5	0.8	4.50	1	1	0
09/18/2020 12:00	1.0	13.9	1,615.5	0.8	4.80	1	1	0
09/18/2020 13:00	0.9	13.9	1,540.2	0.8	4.60	1	1	1
09/18/2020 14:00	1.3	12.3	2,038.5	0.9	6.10	1	1	1
09/18/2020 15:00	1.4	12.1	2,070.8	0.9	6.20	1	1	1
09/18/2020 16:00	1.3	12.2	2,053.0	0.9	6.20	1	1	1
09/18/2020 17:00	1.3	12.3	2,037.3	0.9	6.10	1	1	1
09/18/2020 18:00	1.3	12.3	2,022.3	0.9	6.10	1	1	1
09/18/2020 19:00	1.3	12.4	2,017.2	0.9	6.10	1	1	1
09/18/2020 20:00	1.3	12.5	2,014.7	0.9	6.00	1	1	1
09/18/2020 21:00	1.3	12.5	2,010.1	0.9	6.00	1	1	1
09/18/2020 22:00	1.7	13.7	1,464.3	1.4	5.62	1	0	1
09/18/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.4	13.8	1,569.0	1.4	104.44 #	18 #	14 #	10 #
Minimum:	0.1	12.1	0.2	0.3	0.00	0	0	0
Maximum:	5.2	19.2	2,070.8	5.7	20.10	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOX, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOX, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/19/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2020 04:00	1.5	18.3	356.8	3.4	1.24	1	0	0
09/19/2020 05:00	6.2	15.2	953.0	6.4	22.90	1	0	0
09/19/2020 06:00	0.6	13.9	1,399.2	0.5	2.80	1	1	0
09/19/2020 07:00	0.9	13.9	1,389.0	0.8	4.20	1	1	0
09/19/2020 08:00	0.9	13.9	1,386.4	0.8	4.20	1	1	0
09/19/2020 09:00	1.0	14.0	1,388.2	0.9	4.20	1	1	0
09/19/2020 10:00	1.0	14.0	1,393.4	0.9	4.20	1	1	0
09/19/2020 11:00	1.0	14.0	1,397.6	0.9	4.20	1	1	0
09/19/2020 12:00	1.0	14.0	1,492.4	0.9	4.50	1	1	0
09/19/2020 13:00	0.9	13.9	1,583.3	0.8	4.70	1	1	0
09/19/2020 14:00	0.9	14.0	1,471.3	0.8	4.40	1	1	0
09/19/2020 15:00	0.8	14.0	1,538.0	0.7	4.60	1	1	1
09/19/2020 16:00	1.3	12.3	2,051.9	0.9	6.20	1	1	1
09/19/2020 17:00	1.4	11.5	2,199.3	0.9	6.60	1	1	1
09/19/2020 18:00	1.4	11.7	2,169.4	0.9	6.50	1	1	1
09/19/2020 19:00	1.4	11.7	2,158.4	0.9	6.50	1	1	1
09/19/2020 20:00	1.4	11.7	2,145.3	0.9	6.40	1	1	1
09/19/2020 21:00	1.3	12.0	2,100.9	0.9	6.30	1	1	1
09/19/2020 22:00	1.4	12.0	2,102.3	0.9	6.30	1	1	1
09/19/2020 23:00	1.3	12.7	1,967.5	0.9	5.90	1	1	1
Average/Sum#:	1.4	13.4	1,632.2	1.3	116.84 #	20 #	18 #	9 #
Minimum:	0.6	11.5	356.8	0.5	1.24	0	0	0
Maximum:	6.2	18.3	2,199.3	6.4	22.90	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOX, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/20/2020 00:00	1.3	12.8	1,954.8	0.9	5.90	1	1	1
09/20/2020 01:00	1.3	12.8	1,959.3	0.9	5.90	1	1	1
09/20/2020 02:00	1.3	12.8	1,960.4	0.9	5.90	1	1	1
09/20/2020 03:00	1.3	12.8	1,958.5	0.9	5.90	1	1	1
09/20/2020 04:00	1.2	12.9	1,947.3	0.9	5.80	1	1	1
09/20/2020 05:00	1.3	12.9	1,916.4	1.0	7.70	1	1	1
09/20/2020 06:00	2.6	15.6	659.6	2.9	1.83	1	0	0
09/20/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2020 10:00	1.1	17.9	408.1	2.2	1.58	1	0	0
09/20/2020 11:00	6.4	15.3	951.1	6.7	23.80	1	0	0
09/20/2020 12:00	0.8	14.0	1,486.9	0.7	4.50	1	1	0
09/20/2020 13:00	1.1	13.9	1,546.6	0.9	4.60	1	1	0
09/20/2020 14:00	1.2	13.9	1,602.4	1.0	6.40	1	1	0
09/20/2020 15:00	1.0	13.9	1,478.1	0.8	4.40	1	1	0
09/20/2020 16:00	1.1	13.9	1,588.9	0.9	4.80	1	1	1
09/20/2020 17:00	1.4	12.1	2,077.6	0.9	6.20	1	1	1
09/20/2020 18:00	1.4	11.4	2,205.7	0.9	6.60	1	1	1
09/20/2020 19:00	1.4	11.4	2,198.0	0.9	6.60	1	1	1
09/20/2020 20:00	1.4	11.7	2,160.0	0.9	6.50	1	1	1
09/20/2020 21:00	1.3	12.2	2,013.7	0.9	6.00	1	1	1
09/20/2020 22:00	2.6	15.6	627.8	2.9	1.59	1	0	0
09/20/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.6	13.5	1,635.1	1.5	122.50 #	20 #	16 #	12 #
Minimum:	0.8	11.4	408.1	0.7	1.58	0	0	0
Maximum:	6.4	17.9	2,205.7	6.7	23.80	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/21/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2020 13:00	27.3	17.8	422.7	52.0	42.77	1	0	0
09/21/2020 14:00	14.8	15.5	809.6	16.2	48.60	1	0	0
09/21/2020 15:00	0.7	13.9	1,520.3	0.6	3.00	1	1	1
09/21/2020 16:00	1.3	12.4	1,984.3	0.9	6.00	1	1	1
09/21/2020 17:00	1.3	12.3	2,014.5	0.9	6.00	1	1	1
09/21/2020 18:00	1.4	12.4	1,995.7	1.0	8.00	1	1	1
09/21/2020 19:00	1.3	12.1	2,057.6	0.9	6.20	1	1	1
09/21/2020 20:00	1.4	11.9	2,104.7	0.9	6.30	1	1	1
09/21/2020 21:00	1.3	12.1	2,041.2	0.9	6.10	1	1	1
09/21/2020 22:00	2.4	15.7	620.1	2.7	1.43	1	0	0
09/21/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	5.3	13.6	1,557.1	7.7	134.40 #	10 #	7 #	7 #
Minimum:	0.7	11.9	422.7	0.6	1.43	0	0	0
Maximum:	27.3	17.8	2,104.7	52.0	48.60	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/22/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2020 14:00	24.3	17.9	412.5	47.8	32.67	1	0	0
09/22/2020 15:00	20.0	15.5	828.1	21.9	67.10	1	0	0
09/22/2020 16:00	0.7	13.9	1,522.4	0.6	3.00	1	1	1
09/22/2020 17:00	1.3	12.6	1,765.3	0.9	5.30	1	1	1
09/22/2020 18:00	1.3	12.7	1,775.9	0.9	5.30	1	1	1
09/22/2020 19:00	1.3	12.7	1,775.9	0.9	5.30	1	1	1
09/22/2020 20:00	1.3	12.7	1,775.0	0.9	5.30	1	1	1
09/22/2020 21:00	2.1	14.2	1,185.6	1.8	3.90	1	0	1
09/22/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	6.5	14.0	1,380.1	9.5	127.87 #	8 #	5 #	6 #
Minimum:	0.7	12.6	412.5	0.6	3.00	0	0	0
Maximum:	24.3	17.9	1,775.9	47.8	67.10	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/23/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/23/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/23/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/23/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/23/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/23/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/23/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/23/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/23/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/23/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/23/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/23/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/23/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/23/2020 13:00	25.8	17.8	423.1	49.1	32.94	1	0	0
09/23/2020 14:00	21.5	15.7	795.1	24.4	71.60	1	0	0
09/23/2020 15:00	0.8	13.9	1,553.8	0.7	3.10	1	1	1
09/23/2020 16:00	1.3	12.3	2,024.5	0.9	6.10	1	1	1
09/23/2020 17:00	1.3	12.3	2,019.3	0.9	6.10	1	1	1
09/23/2020 18:00	1.3	12.6	1,989.1	0.9	6.00	1	1	1
09/23/2020 19:00	1.4	12.3	2,062.2	1.0	8.20	1	1	1
09/23/2020 20:00	1.3	12.8	1,941.0	0.9	5.80	1	1	1
09/23/2020 21:00	2.7	15.8	606.2	3.1	1.68	1	0	0
09/23/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/23/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	6.4	13.9	1,490.5	9.1	141.52 #	9 #	6 #	6 #
Minimum:	0.8	12.3	423.1	0.7	1.68	0	0	0
Maximum:	25.8	17.8	2,062.2	49.1	71.60	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOX, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOX, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/24/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/24/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/24/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/24/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/24/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/24/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/24/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/24/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/24/2020 08:00	22.0	18.0	396.8	44.8	24.24	1	0	0
09/24/2020 09:00	12.8	17.1	515.3	19.9	37.60	1	0	0
09/24/2020 10:00	5.9	15.5	870.0	6.4	20.90	1	0	0
09/24/2020 11:00	0.6	14.0	1,380.6	0.5	2.80	1	1	0
09/24/2020 12:00	0.9	14.0	1,367.0	0.8	4.10	1	1	0
09/24/2020 13:00	1.0	13.9	1,577.5	0.8	4.70	1	1	0
09/24/2020 14:00	0.9	14.0	1,408.9	0.8	4.20	1	1	0
09/24/2020 15:00	1.1	13.9	1,659.9	0.9	5.00	1	1	0
09/24/2020 16:00	1.2	13.1	1,821.4	0.9	5.50	1	1	1
09/24/2020 17:00	1.4	11.9	2,104.3	0.9	6.30	1	1	1
09/24/2020 18:00	1.4	12.0	2,093.7	0.9	6.30	1	1	1
09/24/2020 19:00	1.2	12.1	2,086.4	0.8	6.30	1	1	1
09/24/2020 20:00	2.1	14.1	1,203.9	1.8	4.03	1	0	1
09/24/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/24/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/24/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	4.0	14.1	1,422.0	6.2	131.97 #	13 #	9 #	5 #
Minimum:	0.6	11.9	396.8	0.5	2.80	0	0	0
Maximum:	22.0	18.0	2,104.3	44.8	37.60	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/25/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/26/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/27/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2020 08:00	4.2	19.8	121.9	22.5	0.77	1	0	0
09/27/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2020 13:00	11.0	19.2	216.0	38.2	4.62	1	0	0
09/27/2020 14:00	39.3	16.5	601.3	52.7	116.70	1	0	0
09/27/2020 15:00	3.5	14.0	1,610.3	3.0	17.70	1	0	0
09/27/2020 16:00	0.0	0.0	1,618.6	0.0	0.00	1	1	1
09/27/2020 17:00	1.4	11.8	2,097.3	0.9	6.30	1	1	1
09/27/2020 18:00	1.4	11.9	2,137.0	0.9	6.40	1	1	1
09/27/2020 19:00	1.4	11.8	2,148.4	0.9	6.40	1	1	1
09/27/2020 20:00	1.4	11.9	2,146.1	0.9	6.40	1	1	1
09/27/2020 21:00	1.4	11.9	2,140.9	0.9	6.40	1	1	1
09/27/2020 22:00	2.3	13.7	1,277.6	1.9	4.27	1	0	1
09/27/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	6.7	14.3	1,465.0	12.3	175.96 #	11 #	6 #	7 #
Minimum:	1.4	11.8	121.9	0.9	0.77	0	0	0
Maximum:	39.3	19.8	2,148.4	52.7	116.70	1	1	1
%SI	58.33	58.33	54.17	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/28/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2020 06:00	25.3	18.0	402.9	51.5	28.34	1	0	0
09/28/2020 07:00	17.7	15.5	897.4	19.3	63.70	1	0	0
09/28/2020 08:00	0.6	14.1	1,383.9	0.5	2.80	1	1	0
09/28/2020 09:00	0.8	14.1	1,368.3	0.7	4.10	1	1	0
09/28/2020 10:00	1.0	13.9	1,641.9	0.8	4.90	1	1	0
09/28/2020 11:00	1.0	14.0	1,465.0	0.9	4.40	1	1	0
09/28/2020 12:00	1.1	13.9	1,731.9	0.9	5.20	1	1	0
09/28/2020 13:00	1.1	13.6	1,690.7	0.9	5.10	1	1	1
09/28/2020 14:00	1.4	12.0	2,125.5	0.9	6.40	1	1	1
09/28/2020 15:00	1.4	11.5	2,208.3	0.9	6.60	1	1	1
09/28/2020 16:00	1.4	11.5	2,206.8	0.9	6.60	1	1	1
09/28/2020 17:00	1.4	11.6	2,191.5	0.9	6.60	1	1	1
09/28/2020 18:00	1.4	11.6	2,187.1	0.9	6.60	1	1	1
09/28/2020 19:00	1.4	11.9	2,131.0	0.9	6.40	1	1	1
09/28/2020 20:00	1.4	11.9	2,141.9	0.9	6.40	1	1	1
09/28/2020 21:00	1.4	12.1	2,105.4	0.9	6.30	1	1	1
09/28/2020 22:00	2.1	14.0	1,261.1	1.8	4.40	1	0	1
09/28/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	3.6	13.2	1,714.2	5.0	174.84 #	17 #	14 #	10 #
Minimum:	0.6	11.5	402.9	0.5	2.80	0	0	0
Maximum:	25.3	18.0	2,208.3	51.5	63.70	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/29/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2020 06:00	21.3	18.0	412.2	43.3	26.40	1	0	0
09/29/2020 07:00	16.3	15.6	873.1	18.1	58.50	1	0	0
09/29/2020 08:00	0.6	14.1	1,374.8	0.5	2.70	1	1	0
09/29/2020 09:00	0.8	14.1	1,361.9	0.7	4.10	1	1	0
09/29/2020 10:00	0.9	13.9	1,610.6	0.8	4.80	1	1	0
09/29/2020 11:00	1.0	14.0	1,484.3	0.9	4.50	1	1	0
09/29/2020 12:00	1.1	13.9	1,718.3	0.9	5.20	1	1	0
09/29/2020 13:00	1.2	13.3	1,794.9	0.9	5.40	1	1	1
09/29/2020 14:00	1.4	11.9	2,140.7	0.9	6.40	1	1	1
09/29/2020 15:00	1.4	11.7	2,162.4	0.9	6.50	1	1	1
09/29/2020 16:00	1.4	11.5	2,198.0	0.9	6.60	1	1	1
09/29/2020 17:00	1.4	11.5	2,198.4	0.9	6.60	1	1	1
09/29/2020 18:00	1.4	11.8	2,150.6	0.9	6.50	1	1	1
09/29/2020 19:00	1.4	11.7	2,187.4	0.9	6.60	1	1	1
09/29/2020 20:00	1.4	11.8	2,169.2	0.9	6.50	1	1	1
09/29/2020 21:00	1.4	11.9	2,148.6	0.9	6.40	1	1	1
09/29/2020 22:00	1.4	12.1	2,114.4	0.9	6.30	1	1	1
09/29/2020 23:00	1.3	12.2	2,103.0	0.9	6.30	1	1	1
Average/Sum#:	3.2	13.1	1,789.0	4.2	176.30 #	18 #	16 #	11 #
Minimum:	0.6	11.5	412.2	0.5	2.70	0	0	0
Maximum:	21.3	18.0	2,198.4	43.3	58.50	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:47 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/30/2020 00:00	1.3	12.6	2,012.9	0.9	6.00	1	1	1
09/30/2020 01:00	1.0	13.9	1,653.9	0.8	5.00	1	1	0
09/30/2020 02:00	1.1	13.9	1,693.5	0.9	5.10	1	1	0
09/30/2020 03:00	1.1	13.9	1,673.6	0.9	5.00	1	1	0
09/30/2020 04:00	1.1	13.7	1,718.6	0.9	5.20	1	1	1
09/30/2020 05:00	1.4	12.4	2,046.5	1.0	8.20	1	1	1
09/30/2020 06:00	1.3	12.4	2,035.4	0.9	6.10	1	1	1
09/30/2020 07:00	1.0	13.9	1,661.0	0.8	5.00	1	1	0
09/30/2020 08:00	1.1	13.9	1,695.7	0.9	5.10	1	1	0
09/30/2020 09:00	1.1	13.9	1,699.6	0.9	5.10	1	1	0
09/30/2020 10:00	1.1	13.6	1,696.0	0.9	5.10	1	1	1
09/30/2020 11:00	1.4	12.1	2,112.0	0.9	6.30	1	1	1
09/30/2020 12:00	1.4	11.8	2,147.5	0.9	6.40	1	1	1
09/30/2020 13:00	1.4	11.6	2,177.0	0.9	6.50	1	1	1
09/30/2020 14:00	1.4	11.8	2,116.5	0.9	6.30	1	1	1
09/30/2020 15:00	1.4	11.7	2,151.0	0.9	6.50	1	1	1
09/30/2020 16:00	1.4	11.7	2,142.2	0.9	6.40	1	1	1
09/30/2020 17:00	1.4	11.8	2,121.0	0.9	6.40	1	1	1
09/30/2020 18:00	1.4	11.8	2,139.7	0.9	6.40	1	1	1
09/30/2020 19:00	1.4	11.7	2,163.6	0.9	6.50	1	1	1
09/30/2020 20:00	1.4	11.8	2,146.1	0.9	6.40	1	1	1
09/30/2020 21:00	1.4	11.9	2,128.7	0.9	6.40	1	1	1
09/30/2020 22:00	1.4	12.0	2,113.7	0.9	6.30	1	1	1
09/30/2020 23:00	1.3	12.5	1,981.1	0.9	5.90	1	1	1
Average/Sum#:	1.3	12.6	1,967.8	0.9	143.60 #	24 #	24 #	18 #
Minimum:	1.0	11.6	1,653.9	0.8	5.00	1	1	0
Maximum:	1.4	13.9	2,177.0	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/01/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/02/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOX, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/03/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2020 08:00	27.5	17.6	451.6	49.2	57.19	1	0	0
07/03/2020 09:00	10.9	17.1	517.8	16.9	32.10	1	0	0
07/03/2020 10:00	7.1	15.8	830.3	8.2	24.90	1	0	0
07/03/2020 11:00	0.5	13.9	1,391.9	0.4	2.80	1	1	0
07/03/2020 12:00	0.6	13.9	1,359.1	0.5	2.70	1	1	0
07/03/2020 13:00	0.9	13.9	1,606.0	0.8	4.80	1	1	0
07/03/2020 14:00	0.7	13.9	1,451.0	0.6	2.90	1	1	0
07/03/2020 15:00	1.0	13.8	1,676.5	0.8	5.00	1	1	0
07/03/2020 16:00	0.9	13.8	1,641.4	0.7	4.90	1	1	1
07/03/2020 17:00	1.4	12.4	2,019.1	1.0	8.10	1	1	1
07/03/2020 18:00	1.6	12.0	2,108.2	1.1	8.40	1	1	1
07/03/2020 19:00	1.6	12.0	2,089.5	1.1	8.40	1	1	1
07/03/2020 20:00	1.6	11.9	2,117.2	1.0	8.50	1	1	1
07/03/2020 21:00	1.5	12.3	2,033.4	1.0	8.10	1	1	1
07/03/2020 22:00	1.6	12.3	2,052.5	1.1	8.20	1	1	1
07/03/2020 23:00	2.8	14.1	1,216.3	2.4	5.67	1	0	1
Average/Sum#:	3.9	13.8	1,535.1	5.4	192.66 #	16 #	12 #	8 #
Minimum:	0.5	11.9	451.6	0.4	2.70	0	0	0
Maximum:	27.5	17.6	2,117.2	49.2	57.19	1	1	1
%SI	33.33	33.33	33.33	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/04/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/05/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2020 09:00	31.6	17.5	455.8	54.8	64.47	1	0	0
07/05/2020 10:00	12.7	17.0	520.2	19.2	36.90	1	0	0
07/05/2020 11:00	15.3	15.4	867.4	16.4	52.00	1	0	0
07/05/2020 12:00	0.5	14.0	1,394.7	0.4	2.80	1	1	0
07/05/2020 13:00	0.6	14.0	1,383.8	0.5	2.80	1	1	0
07/05/2020 14:00	1.0	13.8	1,632.8	0.8	4.90	1	1	0
07/05/2020 15:00	0.7	14.0	1,389.5	0.6	2.80	1	1	0
07/05/2020 16:00	0.9	13.8	1,603.7	0.7	4.80	1	1	0
07/05/2020 17:00	1.2	13.0	1,813.1	0.9	5.40	1	1	1
07/05/2020 18:00	1.6	11.9	2,095.0	1.0	8.40	1	1	1
07/05/2020 19:00	1.6	12.0	2,077.3	1.1	8.30	1	1	1
07/05/2020 20:00	1.6	12.0	2,095.4	1.1	8.40	1	1	1
07/05/2020 21:00	1.6	12.2	2,082.0	1.1	8.30	1	1	1
07/05/2020 22:00	2.6	13.6	1,379.2	2.1	6.60	1	0	1
07/05/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	5.3	13.9	1,485.0	7.2	216.87 #	14 #	10 #	6 #
Minimum:	0.5	11.9	455.8	0.4	2.80	0	0	0
Maximum:	31.6	17.5	2,095.4	54.8	64.47	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOX, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOX, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/06/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2020 02:00	1.1	17.7	448.7	2.0	1.09	1	0	0
07/06/2020 03:00	7.4	14.5	1,146.4	6.8	28.70	1	0	0
07/06/2020 04:00	0.6	13.9	1,375.6	0.5	2.80	1	1	0
07/06/2020 05:00	0.7	13.9	1,375.6	0.6	2.80	1	1	0
07/06/2020 06:00	0.6	13.9	1,378.4	0.5	2.80	1	1	0
07/06/2020 07:00	0.7	13.9	1,379.4	0.6	2.80	1	1	0
07/06/2020 08:00	0.7	14.0	1,382.7	0.6	2.80	1	1	0
07/06/2020 09:00	0.7	13.9	1,384.9	0.6	2.80	1	1	0
07/06/2020 10:00	0.7	13.9	1,389.9	0.6	2.80	1	1	0
07/06/2020 11:00	1.0	13.8	1,637.8	0.8	4.90	1	1	0
07/06/2020 12:00	0.8	13.8	1,507.3	0.7	3.00	1	1	0
07/06/2020 13:00	1.0	13.7	1,697.7	0.8	5.10	1	1	0
07/06/2020 14:00	0.9	13.8	1,627.3	0.7	4.90	1	1	0
07/06/2020 15:00	1.0	13.7	1,556.1	0.8	4.70	1	1	1
07/06/2020 16:00	1.6	12.3	2,050.3	1.1	8.20	1	1	1
07/06/2020 17:00	1.6	12.0	2,098.7	1.1	8.40	1	1	1
07/06/2020 18:00	1.6	11.9	2,111.2	1.0	8.40	1	1	1
07/06/2020 19:00	1.6	12.1	2,085.5	1.1	8.30	1	1	1
07/06/2020 20:00	1.6	12.3	2,065.3	1.1	8.30	1	1	1
07/06/2020 21:00	1.6	12.4	2,040.8	1.1	8.20	1	1	1
07/06/2020 22:00	1.5	12.8	1,951.6	1.1	7.80	1	1	1
07/06/2020 23:00	1.3	13.1	1,794.6	1.0	7.20	1	1	1
Average/Sum#:	1.4	13.5	1,613.0	1.1	136.79 #	22 #	20 #	9 #
Minimum:	0.6	11.9	448.7	0.5	1.09	0	0	0
Maximum:	7.4	17.7	2,111.2	6.8	28.70	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/07/2020 00:00	0.7	13.9	1,294.8	0.6	2.60	1	1	0
07/07/2020 01:00	0.7	13.9	1,344.3	0.6	2.70	1	1	0
07/07/2020 02:00	0.7	13.9	1,301.2	0.6	2.60	1	1	0
07/07/2020 03:00	0.7	13.9	1,292.5	0.6	2.60	1	1	0
07/07/2020 04:00	0.7	13.9	1,283.1	0.6	2.60	1	1	0
07/07/2020 05:00	0.7	13.9	1,306.7	0.6	2.60	1	1	0
07/07/2020 06:00	0.7	13.9	1,293.5	0.6	2.60	1	1	0
07/07/2020 07:00	0.6	13.9	1,310.8	0.5	2.60	1	1	0
07/07/2020 08:00	0.7	14.0	1,329.5	0.6	2.70	1	1	0
07/07/2020 09:00	0.7	13.9	1,305.9	0.6	2.60	1	1	0
07/07/2020 10:00	0.7	13.9	1,295.0	0.6	2.60	1	1	0
07/07/2020 11:00	0.7	14.0	1,299.5	0.6	2.60	1	1	0
07/07/2020 12:00	0.7	14.0	1,301.5	0.6	2.60	1	1	0
07/07/2020 13:00	1.0	13.9	1,403.2	0.8	4.20	1	1	0
07/07/2020 14:00	0.8	13.9	1,374.7	0.7	2.70	1	1	0
07/07/2020 15:00	0.9	13.9	1,514.4	0.8	4.50	1	1	1
07/07/2020 16:00	1.5	12.3	2,035.3	1.0	8.10	1	1	1
07/07/2020 17:00	1.6	12.0	2,107.7	1.1	8.40	1	1	1
07/07/2020 18:00	1.6	12.1	2,081.0	1.1	8.30	1	1	1
07/07/2020 19:00	1.6	12.2	2,071.5	1.1	8.30	1	1	1
07/07/2020 20:00	1.6	12.2	2,075.5	1.1	8.30	1	1	1
07/07/2020 21:00	1.6	12.3	2,066.0	1.1	8.30	1	1	1
07/07/2020 22:00	1.5	12.7	1,966.2	1.1	7.90	1	1	1
07/07/2020 23:00	1.4	13.0	1,849.4	1.0	7.40	1	1	1
Average/Sum#:	1.0	13.4	1,562.6	0.8	110.40 #	24 #	24 #	9 #
Minimum:	0.6	12.0	1,283.1	0.5	2.60	1	1	0
Maximum:	1.6	14.0	2,107.7	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/08/2020 00:00	0.7	14.0	1,316.6	0.6	2.60	1	1	0
07/08/2020 01:00	0.7	14.0	1,283.1	0.6	2.60	1	1	0
07/08/2020 02:00	0.7	14.0	1,283.2	0.6	2.60	1	1	0
07/08/2020 03:00	0.7	14.0	1,283.2	0.6	2.60	1	1	0
07/08/2020 04:00	0.7	14.0	1,285.2	0.6	2.60	1	1	0
07/08/2020 05:00	0.7	14.0	1,296.4	0.6	2.60	1	1	0
07/08/2020 06:00	0.7	14.0	1,287.7	0.6	2.60	1	1	0
07/08/2020 07:00	0.6	14.0	1,291.8	0.5	2.60	1	1	0
07/08/2020 08:00	0.7	14.0	1,289.9	0.6	2.60	1	1	0
07/08/2020 09:00	0.7	14.0	1,289.4	0.6	2.60	1	1	0
07/08/2020 10:00	0.7	14.0	1,291.4	0.6	2.60	1	1	0
07/08/2020 11:00	0.7	14.0	1,308.4	0.6	2.60	1	1	0
07/08/2020 12:00	0.8	14.0	1,363.9	0.7	4.10	1	1	0
07/08/2020 13:00	0.7	14.0	1,315.9	0.6	2.60	1	1	0
07/08/2020 14:00	0.8	14.0	1,367.2	0.7	4.10	1	1	0
07/08/2020 15:00	0.9	13.9	1,455.6	0.8	4.40	1	1	1
07/08/2020 16:00	1.5	12.2	2,035.2	1.0	8.10	1	1	1
07/08/2020 17:00	1.6	12.0	2,067.8	1.1	8.30	1	1	1
07/08/2020 18:00	1.7	12.0	2,077.6	1.1	8.30	1	1	1
07/08/2020 19:00	1.6	12.0	2,075.5	1.1	8.30	1	1	1
07/08/2020 20:00	1.6	12.0	2,077.7	1.1	8.30	1	1	1
07/08/2020 21:00	1.5	12.3	2,016.0	1.0	8.10	1	1	1
07/08/2020 22:00	1.5	12.6	1,969.5	1.1	7.90	1	1	1
07/08/2020 23:00	1.4	12.9	1,805.0	1.0	7.20	1	1	1
Average/Sum#:	1.0	13.4	1,547.2	0.8	110.90 #	24 #	24 #	9 #
Minimum:	0.6	12.0	1,283.1	0.5	2.60	1	1	0
Maximum:	1.7	14.0	2,077.7	1.1	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/09/2020 00:00	0.8	13.9	1,304.7	0.7	2.60	1	1	0
07/09/2020 01:00	0.8	13.9	1,300.1	0.7	2.60	1	1	0
07/09/2020 02:00	0.7	13.9	1,282.4	0.6	2.60	1	1	0
07/09/2020 03:00	0.7	13.9	1,343.4	0.6	2.70	1	1	0
07/09/2020 04:00	0.7	13.9	1,312.4	0.6	2.60	1	1	0
07/09/2020 05:00	0.7	13.9	1,366.0	0.6	2.70	1	1	0
07/09/2020 06:00	0.7	14.0	1,295.6	0.6	2.60	1	1	0
07/09/2020 07:00	0.7	14.0	1,295.1	0.6	2.60	1	1	0
07/09/2020 08:00	0.7	14.0	1,298.9	0.6	2.60	1	1	0
07/09/2020 09:00	0.7	14.0	1,301.3	0.6	2.60	1	1	0
07/09/2020 10:00	0.7	13.9	1,296.7	0.6	2.60	1	1	0
07/09/2020 11:00	0.7	14.0	1,296.8	0.6	2.60	1	1	0
07/09/2020 12:00	1.0	13.9	1,545.2	0.8	4.60	1	1	0
07/09/2020 13:00	1.1	13.8	1,663.7	0.9	5.00	1	1	0
07/09/2020 14:00	1.0	13.8	1,535.0	0.8	4.60	1	1	1
07/09/2020 15:00	1.6	12.2	2,036.1	1.1	8.10	1	1	1
07/09/2020 16:00	1.6	12.0	2,070.7	1.1	8.30	1	1	1
07/09/2020 17:00	1.7	11.9	2,086.0	1.1	8.30	1	1	1
07/09/2020 18:00	1.7	11.8	2,106.8	1.1	8.40	1	1	1
07/09/2020 19:00	1.6	11.8	2,104.1	1.0	8.40	1	1	1
07/09/2020 20:00	1.6	12.0	2,070.7	1.1	8.30	1	1	1
07/09/2020 21:00	1.6	12.1	2,069.5	1.1	8.30	1	1	1
07/09/2020 22:00	1.5	12.6	1,975.0	1.1	7.90	1	1	1
07/09/2020 23:00	1.5	12.7	1,920.2	1.1	7.70	1	1	1
Average/Sum#:	1.1	13.2	1,619.9	0.8	119.30 #	24 #	24 #	10 #
Minimum:	0.7	11.8	1,282.4	0.6	2.60	1	1	0
Maximum:	1.7	14.0	2,106.8	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/10/2020 00:00	0.8	13.9	1,390.8	0.7	2.80	1	1	0
07/10/2020 01:00	0.6	14.0	1,287.0	0.5	2.60	1	1	0
07/10/2020 02:00	0.6	14.0	1,286.1	0.5	2.60	1	1	0
07/10/2020 03:00	0.6	14.0	1,283.4	0.5	2.60	1	1	0
07/10/2020 04:00	0.6	13.9	1,293.4	0.5	2.60	1	1	0
07/10/2020 05:00	0.8	13.9	1,564.4	0.7	3.10	1	1	0
07/10/2020 06:00	0.9	13.9	1,666.7	0.8	5.00	1	1	0
07/10/2020 07:00	1.0	13.8	1,666.7	0.8	5.00	1	1	0
07/10/2020 08:00	0.9	13.9	1,579.1	0.8	4.70	1	1	0
07/10/2020 09:00	0.8	13.9	1,443.5	0.7	2.90	1	1	0
07/10/2020 10:00	0.8	13.9	1,479.8	0.7	3.00	1	1	0
07/10/2020 11:00	0.7	13.9	1,373.5	0.6	2.70	1	1	0
07/10/2020 12:00	1.0	13.8	1,529.8	0.8	4.60	1	1	1
07/10/2020 13:00	1.5	12.3	2,008.5	1.0	8.00	1	1	1
07/10/2020 14:00	1.6	12.0	2,064.0	1.1	8.30	1	1	1
07/10/2020 15:00	1.6	12.0	2,067.6	1.1	8.30	1	1	1
07/10/2020 16:00	1.6	11.8	2,090.1	1.0	8.40	1	1	1
07/10/2020 17:00	1.7	11.7	2,103.5	1.1	8.40	1	1	1
07/10/2020 18:00	1.7	11.7	2,111.5	1.1	8.40	1	1	1
07/10/2020 19:00	1.6	11.7	2,115.1	1.0	8.50	1	1	1
07/10/2020 20:00	1.7	11.7	2,114.5	1.1	8.50	1	1	1
07/10/2020 21:00	1.6	12.1	2,042.9	1.1	8.20	1	1	1
07/10/2020 22:00	1.6	12.1	2,059.0	1.1	8.20	1	1	1
07/10/2020 23:00	1.4	12.9	1,788.6	1.0	7.20	1	1	1
Average/Sum#:	1.2	13.0	1,725.4	0.8	134.60 #	24 #	24 #	12 #
Minimum:	0.6	11.7	1,283.4	0.5	2.60	1	1	0
Maximum:	1.7	14.0	2,115.1	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/11/2020 00:00	0.8	13.9	1,296.6	0.7	2.60	1	1	0
07/11/2020 01:00	0.8	13.9	1,344.8	0.7	2.70	1	1	0
07/11/2020 02:00	0.8	13.9	1,352.0	0.7	2.70	1	1	0
07/11/2020 03:00	0.8	13.9	1,368.2	0.7	2.70	1	1	0
07/11/2020 04:00	0.7	13.9	1,333.1	0.6	2.70	1	1	0
07/11/2020 05:00	1.0	13.9	1,655.3	0.8	5.00	1	1	0
07/11/2020 06:00	0.9	13.9	1,585.4	0.8	4.80	1	1	0
07/11/2020 07:00	0.8	13.9	1,360.0	0.7	2.70	1	1	0
07/11/2020 08:00	1.0	13.9	1,577.4	0.8	4.70	1	1	0
07/11/2020 09:00	0.7	13.9	1,308.9	0.6	2.60	1	1	0
07/11/2020 10:00	0.9	13.9	1,479.0	0.8	4.40	1	1	0
07/11/2020 11:00	1.1	13.8	1,610.3	0.9	4.80	1	1	0
07/11/2020 12:00	1.1	13.9	1,619.1	0.9	4.90	1	1	0
07/11/2020 13:00	0.8	13.9	1,364.5	0.7	2.70	1	1	0
07/11/2020 14:00	0.8	13.9	1,363.2	0.7	2.70	1	1	0
07/11/2020 15:00	1.3	13.0	1,786.6	1.0	7.10	1	1	1
07/11/2020 16:00	1.6	11.9	2,090.2	1.0	8.40	1	1	1
07/11/2020 17:00	1.7	11.8	2,113.8	1.1	8.50	1	1	1
07/11/2020 18:00	1.7	11.8	2,122.3	1.1	8.50	1	1	1
07/11/2020 19:00	1.6	11.8	2,127.3	1.0	8.50	1	1	1
07/11/2020 20:00	1.6	12.0	2,085.5	1.1	8.30	1	1	1
07/11/2020 21:00	1.6	12.2	2,050.1	1.1	8.20	1	1	1
07/11/2020 22:00	1.6	12.2	2,065.3	1.1	8.30	1	1	1
07/11/2020 23:00	1.4	12.9	1,805.9	1.0	7.20	1	1	1
Average/Sum#:	1.1	13.3	1,661.0	0.9	125.70 #	24 #	24 #	9 #
Minimum:	0.7	11.8	1,296.6	0.6	2.60	1	1	0
Maximum:	1.7	13.9	2,127.3	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/12/2020 00:00	0.7	13.9	1,295.6	0.6	2.60	1	1	0
07/12/2020 01:00	0.7	13.9	1,287.2	0.6	2.60	1	1	0
07/12/2020 02:00	0.7	13.9	1,286.0	0.6	2.60	1	1	0
07/12/2020 03:00	0.7	13.9	1,285.9	0.6	2.60	1	1	0
07/12/2020 04:00	0.7	13.9	1,287.1	0.6	2.60	1	1	0
07/12/2020 05:00	0.7	13.9	1,288.6	0.6	2.60	1	1	0
07/12/2020 06:00	0.7	14.0	1,299.8	0.6	2.60	1	1	0
07/12/2020 07:00	0.7	14.0	1,295.9	0.6	2.60	1	1	0
07/12/2020 08:00	0.7	14.0	1,290.6	0.6	2.60	1	1	0
07/12/2020 09:00	0.7	14.0	1,300.9	0.6	2.60	1	1	0
07/12/2020 10:00	0.8	14.0	1,403.5	0.7	4.20	1	1	0
07/12/2020 11:00	0.8	13.9	1,371.6	0.7	2.70	1	1	0
07/12/2020 12:00	0.9	13.9	1,427.6	0.8	4.30	1	1	0
07/12/2020 13:00	0.8	14.0	1,365.6	0.7	4.10	1	1	0
07/12/2020 14:00	0.7	14.0	1,313.3	0.6	2.60	1	1	0
07/12/2020 15:00	1.1	13.7	1,643.7	0.9	4.90	1	1	1
07/12/2020 16:00	1.6	12.1	2,053.3	1.1	8.20	1	1	1
07/12/2020 17:00	1.6	11.7	2,111.8	1.0	8.40	1	1	1
07/12/2020 18:00	1.7	11.7	2,102.2	1.1	8.40	1	1	1
07/12/2020 19:00	1.7	11.8	2,091.2	1.1	8.40	1	1	1
07/12/2020 20:00	1.6	12.0	2,048.7	1.1	8.20	1	1	1
07/12/2020 21:00	1.6	12.2	2,022.0	1.1	8.10	1	1	1
07/12/2020 22:00	1.6	12.0	2,061.4	1.1	8.20	1	1	1
07/12/2020 23:00	1.5	12.5	1,936.2	1.1	7.70	1	1	1
Average/Sum#:	1.0	13.3	1,577.9	0.8	114.40 #	24 #	24 #	9 #
Minimum:	0.7	11.7	1,285.9	0.6	2.60	1	1	0
Maximum:	1.7	14.0	2,111.8	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/13/2020 00:00	1.0	13.8	1,575.8	0.8	4.70	1	1	0
07/13/2020 01:00	0.9	13.8	1,438.5	0.7	4.30	1	1	0
07/13/2020 02:00	0.7	13.9	1,319.9	0.6	2.60	1	1	0
07/13/2020 03:00	0.7	13.9	1,289.0	0.6	2.60	1	1	0
07/13/2020 04:00	0.7	13.9	1,289.2	0.6	2.60	1	1	0
07/13/2020 05:00	0.9	13.8	1,622.3	0.7	4.90	1	1	0
07/13/2020 06:00	0.8	13.8	1,486.7	0.7	3.00	1	1	0
07/13/2020 07:00	0.8	13.9	1,390.0	0.7	2.80	1	1	0
07/13/2020 08:00	0.9	13.9	1,521.8	0.8	4.60	1	1	0
07/13/2020 09:00	0.7	13.9	1,306.4	0.6	2.60	1	1	0
07/13/2020 10:00	0.9	13.9	1,480.7	0.8	4.40	1	1	0
07/13/2020 11:00	1.1	13.8	1,617.5	0.9	4.90	1	1	1
07/13/2020 12:00	1.5	12.4	2,000.9	1.0	8.00	1	1	1
07/13/2020 13:00	1.6	12.0	2,050.8	1.1	8.20	1	1	1
07/13/2020 14:00	1.6	12.0	2,063.9	1.1	8.30	1	1	1
07/13/2020 15:00	1.7	11.9	2,064.6	1.1	8.30	1	1	1
07/13/2020 16:00	1.7	11.9	2,074.4	1.1	8.30	1	1	1
07/13/2020 17:00	1.7	11.8	2,083.9	1.1	8.30	1	1	1
07/13/2020 18:00	1.7	11.8	2,083.5	1.1	8.30	1	1	1
07/13/2020 19:00	1.7	11.9	2,079.3	1.1	8.30	1	1	1
07/13/2020 20:00	1.6	12.0	2,067.4	1.1	8.30	1	1	1
07/13/2020 21:00	1.6	12.1	2,056.2	1.1	8.20	1	1	1
07/13/2020 22:00	1.6	12.2	2,056.1	1.1	8.20	1	1	1
07/13/2020 23:00	1.5	12.7	1,946.3	1.1	7.80	1	1	1
Average/Sum#:	1.2	13.0	1,748.5	0.9	142.50 #	24 #	24 #	13 #
Minimum:	0.7	11.8	1,289.0	0.6	2.60	1	1	0
Maximum:	1.7	13.9	2,083.9	1.1	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/14/2020 00:00	1.3	13.1	1,776.5	1.0	7.10	1	1	1
07/14/2020 01:00	0.7	13.8	1,294.3	0.6	2.60	1	1	0
07/14/2020 02:00	0.7	13.9	1,351.9	0.6	2.70	1	1	0
07/14/2020 03:00	0.7	13.9	1,292.8	0.6	2.60	1	1	0
07/14/2020 04:00	0.7	13.9	1,286.6	0.6	2.60	1	1	0
07/14/2020 05:00	0.9	13.8	1,625.6	0.7	4.90	1	1	0
07/14/2020 06:00	1.0	13.8	1,657.9	0.8	5.00	1	1	0
07/14/2020 07:00	1.1	13.8	1,671.9	0.9	5.00	1	1	0
07/14/2020 08:00	0.9	13.8	1,546.9	0.7	4.60	1	1	0
07/14/2020 09:00	0.7	13.9	1,297.9	0.6	2.60	1	1	0
07/14/2020 10:00	0.7	13.9	1,313.5	0.6	2.60	1	1	0
07/14/2020 11:00	0.8	13.9	1,359.7	0.7	2.70	1	1	0
07/14/2020 12:00	0.9	13.8	1,530.8	0.7	4.60	1	1	0
07/14/2020 13:00	0.7	13.9	1,340.1	0.6	2.70	1	1	0
07/14/2020 14:00	1.5	12.4	1,959.1	1.0	7.80	1	1	1
07/14/2020 15:00	1.6	12.0	2,041.4	1.1	8.20	1	1	1
07/14/2020 16:00	1.6	12.0	2,060.0	1.1	8.20	1	1	1
07/14/2020 17:00	1.6	11.9	2,062.9	1.0	8.30	1	1	1
07/14/2020 18:00	1.7	11.9	2,078.4	1.1	8.30	1	1	1
07/14/2020 19:00	1.7	11.9	2,075.3	1.1	8.30	1	1	1
07/14/2020 20:00	1.6	12.0	2,068.2	1.1	8.30	1	1	1
07/14/2020 21:00	1.6	12.0	2,072.3	1.1	8.30	1	1	1
07/14/2020 22:00	1.5	12.6	1,952.5	1.1	7.80	1	1	1
07/14/2020 23:00	1.4	13.0	1,777.5	1.0	7.10	1	1	1
Average/Sum#:	1.2	13.1	1,687.3	0.9	132.90 #	24 #	24 #	11 #
Minimum:	0.7	11.9	1,286.6	0.6	2.60	1	1	0
Maximum:	1.7	13.9	2,078.4	1.1	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/15/2020 00:00	0.8	13.8	1,290.4	0.7	2.60	1	1	0
07/15/2020 01:00	0.7	13.9	1,289.2	0.6	2.60	1	1	0
07/15/2020 02:00	0.7	13.9	1,287.8	0.6	2.60	1	1	0
07/15/2020 03:00	0.7	13.9	1,289.4	0.6	2.60	1	1	0
07/15/2020 04:00	0.7	13.9	1,289.8	0.6	2.60	1	1	0
07/15/2020 05:00	0.7	13.9	1,315.0	0.6	2.60	1	1	0
07/15/2020 06:00	0.7	13.9	1,301.2	0.6	2.60	1	1	0
07/15/2020 07:00	0.7	13.9	1,288.0	0.6	2.60	1	1	0
07/15/2020 08:00	0.7	13.9	1,289.7	0.6	2.60	1	1	0
07/15/2020 09:00	0.7	13.9	1,293.4	0.6	2.60	1	1	0
07/15/2020 10:00	0.7	13.9	1,294.1	0.6	2.60	1	1	0
07/15/2020 11:00	0.7	13.9	1,297.3	0.6	2.60	1	1	0
07/15/2020 12:00	0.7	13.9	1,295.2	0.6	2.60	1	1	0
07/15/2020 13:00	0.8	13.9	1,298.7	0.7	2.60	1	1	0
07/15/2020 14:00	0.7	13.9	1,307.2	0.6	2.60	1	1	0
07/15/2020 15:00	0.7	13.9	1,302.6	0.6	2.60	1	1	0
07/15/2020 16:00	0.8	13.9	1,308.4	0.7	2.60	1	1	0
07/15/2020 17:00	0.8	13.9	1,308.3	0.7	2.60	1	1	0
07/15/2020 18:00	0.9	13.9	1,391.6	0.8	4.20	1	1	0
07/15/2020 19:00	0.9	13.9	1,459.0	0.8	4.40	1	1	0
07/15/2020 20:00	0.8	13.9	1,355.3	0.7	2.70	1	1	0
07/15/2020 21:00	0.7	13.9	1,287.3	0.6	2.60	1	1	0
07/15/2020 22:00	0.7	13.9	1,284.0	0.6	2.60	1	1	0
07/15/2020 23:00	0.7	13.9	1,315.6	0.6	2.60	1	1	0
Average/Sum#:	0.7	13.9	1,309.9	0.6	65.90 #	24 #	24 #	0 #
Minimum:	0.7	13.8	1,284.0	0.6	2.60	1	1	0
Maximum:	0.9	13.9	1,459.0	0.8	4.40	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/16/2020 00:00	0.7	13.9	1,284.2	0.6	2.60	1	1	0
07/16/2020 01:00	0.7	13.9	1,285.8	0.6	2.60	1	1	0
07/16/2020 02:00	0.7	13.9	1,284.0	0.6	2.60	1	1	0
07/16/2020 03:00	0.7	13.9	1,282.1	0.6	2.60	1	1	0
07/16/2020 04:00	0.7	13.9	1,282.7	0.6	2.60	1	1	0
07/16/2020 05:00	0.7	13.9	1,283.3	0.6	2.60	1	1	0
07/16/2020 06:00	0.7	13.9	1,285.5	0.6	2.60	1	1	0
07/16/2020 07:00	0.7	13.9	1,286.5	0.6	2.60	1	1	0
07/16/2020 08:00	0.7	13.9	1,289.6	0.6	2.60	1	1	0
07/16/2020 09:00	0.7	13.9	1,292.8	0.6	2.60	1	1	0
07/16/2020 10:00	0.7	13.9	1,297.8	0.6	2.60	1	1	0
07/16/2020 11:00	0.7	13.9	1,295.1	0.6	2.60	1	1	0
07/16/2020 12:00	0.7	13.9	1,294.3	0.6	2.60	1	1	0
07/16/2020 13:00	0.7	13.9	1,296.7	0.6	2.60	1	1	0
07/16/2020 14:00	0.9	13.9	1,462.0	0.8	4.40	1	1	0
07/16/2020 15:00	1.0	13.8	1,503.0	0.8	4.50	1	1	1
07/16/2020 16:00	1.5	12.1	2,030.0	1.0	8.10	1	1	1
07/16/2020 17:00	1.6	11.9	2,061.3	1.0	8.20	1	1	1
07/16/2020 18:00	1.6	12.0	2,051.2	1.1	8.20	1	1	1
07/16/2020 19:00	1.6	11.9	2,075.9	1.0	8.30	1	1	1
07/16/2020 20:00	1.6	11.9	2,075.5	1.0	8.30	1	1	1
07/16/2020 21:00	1.6	12.1	2,069.2	1.1	8.30	1	1	1
07/16/2020 22:00	1.5	12.7	1,952.5	1.1	7.80	1	1	1
07/16/2020 23:00	1.4	13.1	1,778.6	1.1	7.10	1	1	1
Average/Sum#:	1.0	13.3	1,545.8	0.8	109.60 #	24 #	24 #	9 #
Minimum:	0.7	11.9	1,282.1	0.6	2.60	1	1	0
Maximum:	1.6	13.9	2,075.9	1.1	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/17/2020 00:00	0.7	13.8	1,294.0	0.6	2.60	1	1	0
07/17/2020 01:00	0.7	13.9	1,295.3	0.6	2.60	1	1	0
07/17/2020 02:00	0.7	13.9	1,290.3	0.6	2.60	1	1	0
07/17/2020 03:00	0.7	13.9	1,297.8	0.6	2.60	1	1	0
07/17/2020 04:00	0.7	13.9	1,292.6	0.6	2.60	1	1	0
07/17/2020 05:00	0.7	13.9	1,300.2	0.6	2.60	1	1	0
07/17/2020 06:00	0.7	13.9	1,300.7	0.6	2.60	1	1	0
07/17/2020 07:00	0.7	13.9	1,295.6	0.6	2.60	1	1	0
07/17/2020 08:00	0.7	13.9	1,298.0	0.6	2.60	1	1	0
07/17/2020 09:00	0.7	13.9	1,311.9	0.6	2.60	1	1	0
07/17/2020 10:00	0.7	13.9	1,305.6	0.6	2.60	1	1	0
07/17/2020 11:00	0.7	13.9	1,308.6	0.6	2.60	1	1	0
07/17/2020 12:00	0.7	13.9	1,317.7	0.6	2.60	1	1	0
07/17/2020 13:00	0.8	13.9	1,327.4	0.7	2.70	1	1	0
07/17/2020 14:00	0.7	13.9	1,300.2	0.6	2.60	1	1	0
07/17/2020 15:00	0.7	13.9	1,303.1	0.6	2.60	1	1	0
07/17/2020 16:00	1.0	13.8	1,502.9	0.8	4.50	1	1	1
07/17/2020 17:00	1.5	12.1	2,019.1	1.0	8.10	1	1	1
07/17/2020 18:00	1.6	11.9	2,064.0	1.0	8.30	1	1	1
07/17/2020 19:00	1.6	12.0	2,071.5	1.1	8.30	1	1	1
07/17/2020 20:00	1.6	12.0	2,077.0	1.1	8.30	1	1	1
07/17/2020 21:00	1.6	12.1	2,067.4	1.1	8.30	1	1	1
07/17/2020 22:00	1.5	12.6	1,961.4	1.1	7.80	1	1	1
07/17/2020 23:00	1.4	13.0	1,848.1	1.0	7.40	1	1	1
Average/Sum#:	1.0	13.4	1,518.8	0.7	102.70 #	24 #	24 #	8 #
Minimum:	0.7	11.9	1,290.3	0.6	2.60	1	1	0
Maximum:	1.6	13.9	2,077.0	1.1	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/18/2020 00:00	1.2	13.7	1,746.9	1.0	7.00	1	1	0
07/18/2020 01:00	1.0	13.8	1,590.9	0.8	4.80	1	1	0
07/18/2020 02:00	0.7	13.9	1,306.2	0.6	2.60	1	1	0
07/18/2020 03:00	0.7	13.9	1,307.2	0.6	2.60	1	1	0
07/18/2020 04:00	0.7	13.9	1,318.6	0.6	2.60	1	1	0
07/18/2020 05:00	0.7	13.9	1,351.5	0.6	2.70	1	1	0
07/18/2020 06:00	0.7	13.9	1,291.8	0.6	2.60	1	1	0
07/18/2020 07:00	0.7	13.9	1,292.0	0.6	2.60	1	1	0
07/18/2020 08:00	0.7	13.9	1,292.2	0.6	2.60	1	1	0
07/18/2020 09:00	0.7	13.9	1,298.2	0.6	2.60	1	1	0
07/18/2020 10:00	0.7	13.9	1,299.4	0.6	2.60	1	1	0
07/18/2020 11:00	0.8	13.9	1,389.3	0.7	2.80	1	1	0
07/18/2020 12:00	0.8	13.9	1,404.9	0.7	2.80	1	1	0
07/18/2020 13:00	1.1	13.8	1,584.1	0.9	4.80	1	1	1
07/18/2020 14:00	1.5	12.5	1,978.2	1.1	7.90	1	1	1
07/18/2020 15:00	1.1	13.5	1,508.7	0.9	4.50	1	1	1
07/18/2020 16:00	1.1	13.8	1,593.0	0.9	4.80	1	1	1
07/18/2020 17:00	1.6	12.2	2,011.9	1.1	8.00	1	1	1
07/18/2020 18:00	1.7	11.8	2,089.1	1.1	8.40	1	1	1
07/18/2020 19:00	1.7	11.8	2,109.3	1.1	8.40	1	1	1
07/18/2020 20:00	1.6	11.9	2,081.8	1.0	8.30	1	1	1
07/18/2020 21:00	1.6	12.4	1,980.3	1.1	7.90	1	1	1
07/18/2020 22:00	1.5	12.5	1,966.0	1.1	7.90	1	1	1
07/18/2020 23:00	1.5	12.8	1,846.1	1.1	7.40	1	1	1
Average/Sum#:	1.1	13.3	1,609.9	0.8	119.20 #	24 #	24 #	11 #
Minimum:	0.7	11.8	1,291.8	0.6	2.60	1	1	0
Maximum:	1.7	13.9	2,109.3	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOX, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/19/2020 00:00	1.3	13.6	1,734.9	1.1	6.90	1	1	0
07/19/2020 01:00	0.8	13.8	1,311.7	0.7	2.60	1	1	0
07/19/2020 02:00	0.8	13.9	1,287.7	0.7	2.60	1	1	0
07/19/2020 03:00	0.7	13.9	1,292.9	0.6	2.60	1	1	0
07/19/2020 04:00	0.8	13.9	1,287.0	0.7	2.60	1	1	0
07/19/2020 05:00	0.7	13.9	1,288.6	0.6	2.60	1	1	0
07/19/2020 06:00	0.7	13.9	1,287.1	0.6	2.60	1	1	0
07/19/2020 07:00	0.7	13.9	1,290.5	0.6	2.60	1	1	0
07/19/2020 08:00	0.7	13.9	1,299.2	0.6	2.60	1	1	0
07/19/2020 09:00	0.7	13.9	1,293.6	0.6	2.60	1	1	0
07/19/2020 10:00	0.8	13.9	1,300.8	0.7	2.60	1	1	0
07/19/2020 11:00	0.7	13.9	1,300.0	0.6	2.60	1	1	0
07/19/2020 12:00	0.7	13.9	1,300.4	0.6	2.60	1	1	0
07/19/2020 13:00	0.7	13.9	1,302.9	0.6	2.60	1	1	0
07/19/2020 14:00	0.7	13.9	1,308.9	0.6	2.60	1	1	0
07/19/2020 15:00	0.7	13.9	1,307.1	0.6	2.60	1	1	0
07/19/2020 16:00	0.9	13.8	1,496.4	0.7	4.50	1	1	0
07/19/2020 17:00	1.5	12.1	2,012.9	1.0	8.10	1	1	1
07/19/2020 18:00	1.7	11.8	2,080.7	1.1	8.30	1	1	1
07/19/2020 19:00	1.7	11.9	2,077.1	1.1	8.30	1	1	1
07/19/2020 20:00	1.6	12.0	2,068.7	1.1	8.30	1	1	1
07/19/2020 21:00	1.6	12.1	2,054.1	1.1	8.20	1	1	1
07/19/2020 22:00	1.5	12.6	1,951.2	1.1	7.80	1	1	1
07/19/2020 23:00	1.3	13.1	1,772.0	1.0	7.10	1	1	1
Average/Sum#:	1.0	13.4	1,529.4	0.8	106.50 #	24 #	24 #	7 #
Minimum:	0.7	11.8	1,287.0	0.6	2.60	1	1	0
Maximum:	1.7	13.9	2,080.7	1.1	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/20/2020 00:00	0.7	13.9	1,290.5	0.6	2.60	1	1	0
07/20/2020 01:00	0.7	13.9	1,282.2	0.6	2.60	1	1	0
07/20/2020 02:00	0.7	13.9	1,280.9	0.6	2.60	1	1	0
07/20/2020 03:00	0.7	13.9	1,280.1	0.6	2.60	1	1	0
07/20/2020 04:00	0.7	13.9	1,278.7	0.6	2.60	1	1	0
07/20/2020 05:00	0.7	13.9	1,294.2	0.6	2.60	1	1	0
07/20/2020 06:00	0.9	13.8	1,655.8	0.7	5.00	1	1	0
07/20/2020 07:00	0.9	13.8	1,628.1	0.7	4.90	1	1	0
07/20/2020 08:00	1.0	13.8	1,671.1	0.8	5.00	1	1	0
07/20/2020 09:00	0.8	13.9	1,381.4	0.7	2.80	1	1	0
07/20/2020 10:00	0.9	13.9	1,529.3	0.8	4.60	1	1	0
07/20/2020 11:00	0.9	13.8	1,539.5	0.7	4.60	1	1	0
07/20/2020 12:00	1.0	13.8	1,517.4	0.8	4.60	1	1	1
07/20/2020 13:00	1.5	12.3	1,998.7	1.0	8.00	1	1	1
07/20/2020 14:00	1.6	12.4	1,977.0	1.1	7.90	1	1	1
07/20/2020 15:00	1.6	12.0	2,036.8	1.1	8.10	1	1	1
07/20/2020 16:00	1.6	12.0	2,041.7	1.1	8.20	1	1	1
07/20/2020 17:00	1.6	12.0	2,044.4	1.1	8.20	1	1	1
07/20/2020 18:00	1.6	11.9	2,070.5	1.0	8.30	1	1	1
07/20/2020 19:00	1.6	11.9	2,072.5	1.0	8.30	1	1	1
07/20/2020 20:00	1.6	12.0	2,066.0	1.1	8.30	1	1	1
07/20/2020 21:00	1.6	12.1	2,049.1	1.1	8.20	1	1	1
07/20/2020 22:00	1.5	12.5	1,977.5	1.1	7.90	1	1	1
07/20/2020 23:00	1.4	13.0	1,759.6	1.0	7.00	1	1	1
Average/Sum#:	1.2	13.1	1,696.8	0.9	135.50 #	24 #	24 #	12 #
Minimum:	0.7	11.9	1,278.7	0.6	2.60	1	1	0
Maximum:	1.6	13.9	2,072.5	1.1	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOX, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOX, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/21/2020 00:00	0.7	13.9	1,283.2	0.6	2.60	1	1	0
07/21/2020 01:00	0.7	13.9	1,282.2	0.6	2.60	1	1	0
07/21/2020 02:00	0.7	13.9	1,281.7	0.6	2.60	1	1	0
07/21/2020 03:00	0.7	13.9	1,280.8	0.6	2.60	1	1	0
07/21/2020 04:00	0.7	13.9	1,280.5	0.6	2.60	1	1	0
07/21/2020 05:00	0.7	13.9	1,292.2	0.6	2.60	1	1	0
07/21/2020 06:00	1.0	13.8	1,647.1	0.8	4.90	1	1	0
07/21/2020 07:00	0.9	13.8	1,522.9	0.7	4.60	1	1	0
07/21/2020 08:00	0.8	13.9	1,520.4	0.7	3.00	1	1	0
07/21/2020 09:00	0.8	13.9	1,368.6	0.7	2.70	1	1	0
07/21/2020 10:00	0.9	13.8	1,505.2	0.7	4.50	1	1	0
07/21/2020 11:00	0.8	13.9	1,367.2	0.7	2.70	1	1	0
07/21/2020 12:00	0.8	13.9	1,381.4	0.7	2.80	1	1	0
07/21/2020 13:00	1.3	12.9	1,790.1	1.0	7.20	1	1	1
07/21/2020 14:00	1.6	12.0	2,044.0	1.1	8.20	1	1	1
07/21/2020 15:00	1.6	11.9	2,051.2	1.0	8.20	1	1	1
07/21/2020 16:00	1.6	11.8	2,068.3	1.0	8.30	1	1	1
07/21/2020 17:00	1.6	11.8	2,089.8	1.0	8.40	1	1	1
07/21/2020 18:00	1.7	11.8	2,086.9	1.1	8.30	1	1	1
07/21/2020 19:00	1.6	11.9	2,074.8	1.0	8.30	1	1	1
07/21/2020 20:00	1.6	12.0	2,076.0	1.1	8.30	1	1	1
07/21/2020 21:00	1.6	12.1	2,060.2	1.1	8.20	1	1	1
07/21/2020 22:00	1.5	12.6	1,968.2	1.1	7.90	1	1	1
07/21/2020 23:00	1.4	13.0	1,829.4	1.0	7.30	1	1	1
Average/Sum#:	1.1	13.1	1,673.0	0.8	129.40 #	24 #	24 #	11 #
Minimum:	0.7	11.8	1,280.5	0.6	2.60	1	1	0
Maximum:	1.7	13.9	2,089.8	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOX, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/22/2020 00:00	0.9	13.8	1,393.5	0.7	4.20	1	1	0
07/22/2020 01:00	0.7	13.9	1,280.2	0.6	2.60	1	1	0
07/22/2020 02:00	0.7	13.9	1,280.8	0.6	2.60	1	1	0
07/22/2020 03:00	0.7	13.9	1,277.9	0.6	2.60	1	1	0
07/22/2020 04:00	0.7	13.9	1,292.5	0.6	2.60	1	1	0
07/22/2020 05:00	0.7	13.8	1,372.8	0.6	2.70	1	1	0
07/22/2020 06:00	1.0	13.8	1,655.6	0.8	5.00	1	1	0
07/22/2020 07:00	0.7	13.9	1,357.5	0.6	2.70	1	1	0
07/22/2020 08:00	0.7	13.9	1,294.0	0.6	2.60	1	1	0
07/22/2020 09:00	0.7	13.9	1,296.2	0.6	2.60	1	1	0
07/22/2020 10:00	0.7	13.9	1,298.0	0.6	2.60	1	1	0
07/22/2020 11:00	0.7	13.9	1,298.3	0.6	2.60	1	1	0
07/22/2020 12:00	0.7	13.9	1,292.9	0.6	2.60	1	1	0
07/22/2020 13:00	0.7	13.9	1,291.8	0.6	2.60	1	1	0
07/22/2020 14:00	0.7	13.9	1,292.6	0.6	2.60	1	1	0
07/22/2020 15:00	0.7	13.9	1,301.0	0.6	2.60	1	1	0
07/22/2020 16:00	1.1	13.8	1,630.9	0.9	4.90	1	1	1
07/22/2020 17:00	1.5	12.3	1,997.3	1.0	8.00	1	1	1
07/22/2020 18:00	1.6	12.1	2,043.0	1.1	8.20	1	1	1
07/22/2020 19:00	1.6	12.2	2,040.0	1.1	8.20	1	1	1
07/22/2020 20:00	1.6	12.3	2,039.7	1.1	8.20	1	1	1
07/22/2020 21:00	1.6	12.3	2,037.5	1.1	8.20	1	1	1
07/22/2020 22:00	1.5	12.7	1,948.7	1.1	7.80	1	1	1
07/22/2020 23:00	1.3	13.1	1,770.4	1.0	7.10	1	1	1
Average/Sum#:	1.0	13.5	1,532.6	0.8	106.40 #	24 #	24 #	8 #
Minimum:	0.7	12.1	1,277.9	0.6	2.60	1	1	0
Maximum:	1.6	13.9	2,043.0	1.1	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/23/2020 00:00	0.7	13.9	1,284.3	0.6	2.60	1	1	0
07/23/2020 01:00	0.7	13.9	1,278.5	0.6	2.60	1	1	0
07/23/2020 02:00	0.7	13.9	1,277.1	0.6	2.60	1	1	0
07/23/2020 03:00	0.7	13.9	1,277.6	0.6	2.60	1	1	0
07/23/2020 04:00	0.7	13.9	1,279.5	0.6	2.60	1	1	0
07/23/2020 05:00	0.7	13.9	1,283.9	0.6	2.60	1	1	0
07/23/2020 06:00	0.7	13.9	1,288.3	0.6	2.60	1	1	0
07/23/2020 07:00	0.7	13.9	1,291.3	0.6	2.60	1	1	0
07/23/2020 08:00	0.7	13.9	1,295.3	0.6	2.60	1	1	0
07/23/2020 09:00	0.7	13.9	1,295.3	0.6	2.60	1	1	0
07/23/2020 10:00	0.7	13.9	1,300.3	0.6	2.60	1	1	0
07/23/2020 11:00	0.7	13.9	1,295.2	0.6	2.60	1	1	0
07/23/2020 12:00	0.7	13.9	1,296.2	0.6	2.60	1	1	0
07/23/2020 13:00	0.7	13.9	1,287.5	0.6	2.60	1	1	0
07/23/2020 14:00	0.7	13.9	1,291.4	0.6	2.60	1	1	0
07/23/2020 15:00	0.7	13.9	1,294.7	0.6	2.60	1	1	0
07/23/2020 16:00	0.7	13.9	1,293.3	0.6	2.60	1	1	0
07/23/2020 17:00	0.8	13.9	1,405.7	0.7	2.80	1	1	0
07/23/2020 18:00	1.0	13.8	1,626.5	0.8	4.90	1	1	0
07/23/2020 19:00	1.0	13.8	1,608.9	0.8	4.80	1	1	0
07/23/2020 20:00	0.9	13.8	1,427.6	0.7	4.30	1	1	0
07/23/2020 21:00	0.8	13.9	1,333.8	0.7	2.70	1	1	0
07/23/2020 22:00	0.7	13.9	1,286.5	0.6	2.60	1	1	0
07/23/2020 23:00	0.8	13.9	1,324.1	0.7	2.60	1	1	0
Average/Sum#:	0.7	13.9	1,330.1	0.6	68.90 #	24 #	24 #	0 #
Minimum:	0.7	13.8	1,277.1	0.6	2.60	1	1	0
Maximum:	1.0	13.9	1,626.5	0.8	4.90	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/24/2020 00:00	0.7	13.9	1,280.6	0.6	2.60	1	1	0
07/24/2020 01:00	0.7	13.9	1,282.8	0.6	2.60	1	1	0
07/24/2020 02:00	0.7	13.9	1,278.9	0.6	2.60	1	1	0
07/24/2020 03:00	0.7	13.9	1,278.1	0.6	2.60	1	1	0
07/24/2020 04:00	0.7	13.9	1,281.6	0.6	2.60	1	1	0
07/24/2020 05:00	0.7	13.9	1,288.0	0.6	2.60	1	1	0
07/24/2020 06:00	0.7	13.9	1,320.4	0.6	2.60	1	1	0
07/24/2020 07:00	0.7	13.9	1,268.1	0.6	0.75	1	1	0
07/24/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/24/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/24/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/24/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/24/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/24/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/24/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/24/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/24/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/24/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/24/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/24/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/24/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/24/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/24/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/24/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.7	13.9	1,284.8	0.6	18.95 #	8 #	8 #	0 #
Minimum:	0.7	13.9	1,268.1	0.6	0.75	0	0	0
Maximum:	0.7	13.9	1,320.4	0.6	2.60	1	1	0
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/25/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/25/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/25/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/25/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/25/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/25/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/25/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/25/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/25/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/25/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/25/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/25/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/25/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/25/2020 13:00	28.1	17.7	427.2	51.8	40.80	1	0	0
07/25/2020 14:00	16.8	15.7	797.3	19.1	55.80	1	0	0
07/25/2020 15:00	0.8	13.8	1,548.8	0.7	3.10	1	1	0
07/25/2020 16:00	1.0	13.8	1,536.9	0.8	4.60	1	1	1
07/25/2020 17:00	1.5	12.3	2,011.5	1.0	8.00	1	1	1
07/25/2020 18:00	1.6	11.9	2,073.0	1.0	8.30	1	1	1
07/25/2020 19:00	1.6	11.9	2,077.3	1.0	8.30	1	1	1
07/25/2020 20:00	1.6	12.0	2,077.8	1.1	8.30	1	1	1
07/25/2020 21:00	1.6	12.1	2,061.6	1.1	8.20	1	1	1
07/25/2020 22:00	1.6	12.4	2,009.6	1.1	8.00	1	1	1
07/25/2020 23:00	1.6	12.3	2,013.6	1.1	8.10	1	1	1
Average/Sum#:	5.3	13.3	1,694.1	7.3	161.50 #	11 #	9 #	8 #
Minimum:	0.8	11.9	427.2	0.7	3.10	0	0	0
Maximum:	28.1	17.7	2,077.8	51.8	55.80	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOX, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/26/2020 00:00	0.8	13.9	1,442.7	0.7	2.90	1	1	0
07/26/2020 01:00	0.9	13.9	1,598.1	0.8	4.80	1	1	0
07/26/2020 02:00	0.8	13.9	1,538.2	0.7	3.10	1	1	0
07/26/2020 03:00	0.8	13.9	1,497.6	0.7	3.00	1	1	0
07/26/2020 04:00	0.8	13.9	1,529.1	0.7	3.10	1	1	0
07/26/2020 05:00	0.8	13.9	1,408.7	0.7	2.80	1	1	0
07/26/2020 06:00	0.7	13.9	1,282.0	0.6	2.60	1	1	0
07/26/2020 07:00	0.7	13.9	1,283.8	0.6	2.60	1	1	0
07/26/2020 08:00	0.7	13.9	1,285.7	0.6	2.60	1	1	0
07/26/2020 09:00	0.7	13.9	1,289.3	0.6	2.60	1	1	0
07/26/2020 10:00	0.8	13.9	1,377.9	0.7	2.80	1	1	0
07/26/2020 11:00	0.9	13.9	1,533.2	0.8	4.60	1	1	0
07/26/2020 12:00	0.9	13.9	1,543.7	0.8	4.60	1	1	0
07/26/2020 13:00	1.2	13.7	1,686.1	1.0	6.70	1	1	1
07/26/2020 14:00	1.5	12.3	2,005.1	1.0	8.00	1	1	1
07/26/2020 15:00	1.2	13.4	1,623.8	0.9	4.90	1	1	1
07/26/2020 16:00	1.3	13.0	1,776.3	1.0	7.10	1	1	1
07/26/2020 17:00	1.7	11.7	2,098.0	1.1	8.40	1	1	1
07/26/2020 18:00	1.7	11.7	2,101.2	1.1	8.40	1	1	1
07/26/2020 19:00	1.7	11.7	2,102.1	1.1	8.40	1	1	1
07/26/2020 20:00	1.7	11.9	2,077.3	1.1	8.30	1	1	1
07/26/2020 21:00	1.6	12.0	2,069.2	1.1	8.30	1	1	1
07/26/2020 22:00	1.5	12.5	1,960.9	1.1	7.80	1	1	1
07/26/2020 23:00	1.4	12.9	1,774.5	1.0	7.10	1	1	1
Average/Sum#:	1.1	13.2	1,661.9	0.9	125.50 #	24 #	24 #	11 #
Minimum:	0.7	11.7	1,282.0	0.6	2.60	1	1	0
Maximum:	1.7	13.9	2,102.1	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/27/2020 00:00	0.7	13.9	1,287.3	0.6	2.60	1	1	0
07/27/2020 01:00	0.7	13.9	1,283.4	0.6	2.60	1	1	0
07/27/2020 02:00	0.7	13.9	1,283.0	0.6	2.60	1	1	0
07/27/2020 03:00	0.7	13.9	1,285.6	0.6	2.60	1	1	0
07/27/2020 04:00	0.7	13.9	1,293.1	0.6	2.60	1	1	0
07/27/2020 05:00	1.0	13.8	1,640.1	0.8	4.90	1	1	0
07/27/2020 06:00	1.1	13.9	1,672.1	0.9	5.00	1	1	0
07/27/2020 07:00	1.0	13.8	1,676.8	0.8	5.00	1	1	0
07/27/2020 08:00	1.0	13.9	1,640.1	0.8	4.90	1	1	0
07/27/2020 09:00	0.7	13.9	1,343.5	0.6	2.70	1	1	0
07/27/2020 10:00	1.0	13.9	1,569.2	0.8	4.70	1	1	0
07/27/2020 11:00	1.0	13.8	1,535.7	0.8	4.60	1	1	1
07/27/2020 12:00	1.5	12.2	2,027.6	1.0	8.10	1	1	1
07/27/2020 13:00	1.7	11.8	2,085.5	1.1	8.30	1	1	1
07/27/2020 14:00	1.6	11.9	2,060.3	1.0	8.20	1	1	1
07/27/2020 15:00	1.7	11.7	2,086.6	1.1	8.30	1	1	1
07/27/2020 16:00	1.7	11.6	2,091.1	1.1	8.40	1	1	1
07/27/2020 17:00	1.7	11.6	2,093.1	1.1	8.40	1	1	1
07/27/2020 18:00	1.7	11.7	2,078.0	1.1	8.30	1	1	1
07/27/2020 19:00	1.6	11.8	2,071.9	1.0	8.30	1	1	1
07/27/2020 20:00	1.6	11.7	2,105.5	1.0	8.40	1	1	1
07/27/2020 21:00	1.6	11.9	2,079.3	1.0	8.30	1	1	1
07/27/2020 22:00	1.6	11.9	2,080.1	1.0	8.30	1	1	1
07/27/2020 23:00	1.5	12.5	1,937.3	1.1	7.70	1	1	1
Average/Sum#:	1.2	12.9	1,762.8	0.9	143.80 #	24 #	24 #	13 #
Minimum:	0.7	11.6	1,283.0	0.6	2.60	1	1	0
Maximum:	1.7	13.9	2,105.5	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/28/2020 00:00	0.9	13.8	1,538.6	0.7	4.60	1	1	0
07/28/2020 01:00	0.8	13.8	1,499.8	0.7	3.00	1	1	0
07/28/2020 02:00	0.7	13.9	1,422.9	0.6	2.80	1	1	0
07/28/2020 03:00	0.8	13.9	1,497.9	0.7	3.00	1	1	0
07/28/2020 04:00	0.8	13.8	1,536.7	0.7	3.10	1	1	0
07/28/2020 05:00	0.9	13.8	1,594.4	0.7	4.80	1	1	0
07/28/2020 06:00	1.0	13.8	1,688.1	0.8	5.10	1	1	0
07/28/2020 07:00	1.0	13.8	1,668.9	0.8	5.00	1	1	0
07/28/2020 08:00	0.8	13.9	1,518.4	0.7	3.00	1	1	0
07/28/2020 09:00	0.7	13.9	1,313.4	0.6	2.60	1	1	0
07/28/2020 10:00	0.9	13.9	1,518.3	0.8	4.60	1	1	0
07/28/2020 11:00	0.9	13.8	1,493.3	0.7	4.50	1	1	1
07/28/2020 12:00	1.6	12.2	2,029.0	1.1	8.10	1	1	1
07/28/2020 13:00	1.6	12.0	2,071.3	1.1	8.30	1	1	1
07/28/2020 14:00	1.6	11.9	2,077.8	1.0	8.30	1	1	1
07/28/2020 15:00	1.6	11.7	2,103.0	1.0	8.40	1	1	1
07/28/2020 16:00	1.7	11.7	2,105.9	1.1	8.40	1	1	1
07/28/2020 17:00	1.7	11.7	2,096.4	1.1	8.40	1	1	1
07/28/2020 18:00	1.7	11.7	2,098.7	1.1	8.40	1	1	1
07/28/2020 19:00	1.6	11.9	2,071.0	1.0	8.30	1	1	1
07/28/2020 20:00	1.6	12.0	2,090.5	1.1	8.40	1	1	1
07/28/2020 21:00	1.6	12.0	2,096.2	1.1	8.40	1	1	1
07/28/2020 22:00	1.6	12.1	2,075.7	1.1	8.30	1	1	1
07/28/2020 23:00	1.6	12.1	2,058.1	1.1	8.20	1	1	1
Average/Sum#:	1.2	12.9	1,802.7	0.9	146.00 #	24 #	24 #	13 #
Minimum:	0.7	11.7	1,313.4	0.6	2.60	1	1	0
Maximum:	1.7	13.9	2,105.9	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/29/2020 00:00	1.5	12.7	1,953.1	1.1	7.80	1	1	1
07/29/2020 01:00	1.5	12.8	1,935.1	1.1	7.70	1	1	1
07/29/2020 02:00	1.5	12.8	1,936.4	1.1	7.70	1	1	1
07/29/2020 03:00	1.5	12.8	1,948.8	1.1	7.80	1	1	1
07/29/2020 04:00	1.5	12.3	2,052.0	1.0	8.20	1	1	1
07/29/2020 05:00	1.6	12.3	2,067.7	1.1	8.30	1	1	1
07/29/2020 06:00	1.6	12.3	2,052.8	1.1	8.20	1	1	1
07/29/2020 07:00	1.5	12.8	1,950.5	1.1	7.80	1	1	1
07/29/2020 08:00	1.5	12.7	1,943.7	1.1	7.80	1	1	1
07/29/2020 09:00	1.5	12.7	1,958.0	1.1	7.80	1	1	1
07/29/2020 10:00	1.6	12.2	2,064.2	1.1	8.30	1	1	1
07/29/2020 11:00	1.6	12.1	2,065.3	1.1	8.30	1	1	1
07/29/2020 12:00	1.6	12.0	2,076.1	1.1	8.30	1	1	1
07/29/2020 13:00	1.6	12.0	2,067.9	1.1	8.30	1	1	1
07/29/2020 14:00	1.7	11.8	2,097.9	1.1	8.40	1	1	1
07/29/2020 15:00	1.7	11.7	2,104.7	1.1	8.40	1	1	1
07/29/2020 16:00	1.6	11.8	2,109.2	1.0	8.40	1	1	1
07/29/2020 17:00	1.7	11.8	2,104.8	1.1	8.40	1	1	1
07/29/2020 18:00	1.7	11.8	2,101.5	1.1	8.40	1	1	1
07/29/2020 19:00	1.7	11.8	2,116.9	1.1	8.50	1	1	1
07/29/2020 20:00	1.6	11.9	2,110.0	1.0	8.40	1	1	1
07/29/2020 21:00	1.6	12.1	2,074.6	1.1	8.30	1	1	1
07/29/2020 22:00	1.6	12.0	2,094.1	1.1	8.40	1	1	1
07/29/2020 23:00	1.6	12.1	2,078.4	1.1	8.30	1	1	1
Average/Sum#:	1.6	12.2	2,044.3	1.1	196.20 #	24 #	24 #	24 #
Minimum:	1.5	11.7	1,935.1	1.0	7.70	1	1	1
Maximum:	1.7	12.8	2,116.9	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/30/2020 00:00	1.6	12.2	2,058.9	1.1	8.20	1	1	1
07/30/2020 01:00	1.5	12.7	1,949.2	1.1	7.80	1	1	1
07/30/2020 02:00	1.5	12.8	1,937.6	1.1	7.80	1	1	1
07/30/2020 03:00	1.5	12.9	1,935.5	1.1	7.70	1	1	1
07/30/2020 04:00	1.5	12.9	1,947.5	1.1	7.80	1	1	1
07/30/2020 05:00	1.6	12.3	2,064.6	1.1	8.30	1	1	1
07/30/2020 06:00	1.6	12.4	2,050.3	1.1	8.20	1	1	1
07/30/2020 07:00	1.5	12.8	1,947.2	1.1	7.80	1	1	1
07/30/2020 08:00	1.5	12.8	1,941.0	1.1	7.80	1	1	1
07/30/2020 09:00	1.5	12.7	1,951.7	1.1	7.80	1	1	1
07/30/2020 10:00	1.6	12.2	2,057.9	1.1	8.20	1	1	1
07/30/2020 11:00	1.6	12.1	2,079.2	1.1	8.30	1	1	1
07/30/2020 12:00	1.6	12.1	2,068.6	1.1	8.30	1	1	1
07/30/2020 13:00	1.6	12.0	2,071.7	1.1	8.30	1	1	1
07/30/2020 14:00	1.6	11.9	2,077.8	1.0	8.30	1	1	1
07/30/2020 15:00	1.7	11.8	2,098.6	1.1	8.40	1	1	1
07/30/2020 16:00	1.7	11.7	2,105.1	1.1	8.40	1	1	1
07/30/2020 17:00	1.7	11.7	2,106.1	1.1	8.40	1	1	1
07/30/2020 18:00	1.7	11.7	2,105.0	1.1	8.40	1	1	1
07/30/2020 19:00	1.6	12.1	2,029.4	1.1	8.10	1	1	1
07/30/2020 20:00	1.6	12.1	2,046.5	1.1	8.20	1	1	1
07/30/2020 21:00	1.6	12.2	2,037.9	1.1	8.20	1	1	1
07/30/2020 22:00	1.6	12.1	2,077.1	1.1	8.30	1	1	1
07/30/2020 23:00	1.6	12.3	2,027.2	1.1	8.10	1	1	1
Average/Sum#:	1.6	12.3	2,032.2	1.1	195.10 #	24 #	24 #	24 #
Minimum:	1.5	11.7	1,935.5	1.0	7.70	1	1	1
Maximum:	1.7	12.9	2,106.1	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/31/2020 00:00	1.5	12.7	1,955.0	1.1	7.80	1	1	1
07/31/2020 01:00	1.5	12.8	1,931.2	1.1	7.70	1	1	1
07/31/2020 02:00	1.5	12.9	1,931.0	1.1	7.70	1	1	1
07/31/2020 03:00	1.5	12.9	1,929.8	1.1	7.70	1	1	1
07/31/2020 04:00	1.5	12.9	1,933.6	1.1	7.70	1	1	1
07/31/2020 05:00	1.6	12.5	2,031.2	1.1	8.10	1	1	1
07/31/2020 06:00	1.5	12.4	2,037.4	1.0	8.10	1	1	1
07/31/2020 07:00	1.5	12.7	1,955.1	1.1	7.80	1	1	1
07/31/2020 08:00	1.5	12.8	1,931.4	1.1	7.70	1	1	1
07/31/2020 09:00	1.5	12.5	1,988.5	1.1	8.00	1	1	1
07/31/2020 10:00	1.6	12.2	2,049.5	1.1	8.20	1	1	1
07/31/2020 11:00	1.6	12.1	2,062.5	1.1	8.30	1	1	1
07/31/2020 12:00	1.6	12.0	2,063.9	1.1	8.30	1	1	1
07/31/2020 13:00	1.6	12.0	2,071.5	1.1	8.30	1	1	1
07/31/2020 14:00	1.6	11.9	2,077.1	1.0	8.30	1	1	1
07/31/2020 15:00	1.6	11.9	2,086.0	1.0	8.30	1	1	1
07/31/2020 16:00	1.6	11.8	2,086.3	1.0	8.30	1	1	1
07/31/2020 17:00	1.6	11.9	2,075.8	1.0	8.30	1	1	1
07/31/2020 18:00	1.7	11.7	2,102.4	1.1	8.40	1	1	1
07/31/2020 19:00	1.6	12.0	2,068.0	1.1	8.30	1	1	1
07/31/2020 20:00	1.6	12.0	2,074.9	1.1	8.30	1	1	1
07/31/2020 21:00	1.6	12.1	2,058.3	1.1	8.20	1	1	1
07/31/2020 22:00	1.6	12.2	2,051.8	1.1	8.20	1	1	1
07/31/2020 23:00	1.6	12.3	2,043.5	1.1	8.20	1	1	1
Average/Sum#:	1.6	12.3	2,024.8	1.1	194.20 #	24 #	24 #	24 #
Minimum:	1.5	11.7	1,929.8	1.0	7.70	1	1	1
Maximum:	1.7	12.9	2,102.4	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOX, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOX, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/01/2020 00:00	1.6	12.3	2,032.5	1.1	8.10	1	1	1
08/01/2020 01:00	1.5	12.8	1,938.5	1.1	7.80	1	1	1
08/01/2020 02:00	1.5	12.9	1,901.9	1.1	7.60	1	1	1
08/01/2020 03:00	0.8	13.9	1,431.2	0.7	2.90	1	1	0
08/01/2020 04:00	0.8	13.8	1,519.6	0.7	3.00	1	1	0
08/01/2020 05:00	0.8	13.8	1,535.3	0.7	3.10	1	1	0
08/01/2020 06:00	0.7	13.9	1,297.8	0.6	2.60	1	1	0
08/01/2020 07:00	0.7	13.9	1,286.6	0.6	2.60	1	1	0
08/01/2020 08:00	0.7	13.9	1,289.2	0.6	2.60	1	1	0
08/01/2020 09:00	0.7	13.9	1,295.2	0.6	2.60	1	1	0
08/01/2020 10:00	0.8	13.9	1,431.1	0.7	2.90	1	1	0
08/01/2020 11:00	0.9	13.8	1,505.5	0.7	4.50	1	1	1
08/01/2020 12:00	1.5	12.4	2,017.4	1.0	8.10	1	1	1
08/01/2020 13:00	1.6	12.1	2,063.3	1.1	8.30	1	1	1
08/01/2020 14:00	1.6	12.0	2,069.7	1.1	8.30	1	1	1
08/01/2020 15:00	1.6	12.0	2,078.0	1.1	8.30	1	1	1
08/01/2020 16:00	1.6	11.9	2,094.7	1.0	8.40	1	1	1
08/01/2020 17:00	1.6	11.9	2,102.2	1.0	8.40	1	1	1
08/01/2020 18:00	1.6	11.9	2,105.6	1.0	8.40	1	1	1
08/01/2020 19:00	1.6	11.9	2,108.5	1.0	8.40	1	1	1
08/01/2020 20:00	1.6	11.9	2,110.8	1.0	8.40	1	1	1
08/01/2020 21:00	1.6	12.1	2,068.9	1.1	8.30	1	1	1
08/01/2020 22:00	1.6	12.1	2,061.4	1.1	8.20	1	1	1
08/01/2020 23:00	1.5	12.7	1,921.6	1.1	7.70	1	1	1
Average/Sum#:	1.3	12.8	1,802.8	0.9	149.50 #	24 #	24 #	16 #
Minimum:	0.7	11.9	1,286.6	0.6	2.60	1	1	0
Maximum:	1.6	13.9	2,110.8	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/02/2020 00:00	0.9	13.8	1,423.9	0.7	4.30	1	1	0
08/02/2020 01:00	0.7	13.9	1,282.9	0.6	2.60	1	1	0
08/02/2020 02:00	0.7	13.9	1,285.9	0.6	2.60	1	1	0
08/02/2020 03:00	0.7	13.9	1,288.9	0.6	2.60	1	1	0
08/02/2020 04:00	0.8	13.9	1,492.7	0.7	3.00	1	1	0
08/02/2020 05:00	0.7	13.9	1,379.2	0.6	2.80	1	1	0
08/02/2020 06:00	0.7	13.9	1,293.1	0.6	2.60	1	1	0
08/02/2020 07:00	0.7	13.9	1,291.2	0.6	2.60	1	1	0
08/02/2020 08:00	0.7	13.9	1,292.8	0.6	2.60	1	1	0
08/02/2020 09:00	0.7	13.9	1,297.0	0.6	2.60	1	1	0
08/02/2020 10:00	0.7	13.9	1,301.8	0.6	2.60	1	1	0
08/02/2020 11:00	0.7	13.9	1,303.8	0.6	2.60	1	1	0
08/02/2020 12:00	0.7	13.9	1,300.9	0.6	2.60	1	1	0
08/02/2020 13:00	0.7	13.9	1,313.3	0.6	2.60	1	1	0
08/02/2020 14:00	0.8	13.9	1,364.7	0.7	2.70	1	1	0
08/02/2020 15:00	1.0	13.8	1,508.1	0.8	4.50	1	1	0
08/02/2020 16:00	1.5	12.5	1,927.7	1.1	7.70	1	1	1
08/02/2020 17:00	1.6	12.1	2,051.9	1.1	8.20	1	1	1
08/02/2020 18:00	1.6	12.1	2,052.8	1.1	8.20	1	1	1
08/02/2020 19:00	1.6	11.9	2,081.6	1.0	8.30	1	1	1
08/02/2020 20:00	1.6	12.0	2,058.6	1.1	8.20	1	1	1
08/02/2020 21:00	1.6	12.0	2,073.1	1.1	8.30	1	1	1
08/02/2020 22:00	1.6	12.1	2,056.7	1.1	8.20	1	1	1
08/02/2020 23:00	1.5	12.6	1,925.6	1.1	7.70	1	1	1
Average/Sum#:	1.0	13.3	1,568.7	0.8	110.70 #	24 #	24 #	8 #
Minimum:	0.7	11.9	1,282.9	0.6	2.60	1	1	0
Maximum:	1.6	13.9	2,081.6	1.1	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOX, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/03/2020 00:00	0.9	13.8	1,431.1	0.7	4.30	1	1	0
08/03/2020 01:00	0.7	13.9	1,318.3	0.6	2.60	1	1	0
08/03/2020 02:00	0.7	13.9	1,290.1	0.6	2.60	1	1	0
08/03/2020 03:00	0.7	13.9	1,290.4	0.6	2.60	1	1	0
08/03/2020 04:00	0.8	13.9	1,505.7	0.7	3.00	1	1	0
08/03/2020 05:00	0.8	13.9	1,484.8	0.7	3.00	1	1	0
08/03/2020 06:00	0.9	13.8	1,575.3	0.7	4.70	1	1	0
08/03/2020 07:00	0.9	13.9	1,535.1	0.8	4.60	1	1	0
08/03/2020 08:00	0.8	13.9	1,480.0	0.7	3.00	1	1	0
08/03/2020 09:00	0.8	13.9	1,373.1	0.7	2.70	1	1	0
08/03/2020 10:00	0.7	14.0	1,299.1	0.6	2.60	1	1	0
08/03/2020 11:00	0.8	14.0	1,361.6	0.7	4.10	1	1	0
08/03/2020 12:00	0.9	13.9	1,497.7	0.8	4.50	1	1	1
08/03/2020 13:00	1.5	12.3	2,021.3	1.0	8.10	1	1	1
08/03/2020 14:00	1.6	12.1	2,054.2	1.1	8.20	1	1	1
08/03/2020 15:00	1.6	12.1	2,052.0	1.1	8.20	1	1	1
08/03/2020 16:00	1.6	12.0	2,059.1	1.1	8.20	1	1	1
08/03/2020 17:00	1.6	12.0	2,062.2	1.1	8.20	1	1	1
08/03/2020 18:00	1.6	12.0	2,057.4	1.1	8.20	1	1	1
08/03/2020 19:00	1.6	12.0	2,076.1	1.1	8.30	1	1	1
08/03/2020 20:00	1.6	12.0	2,062.8	1.1	8.30	1	1	1
08/03/2020 21:00	1.6	12.0	2,066.2	1.1	8.30	1	1	1
08/03/2020 22:00	1.6	12.1	2,059.1	1.1	8.20	1	1	1
08/03/2020 23:00	1.4	12.9	1,782.2	1.0	7.10	1	1	1
Average/Sum#:	1.2	13.1	1,699.8	0.9	133.60 #	24 #	24 #	12 #
Minimum:	0.7	12.0	1,290.1	0.6	2.60	1	1	0
Maximum:	1.6	14.0	2,076.1	1.1	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/04/2020 00:00	0.7	13.9	1,285.7	0.6	2.60	1	1	0
08/04/2020 01:00	0.7	13.9	1,282.8	0.6	2.60	1	1	0
08/04/2020 02:00	0.7	13.9	1,291.9	0.6	2.60	1	1	0
08/04/2020 03:00	0.7	13.9	1,285.9	0.6	2.60	1	1	0
08/04/2020 04:00	0.7	13.9	1,288.3	0.6	2.60	1	1	0
08/04/2020 05:00	0.8	13.9	1,402.3	0.7	2.80	1	1	0
08/04/2020 06:00	0.7	13.9	1,299.5	0.6	2.60	1	1	0
08/04/2020 07:00	0.7	13.9	1,287.3	0.6	2.60	1	1	0
08/04/2020 08:00	0.7	13.9	1,288.7	0.6	2.60	1	1	0
08/04/2020 09:00	0.7	13.9	1,291.8	0.6	2.60	1	1	0
08/04/2020 10:00	0.7	13.9	1,298.3	0.6	2.60	1	1	0
08/04/2020 11:00	0.7	13.9	1,299.6	0.6	2.60	1	1	0
08/04/2020 12:00	0.8	13.9	1,435.8	0.7	2.90	1	1	0
08/04/2020 13:00	0.9	13.8	1,472.1	0.7	4.40	1	1	0
08/04/2020 14:00	0.7	13.9	1,319.7	0.6	2.60	1	1	0
08/04/2020 15:00	1.0	13.8	1,528.4	0.8	4.60	1	1	0
08/04/2020 16:00	0.9	13.8	1,503.4	0.7	4.50	1	1	1
08/04/2020 17:00	1.6	12.1	2,025.5	1.1	8.10	1	1	1
08/04/2020 18:00	1.7	11.9	2,070.5	1.1	8.30	1	1	1
08/04/2020 19:00	1.6	11.9	2,075.1	1.0	8.30	1	1	1
08/04/2020 20:00	1.6	12.0	2,062.1	1.1	8.20	1	1	1
08/04/2020 21:00	1.6	12.1	2,055.7	1.1	8.20	1	1	1
08/04/2020 22:00	1.5	12.6	1,952.7	1.1	7.80	1	1	1
08/04/2020 23:00	1.3	13.1	1,773.9	1.0	7.10	1	1	1
Average/Sum#:	1.0	13.4	1,536.5	0.8	106.40 #	24 #	24 #	8 #
Minimum:	0.7	11.9	1,282.8	0.6	2.60	1	1	0
Maximum:	1.7	13.9	2,075.1	1.1	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOX, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/05/2020 00:00	0.7	13.9	1,284.6	0.6	2.60	1	1	0
08/05/2020 01:00	0.7	13.9	1,283.4	0.6	2.60	1	1	0
08/05/2020 02:00	0.7	13.9	1,277.6	0.6	2.60	1	1	0
08/05/2020 03:00	0.7	13.9	1,277.3	0.6	2.60	1	1	0
08/05/2020 04:00	0.7	13.9	1,280.0	0.6	2.60	1	1	0
08/05/2020 05:00	0.7	13.9	1,313.3	0.6	2.60	1	1	0
08/05/2020 06:00	0.7	13.9	1,277.2	0.6	2.60	1	1	0
08/05/2020 07:00	0.7	13.9	1,277.6	0.6	2.60	1	1	0
08/05/2020 08:00	0.7	13.9	1,281.6	0.6	2.60	1	1	0
08/05/2020 09:00	0.7	13.9	1,285.0	0.6	2.60	1	1	0
08/05/2020 10:00	0.7	13.9	1,288.8	0.6	2.60	1	1	0
08/05/2020 11:00	0.7	13.9	1,291.1	0.6	2.60	1	1	0
08/05/2020 12:00	0.7	13.9	1,292.1	0.6	2.60	1	1	0
08/05/2020 13:00	0.7	13.9	1,292.8	0.6	2.60	1	1	0
08/05/2020 14:00	0.7	13.9	1,291.1	0.6	2.60	1	1	0
08/05/2020 15:00	0.7	13.9	1,290.2	0.6	2.60	1	1	0
08/05/2020 16:00	0.7	13.9	1,299.2	0.6	2.60	1	1	0
08/05/2020 17:00	1.3	13.2	1,748.8	1.0	7.00	1	1	1
08/05/2020 18:00	1.6	12.0	2,059.3	1.1	8.20	1	1	1
08/05/2020 19:00	1.6	12.3	1,993.6	1.1	8.00	1	1	1
08/05/2020 20:00	0.9	13.8	1,573.0	0.7	4.70	1	1	0
08/05/2020 21:00	0.7	13.9	1,399.3	0.6	2.80	1	1	0
08/05/2020 22:00	0.7	13.9	1,378.3	0.6	2.80	1	1	0
08/05/2020 23:00	0.6	13.9	1,278.4	0.5	2.60	1	1	0
Average/Sum#:	0.8	13.7	1,388.1	0.7	80.30 #	24 #	24 #	3 #
Minimum:	0.6	12.0	1,277.2	0.5	2.60	1	1	0
Maximum:	1.6	13.9	2,059.3	1.1	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/06/2020 00:00	0.6	13.9	1,277.6	0.5	2.60	1	1	0
08/06/2020 01:00	0.6	13.9	1,276.8	0.5	2.60	1	1	0
08/06/2020 02:00	0.6	13.9	1,277.4	0.5	2.60	1	1	0
08/06/2020 03:00	0.6	13.9	1,281.5	0.5	2.60	1	1	0
08/06/2020 04:00	0.6	13.9	1,298.5	0.5	2.60	1	1	0
08/06/2020 05:00	0.7	13.9	1,322.0	0.6	2.60	1	1	0
08/06/2020 06:00	0.7	13.9	1,286.7	0.6	2.60	1	1	0
08/06/2020 07:00	0.6	13.9	1,292.2	0.5	2.60	1	1	0
08/06/2020 08:00	0.6	13.9	1,293.7	0.5	2.60	1	1	0
08/06/2020 09:00	0.7	13.9	1,294.5	0.6	2.60	1	1	0
08/06/2020 10:00	0.7	13.9	1,294.2	0.6	2.60	1	1	0
08/06/2020 11:00	0.7	13.9	1,294.3	0.6	2.60	1	1	0
08/06/2020 12:00	0.7	13.9	1,294.7	0.6	2.60	1	1	0
08/06/2020 13:00	0.7	13.9	1,290.4	0.6	2.60	1	1	0
08/06/2020 14:00	0.7	13.9	1,290.4	0.6	2.60	1	1	0
08/06/2020 15:00	0.7	13.9	1,292.0	0.6	2.60	1	1	0
08/06/2020 16:00	0.7	13.9	1,289.2	0.6	2.60	1	1	0
08/06/2020 17:00	0.8	13.9	1,398.1	0.7	2.80	1	1	0
08/06/2020 18:00	0.8	13.9	1,398.6	0.7	2.80	1	1	0
08/06/2020 19:00	0.7	13.9	1,306.9	0.6	2.60	1	1	0
08/06/2020 20:00	0.7	13.9	1,282.9	0.6	2.60	1	1	0
08/06/2020 21:00	0.7	13.9	1,279.2	0.6	2.60	1	1	0
08/06/2020 22:00	0.7	13.9	1,278.1	0.6	2.60	1	1	0
08/06/2020 23:00	0.7	13.9	1,280.0	0.6	2.60	1	1	0
Average/Sum#:	0.7	13.9	1,298.7	0.6	62.80 #	24 #	24 #	0 #
Minimum:	0.6	13.9	1,276.8	0.5	2.60	1	1	0
Maximum:	0.8	13.9	1,398.6	0.7	2.80	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOX, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/07/2020 00:00	0.7	13.9	1,279.9	0.6	2.60	1	1	0
08/07/2020 01:00	0.7	13.9	1,278.6	0.6	2.60	1	1	0
08/07/2020 02:00	0.7	13.9	1,278.9	0.6	2.60	1	1	0
08/07/2020 03:00	0.7	13.9	1,279.4	0.6	2.60	1	1	0
08/07/2020 04:00	0.7	13.9	1,324.1	0.6	2.60	1	1	0
08/07/2020 05:00	0.7	13.9	1,314.5	0.6	2.60	1	1	0
08/07/2020 06:00	0.7	13.9	1,280.2	0.6	2.60	1	1	0
08/07/2020 07:00	0.7	13.9	1,284.8	0.6	2.60	1	1	0
08/07/2020 08:00	0.7	13.9	1,291.6	0.6	2.60	1	1	0
08/07/2020 09:00	0.7	13.9	1,294.4	0.6	2.60	1	1	0
08/07/2020 10:00	0.7	13.9	1,293.3	0.6	2.60	1	1	0
08/07/2020 11:00	0.6	14.0	1,293.3	0.5	2.60	1	1	0
08/07/2020 12:00	0.6	14.0	1,289.1	0.5	2.60	1	1	0
08/07/2020 13:00	0.7	13.9	1,344.8	0.6	2.70	1	1	0
08/07/2020 14:00	0.8	14.0	1,355.9	0.7	4.10	1	1	0
08/07/2020 15:00	0.7	14.0	1,294.0	0.6	2.60	1	1	0
08/07/2020 16:00	0.8	13.9	1,399.7	0.7	2.80	1	1	0
08/07/2020 17:00	0.9	13.9	1,462.5	0.8	4.40	1	1	0
08/07/2020 18:00	1.2	13.8	1,667.4	1.0	6.70	1	1	0
08/07/2020 19:00	1.0	13.8	1,637.6	0.8	4.90	1	1	0
08/07/2020 20:00	0.9	13.8	1,479.5	0.7	4.40	1	1	0
08/07/2020 21:00	0.7	13.9	1,334.9	0.6	2.70	1	1	0
08/07/2020 22:00	0.8	13.9	1,387.2	0.7	2.80	1	1	0
08/07/2020 23:00	0.8	13.9	1,441.3	0.7	2.90	1	1	0
Average/Sum#:	0.8	13.9	1,357.8	0.6	74.80 #	24 #	24 #	0 #
Minimum:	0.6	13.8	1,278.6	0.5	2.60	1	1	0
Maximum:	1.2	14.0	1,667.4	1.0	6.70	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOX, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/08/2020 00:00	0.7	13.9	1,346.0	0.6	2.70	1	1	0
08/08/2020 01:00	0.7	13.9	1,280.5	0.6	2.60	1	1	0
08/08/2020 02:00	0.7	13.9	1,278.5	0.6	2.60	1	1	0
08/08/2020 03:00	0.7	13.9	1,281.5	0.6	2.60	1	1	0
08/08/2020 04:00	0.7	13.9	1,284.5	0.6	2.60	1	1	0
08/08/2020 05:00	0.7	13.9	1,280.0	0.6	2.60	1	1	0
08/08/2020 06:00	0.7	13.9	1,281.0	0.6	2.60	1	1	0
08/08/2020 07:00	0.7	13.9	1,289.1	0.6	2.60	1	1	0
08/08/2020 08:00	0.7	13.9	1,288.1	0.6	2.60	1	1	0
08/08/2020 09:00	0.7	13.9	1,290.9	0.6	2.60	1	1	0
08/08/2020 10:00	0.7	13.9	1,293.6	0.6	2.60	1	1	0
08/08/2020 11:00	0.7	13.9	1,291.2	0.6	2.60	1	1	0
08/08/2020 12:00	0.7	13.9	1,290.6	0.6	2.60	1	1	0
08/08/2020 13:00	0.8	13.9	1,411.6	0.7	2.80	1	1	0
08/08/2020 14:00	0.7	13.9	1,324.5	0.6	2.60	1	1	0
08/08/2020 15:00	0.8	13.9	1,370.4	0.7	2.70	1	1	0
08/08/2020 16:00	0.9	13.9	1,443.7	0.8	4.30	1	1	1
08/08/2020 17:00	1.5	12.2	2,027.0	1.0	8.10	1	1	1
08/08/2020 18:00	1.7	11.8	2,092.8	1.1	8.40	1	1	1
08/08/2020 19:00	1.7	11.8	2,097.0	1.1	8.40	1	1	1
08/08/2020 20:00	1.6	12.0	2,066.4	1.1	8.30	1	1	1
08/08/2020 21:00	1.6	12.1	2,055.3	1.1	8.20	1	1	1
08/08/2020 22:00	1.5	12.5	1,975.4	1.1	7.90	1	1	1
08/08/2020 23:00	1.5	12.7	1,914.0	1.1	7.70	1	1	1
Average/Sum#:	1.0	13.4	1,523.1	0.8	103.30 #	24 #	24 #	8 #
Minimum:	0.7	11.8	1,278.5	0.6	2.60	1	1	0
Maximum:	1.7	13.9	2,097.0	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/09/2020 00:00	0.9	13.8	1,538.1	0.7	4.60	1	1	0
08/09/2020 01:00	0.7	13.9	1,304.6	0.6	2.60	1	1	0
08/09/2020 02:00	0.7	13.9	1,284.8	0.6	2.60	1	1	0
08/09/2020 03:00	0.7	13.9	1,285.5	0.6	2.60	1	1	0
08/09/2020 04:00	0.7	13.9	1,283.7	0.6	2.60	1	1	0
08/09/2020 05:00	0.7	13.9	1,284.9	0.6	2.60	1	1	0
08/09/2020 06:00	0.7	13.9	1,289.2	0.6	2.60	1	1	0
08/09/2020 07:00	0.7	13.9	1,291.7	0.6	2.60	1	1	0
08/09/2020 08:00	0.7	13.9	1,292.5	0.6	2.60	1	1	0
08/09/2020 09:00	0.7	13.9	1,287.1	0.6	2.60	1	1	0
08/09/2020 10:00	0.7	13.9	1,292.4	0.6	2.60	1	1	0
08/09/2020 11:00	0.7	13.9	1,294.1	0.6	2.60	1	1	0
08/09/2020 12:00	0.9	13.9	1,436.4	0.8	4.30	1	1	0
08/09/2020 13:00	1.0	13.8	1,507.2	0.8	4.50	1	1	0
08/09/2020 14:00	0.8	13.9	1,381.6	0.7	2.80	1	1	0
08/09/2020 15:00	1.1	13.7	1,596.0	0.9	4.80	1	1	1
08/09/2020 16:00	1.6	12.0	2,037.9	1.1	8.20	1	1	1
08/09/2020 17:00	1.7	11.8	2,079.1	1.1	8.30	1	1	1
08/09/2020 18:00	1.7	11.8	2,089.2	1.1	8.40	1	1	1
08/09/2020 19:00	1.7	11.9	2,058.6	1.1	8.20	1	1	1
08/09/2020 20:00	1.6	12.0	2,041.8	1.1	8.20	1	1	1
08/09/2020 21:00	1.6	11.9	2,062.3	1.0	8.20	1	1	1
08/09/2020 22:00	1.6	12.3	1,981.5	1.1	7.90	1	1	1
08/09/2020 23:00	1.5	12.6	1,911.2	1.1	7.60	1	1	1
Average/Sum#:	1.1	13.3	1,579.6	0.8	114.60 #	24 #	24 #	9 #
Minimum:	0.7	11.8	1,283.7	0.6	2.60	1	1	0
Maximum:	1.7	13.9	2,089.2	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/10/2020 00:00	0.9	13.8	1,413.6	0.7	4.20	1	1	0
08/10/2020 01:00	0.7	13.9	1,284.4	0.6	2.60	1	1	0
08/10/2020 02:00	0.7	13.9	1,291.1	0.6	2.60	1	1	0
08/10/2020 03:00	0.8	13.9	1,492.6	0.7	3.00	1	1	0
08/10/2020 04:00	0.9	13.9	1,521.0	0.8	4.60	1	1	0
08/10/2020 05:00	0.9	13.9	1,512.5	0.8	4.50	1	1	0
08/10/2020 06:00	1.0	13.9	1,608.3	0.8	4.80	1	1	0
08/10/2020 07:00	0.8	13.9	1,365.3	0.7	2.70	1	1	0
08/10/2020 08:00	0.9	13.9	1,492.7	0.8	4.50	1	1	0
08/10/2020 09:00	0.7	13.9	1,309.3	0.6	2.60	1	1	0
08/10/2020 10:00	1.0	13.9	1,523.3	0.8	4.60	1	1	0
08/10/2020 11:00	1.0	13.9	1,518.2	0.8	4.60	1	1	0
08/10/2020 12:00	0.7	13.9	1,305.8	0.6	2.60	1	1	0
08/10/2020 13:00	0.7	13.9	1,325.6	0.6	2.70	1	1	0
08/10/2020 14:00	0.7	13.9	1,332.3	0.6	2.70	1	1	0
08/10/2020 15:00	1.2	13.7	1,638.9	1.0	6.60	1	1	1
08/10/2020 16:00	1.6	12.0	2,038.2	1.1	8.20	1	1	1
08/10/2020 17:00	1.7	11.7	2,089.9	1.1	8.40	1	1	1
08/10/2020 18:00	1.6	11.9	2,046.6	1.0	8.20	1	1	1
08/10/2020 19:00	1.6	12.2	2,016.9	1.1	8.10	1	1	1
08/10/2020 20:00	1.6	12.2	2,002.9	1.1	8.00	1	1	1
08/10/2020 21:00	1.6	12.3	1,995.2	1.1	8.00	1	1	1
08/10/2020 22:00	1.5	12.6	1,950.2	1.1	7.80	1	1	1
08/10/2020 23:00	1.3	13.0	1,763.2	1.0	7.10	1	1	1
Average/Sum#:	1.1	13.3	1,618.3	0.8	123.70 #	24 #	24 #	9 #
Minimum:	0.7	11.7	1,284.4	0.6	2.60	1	1	0
Maximum:	1.7	13.9	2,089.9	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOX, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/11/2020 00:00	0.7	13.9	1,282.3	0.6	2.60	1	1	0
08/11/2020 01:00	0.7	13.9	1,281.7	0.6	2.60	1	1	0
08/11/2020 02:00	0.6	13.9	1,282.8	0.5	2.60	1	1	0
08/11/2020 03:00	0.6	13.9	1,281.9	0.5	2.60	1	1	0
08/11/2020 04:00	0.7	13.9	1,289.8	0.6	2.60	1	1	0
08/11/2020 05:00	0.7	13.9	1,299.2	0.6	2.60	1	1	0
08/11/2020 06:00	0.6	13.9	1,333.4	0.5	2.70	1	1	0
08/11/2020 07:00	0.6	13.9	1,283.8	0.5	2.60	1	1	0
08/11/2020 08:00	0.7	13.9	1,289.0	0.6	2.60	1	1	0
08/11/2020 09:00	0.7	13.9	1,291.7	0.6	2.60	1	1	0
08/11/2020 10:00	0.7	13.9	1,295.2	0.6	2.60	1	1	0
08/11/2020 11:00	0.7	13.9	1,298.4	0.6	2.60	1	1	0
08/11/2020 12:00	0.7	13.9	1,296.0	0.6	2.60	1	1	0
08/11/2020 13:00	0.7	13.9	1,296.8	0.6	2.60	1	1	0
08/11/2020 14:00	0.7	13.9	1,315.4	0.6	2.60	1	1	0
08/11/2020 15:00	0.7	13.9	1,331.2	0.6	2.70	1	1	0
08/11/2020 16:00	0.8	13.9	1,425.6	0.7	2.90	1	1	0
08/11/2020 17:00	1.0	13.9	1,567.4	0.8	4.70	1	1	0
08/11/2020 18:00	1.0	13.9	1,519.2	0.8	4.60	1	1	0
08/11/2020 19:00	0.8	13.9	1,374.5	0.7	2.70	1	1	0
08/11/2020 20:00	0.8	13.9	1,356.4	0.7	2.70	1	1	0
08/11/2020 21:00	0.7	13.9	1,306.4	0.6	2.60	1	1	0
08/11/2020 22:00	0.8	13.9	1,390.3	0.7	2.80	1	1	0
08/11/2020 23:00	0.7	13.9	1,297.8	0.6	2.60	1	1	0
Average/Sum#:	0.7	13.9	1,332.8	0.6	67.40 #	24 #	24 #	0 #
Minimum:	0.6	13.9	1,281.7	0.5	2.60	1	1	0
Maximum:	1.0	13.9	1,567.4	0.8	4.70	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/12/2020 00:00	0.7	13.9	1,284.9	0.6	2.60	1	1	0
08/12/2020 01:00	0.7	13.9	1,307.3	0.6	2.60	1	1	0
08/12/2020 02:00	0.7	13.9	1,282.6	0.6	2.60	1	1	0
08/12/2020 03:00	0.7	13.9	1,286.3	0.6	2.60	1	1	0
08/12/2020 04:00	0.7	13.9	1,307.4	0.6	2.60	1	1	0
08/12/2020 05:00	0.7	13.9	1,298.2	0.6	2.60	1	1	0
08/12/2020 06:00	0.7	13.9	1,292.9	0.6	2.60	1	1	0
08/12/2020 07:00	0.7	13.9	1,308.0	0.6	2.60	1	1	0
08/12/2020 08:00	0.7	13.9	1,379.6	0.6	2.80	1	1	0
08/12/2020 09:00	0.7	13.9	1,332.9	0.6	2.70	1	1	0
08/12/2020 10:00	0.7	13.9	1,339.6	0.6	2.70	1	1	0
08/12/2020 11:00	0.7	13.9	1,382.5	0.6	2.80	1	1	0
08/12/2020 12:00	1.1	13.8	1,636.7	0.9	4.90	1	1	1
08/12/2020 13:00	1.5	12.3	2,004.7	1.0	8.00	1	1	1
08/12/2020 14:00	1.6	12.0	2,053.5	1.1	8.20	1	1	1
08/12/2020 15:00	1.7	11.8	2,078.9	1.1	8.30	1	1	1
08/12/2020 16:00	1.7	11.8	2,078.6	1.1	8.30	1	1	1
08/12/2020 17:00	1.7	11.9	2,073.2	1.1	8.30	1	1	1
08/12/2020 18:00	1.6	12.0	2,059.2	1.1	8.20	1	1	1
08/12/2020 19:00	1.6	12.0	2,054.2	1.1	8.20	1	1	1
08/12/2020 20:00	1.6	12.2	2,025.0	1.1	8.10	1	1	1
08/12/2020 21:00	1.6	12.3	2,017.2	1.1	8.10	1	1	1
08/12/2020 22:00	1.6	12.3	2,032.1	1.1	8.10	1	1	1
08/12/2020 23:00	1.5	12.7	1,920.1	1.1	7.70	1	1	1
Average/Sum#:	1.1	13.1	1,659.8	0.8	126.20 #	24 #	24 #	12 #
Minimum:	0.7	11.8	1,282.6	0.6	2.60	1	1	0
Maximum:	1.7	13.9	2,078.9	1.1	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOX, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/13/2020 00:00	1.1	13.8	1,672.4	0.9	5.00	1	1	0
08/13/2020 01:00	0.9	13.8	1,611.4	0.7	4.80	1	1	0
08/13/2020 02:00	0.8	13.9	1,543.7	0.7	3.10	1	1	0
08/13/2020 03:00	0.9	13.9	1,577.0	0.8	4.70	1	1	0
08/13/2020 04:00	0.8	13.9	1,586.3	0.7	3.20	1	1	0
08/13/2020 05:00	0.8	13.9	1,608.0	0.7	3.20	1	1	0
08/13/2020 06:00	1.0	13.9	1,696.0	0.8	5.10	1	1	0
08/13/2020 07:00	0.9	13.9	1,598.1	0.8	4.80	1	1	0
08/13/2020 08:00	1.0	13.8	1,672.6	0.8	5.00	1	1	0
08/13/2020 09:00	0.9	13.8	1,595.3	0.7	4.80	1	1	1
08/13/2020 10:00	1.5	12.6	1,972.3	1.1	7.90	1	1	1
08/13/2020 11:00	1.6	12.1	2,072.7	1.1	8.30	1	1	1
08/13/2020 12:00	1.6	12.1	2,065.6	1.1	8.30	1	1	1
08/13/2020 13:00	1.6	12.1	2,052.3	1.1	8.20	1	1	1
08/13/2020 14:00	1.6	12.1	2,039.5	1.1	8.20	1	1	1
08/13/2020 15:00	1.6	11.9	2,071.2	1.0	8.30	1	1	1
08/13/2020 16:00	1.7	12.0	2,062.8	1.1	8.30	1	1	1
08/13/2020 17:00	1.7	11.9	2,064.0	1.1	8.30	1	1	1
08/13/2020 18:00	1.7	12.0	2,062.5	1.1	8.30	1	1	1
08/13/2020 19:00	1.6	12.0	2,069.0	1.1	8.30	1	1	1
08/13/2020 20:00	1.6	12.1	2,044.2	1.1	8.20	1	1	1
08/13/2020 21:00	1.6	12.3	2,030.4	1.1	8.10	1	1	1
08/13/2020 22:00	1.6	12.1	2,071.5	1.1	8.30	1	1	1
08/13/2020 23:00	1.6	11.9	2,118.2	1.0	8.50	1	1	1
Average/Sum#:	1.3	12.8	1,873.2	1.0	159.20 #	24 #	24 #	15 #
Minimum:	0.8	11.9	1,543.7	0.7	3.10	1	1	0
Maximum:	1.7	13.9	2,118.2	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/14/2020 00:00	1.6	11.9	2,127.6	1.0	8.50	1	1	1
08/14/2020 01:00	1.6	11.9	2,114.6	1.0	8.50	1	1	1
08/14/2020 02:00	1.6	12.1	2,094.7	1.1	8.40	1	1	1
08/14/2020 03:00	1.6	12.2	2,084.2	1.1	8.30	1	1	1
08/14/2020 04:00	1.6	12.0	2,126.6	1.1	8.50	1	1	1
08/14/2020 05:00	1.6	12.2	2,079.0	1.1	8.30	1	1	1
08/14/2020 06:00	1.5	12.3	2,052.6	1.0	8.20	1	1	1
08/14/2020 07:00	1.6	12.3	2,046.2	1.1	8.20	1	1	1
08/14/2020 08:00	1.6	12.2	2,069.2	1.1	8.30	1	1	1
08/14/2020 09:00	1.6	12.0	2,080.2	1.1	8.30	1	1	1
08/14/2020 10:00	1.6	11.8	2,106.6	1.0	8.40	1	1	1
08/14/2020 11:00	1.6	11.9	2,085.6	1.0	8.30	1	1	1
08/14/2020 12:00	1.6	11.9	2,097.4	1.0	8.40	1	1	1
08/14/2020 13:00	1.6	11.9	2,082.2	1.0	8.30	1	1	1
08/14/2020 14:00	1.6	11.9	2,065.2	1.0	8.30	1	1	1
08/14/2020 15:00	1.6	12.0	2,058.3	1.1	8.20	1	1	1
08/14/2020 16:00	1.6	12.0	2,041.3	1.1	8.20	1	1	1
08/14/2020 17:00	1.6	12.0	2,057.0	1.1	8.20	1	1	1
08/14/2020 18:00	1.6	12.0	2,059.1	1.1	8.20	1	1	1
08/14/2020 19:00	1.7	11.9	2,077.9	1.1	8.30	1	1	1
08/14/2020 20:00	1.6	11.8	2,092.5	1.0	8.40	1	1	1
08/14/2020 21:00	1.6	11.9	2,091.0	1.0	8.40	1	1	1
08/14/2020 22:00	1.6	11.8	2,109.5	1.0	8.40	1	1	1
08/14/2020 23:00	1.6	11.8	2,115.7	1.0	8.50	1	1	1
Average/Sum#:	1.6	12.0	2,083.9	1.1	200.00 #	24 #	24 #	24 #
Minimum:	1.5	11.8	2,041.3	1.0	8.20	1	1	1
Maximum:	1.7	12.3	2,127.6	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/15/2020 00:00	1.6	11.8	2,118.3	1.0	8.50	1	1	1
08/15/2020 01:00	1.7	11.8	2,121.3	1.1	8.50	1	1	1
08/15/2020 02:00	1.6	11.9	2,096.5	1.0	8.40	1	1	1
08/15/2020 03:00	1.6	12.0	2,086.7	1.1	8.30	1	1	1
08/15/2020 04:00	1.6	12.1	2,072.4	1.1	8.30	1	1	1
08/15/2020 05:00	1.6	12.2	2,063.2	1.1	8.30	1	1	1
08/15/2020 06:00	1.4	12.2	2,065.6	0.9	6.20	1	1	1
08/15/2020 07:00	1.6	12.1	2,062.5	1.1	8.30	1	1	1
08/15/2020 08:00	1.6	12.5	1,983.4	1.1	7.90	1	1	1
08/15/2020 09:00	1.6	12.1	2,053.2	1.1	8.20	1	1	1
08/15/2020 10:00	1.6	12.0	2,057.7	1.1	8.20	1	1	1
08/15/2020 11:00	1.7	11.9	2,084.9	1.1	8.30	1	1	1
08/15/2020 12:00	1.7	11.8	2,094.6	1.1	8.40	1	1	1
08/15/2020 13:00	1.7	11.7	2,089.3	1.1	8.40	1	1	1
08/15/2020 14:00	1.7	11.8	2,085.4	1.1	8.30	1	1	1
08/15/2020 15:00	1.7	11.7	2,080.6	1.1	8.30	1	1	1
08/15/2020 16:00	1.7	11.7	2,079.9	1.1	8.30	1	1	1
08/15/2020 17:00	1.7	11.7	2,077.3	1.1	8.30	1	1	1
08/15/2020 18:00	1.7	11.8	2,074.5	1.1	8.30	1	1	1
08/15/2020 19:00	1.7	11.8	2,077.1	1.1	8.30	1	1	1
08/15/2020 20:00	1.7	11.8	2,094.6	1.1	8.40	1	1	1
08/15/2020 21:00	1.7	11.9	2,079.5	1.1	8.30	1	1	1
08/15/2020 22:00	1.7	12.0	2,063.2	1.1	8.30	1	1	1
08/15/2020 23:00	1.7	11.8	2,111.4	1.1	8.40	1	1	1
Average/Sum#:	1.7	11.9	2,078.0	1.1	197.40 #	24 #	24 #	24 #
Minimum:	1.4	11.7	1,983.4	0.9	6.20	1	1	1
Maximum:	1.7	12.5	2,121.3	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/16/2020 00:00	1.7	11.8	2,118.1	1.1	8.50	1	1	1
08/16/2020 01:00	1.7	11.8	2,116.0	1.1	8.50	1	1	1
08/16/2020 02:00	1.7	11.8	2,116.5	1.1	8.50	1	1	1
08/16/2020 03:00	1.6	12.0	2,097.9	1.1	8.40	1	1	1
08/16/2020 04:00	1.6	11.9	2,116.9	1.0	8.50	1	1	1
08/16/2020 05:00	1.6	11.9	2,106.8	1.0	8.40	1	1	1
08/16/2020 06:00	1.6	11.9	2,094.0	1.0	8.40	1	1	1
08/16/2020 07:00	1.6	12.3	2,003.3	1.1	8.00	1	1	1
08/16/2020 08:00	1.5	12.6	1,954.7	1.1	7.80	1	1	1
08/16/2020 09:00	1.6	12.3	2,011.5	1.1	8.00	1	1	1
08/16/2020 10:00	1.6	12.2	2,018.7	1.1	8.10	1	1	1
08/16/2020 11:00	1.6	12.2	2,013.9	1.1	8.10	1	1	1
08/16/2020 12:00	1.6	12.1	2,038.7	1.1	8.20	1	1	1
08/16/2020 13:00	1.6	12.0	2,054.5	1.1	8.20	1	1	1
08/16/2020 14:00	1.7	11.9	2,092.5	1.1	8.40	1	1	1
08/16/2020 15:00	1.6	11.8	2,095.2	1.0	8.40	1	1	1
08/16/2020 16:00	1.7	11.8	2,101.8	1.1	8.40	1	1	1
08/16/2020 17:00	1.7	11.7	2,096.0	1.1	8.40	1	1	1
08/16/2020 18:00	1.7	11.7	2,089.5	1.1	8.40	1	1	1
08/16/2020 19:00	1.7	11.8	2,082.7	1.1	8.30	1	1	1
08/16/2020 20:00	1.7	11.8	2,087.1	1.1	8.30	1	1	1
08/16/2020 21:00	1.6	11.9	2,076.1	1.0	8.30	1	1	1
08/16/2020 22:00	1.7	11.9	2,073.7	1.1	8.30	1	1	1
08/16/2020 23:00	1.7	11.9	2,081.0	1.1	8.30	1	1	1
Average/Sum#:	1.6	12.0	2,072.4	1.1	199.10 #	24 #	24 #	24 #
Minimum:	1.5	11.7	1,954.7	1.0	7.80	1	1	1
Maximum:	1.7	12.6	2,118.1	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/17/2020 00:00	1.6	11.9	2,087.8	1.0	8.40	1	1	1
08/17/2020 01:00	1.6	12.0	2,079.6	1.1	8.30	1	1	1
08/17/2020 02:00	1.6	12.0	2,074.8	1.1	8.30	1	1	1
08/17/2020 03:00	1.6	12.0	2,085.7	1.1	8.30	1	1	1
08/17/2020 04:00	1.6	12.0	2,087.5	1.1	8.40	1	1	1
08/17/2020 05:00	1.6	12.0	2,080.3	1.1	8.30	1	1	1
08/17/2020 06:00	1.3	11.9	2,100.5	0.9	6.30	1	1	1
08/17/2020 07:00	1.6	11.9	2,106.7	1.0	8.40	1	1	1
08/17/2020 08:00	1.6	11.9	2,092.4	1.0	8.40	1	1	1
08/17/2020 09:00	1.7	11.8	2,108.6	1.1	8.40	1	1	1
08/17/2020 10:00	1.7	11.8	2,110.2	1.1	8.40	1	1	1
08/17/2020 11:00	1.7	11.9	2,082.2	1.1	8.30	1	1	1
08/17/2020 12:00	1.7	11.9	2,087.8	1.1	8.40	1	1	1
08/17/2020 13:00	1.6	12.0	2,058.6	1.1	8.20	1	1	1
08/17/2020 14:00	1.6	12.0	2,063.5	1.1	8.30	1	1	1
08/17/2020 15:00	1.7	11.8	2,092.7	1.1	8.40	1	1	1
08/17/2020 16:00	1.7	11.8	2,093.7	1.1	8.40	1	1	1
08/17/2020 17:00	1.6	11.9	2,065.1	1.0	8.30	1	1	1
08/17/2020 18:00	1.6	12.1	2,045.7	1.1	8.20	1	1	1
08/17/2020 19:00	1.6	12.1	2,047.1	1.1	8.20	1	1	1
08/17/2020 20:00	1.6	12.1	2,067.5	1.1	8.30	1	1	1
08/17/2020 21:00	1.6	11.9	2,097.8	1.0	8.40	1	1	1
08/17/2020 22:00	1.6	11.9	2,088.7	1.0	8.40	1	1	1
08/17/2020 23:00	1.6	12.0	2,089.0	1.1	8.40	1	1	1
Average/Sum#:	1.6	11.9	2,083.1	1.1	198.10 #	24 #	24 #	24 #
Minimum:	1.3	11.8	2,045.7	0.9	6.30	1	1	1
Maximum:	1.7	12.1	2,110.2	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/18/2020 00:00	1.6	12.1	2,055.8	1.1	8.20	1	1	1
08/18/2020 01:00	1.6	12.0	2,079.6	1.1	8.30	1	1	1
08/18/2020 02:00	1.7	11.9	2,093.1	1.1	8.40	1	1	1
08/18/2020 03:00	1.6	12.1	2,069.7	1.1	8.30	1	1	1
08/18/2020 04:00	1.6	12.0	2,085.1	1.1	8.30	1	1	1
08/18/2020 05:00	1.6	12.0	2,077.7	1.1	8.30	1	1	1
08/18/2020 06:00	1.5	11.9	2,099.8	1.0	8.40	1	1	1
08/18/2020 07:00	1.6	12.0	2,079.2	1.1	8.30	1	1	1
08/18/2020 08:00	1.6	12.1	2,056.0	1.1	8.20	1	1	1
08/18/2020 09:00	1.6	12.1	2,049.8	1.1	8.20	1	1	1
08/18/2020 10:00	1.6	12.0	2,063.2	1.1	8.30	1	1	1
08/18/2020 11:00	1.6	12.0	2,028.5	1.1	8.10	1	1	1
08/18/2020 12:00	1.7	11.8	2,071.7	1.1	8.30	1	1	1
08/18/2020 13:00	1.7	11.7	2,078.3	1.1	8.30	1	1	1
08/18/2020 14:00	1.7	11.7	2,083.1	1.1	8.30	1	1	1
08/18/2020 15:00	1.7	11.7	2,077.1	1.1	8.30	1	1	1
08/18/2020 16:00	1.7	11.7	2,077.9	1.1	8.30	1	1	1
08/18/2020 17:00	1.7	11.7	2,080.9	1.1	8.30	1	1	1
08/18/2020 18:00	1.7	11.7	2,080.6	1.1	8.30	1	1	1
08/18/2020 19:00	1.7	11.7	2,084.6	1.1	8.30	1	1	1
08/18/2020 20:00	1.7	11.8	2,098.2	1.1	8.40	1	1	1
08/18/2020 21:00	1.6	12.0	2,098.2	1.1	8.40	1	1	1
08/18/2020 22:00	1.6	11.9	2,109.5	1.0	8.40	1	1	1
08/18/2020 23:00	1.6	11.9	2,116.9	1.0	8.50	1	1	1
Average/Sum#:	1.6	11.9	2,078.9	1.1	199.40 #	24 #	24 #	24 #
Minimum:	1.5	11.7	2,028.5	1.0	8.10	1	1	1
Maximum:	1.7	12.1	2,116.9	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/19/2020 00:00	1.6	12.0	2,086.1	1.1	8.30	1	1	1
08/19/2020 01:00	1.6	12.0	2,080.9	1.1	8.30	1	1	1
08/19/2020 02:00	1.6	12.0	2,091.8	1.1	8.40	1	1	1
08/19/2020 03:00	1.6	12.1	2,069.2	1.1	8.30	1	1	1
08/19/2020 04:00	1.6	12.1	2,076.8	1.1	8.30	1	1	1
08/19/2020 05:00	1.6	12.2	2,069.1	1.1	8.30	1	1	1
08/19/2020 06:00	1.5	12.2	2,066.5	1.0	8.30	1	1	1
08/19/2020 07:00	1.6	12.0	2,106.3	1.1	8.40	1	1	1
08/19/2020 08:00	1.6	12.2	2,056.1	1.1	8.20	1	1	1
08/19/2020 09:00	1.6	12.0	2,098.4	1.1	8.40	1	1	1
08/19/2020 10:00	1.6	11.8	2,115.1	1.0	8.50	1	1	1
08/19/2020 11:00	1.6	11.8	2,102.4	1.0	8.40	1	1	1
08/19/2020 12:00	1.6	11.9	2,076.7	1.0	8.30	1	1	1
08/19/2020 13:00	1.6	11.8	2,099.7	1.0	8.40	1	1	1
08/19/2020 14:00	1.7	11.8	2,092.0	1.1	8.40	1	1	1
08/19/2020 15:00	1.7	11.7	2,082.8	1.1	8.30	1	1	1
08/19/2020 16:00	1.7	11.8	2,085.0	1.1	8.30	1	1	1
08/19/2020 17:00	1.6	11.9	2,089.1	1.0	8.40	1	1	1
08/19/2020 18:00	1.6	11.9	2,110.1	1.0	8.40	1	1	1
08/19/2020 19:00	1.6	12.0	2,101.6	1.1	8.40	1	1	1
08/19/2020 20:00	1.6	12.0	2,098.1	1.1	8.40	1	1	1
08/19/2020 21:00	1.6	12.2	2,073.9	1.1	8.30	1	1	1
08/19/2020 22:00	1.6	12.3	2,062.5	1.1	8.30	1	1	1
08/19/2020 23:00	1.6	12.4	2,048.7	1.1	8.20	1	1	1
Average/Sum#:	1.6	12.0	2,085.0	1.1	200.20 #	24 #	24 #	24 #
Minimum:	1.5	11.7	2,048.7	1.0	8.20	1	1	1
Maximum:	1.7	12.4	2,115.1	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOX, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOX, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/20/2020 00:00	1.6	12.4	2,052.7	1.1	8.20	1	1	1
08/20/2020 01:00	1.5	12.4	2,042.7	1.0	8.20	1	1	1
08/20/2020 02:00	1.5	12.5	2,032.3	1.1	8.10	1	1	1
08/20/2020 03:00	1.5	12.5	2,033.4	1.1	8.10	1	1	1
08/20/2020 04:00	1.5	12.4	2,041.0	1.0	8.20	1	1	1
08/20/2020 05:00	1.5	12.4	2,043.8	1.0	8.20	1	1	1
08/20/2020 06:00	1.5	12.5	2,031.9	1.1	8.10	1	1	1
08/20/2020 07:00	1.6	12.5	2,028.1	1.1	8.10	1	1	1
08/20/2020 08:00	1.5	12.4	2,034.2	1.0	8.10	1	1	1
08/20/2020 09:00	1.6	12.3	2,049.0	1.1	8.20	1	1	1
08/20/2020 10:00	1.6	12.3	2,053.1	1.1	8.20	1	1	1
08/20/2020 11:00	1.6	12.3	2,049.9	1.1	8.20	1	1	1
08/20/2020 12:00	1.6	12.3	2,054.9	1.1	8.20	1	1	1
08/20/2020 13:00	1.6	12.3	2,056.9	1.1	8.20	1	1	1
08/20/2020 14:00	1.5	12.3	2,054.5	1.0	8.20	1	1	1
08/20/2020 15:00	1.6	12.3	2,042.9	1.1	8.20	1	1	1
08/20/2020 16:00	1.6	12.3	2,039.1	1.1	8.20	1	1	1
08/20/2020 17:00	1.6	12.1	2,051.5	1.1	8.20	1	1	1
08/20/2020 18:00	1.6	12.2	2,048.2	1.1	8.20	1	1	1
08/20/2020 19:00	1.6	12.2	2,052.3	1.1	8.20	1	1	1
08/20/2020 20:00	1.6	12.2	2,055.6	1.1	8.20	1	1	1
08/20/2020 21:00	1.6	12.3	2,050.7	1.1	8.20	1	1	1
08/20/2020 22:00	1.6	12.3	2,039.5	1.1	8.20	1	1	1
08/20/2020 23:00	1.6	12.2	2,037.1	1.1	8.10	1	1	1
Average/Sum#:	1.6	12.3	2,044.8	1.1	196.20 #	24 #	24 #	24 #
Minimum:	1.5	12.1	2,028.1	1.0	8.10	1	1	1
Maximum:	1.6	12.5	2,056.9	1.1	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/21/2020 00:00	1.5	12.2	2,053.6	1.0	8.20	1	1	1
08/21/2020 01:00	1.5	12.3	2,026.0	1.0	8.10	1	1	1
08/21/2020 02:00	1.5	12.7	1,948.9	1.1	7.80	1	1	1
08/21/2020 03:00	1.5	12.3	2,030.5	1.0	8.10	1	1	1
08/21/2020 04:00	1.5	12.3	2,039.2	1.0	8.20	1	1	1
08/21/2020 05:00	1.5	12.3	2,033.1	1.0	8.10	1	1	1
08/21/2020 06:00	1.4	12.1	2,065.3	0.9	6.20	1	1	1
08/21/2020 07:00	1.5	12.2	2,062.1	1.0	8.20	1	1	1
08/21/2020 08:00	1.5	12.2	2,044.3	1.0	8.20	1	1	1
08/21/2020 09:00	1.6	12.1	2,068.7	1.1	8.30	1	1	1
08/21/2020 10:00	1.6	12.0	2,069.0	1.1	8.30	1	1	1
08/21/2020 11:00	1.6	12.0	2,062.8	1.1	8.30	1	1	1
08/21/2020 12:00	1.6	12.1	2,073.1	1.1	8.30	1	1	1
08/21/2020 13:00	1.6	11.9	2,092.9	1.0	8.40	1	1	1
08/21/2020 14:00	1.6	12.0	2,061.2	1.1	8.20	1	1	1
08/21/2020 15:00	1.6	12.0	2,058.9	1.1	8.20	1	1	1
08/21/2020 16:00	1.6	11.9	2,076.2	1.0	8.30	1	1	1
08/21/2020 17:00	1.6	11.9	2,080.0	1.0	8.30	1	1	1
08/21/2020 18:00	1.6	12.0	2,063.1	1.1	8.30	1	1	1
08/21/2020 19:00	1.6	12.1	2,047.4	1.1	8.20	1	1	1
08/21/2020 20:00	1.6	12.1	2,059.0	1.1	8.20	1	1	1
08/21/2020 21:00	1.6	12.2	2,042.1	1.1	8.20	1	1	1
08/21/2020 22:00	1.6	12.1	2,053.2	1.1	8.20	1	1	1
08/21/2020 23:00	1.6	12.1	2,058.8	1.1	8.20	1	1	1
Average/Sum#:	1.6	12.1	2,052.9	1.1	195.00 #	24 #	24 #	24 #
Minimum:	1.4	11.9	1,948.9	0.9	6.20	1	1	1
Maximum:	1.6	12.7	2,092.9	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/22/2020 00:00	1.6	12.1	2,061.8	1.1	8.20	1	1	1
08/22/2020 01:00	1.5	12.6	1,918.4	1.1	7.70	1	1	1
08/22/2020 02:00	1.1	13.8	1,666.9	0.9	5.00	1	1	0
08/22/2020 03:00	0.8	13.9	1,534.7	0.7	3.10	1	1	0
08/22/2020 04:00	1.0	13.9	1,660.7	0.8	5.00	1	1	0
08/22/2020 05:00	1.1	13.8	1,682.1	0.9	5.00	1	1	0
08/22/2020 06:00	1.0	13.9	1,681.6	0.8	5.00	1	1	0
08/22/2020 07:00	1.0	13.9	1,673.1	0.8	5.00	1	1	0
08/22/2020 08:00	1.0	13.8	1,666.4	0.8	5.00	1	1	0
08/22/2020 09:00	1.1	13.8	1,645.9	0.9	4.90	1	1	0
08/22/2020 10:00	1.0	13.9	1,562.6	0.8	4.70	1	1	1
08/22/2020 11:00	1.5	12.4	2,009.3	1.0	8.00	1	1	1
08/22/2020 12:00	1.6	11.9	2,074.7	1.0	8.30	1	1	1
08/22/2020 13:00	1.6	11.9	2,082.5	1.0	8.30	1	1	1
08/22/2020 14:00	1.6	12.0	2,050.3	1.1	8.20	1	1	1
08/22/2020 15:00	1.7	11.8	2,086.1	1.1	8.30	1	1	1
08/22/2020 16:00	1.7	11.7	2,095.1	1.1	8.40	1	1	1
08/22/2020 17:00	1.6	11.9	2,073.7	1.0	8.30	1	1	1
08/22/2020 18:00	1.6	12.0	2,058.8	1.1	8.20	1	1	1
08/22/2020 19:00	1.6	12.0	2,058.1	1.1	8.20	1	1	1
08/22/2020 20:00	1.6	12.0	2,049.9	1.1	8.20	1	1	1
08/22/2020 21:00	1.6	11.9	2,083.8	1.0	8.30	1	1	1
08/22/2020 22:00	1.6	12.0	2,069.1	1.1	8.30	1	1	1
08/22/2020 23:00	1.6	11.9	2,090.1	1.0	8.40	1	1	1
Average/Sum#:	1.4	12.7	1,901.5	1.0	166.00 #	24 #	24 #	16 #
Minimum:	0.8	11.7	1,534.7	0.7	3.10	1	1	0
Maximum:	1.7	13.9	2,095.1	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/23/2020 00:00	1.6	12.1	2,060.0	1.1	8.20	1	1	1
08/23/2020 01:00	1.6	12.2	2,031.2	1.1	8.10	1	1	1
08/23/2020 02:00	1.6	12.2	2,048.3	1.1	8.20	1	1	1
08/23/2020 03:00	1.6	12.3	2,034.9	1.1	8.10	1	1	1
08/23/2020 04:00	1.5	12.7	1,936.3	1.1	7.70	1	1	1
08/23/2020 05:00	1.0	13.8	1,683.3	0.8	5.00	1	1	0
08/23/2020 06:00	0.9	13.9	1,636.0	0.8	4.90	1	1	0
08/23/2020 07:00	0.8	13.9	1,581.3	0.7	3.20	1	1	0
08/23/2020 08:00	1.0	13.8	1,641.8	0.8	4.90	1	1	0
08/23/2020 09:00	1.0	13.8	1,608.6	0.8	4.80	1	1	0
08/23/2020 10:00	1.0	13.9	1,529.4	0.8	4.60	1	1	1
08/23/2020 11:00	1.5	12.4	2,010.5	1.0	8.00	1	1	1
08/23/2020 12:00	1.6	12.0	2,081.1	1.1	8.30	1	1	1
08/23/2020 13:00	1.6	11.9	2,077.2	1.0	8.30	1	1	1
08/23/2020 14:00	1.6	12.0	2,072.5	1.1	8.30	1	1	1
08/23/2020 15:00	1.7	11.8	2,092.8	1.1	8.40	1	1	1
08/23/2020 16:00	1.6	11.7	2,092.5	1.0	8.40	1	1	1
08/23/2020 17:00	1.7	11.7	2,097.6	1.1	8.40	1	1	1
08/23/2020 18:00	1.6	11.7	2,099.7	1.0	8.40	1	1	1
08/23/2020 19:00	1.7	11.7	2,101.8	1.1	8.40	1	1	1
08/23/2020 20:00	1.6	11.8	2,111.9	1.0	8.40	1	1	1
08/23/2020 21:00	1.6	12.0	2,086.7	1.1	8.30	1	1	1
08/23/2020 22:00	1.6	12.0	2,075.3	1.1	8.30	1	1	1
08/23/2020 23:00	1.6	12.0	2,072.4	1.1	8.30	1	1	1
Average/Sum#:	1.4	12.5	1,952.6	1.0	175.90 #	24 #	24 #	19 #
Minimum:	0.8	11.7	1,529.4	0.7	3.20	1	1	0
Maximum:	1.7	13.9	2,111.9	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/24/2020 00:00	1.6	12.0	2,077.3	1.1	8.30	1	1	1
08/24/2020 01:00	1.6	12.1	2,072.8	1.1	8.30	1	1	1
08/24/2020 02:00	1.6	12.0	2,086.4	1.1	8.30	1	1	1
08/24/2020 03:00	1.6	11.9	2,106.5	1.0	8.40	1	1	1
08/24/2020 04:00	1.6	12.0	2,098.2	1.1	8.40	1	1	1
08/24/2020 05:00	1.6	12.0	2,092.4	1.1	8.40	1	1	1
08/24/2020 06:00	1.5	12.0	2,083.2	1.0	8.30	1	1	1
08/24/2020 07:00	1.6	12.2	2,057.4	1.1	8.20	1	1	1
08/24/2020 08:00	1.6	12.2	2,046.8	1.1	8.20	1	1	1
08/24/2020 09:00	1.6	12.1	2,062.3	1.1	8.20	1	1	1
08/24/2020 10:00	1.6	11.9	2,096.5	1.0	8.40	1	1	1
08/24/2020 11:00	1.6	11.8	2,106.9	1.0	8.40	1	1	1
08/24/2020 12:00	1.6	12.0	2,088.4	1.1	8.40	1	1	1
08/24/2020 13:00	1.6	11.9	2,086.5	1.0	8.30	1	1	1
08/24/2020 14:00	1.6	11.9	2,067.3	1.0	8.30	1	1	1
08/24/2020 15:00	1.6	11.8	2,072.7	1.0	8.30	1	1	1
08/24/2020 16:00	1.7	11.8	2,084.1	1.1	8.30	1	1	1
08/24/2020 17:00	1.6	11.8	2,078.3	1.0	8.30	1	1	1
08/24/2020 18:00	1.6	11.8	2,081.4	1.0	8.30	1	1	1
08/24/2020 19:00	1.6	12.0	2,053.6	1.1	8.20	1	1	1
08/24/2020 20:00	1.6	12.0	2,070.3	1.1	8.30	1	1	1
08/24/2020 21:00	1.6	12.0	2,071.0	1.1	8.30	1	1	1
08/24/2020 22:00	1.6	12.0	2,078.3	1.1	8.30	1	1	1
08/24/2020 23:00	1.6	12.0	2,076.6	1.1	8.30	1	1	1
Average/Sum#:	1.6	12.0	2,079.0	1.1	199.40 #	24 #	24 #	24 #
Minimum:	1.5	11.8	2,046.8	1.0	8.20	1	1	1
Maximum:	1.7	12.2	2,106.9	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/25/2020 00:00	1.6	12.1	2,054.6	1.1	8.20	1	1	1
08/25/2020 01:00	1.6	12.1	2,047.5	1.1	8.20	1	1	1
08/25/2020 02:00	1.6	12.2	2,037.7	1.1	8.20	1	1	1
08/25/2020 03:00	1.5	12.5	1,990.2	1.1	8.00	1	1	1
08/25/2020 04:00	1.6	12.3	2,035.3	1.1	8.10	1	1	1
08/25/2020 05:00	1.6	12.2	2,044.2	1.1	8.20	1	1	1
08/25/2020 06:00	1.4	12.3	2,043.5	1.0	8.20	1	1	1
08/25/2020 07:00	1.5	12.4	2,029.6	1.0	8.10	1	1	1
08/25/2020 08:00	1.6	12.3	2,027.0	1.1	8.10	1	1	1
08/25/2020 09:00	1.6	12.2	2,047.7	1.1	8.20	1	1	1
08/25/2020 10:00	1.6	12.1	2,049.2	1.1	8.20	1	1	1
08/25/2020 11:00	1.6	12.1	2,043.7	1.1	8.20	1	1	1
08/25/2020 12:00	1.6	12.1	2,039.4	1.1	8.20	1	1	1
08/25/2020 13:00	1.6	12.1	2,037.6	1.1	8.20	1	1	1
08/25/2020 14:00	1.6	12.0	2,040.4	1.1	8.20	1	1	1
08/25/2020 15:00	1.6	12.0	2,047.2	1.1	8.20	1	1	1
08/25/2020 16:00	1.6	11.9	2,062.0	1.0	8.20	1	1	1
08/25/2020 17:00	1.6	11.8	2,079.2	1.0	8.30	1	1	1
08/25/2020 18:00	1.7	11.8	2,087.2	1.1	8.30	1	1	1
08/25/2020 19:00	1.6	11.8	2,090.0	1.0	8.40	1	1	1
08/25/2020 20:00	1.6	11.9	2,069.9	1.0	8.30	1	1	1
08/25/2020 21:00	1.6	12.0	2,055.4	1.1	8.20	1	1	1
08/25/2020 22:00	1.6	12.1	2,050.1	1.1	8.20	1	1	1
08/25/2020 23:00	1.6	12.0	2,054.9	1.1	8.20	1	1	1
Average/Sum#:	1.6	12.1	2,048.5	1.1	196.80 #	24 #	24 #	24 #
Minimum:	1.4	11.8	1,990.2	1.0	8.00	1	1	1
Maximum:	1.7	12.5	2,090.0	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/26/2020 00:00	1.6	12.2	2,023.2	1.1	8.10	1	1	1
08/26/2020 01:00	1.5	12.7	1,929.4	1.1	7.70	1	1	1
08/26/2020 02:00	1.5	12.8	1,936.0	1.1	7.70	1	1	1
08/26/2020 03:00	1.6	12.4	2,022.2	1.1	8.10	1	1	1
08/26/2020 04:00	1.5	12.3	2,032.4	1.0	8.10	1	1	1
08/26/2020 05:00	1.6	12.3	2,033.1	1.1	8.10	1	1	1
08/26/2020 06:00	1.5	12.3	2,036.4	1.0	8.10	1	1	1
08/26/2020 07:00	1.5	12.7	1,940.8	1.1	7.80	1	1	1
08/26/2020 08:00	1.5	12.7	1,941.9	1.1	7.80	1	1	1
08/26/2020 09:00	1.6	12.2	2,037.0	1.1	8.10	1	1	1
08/26/2020 10:00	1.6	12.1	2,058.3	1.1	8.20	1	1	1
08/26/2020 11:00	1.6	12.1	2,047.6	1.1	8.20	1	1	1
08/26/2020 12:00	1.6	12.0	2,049.7	1.1	8.20	1	1	1
08/26/2020 13:00	1.6	12.0	2,048.1	1.1	8.20	1	1	1
08/26/2020 14:00	1.6	11.9	2,060.9	1.0	8.20	1	1	1
08/26/2020 15:00	1.7	11.8	2,081.2	1.1	8.30	1	1	1
08/26/2020 16:00	1.6	12.0	2,029.7	1.1	8.10	1	1	1
08/26/2020 17:00	1.6	12.1	2,009.6	1.1	8.00	1	1	1
08/26/2020 18:00	1.6	12.1	2,008.2	1.1	8.00	1	1	1
08/26/2020 19:00	1.6	12.2	1,999.6	1.1	8.00	1	1	1
08/26/2020 20:00	1.6	12.3	1,991.8	1.1	8.00	1	1	1
08/26/2020 21:00	1.6	12.4	1,989.2	1.1	8.00	1	1	1
08/26/2020 22:00	1.5	12.7	1,934.7	1.1	7.70	1	1	1
08/26/2020 23:00	1.5	12.8	1,926.6	1.1	7.70	1	1	1
Average/Sum#:	1.6	12.3	2,007.0	1.1	192.40 #	24 #	24 #	24 #
Minimum:	1.5	11.8	1,926.6	1.0	7.70	1	1	1
Maximum:	1.7	12.8	2,081.2	1.1	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/27/2020 00:00	1.5	12.8	1,929.7	1.1	7.70	1	1	1
08/27/2020 01:00	1.4	12.9	1,929.8	1.0	7.70	1	1	1
08/27/2020 02:00	1.4	12.9	1,924.3	1.0	7.70	1	1	1
08/27/2020 03:00	1.4	12.9	1,931.0	1.0	7.70	1	1	1
08/27/2020 04:00	1.5	12.4	2,032.6	1.0	8.10	1	1	1
08/27/2020 05:00	1.5	12.4	2,037.2	1.0	8.10	1	1	1
08/27/2020 06:00	1.4	12.4	2,054.3	1.0	8.20	1	1	1
08/27/2020 07:00	1.5	12.8	1,939.6	1.1	7.80	1	1	1
08/27/2020 08:00	1.5	12.5	1,996.3	1.1	8.00	1	1	1
08/27/2020 09:00	1.5	12.5	1,995.3	1.1	8.00	1	1	1
08/27/2020 10:00	1.5	12.5	1,990.3	1.1	8.00	1	1	1
08/27/2020 11:00	1.6	12.0	2,089.5	1.1	8.40	1	1	1
08/27/2020 12:00	1.6	11.9	2,101.6	1.0	8.40	1	1	1
08/27/2020 13:00	1.7	11.8	2,096.2	1.1	8.40	1	1	1
08/27/2020 14:00	1.7	11.8	2,097.0	1.1	8.40	1	1	1
08/27/2020 15:00	1.6	11.8	2,105.0	1.0	8.40	1	1	1
08/27/2020 16:00	1.6	12.1	2,042.6	1.1	8.20	1	1	1
08/27/2020 17:00	1.6	12.1	2,041.8	1.1	8.20	1	1	1
08/27/2020 18:00	1.6	12.1	2,048.4	1.1	8.20	1	1	1
08/27/2020 19:00	1.6	12.0	2,080.0	1.1	8.30	1	1	1
08/27/2020 20:00	1.6	12.0	2,094.5	1.1	8.40	1	1	1
08/27/2020 21:00	1.7	11.9	2,115.9	1.1	8.50	1	1	1
08/27/2020 22:00	1.6	11.9	2,115.0	1.0	8.50	1	1	1
08/27/2020 23:00	1.6	12.4	2,008.0	1.1	8.00	1	1	1
Average/Sum#:	1.6	12.3	2,033.2	1.1	195.30 #	24 #	24 #	24 #
Minimum:	1.4	11.8	1,924.3	1.0	7.70	1	1	1
Maximum:	1.7	12.9	2,115.9	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/28/2020 00:00	1.5	12.8	1,915.3	1.1	7.70	1	1	1
08/28/2020 01:00	0.9	13.8	1,514.1	0.7	4.50	1	1	0
08/28/2020 02:00	0.7	13.9	1,443.2	0.6	2.90	1	1	0
08/28/2020 03:00	0.6	13.9	1,285.5	0.5	2.60	1	1	0
08/28/2020 04:00	0.8	13.9	1,467.2	0.7	2.90	1	1	0
08/28/2020 05:00	0.9	13.9	1,589.7	0.8	4.80	1	1	0
08/28/2020 06:00	0.7	13.9	1,449.3	0.6	2.90	1	1	0
08/28/2020 07:00	0.7	13.9	1,371.8	0.6	2.70	1	1	0
08/28/2020 08:00	0.8	13.9	1,392.1	0.7	2.80	1	1	0
08/28/2020 09:00	0.8	13.9	1,422.3	0.7	2.80	1	1	0
08/28/2020 10:00	0.8	13.9	1,456.5	0.7	2.90	1	1	0
08/28/2020 11:00	0.9	13.9	1,505.7	0.8	4.50	1	1	1
08/28/2020 12:00	1.5	12.3	1,993.4	1.0	8.00	1	1	1
08/28/2020 13:00	1.6	11.9	2,066.0	1.0	8.30	1	1	1
08/28/2020 14:00	1.6	11.9	2,061.2	1.0	8.20	1	1	1
08/28/2020 15:00	1.6	11.9	2,060.2	1.0	8.20	1	1	1
08/28/2020 16:00	1.7	11.9	2,062.4	1.1	8.20	1	1	1
08/28/2020 17:00	1.7	11.9	2,051.9	1.1	8.20	1	1	1
08/28/2020 18:00	1.6	12.0	2,051.4	1.1	8.20	1	1	1
08/28/2020 19:00	1.6	12.3	2,002.0	1.1	8.00	1	1	1
08/28/2020 20:00	1.6	12.3	1,995.3	1.1	8.00	1	1	1
08/28/2020 21:00	1.6	12.4	1,993.7	1.1	8.00	1	1	1
08/28/2020 22:00	1.5	12.5	1,963.5	1.1	7.90	1	1	1
08/28/2020 23:00	1.6	12.2	2,034.4	1.1	8.10	1	1	1
Average/Sum#:	1.2	13.0	1,756.2	0.9	141.30 #	24 #	24 #	14 #
Minimum:	0.6	11.9	1,285.5	0.5	2.60	1	1	0
Maximum:	1.7	13.9	2,066.0	1.1	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOX, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/29/2020 00:00	1.6	12.2	2,040.2	1.1	8.20	1	1	1
08/29/2020 01:00	1.6	12.3	2,038.1	1.1	8.20	1	1	1
08/29/2020 02:00	1.6	12.4	2,019.7	1.1	8.10	1	1	1
08/29/2020 03:00	1.5	12.7	1,925.4	1.1	7.70	1	1	1
08/29/2020 04:00	1.0	13.8	1,598.5	0.8	4.80	1	1	0
08/29/2020 05:00	0.9	13.8	1,578.3	0.7	4.70	1	1	0
08/29/2020 06:00	1.0	13.8	1,551.9	0.8	4.70	1	1	0
08/29/2020 07:00	0.8	13.8	1,422.5	0.7	2.80	1	1	0
08/29/2020 08:00	0.8	13.9	1,376.4	0.7	2.80	1	1	0
08/29/2020 09:00	0.7	13.9	1,280.9	0.6	2.60	1	1	0
08/29/2020 10:00	0.7	13.9	1,293.5	0.6	2.60	1	1	0
08/29/2020 11:00	0.8	13.9	1,327.6	0.7	2.70	1	1	0
08/29/2020 12:00	0.7	13.9	1,286.3	0.6	2.60	1	1	0
08/29/2020 13:00	1.1	13.9	1,589.7	0.9	4.80	1	1	0
08/29/2020 14:00	1.1	13.8	1,596.4	0.9	4.80	1	1	0
08/29/2020 15:00	1.1	13.8	1,604.2	0.9	4.80	1	1	0
08/29/2020 16:00	1.1	13.8	1,652.1	0.9	5.00	1	1	1
08/29/2020 17:00	1.6	12.2	2,022.2	1.1	8.10	1	1	1
08/29/2020 18:00	1.6	11.9	2,060.2	1.0	8.20	1	1	1
08/29/2020 19:00	1.6	12.0	2,061.8	1.1	8.20	1	1	1
08/29/2020 20:00	1.6	11.8	2,106.0	1.0	8.40	1	1	1
08/29/2020 21:00	1.6	11.9	2,083.8	1.0	8.30	1	1	1
08/29/2020 22:00	1.6	12.4	1,992.5	1.1	8.00	1	1	1
08/29/2020 23:00	1.6	12.5	1,988.3	1.1	8.00	1	1	1
Average/Sum#:	1.2	13.1	1,729.0	0.9	139.10 #	24 #	24 #	12 #
Minimum:	0.7	11.8	1,280.9	0.6	2.60	1	1	0
Maximum:	1.6	13.9	2,106.0	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/30/2020 00:00	1.5	12.8	1,911.7	1.1	7.60	1	1	1
08/30/2020 01:00	1.2	13.7	1,739.2	1.0	7.00	1	1	0
08/30/2020 02:00	1.2	13.7	1,742.8	1.0	7.00	1	1	0
08/30/2020 03:00	1.2	13.7	1,744.6	1.0	7.00	1	1	0
08/30/2020 04:00	1.2	13.7	1,744.5	1.0	7.00	1	1	0
08/30/2020 05:00	1.2	13.7	1,749.0	1.0	7.00	1	1	0
08/30/2020 06:00	1.1	13.7	1,743.9	0.9	5.20	1	1	0
08/30/2020 07:00	1.1	13.7	1,738.2	0.9	5.20	1	1	0
08/30/2020 08:00	1.2	13.7	1,746.3	1.0	7.00	1	1	0
08/30/2020 09:00	1.3	13.6	1,745.0	1.1	7.00	1	1	0
08/30/2020 10:00	1.3	13.6	1,736.1	1.1	6.90	1	1	0
08/30/2020 11:00	1.3	13.6	1,726.9	1.1	6.90	1	1	0
08/30/2020 12:00	1.3	13.6	1,718.3	1.1	6.90	1	1	0
08/30/2020 13:00	1.1	13.7	1,621.7	0.9	4.90	1	1	0
08/30/2020 14:00	1.0	13.8	1,533.0	0.8	4.60	1	1	1
08/30/2020 15:00	1.6	12.1	2,037.2	1.1	8.10	1	1	1
08/30/2020 16:00	1.7	11.8	2,104.1	1.1	8.40	1	1	1
08/30/2020 17:00	1.6	12.0	2,065.7	1.1	8.30	1	1	1
08/30/2020 18:00	1.6	12.1	2,045.5	1.1	8.20	1	1	1
08/30/2020 19:00	1.6	12.3	2,013.0	1.1	8.10	1	1	1
08/30/2020 20:00	1.6	12.3	2,007.3	1.1	8.00	1	1	1
08/30/2020 21:00	1.6	12.4	2,003.0	1.1	8.00	1	1	1
08/30/2020 22:00	1.6	12.4	1,998.5	1.1	8.00	1	1	1
08/30/2020 23:00	1.5	12.7	1,919.1	1.1	7.70	1	1	1
Average/Sum#:	1.4	13.1	1,838.9	1.0	170.00 #	24 #	24 #	11 #
Minimum:	1.0	11.8	1,533.0	0.8	4.60	1	1	0
Maximum:	1.7	13.8	2,104.1	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/31/2020 00:00	1.0	13.8	1,609.2	0.8	4.80	1	1	0
08/31/2020 01:00	0.7	13.9	1,299.3	0.6	2.60	1	1	0
08/31/2020 02:00	0.7	13.9	1,285.5	0.6	2.60	1	1	0
08/31/2020 03:00	0.7	13.9	1,296.5	0.6	2.60	1	1	0
08/31/2020 04:00	1.0	13.8	1,632.0	0.8	4.90	1	1	0
08/31/2020 05:00	1.0	13.8	1,662.9	0.8	5.00	1	1	0
08/31/2020 06:00	1.1	13.8	1,685.2	0.9	5.10	1	1	0
08/31/2020 07:00	0.8	13.9	1,381.8	0.7	2.80	1	1	0
08/31/2020 08:00	0.8	13.9	1,404.7	0.7	2.80	1	1	0
08/31/2020 09:00	0.7	14.0	1,310.4	0.6	2.60	1	1	0
08/31/2020 10:00	0.6	14.0	1,299.2	0.5	2.60	1	1	0
08/31/2020 11:00	0.8	14.0	1,500.0	0.7	4.50	1	1	0
08/31/2020 12:00	0.8	13.9	1,474.2	0.7	2.90	1	1	0
08/31/2020 13:00	1.5	12.3	2,014.8	1.0	8.10	1	1	1
08/31/2020 14:00	1.6	11.9	2,114.8	1.0	8.50	1	1	1
08/31/2020 15:00	1.6	11.8	2,106.2	1.0	8.40	1	1	1
08/31/2020 16:00	1.6	12.2	2,028.6	1.1	8.10	1	1	1
08/31/2020 17:00	1.6	12.4	2,006.2	1.1	8.00	1	1	1
08/31/2020 18:00	1.6	12.4	2,003.4	1.1	8.00	1	1	1
08/31/2020 19:00	1.6	12.4	1,998.8	1.1	8.00	1	1	1
08/31/2020 20:00	1.6	12.4	1,995.8	1.1	8.00	1	1	1
08/31/2020 21:00	1.6	12.5	1,993.9	1.1	8.00	1	1	1
08/31/2020 22:00	1.5	12.5	1,991.8	1.1	8.00	1	1	1
08/31/2020 23:00	1.4	13.0	1,777.2	1.0	7.10	1	1	1
Average/Sum#:	1.2	13.2	1,703.0	0.9	134.00 #	24 #	24 #	11 #
Minimum:	0.6	11.8	1,285.5	0.5	2.60	1	1	0
Maximum:	1.6	14.0	2,114.8	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/01/2020 00:00	0.7	13.9	1,295.3	0.6	2.60	1	1	0
09/01/2020 01:00	0.8	13.9	1,492.9	0.7	3.00	1	1	0
09/01/2020 02:00	0.7	14.0	1,388.5	0.6	2.80	1	1	0
09/01/2020 03:00	0.7	14.0	1,297.5	0.6	2.60	1	1	0
09/01/2020 04:00	0.7	14.0	1,345.1	0.6	2.70	1	1	0
09/01/2020 05:00	1.1	13.8	1,663.8	0.9	5.00	1	1	0
09/01/2020 06:00	1.0	13.8	1,650.7	0.8	5.00	1	1	0
09/01/2020 07:00	1.0	13.8	1,671.7	0.8	5.00	1	1	0
09/01/2020 08:00	0.9	13.8	1,592.9	0.7	4.80	1	1	0
09/01/2020 09:00	1.0	13.8	1,620.6	0.8	4.90	1	1	0
09/01/2020 10:00	0.9	13.8	1,479.3	0.7	4.40	1	1	0
09/01/2020 11:00	0.6	14.0	1,309.3	0.5	2.60	1	1	0
09/01/2020 12:00	0.6	14.0	1,338.3	0.5	2.70	1	1	0
09/01/2020 13:00	0.8	14.0	1,486.0	0.7	4.50	1	1	0
09/01/2020 14:00	1.0	13.8	1,645.6	0.8	4.90	1	1	0
09/01/2020 15:00	1.0	13.8	1,613.3	0.8	4.80	1	1	0
09/01/2020 16:00	1.0	13.8	1,535.0	0.8	4.60	1	1	1
09/01/2020 17:00	1.5	12.2	2,024.7	1.0	8.10	1	1	1
09/01/2020 18:00	1.7	11.8	2,100.8	1.1	8.40	1	1	1
09/01/2020 19:00	1.6	11.9	2,078.1	1.0	8.30	1	1	1
09/01/2020 20:00	1.6	12.4	1,995.8	1.1	8.00	1	1	1
09/01/2020 21:00	1.5	12.5	1,986.9	1.1	7.90	1	1	1
09/01/2020 22:00	1.5	12.8	1,931.4	1.1	7.70	1	1	1
09/01/2020 23:00	1.3	13.2	1,771.7	1.0	7.10	1	1	1
Average/Sum#:	1.1	13.5	1,638.1	0.8	122.40 #	24 #	24 #	8 #
Minimum:	0.6	11.8	1,295.3	0.5	2.60	1	1	0
Maximum:	1.7	14.0	2,100.8	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/02/2020 00:00	0.6	13.9	1,282.2	0.5	2.60	1	1	0
09/02/2020 01:00	0.6	13.9	1,277.4	0.5	2.60	1	1	0
09/02/2020 02:00	0.6	13.9	1,294.5	0.5	2.60	1	1	0
09/02/2020 03:00	0.6	13.9	1,288.3	0.5	2.60	1	1	0
09/02/2020 04:00	0.6	13.9	1,312.6	0.5	2.60	1	1	0
09/02/2020 05:00	0.6	13.9	1,279.0	0.5	2.60	1	1	0
09/02/2020 06:00	0.6	13.9	1,286.2	0.5	2.60	1	1	0
09/02/2020 07:00	1.9	14.8	943.4	1.8	2.84	1	0	0
09/02/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.8	14.0	1,245.5	0.7	21.04 #	8 #	7 #	0 #
Minimum:	0.6	13.9	943.4	0.5	2.60	0	0	0
Maximum:	1.9	14.8	1,312.6	1.8	2.84	1	1	0
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/03/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2020 03:00	22.5	17.8	416.5	42.8	29.61	1	0	0
09/03/2020 04:00	15.8	15.1	986.1	16.1	58.20	1	0	0
09/03/2020 05:00	0.8	13.8	1,569.2	0.7	3.10	1	1	0
09/03/2020 06:00	0.8	13.8	1,582.8	0.7	3.20	1	1	0
09/03/2020 07:00	0.9	13.8	1,640.8	0.7	4.90	1	1	0
09/03/2020 08:00	0.8	13.8	1,636.3	0.7	3.30	1	1	0
09/03/2020 09:00	0.8	13.9	1,532.0	0.7	3.10	1	1	0
09/03/2020 10:00	0.9	13.9	1,572.1	0.8	4.70	1	1	0
09/03/2020 11:00	0.9	13.8	1,522.4	0.7	4.60	1	1	1
09/03/2020 12:00	1.5	12.2	2,044.8	1.0	8.20	1	1	1
09/03/2020 13:00	1.7	11.9	2,092.8	1.1	8.40	1	1	1
09/03/2020 14:00	1.6	12.0	2,057.6	1.1	8.20	1	1	1
09/03/2020 15:00	1.7	11.8	2,089.3	1.1	8.40	1	1	1
09/03/2020 16:00	1.7	11.8	2,089.4	1.1	8.40	1	1	1
09/03/2020 17:00	1.7	11.8	2,093.2	1.1	8.40	1	1	1
09/03/2020 18:00	1.7	11.8	2,096.0	1.1	8.40	1	1	1
09/03/2020 19:00	1.6	12.0	2,054.4	1.1	8.20	1	1	1
09/03/2020 20:00	1.6	12.3	1,995.8	1.1	8.00	1	1	1
09/03/2020 21:00	1.6	12.3	1,997.3	1.1	8.00	1	1	1
09/03/2020 22:00	1.6	12.2	2,029.0	1.1	8.10	1	1	1
09/03/2020 23:00	1.7	11.9	2,096.6	1.1	8.40	1	1	1
Average/Sum#:	3.0	13.0	1,771.2	3.7	213.81 #	21 #	19 #	13 #
Minimum:	0.8	11.8	416.5	0.7	3.10	0	0	0
Maximum:	22.5	17.8	2,096.6	42.8	58.20	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/04/2020 00:00	1.5	12.4	2,011.2	1.0	8.00	1	1	1
09/04/2020 01:00	1.5	12.5	1,980.2	1.1	7.90	1	1	1
09/04/2020 02:00	1.5	12.5	1,981.1	1.1	7.90	1	1	1
09/04/2020 03:00	1.5	12.6	1,983.8	1.1	7.90	1	1	1
09/04/2020 04:00	1.6	12.0	2,104.0	1.1	8.40	1	1	1
09/04/2020 05:00	1.6	11.9	2,127.7	1.0	8.50	1	1	1
09/04/2020 06:00	1.5	12.0	2,107.3	1.0	8.40	1	1	1
09/04/2020 07:00	1.6	12.0	2,095.1	1.1	8.40	1	1	1
09/04/2020 08:00	1.6	12.4	2,016.9	1.1	8.10	1	1	1
09/04/2020 09:00	1.5	12.5	1,983.2	1.1	7.90	1	1	1
09/04/2020 10:00	1.6	12.1	2,041.7	1.1	8.20	1	1	1
09/04/2020 11:00	1.6	12.0	2,065.9	1.1	8.30	1	1	1
09/04/2020 12:00	1.6	11.9	2,071.3	1.0	8.30	1	1	1
09/04/2020 13:00	1.7	11.9	2,072.3	1.1	8.30	1	1	1
09/04/2020 14:00	1.7	11.9	2,077.4	1.1	8.30	1	1	1
09/04/2020 15:00	1.7	11.8	2,077.0	1.1	8.30	1	1	1
09/04/2020 16:00	1.7	11.8	2,076.8	1.1	8.30	1	1	1
09/04/2020 17:00	1.7	11.8	2,080.4	1.1	8.30	1	1	1
09/04/2020 18:00	1.7	11.8	2,088.3	1.1	8.40	1	1	1
09/04/2020 19:00	1.7	11.8	2,093.8	1.1	8.40	1	1	1
09/04/2020 20:00	1.7	11.8	2,097.4	1.1	8.40	1	1	1
09/04/2020 21:00	1.7	11.9	2,081.3	1.1	8.30	1	1	1
09/04/2020 22:00	1.6	12.0	2,082.2	1.1	8.30	1	1	1
09/04/2020 23:00	1.6	12.3	2,021.0	1.1	8.10	1	1	1
Average/Sum#:	1.6	12.1	2,059.1	1.1	197.60 #	24 #	24 #	24 #
Minimum:	1.5	11.8	1,980.2	1.0	7.90	1	1	1
Maximum:	1.7	12.6	2,127.7	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/05/2020 00:00	1.5	12.4	1,996.9	1.0	8.00	1	1	1
09/05/2020 01:00	1.5	12.4	1,996.3	1.0	8.00	1	1	1
09/05/2020 02:00	1.5	12.4	1,996.8	1.0	8.00	1	1	1
09/05/2020 03:00	1.5	12.4	1,997.8	1.0	8.00	1	1	1
09/05/2020 04:00	1.5	12.4	2,010.4	1.0	8.00	1	1	1
09/05/2020 05:00	1.6	12.4	1,978.8	1.1	7.90	1	1	1
09/05/2020 06:00	0.9	13.8	1,639.9	0.7	4.90	1	1	0
09/05/2020 07:00	0.9	13.8	1,568.3	0.7	4.70	1	1	0
09/05/2020 08:00	0.9	13.8	1,612.8	0.7	4.80	1	1	0
09/05/2020 09:00	0.9	13.8	1,592.3	0.7	4.80	1	1	0
09/05/2020 10:00	1.0	13.8	1,621.0	0.8	4.90	1	1	1
09/05/2020 11:00	1.5	12.2	2,025.4	1.0	8.10	1	1	1
09/05/2020 12:00	1.7	11.8	2,086.7	1.1	8.30	1	1	1
09/05/2020 13:00	1.7	11.8	2,091.8	1.1	8.40	1	1	1
09/05/2020 14:00	1.7	11.8	2,092.9	1.1	8.40	1	1	1
09/05/2020 15:00	1.7	11.7	2,084.3	1.1	8.30	1	1	1
09/05/2020 16:00	1.7	11.7	2,078.5	1.1	8.30	1	1	1
09/05/2020 17:00	1.7	11.7	2,087.3	1.1	8.30	1	1	1
09/05/2020 18:00	1.7	11.8	2,089.9	1.1	8.40	1	1	1
09/05/2020 19:00	1.7	11.8	2,095.1	1.1	8.40	1	1	1
09/05/2020 20:00	1.7	11.8	2,100.4	1.1	8.40	1	1	1
09/05/2020 21:00	1.7	11.8	2,109.4	1.1	8.40	1	1	1
09/05/2020 22:00	1.7	11.8	2,117.7	1.1	8.50	1	1	1
09/05/2020 23:00	1.6	12.0	2,071.7	1.1	8.30	1	1	1
Average/Sum#:	1.5	12.4	1,964.3	1.0	180.50 #	24 #	24 #	20 #
Minimum:	0.9	11.7	1,568.3	0.7	4.70	1	1	0
Maximum:	1.7	13.8	2,117.7	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/06/2020 00:00	1.7	12.0	2,093.1	1.1	8.40	1	1	1
09/06/2020 01:00	1.6	12.2	2,049.0	1.1	8.20	1	1	1
09/06/2020 02:00	1.7	12.0	2,098.3	1.1	8.40	1	1	1
09/06/2020 03:00	1.7	11.9	2,113.8	1.1	8.50	1	1	1
09/06/2020 04:00	1.6	12.3	2,035.4	1.1	8.10	1	1	1
09/06/2020 05:00	1.6	12.4	2,020.5	1.1	8.10	1	1	1
09/06/2020 06:00	1.5	12.8	1,965.9	1.1	7.90	1	1	1
09/06/2020 07:00	1.6	12.2	2,070.9	1.1	8.30	1	1	1
09/06/2020 08:00	1.6	12.0	2,086.9	1.1	8.30	1	1	1
09/06/2020 09:00	1.6	12.0	2,092.4	1.1	8.40	1	1	1
09/06/2020 10:00	1.7	11.9	2,081.9	1.1	8.30	1	1	1
09/06/2020 11:00	1.6	11.9	2,078.0	1.0	8.30	1	1	1
09/06/2020 12:00	1.6	11.8	2,078.3	1.0	8.30	1	1	1
09/06/2020 13:00	1.6	11.8	2,079.9	1.0	8.30	1	1	1
09/06/2020 14:00	1.7	11.8	2,082.4	1.1	8.30	1	1	1
09/06/2020 15:00	1.7	11.8	2,080.6	1.1	8.30	1	1	1
09/06/2020 16:00	1.6	12.0	2,028.6	1.1	8.10	1	1	1
09/06/2020 17:00	1.7	11.8	2,069.5	1.1	8.30	1	1	1
09/06/2020 18:00	1.7	11.9	2,062.2	1.1	8.20	1	1	1
09/06/2020 19:00	1.6	12.0	2,043.3	1.1	8.20	1	1	1
09/06/2020 20:00	1.6	12.1	2,044.6	1.1	8.20	1	1	1
09/06/2020 21:00	1.6	12.0	2,081.7	1.1	8.30	1	1	1
09/06/2020 22:00	1.7	11.9	2,104.0	1.1	8.40	1	1	1
09/06/2020 23:00	1.7	11.8	2,102.0	1.1	8.40	1	1	1
Average/Sum#:	1.6	12.0	2,068.5	1.1	198.50 #	24 #	24 #	24 #
Minimum:	1.5	11.8	1,965.9	1.0	7.90	1	1	1
Maximum:	1.7	12.8	2,113.8	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/07/2020 00:00	1.7	11.8	2,102.5	1.1	8.40	1	1	1
09/07/2020 01:00	1.6	11.9	2,111.4	1.0	8.40	1	1	1
09/07/2020 02:00	1.7	11.9	2,111.5	1.1	8.40	1	1	1
09/07/2020 03:00	1.6	12.1	2,059.3	1.1	8.20	1	1	1
09/07/2020 04:00	1.6	12.4	2,009.9	1.1	8.00	1	1	1
09/07/2020 05:00	1.6	12.3	2,008.6	1.1	8.00	1	1	1
09/07/2020 06:00	0.7	13.9	1,585.5	0.6	3.20	1	1	0
09/07/2020 07:00	0.8	14.0	1,586.7	0.7	4.80	1	1	0
09/07/2020 08:00	0.9	14.0	1,603.4	0.8	4.80	1	1	0
09/07/2020 09:00	0.8	14.0	1,564.5	0.7	4.70	1	1	0
09/07/2020 10:00	0.8	13.9	1,503.8	0.7	3.00	1	1	0
09/07/2020 11:00	0.8	13.9	1,500.8	0.7	3.00	1	1	1
09/07/2020 12:00	1.4	12.7	1,930.7	1.0	7.70	1	1	1
09/07/2020 13:00	1.4	13.3	1,727.3	1.1	6.90	1	1	1
09/07/2020 14:00	1.2	13.7	1,656.1	1.0	6.60	1	1	0
09/07/2020 15:00	1.2	13.6	1,695.7	1.0	6.80	1	1	0
09/07/2020 16:00	1.3	13.1	1,754.8	1.0	7.00	1	1	1
09/07/2020 17:00	1.6	12.3	1,991.8	1.1	8.00	1	1	1
09/07/2020 18:00	1.6	12.3	1,985.5	1.1	7.90	1	1	1
09/07/2020 19:00	1.6	12.0	2,066.3	1.1	8.30	1	1	1
09/07/2020 20:00	1.6	12.0	2,056.8	1.1	8.20	1	1	1
09/07/2020 21:00	1.6	12.2	2,005.7	1.1	8.00	1	1	1
09/07/2020 22:00	1.6	12.2	2,009.0	1.1	8.00	1	1	1
09/07/2020 23:00	1.6	12.3	2,009.5	1.1	8.00	1	1	1
Average/Sum#:	1.3	12.8	1,859.9	1.0	164.30 #	24 #	24 #	17 #
Minimum:	0.7	11.8	1,500.8	0.6	3.00	1	1	0
Maximum:	1.7	14.0	2,111.5	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/08/2020 00:00	1.6	12.3	2,013.9	1.1	8.10	1	1	1
09/08/2020 01:00	1.6	12.2	2,058.6	1.1	8.20	1	1	1
09/08/2020 02:00	1.6	12.2	2,046.0	1.1	8.20	1	1	1
09/08/2020 03:00	1.6	12.0	2,099.6	1.1	8.40	1	1	1
09/08/2020 04:00	1.6	12.3	2,054.2	1.1	8.20	1	1	1
09/08/2020 05:00	1.5	12.4	2,022.9	1.0	8.10	1	1	1
09/08/2020 06:00	0.9	13.9	1,627.5	0.8	4.90	1	1	0
09/08/2020 07:00	0.9	14.0	1,629.4	0.8	4.90	1	1	0
09/08/2020 08:00	0.7	14.0	1,506.0	0.6	3.00	1	1	0
09/08/2020 09:00	1.0	13.9	1,624.4	0.8	4.90	1	1	0
09/08/2020 10:00	0.9	14.0	1,567.9	0.8	4.70	1	1	0
09/08/2020 11:00	1.0	13.9	1,679.8	0.8	5.00	1	1	0
09/08/2020 12:00	0.9	13.9	1,531.8	0.8	4.60	1	1	1
09/08/2020 13:00	1.5	12.4	2,040.3	1.0	8.20	1	1	1
09/08/2020 14:00	1.6	12.0	2,116.2	1.1	8.50	1	1	1
09/08/2020 15:00	1.6	11.9	2,119.9	1.0	8.50	1	1	1
09/08/2020 16:00	1.6	11.9	2,121.3	1.0	8.50	1	1	1
09/08/2020 17:00	1.6	11.9	2,127.9	1.0	8.50	1	1	1
09/08/2020 18:00	1.6	11.9	2,133.9	1.0	8.50	1	1	1
09/08/2020 19:00	1.6	12.2	2,075.5	1.1	8.30	1	1	1
09/08/2020 20:00	1.6	12.3	2,061.0	1.1	8.20	1	1	1
09/08/2020 21:00	1.6	12.3	2,069.6	1.1	8.30	1	1	1
09/08/2020 22:00	1.5	12.6	2,016.3	1.1	8.10	1	1	1
09/08/2020 23:00	1.6	12.5	2,019.1	1.1	8.10	1	1	1
Average/Sum#:	1.4	12.7	1,931.8	1.0	172.90 #	24 #	24 #	18 #
Minimum:	0.7	11.9	1,506.0	0.6	3.00	1	1	0
Maximum:	1.6	14.0	2,133.9	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOX, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOX, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/09/2020 00:00	1.4	12.6	1,928.1	1.0	7.70	1	1	1
09/09/2020 01:00	1.2	13.9	1,662.9	1.0	6.70	1	1	0
09/09/2020 02:00	0.7	14.1	1,392.9	0.6	2.80	1	1	0
09/09/2020 03:00	1.0	14.0	1,656.6	0.9	5.00	1	1	0
09/09/2020 04:00	0.7	14.0	1,498.8	0.6	3.00	1	1	0
09/09/2020 05:00	0.7	14.0	1,572.3	0.6	3.10	1	1	0
09/09/2020 06:00	0.7	14.0	1,574.7	0.6	3.10	1	1	0
09/09/2020 07:00	0.7	14.0	1,551.0	0.6	3.10	1	1	0
09/09/2020 08:00	0.7	14.0	1,507.7	0.6	3.00	1	1	0
09/09/2020 09:00	0.6	14.1	1,430.9	0.5	2.90	1	1	0
09/09/2020 10:00	0.6	14.1	1,418.0	0.5	2.80	1	1	0
09/09/2020 11:00	0.7	14.0	1,490.1	0.6	3.00	1	1	0
09/09/2020 12:00	0.8	14.0	1,512.7	0.7	4.50	1	1	1
09/09/2020 13:00	1.5	12.5	2,054.2	1.1	8.20	1	1	1
09/09/2020 14:00	1.5	12.5	2,024.4	1.1	8.10	1	1	1
09/09/2020 15:00	1.5	12.6	1,999.6	1.1	8.00	1	1	1
09/09/2020 16:00	1.5	12.6	1,991.4	1.1	8.00	1	1	1
09/09/2020 17:00	1.5	12.6	1,989.7	1.1	8.00	1	1	1
09/09/2020 18:00	1.5	12.7	1,989.7	1.1	8.00	1	1	1
09/09/2020 19:00	1.5	12.7	1,992.4	1.1	8.00	1	1	1
09/09/2020 20:00	1.5	12.7	1,995.2	1.1	8.00	1	1	1
09/09/2020 21:00	1.5	12.8	1,990.1	1.1	8.00	1	1	1
09/09/2020 22:00	1.5	12.8	1,990.6	1.1	8.00	1	1	1
09/09/2020 23:00	1.4	13.0	1,919.1	1.0	7.70	1	1	1
Average/Sum#:	1.1	13.3	1,755.5	0.9	138.70 #	24 #	24 #	13 #
Minimum:	0.6	12.5	1,392.9	0.5	2.80	1	1	0
Maximum:	1.5	14.1	2,054.2	1.1	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/10/2020 00:00	0.8	13.9	1,511.8	0.7	3.00	1	1	0
09/10/2020 01:00	0.7	13.9	1,485.8	0.6	3.00	1	1	0
09/10/2020 02:00	0.6	14.0	1,308.9	0.5	2.60	1	1	0
09/10/2020 03:00	0.7	13.9	1,587.5	0.6	3.20	1	1	0
09/10/2020 04:00	0.7	13.9	1,557.7	0.6	3.10	1	1	0
09/10/2020 05:00	0.7	13.9	1,551.4	0.6	3.10	1	1	0
09/10/2020 06:00	0.8	13.9	1,600.0	0.7	3.20	1	1	0
09/10/2020 07:00	0.7	13.9	1,637.2	0.6	3.30	1	1	0
09/10/2020 08:00	0.8	13.9	1,672.9	0.7	3.30	1	1	0
09/10/2020 09:00	0.8	14.0	1,617.4	0.7	4.90	1	1	0
09/10/2020 10:00	0.8	13.9	1,673.4	0.7	3.30	1	1	0
09/10/2020 11:00	0.7	14.0	1,468.0	0.6	2.90	1	1	0
09/10/2020 12:00	0.7	14.0	1,444.0	0.6	2.90	1	1	0
09/10/2020 13:00	0.7	14.0	1,453.9	0.6	2.90	1	1	0
09/10/2020 14:00	0.9	13.9	1,596.3	0.8	4.80	1	1	0
09/10/2020 15:00	0.9	13.9	1,565.1	0.8	4.70	1	1	1
09/10/2020 16:00	1.5	12.4	2,032.2	1.0	8.10	1	1	1
09/10/2020 17:00	1.5	12.5	2,014.2	1.1	8.10	1	1	1
09/10/2020 18:00	1.5	12.6	1,992.7	1.1	8.00	1	1	1
09/10/2020 19:00	1.5	12.6	1,990.1	1.1	8.00	1	1	1
09/10/2020 20:00	1.5	12.7	1,987.7	1.1	8.00	1	1	1
09/10/2020 21:00	1.5	12.8	1,984.7	1.1	7.90	1	1	1
09/10/2020 22:00	1.5	12.7	1,982.2	1.1	7.90	1	1	1
09/10/2020 23:00	1.4	13.2	1,831.4	1.1	7.30	1	1	1
Average/Sum#:	1.0	13.5	1,689.4	0.8	117.50 #	24 #	24 #	9 #
Minimum:	0.6	12.4	1,308.9	0.5	2.60	1	1	0
Maximum:	1.5	14.0	2,032.2	1.1	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOX, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/11/2020 00:00	0.8	13.9	1,409.2	0.7	2.80	1	1	0
09/11/2020 01:00	0.6	13.9	1,287.7	0.5	2.60	1	1	0
09/11/2020 02:00	0.6	13.9	1,286.4	0.5	2.60	1	1	0
09/11/2020 03:00	0.6	13.9	1,285.5	0.5	2.60	1	1	0
09/11/2020 04:00	0.6	13.9	1,286.7	0.5	2.60	1	1	0
09/11/2020 05:00	0.7	13.9	1,479.1	0.6	3.00	1	1	0
09/11/2020 06:00	0.6	14.0	1,292.3	0.5	2.60	1	1	0
09/11/2020 07:00	0.6	14.0	1,318.9	0.5	2.60	1	1	0
09/11/2020 08:00	0.6	14.0	1,342.0	0.5	2.70	1	1	0
09/11/2020 09:00	0.7	13.9	1,566.1	0.6	3.10	1	1	0
09/11/2020 10:00	0.7	13.9	1,548.5	0.6	3.10	1	1	0
09/11/2020 11:00	0.8	13.9	1,534.6	0.7	3.10	1	1	0
09/11/2020 12:00	0.9	13.9	1,581.7	0.8	4.70	1	1	0
09/11/2020 13:00	0.6	14.0	1,295.7	0.5	2.60	1	1	0
09/11/2020 14:00	0.6	14.0	1,299.3	0.5	2.60	1	1	0
09/11/2020 15:00	0.7	14.0	1,334.2	0.6	2.70	1	1	0
09/11/2020 16:00	0.9	13.8	1,646.7	0.7	4.90	1	1	0
09/11/2020 17:00	0.9	13.8	1,635.4	0.7	4.90	1	1	0
09/11/2020 18:00	1.2	13.3	1,786.5	0.9	5.40	1	1	1
09/11/2020 19:00	1.5	12.4	2,023.3	1.0	8.10	1	1	1
09/11/2020 20:00	1.5	12.6	1,994.5	1.1	8.00	1	1	1
09/11/2020 21:00	1.5	12.8	1,954.8	1.1	7.80	1	1	1
09/11/2020 22:00	1.0	13.6	1,477.3	0.8	4.40	1	1	1
09/11/2020 23:00	5.1	16.5	368.3	6.8	1.56	1	0	0
Average/Sum#:	1.0	13.8	1,459.8	0.9	91.06 #	24 #	23 #	5 #
Minimum:	0.6	12.4	368.3	0.5	1.56	1	0	0
Maximum:	5.1	16.5	2,023.3	6.8	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOX, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOX, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/12/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2020 17:00	26.8	17.5	450.7	46.5	60.14	1	0	0
09/12/2020 18:00	7.1	17.1	512.4	11.0	21.00	1	0	0
09/12/2020 19:00	10.0	15.5	927.2	10.9	37.10	1	0	0
09/12/2020 20:00	0.7	13.9	1,478.5	0.6	3.00	1	1	0
09/12/2020 21:00	0.8	14.0	1,493.7	0.7	4.50	1	1	0
09/12/2020 22:00	0.8	13.9	1,456.6	0.7	2.90	1	1	0
09/12/2020 23:00	0.7	13.9	1,354.2	0.6	2.70	1	1	0
Average/Sum#:	6.7	15.1	1,096.2	10.1	131.34 #	7 #	4 #	0 #
Minimum:	0.7	13.9	450.7	0.6	2.70	0	0	0
Maximum:	26.8	17.5	1,493.7	46.5	60.14	1	1	0
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/13/2020 00:00	0.6	13.9	1,351.9	0.5	2.70	1	1	0
09/13/2020 01:00	0.6	14.0	1,334.7	0.5	2.70	1	1	0
09/13/2020 02:00	4.6	16.8	311.5	6.6	1.28	1	0	0
09/13/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2020 17:00	24.7	17.4	461.3	41.6	63.54	1	0	0
09/13/2020 18:00	7.0	17.1	514.6	10.9	20.60	1	0	0
09/13/2020 19:00	11.8	15.1	1,019.4	12.0	44.90	1	0	0
09/13/2020 20:00	0.8	13.9	1,474.7	0.7	2.90	1	1	0
09/13/2020 21:00	0.7	13.9	1,382.1	0.6	2.80	1	1	0
09/13/2020 22:00	0.7	13.9	1,377.7	0.6	2.80	1	1	0
09/13/2020 23:00	0.7	13.9	1,342.7	0.6	2.70	1	1	0
Average/Sum#:	5.2	15.0	1,057.1	7.5	146.92 #	10 #	6 #	0 #
Minimum:	0.6	13.9	311.5	0.5	1.28	0	0	0
Maximum:	24.7	17.4	1,474.7	41.6	63.54	1	1	0
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/14/2020 00:00	0.7	13.9	1,341.7	0.6	2.70	1	1	0
09/14/2020 01:00	0.7	13.9	1,326.0	0.6	2.70	1	1	0
09/14/2020 02:00	4.0	16.8	309.0	5.8	1.11	1	0	0
09/14/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2020 09:00	0.5	19.4	181.0	2.0	0.17	1	0	0
09/14/2020 10:00	25.4	16.3	627.1	32.6	75.30	1	0	0
09/14/2020 11:00	4.1	14.1	1,326.1	3.6	17.20	1	0	0
09/14/2020 12:00	0.7	14.0	1,346.6	0.6	2.70	1	1	0
09/14/2020 13:00	1.0	13.9	1,599.4	0.8	4.80	1	1	0
09/14/2020 14:00	0.9	14.0	1,524.2	0.8	4.60	1	1	0
09/14/2020 15:00	1.0	13.9	1,580.1	0.8	4.70	1	1	0
09/14/2020 16:00	1.2	13.2	1,785.1	0.9	5.40	1	1	1
09/14/2020 17:00	1.6	12.0	2,103.7	1.1	8.40	1	1	1
09/14/2020 18:00	1.6	12.0	2,106.2	1.1	8.40	1	1	1
09/14/2020 19:00	1.6	12.1	2,085.4	1.1	8.30	1	1	1
09/14/2020 20:00	1.6	12.0	2,098.9	1.1	8.40	1	1	1
09/14/2020 21:00	1.5	12.4	2,012.9	1.0	8.10	1	1	1
09/14/2020 22:00	1.5	12.8	1,947.3	1.1	7.80	1	1	1
09/14/2020 23:00	1.5	12.8	1,942.6	1.1	7.80	1	1	1
Average/Sum#:	2.8	13.9	1,513.5	3.2	178.58 #	18 #	14 #	8 #
Minimum:	0.5	12.0	181.0	0.6	0.17	0	0	0
Maximum:	25.4	19.4	2,106.2	32.6	75.30	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/15/2020 00:00	0.8	13.9	1,442.8	0.7	2.90	1	1	0
09/15/2020 01:00	0.6	13.9	1,325.8	0.5	2.70	1	1	0
09/15/2020 02:00	0.6	14.0	1,283.9	0.5	2.60	1	1	0
09/15/2020 03:00	0.6	14.0	1,285.0	0.5	2.60	1	1	0
09/15/2020 04:00	0.6	14.0	1,311.6	0.5	2.60	1	1	0
09/15/2020 05:00	0.8	13.9	1,565.6	0.7	3.10	1	1	0
09/15/2020 06:00	0.8	13.9	1,605.4	0.7	3.20	1	1	0
09/15/2020 07:00	0.7	13.9	1,427.6	0.6	2.90	1	1	0
09/15/2020 08:00	0.7	13.9	1,417.1	0.6	2.80	1	1	0
09/15/2020 09:00	0.6	14.0	1,289.6	0.5	2.60	1	1	0
09/15/2020 10:00	0.8	14.0	1,585.9	0.7	4.80	1	1	0
09/15/2020 11:00	0.9	14.0	1,611.7	0.8	4.80	1	1	0
09/15/2020 12:00	1.0	14.0	1,603.2	0.9	4.80	1	1	0
09/15/2020 13:00	1.1	13.8	1,662.7	0.9	5.00	1	1	1
09/15/2020 14:00	1.5	12.2	2,067.7	1.0	8.30	1	1	1
09/15/2020 15:00	1.6	12.1	2,087.9	1.1	8.40	1	1	1
09/15/2020 16:00	1.6	12.4	2,028.3	1.1	8.10	1	1	1
09/15/2020 17:00	1.6	12.4	2,021.6	1.1	8.10	1	1	1
09/15/2020 18:00	1.6	12.4	2,010.5	1.1	8.00	1	1	1
09/15/2020 19:00	1.6	12.4	2,026.9	1.1	8.10	1	1	1
09/15/2020 20:00	1.6	12.0	2,104.4	1.1	8.40	1	1	1
09/15/2020 21:00	1.6	12.3	2,046.6	1.1	8.20	1	1	1
09/15/2020 22:00	2.8	14.1	1,224.9	2.4	5.72	1	0	1
09/15/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.1	13.4	1,653.8	0.9	118.72 #	23 #	22 #	10 #
Minimum:	0.6	12.0	1,224.9	0.5	2.60	0	0	0
Maximum:	2.8	14.1	2,104.4	2.4	8.40	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/16/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2020 11:00	25.6	17.3	492.4	42.0	49.60	1	0	0
09/16/2020 12:00	10.0	14.4	1,209.8	9.1	39.90	1	0	0
09/16/2020 13:00	1.1	13.8	1,665.4	0.9	5.00	1	1	0
09/16/2020 14:00	1.2	13.8	1,665.2	1.0	6.70	1	1	1
09/16/2020 15:00	1.5	12.4	2,040.2	1.0	8.20	1	1	1
09/16/2020 16:00	1.5	12.0	2,089.5	1.0	8.40	1	1	1
09/16/2020 17:00	1.6	11.9	2,121.2	1.0	8.50	1	1	1
09/16/2020 18:00	1.6	12.0	2,108.5	1.1	8.40	1	1	1
09/16/2020 19:00	1.5	12.5	1,998.9	1.1	8.00	1	1	1
09/16/2020 20:00	1.5	12.4	2,015.2	1.0	8.10	1	1	1
09/16/2020 21:00	1.5	12.5	2,008.7	1.1	8.00	1	1	1
09/16/2020 22:00	1.5	12.6	1,991.1	1.1	8.00	1	1	1
09/16/2020 23:00	1.5	12.8	1,932.9	1.1	7.70	1	1	1
Average/Sum#:	4.0	13.1	1,795.3	4.8	174.50 #	13 #	11 #	10 #
Minimum:	1.1	11.9	492.4	0.9	5.00	0	0	0
Maximum:	25.6	17.3	2,121.2	42.0	49.60	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/17/2020 00:00	0.7	13.9	1,401.0	0.6	2.80	1	1	0
09/17/2020 01:00	0.6	13.9	1,307.6	0.5	2.60	1	1	0
09/17/2020 02:00	0.6	13.9	1,288.0	0.5	2.60	1	1	0
09/17/2020 03:00	0.6	13.9	1,288.8	0.5	2.60	1	1	0
09/17/2020 04:00	0.6	13.9	1,458.7	0.5	2.90	1	1	0
09/17/2020 05:00	0.7	13.9	1,568.9	0.6	3.10	1	1	0
09/17/2020 06:00	0.7	13.9	1,535.0	0.6	3.10	1	1	0
09/17/2020 07:00	0.8	13.8	1,613.9	0.7	3.20	1	1	0
09/17/2020 08:00	0.7	13.8	1,587.1	0.6	3.20	1	1	0
09/17/2020 09:00	0.8	13.9	1,601.9	0.7	3.20	1	1	0
09/17/2020 10:00	0.7	13.9	1,416.0	0.6	2.80	1	1	0
09/17/2020 11:00	0.7	13.9	1,423.0	0.6	2.80	1	1	0
09/17/2020 12:00	1.0	13.9	1,616.6	0.8	4.80	1	1	1
09/17/2020 13:00	1.5	12.2	2,068.0	1.0	8.30	1	1	1
09/17/2020 14:00	1.7	11.8	2,118.9	1.1	8.50	1	1	1
09/17/2020 15:00	1.7	11.8	2,114.4	1.1	8.50	1	1	1
09/17/2020 16:00	1.7	11.8	2,109.3	1.1	8.40	1	1	1
09/17/2020 17:00	1.6	12.0	2,077.6	1.1	8.30	1	1	1
09/17/2020 18:00	1.6	12.3	2,022.5	1.1	8.10	1	1	1
09/17/2020 19:00	1.6	12.1	2,079.4	1.1	8.30	1	1	1
09/17/2020 20:00	1.6	12.4	2,023.4	1.1	8.10	1	1	1
09/17/2020 21:00	1.5	12.4	2,033.9	1.0	8.10	1	1	1
09/17/2020 22:00	1.6	12.2	2,071.3	1.1	8.30	1	1	1
09/17/2020 23:00	2.6	12.6	1,769.1	1.8	12.40	1	0	1
Average/Sum#:	1.2	13.1	1,733.1	0.9	135.00 #	24 #	23 #	12 #
Minimum:	0.6	11.8	1,288.0	0.5	2.60	1	0	0
Maximum:	2.6	13.9	2,118.9	1.8	12.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/18/2020 00:00	0.3	19.0	0.2	0.9	0.00	1	0	0
09/18/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2020 10:00	9.9	18.5	329.7	24.3	6.83	1	0	0
09/18/2020 11:00	22.0	15.5	834.3	24.0	74.30	1	0	0
09/18/2020 12:00	0.8	13.8	1,606.4	0.7	3.20	1	1	0
09/18/2020 13:00	0.9	13.8	1,530.2	0.7	4.60	1	1	1
09/18/2020 14:00	1.5	12.5	2,003.3	1.1	8.00	1	1	1
09/18/2020 15:00	1.6	12.3	2,043.1	1.1	8.20	1	1	1
09/18/2020 16:00	1.6	12.4	2,030.4	1.1	8.10	1	1	1
09/18/2020 17:00	1.5	12.5	2,012.8	1.1	8.10	1	1	1
09/18/2020 18:00	1.5	12.5	2,008.6	1.1	8.00	1	1	1
09/18/2020 19:00	1.5	12.6	1,999.6	1.1	8.00	1	1	1
09/18/2020 20:00	1.5	12.6	1,996.1	1.1	8.00	1	1	1
09/18/2020 21:00	1.5	12.6	1,993.1	1.1	8.00	1	1	1
09/18/2020 22:00	2.6	13.7	1,457.5	2.1	9.01	1	0	1
09/18/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	3.5	13.9	1,560.4	4.4	162.34 #	14 #	10 #	10 #
Minimum:	0.3	12.3	0.2	0.7	0.00	0	0	0
Maximum:	22.0	19.0	2,043.1	24.3	74.30	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/19/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2020 13:00	23.4	17.9	411.0	46.0	30.06	1	0	0
09/19/2020 14:00	20.3	15.5	857.3	22.2	70.30	1	0	0
09/19/2020 15:00	0.7	13.9	1,530.7	0.6	3.10	1	1	1
09/19/2020 16:00	1.5	12.5	2,012.4	1.1	8.00	1	1	1
09/19/2020 17:00	1.6	11.9	2,132.9	1.0	8.50	1	1	1
09/19/2020 18:00	1.5	12.1	2,113.5	1.0	8.50	1	1	1
09/19/2020 19:00	1.6	12.1	2,109.2	1.1	8.40	1	1	1
09/19/2020 20:00	1.6	12.1	2,101.4	1.1	8.40	1	1	1
09/19/2020 21:00	1.6	12.2	2,069.2	1.1	8.30	1	1	1
09/19/2020 22:00	1.6	12.2	2,071.7	1.1	8.30	1	1	1
09/19/2020 23:00	1.5	12.8	1,954.3	1.1	7.80	1	1	1
Average/Sum#:	5.2	13.2	1,760.3	7.0	169.66 #	11 #	9 #	9 #
Minimum:	0.7	11.9	411.0	0.6	3.10	0	0	0
Maximum:	23.4	17.9	2,132.9	46.0	70.30	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/20/2020 00:00	1.5	12.9	1,941.4	1.1	7.80	1	1	1
09/20/2020 01:00	1.5	12.9	1,945.9	1.1	7.80	1	1	1
09/20/2020 02:00	1.5	12.9	1,947.9	1.1	7.80	1	1	1
09/20/2020 03:00	1.5	12.9	1,944.9	1.1	7.80	1	1	1
09/20/2020 04:00	1.4	13.0	1,935.4	1.0	7.70	1	1	1
09/20/2020 05:00	1.4	13.0	1,901.8	1.0	7.60	1	1	1
09/20/2020 06:00	0.0	0.0	666.9	0.0	0.00	1	0	0
09/20/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2020 14:00	18.9	17.7	433.1	34.8	34.35	1	0	0
09/20/2020 15:00	7.3	15.3	940.3	7.7	26.30	1	0	0
09/20/2020 16:00	0.9	13.8	1,583.1	0.7	4.70	1	1	0
09/20/2020 17:00	1.5	12.4	2,017.5	1.0	8.10	1	1	1
09/20/2020 18:00	1.6	11.8	2,137.7	1.0	8.60	1	1	1
09/20/2020 19:00	1.6	11.8	2,134.1	1.0	8.50	1	1	1
09/20/2020 20:00	1.6	12.0	2,104.1	1.1	8.40	1	1	1
09/20/2020 21:00	1.5	12.4	1,981.5	1.0	7.90	1	1	1
09/20/2020 22:00	4.4	15.6	632.2	4.9	2.62	1	0	0
09/20/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	3.2	13.4	1,640.5	4.0	155.97 #	16 #	12 #	11 #
Minimum:	0.9	11.8	433.1	0.7	2.62	0	0	0
Maximum:	18.9	17.7	2,137.7	34.8	34.35	1	1	1
%SI	37.50	37.50	33.33	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/21/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2020 08:00	21.3	18.0	391.1	43.3	25.04	1	0	0
09/21/2020 09:00	12.5	17.1	517.4	19.4	36.70	1	0	0
09/21/2020 10:00	10.9	15.5	870.6	11.9	38.30	1	0	0
09/21/2020 11:00	0.6	13.9	1,486.4	0.5	3.00	1	1	0
09/21/2020 12:00	1.1	13.8	1,664.1	0.9	5.00	1	1	0
09/21/2020 13:00	1.0	13.9	1,575.1	0.8	4.70	1	1	0
09/21/2020 14:00	0.8	13.9	1,458.3	0.7	2.90	1	1	0
09/21/2020 15:00	0.8	13.9	1,510.1	0.7	3.00	1	1	1
09/21/2020 16:00	1.4	12.6	1,957.1	1.0	7.80	1	1	1
09/21/2020 17:00	1.5	12.4	1,984.2	1.0	7.90	1	1	1
09/21/2020 18:00	1.5	12.6	1,965.9	1.1	7.90	1	1	1
09/21/2020 19:00	1.4	12.5	2,019.7	1.0	8.10	1	1	1
09/21/2020 20:00	1.6	12.2	2,059.0	1.1	8.20	1	1	1
09/21/2020 21:00	1.6	12.3	2,000.9	1.1	8.00	1	1	1
09/21/2020 22:00	4.5	15.6	628.4	5.0	2.60	1	0	0
09/21/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	4.2	14.0	1,472.6	6.0	169.14 #	15 #	11 #	7 #
Minimum:	0.6	12.2	391.1	0.5	2.60	0	0	0
Maximum:	21.3	18.0	2,059.0	43.3	38.30	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/22/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2020 08:00	21.2	18.0	393.7	43.1	23.16	1	0	0
09/22/2020 09:00	13.4	17.1	521.6	20.8	40.20	1	0	0
09/22/2020 10:00	11.5	15.5	855.1	12.6	39.30	1	0	0
09/22/2020 11:00	0.7	13.9	1,500.8	0.6	3.00	1	1	0
09/22/2020 12:00	1.3	13.2	1,817.2	1.0	7.30	1	1	1
09/22/2020 13:00	1.5	12.6	1,947.6	1.1	7.80	1	1	1
09/22/2020 14:00	0.9	13.9	1,540.5	0.8	4.60	1	1	0
09/22/2020 15:00	0.8	14.0	1,449.5	0.7	4.30	1	1	0
09/22/2020 16:00	0.9	13.9	1,512.1	0.8	4.50	1	1	1
09/22/2020 17:00	1.4	12.8	1,946.1	1.0	7.80	1	1	1
09/22/2020 18:00	1.5	12.9	1,936.3	1.1	7.70	1	1	1
09/22/2020 19:00	1.4	12.9	1,933.3	1.0	7.70	1	1	1
09/22/2020 20:00	1.4	12.9	1,935.9	1.0	7.70	1	1	1
09/22/2020 21:00	2.9	14.4	1,179.1	2.6	5.66	1	0	1
09/22/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	4.3	14.1	1,462.1	6.3	170.72 #	14 #	10 #	8 #
Minimum:	0.7	12.6	393.7	0.6	3.00	0	0	0
Maximum:	21.2	18.0	1,947.6	43.1	40.20	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/23/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/23/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/23/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/23/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/23/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/23/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/23/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/23/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/23/2020 08:00	26.2	17.8	431.3	49.9	42.08	1	0	0
09/23/2020 09:00	9.8	17.1	519.6	15.2	29.10	1	0	0
09/23/2020 10:00	12.5	15.3	909.8	13.2	44.60	1	0	0
09/23/2020 11:00	0.6	14.0	1,375.5	0.5	2.80	1	1	0
09/23/2020 12:00	0.8	14.0	1,456.4	0.7	4.40	1	1	0
09/23/2020 13:00	0.9	14.0	1,526.6	0.8	4.60	1	1	0
09/23/2020 14:00	0.8	14.0	1,459.5	0.7	4.40	1	1	0
09/23/2020 15:00	0.9	13.9	1,540.0	0.8	4.60	1	1	1
09/23/2020 16:00	1.4	12.5	1,992.2	1.0	8.00	1	1	1
09/23/2020 17:00	1.5	12.5	1,988.8	1.1	8.00	1	1	1
09/23/2020 18:00	1.5	12.7	1,959.3	1.1	7.80	1	1	1
09/23/2020 19:00	1.4	12.5	2,023.9	1.0	8.10	1	1	1
09/23/2020 20:00	1.5	12.9	1,916.5	1.1	7.70	1	1	1
09/23/2020 21:00	6.2	15.7	610.9	7.0	3.66	1	0	0
09/23/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/23/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	4.7	14.2	1,407.9	6.7	179.84 #	14 #	10 #	6 #
Minimum:	0.6	12.5	431.3	0.5	2.80	0	0	0
Maximum:	26.2	17.8	2,023.9	49.9	44.60	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/24/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/24/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/24/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/24/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/24/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/24/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/24/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/24/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/24/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/24/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/24/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/24/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/24/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/24/2020 13:00	28.5	17.6	445.5	51.0	56.98	1	0	0
09/24/2020 14:00	14.8	14.9	1,026.7	14.6	55.40	1	0	0
09/24/2020 15:00	1.0	13.8	1,651.3	0.8	5.00	1	1	0
09/24/2020 16:00	1.2	13.4	1,757.8	0.9	5.30	1	1	1
09/24/2020 17:00	1.6	12.1	2,081.8	1.1	8.30	1	1	1
09/24/2020 18:00	1.6	12.2	2,071.0	1.1	8.30	1	1	1
09/24/2020 19:00	1.6	12.3	2,061.5	1.1	8.20	1	1	1
09/24/2020 20:00	3.3	14.2	1,199.0	2.9	6.34	1	0	1
09/24/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/24/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/24/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	6.7	13.8	1,536.8	9.2	153.82 #	8 #	5 #	5 #
Minimum:	1.0	12.1	445.5	0.8	5.00	0	0	0
Maximum:	28.5	17.6	2,081.8	51.0	56.98	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/25/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/26/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/27/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2020 08:00	0.0	21.0	34.5	0.0	0.00	1	0	0
09/27/2020 09:00	34.7	17.2	502.0	55.3	102.40	1	0	0
09/27/2020 10:00	13.7	16.2	706.9	17.2	44.50	1	0	0
09/27/2020 11:00	0.5	14.1	1,404.1	0.4	2.80	1	1	0
09/27/2020 12:00	0.6	14.1	1,374.0	0.5	2.70	1	1	0
09/27/2020 13:00	1.0	14.0	1,585.8	0.9	4.80	1	1	0
09/27/2020 14:00	1.2	13.9	1,601.5	1.0	6.40	1	1	0
09/27/2020 15:00	1.1	13.9	1,622.0	0.9	4.90	1	1	0
09/27/2020 16:00	1.1	13.7	1,602.1	0.9	4.80	1	1	1
09/27/2020 17:00	1.6	12.3	2,074.7	1.1	8.30	1	1	1
09/27/2020 18:00	1.6	12.1	2,114.4	1.1	8.50	1	1	1
09/27/2020 19:00	1.6	12.1	2,122.4	1.1	8.50	1	1	1
09/27/2020 20:00	1.6	12.1	2,121.0	1.1	8.50	1	1	1
09/27/2020 21:00	1.6	12.1	2,124.8	1.1	8.50	1	1	1
09/27/2020 22:00	3.2	13.9	1,273.5	2.7	6.10	1	0	1
09/27/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	4.3	14.2	1,484.2	5.7	221.70 #	15 #	11 #	7 #
Minimum:	0.0	12.1	34.5	0.0	0.00	0	0	0
Maximum:	34.7	21.0	2,124.8	55.3	102.40	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/28/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2020 10:00	29.1	17.6	451.6	52.0	60.69	1	0	0
09/28/2020 11:00	12.6	15.1	979.1	12.8	46.00	1	0	0
09/28/2020 12:00	1.1	13.8	1,716.2	0.9	5.10	1	1	0
09/28/2020 13:00	1.1	13.7	1,657.2	0.9	5.00	1	1	1
09/28/2020 14:00	1.6	12.2	2,089.4	1.1	8.40	1	1	1
09/28/2020 15:00	1.6	11.7	2,170.6	1.0	8.70	1	1	1
09/28/2020 16:00	1.6	11.7	2,167.8	1.0	8.70	1	1	1
09/28/2020 17:00	1.6	11.9	2,152.6	1.0	8.60	1	1	1
09/28/2020 18:00	1.6	11.9	2,146.5	1.0	8.60	1	1	1
09/28/2020 19:00	1.6	12.1	2,096.1	1.1	8.40	1	1	1
09/28/2020 20:00	1.6	12.1	2,105.7	1.1	8.40	1	1	1
09/28/2020 21:00	1.6	12.3	2,076.1	1.1	8.30	1	1	1
09/28/2020 22:00	3.2	14.1	1,250.6	2.8	6.25	1	0	1
09/28/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	4.6	13.1	1,773.8	6.0	191.14 #	13 #	10 #	10 #
Minimum:	1.1	11.7	451.6	0.9	5.00	0	0	0
Maximum:	29.1	17.6	2,170.6	52.0	60.69	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOX, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOX, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOX, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/29/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2020 10:00	24.7	17.5	459.6	42.9	56.63	1	0	0
09/29/2020 11:00	11.0	15.1	1,006.2	11.2	41.30	1	0	0
09/29/2020 12:00	1.0	13.9	1,704.3	0.8	5.10	1	1	0
09/29/2020 13:00	1.2	13.4	1,762.3	0.9	5.30	1	1	1
09/29/2020 14:00	1.6	12.2	2,089.8	1.1	8.40	1	1	1
09/29/2020 15:00	1.5	12.1	2,105.1	1.0	8.40	1	1	1
09/29/2020 16:00	1.6	12.0	2,127.0	1.1	8.50	1	1	1
09/29/2020 17:00	1.6	12.1	2,126.7	1.1	8.50	1	1	1
09/29/2020 18:00	1.6	12.2	2,091.6	1.1	8.40	1	1	1
09/29/2020 19:00	1.6	12.1	2,119.8	1.1	8.50	1	1	1
09/29/2020 20:00	1.6	12.2	2,104.9	1.1	8.40	1	1	1
09/29/2020 21:00	1.6	12.3	2,091.1	1.1	8.40	1	1	1
09/29/2020 22:00	1.6	12.4	2,068.3	1.1	8.30	1	1	1
09/29/2020 23:00	1.6	12.5	2,062.3	1.1	8.20	1	1	1
Average/Sum#:	3.8	13.0	1,851.4	4.8	192.33 #	14 #	12 #	11 #
Minimum:	1.0	12.0	459.6	0.8	5.10	0	0	0
Maximum:	24.7	17.5	2,127.0	42.9	56.63	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:48 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/30/2020 00:00	1.5	12.8	1,987.6	1.1	8.00	1	1	1
09/30/2020 01:00	0.9	13.9	1,639.6	0.8	4.90	1	1	0
09/30/2020 02:00	0.9	13.9	1,676.0	0.8	5.00	1	1	0
09/30/2020 03:00	0.9	13.9	1,656.5	0.8	5.00	1	1	0
09/30/2020 04:00	1.0	13.7	1,699.1	0.8	5.10	1	1	1
09/30/2020 05:00	1.5	12.7	2,024.7	1.1	8.10	1	1	1
09/30/2020 06:00	1.2	12.7	2,016.1	0.9	6.00	1	1	1
09/30/2020 07:00	0.9	13.9	1,645.5	0.8	4.90	1	1	0
09/30/2020 08:00	0.9	13.9	1,677.7	0.8	5.00	1	1	0
09/30/2020 09:00	1.0	13.9	1,682.6	0.8	5.00	1	1	0
09/30/2020 10:00	1.1	13.6	1,675.8	0.9	5.00	1	1	1
09/30/2020 11:00	1.6	12.3	2,076.6	1.1	8.30	1	1	1
09/30/2020 12:00	1.6	12.0	2,129.2	1.1	8.50	1	1	1
09/30/2020 13:00	1.6	11.8	2,166.7	1.0	8.70	1	1	1
09/30/2020 14:00	1.6	11.9	2,126.2	1.0	8.50	1	1	1
09/30/2020 15:00	1.6	11.9	2,135.5	1.0	8.50	1	1	1
09/30/2020 16:00	1.6	11.9	2,124.4	1.0	8.50	1	1	1
09/30/2020 17:00	1.6	12.1	2,097.4	1.1	8.40	1	1	1
09/30/2020 18:00	1.6	12.0	2,119.5	1.1	8.50	1	1	1
09/30/2020 19:00	1.6	11.9	2,148.3	1.0	8.60	1	1	1
09/30/2020 20:00	1.6	12.0	2,130.3	1.1	8.50	1	1	1
09/30/2020 21:00	1.6	12.1	2,110.9	1.1	8.40	1	1	1
09/30/2020 22:00	1.6	12.2	2,096.2	1.1	8.40	1	1	1
09/30/2020 23:00	1.5	12.7	1,959.2	1.1	7.80	1	1	1
Average/Sum#:	1.4	12.7	1,950.1	1.0	171.60 #	24 #	24 #	18 #
Minimum:	0.9	11.8	1,639.6	0.8	4.90	1	1	0
Maximum:	1.6	13.9	2,166.7	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

ATTACHMENT 7
Hourly Emissions – CO

FCD: AQ-16
Title V: #6

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/03/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/03/2020 13:00	72.6	17.6	440.0	0.0	89.5	1	1	0
07/03/2020 14:00	17.6	15.0	1,031.2	0.0	40.6	1	1	0
07/03/2020 15:00	0.0	13.9	1,652.8	0.0	0.0	1	1	0
07/03/2020 16:00	0.0	13.9	1,611.1	0.0	0.0	1	1	1
07/03/2020 17:00	0.8	12.3	2,011.2	0.2	2.5	1	1	1
07/03/2020 18:00	0.6	11.6	2,116.1	0.3	1.8	1	1	1
07/03/2020 19:00	0.6	11.8	2,094.2	0.4	1.8	1	1	1
07/03/2020 20:00	0.6	11.6	2,130.8	0.4	1.8	1	1	1
07/03/2020 21:00	0.7	12.2	2,025.1	0.4	2.2	1	1	1
07/03/2020 22:00	0.7	12.1	2,048.1	0.5	2.2	1	1	1
07/03/2020 23:00	7.9	13.9	1,231.3	0.0	9.2	1	0	1
Average/Sum#:	9.3	13.3	1,672.0	0.4	151.6 #	11 #	12 #	8 #
Minimum:	0.0	11.6	440.0	0.2	0.0	0	0	0
Maximum:	72.6	17.6	2,130.8	0.5	89.5	1	1	1
%SI	54.17	54.17	54.17	75.00	54.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/04/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/05/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/05/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/05/2020 14:00	62.4	17.7	423.1	0.0	65.4	1	1	0
07/05/2020 15:00	18.8	15.1	952.5	0.0	40.8	1	1	0
07/05/2020 16:00	0.0	13.9	1,572.4	0.0	0.0	1	1	0
07/05/2020 17:00	0.5	12.9	1,789.5	0.0	1.5	1	1	1
07/05/2020 18:00	0.7	11.6	2,104.3	0.3	2.1	1	1	1
07/05/2020 19:00	0.7	11.7	2,078.1	0.4	2.1	1	1	1
07/05/2020 20:00	0.7	11.7	2,105.4	0.4	2.1	1	1	1
07/05/2020 21:00	0.7	11.9	2,083.7	0.4	2.1	1	1	1
07/05/2020 22:00	6.2	13.5	1,360.8	0.0	9.1	1	0	1
07/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	10.1	13.3	1,607.8	0.4	125.2 #	9 #	10 #	6 #
Minimum:	0.0	11.6	423.1	0.3	0.0	0	0	0
Maximum:	62.4	17.7	2,105.4	0.4	65.4	1	1	1
%SI	62.50	62.50	62.50	83.33	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/06/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/06/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/06/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/06/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/06/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/06/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/06/2020 11:00	17.7	18.0	379.4	0.0	11.6	1	1	0
07/06/2020 12:00	22.1	15.5	891.9	0.0	48.2	1	1	0
07/06/2020 13:00	0.0	13.9	1,665.8	0.0	0.0	1	1	0
07/06/2020 14:00	0.3	13.9	1,595.1	0.0	0.9	1	1	0
07/06/2020 15:00	0.6	13.9	1,524.3	0.3	1.7	1	1	1
07/06/2020 16:00	1.4	12.2	2,035.3	0.6	4.3	1	1	1
07/06/2020 17:00	1.3	11.9	2,099.2	0.8	4.0	1	1	1
07/06/2020 18:00	1.2	11.8	2,114.2	0.9	3.7	1	1	1
07/06/2020 19:00	1.3	12.0	2,086.2	0.9	4.0	1	1	1
07/06/2020 20:00	1.4	12.2	2,059.5	0.9	4.4	1	1	1
07/06/2020 21:00	1.4	12.3	2,026.6	0.9	4.4	1	1	1
07/06/2020 22:00	1.3	12.8	1,924.2	0.9	4.1	1	1	1
07/06/2020 23:00	1.2	13.2	1,764.1	0.9	3.6	1	1	1
Average/Sum#:	3.9	13.4	1,705.1	0.8	94.9 #	13 #	20 #	9 #
Minimum:	0.0	11.8	379.4	0.3	0.0	0	0	0
Maximum:	22.1	18.0	2,114.2	0.9	48.2	1	1	1
%SI	45.83	45.83	45.83	62.50	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/07/2020 00:00	0.7	14.0	1,266.8	0.8	1.7	1	1	0
07/07/2020 01:00	0.6	14.0	1,318.2	0.7	1.5	1	1	0
07/07/2020 02:00	0.6	14.0	1,276.7	0.5	1.5	1	1	0
07/07/2020 03:00	0.6	14.0	1,267.0	0.5	1.5	1	1	0
07/07/2020 04:00	0.6	14.0	1,258.2	0.5	1.4	1	1	0
07/07/2020 05:00	0.6	14.0	1,279.5	0.5	1.5	1	1	0
07/07/2020 06:00	0.6	14.0	1,266.6	0.5	1.5	1	1	0
07/07/2020 07:00	0.5	14.0	1,284.4	0.5	1.2	1	1	0
07/07/2020 08:00	0.5	14.0	1,302.6	0.4	1.2	1	1	0
07/07/2020 09:00	0.5	14.0	1,277.3	0.4	1.2	1	1	0
07/07/2020 10:00	0.5	14.0	1,266.6	0.4	1.2	1	1	0
07/07/2020 11:00	0.5	14.1	1,270.9	0.4	1.2	1	1	0
07/07/2020 12:00	0.4	14.1	1,272.5	0.4	1.0	1	1	0
07/07/2020 13:00	0.7	14.0	1,372.0	0.4	1.8	1	1	0
07/07/2020 14:00	0.6	14.0	1,344.6	0.5	1.5	1	1	0
07/07/2020 15:00	0.0	0.0	1,482.0	0.0	0.0	1	1	1
07/07/2020 16:00	1.5	12.3	2,028.5	0.0	4.7	1	1	1
07/07/2020 17:00	1.3	11.8	2,115.5	0.0	4.0	1	1	1
07/07/2020 18:00	1.3	12.0	2,077.4	0.9	4.0	1	1	1
07/07/2020 19:00	1.3	12.0	2,065.7	0.9	4.0	1	1	1
07/07/2020 20:00	1.3	12.0	2,063.7	0.9	4.0	1	1	1
07/07/2020 21:00	1.3	12.1	2,052.5	0.9	4.0	1	1	1
07/07/2020 22:00	1.4	12.7	1,936.7	0.9	4.4	1	1	1
07/07/2020 23:00	1.2	12.9	1,818.2	0.9	3.6	1	1	1
Average/Sum#:	0.8	13.4	1,540.2	0.6	53.6 #	24 #	24 #	9 #
Minimum:	0.4	11.8	1,258.2	0.4	1.0	1	1	0
Maximum:	1.5	14.1	2,115.5	0.9	4.7	1	1	1
%SI	4.17	4.17	0.00	12.50	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/08/2020 00:00	0.6	14.0	1,288.8	0.8	1.5	1	1	0
07/08/2020 01:00	0.6	14.0	1,255.5	0.6	1.4	1	1	0
07/08/2020 02:00	0.5	14.0	1,255.4	0.5	1.2	1	1	0
07/08/2020 03:00	0.5	14.1	1,254.9	0.4	1.2	1	1	0
07/08/2020 04:00	0.5	14.1	1,257.1	0.4	1.2	1	1	0
07/08/2020 05:00	0.5	14.0	1,268.0	0.4	1.2	1	1	0
07/08/2020 06:00	0.5	14.1	1,259.1	0.4	1.2	1	1	0
07/08/2020 07:00	0.5	14.0	1,263.0	0.4	1.2	1	1	0
07/08/2020 08:00	0.5	14.0	1,261.3	0.4	1.2	1	1	0
07/08/2020 09:00	0.6	14.0	1,261.6	0.4	1.4	1	1	0
07/08/2020 10:00	0.5	14.1	1,263.6	0.4	1.2	1	1	0
07/08/2020 11:00	0.5	14.1	1,279.9	0.4	1.2	1	1	0
07/08/2020 12:00	0.5	14.0	1,336.2	0.4	1.3	1	1	0
07/08/2020 13:00	0.6	14.1	1,287.4	0.4	1.5	1	1	0
07/08/2020 14:00	0.5	14.1	1,336.3	0.4	1.3	1	1	0
07/08/2020 15:00	0.5	14.0	1,424.2	0.4	1.4	1	1	1
07/08/2020 16:00	1.5	12.1	2,027.1	0.6	4.6	1	1	1
07/08/2020 17:00	1.3	11.8	2,070.5	0.7	3.9	1	1	1
07/08/2020 18:00	1.3	11.8	2,088.0	0.9	3.9	1	1	1
07/08/2020 19:00	1.4	11.8	2,084.1	0.8	4.2	1	1	1
07/08/2020 20:00	1.3	11.8	2,084.8	0.8	3.9	1	1	1
07/08/2020 21:00	1.4	12.2	2,007.9	0.9	4.3	1	1	1
07/08/2020 22:00	1.4	12.5	1,955.0	0.9	4.3	1	1	1
07/08/2020 23:00	1.2	12.9	1,782.9	0.9	3.5	1	1	1
Average/Sum#:	0.8	13.4	1,527.2	0.6	53.2 #	24 #	24 #	9 #
Minimum:	0.5	11.8	1,254.9	0.4	1.2	1	1	0
Maximum:	1.5	14.1	2,088.0	0.9	4.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/09/2020 00:00	0.8	14.0	1,274.2	0.9	2.0	1	1	0
07/09/2020 01:00	0.8	14.0	1,271.2	0.8	1.9	1	1	0
07/09/2020 02:00	0.7	14.0	1,253.3	0.7	1.7	1	1	0
07/09/2020 03:00	0.7	14.0	1,314.5	0.6	1.8	1	1	0
07/09/2020 04:00	0.8	14.0	1,284.5	0.6	2.0	1	1	0
07/09/2020 05:00	0.7	14.0	1,339.3	0.6	1.8	1	1	0
07/09/2020 06:00	0.7	14.0	1,268.0	0.6	1.7	1	1	0
07/09/2020 07:00	0.7	14.0	1,257.2	0.6	1.7	1	1	0
07/09/2020 08:00	0.6	14.0	1,259.5	0.6	1.4	1	1	0
07/09/2020 09:00	0.6	14.0	1,267.0	0.5	1.5	1	1	0
07/09/2020 10:00	0.6	14.0	1,266.4	0.5	1.5	1	1	0
07/09/2020 11:00	0.5	14.1	1,266.7	0.5	1.2	1	1	0
07/09/2020 12:00	0.5	14.0	1,511.9	0.4	1.4	1	1	0
07/09/2020 13:00	0.5	13.9	1,629.0	0.4	1.5	1	1	0
07/09/2020 14:00	0.6	13.9	1,501.0	0.4	1.7	1	1	1
07/09/2020 15:00	1.4	12.1	2,021.6	0.6	4.2	1	1	1
07/09/2020 16:00	1.3	11.8	2,068.6	0.7	3.9	1	1	1
07/09/2020 17:00	1.2	11.7	2,100.2	0.8	3.6	1	1	1
07/09/2020 18:00	1.2	11.5	2,127.9	0.8	3.6	1	1	1
07/09/2020 19:00	1.2	11.6	2,122.3	0.8	3.6	1	1	1
07/09/2020 20:00	1.2	11.8	2,076.6	0.8	3.6	1	1	1
07/09/2020 21:00	1.3	11.9	2,074.2	0.8	4.0	1	1	1
07/09/2020 22:00	1.3	12.5	1,959.7	0.9	4.0	1	1	1
07/09/2020 23:00	1.4	12.8	1,900.4	0.9	4.3	1	1	1
Average/Sum#:	0.9	13.2	1,600.6	0.7	59.6 #	24 #	24 #	10 #
Minimum:	0.5	11.5	1,253.3	0.4	1.2	1	1	0
Maximum:	1.4	14.1	2,127.9	0.9	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/10/2020 00:00	0.5	14.0	1,360.6	0.8	1.3	1	1	0
07/10/2020 01:00	0.4	14.1	1,258.3	0.6	1.0	1	1	0
07/10/2020 02:00	0.4	14.1	1,257.3	0.3	1.0	1	1	0
07/10/2020 03:00	0.4	14.1	1,254.8	0.3	1.0	1	1	0
07/10/2020 04:00	0.4	14.1	1,265.3	0.3	1.0	1	1	0
07/10/2020 05:00	0.4	14.0	1,530.4	0.3	1.2	1	1	0
07/10/2020 06:00	0.5	14.0	1,670.6	0.3	1.6	1	1	0
07/10/2020 07:00	0.4	14.0	1,668.0	0.3	1.3	1	1	0
07/10/2020 08:00	0.4	14.0	1,578.2	0.3	1.2	1	1	0
07/10/2020 09:00	0.4	14.0	1,447.8	0.3	1.1	1	1	0
07/10/2020 10:00	0.4	14.0	1,483.2	0.3	1.1	1	1	0
07/10/2020 11:00	0.4	14.1	1,373.7	0.3	1.1	1	1	0
07/10/2020 12:00	0.5	14.0	1,542.6	0.3	1.5	1	1	0
07/10/2020 13:00	1.4	12.2	2,047.2	0.5	4.4	1	1	1
07/10/2020 14:00	1.3	11.9	2,108.3	0.7	4.0	1	1	1
07/10/2020 15:00	1.2	11.9	2,113.7	0.9	3.7	1	1	1
07/10/2020 16:00	1.2	11.7	2,149.4	0.8	3.7	1	1	1
07/10/2020 17:00	1.1	11.5	2,182.9	0.8	3.4	1	1	1
07/10/2020 18:00	1.1	11.4	2,197.2	0.7	3.4	1	1	1
07/10/2020 19:00	1.1	11.5	2,198.8	0.7	3.4	1	1	1
07/10/2020 20:00	1.1	11.5	2,190.3	0.7	3.4	1	1	1
07/10/2020 21:00	1.3	12.0	2,091.3	0.8	4.0	1	1	1
07/10/2020 22:00	1.3	12.0	2,106.0	0.8	4.1	1	1	1
07/10/2020 23:00	1.1	12.9	1,809.6	0.9	3.3	1	1	1
Average/Sum#:	0.8	13.0	1,745.2	0.5	56.2 #	24 #	24 #	11 #
Minimum:	0.4	11.4	1,254.8	0.3	1.0	1	1	0
Maximum:	1.4	14.1	2,198.8	0.9	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/11/2020 00:00	0.9	14.0	1,298.4	0.8	2.2	1	1	0
07/11/2020 01:00	0.8	14.0	1,345.5	0.8	2.1	1	1	0
07/11/2020 02:00	0.7	14.0	1,352.3	0.7	1.8	1	1	0
07/11/2020 03:00	0.7	14.0	1,368.3	0.6	1.8	1	1	0
07/11/2020 04:00	0.6	14.0	1,333.5	0.6	1.5	1	1	0
07/11/2020 05:00	0.6	14.0	1,654.7	0.5	1.9	1	1	0
07/11/2020 06:00	0.7	14.0	1,589.2	0.5	2.1	1	1	0
07/11/2020 07:00	0.6	14.0	1,362.1	0.5	1.6	1	1	0
07/11/2020 08:00	0.5	14.0	1,583.8	0.5	1.5	1	1	0
07/11/2020 09:00	0.6	14.0	1,309.6	0.5	1.5	1	1	0
07/11/2020 10:00	0.5	14.0	1,480.9	0.4	1.4	1	1	0
07/11/2020 11:00	0.5	13.9	1,613.9	0.4	1.5	1	1	0
07/11/2020 12:00	0.5	14.0	1,617.0	0.4	1.5	1	1	0
07/11/2020 13:00	0.5	14.1	1,365.0	0.4	1.3	1	1	0
07/11/2020 14:00	0.5	14.0	1,363.0	0.4	1.3	1	1	0
07/11/2020 15:00	1.1	13.0	1,816.3	0.5	3.3	1	1	1
07/11/2020 16:00	1.3	11.8	2,135.4	0.7	4.0	1	1	1
07/11/2020 17:00	1.2	11.5	2,177.4	0.8	3.7	1	1	1
07/11/2020 18:00	1.1	11.5	2,188.6	0.8	3.4	1	1	1
07/11/2020 19:00	1.1	11.5	2,199.7	0.7	3.4	1	1	1
07/11/2020 20:00	1.2	11.8	2,144.8	0.7	3.7	1	1	1
07/11/2020 21:00	1.3	12.0	2,097.6	0.8	4.0	1	1	1
07/11/2020 22:00	1.3	12.0	2,112.8	0.9	4.1	1	1	1
07/11/2020 23:00	1.2	12.9	1,826.2	0.9	3.6	1	1	1
Average/Sum#:	0.8	13.3	1,680.7	0.6	58.2 #	24 #	24 #	9 #
Minimum:	0.5	11.5	1,298.4	0.4	1.3	1	1	0
Maximum:	1.3	14.1	2,199.7	0.9	4.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/12/2020 00:00	0.7	14.0	1,296.8	0.8	1.7	1	1	0
07/12/2020 01:00	0.6	14.0	1,288.6	0.7	1.5	1	1	0
07/12/2020 02:00	0.8	14.0	1,287.3	0.6	2.0	1	1	0
07/12/2020 03:00	0.7	14.0	1,287.2	0.6	1.7	1	1	0
07/12/2020 04:00	0.6	14.0	1,288.3	0.6	1.5	1	1	0
07/12/2020 05:00	0.7	14.0	1,286.8	0.6	1.7	1	1	0
07/12/2020 06:00	0.7	14.0	1,291.7	0.6	1.7	1	1	0
07/12/2020 07:00	0.5	14.0	1,290.0	0.5	1.2	1	1	0
07/12/2020 08:00	0.5	14.1	1,291.8	0.5	1.3	1	1	0
07/12/2020 09:00	0.5	14.1	1,302.2	0.4	1.3	1	1	0
07/12/2020 10:00	0.5	14.1	1,404.8	0.4	1.4	1	1	0
07/12/2020 11:00	0.6	14.0	1,371.8	0.4	1.6	1	1	0
07/12/2020 12:00	0.6	14.0	1,428.8	0.5	1.6	1	1	0
07/12/2020 13:00	0.5	14.1	1,365.6	0.5	1.3	1	1	0
07/12/2020 14:00	0.5	14.1	1,313.3	0.4	1.3	1	1	0
07/12/2020 15:00	0.5	13.9	1,643.0	0.4	1.5	1	1	1
07/12/2020 16:00	1.4	11.9	2,097.6	0.6	4.3	1	1	1
07/12/2020 17:00	1.1	11.4	2,178.4	0.7	3.3	1	1	1
07/12/2020 18:00	1.2	11.4	2,170.1	0.8	3.6	1	1	1
07/12/2020 19:00	1.2	11.5	2,153.6	0.7	3.6	1	1	1
07/12/2020 20:00	1.3	11.9	2,097.4	0.8	4.0	1	1	1
07/12/2020 21:00	1.4	12.1	2,065.8	0.9	4.3	1	1	1
07/12/2020 22:00	1.3	11.9	2,112.3	0.9	4.0	1	1	1
07/12/2020 23:00	1.4	12.5	1,966.2	0.9	4.3	1	1	1
Average/Sum#:	0.8	13.3	1,595.0	0.6	55.7 #	24 #	24 #	9 #
Minimum:	0.5	11.4	1,286.8	0.4	1.2	1	1	0
Maximum:	1.4	14.1	2,178.4	0.9	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/13/2020 00:00	0.7	13.9	1,583.2	0.8	2.1	1	1	0
07/13/2020 01:00	0.7	13.9	1,443.0	0.7	1.9	1	1	0
07/13/2020 02:00	0.8	14.0	1,322.5	0.6	2.0	1	1	0
07/13/2020 03:00	0.8	14.0	1,291.4	0.7	2.0	1	1	0
07/13/2020 04:00	0.7	14.0	1,292.8	0.7	1.7	1	1	0
07/13/2020 05:00	0.6	13.9	1,629.1	0.6	1.8	1	1	0
07/13/2020 06:00	0.7	13.9	1,493.1	0.6	2.0	1	1	0
07/13/2020 07:00	0.7	13.9	1,394.0	0.6	1.8	1	1	0
07/13/2020 08:00	0.6	13.9	1,526.5	0.6	1.7	1	1	0
07/13/2020 09:00	0.7	14.0	1,307.3	0.6	1.8	1	1	0
07/13/2020 10:00	0.5	14.0	1,483.2	0.5	1.4	1	1	0
07/13/2020 11:00	0.5	13.9	1,621.6	0.5	1.5	1	1	1
07/13/2020 12:00	1.5	12.3	2,042.9	0.6	4.7	1	1	1
07/13/2020 13:00	1.4	11.9	2,098.4	0.8	4.3	1	1	1
07/13/2020 14:00	1.3	11.8	2,117.1	0.9	4.0	1	1	1
07/13/2020 15:00	1.2	11.7	2,119.4	0.8	3.7	1	1	1
07/13/2020 16:00	1.2	11.6	2,140.3	0.8	3.6	1	1	1
07/13/2020 17:00	1.2	11.5	2,165.0	0.8	3.7	1	1	1
07/13/2020 18:00	1.1	11.5	2,163.0	0.8	3.3	1	1	1
07/13/2020 19:00	1.2	11.6	2,146.9	0.8	3.7	1	1	1
07/13/2020 20:00	1.2	11.8	2,120.6	0.8	3.7	1	1	1
07/13/2020 21:00	1.3	11.9	2,103.0	0.8	4.0	1	1	1
07/13/2020 22:00	1.3	12.0	2,098.0	0.9	4.0	1	1	1
07/13/2020 23:00	1.3	12.7	1,965.5	0.9	4.1	1	1	1
Average/Sum#:	1.0	12.9	1,777.8	0.7	68.5 #	24 #	24 #	13 #
Minimum:	0.5	11.5	1,291.4	0.5	1.4	1	1	0
Maximum:	1.5	14.0	2,165.0	0.9	4.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/14/2020 00:00	1.1	13.1	1,788.3	0.9	3.3	1	1	1
07/14/2020 01:00	0.9	13.9	1,296.1	0.8	2.2	1	1	0
07/14/2020 02:00	0.7	13.9	1,354.6	0.7	1.8	1	1	0
07/14/2020 03:00	0.8	14.0	1,295.9	0.7	2.0	1	1	0
07/14/2020 04:00	0.8	14.0	1,292.0	0.7	2.0	1	1	0
07/14/2020 05:00	0.7	13.9	1,629.2	0.7	2.2	1	1	0
07/14/2020 06:00	0.7	13.9	1,662.5	0.6	2.2	1	1	0
07/14/2020 07:00	0.6	13.9	1,676.8	0.6	1.9	1	1	0
07/14/2020 08:00	0.5	13.9	1,552.4	0.5	1.5	1	1	0
07/14/2020 09:00	0.7	14.0	1,299.1	0.5	1.7	1	1	0
07/14/2020 10:00	0.7	14.0	1,314.4	0.5	1.8	1	1	0
07/14/2020 11:00	0.7	14.0	1,361.5	0.6	1.8	1	1	0
07/14/2020 12:00	0.6	13.9	1,531.6	0.6	1.7	1	1	0
07/14/2020 13:00	0.7	14.0	1,346.7	0.6	1.8	1	1	1
07/14/2020 14:00	1.5	12.3	2,026.7	0.7	4.7	1	1	1
07/14/2020 15:00	1.4	11.9	2,076.4	0.8	4.3	1	1	1
07/14/2020 16:00	1.3	11.8	2,099.9	0.9	4.0	1	1	1
07/14/2020 17:00	1.3	11.8	2,109.9	0.8	4.0	1	1	1
07/14/2020 18:00	1.3	11.7	2,135.2	0.8	4.0	1	1	1
07/14/2020 19:00	1.3	11.6	2,131.9	0.8	3.9	1	1	1
07/14/2020 20:00	1.3	11.8	2,119.8	0.8	4.0	1	1	1
07/14/2020 21:00	1.3	11.8	2,125.8	0.8	4.0	1	1	1
07/14/2020 22:00	1.4	12.5	1,981.5	0.9	4.4	1	1	1
07/14/2020 23:00	1.2	13.0	1,795.1	0.9	3.6	1	1	1
Average/Sum#:	1.0	13.1	1,708.5	0.7	68.8 #	24 #	24 #	12 #
Minimum:	0.5	11.6	1,292.0	0.5	1.5	1	1	0
Maximum:	1.5	14.0	2,135.2	0.9	4.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/15/2020 00:00	1.1	13.9	1,292.8	0.9	2.7	1	1	0
07/15/2020 01:00	0.9	14.0	1,288.0	0.9	2.2	1	1	0
07/15/2020 02:00	0.8	14.0	1,291.6	0.8	2.0	1	1	0
07/15/2020 03:00	0.8	14.0	1,293.1	0.7	2.0	1	1	0
07/15/2020 04:00	0.8	14.0	1,293.8	0.7	2.0	1	1	0
07/15/2020 05:00	0.9	13.9	1,319.3	0.7	2.2	1	1	0
07/15/2020 06:00	0.9	13.9	1,305.0	0.8	2.2	1	1	0
07/15/2020 07:00	0.8	14.0	1,289.2	0.8	2.0	1	1	0
07/15/2020 08:00	0.8	14.0	1,290.7	0.7	2.0	1	1	0
07/15/2020 09:00	0.8	14.0	1,294.0	0.7	2.0	1	1	0
07/15/2020 10:00	0.8	14.0	1,295.0	0.7	2.0	1	1	0
07/15/2020 11:00	0.7	14.0	1,297.5	0.7	1.7	1	1	0
07/15/2020 12:00	0.7	14.0	1,296.0	0.6	1.7	1	1	0
07/15/2020 13:00	0.7	14.0	1,299.5	0.6	1.7	1	1	0
07/15/2020 14:00	0.7	14.0	1,307.4	0.6	1.8	1	1	0
07/15/2020 15:00	0.7	14.0	1,302.6	0.6	1.7	1	1	0
07/15/2020 16:00	0.7	14.0	1,307.9	0.6	1.8	1	1	0
07/15/2020 17:00	0.7	14.0	1,308.4	0.6	1.8	1	1	0
07/15/2020 18:00	0.7	13.9	1,392.0	0.6	1.8	1	1	0
07/15/2020 19:00	0.6	13.9	1,462.8	0.6	1.7	1	1	0
07/15/2020 20:00	0.7	14.0	1,358.8	0.6	1.8	1	1	0
07/15/2020 21:00	0.8	14.0	1,288.7	0.6	2.0	1	1	0
07/15/2020 22:00	1.0	13.9	1,285.1	0.7	2.4	1	1	0
07/15/2020 23:00	0.8	14.0	1,323.4	0.7	2.0	1	1	0
Average/Sum#:	0.8	14.0	1,311.8	0.7	47.2 #	24 #	24 #	0 #
Minimum:	0.6	13.9	1,285.1	0.6	1.7	1	1	0
Maximum:	1.1	14.0	1,462.8	0.9	2.7	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/16/2020 00:00	0.8	14.0	1,288.8	0.7	2.0	1	1	0
07/16/2020 01:00	0.9	14.0	1,288.2	0.7	2.2	1	1	0
07/16/2020 02:00	0.9	14.0	1,286.5	0.8	2.2	1	1	0
07/16/2020 03:00	1.0	13.9	1,286.3	0.8	2.4	1	1	0
07/16/2020 04:00	1.0	13.9	1,287.1	0.8	2.4	1	1	0
07/16/2020 05:00	1.0	13.9	1,287.0	0.8	2.4	1	1	0
07/16/2020 06:00	0.9	14.0	1,287.8	0.8	2.2	1	1	0
07/16/2020 07:00	0.9	14.0	1,288.1	0.8	2.2	1	1	0
07/16/2020 08:00	0.8	14.0	1,291.1	0.8	2.0	1	1	0
07/16/2020 09:00	0.8	14.0	1,293.9	0.7	2.0	1	1	0
07/16/2020 10:00	0.7	14.0	1,298.6	0.7	1.7	1	1	0
07/16/2020 11:00	0.7	14.0	1,297.0	0.6	1.7	1	1	0
07/16/2020 12:00	0.8	14.0	1,295.0	0.6	2.0	1	1	0
07/16/2020 13:00	0.7	14.0	1,297.3	0.6	1.7	1	1	0
07/16/2020 14:00	0.6	13.9	1,463.7	0.6	1.7	1	1	0
07/16/2020 15:00	0.7	13.9	1,504.0	0.6	2.0	1	1	1
07/16/2020 16:00	1.5	11.9	2,067.7	0.7	4.6	1	1	1
07/16/2020 17:00	1.4	11.7	2,107.8	0.8	4.2	1	1	1
07/16/2020 18:00	1.4	11.8	2,094.6	0.9	4.3	1	1	1
07/16/2020 19:00	1.3	11.7	2,128.9	0.9	4.0	1	1	1
07/16/2020 20:00	1.3	11.7	2,126.3	0.8	4.0	1	1	1
07/16/2020 21:00	1.4	11.9	2,111.6	0.8	4.3	1	1	1
07/16/2020 22:00	1.4	12.6	1,974.7	0.9	4.4	1	1	1
07/16/2020 23:00	1.2	13.1	1,789.3	0.9	3.6	1	1	1
Average/Sum#:	1.0	13.3	1,560.1	0.8	66.2 #	24 #	24 #	9 #
Minimum:	0.6	11.7	1,286.3	0.6	1.7	1	1	0
Maximum:	1.5	14.0	2,128.9	0.9	4.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/17/2020 00:00	1.1	13.9	1,292.7	0.9	2.7	1	1	0
07/17/2020 01:00	0.8	13.9	1,297.8	0.8	2.0	1	1	0
07/17/2020 02:00	0.8	14.0	1,293.2	0.8	2.0	1	1	0
07/17/2020 03:00	0.8	14.0	1,300.9	0.7	2.0	1	1	0
07/17/2020 04:00	0.8	14.0	1,298.0	0.7	2.0	1	1	0
07/17/2020 05:00	0.9	13.9	1,304.6	0.7	2.2	1	1	0
07/17/2020 06:00	0.8	13.9	1,304.4	0.7	2.0	1	1	0
07/17/2020 07:00	0.7	14.0	1,298.6	0.7	1.7	1	1	0
07/17/2020 08:00	0.6	14.0	1,300.4	0.6	1.5	1	1	0
07/17/2020 09:00	0.6	14.0	1,312.8	0.5	1.5	1	1	0
07/17/2020 10:00	0.7	14.0	1,305.3	0.5	1.7	1	1	0
07/17/2020 11:00	0.7	14.0	1,308.2	0.6	1.8	1	1	0
07/17/2020 12:00	0.7	14.0	1,317.9	0.6	1.8	1	1	0
07/17/2020 13:00	0.7	14.0	1,327.9	0.6	1.8	1	1	0
07/17/2020 14:00	0.7	14.0	1,300.6	0.6	1.7	1	1	0
07/17/2020 15:00	0.7	14.0	1,303.4	0.6	1.7	1	1	0
07/17/2020 16:00	0.7	13.9	1,505.4	0.6	2.0	1	1	1
07/17/2020 17:00	1.5	12.0	2,071.3	0.7	4.6	1	1	1
07/17/2020 18:00	1.4	11.8	2,107.8	0.8	4.3	1	1	1
07/17/2020 19:00	1.4	11.8	2,119.7	0.9	4.3	1	1	1
07/17/2020 20:00	1.4	11.8	2,123.3	0.9	4.3	1	1	1
07/17/2020 21:00	1.4	11.9	2,108.4	0.9	4.3	1	1	1
07/17/2020 22:00	1.4	12.6	1,985.7	0.9	4.4	1	1	1
07/17/2020 23:00	1.2	13.0	1,865.4	0.9	3.7	1	1	1
Average/Sum#:	0.9	13.4	1,531.4	0.7	62.0 #	24 #	24 #	8 #
Minimum:	0.6	11.8	1,292.7	0.5	1.5	1	1	0
Maximum:	1.5	14.0	2,123.3	0.9	4.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/18/2020 00:00	0.6	13.7	1,757.5	0.8	1.9	1	1	0
07/18/2020 01:00	0.7	13.8	1,599.1	0.7	2.1	1	1	0
07/18/2020 02:00	1.1	13.9	1,308.4	0.7	2.7	1	1	0
07/18/2020 03:00	0.8	13.9	1,310.0	0.7	2.0	1	1	0
07/18/2020 04:00	0.8	13.9	1,319.9	0.8	2.0	1	1	0
07/18/2020 05:00	0.7	13.9	1,355.7	0.7	1.8	1	1	0
07/18/2020 06:00	0.8	13.9	1,294.4	0.7	2.0	1	1	0
07/18/2020 07:00	0.7	14.0	1,294.7	0.6	1.7	1	1	0
07/18/2020 08:00	0.7	14.0	1,294.6	0.6	1.7	1	1	0
07/18/2020 09:00	0.7	14.0	1,301.1	0.6	1.7	1	1	0
07/18/2020 10:00	0.7	14.0	1,301.4	0.6	1.7	1	1	0
07/18/2020 11:00	0.6	14.0	1,392.7	0.6	1.6	1	1	0
07/18/2020 12:00	0.6	13.9	1,407.3	0.5	1.6	1	1	0
07/18/2020 13:00	0.6	13.9	1,587.2	0.5	1.8	1	1	1
07/18/2020 14:00	1.6	12.4	2,007.4	0.7	5.0	1	1	1
07/18/2020 15:00	0.8	13.5	1,515.8	0.7	2.2	1	1	1
07/18/2020 16:00	0.6	13.9	1,599.3	0.7	1.8	1	1	1
07/18/2020 17:00	1.4	12.0	2,074.1	0.7	4.3	1	1	1
07/18/2020 18:00	1.2	11.5	2,149.9	0.7	3.6	1	1	1
07/18/2020 19:00	1.2	11.4	2,177.7	0.8	3.6	1	1	1
07/18/2020 20:00	1.3	11.6	2,134.0	0.8	3.9	1	1	1
07/18/2020 21:00	1.4	12.3	2,006.8	0.8	4.3	1	1	1
07/18/2020 22:00	1.5	12.4	1,990.9	0.9	4.6	1	1	1
07/18/2020 23:00	1.3	12.8	1,867.6	1.0	4.0	1	1	1
Average/Sum#:	0.9	13.3	1,627.0	0.7	63.6 #	24 #	24 #	11 #
Minimum:	0.6	11.4	1,294.4	0.5	1.6	1	1	0
Maximum:	1.6	14.0	2,177.7	1.0	5.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/19/2020 00:00	0.8	13.6	1,759.1	0.8	2.5	1	1	0
07/19/2020 01:00	1.2	13.9	1,313.6	0.8	3.0	1	1	0
07/19/2020 02:00	1.1	13.9	1,289.2	0.8	2.7	1	1	0
07/19/2020 03:00	1.1	13.9	1,293.5	0.9	2.7	1	1	0
07/19/2020 04:00	0.9	13.9	1,289.8	0.9	2.2	1	1	0
07/19/2020 05:00	0.9	13.9	1,290.7	0.8	2.2	1	1	0
07/19/2020 06:00	0.9	13.9	1,289.1	0.8	2.2	1	1	0
07/19/2020 07:00	0.8	14.0	1,292.4	0.8	2.0	1	1	0
07/19/2020 08:00	0.7	14.0	1,300.6	0.7	1.7	1	1	0
07/19/2020 09:00	0.7	14.0	1,300.7	0.6	1.7	1	1	0
07/19/2020 10:00	0.7	14.0	1,301.4	0.6	1.7	1	1	0
07/19/2020 11:00	0.7	14.0	1,300.7	0.6	1.7	1	1	0
07/19/2020 12:00	0.7	14.0	1,301.3	0.6	1.7	1	1	0
07/19/2020 13:00	0.7	14.0	1,304.0	0.6	1.7	1	1	0
07/19/2020 14:00	0.6	14.0	1,309.0	0.6	1.5	1	1	0
07/19/2020 15:00	0.6	14.0	1,306.8	0.5	1.5	1	1	0
07/19/2020 16:00	0.6	13.9	1,498.4	0.5	1.7	1	1	1
07/19/2020 17:00	1.5	12.0	2,048.3	0.7	4.6	1	1	1
07/19/2020 18:00	1.2	11.6	2,130.2	0.8	3.6	1	1	1
07/19/2020 19:00	1.2	11.7	2,124.6	0.9	3.7	1	1	1
07/19/2020 20:00	1.3	11.8	2,110.5	0.8	4.0	1	1	1
07/19/2020 21:00	1.4	12.0	2,091.8	0.8	4.3	1	1	1
07/19/2020 22:00	1.4	12.6	1,970.3	0.9	4.4	1	1	1
07/19/2020 23:00	1.2	13.1	1,786.8	0.9	3.6	1	1	1
Average/Sum#:	1.0	13.4	1,541.8	0.7	62.6 #	24 #	24 #	8 #
Minimum:	0.6	11.6	1,289.1	0.5	1.5	1	1	0
Maximum:	1.5	14.0	2,130.2	0.9	4.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/20/2020 00:00	1.0	13.9	1,291.9	0.9	2.4	1	1	0
07/20/2020 01:00	0.8	13.9	1,284.9	0.8	1.9	1	1	0
07/20/2020 02:00	0.8	13.9	1,283.5	0.7	1.9	1	1	0
07/20/2020 03:00	0.8	13.9	1,283.1	0.7	1.9	1	1	0
07/20/2020 04:00	0.8	13.9	1,284.7	0.7	1.9	1	1	0
07/20/2020 05:00	0.9	13.9	1,300.2	0.7	2.2	1	1	0
07/20/2020 06:00	0.6	13.9	1,661.5	0.7	1.9	1	1	0
07/20/2020 07:00	0.5	13.9	1,634.1	0.6	1.5	1	1	0
07/20/2020 08:00	0.5	13.9	1,676.7	0.4	1.6	1	1	0
07/20/2020 09:00	0.6	13.9	1,385.1	0.4	1.6	1	1	0
07/20/2020 10:00	0.5	13.9	1,530.8	0.4	1.4	1	1	0
07/20/2020 11:00	0.5	13.9	1,543.3	0.4	1.5	1	1	0
07/20/2020 12:00	0.6	13.8	1,523.7	0.4	1.7	1	1	1
07/20/2020 13:00	1.5	12.2	2,029.1	0.6	4.6	1	1	1
07/20/2020 14:00	1.4	12.3	1,999.1	0.8	4.3	1	1	1
07/20/2020 15:00	1.3	11.9	2,072.1	1.0	4.0	1	1	1
07/20/2020 16:00	1.3	11.9	2,076.3	0.9	4.0	1	1	1
07/20/2020 17:00	1.3	11.8	2,084.5	0.9	3.9	1	1	1
07/20/2020 18:00	1.2	11.6	2,124.9	0.8	3.6	1	1	1
07/20/2020 19:00	1.3	11.7	2,122.1	0.8	4.0	1	1	1
07/20/2020 20:00	1.3	11.8	2,110.2	0.8	4.0	1	1	1
07/20/2020 21:00	1.4	12.0	2,089.5	0.8	4.3	1	1	1
07/20/2020 22:00	1.3	12.4	2,003.9	0.9	4.0	1	1	1
07/20/2020 23:00	0.9	13.0	1,777.5	0.8	2.7	1	1	1
Average/Sum#:	1.0	13.1	1,715.5	0.7	66.8 #	24 #	24 #	12 #
Minimum:	0.5	11.6	1,283.1	0.4	1.4	1	1	0
Maximum:	1.5	13.9	2,124.9	1.0	4.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/21/2020 00:00	0.7	13.9	1,284.2	0.7	1.7	1	1	0
07/21/2020 01:00	0.7	13.9	1,285.2	0.6	1.7	1	1	0
07/21/2020 02:00	0.8	13.9	1,285.0	0.6	1.9	1	1	0
07/21/2020 03:00	0.8	13.9	1,283.1	0.7	1.9	1	1	0
07/21/2020 04:00	0.8	13.9	1,283.6	0.7	1.9	1	1	0
07/21/2020 05:00	0.9	13.9	1,296.0	0.7	2.2	1	1	0
07/21/2020 06:00	0.6	13.9	1,652.7	0.7	1.9	1	1	0
07/21/2020 07:00	0.6	13.9	1,529.9	0.6	1.7	1	1	0
07/21/2020 08:00	0.6	13.9	1,526.6	0.5	1.7	1	1	0
07/21/2020 09:00	0.7	13.9	1,371.1	0.5	1.8	1	1	0
07/21/2020 10:00	0.5	13.9	1,507.4	0.5	1.4	1	1	0
07/21/2020 11:00	0.6	13.9	1,369.6	0.5	1.6	1	1	0
07/21/2020 12:00	0.7	13.9	1,383.2	0.5	1.8	1	1	0
07/21/2020 13:00	1.2	12.9	1,810.3	0.7	3.6	1	1	1
07/21/2020 14:00	1.4	11.8	2,078.6	0.8	4.2	1	1	1
07/21/2020 15:00	1.3	11.7	2,090.3	0.9	3.9	1	1	1
07/21/2020 16:00	1.3	11.6	2,122.9	0.8	3.9	1	1	1
07/21/2020 17:00	1.2	11.5	2,161.6	0.8	3.6	1	1	1
07/21/2020 18:00	1.2	11.5	2,152.9	0.8	3.6	1	1	1
07/21/2020 19:00	1.2	11.7	2,123.4	0.8	3.7	1	1	1
07/21/2020 20:00	1.3	11.8	2,120.7	0.8	4.0	1	1	1
07/21/2020 21:00	1.3	12.0	2,091.9	0.8	4.0	1	1	1
07/21/2020 22:00	1.4	12.5	1,984.9	0.9	4.4	1	1	1
07/21/2020 23:00	0.9	13.0	1,838.6	0.9	2.8	1	1	1
Average/Sum#:	0.9	13.0	1,693.1	0.7	64.9 #	24 #	24 #	11 #
Minimum:	0.5	11.5	1,283.1	0.5	1.4	1	1	0
Maximum:	1.4	13.9	2,161.6	0.9	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/22/2020 00:00	0.7	13.9	1,394.0	0.8	1.8	1	1	0
07/22/2020 01:00	0.7	13.9	1,283.5	0.6	1.7	1	1	0
07/22/2020 02:00	0.8	13.9	1,284.0	0.6	1.9	1	1	0
07/22/2020 03:00	0.9	13.9	1,284.0	0.7	2.2	1	1	0
07/22/2020 04:00	0.9	13.9	1,297.4	0.8	2.2	1	1	0
07/22/2020 05:00	1.0	13.9	1,377.5	0.8	2.6	1	1	0
07/22/2020 06:00	0.6	13.8	1,661.4	0.7	1.9	1	1	0
07/22/2020 07:00	0.8	13.9	1,360.4	0.7	2.1	1	1	0
07/22/2020 08:00	0.8	13.9	1,297.1	0.6	2.0	1	1	0
07/22/2020 09:00	0.7	13.9	1,299.4	0.7	1.7	1	1	0
07/22/2020 10:00	0.7	13.9	1,301.1	0.6	1.7	1	1	0
07/22/2020 11:00	0.6	14.0	1,301.5	0.6	1.5	1	1	0
07/22/2020 12:00	0.7	14.0	1,294.0	0.6	1.7	1	1	0
07/22/2020 13:00	0.7	14.0	1,292.3	0.6	1.7	1	1	0
07/22/2020 14:00	0.7	14.0	1,293.2	0.6	1.7	1	1	0
07/22/2020 15:00	0.7	14.0	1,301.2	0.6	1.7	1	1	0
07/22/2020 16:00	0.6	13.9	1,629.3	0.6	1.8	1	1	1
07/22/2020 17:00	1.5	12.1	2,047.5	0.7	4.6	1	1	1
07/22/2020 18:00	1.3	11.9	2,102.4	0.8	4.0	1	1	1
07/22/2020 19:00	1.4	11.9	2,097.8	0.9	4.3	1	1	1
07/22/2020 20:00	1.4	12.0	2,098.2	0.9	4.4	1	1	1
07/22/2020 21:00	1.4	12.0	2,092.7	0.9	4.3	1	1	1
07/22/2020 22:00	1.4	12.6	1,971.0	0.9	4.4	1	1	1
07/22/2020 23:00	1.2	13.1	1,778.2	0.9	3.6	1	1	1
Average/Sum#:	0.9	13.4	1,547.5	0.7	61.5 #	24 #	24 #	8 #
Minimum:	0.6	11.9	1,283.5	0.6	1.5	1	1	0
Maximum:	1.5	14.0	2,102.4	0.9	4.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/23/2020 00:00	1.0	13.9	1,288.7	0.9	2.4	1	1	0
07/23/2020 01:00	0.9	13.9	1,283.7	0.8	2.2	1	1	0
07/23/2020 02:00	0.9	13.9	1,282.6	0.8	2.2	1	1	0
07/23/2020 03:00	0.9	13.9	1,282.1	0.8	2.2	1	1	0
07/23/2020 04:00	0.9	13.9	1,283.1	0.8	2.2	1	1	0
07/23/2020 05:00	1.0	13.9	1,287.5	0.8	2.4	1	1	0
07/23/2020 06:00	1.0	13.9	1,293.0	0.8	2.4	1	1	0
07/23/2020 07:00	0.9	13.9	1,296.0	0.8	2.2	1	1	0
07/23/2020 08:00	0.8	13.9	1,298.4	0.8	2.0	1	1	0
07/23/2020 09:00	0.7	13.9	1,297.5	0.7	1.7	1	1	0
07/23/2020 10:00	0.7	13.9	1,298.5	0.6	1.7	1	1	0
07/23/2020 11:00	0.7	13.9	1,288.6	0.6	1.7	1	1	0
07/23/2020 12:00	0.7	14.0	1,296.9	0.6	1.7	1	1	0
07/23/2020 13:00	0.7	14.0	1,288.4	0.6	1.7	1	1	0
07/23/2020 14:00	0.6	14.0	1,292.5	0.6	1.5	1	1	0
07/23/2020 15:00	0.6	14.0	1,295.6	0.5	1.5	1	1	0
07/23/2020 16:00	0.6	14.0	1,293.9	0.5	1.5	1	1	0
07/23/2020 17:00	0.6	13.9	1,409.0	0.5	1.6	1	1	0
07/23/2020 18:00	0.6	13.8	1,628.4	0.5	1.8	1	1	0
07/23/2020 19:00	0.6	13.8	1,612.2	0.5	1.8	1	1	0
07/23/2020 20:00	0.9	13.8	1,431.3	0.6	2.4	1	1	0
07/23/2020 21:00	0.8	13.9	1,336.6	0.6	2.0	1	1	0
07/23/2020 22:00	0.9	13.9	1,288.1	0.7	2.2	1	1	0
07/23/2020 23:00	0.9	13.9	1,325.9	0.8	2.3	1	1	0
Average/Sum#:	0.8	13.9	1,332.4	0.7	47.3 #	24 #	24 #	0 #
Minimum:	0.6	13.8	1,282.1	0.5	1.5	1	1	0
Maximum:	1.0	14.0	1,628.4	0.9	2.4	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/24/2020 00:00	0.9	13.9	1,283.6	0.8	2.2	1	1	0
07/24/2020 01:00	0.9	13.9	1,285.1	0.8	2.2	1	1	0
07/24/2020 02:00	0.9	13.9	1,281.4	0.8	2.2	1	1	0
07/24/2020 03:00	1.0	13.9	1,281.9	0.8	2.4	1	1	0
07/24/2020 04:00	1.0	13.9	1,287.1	0.8	2.4	1	1	0
07/24/2020 05:00	1.1	13.9	1,292.4	0.8	2.7	1	1	0
07/24/2020 06:00	1.1	13.9	1,323.8	0.9	2.7	1	1	0
07/24/2020 07:00	0.7	13.8	1,555.6	0.8	2.0	1	1	0
07/24/2020 08:00	0.7	13.8	1,472.3	0.7	1.9	1	0	0
07/24/2020 09:00	0.7	13.9	1,375.7	0.6	1.8	1	0	0
07/24/2020 10:00	0.7	13.9	1,380.6	0.6	1.8	1	0	0
07/24/2020 11:00	0.6	13.9	1,388.3	0.6	1.6	1	0	0
07/24/2020 12:00	0.6	13.9	1,391.0	0.5	1.6	1	0	0
07/24/2020 13:00	0.6	13.9	1,393.8	0.5	1.6	1	0	0
07/24/2020 14:00	0.6	13.9	1,396.5	0.5	1.6	1	0	0
07/24/2020 15:00	0.6	14.0	1,396.5	0.5	1.6	1	0	0
07/24/2020 16:00	0.6	13.9	1,418.4	0.5	1.6	1	0	1
07/24/2020 17:00	1.9	12.5	1,951.8	0.8	5.8	1	0	1
07/24/2020 18:00	1.9	12.4	1,975.1	1.0	5.8	1	0	1
07/24/2020 19:00	1.9	12.5	1,969.8	1.3	5.9	1	0	1
07/24/2020 20:00	1.9	12.5	1,930.2	1.3	5.8	1	0	1
07/24/2020 21:00	0.8	13.9	1,387.5	1.1	2.1	1	0	0
07/24/2020 22:00	0.7	13.9	1,373.4	0.9	1.8	1	0	0
07/24/2020 23:00	0.8	13.9	1,373.1	0.7	2.1	1	0	0
Average/Sum#:	1.0	13.7	1,465.2	0.8	63.2 #	24 #	8 #	5 #
Minimum:	0.6	12.4	1,281.4	0.5	1.6	1	0	0
Maximum:	1.9	14.0	1,975.1	1.3	5.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/25/2020 00:00	0.8	13.9	1,374.7	0.7	2.1	1	0	0
07/25/2020 01:00	0.9	13.9	1,377.2	0.7	2.3	1	0	0
07/25/2020 02:00	0.9	13.9	1,376.3	0.8	2.3	1	0	0
07/25/2020 03:00	0.9	13.9	1,374.2	0.8	2.3	1	0	0
07/25/2020 04:00	1.0	13.9	1,373.5	0.8	2.6	1	0	0
07/25/2020 05:00	1.0	13.9	1,373.9	0.8	2.6	1	0	0
07/25/2020 06:00	1.0	13.9	1,378.8	0.8	2.6	1	0	0
07/25/2020 07:00	0.8	13.9	1,386.9	0.8	2.1	1	0	0
07/25/2020 08:00	0.7	13.9	1,390.1	0.7	1.8	1	0	0
07/25/2020 09:00	0.7	13.9	1,390.3	0.6	1.8	1	0	0
07/25/2020 10:00	0.6	13.9	1,393.8	0.6	1.6	1	0	0
07/25/2020 11:00	0.6	13.9	1,393.4	0.5	1.6	1	0	0
07/25/2020 12:00	0.6	13.9	1,394.1	0.5	1.6	1	0	0
07/25/2020 13:00	0.6	13.9	1,546.5	0.5	1.8	1	0	0
07/25/2020 14:00	0.7	13.9	1,494.7	0.5	2.0	1	0	0
07/25/2020 15:00	0.5	13.9	1,555.1	0.5	1.5	1	1	0
07/25/2020 16:00	0.6	13.9	1,543.5	0.5	1.7	1	1	1
07/25/2020 17:00	1.5	12.1	2,050.1	0.6	4.6	1	1	1
07/25/2020 18:00	1.2	11.7	2,123.1	0.8	3.7	1	1	1
07/25/2020 19:00	1.2	11.7	2,128.3	0.9	3.7	1	1	1
07/25/2020 20:00	1.2	11.8	2,123.7	0.8	3.7	1	1	1
07/25/2020 21:00	1.3	11.9	2,104.6	0.8	4.0	1	1	1
07/25/2020 22:00	1.4	12.2	2,043.3	0.9	4.3	1	1	1
07/25/2020 23:00	1.3	12.0	2,056.7	0.9	4.0	1	1	1
Average/Sum#:	0.9	13.3	1,614.5	0.7	62.3 #	24 #	9 #	8 #
Minimum:	0.5	11.7	1,373.5	0.5	1.5	1	0	0
Maximum:	1.5	13.9	2,128.3	0.9	4.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/26/2020 00:00	0.7	13.9	1,446.6	0.8	1.9	1	1	0
07/26/2020 01:00	0.6	13.9	1,600.8	0.7	1.8	1	1	0
07/26/2020 02:00	0.6	13.9	1,545.7	0.5	1.7	1	1	0
07/26/2020 03:00	0.7	13.9	1,502.5	0.5	2.0	1	1	0
07/26/2020 04:00	0.6	13.9	1,533.0	0.5	1.7	1	1	0
07/26/2020 05:00	0.8	13.9	1,412.1	0.6	2.1	1	1	0
07/26/2020 06:00	0.9	13.9	1,284.0	0.7	2.2	1	1	0
07/26/2020 07:00	0.8	13.9	1,284.6	0.7	1.9	1	1	0
07/26/2020 08:00	0.7	13.9	1,286.0	0.7	1.7	1	1	0
07/26/2020 09:00	0.8	13.9	1,290.0	0.7	1.9	1	1	0
07/26/2020 10:00	0.7	13.9	1,380.2	0.6	1.8	1	1	0
07/26/2020 11:00	0.6	13.9	1,535.8	0.6	1.7	1	1	0
07/26/2020 12:00	0.5	13.9	1,549.6	0.5	1.5	1	1	0
07/26/2020 13:00	0.6	13.8	1,700.5	0.5	1.9	1	1	1
07/26/2020 14:00	1.5	12.1	2,034.1	0.6	4.6	1	1	1
07/26/2020 15:00	0.8	13.4	1,629.4	0.7	2.3	1	1	1
07/26/2020 16:00	1.1	12.9	1,790.6	0.8	3.3	1	1	1
07/26/2020 17:00	1.3	11.4	2,168.3	0.7	3.9	1	1	1
07/26/2020 18:00	1.2	11.4	2,165.2	0.8	3.6	1	1	1
07/26/2020 19:00	1.1	11.3	2,175.3	0.7	3.3	1	1	1
07/26/2020 20:00	1.2	11.6	2,131.5	0.7	3.6	1	1	1
07/26/2020 21:00	1.2	11.7	2,119.2	0.8	3.7	1	1	1
07/26/2020 22:00	1.4	12.4	1,988.7	0.9	4.3	1	1	1
07/26/2020 23:00	1.2	12.8	1,795.9	0.9	3.5	1	1	1
Average/Sum#:	0.9	13.1	1,681.2	0.7	61.9 #	24 #	24 #	11 #
Minimum:	0.5	11.3	1,284.0	0.5	1.5	1	1	0
Maximum:	1.5	13.9	2,175.3	0.9	4.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/27/2020 00:00	1.0	13.9	1,288.5	0.9	2.4	1	1	0
07/27/2020 01:00	1.0	13.9	1,284.7	0.8	2.4	1	1	0
07/27/2020 02:00	0.8	13.9	1,285.9	0.8	1.9	1	1	0
07/27/2020 03:00	0.7	13.9	1,288.4	0.7	1.7	1	1	0
07/27/2020 04:00	0.9	13.9	1,297.2	0.7	2.2	1	1	0
07/27/2020 05:00	0.6	13.8	1,645.4	0.6	1.8	1	1	0
07/27/2020 06:00	0.6	13.9	1,674.0	0.6	1.9	1	1	0
07/27/2020 07:00	0.5	13.9	1,681.9	0.5	1.6	1	1	0
07/27/2020 08:00	0.5	13.9	1,646.3	0.4	1.6	1	1	0
07/27/2020 09:00	0.6	13.9	1,345.5	0.4	1.5	1	1	0
07/27/2020 10:00	0.5	13.9	1,572.6	0.4	1.5	1	1	0
07/27/2020 11:00	0.6	13.8	1,545.0	0.5	1.7	1	1	1
07/27/2020 12:00	1.5	12.0	2,071.9	0.6	4.6	1	1	1
07/27/2020 13:00	1.3	11.5	2,140.3	0.8	3.9	1	1	1
07/27/2020 14:00	1.3	11.6	2,107.6	0.9	3.9	1	1	1
07/27/2020 15:00	1.3	11.4	2,149.8	0.8	3.9	1	1	1
07/27/2020 16:00	1.3	11.3	2,155.5	0.8	3.9	1	1	1
07/27/2020 17:00	1.3	11.3	2,161.2	0.8	3.9	1	1	1
07/27/2020 18:00	1.2	11.4	2,144.7	0.8	3.6	1	1	1
07/27/2020 19:00	1.2	11.5	2,130.7	0.8	3.6	1	1	1
07/27/2020 20:00	1.2	11.3	2,174.2	0.7	3.6	1	1	1
07/27/2020 21:00	1.2	11.5	2,134.4	0.8	3.6	1	1	1
07/27/2020 22:00	1.2	11.6	2,129.7	0.8	3.6	1	1	1
07/27/2020 23:00	1.3	12.3	1,962.6	0.8	3.9	1	1	1
Average/Sum#:	1.0	12.7	1,792.4	0.7	68.2 #	24 #	24 #	13 #
Minimum:	0.5	11.3	1,284.7	0.4	1.5	1	1	0
Maximum:	1.5	13.9	2,174.2	0.9	4.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/28/2020 00:00	0.6	13.8	1,545.8	0.7	1.7	1	1	0
07/28/2020 01:00	0.8	13.8	1,507.2	0.7	2.2	1	1	0
07/28/2020 02:00	0.7	13.8	1,427.7	0.6	1.9	1	1	0
07/28/2020 03:00	0.6	13.8	1,505.6	0.6	1.7	1	1	0
07/28/2020 04:00	0.6	13.8	1,541.3	0.5	1.7	1	1	0
07/28/2020 05:00	0.6	13.8	1,600.3	0.5	1.8	1	1	0
07/28/2020 06:00	0.6	13.8	1,690.1	0.5	1.9	1	1	0
07/28/2020 07:00	0.5	13.8	1,674.4	0.5	1.6	1	1	0
07/28/2020 08:00	0.6	13.8	1,524.7	0.5	1.7	1	1	0
07/28/2020 09:00	0.8	13.9	1,314.4	0.5	2.0	1	1	0
07/28/2020 10:00	0.5	13.9	1,519.9	0.5	1.4	1	1	0
07/28/2020 11:00	0.6	13.8	1,511.6	0.5	1.7	1	1	1
07/28/2020 12:00	1.5	12.0	2,070.1	0.6	4.6	1	1	1
07/28/2020 13:00	1.3	11.7	2,115.1	0.8	3.9	1	1	1
07/28/2020 14:00	1.3	11.5	2,123.5	0.9	3.9	1	1	1
07/28/2020 15:00	1.3	11.3	2,159.6	0.8	3.9	1	1	1
07/28/2020 16:00	1.3	11.3	2,162.5	0.8	3.9	1	1	1
07/28/2020 17:00	1.3	11.3	2,159.1	0.8	3.9	1	1	1
07/28/2020 18:00	1.2	11.3	2,163.8	0.8	3.6	1	1	1
07/28/2020 19:00	1.2	11.5	2,123.5	0.8	3.6	1	1	1
07/28/2020 20:00	1.1	11.7	2,144.0	0.7	3.4	1	1	1
07/28/2020 21:00	1.2	11.7	2,146.5	0.8	3.7	1	1	1
07/28/2020 22:00	1.2	11.8	2,119.2	0.8	3.7	1	1	1
07/28/2020 23:00	1.4	11.9	2,093.8	0.8	4.3	1	1	1
Average/Sum#:	1.0	12.7	1,831.0	0.7	67.7 #	24 #	24 #	13 #
Minimum:	0.5	11.3	1,314.4	0.5	1.4	1	1	0
Maximum:	1.5	13.9	2,163.8	0.9	4.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/29/2020 00:00	1.4	12.5	1,974.7	0.9	4.3	1	1	1
07/29/2020 01:00	1.4	12.7	1,946.8	1.0	4.4	1	1	1
07/29/2020 02:00	1.4	12.7	1,945.1	1.0	4.4	1	1	1
07/29/2020 03:00	1.4	12.7	1,955.6	1.0	4.4	1	1	1
07/29/2020 04:00	1.4	12.2	2,066.8	1.0	4.4	1	1	1
07/29/2020 05:00	1.4	12.1	2,085.2	0.9	4.4	1	1	1
07/29/2020 06:00	1.4	12.2	2,070.4	0.9	4.4	1	1	1
07/29/2020 07:00	1.4	12.7	1,955.9	0.9	4.4	1	1	1
07/29/2020 08:00	1.4	12.7	1,952.9	1.0	4.4	1	1	1
07/29/2020 09:00	1.4	12.6	1,969.4	1.0	4.4	1	1	1
07/29/2020 10:00	1.3	12.0	2,090.0	1.0	4.0	1	1	1
07/29/2020 11:00	1.3	11.8	2,107.2	0.9	4.0	1	1	1
07/29/2020 12:00	1.3	11.8	2,122.6	0.8	4.0	1	1	1
07/29/2020 13:00	1.3	11.7	2,114.3	0.8	3.9	1	1	1
07/29/2020 14:00	1.3	11.4	2,160.3	0.8	3.9	1	1	1
07/29/2020 15:00	1.2	11.3	2,173.9	0.8	3.6	1	1	1
07/29/2020 16:00	1.2	11.4	2,165.9	0.7	3.6	1	1	1
07/29/2020 17:00	1.2	11.4	2,164.1	0.7	3.6	1	1	1
07/29/2020 18:00	1.2	11.4	2,157.9	0.7	3.6	1	1	1
07/29/2020 19:00	1.1	11.4	2,176.3	0.7	3.3	1	1	1
07/29/2020 20:00	1.1	11.5	2,164.4	0.7	3.3	1	1	1
07/29/2020 21:00	1.2	11.8	2,113.1	0.7	3.7	1	1	1
07/29/2020 22:00	1.2	11.7	2,136.9	0.8	3.7	1	1	1
07/29/2020 23:00	1.2	11.8	2,114.2	0.8	3.7	1	1	1
Average/Sum#:	1.3	12.0	2,078.5	0.9	95.8 #	24 #	24 #	24 #
Minimum:	1.1	11.3	1,945.1	0.7	3.3	1	1	1
Maximum:	1.4	12.7	2,176.3	1.0	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/30/2020 00:00	1.3	12.0	2,084.3	0.8	4.0	1	1	1
07/30/2020 01:00	1.3	12.6	1,963.5	0.9	4.1	1	1	1
07/30/2020 02:00	1.4	12.7	1,947.6	0.9	4.4	1	1	1
07/30/2020 03:00	1.4	12.8	1,942.8	1.0	4.4	1	1	1
07/30/2020 04:00	1.4	12.8	1,954.0	1.0	4.5	1	1	1
07/30/2020 05:00	1.4	12.1	2,080.0	1.0	4.4	1	1	1
07/30/2020 06:00	1.4	12.2	2,065.9	0.9	4.4	1	1	1
07/30/2020 07:00	1.3	12.7	1,951.1	0.9	4.1	1	1	1
07/30/2020 08:00	1.3	12.7	1,947.5	0.9	4.1	1	1	1
07/30/2020 09:00	1.3	12.6	1,966.1	0.9	4.1	1	1	1
07/30/2020 10:00	1.2	12.0	2,087.4	0.9	3.7	1	1	1
07/30/2020 11:00	1.2	11.8	2,121.5	0.8	3.7	1	1	1
07/30/2020 12:00	1.2	11.9	2,110.1	0.8	3.7	1	1	1
07/30/2020 13:00	1.2	11.8	2,112.2	0.8	3.7	1	1	1
07/30/2020 14:00	1.2	11.7	2,121.2	0.8	3.7	1	1	1
07/30/2020 15:00	1.2	11.4	2,151.8	0.8	3.6	1	1	1
07/30/2020 16:00	1.2	11.4	2,159.8	0.7	3.6	1	1	1
07/30/2020 17:00	1.2	11.3	2,173.8	0.7	3.6	1	1	1
07/30/2020 18:00	1.2	11.3	2,169.5	0.7	3.6	1	1	1
07/30/2020 19:00	1.2	11.9	2,066.4	0.7	3.6	1	1	1
07/30/2020 20:00	1.2	11.9	2,081.1	0.8	3.7	1	1	1
07/30/2020 21:00	1.3	12.0	2,068.3	0.8	4.0	1	1	1
07/30/2020 22:00	1.2	11.8	2,113.9	0.8	3.7	1	1	1
07/30/2020 23:00	1.2	12.1	2,056.0	0.8	3.7	1	1	1
Average/Sum#:	1.3	12.1	2,062.3	0.8	94.1 #	24 #	24 #	24 #
Minimum:	1.2	11.3	1,942.8	0.7	3.6	1	1	1
Maximum:	1.4	12.8	2,173.8	1.0	4.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/31/2020 00:00	1.4	12.5	1,975.4	0.9	4.3	1	1	1
07/31/2020 01:00	1.4	12.7	1,939.8	0.9	4.4	1	1	1
07/31/2020 02:00	1.4	12.8	1,936.5	1.0	4.4	1	1	1
07/31/2020 03:00	1.4	12.8	1,935.9	1.0	4.4	1	1	1
07/31/2020 04:00	1.4	12.8	1,944.4	1.0	4.4	1	1	1
07/31/2020 05:00	1.5	12.2	2,042.6	1.0	4.7	1	1	1
07/31/2020 06:00	1.5	12.2	2,052.4	1.0	4.7	1	1	1
07/31/2020 07:00	1.4	12.6	1,963.0	1.0	4.4	1	1	1
07/31/2020 08:00	1.4	12.7	1,938.8	1.0	4.4	1	1	1
07/31/2020 09:00	1.3	12.4	2,004.3	1.0	4.0	1	1	1
07/31/2020 10:00	1.2	12.0	2,080.2	0.9	3.7	1	1	1
07/31/2020 11:00	1.3	11.8	2,104.9	0.8	4.0	1	1	1
07/31/2020 12:00	1.3	11.8	2,105.7	0.8	4.0	1	1	1
07/31/2020 13:00	1.3	11.7	2,115.5	0.8	3.9	1	1	1
07/31/2020 14:00	1.3	11.6	2,120.0	0.8	3.9	1	1	1
07/31/2020 15:00	1.3	11.5	2,131.8	0.8	3.9	1	1	1
07/31/2020 16:00	1.3	11.5	2,132.0	0.8	3.9	1	1	1
07/31/2020 17:00	1.3	11.5	2,123.0	0.8	3.9	1	1	1
07/31/2020 18:00	1.2	11.3	2,165.2	0.8	3.6	1	1	1
07/31/2020 19:00	1.2	11.6	2,114.5	0.8	3.6	1	1	1
07/31/2020 20:00	1.3	11.7	2,118.4	0.8	4.0	1	1	1
07/31/2020 21:00	1.2	11.8	2,093.8	0.8	3.6	1	1	1
07/31/2020 22:00	1.3	11.9	2,084.6	0.8	4.0	1	1	1
07/31/2020 23:00	1.4	12.0	2,063.1	0.9	4.3	1	1	1
Average/Sum#:	1.3	12.1	2,053.6	0.9	98.4 #	24 #	24 #	24 #
Minimum:	1.2	11.3	1,935.9	0.8	3.6	1	1	1
Maximum:	1.5	12.8	2,165.2	1.0	4.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/01/2020 00:00	1.3	12.2	2,048.4	0.9	4.0	1	1	1
08/01/2020 01:00	1.4	12.7	1,949.3	0.9	4.4	1	1	1
08/01/2020 02:00	1.4	12.8	1,909.8	1.0	4.4	1	1	1
08/01/2020 03:00	0.8	13.8	1,435.4	0.9	2.1	1	1	0
08/01/2020 04:00	0.5	13.8	1,527.8	0.7	1.4	1	1	0
08/01/2020 05:00	0.6	13.8	1,543.4	0.5	1.7	1	1	0
08/01/2020 06:00	0.7	13.9	1,302.0	0.5	1.7	1	1	0
08/01/2020 07:00	0.7	13.9	1,290.5	0.6	1.7	1	1	0
08/01/2020 08:00	0.6	13.9	1,292.1	0.6	1.5	1	1	0
08/01/2020 09:00	0.6	13.9	1,297.1	0.5	1.5	1	1	0
08/01/2020 10:00	0.5	13.8	1,436.9	0.5	1.3	1	1	0
08/01/2020 11:00	0.6	13.8	1,511.6	0.5	1.7	1	1	1
08/01/2020 12:00	1.5	12.1	2,052.7	0.6	4.6	1	1	1
08/01/2020 13:00	1.4	11.8	2,103.4	0.8	4.3	1	1	1
08/01/2020 14:00	1.4	11.7	2,108.3	0.9	4.2	1	1	1
08/01/2020 15:00	1.4	11.7	2,129.4	0.9	4.3	1	1	1
08/01/2020 16:00	1.4	11.6	2,149.5	0.9	4.3	1	1	1
08/01/2020 17:00	1.3	11.6	2,161.5	0.9	4.0	1	1	1
08/01/2020 18:00	1.3	11.6	2,154.9	0.8	4.0	1	1	1
08/01/2020 19:00	1.3	11.6	2,155.9	0.8	4.0	1	1	1
08/01/2020 20:00	1.3	11.6	2,149.8	0.8	4.0	1	1	1
08/01/2020 21:00	1.3	11.8	2,093.4	0.8	3.9	1	1	1
08/01/2020 22:00	1.3	11.9	2,087.7	0.8	4.0	1	1	1
08/01/2020 23:00	1.3	12.5	1,932.0	0.9	3.9	1	1	1
Average/Sum#:	1.1	12.7	1,826.0	0.8	76.9 #	24 #	24 #	16 #
Minimum:	0.5	11.6	1,290.5	0.5	1.3	1	1	0
Maximum:	1.5	13.9	2,161.5	1.0	4.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/02/2020 00:00	0.8	13.8	1,427.2	0.8	2.1	1	1	0
08/02/2020 01:00	0.9	13.9	1,285.3	0.8	2.2	1	1	0
08/02/2020 02:00	0.8	13.9	1,288.3	0.7	1.9	1	1	0
08/02/2020 03:00	0.7	13.9	1,292.4	0.7	1.7	1	1	0
08/02/2020 04:00	0.6	13.8	1,497.1	0.6	1.7	1	1	0
08/02/2020 05:00	0.7	13.9	1,383.8	0.6	1.8	1	1	0
08/02/2020 06:00	0.6	13.9	1,295.7	0.5	1.5	1	1	0
08/02/2020 07:00	0.6	13.9	1,293.1	0.5	1.5	1	1	0
08/02/2020 08:00	0.6	13.9	1,294.2	0.5	1.5	1	1	0
08/02/2020 09:00	0.6	13.9	1,298.7	0.5	1.5	1	1	0
08/02/2020 10:00	0.6	13.9	1,302.2	0.5	1.5	1	1	0
08/02/2020 11:00	0.6	13.9	1,304.3	0.5	1.5	1	1	0
08/02/2020 12:00	0.7	13.9	1,301.4	0.5	1.7	1	1	0
08/02/2020 13:00	0.7	13.9	1,313.6	0.6	1.7	1	1	0
08/02/2020 14:00	0.6	13.9	1,365.4	0.6	1.5	1	1	0
08/02/2020 15:00	0.6	13.8	1,520.5	0.5	1.7	1	1	1
08/02/2020 16:00	1.6	12.2	2,010.3	0.7	4.9	1	1	1
08/02/2020 17:00	1.5	11.8	2,090.9	0.9	4.6	1	1	1
08/02/2020 18:00	1.4	11.8	2,093.1	1.0	4.3	1	1	1
08/02/2020 19:00	1.4	11.6	2,123.9	0.9	4.2	1	1	1
08/02/2020 20:00	1.4	11.8	2,100.9	0.9	4.3	1	1	1
08/02/2020 21:00	1.4	11.7	2,115.0	0.9	4.3	1	1	1
08/02/2020 22:00	1.4	11.8	2,094.1	0.9	4.3	1	1	1
08/02/2020 23:00	1.4	12.5	1,947.4	0.9	4.3	1	1	1
Average/Sum#:	0.9	13.2	1,585.0	0.7	62.2 #	24 #	24 #	9 #
Minimum:	0.6	11.6	1,285.3	0.5	1.5	1	1	0
Maximum:	1.6	13.9	2,123.9	1.0	4.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/03/2020 00:00	0.9	13.8	1,436.0	0.9	2.4	1	1	0
08/03/2020 01:00	0.9	13.8	1,320.2	0.8	2.2	1	1	0
08/03/2020 02:00	0.9	13.9	1,284.0	0.7	2.2	1	1	0
08/03/2020 03:00	0.8	13.9	1,292.9	0.7	2.0	1	1	0
08/03/2020 04:00	0.6	13.8	1,509.6	0.7	1.7	1	1	0
08/03/2020 05:00	0.7	13.8	1,490.3	0.6	1.9	1	1	0
08/03/2020 06:00	0.7	13.8	1,577.3	0.6	2.1	1	1	0
08/03/2020 07:00	0.6	13.8	1,539.3	0.6	1.7	1	1	0
08/03/2020 08:00	0.6	13.8	1,485.5	0.5	1.7	1	1	0
08/03/2020 09:00	0.8	13.8	1,375.4	0.6	2.0	1	1	0
08/03/2020 10:00	0.6	13.9	1,301.4	0.6	1.5	1	1	0
08/03/2020 11:00	0.6	13.9	1,363.0	0.6	1.5	1	1	0
08/03/2020 12:00	0.6	13.8	1,501.1	0.5	1.7	1	1	1
08/03/2020 13:00	1.5	12.0	2,057.8	0.7	4.6	1	1	1
08/03/2020 14:00	1.4	11.8	2,097.3	0.8	4.3	1	1	1
08/03/2020 15:00	1.4	11.8	2,088.5	0.9	4.2	1	1	1
08/03/2020 16:00	1.4	11.7	2,090.2	0.9	4.2	1	1	1
08/03/2020 17:00	1.4	11.6	2,101.4	0.9	4.2	1	1	1
08/03/2020 18:00	1.4	11.6	2,094.0	0.9	4.2	1	1	1
08/03/2020 19:00	1.4	11.6	2,118.2	0.9	4.2	1	1	1
08/03/2020 20:00	1.4	11.7	2,103.1	0.9	4.2	1	1	1
08/03/2020 21:00	1.4	11.7	2,108.6	0.9	4.2	1	1	1
08/03/2020 22:00	1.4	11.8	2,095.8	0.9	4.3	1	1	1
08/03/2020 23:00	1.2	12.8	1,799.3	0.9	3.5	1	1	1
Average/Sum#:	1.0	12.9	1,717.9	0.8	70.7 #	24 #	24 #	12 #
Minimum:	0.6	11.6	1,284.0	0.5	1.5	1	1	0
Maximum:	1.5	13.9	2,118.2	0.9	4.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/04/2020 00:00	0.9	13.8	1,288.2	0.8	2.2	1	1	0
08/04/2020 01:00	0.8	13.8	1,284.7	0.8	1.9	1	1	0
08/04/2020 02:00	0.7	13.8	1,294.4	0.7	1.7	1	1	0
08/04/2020 03:00	0.8	13.8	1,290.2	0.7	1.9	1	1	0
08/04/2020 04:00	0.8	13.8	1,293.1	0.7	1.9	1	1	0
08/04/2020 05:00	0.8	13.8	1,407.2	0.7	2.1	1	1	0
08/04/2020 06:00	0.9	13.8	1,303.5	0.7	2.2	1	1	0
08/04/2020 07:00	0.8	13.8	1,290.6	0.7	1.9	1	1	0
08/04/2020 08:00	0.7	13.8	1,291.4	0.7	1.7	1	1	0
08/04/2020 09:00	0.7	13.9	1,293.8	0.6	1.7	1	1	0
08/04/2020 10:00	0.6	13.9	1,301.9	0.6	1.5	1	1	0
08/04/2020 11:00	0.6	13.9	1,300.3	0.5	1.5	1	1	0
08/04/2020 12:00	0.6	13.9	1,438.4	0.5	1.6	1	1	0
08/04/2020 13:00	0.6	13.8	1,476.4	0.5	1.6	1	1	0
08/04/2020 14:00	0.7	13.9	1,319.8	0.5	1.7	1	1	0
08/04/2020 15:00	0.6	13.8	1,529.7	0.5	1.7	1	1	0
08/04/2020 16:00	0.7	13.8	1,506.0	0.6	2.0	1	1	1
08/04/2020 17:00	1.5	11.8	2,065.6	0.7	4.5	1	1	1
08/04/2020 18:00	1.4	11.5	2,118.0	0.8	4.2	1	1	1
08/04/2020 19:00	1.4	11.5	2,121.8	0.9	4.2	1	1	1
08/04/2020 20:00	1.4	11.7	2,104.5	0.9	4.2	1	1	1
08/04/2020 21:00	1.4	11.8	2,095.2	0.9	4.3	1	1	1
08/04/2020 22:00	1.3	12.4	1,975.2	0.9	4.0	1	1	1
08/04/2020 23:00	1.0	13.0	1,784.8	0.8	3.0	1	1	1
Average/Sum#:	0.9	13.3	1,548.9	0.7	59.2 #	24 #	24 #	8 #
Minimum:	0.6	11.5	1,284.7	0.5	1.5	1	1	0
Maximum:	1.5	13.9	2,121.8	0.9	4.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/05/2020 00:00	0.8	13.8	1,287.7	0.8	1.9	1	1	0
08/05/2020 01:00	0.7	13.8	1,288.6	0.7	1.7	1	1	0
08/05/2020 02:00	0.7	13.8	1,283.8	0.6	1.7	1	1	0
08/05/2020 03:00	0.8	13.8	1,284.0	0.6	1.9	1	1	0
08/05/2020 04:00	0.9	13.8	1,286.1	0.7	2.2	1	1	0
08/05/2020 05:00	0.9	13.8	1,319.3	0.7	2.2	1	1	0
08/05/2020 06:00	0.9	13.8	1,283.7	0.7	2.1	1	1	0
08/05/2020 07:00	0.8	13.8	1,284.1	0.7	1.9	1	1	0
08/05/2020 08:00	0.7	13.8	1,286.4	0.7	1.7	1	1	0
08/05/2020 09:00	0.6	13.8	1,288.3	0.6	1.4	1	1	0
08/05/2020 10:00	0.6	13.8	1,291.1	0.5	1.4	1	1	0
08/05/2020 11:00	0.6	13.8	1,293.9	0.5	1.4	1	1	0
08/05/2020 12:00	0.6	13.9	1,293.9	0.5	1.5	1	1	0
08/05/2020 13:00	0.6	13.9	1,294.5	0.5	1.5	1	1	0
08/05/2020 14:00	0.7	13.8	1,292.5	0.5	1.7	1	1	0
08/05/2020 15:00	0.7	13.8	1,290.9	0.6	1.7	1	1	0
08/05/2020 16:00	0.7	13.8	1,299.8	0.6	1.7	1	1	0
08/05/2020 17:00	1.1	13.1	1,762.6	0.7	3.3	1	1	1
08/05/2020 18:00	1.5	11.9	2,085.8	0.8	4.6	1	1	1
08/05/2020 19:00	1.4	12.1	2,011.9	0.9	4.2	1	1	1
08/05/2020 20:00	0.5	13.8	1,582.2	0.8	1.5	1	1	0
08/05/2020 21:00	0.6	13.8	1,405.7	0.6	1.6	1	1	0
08/05/2020 22:00	0.6	13.8	1,386.0	0.5	1.5	1	1	0
08/05/2020 23:00	0.8	13.8	1,284.9	0.6	1.9	1	1	0
Average/Sum#:	0.8	13.6	1,394.5	0.6	48.2 #	24 #	24 #	3 #
Minimum:	0.5	11.9	1,283.7	0.5	1.4	1	1	0
Maximum:	1.5	13.9	2,085.8	0.9	4.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/06/2020 00:00	0.8	13.8	1,283.5	0.6	1.9	1	1	0
08/06/2020 01:00	0.8	13.8	1,283.2	0.7	1.9	1	1	0
08/06/2020 02:00	0.8	13.8	1,283.6	0.7	1.9	1	1	0
08/06/2020 03:00	0.8	13.8	1,286.8	0.7	1.9	1	1	0
08/06/2020 04:00	0.8	13.8	1,303.4	0.7	1.9	1	1	0
08/06/2020 05:00	0.9	13.8	1,326.8	0.7	2.2	1	1	0
08/06/2020 06:00	0.9	13.8	1,290.6	0.7	2.2	1	1	0
08/06/2020 07:00	0.7	13.8	1,296.8	0.7	1.7	1	1	0
08/06/2020 08:00	0.7	13.8	1,298.4	0.6	1.7	1	1	0
08/06/2020 09:00	0.6	13.8	1,297.9	0.6	1.4	1	1	0
08/06/2020 10:00	0.6	13.8	1,296.8	0.5	1.4	1	1	0
08/06/2020 11:00	0.6	13.8	1,296.1	0.5	1.4	1	1	0
08/06/2020 12:00	0.6	13.9	1,296.0	0.5	1.5	1	1	0
08/06/2020 13:00	0.6	13.9	1,291.5	0.5	1.5	1	1	0
08/06/2020 14:00	0.7	13.9	1,290.9	0.5	1.7	1	1	0
08/06/2020 15:00	0.7	13.9	1,292.1	0.6	1.7	1	1	0
08/06/2020 16:00	0.7	13.9	1,289.8	0.6	1.7	1	1	0
08/06/2020 17:00	0.6	13.9	1,400.8	0.6	1.6	1	1	0
08/06/2020 18:00	0.6	13.8	1,401.5	0.5	1.6	1	1	0
08/06/2020 19:00	0.8	13.8	1,308.2	0.6	1.9	1	1	0
08/06/2020 20:00	0.8	13.8	1,284.3	0.6	1.9	1	1	0
08/06/2020 21:00	0.8	13.8	1,280.5	0.7	1.9	1	1	0
08/06/2020 22:00	0.9	13.8	1,279.5	0.7	2.1	1	1	0
08/06/2020 23:00	0.9	13.8	1,276.5	0.7	2.1	1	1	0
Average/Sum#:	0.7	13.8	1,301.5	0.6	42.7 #	24 #	24 #	0 #
Minimum:	0.6	13.8	1,276.5	0.5	1.4	1	1	0
Maximum:	0.9	13.9	1,401.5	0.7	2.2	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/07/2020 00:00	0.8	13.8	1,283.3	0.7	1.9	1	1	0
08/07/2020 01:00	0.8	13.8	1,282.3	0.7	1.9	1	1	0
08/07/2020 02:00	0.7	13.8	1,282.5	0.7	1.7	1	1	0
08/07/2020 03:00	0.7	13.8	1,283.2	0.6	1.7	1	1	0
08/07/2020 04:00	0.8	13.8	1,327.8	0.6	2.0	1	1	0
08/07/2020 05:00	1.0	13.8	1,317.6	0.7	2.5	1	1	0
08/07/2020 06:00	0.8	13.8	1,283.4	0.7	1.9	1	1	0
08/07/2020 07:00	0.8	13.8	1,287.6	0.7	1.9	1	1	0
08/07/2020 08:00	0.7	13.8	1,294.2	0.7	1.7	1	1	0
08/07/2020 09:00	0.6	13.9	1,297.4	0.6	1.5	1	1	0
08/07/2020 10:00	0.6	13.9	1,295.5	0.5	1.5	1	1	0
08/07/2020 11:00	0.6	13.9	1,295.8	0.5	1.5	1	1	0
08/07/2020 12:00	0.7	13.9	1,291.2	0.5	1.7	1	1	0
08/07/2020 13:00	0.6	13.9	1,347.5	0.5	1.5	1	1	0
08/07/2020 14:00	0.6	13.9	1,357.5	0.5	1.5	1	1	0
08/07/2020 15:00	0.7	13.9	1,295.0	0.5	1.7	1	1	0
08/07/2020 16:00	0.7	13.9	1,399.1	0.6	1.8	1	1	0
08/07/2020 17:00	0.6	13.8	1,464.7	0.6	1.6	1	1	0
08/07/2020 18:00	0.7	13.7	1,681.6	0.6	2.2	1	1	0
08/07/2020 19:00	0.7	13.7	1,643.7	0.6	2.1	1	1	0
08/07/2020 20:00	0.8	13.8	1,483.6	0.6	2.2	1	1	0
08/07/2020 21:00	0.9	13.8	1,338.2	0.7	2.2	1	1	0
08/07/2020 22:00	0.7	13.8	1,391.2	0.7	1.8	1	1	0
08/07/2020 23:00	0.7	13.8	1,445.2	0.6	1.9	1	1	0
Average/Sum#:	0.7	13.8	1,361.2	0.6	43.9 #	24 #	24 #	0 #
Minimum:	0.6	13.7	1,282.3	0.5	1.5	1	1	0
Maximum:	1.0	13.9	1,681.6	0.7	2.5	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/08/2020 00:00	0.8	13.8	1,350.6	0.6	2.0	1	1	0
08/08/2020 01:00	0.9	13.8	1,283.4	0.7	2.1	1	1	0
08/08/2020 02:00	0.9	13.8	1,280.7	0.7	2.1	1	1	0
08/08/2020 03:00	0.9	13.8	1,284.7	0.7	2.2	1	1	0
08/08/2020 04:00	0.8	13.8	1,288.0	0.7	1.9	1	1	0
08/08/2020 05:00	1.0	13.8	1,283.6	0.7	2.4	1	1	0
08/08/2020 06:00	1.0	13.8	1,284.2	0.8	2.4	1	1	0
08/08/2020 07:00	0.8	13.8	1,291.8	0.8	1.9	1	1	0
08/08/2020 08:00	0.7	13.8	1,290.4	0.7	1.7	1	1	0
08/08/2020 09:00	0.7	13.8	1,292.5	0.6	1.7	1	1	0
08/08/2020 10:00	0.8	13.8	1,295.0	0.6	1.9	1	1	0
08/08/2020 11:00	0.8	13.9	1,293.2	0.7	2.0	1	1	0
08/08/2020 12:00	0.7	13.9	1,292.2	0.7	1.7	1	1	0
08/08/2020 13:00	0.6	13.9	1,415.5	0.6	1.6	1	1	0
08/08/2020 14:00	0.7	13.9	1,325.3	0.6	1.8	1	1	0
08/08/2020 15:00	0.6	13.9	1,370.9	0.5	1.6	1	1	0
08/08/2020 16:00	0.7	13.8	1,446.5	0.6	1.9	1	1	1
08/08/2020 17:00	1.6	11.8	2,070.2	0.7	4.8	1	1	1
08/08/2020 18:00	1.3	11.4	2,149.9	0.8	3.9	1	1	1
08/08/2020 19:00	1.3	11.3	2,153.3	0.9	3.9	1	1	1
08/08/2020 20:00	1.4	11.6	2,109.5	0.8	4.2	1	1	1
08/08/2020 21:00	1.4	11.7	2,098.2	0.9	4.2	1	1	1
08/08/2020 22:00	1.4	12.2	2,002.8	0.9	4.3	1	1	1
08/08/2020 23:00	1.5	12.5	1,935.2	1.0	4.6	1	1	1
Average/Sum#:	1.0	13.2	1,537.0	0.7	62.8 #	24 #	24 #	8 #
Minimum:	0.6	11.3	1,280.7	0.5	1.6	1	1	0
Maximum:	1.6	13.9	2,153.3	1.0	4.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/09/2020 00:00	0.9	13.7	1,543.1	0.9	2.5	1	1	0
08/09/2020 01:00	1.1	13.8	1,303.9	0.9	2.7	1	1	0
08/09/2020 02:00	1.0	13.8	1,279.4	0.8	2.4	1	1	0
08/09/2020 03:00	0.9	13.8	1,285.1	0.8	2.2	1	1	0
08/09/2020 04:00	0.8	13.8	1,286.9	0.7	1.9	1	1	0
08/09/2020 05:00	0.8	13.8	1,287.5	0.7	1.9	1	1	0
08/09/2020 06:00	0.8	13.8	1,291.3	0.7	1.9	1	1	0
08/09/2020 07:00	0.7	13.8	1,294.1	0.7	1.7	1	1	0
08/09/2020 08:00	0.7	13.8	1,296.8	0.6	1.7	1	1	0
08/09/2020 09:00	0.7	13.8	1,294.8	0.6	1.7	1	1	0
08/09/2020 10:00	0.7	13.8	1,293.0	0.6	1.7	1	1	0
08/09/2020 11:00	0.6	13.9	1,295.2	0.6	1.5	1	1	0
08/09/2020 12:00	0.6	13.8	1,440.5	0.5	1.6	1	1	0
08/09/2020 13:00	0.8	13.8	1,511.7	0.6	2.2	1	1	0
08/09/2020 14:00	0.7	13.9	1,382.5	0.6	1.8	1	1	0
08/09/2020 15:00	0.8	13.6	1,599.8	0.6	2.3	1	1	1
08/09/2020 16:00	1.4	11.7	2,074.2	0.7	4.2	1	1	1
08/09/2020 17:00	1.3	11.3	2,135.8	0.8	3.8	1	1	1
08/09/2020 18:00	1.2	11.3	2,143.8	0.8	3.5	1	1	1
08/09/2020 19:00	1.2	11.5	2,105.2	0.8	3.5	1	1	1
08/09/2020 20:00	1.3	11.6	2,083.6	0.8	3.8	1	1	1
08/09/2020 21:00	1.3	11.6	2,110.4	0.8	3.9	1	1	1
08/09/2020 22:00	1.3	12.1	2,009.5	0.8	3.9	1	1	1
08/09/2020 23:00	1.4	12.4	1,931.7	0.9	4.2	1	1	1
Average/Sum#:	1.0	13.1	1,595.0	0.7	62.5 #	24 #	24 #	9 #
Minimum:	0.6	11.3	1,279.4	0.5	1.5	1	1	0
Maximum:	1.4	13.9	2,143.8	0.9	4.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/10/2020 00:00	0.8	13.7	1,416.0	0.9	2.1	1	1	0
08/10/2020 01:00	0.8	13.8	1,285.9	0.8	1.9	1	1	0
08/10/2020 02:00	0.8	13.8	1,293.1	0.7	1.9	1	1	0
08/10/2020 03:00	0.6	13.8	1,499.2	0.6	1.7	1	1	0
08/10/2020 04:00	0.6	13.8	1,528.1	0.6	1.7	1	1	0
08/10/2020 05:00	0.7	13.8	1,519.4	0.5	2.0	1	1	0
08/10/2020 06:00	0.7	13.7	1,614.1	0.6	2.1	1	1	0
08/10/2020 07:00	0.7	13.8	1,368.8	0.6	1.8	1	1	0
08/10/2020 08:00	0.6	13.8	1,499.3	0.6	1.7	1	1	0
08/10/2020 09:00	0.7	13.8	1,310.5	0.6	1.7	1	1	0
08/10/2020 10:00	0.6	13.8	1,523.8	0.5	1.7	1	1	0
08/10/2020 11:00	0.6	13.8	1,521.1	0.5	1.7	1	1	0
08/10/2020 12:00	0.7	13.9	1,306.0	0.5	1.7	1	1	0
08/10/2020 13:00	0.7	13.9	1,325.3	0.6	1.8	1	1	0
08/10/2020 14:00	0.6	13.9	1,332.1	0.6	1.5	1	1	0
08/10/2020 15:00	0.7	13.6	1,639.8	0.6	2.1	1	1	1
08/10/2020 16:00	1.5	11.6	2,082.7	0.7	4.4	1	1	1
08/10/2020 17:00	1.3	11.2	2,149.8	0.8	3.8	1	1	1
08/10/2020 18:00	1.3	11.5	2,089.6	0.9	3.8	1	1	1
08/10/2020 19:00	1.4	11.8	2,051.2	0.8	4.2	1	1	1
08/10/2020 20:00	1.4	11.9	2,037.5	0.9	4.2	1	1	1
08/10/2020 21:00	1.4	12.0	2,027.7	0.9	4.2	1	1	1
08/10/2020 22:00	1.5	12.3	1,975.4	0.9	4.6	1	1	1
08/10/2020 23:00	1.2	12.9	1,778.1	0.9	3.5	1	1	1
Average/Sum#:	0.9	13.2	1,632.3	0.7	61.8 #	24 #	24 #	9 #
Minimum:	0.6	11.2	1,285.9	0.5	1.5	1	1	0
Maximum:	1.5	13.9	2,149.8	0.9	4.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/11/2020 00:00	1.0	13.8	1,285.0	0.9	2.4	1	1	0
08/11/2020 01:00	0.8	13.8	1,284.5	0.8	1.9	1	1	0
08/11/2020 02:00	0.8	13.8	1,287.0	0.7	1.9	1	1	0
08/11/2020 03:00	0.8	13.8	1,288.2	0.7	1.9	1	1	0
08/11/2020 04:00	0.8	13.8	1,296.4	0.7	1.9	1	1	0
08/11/2020 05:00	0.9	13.8	1,305.9	0.7	2.2	1	1	0
08/11/2020 06:00	0.8	13.8	1,340.9	0.7	2.0	1	1	0
08/11/2020 07:00	0.8	13.8	1,290.2	0.7	1.9	1	1	0
08/11/2020 08:00	0.7	13.8	1,292.4	0.7	1.7	1	1	0
08/11/2020 09:00	0.7	13.8	1,294.6	0.6	1.7	1	1	0
08/11/2020 10:00	0.7	13.8	1,297.6	0.6	1.7	1	1	0
08/11/2020 11:00	0.7	13.8	1,300.1	0.6	1.7	1	1	0
08/11/2020 12:00	0.8	13.8	1,297.5	0.6	1.9	1	1	0
08/11/2020 13:00	0.8	13.8	1,298.2	0.7	1.9	1	1	0
08/11/2020 14:00	0.7	13.8	1,317.1	0.7	1.7	1	1	0
08/11/2020 15:00	0.7	13.8	1,332.3	0.6	1.7	1	1	0
08/11/2020 16:00	0.6	13.8	1,427.9	0.6	1.6	1	1	0
08/11/2020 17:00	0.6	13.8	1,568.3	0.5	1.8	1	1	0
08/11/2020 18:00	0.6	13.8	1,521.0	0.5	1.7	1	1	0
08/11/2020 19:00	0.7	13.8	1,377.6	0.5	1.8	1	1	0
08/11/2020 20:00	0.8	13.8	1,359.2	0.6	2.0	1	1	0
08/11/2020 21:00	0.8	13.8	1,306.5	0.7	1.9	1	1	0
08/11/2020 22:00	0.7	13.8	1,394.4	0.7	1.8	1	1	0
08/11/2020 23:00	0.8	13.8	1,300.7	0.7	1.9	1	1	0
Average/Sum#:	0.8	13.8	1,336.0	0.7	44.6 #	24 #	24 #	0 #
Minimum:	0.6	13.8	1,284.5	0.5	1.6	1	1	0
Maximum:	1.0	13.8	1,568.3	0.9	2.4	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/12/2020 00:00	0.8	13.8	1,288.7	0.7	1.9	1	1	0
08/12/2020 01:00	0.8	13.8	1,311.8	0.7	2.0	1	1	0
08/12/2020 02:00	0.9	13.8	1,288.9	0.7	2.2	1	1	0
08/12/2020 03:00	0.9	13.8	1,292.7	0.7	2.2	1	1	0
08/12/2020 04:00	1.0	13.8	1,312.3	0.7	2.4	1	1	0
08/12/2020 05:00	1.0	13.8	1,304.8	0.8	2.4	1	1	0
08/12/2020 06:00	1.0	13.8	1,299.1	0.8	2.4	1	1	0
08/12/2020 07:00	0.9	13.8	1,313.4	0.8	2.2	1	1	0
08/12/2020 08:00	0.7	13.8	1,385.8	0.7	1.8	1	1	0
08/12/2020 09:00	0.7	13.8	1,334.8	0.6	1.7	1	1	0
08/12/2020 10:00	0.7	13.8	1,342.3	0.6	1.7	1	1	0
08/12/2020 11:00	0.6	13.8	1,386.2	0.6	1.5	1	1	0
08/12/2020 12:00	0.6	13.7	1,644.1	0.5	1.8	1	1	1
08/12/2020 13:00	1.6	12.0	2,040.5	0.7	4.8	1	1	1
08/12/2020 14:00	1.4	11.6	2,096.4	0.8	4.2	1	1	1
08/12/2020 15:00	1.3	11.4	2,138.8	0.9	3.9	1	1	1
08/12/2020 16:00	1.3	11.4	2,135.0	0.8	3.9	1	1	1
08/12/2020 17:00	1.3	11.5	2,117.9	0.8	3.9	1	1	1
08/12/2020 18:00	1.3	11.6	2,104.3	0.8	3.9	1	1	1
08/12/2020 19:00	1.3	11.7	2,098.7	0.8	3.9	1	1	1
08/12/2020 20:00	1.4	11.9	2,061.5	0.8	4.2	1	1	1
08/12/2020 21:00	1.4	12.0	2,052.1	0.9	4.3	1	1	1
08/12/2020 22:00	1.5	12.0	2,068.1	0.9	4.6	1	1	1
08/12/2020 23:00	1.4	12.5	1,943.7	1.0	4.3	1	1	1
Average/Sum#:	1.1	12.9	1,681.7	0.8	72.1 #	24 #	24 #	12 #
Minimum:	0.6	11.4	1,288.7	0.5	1.5	1	1	0
Maximum:	1.6	13.8	2,138.8	1.0	4.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/13/2020 00:00	0.6	13.8	1,680.1	0.8	1.9	1	1	0
08/13/2020 01:00	0.7	13.8	1,618.5	0.7	2.1	1	1	0
08/13/2020 02:00	0.6	13.8	1,551.6	0.5	1.7	1	1	0
08/13/2020 03:00	0.5	13.8	1,584.1	0.5	1.5	1	1	0
08/13/2020 04:00	0.5	13.8	1,590.2	0.4	1.5	1	1	0
08/13/2020 05:00	0.6	13.8	1,610.2	0.4	1.8	1	1	0
08/13/2020 06:00	0.5	13.9	1,697.3	0.4	1.6	1	1	0
08/13/2020 07:00	0.5	13.8	1,599.5	0.4	1.5	1	1	0
08/13/2020 08:00	0.5	13.8	1,679.6	0.4	1.6	1	1	0
08/13/2020 09:00	0.6	13.8	1,603.7	0.4	1.8	1	1	1
08/13/2020 10:00	1.6	12.4	2,006.5	0.7	5.0	1	1	1
08/13/2020 11:00	1.4	11.8	2,120.2	0.8	4.3	1	1	1
08/13/2020 12:00	1.4	11.7	2,114.4	1.0	4.2	1	1	1
08/13/2020 13:00	1.4	11.8	2,097.7	0.9	4.3	1	1	1
08/13/2020 14:00	1.3	11.8	2,087.1	0.9	3.9	1	1	1
08/13/2020 15:00	1.2	11.6	2,116.5	0.8	3.6	1	1	1
08/13/2020 16:00	1.3	11.6	2,105.9	0.8	3.9	1	1	1
08/13/2020 17:00	1.2	11.6	2,118.3	0.8	3.6	1	1	1
08/13/2020 18:00	1.2	11.6	2,115.0	0.8	3.6	1	1	1
08/13/2020 19:00	1.2	11.6	2,117.0	0.8	3.6	1	1	1
08/13/2020 20:00	1.3	11.9	2,082.8	0.8	4.0	1	1	1
08/13/2020 21:00	1.4	12.0	2,063.7	0.9	4.3	1	1	1
08/13/2020 22:00	1.3	11.8	2,112.7	0.9	4.0	1	1	1
08/13/2020 23:00	1.2	11.5	2,179.2	0.8	3.7	1	1	1
Average/Sum#:	1.0	12.6	1,902.2	0.7	73.0 #	24 #	24 #	15 #
Minimum:	0.5	11.5	1,551.6	0.4	1.5	1	1	0
Maximum:	1.6	13.9	2,179.2	1.0	5.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/14/2020 00:00	1.2	11.5	2,187.9	0.8	3.7	1	1	1
08/14/2020 01:00	1.3	11.6	2,166.9	0.8	4.0	1	1	1
08/14/2020 02:00	1.3	11.8	2,128.4	0.8	4.0	1	1	1
08/14/2020 03:00	1.4	11.9	2,108.6	0.8	4.3	1	1	1
08/14/2020 04:00	1.2	11.6	2,168.6	0.8	3.7	1	1	1
08/14/2020 05:00	1.4	12.0	2,103.8	0.9	4.4	1	1	1
08/14/2020 06:00	1.5	12.1	2,075.3	0.9	4.7	1	1	1
08/14/2020 07:00	1.4	12.1	2,068.8	0.9	4.3	1	1	1
08/14/2020 08:00	1.4	11.9	2,097.3	0.9	4.3	1	1	1
08/14/2020 09:00	1.3	11.7	2,119.8	0.9	4.0	1	1	1
08/14/2020 10:00	1.2	11.4	2,169.8	0.8	3.6	1	1	1
08/14/2020 11:00	1.2	11.6	2,136.3	0.8	3.6	1	1	1
08/14/2020 12:00	1.2	11.5	2,151.6	0.8	3.6	1	1	1
08/14/2020 13:00	1.2	11.6	2,131.5	0.8	3.6	1	1	1
08/14/2020 14:00	1.2	11.6	2,115.3	0.8	3.6	1	1	1
08/14/2020 15:00	1.2	11.6	2,104.3	0.8	3.6	1	1	1
08/14/2020 16:00	1.3	11.7	2,081.0	0.8	3.9	1	1	1
08/14/2020 17:00	1.2	11.6	2,102.1	0.8	3.6	1	1	1
08/14/2020 18:00	1.2	11.6	2,105.7	0.8	3.6	1	1	1
08/14/2020 19:00	1.2	11.5	2,135.2	0.8	3.6	1	1	1
08/14/2020 20:00	1.2	11.4	2,155.8	0.8	3.6	1	1	1
08/14/2020 21:00	1.2	11.5	2,144.6	0.8	3.6	1	1	1
08/14/2020 22:00	1.2	11.4	2,172.8	0.7	3.6	1	1	1
08/14/2020 23:00	1.2	11.4	2,179.0	0.7	3.6	1	1	1
Average/Sum#:	1.3	11.7	2,129.6	0.8	92.1 #	24 #	24 #	24 #
Minimum:	1.2	11.4	2,068.8	0.7	3.6	1	1	1
Maximum:	1.5	12.1	2,187.9	0.9	4.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/15/2020 00:00	1.1	11.4	2,183.5	0.7	3.3	1	1	1
08/15/2020 01:00	1.1	11.4	2,182.7	0.7	3.3	1	1	1
08/15/2020 02:00	1.2	11.6	2,139.3	0.7	3.6	1	1	1
08/15/2020 03:00	1.2	11.7	2,124.0	0.8	3.7	1	1	1
08/15/2020 04:00	1.3	11.9	2,108.2	0.8	4.0	1	1	1
08/15/2020 05:00	1.3	11.9	2,098.6	0.9	4.0	1	1	1
08/15/2020 06:00	1.4	11.9	2,101.5	0.9	4.3	1	1	1
08/15/2020 07:00	1.4	11.9	2,099.7	0.9	4.3	1	1	1
08/15/2020 08:00	1.4	12.3	2,011.5	0.9	4.3	1	1	1
08/15/2020 09:00	1.3	11.8	2,098.5	0.9	4.0	1	1	1
08/15/2020 10:00	1.3	11.7	2,106.4	0.9	3.9	1	1	1
08/15/2020 11:00	1.2	11.5	2,149.6	0.8	3.6	1	1	1
08/15/2020 12:00	1.2	11.3	2,171.3	0.8	3.6	1	1	1
08/15/2020 13:00	1.2	11.3	2,160.8	0.7	3.6	1	1	1
08/15/2020 14:00	1.1	11.3	2,152.7	0.7	3.3	1	1	1
08/15/2020 15:00	1.1	11.3	2,144.8	0.7	3.2	1	1	1
08/15/2020 16:00	1.2	11.3	2,143.1	0.7	3.5	1	1	1
08/15/2020 17:00	1.2	11.2	2,140.8	0.7	3.5	1	1	1
08/15/2020 18:00	1.1	11.3	2,137.6	0.7	3.2	1	1	1
08/15/2020 19:00	1.1	11.3	2,144.9	0.7	3.2	1	1	1
08/15/2020 20:00	1.1	11.3	2,165.2	0.7	3.3	1	1	1
08/15/2020 21:00	1.1	11.5	2,139.8	0.7	3.3	1	1	1
08/15/2020 22:00	1.1	11.7	2,111.9	0.7	3.3	1	1	1
08/15/2020 23:00	1.1	11.4	2,178.8	0.7	3.3	1	1	1
Average/Sum#:	1.2	11.6	2,133.1	0.8	86.6 #	24 #	24 #	24 #
Minimum:	1.1	11.2	2,011.5	0.7	3.2	1	1	1
Maximum:	1.4	12.3	2,183.5	0.9	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/16/2020 00:00	1.0	11.3	2,187.2	0.7	3.0	1	1	1
08/16/2020 01:00	1.0	11.4	2,186.4	0.6	3.0	1	1	1
08/16/2020 02:00	1.0	11.4	2,185.3	0.6	3.0	1	1	1
08/16/2020 03:00	1.0	11.6	2,153.8	0.6	3.1	1	1	1
08/16/2020 04:00	1.0	11.4	2,182.7	0.6	3.0	1	1	1
08/16/2020 05:00	1.1	11.5	2,164.7	0.6	3.3	1	1	1
08/16/2020 06:00	1.1	11.6	2,146.0	0.7	3.4	1	1	1
08/16/2020 07:00	1.2	12.1	2,037.3	0.7	3.7	1	1	1
08/16/2020 08:00	1.3	12.4	1,982.1	0.8	4.0	1	1	1
08/16/2020 09:00	1.3	12.0	2,049.4	0.9	4.0	1	1	1
08/16/2020 10:00	1.2	12.0	2,058.1	0.9	3.7	1	1	1
08/16/2020 11:00	1.2	12.0	2,052.7	0.8	3.7	1	1	1
08/16/2020 12:00	1.2	11.8	2,081.4	0.8	3.6	1	1	1
08/16/2020 13:00	1.1	11.7	2,103.1	0.8	3.3	1	1	1
08/16/2020 14:00	1.1	11.5	2,146.6	0.7	3.3	1	1	1
08/16/2020 15:00	1.1	11.4	2,150.1	0.7	3.3	1	1	1
08/16/2020 16:00	1.1	11.3	2,162.3	0.7	3.3	1	1	1
08/16/2020 17:00	1.1	11.3	2,161.3	0.7	3.3	1	1	1
08/16/2020 18:00	1.1	11.3	2,153.3	0.7	3.3	1	1	1
08/16/2020 19:00	1.2	11.3	2,145.7	0.7	3.5	1	1	1
08/16/2020 20:00	1.2	11.4	2,146.2	0.7	3.6	1	1	1
08/16/2020 21:00	1.2	11.5	2,127.8	0.7	3.6	1	1	1
08/16/2020 22:00	1.2	11.5	2,126.3	0.8	3.6	1	1	1
08/16/2020 23:00	1.1	11.5	2,136.4	0.8	3.3	1	1	1
Average/Sum#:	1.1	11.6	2,126.1	0.7	81.9 #	24 #	24 #	24 #
Minimum:	1.0	11.3	1,982.1	0.6	3.0	1	1	1
Maximum:	1.3	12.4	2,187.2	0.9	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/17/2020 00:00	1.1	11.5	2,147.9	0.7	3.3	1	1	1
08/17/2020 01:00	1.2	11.6	2,132.9	0.7	3.6	1	1	1
08/17/2020 02:00	1.2	11.6	2,129.3	0.8	3.6	1	1	1
08/17/2020 03:00	1.2	11.6	2,144.1	0.8	3.7	1	1	1
08/17/2020 04:00	1.2	11.6	2,142.1	0.8	3.7	1	1	1
08/17/2020 05:00	1.3	11.7	2,129.3	0.8	4.0	1	1	1
08/17/2020 06:00	1.2	11.6	2,157.3	0.8	3.7	1	1	1
08/17/2020 07:00	1.2	11.5	2,163.1	0.8	3.6	1	1	1
08/17/2020 08:00	1.1	11.6	2,147.0	0.8	3.4	1	1	1
08/17/2020 09:00	1.1	11.4	2,175.3	0.7	3.3	1	1	1
08/17/2020 10:00	1.1	11.3	2,178.6	0.7	3.3	1	1	1
08/17/2020 11:00	1.1	11.5	2,135.8	0.7	3.3	1	1	1
08/17/2020 12:00	1.1	11.5	2,152.4	0.7	3.3	1	1	1
08/17/2020 13:00	1.1	11.6	2,107.7	0.7	3.3	1	1	1
08/17/2020 14:00	1.1	11.6	2,116.7	0.7	3.3	1	1	1
08/17/2020 15:00	1.0	11.3	2,166.6	0.7	3.0	1	1	1
08/17/2020 16:00	1.0	11.3	2,170.8	0.6	3.0	1	1	1
08/17/2020 17:00	1.1	11.6	2,121.9	0.6	3.3	1	1	1
08/17/2020 18:00	1.2	11.8	2,089.1	0.7	3.6	1	1	1
08/17/2020 19:00	1.2	11.8	2,089.4	0.8	3.6	1	1	1
08/17/2020 20:00	1.2	11.7	2,120.7	0.8	3.7	1	1	1
08/17/2020 21:00	1.1	11.4	2,167.2	0.8	3.3	1	1	1
08/17/2020 22:00	1.1	11.5	2,150.3	0.7	3.3	1	1	1
08/17/2020 23:00	1.1	11.6	2,148.8	0.7	3.4	1	1	1
Average/Sum#:	1.1	11.6	2,141.0	0.7	82.6 #	24 #	24 #	24 #
Minimum:	1.0	11.3	2,089.1	0.6	3.0	1	1	1
Maximum:	1.3	11.8	2,178.6	0.8	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/18/2020 00:00	1.2	11.8	2,098.0	0.7	3.7	1	1	1
08/18/2020 01:00	1.1	11.6	2,135.2	0.7	3.3	1	1	1
08/18/2020 02:00	1.1	11.5	2,153.5	0.7	3.3	1	1	1
08/18/2020 03:00	1.2	11.8	2,116.8	0.7	3.7	1	1	1
08/18/2020 04:00	1.2	11.6	2,133.5	0.8	3.6	1	1	1
08/18/2020 05:00	1.2	11.7	2,124.5	0.8	3.7	1	1	1
08/18/2020 06:00	1.2	11.5	2,157.1	0.8	3.6	1	1	1
08/18/2020 07:00	1.2	11.7	2,125.3	0.8	3.7	1	1	1
08/18/2020 08:00	1.2	11.8	2,101.0	0.8	3.7	1	1	1
08/18/2020 09:00	1.2	11.7	2,093.7	0.8	3.6	1	1	1
08/18/2020 10:00	1.2	11.6	2,110.9	0.8	3.6	1	1	1
08/18/2020 11:00	1.2	11.7	2,069.5	0.8	3.6	1	1	1
08/18/2020 12:00	1.1	11.4	2,134.0	0.8	3.3	1	1	1
08/18/2020 13:00	1.1	11.3	2,143.3	0.7	3.2	1	1	1
08/18/2020 14:00	1.0	11.3	2,150.8	0.7	3.0	1	1	1
08/18/2020 15:00	1.0	11.3	2,142.5	0.6	2.9	1	1	1
08/18/2020 16:00	1.1	11.2	2,141.8	0.6	3.2	1	1	1
08/18/2020 17:00	1.0	11.2	2,146.7	0.6	2.9	1	1	1
08/18/2020 18:00	1.1	11.2	2,151.6	0.7	3.2	1	1	1
08/18/2020 19:00	1.0	11.2	2,160.3	0.6	2.9	1	1	1
08/18/2020 20:00	1.0	11.3	2,169.4	0.6	3.0	1	1	1
08/18/2020 21:00	1.0	11.5	2,150.8	0.6	3.0	1	1	1
08/18/2020 22:00	1.0	11.4	2,174.2	0.6	3.0	1	1	1
08/18/2020 23:00	1.0	11.5	2,181.3	0.6	3.1	1	1	1
Average/Sum#:	1.1	11.5	2,136.1	0.7	79.8 #	24 #	24 #	24 #
Minimum:	1.0	11.2	2,069.5	0.6	2.9	1	1	1
Maximum:	1.2	11.8	2,181.3	0.8	3.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/19/2020 00:00	1.0	11.6	2,141.3	0.6	3.0	1	1	1
08/19/2020 01:00	1.0	11.6	2,137.3	0.6	3.0	1	1	1
08/19/2020 02:00	1.0	11.6	2,137.9	0.6	3.0	1	1	1
08/19/2020 03:00	1.2	11.8	2,110.3	0.7	3.7	1	1	1
08/19/2020 04:00	1.2	11.8	2,124.0	0.7	3.7	1	1	1
08/19/2020 05:00	1.3	11.8	2,114.3	0.8	4.0	1	1	1
08/19/2020 06:00	1.3	11.9	2,108.5	0.8	4.0	1	1	1
08/19/2020 07:00	1.2	11.6	2,161.1	0.8	3.7	1	1	1
08/19/2020 08:00	1.3	11.9	2,097.6	0.9	4.0	1	1	1
08/19/2020 09:00	1.2	11.5	2,163.5	0.8	3.6	1	1	1
08/19/2020 10:00	1.1	11.4	2,176.1	0.8	3.3	1	1	1
08/19/2020 11:00	1.1	11.3	2,162.9	0.7	3.3	1	1	1
08/19/2020 12:00	1.1	11.4	2,130.8	0.7	3.3	1	1	1
08/19/2020 13:00	1.1	11.4	2,157.3	0.7	3.3	1	1	1
08/19/2020 14:00	1.0	11.3	2,154.6	0.7	3.0	1	1	1
08/19/2020 15:00	1.0	11.2	2,144.5	0.6	2.9	1	1	1
08/19/2020 16:00	1.0	11.3	2,146.0	0.6	3.0	1	1	1
08/19/2020 17:00	1.1	11.4	2,153.3	0.6	3.3	1	1	1
08/19/2020 18:00	1.0	11.4	2,173.5	0.6	3.0	1	1	1
08/19/2020 19:00	1.1	11.6	2,149.7	0.7	3.4	1	1	1
08/19/2020 20:00	1.1	11.6	2,149.0	0.7	3.4	1	1	1
08/19/2020 21:00	1.2	11.8	2,118.7	0.7	3.7	1	1	1
08/19/2020 22:00	1.2	12.0	2,097.9	0.8	3.7	1	1	1
08/19/2020 23:00	1.2	12.1	2,073.4	0.8	3.7	1	1	1
Average/Sum#:	1.1	11.6	2,136.8	0.7	82.0 #	24 #	24 #	24 #
Minimum:	1.0	11.2	2,073.4	0.6	2.9	1	1	1
Maximum:	1.3	12.1	2,176.1	0.9	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/20/2020 00:00	1.3	12.1	2,075.8	0.8	4.0	1	1	1
08/20/2020 01:00	1.3	12.2	2,064.4	0.9	4.1	1	1	1
08/20/2020 02:00	1.3	12.2	2,047.5	0.9	4.0	1	1	1
08/20/2020 03:00	1.3	12.2	2,052.8	0.9	4.1	1	1	1
08/20/2020 04:00	1.3	12.1	2,059.3	0.9	4.0	1	1	1
08/20/2020 05:00	1.4	12.1	2,067.5	0.9	4.3	1	1	1
08/20/2020 06:00	1.4	12.2	2,050.6	0.9	4.4	1	1	1
08/20/2020 07:00	1.4	12.2	2,048.8	0.9	4.4	1	1	1
08/20/2020 08:00	1.4	12.1	2,053.6	0.9	4.3	1	1	1
08/20/2020 09:00	1.3	12.0	2,069.7	0.9	4.0	1	1	1
08/20/2020 10:00	1.3	11.9	2,082.6	0.9	4.0	1	1	1
08/20/2020 11:00	1.3	12.0	2,075.5	0.9	4.0	1	1	1
08/20/2020 12:00	1.3	11.9	2,089.7	0.9	4.0	1	1	1
08/20/2020 13:00	1.3	11.9	2,088.4	0.9	4.0	1	1	1
08/20/2020 14:00	1.4	12.0	2,072.1	0.9	4.3	1	1	1
08/20/2020 15:00	1.4	12.0	2,064.1	0.9	4.3	1	1	1
08/20/2020 16:00	1.4	11.9	2,061.1	0.9	4.2	1	1	1
08/20/2020 17:00	1.5	11.8	2,085.0	0.9	4.5	1	1	1
08/20/2020 18:00	1.4	11.8	2,086.6	0.9	4.2	1	1	1
08/20/2020 19:00	1.5	11.8	2,088.7	1.0	4.5	1	1	1
08/20/2020 20:00	1.4	11.7	2,092.7	0.9	4.2	1	1	1
08/20/2020 21:00	1.4	11.8	2,082.3	0.9	4.2	1	1	1
08/20/2020 22:00	1.4	11.8	2,069.2	0.9	4.2	1	1	1
08/20/2020 23:00	1.1	11.7	2,084.0	0.8	3.3	1	1	1
Average/Sum#:	1.4	12.0	2,071.3	0.9	99.5 #	24 #	24 #	24 #
Minimum:	1.1	11.7	2,047.5	0.8	3.3	1	1	1
Maximum:	1.5	12.2	2,092.7	1.0	4.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/21/2020 00:00	0.9	11.6	2,099.4	0.7	2.7	1	1	1
08/21/2020 01:00	1.0	11.7	2,080.3	0.6	3.0	1	1	1
08/21/2020 02:00	1.0	12.2	1,980.8	0.6	3.0	1	1	1
08/21/2020 03:00	1.0	11.7	2,081.2	0.6	3.0	1	1	1
08/21/2020 04:00	0.9	11.6	2,093.4	0.6	2.7	1	1	1
08/21/2020 05:00	1.0	0.0	2,083.6	0.0	1.3	1	1	1
08/21/2020 06:00	1.0	0.0	2,116.1	0.0	1.3	1	1	1
08/21/2020 07:00	0.9	0.0	2,109.1	0.0	1.2	1	1	1
08/21/2020 08:00	0.9	0.0	2,088.0	0.0	1.2	1	1	1
08/21/2020 09:00	0.9	0.0	2,119.9	0.0	1.2	1	1	1
08/21/2020 10:00	0.9	0.0	2,126.5	0.0	1.2	1	1	1
08/21/2020 11:00	0.7	0.0	2,131.5	0.0	0.9	1	1	1
08/21/2020 12:00	1.0	12.0	2,086.6	0.0	3.1	1	1	1
08/21/2020 13:00	0.7	11.7	2,086.3	0.0	2.1	1	1	1
08/21/2020 14:00	0.7	11.9	2,034.2	0.5	2.1	1	1	1
08/21/2020 15:00	1.0	11.9	2,071.7	0.5	3.0	1	1	1
08/21/2020 16:00	1.1	11.7	2,132.2	0.6	3.4	1	1	1
08/21/2020 17:00	1.1	11.6	2,143.3	0.7	3.3	1	1	1
08/21/2020 18:00	1.1	11.7	2,118.4	0.7	3.3	1	1	1
08/21/2020 19:00	1.2	11.9	2,087.5	0.7	3.7	1	1	1
08/21/2020 20:00	1.2	11.8	2,102.3	0.8	3.7	1	1	1
08/21/2020 21:00	1.2	12.0	2,081.8	0.8	3.7	1	1	1
08/21/2020 22:00	1.2	11.9	2,098.9	0.8	3.7	1	1	1
08/21/2020 23:00	1.2	11.8	2,111.5	0.8	3.7	1	1	1
Average/Sum#:	1.0	11.8	2,094.4	0.7	53.2 #	24 #	24 #	24 #
Minimum:	0.7	11.6	1,980.8	0.5	2.1	1	1	1
Maximum:	1.2	12.2	2,143.3	0.8	3.7	1	1	1
%SI	0.00	29.17	0.00	37.50	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/22/2020 00:00	1.1	11.8	2,116.8	0.8	3.4	1	1	1
08/22/2020 01:00	1.1	12.5	1,942.8	0.8	3.4	1	1	1
08/22/2020 02:00	0.3	13.8	1,670.8	0.6	0.9	1	1	0
08/22/2020 03:00	0.4	13.9	1,539.8	0.4	1.2	1	1	0
08/22/2020 04:00	0.5	13.8	1,663.0	0.3	1.5	1	1	0
08/22/2020 05:00	0.6	13.8	1,689.1	0.4	1.9	1	1	0
08/22/2020 06:00	0.5	13.8	1,688.3	0.4	1.6	1	1	0
08/22/2020 07:00	0.4	13.8	1,680.0	0.4	1.3	1	1	0
08/22/2020 08:00	0.4	13.8	1,673.5	0.3	1.2	1	1	0
08/22/2020 09:00	0.4	13.8	1,653.0	0.3	1.2	1	1	0
08/22/2020 10:00	0.6	13.8	1,568.2	0.4	1.8	1	1	1
08/22/2020 11:00	1.5	12.1	2,044.5	0.6	4.6	1	1	1
08/22/2020 12:00	1.3	11.5	2,130.6	0.8	3.9	1	1	1
08/22/2020 13:00	1.2	11.4	2,145.7	0.8	3.6	1	1	1
08/22/2020 14:00	1.3	11.6	2,099.0	0.8	3.9	1	1	1
08/22/2020 15:00	1.2	11.3	2,152.1	0.7	3.6	1	1	1
08/22/2020 16:00	1.2	11.2	2,161.3	0.7	3.5	1	1	1
08/22/2020 17:00	1.2	11.3	2,124.6	0.7	3.5	1	1	1
08/22/2020 18:00	1.2	11.5	2,106.9	0.7	3.6	1	1	1
08/22/2020 19:00	1.2	11.6	2,098.7	0.8	3.6	1	1	1
08/22/2020 20:00	1.2	11.6	2,085.6	0.8	3.6	1	1	1
08/22/2020 21:00	1.1	11.4	2,132.2	0.8	3.3	1	1	1
08/22/2020 22:00	1.1	11.6	2,106.8	0.7	3.3	1	1	1
08/22/2020 23:00	1.1	11.4	2,137.4	0.7	3.3	1	1	1
Average/Sum#:	0.9	12.4	1,933.8	0.6	66.7 #	24 #	24 #	16 #
Minimum:	0.3	11.2	1,539.8	0.3	0.9	1	1	0
Maximum:	1.5	13.9	2,161.3	0.8	4.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/23/2020 00:00	1.2	11.7	2,096.8	0.7	3.6	1	1	1
08/23/2020 01:00	1.2	11.9	2,059.8	0.8	3.6	1	1	1
08/23/2020 02:00	1.2	11.8	2,081.4	0.8	3.6	1	1	1
08/23/2020 03:00	1.2	11.9	2,065.7	0.8	3.6	1	1	1
08/23/2020 04:00	1.2	12.4	1,949.8	0.8	3.6	1	1	1
08/23/2020 05:00	0.4	13.7	1,688.4	0.6	1.2	1	1	0
08/23/2020 06:00	0.4	13.7	1,637.8	0.5	1.2	1	1	0
08/23/2020 07:00	0.4	13.7	1,584.7	0.3	1.2	1	1	0
08/23/2020 08:00	0.4	13.6	1,649.5	0.3	1.2	1	1	0
08/23/2020 09:00	0.3	13.6	1,616.9	0.3	0.9	1	1	0
08/23/2020 10:00	0.4	13.7	1,536.0	0.3	1.1	1	1	1
08/23/2020 11:00	1.3	11.9	2,043.9	0.5	3.9	1	1	1
08/23/2020 12:00	1.1	11.5	2,127.5	0.6	3.3	1	1	1
08/23/2020 13:00	1.1	11.4	2,125.7	0.8	3.3	1	1	1
08/23/2020 14:00	1.1	11.4	2,118.2	0.7	3.2	1	1	1
08/23/2020 15:00	1.1	11.2	2,155.8	0.7	3.2	1	1	1
08/23/2020 16:00	1.0	11.1	2,157.6	0.7	2.9	1	1	1
08/23/2020 17:00	1.0	11.0	2,162.2	0.6	2.9	1	1	1
08/23/2020 18:00	1.0	11.0	2,163.3	0.6	2.9	1	1	1
08/23/2020 19:00	1.0	11.1	2,168.1	0.6	2.9	1	1	1
08/23/2020 20:00	1.1	11.1	2,178.8	0.6	3.2	1	1	1
08/23/2020 21:00	1.1	11.4	2,137.0	0.7	3.3	1	1	1
08/23/2020 22:00	1.2	11.5	2,118.5	0.7	3.6	1	1	1
08/23/2020 23:00	1.3	11.5	2,116.4	0.8	3.9	1	1	1
Average/Sum#:	0.9	12.0	1,989.2	0.6	67.3 #	24 #	24 #	19 #
Minimum:	0.3	11.0	1,536.0	0.3	0.9	1	1	0
Maximum:	1.3	13.7	2,178.8	0.8	3.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/24/2020 00:00	1.2	11.5	2,125.6	0.8	3.6	1	1	1
08/24/2020 01:00	1.2	11.5	2,119.2	0.8	3.6	1	1	1
08/24/2020 02:00	1.2	11.4	2,139.1	0.8	3.6	1	1	1
08/24/2020 03:00	1.2	11.3	2,162.5	0.7	3.6	1	1	1
08/24/2020 04:00	1.1	11.4	2,146.4	0.7	3.3	1	1	1
08/24/2020 05:00	1.2	11.4	2,137.3	0.7	3.6	1	1	1
08/24/2020 06:00	1.2	11.5	2,126.2	0.7	3.6	1	1	1
08/24/2020 07:00	1.3	11.7	2,095.1	0.8	3.9	1	1	1
08/24/2020 08:00	1.3	11.7	2,086.9	0.8	3.9	1	1	1
08/24/2020 09:00	1.2	11.5	2,106.7	0.8	3.6	1	1	1
08/24/2020 10:00	1.1	11.4	2,149.2	0.8	3.3	1	1	1
08/24/2020 11:00	1.1	11.9	2,162.0	0.7	3.5	1	1	1
08/24/2020 12:00	1.1	12.1	2,138.3	0.7	3.5	1	1	1
08/24/2020 13:00	1.1	11.9	2,145.0	0.7	3.5	1	1	1
08/24/2020 14:00	1.1	12.0	2,116.6	0.7	3.5	1	1	1
08/24/2020 15:00	1.0	11.9	2,132.6	0.7	3.1	1	1	1
08/24/2020 16:00	1.1	11.8	2,150.9	0.7	3.4	1	1	1
08/24/2020 17:00	1.1	11.8	2,147.6	0.7	3.4	1	1	1
08/24/2020 18:00	1.1	11.8	2,152.1	0.7	3.4	1	1	1
08/24/2020 19:00	1.1	12.0	2,110.0	0.7	3.4	1	1	1
08/24/2020 20:00	1.1	12.0	2,130.4	0.7	3.5	1	1	1
08/24/2020 21:00	1.2	12.0	2,126.5	0.7	3.8	1	1	1
08/24/2020 22:00	1.2	12.1	2,130.9	0.8	3.8	1	1	1
08/24/2020 23:00	1.2	12.1	2,125.4	0.8	3.8	1	1	1
Average/Sum#:	1.2	11.7	2,131.8	0.7	85.2 #	24 #	24 #	24 #
Minimum:	1.0	11.3	2,086.9	0.7	3.1	1	1	1
Maximum:	1.3	12.1	2,162.5	0.8	3.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/25/2020 00:00	1.2	12.2	2,096.7	0.8	3.8	1	1	1
08/25/2020 01:00	1.2	12.2	2,088.1	0.8	3.8	1	1	1
08/25/2020 02:00	1.2	12.3	2,079.2	0.8	3.8	1	1	1
08/25/2020 03:00	1.3	12.7	2,021.9	0.8	4.2	1	1	1
08/25/2020 04:00	1.3	12.4	2,067.9	0.9	4.2	1	1	1
08/25/2020 05:00	1.3	12.4	2,074.6	0.9	4.2	1	1	1
08/25/2020 06:00	1.3	12.4	2,079.3	0.9	4.2	1	1	1
08/25/2020 07:00	1.3	12.5	2,062.8	0.9	4.2	1	1	1
08/25/2020 08:00	1.2	12.5	2,066.0	0.9	3.9	1	1	1
08/25/2020 09:00	1.2	12.3	2,086.6	0.8	3.8	1	1	1
08/25/2020 10:00	1.1	12.3	2,096.1	0.8	3.5	1	1	1
08/25/2020 11:00	1.1	12.3	2,088.2	0.8	3.5	1	1	1
08/25/2020 12:00	1.1	12.2	2,084.5	0.8	3.5	1	1	1
08/25/2020 13:00	1.1	12.2	2,087.7	0.7	3.5	1	1	1
08/25/2020 14:00	1.1	12.1	2,090.9	0.7	3.5	1	1	1
08/25/2020 15:00	1.1	12.0	2,097.9	0.7	3.4	1	1	1
08/25/2020 16:00	1.1	11.9	2,120.9	0.7	3.4	1	1	1
08/25/2020 17:00	1.1	11.8	2,151.1	0.7	3.4	1	1	1
08/25/2020 18:00	1.0	11.7	2,164.3	0.7	3.1	1	1	1
08/25/2020 19:00	1.0	11.7	2,162.3	0.6	3.1	1	1	1
08/25/2020 20:00	1.1	12.0	2,120.9	0.6	3.5	1	1	1
08/25/2020 21:00	1.1	12.0	2,107.4	0.7	3.4	1	1	1
08/25/2020 22:00	1.2	12.1	2,097.1	0.7	3.8	1	1	1
08/25/2020 23:00	1.2	12.1	2,096.9	0.8	3.8	1	1	1
Average/Sum#:	1.2	12.2	2,095.4	0.8	88.5 #	24 #	24 #	24 #
Minimum:	1.0	11.7	2,021.9	0.6	3.1	1	1	1
Maximum:	1.3	12.7	2,164.3	0.9	4.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/26/2020 00:00	1.2	12.4	2,060.4	0.8	3.8	1	1	1
08/26/2020 01:00	1.3	12.9	1,955.0	0.9	4.2	1	1	1
08/26/2020 02:00	1.3	13.0	1,956.7	0.9	4.3	1	1	1
08/26/2020 03:00	1.3	12.5	2,053.0	1.0	4.2	1	1	1
08/26/2020 04:00	1.3	12.5	2,064.3	0.9	4.2	1	1	1
08/26/2020 05:00	1.2	12.5	2,067.7	0.9	3.9	1	1	1
08/26/2020 06:00	1.3	12.5	2,067.5	0.9	4.2	1	1	1
08/26/2020 07:00	1.2	13.0	1,955.3	0.9	3.9	1	1	1
08/26/2020 08:00	1.3	13.0	1,958.9	0.9	4.3	1	1	1
08/26/2020 09:00	1.2	12.4	2,071.7	0.9	3.9	1	1	1
08/26/2020 10:00	1.2	12.3	2,099.5	0.9	3.9	1	1	1
08/26/2020 11:00	1.1	12.2	2,095.0	0.8	3.5	1	1	1
08/26/2020 12:00	1.1	12.1	2,105.0	0.7	3.5	1	1	1
08/26/2020 13:00	1.1	12.1	2,102.9	0.7	3.5	1	1	1
08/26/2020 14:00	1.0	11.9	2,126.4	0.7	3.1	1	1	1
08/26/2020 15:00	1.0	11.7	2,154.4	0.7	3.1	1	1	1
08/26/2020 16:00	1.1	12.1	2,079.4	0.7	3.4	1	1	1
08/26/2020 17:00	1.1	12.2	2,059.5	0.7	3.4	1	1	1
08/26/2020 18:00	1.1	12.2	2,060.7	0.7	3.4	1	1	1
08/26/2020 19:00	1.1	12.3	2,052.0	0.7	3.5	1	1	1
08/26/2020 20:00	1.2	12.5	2,035.7	0.8	3.8	1	1	1
08/26/2020 21:00	1.2	12.6	2,021.4	0.8	3.9	1	1	1
08/26/2020 22:00	1.2	12.9	1,960.4	0.9	3.9	1	1	1
08/26/2020 23:00	1.2	13.0	1,948.0	0.9	3.9	1	1	1
Average/Sum#:	1.2	12.5	2,046.3	0.8	90.7 #	24 #	24 #	24 #
Minimum:	1.0	11.7	1,948.0	0.7	3.1	1	1	1
Maximum:	1.3	13.0	2,154.4	1.0	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/27/2020 00:00	1.2	13.1	1,941.9	0.9	3.9	1	1	1
08/27/2020 01:00	1.2	13.1	1,940.0	0.9	3.9	1	1	1
08/27/2020 02:00	1.1	13.1	1,939.9	0.9	3.6	1	1	1
08/27/2020 03:00	0.9	13.1	1,954.4	0.8	3.0	1	1	1
08/27/2020 04:00	1.0	12.5	2,065.4	0.7	3.2	1	1	1
08/27/2020 05:00	0.9	12.5	2,067.8	0.7	2.9	1	1	1
08/27/2020 06:00	0.9	12.4	2,086.7	0.6	2.9	1	1	1
08/27/2020 07:00	1.2	13.1	1,951.4	0.7	4.0	1	1	1
08/27/2020 08:00	1.2	12.7	2,018.3	0.8	3.9	1	1	1
08/27/2020 09:00	1.2	12.7	2,017.7	0.9	3.9	1	1	1
08/27/2020 10:00	1.2	12.6	2,015.6	0.9	3.8	1	1	1
08/27/2020 11:00	1.0	12.0	2,151.9	0.8	3.2	1	1	1
08/27/2020 12:00	0.9	11.8	2,177.8	0.7	2.8	1	1	1
08/27/2020 13:00	0.9	11.8	2,174.1	0.6	2.8	1	1	1
08/27/2020 14:00	0.9	11.5	2,166.7	0.6	2.7	1	1	1
08/27/2020 15:00	0.9	11.5	2,173.4	0.6	2.7	1	1	1
08/27/2020 16:00	1.1	12.0	2,087.0	0.6	3.4	1	1	1
08/27/2020 17:00	1.1	11.9	2,092.6	0.7	3.4	1	1	1
08/27/2020 18:00	1.1	11.9	2,099.6	0.7	3.4	1	1	1
08/27/2020 19:00	1.0	11.8	2,135.9	0.7	3.1	1	1	1
08/27/2020 20:00	1.1	11.7	2,154.5	0.7	3.4	1	1	1
08/27/2020 21:00	1.1	11.5	2,184.2	0.7	3.4	1	1	1
08/27/2020 22:00	1.1	11.5	2,186.5	0.7	3.4	1	1	1
08/27/2020 23:00	1.3	12.3	2,037.7	0.8	4.1	1	1	1
Average/Sum#:	1.1	12.3	2,075.9	0.7	80.8 #	24 #	24 #	24 #
Minimum:	0.9	11.5	1,939.9	0.6	2.7	1	1	1
Maximum:	1.3	13.1	2,186.5	0.9	4.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/28/2020 00:00	1.3	12.7	1,935.7	0.8	4.1	1	1	1
08/28/2020 01:00	0.5	13.9	1,524.3	0.7	1.4	1	1	0
08/28/2020 02:00	0.3	14.0	1,449.8	0.5	0.8	1	1	0
08/28/2020 03:00	0.5	14.0	1,288.9	0.4	1.2	1	1	0
08/28/2020 04:00	0.3	14.0	1,473.3	0.3	0.8	1	1	0
08/28/2020 05:00	0.4	14.0	1,595.0	0.3	1.2	1	1	0
08/28/2020 06:00	0.5	14.0	1,454.6	0.3	1.4	1	1	0
08/28/2020 07:00	0.6	14.0	1,375.4	0.4	1.6	1	1	0
08/28/2020 08:00	0.5	14.0	1,396.1	0.4	1.3	1	1	0
08/28/2020 09:00	0.4	14.0	1,426.6	0.4	1.1	1	1	0
08/28/2020 10:00	0.3	14.0	1,461.0	0.3	0.8	1	1	0
08/28/2020 11:00	0.4	13.9	1,514.1	0.3	1.1	1	1	0
08/28/2020 12:00	1.4	12.0	2,058.2	0.5	4.3	1	1	1
08/28/2020 13:00	1.2	11.4	2,176.6	0.6	3.6	1	1	1
08/28/2020 14:00	1.2	11.4	2,169.6	0.8	3.6	1	1	1
08/28/2020 15:00	1.2	11.4	2,165.3	0.7	3.6	1	1	1
08/28/2020 16:00	1.2	11.4	2,173.3	0.7	3.6	1	1	1
08/28/2020 17:00	1.1	11.4	2,163.3	0.7	3.3	1	1	1
08/28/2020 18:00	1.2	11.5	2,151.2	0.7	3.6	1	1	1
08/28/2020 19:00	1.2	12.0	2,059.6	0.8	3.7	1	1	1
08/28/2020 20:00	1.3	12.1	2,046.1	0.8	4.0	1	1	1
08/28/2020 21:00	1.3	12.2	2,045.5	0.9	4.0	1	1	1
08/28/2020 22:00	1.3	12.4	1,994.0	0.9	4.0	1	1	1
08/28/2020 23:00	1.3	12.0	2,090.7	0.9	4.0	1	1	1
Average/Sum#:	0.9	12.8	1,799.5	0.6	62.1 #	24 #	24 #	13 #
Minimum:	0.3	11.4	1,288.9	0.3	0.8	1	1	0
Maximum:	1.4	14.0	2,176.6	0.9	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/29/2020 00:00	1.3	11.9	2,100.2	0.9	4.0	1	1	1
08/29/2020 01:00	1.3	12.0	2,098.1	0.9	4.0	1	1	1
08/29/2020 02:00	1.3	12.2	2,069.6	0.9	4.1	1	1	1
08/29/2020 03:00	1.3	12.7	1,949.2	0.9	4.1	1	1	1
08/29/2020 04:00	0.5	13.9	1,606.0	0.7	1.5	1	1	0
08/29/2020 05:00	0.6	13.9	1,586.5	0.6	1.8	1	1	0
08/29/2020 06:00	0.6	13.9	1,559.4	0.5	1.8	1	1	0
08/29/2020 07:00	0.6	13.9	1,428.6	0.5	1.6	1	1	0
08/29/2020 08:00	0.5	13.9	1,381.1	0.5	1.3	1	1	0
08/29/2020 09:00	0.6	14.0	1,282.5	0.5	1.5	1	1	0
08/29/2020 10:00	0.5	14.0	1,295.9	0.4	1.2	1	1	0
08/29/2020 11:00	0.4	14.0	1,329.1	0.4	1.0	1	1	0
08/29/2020 12:00	0.5	14.0	1,287.9	0.4	1.2	1	1	0
08/29/2020 13:00	0.4	13.9	1,589.9	0.3	1.2	1	1	0
08/29/2020 14:00	0.4	13.9	1,597.3	0.3	1.2	1	1	0
08/29/2020 15:00	0.5	13.8	1,604.5	0.3	1.5	1	1	0
08/29/2020 16:00	0.5	13.8	1,654.1	0.4	1.5	1	1	1
08/29/2020 17:00	1.4	11.9	2,065.0	0.6	4.2	1	1	1
08/29/2020 18:00	1.2	11.6	2,109.7	0.7	3.6	1	1	1
08/29/2020 19:00	1.2	11.7	2,110.7	0.8	3.6	1	1	1
08/29/2020 20:00	1.2	11.4	2,172.4	0.8	3.6	1	1	1
08/29/2020 21:00	1.2	11.6	2,145.4	0.8	3.7	1	1	1
08/29/2020 22:00	1.4	12.3	2,023.0	0.8	4.3	1	1	1
08/29/2020 23:00	1.4	12.4	2,018.0	0.9	4.4	1	1	1
Average/Sum#:	0.9	13.0	1,752.7	0.6	61.9 #	24 #	24 #	12 #
Minimum:	0.4	11.4	1,282.5	0.3	1.0	1	1	0
Maximum:	1.4	14.0	2,172.4	0.9	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/30/2020 00:00	1.3	12.7	1,930.6	1.0	4.0	1	1	1
08/30/2020 01:00	0.5	13.7	1,750.8	0.8	1.6	1	1	0
08/30/2020 02:00	0.5	13.7	1,754.2	0.6	1.6	1	1	0
08/30/2020 03:00	0.5	13.7	1,754.7	0.4	1.6	1	1	0
08/30/2020 04:00	0.5	13.8	1,755.6	0.4	1.6	1	1	0
08/30/2020 05:00	0.5	13.7	1,747.0	0.4	1.6	1	1	0
08/30/2020 06:00	0.5	13.8	1,747.0	0.4	1.6	1	1	0
08/30/2020 07:00	0.4	13.7	1,750.7	0.4	1.3	1	1	0
08/30/2020 08:00	0.5	13.7	1,756.7	0.4	1.6	1	1	0
08/30/2020 09:00	0.5	13.6	1,763.4	0.4	1.6	1	1	0
08/30/2020 10:00	0.5	13.6	1,761.2	0.4	1.6	1	1	0
08/30/2020 11:00	0.5	13.6	1,753.6	0.4	1.6	1	1	0
08/30/2020 12:00	0.5	13.6	1,744.7	0.4	1.6	1	1	0
08/30/2020 13:00	0.5	13.7	1,633.1	0.4	1.5	1	1	0
08/30/2020 14:00	0.6	13.8	1,540.0	0.4	1.7	1	1	1
08/30/2020 15:00	1.3	11.9	2,091.5	0.6	4.0	1	1	1
08/30/2020 16:00	1.1	11.3	2,177.6	0.7	3.3	1	1	1
08/30/2020 17:00	1.2	11.6	2,126.6	0.8	3.6	1	1	1
08/30/2020 18:00	1.2	11.8	2,098.2	0.8	3.7	1	1	1
08/30/2020 19:00	1.3	12.1	2,055.0	0.8	4.0	1	1	1
08/30/2020 20:00	1.3	12.1	2,048.7	0.9	4.0	1	1	1
08/30/2020 21:00	1.4	12.2	2,037.1	0.9	4.3	1	1	1
08/30/2020 22:00	1.3	12.2	2,031.9	0.9	4.0	1	1	1
08/30/2020 23:00	1.3	12.6	1,944.3	0.9	4.0	1	1	1
Average/Sum#:	0.8	13.0	1,864.8	0.6	61.0 #	24 #	24 #	11 #
Minimum:	0.4	11.3	1,540.0	0.4	1.3	1	1	0
Maximum:	1.4	13.8	2,177.6	1.0	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/31/2020 00:00	0.6	13.8	1,614.4	0.8	1.8	1	1	0
08/31/2020 01:00	0.9	13.9	1,303.1	0.7	2.2	1	1	0
08/31/2020 02:00	0.6	14.0	1,289.4	0.6	1.5	1	1	0
08/31/2020 03:00	0.6	14.0	1,299.9	0.6	1.5	1	1	0
08/31/2020 04:00	0.5	13.8	1,639.1	0.5	1.5	1	1	0
08/31/2020 05:00	0.5	13.8	1,669.3	0.4	1.6	1	1	0
08/31/2020 06:00	0.5	13.8	1,693.4	0.4	1.6	1	1	0
08/31/2020 07:00	0.8	13.9	1,385.4	0.5	2.1	1	1	0
08/31/2020 08:00	0.5	13.9	1,407.3	0.5	1.3	1	1	0
08/31/2020 09:00	0.4	14.0	1,312.4	0.5	1.0	1	1	0
08/31/2020 10:00	0.4	14.0	1,302.1	0.3	1.0	1	1	0
08/31/2020 11:00	0.3	14.0	1,504.4	0.3	0.9	1	1	0
08/31/2020 12:00	0.3	13.9	1,488.2	0.3	0.8	1	1	1
08/31/2020 13:00	1.3	11.9	2,098.1	0.5	4.0	1	1	1
08/31/2020 14:00	1.2	11.4	2,187.6	0.6	3.6	1	1	1
08/31/2020 15:00	1.1	11.4	2,181.2	0.8	3.3	1	1	1
08/31/2020 16:00	1.2	11.9	2,075.9	0.7	3.7	1	1	1
08/31/2020 17:00	1.2	12.1	2,046.7	0.8	3.7	1	1	1
08/31/2020 18:00	1.3	12.2	2,042.4	0.8	4.0	1	1	1
08/31/2020 19:00	1.3	12.2	2,034.7	0.9	4.0	1	1	1
08/31/2020 20:00	1.3	12.2	2,032.1	0.9	4.0	1	1	1
08/31/2020 21:00	1.3	12.3	2,028.6	0.9	4.0	1	1	1
08/31/2020 22:00	1.3	12.3	2,024.4	0.9	4.0	1	1	1
08/31/2020 23:00	1.1	13.0	1,793.4	0.9	3.3	1	1	1
Average/Sum#:	0.9	13.1	1,727.2	0.6	60.4 #	24 #	24 #	12 #
Minimum:	0.3	11.4	1,289.4	0.3	0.8	1	1	0
Maximum:	1.3	14.0	2,187.6	0.9	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2020 00:00	0.7	14.0	1,298.4	0.8	1.7	1	1	0
09/01/2020 01:00	0.3	13.9	1,497.3	0.6	0.8	1	1	0
09/01/2020 02:00	0.4	14.0	1,393.5	0.4	1.1	1	1	0
09/01/2020 03:00	0.6	14.0	1,300.4	0.4	1.5	1	1	0
09/01/2020 04:00	0.4	14.0	1,347.1	0.4	1.0	1	1	0
09/01/2020 05:00	0.3	13.8	1,678.7	0.3	0.9	1	1	0
09/01/2020 06:00	0.4	13.9	1,653.2	0.3	1.2	1	1	0
09/01/2020 07:00	0.5	13.8	1,676.8	0.3	1.6	1	1	0
09/01/2020 08:00	0.0	0.0	1,596.3	0.0	0.0	1	1	0
09/01/2020 09:00	0.2	13.9	1,623.2	0.0	0.6	1	1	0
09/01/2020 10:00	0.1	13.9	1,483.8	0.0	0.3	1	1	0
09/01/2020 11:00	0.1	14.1	1,311.8	0.1	0.3	1	1	0
09/01/2020 12:00	0.0	14.1	1,340.5	0.1	0.0	1	1	0
09/01/2020 13:00	0.0	14.1	1,488.6	0.0	0.0	1	1	0
09/01/2020 14:00	0.0	14.0	1,648.6	0.0	0.0	1	1	0
09/01/2020 15:00	0.0	14.0	1,612.3	0.0	0.0	1	1	0
09/01/2020 16:00	0.0	13.9	1,541.1	0.0	0.0	1	1	1
09/01/2020 17:00	0.9	12.0	2,064.4	0.2	2.8	1	1	1
09/01/2020 18:00	0.7	11.6	2,157.9	0.3	2.1	1	1	1
09/01/2020 19:00	0.7	11.7	2,131.3	0.5	2.1	1	1	1
09/01/2020 20:00	0.8	12.3	2,027.7	0.4	2.5	1	1	1
09/01/2020 21:00	0.9	12.4	2,014.1	0.5	2.8	1	1	1
09/01/2020 22:00	0.8	12.8	1,946.1	0.6	2.5	1	1	1
09/01/2020 23:00	0.6	13.2	1,783.2	0.6	1.8	1	1	1
Average/Sum#:	0.4	13.5	1,650.7	0.3	27.6 #	24 #	24 #	8 #
Minimum:	0.0	11.6	1,298.4	0.0	0.0	1	1	0
Maximum:	0.9	14.1	2,157.9	0.8	2.8	1	1	1
%SI	4.17	4.17	0.00	12.50	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/02/2020 00:00	0.4	14.0	1,287.8	0.5	1.0	1	1	0
09/02/2020 01:00	0.3	14.0	1,284.2	0.4	0.7	1	1	0
09/02/2020 02:00	0.3	14.0	1,301.4	0.3	0.7	1	1	0
09/02/2020 03:00	0.2	14.0	1,294.8	0.3	0.5	1	1	0
09/02/2020 04:00	0.2	14.0	1,318.3	0.2	0.5	1	1	0
09/02/2020 05:00	0.3	14.0	1,285.9	0.2	0.7	1	1	0
09/02/2020 06:00	0.2	14.0	1,292.6	0.2	0.5	1	1	0
09/02/2020 07:00	0.2	14.0	1,408.7	0.2	0.5	1	0	0
09/02/2020 08:00	0.4	14.0	1,367.6	0.2	1.0	1	0	0
09/02/2020 09:00	0.2	14.0	1,374.7	0.2	0.5	1	0	0
09/02/2020 10:00	0.0	14.0	1,383.4	0.2	0.0	1	0	0
09/02/2020 11:00	0.0	14.0	1,392.2	0.1	0.0	1	0	0
09/02/2020 12:00	0.0	14.0	1,394.6	0.0	0.0	1	0	0
09/02/2020 13:00	0.0	14.0	1,394.8	0.0	0.0	1	0	0
09/02/2020 14:00	0.0	14.0	1,394.3	0.0	0.0	1	0	0
09/02/2020 15:00	0.0	14.0	1,419.1	0.0	0.0	1	0	0
09/02/2020 16:00	1.2	12.8	1,921.0	0.3	3.8	1	0	1
09/02/2020 17:00	1.3	12.6	1,963.9	0.6	4.1	1	0	1
09/02/2020 18:00	1.2	12.7	1,957.9	0.9	3.8	1	0	1
09/02/2020 19:00	1.2	12.8	1,948.7	0.9	3.8	1	0	1
09/02/2020 20:00	1.2	12.8	1,911.9	0.9	3.7	1	0	1
09/02/2020 21:00	0.2	14.0	1,390.6	0.7	0.5	1	0	0
09/02/2020 22:00	0.1	14.0	1,373.7	0.4	0.3	1	0	0
09/02/2020 23:00	0.2	14.0	1,377.5	0.2	0.5	1	0	0
Average/Sum#:	0.4	13.7	1,476.7	0.3	27.1 #	24 #	7 #	5 #
Minimum:	0.0	12.6	1,284.2	0.0	0.0	1	0	0
Maximum:	1.3	14.0	1,963.9	0.9	4.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/03/2020 00:00	0.2	14.0	1,374.0	0.2	0.5	1	0	0
09/03/2020 01:00	0.3	14.0	1,373.5	0.2	0.8	1	0	0
09/03/2020 02:00	0.3	14.0	1,376.0	0.3	0.8	1	0	0
09/03/2020 03:00	0.1	14.0	1,621.5	0.2	0.3	1	0	0
09/03/2020 04:00	0.2	14.0	1,445.9	0.2	0.6	1	0	0
09/03/2020 05:00	0.1	14.0	1,573.4	0.1	0.3	1	1	0
09/03/2020 06:00	0.0	14.0	1,588.8	0.1	0.0	1	1	0
09/03/2020 07:00	0.0	14.0	1,645.9	0.0	0.0	1	1	0
09/03/2020 08:00	0.0	14.0	1,642.0	0.0	0.0	1	1	0
09/03/2020 09:00	0.0	14.0	1,539.7	0.0	0.0	1	1	0
09/03/2020 10:00	0.0	14.0	1,577.0	0.0	0.0	1	1	0
09/03/2020 11:00	0.0	14.0	1,528.5	0.0	0.0	1	1	1
09/03/2020 12:00	1.2	12.1	2,093.4	0.3	3.8	1	1	1
09/03/2020 13:00	0.7	11.7	2,155.4	0.4	2.2	1	1	1
09/03/2020 14:00	0.8	11.9	2,109.7	0.6	2.5	1	1	1
09/03/2020 15:00	0.7	11.6	2,161.1	0.4	2.1	1	1	1
09/03/2020 16:00	0.6	11.5	2,166.8	0.4	1.8	1	1	1
09/03/2020 17:00	0.6	11.5	2,166.4	0.4	1.8	1	1	1
09/03/2020 18:00	0.6	11.5	2,170.5	0.4	1.8	1	1	1
09/03/2020 19:00	0.7	11.8	2,114.6	0.4	2.1	1	1	1
09/03/2020 20:00	0.8	12.2	2,034.1	0.5	2.5	1	1	1
09/03/2020 21:00	0.8	12.3	2,030.5	0.5	2.5	1	1	1
09/03/2020 22:00	0.7	12.1	2,068.9	0.5	2.2	1	1	1
09/03/2020 23:00	0.6	11.7	2,160.1	0.5	1.9	1	1	1
Average/Sum#:	0.4	12.9	1,821.6	0.3	30.5 #	24 #	19 #	13 #
Minimum:	0.0	11.5	1,373.5	0.0	0.0	1	0	0
Maximum:	1.2	14.0	2,170.5	0.6	3.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/04/2020 00:00	0.8	12.4	2,044.7	0.5	2.5	1	1	1
09/04/2020 01:00	0.8	12.6	2,004.7	0.5	2.6	1	1	1
09/04/2020 02:00	0.8	12.6	2,006.5	0.6	2.6	1	1	1
09/04/2020 03:00	0.8	12.7	2,008.8	0.6	2.6	1	1	1
09/04/2020 04:00	0.7	11.9	2,159.5	0.6	2.2	1	1	1
09/04/2020 05:00	0.6	11.7	2,192.1	0.5	1.9	1	1	1
09/04/2020 06:00	0.6	11.8	2,162.4	0.4	1.9	1	1	1
09/04/2020 07:00	0.6	11.9	2,144.0	0.4	1.9	1	1	1
09/04/2020 08:00	0.7	12.4	2,039.1	0.4	2.2	1	1	1
09/04/2020 09:00	0.7	12.5	2,004.2	0.5	2.2	1	1	1
09/04/2020 10:00	0.7	12.1	2,087.7	0.5	2.2	1	1	1
09/04/2020 11:00	0.6	11.9	2,121.9	0.5	1.9	1	1	1
09/04/2020 12:00	0.6	11.8	2,139.3	0.4	1.9	1	1	1
09/04/2020 13:00	0.5	11.7	2,143.8	0.4	1.5	1	1	1
09/04/2020 14:00	0.5	11.7	2,143.4	0.3	1.5	1	1	1
09/04/2020 15:00	0.5	11.7	2,151.6	0.3	1.5	1	1	1
09/04/2020 16:00	0.5	11.6	2,155.4	0.3	1.5	1	1	1
09/04/2020 17:00	0.5	11.6	2,160.4	0.3	1.5	1	1	1
09/04/2020 18:00	0.6	11.6	2,164.8	0.3	1.8	1	1	1
09/04/2020 19:00	0.5	11.6	2,169.0	0.3	1.5	1	1	1
09/04/2020 20:00	0.5	11.6	2,170.4	0.3	1.5	1	1	1
09/04/2020 21:00	0.5	11.8	2,137.3	0.3	1.6	1	1	1
09/04/2020 22:00	0.5	11.9	2,137.2	0.3	1.6	1	1	1
09/04/2020 23:00	0.6	12.4	2,052.0	0.3	1.9	1	1	1
Average/Sum#:	0.6	12.0	2,112.5	0.4	46.0 #	24 #	24 #	24 #
Minimum:	0.5	11.6	2,004.2	0.3	1.5	1	1	1
Maximum:	0.8	12.7	2,192.1	0.6	2.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/05/2020 00:00	0.7	12.5	2,028.9	0.4	2.2	1	1	1
09/05/2020 01:00	0.7	12.5	2,033.6	0.5	2.2	1	1	1
09/05/2020 02:00	0.7	12.5	2,032.6	0.5	2.2	1	1	1
09/05/2020 03:00	0.7	12.5	2,034.7	0.5	2.2	1	1	1
09/05/2020 04:00	0.7	12.5	2,047.1	0.5	2.3	1	1	1
09/05/2020 05:00	0.8	12.7	1,996.2	0.5	2.6	1	1	1
09/05/2020 06:00	0.1	14.0	1,646.2	0.4	0.3	1	1	0
09/05/2020 07:00	0.1	14.0	1,575.4	0.3	0.3	1	1	0
09/05/2020 08:00	0.1	14.0	1,619.3	0.1	0.3	1	1	0
09/05/2020 09:00	0.2	14.0	1,596.6	0.1	0.6	1	1	0
09/05/2020 10:00	0.2	14.0	1,628.7	0.2	0.6	1	1	1
09/05/2020 11:00	0.9	12.2	2,070.4	0.3	2.8	1	1	1
09/05/2020 12:00	0.6	11.7	2,146.3	0.4	1.8	1	1	1
09/05/2020 13:00	0.5	11.6	2,158.0	0.4	1.5	1	1	1
09/05/2020 14:00	0.5	11.6	2,159.4	0.3	1.5	1	1	1
09/05/2020 15:00	0.5	11.5	2,156.1	0.3	1.5	1	1	1
09/05/2020 16:00	0.6	11.5	2,146.5	0.3	1.8	1	1	1
09/05/2020 17:00	0.5	11.5	2,155.9	0.3	1.5	1	1	1
09/05/2020 18:00	0.5	11.5	2,162.8	0.3	1.5	1	1	1
09/05/2020 19:00	0.5	11.5	2,167.9	0.3	1.5	1	1	1
09/05/2020 20:00	0.5	11.5	2,171.2	0.3	1.5	1	1	1
09/05/2020 21:00	0.5	11.5	2,177.1	0.3	1.5	1	1	1
09/05/2020 22:00	0.5	11.6	2,186.6	0.3	1.6	1	1	1
09/05/2020 23:00	0.5	11.9	2,117.7	0.3	1.6	1	1	1
Average/Sum#:	0.5	12.3	2,009.0	0.3	37.4 #	24 #	24 #	20 #
Minimum:	0.1	11.5	1,575.4	0.1	0.3	1	1	0
Maximum:	0.9	14.0	2,186.6	0.5	2.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/06/2020 00:00	0.5	11.8	2,154.4	0.3	1.6	1	1	1
09/06/2020 01:00	0.5	12.1	2,086.4	0.3	1.6	1	1	1
09/06/2020 02:00	0.2	11.9	2,082.6	0.2	0.6	1	1	1
09/06/2020 03:00	0.2	11.8	2,105.5	0.2	0.6	1	1	1
09/06/2020 04:00	0.7	12.3	2,069.1	0.2	2.2	1	1	1
09/06/2020 05:00	0.9	12.4	2,055.1	0.4	2.9	1	1	1
09/06/2020 06:00	0.9	12.7	1,987.4	0.6	2.9	1	1	1
09/06/2020 07:00	0.8	12.1	2,110.9	0.6	2.5	1	1	1
09/06/2020 08:00	0.7	11.8	2,133.1	0.5	2.2	1	1	1
09/06/2020 09:00	0.6	11.7	2,146.1	0.5	1.8	1	1	1
09/06/2020 10:00	0.5	11.6	2,144.2	0.4	1.5	1	1	1
09/06/2020 11:00	0.5	11.6	2,139.2	0.3	1.5	1	1	1
09/06/2020 12:00	0.5	11.5	2,140.0	0.3	1.5	1	1	1
09/06/2020 13:00	0.5	11.6	2,145.4	0.3	1.5	1	1	1
09/06/2020 14:00	0.5	11.6	2,145.7	0.3	1.5	1	1	1
09/06/2020 15:00	0.4	11.5	2,148.3	0.3	1.2	1	1	1
09/06/2020 16:00	0.5	11.9	2,078.4	0.3	1.5	1	1	1
09/06/2020 17:00	0.4	11.5	2,141.4	0.3	1.2	1	1	1
09/06/2020 18:00	0.5	11.6	2,121.0	0.3	1.5	1	1	1
09/06/2020 19:00	0.5	11.8	2,090.2	0.3	1.5	1	1	1
09/06/2020 20:00	0.5	11.9	2,092.8	0.3	1.5	1	1	1
09/06/2020 21:00	0.5	11.7	2,146.3	0.3	1.5	1	1	1
09/06/2020 22:00	0.2	11.6	2,142.3	0.2	0.6	1	1	1
09/06/2020 23:00	0.1	11.6	2,099.9	0.2	0.3	1	1	1
Average/Sum#:	0.5	11.8	2,112.7	0.3	37.2 #	24 #	24 #	24 #
Minimum:	0.1	11.5	1,987.4	0.2	0.3	1	1	1
Maximum:	0.9	12.7	2,154.4	0.6	2.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/07/2020 00:00	0.1	11.6	2,087.2	0.1	0.3	1	1	1
09/07/2020 01:00	0.1	11.7	2,080.0	0.1	0.3	1	1	1
09/07/2020 02:00	0.1	11.7	2,090.5	0.1	0.3	1	1	1
09/07/2020 03:00	0.6	12.0	2,105.0	0.2	1.9	1	1	1
09/07/2020 04:00	0.7	12.3	2,038.4	0.3	2.2	1	1	1
09/07/2020 05:00	0.7	12.3	2,045.0	0.5	2.2	1	1	1
09/07/2020 06:00	0.0	14.0	1,593.0	0.3	0.0	1	1	0
09/07/2020 07:00	0.0	14.1	1,591.9	0.2	0.0	1	1	0
09/07/2020 08:00	0.0	14.1	1,604.2	0.0	0.0	1	1	0
09/07/2020 09:00	0.0	14.1	1,566.2	0.0	0.0	1	1	0
09/07/2020 10:00	0.0	14.0	1,507.6	0.0	0.0	1	1	0
09/07/2020 11:00	0.0	14.0	1,508.2	0.0	0.0	1	1	1
09/07/2020 12:00	1.0	12.6	1,958.9	0.2	3.1	1	1	1
09/07/2020 13:00	0.5	13.4	1,742.4	0.4	1.5	1	1	1
09/07/2020 14:00	0.0	13.8	1,673.7	0.4	0.0	1	1	0
09/07/2020 15:00	0.0	13.7	1,721.1	0.1	0.0	1	1	0
09/07/2020 16:00	0.4	13.1	1,782.9	0.1	1.2	1	1	1
09/07/2020 17:00	0.8	12.2	2,027.4	0.3	2.5	1	1	1
09/07/2020 18:00	0.7	12.2	2,022.2	0.4	2.1	1	1	1
09/07/2020 19:00	0.6	11.7	2,124.7	0.5	1.8	1	1	1
09/07/2020 20:00	0.6	11.7	2,112.8	0.4	1.8	1	1	1
09/07/2020 21:00	0.7	12.0	2,049.3	0.4	2.1	1	1	1
09/07/2020 22:00	0.7	12.0	2,052.9	0.5	2.1	1	1	1
09/07/2020 23:00	0.7	12.1	2,052.7	0.5	2.2	1	1	1
Average/Sum#:	0.4	12.8	1,880.8	0.3	27.6 #	24 #	24 #	17 #
Minimum:	0.0	11.6	1,507.6	0.0	0.0	1	1	0
Maximum:	1.0	14.1	2,124.7	0.5	3.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/08/2020 00:00	0.7	12.2	2,055.9	0.5	2.2	1	1	1
09/08/2020 01:00	0.6	11.9	2,111.0	0.5	1.9	1	1	1
09/08/2020 02:00	0.6	12.0	2,087.8	0.4	1.9	1	1	1
09/08/2020 03:00	0.6	11.8	2,152.6	0.4	1.9	1	1	1
09/08/2020 04:00	0.6	12.2	2,089.1	0.4	1.9	1	1	1
09/08/2020 05:00	0.7	12.4	2,050.2	0.4	2.2	1	1	1
09/08/2020 06:00	0.0	14.0	1,636.4	0.3	0.0	1	1	0
09/08/2020 07:00	0.0	14.1	1,637.4	0.2	0.0	1	1	0
09/08/2020 08:00	0.0	14.1	1,515.2	0.0	0.0	1	1	0
09/08/2020 09:00	0.0	14.0	1,642.7	0.0	0.0	1	1	0
09/08/2020 10:00	0.0	14.0	1,583.1	0.0	0.0	1	1	0
09/08/2020 11:00	0.0	13.9	1,688.0	0.0	0.0	1	1	0
09/08/2020 12:00	0.0	14.0	1,538.9	0.0	0.0	1	1	1
09/08/2020 13:00	0.9	12.3	2,083.3	0.2	2.9	1	1	1
09/08/2020 14:00	0.6	11.7	2,176.1	0.3	1.9	1	1	1
09/08/2020 15:00	0.6	11.6	2,186.3	0.5	1.9	1	1	1
09/08/2020 16:00	0.6	11.6	2,191.0	0.4	1.9	1	1	1
09/08/2020 17:00	0.5	11.5	2,198.7	0.4	1.5	1	1	1
09/08/2020 18:00	0.1	11.7	2,084.9	0.3	0.3	1	1	1
09/08/2020 19:00	0.4	12.0	2,091.8	0.2	1.2	1	1	1
09/08/2020 20:00	0.7	12.2	2,095.8	0.3	2.2	1	1	1
09/08/2020 21:00	0.7	12.1	2,103.1	0.4	2.2	1	1	1
09/08/2020 22:00	0.7	12.5	2,037.8	0.5	2.2	1	1	1
09/08/2020 23:00	0.7	12.4	2,056.6	0.5	2.2	1	1	1
Average/Sum#:	0.4	12.6	1,962.2	0.3	32.4 #	24 #	24 #	18 #
Minimum:	0.0	11.5	1,515.2	0.0	0.0	1	1	0
Maximum:	0.9	14.1	2,198.7	0.5	2.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/09/2020 00:00	0.6	12.4	2,003.3	0.5	1.9	1	1	1
09/09/2020 01:00	0.0	14.0	1,665.4	0.3	0.0	1	1	0
09/09/2020 02:00	0.0	14.1	1,398.7	0.1	0.0	1	1	0
09/09/2020 03:00	0.0	14.0	1,657.4	0.0	0.0	1	1	0
09/09/2020 04:00	0.0	14.1	1,507.6	0.0	0.0	1	1	0
09/09/2020 05:00	0.0	14.1	1,580.1	0.0	0.0	1	1	0
09/09/2020 06:00	0.0	14.1	1,583.4	0.0	0.0	1	1	0
09/09/2020 07:00	0.0	14.1	1,560.6	0.0	0.0	1	1	0
09/09/2020 08:00	0.0	14.1	1,517.1	0.0	0.0	1	1	0
09/09/2020 09:00	0.0	14.1	1,437.2	0.0	0.0	1	1	0
09/09/2020 10:00	0.0	14.1	1,423.5	0.0	0.0	1	1	0
09/09/2020 11:00	0.0	14.1	1,496.9	0.0	0.0	1	1	0
09/09/2020 12:00	0.0	14.1	1,521.1	0.0	0.0	1	1	1
09/09/2020 13:00	1.0	12.3	2,084.9	0.2	3.2	1	1	1
09/09/2020 14:00	0.9	12.4	2,045.1	0.4	2.9	1	1	1
09/09/2020 15:00	0.9	12.5	2,020.4	0.6	2.9	1	1	1
09/09/2020 16:00	0.9	12.5	2,013.2	0.6	2.8	1	1	1
09/09/2020 17:00	0.8	12.5	2,010.1	0.6	2.5	1	1	1
09/09/2020 18:00	0.9	12.6	2,009.5	0.6	2.9	1	1	1
09/09/2020 19:00	0.8	12.6	2,008.5	0.6	2.6	1	1	1
09/09/2020 20:00	0.8	12.6	2,009.2	0.6	2.6	1	1	1
09/09/2020 21:00	0.9	12.7	2,006.3	0.6	2.9	1	1	1
09/09/2020 22:00	0.8	12.7	2,003.5	0.6	2.6	1	1	1
09/09/2020 23:00	0.8	13.0	1,921.5	0.6	2.6	1	1	1
Average/Sum#:	0.4	13.3	1,770.2	0.3	32.4 #	24 #	24 #	13 #
Minimum:	0.0	12.3	1,398.7	0.0	0.0	1	1	0
Maximum:	1.0	14.1	2,084.9	0.6	3.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/10/2020 00:00	0.0	14.0	1,517.9	0.4	0.0	1	1	0
09/10/2020 01:00	0.0	14.0	1,492.0	0.2	0.0	1	1	0
09/10/2020 02:00	0.0	14.1	1,313.6	0.0	0.0	1	1	0
09/10/2020 03:00	0.0	14.0	1,594.4	0.0	0.0	1	1	0
09/10/2020 04:00	0.0	14.0	1,563.7	0.0	0.0	1	1	0
09/10/2020 05:00	0.0	14.0	1,559.1	0.0	0.0	1	1	0
09/10/2020 06:00	0.0	14.0	1,605.5	0.0	0.0	1	1	0
09/10/2020 07:00	0.0	14.0	1,643.9	0.0	0.0	1	1	0
09/10/2020 08:00	0.0	14.0	1,680.9	0.0	0.0	1	1	0
09/10/2020 09:00	0.0	14.0	1,621.3	0.0	0.0	1	1	0
09/10/2020 10:00	0.0	14.0	1,673.5	0.0	0.0	1	1	0
09/10/2020 11:00	0.0	14.0	1,474.6	0.0	0.0	1	1	0
09/10/2020 12:00	0.0	14.0	1,449.0	0.0	0.0	1	1	0
09/10/2020 13:00	0.0	14.0	1,460.1	0.0	0.0	1	1	0
09/10/2020 14:00	0.0	14.0	1,599.9	0.0	0.0	1	1	0
09/10/2020 15:00	0.0	13.9	1,573.5	0.0	0.0	1	1	1
09/10/2020 16:00	1.1	12.3	2,059.3	0.3	3.5	1	1	1
09/10/2020 17:00	1.0	12.4	2,032.5	0.5	3.2	1	1	1
09/10/2020 18:00	0.9	12.5	2,011.4	0.7	2.8	1	1	1
09/10/2020 19:00	0.9	12.6	2,011.1	0.6	2.9	1	1	1
09/10/2020 20:00	0.9	12.6	2,007.6	0.6	2.9	1	1	1
09/10/2020 21:00	0.9	12.7	2,000.6	0.6	2.9	1	1	1
09/10/2020 22:00	0.9	12.6	2,001.6	0.6	2.9	1	1	1
09/10/2020 23:00	0.7	13.2	1,843.3	0.6	2.2	1	1	1
Average/Sum#:	0.3	13.5	1,699.6	0.2	23.3 #	24 #	24 #	9 #
Minimum:	0.0	12.3	1,313.6	0.0	0.0	1	1	0
Maximum:	1.1	14.1	2,059.3	0.7	3.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/11/2020 00:00	0.4	13.9	1,416.1	0.5	1.1	1	1	0
09/11/2020 01:00	0.3	14.0	1,292.7	0.4	0.7	1	1	0
09/11/2020 02:00	0.2	14.0	1,292.1	0.3	0.5	1	1	0
09/11/2020 03:00	0.2	14.0	1,291.9	0.2	0.5	1	1	0
09/11/2020 04:00	0.1	14.0	1,291.9	0.2	0.2	1	1	0
09/11/2020 05:00	0.0	14.0	1,484.0	0.1	0.0	1	1	0
09/11/2020 06:00	0.2	14.1	1,297.4	0.1	0.5	1	1	0
09/11/2020 07:00	0.3	14.1	1,323.4	0.2	0.8	1	1	0
09/11/2020 08:00	0.2	14.1	1,345.4	0.2	0.5	1	1	0
09/11/2020 09:00	0.0	14.0	1,569.9	0.2	0.0	1	1	0
09/11/2020 10:00	0.0	14.0	1,553.5	0.1	0.0	1	1	0
09/11/2020 11:00	0.0	14.0	1,540.7	0.0	0.0	1	1	0
09/11/2020 12:00	0.0	14.0	1,587.4	0.0	0.0	1	1	0
09/11/2020 13:00	0.2	14.0	1,298.0	0.1	0.5	1	1	0
09/11/2020 14:00	0.1	14.1	1,300.6	0.1	0.3	1	1	0
09/11/2020 15:00	0.1	14.0	1,335.3	0.1	0.3	1	1	0
09/11/2020 16:00	0.1	13.9	1,647.5	0.1	0.3	1	1	0
09/11/2020 17:00	0.1	13.9	1,641.0	0.1	0.3	1	1	0
09/11/2020 18:00	0.6	13.3	1,805.5	0.2	1.9	1	1	1
09/11/2020 19:00	0.9	12.3	2,053.2	0.4	2.8	1	1	1
09/11/2020 20:00	1.0	12.4	2,015.8	0.6	3.1	1	1	1
09/11/2020 21:00	1.0	12.7	1,971.8	0.7	3.2	1	1	1
09/11/2020 22:00	0.6	13.7	1,484.3	0.6	1.6	1	1	1
09/11/2020 23:00	20.4	16.6	355.5	0.0	3.8	1	0	0
Average/Sum#:	1.1	13.9	1,466.5	0.2	22.9 #	24 #	23 #	5 #
Minimum:	0.0	12.3	355.5	0.0	0.0	1	0	0
Maximum:	20.4	16.6	2,053.2	0.7	3.8	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/12/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/12/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/12/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	4 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/13/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/13/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/13/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/13/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/13/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/13/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	6 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/14/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/14/2020 13:00	76.6	17.7	434.1	0.0	79.6	1	1	0
09/14/2020 14:00	33.4	15.8	688.2	0.0	59.5	1	1	0
09/14/2020 15:00	1.9	13.9	1,567.4	0.0	5.6	1	1	0
09/14/2020 16:00	0.5	13.1	1,814.4	0.0	1.5	1	1	1
09/14/2020 17:00	0.6	11.7	2,156.7	0.0	1.9	1	1	1
09/14/2020 18:00	0.6	11.7	2,159.9	0.4	1.9	1	1	1
09/14/2020 19:00	0.6	11.8	2,137.7	0.4	1.9	1	1	1
09/14/2020 20:00	0.6	11.7	2,152.2	0.4	1.9	1	1	1
09/14/2020 21:00	0.7	12.3	2,034.4	0.4	2.2	1	1	1
09/14/2020 22:00	0.7	12.7	1,957.7	0.5	2.2	1	1	1
09/14/2020 23:00	0.8	12.7	1,953.4	0.5	2.5	1	1	1
Average/Sum#:	10.6	13.2	1,732.4	0.4	160.7 #	11 #	14 #	8 #
Minimum:	0.5	11.7	434.1	0.4	1.5	0	0	0
Maximum:	76.6	17.7	2,159.9	0.5	79.6	1	1	1
%SI	54.17	54.17	54.17	75.00	54.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/15/2020 00:00	0.0	13.9	1,447.3	0.4	0.0	1	1	0
09/15/2020 01:00	0.0	14.0	1,330.6	0.2	0.0	1	1	0
09/15/2020 02:00	0.0	14.0	1,288.5	0.0	0.0	1	1	0
09/15/2020 03:00	0.0	14.0	1,289.5	0.0	0.0	1	1	0
09/15/2020 04:00	0.0	14.0	1,317.0	0.0	0.0	1	1	0
09/15/2020 05:00	0.0	13.9	1,573.3	0.0	0.0	1	1	0
09/15/2020 06:00	0.0	13.9	1,611.6	0.0	0.0	1	1	0
09/15/2020 07:00	0.0	14.0	1,434.8	0.0	0.0	1	1	0
09/15/2020 08:00	0.0	14.0	1,422.2	0.0	0.0	1	1	0
09/15/2020 09:00	0.0	14.0	1,289.1	0.0	0.0	1	1	0
09/15/2020 10:00	0.0	14.0	1,588.3	0.0	0.0	1	1	0
09/15/2020 11:00	0.0	14.0	1,614.0	0.0	0.0	1	1	0
09/15/2020 12:00	0.0	14.0	1,606.4	0.0	0.0	1	1	0
09/15/2020 13:00	0.0	13.8	1,674.8	0.0	0.0	1	1	1
09/15/2020 14:00	0.8	11.9	2,112.3	0.2	2.5	1	1	1
09/15/2020 15:00	0.7	11.7	2,134.4	0.3	2.1	1	1	1
09/15/2020 16:00	0.7	12.1	2,060.6	0.5	2.2	1	1	1
09/15/2020 17:00	0.7	12.2	2,054.1	0.5	2.2	1	1	1
09/15/2020 18:00	0.7	12.3	2,042.1	0.5	2.2	1	1	1
09/15/2020 19:00	0.8	12.2	2,061.5	0.5	2.5	1	1	1
09/15/2020 20:00	0.6	11.7	2,153.7	0.5	1.9	1	1	1
09/15/2020 21:00	0.6	12.1	2,079.8	0.4	1.9	1	1	1
09/15/2020 22:00	5.0	13.4	1,411.0	0.0	5.6	1	0	1
09/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.5	13.3	1,678.1	0.2	23.1 #	23 #	22 #	10 #
Minimum:	0.0	11.7	1,288.5	0.0	0.0	0	0	0
Maximum:	5.0	14.0	2,153.7	0.5	5.6	1	1	1
%SI	4.17	4.17	4.17	8.33	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 06:00	18.0	17.7	450.7	0.0	17.4	1	0	0
09/16/2020 07:00	18.1	14.6	1,111.1	0.0	42.2	1	0	0
09/16/2020 08:00	0.0	14.0	1,388.7	0.0	0.0	1	0	0
09/16/2020 09:00	0.0	13.9	1,386.8	0.0	0.0	1	0	0
09/16/2020 10:00	0.0	14.0	1,384.2	0.0	0.0	1	0	0
09/16/2020 11:00	0.0	13.9	1,602.5	0.0	0.0	1	0	0
09/16/2020 12:00	0.0	13.9	1,464.2	0.0	0.0	1	0	0
09/16/2020 13:00	0.0	13.8	1,690.5	0.0	0.0	1	1	0
09/16/2020 14:00	0.0	13.8	1,692.8	0.0	0.0	1	1	1
09/16/2020 15:00	0.8	12.0	2,086.2	0.2	2.5	1	1	1
09/16/2020 16:00	0.6	11.7	2,138.3	0.3	1.8	1	1	1
09/16/2020 17:00	0.5	11.5	2,182.1	0.4	1.5	1	1	1
09/16/2020 18:00	0.5	11.6	2,163.7	0.3	1.5	1	1	1
09/16/2020 19:00	0.7	12.3	2,029.2	0.4	2.2	1	1	1
09/16/2020 20:00	0.7	12.2	2,047.9	0.4	2.2	1	1	1
09/16/2020 21:00	0.7	12.3	2,036.4	0.5	2.2	1	1	1
09/16/2020 22:00	0.7	12.4	2,014.8	0.5	2.2	1	1	1
09/16/2020 23:00	0.7	12.7	1,944.5	0.5	2.2	1	1	1
Average/Sum#:	2.3	13.2	1,711.9	0.3	77.9 #	18 #	11 #	10 #
Minimum:	0.0	11.5	450.7	0.0	0.0	0	0	0
Maximum:	18.1	17.7	2,182.1	0.5	42.2	1	1	1
%SI	25.00	25.00	25.00	41.67	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/17/2020 00:00	0.0	13.9	1,406.6	0.3	0.0	1	1	0
09/17/2020 01:00	0.0	14.0	1,311.3	0.2	0.0	1	1	0
09/17/2020 02:00	0.0	14.0	1,292.7	0.0	0.0	1	1	0
09/17/2020 03:00	0.0	14.0	1,293.5	0.0	0.0	1	1	0
09/17/2020 04:00	0.0	13.9	1,466.9	0.0	0.0	1	1	0
09/17/2020 05:00	0.0	13.9	1,575.1	0.0	0.0	1	1	0
09/17/2020 06:00	0.0	13.9	1,541.3	0.0	0.0	1	1	0
09/17/2020 07:00	0.1	13.9	1,618.7	0.0	0.3	1	1	0
09/17/2020 08:00	0.0	13.9	1,592.2	0.0	0.0	1	1	0
09/17/2020 09:00	0.0	13.9	1,605.5	0.0	0.0	1	1	0
09/17/2020 10:00	0.0	13.9	1,420.9	0.0	0.0	1	1	0
09/17/2020 11:00	0.0	13.9	1,429.0	0.0	0.0	1	1	0
09/17/2020 12:00	0.0	13.9	1,625.5	0.0	0.0	1	1	1
09/17/2020 13:00	0.8	11.9	2,094.6	0.2	2.5	1	1	1
09/17/2020 14:00	0.5	11.5	2,149.9	0.3	1.5	1	1	1
09/17/2020 15:00	0.4	11.5	2,160.6	0.4	1.2	1	1	1
09/17/2020 16:00	0.3	11.4	2,177.0	0.3	0.9	1	1	1
09/17/2020 17:00	0.4	11.6	2,131.3	0.3	1.2	1	1	1
09/17/2020 18:00	0.5	12.1	2,057.5	0.3	1.5	1	1	1
09/17/2020 19:00	0.4	11.8	2,123.8	0.3	1.2	1	1	1
09/17/2020 20:00	0.5	12.2	2,055.5	0.3	1.6	1	1	1
09/17/2020 21:00	0.5	12.2	2,063.7	0.3	1.6	1	1	1
09/17/2020 22:00	0.5	12.0	2,108.0	0.3	1.6	1	1	1
09/17/2020 23:00	3.2	12.4	1,794.5	0.0	8.9	1	0	1
Average/Sum#:	0.3	13.0	1,754.0	0.2	24.0 #	24 #	23 #	12 #
Minimum:	0.0	11.4	1,292.7	0.0	0.0	1	0	0
Maximum:	3.2	14.0	2,177.0	0.4	8.9	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/18/2020 00:00	15.1	19.2	0.2	0.0	0.0	1	0	0
09/18/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 06:00	16.3	17.9	413.9	0.0	13.4	1	0	0
09/18/2020 07:00	21.4	15.4	957.2	0.0	49.2	1	0	0
09/18/2020 08:00	0.0	13.9	1,401.3	0.0	0.0	1	0	0
09/18/2020 09:00	0.0	14.0	1,397.2	0.0	0.0	1	0	0
09/18/2020 10:00	0.0	13.9	1,691.6	0.0	0.0	1	0	0
09/18/2020 11:00	0.0	13.9	1,496.5	0.0	0.0	1	0	0
09/18/2020 12:00	0.0	13.9	1,615.5	0.0	0.0	1	1	0
09/18/2020 13:00	0.0	13.9	1,540.2	0.0	0.0	1	1	1
09/18/2020 14:00	0.9	12.3	2,038.5	0.2	2.8	1	1	1
09/18/2020 15:00	0.8	12.1	2,070.8	0.4	2.5	1	1	1
09/18/2020 16:00	0.8	12.2	2,053.0	0.5	2.5	1	1	1
09/18/2020 17:00	0.7	12.3	2,037.3	0.5	2.2	1	1	1
09/18/2020 18:00	0.8	12.3	2,022.3	0.5	2.5	1	1	1
09/18/2020 19:00	0.8	12.4	2,017.2	0.5	2.5	1	1	1
09/18/2020 20:00	0.7	12.5	2,014.7	0.5	2.2	1	1	1
09/18/2020 21:00	0.7	12.5	2,010.1	0.5	2.2	1	1	1
09/18/2020 22:00	5.4	13.7	1,464.3	0.0	11.2	1	0	1
09/18/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	3.6	13.8	1,569.0	0.3	93.2 #	18 #	10 #	10 #
Minimum:	0.0	12.1	0.2	0.0	0.0	0	0	0
Maximum:	21.4	19.2	2,070.8	0.5	49.2	1	1	1
%SI	25.00	25.00	25.00	50.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/19/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 04:00	13.9	18.3	356.8	0.0	6.8	1	0	0
09/19/2020 05:00	27.7	15.2	953.0	0.0	61.2	1	0	0
09/19/2020 06:00	0.0	13.9	1,399.2	0.0	0.0	1	0	0
09/19/2020 07:00	0.0	13.9	1,389.0	0.0	0.0	1	0	0
09/19/2020 08:00	0.0	13.9	1,386.4	0.0	0.0	1	0	0
09/19/2020 09:00	0.0	14.0	1,388.2	0.0	0.0	1	0	0
09/19/2020 10:00	0.0	14.0	1,393.4	0.0	0.0	1	0	0
09/19/2020 11:00	0.0	14.0	1,397.6	0.0	0.0	1	0	0
09/19/2020 12:00	0.0	14.0	1,492.4	0.0	0.0	1	0	0
09/19/2020 13:00	0.0	13.9	1,583.3	0.0	0.0	1	0	0
09/19/2020 14:00	0.0	14.0	1,471.3	0.0	0.0	1	0	0
09/19/2020 15:00	0.0	14.0	1,538.0	0.0	0.0	1	1	1
09/19/2020 16:00	0.9	12.3	2,051.9	0.2	2.8	1	1	1
09/19/2020 17:00	0.6	11.5	2,199.3	0.3	1.9	1	1	1
09/19/2020 18:00	0.7	11.7	2,169.4	0.5	2.2	1	1	1
09/19/2020 19:00	0.7	11.7	2,158.4	0.4	2.2	1	1	1
09/19/2020 20:00	0.7	11.7	2,145.3	0.4	2.2	1	1	1
09/19/2020 21:00	0.7	12.0	2,100.9	0.4	2.2	1	1	1
09/19/2020 22:00	0.8	12.0	2,102.3	0.5	2.5	1	1	1
09/19/2020 23:00	0.8	12.7	1,967.5	0.5	2.5	1	1	1
Average/Sum#:	2.4	13.4	1,632.2	0.2	86.5 #	20 #	9 #	9 #
Minimum:	0.0	11.5	356.8	0.0	0.0	0	0	0
Maximum:	27.7	18.3	2,199.3	0.5	61.2	1	1	1
%SI	16.67	16.67	16.67	33.33	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/20/2020 00:00	0.9	12.8	1,954.8	0.6	2.9	1	1	1
09/20/2020 01:00	0.9	12.8	1,959.3	0.7	2.9	1	1	1
09/20/2020 02:00	0.9	12.8	1,960.4	0.7	2.9	1	1	1
09/20/2020 03:00	0.9	12.8	1,958.5	0.7	2.9	1	1	1
09/20/2020 04:00	0.9	12.9	1,947.3	0.7	2.9	1	1	1
09/20/2020 05:00	0.6	12.9	1,916.4	0.6	1.9	1	1	1
09/20/2020 06:00	12.8	15.6	659.6	0.0	5.3	1	0	0
09/20/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2020 10:00	12.0	17.9	408.1	0.0	10.4	1	0	0
09/20/2020 11:00	13.9	15.3	951.1	0.0	31.2	1	0	0
09/20/2020 12:00	0.0	14.0	1,486.9	0.0	0.0	1	0	0
09/20/2020 13:00	0.0	13.9	1,546.6	0.0	0.0	1	0	0
09/20/2020 14:00	0.0	13.9	1,602.4	0.0	0.0	1	0	0
09/20/2020 15:00	0.0	13.9	1,478.1	0.0	0.0	1	0	0
09/20/2020 16:00	0.0	13.9	1,588.9	0.0	0.0	1	1	1
09/20/2020 17:00	1.0	12.1	2,077.6	0.2	3.1	1	1	1
09/20/2020 18:00	0.7	11.4	2,205.7	0.4	2.1	1	1	1
09/20/2020 19:00	0.7	11.4	2,198.0	0.5	2.1	1	1	1
09/20/2020 20:00	0.7	11.7	2,160.0	0.4	2.2	1	1	1
09/20/2020 21:00	0.8	12.2	2,013.7	0.4	2.4	1	1	1
09/20/2020 22:00	15.4	15.6	627.8	0.0	5.5	1	0	0
09/20/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	3.2	13.5	1,635.1	0.4	80.7 #	20 #	12 #	12 #
Minimum:	0.0	11.4	408.1	0.0	0.0	0	0	0
Maximum:	15.4	17.9	2,205.7	0.7	31.2	1	1	1
%SI	16.67	16.67	16.67	41.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/21/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/21/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/21/2020 13:00	52.2	17.8	422.7	0.0	49.8	1	1	0
09/21/2020 14:00	24.1	15.5	809.6	0.0	47.7	1	1	0
09/21/2020 15:00	0.0	13.9	1,520.3	0.0	0.0	1	1	1
09/21/2020 16:00	0.8	12.4	1,984.3	0.0	2.5	1	1	1
09/21/2020 17:00	0.8	12.3	2,014.5	0.4	2.5	1	1	1
09/21/2020 18:00	0.8	12.4	1,995.7	0.6	2.5	1	1	1
09/21/2020 19:00	0.7	12.1	2,057.6	0.5	2.2	1	1	1
09/21/2020 20:00	0.7	11.9	2,104.7	0.5	2.2	1	1	1
09/21/2020 21:00	0.7	12.1	2,041.2	0.5	2.1	1	1	1
09/21/2020 22:00	13.1	15.7	620.1	0.0	4.7	1	0	0
09/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	9.4	13.6	1,557.1	0.5	116.2 #	10 #	11 #	7 #
Minimum:	0.0	11.9	422.7	0.4	0.0	0	0	0
Maximum:	52.2	17.8	2,104.7	0.6	49.8	1	1	1
%SI	58.33	58.33	58.33	79.17	58.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/22/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/22/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/22/2020 14:00	66.2	17.9	412.5	0.0	54.1	1	1	0
09/22/2020 15:00	24.4	15.5	828.1	0.0	49.4	1	1	0
09/22/2020 16:00	0.0	13.9	1,522.4	0.0	0.0	1	1	1
09/22/2020 17:00	0.7	12.6	1,765.3	0.0	2.0	1	1	1
09/22/2020 18:00	0.6	12.7	1,775.9	0.3	1.7	1	1	1
09/22/2020 19:00	0.6	12.7	1,775.9	0.4	1.7	1	1	1
09/22/2020 20:00	0.6	12.7	1,775.0	0.4	1.7	1	1	1
09/22/2020 21:00	8.0	14.2	1,185.6	0.0	8.8	1	0	1
09/22/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	12.6	14.0	1,380.1	0.4	119.4 #	8 #	10 #	6 #
Minimum:	0.0	12.6	412.5	0.3	0.0	0	0	0
Maximum:	66.2	17.9	1,775.9	0.4	54.1	1	1	1
%SI	66.67	66.67	66.67	87.50	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/23/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/23/2020 13:00	64.4	17.8	423.1	0.0	49.9	1	1	0
09/23/2020 14:00	24.4	15.7	795.1	0.0	49.3	1	1	0
09/23/2020 15:00	0.0	13.9	1,553.8	0.0	0.0	1	1	1
09/23/2020 16:00	0.8	12.3	2,024.5	0.0	2.5	1	1	1
09/23/2020 17:00	0.8	12.3	2,019.3	0.3	2.5	1	1	1
09/23/2020 18:00	0.8	12.6	1,989.1	0.5	2.5	1	1	1
09/23/2020 19:00	0.8	12.3	2,062.2	0.5	2.5	1	1	1
09/23/2020 20:00	0.8	12.8	1,941.0	0.6	2.5	1	1	1
09/23/2020 21:00	13.8	15.8	606.2	0.0	5.0	1	0	0
09/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	11.8	13.9	1,490.5	0.5	116.7 #	9 #	10 #	6 #
Minimum:	0.0	12.3	423.1	0.3	0.0	0	0	0
Maximum:	64.4	17.8	2,062.2	0.6	49.9	1	1	1
%SI	62.50	62.50	62.50	83.33	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 08:00	43.8	18.0	396.8	0.0	29.3	1	0	0
09/24/2020 09:00	19.0	17.1	515.3	0.0	34.0	1	0	0
09/24/2020 10:00	21.5	15.5	870.0	0.0	45.7	1	0	0
09/24/2020 11:00	0.0	14.0	1,380.6	0.0	0.0	1	0	0
09/24/2020 12:00	0.0	14.0	1,367.0	0.0	0.0	1	0	0
09/24/2020 13:00	0.0	13.9	1,577.5	0.0	0.0	1	0	0
09/24/2020 14:00	0.0	14.0	1,408.9	0.0	0.0	1	0	0
09/24/2020 15:00	0.0	13.9	1,659.9	0.0	0.0	1	1	0
09/24/2020 16:00	0.5	13.1	1,821.4	0.1	1.5	1	1	1
09/24/2020 17:00	0.8	11.9	2,104.3	0.3	2.5	1	1	1
09/24/2020 18:00	0.8	12.0	2,093.7	0.5	2.5	1	1	1
09/24/2020 19:00	0.8	12.1	2,086.4	0.5	2.5	1	1	1
09/24/2020 20:00	8.0	14.1	1,203.9	0.0	9.0	1	0	1
09/24/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	7.3	14.1	1,422.0	0.2	127.0 #	13 #	5 #	5 #
Minimum:	0.0	11.9	396.8	0.0	0.0	0	0	0
Maximum:	43.8	18.0	2,104.3	0.5	45.7	1	1	1
%SI	45.83	45.83	45.83	70.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 08:00	116.2	19.8	121.9	0.0	22.1	1	0	0
09/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/27/2020 13:00	83.1	19.2	216.0	0.0	23.7	1	1	0
09/27/2020 14:00	28.5	16.5	601.3	0.0	51.4	1	1	0
09/27/2020 15:00	0.8	14.0	1,610.3	0.0	2.5	1	1	0
09/27/2020 16:00	0.2	0.0	1,618.6	0.0	0.2	1	1	1
09/27/2020 17:00	0.9	11.8	2,097.3	0.0	2.7	1	1	1
09/27/2020 18:00	0.8	11.9	2,137.0	0.0	2.5	1	1	1
09/27/2020 19:00	0.8	11.8	2,148.4	0.5	2.5	1	1	1
09/27/2020 20:00	0.8	11.9	2,146.1	0.5	2.5	1	1	1
09/27/2020 21:00	0.8	11.9	2,140.9	0.5	2.5	1	1	1
09/27/2020 22:00	7.5	13.7	1,277.6	0.0	8.4	1	0	1
09/27/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	21.9	14.3	1,465.0	0.5	120.8 #	11 #	11 #	7 #
Minimum:	0.2	11.8	121.9	0.5	2.5	0	0	0
Maximum:	116.2	19.8	2,148.4	0.5	51.4	1	1	1
%SI	54.17	58.33	54.17	87.50	58.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/28/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 06:00	13.8	18.0	402.9	0.0	9.4	1	0	0
09/28/2020 07:00	15.3	15.5	897.4	0.0	33.6	1	0	0
09/28/2020 08:00	0.0	14.1	1,383.9	0.0	0.0	1	0	0
09/28/2020 09:00	0.0	14.1	1,368.3	0.0	0.0	1	0	0
09/28/2020 10:00	0.0	13.9	1,641.9	0.0	0.0	1	0	0
09/28/2020 11:00	0.0	14.0	1,465.0	0.0	0.0	1	0	0
09/28/2020 12:00	0.0	13.9	1,731.9	0.0	0.0	1	1	0
09/28/2020 13:00	0.3	13.6	1,690.7	0.1	0.9	1	1	1
09/28/2020 14:00	0.8	12.0	2,125.5	0.2	2.5	1	1	1
09/28/2020 15:00	0.5	11.5	2,208.3	0.3	1.6	1	1	1
09/28/2020 16:00	0.5	11.5	2,206.8	0.4	1.6	1	1	1
09/28/2020 17:00	0.6	11.6	2,191.5	0.3	1.9	1	1	1
09/28/2020 18:00	0.6	11.6	2,187.1	0.4	1.9	1	1	1
09/28/2020 19:00	0.7	11.9	2,131.0	0.4	2.2	1	1	1
09/28/2020 20:00	0.7	11.9	2,141.9	0.5	2.2	1	1	1
09/28/2020 21:00	0.8	12.1	2,105.4	0.5	2.5	1	1	1
09/28/2020 22:00	7.4	14.0	1,261.1	0.0	9.0	1	0	1
09/28/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	2.5	13.2	1,714.2	0.3	69.3 #	17 #	10 #	10 #
Minimum:	0.0	11.5	402.9	0.0	0.0	0	0	0
Maximum:	15.3	18.0	2,208.3	0.5	33.6	1	1	1
%SI	29.17	29.17	29.17	50.00	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 06:00	14.8	18.0	412.2	0.0	11.1	1	0	0
09/29/2020 07:00	19.9	15.6	873.1	0.0	43.3	1	0	0
09/29/2020 08:00	0.0	14.1	1,374.8	0.0	0.0	1	0	0
09/29/2020 09:00	0.0	14.1	1,361.9	0.0	0.0	1	0	0
09/29/2020 10:00	0.0	13.9	1,610.6	0.0	0.0	1	0	0
09/29/2020 11:00	0.0	14.0	1,484.3	0.0	0.0	1	0	0
09/29/2020 12:00	0.0	13.9	1,718.3	0.0	0.0	1	1	0
09/29/2020 13:00	0.6	13.3	1,794.9	0.2	1.9	1	1	1
09/29/2020 14:00	0.9	11.9	2,140.7	0.4	2.8	1	1	1
09/29/2020 15:00	0.8	11.7	2,162.4	0.5	2.5	1	1	1
09/29/2020 16:00	0.7	11.5	2,198.0	0.5	2.2	1	1	1
09/29/2020 17:00	0.6	11.5	2,198.4	0.4	1.9	1	1	1
09/29/2020 18:00	0.7	11.8	2,150.6	0.4	2.2	1	1	1
09/29/2020 19:00	0.7	11.7	2,187.4	0.4	2.2	1	1	1
09/29/2020 20:00	0.7	11.8	2,169.2	0.5	2.2	1	1	1
09/29/2020 21:00	0.8	11.9	2,148.6	0.5	2.5	1	1	1
09/29/2020 22:00	0.8	12.1	2,114.4	0.5	2.5	1	1	1
09/29/2020 23:00	0.8	12.2	2,103.0	0.5	2.6	1	1	1
Average/Sum#:	2.4	13.1	1,789.0	0.3	79.9 #	18 #	12 #	11 #
Minimum:	0.0	11.5	412.2	0.0	0.0	0	0	0
Maximum:	19.9	18.0	2,198.4	0.5	43.3	1	1	1
%SI	25.00	25.00	25.00	41.67	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:49 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/30/2020 00:00	0.8	12.6	2,012.9	0.5	2.6	1	1	1
09/30/2020 01:00	0.0	13.9	1,653.9	0.4	0.0	1	1	0
09/30/2020 02:00	0.0	13.9	1,693.5	0.2	0.0	1	1	0
09/30/2020 03:00	0.0	13.9	1,673.6	0.0	0.0	1	1	0
09/30/2020 04:00	0.3	13.7	1,718.6	0.1	0.9	1	1	1
09/30/2020 05:00	1.0	12.4	2,046.5	0.3	3.2	1	1	1
09/30/2020 06:00	0.9	12.4	2,035.4	0.5	2.8	1	1	1
09/30/2020 07:00	0.0	13.9	1,661.0	0.4	0.0	1	1	0
09/30/2020 08:00	0.1	13.9	1,695.7	0.2	0.3	1	1	0
09/30/2020 09:00	0.0	13.9	1,699.6	0.0	0.0	1	1	0
09/30/2020 10:00	0.3	13.6	1,696.0	0.1	0.9	1	1	1
09/30/2020 11:00	0.9	12.1	2,112.0	0.3	2.9	1	1	1
09/30/2020 12:00	0.8	11.8	2,147.5	0.4	2.5	1	1	1
09/30/2020 13:00	0.6	11.6	2,177.0	0.5	1.9	1	1	1
09/30/2020 14:00	0.6	11.8	2,116.5	0.4	1.8	1	1	1
09/30/2020 15:00	0.7	11.7	2,151.0	0.4	2.2	1	1	1
09/30/2020 16:00	0.6	11.7	2,142.2	0.4	1.8	1	1	1
09/30/2020 17:00	0.7	11.8	2,121.0	0.4	2.2	1	1	1
09/30/2020 18:00	0.7	11.8	2,139.7	0.5	2.2	1	1	1
09/30/2020 19:00	0.7	11.7	2,163.6	0.5	2.2	1	1	1
09/30/2020 20:00	0.7	11.8	2,146.1	0.5	2.2	1	1	1
09/30/2020 21:00	0.7	11.9	2,128.7	0.5	2.2	1	1	1
09/30/2020 22:00	0.7	12.0	2,113.7	0.5	2.2	1	1	1
09/30/2020 23:00	0.8	12.5	1,981.1	0.5	2.5	1	1	1
Average/Sum#:	0.5	12.6	1,967.8	0.4	39.5 #	24 #	24 #	18 #
Minimum:	0.0	11.6	1,653.9	0.0	0.0	1	1	0
Maximum:	1.0	13.9	2,177.0	0.5	3.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2020 08:00	74.7	17.6	451.6	0.0	94.5	1	0	0
07/03/2020 09:00	16.1	17.1	517.8	0.0	29.0	1	0	0
07/03/2020 10:00	18.5	15.8	830.3	0.0	39.8	1	0	0
07/03/2020 11:00	0.2	13.9	1,391.9	0.0	0.5	1	1	0
07/03/2020 12:00	0.3	13.9	1,359.1	0.0	0.8	1	1	0
07/03/2020 13:00	0.3	13.9	1,606.0	0.3	0.9	1	1	0
07/03/2020 14:00	0.3	13.9	1,451.0	0.3	0.8	1	1	0
07/03/2020 15:00	0.3	13.8	1,676.5	0.3	0.9	1	1	0
07/03/2020 16:00	0.3	13.8	1,641.4	0.2	0.9	1	1	1
07/03/2020 17:00	0.6	12.4	2,019.1	0.3	1.9	1	1	1
07/03/2020 18:00	0.4	12.0	2,108.2	0.3	1.3	1	1	1
07/03/2020 19:00	0.4	12.0	2,089.5	0.3	1.2	1	1	1
07/03/2020 20:00	0.4	11.9	2,117.2	0.3	1.2	1	1	1
07/03/2020 21:00	0.5	12.3	2,033.4	0.3	1.6	1	1	1
07/03/2020 22:00	0.5	12.3	2,052.5	0.3	1.6	1	1	1
07/03/2020 23:00	6.9	14.1	1,216.3	0.0	8.5	1	0	1
Average/Sum#:	7.5	13.8	1,535.1	0.3	185.4 #	16 #	12 #	8 #
Minimum:	0.2	11.9	451.6	0.2	0.5	0	0	0
Maximum:	74.7	17.6	2,117.2	0.3	94.5	1	1	1
%SI	33.33	33.33	33.33	58.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/04/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/05/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2020 09:00	57.4	17.5	455.8	0.0	71.1	1	0	0
07/05/2020 10:00	13.0	17.0	520.2	0.0	22.9	1	0	0
07/05/2020 11:00	19.7	15.4	867.4	0.0	41.0	1	0	0
07/05/2020 12:00	0.2	14.0	1,394.7	0.0	0.5	1	1	0
07/05/2020 13:00	0.2	14.0	1,383.8	0.0	0.5	1	1	0
07/05/2020 14:00	0.3	13.8	1,632.8	0.2	0.9	1	1	0
07/05/2020 15:00	0.2	14.0	1,389.5	0.2	0.5	1	1	0
07/05/2020 16:00	0.4	13.8	1,603.7	0.2	1.2	1	1	0
07/05/2020 17:00	0.5	13.0	1,813.1	0.3	1.5	1	1	1
07/05/2020 18:00	0.5	11.9	2,095.0	0.3	1.5	1	1	1
07/05/2020 19:00	0.5	12.0	2,077.3	0.3	1.5	1	1	1
07/05/2020 20:00	0.5	12.0	2,095.4	0.3	1.6	1	1	1
07/05/2020 21:00	0.5	12.2	2,082.0	0.3	1.6	1	1	1
07/05/2020 22:00	4.8	13.6	1,379.2	0.0	7.2	1	0	1
07/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	7.1	13.9	1,485.0	0.3	153.5 #	14 #	10 #	6 #
Minimum:	0.2	11.9	455.8	0.2	0.5	0	0	0
Maximum:	57.4	17.5	2,095.4	0.3	71.1	1	1	1
%SI	41.67	41.67	41.67	66.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2020 02:00	14.7	17.7	448.7	0.0	9.5	1	0	0
07/06/2020 03:00	12.0	14.5	1,146.4	0.0	28.4	1	0	0
07/06/2020 04:00	0.2	13.9	1,375.6	0.0	0.5	1	1	0
07/06/2020 05:00	0.3	13.9	1,375.6	0.0	0.8	1	1	0
07/06/2020 06:00	0.3	13.9	1,378.4	0.3	0.8	1	1	0
07/06/2020 07:00	0.3	13.9	1,379.4	0.3	0.8	1	1	0
07/06/2020 08:00	0.3	14.0	1,382.7	0.3	0.8	1	1	0
07/06/2020 09:00	0.3	13.9	1,384.9	0.3	0.8	1	1	0
07/06/2020 10:00	0.3	13.9	1,389.9	0.3	0.8	1	1	0
07/06/2020 11:00	0.4	13.8	1,637.8	0.3	1.2	1	1	0
07/06/2020 12:00	0.4	13.8	1,507.3	0.3	1.1	1	1	0
07/06/2020 13:00	0.4	13.7	1,697.7	0.3	1.2	1	1	0
07/06/2020 14:00	0.4	13.8	1,627.3	0.3	1.2	1	1	0
07/06/2020 15:00	0.4	13.7	1,556.1	0.3	1.1	1	1	1
07/06/2020 16:00	0.7	12.3	2,050.3	0.4	2.2	1	1	1
07/06/2020 17:00	0.5	12.0	2,098.7	0.4	1.6	1	1	1
07/06/2020 18:00	0.5	11.9	2,111.2	0.4	1.5	1	1	1
07/06/2020 19:00	0.5	12.1	2,085.5	0.3	1.6	1	1	1
07/06/2020 20:00	0.6	12.3	2,065.3	0.3	1.9	1	1	1
07/06/2020 21:00	0.6	12.4	2,040.8	0.4	1.9	1	1	1
07/06/2020 22:00	0.6	12.8	1,951.6	0.4	1.9	1	1	1
07/06/2020 23:00	0.5	13.1	1,794.6	0.4	1.5	1	1	1
Average/Sum#:	1.6	13.5	1,613.0	0.3	63.1 #	22 #	20 #	9 #
Minimum:	0.2	11.9	448.7	0.3	0.5	0	0	0
Maximum:	14.7	17.7	2,111.2	0.4	28.4	1	1	1
%SI	8.33	8.33	8.33	25.00	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/07/2020 00:00	0.3	13.9	1,294.8	0.4	0.7	1	1	0
07/07/2020 01:00	0.3	13.9	1,344.3	0.3	0.8	1	1	0
07/07/2020 02:00	0.3	13.9	1,301.2	0.3	0.7	1	1	0
07/07/2020 03:00	0.3	13.9	1,292.5	0.3	0.7	1	1	0
07/07/2020 04:00	0.3	13.9	1,283.1	0.3	0.7	1	1	0
07/07/2020 05:00	0.3	13.9	1,306.7	0.3	0.7	1	1	0
07/07/2020 06:00	0.3	13.9	1,293.5	0.3	0.7	1	1	0
07/07/2020 07:00	0.3	13.9	1,310.8	0.3	0.7	1	1	0
07/07/2020 08:00	0.3	14.0	1,329.5	0.3	0.8	1	1	0
07/07/2020 09:00	0.3	13.9	1,305.9	0.3	0.7	1	1	0
07/07/2020 10:00	0.2	13.9	1,295.0	0.3	0.5	1	1	0
07/07/2020 11:00	0.2	14.0	1,299.5	0.2	0.5	1	1	0
07/07/2020 12:00	0.2	14.0	1,301.5	0.2	0.5	1	1	0
07/07/2020 13:00	0.4	13.9	1,403.2	0.2	1.1	1	1	0
07/07/2020 14:00	0.3	13.9	1,374.7	0.3	0.8	1	1	0
07/07/2020 15:00	0.3	13.9	1,514.4	0.3	0.9	1	1	1
07/07/2020 16:00	0.6	12.3	2,035.3	0.3	1.9	1	1	1
07/07/2020 17:00	0.4	12.0	2,107.7	0.3	1.3	1	1	1
07/07/2020 18:00	0.4	12.1	2,081.0	0.3	1.2	1	1	1
07/07/2020 19:00	0.4	12.2	2,071.5	0.3	1.3	1	1	1
07/07/2020 20:00	0.4	12.2	2,075.5	0.3	1.3	1	1	1
07/07/2020 21:00	0.4	12.3	2,066.0	0.3	1.3	1	1	1
07/07/2020 22:00	0.6	12.7	1,966.2	0.3	1.9	1	1	1
07/07/2020 23:00	0.5	13.0	1,849.4	0.4	1.5	1	1	1
Average/Sum#:	0.3	13.4	1,562.6	0.3	23.2 #	24 #	24 #	9 #
Minimum:	0.2	12.0	1,283.1	0.2	0.5	1	1	0
Maximum:	0.6	14.0	2,107.7	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/08/2020 00:00	0.1	14.0	1,316.6	0.3	0.3	1	1	0
07/08/2020 01:00	0.2	14.0	1,283.1	0.2	0.5	1	1	0
07/08/2020 02:00	0.2	14.0	1,283.2	0.2	0.5	1	1	0
07/08/2020 03:00	0.1	14.0	1,283.2	0.2	0.2	1	1	0
07/08/2020 04:00	0.1	14.0	1,285.2	0.1	0.2	1	1	0
07/08/2020 05:00	0.1	14.0	1,296.4	0.1	0.2	1	1	0
07/08/2020 06:00	0.1	14.0	1,287.7	0.1	0.2	1	1	0
07/08/2020 07:00	0.0	14.0	1,291.8	0.1	0.0	1	1	0
07/08/2020 08:00	0.1	14.0	1,289.9	0.1	0.2	1	1	0
07/08/2020 09:00	0.1	14.0	1,289.4	0.1	0.2	1	1	0
07/08/2020 10:00	0.1	14.0	1,291.4	0.1	0.2	1	1	0
07/08/2020 11:00	0.2	14.0	1,308.4	0.1	0.5	1	1	0
07/08/2020 12:00	0.2	14.0	1,363.9	0.2	0.5	1	1	0
07/08/2020 13:00	0.2	14.0	1,315.9	0.2	0.5	1	1	0
07/08/2020 14:00	0.2	14.0	1,367.2	0.2	0.5	1	1	0
07/08/2020 15:00	0.2	13.9	1,455.6	0.2	0.5	1	1	1
07/08/2020 16:00	0.5	12.2	2,035.2	0.2	1.5	1	1	1
07/08/2020 17:00	0.4	12.0	2,067.8	0.3	1.2	1	1	1
07/08/2020 18:00	0.3	12.0	2,077.6	0.3	0.9	1	1	1
07/08/2020 19:00	0.4	12.0	2,075.5	0.3	1.2	1	1	1
07/08/2020 20:00	0.4	12.0	2,077.7	0.3	1.2	1	1	1
07/08/2020 21:00	0.4	12.3	2,016.0	0.3	1.2	1	1	1
07/08/2020 22:00	0.5	12.6	1,969.5	0.3	1.6	1	1	1
07/08/2020 23:00	0.4	12.9	1,805.0	0.3	1.2	1	1	1
Average/Sum#:	0.2	13.4	1,547.2	0.2	15.2 #	24 #	24 #	9 #
Minimum:	0.0	12.0	1,283.1	0.1	0.0	1	1	0
Maximum:	0.5	14.0	2,077.7	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/09/2020 00:00	0.2	13.9	1,304.7	0.3	0.5	1	1	0
07/09/2020 01:00	0.2	13.9	1,300.1	0.2	0.5	1	1	0
07/09/2020 02:00	0.2	13.9	1,282.4	0.2	0.5	1	1	0
07/09/2020 03:00	0.2	13.9	1,343.4	0.2	0.5	1	1	0
07/09/2020 04:00	0.2	13.9	1,312.4	0.2	0.5	1	1	0
07/09/2020 05:00	0.2	13.9	1,366.0	0.2	0.5	1	1	0
07/09/2020 06:00	0.2	14.0	1,295.6	0.2	0.5	1	1	0
07/09/2020 07:00	0.1	14.0	1,295.1	0.2	0.2	1	1	0
07/09/2020 08:00	0.1	14.0	1,298.9	0.1	0.2	1	1	0
07/09/2020 09:00	0.2	14.0	1,301.3	0.1	0.5	1	1	0
07/09/2020 10:00	0.3	13.9	1,296.7	0.2	0.7	1	1	0
07/09/2020 11:00	0.2	14.0	1,296.8	0.2	0.5	1	1	0
07/09/2020 12:00	0.3	13.9	1,545.2	0.3	0.9	1	1	0
07/09/2020 13:00	0.3	13.8	1,663.7	0.2	0.9	1	1	0
07/09/2020 14:00	0.3	13.8	1,535.0	0.2	0.9	1	1	1
07/09/2020 15:00	0.6	12.2	2,036.1	0.3	1.9	1	1	1
07/09/2020 16:00	0.5	12.0	2,070.7	0.3	1.5	1	1	1
07/09/2020 17:00	0.4	11.9	2,086.0	0.3	1.2	1	1	1
07/09/2020 18:00	0.4	11.8	2,106.8	0.3	1.2	1	1	1
07/09/2020 19:00	0.4	11.8	2,104.1	0.3	1.2	1	1	1
07/09/2020 20:00	0.4	12.0	2,070.7	0.3	1.2	1	1	1
07/09/2020 21:00	0.4	12.1	2,069.5	0.3	1.2	1	1	1
07/09/2020 22:00	0.5	12.6	1,975.0	0.3	1.6	1	1	1
07/09/2020 23:00	0.6	12.7	1,920.2	0.4	1.9	1	1	1
Average/Sum#:	0.3	13.2	1,619.9	0.2	21.2 #	24 #	24 #	10 #
Minimum:	0.1	11.8	1,282.4	0.1	0.2	1	1	0
Maximum:	0.6	14.0	2,106.8	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/10/2020 00:00	0.2	13.9	1,390.8	0.3	0.5	1	1	0
07/10/2020 01:00	0.2	14.0	1,287.0	0.3	0.5	1	1	0
07/10/2020 02:00	0.1	14.0	1,286.1	0.2	0.2	1	1	0
07/10/2020 03:00	0.1	14.0	1,283.4	0.1	0.2	1	1	0
07/10/2020 04:00	0.1	13.9	1,293.4	0.1	0.2	1	1	0
07/10/2020 05:00	0.2	13.9	1,564.4	0.1	0.6	1	1	0
07/10/2020 06:00	0.2	13.9	1,666.7	0.2	0.6	1	1	0
07/10/2020 07:00	0.2	13.8	1,666.7	0.2	0.6	1	1	0
07/10/2020 08:00	0.2	13.9	1,579.1	0.2	0.6	1	1	0
07/10/2020 09:00	0.2	13.9	1,443.5	0.2	0.5	1	1	0
07/10/2020 10:00	0.2	13.9	1,479.8	0.2	0.6	1	1	0
07/10/2020 11:00	0.2	13.9	1,373.5	0.2	0.5	1	1	0
07/10/2020 12:00	0.3	13.8	1,529.8	0.2	0.9	1	1	1
07/10/2020 13:00	0.6	12.3	2,008.5	0.3	1.9	1	1	1
07/10/2020 14:00	0.5	12.0	2,064.0	0.3	1.5	1	1	1
07/10/2020 15:00	0.5	12.0	2,067.6	0.3	1.5	1	1	1
07/10/2020 16:00	0.4	11.8	2,090.1	0.3	1.2	1	1	1
07/10/2020 17:00	0.4	11.7	2,103.5	0.3	1.2	1	1	1
07/10/2020 18:00	0.4	11.7	2,111.5	0.3	1.2	1	1	1
07/10/2020 19:00	0.4	11.7	2,115.1	0.3	1.2	1	1	1
07/10/2020 20:00	0.4	11.7	2,114.5	0.3	1.2	1	1	1
07/10/2020 21:00	0.5	12.1	2,042.9	0.3	1.5	1	1	1
07/10/2020 22:00	0.5	12.1	2,059.0	0.3	1.5	1	1	1
07/10/2020 23:00	0.5	12.9	1,788.6	0.3	1.5	1	1	1
Average/Sum#:	0.3	13.0	1,725.4	0.2	21.9 #	24 #	24 #	12 #
Minimum:	0.1	11.7	1,283.4	0.1	0.2	1	1	0
Maximum:	0.6	14.0	2,115.1	0.3	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/11/2020 00:00	0.3	13.9	1,296.6	0.3	0.7	1	1	0
07/11/2020 01:00	0.4	13.9	1,344.8	0.3	1.0	1	1	0
07/11/2020 02:00	0.3	13.9	1,352.0	0.3	0.8	1	1	0
07/11/2020 03:00	0.3	13.9	1,368.2	0.3	0.8	1	1	0
07/11/2020 04:00	0.3	13.9	1,333.1	0.3	0.8	1	1	0
07/11/2020 05:00	0.4	13.9	1,655.3	0.3	1.2	1	1	0
07/11/2020 06:00	0.4	13.9	1,585.4	0.3	1.2	1	1	0
07/11/2020 07:00	0.3	13.9	1,360.0	0.3	0.8	1	1	0
07/11/2020 08:00	0.3	13.9	1,577.4	0.3	0.9	1	1	0
07/11/2020 09:00	0.3	13.9	1,308.9	0.3	0.7	1	1	0
07/11/2020 10:00	0.3	13.9	1,479.0	0.3	0.8	1	1	0
07/11/2020 11:00	0.3	13.8	1,610.3	0.3	0.9	1	1	0
07/11/2020 12:00	0.3	13.9	1,619.1	0.3	0.9	1	1	0
07/11/2020 13:00	0.3	13.9	1,364.5	0.3	0.8	1	1	0
07/11/2020 14:00	0.2	13.9	1,363.2	0.3	0.5	1	1	0
07/11/2020 15:00	0.5	13.0	1,786.6	0.3	1.5	1	1	1
07/11/2020 16:00	0.4	11.9	2,090.2	0.3	1.2	1	1	1
07/11/2020 17:00	0.3	11.8	2,113.8	0.3	0.9	1	1	1
07/11/2020 18:00	0.3	11.8	2,122.3	0.2	0.9	1	1	1
07/11/2020 19:00	0.3	11.8	2,127.3	0.2	0.9	1	1	1
07/11/2020 20:00	0.4	12.0	2,085.5	0.2	1.2	1	1	1
07/11/2020 21:00	0.4	12.2	2,050.1	0.3	1.2	1	1	1
07/11/2020 22:00	0.5	12.2	2,065.3	0.3	1.6	1	1	1
07/11/2020 23:00	0.5	12.9	1,805.9	0.3	1.5	1	1	1
Average/Sum#:	0.3	13.3	1,661.0	0.3	23.7 #	24 #	24 #	9 #
Minimum:	0.2	11.8	1,296.6	0.2	0.5	1	1	0
Maximum:	0.5	13.9	2,127.3	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/12/2020 00:00	0.2	13.9	1,295.6	0.3	0.5	1	1	0
07/12/2020 01:00	0.2	13.9	1,287.2	0.3	0.5	1	1	0
07/12/2020 02:00	0.3	13.9	1,286.0	0.2	0.7	1	1	0
07/12/2020 03:00	0.3	13.9	1,285.9	0.3	0.7	1	1	0
07/12/2020 04:00	0.2	13.9	1,287.1	0.3	0.5	1	1	0
07/12/2020 05:00	0.2	13.9	1,288.6	0.2	0.5	1	1	0
07/12/2020 06:00	0.2	14.0	1,299.8	0.2	0.5	1	1	0
07/12/2020 07:00	0.2	14.0	1,295.9	0.2	0.5	1	1	0
07/12/2020 08:00	0.2	14.0	1,290.6	0.2	0.5	1	1	0
07/12/2020 09:00	0.2	14.0	1,300.9	0.2	0.5	1	1	0
07/12/2020 10:00	0.2	14.0	1,403.5	0.2	0.5	1	1	0
07/12/2020 11:00	0.3	13.9	1,371.6	0.2	0.8	1	1	0
07/12/2020 12:00	0.3	13.9	1,427.6	0.3	0.8	1	1	0
07/12/2020 13:00	0.3	14.0	1,365.6	0.3	0.8	1	1	0
07/12/2020 14:00	0.2	14.0	1,313.3	0.3	0.5	1	1	0
07/12/2020 15:00	0.3	13.7	1,643.7	0.2	0.9	1	1	1
07/12/2020 16:00	0.5	12.1	2,053.3	0.2	1.5	1	1	1
07/12/2020 17:00	0.4	11.7	2,111.8	0.3	1.2	1	1	1
07/12/2020 18:00	0.4	11.7	2,102.2	0.3	1.2	1	1	1
07/12/2020 19:00	0.4	11.8	2,091.2	0.3	1.2	1	1	1
07/12/2020 20:00	0.4	12.0	2,048.7	0.3	1.2	1	1	1
07/12/2020 21:00	0.5	12.2	2,022.0	0.3	1.5	1	1	1
07/12/2020 22:00	0.5	12.0	2,061.4	0.3	1.5	1	1	1
07/12/2020 23:00	0.6	12.5	1,936.2	0.3	1.8	1	1	1
Average/Sum#:	0.3	13.3	1,577.9	0.3	20.8 #	24 #	24 #	9 #
Minimum:	0.2	11.7	1,285.9	0.2	0.5	1	1	0
Maximum:	0.6	14.0	2,111.8	0.3	1.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/13/2020 00:00	0.4	13.8	1,575.8	0.3	1.2	1	1	0
07/13/2020 01:00	0.4	13.8	1,438.5	0.3	1.1	1	1	0
07/13/2020 02:00	0.3	13.9	1,319.9	0.3	0.7	1	1	0
07/13/2020 03:00	0.3	13.9	1,289.0	0.3	0.7	1	1	0
07/13/2020 04:00	0.3	13.9	1,289.2	0.3	0.7	1	1	0
07/13/2020 05:00	0.4	13.8	1,622.3	0.3	1.2	1	1	0
07/13/2020 06:00	0.4	13.8	1,486.7	0.3	1.1	1	1	0
07/13/2020 07:00	0.4	13.9	1,390.0	0.3	1.0	1	1	0
07/13/2020 08:00	0.4	13.9	1,521.8	0.3	1.1	1	1	0
07/13/2020 09:00	0.3	13.9	1,306.4	0.3	0.7	1	1	0
07/13/2020 10:00	0.3	13.9	1,480.7	0.3	0.8	1	1	0
07/13/2020 11:00	0.3	13.8	1,617.5	0.3	0.9	1	1	1
07/13/2020 12:00	0.6	12.4	2,000.9	0.3	1.9	1	1	1
07/13/2020 13:00	0.4	12.0	2,050.8	0.3	1.2	1	1	1
07/13/2020 14:00	0.4	12.0	2,063.9	0.3	1.2	1	1	1
07/13/2020 15:00	0.4	11.9	2,064.6	0.3	1.2	1	1	1
07/13/2020 16:00	0.4	11.9	2,074.4	0.3	1.2	1	1	1
07/13/2020 17:00	0.4	11.8	2,083.9	0.3	1.2	1	1	1
07/13/2020 18:00	0.3	11.8	2,083.5	0.3	0.9	1	1	1
07/13/2020 19:00	0.3	11.9	2,079.3	0.2	0.9	1	1	1
07/13/2020 20:00	0.4	12.0	2,067.4	0.2	1.2	1	1	1
07/13/2020 21:00	0.4	12.1	2,056.2	0.3	1.2	1	1	1
07/13/2020 22:00	0.4	12.2	2,056.1	0.3	1.2	1	1	1
07/13/2020 23:00	0.6	12.7	1,946.3	0.3	1.9	1	1	1
Average/Sum#:	0.4	13.0	1,748.5	0.3	26.4 #	24 #	24 #	13 #
Minimum:	0.3	11.8	1,289.0	0.2	0.7	1	1	0
Maximum:	0.6	13.9	2,083.9	0.3	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/14/2020 00:00	0.5	13.1	1,776.5	0.4	1.5	1	1	1
07/14/2020 01:00	0.2	13.8	1,294.3	0.3	0.5	1	1	0
07/14/2020 02:00	0.2	13.9	1,351.9	0.3	0.5	1	1	0
07/14/2020 03:00	0.3	13.9	1,292.8	0.2	0.7	1	1	0
07/14/2020 04:00	0.3	13.9	1,286.6	0.3	0.7	1	1	0
07/14/2020 05:00	0.4	13.8	1,625.6	0.3	1.2	1	1	0
07/14/2020 06:00	0.4	13.8	1,657.9	0.3	1.2	1	1	0
07/14/2020 07:00	0.3	13.8	1,671.9	0.3	0.9	1	1	0
07/14/2020 08:00	0.3	13.8	1,546.9	0.2	0.9	1	1	0
07/14/2020 09:00	0.3	13.9	1,297.9	0.2	0.7	1	1	0
07/14/2020 10:00	0.3	13.9	1,313.5	0.3	0.7	1	1	0
07/14/2020 11:00	0.3	13.9	1,359.7	0.3	0.8	1	1	0
07/14/2020 12:00	0.3	13.8	1,530.8	0.3	0.9	1	1	0
07/14/2020 13:00	0.3	13.9	1,340.1	0.3	0.8	1	1	0
07/14/2020 14:00	0.6	12.4	1,959.1	0.3	1.8	1	1	1
07/14/2020 15:00	0.5	12.0	2,041.4	0.3	1.5	1	1	1
07/14/2020 16:00	0.5	12.0	2,060.0	0.3	1.5	1	1	1
07/14/2020 17:00	0.4	11.9	2,062.9	0.3	1.2	1	1	1
07/14/2020 18:00	0.4	11.9	2,078.4	0.3	1.2	1	1	1
07/14/2020 19:00	0.4	11.9	2,075.3	0.3	1.2	1	1	1
07/14/2020 20:00	0.4	12.0	2,068.2	0.3	1.2	1	1	1
07/14/2020 21:00	0.4	12.0	2,072.3	0.3	1.2	1	1	1
07/14/2020 22:00	0.5	12.6	1,952.5	0.3	1.6	1	1	1
07/14/2020 23:00	0.5	13.0	1,777.5	0.4	1.5	1	1	1
Average/Sum#:	0.4	13.1	1,687.3	0.3	25.9 #	24 #	24 #	11 #
Minimum:	0.2	11.9	1,286.6	0.2	0.5	1	1	0
Maximum:	0.6	13.9	2,078.4	0.4	1.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/15/2020 00:00	0.3	13.8	1,290.4	0.3	0.7	1	1	0
07/15/2020 01:00	0.3	13.9	1,289.2	0.3	0.7	1	1	0
07/15/2020 02:00	0.3	13.9	1,287.8	0.3	0.7	1	1	0
07/15/2020 03:00	0.3	13.9	1,289.4	0.3	0.7	1	1	0
07/15/2020 04:00	0.3	13.9	1,289.8	0.3	0.7	1	1	0
07/15/2020 05:00	0.3	13.9	1,315.0	0.3	0.7	1	1	0
07/15/2020 06:00	0.3	13.9	1,301.2	0.3	0.7	1	1	0
07/15/2020 07:00	0.3	13.9	1,288.0	0.3	0.7	1	1	0
07/15/2020 08:00	0.3	13.9	1,289.7	0.3	0.7	1	1	0
07/15/2020 09:00	0.3	13.9	1,293.4	0.3	0.7	1	1	0
07/15/2020 10:00	0.3	13.9	1,294.1	0.3	0.7	1	1	0
07/15/2020 11:00	0.3	13.9	1,297.3	0.3	0.7	1	1	0
07/15/2020 12:00	0.3	13.9	1,295.2	0.3	0.7	1	1	0
07/15/2020 13:00	0.3	13.9	1,298.7	0.3	0.7	1	1	0
07/15/2020 14:00	0.3	13.9	1,307.2	0.3	0.7	1	1	0
07/15/2020 15:00	0.3	13.9	1,302.6	0.3	0.7	1	1	0
07/15/2020 16:00	0.4	13.9	1,308.4	0.3	1.0	1	1	0
07/15/2020 17:00	0.3	13.9	1,308.3	0.3	0.7	1	1	0
07/15/2020 18:00	0.3	13.9	1,391.6	0.3	0.8	1	1	0
07/15/2020 19:00	0.4	13.9	1,459.0	0.3	1.1	1	1	0
07/15/2020 20:00	0.3	13.9	1,355.3	0.3	0.8	1	1	0
07/15/2020 21:00	0.3	13.9	1,287.3	0.3	0.7	1	1	0
07/15/2020 22:00	0.3	13.9	1,284.0	0.3	0.7	1	1	0
07/15/2020 23:00	0.3	13.9	1,315.6	0.3	0.7	1	1	0
Average/Sum#:	0.3	13.9	1,309.9	0.3	17.7 #	24 #	24 #	0 #
Minimum:	0.3	13.8	1,284.0	0.3	0.7	1	1	0
Maximum:	0.4	13.9	1,459.0	0.3	1.1	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/16/2020 00:00	0.3	13.9	1,284.2	0.3	0.7	1	1	0
07/16/2020 01:00	0.3	13.9	1,285.8	0.3	0.7	1	1	0
07/16/2020 02:00	0.3	13.9	1,284.0	0.3	0.7	1	1	0
07/16/2020 03:00	0.3	13.9	1,282.1	0.3	0.7	1	1	0
07/16/2020 04:00	0.4	13.9	1,282.7	0.3	1.0	1	1	0
07/16/2020 05:00	0.4	13.9	1,283.3	0.3	1.0	1	1	0
07/16/2020 06:00	0.3	13.9	1,285.5	0.3	0.7	1	1	0
07/16/2020 07:00	0.3	13.9	1,286.5	0.3	0.7	1	1	0
07/16/2020 08:00	0.4	13.9	1,289.6	0.3	1.0	1	1	0
07/16/2020 09:00	0.3	13.9	1,292.8	0.3	0.7	1	1	0
07/16/2020 10:00	0.3	13.9	1,297.8	0.3	0.7	1	1	0
07/16/2020 11:00	0.3	13.9	1,295.1	0.3	0.7	1	1	0
07/16/2020 12:00	0.3	13.9	1,294.3	0.3	0.7	1	1	0
07/16/2020 13:00	0.3	13.9	1,296.7	0.3	0.7	1	1	0
07/16/2020 14:00	0.3	13.9	1,462.0	0.3	0.8	1	1	0
07/16/2020 15:00	0.4	13.8	1,503.0	0.3	1.1	1	1	1
07/16/2020 16:00	0.6	12.1	2,030.0	0.3	1.8	1	1	1
07/16/2020 17:00	0.4	11.9	2,061.3	0.3	1.2	1	1	1
07/16/2020 18:00	0.4	12.0	2,051.2	0.3	1.2	1	1	1
07/16/2020 19:00	0.4	11.9	2,075.9	0.3	1.2	1	1	1
07/16/2020 20:00	0.4	11.9	2,075.5	0.3	1.2	1	1	1
07/16/2020 21:00	0.4	12.1	2,069.2	0.3	1.2	1	1	1
07/16/2020 22:00	0.6	12.7	1,952.5	0.3	1.9	1	1	1
07/16/2020 23:00	0.5	13.1	1,778.6	0.4	1.5	1	1	1
Average/Sum#:	0.4	13.3	1,545.8	0.3	23.8 #	24 #	24 #	9 #
Minimum:	0.3	11.9	1,282.1	0.3	0.7	1	1	0
Maximum:	0.6	13.9	2,075.9	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/17/2020 00:00	0.2	13.8	1,294.0	0.3	0.5	1	1	0
07/17/2020 01:00	0.3	13.9	1,295.3	0.3	0.7	1	1	0
07/17/2020 02:00	0.3	13.9	1,290.3	0.3	0.7	1	1	0
07/17/2020 03:00	0.3	13.9	1,297.8	0.3	0.7	1	1	0
07/17/2020 04:00	0.3	13.9	1,292.6	0.3	0.7	1	1	0
07/17/2020 05:00	0.3	13.9	1,300.2	0.3	0.7	1	1	0
07/17/2020 06:00	0.3	13.9	1,300.7	0.3	0.7	1	1	0
07/17/2020 07:00	0.2	13.9	1,295.6	0.3	0.5	1	1	0
07/17/2020 08:00	0.2	13.9	1,298.0	0.2	0.5	1	1	0
07/17/2020 09:00	0.3	13.9	1,311.9	0.2	0.7	1	1	0
07/17/2020 10:00	0.3	13.9	1,305.6	0.3	0.7	1	1	0
07/17/2020 11:00	0.3	13.9	1,308.6	0.3	0.7	1	1	0
07/17/2020 12:00	0.3	13.9	1,317.7	0.3	0.7	1	1	0
07/17/2020 13:00	0.3	13.9	1,327.4	0.3	0.8	1	1	0
07/17/2020 14:00	0.3	13.9	1,300.2	0.3	0.7	1	1	0
07/17/2020 15:00	0.3	13.9	1,303.1	0.3	0.7	1	1	0
07/17/2020 16:00	0.4	13.8	1,502.9	0.3	1.1	1	1	1
07/17/2020 17:00	0.6	12.1	2,019.1	0.3	1.8	1	1	1
07/17/2020 18:00	0.5	11.9	2,064.0	0.3	1.5	1	1	1
07/17/2020 19:00	0.5	12.0	2,071.5	0.3	1.5	1	1	1
07/17/2020 20:00	0.5	12.0	2,077.0	0.3	1.5	1	1	1
07/17/2020 21:00	0.5	12.1	2,067.4	0.3	1.6	1	1	1
07/17/2020 22:00	0.6	12.6	1,961.4	0.3	1.9	1	1	1
07/17/2020 23:00	0.6	13.0	1,848.1	0.4	1.9	1	1	1
Average/Sum#:	0.4	13.4	1,518.8	0.3	23.5 #	24 #	24 #	8 #
Minimum:	0.2	11.9	1,290.3	0.2	0.5	1	1	0
Maximum:	0.6	13.9	2,077.0	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/18/2020 00:00	0.3	13.7	1,746.9	0.3	1.0	1	1	0
07/18/2020 01:00	0.4	13.8	1,590.9	0.3	1.2	1	1	0
07/18/2020 02:00	0.3	13.9	1,306.2	0.3	0.7	1	1	0
07/18/2020 03:00	0.3	13.9	1,307.2	0.3	0.7	1	1	0
07/18/2020 04:00	0.3	13.9	1,318.6	0.3	0.7	1	1	0
07/18/2020 05:00	0.3	13.9	1,351.5	0.3	0.8	1	1	0
07/18/2020 06:00	0.3	13.9	1,291.8	0.3	0.7	1	1	0
07/18/2020 07:00	0.3	13.9	1,292.0	0.3	0.7	1	1	0
07/18/2020 08:00	0.3	13.9	1,292.2	0.3	0.7	1	1	0
07/18/2020 09:00	0.3	13.9	1,298.2	0.3	0.7	1	1	0
07/18/2020 10:00	0.3	13.9	1,299.4	0.3	0.7	1	1	0
07/18/2020 11:00	0.3	13.9	1,389.3	0.3	0.8	1	1	0
07/18/2020 12:00	0.3	13.9	1,404.9	0.3	0.8	1	1	0
07/18/2020 13:00	0.4	13.8	1,584.1	0.3	1.2	1	1	1
07/18/2020 14:00	0.7	12.5	1,978.2	0.4	2.2	1	1	1
07/18/2020 15:00	0.4	13.5	1,508.7	0.4	1.1	1	1	1
07/18/2020 16:00	0.3	13.8	1,593.0	0.3	0.9	1	1	1
07/18/2020 17:00	0.5	12.2	2,011.9	0.3	1.5	1	1	1
07/18/2020 18:00	0.4	11.8	2,089.1	0.3	1.2	1	1	1
07/18/2020 19:00	0.4	11.8	2,109.3	0.3	1.2	1	1	1
07/18/2020 20:00	0.4	11.9	2,081.8	0.3	1.2	1	1	1
07/18/2020 21:00	0.5	12.4	1,980.3	0.3	1.5	1	1	1
07/18/2020 22:00	0.6	12.5	1,966.0	0.3	1.9	1	1	1
07/18/2020 23:00	0.6	12.8	1,846.1	0.4	1.8	1	1	1
Average/Sum#:	0.4	13.3	1,609.9	0.3	25.9 #	24 #	24 #	11 #
Minimum:	0.3	11.8	1,291.8	0.3	0.7	1	1	0
Maximum:	0.7	13.9	2,109.3	0.4	2.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/19/2020 00:00	0.5	13.6	1,734.9	0.4	1.6	1	1	0
07/19/2020 01:00	0.4	13.8	1,311.7	0.4	1.0	1	1	0
07/19/2020 02:00	0.4	13.9	1,287.7	0.3	1.0	1	1	0
07/19/2020 03:00	0.4	13.9	1,292.9	0.3	1.0	1	1	0
07/19/2020 04:00	0.4	13.9	1,287.0	0.3	1.0	1	1	0
07/19/2020 05:00	0.3	13.9	1,288.6	0.3	0.7	1	1	0
07/19/2020 06:00	0.3	13.9	1,287.1	0.3	0.7	1	1	0
07/19/2020 07:00	0.3	13.9	1,290.5	0.3	0.7	1	1	0
07/19/2020 08:00	0.3	13.9	1,299.2	0.3	0.7	1	1	0
07/19/2020 09:00	0.3	13.9	1,293.6	0.3	0.7	1	1	0
07/19/2020 10:00	0.3	13.9	1,300.8	0.3	0.7	1	1	0
07/19/2020 11:00	0.3	13.9	1,300.0	0.3	0.7	1	1	0
07/19/2020 12:00	0.3	13.9	1,300.4	0.3	0.7	1	1	0
07/19/2020 13:00	0.3	13.9	1,302.9	0.3	0.7	1	1	0
07/19/2020 14:00	0.3	13.9	1,308.9	0.3	0.7	1	1	0
07/19/2020 15:00	0.3	13.9	1,307.1	0.3	0.7	1	1	0
07/19/2020 16:00	0.3	13.8	1,496.4	0.3	0.8	1	1	0
07/19/2020 17:00	0.5	12.1	2,012.9	0.3	1.5	1	1	1
07/19/2020 18:00	0.4	11.8	2,080.7	0.3	1.2	1	1	1
07/19/2020 19:00	0.4	11.9	2,077.1	0.3	1.2	1	1	1
07/19/2020 20:00	0.4	12.0	2,068.7	0.3	1.2	1	1	1
07/19/2020 21:00	0.5	12.1	2,054.1	0.3	1.5	1	1	1
07/19/2020 22:00	0.6	12.6	1,951.2	0.3	1.9	1	1	1
07/19/2020 23:00	0.5	13.1	1,772.0	0.4	1.5	1	1	1
Average/Sum#:	0.4	13.4	1,529.4	0.3	24.1 #	24 #	24 #	7 #
Minimum:	0.3	11.8	1,287.0	0.3	0.7	1	1	0
Maximum:	0.6	13.9	2,080.7	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/20/2020 00:00	0.2	13.9	1,290.5	0.3	0.5	1	1	0
07/20/2020 01:00	0.3	13.9	1,282.2	0.3	0.7	1	1	0
07/20/2020 02:00	0.3	13.9	1,280.9	0.3	0.7	1	1	0
07/20/2020 03:00	0.3	13.9	1,280.1	0.3	0.7	1	1	0
07/20/2020 04:00	0.3	13.9	1,278.7	0.3	0.7	1	1	0
07/20/2020 05:00	0.3	13.9	1,294.2	0.3	0.7	1	1	0
07/20/2020 06:00	0.3	13.8	1,655.8	0.3	0.9	1	1	0
07/20/2020 07:00	0.3	13.8	1,628.1	0.2	0.9	1	1	0
07/20/2020 08:00	0.3	13.8	1,671.1	0.2	0.9	1	1	0
07/20/2020 09:00	0.3	13.9	1,381.4	0.2	0.8	1	1	0
07/20/2020 10:00	0.3	13.9	1,529.3	0.3	0.9	1	1	0
07/20/2020 11:00	0.3	13.8	1,539.5	0.3	0.9	1	1	0
07/20/2020 12:00	0.4	13.8	1,517.4	0.3	1.1	1	1	1
07/20/2020 13:00	0.6	12.3	1,998.7	0.3	1.8	1	1	1
07/20/2020 14:00	0.6	12.4	1,977.0	0.4	1.8	1	1	1
07/20/2020 15:00	0.5	12.0	2,036.8	0.4	1.5	1	1	1
07/20/2020 16:00	0.4	12.0	2,041.7	0.3	1.2	1	1	1
07/20/2020 17:00	0.4	12.0	2,044.4	0.3	1.2	1	1	1
07/20/2020 18:00	0.4	11.9	2,070.5	0.3	1.2	1	1	1
07/20/2020 19:00	0.4	11.9	2,072.5	0.3	1.2	1	1	1
07/20/2020 20:00	0.4	12.0	2,066.0	0.3	1.2	1	1	1
07/20/2020 21:00	0.5	12.1	2,049.1	0.3	1.5	1	1	1
07/20/2020 22:00	0.5	12.5	1,977.5	0.3	1.6	1	1	1
07/20/2020 23:00	0.4	13.0	1,759.6	0.3	1.2	1	1	1
Average/Sum#:	0.4	13.1	1,696.8	0.3	25.8 #	24 #	24 #	12 #
Minimum:	0.2	11.9	1,278.7	0.2	0.5	1	1	0
Maximum:	0.6	13.9	2,072.5	0.4	1.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/21/2020 00:00	0.2	13.9	1,283.2	0.3	0.5	1	1	0
07/21/2020 01:00	0.2	13.9	1,282.2	0.2	0.5	1	1	0
07/21/2020 02:00	0.2	13.9	1,281.7	0.2	0.5	1	1	0
07/21/2020 03:00	0.3	13.9	1,280.8	0.2	0.7	1	1	0
07/21/2020 04:00	0.3	13.9	1,280.5	0.3	0.7	1	1	0
07/21/2020 05:00	0.3	13.9	1,292.2	0.3	0.7	1	1	0
07/21/2020 06:00	0.3	13.8	1,647.1	0.3	0.9	1	1	0
07/21/2020 07:00	0.3	13.8	1,522.9	0.2	0.8	1	1	0
07/21/2020 08:00	0.3	13.9	1,520.4	0.2	0.9	1	1	0
07/21/2020 09:00	0.3	13.9	1,368.6	0.3	0.8	1	1	0
07/21/2020 10:00	0.3	13.8	1,505.2	0.3	0.8	1	1	0
07/21/2020 11:00	0.3	13.9	1,367.2	0.3	0.8	1	1	0
07/21/2020 12:00	0.3	13.9	1,381.4	0.3	0.8	1	1	0
07/21/2020 13:00	0.6	12.9	1,790.1	0.3	1.8	1	1	1
07/21/2020 14:00	0.5	12.0	2,044.0	0.3	1.5	1	1	1
07/21/2020 15:00	0.4	11.9	2,051.2	0.3	1.2	1	1	1
07/21/2020 16:00	0.4	11.8	2,068.3	0.3	1.2	1	1	1
07/21/2020 17:00	0.4	11.8	2,089.8	0.3	1.2	1	1	1
07/21/2020 18:00	0.4	11.8	2,086.9	0.3	1.2	1	1	1
07/21/2020 19:00	0.4	11.9	2,074.8	0.3	1.2	1	1	1
07/21/2020 20:00	0.4	12.0	2,076.0	0.3	1.2	1	1	1
07/21/2020 21:00	0.4	12.1	2,060.2	0.3	1.2	1	1	1
07/21/2020 22:00	0.5	12.6	1,968.2	0.3	1.6	1	1	1
07/21/2020 23:00	0.4	13.0	1,829.4	0.3	1.2	1	1	1
Average/Sum#:	0.4	13.1	1,673.0	0.3	23.9 #	24 #	24 #	11 #
Minimum:	0.2	11.8	1,280.5	0.2	0.5	1	1	0
Maximum:	0.6	13.9	2,089.8	0.3	1.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/22/2020 00:00	0.2	13.8	1,393.5	0.3	0.5	1	1	0
07/22/2020 01:00	0.2	13.9	1,280.2	0.2	0.5	1	1	0
07/22/2020 02:00	0.3	13.9	1,280.8	0.2	0.7	1	1	0
07/22/2020 03:00	0.3	13.9	1,277.9	0.3	0.7	1	1	0
07/22/2020 04:00	0.3	13.9	1,292.5	0.3	0.7	1	1	0
07/22/2020 05:00	0.3	13.8	1,372.8	0.3	0.8	1	1	0
07/22/2020 06:00	0.3	13.8	1,655.6	0.2	0.9	1	1	0
07/22/2020 07:00	0.3	13.9	1,357.5	0.2	0.8	1	1	0
07/22/2020 08:00	0.3	13.9	1,294.0	0.3	0.7	1	1	0
07/22/2020 09:00	0.2	13.9	1,296.2	0.3	0.5	1	1	0
07/22/2020 10:00	0.3	13.9	1,298.0	0.3	0.7	1	1	0
07/22/2020 11:00	0.3	13.9	1,298.3	0.3	0.7	1	1	0
07/22/2020 12:00	0.3	13.9	1,292.9	0.3	0.7	1	1	0
07/22/2020 13:00	0.3	13.9	1,291.8	0.3	0.7	1	1	0
07/22/2020 14:00	0.3	13.9	1,292.6	0.3	0.7	1	1	0
07/22/2020 15:00	0.3	13.9	1,301.0	0.3	0.7	1	1	0
07/22/2020 16:00	0.3	13.8	1,630.9	0.3	0.9	1	1	1
07/22/2020 17:00	0.6	12.3	1,997.3	0.3	1.8	1	1	1
07/22/2020 18:00	0.5	12.1	2,043.0	0.3	1.5	1	1	1
07/22/2020 19:00	0.4	12.2	2,040.0	0.3	1.2	1	1	1
07/22/2020 20:00	0.5	12.3	2,039.7	0.3	1.6	1	1	1
07/22/2020 21:00	0.4	12.3	2,037.5	0.3	1.3	1	1	1
07/22/2020 22:00	0.5	12.7	1,948.7	0.3	1.6	1	1	1
07/22/2020 23:00	0.5	13.1	1,770.4	0.4	1.5	1	1	1
Average/Sum#:	0.3	13.5	1,532.6	0.3	22.4 #	24 #	24 #	8 #
Minimum:	0.2	12.1	1,277.9	0.2	0.5	1	1	0
Maximum:	0.6	13.9	2,043.0	0.4	1.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/23/2020 00:00	0.2	13.9	1,284.3	0.3	0.5	1	1	0
07/23/2020 01:00	0.3	13.9	1,278.5	0.3	0.7	1	1	0
07/23/2020 02:00	0.3	13.9	1,277.1	0.3	0.7	1	1	0
07/23/2020 03:00	0.3	13.9	1,277.6	0.3	0.7	1	1	0
07/23/2020 04:00	0.3	13.9	1,279.5	0.3	0.7	1	1	0
07/23/2020 05:00	0.3	13.9	1,283.9	0.3	0.7	1	1	0
07/23/2020 06:00	0.3	13.9	1,288.3	0.3	0.7	1	1	0
07/23/2020 07:00	0.3	13.9	1,291.3	0.3	0.7	1	1	0
07/23/2020 08:00	0.3	13.9	1,295.3	0.3	0.7	1	1	0
07/23/2020 09:00	0.3	13.9	1,295.3	0.3	0.7	1	1	0
07/23/2020 10:00	0.3	13.9	1,300.3	0.3	0.7	1	1	0
07/23/2020 11:00	0.3	13.9	1,295.2	0.3	0.7	1	1	0
07/23/2020 12:00	0.3	13.9	1,296.2	0.3	0.7	1	1	0
07/23/2020 13:00	0.3	13.9	1,287.5	0.3	0.7	1	1	0
07/23/2020 14:00	0.3	13.9	1,291.4	0.3	0.7	1	1	0
07/23/2020 15:00	0.3	13.9	1,294.7	0.3	0.7	1	1	0
07/23/2020 16:00	0.3	13.9	1,293.3	0.3	0.7	1	1	0
07/23/2020 17:00	0.3	13.9	1,405.7	0.3	0.8	1	1	0
07/23/2020 18:00	0.4	13.8	1,626.5	0.3	1.2	1	1	0
07/23/2020 19:00	0.4	13.8	1,608.9	0.3	1.2	1	1	0
07/23/2020 20:00	0.4	13.8	1,427.6	0.3	1.1	1	1	0
07/23/2020 21:00	0.3	13.9	1,333.8	0.3	0.8	1	1	0
07/23/2020 22:00	0.4	13.9	1,286.5	0.3	1.0	1	1	0
07/23/2020 23:00	0.4	13.9	1,324.1	0.3	1.0	1	1	0
Average/Sum#:	0.3	13.9	1,330.1	0.3	18.8 #	24 #	24 #	0 #
Minimum:	0.2	13.8	1,277.1	0.3	0.5	1	1	0
Maximum:	0.4	13.9	1,626.5	0.3	1.2	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/24/2020 00:00	0.4	13.9	1,280.6	0.3	1.0	1	1	0
07/24/2020 01:00	0.3	13.9	1,282.8	0.3	0.7	1	1	0
07/24/2020 02:00	0.3	13.9	1,278.9	0.3	0.7	1	1	0
07/24/2020 03:00	0.3	13.9	1,278.1	0.3	0.7	1	1	0
07/24/2020 04:00	0.4	13.9	1,281.6	0.3	1.0	1	1	0
07/24/2020 05:00	0.4	13.9	1,288.0	0.3	1.0	1	1	0
07/24/2020 06:00	0.4	13.9	1,320.4	0.3	1.0	1	1	0
07/24/2020 07:00	0.3	13.9	1,268.1	0.3	0.2	1	1	0
07/24/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/24/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.4	13.9	1,284.8	0.3	6.3 #	8 #	8 #	0 #
Minimum:	0.3	13.9	1,268.1	0.3	0.2	0	0	0
Maximum:	0.4	13.9	1,320.4	0.3	1.0	1	1	0
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/25/2020 13:00	51.1	17.7	427.2	0.0	45.1	1	0	0
07/25/2020 14:00	17.7	15.7	797.3	0.0	35.8	1	0	0
07/25/2020 15:00	0.3	13.8	1,548.8	0.0	0.9	1	1	0
07/25/2020 16:00	0.3	13.8	1,536.9	0.0	0.9	1	1	1
07/25/2020 17:00	0.5	12.3	2,011.5	0.2	1.5	1	1	1
07/25/2020 18:00	0.4	11.9	2,073.0	0.3	1.2	1	1	1
07/25/2020 19:00	0.4	11.9	2,077.3	0.3	1.2	1	1	1
07/25/2020 20:00	0.4	12.0	2,077.8	0.3	1.2	1	1	1
07/25/2020 21:00	0.4	12.1	2,061.6	0.3	1.2	1	1	1
07/25/2020 22:00	0.5	12.4	2,009.6	0.3	1.6	1	1	1
07/25/2020 23:00	0.4	12.3	2,013.6	0.3	1.2	1	1	1
Average/Sum#:	6.6	13.3	1,694.1	0.3	91.8 #	11 #	9 #	8 #
Minimum:	0.3	11.9	427.2	0.2	0.9	0	0	0
Maximum:	51.1	17.7	2,077.8	0.3	45.1	1	1	1
%SI	54.17	54.17	54.17	70.83	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/26/2020 00:00	0.2	13.9	1,442.7	0.3	0.5	1	1	0
07/26/2020 01:00	0.2	13.9	1,598.1	0.2	0.6	1	1	0
07/26/2020 02:00	0.3	13.9	1,538.2	0.2	0.9	1	1	0
07/26/2020 03:00	0.3	13.9	1,497.6	0.3	0.8	1	1	0
07/26/2020 04:00	0.3	13.9	1,529.1	0.3	0.9	1	1	0
07/26/2020 05:00	0.2	13.9	1,408.7	0.3	0.5	1	1	0
07/26/2020 06:00	0.2	13.9	1,282.0	0.2	0.5	1	1	0
07/26/2020 07:00	0.2	13.9	1,283.8	0.2	0.5	1	1	0
07/26/2020 08:00	0.2	13.9	1,285.7	0.2	0.5	1	1	0
07/26/2020 09:00	0.3	13.9	1,289.3	0.2	0.7	1	1	0
07/26/2020 10:00	0.3	13.9	1,377.9	0.3	0.8	1	1	0
07/26/2020 11:00	0.3	13.9	1,533.2	0.3	0.9	1	1	0
07/26/2020 12:00	0.3	13.9	1,543.7	0.3	0.9	1	1	0
07/26/2020 13:00	0.3	13.7	1,686.1	0.3	0.9	1	1	1
07/26/2020 14:00	0.5	12.3	2,005.1	0.3	1.5	1	1	1
07/26/2020 15:00	0.4	13.4	1,623.8	0.3	1.1	1	1	1
07/26/2020 16:00	0.4	13.0	1,776.3	0.3	1.2	1	1	1
07/26/2020 17:00	0.4	11.7	2,098.0	0.3	1.2	1	1	1
07/26/2020 18:00	0.3	11.7	2,101.2	0.3	0.9	1	1	1
07/26/2020 19:00	0.3	11.7	2,102.1	0.2	0.9	1	1	1
07/26/2020 20:00	0.4	11.9	2,077.3	0.2	1.2	1	1	1
07/26/2020 21:00	0.4	12.0	2,069.2	0.3	1.2	1	1	1
07/26/2020 22:00	0.5	12.5	1,960.9	0.3	1.5	1	1	1
07/26/2020 23:00	0.4	12.9	1,774.5	0.3	1.2	1	1	1
Average/Sum#:	0.3	13.2	1,661.9	0.3	21.8 #	24 #	24 #	11 #
Minimum:	0.2	11.7	1,282.0	0.2	0.5	1	1	0
Maximum:	0.5	13.9	2,102.1	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/27/2020 00:00	0.3	13.9	1,287.3	0.3	0.7	1	1	0
07/27/2020 01:00	0.3	13.9	1,283.4	0.3	0.7	1	1	0
07/27/2020 02:00	0.3	13.9	1,283.0	0.3	0.7	1	1	0
07/27/2020 03:00	0.2	13.9	1,285.6	0.3	0.5	1	1	0
07/27/2020 04:00	0.3	13.9	1,293.1	0.3	0.7	1	1	0
07/27/2020 05:00	0.3	13.8	1,640.1	0.2	0.9	1	1	0
07/27/2020 06:00	0.3	13.9	1,672.1	0.3	0.9	1	1	0
07/27/2020 07:00	0.2	13.8	1,676.8	0.2	0.6	1	1	0
07/27/2020 08:00	0.2	13.9	1,640.1	0.2	0.6	1	1	0
07/27/2020 09:00	0.2	13.9	1,343.5	0.2	0.5	1	1	0
07/27/2020 10:00	0.3	13.9	1,569.2	0.2	0.9	1	1	0
07/27/2020 11:00	0.3	13.8	1,535.7	0.2	0.9	1	1	1
07/27/2020 12:00	0.6	12.2	2,027.6	0.3	1.8	1	1	1
07/27/2020 13:00	0.4	11.8	2,085.5	0.3	1.2	1	1	1
07/27/2020 14:00	0.4	11.9	2,060.3	0.3	1.2	1	1	1
07/27/2020 15:00	0.4	11.7	2,086.6	0.3	1.2	1	1	1
07/27/2020 16:00	0.4	11.6	2,091.1	0.3	1.2	1	1	1
07/27/2020 17:00	0.4	11.6	2,093.1	0.3	1.2	1	1	1
07/27/2020 18:00	0.3	11.7	2,078.0	0.3	0.9	1	1	1
07/27/2020 19:00	0.4	11.8	2,071.9	0.3	1.2	1	1	1
07/27/2020 20:00	0.3	11.7	2,105.5	0.2	0.9	1	1	1
07/27/2020 21:00	0.3	11.9	2,079.3	0.2	0.9	1	1	1
07/27/2020 22:00	0.3	11.9	2,080.1	0.2	0.9	1	1	1
07/27/2020 23:00	0.4	12.5	1,937.3	0.2	1.2	1	1	1
Average/Sum#:	0.3	12.9	1,762.8	0.3	22.4 #	24 #	24 #	13 #
Minimum:	0.2	11.6	1,283.0	0.2	0.5	1	1	0
Maximum:	0.6	13.9	2,105.5	0.3	1.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/28/2020 00:00	0.2	13.8	1,538.6	0.2	0.6	1	1	0
07/28/2020 01:00	0.3	13.8	1,499.8	0.2	0.8	1	1	0
07/28/2020 02:00	0.3	13.9	1,422.9	0.2	0.8	1	1	0
07/28/2020 03:00	0.3	13.9	1,497.9	0.3	0.8	1	1	0
07/28/2020 04:00	0.3	13.8	1,536.7	0.3	0.9	1	1	0
07/28/2020 05:00	0.3	13.8	1,594.4	0.2	0.9	1	1	0
07/28/2020 06:00	0.3	13.8	1,688.1	0.2	0.9	1	1	0
07/28/2020 07:00	0.3	13.8	1,668.9	0.2	0.9	1	1	0
07/28/2020 08:00	0.3	13.9	1,518.4	0.2	0.9	1	1	0
07/28/2020 09:00	0.2	13.9	1,313.4	0.2	0.5	1	1	0
07/28/2020 10:00	0.2	13.9	1,518.3	0.2	0.6	1	1	0
07/28/2020 11:00	0.2	13.8	1,493.3	0.2	0.6	1	1	1
07/28/2020 12:00	0.5	12.2	2,029.0	0.2	1.5	1	1	1
07/28/2020 13:00	0.4	12.0	2,071.3	0.3	1.2	1	1	1
07/28/2020 14:00	0.4	11.9	2,077.8	0.3	1.2	1	1	1
07/28/2020 15:00	0.3	11.7	2,103.0	0.3	0.9	1	1	1
07/28/2020 16:00	0.3	11.7	2,105.9	0.2	0.9	1	1	1
07/28/2020 17:00	0.3	11.7	2,096.4	0.2	0.9	1	1	1
07/28/2020 18:00	0.3	11.7	2,098.7	0.2	0.9	1	1	1
07/28/2020 19:00	0.3	11.9	2,071.0	0.2	0.9	1	1	1
07/28/2020 20:00	0.4	12.0	2,090.5	0.2	1.2	1	1	1
07/28/2020 21:00	0.4	12.0	2,096.2	0.3	1.2	1	1	1
07/28/2020 22:00	0.4	12.1	2,075.7	0.3	1.2	1	1	1
07/28/2020 23:00	0.5	12.1	2,058.1	0.3	1.5	1	1	1
Average/Sum#:	0.3	12.9	1,802.7	0.2	22.7 #	24 #	24 #	13 #
Minimum:	0.2	11.7	1,313.4	0.2	0.5	1	1	0
Maximum:	0.5	13.9	2,105.9	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/29/2020 00:00	0.6	12.7	1,953.1	0.3	1.9	1	1	1
07/29/2020 01:00	0.6	12.8	1,935.1	0.4	1.9	1	1	1
07/29/2020 02:00	0.6	12.8	1,936.4	0.4	1.9	1	1	1
07/29/2020 03:00	0.6	12.8	1,948.8	0.4	1.9	1	1	1
07/29/2020 04:00	0.5	12.3	2,052.0	0.4	1.6	1	1	1
07/29/2020 05:00	0.5	12.3	2,067.7	0.3	1.6	1	1	1
07/29/2020 06:00	0.4	12.3	2,052.8	0.3	1.3	1	1	1
07/29/2020 07:00	0.5	12.8	1,950.5	0.3	1.6	1	1	1
07/29/2020 08:00	0.5	12.7	1,943.7	0.4	1.6	1	1	1
07/29/2020 09:00	0.5	12.7	1,958.0	0.4	1.6	1	1	1
07/29/2020 10:00	0.4	12.2	2,064.2	0.4	1.3	1	1	1
07/29/2020 11:00	0.4	12.1	2,065.3	0.3	1.2	1	1	1
07/29/2020 12:00	0.4	12.0	2,076.1	0.3	1.2	1	1	1
07/29/2020 13:00	0.4	12.0	2,067.9	0.3	1.2	1	1	1
07/29/2020 14:00	0.4	11.8	2,097.9	0.3	1.2	1	1	1
07/29/2020 15:00	0.3	11.7	2,104.7	0.3	0.9	1	1	1
07/29/2020 16:00	0.3	11.8	2,109.2	0.2	0.9	1	1	1
07/29/2020 17:00	0.3	11.8	2,104.8	0.2	0.9	1	1	1
07/29/2020 18:00	0.3	11.8	2,101.5	0.2	0.9	1	1	1
07/29/2020 19:00	0.3	11.8	2,116.9	0.2	0.9	1	1	1
07/29/2020 20:00	0.3	11.9	2,110.0	0.2	0.9	1	1	1
07/29/2020 21:00	0.4	12.1	2,074.6	0.2	1.2	1	1	1
07/29/2020 22:00	0.4	12.0	2,094.1	0.3	1.2	1	1	1
07/29/2020 23:00	0.4	12.1	2,078.4	0.3	1.2	1	1	1
Average/Sum#:	0.4	12.2	2,044.3	0.3	32.0 #	24 #	24 #	24 #
Minimum:	0.3	11.7	1,935.1	0.2	0.9	1	1	1
Maximum:	0.6	12.8	2,116.9	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/30/2020 00:00	0.4	12.2	2,058.9	0.3	1.3	1	1	1
07/30/2020 01:00	0.6	12.7	1,949.2	0.3	1.9	1	1	1
07/30/2020 02:00	0.6	12.8	1,937.6	0.4	1.9	1	1	1
07/30/2020 03:00	0.6	12.9	1,935.5	0.4	1.9	1	1	1
07/30/2020 04:00	0.6	12.9	1,947.5	0.4	1.9	1	1	1
07/30/2020 05:00	0.5	12.3	2,064.6	0.4	1.6	1	1	1
07/30/2020 06:00	0.5	12.4	2,050.3	0.3	1.6	1	1	1
07/30/2020 07:00	0.5	12.8	1,947.2	0.3	1.6	1	1	1
07/30/2020 08:00	0.5	12.8	1,941.0	0.4	1.6	1	1	1
07/30/2020 09:00	0.5	12.7	1,951.7	0.4	1.6	1	1	1
07/30/2020 10:00	0.5	12.2	2,057.9	0.4	1.6	1	1	1
07/30/2020 11:00	0.4	12.1	2,079.2	0.3	1.2	1	1	1
07/30/2020 12:00	0.4	12.1	2,068.6	0.3	1.2	1	1	1
07/30/2020 13:00	0.4	12.0	2,071.7	0.3	1.2	1	1	1
07/30/2020 14:00	0.4	11.9	2,077.8	0.3	1.2	1	1	1
07/30/2020 15:00	0.3	11.8	2,098.6	0.3	0.9	1	1	1
07/30/2020 16:00	0.3	11.7	2,105.1	0.2	0.9	1	1	1
07/30/2020 17:00	0.3	11.7	2,106.1	0.2	0.9	1	1	1
07/30/2020 18:00	0.3	11.7	2,105.0	0.2	0.9	1	1	1
07/30/2020 19:00	0.4	12.1	2,029.4	0.2	1.2	1	1	1
07/30/2020 20:00	0.4	12.1	2,046.5	0.3	1.2	1	1	1
07/30/2020 21:00	0.4	12.2	2,037.9	0.3	1.2	1	1	1
07/30/2020 22:00	0.4	12.1	2,077.1	0.3	1.2	1	1	1
07/30/2020 23:00	0.4	12.3	2,027.2	0.3	1.2	1	1	1
Average/Sum#:	0.4	12.3	2,032.2	0.3	32.9 #	24 #	24 #	24 #
Minimum:	0.3	11.7	1,935.5	0.2	0.9	1	1	1
Maximum:	0.6	12.9	2,106.1	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/31/2020 00:00	0.5	12.7	1,955.0	0.3	1.6	1	1	1
07/31/2020 01:00	0.6	12.8	1,931.2	0.4	1.9	1	1	1
07/31/2020 02:00	0.6	12.9	1,931.0	0.4	1.9	1	1	1
07/31/2020 03:00	0.6	12.9	1,929.8	0.4	1.9	1	1	1
07/31/2020 04:00	0.6	12.9	1,933.6	0.4	1.9	1	1	1
07/31/2020 05:00	0.6	12.5	2,031.2	0.4	1.9	1	1	1
07/31/2020 06:00	0.5	12.4	2,037.4	0.4	1.6	1	1	1
07/31/2020 07:00	0.5	12.7	1,955.1	0.4	1.6	1	1	1
07/31/2020 08:00	0.6	12.8	1,931.4	0.4	1.9	1	1	1
07/31/2020 09:00	0.5	12.5	1,988.5	0.4	1.6	1	1	1
07/31/2020 10:00	0.4	12.2	2,049.5	0.4	1.2	1	1	1
07/31/2020 11:00	0.4	12.1	2,062.5	0.3	1.2	1	1	1
07/31/2020 12:00	0.4	12.0	2,063.9	0.3	1.2	1	1	1
07/31/2020 13:00	0.4	12.0	2,071.5	0.3	1.2	1	1	1
07/31/2020 14:00	0.4	11.9	2,077.1	0.3	1.2	1	1	1
07/31/2020 15:00	0.4	11.9	2,086.0	0.3	1.2	1	1	1
07/31/2020 16:00	0.4	11.8	2,086.3	0.3	1.2	1	1	1
07/31/2020 17:00	0.4	11.9	2,075.8	0.3	1.2	1	1	1
07/31/2020 18:00	0.3	11.7	2,102.4	0.3	0.9	1	1	1
07/31/2020 19:00	0.4	12.0	2,068.0	0.3	1.2	1	1	1
07/31/2020 20:00	0.4	12.0	2,074.9	0.3	1.2	1	1	1
07/31/2020 21:00	0.4	12.1	2,058.3	0.3	1.2	1	1	1
07/31/2020 22:00	0.5	12.2	2,051.8	0.3	1.6	1	1	1
07/31/2020 23:00	0.5	12.3	2,043.5	0.3	1.6	1	1	1
Average/Sum#:	0.5	12.3	2,024.8	0.3	35.1 #	24 #	24 #	24 #
Minimum:	0.3	11.7	1,929.8	0.3	0.9	1	1	1
Maximum:	0.6	12.9	2,102.4	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2020 00:00	0.5	12.3	2,032.5	0.3	1.6	1	1	1
08/01/2020 01:00	0.5	12.8	1,938.5	0.3	1.6	1	1	1
08/01/2020 02:00	0.6	12.9	1,901.9	0.4	1.9	1	1	1
08/01/2020 03:00	0.2	13.9	1,431.2	0.3	0.5	1	1	0
08/01/2020 04:00	0.2	13.8	1,519.6	0.3	0.6	1	1	0
08/01/2020 05:00	0.2	13.8	1,535.3	0.2	0.6	1	1	0
08/01/2020 06:00	0.2	13.9	1,297.8	0.2	0.5	1	1	0
08/01/2020 07:00	0.2	13.9	1,286.6	0.2	0.5	1	1	0
08/01/2020 08:00	0.2	13.9	1,289.2	0.2	0.5	1	1	0
08/01/2020 09:00	0.2	13.9	1,295.2	0.2	0.5	1	1	0
08/01/2020 10:00	0.2	13.9	1,431.1	0.2	0.5	1	1	0
08/01/2020 11:00	0.3	13.8	1,505.5	0.2	0.8	1	1	1
08/01/2020 12:00	0.6	12.4	2,017.4	0.3	1.9	1	1	1
08/01/2020 13:00	0.5	12.1	2,063.3	0.3	1.5	1	1	1
08/01/2020 14:00	0.5	12.0	2,069.7	0.3	1.5	1	1	1
08/01/2020 15:00	0.4	12.0	2,078.0	0.3	1.2	1	1	1
08/01/2020 16:00	0.4	11.9	2,094.7	0.3	1.2	1	1	1
08/01/2020 17:00	0.4	11.9	2,102.2	0.3	1.2	1	1	1
08/01/2020 18:00	0.4	11.9	2,105.6	0.3	1.2	1	1	1
08/01/2020 19:00	0.4	11.9	2,108.5	0.3	1.2	1	1	1
08/01/2020 20:00	0.4	11.9	2,110.8	0.3	1.2	1	1	1
08/01/2020 21:00	0.5	12.1	2,068.9	0.3	1.6	1	1	1
08/01/2020 22:00	0.4	12.1	2,061.4	0.3	1.2	1	1	1
08/01/2020 23:00	0.6	12.7	1,921.6	0.3	1.9	1	1	1
Average/Sum#:	0.4	12.8	1,802.8	0.3	26.9 #	24 #	24 #	16 #
Minimum:	0.2	11.9	1,286.6	0.2	0.5	1	1	0
Maximum:	0.6	13.9	2,110.8	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/02/2020 00:00	0.3	13.8	1,423.9	0.3	0.8	1	1	0
08/02/2020 01:00	0.2	13.9	1,282.9	0.3	0.5	1	1	0
08/02/2020 02:00	0.2	13.9	1,285.9	0.2	0.5	1	1	0
08/02/2020 03:00	0.2	13.9	1,288.9	0.2	0.5	1	1	0
08/02/2020 04:00	0.3	13.9	1,492.7	0.2	0.8	1	1	0
08/02/2020 05:00	0.2	13.9	1,379.2	0.2	0.5	1	1	0
08/02/2020 06:00	0.2	13.9	1,293.1	0.2	0.5	1	1	0
08/02/2020 07:00	0.2	13.9	1,291.2	0.2	0.5	1	1	0
08/02/2020 08:00	0.2	13.9	1,292.8	0.2	0.5	1	1	0
08/02/2020 09:00	0.2	13.9	1,297.0	0.2	0.5	1	1	0
08/02/2020 10:00	0.2	13.9	1,301.8	0.2	0.5	1	1	0
08/02/2020 11:00	0.3	13.9	1,303.8	0.2	0.7	1	1	0
08/02/2020 12:00	0.3	13.9	1,300.9	0.3	0.7	1	1	0
08/02/2020 13:00	0.3	13.9	1,313.3	0.3	0.7	1	1	0
08/02/2020 14:00	0.3	13.9	1,364.7	0.3	0.8	1	1	0
08/02/2020 15:00	0.3	13.8	1,508.1	0.3	0.8	1	1	0
08/02/2020 16:00	0.5	12.5	1,927.7	0.3	1.5	1	1	1
08/02/2020 17:00	0.5	12.1	2,051.9	0.3	1.5	1	1	1
08/02/2020 18:00	0.5	12.1	2,052.8	0.3	1.5	1	1	1
08/02/2020 19:00	0.4	11.9	2,081.6	0.3	1.2	1	1	1
08/02/2020 20:00	0.4	12.0	2,058.6	0.3	1.2	1	1	1
08/02/2020 21:00	0.4	12.0	2,073.1	0.3	1.2	1	1	1
08/02/2020 22:00	0.5	12.1	2,056.7	0.3	1.5	1	1	1
08/02/2020 23:00	0.5	12.6	1,925.6	0.3	1.5	1	1	1
Average/Sum#:	0.3	13.3	1,568.7	0.3	20.9 #	24 #	24 #	8 #
Minimum:	0.2	11.9	1,282.9	0.2	0.5	1	1	0
Maximum:	0.5	13.9	2,081.6	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/03/2020 00:00	0.3	13.8	1,431.1	0.3	0.8	1	1	0
08/03/2020 01:00	0.3	13.9	1,318.3	0.3	0.7	1	1	0
08/03/2020 02:00	0.2	13.9	1,290.1	0.2	0.5	1	1	0
08/03/2020 03:00	0.2	13.9	1,290.4	0.2	0.5	1	1	0
08/03/2020 04:00	0.3	13.9	1,505.7	0.2	0.9	1	1	0
08/03/2020 05:00	0.3	13.9	1,484.8	0.3	0.8	1	1	0
08/03/2020 06:00	0.3	13.8	1,575.3	0.3	0.9	1	1	0
08/03/2020 07:00	0.3	13.9	1,535.1	0.3	0.9	1	1	0
08/03/2020 08:00	0.3	13.9	1,480.0	0.3	0.8	1	1	0
08/03/2020 09:00	0.2	13.9	1,373.1	0.3	0.5	1	1	0
08/03/2020 10:00	0.2	14.0	1,299.1	0.2	0.5	1	1	0
08/03/2020 11:00	0.2	14.0	1,361.6	0.2	0.5	1	1	0
08/03/2020 12:00	0.3	13.9	1,497.7	0.2	0.8	1	1	1
08/03/2020 13:00	0.6	12.3	2,021.3	0.3	1.9	1	1	1
08/03/2020 14:00	0.4	12.1	2,054.2	0.3	1.2	1	1	1
08/03/2020 15:00	0.4	12.1	2,052.0	0.3	1.2	1	1	1
08/03/2020 16:00	0.4	12.0	2,059.1	0.3	1.2	1	1	1
08/03/2020 17:00	0.3	12.0	2,062.2	0.3	0.9	1	1	1
08/03/2020 18:00	0.4	12.0	2,057.4	0.3	1.2	1	1	1
08/03/2020 19:00	0.4	12.0	2,076.1	0.3	1.2	1	1	1
08/03/2020 20:00	0.4	12.0	2,062.8	0.3	1.2	1	1	1
08/03/2020 21:00	0.4	12.0	2,066.2	0.3	1.2	1	1	1
08/03/2020 22:00	0.4	12.1	2,059.1	0.3	1.2	1	1	1
08/03/2020 23:00	0.5	12.9	1,782.2	0.3	1.5	1	1	1
Average/Sum#:	0.3	13.1	1,699.8	0.3	23.0 #	24 #	24 #	12 #
Minimum:	0.2	12.0	1,290.1	0.2	0.5	1	1	0
Maximum:	0.6	14.0	2,076.1	0.3	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/04/2020 00:00	0.2	13.9	1,285.7	0.3	0.5	1	1	0
08/04/2020 01:00	0.2	13.9	1,282.8	0.3	0.5	1	1	0
08/04/2020 02:00	0.2	13.9	1,291.9	0.2	0.5	1	1	0
08/04/2020 03:00	0.2	13.9	1,285.9	0.2	0.5	1	1	0
08/04/2020 04:00	0.2	13.9	1,288.3	0.2	0.5	1	1	0
08/04/2020 05:00	0.3	13.9	1,402.3	0.2	0.8	1	1	0
08/04/2020 06:00	0.2	13.9	1,299.5	0.2	0.5	1	1	0
08/04/2020 07:00	0.2	13.9	1,287.3	0.2	0.5	1	1	0
08/04/2020 08:00	0.2	13.9	1,288.7	0.2	0.5	1	1	0
08/04/2020 09:00	0.2	13.9	1,291.8	0.2	0.5	1	1	0
08/04/2020 10:00	0.2	13.9	1,298.3	0.2	0.5	1	1	0
08/04/2020 11:00	0.2	13.9	1,299.6	0.2	0.5	1	1	0
08/04/2020 12:00	0.3	13.9	1,435.8	0.2	0.8	1	1	0
08/04/2020 13:00	0.3	13.8	1,472.1	0.2	0.8	1	1	0
08/04/2020 14:00	0.2	13.9	1,319.7	0.2	0.5	1	1	0
08/04/2020 15:00	0.3	13.8	1,528.4	0.2	0.9	1	1	0
08/04/2020 16:00	0.3	13.8	1,503.4	0.2	0.8	1	1	1
08/04/2020 17:00	0.6	12.1	2,025.5	0.3	1.8	1	1	1
08/04/2020 18:00	0.4	11.9	2,070.5	0.3	1.2	1	1	1
08/04/2020 19:00	0.4	11.9	2,075.1	0.3	1.2	1	1	1
08/04/2020 20:00	0.4	12.0	2,062.1	0.3	1.2	1	1	1
08/04/2020 21:00	0.4	12.1	2,055.7	0.3	1.2	1	1	1
08/04/2020 22:00	0.5	12.6	1,952.7	0.3	1.6	1	1	1
08/04/2020 23:00	0.4	13.1	1,773.9	0.3	1.2	1	1	1
Average/Sum#:	0.3	13.4	1,536.5	0.2	19.5 #	24 #	24 #	8 #
Minimum:	0.2	11.9	1,282.8	0.2	0.5	1	1	0
Maximum:	0.6	13.9	2,075.1	0.3	1.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/05/2020 00:00	0.2	13.9	1,284.6	0.3	0.5	1	1	0
08/05/2020 01:00	0.2	13.9	1,283.4	0.2	0.5	1	1	0
08/05/2020 02:00	0.2	13.9	1,277.6	0.2	0.5	1	1	0
08/05/2020 03:00	0.2	13.9	1,277.3	0.2	0.5	1	1	0
08/05/2020 04:00	0.2	13.9	1,280.0	0.2	0.5	1	1	0
08/05/2020 05:00	0.2	13.9	1,313.3	0.2	0.5	1	1	0
08/05/2020 06:00	0.2	13.9	1,277.2	0.2	0.5	1	1	0
08/05/2020 07:00	0.2	13.9	1,277.6	0.2	0.5	1	1	0
08/05/2020 08:00	0.2	13.9	1,281.6	0.2	0.5	1	1	0
08/05/2020 09:00	0.2	13.9	1,285.0	0.2	0.5	1	1	0
08/05/2020 10:00	0.2	13.9	1,288.8	0.2	0.5	1	1	0
08/05/2020 11:00	0.2	13.9	1,291.1	0.2	0.5	1	1	0
08/05/2020 12:00	0.2	13.9	1,292.1	0.2	0.5	1	1	0
08/05/2020 13:00	0.2	13.9	1,292.8	0.2	0.5	1	1	0
08/05/2020 14:00	0.2	13.9	1,291.1	0.2	0.5	1	1	0
08/05/2020 15:00	0.2	13.9	1,290.2	0.2	0.5	1	1	0
08/05/2020 16:00	0.2	13.9	1,299.2	0.2	0.5	1	1	0
08/05/2020 17:00	0.5	13.2	1,748.8	0.3	1.5	1	1	1
08/05/2020 18:00	0.5	12.0	2,059.3	0.3	1.5	1	1	1
08/05/2020 19:00	0.4	12.3	1,993.6	0.3	1.2	1	1	1
08/05/2020 20:00	0.2	13.8	1,573.0	0.3	0.6	1	1	0
08/05/2020 21:00	0.2	13.9	1,399.3	0.2	0.5	1	1	0
08/05/2020 22:00	0.2	13.9	1,378.3	0.2	0.5	1	1	0
08/05/2020 23:00	0.2	13.9	1,278.4	0.2	0.5	1	1	0
Average/Sum#:	0.2	13.7	1,388.1	0.2	14.8 #	24 #	24 #	3 #
Minimum:	0.2	12.0	1,277.2	0.2	0.5	1	1	0
Maximum:	0.5	13.9	2,059.3	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/06/2020 00:00	0.2	13.9	1,277.6	0.2	0.5	1	1	0
08/06/2020 01:00	0.2	13.9	1,276.8	0.2	0.5	1	1	0
08/06/2020 02:00	0.2	13.9	1,277.4	0.2	0.5	1	1	0
08/06/2020 03:00	0.2	13.9	1,281.5	0.2	0.5	1	1	0
08/06/2020 04:00	0.2	13.9	1,298.5	0.2	0.5	1	1	0
08/06/2020 05:00	0.2	13.9	1,322.0	0.2	0.5	1	1	0
08/06/2020 06:00	0.2	13.9	1,286.7	0.2	0.5	1	1	0
08/06/2020 07:00	0.2	13.9	1,292.2	0.2	0.5	1	1	0
08/06/2020 08:00	0.2	13.9	1,293.7	0.2	0.5	1	1	0
08/06/2020 09:00	0.2	13.9	1,294.5	0.2	0.5	1	1	0
08/06/2020 10:00	0.2	13.9	1,294.2	0.2	0.5	1	1	0
08/06/2020 11:00	0.2	13.9	1,294.3	0.2	0.5	1	1	0
08/06/2020 12:00	0.2	13.9	1,294.7	0.2	0.5	1	1	0
08/06/2020 13:00	0.2	13.9	1,290.4	0.2	0.5	1	1	0
08/06/2020 14:00	0.2	13.9	1,290.4	0.2	0.5	1	1	0
08/06/2020 15:00	0.2	13.9	1,292.0	0.2	0.5	1	1	0
08/06/2020 16:00	0.2	13.9	1,289.2	0.2	0.5	1	1	0
08/06/2020 17:00	0.3	13.9	1,398.1	0.2	0.8	1	1	0
08/06/2020 18:00	0.3	13.9	1,398.6	0.3	0.8	1	1	0
08/06/2020 19:00	0.2	13.9	1,306.9	0.3	0.5	1	1	0
08/06/2020 20:00	0.2	13.9	1,282.9	0.2	0.5	1	1	0
08/06/2020 21:00	0.2	13.9	1,279.2	0.2	0.5	1	1	0
08/06/2020 22:00	0.2	13.9	1,278.1	0.2	0.5	1	1	0
08/06/2020 23:00	0.2	13.9	1,280.0	0.2	0.5	1	1	0
Average/Sum#:	0.2	13.9	1,298.7	0.2	12.6 #	24 #	24 #	0 #
Minimum:	0.2	13.9	1,276.8	0.2	0.5	1	1	0
Maximum:	0.3	13.9	1,398.6	0.3	0.8	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/07/2020 00:00	0.2	13.9	1,279.9	0.2	0.5	1	1	0
08/07/2020 01:00	0.2	13.9	1,278.6	0.2	0.5	1	1	0
08/07/2020 02:00	0.2	13.9	1,278.9	0.2	0.5	1	1	0
08/07/2020 03:00	0.2	13.9	1,279.4	0.2	0.5	1	1	0
08/07/2020 04:00	0.2	13.9	1,324.1	0.2	0.5	1	1	0
08/07/2020 05:00	0.2	13.9	1,314.5	0.2	0.5	1	1	0
08/07/2020 06:00	0.2	13.9	1,280.2	0.2	0.5	1	1	0
08/07/2020 07:00	0.2	13.9	1,284.8	0.2	0.5	1	1	0
08/07/2020 08:00	0.2	13.9	1,291.6	0.2	0.5	1	1	0
08/07/2020 09:00	0.2	13.9	1,294.4	0.2	0.5	1	1	0
08/07/2020 10:00	0.2	13.9	1,293.3	0.2	0.5	1	1	0
08/07/2020 11:00	0.2	14.0	1,293.3	0.2	0.5	1	1	0
08/07/2020 12:00	0.2	14.0	1,289.1	0.2	0.5	1	1	0
08/07/2020 13:00	0.2	13.9	1,344.8	0.2	0.5	1	1	0
08/07/2020 14:00	0.2	14.0	1,355.9	0.2	0.5	1	1	0
08/07/2020 15:00	0.2	14.0	1,294.0	0.2	0.5	1	1	0
08/07/2020 16:00	0.2	13.9	1,399.7	0.2	0.5	1	1	0
08/07/2020 17:00	0.2	13.9	1,462.5	0.2	0.6	1	1	0
08/07/2020 18:00	0.3	13.8	1,667.4	0.2	0.9	1	1	0
08/07/2020 19:00	0.3	13.8	1,637.6	0.2	0.9	1	1	0
08/07/2020 20:00	0.3	13.8	1,479.5	0.2	0.8	1	1	0
08/07/2020 21:00	0.2	13.9	1,334.9	0.2	0.5	1	1	0
08/07/2020 22:00	0.3	13.9	1,387.2	0.2	0.8	1	1	0
08/07/2020 23:00	0.3	13.9	1,441.3	0.3	0.8	1	1	0
Average/Sum#:	0.2	13.9	1,357.8	0.2	13.8 #	24 #	24 #	0 #
Minimum:	0.2	13.8	1,278.6	0.2	0.5	1	1	0
Maximum:	0.3	14.0	1,667.4	0.3	0.9	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/08/2020 00:00	0.2	13.9	1,346.0	0.3	0.5	1	1	0
08/08/2020 01:00	0.2	13.9	1,280.5	0.2	0.5	1	1	0
08/08/2020 02:00	0.2	13.9	1,278.5	0.2	0.5	1	1	0
08/08/2020 03:00	0.3	13.9	1,281.5	0.2	0.7	1	1	0
08/08/2020 04:00	0.3	13.9	1,284.5	0.3	0.7	1	1	0
08/08/2020 05:00	0.3	13.9	1,280.0	0.3	0.7	1	1	0
08/08/2020 06:00	0.3	13.9	1,281.0	0.3	0.7	1	1	0
08/08/2020 07:00	0.3	13.9	1,289.1	0.3	0.7	1	1	0
08/08/2020 08:00	0.2	13.9	1,288.1	0.3	0.5	1	1	0
08/08/2020 09:00	0.3	13.9	1,290.9	0.3	0.7	1	1	0
08/08/2020 10:00	0.3	13.9	1,293.6	0.3	0.7	1	1	0
08/08/2020 11:00	0.2	13.9	1,291.2	0.3	0.5	1	1	0
08/08/2020 12:00	0.2	13.9	1,290.6	0.2	0.5	1	1	0
08/08/2020 13:00	0.3	13.9	1,411.6	0.2	0.8	1	1	0
08/08/2020 14:00	0.3	13.9	1,324.5	0.3	0.7	1	1	0
08/08/2020 15:00	0.3	13.9	1,370.4	0.3	0.8	1	1	0
08/08/2020 16:00	0.3	13.9	1,443.7	0.3	0.8	1	1	1
08/08/2020 17:00	0.6	12.2	2,027.0	0.3	1.8	1	1	1
08/08/2020 18:00	0.4	11.8	2,092.8	0.3	1.2	1	1	1
08/08/2020 19:00	0.4	11.8	2,097.0	0.3	1.2	1	1	1
08/08/2020 20:00	0.4	12.0	2,066.4	0.3	1.2	1	1	1
08/08/2020 21:00	0.5	12.1	2,055.3	0.3	1.5	1	1	1
08/08/2020 22:00	0.5	12.5	1,975.4	0.3	1.6	1	1	1
08/08/2020 23:00	0.6	12.7	1,914.0	0.4	1.8	1	1	1
Average/Sum#:	0.3	13.4	1,523.1	0.3	21.3 #	24 #	24 #	8 #
Minimum:	0.2	11.8	1,278.5	0.2	0.5	1	1	0
Maximum:	0.6	13.9	2,097.0	0.4	1.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/09/2020 00:00	0.4	13.8	1,538.1	0.4	1.1	1	1	0
08/09/2020 01:00	0.2	13.9	1,304.6	0.3	0.5	1	1	0
08/09/2020 02:00	0.2	13.9	1,284.8	0.2	0.5	1	1	0
08/09/2020 03:00	0.2	13.9	1,285.5	0.2	0.5	1	1	0
08/09/2020 04:00	0.2	13.9	1,283.7	0.2	0.5	1	1	0
08/09/2020 05:00	0.2	13.9	1,284.9	0.2	0.5	1	1	0
08/09/2020 06:00	0.2	13.9	1,289.2	0.2	0.5	1	1	0
08/09/2020 07:00	0.2	13.9	1,291.7	0.2	0.5	1	1	0
08/09/2020 08:00	0.2	13.9	1,292.5	0.2	0.5	1	1	0
08/09/2020 09:00	0.2	13.9	1,287.1	0.2	0.5	1	1	0
08/09/2020 10:00	0.3	13.9	1,292.4	0.2	0.7	1	1	0
08/09/2020 11:00	0.2	13.9	1,294.1	0.2	0.5	1	1	0
08/09/2020 12:00	0.3	13.9	1,436.4	0.3	0.8	1	1	0
08/09/2020 13:00	0.3	13.8	1,507.2	0.2	0.8	1	1	0
08/09/2020 14:00	0.3	13.9	1,381.6	0.3	0.8	1	1	0
08/09/2020 15:00	0.4	13.7	1,596.0	0.3	1.2	1	1	1
08/09/2020 16:00	0.5	12.0	2,037.9	0.3	1.5	1	1	1
08/09/2020 17:00	0.4	11.8	2,079.1	0.3	1.2	1	1	1
08/09/2020 18:00	0.3	11.8	2,089.2	0.3	0.9	1	1	1
08/09/2020 19:00	0.4	11.9	2,058.6	0.3	1.2	1	1	1
08/09/2020 20:00	0.4	12.0	2,041.8	0.3	1.2	1	1	1
08/09/2020 21:00	0.4	11.9	2,062.3	0.3	1.2	1	1	1
08/09/2020 22:00	0.4	12.3	1,981.5	0.3	1.2	1	1	1
08/09/2020 23:00	0.5	12.6	1,911.2	0.3	1.5	1	1	1
Average/Sum#:	0.3	13.3	1,579.6	0.3	20.3 #	24 #	24 #	9 #
Minimum:	0.2	11.8	1,283.7	0.2	0.5	1	1	0
Maximum:	0.5	13.9	2,089.2	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/10/2020 00:00	0.3	13.8	1,413.6	0.3	0.8	1	1	0
08/10/2020 01:00	0.2	13.9	1,284.4	0.3	0.5	1	1	0
08/10/2020 02:00	0.2	13.9	1,291.1	0.2	0.5	1	1	0
08/10/2020 03:00	0.3	13.9	1,492.6	0.2	0.8	1	1	0
08/10/2020 04:00	0.3	13.9	1,521.0	0.3	0.9	1	1	0
08/10/2020 05:00	0.3	13.9	1,512.5	0.3	0.9	1	1	0
08/10/2020 06:00	0.3	13.9	1,608.3	0.3	0.9	1	1	0
08/10/2020 07:00	0.2	13.9	1,365.3	0.3	0.5	1	1	0
08/10/2020 08:00	0.2	13.9	1,492.7	0.2	0.6	1	1	0
08/10/2020 09:00	0.2	13.9	1,309.3	0.2	0.5	1	1	0
08/10/2020 10:00	0.3	13.9	1,523.3	0.2	0.9	1	1	0
08/10/2020 11:00	0.3	13.9	1,518.2	0.3	0.9	1	1	0
08/10/2020 12:00	0.2	13.9	1,305.8	0.3	0.5	1	1	0
08/10/2020 13:00	0.2	13.9	1,325.6	0.2	0.5	1	1	0
08/10/2020 14:00	0.2	13.9	1,332.3	0.2	0.5	1	1	0
08/10/2020 15:00	0.3	13.7	1,638.9	0.2	0.9	1	1	1
08/10/2020 16:00	0.5	12.0	2,038.2	0.2	1.5	1	1	1
08/10/2020 17:00	0.4	11.7	2,089.9	0.3	1.2	1	1	1
08/10/2020 18:00	0.4	11.9	2,046.6	0.3	1.2	1	1	1
08/10/2020 19:00	0.4	12.2	2,016.9	0.3	1.2	1	1	1
08/10/2020 20:00	0.4	12.2	2,002.9	0.3	1.2	1	1	1
08/10/2020 21:00	0.5	12.3	1,995.2	0.3	1.5	1	1	1
08/10/2020 22:00	0.5	12.6	1,950.2	0.3	1.6	1	1	1
08/10/2020 23:00	0.5	13.0	1,763.2	0.4	1.5	1	1	1
Average/Sum#:	0.3	13.3	1,618.3	0.3	22.0 #	24 #	24 #	9 #
Minimum:	0.2	11.7	1,284.4	0.2	0.5	1	1	0
Maximum:	0.5	13.9	2,089.9	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/11/2020 00:00	0.2	13.9	1,282.3	0.3	0.5	1	1	0
08/11/2020 01:00	0.2	13.9	1,281.7	0.3	0.5	1	1	0
08/11/2020 02:00	0.2	13.9	1,282.8	0.2	0.5	1	1	0
08/11/2020 03:00	0.2	13.9	1,281.9	0.2	0.5	1	1	0
08/11/2020 04:00	0.2	13.9	1,289.8	0.2	0.5	1	1	0
08/11/2020 05:00	0.2	13.9	1,299.2	0.2	0.5	1	1	0
08/11/2020 06:00	0.2	13.9	1,333.4	0.2	0.5	1	1	0
08/11/2020 07:00	0.2	13.9	1,283.8	0.2	0.5	1	1	0
08/11/2020 08:00	0.2	13.9	1,289.0	0.2	0.5	1	1	0
08/11/2020 09:00	0.2	13.9	1,291.7	0.2	0.5	1	1	0
08/11/2020 10:00	0.2	13.9	1,295.2	0.2	0.5	1	1	0
08/11/2020 11:00	0.2	13.9	1,298.4	0.2	0.5	1	1	0
08/11/2020 12:00	0.2	13.9	1,296.0	0.2	0.5	1	1	0
08/11/2020 13:00	0.2	13.9	1,296.8	0.2	0.5	1	1	0
08/11/2020 14:00	0.2	13.9	1,315.4	0.2	0.5	1	1	0
08/11/2020 15:00	0.3	13.9	1,331.2	0.2	0.8	1	1	0
08/11/2020 16:00	0.3	13.9	1,425.6	0.3	0.8	1	1	0
08/11/2020 17:00	0.3	13.9	1,567.4	0.3	0.9	1	1	0
08/11/2020 18:00	0.3	13.9	1,519.2	0.3	0.9	1	1	0
08/11/2020 19:00	0.3	13.9	1,374.5	0.3	0.8	1	1	0
08/11/2020 20:00	0.2	13.9	1,356.4	0.3	0.5	1	1	0
08/11/2020 21:00	0.2	13.9	1,306.4	0.2	0.5	1	1	0
08/11/2020 22:00	0.2	13.9	1,390.3	0.2	0.5	1	1	0
08/11/2020 23:00	0.2	13.9	1,297.8	0.2	0.5	1	1	0
Average/Sum#:	0.2	13.9	1,332.8	0.2	13.7 #	24 #	24 #	0 #
Minimum:	0.2	13.9	1,281.7	0.2	0.5	1	1	0
Maximum:	0.3	13.9	1,567.4	0.3	0.9	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/12/2020 00:00	0.2	13.9	1,284.9	0.2	0.5	1	1	0
08/12/2020 01:00	0.3	13.9	1,307.3	0.2	0.7	1	1	0
08/12/2020 02:00	0.2	13.9	1,282.6	0.2	0.5	1	1	0
08/12/2020 03:00	0.3	13.9	1,286.3	0.3	0.7	1	1	0
08/12/2020 04:00	0.3	13.9	1,307.4	0.3	0.7	1	1	0
08/12/2020 05:00	0.3	13.9	1,298.2	0.3	0.7	1	1	0
08/12/2020 06:00	0.3	13.9	1,292.9	0.3	0.7	1	1	0
08/12/2020 07:00	0.3	13.9	1,308.0	0.3	0.7	1	1	0
08/12/2020 08:00	0.2	13.9	1,379.6	0.3	0.5	1	1	0
08/12/2020 09:00	0.2	13.9	1,332.9	0.2	0.5	1	1	0
08/12/2020 10:00	0.2	13.9	1,339.6	0.2	0.5	1	1	0
08/12/2020 11:00	0.2	13.9	1,382.5	0.2	0.5	1	1	0
08/12/2020 12:00	0.3	13.8	1,636.7	0.2	0.9	1	1	1
08/12/2020 13:00	0.6	12.3	2,004.7	0.3	1.8	1	1	1
08/12/2020 14:00	0.5	12.0	2,053.5	0.3	1.5	1	1	1
08/12/2020 15:00	0.4	11.8	2,078.9	0.3	1.2	1	1	1
08/12/2020 16:00	0.4	11.8	2,078.6	0.3	1.2	1	1	1
08/12/2020 17:00	0.4	11.9	2,073.2	0.3	1.2	1	1	1
08/12/2020 18:00	0.4	12.0	2,059.2	0.3	1.2	1	1	1
08/12/2020 19:00	0.5	12.0	2,054.2	0.3	1.5	1	1	1
08/12/2020 20:00	0.5	12.2	2,025.0	0.3	1.5	1	1	1
08/12/2020 21:00	0.5	12.3	2,017.2	0.3	1.5	1	1	1
08/12/2020 22:00	0.5	12.3	2,032.1	0.3	1.6	1	1	1
08/12/2020 23:00	0.6	12.7	1,920.1	0.3	1.9	1	1	1
Average/Sum#:	0.4	13.1	1,659.8	0.3	24.2 #	24 #	24 #	12 #
Minimum:	0.2	11.8	1,282.6	0.2	0.5	1	1	0
Maximum:	0.6	13.9	2,078.9	0.3	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/13/2020 00:00	0.3	13.8	1,672.4	0.3	0.9	1	1	0
08/13/2020 01:00	0.3	13.8	1,611.4	0.3	0.9	1	1	0
08/13/2020 02:00	0.3	13.9	1,543.7	0.2	0.9	1	1	0
08/13/2020 03:00	0.3	13.9	1,577.0	0.3	0.9	1	1	0
08/13/2020 04:00	0.3	13.9	1,586.3	0.3	0.9	1	1	0
08/13/2020 05:00	0.3	13.9	1,608.0	0.3	0.9	1	1	0
08/13/2020 06:00	0.2	13.9	1,696.0	0.3	0.6	1	1	0
08/13/2020 07:00	0.2	13.9	1,598.1	0.2	0.6	1	1	0
08/13/2020 08:00	0.2	13.8	1,672.6	0.2	0.6	1	1	0
08/13/2020 09:00	0.2	13.8	1,595.3	0.2	0.6	1	1	1
08/13/2020 10:00	0.6	12.6	1,972.3	0.3	1.9	1	1	1
08/13/2020 11:00	0.5	12.1	2,072.7	0.3	1.6	1	1	1
08/13/2020 12:00	0.5	12.1	2,065.6	0.3	1.6	1	1	1
08/13/2020 13:00	0.4	12.1	2,052.3	0.3	1.2	1	1	1
08/13/2020 14:00	0.5	12.1	2,039.5	0.3	1.5	1	1	1
08/13/2020 15:00	0.4	11.9	2,071.2	0.3	1.2	1	1	1
08/13/2020 16:00	0.4	12.0	2,062.8	0.3	1.2	1	1	1
08/13/2020 17:00	0.4	11.9	2,064.0	0.3	1.2	1	1	1
08/13/2020 18:00	0.4	12.0	2,062.5	0.3	1.2	1	1	1
08/13/2020 19:00	0.4	12.0	2,069.0	0.3	1.2	1	1	1
08/13/2020 20:00	0.4	12.1	2,044.2	0.3	1.2	1	1	1
08/13/2020 21:00	0.4	12.3	2,030.4	0.3	1.2	1	1	1
08/13/2020 22:00	0.4	12.1	2,071.5	0.3	1.2	1	1	1
08/13/2020 23:00	0.4	11.9	2,118.2	0.3	1.2	1	1	1
Average/Sum#:	0.4	12.8	1,873.2	0.3	26.4 #	24 #	24 #	15 #
Minimum:	0.2	11.9	1,543.7	0.2	0.6	1	1	0
Maximum:	0.6	13.9	2,118.2	0.3	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/14/2020 00:00	0.4	11.9	2,127.6	0.3	1.2	1	1	1
08/14/2020 01:00	0.4	11.9	2,114.6	0.3	1.2	1	1	1
08/14/2020 02:00	0.4	12.1	2,094.7	0.3	1.3	1	1	1
08/14/2020 03:00	0.4	12.2	2,084.2	0.3	1.3	1	1	1
08/14/2020 04:00	0.4	12.0	2,126.6	0.3	1.3	1	1	1
08/14/2020 05:00	0.4	12.2	2,079.0	0.3	1.3	1	1	1
08/14/2020 06:00	0.5	12.3	2,052.6	0.3	1.6	1	1	1
08/14/2020 07:00	0.5	12.3	2,046.2	0.3	1.6	1	1	1
08/14/2020 08:00	0.4	12.2	2,069.2	0.3	1.3	1	1	1
08/14/2020 09:00	0.4	12.0	2,080.2	0.3	1.2	1	1	1
08/14/2020 10:00	0.3	11.8	2,106.6	0.3	0.9	1	1	1
08/14/2020 11:00	0.3	11.9	2,085.6	0.2	0.9	1	1	1
08/14/2020 12:00	0.4	11.9	2,097.4	0.2	1.2	1	1	1
08/14/2020 13:00	0.4	11.9	2,082.2	0.3	1.2	1	1	1
08/14/2020 14:00	0.4	11.9	2,065.2	0.3	1.2	1	1	1
08/14/2020 15:00	0.4	12.0	2,058.3	0.3	1.2	1	1	1
08/14/2020 16:00	0.4	12.0	2,041.3	0.3	1.2	1	1	1
08/14/2020 17:00	0.4	12.0	2,057.0	0.3	1.2	1	1	1
08/14/2020 18:00	0.4	12.0	2,059.1	0.3	1.2	1	1	1
08/14/2020 19:00	0.4	11.9	2,077.9	0.3	1.2	1	1	1
08/14/2020 20:00	0.4	11.8	2,092.5	0.3	1.2	1	1	1
08/14/2020 21:00	0.4	11.9	2,091.0	0.3	1.2	1	1	1
08/14/2020 22:00	0.3	11.8	2,109.5	0.3	0.9	1	1	1
08/14/2020 23:00	0.3	11.8	2,115.7	0.2	0.9	1	1	1
Average/Sum#:	0.4	12.0	2,083.9	0.3	28.9 #	24 #	24 #	24 #
Minimum:	0.3	11.8	2,041.3	0.2	0.9	1	1	1
Maximum:	0.5	12.3	2,127.6	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/15/2020 00:00	0.4	11.8	2,118.3	0.2	1.2	1	1	1
08/15/2020 01:00	0.4	11.8	2,121.3	0.3	1.2	1	1	1
08/15/2020 02:00	0.4	11.9	2,096.5	0.3	1.2	1	1	1
08/15/2020 03:00	0.4	12.0	2,086.7	0.3	1.2	1	1	1
08/15/2020 04:00	0.4	12.1	2,072.4	0.3	1.2	1	1	1
08/15/2020 05:00	0.4	12.2	2,063.2	0.3	1.3	1	1	1
08/15/2020 06:00	0.4	12.2	2,065.6	0.3	1.3	1	1	1
08/15/2020 07:00	0.5	12.1	2,062.5	0.3	1.5	1	1	1
08/15/2020 08:00	0.5	12.5	1,983.4	0.3	1.6	1	1	1
08/15/2020 09:00	0.4	12.1	2,053.2	0.3	1.2	1	1	1
08/15/2020 10:00	0.4	12.0	2,057.7	0.3	1.2	1	1	1
08/15/2020 11:00	0.4	11.9	2,084.9	0.3	1.2	1	1	1
08/15/2020 12:00	0.4	11.8	2,094.6	0.3	1.2	1	1	1
08/15/2020 13:00	0.4	11.7	2,089.3	0.3	1.2	1	1	1
08/15/2020 14:00	0.4	11.8	2,085.4	0.3	1.2	1	1	1
08/15/2020 15:00	0.4	11.7	2,080.6	0.3	1.2	1	1	1
08/15/2020 16:00	0.4	11.7	2,079.9	0.3	1.2	1	1	1
08/15/2020 17:00	0.4	11.7	2,077.3	0.3	1.2	1	1	1
08/15/2020 18:00	0.4	11.8	2,074.5	0.3	1.2	1	1	1
08/15/2020 19:00	0.4	11.8	2,077.1	0.3	1.2	1	1	1
08/15/2020 20:00	0.3	11.8	2,094.6	0.3	0.9	1	1	1
08/15/2020 21:00	0.3	11.9	2,079.5	0.2	0.9	1	1	1
08/15/2020 22:00	0.3	12.0	2,063.2	0.2	0.9	1	1	1
08/15/2020 23:00	0.3	11.8	2,111.4	0.2	0.9	1	1	1
Average/Sum#:	0.4	11.9	2,078.0	0.3	28.5 #	24 #	24 #	24 #
Minimum:	0.3	11.7	1,983.4	0.2	0.9	1	1	1
Maximum:	0.5	12.5	2,121.3	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/16/2020 00:00	0.3	11.8	2,118.1	0.2	0.9	1	1	1
08/16/2020 01:00	0.3	11.8	2,116.0	0.2	0.9	1	1	1
08/16/2020 02:00	0.3	11.8	2,116.5	0.2	0.9	1	1	1
08/16/2020 03:00	0.3	12.0	2,097.9	0.2	0.9	1	1	1
08/16/2020 04:00	0.3	11.9	2,116.9	0.2	0.9	1	1	1
08/16/2020 05:00	0.3	11.9	2,106.8	0.2	0.9	1	1	1
08/16/2020 06:00	0.3	11.9	2,094.0	0.2	0.9	1	1	1
08/16/2020 07:00	0.4	12.3	2,003.3	0.2	1.2	1	1	1
08/16/2020 08:00	0.5	12.6	1,954.7	0.3	1.6	1	1	1
08/16/2020 09:00	0.4	12.3	2,011.5	0.3	1.2	1	1	1
08/16/2020 10:00	0.4	12.2	2,018.7	0.3	1.2	1	1	1
08/16/2020 11:00	0.4	12.2	2,013.9	0.3	1.2	1	1	1
08/16/2020 12:00	0.3	12.1	2,038.7	0.3	0.9	1	1	1
08/16/2020 13:00	0.3	12.0	2,054.5	0.2	0.9	1	1	1
08/16/2020 14:00	0.3	11.9	2,092.5	0.2	0.9	1	1	1
08/16/2020 15:00	0.3	11.8	2,095.2	0.2	0.9	1	1	1
08/16/2020 16:00	0.3	11.8	2,101.8	0.2	0.9	1	1	1
08/16/2020 17:00	0.3	11.7	2,096.0	0.2	0.9	1	1	1
08/16/2020 18:00	0.3	11.7	2,089.5	0.2	0.9	1	1	1
08/16/2020 19:00	0.3	11.8	2,082.7	0.2	0.9	1	1	1
08/16/2020 20:00	0.3	11.8	2,087.1	0.2	0.9	1	1	1
08/16/2020 21:00	0.4	11.9	2,076.1	0.2	1.2	1	1	1
08/16/2020 22:00	0.3	11.9	2,073.7	0.2	0.9	1	1	1
08/16/2020 23:00	0.3	11.9	2,081.0	0.2	0.9	1	1	1
Average/Sum#:	0.3	12.0	2,072.4	0.2	23.8 #	24 #	24 #	24 #
Minimum:	0.3	11.7	1,954.7	0.2	0.9	1	1	1
Maximum:	0.5	12.6	2,118.1	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/17/2020 00:00	0.3	11.9	2,087.8	0.2	0.9	1	1	1
08/17/2020 01:00	0.3	12.0	2,079.6	0.2	0.9	1	1	1
08/17/2020 02:00	0.3	12.0	2,074.8	0.2	0.9	1	1	1
08/17/2020 03:00	0.3	12.0	2,085.7	0.2	0.9	1	1	1
08/17/2020 04:00	0.3	12.0	2,087.5	0.2	0.9	1	1	1
08/17/2020 05:00	0.3	12.0	2,080.3	0.2	0.9	1	1	1
08/17/2020 06:00	0.3	11.9	2,100.5	0.2	0.9	1	1	1
08/17/2020 07:00	0.3	11.9	2,106.7	0.2	0.9	1	1	1
08/17/2020 08:00	0.3	11.9	2,092.4	0.2	0.9	1	1	1
08/17/2020 09:00	0.3	11.8	2,108.6	0.2	0.9	1	1	1
08/17/2020 10:00	0.3	11.8	2,110.2	0.2	0.9	1	1	1
08/17/2020 11:00	0.3	11.9	2,082.2	0.2	0.9	1	1	1
08/17/2020 12:00	0.3	11.9	2,087.8	0.2	0.9	1	1	1
08/17/2020 13:00	0.3	12.0	2,058.6	0.2	0.9	1	1	1
08/17/2020 14:00	0.3	12.0	2,063.5	0.2	0.9	1	1	1
08/17/2020 15:00	0.3	11.8	2,092.7	0.2	0.9	1	1	1
08/17/2020 16:00	0.2	11.8	2,093.7	0.2	0.6	1	1	1
08/17/2020 17:00	0.3	11.9	2,065.1	0.2	0.9	1	1	1
08/17/2020 18:00	0.3	12.1	2,045.7	0.2	0.9	1	1	1
08/17/2020 19:00	0.3	12.1	2,047.1	0.2	0.9	1	1	1
08/17/2020 20:00	0.3	12.1	2,067.5	0.2	0.9	1	1	1
08/17/2020 21:00	0.3	11.9	2,097.8	0.2	0.9	1	1	1
08/17/2020 22:00	0.3	11.9	2,088.7	0.2	0.9	1	1	1
08/17/2020 23:00	0.3	12.0	2,089.0	0.2	0.9	1	1	1
Average/Sum#:	0.3	11.9	2,083.1	0.2	21.3 #	24 #	24 #	24 #
Minimum:	0.2	11.8	2,045.7	0.2	0.6	1	1	1
Maximum:	0.3	12.1	2,110.2	0.2	0.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/18/2020 00:00	0.3	12.1	2,055.8	0.2	0.9	1	1	1
08/18/2020 01:00	0.3	12.0	2,079.6	0.2	0.9	1	1	1
08/18/2020 02:00	0.3	11.9	2,093.1	0.2	0.9	1	1	1
08/18/2020 03:00	0.3	12.1	2,069.7	0.2	0.9	1	1	1
08/18/2020 04:00	0.3	12.0	2,085.1	0.2	0.9	1	1	1
08/18/2020 05:00	0.3	12.0	2,077.7	0.2	0.9	1	1	1
08/18/2020 06:00	0.3	11.9	2,099.8	0.2	0.9	1	1	1
08/18/2020 07:00	0.3	12.0	2,079.2	0.2	0.9	1	1	1
08/18/2020 08:00	0.4	12.1	2,056.0	0.2	1.2	1	1	1
08/18/2020 09:00	0.4	12.1	2,049.8	0.3	1.2	1	1	1
08/18/2020 10:00	0.3	12.0	2,063.2	0.3	0.9	1	1	1
08/18/2020 11:00	0.3	12.0	2,028.5	0.2	0.9	1	1	1
08/18/2020 12:00	0.3	11.8	2,071.7	0.2	0.9	1	1	1
08/18/2020 13:00	0.3	11.7	2,078.3	0.2	0.9	1	1	1
08/18/2020 14:00	0.3	11.7	2,083.1	0.2	0.9	1	1	1
08/18/2020 15:00	0.3	11.7	2,077.1	0.2	0.9	1	1	1
08/18/2020 16:00	0.3	11.7	2,077.9	0.2	0.9	1	1	1
08/18/2020 17:00	0.3	11.7	2,080.9	0.2	0.9	1	1	1
08/18/2020 18:00	0.3	11.7	2,080.6	0.2	0.9	1	1	1
08/18/2020 19:00	0.3	11.7	2,084.6	0.2	0.9	1	1	1
08/18/2020 20:00	0.2	11.8	2,098.2	0.2	0.6	1	1	1
08/18/2020 21:00	0.3	12.0	2,098.2	0.2	0.9	1	1	1
08/18/2020 22:00	0.3	11.9	2,109.5	0.2	0.9	1	1	1
08/18/2020 23:00	0.3	11.9	2,116.9	0.2	0.9	1	1	1
Average/Sum#:	0.3	11.9	2,078.9	0.2	21.9 #	24 #	24 #	24 #
Minimum:	0.2	11.7	2,028.5	0.2	0.6	1	1	1
Maximum:	0.4	12.1	2,116.9	0.3	1.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/19/2020 00:00	0.3	12.0	2,086.1	0.2	0.9	1	1	1
08/19/2020 01:00	0.3	12.0	2,080.9	0.2	0.9	1	1	1
08/19/2020 02:00	0.3	12.0	2,091.8	0.2	0.9	1	1	1
08/19/2020 03:00	0.3	12.1	2,069.2	0.2	0.9	1	1	1
08/19/2020 04:00	0.4	12.1	2,076.8	0.2	1.2	1	1	1
08/19/2020 05:00	0.4	12.2	2,069.1	0.3	1.3	1	1	1
08/19/2020 06:00	0.4	12.2	2,066.5	0.3	1.3	1	1	1
08/19/2020 07:00	0.3	12.0	2,106.3	0.3	0.9	1	1	1
08/19/2020 08:00	0.4	12.2	2,056.1	0.3	1.2	1	1	1
08/19/2020 09:00	0.3	12.0	2,098.4	0.2	0.9	1	1	1
08/19/2020 10:00	0.3	11.8	2,115.1	0.2	0.9	1	1	1
08/19/2020 11:00	0.3	11.8	2,102.4	0.2	0.9	1	1	1
08/19/2020 12:00	0.3	11.9	2,076.7	0.2	0.9	1	1	1
08/19/2020 13:00	0.3	11.8	2,099.7	0.2	0.9	1	1	1
08/19/2020 14:00	0.3	11.8	2,092.0	0.2	0.9	1	1	1
08/19/2020 15:00	0.3	11.7	2,082.8	0.2	0.9	1	1	1
08/19/2020 16:00	0.3	11.8	2,085.0	0.2	0.9	1	1	1
08/19/2020 17:00	0.3	11.9	2,089.1	0.2	0.9	1	1	1
08/19/2020 18:00	0.3	11.9	2,110.1	0.2	0.9	1	1	1
08/19/2020 19:00	0.3	12.0	2,101.6	0.2	0.9	1	1	1
08/19/2020 20:00	0.3	12.0	2,098.1	0.2	0.9	1	1	1
08/19/2020 21:00	0.4	12.2	2,073.9	0.2	1.3	1	1	1
08/19/2020 22:00	0.4	12.3	2,062.5	0.3	1.3	1	1	1
08/19/2020 23:00	0.4	12.4	2,048.7	0.3	1.3	1	1	1
Average/Sum#:	0.3	12.0	2,085.0	0.2	24.2 #	24 #	24 #	24 #
Minimum:	0.3	11.7	2,048.7	0.2	0.9	1	1	1
Maximum:	0.4	12.4	2,115.1	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/20/2020 00:00	0.4	12.4	2,052.7	0.3	1.3	1	1	1
08/20/2020 01:00	0.4	12.4	2,042.7	0.3	1.3	1	1	1
08/20/2020 02:00	0.4	12.5	2,032.3	0.3	1.3	1	1	1
08/20/2020 03:00	0.5	12.5	2,033.4	0.3	1.6	1	1	1
08/20/2020 04:00	0.4	12.4	2,041.0	0.3	1.3	1	1	1
08/20/2020 05:00	0.4	12.4	2,043.8	0.3	1.3	1	1	1
08/20/2020 06:00	0.4	12.5	2,031.9	0.3	1.3	1	1	1
08/20/2020 07:00	0.4	12.5	2,028.1	0.3	1.3	1	1	1
08/20/2020 08:00	0.4	12.4	2,034.2	0.3	1.3	1	1	1
08/20/2020 09:00	0.4	12.3	2,049.0	0.3	1.3	1	1	1
08/20/2020 10:00	0.4	12.3	2,053.1	0.3	1.3	1	1	1
08/20/2020 11:00	0.4	12.3	2,049.9	0.3	1.3	1	1	1
08/20/2020 12:00	0.4	12.3	2,054.9	0.3	1.3	1	1	1
08/20/2020 13:00	0.4	12.3	2,056.9	0.3	1.3	1	1	1
08/20/2020 14:00	0.4	12.3	2,054.5	0.3	1.3	1	1	1
08/20/2020 15:00	0.5	12.3	2,042.9	0.3	1.6	1	1	1
08/20/2020 16:00	0.5	12.3	2,039.1	0.3	1.6	1	1	1
08/20/2020 17:00	0.5	12.1	2,051.5	0.3	1.5	1	1	1
08/20/2020 18:00	0.4	12.2	2,048.2	0.3	1.2	1	1	1
08/20/2020 19:00	0.5	12.2	2,052.3	0.3	1.6	1	1	1
08/20/2020 20:00	0.5	12.2	2,055.6	0.3	1.6	1	1	1
08/20/2020 21:00	0.5	12.3	2,050.7	0.3	1.6	1	1	1
08/20/2020 22:00	0.5	12.3	2,039.5	0.3	1.6	1	1	1
08/20/2020 23:00	0.3	12.2	2,037.1	0.3	0.9	1	1	1
Average/Sum#:	0.4	12.3	2,044.8	0.3	33.0 #	24 #	24 #	24 #
Minimum:	0.3	12.1	2,028.1	0.3	0.9	1	1	1
Maximum:	0.5	12.5	2,056.9	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/21/2020 00:00	0.2	12.2	2,053.6	0.2	0.6	1	1	1
08/21/2020 01:00	0.3	12.3	2,026.0	0.2	0.9	1	1	1
08/21/2020 02:00	0.3	12.7	1,948.9	0.2	0.9	1	1	1
08/21/2020 03:00	0.3	12.3	2,030.5	0.2	0.9	1	1	1
08/21/2020 04:00	0.3	12.3	2,039.2	0.2	0.9	1	1	1
08/21/2020 05:00	0.3	12.3	2,033.1	0.2	0.9	1	1	1
08/21/2020 06:00	0.2	12.1	2,065.3	0.2	0.6	1	1	1
08/21/2020 07:00	0.2	12.2	2,062.1	0.1	0.6	1	1	1
08/21/2020 08:00	0.2	12.2	2,044.3	0.1	0.6	1	1	1
08/21/2020 09:00	0.2	12.1	2,068.7	0.1	0.6	1	1	1
08/21/2020 10:00	0.2	12.0	2,069.0	0.1	0.6	1	1	1
08/21/2020 11:00	0.2	12.0	2,062.8	0.1	0.6	1	1	1
08/21/2020 12:00	0.4	12.1	2,073.1	0.2	1.2	1	1	1
08/21/2020 13:00	0.3	11.9	2,092.9	0.2	0.9	1	1	1
08/21/2020 14:00	0.4	12.0	2,061.2	0.3	1.2	1	1	1
08/21/2020 15:00	0.4	12.0	2,058.9	0.3	1.2	1	1	1
08/21/2020 16:00	0.4	11.9	2,076.2	0.3	1.2	1	1	1
08/21/2020 17:00	0.3	11.9	2,080.0	0.3	0.9	1	1	1
08/21/2020 18:00	0.4	12.0	2,063.1	0.3	1.2	1	1	1
08/21/2020 19:00	0.4	12.1	2,047.4	0.3	1.2	1	1	1
08/21/2020 20:00	0.4	12.1	2,059.0	0.3	1.2	1	1	1
08/21/2020 21:00	0.4	12.2	2,042.1	0.3	1.2	1	1	1
08/21/2020 22:00	0.4	12.1	2,053.2	0.3	1.2	1	1	1
08/21/2020 23:00	0.4	12.1	2,058.8	0.3	1.2	1	1	1
Average/Sum#:	0.3	12.1	2,052.9	0.2	22.5 #	24 #	24 #	24 #
Minimum:	0.2	11.9	1,948.9	0.1	0.6	1	1	1
Maximum:	0.4	12.7	2,092.9	0.3	1.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/22/2020 00:00	0.4	12.1	2,061.8	0.3	1.2	1	1	1
08/22/2020 01:00	0.4	12.6	1,918.4	0.3	1.2	1	1	1
08/22/2020 02:00	0.2	13.8	1,666.9	0.3	0.6	1	1	0
08/22/2020 03:00	0.2	13.9	1,534.7	0.2	0.6	1	1	0
08/22/2020 04:00	0.3	13.9	1,660.7	0.2	0.9	1	1	0
08/22/2020 05:00	0.3	13.8	1,682.1	0.2	0.9	1	1	0
08/22/2020 06:00	0.3	13.9	1,681.6	0.3	1.0	1	1	0
08/22/2020 07:00	0.3	13.9	1,673.1	0.3	0.9	1	1	0
08/22/2020 08:00	0.3	13.8	1,666.4	0.3	0.9	1	1	0
08/22/2020 09:00	0.3	13.8	1,645.9	0.2	0.9	1	1	0
08/22/2020 10:00	0.3	13.9	1,562.6	0.2	0.9	1	1	1
08/22/2020 11:00	0.6	12.4	2,009.3	0.3	1.9	1	1	1
08/22/2020 12:00	0.5	11.9	2,074.7	0.3	1.5	1	1	1
08/22/2020 13:00	0.4	11.9	2,082.5	0.3	1.2	1	1	1
08/22/2020 14:00	0.5	12.0	2,050.3	0.3	1.5	1	1	1
08/22/2020 15:00	0.4	11.8	2,086.1	0.3	1.2	1	1	1
08/22/2020 16:00	0.4	11.7	2,095.1	0.3	1.2	1	1	1
08/22/2020 17:00	0.4	11.9	2,073.7	0.3	1.2	1	1	1
08/22/2020 18:00	0.4	12.0	2,058.8	0.3	1.2	1	1	1
08/22/2020 19:00	0.4	12.0	2,058.1	0.3	1.2	1	1	1
08/22/2020 20:00	0.4	12.0	2,049.9	0.3	1.2	1	1	1
08/22/2020 21:00	0.4	11.9	2,083.8	0.3	1.2	1	1	1
08/22/2020 22:00	0.4	12.0	2,069.1	0.3	1.2	1	1	1
08/22/2020 23:00	0.4	11.9	2,090.1	0.3	1.2	1	1	1
Average/Sum#:	0.4	12.7	1,901.5	0.3	26.9 #	24 #	24 #	16 #
Minimum:	0.2	11.7	1,534.7	0.2	0.6	1	1	0
Maximum:	0.6	13.9	2,095.1	0.3	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/23/2020 00:00	0.4	12.1	2,060.0	0.3	1.2	1	1	1
08/23/2020 01:00	0.4	12.2	2,031.2	0.3	1.2	1	1	1
08/23/2020 02:00	0.4	12.2	2,048.3	0.3	1.2	1	1	1
08/23/2020 03:00	0.4	12.3	2,034.9	0.3	1.2	1	1	1
08/23/2020 04:00	0.5	12.7	1,936.3	0.3	1.6	1	1	1
08/23/2020 05:00	0.3	13.8	1,683.3	0.3	0.9	1	1	0
08/23/2020 06:00	0.2	13.9	1,636.0	0.3	0.6	1	1	0
08/23/2020 07:00	0.2	13.9	1,581.3	0.2	0.6	1	1	0
08/23/2020 08:00	0.2	13.8	1,641.8	0.2	0.6	1	1	0
08/23/2020 09:00	0.2	13.8	1,608.6	0.2	0.6	1	1	0
08/23/2020 10:00	0.3	13.9	1,529.4	0.2	0.9	1	1	1
08/23/2020 11:00	0.5	12.4	2,010.5	0.3	1.6	1	1	1
08/23/2020 12:00	0.4	12.0	2,081.1	0.3	1.2	1	1	1
08/23/2020 13:00	0.4	11.9	2,077.2	0.3	1.2	1	1	1
08/23/2020 14:00	0.4	12.0	2,072.5	0.3	1.2	1	1	1
08/23/2020 15:00	0.3	11.8	2,092.8	0.3	0.9	1	1	1
08/23/2020 16:00	0.3	11.7	2,092.5	0.2	0.9	1	1	1
08/23/2020 17:00	0.3	11.7	2,097.6	0.2	0.9	1	1	1
08/23/2020 18:00	0.3	11.7	2,099.7	0.2	0.9	1	1	1
08/23/2020 19:00	0.3	11.7	2,101.8	0.2	0.9	1	1	1
08/23/2020 20:00	0.3	11.8	2,111.9	0.2	0.9	1	1	1
08/23/2020 21:00	0.4	12.0	2,086.7	0.2	1.2	1	1	1
08/23/2020 22:00	0.4	12.0	2,075.3	0.3	1.2	1	1	1
08/23/2020 23:00	0.4	12.0	2,072.4	0.3	1.2	1	1	1
Average/Sum#:	0.3	12.5	1,952.6	0.3	24.8 #	24 #	24 #	19 #
Minimum:	0.2	11.7	1,529.4	0.2	0.6	1	1	0
Maximum:	0.5	13.9	2,111.9	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/24/2020 00:00	0.4	12.0	2,077.3	0.3	1.2	1	1	1
08/24/2020 01:00	0.4	12.1	2,072.8	0.3	1.2	1	1	1
08/24/2020 02:00	0.4	12.0	2,086.4	0.3	1.2	1	1	1
08/24/2020 03:00	0.4	11.9	2,106.5	0.3	1.2	1	1	1
08/24/2020 04:00	0.4	12.0	2,098.2	0.3	1.2	1	1	1
08/24/2020 05:00	0.4	12.0	2,092.4	0.3	1.2	1	1	1
08/24/2020 06:00	0.4	12.0	2,083.2	0.3	1.2	1	1	1
08/24/2020 07:00	0.4	12.2	2,057.4	0.3	1.2	1	1	1
08/24/2020 08:00	0.4	12.2	2,046.8	0.3	1.2	1	1	1
08/24/2020 09:00	0.4	12.1	2,062.3	0.3	1.2	1	1	1
08/24/2020 10:00	0.3	11.9	2,096.5	0.3	0.9	1	1	1
08/24/2020 11:00	0.3	11.8	2,106.9	0.2	0.9	1	1	1
08/24/2020 12:00	0.3	12.0	2,088.4	0.2	0.9	1	1	1
08/24/2020 13:00	0.3	11.9	2,086.5	0.2	0.9	1	1	1
08/24/2020 14:00	0.3	11.9	2,067.3	0.2	0.9	1	1	1
08/24/2020 15:00	0.3	11.8	2,072.7	0.2	0.9	1	1	1
08/24/2020 16:00	0.4	11.8	2,084.1	0.2	1.2	1	1	1
08/24/2020 17:00	0.3	11.8	2,078.3	0.2	0.9	1	1	1
08/24/2020 18:00	0.3	11.8	2,081.4	0.2	0.9	1	1	1
08/24/2020 19:00	0.4	12.0	2,053.6	0.2	1.2	1	1	1
08/24/2020 20:00	0.4	12.0	2,070.3	0.3	1.2	1	1	1
08/24/2020 21:00	0.4	12.0	2,071.0	0.3	1.2	1	1	1
08/24/2020 22:00	0.4	12.0	2,078.3	0.3	1.2	1	1	1
08/24/2020 23:00	0.4	12.0	2,076.6	0.3	1.2	1	1	1
Average/Sum#:	0.4	12.0	2,079.0	0.3	26.4 #	24 #	24 #	24 #
Minimum:	0.3	11.8	2,046.8	0.2	0.9	1	1	1
Maximum:	0.4	12.2	2,106.9	0.3	1.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/25/2020 00:00	0.4	12.1	2,054.6	0.3	1.2	1	1	1
08/25/2020 01:00	0.4	12.1	2,047.5	0.3	1.2	1	1	1
08/25/2020 02:00	0.4	12.2	2,037.7	0.3	1.2	1	1	1
08/25/2020 03:00	0.5	12.5	1,990.2	0.3	1.6	1	1	1
08/25/2020 04:00	0.5	12.3	2,035.3	0.3	1.6	1	1	1
08/25/2020 05:00	0.4	12.2	2,044.2	0.3	1.2	1	1	1
08/25/2020 06:00	0.5	12.3	2,043.5	0.3	1.6	1	1	1
08/25/2020 07:00	0.4	12.4	2,029.6	0.3	1.3	1	1	1
08/25/2020 08:00	0.5	12.3	2,027.0	0.3	1.6	1	1	1
08/25/2020 09:00	0.4	12.2	2,047.7	0.3	1.2	1	1	1
08/25/2020 10:00	0.4	12.1	2,049.2	0.3	1.2	1	1	1
08/25/2020 11:00	0.4	12.1	2,043.7	0.3	1.2	1	1	1
08/25/2020 12:00	0.4	12.1	2,039.4	0.3	1.2	1	1	1
08/25/2020 13:00	0.4	12.1	2,037.6	0.3	1.2	1	1	1
08/25/2020 14:00	0.4	12.0	2,040.4	0.3	1.2	1	1	1
08/25/2020 15:00	0.3	12.0	2,047.2	0.3	0.9	1	1	1
08/25/2020 16:00	0.3	11.9	2,062.0	0.2	0.9	1	1	1
08/25/2020 17:00	0.3	11.8	2,079.2	0.2	0.9	1	1	1
08/25/2020 18:00	0.3	11.8	2,087.2	0.2	0.9	1	1	1
08/25/2020 19:00	0.3	11.8	2,090.0	0.2	0.9	1	1	1
08/25/2020 20:00	0.3	11.9	2,069.9	0.2	0.9	1	1	1
08/25/2020 21:00	0.4	12.0	2,055.4	0.2	1.2	1	1	1
08/25/2020 22:00	0.4	12.1	2,050.1	0.3	1.2	1	1	1
08/25/2020 23:00	0.4	12.0	2,054.9	0.3	1.2	1	1	1
Average/Sum#:	0.4	12.1	2,048.5	0.3	28.7 #	24 #	24 #	24 #
Minimum:	0.3	11.8	1,990.2	0.2	0.9	1	1	1
Maximum:	0.5	12.5	2,090.0	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/26/2020 00:00	0.4	12.2	2,023.2	0.3	1.2	1	1	1
08/26/2020 01:00	0.5	12.7	1,929.4	0.3	1.6	1	1	1
08/26/2020 02:00	0.5	12.8	1,936.0	0.4	1.6	1	1	1
08/26/2020 03:00	0.5	12.4	2,022.2	0.4	1.6	1	1	1
08/26/2020 04:00	0.4	12.3	2,032.4	0.3	1.2	1	1	1
08/26/2020 05:00	0.4	12.3	2,033.1	0.3	1.2	1	1	1
08/26/2020 06:00	0.4	12.3	2,036.4	0.3	1.3	1	1	1
08/26/2020 07:00	0.5	12.7	1,940.8	0.3	1.6	1	1	1
08/26/2020 08:00	0.5	12.7	1,941.9	0.4	1.6	1	1	1
08/26/2020 09:00	0.4	12.2	2,037.0	0.4	1.2	1	1	1
08/26/2020 10:00	0.4	12.1	2,058.3	0.3	1.2	1	1	1
08/26/2020 11:00	0.4	12.1	2,047.6	0.3	1.2	1	1	1
08/26/2020 12:00	0.4	12.0	2,049.7	0.3	1.2	1	1	1
08/26/2020 13:00	0.4	12.0	2,048.1	0.3	1.2	1	1	1
08/26/2020 14:00	0.4	11.9	2,060.9	0.3	1.2	1	1	1
08/26/2020 15:00	0.3	11.8	2,081.2	0.3	0.9	1	1	1
08/26/2020 16:00	0.4	12.0	2,029.7	0.3	1.2	1	1	1
08/26/2020 17:00	0.4	12.1	2,009.6	0.3	1.2	1	1	1
08/26/2020 18:00	0.4	12.1	2,008.2	0.3	1.2	1	1	1
08/26/2020 19:00	0.4	12.2	1,999.6	0.3	1.2	1	1	1
08/26/2020 20:00	0.4	12.3	1,991.8	0.3	1.2	1	1	1
08/26/2020 21:00	0.4	12.4	1,989.2	0.3	1.2	1	1	1
08/26/2020 22:00	0.5	12.7	1,934.7	0.3	1.6	1	1	1
08/26/2020 23:00	0.5	12.8	1,926.6	0.4	1.6	1	1	1
Average/Sum#:	0.4	12.3	2,007.0	0.3	31.4 #	24 #	24 #	24 #
Minimum:	0.3	11.8	1,926.6	0.3	0.9	1	1	1
Maximum:	0.5	12.8	2,081.2	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/27/2020 00:00	0.5	12.8	1,929.7	0.4	1.6	1	1	1
08/27/2020 01:00	0.5	12.9	1,929.8	0.4	1.6	1	1	1
08/27/2020 02:00	0.6	12.9	1,924.3	0.4	1.9	1	1	1
08/27/2020 03:00	0.4	12.9	1,931.0	0.4	1.3	1	1	1
08/27/2020 04:00	0.4	12.4	2,032.6	0.3	1.3	1	1	1
08/27/2020 05:00	0.4	12.4	2,037.2	0.3	1.3	1	1	1
08/27/2020 06:00	0.4	12.4	2,054.3	0.3	1.3	1	1	1
08/27/2020 07:00	0.6	12.8	1,939.6	0.3	1.9	1	1	1
08/27/2020 08:00	0.5	12.5	1,996.3	0.4	1.6	1	1	1
08/27/2020 09:00	0.4	12.5	1,995.3	0.4	1.3	1	1	1
08/27/2020 10:00	0.4	12.5	1,990.3	0.3	1.3	1	1	1
08/27/2020 11:00	0.3	12.0	2,089.5	0.3	0.9	1	1	1
08/27/2020 12:00	0.3	11.9	2,101.6	0.2	0.9	1	1	1
08/27/2020 13:00	0.3	11.8	2,096.2	0.2	0.9	1	1	1
08/27/2020 14:00	0.3	11.8	2,097.0	0.2	0.9	1	1	1
08/27/2020 15:00	0.3	11.8	2,105.0	0.2	0.9	1	1	1
08/27/2020 16:00	0.4	12.1	2,042.6	0.2	1.2	1	1	1
08/27/2020 17:00	0.4	12.1	2,041.8	0.3	1.2	1	1	1
08/27/2020 18:00	0.3	12.1	2,048.4	0.3	0.9	1	1	1
08/27/2020 19:00	0.3	12.0	2,080.0	0.2	0.9	1	1	1
08/27/2020 20:00	0.4	12.0	2,094.5	0.2	1.2	1	1	1
08/27/2020 21:00	0.3	11.9	2,115.9	0.2	0.9	1	1	1
08/27/2020 22:00	0.3	11.9	2,115.0	0.2	0.9	1	1	1
08/27/2020 23:00	0.5	12.4	2,008.0	0.2	1.6	1	1	1
Average/Sum#:	0.4	12.3	2,033.2	0.3	29.7 #	24 #	24 #	24 #
Minimum:	0.3	11.8	1,924.3	0.2	0.9	1	1	1
Maximum:	0.6	12.9	2,115.9	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/28/2020 00:00	0.6	12.8	1,915.3	0.3	1.9	1	1	1
08/28/2020 01:00	0.2	13.8	1,514.1	0.3	0.6	1	1	0
08/28/2020 02:00	0.2	13.9	1,443.2	0.3	0.5	1	1	0
08/28/2020 03:00	0.2	13.9	1,285.5	0.2	0.5	1	1	0
08/28/2020 04:00	0.2	13.9	1,467.2	0.2	0.6	1	1	0
08/28/2020 05:00	0.2	13.9	1,589.7	0.2	0.6	1	1	0
08/28/2020 06:00	0.2	13.9	1,449.3	0.2	0.5	1	1	0
08/28/2020 07:00	0.3	13.9	1,371.8	0.2	0.8	1	1	0
08/28/2020 08:00	0.2	13.9	1,392.1	0.2	0.5	1	1	0
08/28/2020 09:00	0.2	13.9	1,422.3	0.2	0.5	1	1	0
08/28/2020 10:00	0.2	13.9	1,456.5	0.2	0.5	1	1	0
08/28/2020 11:00	0.2	13.9	1,505.7	0.2	0.6	1	1	1
08/28/2020 12:00	0.6	12.3	1,993.4	0.3	1.8	1	1	1
08/28/2020 13:00	0.4	11.9	2,066.0	0.3	1.2	1	1	1
08/28/2020 14:00	0.4	11.9	2,061.2	0.3	1.2	1	1	1
08/28/2020 15:00	0.4	11.9	2,060.2	0.3	1.2	1	1	1
08/28/2020 16:00	0.4	11.9	2,062.4	0.3	1.2	1	1	1
08/28/2020 17:00	0.4	11.9	2,051.9	0.3	1.2	1	1	1
08/28/2020 18:00	0.4	12.0	2,051.4	0.3	1.2	1	1	1
08/28/2020 19:00	0.4	12.3	2,002.0	0.3	1.2	1	1	1
08/28/2020 20:00	0.5	12.3	1,995.3	0.3	1.5	1	1	1
08/28/2020 21:00	0.5	12.4	1,993.7	0.3	1.5	1	1	1
08/28/2020 22:00	0.5	12.5	1,963.5	0.3	1.5	1	1	1
08/28/2020 23:00	0.4	12.2	2,034.4	0.3	1.2	1	1	1
Average/Sum#:	0.3	13.0	1,756.2	0.3	24.0 #	24 #	24 #	14 #
Minimum:	0.2	11.9	1,285.5	0.2	0.5	1	1	0
Maximum:	0.6	13.9	2,066.0	0.3	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/29/2020 00:00	0.4	12.2	2,040.2	0.3	1.2	1	1	1
08/29/2020 01:00	0.4	12.3	2,038.1	0.3	1.3	1	1	1
08/29/2020 02:00	0.4	12.4	2,019.7	0.3	1.3	1	1	1
08/29/2020 03:00	0.5	12.7	1,925.4	0.3	1.6	1	1	1
08/29/2020 04:00	0.3	13.8	1,598.5	0.3	0.9	1	1	0
08/29/2020 05:00	0.3	13.8	1,578.3	0.3	0.9	1	1	0
08/29/2020 06:00	0.3	13.8	1,551.9	0.2	0.9	1	1	0
08/29/2020 07:00	0.3	13.8	1,422.5	0.2	0.8	1	1	0
08/29/2020 08:00	0.2	13.9	1,376.4	0.2	0.5	1	1	0
08/29/2020 09:00	0.2	13.9	1,280.9	0.2	0.5	1	1	0
08/29/2020 10:00	0.2	13.9	1,293.5	0.2	0.5	1	1	0
08/29/2020 11:00	0.2	13.9	1,327.6	0.2	0.5	1	1	0
08/29/2020 12:00	0.2	13.9	1,286.3	0.2	0.5	1	1	0
08/29/2020 13:00	0.3	13.9	1,589.7	0.2	0.9	1	1	0
08/29/2020 14:00	0.4	13.8	1,596.4	0.3	1.2	1	1	0
08/29/2020 15:00	0.4	13.8	1,604.2	0.3	1.2	1	1	0
08/29/2020 16:00	0.4	13.8	1,652.1	0.3	1.2	1	1	1
08/29/2020 17:00	0.5	12.2	2,022.2	0.3	1.5	1	1	1
08/29/2020 18:00	0.4	11.9	2,060.2	0.3	1.2	1	1	1
08/29/2020 19:00	0.4	12.0	2,061.8	0.3	1.2	1	1	1
08/29/2020 20:00	0.4	11.8	2,106.0	0.3	1.2	1	1	1
08/29/2020 21:00	0.4	11.9	2,083.8	0.3	1.2	1	1	1
08/29/2020 22:00	0.5	12.4	1,992.5	0.3	1.5	1	1	1
08/29/2020 23:00	0.5	12.5	1,988.3	0.3	1.6	1	1	1
Average/Sum#:	0.4	13.1	1,729.0	0.3	25.3 #	24 #	24 #	12 #
Minimum:	0.2	11.8	1,280.9	0.2	0.5	1	1	0
Maximum:	0.5	13.9	2,106.0	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/30/2020 00:00	0.5	12.8	1,911.7	0.4	1.6	1	1	1
08/30/2020 01:00	0.3	13.7	1,739.2	0.3	1.0	1	1	0
08/30/2020 02:00	0.3	13.7	1,742.8	0.3	1.0	1	1	0
08/30/2020 03:00	0.3	13.7	1,744.6	0.2	1.0	1	1	0
08/30/2020 04:00	0.3	13.7	1,744.5	0.2	1.0	1	1	0
08/30/2020 05:00	0.3	13.7	1,749.0	0.2	1.0	1	1	0
08/30/2020 06:00	0.3	13.7	1,743.9	0.2	1.0	1	1	0
08/30/2020 07:00	0.2	13.7	1,738.2	0.2	0.6	1	1	0
08/30/2020 08:00	0.3	13.7	1,746.3	0.2	1.0	1	1	0
08/30/2020 09:00	0.3	13.6	1,745.0	0.2	0.9	1	1	0
08/30/2020 10:00	0.3	13.6	1,736.1	0.2	0.9	1	1	0
08/30/2020 11:00	0.3	13.6	1,726.9	0.2	0.9	1	1	0
08/30/2020 12:00	0.3	13.6	1,718.3	0.2	0.9	1	1	0
08/30/2020 13:00	0.3	13.7	1,621.7	0.2	0.9	1	1	0
08/30/2020 14:00	0.3	13.8	1,533.0	0.2	0.9	1	1	1
08/30/2020 15:00	0.5	12.1	2,037.2	0.2	1.5	1	1	1
08/30/2020 16:00	0.4	11.8	2,104.1	0.3	1.2	1	1	1
08/30/2020 17:00	0.4	12.0	2,065.7	0.3	1.2	1	1	1
08/30/2020 18:00	0.4	12.1	2,045.5	0.3	1.2	1	1	1
08/30/2020 19:00	0.5	12.3	2,013.0	0.3	1.5	1	1	1
08/30/2020 20:00	0.5	12.3	2,007.3	0.3	1.5	1	1	1
08/30/2020 21:00	0.5	12.4	2,003.0	0.3	1.6	1	1	1
08/30/2020 22:00	0.5	12.4	1,998.5	0.3	1.6	1	1	1
08/30/2020 23:00	0.6	12.7	1,919.1	0.3	1.9	1	1	1
Average/Sum#:	0.4	13.1	1,838.9	0.3	27.8 #	24 #	24 #	11 #
Minimum:	0.2	11.8	1,533.0	0.2	0.6	1	1	0
Maximum:	0.6	13.8	2,104.1	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/31/2020 00:00	0.3	13.8	1,609.2	0.3	0.9	1	1	0
08/31/2020 01:00	0.3	13.9	1,299.3	0.3	0.7	1	1	0
08/31/2020 02:00	0.2	13.9	1,285.5	0.2	0.5	1	1	0
08/31/2020 03:00	0.2	13.9	1,296.5	0.2	0.5	1	1	0
08/31/2020 04:00	0.3	13.8	1,632.0	0.2	0.9	1	1	0
08/31/2020 05:00	0.3	13.8	1,662.9	0.2	0.9	1	1	0
08/31/2020 06:00	0.3	13.8	1,685.2	0.2	0.9	1	1	0
08/31/2020 07:00	0.3	13.9	1,381.8	0.2	0.8	1	1	0
08/31/2020 08:00	0.3	13.9	1,404.7	0.3	0.8	1	1	0
08/31/2020 09:00	0.2	14.0	1,310.4	0.3	0.5	1	1	0
08/31/2020 10:00	0.1	14.0	1,299.2	0.2	0.2	1	1	0
08/31/2020 11:00	0.1	14.0	1,500.0	0.1	0.3	1	1	0
08/31/2020 12:00	0.1	13.9	1,474.2	0.1	0.3	1	1	0
08/31/2020 13:00	0.5	12.3	2,014.8	0.2	1.5	1	1	1
08/31/2020 14:00	0.4	11.9	2,114.8	0.2	1.2	1	1	1
08/31/2020 15:00	0.4	11.8	2,106.2	0.3	1.2	1	1	1
08/31/2020 16:00	0.4	12.2	2,028.6	0.3	1.2	1	1	1
08/31/2020 17:00	0.5	12.4	2,006.2	0.3	1.6	1	1	1
08/31/2020 18:00	0.5	12.4	2,003.4	0.3	1.6	1	1	1
08/31/2020 19:00	0.5	12.4	1,998.8	0.3	1.6	1	1	1
08/31/2020 20:00	0.5	12.4	1,995.8	0.3	1.6	1	1	1
08/31/2020 21:00	0.5	12.5	1,993.9	0.3	1.6	1	1	1
08/31/2020 22:00	0.5	12.5	1,991.8	0.4	1.6	1	1	1
08/31/2020 23:00	0.5	13.0	1,777.2	0.4	1.5	1	1	1
Average/Sum#:	0.3	13.2	1,703.0	0.3	24.4 #	24 #	24 #	11 #
Minimum:	0.1	11.8	1,285.5	0.1	0.2	1	1	0
Maximum:	0.5	14.0	2,114.8	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2020 00:00	0.2	13.9	1,295.3	0.3	0.5	1	1	0
09/01/2020 01:00	0.2	13.9	1,492.9	0.3	0.6	1	1	0
09/01/2020 02:00	0.2	14.0	1,388.5	0.2	0.5	1	1	0
09/01/2020 03:00	0.2	14.0	1,297.5	0.2	0.5	1	1	0
09/01/2020 04:00	0.2	14.0	1,345.1	0.2	0.5	1	1	0
09/01/2020 05:00	0.2	13.8	1,663.8	0.2	0.6	1	1	0
09/01/2020 06:00	0.3	13.8	1,650.7	0.2	0.9	1	1	0
09/01/2020 07:00	0.3	13.8	1,671.7	0.2	0.9	1	1	0
09/01/2020 08:00	0.3	13.8	1,592.9	0.2	0.9	1	1	0
09/01/2020 09:00	0.3	13.8	1,620.6	0.2	0.9	1	1	0
09/01/2020 10:00	0.3	13.8	1,479.3	0.2	0.8	1	1	0
09/01/2020 11:00	0.1	14.0	1,309.3	0.2	0.3	1	1	0
09/01/2020 12:00	0.1	14.0	1,338.3	0.1	0.3	1	1	0
09/01/2020 13:00	0.1	14.0	1,486.0	0.1	0.3	1	1	0
09/01/2020 14:00	0.3	13.8	1,645.6	0.1	0.9	1	1	0
09/01/2020 15:00	0.3	13.8	1,613.3	0.2	0.9	1	1	0
09/01/2020 16:00	0.3	13.8	1,535.0	0.2	0.9	1	1	1
09/01/2020 17:00	0.5	12.2	2,024.7	0.2	1.5	1	1	1
09/01/2020 18:00	0.4	11.8	2,100.8	0.3	1.2	1	1	1
09/01/2020 19:00	0.4	11.9	2,078.1	0.3	1.2	1	1	1
09/01/2020 20:00	0.5	12.4	1,995.8	0.3	1.6	1	1	1
09/01/2020 21:00	0.5	12.5	1,986.9	0.3	1.6	1	1	1
09/01/2020 22:00	0.6	12.8	1,931.4	0.4	1.9	1	1	1
09/01/2020 23:00	0.4	13.2	1,771.7	0.4	1.2	1	1	1
Average/Sum#:	0.3	13.5	1,638.1	0.2	21.4 #	24 #	24 #	8 #
Minimum:	0.1	11.8	1,295.3	0.1	0.3	1	1	0
Maximum:	0.6	14.0	2,100.8	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/02/2020 00:00	0.2	13.9	1,282.2	0.3	0.5	1	1	0
09/02/2020 01:00	0.2	13.9	1,277.4	0.2	0.5	1	1	0
09/02/2020 02:00	0.2	13.9	1,294.5	0.2	0.5	1	1	0
09/02/2020 03:00	0.2	13.9	1,288.3	0.2	0.5	1	1	0
09/02/2020 04:00	0.2	13.9	1,312.6	0.2	0.5	1	1	0
09/02/2020 05:00	0.2	13.9	1,279.0	0.2	0.5	1	1	0
09/02/2020 06:00	0.2	13.9	1,286.2	0.2	0.5	1	1	0
09/02/2020 07:00	6.9	14.8	943.4	0.0	6.1	1	0	0
09/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	1.0	14.0	1,245.5	0.2	9.6 #	8 #	7 #	0 #
Minimum:	0.2	13.9	943.4	0.2	0.5	0	0	0
Maximum:	6.9	14.8	1,312.6	0.3	6.1	1	1	0
%SI	66.67	66.67	66.67	70.83	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2020 03:00	40.9	17.8	416.5	0.0	32.7	1	0	0
09/03/2020 04:00	14.4	15.1	986.1	0.0	32.3	1	0	0
09/03/2020 05:00	0.2	13.8	1,569.2	0.0	0.6	1	1	0
09/03/2020 06:00	0.2	13.8	1,582.8	0.0	0.6	1	1	0
09/03/2020 07:00	0.2	13.8	1,640.8	0.2	0.6	1	1	0
09/03/2020 08:00	0.2	13.8	1,636.3	0.2	0.6	1	1	0
09/03/2020 09:00	0.2	13.9	1,532.0	0.2	0.6	1	1	0
09/03/2020 10:00	0.2	13.9	1,572.1	0.2	0.6	1	1	0
09/03/2020 11:00	0.2	13.8	1,522.4	0.2	0.6	1	1	1
09/03/2020 12:00	0.7	12.2	2,044.8	0.3	2.2	1	1	1
09/03/2020 13:00	0.3	11.9	2,092.8	0.3	0.9	1	1	1
09/03/2020 14:00	0.4	12.0	2,057.6	0.3	1.2	1	1	1
09/03/2020 15:00	0.3	11.8	2,089.3	0.2	0.9	1	1	1
09/03/2020 16:00	0.3	11.8	2,089.4	0.2	0.9	1	1	1
09/03/2020 17:00	0.3	11.8	2,093.2	0.2	0.9	1	1	1
09/03/2020 18:00	0.3	11.8	2,096.0	0.2	0.9	1	1	1
09/03/2020 19:00	0.3	12.0	2,054.4	0.2	0.9	1	1	1
09/03/2020 20:00	0.4	12.3	1,995.8	0.2	1.2	1	1	1
09/03/2020 21:00	0.3	12.3	1,997.3	0.2	0.9	1	1	1
09/03/2020 22:00	0.3	12.2	2,029.0	0.2	0.9	1	1	1
09/03/2020 23:00	0.3	11.9	2,096.6	0.2	0.9	1	1	1
Average/Sum#:	2.9	13.0	1,771.2	0.2	81.9 #	21 #	19 #	13 #
Minimum:	0.2	11.8	416.5	0.2	0.6	0	0	0
Maximum:	40.9	17.8	2,096.6	0.3	32.7	1	1	1
%SI	12.50	12.50	12.50	29.17	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/04/2020 00:00	0.4	12.4	2,011.2	0.2	1.2	1	1	1
09/04/2020 01:00	0.4	12.5	1,980.2	0.3	1.2	1	1	1
09/04/2020 02:00	0.4	12.5	1,981.1	0.3	1.2	1	1	1
09/04/2020 03:00	0.5	12.6	1,983.8	0.3	1.6	1	1	1
09/04/2020 04:00	0.3	12.0	2,104.0	0.3	0.9	1	1	1
09/04/2020 05:00	0.3	11.9	2,127.7	0.3	0.9	1	1	1
09/04/2020 06:00	0.3	12.0	2,107.3	0.2	0.9	1	1	1
09/04/2020 07:00	0.3	12.0	2,095.1	0.2	0.9	1	1	1
09/04/2020 08:00	0.3	12.4	2,016.9	0.2	0.9	1	1	1
09/04/2020 09:00	0.4	12.5	1,983.2	0.2	1.2	1	1	1
09/04/2020 10:00	0.3	12.1	2,041.7	0.2	0.9	1	1	1
09/04/2020 11:00	0.3	12.0	2,065.9	0.2	0.9	1	1	1
09/04/2020 12:00	0.3	11.9	2,071.3	0.2	0.9	1	1	1
09/04/2020 13:00	0.3	11.9	2,072.3	0.2	0.9	1	1	1
09/04/2020 14:00	0.3	11.9	2,077.4	0.2	0.9	1	1	1
09/04/2020 15:00	0.3	11.8	2,077.0	0.2	0.9	1	1	1
09/04/2020 16:00	0.3	11.8	2,076.8	0.2	0.9	1	1	1
09/04/2020 17:00	0.3	11.8	2,080.4	0.2	0.9	1	1	1
09/04/2020 18:00	0.3	11.8	2,088.3	0.2	0.9	1	1	1
09/04/2020 19:00	0.3	11.8	2,093.8	0.2	0.9	1	1	1
09/04/2020 20:00	0.3	11.8	2,097.4	0.2	0.9	1	1	1
09/04/2020 21:00	0.3	11.9	2,081.3	0.2	0.9	1	1	1
09/04/2020 22:00	0.3	12.0	2,082.2	0.2	0.9	1	1	1
09/04/2020 23:00	0.4	12.3	2,021.0	0.2	1.2	1	1	1
Average/Sum#:	0.3	12.1	2,059.1	0.2	23.8 #	24 #	24 #	24 #
Minimum:	0.3	11.8	1,980.2	0.2	0.9	1	1	1
Maximum:	0.5	12.6	2,127.7	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/05/2020 00:00	0.4	12.4	1,996.9	0.3	1.2	1	1	1
09/05/2020 01:00	0.4	12.4	1,996.3	0.3	1.2	1	1	1
09/05/2020 02:00	0.4	12.4	1,996.8	0.3	1.2	1	1	1
09/05/2020 03:00	0.4	12.4	1,997.8	0.3	1.2	1	1	1
09/05/2020 04:00	0.4	12.4	2,010.4	0.3	1.2	1	1	1
09/05/2020 05:00	0.4	12.4	1,978.8	0.3	1.2	1	1	1
09/05/2020 06:00	0.3	13.8	1,639.9	0.3	0.9	1	1	0
09/05/2020 07:00	0.3	13.8	1,568.3	0.2	0.9	1	1	0
09/05/2020 08:00	0.3	13.8	1,612.8	0.2	0.9	1	1	0
09/05/2020 09:00	0.4	13.8	1,592.3	0.2	1.2	1	1	0
09/05/2020 10:00	0.3	13.8	1,621.0	0.2	0.9	1	1	1
09/05/2020 11:00	0.5	12.2	2,025.4	0.3	1.5	1	1	1
09/05/2020 12:00	0.3	11.8	2,086.7	0.2	0.9	1	1	1
09/05/2020 13:00	0.3	11.8	2,091.8	0.2	0.9	1	1	1
09/05/2020 14:00	0.3	11.8	2,092.9	0.2	0.9	1	1	1
09/05/2020 15:00	0.3	11.7	2,084.3	0.2	0.9	1	1	1
09/05/2020 16:00	0.3	11.7	2,078.5	0.2	0.9	1	1	1
09/05/2020 17:00	0.3	11.7	2,087.3	0.2	0.9	1	1	1
09/05/2020 18:00	0.3	11.8	2,089.9	0.2	0.9	1	1	1
09/05/2020 19:00	0.3	11.8	2,095.1	0.2	0.9	1	1	1
09/05/2020 20:00	0.3	11.8	2,100.4	0.2	0.9	1	1	1
09/05/2020 21:00	0.3	11.8	2,109.4	0.2	0.9	1	1	1
09/05/2020 22:00	0.3	11.8	2,117.7	0.2	0.9	1	1	1
09/05/2020 23:00	0.4	12.0	2,071.7	0.2	1.2	1	1	1
Average/Sum#:	0.3	12.4	1,964.3	0.2	24.6 #	24 #	24 #	20 #
Minimum:	0.3	11.7	1,568.3	0.2	0.9	1	1	0
Maximum:	0.5	13.8	2,117.7	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/06/2020 00:00	0.3	12.0	2,093.1	0.2	0.9	1	1	1
09/06/2020 01:00	0.4	12.2	2,049.0	0.3	1.2	1	1	1
09/06/2020 02:00	0.4	12.0	2,098.3	0.3	1.2	1	1	1
09/06/2020 03:00	0.4	11.9	2,113.8	0.3	1.2	1	1	1
09/06/2020 04:00	0.5	12.3	2,035.4	0.3	1.6	1	1	1
09/06/2020 05:00	0.5	12.4	2,020.5	0.3	1.6	1	1	1
09/06/2020 06:00	0.6	12.8	1,965.9	0.3	1.9	1	1	1
09/06/2020 07:00	0.5	12.2	2,070.9	0.3	1.6	1	1	1
09/06/2020 08:00	0.4	12.0	2,086.9	0.3	1.2	1	1	1
09/06/2020 09:00	0.4	12.0	2,092.4	0.3	1.2	1	1	1
09/06/2020 10:00	0.3	11.9	2,081.9	0.3	0.9	1	1	1
09/06/2020 11:00	0.3	11.9	2,078.0	0.2	0.9	1	1	1
09/06/2020 12:00	0.3	11.8	2,078.3	0.2	0.9	1	1	1
09/06/2020 13:00	0.3	11.8	2,079.9	0.2	0.9	1	1	1
09/06/2020 14:00	0.3	11.8	2,082.4	0.2	0.9	1	1	1
09/06/2020 15:00	0.3	11.8	2,080.6	0.2	0.9	1	1	1
09/06/2020 16:00	0.3	12.0	2,028.6	0.2	0.9	1	1	1
09/06/2020 17:00	0.3	11.8	2,069.5	0.2	0.9	1	1	1
09/06/2020 18:00	0.3	11.9	2,062.2	0.2	0.9	1	1	1
09/06/2020 19:00	0.3	12.0	2,043.3	0.2	0.9	1	1	1
09/06/2020 20:00	0.3	12.1	2,044.6	0.2	0.9	1	1	1
09/06/2020 21:00	0.3	12.0	2,081.7	0.2	0.9	1	1	1
09/06/2020 22:00	0.3	11.9	2,104.0	0.2	0.9	1	1	1
09/06/2020 23:00	0.3	11.8	2,102.0	0.2	0.9	1	1	1
Average/Sum#:	0.4	12.0	2,068.5	0.2	26.2 #	24 #	24 #	24 #
Minimum:	0.3	11.8	1,965.9	0.2	0.9	1	1	1
Maximum:	0.6	12.8	2,113.8	0.3	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/07/2020 00:00	0.3	11.8	2,102.5	0.2	0.9	1	1	1
09/07/2020 01:00	0.3	11.9	2,111.4	0.2	0.9	1	1	1
09/07/2020 02:00	0.3	11.9	2,111.5	0.2	0.9	1	1	1
09/07/2020 03:00	0.4	12.1	2,059.3	0.2	1.2	1	1	1
09/07/2020 04:00	0.5	12.4	2,009.9	0.3	1.6	1	1	1
09/07/2020 05:00	0.4	12.3	2,008.6	0.3	1.2	1	1	1
09/07/2020 06:00	0.3	13.9	1,585.5	0.3	0.9	1	1	0
09/07/2020 07:00	0.2	14.0	1,586.7	0.3	0.6	1	1	0
09/07/2020 08:00	0.2	14.0	1,603.4	0.2	0.6	1	1	0
09/07/2020 09:00	0.2	14.0	1,564.5	0.2	0.6	1	1	0
09/07/2020 10:00	0.3	13.9	1,503.8	0.2	0.9	1	1	0
09/07/2020 11:00	0.2	13.9	1,500.8	0.2	0.6	1	1	1
09/07/2020 12:00	0.6	12.7	1,930.7	0.3	1.9	1	1	1
09/07/2020 13:00	0.5	13.3	1,727.3	0.3	1.5	1	1	1
09/07/2020 14:00	0.3	13.7	1,656.1	0.3	0.9	1	1	0
09/07/2020 15:00	0.3	13.6	1,695.7	0.3	0.9	1	1	0
09/07/2020 16:00	0.4	13.1	1,754.8	0.2	1.2	1	1	1
09/07/2020 17:00	0.5	12.3	1,991.8	0.3	1.5	1	1	1
09/07/2020 18:00	0.5	12.3	1,985.5	0.3	1.5	1	1	1
09/07/2020 19:00	0.4	12.0	2,066.3	0.3	1.2	1	1	1
09/07/2020 20:00	0.4	12.0	2,056.8	0.3	1.2	1	1	1
09/07/2020 21:00	0.4	12.2	2,005.7	0.3	1.2	1	1	1
09/07/2020 22:00	0.4	12.2	2,009.0	0.3	1.2	1	1	1
09/07/2020 23:00	0.4	12.3	2,009.5	0.3	1.2	1	1	1
Average/Sum#:	0.4	12.8	1,859.9	0.3	26.3 #	24 #	24 #	17 #
Minimum:	0.2	11.8	1,500.8	0.2	0.6	1	1	0
Maximum:	0.6	14.0	2,111.5	0.3	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/08/2020 00:00	0.5	12.3	2,013.9	0.3	1.5	1	1	1
09/08/2020 01:00	0.4	12.2	2,058.6	0.3	1.3	1	1	1
09/08/2020 02:00	0.4	12.2	2,046.0	0.3	1.2	1	1	1
09/08/2020 03:00	0.4	12.0	2,099.6	0.3	1.2	1	1	1
09/08/2020 04:00	0.4	12.3	2,054.2	0.3	1.3	1	1	1
09/08/2020 05:00	0.5	12.4	2,022.9	0.3	1.6	1	1	1
09/08/2020 06:00	0.2	13.9	1,627.5	0.3	0.6	1	1	0
09/08/2020 07:00	0.2	14.0	1,629.4	0.2	0.6	1	1	0
09/08/2020 08:00	0.1	14.0	1,506.0	0.2	0.3	1	1	0
09/08/2020 09:00	0.1	13.9	1,624.4	0.1	0.3	1	1	0
09/08/2020 10:00	0.1	14.0	1,567.9	0.1	0.3	1	1	0
09/08/2020 11:00	0.3	13.9	1,679.8	0.2	1.0	1	1	0
09/08/2020 12:00	0.3	13.9	1,531.8	0.2	0.9	1	1	1
09/08/2020 13:00	0.6	12.4	2,040.3	0.3	1.9	1	1	1
09/08/2020 14:00	0.4	12.0	2,116.2	0.3	1.3	1	1	1
09/08/2020 15:00	0.4	11.9	2,119.9	0.3	1.2	1	1	1
09/08/2020 16:00	0.4	11.9	2,121.3	0.3	1.2	1	1	1
09/08/2020 17:00	0.3	11.9	2,127.9	0.3	0.9	1	1	1
09/08/2020 18:00	0.3	11.9	2,133.9	0.2	0.9	1	1	1
09/08/2020 19:00	0.4	12.2	2,075.5	0.2	1.3	1	1	1
09/08/2020 20:00	0.4	12.3	2,061.0	0.3	1.3	1	1	1
09/08/2020 21:00	0.4	12.3	2,069.6	0.3	1.3	1	1	1
09/08/2020 22:00	0.5	12.6	2,016.3	0.3	1.6	1	1	1
09/08/2020 23:00	0.5	12.5	2,019.1	0.4	1.6	1	1	1
Average/Sum#:	0.4	12.7	1,931.8	0.3	26.6 #	24 #	24 #	18 #
Minimum:	0.1	11.9	1,506.0	0.1	0.3	1	1	0
Maximum:	0.6	14.0	2,133.9	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/09/2020 00:00	0.3	12.6	1,928.1	0.3	0.9	1	1	1
09/09/2020 01:00	0.1	13.9	1,662.9	0.2	0.3	1	1	0
09/09/2020 02:00	0.1	14.1	1,392.9	0.1	0.3	1	1	0
09/09/2020 03:00	0.1	14.0	1,656.6	0.1	0.3	1	1	0
09/09/2020 04:00	0.1	14.0	1,498.8	0.1	0.3	1	1	0
09/09/2020 05:00	0.1	14.0	1,572.3	0.1	0.3	1	1	0
09/09/2020 06:00	0.1	14.0	1,574.7	0.1	0.3	1	1	0
09/09/2020 07:00	0.1	14.0	1,551.0	0.1	0.3	1	1	0
09/09/2020 08:00	0.1	14.0	1,507.7	0.1	0.3	1	1	0
09/09/2020 09:00	0.1	14.1	1,430.9	0.1	0.3	1	1	0
09/09/2020 10:00	0.1	14.1	1,418.0	0.1	0.3	1	1	0
09/09/2020 11:00	0.1	14.0	1,490.1	0.1	0.3	1	1	0
09/09/2020 12:00	0.2	14.0	1,512.7	0.1	0.6	1	1	1
09/09/2020 13:00	0.6	12.5	2,054.2	0.2	1.9	1	1	1
09/09/2020 14:00	0.5	12.5	2,024.4	0.3	1.6	1	1	1
09/09/2020 15:00	0.5	12.6	1,999.6	0.4	1.6	1	1	1
09/09/2020 16:00	0.5	12.6	1,991.4	0.4	1.6	1	1	1
09/09/2020 17:00	0.5	12.6	1,989.7	0.4	1.6	1	1	1
09/09/2020 18:00	0.5	12.7	1,989.7	0.4	1.6	1	1	1
09/09/2020 19:00	0.5	12.7	1,992.4	0.4	1.6	1	1	1
09/09/2020 20:00	0.5	12.7	1,995.2	0.4	1.6	1	1	1
09/09/2020 21:00	0.5	12.8	1,990.1	0.4	1.6	1	1	1
09/09/2020 22:00	0.5	12.8	1,990.6	0.4	1.6	1	1	1
09/09/2020 23:00	0.5	13.0	1,919.1	0.4	1.6	1	1	1
Average/Sum#:	0.3	13.3	1,755.5	0.2	22.7 #	24 #	24 #	13 #
Minimum:	0.1	12.5	1,392.9	0.1	0.3	1	1	0
Maximum:	0.6	14.1	2,054.2	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/10/2020 00:00	0.2	13.9	1,511.8	0.3	0.6	1	1	0
09/10/2020 01:00	0.2	13.9	1,485.8	0.3	0.6	1	1	0
09/10/2020 02:00	0.1	14.0	1,308.9	0.2	0.3	1	1	0
09/10/2020 03:00	0.2	13.9	1,587.5	0.2	0.6	1	1	0
09/10/2020 04:00	0.2	13.9	1,557.7	0.2	0.6	1	1	0
09/10/2020 05:00	0.2	13.9	1,551.4	0.2	0.6	1	1	0
09/10/2020 06:00	0.2	13.9	1,600.0	0.2	0.6	1	1	0
09/10/2020 07:00	0.2	13.9	1,637.2	0.2	0.6	1	1	0
09/10/2020 08:00	0.2	13.9	1,672.9	0.2	0.6	1	1	0
09/10/2020 09:00	0.3	14.0	1,617.4	0.2	0.9	1	1	0
09/10/2020 10:00	0.2	13.9	1,673.4	0.2	0.6	1	1	0
09/10/2020 11:00	0.2	14.0	1,468.0	0.2	0.6	1	1	0
09/10/2020 12:00	0.2	14.0	1,444.0	0.2	0.6	1	1	0
09/10/2020 13:00	0.2	14.0	1,453.9	0.2	0.6	1	1	0
09/10/2020 14:00	0.3	13.9	1,596.3	0.2	0.9	1	1	0
09/10/2020 15:00	0.3	13.9	1,565.1	0.3	0.9	1	1	1
09/10/2020 16:00	0.6	12.4	2,032.2	0.3	1.9	1	1	1
09/10/2020 17:00	0.5	12.5	2,014.2	0.4	1.6	1	1	1
09/10/2020 18:00	0.5	12.6	1,992.7	0.4	1.6	1	1	1
09/10/2020 19:00	0.5	12.6	1,990.1	0.4	1.6	1	1	1
09/10/2020 20:00	0.5	12.7	1,987.7	0.4	1.6	1	1	1
09/10/2020 21:00	0.5	12.8	1,984.7	0.4	1.6	1	1	1
09/10/2020 22:00	0.5	12.7	1,982.2	0.4	1.6	1	1	1
09/10/2020 23:00	0.5	13.2	1,831.4	0.4	1.6	1	1	1
Average/Sum#:	0.3	13.5	1,689.4	0.3	23.3 #	24 #	24 #	9 #
Minimum:	0.1	12.4	1,308.9	0.2	0.3	1	1	0
Maximum:	0.6	14.0	2,032.2	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/11/2020 00:00	0.3	13.9	1,409.2	0.4	0.8	1	1	0
09/11/2020 01:00	0.2	13.9	1,287.7	0.3	0.5	1	1	0
09/11/2020 02:00	0.2	13.9	1,286.4	0.2	0.5	1	1	0
09/11/2020 03:00	0.2	13.9	1,285.5	0.2	0.5	1	1	0
09/11/2020 04:00	0.2	13.9	1,286.7	0.2	0.5	1	1	0
09/11/2020 05:00	0.2	13.9	1,479.1	0.2	0.6	1	1	0
09/11/2020 06:00	0.2	14.0	1,292.3	0.2	0.5	1	1	0
09/11/2020 07:00	0.2	14.0	1,318.9	0.2	0.5	1	1	0
09/11/2020 08:00	0.2	14.0	1,342.0	0.2	0.5	1	1	0
09/11/2020 09:00	0.2	13.9	1,566.1	0.2	0.6	1	1	0
09/11/2020 10:00	0.2	13.9	1,548.5	0.2	0.6	1	1	0
09/11/2020 11:00	0.3	13.9	1,534.6	0.2	0.9	1	1	0
09/11/2020 12:00	0.3	13.9	1,581.7	0.3	0.9	1	1	0
09/11/2020 13:00	0.2	14.0	1,295.7	0.3	0.5	1	1	0
09/11/2020 14:00	0.2	14.0	1,299.3	0.2	0.5	1	1	0
09/11/2020 15:00	0.3	14.0	1,334.2	0.2	0.8	1	1	0
09/11/2020 16:00	0.4	13.8	1,646.7	0.3	1.2	1	1	0
09/11/2020 17:00	0.3	13.8	1,635.4	0.3	0.9	1	1	0
09/11/2020 18:00	0.5	13.3	1,786.5	0.3	1.6	1	1	1
09/11/2020 19:00	0.5	12.4	2,023.3	0.3	1.6	1	1	1
09/11/2020 20:00	0.5	12.6	1,994.5	0.4	1.6	1	1	1
09/11/2020 21:00	0.6	12.8	1,954.8	0.4	1.9	1	1	1
09/11/2020 22:00	0.3	13.6	1,477.3	0.3	0.8	1	1	1
09/11/2020 23:00	14.6	16.5	368.3	0.0	2.7	1	0	0
Average/Sum#:	0.9	13.8	1,459.8	0.3	22.0 #	24 #	23 #	5 #
Minimum:	0.2	12.4	368.3	0.2	0.5	1	0	0
Maximum:	14.6	16.5	2,023.3	0.4	2.7	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2020 17:00	15.8	17.5	450.7	0.0	21.6	1	0	0
09/12/2020 18:00	10.5	17.1	512.4	0.0	18.7	1	0	0
09/12/2020 19:00	11.5	15.5	927.2	0.0	26.1	1	0	0
09/12/2020 20:00	0.2	13.9	1,478.5	0.0	0.6	1	1	0
09/12/2020 21:00	0.2	14.0	1,493.7	0.0	0.6	1	1	0
09/12/2020 22:00	0.2	13.9	1,456.6	0.2	0.5	1	1	0
09/12/2020 23:00	0.2	13.9	1,354.2	0.2	0.5	1	1	0
Average/Sum#:	5.5	15.1	1,096.2	0.2	68.6 #	7 #	4 #	0 #
Minimum:	0.2	13.9	450.7	0.2	0.5	0	0	0
Maximum:	15.8	17.5	1,493.7	0.2	26.1	1	1	0
%SI	70.83	70.83	70.83	91.67	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/13/2020 00:00	0.2	13.9	1,351.9	0.2	0.5	1	1	0
09/13/2020 01:00	0.2	14.0	1,334.7	0.2	0.5	1	1	0
09/13/2020 02:00	14.5	16.8	311.5	0.0	2.5	1	0	0
09/13/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2020 17:00	23.0	17.4	461.3	0.0	36.0	1	0	0
09/13/2020 18:00	11.2	17.1	514.6	0.0	20.0	1	0	0
09/13/2020 19:00	13.4	15.1	1,019.4	0.0	31.1	1	0	0
09/13/2020 20:00	0.3	13.9	1,474.7	0.0	0.8	1	1	0
09/13/2020 21:00	0.3	13.9	1,382.1	0.0	0.8	1	1	0
09/13/2020 22:00	0.3	13.9	1,377.7	0.3	0.8	1	1	0
09/13/2020 23:00	0.3	13.9	1,342.7	0.3	0.8	1	1	0
Average/Sum#:	6.4	15.0	1,057.1	0.3	93.8 #	10 #	6 #	0 #
Minimum:	0.2	13.9	311.5	0.2	0.5	0	0	0
Maximum:	23.0	17.4	1,474.7	0.3	36.0	1	1	0
%SI	58.33	58.33	58.33	83.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/14/2020 00:00	0.3	13.9	1,341.7	0.3	0.8	1	1	0
09/14/2020 01:00	0.3	13.9	1,326.0	0.3	0.8	1	1	0
09/14/2020 02:00	17.5	16.8	309.0	0.0	3.0	1	0	0
09/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2020 09:00	4.9	19.4	181.0	0.0	1.2	1	0	0
09/14/2020 10:00	24.5	16.3	627.1	0.0	44.1	1	0	0
09/14/2020 11:00	2.6	14.1	1,326.1	0.0	6.7	1	0	0
09/14/2020 12:00	0.3	14.0	1,346.6	0.0	0.8	1	1	0
09/14/2020 13:00	0.3	13.9	1,599.4	0.0	0.9	1	1	0
09/14/2020 14:00	0.2	14.0	1,524.2	0.3	0.6	1	1	0
09/14/2020 15:00	0.2	13.9	1,580.1	0.2	0.6	1	1	0
09/14/2020 16:00	0.4	13.2	1,785.1	0.2	1.2	1	1	1
09/14/2020 17:00	0.3	12.0	2,103.7	0.2	0.9	1	1	1
09/14/2020 18:00	0.3	12.0	2,106.2	0.2	0.9	1	1	1
09/14/2020 19:00	0.3	12.1	2,085.4	0.2	0.9	1	1	1
09/14/2020 20:00	0.3	12.0	2,098.9	0.2	0.9	1	1	1
09/14/2020 21:00	0.4	12.4	2,012.9	0.2	1.3	1	1	1
09/14/2020 22:00	0.4	12.8	1,947.3	0.3	1.3	1	1	1
09/14/2020 23:00	0.4	12.8	1,942.6	0.3	1.3	1	1	1
Average/Sum#:	3.0	13.9	1,513.5	0.2	68.2 #	18 #	14 #	8 #
Minimum:	0.2	12.0	181.0	0.2	0.6	0	0	0
Maximum:	24.5	19.4	2,106.2	0.3	44.1	1	1	1
%SI	25.00	25.00	25.00	50.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/15/2020 00:00	0.2	13.9	1,442.8	0.3	0.5	1	1	0
09/15/2020 01:00	0.2	13.9	1,325.8	0.2	0.5	1	1	0
09/15/2020 02:00	0.2	14.0	1,283.9	0.2	0.5	1	1	0
09/15/2020 03:00	0.2	14.0	1,285.0	0.2	0.5	1	1	0
09/15/2020 04:00	0.2	14.0	1,311.6	0.2	0.5	1	1	0
09/15/2020 05:00	0.2	13.9	1,565.6	0.2	0.6	1	1	0
09/15/2020 06:00	0.3	13.9	1,605.4	0.2	0.9	1	1	0
09/15/2020 07:00	0.2	13.9	1,427.6	0.2	0.5	1	1	0
09/15/2020 08:00	0.2	13.9	1,417.1	0.2	0.5	1	1	0
09/15/2020 09:00	0.2	14.0	1,289.6	0.2	0.5	1	1	0
09/15/2020 10:00	0.2	14.0	1,585.9	0.2	0.6	1	1	0
09/15/2020 11:00	0.2	14.0	1,611.7	0.2	0.6	1	1	0
09/15/2020 12:00	0.3	14.0	1,603.2	0.2	0.9	1	1	0
09/15/2020 13:00	0.3	13.8	1,662.7	0.2	0.9	1	1	1
09/15/2020 14:00	0.4	12.2	2,067.7	0.3	1.3	1	1	1
09/15/2020 15:00	0.3	12.1	2,087.9	0.2	0.9	1	1	1
09/15/2020 16:00	0.4	12.4	2,028.3	0.3	1.3	1	1	1
09/15/2020 17:00	0.4	12.4	2,021.6	0.3	1.3	1	1	1
09/15/2020 18:00	0.4	12.4	2,010.5	0.3	1.2	1	1	1
09/15/2020 19:00	0.4	12.4	2,026.9	0.3	1.3	1	1	1
09/15/2020 20:00	0.3	12.0	2,104.4	0.3	0.9	1	1	1
09/15/2020 21:00	0.4	12.3	2,046.6	0.3	1.3	1	1	1
09/15/2020 22:00	4.5	14.1	1,224.9	0.0	5.6	1	0	1
09/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.5	13.4	1,653.8	0.2	23.6 #	23 #	22 #	10 #
Minimum:	0.2	12.0	1,224.9	0.2	0.5	0	0	0
Maximum:	4.5	14.1	2,104.4	0.3	5.6	1	1	1
%SI	4.17	4.17	4.17	8.33	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2020 11:00	16.4	17.3	492.4	0.0	19.2	1	0	0
09/16/2020 12:00	9.6	14.4	1,209.8	0.0	23.6	1	0	0
09/16/2020 13:00	0.2	13.8	1,665.4	0.0	0.6	1	1	0
09/16/2020 14:00	0.2	13.8	1,665.2	0.0	0.6	1	1	1
09/16/2020 15:00	0.4	12.4	2,040.2	0.2	1.3	1	1	1
09/16/2020 16:00	0.3	12.0	2,089.5	0.2	0.9	1	1	1
09/16/2020 17:00	0.2	11.9	2,121.2	0.2	0.6	1	1	1
09/16/2020 18:00	0.2	12.0	2,108.5	0.1	0.6	1	1	1
09/16/2020 19:00	0.4	12.5	1,998.9	0.2	1.3	1	1	1
09/16/2020 20:00	0.4	12.4	2,015.2	0.2	1.3	1	1	1
09/16/2020 21:00	0.4	12.5	2,008.7	0.3	1.3	1	1	1
09/16/2020 22:00	0.4	12.6	1,991.1	0.3	1.3	1	1	1
09/16/2020 23:00	0.4	12.8	1,932.9	0.3	1.3	1	1	1
Average/Sum#:	2.3	13.1	1,795.3	0.2	53.9 #	13 #	11 #	10 #
Minimum:	0.2	11.9	492.4	0.1	0.6	0	0	0
Maximum:	16.4	17.3	2,121.2	0.3	23.6	1	1	1
%SI	45.83	45.83	45.83	62.50	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/17/2020 00:00	0.1	13.9	1,401.0	0.2	0.3	1	1	0
09/17/2020 01:00	0.1	13.9	1,307.6	0.2	0.2	1	1	0
09/17/2020 02:00	0.1	13.9	1,288.0	0.1	0.2	1	1	0
09/17/2020 03:00	0.2	13.9	1,288.8	0.1	0.5	1	1	0
09/17/2020 04:00	0.2	13.9	1,458.7	0.2	0.6	1	1	0
09/17/2020 05:00	0.2	13.9	1,568.9	0.2	0.6	1	1	0
09/17/2020 06:00	0.2	13.9	1,535.0	0.2	0.6	1	1	0
09/17/2020 07:00	0.3	13.8	1,613.9	0.2	0.9	1	1	0
09/17/2020 08:00	0.3	13.8	1,587.1	0.2	0.9	1	1	0
09/17/2020 09:00	0.2	13.9	1,601.9	0.2	0.6	1	1	0
09/17/2020 10:00	0.2	13.9	1,416.0	0.2	0.5	1	1	0
09/17/2020 11:00	0.2	13.9	1,423.0	0.2	0.5	1	1	0
09/17/2020 12:00	0.3	13.9	1,616.6	0.2	0.9	1	1	1
09/17/2020 13:00	0.4	12.2	2,068.0	0.3	1.3	1	1	1
09/17/2020 14:00	0.3	11.8	2,118.9	0.3	0.9	1	1	1
09/17/2020 15:00	0.2	11.8	2,114.4	0.2	0.6	1	1	1
09/17/2020 16:00	0.2	11.8	2,109.3	0.1	0.6	1	1	1
09/17/2020 17:00	0.3	12.0	2,077.6	0.1	0.9	1	1	1
09/17/2020 18:00	0.3	12.3	2,022.5	0.2	0.9	1	1	1
09/17/2020 19:00	0.3	12.1	2,079.4	0.2	0.9	1	1	1
09/17/2020 20:00	0.4	12.4	2,023.4	0.2	1.3	1	1	1
09/17/2020 21:00	0.4	12.4	2,033.9	0.3	1.3	1	1	1
09/17/2020 22:00	0.3	12.2	2,071.3	0.3	0.9	1	1	1
09/17/2020 23:00	2.1	12.6	1,769.1	0.0	5.9	1	0	1
Average/Sum#:	0.3	13.1	1,733.1	0.2	22.8 #	24 #	23 #	12 #
Minimum:	0.1	11.8	1,288.0	0.1	0.2	1	0	0
Maximum:	2.1	13.9	2,118.9	0.3	5.9	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/18/2020 00:00	11.5	19.0	0.2	0.0	0.0	1	0	0
09/18/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2020 10:00	14.2	18.5	329.7	0.0	5.9	1	0	0
09/18/2020 11:00	17.6	15.5	834.3	0.0	35.9	1	0	0
09/18/2020 12:00	0.2	13.8	1,606.4	0.0	0.6	1	1	0
09/18/2020 13:00	0.2	13.8	1,530.2	0.0	0.6	1	1	1
09/18/2020 14:00	0.5	12.5	2,003.3	0.3	1.6	1	1	1
09/18/2020 15:00	0.4	12.3	2,043.1	0.3	1.3	1	1	1
09/18/2020 16:00	0.3	12.4	2,030.4	0.3	0.9	1	1	1
09/18/2020 17:00	0.4	12.5	2,012.8	0.3	1.3	1	1	1
09/18/2020 18:00	0.4	12.5	2,008.6	0.3	1.3	1	1	1
09/18/2020 19:00	0.4	12.6	1,999.6	0.3	1.3	1	1	1
09/18/2020 20:00	0.4	12.6	1,996.1	0.3	1.3	1	1	1
09/18/2020 21:00	0.4	12.6	1,993.1	0.3	1.3	1	1	1
09/18/2020 22:00	3.8	13.7	1,457.5	0.0	7.9	1	0	1
09/18/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	3.6	13.9	1,560.4	0.3	61.2 #	14 #	10 #	10 #
Minimum:	0.2	12.3	0.2	0.3	0.0	0	0	0
Maximum:	17.6	19.0	2,043.1	0.3	35.9	1	1	1
%SI	41.67	41.67	41.67	66.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/19/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2020 13:00	18.3	17.9	411.0	0.0	14.2	1	0	0
09/19/2020 14:00	13.6	15.5	857.3	0.0	28.5	1	0	0
09/19/2020 15:00	0.1	13.9	1,530.7	0.0	0.3	1	1	1
09/19/2020 16:00	0.4	12.5	2,012.4	0.0	1.3	1	1	1
09/19/2020 17:00	0.3	11.9	2,132.9	0.2	0.9	1	1	1
09/19/2020 18:00	0.3	12.1	2,113.5	0.2	1.0	1	1	1
09/19/2020 19:00	0.3	12.1	2,109.2	0.2	0.9	1	1	1
09/19/2020 20:00	0.3	12.1	2,101.4	0.2	0.9	1	1	1
09/19/2020 21:00	0.4	12.2	2,069.2	0.2	1.3	1	1	1
09/19/2020 22:00	0.4	12.2	2,071.7	0.3	1.3	1	1	1
09/19/2020 23:00	0.5	12.8	1,954.3	0.3	1.6	1	1	1
Average/Sum#:	3.2	13.2	1,760.3	0.2	52.2 #	11 #	9 #	9 #
Minimum:	0.1	11.9	411.0	0.2	0.3	0	0	0
Maximum:	18.3	17.9	2,132.9	0.3	28.5	1	1	1
%SI	54.17	54.17	54.17	70.83	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/20/2020 00:00	0.5	12.9	1,941.4	0.4	1.6	1	1	1
09/20/2020 01:00	0.5	12.9	1,945.9	0.4	1.6	1	1	1
09/20/2020 02:00	0.5	12.9	1,947.9	0.4	1.6	1	1	1
09/20/2020 03:00	0.5	12.9	1,944.9	0.4	1.6	1	1	1
09/20/2020 04:00	0.5	13.0	1,935.4	0.4	1.6	1	1	1
09/20/2020 05:00	0.4	13.0	1,901.8	0.4	1.3	1	1	1
09/20/2020 06:00	0.0	0.0	666.9	0.0	0.0	1	0	0
09/20/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2020 14:00	10.2	17.7	433.1	0.0	11.3	1	0	0
09/20/2020 15:00	12.4	15.3	940.3	0.0	27.5	1	0	0
09/20/2020 16:00	0.3	13.8	1,583.1	0.0	0.9	1	1	0
09/20/2020 17:00	0.5	12.4	2,017.5	0.0	1.6	1	1	1
09/20/2020 18:00	0.4	11.8	2,137.7	0.3	1.2	1	1	1
09/20/2020 19:00	0.3	11.8	2,134.1	0.3	0.9	1	1	1
09/20/2020 20:00	0.3	12.0	2,104.1	0.2	0.9	1	1	1
09/20/2020 21:00	0.4	12.4	1,981.5	0.2	1.2	1	1	1
09/20/2020 22:00	10.9	15.6	632.2	0.0	4.0	1	0	0
09/20/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	2.6	13.4	1,640.5	0.3	58.8 #	16 #	12 #	11 #
Minimum:	0.3	11.8	433.1	0.2	0.9	0	0	0
Maximum:	12.4	17.7	2,137.7	0.4	27.5	1	1	1
%SI	37.50	37.50	33.33	58.33	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/21/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2020 08:00	14.5	18.0	391.1	0.0	10.3	1	0	0
09/21/2020 09:00	11.9	17.1	517.4	0.0	21.4	1	0	0
09/21/2020 10:00	13.9	15.5	870.6	0.0	29.6	1	0	0
09/21/2020 11:00	0.1	13.9	1,486.4	0.0	0.3	1	1	0
09/21/2020 12:00	0.2	13.8	1,664.1	0.0	0.6	1	1	0
09/21/2020 13:00	0.2	13.9	1,575.1	0.2	0.6	1	1	0
09/21/2020 14:00	0.2	13.9	1,458.3	0.2	0.6	1	1	0
09/21/2020 15:00	0.2	13.9	1,510.1	0.2	0.6	1	1	1
09/21/2020 16:00	0.5	12.6	1,957.1	0.3	1.6	1	1	1
09/21/2020 17:00	0.4	12.4	1,984.2	0.3	1.2	1	1	1
09/21/2020 18:00	0.5	12.6	1,965.9	0.4	1.6	1	1	1
09/21/2020 19:00	0.4	12.5	2,019.7	0.3	1.3	1	1	1
09/21/2020 20:00	0.4	12.2	2,059.0	0.3	1.3	1	1	1
09/21/2020 21:00	0.3	12.3	2,000.9	0.3	0.9	1	1	1
09/21/2020 22:00	10.3	15.6	628.4	0.0	3.7	1	0	0
09/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	3.6	14.0	1,472.6	0.3	75.6 #	15 #	11 #	7 #
Minimum:	0.1	12.2	391.1	0.2	0.3	0	0	0
Maximum:	14.5	18.0	2,059.0	0.4	29.6	1	1	1
%SI	37.50	37.50	37.50	62.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 08:00	15.3	18.0	393.7	0.0	10.1	1	0	0
09/22/2020 09:00	13.6	17.1	521.6	0.0	24.7	1	0	0
09/22/2020 10:00	17.6	15.5	855.1	0.0	36.8	1	0	0
09/22/2020 11:00	0.1	13.9	1,500.8	0.0	0.3	1	1	0
09/22/2020 12:00	0.5	13.2	1,817.2	0.0	1.6	1	1	1
09/22/2020 13:00	0.6	12.6	1,947.6	0.3	1.9	1	1	1
09/22/2020 14:00	0.2	13.9	1,540.5	0.3	0.6	1	1	0
09/22/2020 15:00	0.2	14.0	1,449.5	0.3	0.6	1	1	0
09/22/2020 16:00	0.2	13.9	1,512.1	0.2	0.6	1	1	1
09/22/2020 17:00	0.4	12.8	1,946.1	0.2	1.3	1	1	1
09/22/2020 18:00	0.4	12.9	1,936.3	0.3	1.3	1	1	1
09/22/2020 19:00	0.4	12.9	1,933.3	0.3	1.3	1	1	1
09/22/2020 20:00	0.4	12.9	1,935.9	0.3	1.3	1	1	1
09/22/2020 21:00	5.7	14.4	1,179.1	0.0	6.6	1	0	1
09/22/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	4.0	14.1	1,462.1	0.3	89.0 #	14 #	10 #	8 #
Minimum:	0.1	12.6	393.7	0.2	0.3	0	0	0
Maximum:	17.6	18.0	1,947.6	0.3	36.8	1	1	1
%SI	41.67	41.67	41.67	66.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/23/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 08:00	16.3	17.8	431.3	0.0	15.9	1	0	0
09/23/2020 09:00	12.0	17.1	519.6	0.0	21.7	1	0	0
09/23/2020 10:00	14.7	15.3	909.8	0.0	31.5	1	0	0
09/23/2020 11:00	0.1	14.0	1,375.5	0.0	0.3	1	1	0
09/23/2020 12:00	0.2	14.0	1,456.4	0.0	0.6	1	1	0
09/23/2020 13:00	0.2	14.0	1,526.6	0.2	0.6	1	1	0
09/23/2020 14:00	0.2	14.0	1,459.5	0.2	0.6	1	1	0
09/23/2020 15:00	0.2	13.9	1,540.0	0.2	0.6	1	1	1
09/23/2020 16:00	0.4	12.5	1,992.2	0.2	1.3	1	1	1
09/23/2020 17:00	0.4	12.5	1,988.8	0.3	1.3	1	1	1
09/23/2020 18:00	0.5	12.7	1,959.3	0.3	1.6	1	1	1
09/23/2020 19:00	0.5	12.5	2,023.9	0.4	1.6	1	1	1
09/23/2020 20:00	0.5	12.9	1,916.5	0.4	1.6	1	1	1
09/23/2020 21:00	10.7	15.7	610.9	0.0	3.8	1	0	0
09/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	4.1	14.2	1,407.9	0.3	83.0 #	14 #	10 #	6 #
Minimum:	0.1	12.5	431.3	0.2	0.3	0	0	0
Maximum:	16.3	17.8	2,023.9	0.4	31.5	1	1	1
%SI	41.67	41.67	41.67	66.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 13:00	28.8	17.6	445.5	0.0	34.9	1	0	0
09/24/2020 14:00	13.3	14.9	1,026.7	0.0	30.1	1	0	0
09/24/2020 15:00	0.2	13.8	1,651.3	0.0	0.6	1	1	0
09/24/2020 16:00	0.3	13.4	1,757.8	0.0	0.9	1	1	1
09/24/2020 17:00	0.4	12.1	2,081.8	0.2	1.2	1	1	1
09/24/2020 18:00	0.4	12.2	2,071.0	0.3	1.3	1	1	1
09/24/2020 19:00	0.4	12.3	2,061.5	0.3	1.3	1	1	1
09/24/2020 20:00	5.2	14.2	1,199.0	0.0	5.9	1	0	1
09/24/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/24/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	6.1	13.8	1,536.8	0.3	76.2 #	8 #	5 #	5 #
Minimum:	0.2	12.1	445.5	0.2	0.6	0	0	0
Maximum:	28.8	17.6	2,081.8	0.3	34.9	1	1	1
%SI	66.67	66.67	66.67	87.50	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2020 08:00	0.5	21.0	34.5	0.0	0.0	1	0	0
09/27/2020 09:00	39.3	17.2	502.0	0.0	70.4	1	0	0
09/27/2020 10:00	10.5	16.2	706.9	0.0	20.9	1	0	0
09/27/2020 11:00	0.1	14.1	1,404.1	0.0	0.3	1	1	0
09/27/2020 12:00	0.1	14.1	1,374.0	0.0	0.3	1	1	0
09/27/2020 13:00	0.1	14.0	1,585.8	0.1	0.3	1	1	0
09/27/2020 14:00	0.1	13.9	1,601.5	0.1	0.3	1	1	0
09/27/2020 15:00	0.2	13.9	1,622.0	0.1	0.6	1	1	0
09/27/2020 16:00	0.3	13.7	1,602.1	0.2	0.9	1	1	1
09/27/2020 17:00	0.5	12.3	2,074.7	0.2	1.6	1	1	1
09/27/2020 18:00	0.4	12.1	2,114.4	0.3	1.3	1	1	1
09/27/2020 19:00	0.4	12.1	2,122.4	0.3	1.3	1	1	1
09/27/2020 20:00	0.4	12.1	2,121.0	0.3	1.3	1	1	1
09/27/2020 21:00	0.4	12.1	2,124.8	0.3	1.3	1	1	1
09/27/2020 22:00	5.2	13.9	1,273.5	0.0	6.0	1	0	1
09/27/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	3.9	14.2	1,484.2	0.2	106.8 #	15 #	11 #	7 #
Minimum:	0.1	12.1	34.5	0.1	0.0	0	0	0
Maximum:	39.3	21.0	2,124.8	0.3	70.4	1	1	1
%SI	37.50	37.50	37.50	62.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/28/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2020 10:00	9.3	17.6	451.6	0.0	11.8	1	0	0
09/28/2020 11:00	10.5	15.1	979.1	0.0	23.4	1	0	0
09/28/2020 12:00	0.3	13.8	1,716.2	0.0	1.0	1	1	0
09/28/2020 13:00	0.4	13.7	1,657.2	0.0	1.2	1	1	1
09/28/2020 14:00	0.5	12.2	2,089.4	0.3	1.6	1	1	1
09/28/2020 15:00	0.3	11.7	2,170.6	0.3	0.9	1	1	1
09/28/2020 16:00	0.3	11.7	2,167.8	0.2	0.9	1	1	1
09/28/2020 17:00	0.3	11.9	2,152.6	0.2	0.9	1	1	1
09/28/2020 18:00	0.3	11.9	2,146.5	0.2	0.9	1	1	1
09/28/2020 19:00	0.4	12.1	2,096.1	0.2	1.3	1	1	1
09/28/2020 20:00	0.4	12.1	2,105.7	0.3	1.3	1	1	1
09/28/2020 21:00	0.4	12.3	2,076.1	0.3	1.3	1	1	1
09/28/2020 22:00	5.2	14.1	1,250.6	0.0	6.3	1	0	1
09/28/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	2.2	13.1	1,773.8	0.3	52.8 #	13 #	10 #	10 #
Minimum:	0.3	11.7	451.6	0.2	0.9	0	0	0
Maximum:	10.5	17.6	2,170.6	0.3	23.4	1	1	1
%SI	45.83	45.83	45.83	66.67	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2020 10:00	9.9	17.5	459.6	0.0	13.8	1	0	0
09/29/2020 11:00	11.4	15.1	1,006.2	0.0	26.1	1	0	0
09/29/2020 12:00	0.3	13.9	1,704.3	0.0	1.0	1	1	0
09/29/2020 13:00	0.4	13.4	1,762.3	0.0	1.2	1	1	1
09/29/2020 14:00	0.5	12.2	2,089.8	0.3	1.6	1	1	1
09/29/2020 15:00	0.4	12.1	2,105.1	0.3	1.3	1	1	1
09/29/2020 16:00	0.4	12.0	2,127.0	0.3	1.3	1	1	1
09/29/2020 17:00	0.3	12.1	2,126.7	0.3	1.0	1	1	1
09/29/2020 18:00	0.4	12.2	2,091.6	0.3	1.3	1	1	1
09/29/2020 19:00	0.4	12.1	2,119.8	0.3	1.3	1	1	1
09/29/2020 20:00	0.4	12.2	2,104.9	0.3	1.3	1	1	1
09/29/2020 21:00	0.4	12.3	2,091.1	0.3	1.3	1	1	1
09/29/2020 22:00	0.4	12.4	2,068.3	0.3	1.3	1	1	1
09/29/2020 23:00	0.4	12.5	2,062.3	0.3	1.3	1	1	1
Average/Sum#:	1.9	13.0	1,851.4	0.3	55.1 #	14 #	12 #	11 #
Minimum:	0.3	12.0	459.6	0.3	1.0	0	0	0
Maximum:	11.4	17.5	2,127.0	0.3	26.1	1	1	1
%SI	41.67	41.67	41.67	58.33	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:50 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/30/2020 00:00	0.4	12.8	1,987.6	0.3	1.3	1	1	1
09/30/2020 01:00	0.3	13.9	1,639.6	0.3	0.9	1	1	0
09/30/2020 02:00	0.3	13.9	1,676.0	0.3	0.9	1	1	0
09/30/2020 03:00	0.3	13.9	1,656.5	0.3	0.9	1	1	0
09/30/2020 04:00	0.4	13.7	1,699.1	0.3	1.2	1	1	1
09/30/2020 05:00	0.5	12.7	2,024.7	0.3	1.6	1	1	1
09/30/2020 06:00	0.5	12.7	2,016.1	0.4	1.6	1	1	1
09/30/2020 07:00	0.3	13.9	1,645.5	0.4	0.9	1	1	0
09/30/2020 08:00	0.3	13.9	1,677.7	0.3	0.9	1	1	0
09/30/2020 09:00	0.3	13.9	1,682.6	0.3	1.0	1	1	0
09/30/2020 10:00	0.4	13.6	1,675.8	0.3	1.2	1	1	1
09/30/2020 11:00	0.5	12.3	2,076.6	0.3	1.6	1	1	1
09/30/2020 12:00	0.4	12.0	2,129.2	0.3	1.3	1	1	1
09/30/2020 13:00	0.3	11.8	2,166.7	0.3	0.9	1	1	1
09/30/2020 14:00	0.3	11.9	2,126.2	0.2	0.9	1	1	1
09/30/2020 15:00	0.3	11.9	2,135.5	0.2	0.9	1	1	1
09/30/2020 16:00	0.3	11.9	2,124.4	0.2	0.9	1	1	1
09/30/2020 17:00	0.4	12.1	2,097.4	0.2	1.3	1	1	1
09/30/2020 18:00	0.4	12.0	2,119.5	0.3	1.3	1	1	1
09/30/2020 19:00	0.3	11.9	2,148.3	0.3	0.9	1	1	1
09/30/2020 20:00	0.3	12.0	2,130.3	0.2	0.9	1	1	1
09/30/2020 21:00	0.4	12.1	2,110.9	0.2	1.3	1	1	1
09/30/2020 22:00	0.4	12.2	2,096.2	0.3	1.3	1	1	1
09/30/2020 23:00	0.5	12.7	1,959.2	0.3	1.6	1	1	1
Average/Sum#:	0.4	12.7	1,950.1	0.3	27.5 #	24 #	24 #	18 #
Minimum:	0.3	11.8	1,639.6	0.2	0.9	1	1	0
Maximum:	0.5	13.9	2,166.7	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Excess Emission Report

CT1 - CO Lb 1-Day Block Average

From: 07/01/2020 00:00 To: 09/30/2020 23:59
Generated: 10/06/2020 08:50

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA



Tag Name: CT1_CO_Lb_1D

Total Operating Time: 1,885.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 323.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,885.00 Hour(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT1 - CO Lb 1-Day Block Average



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 10/06/2020 08:51 Location: Maxwell, CA

Tag Name: CT1_CO_Lb_1D

Total Operating Time: 1,885.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 323.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,885.00 Hour(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

ATTACHMENT 8
Hourly Emissions – NH₃

FCD: AQ-18
Title V: #6

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2020 13:00	35.2	17.3	57.7	0.0	1,825,899.2	440.0	0.0	0.0
07/03/2020 14:00	34.7	14.9	34.1	223.0	2,393,475.3	1,031.2	3.0	1.2
07/03/2020 15:00	9.3	13.8	7.7	118.0	3,233,406.6	1,652.8	1.2	0.8
07/03/2020 16:00	8.9	13.8	7.4	112.9	3,151,828.0	1,611.1	1.2	0.8
07/03/2020 17:00	11.0	13.3	8.5	163.0	3,202,542.2	2,011.2	1.7	1.4
07/03/2020 18:00	11.1	13.2	8.5	197.1	3,115,955.8	2,116.1	2.2	1.7
07/03/2020 19:00	11.0	13.3	8.5	187.9	3,151,481.9	2,094.2	2.1	1.7
07/03/2020 20:00	11.1	13.2	8.5	198.9	3,137,601.6	2,130.8	2.2	1.7
07/03/2020 21:00	10.9	13.3	8.5	171.8	3,187,610.7	2,025.1	1.9	1.4
07/03/2020 22:00	10.8	13.3	8.4	175.7	3,187,179.6	2,048.1	1.9	1.4
07/03/2020 23:00	16.4	14.6	15.4	172.9	2,408,817.5	1,231.3	2.4	1.1
Average/Sum#:	15.5	14.0	15.7	156.5	2,908,708.9	1,672.0	1.8	1.2
Minimum:	8.9	13.2	7.4	0.0	1,825,899.2	440.0	0.0	0.0
Maximum:	35.2	17.3	57.7	223.0	3,233,406.6	2,130.8	3.0	1.7
%SI	54.17	54.17	54.17	54.17	54.17	54.17	54.17	54.17

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/04/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/05/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2020 14:00	37.7	17.4	63.6	0.0	1,810,635.8	423.1	0.0	0.0
07/05/2020 15:00	36.6	15.0	36.6	212.7	2,248,925.4	952.5	3.1	1.1
07/05/2020 16:00	8.8	13.8	7.3	106.4	3,076,118.4	1,572.4	1.2	0.8
07/05/2020 17:00	10.4	13.5	8.3	142.6	3,063,231.2	1,789.5	1.6	1.1
07/05/2020 18:00	11.0	13.2	8.4	188.4	3,098,580.4	2,104.3	2.1	1.7
07/05/2020 19:00	10.9	13.3	8.5	176.9	3,093,261.8	2,078.1	2.0	1.7
07/05/2020 20:00	11.1	13.3	8.6	192.3	3,133,897.9	2,105.4	2.1	1.7
07/05/2020 21:00	11.0	13.3	8.5	188.0	3,170,521.8	2,083.7	2.1	1.7
07/05/2020 22:00	15.4	14.4	14.0	187.1	2,518,260.4	1,360.8	2.5	1.4
07/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	17.0	14.1	18.2	154.9	2,801,492.6	1,607.8	1.9	1.2
Minimum:	8.8	13.2	7.3	0.0	1,810,635.8	423.1	0.0	0.0
Maximum:	37.7	17.4	63.6	212.7	3,170,521.8	2,105.4	3.1	1.7
%SI	62.50	62.50	62.50	62.50	62.50	62.50	62.50	62.50

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2020 11:00	31.7	17.6	56.7	0.0	1,791,584.9	379.4	0.0	0.0
07/06/2020 12:00	42.8	15.4	45.9	248.6	2,261,832.6	891.9	3.4	1.2
07/06/2020 13:00	8.6	13.8	7.1	113.0	3,258,838.8	1,665.8	1.2	0.8
07/06/2020 14:00	8.9	13.9	7.5	113.1	3,120,526.9	1,595.1	1.2	0.8
07/06/2020 15:00	9.9	13.8	8.2	122.1	2,982,019.4	1,524.3	1.4	0.8
07/06/2020 16:00	11.4	13.3	8.9	184.6	3,203,666.0	2,035.3	2.0	1.6
07/06/2020 17:00	11.3	13.3	8.8	202.3	3,194,106.3	2,099.2	2.2	1.7
07/06/2020 18:00	11.3	13.3	8.8	208.9	3,181,579.2	2,114.2	2.3	1.9
07/06/2020 19:00	11.2	13.3	8.7	211.5	3,209,992.3	2,086.2	2.3	1.9
07/06/2020 20:00	10.9	13.3	8.5	191.2	3,241,758.1	2,059.5	2.0	1.6
07/06/2020 21:00	10.9	13.4	8.6	179.4	3,227,064.5	2,026.6	1.9	1.4
07/06/2020 22:00	10.8	13.4	8.5	164.3	3,253,143.7	1,924.2	1.7	1.3
07/06/2020 23:00	10.2	13.5	8.1	149.4	3,137,404.6	1,764.1	1.6	1.1
Average/Sum#:	14.6	13.9	14.9	160.6	3,004,885.9	1,705.1	1.8	1.2
Minimum:	8.6	13.3	7.1	0.0	1,791,584.9	379.4	0.0	0.0
Maximum:	42.8	17.6	56.7	248.6	3,258,838.8	2,114.2	3.4	1.9
%SI	45.83	45.83	45.83	45.83	45.83	45.83	45.83	45.83

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/07/2020 00:00	10.0	13.9	8.4	91.3	2,514,183.8	1,266.8	1.2	0.6
07/07/2020 01:00	9.6	13.9	8.1	90.4	2,616,196.0	1,318.2	1.1	0.5
07/07/2020 02:00	9.9	14.0	8.5	90.1	2,533,832.0	1,276.7	1.2	0.6
07/07/2020 03:00	9.9	14.0	8.5	90.0	2,514,580.7	1,267.0	1.2	0.6
07/07/2020 04:00	9.9	14.0	8.5	90.0	2,497,115.6	1,258.2	1.2	0.6
07/07/2020 05:00	9.7	14.0	8.3	93.5	2,539,389.1	1,279.5	1.2	0.6
07/07/2020 06:00	10.1	14.0	8.6	90.5	2,513,786.8	1,266.6	1.2	0.6
07/07/2020 07:00	9.9	14.0	8.5	90.2	2,549,114.0	1,284.4	1.2	0.6
07/07/2020 08:00	9.7	14.0	8.3	90.0	2,585,235.1	1,302.6	1.1	0.5
07/07/2020 09:00	9.9	14.0	8.5	90.2	2,535,022.8	1,277.3	1.2	0.6
07/07/2020 10:00	10.0	14.0	8.6	90.3	2,513,786.8	1,266.6	1.2	0.6
07/07/2020 11:00	9.9	14.0	8.5	90.1	2,559,413.9	1,270.9	1.1	0.5
07/07/2020 12:00	9.9	14.0	8.5	90.2	2,562,636.1	1,272.5	1.1	0.5
07/07/2020 13:00	9.8	14.0	8.4	102.0	2,722,971.4	1,372.0	1.2	0.7
07/07/2020 14:00	9.4	14.0	8.0	90.2	2,668,591.3	1,344.6	1.1	0.5
07/07/2020 15:00	9.7	13.9	8.2	113.2	971,046.4	1,482.0	4.2	2.4
07/07/2020 16:00	11.4	13.3	8.9	175.4	3,230,090.0	2,028.5	1.9	1.4
07/07/2020 17:00	11.4	13.3	8.9	201.8	3,183,535.5	2,115.5	2.2	1.7
07/07/2020 18:00	11.2	13.3	8.7	196.9	3,196,451.9	2,077.4	2.1	1.7
07/07/2020 19:00	11.1	13.3	8.6	195.0	3,178,449.4	2,065.7	2.1	1.7
07/07/2020 20:00	11.1	13.3	8.6	196.7	3,175,372.0	2,063.7	2.2	1.7
07/07/2020 21:00	10.9	13.3	8.5	189.1	3,194,026.8	2,052.5	2.1	1.6
07/07/2020 22:00	10.8	13.4	8.5	167.3	3,234,346.6	1,936.7	1.8	1.4
07/07/2020 23:00	10.3	13.5	8.2	160.4	3,112,359.3	1,818.2	1.8	1.3
Average/Sum#:	10.2	13.8	8.5	123.5	2,779,586.4	1,540.2	1.5	0.9
Minimum:	9.4	13.3	8.0	90.0	2,497,115.6	1,258.2	1.1	0.5
Maximum:	11.4	14.0	8.9	201.8	3,234,346.6	2,115.5	2.2	1.7
%SI	0.00	0.00	0.00	0.00	4.17	0.00	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/08/2020 00:00	9.6	14.0	8.2	93.7	2,557,846.6	1,288.8	1.2	0.6
07/08/2020 01:00	9.9	14.0	8.5	90.3	2,491,757.0	1,255.5	1.2	0.6
07/08/2020 02:00	9.9	14.0	8.5	90.2	2,491,558.5	1,255.4	1.2	0.6
07/08/2020 03:00	9.8	14.0	8.4	90.0	2,527,192.1	1,254.9	1.2	0.6
07/08/2020 04:00	9.8	14.0	8.4	89.8	2,531,622.6	1,257.1	1.2	0.6
07/08/2020 05:00	9.7	14.0	8.3	87.9	2,516,565.4	1,268.0	1.1	0.5
07/08/2020 06:00	9.9	14.0	8.5	90.0	2,535,650.4	1,259.1	1.2	0.6
07/08/2020 07:00	9.8	14.0	8.4	90.0	2,506,642.0	1,263.0	1.2	0.6
07/08/2020 08:00	9.8	14.0	8.4	90.0	2,503,268.1	1,261.3	1.2	0.6
07/08/2020 09:00	9.9	14.0	8.5	93.1	2,503,863.5	1,261.6	1.2	0.6
07/08/2020 10:00	9.9	14.0	8.5	90.1	2,544,712.7	1,263.6	1.2	0.6
07/08/2020 11:00	9.8	14.0	8.4	90.0	2,577,538.6	1,279.9	1.1	0.5
07/08/2020 12:00	9.7	14.0	8.3	96.4	2,651,920.1	1,336.2	1.2	0.7
07/08/2020 13:00	9.8	14.0	8.4	90.5	2,592,642.6	1,287.4	1.1	0.5
07/08/2020 14:00	9.5	14.0	8.1	90.3	2,691,120.3	1,336.3	1.1	0.5
07/08/2020 15:00	9.7	13.9	8.2	109.8	2,826,571.3	1,424.2	1.3	0.7
07/08/2020 16:00	11.4	13.3	8.9	183.8	3,154,500.2	2,027.1	2.0	1.6
07/08/2020 17:00	11.3	13.3	8.8	198.6	3,115,816.7	2,070.5	2.2	1.7
07/08/2020 18:00	11.3	13.3	8.8	201.6	3,142,151.8	2,088.0	2.2	1.7
07/08/2020 19:00	11.3	13.3	8.8	200.7	3,136,282.8	2,084.1	2.2	1.7
07/08/2020 20:00	11.3	13.3	8.8	203.2	3,137,336.2	2,084.8	2.3	1.9
07/08/2020 21:00	11.0	13.3	8.5	186.8	3,160,537.0	2,007.9	2.0	1.6
07/08/2020 22:00	10.9	13.4	8.6	176.7	3,187,172.2	1,955.0	1.9	1.4
07/08/2020 23:00	10.5	13.5	8.4	160.7	3,051,933.4	1,782.9	1.8	1.2
Average/Sum#:	10.2	13.8	8.5	124.3	2,755,675.1	1,527.2	1.5	0.9
Minimum:	9.5	13.3	8.1	87.9	2,491,558.5	1,254.9	1.1	0.5
Maximum:	11.4	14.0	8.9	203.2	3,187,172.2	2,088.0	2.3	1.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/09/2020 00:00	9.7	13.9	8.2	91.3	2,528,870.4	1,274.2	1.2	0.6
07/09/2020 01:00	9.9	13.9	8.3	90.3	2,522,916.3	1,271.2	1.2	0.6
07/09/2020 02:00	10.0	14.0	8.6	90.3	2,487,390.7	1,253.3	1.2	0.6
07/09/2020 03:00	9.7	13.9	8.2	90.6	2,608,852.7	1,314.5	1.1	0.5
07/09/2020 04:00	9.9	13.9	8.3	90.4	2,549,312.5	1,284.5	1.2	0.6
07/09/2020 05:00	9.5	13.9	8.0	93.7	2,658,072.6	1,339.3	1.2	0.7
07/09/2020 06:00	9.9	14.0	8.5	90.2	2,516,565.4	1,268.0	1.2	0.6
07/09/2020 07:00	10.1	14.0	8.6	90.4	2,495,130.9	1,257.2	1.2	0.6
07/09/2020 08:00	10.1	14.0	8.6	90.4	2,499,695.7	1,259.5	1.2	0.6
07/09/2020 09:00	9.9	14.0	8.5	90.2	2,514,580.7	1,267.0	1.2	0.6
07/09/2020 10:00	9.9	14.0	8.5	90.1	2,513,389.9	1,266.4	1.2	0.6
07/09/2020 11:00	9.8	14.0	8.4	89.9	2,550,955.7	1,266.7	1.2	0.6
07/09/2020 12:00	9.4	13.9	7.9	112.1	3,000,627.1	1,511.9	1.2	0.8
07/09/2020 13:00	9.2	13.9	7.8	119.2	3,186,846.2	1,629.0	1.2	0.8
07/09/2020 14:00	9.6	13.8	8.0	116.7	2,936,437.1	1,501.0	1.3	0.8
07/09/2020 15:00	11.5	13.3	8.9	188.1	3,145,941.3	2,021.6	2.1	1.6
07/09/2020 16:00	11.4	13.3	8.9	198.3	3,112,957.5	2,068.6	2.2	1.7
07/09/2020 17:00	11.3	13.3	8.8	203.6	3,126,157.7	2,100.2	2.3	1.9
07/09/2020 18:00	11.2	13.2	8.6	207.3	3,099,998.0	2,127.9	2.3	1.9
07/09/2020 19:00	11.2	13.2	8.6	211.7	3,125,085.3	2,122.3	2.4	1.9
07/09/2020 20:00	11.1	13.3	8.6	200.2	3,124,996.3	2,076.6	2.2	1.7
07/09/2020 21:00	11.2	13.3	8.7	204.0	3,156,066.7	2,074.2	2.3	1.9
07/09/2020 22:00	11.0	13.4	8.7	177.5	3,194,834.5	1,959.7	1.9	1.4
07/09/2020 23:00	10.9	13.4	8.6	165.3	3,212,906.3	1,900.4	1.8	1.3
Average/Sum#:	10.3	13.7	8.5	133.0	2,827,857.8	1,600.6	1.6	1.0
Minimum:	9.2	13.2	7.8	89.9	2,487,390.7	1,253.3	1.1	0.5
Maximum:	11.5	14.0	8.9	211.7	3,212,906.3	2,127.9	2.4	1.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/10/2020 00:00	9.0	14.0	7.7	97.9	2,700,346.1	1,360.6	1.2	0.7
07/10/2020 01:00	9.4	14.0	8.0	89.1	2,534,039.3	1,258.3	1.2	0.6
07/10/2020 02:00	9.4	14.0	8.0	89.1	2,532,025.4	1,257.3	1.2	0.6
07/10/2020 03:00	9.4	14.0	8.0	89.1	2,526,990.8	1,254.8	1.2	0.6
07/10/2020 04:00	9.3	14.0	8.0	89.3	2,548,136.3	1,265.3	1.2	0.6
07/10/2020 05:00	8.6	14.0	7.4	97.2	3,037,343.6	1,530.4	1.1	0.6
07/10/2020 06:00	8.9	14.0	7.6	108.6	3,315,594.7	1,670.6	1.1	0.7
07/10/2020 07:00	9.2	13.9	7.8	116.6	3,310,434.6	1,668.0	1.2	0.8
07/10/2020 08:00	8.8	14.0	7.5	102.4	3,132,211.0	1,578.2	1.1	0.6
07/10/2020 09:00	9.0	14.0	7.7	94.1	2,873,409.6	1,447.8	1.1	0.6
07/10/2020 10:00	9.0	14.0	7.7	97.0	2,943,667.0	1,483.2	1.1	0.6
07/10/2020 11:00	9.1	14.0	7.8	90.0	2,766,438.6	1,373.7	1.1	0.5
07/10/2020 12:00	9.6	13.9	8.1	125.4	3,061,556.6	1,542.6	1.4	0.8
07/10/2020 13:00	11.6	13.3	9.0	183.7	3,222,397.2	2,047.2	2.0	1.6
07/10/2020 14:00	11.4	13.3	8.9	198.6	3,207,952.7	2,108.3	2.1	1.7
07/10/2020 15:00	11.3	13.3	8.8	196.2	3,216,169.2	2,113.7	2.1	1.7
07/10/2020 16:00	11.1	13.3	8.6	201.8	3,199,392.1	2,149.4	2.2	1.7
07/10/2020 17:00	11.2	13.2	8.6	209.4	3,180,123.9	2,182.9	2.3	2.0
07/10/2020 18:00	11.1	13.2	8.5	203.2	3,167,262.4	2,197.2	2.2	1.8
07/10/2020 19:00	11.2	13.2	8.6	207.0	3,203,287.6	2,198.8	2.3	2.0
07/10/2020 20:00	11.2	13.2	8.6	205.2	3,190,904.5	2,190.3	2.2	1.8
07/10/2020 21:00	11.1	13.3	8.6	183.4	3,217,839.6	2,091.3	2.0	1.7
07/10/2020 22:00	11.2	13.3	8.7	187.5	3,240,458.1	2,106.0	2.0	1.7
07/10/2020 23:00	10.5	13.5	8.4	149.9	3,097,638.0	1,809.6	1.7	1.3
Average/Sum#:	10.1	13.7	8.2	142.2	3,017,734.1	1,745.2	1.6	1.1
Minimum:	8.6	13.2	7.4	89.1	2,526,990.8	1,254.8	1.1	0.5
Maximum:	11.6	14.0	9.0	209.4	3,315,594.7	2,198.8	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/11/2020 00:00	9.8	13.9	8.3	89.1	2,576,899.4	1,298.4	1.1	0.5
07/11/2020 01:00	9.5	13.9	8.0	87.9	2,670,377.5	1,345.5	1.1	0.5
07/11/2020 02:00	9.5	13.9	8.0	87.5	2,683,873.3	1,352.3	1.1	0.5
07/11/2020 03:00	9.4	14.0	8.0	87.6	2,715,628.1	1,368.3	1.1	0.5
07/11/2020 04:00	9.6	14.0	8.2	87.9	2,646,561.5	1,333.5	1.1	0.5
07/11/2020 05:00	8.9	13.9	7.5	105.3	3,284,038.4	1,654.7	1.1	0.7
07/11/2020 06:00	9.1	13.9	7.7	101.3	3,154,042.4	1,589.2	1.1	0.6
07/11/2020 07:00	9.4	14.0	8.0	89.1	2,703,323.1	1,362.1	1.1	0.5
07/11/2020 08:00	9.5	13.9	8.0	115.4	3,143,325.1	1,583.8	1.2	0.8
07/11/2020 09:00	9.7	14.0	8.3	88.5	2,599,127.8	1,309.6	1.1	0.5
07/11/2020 10:00	9.4	13.9	7.9	97.5	2,939,102.3	1,480.9	1.1	0.6
07/11/2020 11:00	9.9	13.9	8.3	126.9	3,157,305.7	1,613.9	1.3	0.8
07/11/2020 12:00	9.5	14.0	8.1	110.1	3,209,216.3	1,617.0	1.1	0.6
07/11/2020 13:00	9.4	14.0	8.0	89.1	2,748,918.1	1,365.0	1.1	0.5
07/11/2020 14:00	9.5	14.0	8.1	87.8	2,705,109.3	1,363.0	1.1	0.5
07/11/2020 15:00	11.2	13.5	8.9	159.6	3,148,462.7	1,816.3	1.7	1.3
07/11/2020 16:00	11.5	13.3	8.9	189.8	3,213,482.2	2,135.4	2.0	1.7
07/11/2020 17:00	11.5	13.2	8.8	203.0	3,172,111.3	2,177.4	2.2	1.7
07/11/2020 18:00	11.4	13.2	8.7	206.2	3,188,427.9	2,188.6	2.3	2.0
07/11/2020 19:00	11.4	13.2	8.7	211.6	3,204,598.7	2,199.7	2.3	2.0
07/11/2020 20:00	11.3	13.3	8.8	196.0	3,227,627.9	2,144.8	2.1	1.7
07/11/2020 21:00	11.1	13.3	8.6	185.0	3,227,533.2	2,097.6	2.0	1.7
07/11/2020 22:00	11.1	13.3	8.6	187.3	3,250,921.2	2,112.8	2.0	1.7
07/11/2020 23:00	10.4	13.5	8.3	151.3	3,126,053.5	1,826.2	1.7	1.3
Average/Sum#:	10.1	13.7	8.3	130.9	2,987,336.1	1,680.7	1.5	1.0
Minimum:	8.9	13.2	7.5	87.5	2,576,899.4	1,298.4	1.1	0.5
Maximum:	11.5	14.0	8.9	211.6	3,284,038.4	2,199.7	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/12/2020 00:00	9.5	14.0	8.1	88.3	2,573,724.0	1,296.8	1.1	0.5
07/12/2020 01:00	9.6	14.0	8.2	87.4	2,557,449.7	1,288.6	1.1	0.5
07/12/2020 02:00	9.8	14.0	8.4	87.9	2,554,869.6	1,287.3	1.1	0.5
07/12/2020 03:00	9.8	14.0	8.4	87.8	2,554,671.1	1,287.2	1.1	0.5
07/12/2020 04:00	9.7	14.0	8.3	87.6	2,556,854.3	1,288.3	1.1	0.5
07/12/2020 05:00	9.8	14.0	8.4	87.2	2,553,877.2	1,286.8	1.1	0.5
07/12/2020 06:00	9.7	14.0	8.3	87.9	2,563,602.1	1,291.7	1.1	0.5
07/12/2020 07:00	9.7	14.0	8.3	87.6	2,560,228.2	1,290.0	1.1	0.5
07/12/2020 08:00	9.6	14.0	8.2	87.5	2,601,503.6	1,291.8	1.1	0.5
07/12/2020 09:00	9.7	14.0	8.3	87.6	2,622,447.7	1,302.2	1.1	0.5
07/12/2020 10:00	9.4	14.0	8.0	99.1	2,829,069.7	1,404.8	1.2	0.7
07/12/2020 11:00	9.6	13.9	8.1	94.0	2,722,574.4	1,371.8	1.1	0.5
07/12/2020 12:00	9.2	14.0	7.9	98.2	2,835,700.8	1,428.8	1.1	0.6
07/12/2020 13:00	9.2	14.0	7.9	87.7	2,750,126.4	1,365.6	1.0	0.5
07/12/2020 14:00	9.4	14.0	8.0	87.1	2,644,801.5	1,313.3	1.1	0.5
07/12/2020 15:00	9.8	13.8	8.1	130.1	3,214,234.7	1,643.0	1.4	0.8
07/12/2020 16:00	11.5	13.3	8.9	176.8	3,191,671.8	2,097.6	1.9	1.5
07/12/2020 17:00	11.6	13.2	8.9	205.6	3,140,162.2	2,178.4	2.3	2.0
07/12/2020 18:00	11.3	13.2	8.7	199.7	3,128,197.7	2,170.1	2.2	1.7
07/12/2020 19:00	11.2	13.2	8.6	196.3	3,137,438.7	2,153.6	2.2	1.7
07/12/2020 20:00	11.1	13.3	8.6	184.4	3,191,367.4	2,097.4	2.0	1.7
07/12/2020 21:00	11.1	13.3	8.6	177.7	3,214,723.7	2,065.8	1.9	1.4
07/12/2020 22:00	11.1	13.3	8.6	183.0	3,214,039.0	2,112.3	2.0	1.7
07/12/2020 23:00	11.0	13.3	8.5	165.1	3,205,431.2	1,966.2	1.8	1.4
Average/Sum#:	10.1	13.7	8.3	123.4	2,838,281.9	1,595.0	1.4	0.9
Minimum:	9.2	13.2	7.9	87.1	2,553,877.2	1,286.8	1.0	0.5
Maximum:	11.6	14.0	8.9	205.6	3,214,723.7	2,178.4	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/13/2020 00:00	9.2	13.8	7.6	112.3	3,097,246.7	1,583.2	1.2	0.8
07/13/2020 01:00	9.2	13.9	7.8	92.3	2,822,970.6	1,443.0	1.1	0.6
07/13/2020 02:00	9.5	13.9	8.0	88.0	2,624,730.1	1,322.5	1.1	0.5
07/13/2020 03:00	9.8	14.0	8.4	88.3	2,563,006.7	1,291.4	1.1	0.5
07/13/2020 04:00	9.8	14.0	8.4	88.3	2,565,785.3	1,292.8	1.1	0.5
07/13/2020 05:00	9.1	13.9	7.7	106.5	3,187,041.8	1,629.1	1.1	0.7
07/13/2020 06:00	9.3	13.9	7.8	96.2	2,920,982.2	1,493.1	1.1	0.6
07/13/2020 07:00	9.4	13.9	7.9	89.4	2,727,110.8	1,394.0	1.1	0.6
07/13/2020 08:00	9.4	13.9	7.9	100.5	2,986,323.3	1,526.5	1.1	0.6
07/13/2020 09:00	9.8	14.0	8.4	88.7	2,594,563.0	1,307.3	1.1	0.5
07/13/2020 10:00	9.3	13.9	7.8	95.2	2,943,667.0	1,483.2	1.1	0.6
07/13/2020 11:00	9.4	13.8	7.8	115.1	3,172,369.4	1,621.6	1.2	0.8
07/13/2020 12:00	11.4	13.3	8.9	170.0	3,253,019.9	2,042.9	1.8	1.4
07/13/2020 13:00	11.4	13.3	8.9	178.5	3,192,889.0	2,098.4	1.9	1.5
07/13/2020 14:00	11.2	13.3	8.7	184.8	3,185,943.3	2,117.1	2.0	1.7
07/13/2020 15:00	11.1	13.3	8.6	184.7	3,154,737.0	2,119.4	2.0	1.7
07/13/2020 16:00	11.1	13.2	8.5	187.6	3,151,590.3	2,140.3	2.1	1.7
07/13/2020 17:00	11.1	13.2	8.5	193.8	3,154,046.6	2,165.0	2.1	1.7
07/13/2020 18:00	11.1	13.2	8.5	192.2	3,151,132.9	2,163.0	2.1	1.7
07/13/2020 19:00	11.2	13.2	8.6	193.6	3,161,308.8	2,146.9	2.1	1.7
07/13/2020 20:00	11.1	13.3	8.6	183.2	3,191,210.3	2,120.6	2.0	1.7
07/13/2020 21:00	11.1	13.3	8.6	180.6	3,199,888.3	2,103.0	1.9	1.5
07/13/2020 22:00	11.0	13.3	8.5	177.2	3,228,148.7	2,098.0	1.9	1.5
07/13/2020 23:00	10.9	13.4	8.6	158.1	3,282,443.4	1,965.5	1.6	1.2
Average/Sum#:	10.3	13.6	8.3	139.4	3,021,339.8	1,777.8	1.5	1.1
Minimum:	9.1	13.2	7.6	88.0	2,563,006.7	1,291.4	1.1	0.5
Maximum:	11.4	14.0	8.9	193.8	3,282,443.4	2,165.0	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/14/2020 00:00	10.3	13.5	8.2	140.2	3,139,668.8	1,788.3	1.5	1.1
07/14/2020 01:00	9.6	13.9	8.1	88.6	2,535,587.1	1,296.1	1.1	0.5
07/14/2020 02:00	9.3	13.9	7.8	87.0	2,650,031.8	1,354.6	1.1	0.5
07/14/2020 03:00	9.7	13.9	8.2	87.6	2,571,937.8	1,295.9	1.1	0.5
07/14/2020 04:00	9.8	13.9	8.3	87.8	2,564,197.5	1,292.0	1.1	0.5
07/14/2020 05:00	9.2	13.9	7.8	117.7	3,187,237.4	1,629.2	1.2	0.8
07/14/2020 06:00	9.2	13.9	7.8	107.1	3,252,382.9	1,662.5	1.1	0.7
07/14/2020 07:00	9.1	13.9	7.7	105.8	3,280,358.3	1,676.8	1.1	0.7
07/14/2020 08:00	9.3	13.9	7.8	100.2	3,036,992.0	1,552.4	1.1	0.6
07/14/2020 09:00	9.9	13.9	8.3	88.8	2,578,288.7	1,299.1	1.1	0.5
07/14/2020 10:00	9.9	13.9	8.3	88.8	2,608,654.2	1,314.4	1.1	0.5
07/14/2020 11:00	9.9	13.9	8.3	99.0	2,702,132.3	1,361.5	1.2	0.7
07/14/2020 12:00	9.5	13.9	8.0	102.2	2,996,300.6	1,531.6	1.1	0.6
07/14/2020 13:00	9.9	14.0	8.5	92.5	2,672,759.2	1,346.7	1.1	0.5
07/14/2020 14:00	11.6	13.3	9.0	178.6	3,227,223.7	2,026.7	1.9	1.4
07/14/2020 15:00	11.4	13.3	8.9	176.8	3,159,414.2	2,076.4	1.9	1.5
07/14/2020 16:00	11.3	13.3	8.8	183.1	3,160,059.6	2,099.9	2.0	1.7
07/14/2020 17:00	11.3	13.2	8.7	182.2	3,175,108.3	2,109.9	2.0	1.7
07/14/2020 18:00	11.3	13.2	8.7	190.7	3,178,255.4	2,135.2	2.1	1.7
07/14/2020 19:00	11.3	13.2	8.7	191.0	3,139,221.3	2,131.9	2.1	1.7
07/14/2020 20:00	11.4	13.2	8.7	189.8	3,190,006.4	2,119.8	2.1	1.7
07/14/2020 21:00	11.3	13.3	8.8	189.6	3,199,035.6	2,125.8	2.1	1.7
07/14/2020 22:00	11.2	13.3	8.7	166.8	3,230,374.3	1,981.5	1.8	1.4
07/14/2020 23:00	10.7	13.5	8.5	149.5	3,111,713.6	1,795.1	1.6	1.1
Average/Sum#:	10.3	13.6	8.4	133.0	2,981,122.5	1,708.5	1.5	1.0
Minimum:	9.1	13.2	7.7	87.0	2,535,587.1	1,292.0	1.1	0.5
Maximum:	11.6	14.0	9.0	191.0	3,280,358.3	2,135.2	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/15/2020 00:00	9.9	13.9	8.3	89.5	2,529,131.2	1,292.8	1.2	0.6
07/15/2020 01:00	10.0	13.9	8.4	88.5	2,556,258.8	1,288.0	1.1	0.5
07/15/2020 02:00	9.9	13.9	8.3	88.3	2,563,403.7	1,291.6	1.1	0.5
07/15/2020 03:00	9.9	14.0	8.5	88.2	2,566,380.7	1,293.1	1.1	0.5
07/15/2020 04:00	9.9	14.0	8.5	88.3	2,567,770.0	1,293.8	1.1	0.5
07/15/2020 05:00	9.8	13.9	8.3	88.6	2,580,973.7	1,319.3	1.1	0.5
07/15/2020 06:00	10.0	13.9	8.4	88.9	2,552,998.3	1,305.0	1.1	0.5
07/15/2020 07:00	10.1	14.0	8.6	88.6	2,558,640.5	1,289.2	1.1	0.5
07/15/2020 08:00	10.2	14.0	8.7	88.8	2,561,617.5	1,290.7	1.1	0.5
07/15/2020 09:00	10.3	13.9	8.7	89.0	2,568,166.9	1,294.0	1.1	0.5
07/15/2020 10:00	10.2	13.9	8.6	88.9	2,570,151.6	1,295.0	1.1	0.5
07/15/2020 11:00	10.2	13.9	8.6	88.8	2,575,113.2	1,297.5	1.1	0.5
07/15/2020 12:00	10.1	13.9	8.5	88.8	2,572,136.2	1,296.0	1.1	0.5
07/15/2020 13:00	10.1	13.9	8.5	88.8	2,579,082.6	1,299.5	1.1	0.5
07/15/2020 14:00	10.0	14.0	8.6	88.7	2,594,761.5	1,307.4	1.1	0.5
07/15/2020 15:00	10.1	14.0	8.6	88.7	2,585,235.1	1,302.6	1.1	0.5
07/15/2020 16:00	10.0	14.0	8.6	88.7	2,595,753.8	1,307.9	1.1	0.5
07/15/2020 17:00	10.1	13.9	8.5	88.7	2,596,746.2	1,308.4	1.1	0.5
07/15/2020 18:00	9.9	13.9	8.3	96.1	2,723,198.2	1,392.0	1.2	0.7
07/15/2020 19:00	9.6	13.9	8.1	98.6	2,861,705.7	1,462.8	1.1	0.6
07/15/2020 20:00	9.9	14.0	8.5	105.1	2,696,773.7	1,358.8	1.3	0.7
07/15/2020 21:00	10.1	13.9	8.5	88.9	2,557,648.1	1,288.7	1.1	0.5
07/15/2020 22:00	10.3	13.9	8.7	88.9	2,514,067.5	1,285.1	1.2	0.6
07/15/2020 23:00	9.9	13.9	8.3	89.1	2,626,516.3	1,323.4	1.1	0.5
Average/Sum#:	10.0	13.9	8.5	90.1	2,593,926.3	1,311.8	1.1	0.5
Minimum:	9.6	13.9	8.1	88.2	2,514,067.5	1,285.1	1.1	0.5
Maximum:	10.3	14.0	8.7	105.1	2,861,705.7	1,462.8	1.3	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/16/2020 00:00	9.9	14.0	8.5	88.3	2,557,846.6	1,288.8	1.1	0.5
07/16/2020 01:00	9.9	13.9	8.3	88.3	2,556,655.8	1,288.2	1.1	0.5
07/16/2020 02:00	9.9	13.9	8.3	88.4	2,553,281.8	1,286.5	1.1	0.5
07/16/2020 03:00	9.9	13.9	8.3	88.3	2,516,415.1	1,286.3	1.1	0.5
07/16/2020 04:00	9.9	13.9	8.3	88.3	2,517,980.2	1,287.1	1.1	0.5
07/16/2020 05:00	9.9	13.9	8.3	87.7	2,517,784.5	1,287.0	1.1	0.5
07/16/2020 06:00	10.1	13.9	8.5	88.8	2,555,861.9	1,287.8	1.1	0.5
07/16/2020 07:00	10.0	13.9	8.4	88.6	2,556,457.3	1,288.1	1.1	0.5
07/16/2020 08:00	10.0	14.0	8.6	88.6	2,562,411.3	1,291.1	1.1	0.5
07/16/2020 09:00	10.0	14.0	8.6	88.5	2,567,968.4	1,293.9	1.1	0.5
07/16/2020 10:00	9.9	14.0	8.5	88.3	2,577,296.4	1,298.6	1.1	0.5
07/16/2020 11:00	9.9	14.0	8.5	88.3	2,574,120.9	1,297.0	1.1	0.5
07/16/2020 12:00	10.0	14.0	8.6	88.4	2,570,151.6	1,295.0	1.1	0.5
07/16/2020 13:00	9.9	14.0	8.5	88.3	2,574,716.3	1,297.3	1.1	0.5
07/16/2020 14:00	9.6	13.9	8.1	98.2	2,863,466.4	1,463.7	1.1	0.6
07/16/2020 15:00	10.0	13.9	8.4	118.4	2,942,306.1	1,504.0	1.3	0.8
07/16/2020 16:00	11.6	13.2	8.9	169.7	3,146,176.4	2,067.7	1.8	1.4
07/16/2020 17:00	11.5	13.2	8.8	183.9	3,137,470.3	2,107.8	2.0	1.7
07/16/2020 18:00	11.4	13.2	8.7	181.0	3,152,083.9	2,094.6	2.0	1.7
07/16/2020 19:00	11.3	13.2	8.7	186.8	3,168,877.8	2,128.9	2.0	1.7
07/16/2020 20:00	11.2	13.2	8.6	187.3	3,165,007.7	2,126.3	2.1	1.7
07/16/2020 21:00	11.1	13.3	8.6	181.4	3,212,973.9	2,111.6	1.9	1.5
07/16/2020 22:00	10.9	13.4	8.6	157.8	3,258,075.1	1,974.7	1.6	1.2
07/16/2020 23:00	10.4	13.5	8.3	145.9	3,141,424.4	1,789.3	1.6	1.1
Average/Sum#:	10.3	13.7	8.5	118.6	2,789,450.4	1,560.1	1.4	0.9
Minimum:	9.6	13.2	8.1	87.7	2,516,415.1	1,286.3	1.1	0.5
Maximum:	11.6	14.0	8.9	187.3	3,258,075.1	2,128.9	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/17/2020 00:00	9.7	13.9	8.2	88.9	2,528,935.6	1,292.7	1.2	0.6
07/17/2020 01:00	9.7	13.9	8.2	87.8	2,538,912.8	1,297.8	1.1	0.5
07/17/2020 02:00	9.7	14.0	8.3	87.8	2,566,579.1	1,293.2	1.1	0.5
07/17/2020 03:00	9.6	13.9	8.1	87.8	2,581,861.1	1,300.9	1.1	0.5
07/17/2020 04:00	9.7	13.9	8.2	87.9	2,576,105.6	1,298.0	1.1	0.5
07/17/2020 05:00	9.7	13.9	8.2	88.8	2,552,215.8	1,304.6	1.1	0.5
07/17/2020 06:00	9.9	13.9	8.3	88.5	2,551,824.5	1,304.4	1.1	0.5
07/17/2020 07:00	9.8	14.0	8.4	88.2	2,577,296.4	1,298.6	1.1	0.5
07/17/2020 08:00	9.8	14.0	8.4	88.0	2,580,868.8	1,300.4	1.1	0.5
07/17/2020 09:00	9.7	14.0	8.3	88.0	2,605,478.7	1,312.8	1.1	0.5
07/17/2020 10:00	9.9	14.0	8.5	88.3	2,590,593.7	1,305.3	1.1	0.5
07/17/2020 11:00	9.9	13.9	8.3	88.3	2,596,349.2	1,308.2	1.1	0.5
07/17/2020 12:00	9.9	13.9	8.3	88.5	2,615,600.6	1,317.9	1.1	0.5
07/17/2020 13:00	9.8	14.0	8.4	88.2	2,635,447.3	1,327.9	1.1	0.5
07/17/2020 14:00	9.9	14.0	8.5	88.4	2,581,265.7	1,300.6	1.1	0.5
07/17/2020 15:00	10.0	13.9	8.4	88.6	2,586,822.8	1,303.4	1.1	0.5
07/17/2020 16:00	10.0	13.9	8.4	114.7	2,945,045.0	1,505.4	1.3	0.8
07/17/2020 17:00	11.6	13.2	8.9	170.0	3,187,066.0	2,071.3	1.8	1.4
07/17/2020 18:00	11.5	13.2	8.8	184.7	3,171,948.0	2,107.8	2.0	1.7
07/17/2020 19:00	11.4	13.2	8.7	185.7	3,189,855.9	2,119.7	2.0	1.7
07/17/2020 20:00	11.4	13.3	8.9	190.9	3,195,273.4	2,123.3	2.1	1.7
07/17/2020 21:00	11.3	13.3	8.8	184.9	3,208,104.9	2,108.4	2.0	1.7
07/17/2020 22:00	11.1	13.4	8.7	167.2	3,276,224.1	1,985.7	1.7	1.4
07/17/2020 23:00	10.7	13.5	8.5	157.4	3,233,575.0	1,865.4	1.7	1.3
Average/Sum#:	10.2	13.8	8.4	115.3	2,778,052.1	1,531.4	1.3	0.8
Minimum:	9.6	13.2	8.1	87.8	2,528,935.6	1,292.7	1.1	0.5
Maximum:	11.6	14.0	8.9	190.9	3,276,224.1	2,123.3	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/18/2020 00:00	9.9	13.7	8.1	131.0	3,342,726.9	1,757.5	1.3	0.9
07/18/2020 01:00	9.4	13.8	7.8	107.6	3,084,290.9	1,599.1	1.2	0.8
07/18/2020 02:00	9.6	13.9	8.1	88.4	2,559,649.8	1,308.4	1.1	0.5
07/18/2020 03:00	9.7	13.9	8.2	88.0	2,562,779.9	1,310.0	1.1	0.5
07/18/2020 04:00	9.6	13.9	8.1	87.8	2,582,147.5	1,319.9	1.1	0.5
07/18/2020 05:00	9.3	13.9	7.8	89.2	2,652,183.8	1,355.7	1.1	0.5
07/18/2020 06:00	9.8	14.0	8.4	87.9	2,532,261.3	1,294.4	1.1	0.5
07/18/2020 07:00	9.8	14.0	8.4	88.1	2,569,556.2	1,294.7	1.1	0.5
07/18/2020 08:00	9.8	14.0	8.4	88.0	2,569,357.7	1,294.6	1.1	0.5
07/18/2020 09:00	9.8	14.0	8.4	88.1	2,582,258.1	1,301.1	1.1	0.5
07/18/2020 10:00	9.9	14.0	8.5	88.4	2,582,853.5	1,301.4	1.1	0.5
07/18/2020 11:00	9.6	14.0	8.2	91.0	2,764,054.1	1,392.7	1.1	0.6
07/18/2020 12:00	9.6	14.0	8.2	91.7	2,753,129.9	1,407.3	1.1	0.6
07/18/2020 13:00	9.6	13.9	8.1	101.0	3,105,072.0	1,587.2	1.1	0.6
07/18/2020 14:00	11.5	13.3	8.9	126.6	3,234,097.1	2,007.4	1.3	1.0
07/18/2020 15:00	9.8	13.8	8.1	101.4	2,805,099.3	1,515.8	1.2	0.8
07/18/2020 16:00	9.7	13.8	8.1	101.3	3,128,743.5	1,599.3	1.1	0.6
07/18/2020 17:00	11.3	13.3	8.8	133.2	3,191,374.3	2,074.1	1.4	1.0
07/18/2020 18:00	11.3	13.2	8.7	140.4	3,132,048.4	2,149.9	1.5	1.3
07/18/2020 19:00	11.3	13.2	8.7	177.3	3,139,153.1	2,177.7	2.0	1.7
07/18/2020 20:00	11.2	13.2	8.6	199.7	3,142,313.6	2,134.0	2.2	1.7
07/18/2020 21:00	11.2	13.3	8.7	180.9	3,195,535.9	2,006.8	2.0	1.6
07/18/2020 22:00	11.1	13.3	8.6	173.5	3,207,514.1	1,990.9	1.9	1.4
07/18/2020 23:00	10.9	13.4	8.6	177.0	3,157,453.1	1,867.6	1.9	1.3
Average/Sum#:	10.2	13.7	8.4	117.8	2,898,985.6	1,627.0	1.3	0.9
Minimum:	9.3	13.2	7.8	87.8	2,532,261.3	1,294.4	1.1	0.5
Maximum:	11.5	14.0	8.9	199.7	3,342,726.9	2,177.7	2.2	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/19/2020 00:00	10.8	13.6	8.7	165.0	3,299,937.6	1,759.1	1.7	1.2
07/19/2020 01:00	9.9	13.9	8.3	95.1	2,569,822.7	1,313.6	1.2	0.7
07/19/2020 02:00	10.1	13.9	8.5	90.8	2,522,088.5	1,289.2	1.2	0.6
07/19/2020 03:00	10.0	13.9	8.4	90.6	2,530,500.6	1,293.5	1.2	0.6
07/19/2020 04:00	9.9	13.9	8.3	90.4	2,523,262.2	1,289.8	1.2	0.6
07/19/2020 05:00	9.9	14.0	8.5	87.8	2,525,022.9	1,290.7	1.1	0.5
07/19/2020 06:00	10.1	13.9	8.5	90.5	2,521,892.8	1,289.1	1.2	0.6
07/19/2020 07:00	10.0	14.0	8.6	90.5	2,564,991.4	1,292.4	1.2	0.6
07/19/2020 08:00	10.0	14.0	8.6	90.5	2,581,265.7	1,300.6	1.1	0.5
07/19/2020 09:00	10.1	14.0	8.6	90.7	2,581,464.2	1,300.7	1.1	0.5
07/19/2020 10:00	10.1	14.0	8.6	90.8	2,582,853.5	1,301.4	1.1	0.5
07/19/2020 11:00	10.1	14.0	8.6	90.7	2,581,464.2	1,300.7	1.1	0.5
07/19/2020 12:00	10.1	14.0	8.6	90.7	2,582,655.0	1,301.3	1.1	0.5
07/19/2020 13:00	10.1	13.9	8.5	90.8	2,588,013.6	1,304.0	1.1	0.5
07/19/2020 14:00	10.0	14.0	8.6	90.7	2,597,937.0	1,309.0	1.1	0.5
07/19/2020 15:00	10.0	14.0	8.6	90.6	2,593,570.7	1,306.8	1.1	0.5
07/19/2020 16:00	10.1	13.8	8.4	123.6	2,931,350.7	1,498.4	1.4	0.7
07/19/2020 17:00	11.6	13.2	8.9	178.9	3,151,676.4	2,048.3	2.0	1.6
07/19/2020 18:00	11.5	13.2	8.8	198.7	3,136,718.1	2,130.2	2.2	1.7
07/19/2020 19:00	11.3	13.2	8.7	197.7	3,162,477.2	2,124.6	2.2	1.7
07/19/2020 20:00	11.2	13.2	8.6	193.1	3,176,011.2	2,110.5	2.1	1.7
07/19/2020 21:00	11.1	13.3	8.6	189.1	3,218,608.9	2,091.8	2.0	1.7
07/19/2020 22:00	11.0	13.4	8.7	171.7	3,250,815.5	1,970.3	1.8	1.4
07/19/2020 23:00	10.5	13.5	8.4	155.0	3,137,035.2	1,786.8	1.7	1.3
Average/Sum#:	10.4	13.7	8.6	122.3	2,787,976.5	1,541.8	1.4	0.9
Minimum:	9.9	13.2	8.3	87.8	2,521,892.8	1,289.1	1.1	0.5
Maximum:	11.6	14.0	8.9	198.7	3,299,937.6	2,130.2	2.2	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/20/2020 00:00	9.9	13.9	8.3	90.9	2,527,370.5	1,291.9	1.2	0.6
07/20/2020 01:00	9.9	13.9	8.3	90.0	2,513,676.3	1,284.9	1.2	0.6
07/20/2020 02:00	9.8	13.9	8.3	89.8	2,510,937.4	1,283.5	1.2	0.6
07/20/2020 03:00	9.8	13.9	8.3	89.9	2,510,154.9	1,283.1	1.2	0.6
07/20/2020 04:00	9.8	13.9	8.3	89.8	2,513,285.0	1,284.7	1.2	0.6
07/20/2020 05:00	9.8	13.9	8.3	89.6	2,543,608.0	1,300.2	1.2	0.7
07/20/2020 06:00	9.1	13.9	7.7	108.2	3,250,426.6	1,661.5	1.1	0.7
07/20/2020 07:00	9.1	13.9	7.7	107.2	3,196,823.4	1,634.1	1.1	0.7
07/20/2020 08:00	9.0	13.9	7.6	110.4	3,280,162.7	1,676.7	1.1	0.7
07/20/2020 09:00	9.3	13.9	7.8	91.8	2,709,699.6	1,385.1	1.1	0.6
07/20/2020 10:00	9.3	13.9	7.8	104.4	2,994,735.5	1,530.8	1.2	0.8
07/20/2020 11:00	9.3	13.9	7.8	105.5	3,019,189.5	1,543.3	1.2	0.8
07/20/2020 12:00	10.0	13.8	8.3	127.7	2,938,861.9	1,523.7	1.5	0.9
07/20/2020 13:00	11.5	13.3	8.9	169.7	3,193,906.9	2,029.1	1.8	1.4
07/20/2020 14:00	11.2	13.3	8.7	174.2	3,183,274.8	1,999.1	1.9	1.4
07/20/2020 15:00	11.3	13.3	8.8	187.9	3,152,871.4	2,072.1	2.1	1.7
07/20/2020 16:00	11.2	13.3	8.7	189.4	3,159,262.1	2,076.3	2.1	1.7
07/20/2020 17:00	11.2	13.2	8.6	189.4	3,136,884.8	2,084.5	2.1	1.7
07/20/2020 18:00	11.2	13.2	8.6	195.5	3,128,913.8	2,124.9	2.2	1.7
07/20/2020 19:00	11.1	13.2	8.5	196.3	3,158,756.0	2,122.1	2.2	1.7
07/20/2020 20:00	11.1	13.3	8.6	194.4	3,175,559.7	2,110.2	2.1	1.7
07/20/2020 21:00	11.1	13.3	8.6	192.5	3,215,069.9	2,089.5	2.1	1.7
07/20/2020 22:00	11.0	13.3	8.5	173.7	3,228,458.3	2,003.9	1.8	1.4
07/20/2020 23:00	10.1	13.5	8.1	143.3	3,081,204.9	1,777.5	1.6	1.1
Average/Sum#:	10.3	13.6	8.3	137.6	2,971,795.6	1,715.5	1.6	1.1
Minimum:	9.0	13.2	7.6	89.6	2,510,154.9	1,283.1	1.1	0.6
Maximum:	11.5	13.9	8.9	196.3	3,280,162.7	2,124.9	2.2	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/21/2020 00:00	9.4	13.9	7.9	91.6	2,512,306.8	1,284.2	1.2	0.6
07/21/2020 01:00	9.7	13.9	8.2	91.0	2,514,263.2	1,285.2	1.2	0.6
07/21/2020 02:00	9.8	13.9	8.3	91.0	2,513,871.9	1,285.0	1.2	0.6
07/21/2020 03:00	9.8	13.9	8.3	91.1	2,510,154.9	1,283.1	1.2	0.6
07/21/2020 04:00	9.8	13.9	8.3	91.2	2,511,133.1	1,283.6	1.2	0.6
07/21/2020 05:00	9.9	13.9	8.3	90.4	2,535,391.4	1,296.0	1.2	0.6
07/21/2020 06:00	9.2	13.9	7.8	111.9	3,233,211.0	1,652.7	1.1	0.7
07/21/2020 07:00	9.3	13.9	7.8	104.0	2,992,974.8	1,529.9	1.2	0.8
07/21/2020 08:00	9.3	13.9	7.8	104.4	2,986,518.9	1,526.6	1.2	0.8
07/21/2020 09:00	9.5	13.9	8.0	92.6	2,682,311.1	1,371.1	1.1	0.5
07/21/2020 10:00	9.4	13.9	7.9	103.8	2,948,957.6	1,507.4	1.2	0.8
07/21/2020 11:00	9.5	13.9	8.0	92.4	2,679,376.6	1,369.6	1.1	0.5
07/21/2020 12:00	9.7	13.9	8.2	100.4	2,705,982.6	1,383.2	1.2	0.7
07/21/2020 13:00	10.7	13.5	8.5	154.4	3,098,836.2	1,810.3	1.7	1.3
07/21/2020 14:00	11.4	13.3	8.9	190.0	3,128,006.1	2,078.6	2.1	1.7
07/21/2020 15:00	11.4	13.2	8.7	197.4	3,111,421.5	2,090.3	2.2	1.7
07/21/2020 16:00	11.5	13.2	8.8	203.4	3,125,968.8	2,122.9	2.3	1.9
07/21/2020 17:00	11.4	13.2	8.7	207.3	3,149,093.3	2,161.6	2.3	1.9
07/21/2020 18:00	11.2	13.2	8.6	202.6	3,136,418.9	2,152.9	2.3	1.9
07/21/2020 19:00	11.2	13.2	8.6	198.1	3,160,691.0	2,123.4	2.2	1.7
07/21/2020 20:00	11.2	13.3	8.7	199.0	3,191,360.8	2,120.7	2.2	1.7
07/21/2020 21:00	11.1	13.3	8.6	191.2	3,218,762.8	2,091.9	2.1	1.7
07/21/2020 22:00	10.9	13.4	8.6	176.6	3,235,917.2	1,984.9	1.9	1.4
07/21/2020 23:00	10.3	13.5	8.2	148.3	3,187,118.6	1,838.6	1.6	1.1
Average/Sum#:	10.3	13.6	8.3	138.5	2,919,585.4	1,693.1	1.6	1.1
Minimum:	9.2	13.2	7.8	90.4	2,510,154.9	1,283.1	1.1	0.5
Maximum:	11.5	13.9	8.9	207.3	3,235,917.2	2,161.6	2.3	1.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/22/2020 00:00	9.5	13.8	7.9	104.6	2,727,110.8	1,394.0	1.3	0.7
07/22/2020 01:00	9.5	13.9	8.0	91.0	2,510,937.4	1,283.5	1.2	0.6
07/22/2020 02:00	9.7	13.9	8.2	91.0	2,511,915.6	1,284.0	1.2	0.6
07/22/2020 03:00	9.7	13.9	8.2	91.1	2,511,915.6	1,284.0	1.2	0.6
07/22/2020 04:00	9.8	13.9	8.3	91.5	2,538,130.3	1,297.4	1.2	0.6
07/22/2020 05:00	9.3	13.9	7.8	93.6	2,694,831.6	1,377.5	1.1	0.6
07/22/2020 06:00	9.2	13.9	7.8	111.8	3,204,453.1	1,661.4	1.2	0.8
07/22/2020 07:00	9.4	13.9	7.9	92.0	2,661,378.5	1,360.4	1.1	0.5
07/22/2020 08:00	9.8	13.9	8.3	91.3	2,537,543.4	1,297.1	1.2	0.6
07/22/2020 09:00	9.8	13.9	8.3	91.2	2,542,042.9	1,299.4	1.2	0.6
07/22/2020 10:00	9.8	14.0	8.4	91.3	2,545,368.7	1,301.1	1.2	0.7
07/22/2020 11:00	9.9	14.0	8.5	91.4	2,583,051.9	1,301.5	1.2	0.7
07/22/2020 12:00	9.9	14.0	8.5	91.5	2,568,166.9	1,294.0	1.2	0.6
07/22/2020 13:00	10.0	14.0	8.6	91.6	2,564,792.9	1,292.3	1.2	0.6
07/22/2020 14:00	10.0	14.0	8.6	91.6	2,566,579.1	1,293.2	1.2	0.6
07/22/2020 15:00	9.9	14.0	8.5	91.8	2,582,456.5	1,301.2	1.2	0.7
07/22/2020 16:00	9.6	13.9	8.1	121.6	3,187,433.1	1,629.3	1.3	0.8
07/22/2020 17:00	11.6	13.3	9.0	187.6	3,186,245.9	2,047.5	2.0	1.6
07/22/2020 18:00	11.5	13.3	8.9	197.3	3,198,975.4	2,102.4	2.1	1.7
07/22/2020 19:00	11.4	13.3	8.9	194.1	3,191,976.1	2,097.8	2.1	1.7
07/22/2020 20:00	11.2	13.3	8.7	191.1	3,228,456.5	2,098.2	2.0	1.7
07/22/2020 21:00	11.3	13.3	8.8	194.7	3,219,993.7	2,092.7	2.1	1.7
07/22/2020 22:00	11.1	13.4	8.7	175.7	3,251,970.4	1,971.0	1.9	1.4
07/22/2020 23:00	10.5	13.5	8.4	155.0	3,121,936.5	1,778.2	1.7	1.2
Average/Sum#:	10.1	13.8	8.4	121.5	2,809,902.6	1,547.5	1.4	0.9
Minimum:	9.2	13.3	7.8	91.0	2,510,937.4	1,283.5	1.1	0.5
Maximum:	11.6	14.0	9.0	197.3	3,251,970.4	2,102.4	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/23/2020 00:00	9.7	13.9	8.2	92.1	2,521,110.3	1,288.7	1.2	0.6
07/23/2020 01:00	9.8	13.9	8.3	90.8	2,511,328.7	1,283.7	1.2	0.6
07/23/2020 02:00	9.9	13.9	8.3	90.9	2,509,176.7	1,282.6	1.2	0.6
07/23/2020 03:00	9.9	13.9	8.3	90.9	2,508,198.6	1,282.1	1.2	0.6
07/23/2020 04:00	9.9	13.9	8.3	91.0	2,510,154.9	1,283.1	1.2	0.6
07/23/2020 05:00	9.9	13.9	8.3	89.0	2,518,762.7	1,287.5	1.2	0.6
07/23/2020 06:00	10.1	13.9	8.5	91.2	2,529,522.5	1,293.0	1.2	0.6
07/23/2020 07:00	10.0	13.9	8.4	91.3	2,535,391.4	1,296.0	1.2	0.6
07/23/2020 08:00	10.0	13.9	8.4	91.3	2,540,086.6	1,298.4	1.2	0.6
07/23/2020 09:00	9.9	14.0	8.5	91.2	2,538,325.9	1,297.5	1.2	0.6
07/23/2020 10:00	10.0	14.0	8.6	91.2	2,540,282.2	1,298.5	1.2	0.6
07/23/2020 11:00	10.1	14.0	8.6	91.4	2,520,914.7	1,288.6	1.2	0.6
07/23/2020 12:00	10.0	14.0	8.6	91.2	2,573,922.4	1,296.9	1.2	0.6
07/23/2020 13:00	10.1	14.0	8.6	91.3	2,557,052.7	1,288.4	1.2	0.6
07/23/2020 14:00	10.0	14.0	8.6	91.2	2,565,189.9	1,292.5	1.2	0.6
07/23/2020 15:00	9.8	14.0	8.4	91.1	2,571,342.4	1,295.6	1.2	0.6
07/23/2020 16:00	9.9	14.0	8.5	91.1	2,567,968.4	1,293.9	1.2	0.6
07/23/2020 17:00	9.7	13.9	8.2	100.1	2,756,455.7	1,409.0	1.2	0.7
07/23/2020 18:00	9.5	13.8	7.9	120.6	3,140,803.8	1,628.4	1.3	0.8
07/23/2020 19:00	9.4	13.8	7.8	115.9	3,109,557.7	1,612.2	1.2	0.8
07/23/2020 20:00	9.7	13.8	8.1	103.3	2,760,643.8	1,431.3	1.2	0.7
07/23/2020 21:00	9.8	14.0	8.4	92.0	2,614,818.0	1,336.6	1.2	0.7
07/23/2020 22:00	9.9	13.9	8.3	91.8	2,519,936.5	1,288.1	1.2	0.6
07/23/2020 23:00	9.7	13.9	8.2	91.2	2,593,885.4	1,325.9	1.2	0.7
Average/Sum#:	9.9	13.9	8.3	94.3	2,608,951.3	1,332.4	1.2	0.6
Minimum:	9.4	13.8	7.8	89.0	2,508,198.6	1,282.1	1.2	0.6
Maximum:	10.1	14.0	8.6	120.6	3,140,803.8	1,628.4	1.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/24/2020 00:00	9.8	13.9	8.3	90.8	2,511,133.1	1,283.6	1.2	0.6
07/24/2020 01:00	9.8	14.0	8.4	90.8	2,514,067.5	1,285.1	1.2	0.6
07/24/2020 02:00	9.8	14.0	8.4	90.8	2,506,829.2	1,281.4	1.2	0.6
07/24/2020 03:00	9.8	13.9	8.3	90.7	2,507,807.3	1,281.9	1.2	0.6
07/24/2020 04:00	9.7	13.9	8.2	90.6	2,517,980.2	1,287.1	1.2	0.6
07/24/2020 05:00	9.7	13.9	8.2	89.2	2,528,348.7	1,292.4	1.2	0.6
07/24/2020 06:00	9.6	13.9	8.1	90.6	2,589,777.1	1,323.8	1.2	0.7
07/24/2020 07:00	10.4	13.8	8.6	145.4	3,000,389.5	1,555.6	1.6	0.9
07/24/2020 08:00	9.7	13.8	8.1	123.5	2,839,723.3	1,472.3	1.5	0.9
07/24/2020 09:00	9.3	13.9	7.8	90.7	2,691,310.2	1,375.7	1.1	0.6
07/24/2020 10:00	9.4	13.9	7.9	91.2	2,700,896.1	1,380.6	1.1	0.6
07/24/2020 11:00	9.3	14.0	8.0	93.0	2,715,959.8	1,388.3	1.1	0.6
07/24/2020 12:00	9.3	14.0	8.0	93.9	2,721,241.9	1,391.0	1.1	0.6
07/24/2020 13:00	9.3	14.0	8.0	94.2	2,726,719.6	1,393.8	1.1	0.6
07/24/2020 14:00	9.3	14.0	8.0	95.8	2,732,001.6	1,396.5	1.2	0.7
07/24/2020 15:00	9.3	14.0	8.0	96.5	2,771,595.9	1,396.5	1.2	0.7
07/24/2020 16:00	9.5	14.0	8.1	99.9	2,774,845.1	1,418.4	1.2	0.7
07/24/2020 17:00	11.8	13.3	9.2	205.0	3,181,955.4	1,951.8	2.2	1.6
07/24/2020 18:00	11.8	13.3	9.2	200.3	3,182,058.9	1,975.1	2.2	1.6
07/24/2020 19:00	11.8	13.3	9.2	198.0	3,211,300.2	1,969.8	2.1	1.6
07/24/2020 20:00	11.7	13.3	9.1	199.5	3,146,741.6	1,930.2	2.2	1.5
07/24/2020 21:00	9.2	13.9	7.8	94.7	2,714,394.8	1,387.5	1.2	0.7
07/24/2020 22:00	9.1	13.9	7.7	90.1	2,686,810.6	1,373.4	1.1	0.5
07/24/2020 23:00	9.1	13.9	7.7	90.0	2,686,223.7	1,373.1	1.1	0.5
Average/Sum#:	9.9	13.8	8.3	114.0	2,756,671.3	1,465.2	1.4	0.8
Minimum:	9.1	13.3	7.7	89.2	2,506,829.2	1,281.4	1.1	0.5
Maximum:	11.8	14.0	9.2	205.0	3,211,300.2	1,975.1	2.2	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/25/2020 00:00	9.1	13.9	7.7	89.8	2,689,353.9	1,374.7	1.1	0.5
07/25/2020 01:00	9.0	13.9	7.6	89.8	2,694,244.7	1,377.2	1.1	0.6
07/25/2020 02:00	9.0	13.9	7.6	89.9	2,692,484.0	1,376.3	1.1	0.6
07/25/2020 03:00	9.0	13.9	7.6	89.8	2,688,375.7	1,374.2	1.1	0.5
07/25/2020 04:00	9.0	13.9	7.6	89.8	2,687,006.3	1,373.5	1.1	0.5
07/25/2020 05:00	9.0	13.9	7.6	88.2	2,687,788.8	1,373.9	1.1	0.5
07/25/2020 06:00	9.2	13.9	7.8	90.3	2,697,374.8	1,378.8	1.1	0.6
07/25/2020 07:00	9.1	13.9	7.7	90.6	2,713,221.0	1,386.9	1.1	0.6
07/25/2020 08:00	9.1	13.9	7.7	90.6	2,719,481.2	1,390.1	1.1	0.6
07/25/2020 09:00	9.3	13.9	7.8	92.6	2,719,872.5	1,390.3	1.1	0.6
07/25/2020 10:00	9.4	14.0	8.0	94.7	2,726,719.6	1,393.8	1.1	0.6
07/25/2020 11:00	9.4	14.0	8.0	95.2	2,725,937.1	1,393.4	1.2	0.7
07/25/2020 12:00	9.3	14.0	8.0	95.7	2,727,306.5	1,394.1	1.2	0.7
07/25/2020 13:00	9.3	13.9	7.8	115.3	3,025,449.7	1,546.5	1.3	0.8
07/25/2020 14:00	9.5	13.9	8.0	102.1	2,924,112.3	1,494.7	1.2	0.7
07/25/2020 15:00	9.4	13.9	7.9	109.6	3,042,274.1	1,555.1	1.2	0.8
07/25/2020 16:00	10.3	13.9	8.7	133.2	3,019,580.8	1,543.5	1.5	0.9
07/25/2020 17:00	11.5	13.3	8.9	174.1	3,190,292.0	2,050.1	1.9	1.4
07/25/2020 18:00	11.4	13.2	8.7	194.6	3,160,244.5	2,123.1	2.1	1.7
07/25/2020 19:00	11.2	13.2	8.6	196.5	3,167,984.7	2,128.3	2.2	1.7
07/25/2020 20:00	11.3	13.3	8.8	199.6	3,195,875.3	2,123.7	2.2	1.7
07/25/2020 21:00	11.3	13.3	8.8	195.7	3,202,322.8	2,104.6	2.1	1.7
07/25/2020 22:00	11.0	13.3	8.5	182.6	3,216,258.4	2,043.3	2.0	1.6
07/25/2020 23:00	11.0	13.3	8.5	194.2	3,164,601.3	2,056.7	2.1	1.6
Average/Sum#:	9.8	13.7	8.1	124.4	2,894,923.4	1,614.5	1.4	0.9
Minimum:	9.0	13.2	7.6	88.2	2,687,006.3	1,373.5	1.1	0.5
Maximum:	11.5	14.0	8.9	199.6	3,216,258.4	2,128.3	2.2	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/26/2020 00:00	8.9	13.9	7.5	97.4	2,830,013.3	1,446.6	1.1	0.6
07/26/2020 01:00	9.1	13.9	7.7	113.5	3,131,677.9	1,600.8	1.2	0.8
07/26/2020 02:00	9.0	13.9	7.6	101.5	3,023,884.7	1,545.7	1.1	0.6
07/26/2020 03:00	9.1	13.9	7.7	99.8	2,939,371.6	1,502.5	1.1	0.6
07/26/2020 04:00	9.1	13.9	7.7	102.1	2,999,039.4	1,533.0	1.1	0.6
07/26/2020 05:00	9.2	13.9	7.8	95.6	2,762,520.2	1,412.1	1.1	0.6
07/26/2020 06:00	9.9	14.0	8.5	91.1	2,511,915.6	1,284.0	1.2	0.6
07/26/2020 07:00	10.0	14.0	8.6	91.2	2,513,089.4	1,284.6	1.2	0.6
07/26/2020 08:00	10.0	14.0	8.6	91.3	2,515,828.2	1,286.0	1.2	0.6
07/26/2020 09:00	10.0	14.0	8.6	91.2	2,523,653.5	1,290.0	1.2	0.6
07/26/2020 10:00	9.8	14.0	8.4	97.0	2,700,113.6	1,380.2	1.2	0.7
07/26/2020 11:00	9.4	13.9	7.9	107.8	3,004,517.1	1,535.8	1.2	0.8
07/26/2020 12:00	9.5	13.9	8.0	109.3	3,031,514.3	1,549.6	1.2	0.8
07/26/2020 13:00	9.7	13.8	8.1	142.9	3,279,867.8	1,700.5	1.5	1.0
07/26/2020 14:00	11.5	13.3	8.9	182.7	3,165,393.3	2,034.1	2.0	1.6
07/26/2020 15:00	9.9	13.7	8.1	132.2	2,975,120.1	1,629.4	1.5	1.0
07/26/2020 16:00	10.7	13.5	8.5	162.8	3,065,114.1	1,790.6	1.8	1.3
07/26/2020 17:00	11.4	13.2	8.7	205.5	3,125,603.0	2,168.3	2.3	2.0
07/26/2020 18:00	11.3	13.2	8.7	211.5	3,121,134.4	2,165.2	2.4	1.9
07/26/2020 19:00	11.1	13.2	8.5	212.3	3,103,030.1	2,175.3	2.4	2.0
07/26/2020 20:00	11.2	13.2	8.6	203.0	3,138,632.3	2,131.5	2.3	1.9
07/26/2020 21:00	11.1	13.3	8.6	196.6	3,154,439.3	2,119.2	2.2	1.7
07/26/2020 22:00	11.0	13.3	8.5	174.2	3,203,969.7	1,988.7	1.9	1.4
07/26/2020 23:00	10.5	13.5	8.4	156.7	3,036,233.6	1,795.9	1.8	1.3
Average/Sum#:	10.1	13.7	8.3	136.2	2,952,319.9	1,681.2	1.6	1.1
Minimum:	8.9	13.2	7.5	91.1	2,511,915.6	1,284.0	1.1	0.6
Maximum:	11.5	14.0	8.9	212.3	3,279,867.8	2,175.3	2.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/27/2020 00:00	9.8	13.9	8.3	92.1	2,520,719.0	1,288.5	1.2	0.6
07/27/2020 01:00	10.0	13.9	8.4	91.3	2,513,285.0	1,284.7	1.2	0.6
07/27/2020 02:00	9.9	14.0	8.5	91.0	2,515,632.6	1,285.9	1.2	0.6
07/27/2020 03:00	9.8	14.0	8.4	90.8	2,520,523.4	1,288.4	1.2	0.6
07/27/2020 04:00	9.9	13.9	8.3	91.2	2,537,739.0	1,297.2	1.2	0.6
07/27/2020 05:00	9.1	13.9	7.7	125.8	3,173,592.8	1,645.4	1.3	0.8
07/27/2020 06:00	9.1	13.9	7.7	110.7	3,274,880.6	1,674.0	1.1	0.7
07/27/2020 07:00	9.2	13.9	7.8	113.7	3,290,335.5	1,681.9	1.1	0.7
07/27/2020 08:00	9.1	13.9	7.7	111.1	3,220,690.5	1,646.3	1.1	0.7
07/27/2020 09:00	9.4	14.0	8.0	91.3	2,632,229.3	1,345.5	1.1	0.5
07/27/2020 10:00	9.3	13.9	7.8	112.1	3,076,509.7	1,572.6	1.2	0.8
07/27/2020 11:00	9.8	13.9	8.3	125.3	2,979,944.6	1,545.0	1.4	0.8
07/27/2020 12:00	11.5	13.3	8.9	168.0	3,187,989.2	2,071.9	1.8	1.5
07/27/2020 13:00	11.4	13.2	8.7	191.3	3,118,062.8	2,140.3	2.1	1.7
07/27/2020 14:00	11.1	13.2	8.5	184.3	3,103,439.6	2,107.6	2.1	1.7
07/27/2020 15:00	11.2	13.2	8.6	194.9	3,098,935.3	2,149.8	2.2	1.7
07/27/2020 16:00	11.1	13.2	8.5	195.0	3,074,785.7	2,155.5	2.2	1.7
07/27/2020 17:00	11.1	13.2	8.5	199.6	3,082,916.6	2,161.2	2.3	1.9
07/27/2020 18:00	11.0	13.2	8.4	192.7	3,091,583.7	2,144.7	2.2	1.7
07/27/2020 19:00	11.2	13.2	8.6	192.6	3,104,077.2	2,130.7	2.2	1.7
07/27/2020 20:00	11.3	13.2	8.7	204.6	3,101,460.9	2,174.2	2.3	2.0
07/27/2020 21:00	11.1	13.2	8.5	191.9	3,109,467.5	2,134.4	2.1	1.7
07/27/2020 22:00	11.1	13.2	8.5	189.8	3,135,981.8	2,129.7	2.1	1.7
07/27/2020 23:00	10.8	13.3	8.4	165.9	3,125,153.8	1,962.6	1.8	1.4
Average/Sum#:	10.3	13.6	8.3	146.5	2,982,914.0	1,792.4	1.7	1.2
Minimum:	9.1	13.2	7.7	90.8	2,513,285.0	1,284.7	1.1	0.5
Maximum:	11.5	14.0	8.9	204.6	3,290,335.5	2,174.2	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/28/2020 00:00	9.2	13.8	7.6	103.1	2,981,487.6	1,545.8	1.2	0.8
07/28/2020 01:00	9.3	13.8	7.7	99.7	2,907,037.2	1,507.2	1.1	0.6
07/28/2020 02:00	9.2	13.9	7.8	93.1	2,753,700.3	1,427.7	1.1	0.6
07/28/2020 03:00	9.2	13.9	7.8	97.8	2,903,951.2	1,505.6	1.1	0.6
07/28/2020 04:00	9.1	13.9	7.7	100.2	2,972,808.2	1,541.3	1.1	0.6
07/28/2020 05:00	9.1	13.9	7.7	103.9	3,086,605.4	1,600.3	1.1	0.6
07/28/2020 06:00	9.2	13.9	7.8	109.5	3,259,808.7	1,690.1	1.1	0.7
07/28/2020 07:00	9.1	13.9	7.7	109.2	3,229,527.0	1,674.4	1.1	0.7
07/28/2020 08:00	9.3	13.9	7.8	100.0	2,940,790.6	1,524.7	1.1	0.6
07/28/2020 09:00	9.8	13.9	8.3	91.3	2,571,387.7	1,314.4	1.2	0.7
07/28/2020 10:00	9.4	13.9	7.9	101.1	2,973,411.6	1,519.9	1.1	0.6
07/28/2020 11:00	10.2	13.8	8.5	121.4	2,915,523.8	1,511.6	1.4	0.8
07/28/2020 12:00	11.4	13.3	8.9	172.6	3,185,219.6	2,070.1	1.9	1.4
07/28/2020 13:00	11.4	13.3	8.9	188.4	3,148,336.4	2,115.1	2.1	1.7
07/28/2020 14:00	11.3	13.2	8.7	191.1	3,093,588.0	2,123.5	2.1	1.7
07/28/2020 15:00	11.3	13.2	8.7	201.2	3,080,634.3	2,159.6	2.3	1.9
07/28/2020 16:00	11.1	13.2	8.5	201.5	3,084,771.1	2,162.5	2.3	1.9
07/28/2020 17:00	11.1	13.2	8.5	197.3	3,079,921.0	2,159.1	2.2	1.7
07/28/2020 18:00	11.1	13.2	8.5	199.8	3,086,625.5	2,163.8	2.3	1.9
07/28/2020 19:00	11.1	13.2	8.5	191.0	3,093,588.0	2,123.5	2.1	1.7
07/28/2020 20:00	11.1	13.3	8.6	196.5	3,191,354.2	2,144.0	2.1	1.7
07/28/2020 21:00	11.2	13.3	8.7	196.6	3,195,075.5	2,146.5	2.1	1.7
07/28/2020 22:00	11.2	13.3	8.7	194.6	3,189,103.5	2,119.2	2.1	1.7
07/28/2020 23:00	11.3	13.3	8.8	190.0	3,185,889.8	2,093.8	2.1	1.7
Average/Sum#:	10.3	13.6	8.3	148.0	3,046,256.1	1,831.0	1.6	1.2
Minimum:	9.1	13.2	7.6	91.3	2,571,387.7	1,314.4	1.1	0.6
Maximum:	11.4	13.9	8.9	201.5	3,259,808.7	2,163.8	2.3	1.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/29/2020 00:00	11.1	13.4	8.7	167.8	3,219,288.5	1,974.7	1.8	1.4
07/29/2020 01:00	11.0	13.4	8.7	163.7	3,251,213.9	1,946.8	1.7	1.4
07/29/2020 02:00	11.1	13.4	8.7	161.9	3,248,374.8	1,945.1	1.7	1.4
07/29/2020 03:00	10.9	13.4	8.6	159.1	3,265,910.2	1,955.6	1.7	1.4
07/29/2020 04:00	11.0	13.3	8.5	171.8	3,253,248.6	2,066.8	1.8	1.4
07/29/2020 05:00	11.1	13.3	8.6	160.0	3,244,913.3	2,085.2	1.7	1.5
07/29/2020 06:00	11.2	13.3	8.7	168.1	3,258,915.2	2,070.4	1.8	1.4
07/29/2020 07:00	11.0	13.4	8.7	160.5	3,266,411.2	1,955.9	1.7	1.4
07/29/2020 08:00	11.0	13.4	8.7	159.0	3,261,401.1	1,952.9	1.7	1.4
07/29/2020 09:00	11.2	13.4	8.8	162.4	3,249,330.6	1,969.4	1.7	1.4
07/29/2020 10:00	11.3	13.3	8.8	180.7	3,215,839.3	2,090.0	1.9	1.5
07/29/2020 11:00	11.0	13.3	8.5	179.3	3,171,045.1	2,107.2	2.0	1.7
07/29/2020 12:00	11.0	13.3	8.5	185.5	3,194,220.0	2,122.6	2.0	1.7
07/29/2020 13:00	11.0	13.3	8.5	184.0	3,147,145.6	2,114.3	2.0	1.7
07/29/2020 14:00	11.0	13.2	8.4	195.6	3,114,071.0	2,160.3	2.2	1.7
07/29/2020 15:00	11.1	13.2	8.5	199.2	3,101,033.0	2,173.9	2.2	1.7
07/29/2020 16:00	10.9	13.2	8.4	199.1	3,122,143.4	2,165.9	2.2	1.7
07/29/2020 17:00	11.0	13.2	8.4	200.3	3,119,548.7	2,164.1	2.2	1.7
07/29/2020 18:00	10.9	13.2	8.4	196.4	3,110,611.5	2,157.9	2.2	1.7
07/29/2020 19:00	11.0	13.2	8.4	200.2	3,137,135.0	2,176.3	2.2	1.7
07/29/2020 20:00	10.9	13.2	8.4	197.5	3,153,172.5	2,164.4	2.2	1.7
07/29/2020 21:00	11.0	13.3	8.5	183.3	3,179,923.8	2,113.1	2.0	1.7
07/29/2020 22:00	10.9	13.3	8.5	189.4	3,180,785.8	2,136.9	2.1	1.7
07/29/2020 23:00	10.9	13.3	8.5	183.3	3,181,579.2	2,114.2	2.0	1.7
Average/Sum#:	11.0	13.3	8.6	179.5	3,193,635.9	2,078.5	1.9	1.6
Minimum:	10.9	13.2	8.4	159.0	3,101,033.0	1,945.1	1.7	1.4
Maximum:	11.3	13.4	8.8	200.3	3,266,411.2	2,176.3	2.2	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/30/2020 00:00	10.8	13.3	8.4	173.9	3,207,068.8	2,084.3	1.9	1.5
07/30/2020 01:00	10.7	13.4	8.4	157.0	3,239,596.1	1,963.5	1.7	1.4
07/30/2020 02:00	10.9	13.4	8.6	155.3	3,252,549.9	1,947.6	1.6	1.2
07/30/2020 03:00	10.8	13.4	8.5	152.9	3,284,589.7	1,942.8	1.6	1.2
07/30/2020 04:00	10.9	13.4	8.6	155.0	3,303,525.0	1,954.0	1.6	1.2
07/30/2020 05:00	11.1	13.3	8.6	174.7	3,236,821.3	2,080.0	1.9	1.5
07/30/2020 06:00	11.1	13.3	8.6	167.0	3,251,832.0	2,065.9	1.8	1.4
07/30/2020 07:00	10.9	13.4	8.6	155.6	3,258,395.0	1,951.1	1.6	1.2
07/30/2020 08:00	10.9	13.4	8.6	156.0	3,252,382.9	1,947.5	1.6	1.2
07/30/2020 09:00	11.0	13.4	8.7	156.8	3,243,885.9	1,966.1	1.6	1.2
07/30/2020 10:00	11.1	13.3	8.6	178.1	3,211,838.7	2,087.4	1.9	1.5
07/30/2020 11:00	11.1	13.3	8.6	185.8	3,192,564.6	2,121.5	2.0	1.7
07/30/2020 12:00	10.9	13.3	8.5	182.2	3,210,691.5	2,110.1	2.0	1.7
07/30/2020 13:00	10.9	13.3	8.5	183.1	3,178,569.4	2,112.2	2.0	1.7
07/30/2020 14:00	10.9	13.3	8.5	188.7	3,157,416.3	2,121.2	2.1	1.7
07/30/2020 15:00	10.9	13.2	8.4	193.2	3,101,818.3	2,151.8	2.2	1.7
07/30/2020 16:00	10.9	13.2	8.4	195.2	3,113,350.3	2,159.8	2.2	1.7
07/30/2020 17:00	11.0	13.2	8.4	200.4	3,100,890.3	2,173.8	2.3	2.0
07/30/2020 18:00	11.0	13.2	8.4	197.6	3,094,756.5	2,169.5	2.2	1.7
07/30/2020 19:00	10.9	13.3	8.5	174.4	3,144,198.4	2,066.4	1.9	1.4
07/30/2020 20:00	11.1	13.3	8.6	179.8	3,166,565.7	2,081.1	2.0	1.7
07/30/2020 21:00	11.1	13.3	8.6	178.2	3,182,449.9	2,068.3	1.9	1.4
07/30/2020 22:00	11.1	13.3	8.6	186.3	3,181,127.7	2,113.9	2.0	1.7
07/30/2020 23:00	10.9	13.3	8.5	174.8	3,199,473.3	2,056.0	1.9	1.4
Average/Sum#:	11.0	13.3	8.5	175.1	3,198,598.2	2,062.3	1.9	1.5
Minimum:	10.7	13.2	8.4	152.9	3,094,756.5	1,942.8	1.6	1.2
Maximum:	11.1	13.4	8.7	200.4	3,303,525.0	2,173.8	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/31/2020 00:00	10.9	13.4	8.6	161.0	3,220,429.7	1,975.4	1.7	1.4
07/31/2020 01:00	10.9	13.4	8.6	155.8	3,239,523.7	1,939.8	1.6	1.2
07/31/2020 02:00	10.8	13.4	8.5	154.0	3,273,938.7	1,936.5	1.6	1.2
07/31/2020 03:00	10.8	13.4	8.5	152.2	3,272,924.3	1,935.9	1.6	1.2
07/31/2020 04:00	10.8	13.4	8.5	153.7	3,287,294.8	1,944.4	1.6	1.2
07/31/2020 05:00	11.0	13.3	8.5	171.2	3,215,156.6	2,042.6	1.8	1.4
07/31/2020 06:00	11.4	13.3	8.9	174.6	3,230,582.3	2,052.4	1.9	1.4
07/31/2020 07:00	11.2	13.4	8.8	165.2	3,238,771.2	1,963.0	1.7	1.4
07/31/2020 08:00	11.1	13.4	8.7	158.0	3,237,853.7	1,938.8	1.7	1.4
07/31/2020 09:00	11.2	13.4	8.8	165.7	3,229,102.7	2,004.3	1.8	1.4
07/31/2020 10:00	11.1	13.3	8.6	179.9	3,200,760.2	2,080.2	1.9	1.5
07/31/2020 11:00	11.1	13.3	8.6	188.0	3,167,583.9	2,104.9	2.1	1.7
07/31/2020 12:00	11.1	13.3	8.6	189.6	3,168,787.8	2,105.7	2.1	1.7
07/31/2020 13:00	11.1	13.3	8.6	189.0	3,148,931.8	2,115.5	2.1	1.7
07/31/2020 14:00	11.1	13.3	8.6	194.1	3,121,698.6	2,120.0	2.2	1.7
07/31/2020 15:00	11.0	13.3	8.5	196.3	3,105,679.7	2,131.8	2.2	1.7
07/31/2020 16:00	11.0	13.3	8.5	198.4	3,105,971.0	2,132.0	2.2	1.7
07/31/2020 17:00	11.0	13.2	8.4	194.0	3,092,859.5	2,123.0	2.2	1.7
07/31/2020 18:00	11.1	13.2	8.5	205.4	3,088,622.6	2,165.2	2.3	1.9
07/31/2020 19:00	11.0	13.3	8.5	191.8	3,113,599.8	2,114.5	2.1	1.7
07/31/2020 20:00	11.1	13.3	8.6	192.0	3,153,248.5	2,118.4	2.1	1.7
07/31/2020 21:00	11.0	13.3	8.5	187.4	3,150,880.0	2,093.8	2.1	1.7
07/31/2020 22:00	11.0	13.3	8.5	184.2	3,171,891.2	2,084.6	2.0	1.7
07/31/2020 23:00	11.0	13.3	8.5	180.9	3,174,448.8	2,063.1	2.0	1.7
Average/Sum#:	11.0	13.3	8.6	178.4	3,183,772.5	2,053.6	1.9	1.5
Minimum:	10.8	13.2	8.4	152.2	3,088,622.6	1,935.9	1.6	1.2
Maximum:	11.4	13.4	8.9	205.4	3,287,294.8	2,165.2	2.3	1.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/01/2020 00:00	11.0	13.3	8.5	173.7	3,224,286.1	2,048.4	1.9	1.4
08/01/2020 01:00	10.8	13.4	8.5	160.6	3,255,389.0	1,949.3	1.7	1.4
08/01/2020 02:00	10.7	13.4	8.4	155.4	3,228,798.4	1,909.8	1.6	1.1
08/01/2020 03:00	9.0	13.9	7.6	93.4	2,768,551.8	1,435.4	1.1	0.6
08/01/2020 04:00	8.9	13.9	7.5	96.7	2,946,769.8	1,527.8	1.1	0.6
08/01/2020 05:00	9.0	13.9	7.6	101.0	2,976,858.6	1,543.4	1.1	0.6
08/01/2020 06:00	9.7	14.0	8.3	88.8	2,547,129.4	1,302.0	1.1	0.5
08/01/2020 07:00	9.8	14.0	8.4	88.4	2,524,631.7	1,290.5	1.1	0.5
08/01/2020 08:00	9.8	14.0	8.4	88.3	2,527,761.8	1,292.1	1.1	0.5
08/01/2020 09:00	9.8	14.0	8.4	88.2	2,537,543.4	1,297.1	1.1	0.5
08/01/2020 10:00	9.3	13.9	7.8	93.7	2,771,444.9	1,436.9	1.1	0.6
08/01/2020 11:00	9.6	13.9	8.1	117.6	2,915,523.8	1,511.6	1.4	0.8
08/01/2020 12:00	11.4	13.3	8.9	169.8	3,194,338.0	2,052.7	1.8	1.4
08/01/2020 13:00	11.3	13.3	8.8	186.6	3,165,326.6	2,103.4	2.0	1.7
08/01/2020 14:00	11.3	13.3	8.8	189.3	3,138,214.6	2,108.3	2.1	1.7
08/01/2020 15:00	11.2	13.3	8.7	194.3	3,169,622.0	2,129.4	2.1	1.7
08/01/2020 16:00	11.4	13.3	8.9	201.1	3,165,137.3	2,149.5	2.2	1.7
08/01/2020 17:00	11.3	13.3	8.8	203.4	3,182,807.3	2,161.5	2.2	1.7
08/01/2020 18:00	11.2	13.3	8.7	202.2	3,173,088.8	2,154.9	2.2	1.7
08/01/2020 19:00	11.1	13.3	8.6	202.4	3,174,561.3	2,155.9	2.2	1.7
08/01/2020 20:00	11.1	13.3	8.6	202.6	3,165,579.1	2,149.8	2.2	1.7
08/01/2020 21:00	11.1	13.3	8.6	189.0	3,150,278.0	2,093.4	2.1	1.7
08/01/2020 22:00	11.1	13.3	8.6	185.1	3,176,608.1	2,087.7	2.0	1.7
08/01/2020 23:00	10.9	13.4	8.6	164.7	3,149,676.1	1,932.0	1.8	1.4
Average/Sum#:	10.5	13.6	8.4	151.5	3,009,580.2	1,826.0	1.7	1.2
Minimum:	8.9	13.3	7.5	88.2	2,524,631.7	1,290.5	1.1	0.5
Maximum:	11.4	14.0	8.9	203.4	3,255,389.0	2,161.5	2.2	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/02/2020 00:00	9.2	13.9	7.8	96.5	2,752,735.9	1,427.2	1.2	0.7
08/02/2020 01:00	9.8	13.9	8.3	87.8	2,514,458.8	1,285.3	1.1	0.5
08/02/2020 02:00	9.8	13.9	8.3	87.9	2,520,327.8	1,288.3	1.1	0.5
08/02/2020 03:00	9.8	14.0	8.4	87.8	2,528,348.7	1,292.4	1.1	0.5
08/02/2020 04:00	9.2	13.9	7.8	95.2	2,887,556.7	1,497.1	1.1	0.6
08/02/2020 05:00	9.4	13.9	7.9	93.7	2,707,156.4	1,383.8	1.1	0.6
08/02/2020 06:00	9.8	14.0	8.4	88.2	2,534,804.5	1,295.7	1.1	0.5
08/02/2020 07:00	9.8	14.0	8.4	87.7	2,529,718.1	1,293.1	1.1	0.5
08/02/2020 08:00	9.8	14.0	8.4	87.9	2,531,870.1	1,294.2	1.1	0.5
08/02/2020 09:00	9.8	14.0	8.4	87.8	2,540,673.5	1,298.7	1.1	0.5
08/02/2020 10:00	9.7	14.0	8.3	87.7	2,547,520.6	1,302.2	1.1	0.5
08/02/2020 11:00	9.7	14.0	8.3	87.8	2,551,628.9	1,304.3	1.1	0.5
08/02/2020 12:00	9.8	14.0	8.4	87.8	2,545,955.6	1,301.4	1.1	0.5
08/02/2020 13:00	9.8	14.0	8.4	88.0	2,569,822.7	1,313.6	1.1	0.5
08/02/2020 14:00	9.5	14.0	8.1	88.8	2,671,160.1	1,365.4	1.1	0.5
08/02/2020 15:00	10.4	13.9	8.8	125.9	2,932,689.8	1,520.5	1.4	0.8
08/02/2020 16:00	11.5	13.3	8.9	167.1	3,164,314.8	2,010.3	1.8	1.4
08/02/2020 17:00	11.4	13.3	8.9	181.9	3,146,515.9	2,090.9	2.0	1.7
08/02/2020 18:00	11.2	13.3	8.7	180.9	3,149,826.6	2,093.1	2.0	1.7
08/02/2020 19:00	11.2	13.3	8.7	188.5	3,127,441.3	2,123.9	2.1	1.7
08/02/2020 20:00	11.0	13.3	8.5	182.9	3,161,564.5	2,100.9	2.0	1.7
08/02/2020 21:00	11.0	13.3	8.5	187.2	3,148,187.6	2,115.0	2.1	1.7
08/02/2020 22:00	11.0	13.3	8.5	181.8	3,151,331.4	2,094.1	2.0	1.7
08/02/2020 23:00	10.9	13.4	8.6	164.5	3,174,782.2	1,947.4	1.8	1.4
Average/Sum#:	10.2	13.7	8.4	120.9	2,795,433.0	1,585.0	1.4	0.9
Minimum:	9.2	13.3	7.8	87.7	2,514,458.8	1,285.3	1.1	0.5
Maximum:	11.5	14.0	8.9	188.5	3,174,782.2	2,123.9	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/03/2020 00:00	9.4	13.9	7.9	100.4	2,769,709.0	1,436.0	1.2	0.7
08/03/2020 01:00	9.5	13.9	8.0	87.8	2,546,357.8	1,320.2	1.1	0.5
08/03/2020 02:00	9.9	13.9	8.3	88.3	2,511,915.6	1,284.0	1.2	0.6
08/03/2020 03:00	9.8	13.9	8.3	88.1	2,529,326.8	1,292.9	1.1	0.5
08/03/2020 04:00	9.1	13.9	7.7	95.5	2,911,666.3	1,509.6	1.1	0.6
08/03/2020 05:00	9.2	13.9	7.8	98.4	2,874,441.1	1,490.3	1.1	0.6
08/03/2020 06:00	9.3	13.9	7.8	101.1	3,042,243.8	1,577.3	1.1	0.6
08/03/2020 07:00	9.3	13.9	7.8	100.1	2,968,950.6	1,539.3	1.1	0.6
08/03/2020 08:00	9.3	13.9	7.8	98.7	2,865,183.0	1,485.5	1.1	0.6
08/03/2020 09:00	9.4	13.9	7.9	88.4	2,652,825.8	1,375.4	1.1	0.6
08/03/2020 10:00	9.7	14.0	8.3	88.0	2,545,955.6	1,301.4	1.1	0.5
08/03/2020 11:00	9.4	14.0	8.0	87.6	2,666,464.9	1,363.0	1.1	0.5
08/03/2020 12:00	9.6	13.9	8.1	115.1	2,895,271.8	1,501.1	1.3	0.8
08/03/2020 13:00	11.6	13.3	9.0	175.0	3,166,293.8	2,057.8	1.9	1.4
08/03/2020 14:00	11.4	13.3	8.9	184.1	3,156,147.0	2,097.3	2.0	1.7
08/03/2020 15:00	11.2	13.3	8.7	186.8	3,142,904.2	2,088.5	2.1	1.7
08/03/2020 16:00	11.0	13.3	8.5	185.6	3,111,272.7	2,090.2	2.1	1.7
08/03/2020 17:00	11.0	13.3	8.5	186.7	3,094,310.1	2,101.4	2.1	1.7
08/03/2020 18:00	11.0	13.2	8.4	184.5	3,083,413.6	2,094.0	2.1	1.7
08/03/2020 19:00	11.0	13.2	8.4	186.3	3,119,048.1	2,118.2	2.1	1.7
08/03/2020 20:00	11.1	13.3	8.6	186.6	3,130,474.4	2,103.1	2.1	1.7
08/03/2020 21:00	11.1	13.3	8.6	187.6	3,138,661.1	2,108.6	2.1	1.7
08/03/2020 22:00	11.0	13.3	8.5	183.5	3,153,889.7	2,095.8	2.0	1.7
08/03/2020 23:00	10.4	13.5	8.3	150.0	3,041,981.8	1,799.3	1.7	1.3
Average/Sum#:	10.2	13.6	8.3	134.8	2,921,612.9	1,717.9	1.5	1.1
Minimum:	9.1	13.2	7.7	87.6	2,511,915.6	1,284.0	1.1	0.5
Maximum:	11.6	14.0	9.0	187.6	3,166,293.8	2,118.2	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/04/2020 00:00	9.7	13.9	8.2	88.6	2,484,637.3	1,288.2	1.2	0.6
08/04/2020 01:00	9.8	13.9	8.3	87.8	2,477,886.6	1,284.7	1.2	0.6
08/04/2020 02:00	9.6	13.9	8.1	87.6	2,496,595.7	1,294.4	1.2	0.6
08/04/2020 03:00	9.7	13.9	8.2	87.5	2,488,494.8	1,290.2	1.2	0.6
08/04/2020 04:00	9.7	13.9	8.2	87.7	2,494,088.3	1,293.1	1.2	0.6
08/04/2020 05:00	9.1	13.9	7.7	92.2	2,714,160.6	1,407.2	1.1	0.6
08/04/2020 06:00	9.9	13.9	8.3	88.4	2,514,147.4	1,303.5	1.2	0.7
08/04/2020 07:00	9.9	13.9	8.3	88.0	2,489,266.4	1,290.6	1.2	0.6
08/04/2020 08:00	9.9	13.9	8.3	88.0	2,490,809.4	1,291.4	1.2	0.6
08/04/2020 09:00	9.9	14.0	8.5	88.0	2,531,087.5	1,293.8	1.1	0.5
08/04/2020 10:00	9.8	14.0	8.4	87.9	2,546,933.7	1,301.9	1.1	0.5
08/04/2020 11:00	9.8	14.0	8.4	87.9	2,543,803.6	1,300.3	1.1	0.5
08/04/2020 12:00	9.6	14.0	8.2	98.5	2,813,971.5	1,438.4	1.2	0.7
08/04/2020 13:00	9.8	13.9	8.3	114.1	2,847,631.2	1,476.4	1.3	0.7
08/04/2020 14:00	9.8	14.0	8.4	89.4	2,581,951.9	1,319.8	1.1	0.5
08/04/2020 15:00	9.5	13.8	7.9	105.8	2,950,434.5	1,529.7	1.2	0.8
08/04/2020 16:00	9.8	13.8	8.1	117.3	2,904,722.7	1,506.0	1.4	0.8
08/04/2020 17:00	11.7	13.3	9.1	173.0	3,108,442.9	2,065.6	1.9	1.4
08/04/2020 18:00	11.4	13.2	8.7	189.5	3,085,575.4	2,118.0	2.1	1.7
08/04/2020 19:00	11.2	13.2	8.6	189.5	3,091,111.3	2,121.8	2.1	1.7
08/04/2020 20:00	11.2	13.3	8.7	187.3	3,132,558.3	2,104.5	2.1	1.7
08/04/2020 21:00	11.1	13.3	8.6	184.5	3,152,986.8	2,095.2	2.0	1.7
08/04/2020 22:00	10.9	13.4	8.6	163.1	3,182,220.1	1,975.2	1.8	1.4
08/04/2020 23:00	10.3	13.5	8.2	140.8	3,093,859.0	1,784.8	1.5	1.1
Average/Sum#:	10.1	13.7	8.3	117.2	2,759,057.4	1,548.9	1.4	0.9
Minimum:	9.1	13.2	7.7	87.5	2,477,886.6	1,284.7	1.1	0.5
Maximum:	11.7	14.0	9.1	189.5	3,182,220.1	2,121.8	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/05/2020 00:00	9.3	13.9	7.8	87.8	2,483,672.9	1,287.7	1.2	0.6
08/05/2020 01:00	9.4	13.9	7.9	87.1	2,485,408.8	1,288.6	1.2	0.6
08/05/2020 02:00	9.5	13.9	8.0	87.1	2,476,150.7	1,283.8	1.2	0.6
08/05/2020 03:00	9.6	13.9	8.1	87.2	2,476,536.5	1,284.0	1.2	0.6
08/05/2020 04:00	9.7	13.9	8.2	87.5	2,480,586.9	1,286.1	1.2	0.6
08/05/2020 05:00	9.5	13.9	8.0	86.0	2,544,622.0	1,319.3	1.1	0.5
08/05/2020 06:00	10.0	13.9	8.4	88.0	2,475,957.9	1,283.7	1.2	0.6
08/05/2020 07:00	9.9	13.9	8.3	88.0	2,476,729.4	1,284.1	1.2	0.6
08/05/2020 08:00	9.8	13.9	8.3	87.8	2,481,165.5	1,286.4	1.2	0.6
08/05/2020 09:00	9.7	13.9	8.2	87.6	2,484,830.2	1,288.3	1.2	0.6
08/05/2020 10:00	9.7	13.9	8.2	87.7	2,490,230.7	1,291.1	1.2	0.6
08/05/2020 11:00	9.7	14.0	8.3	87.6	2,495,631.3	1,293.9	1.2	0.6
08/05/2020 12:00	9.7	14.0	8.3	87.6	2,531,283.2	1,293.9	1.1	0.5
08/05/2020 13:00	9.7	14.0	8.3	87.5	2,532,456.9	1,294.5	1.1	0.5
08/05/2020 14:00	9.8	13.9	8.3	87.8	2,492,931.0	1,292.5	1.2	0.6
08/05/2020 15:00	9.9	13.9	8.3	88.0	2,489,845.0	1,290.9	1.2	0.6
08/05/2020 16:00	9.9	13.9	8.3	88.2	2,507,011.0	1,299.8	1.2	0.6
08/05/2020 17:00	10.4	13.6	8.4	148.7	3,094,548.0	1,762.6	1.6	1.1
08/05/2020 18:00	11.4	13.2	8.7	180.3	3,173,717.1	2,085.8	2.0	1.7
08/05/2020 19:00	11.1	13.3	8.6	173.3	3,130,846.5	2,011.9	1.9	1.4
08/05/2020 20:00	8.9	13.9	7.5	108.0	3,051,694.7	1,582.2	1.2	0.8
08/05/2020 21:00	9.2	13.9	7.8	92.3	2,711,267.4	1,405.7	1.1	0.6
08/05/2020 22:00	9.2	13.9	7.8	90.4	2,673,270.7	1,386.0	1.1	0.6
08/05/2020 23:00	9.6	13.9	8.1	87.4	2,478,272.4	1,284.9	1.2	0.6
Average/Sum#:	9.8	13.8	8.2	98.7	2,613,277.8	1,394.5	1.3	0.7
Minimum:	8.9	13.2	7.5	86.0	2,475,957.9	1,283.7	1.1	0.5
Maximum:	11.4	14.0	8.7	180.3	3,173,717.1	2,085.8	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/06/2020 00:00	9.6	13.9	8.1	87.4	2,475,572.1	1,283.5	1.2	0.6
08/06/2020 01:00	9.6	13.9	8.1	87.4	2,474,993.5	1,283.2	1.2	0.6
08/06/2020 02:00	9.6	13.9	8.1	87.3	2,475,765.0	1,283.6	1.2	0.6
08/06/2020 03:00	9.6	13.9	8.1	87.3	2,481,937.0	1,286.8	1.2	0.6
08/06/2020 04:00	9.5	13.9	8.0	87.5	2,513,954.6	1,303.4	1.1	0.5
08/06/2020 05:00	9.3	13.9	7.8	89.5	2,559,087.7	1,326.8	1.2	0.7
08/06/2020 06:00	9.8	13.9	8.3	88.1	2,489,266.4	1,290.6	1.2	0.6
08/06/2020 07:00	9.5	13.9	8.0	87.4	2,501,224.7	1,296.8	1.2	0.6
08/06/2020 08:00	9.6	13.9	8.1	87.3	2,504,310.7	1,298.4	1.1	0.5
08/06/2020 09:00	9.5	13.9	8.0	87.3	2,503,346.3	1,297.9	1.1	0.5
08/06/2020 10:00	9.6	14.0	8.2	87.5	2,501,224.7	1,296.8	1.1	0.5
08/06/2020 11:00	9.6	14.0	8.2	87.5	2,499,874.6	1,296.1	1.1	0.5
08/06/2020 12:00	9.6	14.0	8.2	87.4	2,535,391.4	1,296.0	1.1	0.5
08/06/2020 13:00	9.7	14.0	8.3	87.5	2,526,588.0	1,291.5	1.1	0.5
08/06/2020 14:00	9.8	14.0	8.4	87.8	2,525,414.2	1,290.9	1.1	0.5
08/06/2020 15:00	9.8	14.0	8.4	87.9	2,527,761.8	1,292.1	1.1	0.5
08/06/2020 16:00	9.8	14.0	8.4	88.0	2,523,262.2	1,289.8	1.1	0.5
08/06/2020 17:00	9.6	14.0	8.2	95.5	2,740,413.8	1,400.8	1.1	0.6
08/06/2020 18:00	9.6	13.9	8.1	94.6	2,703,166.6	1,401.5	1.2	0.7
08/06/2020 19:00	9.7	13.9	8.2	88.1	2,523,212.6	1,308.2	1.1	0.5
08/06/2020 20:00	9.9	13.9	8.3	88.2	2,477,115.1	1,284.3	1.2	0.6
08/06/2020 21:00	10.0	13.9	8.4	88.1	2,469,785.8	1,280.5	1.2	0.6
08/06/2020 22:00	10.0	13.9	8.4	88.2	2,467,857.0	1,279.5	1.2	0.6
08/06/2020 23:00	10.0	13.9	8.4	88.1	2,462,070.7	1,276.5	1.2	0.6
Average/Sum#:	9.7	13.9	8.2	88.4	2,519,274.9	1,301.5	1.2	0.6
Minimum:	9.3	13.9	7.8	87.3	2,462,070.7	1,276.5	1.1	0.5
Maximum:	10.0	14.0	8.4	95.5	2,740,413.8	1,401.5	1.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/07/2020 00:00	9.9	13.9	8.3	87.9	2,475,186.4	1,283.3	1.2	0.6
08/07/2020 01:00	9.9	13.9	8.3	87.8	2,473,257.6	1,282.3	1.2	0.6
08/07/2020 02:00	9.8	13.9	8.3	87.8	2,473,643.3	1,282.5	1.2	0.6
08/07/2020 03:00	9.8	14.0	8.4	87.7	2,474,993.5	1,283.2	1.2	0.6
08/07/2020 04:00	9.4	13.9	7.9	87.1	2,561,016.5	1,327.8	1.1	0.5
08/07/2020 05:00	9.4	13.9	7.9	84.0	2,541,343.1	1,317.6	1.1	0.5
08/07/2020 06:00	9.9	14.0	8.5	87.5	2,475,379.2	1,283.4	1.2	0.6
08/07/2020 07:00	9.8	14.0	8.4	87.9	2,483,480.1	1,287.6	1.2	0.6
08/07/2020 08:00	9.8	14.0	8.4	87.8	2,496,209.9	1,294.2	1.2	0.6
08/07/2020 09:00	9.6	14.0	8.2	87.4	2,538,130.3	1,297.4	1.1	0.5
08/07/2020 10:00	9.6	14.0	8.2	87.4	2,534,413.3	1,295.5	1.1	0.5
08/07/2020 11:00	9.7	14.0	8.3	87.6	2,535,000.2	1,295.8	1.1	0.5
08/07/2020 12:00	9.7	14.0	8.3	87.6	2,526,001.1	1,291.2	1.1	0.5
08/07/2020 13:00	9.5	14.0	8.1	88.8	2,636,141.9	1,347.5	1.1	0.5
08/07/2020 14:00	9.5	14.0	8.1	92.8	2,655,705.1	1,357.5	1.2	0.7
08/07/2020 15:00	9.7	14.0	8.3	88.0	2,533,435.1	1,295.0	1.1	0.5
08/07/2020 16:00	9.6	14.0	8.2	100.1	2,737,088.1	1,399.1	1.2	0.7
08/07/2020 17:00	9.3	13.9	7.8	97.1	2,825,064.6	1,464.7	1.1	0.6
08/07/2020 18:00	9.8	13.8	8.1	129.3	3,198,366.7	1,681.6	1.4	0.8
08/07/2020 19:00	9.3	13.8	7.7	110.9	3,126,281.7	1,643.7	1.2	0.8
08/07/2020 20:00	9.4	13.9	7.9	98.1	2,861,518.3	1,483.6	1.1	0.6
08/07/2020 21:00	9.7	13.9	8.2	90.0	2,581,075.6	1,338.2	1.1	0.5
08/07/2020 22:00	9.5	13.9	8.0	91.9	2,683,300.3	1,391.2	1.1	0.6
08/07/2020 23:00	9.4	13.9	7.9	94.7	2,787,453.7	1,445.2	1.1	0.6
Average/Sum#:	9.6	13.9	8.2	92.4	2,633,895.2	1,361.2	1.2	0.6
Minimum:	9.3	13.8	7.7	84.0	2,473,257.6	1,282.3	1.1	0.5
Maximum:	9.9	14.0	8.5	129.3	3,198,366.7	1,681.6	1.4	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/08/2020 00:00	9.5	13.9	8.0	89.4	2,604,992.4	1,350.6	1.1	0.5
08/08/2020 01:00	9.7	13.9	8.2	87.6	2,475,379.2	1,283.4	1.2	0.6
08/08/2020 02:00	9.7	13.9	8.2	87.7	2,470,171.6	1,280.7	1.2	0.6
08/08/2020 03:00	9.7	13.9	8.2	87.6	2,477,886.6	1,284.7	1.2	0.6
08/08/2020 04:00	9.6	14.0	8.2	87.5	2,484,251.6	1,288.0	1.2	0.6
08/08/2020 05:00	9.8	13.9	8.3	86.9	2,475,765.0	1,283.6	1.2	0.6
08/08/2020 06:00	10.0	13.9	8.4	88.4	2,476,922.2	1,284.2	1.2	0.6
08/08/2020 07:00	9.8	14.0	8.4	88.0	2,491,580.9	1,291.8	1.2	0.6
08/08/2020 08:00	9.9	14.0	8.5	87.9	2,488,880.6	1,290.4	1.2	0.6
08/08/2020 09:00	9.9	14.0	8.5	88.0	2,492,931.0	1,292.5	1.2	0.6
08/08/2020 10:00	9.9	14.0	8.5	88.1	2,497,752.9	1,295.0	1.2	0.6
08/08/2020 11:00	9.9	14.0	8.5	88.1	2,529,913.7	1,293.2	1.1	0.5
08/08/2020 12:00	9.8	14.0	8.4	87.9	2,527,957.4	1,292.2	1.1	0.5
08/08/2020 13:00	9.8	14.0	8.4	108.8	2,769,171.7	1,415.5	1.3	0.7
08/08/2020 14:00	9.5	14.0	8.1	90.6	2,592,711.6	1,325.3	1.1	0.5
08/08/2020 15:00	9.3	14.0	8.0	87.7	2,681,919.8	1,370.9	1.1	0.5
08/08/2020 16:00	9.7	13.9	8.2	112.8	2,789,961.1	1,446.5	1.4	0.7
08/08/2020 17:00	11.5	13.3	8.9	168.7	3,115,365.2	2,070.2	1.9	1.4
08/08/2020 18:00	11.4	13.2	8.7	198.9	3,099,079.5	2,149.9	2.2	1.7
08/08/2020 19:00	11.3	13.2	8.7	201.4	3,071,647.4	2,153.3	2.3	1.9
08/08/2020 20:00	11.2	13.3	8.7	190.4	3,106,237.4	2,109.5	2.1	1.7
08/08/2020 21:00	11.1	13.3	8.6	183.8	3,123,180.7	2,098.2	2.0	1.7
08/08/2020 22:00	11.1	13.3	8.6	167.7	3,152,509.4	2,002.8	1.8	1.4
08/08/2020 23:00	10.9	13.4	8.6	159.4	3,154,892.9	1,935.2	1.7	1.4
Average/Sum#:	10.2	13.8	8.4	117.2	2,714,627.6	1,537.0	1.4	0.9
Minimum:	9.3	13.2	8.0	86.9	2,470,171.6	1,280.7	1.1	0.5
Maximum:	11.5	14.0	8.9	201.4	3,154,892.9	2,153.3	2.3	1.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/09/2020 00:00	9.2	13.8	7.6	103.5	2,934,942.7	1,543.1	1.2	0.8
08/09/2020 01:00	9.8	13.9	8.3	89.0	2,514,918.9	1,303.9	1.2	0.7
08/09/2020 02:00	9.9	13.9	8.3	88.1	2,467,664.2	1,279.4	1.2	0.6
08/09/2020 03:00	9.8	13.9	8.3	87.7	2,478,658.1	1,285.1	1.2	0.6
08/09/2020 04:00	9.7	13.9	8.2	87.5	2,482,129.9	1,286.9	1.2	0.6
08/09/2020 05:00	9.7	14.0	8.3	88.1	2,483,287.2	1,287.5	1.2	0.6
08/09/2020 06:00	9.8	14.0	8.4	88.0	2,490,616.5	1,291.3	1.2	0.6
08/09/2020 07:00	9.7	14.0	8.3	87.7	2,496,017.0	1,294.1	1.2	0.6
08/09/2020 08:00	9.7	14.0	8.3	87.7	2,501,224.7	1,296.8	1.1	0.5
08/09/2020 09:00	9.8	14.0	8.4	87.8	2,497,367.2	1,294.8	1.2	0.6
08/09/2020 10:00	9.9	14.0	8.5	88.0	2,493,895.4	1,293.0	1.2	0.6
08/09/2020 11:00	9.7	14.0	8.3	87.7	2,533,826.4	1,295.2	1.1	0.5
08/09/2020 12:00	9.6	13.9	8.1	113.1	2,778,388.5	1,440.5	1.4	0.7
08/09/2020 13:00	9.5	13.9	8.0	108.3	2,915,716.7	1,511.7	1.2	0.8
08/09/2020 14:00	9.3	14.0	8.0	89.0	2,704,613.2	1,382.5	1.1	0.6
08/09/2020 15:00	9.9	13.8	8.2	130.7	3,001,102.9	1,599.8	1.5	1.0
08/09/2020 16:00	11.5	13.2	8.8	173.4	3,087,456.6	2,074.2	1.9	1.5
08/09/2020 17:00	11.3	13.2	8.7	195.0	3,046,684.0	2,135.8	2.2	1.7
08/09/2020 18:00	11.2	13.2	8.6	198.3	3,058,095.8	2,143.8	2.3	1.9
08/09/2020 19:00	11.1	13.2	8.5	187.0	3,066,927.9	2,105.2	2.1	1.7
08/09/2020 20:00	11.1	13.2	8.5	182.5	3,068,099.6	2,083.6	2.1	1.7
08/09/2020 21:00	10.9	13.2	8.4	186.2	3,107,562.6	2,110.4	2.1	1.7
08/09/2020 22:00	10.9	13.3	8.5	168.6	3,127,111.7	2,009.5	1.9	1.4
08/09/2020 23:00	10.7	13.3	8.3	158.9	3,112,137.7	1,931.7	1.8	1.4
Average/Sum#:	10.2	13.7	8.3	123.4	2,768,685.2	1,595.0	1.5	1.0
Minimum:	9.2	13.2	7.6	87.5	2,467,664.2	1,279.4	1.1	0.5
Maximum:	11.5	14.0	8.8	198.3	3,127,111.7	2,143.8	2.3	1.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/10/2020 00:00	9.1	13.9	7.7	93.0	2,693,201.3	1,416.0	1.1	0.6
08/10/2020 01:00	9.6	14.0	8.2	87.5	2,480,201.1	1,285.9	1.2	0.6
08/10/2020 02:00	9.6	13.9	8.1	87.8	2,494,088.3	1,293.1	1.2	0.6
08/10/2020 03:00	9.0	13.9	7.6	95.2	2,891,607.1	1,499.2	1.1	0.6
08/10/2020 04:00	9.1	13.9	7.7	98.0	2,947,348.5	1,528.1	1.1	0.6
08/10/2020 05:00	9.0	13.9	7.6	98.3	2,930,568.2	1,519.4	1.1	0.6
08/10/2020 06:00	9.3	13.9	7.8	110.3	3,069,983.2	1,614.1	1.2	0.8
08/10/2020 07:00	9.3	13.9	7.8	88.3	2,640,095.9	1,368.8	1.1	0.5
08/10/2020 08:00	9.3	13.9	7.8	97.5	2,891,800.0	1,499.3	1.1	0.6
08/10/2020 09:00	9.6	14.0	8.2	87.8	2,527,648.8	1,310.5	1.1	0.5
08/10/2020 10:00	9.4	13.9	7.9	103.6	2,939,054.8	1,523.8	1.2	0.8
08/10/2020 11:00	9.3	13.9	7.8	103.0	2,933,847.1	1,521.1	1.2	0.8
08/10/2020 12:00	9.6	14.0	8.2	87.9	2,554,954.6	1,306.0	1.1	0.5
08/10/2020 13:00	9.6	14.0	8.2	88.2	2,592,711.6	1,325.3	1.1	0.5
08/10/2020 14:00	9.5	14.0	8.1	87.6	2,606,014.6	1,332.1	1.1	0.5
08/10/2020 15:00	10.0	13.7	8.2	132.8	3,076,139.9	1,639.8	1.5	1.0
08/10/2020 16:00	11.4	13.2	8.7	175.1	3,066,774.4	2,082.7	2.0	1.7
08/10/2020 17:00	11.3	13.2	8.7	194.7	3,035,039.7	2,149.8	2.2	1.7
08/10/2020 18:00	11.1	13.2	8.5	186.6	3,044,201.3	2,089.6	2.1	1.7
08/10/2020 19:00	11.1	13.3	8.6	177.2	3,086,772.9	2,051.2	2.0	1.6
08/10/2020 20:00	11.0	13.3	8.5	174.0	3,100,224.6	2,037.5	1.9	1.4
08/10/2020 21:00	10.9	13.3	8.5	167.6	3,119,979.6	2,027.7	1.8	1.4
08/10/2020 22:00	10.9	13.3	8.5	161.7	3,145,536.0	1,975.4	1.8	1.4
08/10/2020 23:00	10.3	13.5	8.2	144.2	3,043,716.9	1,778.1	1.6	1.1
Average/Sum#:	9.9	13.7	8.1	122.0	2,871,312.9	1,632.3	1.4	0.9
Minimum:	9.0	13.2	7.6	87.5	2,480,201.1	1,285.9	1.1	0.5
Maximum:	11.4	14.0	8.7	194.7	3,145,536.0	2,149.8	2.2	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/11/2020 00:00	9.5	13.9	8.0	88.4	2,478,465.3	1,285.0	1.2	0.6
08/11/2020 01:00	9.5	13.9	8.0	87.4	2,477,500.9	1,284.5	1.2	0.6
08/11/2020 02:00	9.4	13.9	7.9	87.3	2,482,322.8	1,287.0	1.2	0.6
08/11/2020 03:00	9.4	13.9	7.9	87.2	2,484,637.3	1,288.2	1.2	0.6
08/11/2020 04:00	9.4	13.9	7.9	87.2	2,500,453.2	1,296.4	1.2	0.6
08/11/2020 05:00	9.4	13.9	7.9	89.4	2,518,776.5	1,305.9	1.2	0.7
08/11/2020 06:00	9.7	13.9	8.2	89.7	2,586,283.3	1,340.9	1.1	0.5
08/11/2020 07:00	9.7	13.9	8.2	88.0	2,488,494.8	1,290.2	1.2	0.6
08/11/2020 08:00	9.7	13.9	8.2	87.8	2,492,738.1	1,292.4	1.2	0.6
08/11/2020 09:00	9.6	13.9	8.1	87.6	2,496,981.4	1,294.6	1.2	0.6
08/11/2020 10:00	9.6	13.9	8.1	87.8	2,502,767.7	1,297.6	1.2	0.6
08/11/2020 11:00	9.6	14.0	8.2	87.8	2,507,589.6	1,300.1	1.1	0.5
08/11/2020 12:00	9.7	13.9	8.2	87.9	2,502,574.8	1,297.5	1.2	0.6
08/11/2020 13:00	9.8	13.9	8.3	87.9	2,503,925.0	1,298.2	1.2	0.6
08/11/2020 14:00	9.7	13.9	8.2	88.2	2,540,378.7	1,317.1	1.1	0.5
08/11/2020 15:00	9.7	13.9	8.2	90.4	2,569,695.9	1,332.3	1.2	0.7
08/11/2020 16:00	9.4	13.9	7.9	94.2	2,754,086.0	1,427.9	1.1	0.6
08/11/2020 17:00	9.3	13.9	7.8	106.1	3,024,884.9	1,568.3	1.2	0.8
08/11/2020 18:00	9.3	13.9	7.8	100.8	2,933,654.2	1,521.0	1.1	0.6
08/11/2020 19:00	9.2	13.9	7.8	88.1	2,657,069.1	1,377.6	1.1	0.6
08/11/2020 20:00	9.6	13.9	8.1	92.0	2,621,579.8	1,359.2	1.2	0.7
08/11/2020 21:00	9.7	13.9	8.2	88.1	2,519,933.7	1,306.5	1.1	0.5
08/11/2020 22:00	9.5	13.9	8.0	91.6	2,689,472.3	1,394.4	1.1	0.6
08/11/2020 23:00	9.6	13.9	8.1	87.7	2,508,746.9	1,300.7	1.1	0.5
Average/Sum#:	9.5	13.9	8.1	89.9	2,576,792.2	1,336.0	1.2	0.6
Minimum:	9.2	13.9	7.8	87.2	2,477,500.9	1,284.5	1.1	0.5
Maximum:	9.8	14.0	8.3	106.1	3,024,884.9	1,568.3	1.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/12/2020 00:00	9.6	13.9	8.1	87.7	2,485,601.7	1,288.7	1.2	0.6
08/12/2020 01:00	9.4	13.9	7.9	87.3	2,530,156.2	1,311.8	1.1	0.5
08/12/2020 02:00	9.6	13.9	8.1	87.6	2,485,987.4	1,288.9	1.2	0.6
08/12/2020 03:00	9.6	13.9	8.1	87.5	2,493,316.8	1,292.7	1.2	0.6
08/12/2020 04:00	9.4	13.9	7.9	87.4	2,531,120.6	1,312.3	1.1	0.5
08/12/2020 05:00	9.6	13.9	8.1	88.1	2,516,654.8	1,304.8	1.2	0.7
08/12/2020 06:00	9.9	13.9	8.3	88.1	2,505,660.9	1,299.1	1.2	0.6
08/12/2020 07:00	9.7	13.9	8.2	88.0	2,533,242.2	1,313.4	1.1	0.5
08/12/2020 08:00	9.2	13.9	7.8	87.9	2,672,884.9	1,385.8	1.1	0.6
08/12/2020 09:00	9.4	13.9	7.9	87.6	2,574,517.8	1,334.8	1.1	0.5
08/12/2020 10:00	9.3	13.9	7.8	87.4	2,588,983.6	1,342.3	1.1	0.5
08/12/2020 11:00	9.4	13.9	7.9	91.8	2,673,656.5	1,386.2	1.1	0.6
08/12/2020 12:00	9.6	13.8	8.0	129.3	3,127,042.5	1,644.1	1.4	0.8
08/12/2020 13:00	11.4	13.3	8.9	164.7	3,139,674.7	2,040.5	1.8	1.4
08/12/2020 14:00	11.3	13.2	8.7	182.8	3,086,947.6	2,096.4	2.1	1.7
08/12/2020 15:00	11.2	13.2	8.6	193.8	3,083,078.8	2,138.8	2.2	1.7
08/12/2020 16:00	11.1	13.2	8.5	189.1	3,077,601.1	2,135.0	2.1	1.7
08/12/2020 17:00	11.1	13.2	8.5	188.8	3,085,429.7	2,117.9	2.1	1.7
08/12/2020 18:00	11.0	13.3	8.5	185.0	3,098,580.4	2,104.3	2.1	1.7
08/12/2020 19:00	11.0	13.3	8.5	183.8	3,123,925.0	2,098.7	2.0	1.7
08/12/2020 20:00	10.9	13.3	8.5	176.6	3,136,742.6	2,061.5	1.9	1.4
08/12/2020 21:00	11.0	13.3	8.5	176.0	3,157,523.3	2,052.1	1.9	1.4
08/12/2020 22:00	11.1	13.3	8.6	181.1	3,182,142.2	2,068.1	2.0	1.7
08/12/2020 23:00	10.8	13.4	8.5	162.8	3,168,750.2	1,943.7	1.8	1.4
Average/Sum#:	10.2	13.6	8.3	132.1	2,835,800.9	1,681.7	1.5	1.0
Minimum:	9.2	13.2	7.8	87.3	2,485,601.7	1,288.7	1.1	0.5
Maximum:	11.4	13.9	8.9	193.8	3,182,142.2	2,138.8	2.2	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/13/2020 00:00	8.9	13.8	7.4	112.2	3,240,521.0	1,680.1	1.2	0.8
08/13/2020 01:00	9.1	13.9	7.7	106.0	3,121,709.0	1,618.5	1.1	0.6
08/13/2020 02:00	9.0	13.9	7.6	98.5	2,992,674.5	1,551.6	1.1	0.6
08/13/2020 03:00	8.9	13.9	7.5	100.0	3,055,359.4	1,584.1	1.1	0.6
08/13/2020 04:00	8.9	13.9	7.5	101.5	3,067,124.9	1,590.2	1.1	0.6
08/13/2020 05:00	8.8	13.9	7.4	101.3	3,105,700.2	1,610.2	1.1	0.6
08/13/2020 06:00	9.1	13.9	7.7	106.7	3,320,462.9	1,697.3	1.1	0.7
08/13/2020 07:00	9.1	13.9	7.7	104.1	3,085,062.4	1,599.5	1.1	0.6
08/13/2020 08:00	9.5	13.9	8.0	115.9	3,239,556.6	1,679.6	1.2	0.8
08/13/2020 09:00	9.2	13.8	7.6	120.7	3,093,163.2	1,603.7	1.3	0.8
08/13/2020 10:00	11.2	13.4	8.8	159.9	3,232,647.1	2,006.5	1.7	1.4
08/13/2020 11:00	11.4	13.3	8.9	188.5	3,190,608.3	2,120.2	2.0	1.7
08/13/2020 12:00	11.2	13.3	8.7	186.7	3,147,294.5	2,114.4	2.1	1.7
08/13/2020 13:00	11.3	13.3	8.8	187.4	3,156,748.9	2,097.7	2.1	1.7
08/13/2020 14:00	11.1	13.3	8.6	183.8	3,140,797.4	2,087.1	2.0	1.7
08/13/2020 15:00	11.1	13.3	8.6	193.9	3,116,544.8	2,116.5	2.2	1.7
08/13/2020 16:00	11.1	13.3	8.6	192.2	3,100,936.4	2,105.9	2.2	1.7
08/13/2020 17:00	11.0	13.3	8.5	192.8	3,119,195.3	2,118.3	2.2	1.7
08/13/2020 18:00	10.9	13.3	8.5	189.1	3,114,336.1	2,115.0	2.1	1.7
08/13/2020 19:00	10.9	13.3	8.5	189.6	3,117,281.1	2,117.0	2.1	1.7
08/13/2020 20:00	11.0	13.3	8.5	184.8	3,169,152.3	2,082.8	2.0	1.7
08/13/2020 21:00	11.0	13.3	8.5	179.1	3,175,372.0	2,063.7	1.9	1.4
08/13/2020 22:00	11.1	13.3	8.6	186.2	3,179,321.9	2,112.7	2.0	1.7
08/13/2020 23:00	11.1	13.3	8.6	201.8	3,174,733.6	2,179.2	2.2	1.7
Average/Sum#:	10.2	13.5	8.2	153.4	3,144,012.7	1,902.2	1.7	1.2
Minimum:	8.8	13.3	7.4	98.5	2,992,674.5	1,551.6	1.1	0.6
Maximum:	11.4	13.9	8.9	201.8	3,320,462.9	2,179.2	2.2	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/14/2020 00:00	11.0	13.3	8.5	203.2	3,187,408.1	2,187.9	2.2	1.8
08/14/2020 01:00	10.9	13.3	8.5	198.9	3,190,758.8	2,166.9	2.2	1.7
08/14/2020 02:00	10.8	13.3	8.4	190.2	3,202,948.2	2,128.4	2.1	1.7
08/14/2020 03:00	10.8	13.3	8.4	184.7	3,208,409.2	2,108.6	2.0	1.7
08/14/2020 04:00	10.8	13.3	8.4	200.0	3,193,262.1	2,168.6	2.2	1.7
08/14/2020 05:00	10.8	13.3	8.4	221.9	3,237,073.1	2,103.8	2.4	1.9
08/14/2020 06:00	11.2	13.3	8.7	177.1	3,229,507.3	2,075.3	1.9	1.5
08/14/2020 07:00	11.1	13.3	8.6	177.3	3,219,392.2	2,068.8	1.9	1.4
08/14/2020 08:00	11.1	13.3	8.6	185.0	3,191,215.3	2,097.3	2.0	1.7
08/14/2020 09:00	11.1	13.3	8.6	192.1	3,155,332.4	2,119.8	2.1	1.7
08/14/2020 10:00	11.1	13.2	8.5	203.7	3,127,765.3	2,169.8	2.3	2.0
08/14/2020 11:00	11.1	13.3	8.6	198.2	3,145,700.3	2,136.3	2.2	1.7
08/14/2020 12:00	11.1	13.3	8.6	204.3	3,134,525.0	2,151.6	2.3	1.9
08/14/2020 13:00	11.0	13.3	8.5	197.7	3,138,632.3	2,131.5	2.2	1.7
08/14/2020 14:00	11.0	13.3	8.5	192.5	3,114,777.8	2,115.3	2.2	1.7
08/14/2020 15:00	11.0	13.3	8.5	189.5	3,098,580.4	2,104.3	2.1	1.7
08/14/2020 16:00	10.9	13.3	8.5	185.3	3,097,578.4	2,081.0	2.1	1.7
08/14/2020 17:00	11.0	13.3	8.5	192.2	3,095,340.9	2,102.1	2.2	1.7
08/14/2020 18:00	11.1	13.3	8.6	194.9	3,100,641.9	2,105.7	2.2	1.7
08/14/2020 19:00	11.2	13.3	8.7	202.2	3,110,632.9	2,135.2	2.3	1.9
08/14/2020 20:00	11.1	13.3	8.6	205.7	3,107,584.3	2,155.8	2.3	1.9
08/14/2020 21:00	11.2	13.3	8.7	205.6	3,124,327.2	2,144.6	2.3	1.9
08/14/2020 22:00	11.1	13.3	8.6	209.9	3,132,089.8	2,172.8	2.3	2.0
08/14/2020 23:00	11.0	13.2	8.4	210.1	3,141,027.1	2,179.0	2.3	2.0
Average/Sum#:	11.0	13.3	8.5	196.8	3,153,521.3	2,129.6	2.2	1.8
Minimum:	10.8	13.2	8.4	177.1	3,095,340.9	2,068.8	1.9	1.4
Maximum:	11.2	13.3	8.7	221.9	3,237,073.1	2,187.9	2.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/15/2020 00:00	11.1	13.3	8.6	211.5	3,147,513.8	2,183.5	2.4	2.0
08/15/2020 01:00	11.0	13.3	8.5	208.3	3,146,360.6	2,182.7	2.3	2.0
08/15/2020 02:00	10.9	13.3	8.5	196.2	3,150,117.8	2,139.3	2.2	1.7
08/15/2020 03:00	11.0	13.3	8.5	192.7	3,161,584.1	2,124.0	2.1	1.7
08/15/2020 04:00	10.9	13.3	8.5	186.6	3,207,800.5	2,108.2	2.0	1.7
08/15/2020 05:00	11.0	13.3	8.5	170.9	3,193,193.3	2,098.6	1.8	1.5
08/15/2020 06:00	11.3	13.3	8.8	180.1	3,197,605.9	2,101.5	1.9	1.5
08/15/2020 07:00	11.2	13.3	8.7	187.0	3,194,867.1	2,099.7	2.0	1.7
08/15/2020 08:00	11.2	13.3	8.7	173.3	3,203,019.9	2,011.5	1.9	1.4
08/15/2020 09:00	11.1	13.3	8.6	183.4	3,157,952.8	2,098.5	2.0	1.7
08/15/2020 10:00	11.1	13.3	8.6	187.5	3,135,386.4	2,106.4	2.1	1.7
08/15/2020 11:00	11.2	13.3	8.7	201.7	3,131,611.3	2,149.6	2.2	1.7
08/15/2020 12:00	11.1	13.2	8.5	206.1	3,097,324.1	2,171.3	2.3	2.0
08/15/2020 13:00	11.0	13.2	8.4	202.4	3,082,346.1	2,160.8	2.3	1.9
08/15/2020 14:00	10.9	13.2	8.4	200.7	3,070,791.5	2,152.7	2.3	1.9
08/15/2020 15:00	10.9	13.2	8.4	197.1	3,059,522.3	2,144.8	2.3	1.9
08/15/2020 16:00	11.0	13.2	8.4	198.2	3,057,097.3	2,143.1	2.3	1.9
08/15/2020 17:00	11.0	13.2	8.4	194.3	3,022,333.7	2,140.8	2.2	1.7
08/15/2020 18:00	11.0	13.2	8.4	194.6	3,049,251.6	2,137.6	2.2	1.7
08/15/2020 19:00	11.0	13.2	8.4	194.7	3,059,665.0	2,144.9	2.2	1.7
08/15/2020 20:00	10.9	13.2	8.4	198.7	3,088,622.6	2,165.2	2.2	1.7
08/15/2020 21:00	10.8	13.2	8.3	194.3	3,117,334.4	2,139.8	2.2	1.7
08/15/2020 22:00	10.9	13.3	8.5	189.1	3,143,573.2	2,111.9	2.1	1.7
08/15/2020 23:00	10.9	13.2	8.4	204.0	3,140,738.8	2,178.8	2.3	2.0
Average/Sum#:	11.0	13.3	8.5	193.9	3,125,650.6	2,133.1	2.2	1.8
Minimum:	10.8	13.2	8.3	170.9	3,022,333.7	2,011.5	1.8	1.4
Maximum:	11.3	13.3	8.8	211.5	3,207,800.5	2,183.5	2.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/16/2020 00:00	10.9	13.2	8.4	204.7	3,120,005.2	2,187.2	2.3	2.0
08/16/2020 01:00	10.8	13.2	8.3	201.4	3,151,694.2	2,186.4	2.2	1.7
08/16/2020 02:00	10.8	13.2	8.3	202.5	3,150,108.5	2,185.3	2.2	1.7
08/16/2020 03:00	10.8	13.3	8.4	192.7	3,171,469.1	2,153.8	2.1	1.7
08/16/2020 04:00	10.9	13.3	8.5	203.3	3,146,360.6	2,182.7	2.3	2.0
08/16/2020 05:00	10.8	13.3	8.4	204.1	3,153,609.5	2,164.7	2.3	1.9
08/16/2020 06:00	11.2	13.3	8.7	196.2	3,159,983.6	2,146.0	2.2	1.7
08/16/2020 07:00	10.8	13.3	8.4	171.6	3,170,373.1	2,037.3	1.9	1.4
08/16/2020 08:00	10.7	13.4	8.4	160.1	3,193,336.6	1,982.1	1.7	1.4
08/16/2020 09:00	10.9	13.3	8.5	171.7	3,153,368.9	2,049.4	1.9	1.4
08/16/2020 10:00	11.0	13.3	8.5	174.5	3,166,755.4	2,058.1	1.9	1.4
08/16/2020 11:00	11.0	13.3	8.5	172.3	3,158,446.6	2,052.7	1.9	1.4
08/16/2020 12:00	11.0	13.3	8.5	178.3	3,132,219.7	2,081.4	2.0	1.7
08/16/2020 13:00	10.9	13.3	8.5	183.3	3,130,474.4	2,103.1	2.0	1.7
08/16/2020 14:00	10.9	13.2	8.4	198.2	3,127,240.8	2,146.6	2.2	1.7
08/16/2020 15:00	10.9	13.2	8.4	201.1	3,099,367.8	2,150.1	2.3	1.9
08/16/2020 16:00	10.9	13.2	8.4	204.8	3,084,485.8	2,162.3	2.3	1.9
08/16/2020 17:00	10.9	13.2	8.4	201.1	3,083,059.3	2,161.3	2.3	1.9
08/16/2020 18:00	11.0	13.2	8.4	198.7	3,071,647.4	2,153.3	2.3	1.9
08/16/2020 19:00	11.0	13.2	8.4	197.0	3,060,806.1	2,145.7	2.3	1.9
08/16/2020 20:00	11.1	13.2	8.5	196.2	3,093,745.9	2,146.2	2.2	1.7
08/16/2020 21:00	11.0	13.2	8.4	190.6	3,099,852.3	2,127.8	2.1	1.7
08/16/2020 22:00	11.0	13.2	8.4	189.1	3,097,667.1	2,126.3	2.1	1.7
08/16/2020 23:00	11.0	13.2	8.4	192.4	3,112,381.1	2,136.4	2.2	1.7
Average/Sum#:	10.9	13.3	8.4	191.1	3,128,685.8	2,126.1	2.1	1.7
Minimum:	10.7	13.2	8.3	160.1	3,060,806.1	1,982.1	1.7	1.4
Maximum:	11.2	13.4	8.7	204.8	3,193,336.6	2,187.2	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/17/2020 00:00	11.0	13.2	8.4	197.3	3,129,134.7	2,147.9	2.2	1.7
08/17/2020 01:00	10.9	13.3	8.5	195.0	3,140,693.8	2,132.9	2.2	1.7
08/17/2020 02:00	11.1	13.3	8.6	193.7	3,135,392.8	2,129.3	2.1	1.7
08/17/2020 03:00	11.1	13.3	8.6	194.6	3,157,185.8	2,144.1	2.1	1.7
08/17/2020 04:00	11.0	13.3	8.5	194.4	3,154,240.8	2,142.1	2.1	1.7
08/17/2020 05:00	10.9	13.3	8.5	193.7	3,169,473.2	2,129.3	2.1	1.7
08/17/2020 06:00	11.3	13.3	8.8	193.7	3,176,622.8	2,157.3	2.1	1.7
08/17/2020 07:00	11.1	13.2	8.5	200.0	3,151,278.6	2,163.1	2.2	1.7
08/17/2020 08:00	11.0	13.3	8.5	193.7	3,161,456.1	2,147.0	2.1	1.7
08/17/2020 09:00	11.1	13.2	8.5	204.5	3,135,693.5	2,175.3	2.3	2.0
08/17/2020 10:00	11.0	13.2	8.4	206.1	3,107,737.5	2,178.6	2.3	2.0
08/17/2020 11:00	10.9	13.2	8.4	194.0	3,111,507.0	2,135.8	2.2	1.7
08/17/2020 12:00	10.9	13.2	8.4	197.4	3,135,690.5	2,152.4	2.2	1.7
08/17/2020 13:00	10.9	13.3	8.5	188.3	3,103,586.9	2,107.7	2.1	1.7
08/17/2020 14:00	10.9	13.2	8.4	189.3	3,116,839.3	2,116.7	2.1	1.7
08/17/2020 15:00	10.9	13.2	8.4	199.7	3,090,619.7	2,166.6	2.3	1.9
08/17/2020 16:00	10.8	13.2	8.3	201.2	3,096,610.9	2,170.8	2.3	2.0
08/17/2020 17:00	10.7	13.3	8.3	190.1	3,124,496.3	2,121.9	2.1	1.7
08/17/2020 18:00	10.8	13.3	8.4	180.6	3,143,807.1	2,089.1	2.0	1.7
08/17/2020 19:00	10.8	13.3	8.4	181.8	3,144,258.6	2,089.4	2.0	1.7
08/17/2020 20:00	10.9	13.3	8.5	189.4	3,156,672.1	2,120.7	2.1	1.7
08/17/2020 21:00	10.8	13.2	8.3	201.0	3,124,017.4	2,167.2	2.3	2.0
08/17/2020 22:00	10.9	13.3	8.5	200.9	3,132,631.1	2,150.3	2.2	1.7
08/17/2020 23:00	11.0	13.2	8.4	200.9	3,164,106.6	2,148.8	2.2	1.7
Average/Sum#:	10.9	13.3	8.5	195.1	3,135,989.7	2,141.0	2.2	1.8
Minimum:	10.7	13.2	8.3	180.6	3,090,619.7	2,089.1	2.0	1.7
Maximum:	11.3	13.3	8.8	206.1	3,176,622.8	2,178.6	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/18/2020 00:00	10.9	13.3	8.5	186.3	3,157,200.4	2,098.0	2.0	1.7
08/18/2020 01:00	10.8	13.3	8.4	192.1	3,144,080.6	2,135.2	2.1	1.7
08/18/2020 02:00	10.8	13.3	8.4	196.2	3,137,293.0	2,153.5	2.2	1.7
08/18/2020 03:00	10.8	13.3	8.4	185.0	3,185,491.8	2,116.8	2.0	1.7
08/18/2020 04:00	10.8	13.3	8.4	191.3	3,141,577.3	2,133.5	2.1	1.7
08/18/2020 05:00	10.9	13.3	8.5	168.1	3,162,328.4	2,124.5	1.8	1.5
08/18/2020 06:00	11.3	13.3	8.8	197.4	3,142,537.6	2,157.1	2.2	1.7
08/18/2020 07:00	11.0	13.3	8.5	190.6	3,163,519.2	2,125.3	2.1	1.7
08/18/2020 08:00	11.0	13.3	8.5	190.2	3,161,715.0	2,101.0	2.1	1.7
08/18/2020 09:00	11.0	13.3	8.5	185.2	3,116,482.4	2,093.7	2.1	1.7
08/18/2020 10:00	11.2	13.2	8.6	192.3	3,108,298.9	2,110.9	2.2	1.7
08/18/2020 11:00	11.0	13.3	8.5	181.2	3,080,460.6	2,069.5	2.0	1.7
08/18/2020 12:00	11.0	13.2	8.4	196.7	3,076,159.6	2,134.0	2.2	1.7
08/18/2020 13:00	11.1	13.2	8.5	201.7	3,057,382.6	2,143.3	2.3	1.9
08/18/2020 14:00	11.1	13.2	8.5	205.3	3,068,081.2	2,150.8	2.3	1.9
08/18/2020 15:00	11.0	13.2	8.4	202.2	3,056,241.4	2,142.5	2.3	1.9
08/18/2020 16:00	10.9	13.2	8.4	199.5	3,023,745.5	2,141.8	2.3	1.9
08/18/2020 17:00	10.9	13.2	8.4	201.1	3,030,663.2	2,146.7	2.3	1.9
08/18/2020 18:00	10.9	13.2	8.4	200.3	3,037,580.9	2,151.6	2.3	1.9
08/18/2020 19:00	10.8	13.2	8.3	200.4	3,049,863.4	2,160.3	2.3	1.9
08/18/2020 20:00	10.8	13.2	8.3	200.7	3,094,613.8	2,169.4	2.3	2.0
08/18/2020 21:00	10.8	13.3	8.4	198.7	3,133,359.5	2,150.8	2.2	1.7
08/18/2020 22:00	10.7	13.3	8.3	201.6	3,134,107.9	2,174.2	2.3	2.0
08/18/2020 23:00	10.7	13.3	8.3	203.4	3,177,793.0	2,181.3	2.2	1.7
Average/Sum#:	10.9	13.3	8.4	194.5	3,110,024.1	2,136.1	2.2	1.8
Minimum:	10.7	13.2	8.3	168.1	3,023,745.5	2,069.5	1.8	1.5
Maximum:	11.3	13.3	8.8	205.3	3,185,491.8	2,181.3	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/19/2020 00:00	10.6	13.3	8.2	193.3	3,153,062.8	2,141.3	2.1	1.7
08/19/2020 01:00	10.6	13.3	8.2	193.2	3,147,172.8	2,137.3	2.1	1.7
08/19/2020 02:00	10.8	13.3	8.4	197.7	3,148,056.3	2,137.9	2.2	1.7
08/19/2020 03:00	10.9	13.3	8.5	192.5	3,175,710.2	2,110.3	2.1	1.7
08/19/2020 04:00	10.9	13.3	8.5	194.0	3,196,326.8	2,124.0	2.1	1.7
08/19/2020 05:00	10.9	13.3	8.5	168.0	3,181,729.6	2,114.3	1.8	1.5
08/19/2020 06:00	11.4	13.3	8.9	195.2	3,208,257.0	2,108.5	2.1	1.7
08/19/2020 07:00	11.0	13.3	8.5	200.0	3,182,218.3	2,161.1	2.2	1.7
08/19/2020 08:00	10.9	13.3	8.5	185.9	3,191,671.8	2,097.6	2.0	1.7
08/19/2020 09:00	11.0	13.3	8.5	202.0	3,151,861.3	2,163.5	2.2	1.7
08/19/2020 10:00	10.9	13.2	8.4	206.3	3,136,846.7	2,176.1	2.3	2.0
08/19/2020 11:00	11.0	13.2	8.4	203.9	3,085,341.7	2,162.9	2.3	1.9
08/19/2020 12:00	10.9	13.2	8.4	196.8	3,071,546.8	2,130.8	2.2	1.7
08/19/2020 13:00	10.9	13.2	8.4	201.7	3,109,746.6	2,157.3	2.3	1.9
08/19/2020 14:00	10.8	13.2	8.3	204.6	3,073,501.9	2,154.6	2.3	1.9
08/19/2020 15:00	10.8	13.2	8.3	199.8	3,027,557.3	2,144.5	2.3	1.9
08/19/2020 16:00	10.9	13.2	8.4	203.5	3,061,234.1	2,146.0	2.3	1.9
08/19/2020 17:00	10.9	13.3	8.5	199.6	3,103,980.6	2,153.3	2.2	1.7
08/19/2020 18:00	10.9	13.3	8.5	206.4	3,133,098.8	2,173.5	2.3	2.0
08/19/2020 19:00	10.9	13.3	8.5	201.6	3,165,431.8	2,149.7	2.2	1.7
08/19/2020 20:00	10.8	13.3	8.4	199.1	3,164,401.1	2,149.0	2.2	1.7
08/19/2020 21:00	10.8	13.3	8.4	193.2	3,188,351.0	2,118.7	2.1	1.7
08/19/2020 22:00	10.8	13.4	8.5	187.3	3,227,994.8	2,097.9	2.0	1.7
08/19/2020 23:00	10.8	13.4	8.5	182.0	3,226,550.6	2,073.4	1.9	1.5
Average/Sum#:	10.9	13.3	8.4	196.2	3,146,318.8	2,136.8	2.2	1.8
Minimum:	10.6	13.2	8.2	168.0	3,027,557.3	2,073.4	1.8	1.5
Maximum:	11.4	13.4	8.9	206.4	3,227,994.8	2,176.1	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/20/2020 00:00	10.7	13.4	8.4	181.0	3,230,285.4	2,075.8	1.9	1.5
08/20/2020 01:00	10.6	13.4	8.3	177.3	3,249,470.9	2,064.4	1.9	1.4
08/20/2020 02:00	10.6	13.4	8.3	171.1	3,222,869.5	2,047.5	1.8	1.4
08/20/2020 03:00	10.8	13.4	8.5	176.7	3,231,211.9	2,052.8	1.9	1.4
08/20/2020 04:00	10.7	13.4	8.4	175.8	3,204,608.7	2,059.3	1.9	1.4
08/20/2020 05:00	10.8	13.4	8.5	182.4	3,217,369.2	2,067.5	2.0	1.7
08/20/2020 06:00	11.2	13.4	8.8	175.0	3,227,749.0	2,050.6	1.9	1.4
08/20/2020 07:00	10.9	13.4	8.6	174.7	3,224,915.7	2,048.8	1.9	1.4
08/20/2020 08:00	10.9	13.4	8.6	176.7	3,195,738.5	2,053.6	1.9	1.4
08/20/2020 09:00	10.8	13.4	8.5	177.2	3,184,604.1	2,069.7	1.9	1.4
08/20/2020 10:00	10.8	13.3	8.4	182.5	3,168,848.0	2,082.6	2.0	1.7
08/20/2020 11:00	10.7	13.4	8.4	182.0	3,193,528.4	2,075.5	2.0	1.7
08/20/2020 12:00	10.7	13.3	8.3	183.6	3,179,651.3	2,089.7	2.0	1.7
08/20/2020 13:00	10.8	13.3	8.4	185.2	3,177,673.2	2,088.4	2.0	1.7
08/20/2020 14:00	10.9	13.4	8.6	184.4	3,188,296.9	2,072.1	2.0	1.7
08/20/2020 15:00	10.8	13.4	8.5	180.5	3,175,987.5	2,064.1	2.0	1.7
08/20/2020 16:00	10.8	13.4	8.5	181.7	3,136,134.0	2,061.1	2.0	1.6
08/20/2020 17:00	11.0	13.3	8.5	188.2	3,137,637.2	2,085.0	2.1	1.7
08/20/2020 18:00	10.9	13.3	8.5	185.3	3,140,045.0	2,086.6	2.0	1.7
08/20/2020 19:00	11.0	13.3	8.5	188.3	3,143,205.2	2,088.7	2.1	1.7
08/20/2020 20:00	10.9	13.3	8.5	185.9	3,114,993.9	2,092.7	2.1	1.7
08/20/2020 21:00	10.8	13.3	8.4	182.1	3,133,574.1	2,082.3	2.0	1.7
08/20/2020 22:00	10.7	13.3	8.3	172.9	3,113,860.4	2,069.2	1.9	1.4
08/20/2020 23:00	10.7	13.4	8.4	183.6	3,102,043.9	2,084.0	2.1	1.7
Average/Sum#:	10.8	13.4	8.5	180.6	3,178,929.2	2,071.3	2.0	1.6
Minimum:	10.6	13.3	8.3	171.1	3,102,043.9	2,047.5	1.8	1.4
Maximum:	11.2	13.4	8.8	188.3	3,249,470.9	2,092.7	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/21/2020 00:00	10.5	13.4	8.3	191.6	3,091,365.1	2,099.4	2.2	1.7
08/21/2020 01:00	10.4	13.4	8.2	188.0	3,096,536.5	2,080.3	2.1	1.7
08/21/2020 02:00	10.2	13.5	8.1	163.1	3,117,880.3	1,980.8	1.8	1.4
08/21/2020 03:00	10.3	13.4	8.1	181.5	3,097,876.1	2,081.2	2.0	1.7
08/21/2020 04:00	10.2	13.4	8.0	183.9	3,082,530.1	2,093.4	2.1	1.7
08/21/2020 05:00	10.2	13.4	8.0	182.4	1,365,230.9	2,083.6	4.8	3.8
08/21/2020 06:00	10.7	13.4	8.4	187.3	1,386,525.8	2,116.1	4.9	4.0
08/21/2020 07:00	10.3	13.4	8.1	190.1	1,381,939.2	2,109.1	5.0	4.0
08/21/2020 08:00	10.1	13.4	7.9	181.0	1,368,113.9	2,088.0	4.8	3.8
08/21/2020 09:00	10.2	13.4	8.0	191.2	1,389,015.7	2,119.9	5.0	4.0
08/21/2020 10:00	10.3	13.4	8.1	191.2	1,393,340.2	2,126.5	5.0	4.0
08/21/2020 11:00	10.4	13.3	8.1	174.6	1,396,616.3	2,131.5	4.5	3.6
08/21/2020 12:00	10.6	13.3	8.2	196.7	3,210,607.8	2,086.6	2.1	1.7
08/21/2020 13:00	10.4	13.4	8.2	200.6	3,105,467.5	2,086.3	2.3	1.9
08/21/2020 14:00	10.1	13.4	7.9	186.3	3,095,203.4	2,034.2	2.1	1.6
08/21/2020 15:00	10.5	13.3	8.2	200.8	3,152,262.8	2,071.7	2.2	1.7
08/21/2020 16:00	10.9	13.3	8.5	216.3	3,173,789.9	2,132.2	2.4	1.9
08/21/2020 17:00	11.0	13.3	8.5	214.5	3,156,007.8	2,143.3	2.4	1.9
08/21/2020 18:00	11.1	13.3	8.6	208.3	3,153,248.5	2,118.4	2.3	1.9
08/21/2020 19:00	11.1	13.3	8.6	204.7	3,176,303.8	2,087.5	2.2	1.7
08/21/2020 20:00	11.2	13.3	8.7	209.4	3,163,671.3	2,102.3	2.3	1.9
08/21/2020 21:00	11.2	13.3	8.7	206.1	3,203,222.1	2,081.8	2.2	1.7
08/21/2020 22:00	11.1	13.3	8.6	207.7	3,193,649.8	2,098.9	2.3	1.9
08/21/2020 23:00	11.1	13.3	8.6	210.6	3,177,516.0	2,111.5	2.3	1.9
Average/Sum#:	10.6	13.4	8.3	194.5	3,143,949.3	2,094.4	2.2	1.8
Minimum:	10.1	13.3	7.9	163.1	3,082,530.1	1,980.8	1.8	1.4
Maximum:	11.2	13.5	8.7	216.3	3,210,607.8	2,143.3	2.4	1.9
%SI	0.00	0.00	0.00	0.00	29.17	0.00	29.17	29.17

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/22/2020 00:00	10.8	13.3	8.4	205.0	3,185,491.8	2,116.8	2.3	1.9
08/22/2020 01:00	10.6	13.4	8.3	175.1	3,167,283.0	1,942.8	1.9	1.4
08/22/2020 02:00	9.0	13.9	7.6	123.7	3,222,583.5	1,670.8	1.3	0.8
08/22/2020 03:00	8.5	13.9	7.2	99.0	3,012,342.4	1,539.8	1.1	0.6
08/22/2020 04:00	8.6	13.9	7.2	113.1	3,207,539.1	1,663.0	1.2	0.8
08/22/2020 05:00	8.9	13.9	7.5	120.9	3,257,879.9	1,689.1	1.2	0.8
08/22/2020 06:00	8.9	13.9	7.5	116.9	3,256,336.9	1,688.3	1.2	0.8
08/22/2020 07:00	9.2	13.9	7.8	125.3	3,240,328.1	1,680.0	1.3	0.8
08/22/2020 08:00	9.4	13.9	7.9	124.5	3,227,791.1	1,673.5	1.3	0.8
08/22/2020 09:00	9.4	13.9	7.9	125.0	3,188,251.4	1,653.0	1.3	0.8
08/22/2020 10:00	9.2	13.9	7.8	119.2	3,024,692.0	1,568.2	1.3	0.8
08/22/2020 11:00	11.3	13.3	8.8	192.6	3,181,577.4	2,044.5	2.1	1.6
08/22/2020 12:00	11.3	13.2	8.7	211.3	3,103,931.5	2,130.6	2.4	1.9
08/22/2020 13:00	11.2	13.2	8.6	216.5	3,093,025.2	2,145.7	2.5	2.1
08/22/2020 14:00	11.1	13.3	8.6	207.7	3,090,776.1	2,099.0	2.4	1.9
08/22/2020 15:00	11.2	13.2	8.6	218.0	3,069,935.6	2,152.1	2.5	2.2
08/22/2020 16:00	11.3	13.2	8.7	220.7	3,051,275.2	2,161.3	2.5	2.2
08/22/2020 17:00	11.3	13.2	8.7	214.6	3,030,707.3	2,124.6	2.5	2.1
08/22/2020 18:00	11.2	13.2	8.6	210.2	3,069,404.5	2,106.9	2.4	1.9
08/22/2020 19:00	11.1	13.3	8.6	207.6	3,090,334.4	2,098.7	2.4	1.9
08/22/2020 20:00	11.1	13.3	8.6	203.2	3,071,044.6	2,085.6	2.3	1.9
08/22/2020 21:00	11.1	13.3	8.6	213.0	3,073,564.9	2,132.2	2.4	1.9
08/22/2020 22:00	10.9	13.3	8.5	203.7	3,102,261.6	2,106.8	2.3	1.9
08/22/2020 23:00	10.9	13.3	8.5	211.0	3,081,060.7	2,137.4	2.4	1.9
Average/Sum#:	10.3	13.5	8.2	174.1	3,129,142.4	1,933.8	1.9	1.5
Minimum:	8.5	13.2	7.2	99.0	3,012,342.4	1,539.8	1.1	0.6
Maximum:	11.3	13.9	8.8	220.7	3,257,879.9	2,161.3	2.5	2.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/23/2020 00:00	10.9	13.3	8.5	201.6	3,121,096.8	2,096.8	2.3	1.9
08/23/2020 01:00	10.9	13.3	8.5	193.6	3,134,155.9	2,059.8	2.2	1.6
08/23/2020 02:00	11.0	13.3	8.5	197.2	3,132,219.7	2,081.4	2.2	1.7
08/23/2020 03:00	10.9	13.3	8.5	192.8	3,143,133.3	2,065.7	2.1	1.7
08/23/2020 04:00	10.6	13.4	8.3	172.0	3,141,298.4	1,949.8	1.9	1.4
08/23/2020 05:00	8.6	13.9	7.2	151.9	3,211,300.2	1,688.4	1.6	1.0
08/23/2020 06:00	9.0	13.9	7.6	113.7	3,115,060.1	1,637.8	1.2	0.8
08/23/2020 07:00	8.9	13.9	7.5	105.6	3,014,065.0	1,584.7	1.2	0.8
08/23/2020 08:00	9.3	13.8	7.7	130.2	3,094,336.3	1,649.5	1.4	0.8
08/23/2020 09:00	9.4	13.8	7.8	131.2	3,033,181.2	1,616.9	1.5	1.0
08/23/2020 10:00	9.2	13.9	7.8	117.5	2,921,438.7	1,536.0	1.4	0.8
08/23/2020 11:00	11.2	13.3	8.7	191.3	3,109,962.8	2,043.9	2.1	1.6
08/23/2020 12:00	11.1	13.3	8.6	204.3	3,099,415.3	2,127.5	2.3	1.9
08/23/2020 13:00	10.9	13.3	8.5	203.1	3,064,195.2	2,125.7	2.3	1.9
08/23/2020 14:00	10.9	13.3	8.5	207.8	3,053,383.9	2,118.2	2.4	1.9
08/23/2020 15:00	10.9	13.2	8.4	213.2	3,043,510.4	2,155.8	2.5	2.2
08/23/2020 16:00	10.8	13.2	8.3	213.1	3,014,969.4	2,157.6	2.5	2.2
08/23/2020 17:00	10.7	13.2	8.2	211.9	2,990,878.2	2,162.2	2.5	2.2
08/23/2020 18:00	10.6	13.2	8.1	211.9	2,992,399.8	2,163.3	2.5	2.2
08/23/2020 19:00	10.6	13.2	8.1	212.7	3,029,641.8	2,168.1	2.5	2.2
08/23/2020 20:00	10.7	13.2	8.2	219.1	3,044,593.7	2,178.8	2.5	2.2
08/23/2020 21:00	10.7	13.3	8.3	209.1	3,080,484.1	2,137.0	2.4	1.9
08/23/2020 22:00	10.7	13.3	8.3	205.4	3,086,303.8	2,118.5	2.3	1.9
08/23/2020 23:00	10.8	13.3	8.4	205.3	3,083,244.4	2,116.4	2.3	1.9
Average/Sum#:	10.4	13.4	8.2	184.0	3,073,094.5	1,989.2	2.1	1.7
Minimum:	8.6	13.2	7.2	105.6	2,921,438.7	1,536.0	1.2	0.8
Maximum:	11.2	13.9	8.7	219.1	3,211,300.2	2,178.8	2.5	2.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/24/2020 00:00	10.8	13.3	8.4	209.1	3,096,647.3	2,125.6	2.4	1.9
08/24/2020 01:00	10.9	13.3	8.5	206.4	3,087,323.6	2,119.2	2.3	1.9
08/24/2020 02:00	10.9	13.3	8.5	210.1	3,083,511.3	2,139.1	2.4	1.9
08/24/2020 03:00	10.9	13.3	8.5	216.7	3,084,771.1	2,162.5	2.5	2.2
08/24/2020 04:00	11.0	13.3	8.5	215.2	3,094,034.2	2,146.4	2.4	1.9
08/24/2020 05:00	10.9	13.3	8.5	207.4	3,080,916.6	2,137.3	2.4	1.9
08/24/2020 06:00	11.1	13.3	8.6	207.5	3,097,521.4	2,126.2	2.3	1.9
08/24/2020 07:00	11.0	13.3	8.5	201.0	3,118,566.3	2,095.1	2.3	1.9
08/24/2020 08:00	11.0	13.3	8.5	201.8	3,106,360.6	2,086.9	2.3	1.9
08/24/2020 09:00	10.9	13.3	8.5	202.4	3,069,113.1	2,106.7	2.3	1.9
08/24/2020 10:00	10.9	13.3	8.5	211.9	3,098,070.4	2,149.2	2.4	1.9
08/24/2020 11:00	10.9	13.3	8.5	211.1	3,289,661.7	2,162.0	2.2	1.7
08/24/2020 12:00	10.9	13.3	8.5	219.0	3,327,545.6	2,138.3	2.3	1.9
08/24/2020 13:00	10.8	13.2	8.3	220.4	3,263,794.8	2,145.0	2.4	1.9
08/24/2020 14:00	10.9	13.3	8.5	218.3	3,256,768.1	2,116.6	2.3	1.9
08/24/2020 15:00	10.8	13.2	8.3	219.5	3,244,927.2	2,132.6	2.4	1.9
08/24/2020 16:00	10.9	13.2	8.4	221.6	3,236,807.6	2,150.9	2.4	1.9
08/24/2020 17:00	11.0	13.2	8.4	220.8	3,231,841.5	2,147.6	2.4	1.9
08/24/2020 18:00	10.8	13.2	8.3	225.1	3,238,613.4	2,152.1	2.4	1.9
08/24/2020 19:00	10.8	13.3	8.4	217.3	3,246,612.9	2,110.0	2.3	1.9
08/24/2020 20:00	11.1	13.3	8.6	223.8	3,278,001.9	2,130.4	2.4	1.9
08/24/2020 21:00	10.9	13.3	8.5	222.2	3,272,001.1	2,126.5	2.4	1.9
08/24/2020 22:00	10.9	13.3	8.5	217.8	3,316,030.0	2,130.9	2.3	1.9
08/24/2020 23:00	10.8	13.3	8.4	216.3	3,307,471.1	2,125.4	2.3	1.9
Average/Sum#:	10.9	13.3	8.5	214.3	3,188,621.4	2,131.8	2.4	1.9
Minimum:	10.8	13.2	8.3	201.0	3,069,113.1	2,086.9	2.2	1.7
Maximum:	11.1	13.3	8.6	225.1	3,327,545.6	2,162.5	2.5	2.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/25/2020 00:00	10.8	13.3	8.4	208.6	3,300,312.8	2,096.7	2.2	1.7
08/25/2020 01:00	10.9	13.3	8.5	208.5	3,286,775.9	2,088.1	2.2	1.7
08/25/2020 02:00	10.8	13.3	8.4	210.6	3,310,822.3	2,079.2	2.2	1.7
08/25/2020 03:00	10.8	13.3	8.4	198.9	3,376,633.1	2,021.9	2.0	1.6
08/25/2020 04:00	10.7	13.3	8.3	205.7	3,331,567.9	2,067.9	2.2	1.7
08/25/2020 05:00	10.9	13.3	8.5	202.7	3,342,362.1	2,074.6	2.1	1.7
08/25/2020 06:00	10.9	13.3	8.5	199.4	3,349,934.3	2,079.3	2.1	1.7
08/25/2020 07:00	10.9	13.3	8.5	200.5	3,362,915.0	2,062.8	2.1	1.7
08/25/2020 08:00	10.8	13.3	8.4	203.9	3,368,131.9	2,066.0	2.1	1.7
08/25/2020 09:00	10.8	13.3	8.4	210.5	3,322,605.7	2,086.6	2.2	1.7
08/25/2020 10:00	10.9	13.3	8.5	212.1	3,337,733.1	2,096.1	2.2	1.7
08/25/2020 11:00	10.7	13.3	8.3	207.7	3,325,153.5	2,088.2	2.2	1.7
08/25/2020 12:00	10.7	13.3	8.3	205.8	3,281,109.3	2,084.5	2.2	1.7
08/25/2020 13:00	10.7	13.3	8.3	208.3	3,286,146.3	2,087.7	2.2	1.7
08/25/2020 14:00	10.8	13.3	8.4	210.3	3,253,783.5	2,090.9	2.3	1.9
08/25/2020 15:00	10.9	13.3	8.5	213.1	3,227,994.8	2,097.9	2.3	1.9
08/25/2020 16:00	11.0	13.2	8.4	219.4	3,227,124.6	2,120.9	2.4	1.9
08/25/2020 17:00	11.0	13.2	8.4	226.5	3,237,108.6	2,151.1	2.5	2.2
08/25/2020 18:00	11.0	13.2	8.4	227.4	3,221,570.9	2,164.3	2.5	2.2
08/25/2020 19:00	10.9	13.2	8.4	226.4	3,218,593.9	2,162.3	2.5	2.2
08/25/2020 20:00	10.9	13.3	8.5	218.3	3,263,384.5	2,120.9	2.3	1.9
08/25/2020 21:00	10.9	13.3	8.5	236.1	3,242,612.3	2,107.4	2.6	2.1
08/25/2020 22:00	10.8	13.3	8.4	248.6	3,263,431.7	2,097.1	2.7	2.1
08/25/2020 23:00	10.9	13.3	8.5	211.0	3,263,120.4	2,096.9	2.3	1.9
Average/Sum#:	10.9	13.3	8.4	213.3	3,291,705.4	2,095.4	2.3	1.8
Minimum:	10.7	13.2	8.3	198.9	3,218,593.9	2,021.9	2.0	1.6
Maximum:	11.0	13.3	8.5	248.6	3,376,633.1	2,164.3	2.7	2.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/26/2020 00:00	10.8	13.3	8.4	206.7	3,319,484.7	2,060.4	2.2	1.6
08/26/2020 01:00	10.9	13.4	8.6	197.8	3,346,530.8	1,955.0	2.1	1.6
08/26/2020 02:00	10.8	13.4	8.5	184.5	3,391,838.9	1,956.7	1.9	1.4
08/26/2020 03:00	10.8	13.3	8.4	197.6	3,346,938.4	2,053.0	2.1	1.6
08/26/2020 04:00	10.7	13.3	8.3	204.0	3,365,360.4	2,064.3	2.1	1.7
08/26/2020 05:00	10.6	13.3	8.2	169.2	3,370,903.3	2,067.7	1.7	1.4
08/26/2020 06:00	10.9	13.3	8.5	203.3	3,370,577.3	2,067.5	2.1	1.7
08/26/2020 07:00	10.7	13.4	8.4	182.0	3,389,412.0	1,955.3	1.9	1.4
08/26/2020 08:00	10.9	13.4	8.6	193.6	3,395,652.4	1,958.9	2.0	1.6
08/26/2020 09:00	11.0	13.3	8.5	208.4	3,337,690.0	2,071.7	2.2	1.7
08/26/2020 10:00	11.0	13.3	8.5	212.9	3,343,147.1	2,099.5	2.2	1.7
08/26/2020 11:00	11.0	13.3	8.5	209.5	3,297,636.9	2,095.0	2.2	1.7
08/26/2020 12:00	11.0	13.3	8.5	213.1	3,275,725.4	2,105.0	2.3	1.9
08/26/2020 13:00	10.9	13.3	8.5	214.4	3,272,457.4	2,102.9	2.3	1.9
08/26/2020 14:00	11.0	13.2	8.4	219.6	3,235,493.3	2,126.4	2.4	1.9
08/26/2020 15:00	10.9	13.2	8.4	225.7	3,206,834.7	2,154.4	2.5	2.2
08/26/2020 16:00	10.8	13.3	8.4	213.5	3,235,887.6	2,079.4	2.3	1.9
08/26/2020 17:00	10.9	13.3	8.5	208.5	3,241,758.1	2,059.5	2.2	1.6
08/26/2020 18:00	10.9	13.3	8.5	204.6	3,243,646.9	2,060.7	2.2	1.6
08/26/2020 19:00	10.9	13.3	8.5	201.0	3,267,510.3	2,052.0	2.1	1.6
08/26/2020 20:00	10.8	13.3	8.4	198.6	3,318,734.8	2,035.7	2.1	1.6
08/26/2020 21:00	10.8	13.3	8.4	197.1	3,335,125.8	2,021.4	2.1	1.6
08/26/2020 22:00	10.7	13.4	8.4	190.7	3,355,774.5	1,960.4	2.0	1.6
08/26/2020 23:00	10.6	13.4	8.3	178.9	3,376,757.8	1,948.0	1.8	1.4
Average/Sum#:	10.8	13.3	8.4	201.5	3,318,370.0	2,046.3	2.1	1.7
Minimum:	10.6	13.2	8.2	169.2	3,206,834.7	1,948.0	1.7	1.4
Maximum:	11.0	13.4	8.6	225.7	3,395,652.4	2,154.4	2.5	2.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/27/2020 00:00	10.5	13.4	8.3	177.5	3,409,340.0	1,941.9	1.8	1.4
08/27/2020 01:00	10.4	13.4	8.2	180.9	3,406,004.2	1,940.0	1.8	1.4
08/27/2020 02:00	10.3	13.4	8.1	168.2	3,405,828.7	1,939.9	1.7	1.4
08/27/2020 03:00	10.2	13.4	8.0	164.8	3,431,285.9	1,954.4	1.6	1.2
08/27/2020 04:00	10.2	13.4	8.0	183.2	3,367,153.7	2,065.4	1.9	1.4
08/27/2020 05:00	9.9	13.4	7.8	198.1	3,371,066.4	2,067.8	2.1	1.7
08/27/2020 06:00	10.4	13.3	8.1	190.8	3,361,856.3	2,086.7	2.0	1.7
08/27/2020 07:00	10.4	13.4	8.2	180.8	3,426,018.9	1,951.4	1.8	1.4
08/27/2020 08:00	10.6	13.4	8.3	189.6	3,370,621.0	2,018.3	1.9	1.4
08/27/2020 09:00	10.8	13.4	8.5	195.3	3,369,619.0	2,017.7	2.0	1.6
08/27/2020 10:00	10.8	13.3	8.4	191.6	3,325,556.4	2,015.6	2.0	1.6
08/27/2020 11:00	10.8	13.3	8.4	214.1	3,311,083.5	2,151.9	2.3	1.9
08/27/2020 12:00	10.8	13.2	8.3	221.4	3,277,288.4	2,177.8	2.4	2.0
08/27/2020 13:00	10.6	13.2	8.1	201.3	3,271,720.4	2,174.1	2.2	1.7
08/27/2020 14:00	10.7	13.2	8.2	178.6	3,156,523.2	2,166.7	2.0	1.7
08/27/2020 15:00	10.8	13.3	8.4	214.7	3,166,284.0	2,173.4	2.4	2.0
08/27/2020 16:00	10.8	13.3	8.4	197.9	3,211,223.2	2,087.0	2.1	1.7
08/27/2020 17:00	10.8	13.3	8.4	195.6	3,184,063.9	2,092.6	2.1	1.7
08/27/2020 18:00	10.8	13.3	8.4	195.7	3,194,714.9	2,099.6	2.1	1.7
08/27/2020 19:00	10.8	13.3	8.4	203.7	3,214,234.7	2,135.9	2.2	1.7
08/27/2020 20:00	10.8	13.3	8.4	210.0	3,206,983.5	2,154.5	2.3	1.9
08/27/2020 21:00	10.8	13.3	8.4	216.2	3,182,017.8	2,184.2	2.4	2.0
08/27/2020 22:00	10.8	13.3	8.4	216.8	3,185,368.5	2,186.5	2.4	2.0
08/27/2020 23:00	10.6	13.4	8.3	183.1	3,244,739.6	2,037.7	2.0	1.6
Average/Sum#:	10.6	13.3	8.3	194.6	3,293,774.8	2,075.9	2.1	1.7
Minimum:	9.9	13.2	7.8	164.8	3,156,523.2	1,939.9	1.6	1.2
Maximum:	10.8	13.4	8.5	221.4	3,431,285.9	2,186.5	2.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/28/2020 00:00	10.6	13.4	8.3	174.5	3,232,676.6	1,935.7	1.9	1.4
08/28/2020 01:00	9.3	13.8	7.7	118.5	2,982,019.4	1,524.3	1.3	0.8
08/28/2020 02:00	8.9	14.0	7.6	95.3	2,877,378.9	1,449.8	1.1	0.6
08/28/2020 03:00	9.3	14.0	8.0	89.5	2,558,045.1	1,288.9	1.2	0.6
08/28/2020 04:00	8.8	13.9	7.4	97.0	2,924,018.8	1,473.3	1.1	0.6
08/28/2020 05:00	8.7	13.9	7.3	115.0	3,165,553.5	1,595.0	1.2	0.8
08/28/2020 06:00	9.1	13.9	7.7	97.2	2,886,905.4	1,454.6	1.1	0.6
08/28/2020 07:00	9.4	14.0	8.0	95.7	2,729,719.3	1,375.4	1.2	0.7
08/28/2020 08:00	9.3	14.0	8.0	98.3	2,770,802.0	1,396.1	1.2	0.7
08/28/2020 09:00	9.3	13.9	7.8	99.7	2,831,334.5	1,426.6	1.2	0.7
08/28/2020 10:00	9.1	13.9	7.7	102.2	2,899,607.3	1,461.0	1.2	0.7
08/28/2020 11:00	9.4	13.9	7.9	121.3	2,962,064.9	1,514.1	1.4	0.8
08/28/2020 12:00	11.4	13.3	8.9	203.5	3,166,909.3	2,058.2	2.2	1.6
08/28/2020 13:00	11.4	13.2	8.7	218.1	3,137,567.5	2,176.6	2.4	2.0
08/28/2020 14:00	11.2	13.2	8.6	216.7	3,127,477.0	2,169.6	2.4	2.0
08/28/2020 15:00	11.1	13.2	8.5	214.4	3,121,278.5	2,165.3	2.4	1.9
08/28/2020 16:00	11.1	13.2	8.5	217.0	3,132,810.5	2,173.3	2.4	2.0
08/28/2020 17:00	11.0	13.2	8.4	212.9	3,118,395.5	2,163.3	2.4	1.9
08/28/2020 18:00	10.9	13.2	8.4	211.8	3,133,942.3	2,151.2	2.4	1.9
08/28/2020 19:00	10.8	13.3	8.4	191.6	3,169,063.4	2,059.6	2.1	1.6
08/28/2020 20:00	10.8	13.3	8.4	186.7	3,184,067.3	2,046.1	2.0	1.6
08/28/2020 21:00	10.8	13.3	8.4	184.8	3,219,721.4	2,045.5	2.0	1.6
08/28/2020 22:00	10.8	13.4	8.5	180.0	3,212,508.5	1,994.0	1.9	1.4
08/28/2020 23:00	11.0	13.3	8.5	195.4	3,216,916.4	2,090.7	2.1	1.7
Average/Sum#:	10.1	13.6	8.2	155.7	3,031,699.3	1,799.5	1.7	1.3
Minimum:	8.7	13.2	7.3	89.5	2,558,045.1	1,288.9	1.1	0.6
Maximum:	11.4	14.0	8.9	218.1	3,232,676.6	2,176.6	2.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/29/2020 00:00	10.9	13.3	8.5	196.9	3,195,627.9	2,100.2	2.1	1.7
08/29/2020 01:00	11.0	13.3	8.5	196.1	3,228,302.6	2,098.1	2.1	1.7
08/29/2020 02:00	10.8	13.3	8.4	186.3	3,257,656.0	2,069.6	2.0	1.7
08/29/2020 03:00	10.6	13.4	8.3	169.2	3,255,222.0	1,949.2	1.8	1.4
08/29/2020 04:00	8.9	13.9	7.5	116.9	3,141,850.8	1,606.0	1.3	0.8
08/29/2020 05:00	9.1	13.9	7.7	120.5	3,103,702.6	1,586.5	1.3	0.8
08/29/2020 06:00	9.3	13.9	7.8	111.7	3,050,686.3	1,559.4	1.2	0.8
08/29/2020 07:00	9.4	13.9	7.9	96.6	2,794,799.5	1,428.6	1.1	0.6
08/29/2020 08:00	9.3	13.9	7.8	92.7	2,701,874.3	1,381.1	1.1	0.6
08/29/2020 09:00	10.0	13.9	8.4	88.5	2,545,343.1	1,282.5	1.1	0.5
08/29/2020 10:00	10.0	14.0	8.6	89.1	2,571,937.8	1,295.9	1.1	0.5
08/29/2020 11:00	9.6	14.0	8.2	92.1	2,637,828.9	1,329.1	1.1	0.5
08/29/2020 12:00	9.9	14.0	8.5	88.1	2,556,060.4	1,287.9	1.1	0.5
08/29/2020 13:00	9.3	13.9	7.8	119.3	3,110,354.0	1,589.9	1.3	0.8
08/29/2020 14:00	9.2	13.9	7.8	118.9	3,124,830.8	1,597.3	1.3	0.8
08/29/2020 15:00	9.3	13.8	7.7	121.4	3,094,706.2	1,604.5	1.3	0.8
08/29/2020 16:00	9.4	13.8	7.8	127.0	3,190,373.1	1,654.1	1.3	0.8
08/29/2020 17:00	11.3	13.3	8.8	187.6	3,142,068.2	2,065.0	2.1	1.7
08/29/2020 18:00	11.1	13.2	8.5	199.5	3,106,531.9	2,109.7	2.2	1.7
08/29/2020 19:00	11.0	13.3	8.5	199.7	3,141,787.0	2,110.7	2.2	1.7
08/29/2020 20:00	11.1	13.2	8.5	214.7	3,131,513.2	2,172.4	2.4	2.0
08/29/2020 21:00	10.9	13.2	8.4	207.0	3,159,100.1	2,145.4	2.3	1.9
08/29/2020 22:00	10.9	13.3	8.5	184.1	3,221,332.0	2,023.0	2.0	1.6
08/29/2020 23:00	10.9	13.4	8.6	182.2	3,251,174.6	2,018.0	1.9	1.4
Average/Sum#:	10.1	13.6	8.2	146.1	3,029,777.6	1,752.7	1.6	1.1
Minimum:	8.9	13.2	7.5	88.1	2,545,343.1	1,282.5	1.1	0.5
Maximum:	11.3	14.0	8.8	214.7	3,257,656.0	2,172.4	2.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/30/2020 00:00	10.7	13.4	8.4	167.9	3,224,159.4	1,930.6	1.8	1.4
08/30/2020 01:00	9.7	13.7	7.9	147.9	3,329,983.6	1,750.8	1.5	1.1
08/30/2020 02:00	9.8	13.7	8.0	144.3	3,336,450.4	1,754.2	1.5	1.1
08/30/2020 03:00	9.9	13.7	8.1	148.5	3,337,401.3	1,754.7	1.5	1.1
08/30/2020 04:00	9.8	13.7	8.0	139.3	3,386,142.9	1,755.6	1.4	0.9
08/30/2020 05:00	9.9	13.7	8.1	139.3	3,322,756.1	1,747.0	1.4	0.9
08/30/2020 06:00	9.9	13.7	8.1	131.7	3,369,555.5	1,747.0	1.3	0.9
08/30/2020 07:00	10.3	13.7	8.4	143.3	3,329,793.4	1,750.7	1.5	1.1
08/30/2020 08:00	9.9	13.7	8.1	144.5	3,341,205.3	1,756.7	1.5	1.1
08/30/2020 09:00	10.7	13.6	8.6	163.1	3,308,004.1	1,763.4	1.7	1.2
08/30/2020 10:00	11.0	13.6	8.9	169.8	3,303,877.0	1,761.2	1.8	1.2
08/30/2020 11:00	10.9	13.6	8.8	167.1	3,289,620.0	1,753.6	1.7	1.2
08/30/2020 12:00	10.9	13.6	8.8	161.9	3,272,924.3	1,744.7	1.7	1.2
08/30/2020 13:00	9.9	13.7	8.1	131.1	3,106,120.8	1,633.1	1.4	0.8
08/30/2020 14:00	9.7	13.8	8.1	123.4	2,970,300.8	1,540.0	1.4	0.8
08/30/2020 15:00	11.5	13.3	8.9	192.8	3,182,390.1	2,091.5	2.1	1.7
08/30/2020 16:00	11.3	13.2	8.7	215.3	3,106,311.0	2,177.6	2.4	2.0
08/30/2020 17:00	11.2	13.2	8.6	202.6	3,131,417.1	2,126.6	2.3	1.9
08/30/2020 18:00	10.9	13.3	8.5	197.2	3,157,501.4	2,098.2	2.2	1.7
08/30/2020 19:00	11.0	13.3	8.5	188.4	3,197,917.2	2,055.0	2.0	1.6
08/30/2020 20:00	11.1	13.3	8.6	188.7	3,188,113.3	2,048.7	2.1	1.6
08/30/2020 21:00	11.1	13.3	8.6	184.2	3,206,499.3	2,037.1	2.0	1.6
08/30/2020 22:00	11.2	13.3	8.7	184.1	3,198,314.3	2,031.9	2.0	1.6
08/30/2020 23:00	11.0	13.4	8.7	171.2	3,207,917.9	1,944.3	1.8	1.4
Average/Sum#:	10.6	13.5	8.4	164.5	3,241,861.5	1,864.8	1.8	1.3
Minimum:	9.7	13.2	7.9	123.4	2,970,300.8	1,540.0	1.3	0.8
Maximum:	11.5	13.8	8.9	215.3	3,386,142.9	2,177.6	2.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/31/2020 00:00	9.1	13.8	7.6	121.8	3,113,801.0	1,614.4	1.3	0.8
08/31/2020 01:00	9.7	13.9	8.2	89.3	2,549,281.3	1,303.1	1.2	0.7
08/31/2020 02:00	9.6	14.0	8.2	87.9	2,559,037.4	1,289.4	1.1	0.5
08/31/2020 03:00	9.6	14.0	8.2	88.0	2,579,876.5	1,299.9	1.1	0.5
08/31/2020 04:00	9.1	13.8	7.6	121.4	3,161,441.6	1,639.1	1.3	0.8
08/31/2020 05:00	9.2	13.8	7.6	122.4	3,219,690.3	1,669.3	1.3	0.8
08/31/2020 06:00	9.3	13.8	7.7	123.0	3,266,173.6	1,693.4	1.3	0.8
08/31/2020 07:00	9.4	13.9	7.9	90.9	2,710,286.5	1,385.4	1.1	0.6
08/31/2020 08:00	9.3	13.9	7.8	94.4	2,753,129.9	1,407.3	1.1	0.6
08/31/2020 09:00	9.2	14.0	7.9	87.5	2,604,684.9	1,312.4	1.1	0.5
08/31/2020 10:00	9.2	14.0	7.9	87.2	2,584,242.7	1,302.1	1.1	0.5
08/31/2020 11:00	8.7	14.0	7.4	99.2	2,985,742.1	1,504.4	1.1	0.6
08/31/2020 12:00	9.8	13.9	8.3	118.2	2,911,396.2	1,488.2	1.4	0.7
08/31/2020 13:00	11.5	13.3	8.9	191.5	3,192,432.6	2,098.1	2.1	1.7
08/31/2020 14:00	11.4	13.2	8.7	217.9	3,153,424.0	2,187.6	2.4	2.0
08/31/2020 15:00	11.3	13.2	8.7	215.6	3,144,198.4	2,181.2	2.4	2.0
08/31/2020 16:00	11.3	13.3	8.8	194.9	3,158,653.4	2,075.9	2.1	1.7
08/31/2020 17:00	11.2	13.3	8.7	187.7	3,185,001.0	2,046.7	2.0	1.6
08/31/2020 18:00	11.2	13.4	8.8	186.2	3,214,841.8	2,042.4	2.0	1.6
08/31/2020 19:00	11.2	13.3	8.7	181.5	3,202,721.6	2,034.7	2.0	1.6
08/31/2020 20:00	11.3	13.3	8.8	180.6	3,198,629.1	2,032.1	1.9	1.4
08/31/2020 21:00	11.2	13.3	8.7	178.6	3,230,249.2	2,028.6	1.9	1.4
08/31/2020 22:00	11.2	13.4	8.8	175.4	3,223,561.3	2,024.4	1.9	1.4
08/31/2020 23:00	10.5	13.5	8.4	154.3	3,108,766.7	1,793.4	1.7	1.3
Average/Sum#:	10.2	13.6	8.3	141.5	3,000,469.3	1,727.2	1.6	1.1
Minimum:	8.7	13.2	7.4	87.2	2,549,281.3	1,289.4	1.1	0.5
Maximum:	11.5	14.0	8.9	217.9	3,266,173.6	2,187.6	2.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/01/2020 00:00	9.6	14.0	8.2	89.4	2,576,899.4	1,298.4	1.1	0.5
09/01/2020 01:00	9.0	13.9	7.6	95.8	2,929,198.8	1,497.3	1.1	0.6
09/01/2020 02:00	9.4	14.0	8.0	107.4	2,765,641.9	1,393.5	1.3	0.7
09/01/2020 03:00	9.4	14.0	8.0	90.4	2,580,868.8	1,300.4	1.2	0.7
09/01/2020 04:00	9.0	14.0	7.7	86.8	2,673,553.0	1,347.1	1.1	0.5
09/01/2020 05:00	10.4	13.8	8.6	129.4	3,237,820.7	1,678.7	1.3	0.8
09/01/2020 06:00	9.2	13.9	7.8	114.7	3,234,189.1	1,653.2	1.2	0.8
09/01/2020 07:00	9.3	13.9	7.8	116.5	3,234,156.1	1,676.8	1.2	0.8
09/01/2020 08:00	0.0	0.0	0.0	102.8	1,045,938.8	1,596.3	3.7	2.2
09/01/2020 09:00	9.5	13.8	7.9	230.4	3,175,499.5	1,623.2	2.6	1.6
09/01/2020 10:00	9.7	13.9	8.2	97.9	2,902,788.4	1,483.8	1.1	0.6
09/01/2020 11:00	9.8	14.0	8.4	88.7	2,641,780.7	1,311.8	1.1	0.5
09/01/2020 12:00	9.3	14.1	8.1	88.3	2,699,578.5	1,340.5	1.1	0.5
09/01/2020 13:00	9.1	14.0	7.8	95.1	2,997,831.1	1,488.6	1.0	0.6
09/01/2020 14:00	9.4	13.9	7.9	121.3	3,271,931.9	1,648.6	1.2	0.8
09/01/2020 15:00	9.2	13.9	7.8	108.4	3,199,888.3	1,612.3	1.1	0.6
09/01/2020 16:00	10.0	13.9	8.4	125.5	3,014,885.6	1,541.1	1.4	0.8
09/01/2020 17:00	11.5	13.3	8.9	174.0	3,176,449.1	2,064.4	1.9	1.4
09/01/2020 18:00	11.4	13.2	8.7	201.2	3,177,506.3	2,157.9	2.2	1.7
09/01/2020 19:00	11.2	13.2	8.6	193.6	3,172,450.2	2,131.3	2.1	1.7
09/01/2020 20:00	11.1	13.3	8.6	171.4	3,228,816.1	2,027.7	1.8	1.4
09/01/2020 21:00	11.1	13.3	8.6	167.8	3,244,891.4	2,014.1	1.8	1.4
09/01/2020 22:00	10.9	13.4	8.6	158.0	3,290,168.9	1,946.1	1.6	1.2
09/01/2020 23:00	10.3	13.5	8.2	142.2	3,171,373.5	1,783.2	1.5	1.1
Average/Sum#:	9.9	13.7	8.2	129.0	3,026,007.3	1,650.7	1.4	0.9
Minimum:	9.0	13.2	7.6	86.8	2,576,899.4	1,298.4	1.0	0.5
Maximum:	11.5	14.1	8.9	230.4	3,290,168.9	2,157.9	2.6	1.7
%SI	4.17	4.17	4.17	0.00	4.17	0.00	4.17	4.17

Daily Summary Report

CT1 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/02/2020 00:00	9.8	13.9	8.3	89.3	2,555,861.9	1,287.8	1.1	0.5
09/02/2020 01:00	9.8	13.9	8.3	88.1	2,548,717.1	1,284.2	1.1	0.5
09/02/2020 02:00	9.6	13.9	8.1	88.1	2,582,853.5	1,301.4	1.1	0.5
09/02/2020 03:00	9.5	13.9	8.0	87.6	2,569,754.6	1,294.8	1.1	0.5
09/02/2020 04:00	9.5	13.9	8.0	88.3	2,616,394.4	1,318.3	1.1	0.5
09/02/2020 05:00	9.6	13.9	8.1	86.4	2,552,091.0	1,285.9	1.1	0.5
09/02/2020 06:00	9.8	13.9	8.3	87.8	2,565,388.3	1,292.6	1.1	0.5
09/02/2020 07:00	9.3	13.9	7.8	93.5	2,795,808.9	1,408.7	1.1	0.6
09/02/2020 08:00	9.3	13.9	7.8	87.7	2,714,238.8	1,367.6	1.1	0.5
09/02/2020 09:00	9.3	13.9	7.8	87.7	2,728,330.0	1,374.7	1.1	0.5
09/02/2020 10:00	9.2	13.9	7.8	87.5	2,745,596.7	1,383.4	1.0	0.6
09/02/2020 11:00	9.2	13.9	7.8	88.7	2,763,061.8	1,392.2	1.1	0.6
09/02/2020 12:00	9.2	13.9	7.8	90.1	2,767,825.0	1,394.6	1.1	0.6
09/02/2020 13:00	9.3	14.0	8.0	91.3	2,768,221.9	1,394.8	1.1	0.6
09/02/2020 14:00	9.4	14.0	8.0	92.2	2,767,229.6	1,394.3	1.1	0.6
09/02/2020 15:00	9.6	13.9	8.1	95.4	2,816,449.5	1,419.1	1.1	0.6
09/02/2020 16:00	11.5	13.4	9.0	180.2	3,247,733.6	1,921.0	1.9	1.3
09/02/2020 17:00	11.5	13.3	8.9	177.3	3,240,256.1	1,963.9	1.9	1.4
09/02/2020 18:00	11.5	13.4	9.0	169.4	3,269,751.2	1,957.9	1.8	1.4
09/02/2020 19:00	11.4	13.4	9.0	175.9	3,294,564.6	1,948.7	1.8	1.4
09/02/2020 20:00	11.4	13.4	9.0	167.2	3,232,348.7	1,911.9	1.8	1.3
09/02/2020 21:00	9.4	13.9	7.9	91.5	2,759,886.3	1,390.6	1.1	0.6
09/02/2020 22:00	9.4	13.9	7.9	88.1	2,726,345.3	1,373.7	1.1	0.5
09/02/2020 23:00	9.4	13.9	7.9	88.0	2,733,887.1	1,377.5	1.1	0.6
Average/Sum#:	9.9	13.8	8.2	107.0	2,806,774.8	1,476.7	1.3	0.7
Minimum:	9.2	13.3	7.8	86.4	2,548,717.1	1,284.2	1.0	0.5
Maximum:	11.5	14.0	9.0	180.2	3,294,564.6	1,963.9	1.9	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/03/2020 00:00	9.4	13.9	7.9	87.9	2,726,940.7	1,374.0	1.1	0.5
09/03/2020 01:00	9.3	13.9	7.8	87.7	2,725,948.4	1,373.5	1.1	0.5
09/03/2020 02:00	9.3	13.9	7.8	87.8	2,730,910.1	1,376.0	1.1	0.6
09/03/2020 03:00	9.1	13.9	7.7	107.3	3,218,147.3	1,621.5	1.1	0.6
09/03/2020 04:00	9.4	13.9	7.9	94.6	2,869,638.7	1,445.9	1.1	0.6
09/03/2020 05:00	9.1	13.9	7.7	105.4	3,122,684.5	1,573.4	1.1	0.6
09/03/2020 06:00	9.2	13.9	7.8	101.7	3,153,248.5	1,588.8	1.1	0.6
09/03/2020 07:00	9.2	13.9	7.8	107.2	3,266,573.3	1,645.9	1.1	0.7
09/03/2020 08:00	9.1	13.9	7.7	104.4	3,258,833.1	1,642.0	1.1	0.7
09/03/2020 09:00	9.2	13.9	7.8	99.1	3,055,801.0	1,539.7	1.1	0.6
09/03/2020 10:00	9.2	13.9	7.8	102.7	3,129,829.4	1,577.0	1.1	0.6
09/03/2020 11:00	9.5	13.8	7.9	105.7	3,033,572.7	1,528.5	1.2	0.8
09/03/2020 12:00	11.6	13.2	8.9	182.8	3,257,673.9	2,093.4	1.9	1.5
09/03/2020 13:00	11.4	13.2	8.7	199.4	3,208,323.2	2,155.4	2.2	1.7
09/03/2020 14:00	11.3	13.3	8.8	189.4	3,210,082.9	2,109.7	2.0	1.7
09/03/2020 15:00	11.2	13.2	8.6	198.9	3,182,218.3	2,161.1	2.2	1.7
09/03/2020 16:00	11.1	13.2	8.5	199.7	3,156,668.9	2,166.8	2.2	1.7
09/03/2020 17:00	11.2	13.2	8.6	202.7	3,156,086.2	2,166.4	2.2	1.7
09/03/2020 18:00	11.3	13.2	8.7	204.6	3,162,059.2	2,170.5	2.3	2.0
09/03/2020 19:00	11.1	13.2	8.5	190.7	3,182,181.1	2,114.6	2.1	1.7
09/03/2020 20:00	11.0	13.3	8.5	171.9	3,201,777.2	2,034.1	1.8	1.4
09/03/2020 21:00	11.1	13.3	8.6	171.3	3,233,274.7	2,030.5	1.8	1.4
09/03/2020 22:00	11.1	13.3	8.6	176.9	3,219,547.8	2,068.9	1.9	1.4
09/03/2020 23:00	11.1	13.2	8.5	195.4	3,215,319.1	2,160.1	2.1	1.7
Average/Sum#:	10.2	13.6	8.2	144.8	3,111,555.8	1,821.6	1.6	1.1
Minimum:	9.1	13.2	7.7	87.7	2,725,948.4	1,373.5	1.1	0.5
Maximum:	11.6	13.9	8.9	204.6	3,266,573.3	2,170.5	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/04/2020 00:00	10.9	13.3	8.5	173.2	3,294,190.6	2,044.7	1.8	1.4
09/04/2020 01:00	10.9	13.3	8.5	165.6	3,307,572.4	2,004.7	1.7	1.4
09/04/2020 02:00	10.9	13.3	8.5	163.8	3,310,542.2	2,006.5	1.7	1.4
09/04/2020 03:00	10.9	13.4	8.6	164.0	3,354,755.7	2,008.8	1.7	1.4
09/04/2020 04:00	11.1	13.2	8.5	197.7	3,285,857.7	2,159.5	2.1	1.7
09/04/2020 05:00	11.1	13.2	8.5	218.6	3,262,951.3	2,192.1	2.3	2.0
09/04/2020 06:00	11.2	13.2	8.6	189.7	3,254,113.5	2,162.4	2.0	1.7
09/04/2020 07:00	11.0	13.3	8.5	193.8	3,262,273.2	2,144.0	2.1	1.7
09/04/2020 08:00	11.1	13.3	8.6	173.7	3,285,168.5	2,039.1	1.8	1.4
09/04/2020 09:00	11.1	13.3	8.6	168.1	3,267,381.4	2,004.2	1.8	1.4
09/04/2020 10:00	11.1	13.3	8.6	181.5	3,248,803.7	2,087.7	1.9	1.5
09/04/2020 11:00	11.0	13.2	8.4	184.7	3,228,646.2	2,121.9	2.0	1.7
09/04/2020 12:00	11.1	13.2	8.5	191.3	3,219,351.2	2,139.3	2.1	1.7
09/04/2020 13:00	10.9	13.2	8.4	193.9	3,191,056.5	2,143.8	2.1	1.7
09/04/2020 14:00	10.9	13.2	8.4	191.5	3,190,461.1	2,143.4	2.1	1.7
09/04/2020 15:00	10.9	13.2	8.4	193.1	3,202,666.9	2,151.6	2.1	1.7
09/04/2020 16:00	10.9	13.2	8.4	196.1	3,173,825.1	2,155.4	2.2	1.7
09/04/2020 17:00	10.9	13.2	8.4	199.9	3,181,187.6	2,160.4	2.2	1.7
09/04/2020 18:00	10.9	13.2	8.4	199.5	3,187,666.6	2,164.8	2.2	1.7
09/04/2020 19:00	10.9	13.2	8.4	197.4	3,193,851.1	2,169.0	2.2	1.7
09/04/2020 20:00	10.8	13.2	8.3	194.0	3,195,912.6	2,170.4	2.1	1.7
09/04/2020 21:00	10.7	13.2	8.2	185.6	3,216,341.5	2,137.3	2.0	1.7
09/04/2020 22:00	10.9	13.3	8.5	191.0	3,251,926.4	2,137.2	2.0	1.7
09/04/2020 23:00	10.8	13.3	8.4	171.4	3,305,951.6	2,052.0	1.8	1.4
Average/Sum#:	11.0	13.2	8.5	186.6	3,244,685.6	2,112.5	2.0	1.6
Minimum:	10.7	13.2	8.2	163.8	3,173,825.1	2,004.2	1.7	1.4
Maximum:	11.2	13.4	8.6	218.6	3,354,755.7	2,192.1	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/05/2020 00:00	10.9	13.3	8.5	167.8	3,307,649.0	2,028.9	1.7	1.4
09/05/2020 01:00	10.8	13.3	8.4	167.4	3,315,311.2	2,033.6	1.7	1.4
09/05/2020 02:00	10.8	13.3	8.4	165.1	3,313,681.0	2,032.6	1.7	1.4
09/05/2020 03:00	10.8	13.3	8.4	167.1	3,317,104.5	2,034.7	1.7	1.4
09/05/2020 04:00	10.7	13.3	8.3	166.8	3,337,319.8	2,047.1	1.7	1.4
09/05/2020 05:00	10.7	13.3	8.3	172.8	3,333,713.4	1,996.2	1.8	1.4
09/05/2020 06:00	9.2	13.8	7.6	110.5	3,267,168.7	1,646.2	1.1	0.7
09/05/2020 07:00	9.4	13.8	7.8	104.7	3,126,653.9	1,575.4	1.1	0.6
09/05/2020 08:00	9.5	13.8	7.9	110.5	3,213,781.0	1,619.3	1.1	0.6
09/05/2020 09:00	9.5	13.8	7.9	110.0	3,168,728.9	1,596.6	1.1	0.6
09/05/2020 10:00	9.7	13.8	8.1	117.3	3,232,436.9	1,628.7	1.2	0.8
09/05/2020 11:00	11.6	13.3	9.0	179.6	3,258,915.2	2,070.4	1.9	1.4
09/05/2020 12:00	11.4	13.2	8.7	194.7	3,194,777.8	2,146.3	2.1	1.7
09/05/2020 13:00	11.2	13.2	8.6	199.7	3,177,653.6	2,158.0	2.2	1.7
09/05/2020 14:00	10.9	13.2	8.4	200.5	3,179,715.1	2,159.4	2.2	1.7
09/05/2020 15:00	11.0	13.2	8.4	199.4	3,141,080.8	2,156.1	2.2	1.7
09/05/2020 16:00	11.0	13.2	8.4	200.0	3,127,095.1	2,146.5	2.2	1.7
09/05/2020 17:00	10.9	13.2	8.4	198.2	3,140,789.4	2,155.9	2.2	1.7
09/05/2020 18:00	10.9	13.2	8.4	200.0	3,150,841.6	2,162.8	2.2	1.7
09/05/2020 19:00	10.9	13.2	8.4	202.1	3,158,271.4	2,167.9	2.2	1.7
09/05/2020 20:00	10.9	13.2	8.4	201.0	3,163,079.0	2,171.2	2.2	1.7
09/05/2020 21:00	10.9	13.2	8.4	197.5	3,171,674.3	2,177.1	2.2	1.7
09/05/2020 22:00	10.8	13.2	8.3	198.9	3,219,767.1	2,186.6	2.2	1.7
09/05/2020 23:00	10.7	13.3	8.3	185.7	3,222,255.6	2,117.7	2.0	1.7
Average/Sum#:	10.6	13.4	8.3	171.6	3,218,311.0	2,009.0	1.8	1.4
Minimum:	9.2	13.2	7.6	104.7	3,126,653.9	1,575.4	1.1	0.6
Maximum:	11.6	13.8	9.0	202.1	3,337,319.8	2,186.6	2.2	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/06/2020 00:00	10.8	13.2	8.3	191.7	3,242,074.6	2,154.4	2.1	1.7
09/06/2020 01:00	10.6	13.3	8.2	175.3	3,246,780.7	2,086.4	1.9	1.5
09/06/2020 02:00	10.3	13.4	8.1	181.5	3,168,848.0	2,082.6	2.0	1.7
09/06/2020 03:00	10.0	13.4	7.9	188.9	3,168,486.9	2,105.5	2.1	1.7
09/06/2020 04:00	10.4	13.3	8.1	178.0	3,294,739.5	2,069.1	1.9	1.4
09/06/2020 05:00	10.8	13.3	8.4	208.0	3,310,945.9	2,055.1	2.2	1.6
09/06/2020 06:00	11.0	13.4	8.7	158.2	3,319,017.1	1,987.4	1.6	1.2
09/06/2020 07:00	11.1	13.3	8.6	183.6	3,284,906.7	2,110.9	1.9	1.5
09/06/2020 08:00	11.0	13.3	8.5	193.5	3,210,021.0	2,133.1	2.1	1.7
09/06/2020 09:00	10.9	13.3	8.5	199.7	3,194,480.1	2,146.1	2.2	1.7
09/06/2020 10:00	10.8	13.2	8.3	198.5	3,157,333.1	2,144.2	2.2	1.7
09/06/2020 11:00	10.8	13.2	8.3	198.7	3,149,970.6	2,139.2	2.2	1.7
09/06/2020 12:00	10.9	13.2	8.4	197.8	3,117,625.7	2,140.0	2.2	1.7
09/06/2020 13:00	10.9	13.2	8.4	199.7	3,159,100.1	2,145.4	2.2	1.7
09/06/2020 14:00	10.9	13.2	8.4	200.0	3,159,541.8	2,145.7	2.2	1.7
09/06/2020 15:00	10.8	13.2	8.3	197.3	3,129,717.5	2,148.3	2.2	1.7
09/06/2020 16:00	10.7	13.3	8.3	181.6	3,162,457.4	2,078.4	2.0	1.7
09/06/2020 17:00	10.9	13.2	8.4	199.4	3,119,665.3	2,141.4	2.2	1.7
09/06/2020 18:00	10.9	13.2	8.4	195.6	3,123,171.1	2,121.0	2.2	1.7
09/06/2020 19:00	10.9	13.3	8.5	187.8	3,145,462.5	2,090.2	2.1	1.7
09/06/2020 20:00	10.9	13.3	8.5	186.2	3,184,368.2	2,092.8	2.0	1.7
09/06/2020 21:00	10.9	13.3	8.5	199.0	3,194,777.8	2,146.3	2.2	1.7
09/06/2020 22:00	10.5	13.3	8.2	196.0	3,154,535.3	2,142.3	2.2	1.7
09/06/2020 23:00	10.0	13.4	7.9	185.3	3,092,101.4	2,099.9	2.1	1.7
Average/Sum#:	10.7	13.3	8.3	190.9	3,187,088.7	2,112.7	2.1	1.6
Minimum:	10.0	13.2	7.9	158.2	3,092,101.4	1,987.4	1.6	1.2
Maximum:	11.1	13.4	8.7	208.0	3,319,017.1	2,154.4	2.2	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/07/2020 00:00	9.9	13.4	7.8	183.8	3,073,400.6	2,087.2	2.1	1.7
09/07/2020 01:00	9.9	13.5	7.9	192.1	3,096,089.9	2,080.0	2.2	1.7
09/07/2020 02:00	9.9	13.4	7.8	195.2	3,111,719.2	2,090.5	2.2	1.7
09/07/2020 03:00	10.4	13.3	8.1	180.6	3,238,919.5	2,105.0	1.9	1.5
09/07/2020 04:00	10.7	13.4	8.4	172.4	3,245,854.3	2,038.4	1.8	1.4
09/07/2020 05:00	10.9	13.3	8.5	194.7	3,256,363.8	2,045.0	2.1	1.6
09/07/2020 06:00	9.0	13.9	7.6	104.5	3,161,584.1	1,593.0	1.1	0.6
09/07/2020 07:00	9.0	14.0	7.7	100.4	3,205,862.8	1,591.9	1.0	0.6
09/07/2020 08:00	9.0	14.0	7.7	102.2	3,230,633.2	1,604.2	1.0	0.6
09/07/2020 09:00	9.0	14.0	7.7	101.9	3,154,106.6	1,566.2	1.1	0.6
09/07/2020 10:00	9.0	14.0	7.7	97.9	2,992,093.0	1,507.6	1.1	0.6
09/07/2020 11:00	9.2	13.9	7.8	113.6	2,993,283.8	1,508.2	1.3	0.8
09/07/2020 12:00	11.2	13.4	8.8	160.5	3,232,006.5	1,958.9	1.7	1.4
09/07/2020 13:00	10.2	13.6	8.2	140.5	3,181,446.7	1,742.4	1.5	1.0
09/07/2020 14:00	10.4	13.7	8.5	133.8	3,228,176.9	1,673.7	1.4	0.8
09/07/2020 15:00	11.0	13.6	8.9	150.9	3,273,494.9	1,721.1	1.6	1.0
09/07/2020 16:00	11.1	13.5	8.9	149.6	3,130,188.1	1,782.9	1.6	1.1
09/07/2020 17:00	11.2	13.3	8.7	170.1	3,191,231.0	2,027.4	1.8	1.4
09/07/2020 18:00	11.1	13.3	8.6	169.8	3,183,046.0	2,022.2	1.8	1.4
09/07/2020 19:00	11.1	13.3	8.6	192.0	3,162,626.1	2,124.7	2.1	1.7
09/07/2020 20:00	10.9	13.2	8.4	189.9	3,144,912.9	2,112.8	2.1	1.7
09/07/2020 21:00	10.8	13.3	8.4	173.4	3,153,215.0	2,049.3	1.9	1.4
09/07/2020 22:00	10.9	13.3	8.5	176.2	3,158,754.3	2,052.9	1.9	1.4
09/07/2020 23:00	10.9	13.3	8.5	176.4	3,194,338.0	2,052.7	1.9	1.4
Average/Sum#:	10.3	13.5	8.2	155.1	3,166,389.5	1,880.8	1.7	1.2
Minimum:	9.0	13.2	7.6	97.9	2,992,093.0	1,507.6	1.0	0.6
Maximum:	11.2	14.0	8.9	195.2	3,273,494.9	2,124.7	2.2	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/08/2020 00:00	10.8	13.3	8.4	173.4	3,236,091.5	2,055.9	1.8	1.4
09/08/2020 01:00	11.0	13.3	8.5	188.7	3,212,061.0	2,111.0	2.0	1.7
09/08/2020 02:00	11.0	13.3	8.5	186.0	3,212,454.2	2,087.8	2.0	1.7
09/08/2020 03:00	10.8	13.3	8.4	196.2	3,239,365.9	2,152.6	2.1	1.7
09/08/2020 04:00	10.6	13.4	8.3	178.1	3,288,350.0	2,089.1	1.9	1.5
09/08/2020 05:00	10.6	13.4	8.3	175.3	3,303,051.6	2,050.2	1.8	1.4
09/08/2020 06:00	9.0	13.9	7.6	110.7	3,247,718.9	1,636.4	1.1	0.7
09/08/2020 07:00	9.0	14.0	7.7	103.9	3,297,493.4	1,637.4	1.0	0.7
09/08/2020 08:00	8.5	14.1	7.4	94.5	3,051,399.7	1,515.2	1.0	0.6
09/08/2020 09:00	10.0	13.9	8.4	127.0	3,260,222.4	1,642.7	1.3	0.8
09/08/2020 10:00	8.8	14.0	7.5	117.8	3,141,935.9	1,583.1	1.3	0.8
09/08/2020 11:00	8.9	13.9	7.5	109.8	3,302,269.1	1,688.0	1.1	0.7
09/08/2020 12:00	9.4	14.0	8.0	118.1	3,054,213.3	1,538.9	1.3	0.8
09/08/2020 13:00	11.2	13.4	8.8	177.0	3,317,351.0	2,083.3	1.8	1.5
09/08/2020 14:00	11.2	13.3	8.7	205.0	3,239,135.2	2,176.1	2.2	1.7
09/08/2020 15:00	11.1	13.3	8.6	209.8	3,219,325.3	2,186.3	2.3	2.0
09/08/2020 16:00	11.0	13.3	8.5	212.6	3,226,246.0	2,191.0	2.3	2.0
09/08/2020 17:00	10.9	13.3	8.5	212.6	3,203,141.9	2,198.7	2.3	2.0
09/08/2020 18:00	10.4	13.5	8.3	193.0	3,103,383.6	2,084.9	2.2	1.7
09/08/2020 19:00	10.3	13.4	8.1	185.5	3,218,608.9	2,091.8	2.0	1.7
09/08/2020 20:00	10.6	13.4	8.3	181.1	3,298,896.1	2,095.8	1.9	1.5
09/08/2020 21:00	10.6	13.4	8.3	181.8	3,272,768.7	2,103.1	1.9	1.5
09/08/2020 22:00	10.7	13.4	8.4	171.3	3,322,158.3	2,037.8	1.8	1.4
09/08/2020 23:00	10.9	13.4	8.6	175.8	3,313,362.6	2,056.6	1.8	1.4
Average/Sum#:	10.3	13.5	8.2	166.0	3,232,541.9	1,962.2	1.8	1.4
Minimum:	8.5	13.3	7.4	94.5	3,051,399.7	1,515.2	1.0	0.6
Maximum:	11.2	14.1	8.8	212.6	3,322,158.3	2,198.7	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/09/2020 00:00	10.7	13.5	8.5	171.5	3,227,491.6	2,003.3	1.8	1.4
09/09/2020 01:00	9.2	14.0	7.9	121.7	3,305,274.4	1,665.4	1.2	0.8
09/09/2020 02:00	8.5	14.1	7.4	90.3	2,816,785.1	1,398.7	1.1	0.6
09/09/2020 03:00	9.2	14.0	7.9	111.7	3,289,397.1	1,657.4	1.1	0.7
09/09/2020 04:00	8.2	14.1	7.1	93.5	3,036,094.4	1,507.6	1.0	0.6
09/09/2020 05:00	8.5	14.1	7.4	103.0	3,182,099.2	1,580.1	1.1	0.6
09/09/2020 06:00	8.8	14.1	7.6	99.9	3,188,745.0	1,583.4	1.0	0.6
09/09/2020 07:00	8.4	14.1	7.3	101.4	3,142,829.0	1,560.6	1.1	0.6
09/09/2020 08:00	8.3	14.1	7.2	93.8	3,055,226.1	1,517.1	1.0	0.6
09/09/2020 09:00	8.3	14.1	7.2	89.9	2,894,318.7	1,437.2	1.0	0.6
09/09/2020 10:00	8.3	14.1	7.2	88.9	2,866,728.8	1,423.5	1.0	0.6
09/09/2020 11:00	8.2	14.1	7.1	92.1	3,014,546.1	1,496.9	1.0	0.6
09/09/2020 12:00	8.7	14.0	7.4	104.6	3,063,281.5	1,521.1	1.1	0.6
09/09/2020 13:00	10.9	13.4	8.6	175.0	3,319,898.7	2,084.9	1.8	1.5
09/09/2020 14:00	10.8	13.4	8.5	173.3	3,294,835.1	2,045.1	1.8	1.4
09/09/2020 15:00	10.8	13.4	8.5	166.4	3,293,791.7	2,020.4	1.7	1.4
09/09/2020 16:00	10.8	13.4	8.5	165.6	3,282,053.8	2,013.2	1.7	1.4
09/09/2020 17:00	10.7	13.4	8.4	163.5	3,276,999.9	2,010.1	1.7	1.4
09/09/2020 18:00	10.7	13.4	8.4	163.2	3,315,491.9	2,009.5	1.7	1.4
09/09/2020 19:00	10.6	13.4	8.3	164.6	3,313,842.0	2,008.5	1.7	1.4
09/09/2020 20:00	10.6	13.4	8.3	161.0	3,314,997.0	2,009.2	1.7	1.4
09/09/2020 21:00	10.5	13.4	8.3	161.8	3,350,580.7	2,006.3	1.6	1.2
09/09/2020 22:00	10.5	13.4	8.3	159.2	3,345,904.6	2,003.5	1.6	1.2
09/09/2020 23:00	10.1	13.5	8.1	142.8	3,330,821.5	1,921.5	1.5	1.2
Average/Sum#:	9.6	13.7	7.9	131.6	3,188,418.1	1,770.2	1.4	1.0
Minimum:	8.2	13.4	7.1	88.9	2,816,785.1	1,398.7	1.0	0.6
Maximum:	10.9	14.1	8.6	175.0	3,350,580.7	2,084.9	1.8	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/10/2020 00:00	8.7	13.9	7.3	102.7	3,012,535.2	1,517.9	1.1	0.6
09/10/2020 01:00	8.5	14.0	7.3	92.8	2,961,132.1	1,492.0	1.0	0.6
09/10/2020 02:00	8.9	14.0	7.6	86.7	2,645,405.7	1,313.6	1.1	0.5
09/10/2020 03:00	8.2	14.0	7.0	98.0	3,164,362.7	1,594.4	1.0	0.6
09/10/2020 04:00	8.2	14.0	7.0	96.9	3,103,433.2	1,563.7	1.0	0.6
09/10/2020 05:00	8.3	14.0	7.1	94.0	3,094,303.7	1,559.1	1.0	0.6
09/10/2020 06:00	8.4	14.0	7.2	100.1	3,186,392.5	1,605.5	1.0	0.6
09/10/2020 07:00	8.4	14.0	7.2	101.7	3,262,604.0	1,643.9	1.0	0.7
09/10/2020 08:00	8.4	14.0	7.2	104.0	3,336,036.9	1,680.9	1.0	0.7
09/10/2020 09:00	8.5	14.0	7.3	100.7	3,217,750.4	1,621.3	1.0	0.6
09/10/2020 10:00	8.6	14.0	7.4	104.2	3,321,350.3	1,673.5	1.0	0.7
09/10/2020 11:00	8.6	14.0	7.4	92.4	2,926,598.8	1,474.6	1.0	0.6
09/10/2020 12:00	8.7	14.0	7.4	90.8	2,875,791.2	1,449.0	1.0	0.6
09/10/2020 13:00	8.8	14.0	7.5	91.7	2,897,821.1	1,460.1	1.0	0.6
09/10/2020 14:00	8.7	14.0	7.4	101.5	3,175,278.4	1,599.9	1.1	0.6
09/10/2020 15:00	9.3	13.9	7.8	119.9	3,078,270.4	1,573.5	1.3	0.8
09/10/2020 16:00	11.1	13.3	8.6	170.1	3,279,134.5	2,059.3	1.8	1.4
09/10/2020 17:00	11.0	13.4	8.7	170.2	3,274,535.4	2,032.5	1.8	1.4
09/10/2020 18:00	11.0	13.4	8.7	165.3	3,279,119.3	2,011.4	1.7	1.4
09/10/2020 19:00	10.9	13.4	8.6	164.6	3,318,131.8	2,011.1	1.7	1.4
09/10/2020 20:00	10.8	13.4	8.5	163.8	3,312,357.1	2,007.6	1.7	1.4
09/10/2020 21:00	10.8	13.4	8.5	162.4	3,341,061.5	2,000.6	1.7	1.4
09/10/2020 22:00	10.7	13.4	8.4	160.7	3,302,457.6	2,001.6	1.7	1.4
09/10/2020 23:00	10.0	13.6	8.1	143.3	3,278,259.7	1,843.3	1.5	1.1
Average/Sum#:	9.3	13.8	7.7	119.9	3,151,838.5	1,699.6	1.3	0.9
Minimum:	8.2	13.3	7.0	86.7	2,645,405.7	1,313.6	1.0	0.5
Maximum:	11.1	14.0	8.7	170.2	3,341,061.5	2,059.3	1.8	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/11/2020 00:00	9.5	13.9	8.0	116.4	2,770,345.5	1,416.1	1.4	0.7
09/11/2020 01:00	9.4	14.0	8.0	87.6	2,565,586.8	1,292.7	1.1	0.5
09/11/2020 02:00	9.4	14.0	8.0	87.3	2,564,396.0	1,292.1	1.1	0.5
09/11/2020 03:00	9.3	14.0	8.0	87.2	2,563,999.1	1,291.9	1.1	0.5
09/11/2020 04:00	9.3	14.0	8.0	87.1	2,563,999.1	1,291.9	1.1	0.5
09/11/2020 05:00	8.7	14.0	7.4	93.3	2,945,254.8	1,484.0	1.0	0.6
09/11/2020 06:00	9.5	14.0	8.1	88.0	2,612,781.2	1,297.4	1.1	0.5
09/11/2020 07:00	9.0	14.0	7.7	86.7	2,665,141.5	1,323.4	1.1	0.5
09/11/2020 08:00	9.0	14.0	7.7	88.0	2,709,446.4	1,345.4	1.1	0.5
09/11/2020 09:00	8.5	14.0	7.3	97.4	3,115,738.2	1,569.9	1.0	0.6
09/11/2020 10:00	8.6	14.0	7.4	97.0	3,083,189.5	1,553.5	1.0	0.6
09/11/2020 11:00	8.8	14.0	7.5	97.2	3,057,785.7	1,540.7	1.0	0.6
09/11/2020 12:00	8.8	14.0	7.5	100.2	3,150,470.0	1,587.4	1.0	0.6
09/11/2020 13:00	9.4	14.0	8.0	87.8	2,576,105.6	1,298.0	1.1	0.5
09/11/2020 14:00	9.4	14.0	8.0	87.5	2,619,225.5	1,300.6	1.1	0.5
09/11/2020 15:00	9.4	14.0	8.0	88.0	2,650,133.9	1,335.3	1.1	0.5
09/11/2020 16:00	9.1	13.9	7.7	111.6	3,223,038.1	1,647.5	1.1	0.7
09/11/2020 17:00	9.2	13.9	7.8	109.5	3,210,322.0	1,641.0	1.1	0.7
09/11/2020 18:00	10.3	13.6	8.3	141.6	3,253,283.8	1,805.5	1.5	1.1
09/11/2020 19:00	11.3	13.4	8.9	170.4	3,269,421.1	2,053.2	1.8	1.4
09/11/2020 20:00	11.2	13.4	8.8	170.6	3,247,630.2	2,015.8	1.8	1.4
09/11/2020 21:00	11.1	13.4	8.7	166.5	3,292,964.6	1,971.8	1.7	1.4
09/11/2020 22:00	9.7	13.8	8.1	112.5	2,823,106.4	1,484.3	1.3	0.7
09/11/2020 23:00	30.9	17.1	48.0	216.7	1,132,163.6	355.5	6.3	0.9
Average/Sum#:	10.4	14.0	9.6	111.5	2,819,397.0	1,466.5	1.4	0.7
Minimum:	8.5	13.4	7.3	86.7	1,132,163.6	355.5	1.0	0.5
Maximum:	30.9	17.1	48.0	216.7	3,292,964.6	2,053.2	6.3	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/13/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/14/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2020 13:00	37.4	17.4	63.0	0.0	1,857,709.8	434.1	0.0	0.0
09/14/2020 14:00	56.1	15.7	63.7	241.5	1,847,917.4	688.2	4.1	1.1
09/14/2020 15:00	13.2	13.9	11.1	168.7	3,066,336.8	1,567.4	1.9	1.1
09/14/2020 16:00	10.3	13.5	8.2	142.7	3,185,491.8	1,814.4	1.5	1.1
09/14/2020 17:00	11.2	13.3	8.7	193.0	3,210,258.2	2,156.7	2.1	1.7
09/14/2020 18:00	11.0	13.3	8.5	177.0	3,215,021.4	2,159.9	1.9	1.5
09/14/2020 19:00	10.9	13.3	8.5	185.5	3,216,943.4	2,137.7	2.0	1.7
09/14/2020 20:00	10.8	13.3	8.4	190.0	3,203,560.0	2,152.2	2.1	1.7
09/14/2020 21:00	10.6	13.4	8.3	163.1	3,239,484.8	2,034.4	1.7	1.4
09/14/2020 22:00	10.5	13.4	8.3	152.1	3,269,417.2	1,957.7	1.6	1.2
09/14/2020 23:00	10.4	13.4	8.2	153.7	3,262,236.1	1,953.4	1.6	1.2
Average/Sum#:	17.5	14.0	18.6	160.7	2,961,307.0	1,732.4	1.9	1.2
Minimum:	10.3	13.3	8.2	0.0	1,847,917.4	434.1	0.0	0.0
Maximum:	56.1	17.4	63.7	241.5	3,269,417.2	2,159.9	4.1	1.7
%SI	54.17	54.17	54.17	54.17	54.17	54.17	54.17	54.17

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/15/2020 00:00	8.8	13.9	7.4	93.7	2,831,382.7	1,447.3	1.1	0.6
09/15/2020 01:00	9.0	14.0	7.7	86.8	2,640,805.9	1,330.6	1.1	0.5
09/15/2020 02:00	9.2	14.0	7.9	86.6	2,557,251.2	1,288.5	1.1	0.5
09/15/2020 03:00	9.2	14.0	7.9	86.5	2,559,235.9	1,289.5	1.1	0.5
09/15/2020 04:00	9.0	14.0	7.7	86.2	2,613,814.4	1,317.0	1.1	0.5
09/15/2020 05:00	8.5	13.9	7.2	97.4	3,077,879.1	1,573.3	1.0	0.6
09/15/2020 06:00	8.6	13.9	7.2	100.5	3,152,806.2	1,611.6	1.1	0.6
09/15/2020 07:00	8.7	14.0	7.4	89.9	2,847,608.8	1,434.8	1.0	0.6
09/15/2020 08:00	8.6	14.0	7.4	88.4	2,822,602.0	1,422.2	1.0	0.6
09/15/2020 09:00	9.4	14.0	8.0	87.0	2,558,442.0	1,289.1	1.1	0.5
09/15/2020 10:00	8.6	14.0	7.4	98.2	3,152,256.2	1,588.3	1.0	0.6
09/15/2020 11:00	8.5	14.0	7.3	99.8	3,203,262.3	1,614.0	1.0	0.6
09/15/2020 12:00	8.7	14.0	7.4	101.9	3,188,178.7	1,606.4	1.1	0.6
09/15/2020 13:00	9.7	13.8	8.1	129.8	3,230,298.5	1,674.8	1.3	0.8
09/15/2020 14:00	11.2	13.3	8.7	178.5	3,214,039.0	2,112.3	1.9	1.5
09/15/2020 15:00	11.0	13.3	8.5	188.9	3,177,064.6	2,134.4	2.1	1.7
09/15/2020 16:00	10.9	13.3	8.5	175.5	3,206,631.7	2,060.6	1.9	1.4
09/15/2020 17:00	11.0	13.4	8.7	174.6	3,233,258.2	2,054.1	1.9	1.4
09/15/2020 18:00	10.9	13.4	8.6	169.9	3,251,746.0	2,042.1	1.8	1.4
09/15/2020 19:00	10.9	13.3	8.5	173.9	3,244,906.2	2,061.5	1.8	1.4
09/15/2020 20:00	10.7	13.3	8.3	185.0	3,205,792.7	2,153.7	2.0	1.7
09/15/2020 21:00	10.5	13.3	8.2	174.7	3,236,510.0	2,079.8	1.9	1.5
09/15/2020 22:00	17.5	14.0	15.0	163.6	2,576,343.7	1,411.0	2.1	1.1
09/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	10.0	13.7	8.2	126.8	2,990,526.8	1,678.1	1.4	0.9
Minimum:	8.5	13.3	7.2	86.2	2,557,251.2	1,288.5	1.0	0.5
Maximum:	17.5	14.0	15.0	188.9	3,251,746.0	2,153.7	2.1	1.7
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2020 06:00	37.2	17.4	62.7	175.4	1,928,748.7	450.7	0.0	0.0
09/16/2020 07:00	32.4	14.6	30.3	226.4	2,415,186.4	1,111.1	3.0	1.3
09/16/2020 08:00	8.8	14.0	7.5	91.0	2,756,115.4	1,388.7	1.1	0.6
09/16/2020 09:00	8.8	14.0	7.5	89.3	2,713,025.3	1,386.8	1.1	0.6
09/16/2020 10:00	8.9	14.0	7.6	89.3	2,747,184.4	1,384.2	1.1	0.6
09/16/2020 11:00	9.0	13.9	7.6	116.2	3,135,003.7	1,602.5	1.2	0.8
09/16/2020 12:00	9.3	13.9	7.8	103.8	2,864,444.5	1,464.2	1.2	0.7
09/16/2020 13:00	10.6	13.8	8.8	130.2	3,260,580.2	1,690.5	1.3	0.8
09/16/2020 14:00	10.1	13.8	8.4	133.9	3,265,016.3	1,692.8	1.4	0.8
09/16/2020 15:00	11.3	13.3	8.8	172.3	3,209,992.3	2,086.2	1.8	1.5
09/16/2020 16:00	11.2	13.3	8.7	191.4	3,182,869.7	2,138.3	2.1	1.7
09/16/2020 17:00	11.1	13.2	8.5	200.3	3,178,958.5	2,182.1	2.2	1.7
09/16/2020 18:00	11.0	13.2	8.4	196.7	3,186,046.8	2,163.7	2.2	1.7
09/16/2020 19:00	10.7	13.3	8.3	162.3	3,231,204.6	2,029.2	1.7	1.4
09/16/2020 20:00	10.6	13.3	8.2	163.3	3,223,499.1	2,047.9	1.7	1.4
09/16/2020 21:00	10.6	13.4	8.3	166.9	3,242,669.6	2,036.4	1.8	1.4
09/16/2020 22:00	10.6	13.4	8.3	159.2	3,246,019.1	2,014.8	1.7	1.4
09/16/2020 23:00	10.2	13.4	8.0	147.0	3,247,372.8	1,944.5	1.5	1.2
Average/Sum#:	12.9	13.8	12.4	150.8	3,001,885.4	1,711.9	1.6	1.1
Minimum:	8.8	13.2	7.5	89.3	1,928,748.7	450.7	0.0	0.0
Maximum:	37.2	17.4	62.7	226.4	3,265,016.3	2,182.1	3.0	1.7
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/17/2020 00:00	9.0	13.9	7.6	96.6	2,751,760.5	1,406.6	1.2	0.7
09/17/2020 01:00	9.2	14.0	7.9	91.0	2,602,501.7	1,311.3	1.2	0.7
09/17/2020 02:00	9.3	14.0	8.0	91.0	2,565,586.8	1,292.7	1.2	0.6
09/17/2020 03:00	9.3	14.0	8.0	90.9	2,567,174.6	1,293.5	1.2	0.6
09/17/2020 04:00	8.7	13.9	7.3	95.8	2,869,726.6	1,466.9	1.1	0.6
09/17/2020 05:00	8.6	13.9	7.2	98.4	3,081,400.5	1,575.1	1.1	0.6
09/17/2020 06:00	8.9	13.9	7.5	101.9	3,015,276.9	1,541.3	1.1	0.6
09/17/2020 07:00	8.9	13.9	7.5	106.7	3,166,696.1	1,618.7	1.1	0.6
09/17/2020 08:00	8.9	13.9	7.5	105.4	3,114,853.6	1,592.2	1.1	0.6
09/17/2020 09:00	8.8	13.9	7.4	105.3	3,140,872.6	1,605.5	1.1	0.6
09/17/2020 10:00	9.0	13.9	7.6	92.8	2,779,735.9	1,420.9	1.1	0.6
09/17/2020 11:00	9.0	13.9	7.6	90.2	2,795,582.1	1,429.0	1.1	0.6
09/17/2020 12:00	9.2	13.8	7.6	119.7	3,179,999.1	1,625.5	1.3	0.8
09/17/2020 13:00	10.7	13.5	8.5	178.5	3,187,107.0	2,094.6	1.9	1.5
09/17/2020 14:00	10.5	13.5	8.4	195.2	3,132,048.4	2,149.9	2.2	1.7
09/17/2020 15:00	10.6	13.4	8.3	195.7	3,147,636.5	2,160.6	2.2	1.7
09/17/2020 16:00	10.8	13.2	8.3	198.2	3,138,144.1	2,177.0	2.2	1.7
09/17/2020 17:00	10.7	13.2	8.2	186.7	3,138,337.8	2,131.3	2.1	1.7
09/17/2020 18:00	10.6	13.3	8.2	169.0	3,201,807.6	2,057.5	1.8	1.4
09/17/2020 19:00	10.7	13.3	8.3	185.1	3,196,025.8	2,123.8	2.0	1.7
09/17/2020 20:00	10.7	13.3	8.3	169.7	3,235,461.9	2,055.5	1.8	1.4
09/17/2020 21:00	10.6	13.3	8.2	170.0	3,248,369.1	2,063.7	1.8	1.4
09/17/2020 22:00	10.7	13.3	8.3	175.7	3,243,535.5	2,108.0	1.9	1.5
09/17/2020 23:00	13.8	13.7	11.3	182.8	2,891,096.5	1,794.5	2.2	1.4
Average/Sum#:	9.9	13.7	8.0	137.2	3,016,280.7	1,754.0	1.5	1.1
Minimum:	8.6	13.2	7.2	90.2	2,565,586.8	1,292.7	1.1	0.6
Maximum:	13.8	14.0	11.3	198.2	3,248,369.1	2,177.0	2.2	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/18/2020 00:00	3.1	19.4	12.2	142.8	1,611.1	0.2	3,326.2	0.3
09/18/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2020 06:00	33.5	17.5	58.1	175.2	1,889,349.2	413.9	0.0	0.0
09/18/2020 07:00	37.4	15.3	39.4	264.2	2,383,296.4	957.2	3.4	1.2
09/18/2020 08:00	8.8	13.9	7.4	92.8	2,741,392.0	1,401.3	1.1	0.6
09/18/2020 09:00	8.9	13.9	7.5	87.6	2,772,985.1	1,397.2	1.0	0.6
09/18/2020 10:00	8.9	13.9	7.5	114.4	3,309,311.8	1,691.6	1.2	0.8
09/18/2020 11:00	9.0	13.9	7.6	97.9	2,927,633.7	1,496.5	1.1	0.6
09/18/2020 12:00	9.2	13.9	7.8	115.7	3,160,435.8	1,615.5	1.2	0.8
09/18/2020 13:00	9.7	13.8	8.1	115.5	3,013,124.9	1,540.2	1.3	0.8
09/18/2020 14:00	11.0	13.4	8.7	157.9	3,246,013.5	2,038.5	1.7	1.4
09/18/2020 15:00	11.0	13.3	8.5	172.0	3,222,504.6	2,070.8	1.8	1.4
09/18/2020 16:00	10.9	13.3	8.5	169.6	3,231,526.7	2,053.0	1.8	1.4
09/18/2020 17:00	10.7	13.3	8.3	164.8	3,244,102.7	2,037.3	1.7	1.4
09/18/2020 18:00	10.8	13.4	8.5	162.7	3,220,217.4	2,022.3	1.7	1.4
09/18/2020 19:00	10.8	13.4	8.5	163.3	3,249,885.7	2,017.2	1.7	1.4
09/18/2020 20:00	10.6	13.4	8.3	157.5	3,284,499.2	2,014.7	1.6	1.2
09/18/2020 21:00	10.4	13.4	8.2	153.3	3,276,999.9	2,010.1	1.6	1.2
09/18/2020 22:00	14.0	14.3	12.5	158.8	2,785,066.8	1,464.3	1.9	1.0
09/18/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	12.7	14.3	13.1	148.1	2,831,108.7	1,569.0	186.2	1.0
Minimum:	3.1	13.3	7.4	87.6	1,611.1	0.2	0.0	0.0
Maximum:	37.4	19.4	58.1	264.2	3,309,311.8	2,070.8	3,326.2	1.4
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/19/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2020 04:00	27.6	17.8	52.5	172.3	1,879,271.6	356.8	0.0	0.0
09/19/2020 05:00	40.8	15.2	42.2	244.4	2,289,581.5	953.0	3.2	1.1
09/19/2020 06:00	8.8	13.9	7.4	91.7	2,737,283.7	1,399.2	1.1	0.6
09/19/2020 07:00	9.0	13.9	7.6	87.5	2,717,329.2	1,389.0	1.1	0.6
09/19/2020 08:00	9.1	13.9	7.7	87.4	2,712,242.8	1,386.4	1.1	0.6
09/19/2020 09:00	9.1	13.9	7.7	88.0	2,755,123.1	1,388.2	1.0	0.6
09/19/2020 10:00	9.1	14.0	7.8	88.0	2,765,443.4	1,393.4	1.0	0.6
09/19/2020 11:00	9.1	14.0	7.8	88.2	2,773,779.0	1,397.6	1.0	0.6
09/19/2020 12:00	9.1	14.0	7.8	99.6	2,961,926.0	1,492.4	1.1	0.6
09/19/2020 13:00	9.3	13.9	7.8	113.4	3,097,442.3	1,583.3	1.2	0.8
09/19/2020 14:00	8.8	14.0	7.5	93.4	2,920,049.4	1,471.3	1.1	0.6
09/19/2020 15:00	9.3	13.9	7.8	110.9	3,052,427.1	1,538.0	1.2	0.8
09/19/2020 16:00	11.2	13.4	8.8	165.7	3,267,351.0	2,051.9	1.7	1.4
09/19/2020 17:00	11.2	13.3	8.7	203.0	3,204,016.0	2,199.3	2.2	1.8
09/19/2020 18:00	11.0	13.3	8.5	197.0	3,229,162.2	2,169.4	2.1	1.7
09/19/2020 19:00	10.9	13.3	8.5	195.6	3,212,788.7	2,158.4	2.1	1.7
09/19/2020 20:00	10.9	13.3	8.5	195.0	3,193,289.3	2,145.3	2.1	1.7
09/19/2020 21:00	10.9	13.3	8.5	181.4	3,232,610.9	2,100.9	1.9	1.5
09/19/2020 22:00	10.8	13.3	8.4	182.6	3,234,765.0	2,102.3	2.0	1.7
09/19/2020 23:00	10.6	13.4	8.3	156.9	3,285,783.5	1,967.5	1.6	1.2
Average/Sum#:	12.3	14.0	12.0	142.1	2,926,083.3	1,632.2	1.5	1.0
Minimum:	8.8	13.3	7.4	87.4	1,879,271.6	356.8	0.0	0.0
Maximum:	40.8	17.8	52.5	244.4	3,285,783.5	2,199.3	3.2	1.8
%SI	16.67	16.67	16.67	16.67	16.67	16.67	16.67	16.67

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/20/2020 00:00	10.7	13.4	8.4	154.5	3,304,877.5	1,954.8	1.6	1.2
09/20/2020 01:00	10.6	13.4	8.3	154.6	3,312,485.4	1,959.3	1.6	1.2
09/20/2020 02:00	10.7	13.4	8.4	155.5	3,314,345.1	1,960.4	1.6	1.2
09/20/2020 03:00	10.7	13.4	8.4	155.1	3,311,132.9	1,958.5	1.6	1.2
09/20/2020 04:00	10.6	13.4	8.3	148.3	3,333,350.1	1,947.3	1.5	1.2
09/20/2020 05:00	10.1	13.5	8.1	142.0	3,280,456.1	1,916.4	1.5	1.1
09/20/2020 06:00	23.7	16.0	28.5	184.9	1,704,287.4	659.6	3.5	0.9
09/20/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2020 10:00	38.1	17.5	66.1	261.9	1,862,873.6	408.1	3.9	0.6
09/20/2020 11:00	36.9	15.3	38.9	255.5	2,325,820.6	951.1	3.4	1.2
09/20/2020 12:00	8.6	14.0	7.4	95.3	2,951,010.3	1,486.9	1.1	0.6
09/20/2020 13:00	8.9	13.9	7.5	96.2	3,025,645.4	1,546.6	1.0	0.6
09/20/2020 14:00	9.0	13.9	7.6	100.3	3,134,808.0	1,602.4	1.1	0.6
09/20/2020 15:00	9.1	13.9	7.7	93.3	2,891,637.4	1,478.1	1.1	0.6
09/20/2020 16:00	9.2	13.9	7.8	105.2	3,108,397.7	1,588.9	1.1	0.6
09/20/2020 17:00	11.4	13.3	8.9	174.6	3,233,086.5	2,077.6	1.9	1.5
09/20/2020 18:00	11.2	13.2	8.6	202.3	3,179,515.1	2,205.7	2.2	1.8
09/20/2020 19:00	11.0	13.2	8.4	199.7	3,168,415.6	2,198.0	2.2	1.8
09/20/2020 20:00	10.9	13.2	8.4	191.9	3,215,170.3	2,160.0	2.1	1.7
09/20/2020 21:00	10.8	13.4	8.5	170.7	3,169,666.5	2,013.7	1.9	1.4
09/20/2020 22:00	23.2	16.1	28.5	195.4	1,622,121.9	627.8	4.0	0.9
09/20/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	14.3	14.1	14.6	161.9	2,922,455.2	1,635.1	2.0	1.1
Minimum:	8.6	13.2	7.4	93.3	1,622,121.9	408.1	1.0	0.6
Maximum:	38.1	17.5	66.1	261.9	3,333,350.1	2,205.7	4.0	1.8
%SI	16.67	16.67	16.67	16.67	16.67	16.67	16.67	16.67

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/21/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2020 13:00	35.2	17.5	61.1	0.0	1,867,276.4	422.7	0.0	0.0
09/21/2020 14:00	46.4	15.5	50.7	260.7	2,053,122.2	809.6	4.0	1.2
09/21/2020 15:00	9.2	13.9	7.8	117.5	2,974,194.1	1,520.3	1.3	0.8
09/21/2020 16:00	11.0	13.3	8.5	163.4	3,196,880.9	1,984.3	1.8	1.4
09/21/2020 17:00	11.0	13.3	8.5	164.0	3,207,797.0	2,014.5	1.8	1.4
09/21/2020 18:00	11.0	13.4	8.7	165.2	3,215,247.3	1,995.7	1.8	1.4
09/21/2020 19:00	11.1	13.3	8.6	177.2	3,201,963.2	2,057.6	1.9	1.4
09/21/2020 20:00	10.9	13.3	8.5	180.8	3,202,475.0	2,104.7	2.0	1.7
09/21/2020 21:00	10.6	13.4	8.3	173.6	3,176,442.1	2,041.2	1.9	1.4
09/21/2020 22:00	23.3	16.1	28.6	192.9	1,633,038.6	620.1	3.9	0.9
09/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	18.0	14.3	19.9	159.5	2,772,843.7	1,557.1	2.0	1.2
Minimum:	9.2	13.3	7.8	0.0	1,633,038.6	422.7	0.0	0.0
Maximum:	46.4	17.5	61.1	260.7	3,215,247.3	2,104.7	4.0	1.7
%SI	58.33	58.33	58.33	58.33	58.33	58.33	58.33	58.33

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2020 14:00	33.0	17.5	57.3	0.0	1,882,958.5	412.5	0.0	0.0
09/22/2020 15:00	47.0	15.5	51.4	229.9	2,100,037.7	828.1	3.5	1.1
09/22/2020 16:00	9.0	13.9	7.6	108.6	2,978,302.4	1,522.4	1.2	0.8
09/22/2020 17:00	11.2	13.3	8.7	168.7	2,912,584.2	1,765.3	2.0	1.4
09/22/2020 18:00	11.2	13.4	8.8	167.5	2,965,805.8	1,775.9	1.9	1.2
09/22/2020 19:00	11.1	13.4	8.7	153.6	2,965,805.8	1,775.9	1.8	1.2
09/22/2020 20:00	11.1	13.4	8.7	162.1	2,964,302.8	1,775.0	1.9	1.2
09/22/2020 21:00	17.4	14.8	16.8	175.6	2,423,268.0	1,185.6	2.4	1.1
09/22/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	18.9	14.4	21.0	145.8	2,649,133.2	1,380.1	1.8	1.0
Minimum:	9.0	13.3	7.6	0.0	1,882,958.5	412.5	0.0	0.0
Maximum:	47.0	17.5	57.3	229.9	2,978,302.4	1,775.9	3.5	1.4
%SI	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/23/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/23/2020 13:00	35.2	17.5	61.1	0.0	1,869,043.4	423.1	0.0	0.0
09/23/2020 14:00	49.1	15.6	54.7	229.7	2,093,902.6	795.1	3.5	1.0
09/23/2020 15:00	8.9	13.9	7.5	113.5	3,039,730.9	1,553.8	1.3	0.8
09/23/2020 16:00	11.0	13.4	8.7	173.7	3,223,720.5	2,024.5	1.9	1.4
09/23/2020 17:00	10.9	13.4	8.6	168.9	3,215,440.3	2,019.3	1.8	1.4
09/23/2020 18:00	10.8	13.4	8.5	162.6	3,281,833.8	1,989.1	1.7	1.4
09/23/2020 19:00	11.0	13.4	8.7	155.0	3,283,752.3	2,062.2	1.6	1.2
09/23/2020 20:00	10.8	13.4	8.5	160.7	3,281,546.6	1,941.0	1.7	1.4
09/23/2020 21:00	24.2	16.2	30.4	190.6	1,627,735.4	606.2	3.8	0.9
09/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	19.1	14.5	21.9	150.5	2,768,522.9	1,490.5	1.9	1.1
Minimum:	8.9	13.4	7.5	0.0	1,627,735.4	423.1	0.0	0.0
Maximum:	49.1	17.5	61.1	229.7	3,283,752.3	2,062.2	3.8	1.4
%SI	62.50	62.50	62.50	62.50	62.50	62.50	62.50	62.50

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2020 08:00	31.8	17.5	55.2	0.0	1,873,750.3	396.8	0.0	0.0
09/24/2020 09:00	40.7	17.1	63.2	228.9	1,857,011.5	515.3	3.7	0.7
09/24/2020 10:00	37.6	15.4	40.3	276.3	2,206,294.8	870.0	4.0	1.3
09/24/2020 11:00	8.5	14.0	7.3	93.1	2,740,039.6	1,380.6	1.1	0.6
09/24/2020 12:00	8.7	14.0	7.4	85.7	2,713,048.0	1,367.0	1.0	0.5
09/24/2020 13:00	9.1	13.9	7.7	110.8	3,086,095.7	1,577.5	1.2	0.8
09/24/2020 14:00	9.1	14.0	7.8	91.7	2,796,205.8	1,408.9	1.1	0.6
09/24/2020 15:00	9.2	13.8	7.6	109.6	3,247,296.5	1,659.9	1.1	0.7
09/24/2020 16:00	10.5	13.5	8.4	148.2	3,197,781.5	1,821.4	1.6	1.1
09/24/2020 17:00	11.6	13.3	9.0	184.0	3,201,866.4	2,104.3	2.0	1.7
09/24/2020 18:00	11.5	13.3	8.9	184.2	3,221,532.4	2,093.7	2.0	1.7
09/24/2020 19:00	11.4	13.3	8.9	170.2	3,246,780.7	2,086.4	1.8	1.5
09/24/2020 20:00	16.7	14.9	16.4	172.3	2,424,485.3	1,203.9	2.3	1.1
09/24/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	16.6	14.5	19.1	142.7	2,754,783.7	1,422.0	1.8	0.9
Minimum:	8.5	13.3	7.3	0.0	1,857,011.5	396.8	0.0	0.0
Maximum:	40.7	17.5	63.2	276.3	3,247,296.5	2,104.3	4.0	1.7
%SI	45.83	45.83	45.83	45.83	45.83	45.83	45.83	45.83

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2020 08:00	12.7	18.6	32.6	0.0	1,517,571.2	121.9	0.0	0.0
09/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2020 13:00	19.5	18.3	44.3	0.0	1,739,974.5	216.0	0.0	0.0
09/27/2020 14:00	54.9	16.4	72.0	109.8	1,871,442.9	601.3	0.0	0.0
09/27/2020 15:00	12.7	13.9	10.7	160.4	3,195,919.0	1,610.3	1.7	1.1
09/27/2020 16:00	9.9	13.8	8.2	128.6	1,060,550.4	1,618.6	4.4	2.8
09/27/2020 17:00	11.1	13.3	8.6	185.8	3,156,147.0	2,097.3	2.0	1.7
09/27/2020 18:00	11.1	13.3	8.6	193.0	3,251,622.1	2,137.0	2.1	1.7
09/27/2020 19:00	11.2	13.3	8.7	196.3	3,233,045.4	2,148.4	2.1	1.7
09/27/2020 20:00	11.1	13.3	8.6	194.7	3,265,468.5	2,146.1	2.1	1.7
09/27/2020 21:00	10.9	13.3	8.5	192.7	3,257,556.3	2,140.9	2.1	1.7
09/27/2020 22:00	17.3	14.7	16.5	190.0	2,429,967.5	1,277.6	2.6	1.3
09/27/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	16.6	14.7	20.7	141.0	2,691,871.4	1,465.0	1.5	1.1
Minimum:	9.9	13.3	8.2	0.0	1,517,571.2	121.9	0.0	0.0
Maximum:	54.9	18.6	72.0	196.3	3,265,468.5	2,148.4	2.6	1.7
%SI	54.17	54.17	54.17	54.17	58.33	54.17	58.33	58.33

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/28/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2020 06:00	39.7	17.5	68.9	17.8	1,902,555.5	402.9	0.0	0.0
09/28/2020 07:00	48.2	15.5	52.7	244.8	2,275,780.4	897.4	3.3	1.2
09/28/2020 08:00	8.3	14.1	7.2	91.2	2,786,980.0	1,383.9	1.1	0.6
09/28/2020 09:00	8.4	14.1	7.3	85.3	2,755,563.8	1,368.3	1.0	0.5
09/28/2020 10:00	8.8	13.9	7.4	108.0	3,212,082.7	1,641.9	1.1	0.7
09/28/2020 11:00	8.9	14.0	7.6	93.3	2,907,546.0	1,465.0	1.1	0.6
09/28/2020 12:00	9.4	13.8	7.8	122.2	3,388,151.6	1,731.9	1.2	0.9
09/28/2020 13:00	10.8	13.7	8.9	145.6	3,171,624.4	1,690.7	1.5	1.0
09/28/2020 14:00	11.8	13.3	9.2	188.8	3,270,462.4	2,125.5	2.0	1.7
09/28/2020 15:00	11.8	13.3	9.2	215.1	3,217,127.5	2,208.3	2.3	2.0
09/28/2020 16:00	11.7	13.3	9.1	216.4	3,214,942.3	2,206.8	2.3	2.0
09/28/2020 17:00	11.6	13.3	9.0	216.3	3,226,982.3	2,191.5	2.3	2.0
09/28/2020 18:00	11.3	13.3	8.8	208.9	3,220,503.3	2,187.1	2.3	2.0
09/28/2020 19:00	11.3	13.3	8.8	195.4	3,242,492.6	2,131.0	2.1	1.7
09/28/2020 20:00	11.5	13.3	8.9	199.8	3,259,077.9	2,141.9	2.1	1.7
09/28/2020 21:00	11.2	13.4	8.8	187.3	3,276,347.8	2,105.4	2.0	1.7
09/28/2020 22:00	17.2	14.7	16.4	180.6	2,502,871.1	1,261.1	2.4	1.1
09/28/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	14.8	14.0	15.1	159.8	2,990,064.2	1,714.2	1.8	1.3
Minimum:	8.3	13.3	7.2	17.8	1,902,555.5	402.9	0.0	0.0
Maximum:	48.2	17.5	68.9	244.8	3,388,151.6	2,208.3	3.3	2.0
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2020 06:00	39.3	17.5	68.2	54.4	1,946,471.5	412.2	0.0	0.0
09/29/2020 07:00	48.6	15.5	53.1	257.6	2,255,932.9	873.1	3.5	1.1
09/29/2020 08:00	8.5	14.1	7.4	92.4	2,768,653.9	1,374.8	1.1	0.5
09/29/2020 09:00	8.8	14.1	7.6	85.8	2,742,675.1	1,361.9	1.0	0.5
09/29/2020 10:00	9.0	13.9	7.6	122.7	3,150,849.9	1,610.6	1.3	0.8
09/29/2020 11:00	9.0	14.0	7.7	94.5	2,945,850.2	1,484.3	1.1	0.6
09/29/2020 12:00	8.8	13.9	7.4	111.0	3,361,545.6	1,718.3	1.1	0.7
09/29/2020 13:00	10.0	13.7	8.2	140.7	3,234,184.0	1,794.9	1.5	1.1
09/29/2020 14:00	11.4	13.3	8.9	194.3	3,257,252.0	2,140.7	2.1	1.7
09/29/2020 15:00	11.3	13.3	8.8	201.3	3,218,742.7	2,162.4	2.2	1.7
09/29/2020 16:00	11.2	13.3	8.7	208.6	3,202,122.1	2,198.0	2.3	2.0
09/29/2020 17:00	11.0	13.3	8.5	201.4	3,202,704.9	2,198.4	2.2	1.8
09/29/2020 18:00	10.8	13.3	8.4	191.0	3,236,356.1	2,150.6	2.0	1.7
09/29/2020 19:00	10.9	13.3	8.5	199.4	3,255,955.3	2,187.4	2.1	1.7
09/29/2020 20:00	10.8	13.3	8.4	191.0	3,264,346.6	2,169.2	2.0	1.7
09/29/2020 21:00	10.7	13.3	8.3	188.3	3,269,272.5	2,148.6	2.0	1.7
09/29/2020 22:00	10.7	13.4	8.4	181.9	3,290,353.3	2,114.4	1.9	1.5
09/29/2020 23:00	10.7	13.4	8.4	179.4	3,310,229.3	2,103.0	1.9	1.5
Average/Sum#:	14.0	13.9	14.0	160.9	3,050,749.9	1,789.0	1.7	1.2
Minimum:	8.5	13.3	7.4	54.4	1,946,471.5	412.2	0.0	0.0
Maximum:	48.6	17.5	68.2	257.6	3,361,545.6	2,198.4	3.5	2.0
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/30/2020 00:00	10.4	13.5	8.3	163.8	3,321,101.6	2,012.9	1.7	1.4
09/30/2020 01:00	8.5	13.9	7.2	105.3	3,235,558.6	1,653.9	1.1	0.7
09/30/2020 02:00	8.7	13.9	7.3	106.5	3,313,028.8	1,693.5	1.1	0.7
09/30/2020 03:00	8.7	13.9	7.3	105.1	3,274,098.1	1,673.6	1.1	0.7
09/30/2020 04:00	9.3	13.8	7.7	124.4	3,268,739.9	1,718.6	1.3	0.9
09/30/2020 05:00	10.8	13.4	8.5	163.6	3,297,090.6	2,046.5	1.7	1.4
09/30/2020 06:00	10.9	13.4	8.6	166.9	3,279,207.5	2,035.4	1.7	1.4
09/30/2020 07:00	8.6	13.9	7.2	105.9	3,249,448.4	1,661.0	1.1	0.7
09/30/2020 08:00	8.8	13.9	7.4	107.5	3,317,332.8	1,695.7	1.1	0.7
09/30/2020 09:00	8.9	13.9	7.5	108.8	3,324,962.4	1,699.6	1.1	0.7
09/30/2020 10:00	9.5	13.8	7.9	124.2	3,181,566.8	1,696.0	1.3	0.8
09/30/2020 11:00	11.2	13.3	8.7	177.4	3,286,618.5	2,112.0	1.9	1.5
09/30/2020 12:00	10.8	13.6	8.7	194.5	3,231,691.1	2,147.5	2.1	1.7
09/30/2020 13:00	10.7	13.6	8.6	207.0	3,205,631.1	2,177.0	2.3	2.0
09/30/2020 14:00	10.5	13.6	8.5	197.1	3,185,040.3	2,116.5	2.2	1.7
09/30/2020 15:00	10.5	13.6	8.5	201.4	3,201,773.7	2,151.0	2.2	1.7
09/30/2020 16:00	10.3	13.6	8.3	197.3	3,188,674.9	2,142.2	2.2	1.7
09/30/2020 17:00	10.3	13.6	8.3	190.5	3,191,812.2	2,121.0	2.1	1.7
09/30/2020 18:00	10.3	13.6	8.3	194.0	3,219,953.1	2,139.7	2.1	1.7
09/30/2020 19:00	10.4	13.6	8.4	202.3	3,220,528.9	2,163.6	2.2	1.7
09/30/2020 20:00	10.4	13.6	8.4	194.7	3,229,584.3	2,146.1	2.1	1.7
09/30/2020 21:00	10.4	13.6	8.4	190.2	3,238,993.0	2,128.7	2.0	1.7
09/30/2020 22:00	10.3	13.6	8.3	186.4	3,252,306.0	2,113.7	2.0	1.7
09/30/2020 23:00	10.4	13.6	8.4	167.7	3,229,722.2	1,981.1	1.8	1.4
Average/Sum#:	10.0	13.7	8.1	161.8	3,247,686.0	1,967.8	1.7	1.3
Minimum:	8.5	13.3	7.2	105.1	3,181,566.8	1,653.9	1.1	0.7
Maximum:	11.2	13.9	8.7	207.0	3,324,962.4	2,177.0	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2020 08:00	31.6	17.3	51.8	0.0	1,874,036.5	451.6	-0.1	0.0
07/03/2020 09:00	33.9	17.0	51.3	216.9	1,866,020.9	517.8	3.4	0.7
07/03/2020 10:00	32.3	15.5	35.3	240.0	2,229,476.6	830.3	3.2	1.0
07/03/2020 11:00	7.5	13.6	6.1	90.1	2,723,002.6	1,391.9	1.0	0.6
07/03/2020 12:00	7.8	13.7	6.4	87.1	2,658,835.3	1,359.1	1.0	0.5
07/03/2020 13:00	8.1	13.6	6.5	98.2	3,141,850.8	1,606.0	1.0	0.6
07/03/2020 14:00	8.0	13.7	6.6	92.5	2,838,621.1	1,451.0	1.0	0.6
07/03/2020 15:00	8.6	13.5	6.9	105.3	3,233,577.4	1,676.5	1.0	0.7
07/03/2020 16:00	8.1	13.5	6.5	102.6	3,165,877.7	1,641.4	1.0	0.7
07/03/2020 17:00	9.4	12.9	6.9	125.8	3,252,946.8	2,019.1	1.2	1.0
07/03/2020 18:00	9.3	12.8	6.8	136.5	3,243,843.2	2,108.2	1.4	1.1
07/03/2020 19:00	9.1	12.8	6.6	134.0	3,215,069.9	2,089.5	1.4	1.0
07/03/2020 20:00	9.1	12.8	6.6	138.6	3,221,494.8	2,117.2	1.4	1.1
07/03/2020 21:00	8.8	12.9	6.5	126.4	3,237,892.5	2,033.4	1.3	1.0
07/03/2020 22:00	8.9	12.9	6.6	128.7	3,268,306.5	2,052.5	1.3	1.0
07/03/2020 23:00	14.4	14.5	13.3	140.6	2,449,457.2	1,216.3	1.8	0.9
Average/Sum#:	13.4	13.9	14.4	122.7	2,851,269.4	1,535.1	1.4	0.8
Minimum:	7.5	12.8	6.1	0.0	1,866,020.9	451.6	-0.1	0.0
Maximum:	33.9	17.3	51.8	240.0	3,268,306.5	2,117.2	3.4	1.1
%SI	33.33	33.33	33.33	33.33	33.33	33.33	33.33	33.33

Daily Summary Report

CT2 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/04/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/05/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2020 09:00	36.9	17.2	58.8	0.0	1,835,834.2	455.8	-0.1	0.0
07/05/2020 10:00	37.9	16.9	55.9	236.9	1,826,601.4	520.2	3.8	0.8
07/05/2020 11:00	41.1	15.2	42.5	246.6	2,159,706.7	867.4	3.5	1.1
07/05/2020 12:00	7.3	13.7	6.0	89.3	2,768,023.5	1,394.7	1.0	0.6
07/05/2020 13:00	7.7	13.7	6.3	86.8	2,746,390.5	1,383.8	1.0	0.6
07/05/2020 14:00	8.1	13.6	6.5	101.0	3,149,290.3	1,632.8	1.0	0.7
07/05/2020 15:00	7.8	13.8	6.5	89.6	2,757,703.2	1,389.5	1.0	0.6
07/05/2020 16:00	8.1	13.6	6.5	99.5	3,093,163.2	1,603.7	1.0	0.6
07/05/2020 17:00	9.0	13.2	6.9	116.1	3,142,915.6	1,813.1	1.2	0.9
07/05/2020 18:00	9.3	12.8	6.8	135.5	3,187,715.6	2,095.0	1.4	1.0
07/05/2020 19:00	9.1	12.9	6.7	133.0	3,196,298.1	2,077.3	1.3	1.0
07/05/2020 20:00	9.1	12.8	6.6	135.6	3,224,148.2	2,095.4	1.4	1.0
07/05/2020 21:00	8.8	12.9	6.5	132.6	3,277,174.2	2,082.0	1.3	1.0
07/05/2020 22:00	13.5	14.1	11.7	143.2	2,587,274.1	1,379.2	1.7	1.0
07/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	15.3	14.0	16.7	124.7	2,782,302.8	1,485.0	1.5	0.8
Minimum:	7.3	12.8	6.0	0.0	1,826,601.4	455.8	-0.1	0.0
Maximum:	41.1	17.2	58.8	246.6	3,277,174.2	2,095.4	3.8	1.1
%SI	41.67	41.67	41.67	41.67	41.67	41.67	41.67	41.67

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2020 02:00	31.8	17.1	49.4	216.4	1,920,189.8	448.7	3.0	0.5
07/06/2020 03:00	26.6	14.3	23.8	179.3	2,452,981.4	1,146.4	2.2	0.9
07/06/2020 04:00	7.4	13.7	6.1	84.7	2,691,114.5	1,375.6	1.0	0.6
07/06/2020 05:00	7.7	13.7	6.3	85.4	2,691,114.5	1,375.6	1.0	0.6
07/06/2020 06:00	7.9	13.7	6.5	85.9	2,696,592.2	1,378.4	1.0	0.6
07/06/2020 07:00	8.1	13.7	6.6	86.6	2,698,548.6	1,379.4	1.0	0.6
07/06/2020 08:00	8.1	13.7	6.6	86.6	2,744,207.4	1,382.7	1.0	0.6
07/06/2020 09:00	8.1	13.7	6.6	86.7	2,709,308.3	1,384.9	1.0	0.6
07/06/2020 10:00	8.1	13.7	6.6	86.9	2,719,089.9	1,389.9	1.0	0.6
07/06/2020 11:00	8.4	13.6	6.8	102.3	3,158,934.2	1,637.8	1.0	0.7
07/06/2020 12:00	8.1	13.6	6.5	95.0	2,907,230.1	1,507.3	1.0	0.6
07/06/2020 13:00	8.6	13.5	6.9	106.3	3,228,988.6	1,697.7	1.0	0.7
07/06/2020 14:00	8.0	13.6	6.5	101.8	3,138,682.1	1,627.3	1.0	0.7
07/06/2020 15:00	8.7	13.6	7.0	98.8	2,959,668.4	1,556.1	1.0	0.6
07/06/2020 16:00	9.7	13.0	7.2	133.1	3,264,803.3	2,050.3	1.3	1.0
07/06/2020 17:00	9.5	12.9	7.0	144.5	3,229,225.8	2,098.7	1.5	1.3
07/06/2020 18:00	9.4	12.9	6.9	145.7	3,212,365.3	2,111.2	1.5	1.3
07/06/2020 19:00	9.2	12.9	6.8	141.3	3,245,380.2	2,085.5	1.4	1.0
07/06/2020 20:00	9.2	13.0	6.9	137.5	3,288,688.6	2,065.3	1.3	1.0
07/06/2020 21:00	9.1	13.0	6.8	132.6	3,287,907.4	2,040.8	1.3	1.0
07/06/2020 22:00	8.9	13.2	6.8	122.5	3,299,467.4	1,951.6	1.2	1.0
07/06/2020 23:00	8.5	13.3	6.6	114.9	3,150,729.5	1,794.6	1.2	0.9
Average/Sum#:	10.4	13.6	9.4	117.0	2,940,691.7	1,613.0	1.3	0.8
Minimum:	7.4	12.9	6.1	84.7	1,920,189.8	448.7	1.0	0.5
Maximum:	31.8	17.1	49.4	216.4	3,299,467.4	2,111.2	3.0	1.3
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT2 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/07/2020 00:00	8.1	13.7	6.6	86.3	2,533,043.8	1,294.8	1.1	0.5
07/07/2020 01:00	7.9	13.7	6.5	85.8	2,629,881.7	1,344.3	1.0	0.5
07/07/2020 02:00	8.0	13.8	6.6	85.5	2,545,564.3	1,301.2	1.1	0.5
07/07/2020 03:00	8.1	13.8	6.7	85.7	2,528,544.3	1,292.5	1.1	0.5
07/07/2020 04:00	8.2	13.8	6.8	85.8	2,510,154.9	1,283.1	1.1	0.5
07/07/2020 05:00	8.1	13.8	6.7	85.6	2,556,324.1	1,306.7	1.1	0.5
07/07/2020 06:00	8.3	13.8	6.9	86.0	2,530,500.6	1,293.5	1.1	0.5
07/07/2020 07:00	8.1	13.8	6.7	85.8	2,564,345.0	1,310.8	1.0	0.5
07/07/2020 08:00	7.9	13.8	6.6	85.5	2,638,622.8	1,329.5	1.0	0.5
07/07/2020 09:00	8.1	13.8	6.7	85.8	2,554,759.0	1,305.9	1.1	0.5
07/07/2020 10:00	8.2	13.8	6.8	86.1	2,533,435.1	1,295.0	1.1	0.5
07/07/2020 11:00	8.2	13.8	6.8	86.6	2,579,082.6	1,299.5	1.1	0.5
07/07/2020 12:00	8.2	13.8	6.8	87.5	2,583,051.9	1,301.5	1.1	0.5
07/07/2020 13:00	8.2	13.8	6.8	91.2	2,745,109.0	1,403.2	1.0	0.6
07/07/2020 14:00	8.5	13.8	7.1	87.3	2,689,353.9	1,374.7	1.0	0.5
07/07/2020 15:00	9.1	13.6	7.4	96.2	2,962,651.8	1,514.4	1.0	0.6
07/07/2020 16:00	9.9	13.0	7.4	130.9	3,240,918.0	2,035.3	1.3	1.0
07/07/2020 17:00	9.6	12.9	7.1	145.8	3,243,073.9	2,107.7	1.5	1.3
07/07/2020 18:00	9.3	12.9	6.9	140.3	3,238,377.4	2,081.0	1.4	1.0
07/07/2020 19:00	9.2	13.0	6.9	139.8	3,260,646.7	2,071.5	1.4	1.0
07/07/2020 20:00	9.1	13.0	6.8	141.6	3,266,942.9	2,075.5	1.4	1.0
07/07/2020 21:00	9.0	13.0	6.7	137.6	3,289,803.2	2,066.0	1.4	1.0
07/07/2020 22:00	8.9	13.2	6.8	127.8	3,283,612.5	1,966.2	1.3	1.0
07/07/2020 23:00	8.7	13.3	6.8	125.1	3,205,839.8	1,849.4	1.3	0.9
Average/Sum#:	8.5	13.5	6.8	103.4	2,821,401.6	1,562.6	1.2	0.7
Minimum:	7.9	12.9	6.5	85.5	2,510,154.9	1,283.1	1.0	0.5
Maximum:	9.9	13.8	7.4	145.8	3,289,803.2	2,107.7	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/08/2020 00:00	8.0	13.8	6.6	87.6	2,613,020.5	1,316.6	1.1	0.5
07/08/2020 01:00	8.2	13.8	6.8	86.0	2,546,534.0	1,283.1	1.1	0.5
07/08/2020 02:00	8.2	13.8	6.8	86.0	2,546,732.4	1,283.2	1.1	0.5
07/08/2020 03:00	8.2	13.8	6.8	85.8	2,546,732.4	1,283.2	1.1	0.5
07/08/2020 04:00	8.0	13.8	6.6	85.5	2,550,701.8	1,285.2	1.1	0.5
07/08/2020 05:00	8.0	13.8	6.6	85.3	2,572,930.1	1,296.4	1.0	0.5
07/08/2020 06:00	8.1	13.8	6.7	86.0	2,555,663.4	1,287.7	1.1	0.5
07/08/2020 07:00	8.1	13.8	6.7	85.8	2,563,800.6	1,291.8	1.0	0.5
07/08/2020 08:00	8.0	13.8	6.6	85.5	2,560,029.7	1,289.9	1.1	0.5
07/08/2020 09:00	8.1	13.8	6.7	86.0	2,559,037.4	1,289.4	1.1	0.5
07/08/2020 10:00	8.2	13.8	6.8	87.0	2,563,006.7	1,291.4	1.1	0.5
07/08/2020 11:00	8.2	13.8	6.8	88.4	2,596,746.2	1,308.4	1.1	0.5
07/08/2020 12:00	8.3	13.8	6.9	89.4	2,706,895.5	1,363.9	1.0	0.5
07/08/2020 13:00	8.4	13.8	7.0	87.9	2,611,631.2	1,315.9	1.1	0.5
07/08/2020 14:00	8.4	13.8	7.0	87.4	2,713,445.0	1,367.2	1.0	0.5
07/08/2020 15:00	8.5	13.7	7.0	93.7	2,847,620.2	1,455.6	1.0	0.6
07/08/2020 16:00	9.9	13.0	7.4	132.9	3,203,508.6	2,035.2	1.3	1.0
07/08/2020 17:00	9.7	12.9	7.2	142.5	3,181,680.6	2,067.8	1.4	1.0
07/08/2020 18:00	9.6	12.9	7.1	142.7	3,196,759.7	2,077.6	1.4	1.0
07/08/2020 19:00	9.6	12.9	7.1	145.5	3,193,528.4	2,075.5	1.5	1.2
07/08/2020 20:00	9.5	12.9	7.0	144.8	3,196,913.5	2,077.7	1.5	1.2
07/08/2020 21:00	9.3	13.0	6.9	135.1	3,210,185.5	2,016.0	1.4	1.0
07/08/2020 22:00	9.2	13.1	7.0	129.0	3,249,495.6	1,969.5	1.3	1.0
07/08/2020 23:00	8.7	13.3	6.8	119.8	3,089,763.8	1,805.0	1.2	0.9
Average/Sum#:	8.6	13.5	6.9	103.6	2,799,015.1	1,547.2	1.2	0.7
Minimum:	8.0	12.9	6.6	85.3	2,546,534.0	1,283.1	1.0	0.5
Maximum:	9.9	13.8	7.4	145.5	3,249,495.6	2,077.7	1.5	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/09/2020 00:00	8.1	13.7	6.6	86.4	2,552,411.4	1,304.7	1.1	0.5
07/09/2020 01:00	8.4	13.7	6.9	86.4	2,543,412.3	1,300.1	1.1	0.5
07/09/2020 02:00	8.5	13.8	7.1	86.6	2,508,785.5	1,282.4	1.1	0.5
07/09/2020 03:00	8.3	13.7	6.8	87.0	2,628,121.0	1,343.4	1.0	0.5
07/09/2020 04:00	8.4	13.7	6.9	86.9	2,567,475.1	1,312.4	1.1	0.5
07/09/2020 05:00	8.2	13.8	6.8	88.9	2,672,333.9	1,366.0	1.0	0.5
07/09/2020 06:00	8.4	13.8	7.0	86.2	2,571,342.4	1,295.6	1.0	0.5
07/09/2020 07:00	8.4	13.8	7.0	86.5	2,570,350.0	1,295.1	1.1	0.5
07/09/2020 08:00	8.4	13.8	7.0	86.4	2,577,891.8	1,298.9	1.0	0.5
07/09/2020 09:00	8.3	13.8	6.9	86.4	2,582,655.0	1,301.3	1.0	0.5
07/09/2020 10:00	8.4	13.8	7.0	86.7	2,536,760.9	1,296.7	1.1	0.5
07/09/2020 11:00	8.4	13.8	7.0	87.7	2,573,724.0	1,296.8	1.1	0.5
07/09/2020 12:00	8.6	13.7	7.0	98.9	3,022,906.5	1,545.2	1.0	0.6
07/09/2020 13:00	8.5	13.7	7.0	105.0	3,208,889.2	1,663.7	1.0	0.7
07/09/2020 14:00	8.6	13.6	7.0	98.4	2,960,656.9	1,535.0	1.0	0.6
07/09/2020 15:00	9.9	13.0	7.4	131.9	3,204,925.3	2,036.1	1.3	1.0
07/09/2020 16:00	9.7	12.9	7.2	140.8	3,186,142.8	2,070.7	1.4	1.0
07/09/2020 17:00	9.6	12.9	7.1	143.9	3,174,021.4	2,086.0	1.5	1.3
07/09/2020 18:00	9.6	12.9	7.1	147.1	3,170,443.2	2,106.8	1.5	1.3
07/09/2020 19:00	9.5	12.9	7.0	147.7	3,166,380.1	2,104.1	1.5	1.3
07/09/2020 20:00	9.4	12.9	6.9	141.2	3,186,142.8	2,070.7	1.4	1.0
07/09/2020 21:00	9.3	13.0	6.9	140.6	3,220,481.5	2,069.5	1.4	1.0
07/09/2020 22:00	9.0	13.1	6.8	126.6	3,258,570.1	1,975.0	1.2	1.0
07/09/2020 23:00	8.9	13.1	6.7	123.6	3,206,791.1	1,920.2	1.2	1.0
Average/Sum#:	8.8	13.5	7.0	107.8	2,868,817.3	1,619.9	1.2	0.7
Minimum:	8.1	12.9	6.6	86.2	2,508,785.5	1,282.4	1.0	0.5
Maximum:	9.9	13.8	7.4	147.7	3,258,570.1	2,106.8	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/10/2020 00:00	7.7	13.8	6.4	89.9	2,720,850.6	1,390.8	1.0	0.6
07/10/2020 01:00	7.8	13.8	6.5	84.6	2,554,274.2	1,287.0	1.0	0.5
07/10/2020 02:00	7.7	13.8	6.4	84.3	2,552,488.0	1,286.1	1.0	0.5
07/10/2020 03:00	7.6	13.8	6.3	84.3	2,547,129.4	1,283.4	1.0	0.5
07/10/2020 04:00	7.6	13.8	6.3	84.4	2,530,305.0	1,293.4	1.1	0.5
07/10/2020 05:00	7.4	13.8	6.1	95.3	3,060,467.9	1,564.4	1.0	0.6
07/10/2020 06:00	7.8	13.8	6.5	104.6	3,260,599.5	1,666.7	1.0	0.7
07/10/2020 07:00	8.2	13.7	6.7	104.9	3,214,675.5	1,666.7	1.0	0.7
07/10/2020 08:00	7.9	13.8	6.6	98.9	3,089,225.8	1,579.1	1.0	0.6
07/10/2020 09:00	7.8	13.8	6.5	90.0	2,823,948.7	1,443.5	1.0	0.6
07/10/2020 10:00	7.9	13.8	6.6	92.1	2,894,963.1	1,479.8	1.0	0.6
07/10/2020 11:00	8.0	13.8	6.6	88.4	2,687,006.3	1,373.5	1.0	0.5
07/10/2020 12:00	8.5	13.7	7.0	98.0	2,950,627.4	1,529.8	1.0	0.6
07/10/2020 13:00	9.7	13.0	7.2	127.5	3,198,242.9	2,008.5	1.3	1.0
07/10/2020 14:00	9.5	12.9	7.0	138.4	3,175,833.6	2,064.0	1.4	1.0
07/10/2020 15:00	9.4	12.9	6.9	139.4	3,181,372.9	2,067.6	1.4	1.0
07/10/2020 16:00	9.3	12.9	6.9	142.4	3,145,312.0	2,090.1	1.5	1.3
07/10/2020 17:00	9.4	12.8	6.8	146.4	3,131,069.8	2,103.5	1.5	1.3
07/10/2020 18:00	9.4	12.8	6.8	145.8	3,142,977.8	2,111.5	1.5	1.3
07/10/2020 19:00	9.4	12.8	6.8	149.1	3,148,336.4	2,115.1	1.5	1.3
07/10/2020 20:00	9.4	12.8	6.8	147.1	3,147,443.3	2,114.5	1.5	1.3
07/10/2020 21:00	9.2	13.0	6.9	135.0	3,179,087.6	2,042.9	1.4	1.0
07/10/2020 22:00	9.4	13.0	7.0	137.7	3,204,141.8	2,059.0	1.4	1.0
07/10/2020 23:00	8.7	13.3	6.8	118.6	3,061,690.6	1,788.6	1.2	0.9
Average/Sum#:	8.5	13.4	6.7	113.6	2,983,419.6	1,725.4	1.2	0.8
Minimum:	7.4	12.8	6.1	84.3	2,530,305.0	1,283.4	1.0	0.5
Maximum:	9.7	13.8	7.2	149.1	3,260,599.5	2,115.1	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/11/2020 00:00	8.3	13.7	6.8	86.6	2,536,565.2	1,296.6	1.1	0.5
07/11/2020 01:00	8.3	13.8	6.9	86.6	2,630,859.9	1,344.8	1.0	0.5
07/11/2020 02:00	8.3	13.8	6.9	86.5	2,644,945.4	1,352.0	1.0	0.5
07/11/2020 03:00	8.4	13.7	6.9	86.9	2,676,637.8	1,368.2	1.0	0.5
07/11/2020 04:00	8.3	13.8	6.9	86.5	2,607,970.9	1,333.1	1.0	0.5
07/11/2020 05:00	8.2	13.7	6.7	102.4	3,238,297.4	1,655.3	1.0	0.7
07/11/2020 06:00	8.1	13.7	6.6	100.8	3,101,550.6	1,585.4	1.0	0.6
07/11/2020 07:00	8.4	13.8	7.0	88.1	2,660,595.9	1,360.0	1.0	0.5
07/11/2020 08:00	8.5	13.8	7.1	99.2	3,085,900.0	1,577.4	1.0	0.6
07/11/2020 09:00	8.5	13.8	7.1	87.3	2,560,628.0	1,308.9	1.1	0.5
07/11/2020 10:00	8.4	13.8	7.0	93.2	2,893,398.1	1,479.0	1.0	0.6
07/11/2020 11:00	8.8	13.7	7.2	101.4	3,105,893.1	1,610.3	1.0	0.6
07/11/2020 12:00	8.7	13.7	7.1	102.0	3,167,478.6	1,619.1	1.0	0.6
07/11/2020 13:00	8.3	13.8	6.9	88.5	2,669,399.4	1,364.5	1.0	0.5
07/11/2020 14:00	8.4	13.8	7.0	87.7	2,666,856.2	1,363.2	1.0	0.5
07/11/2020 15:00	9.5	13.3	7.4	119.2	3,096,979.2	1,786.6	1.2	0.9
07/11/2020 16:00	9.7	12.9	7.2	141.0	3,180,412.1	2,090.2	1.4	1.0
07/11/2020 17:00	9.5	12.9	7.0	146.2	3,180,977.2	2,113.8	1.5	1.3
07/11/2020 18:00	9.5	12.9	7.0	149.1	3,193,768.5	2,122.3	1.5	1.3
07/11/2020 19:00	9.5	12.9	7.0	152.2	3,201,292.8	2,127.3	1.5	1.3
07/11/2020 20:00	9.2	12.9	6.8	142.8	3,208,915.2	2,085.5	1.4	1.0
07/11/2020 21:00	9.2	13.0	6.9	136.7	3,226,962.0	2,050.1	1.4	1.0
07/11/2020 22:00	9.1	13.0	6.8	136.6	3,250,887.6	2,065.3	1.4	1.0
07/11/2020 23:00	8.6	13.2	6.6	117.0	3,091,304.4	1,805.9	1.2	0.9
Average/Sum#:	8.7	13.5	7.0	109.4	2,953,269.8	1,661.0	1.2	0.7
Minimum:	8.1	12.9	6.6	86.5	2,536,565.2	1,296.6	1.0	0.5
Maximum:	9.7	13.8	7.4	152.2	3,250,887.6	2,127.3	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/12/2020 00:00	8.1	13.8	6.7	86.2	2,534,608.9	1,295.6	1.1	0.5
07/12/2020 01:00	8.2	13.8	6.8	86.0	2,518,175.8	1,287.2	1.1	0.5
07/12/2020 02:00	8.4	13.8	7.0	86.4	2,515,828.2	1,286.0	1.1	0.5
07/12/2020 03:00	8.4	13.8	7.0	86.4	2,515,632.6	1,285.9	1.1	0.5
07/12/2020 04:00	8.3	13.8	6.9	86.0	2,517,980.2	1,287.1	1.1	0.5
07/12/2020 05:00	8.3	13.8	6.9	86.1	2,520,914.7	1,288.6	1.1	0.5
07/12/2020 06:00	8.3	13.8	6.9	86.7	2,579,678.0	1,299.8	1.1	0.5
07/12/2020 07:00	8.3	13.8	6.9	86.4	2,571,937.8	1,295.9	1.1	0.5
07/12/2020 08:00	8.3	13.8	6.9	86.2	2,561,419.0	1,290.6	1.1	0.5
07/12/2020 09:00	8.3	13.8	6.9	86.5	2,581,861.1	1,300.9	1.0	0.5
07/12/2020 10:00	8.4	13.8	7.0	90.2	2,785,488.6	1,403.5	1.0	0.6
07/12/2020 11:00	8.4	13.8	7.0	90.2	2,683,289.3	1,371.6	1.1	0.5
07/12/2020 12:00	8.4	13.8	7.0	90.7	2,792,843.2	1,427.6	1.0	0.6
07/12/2020 13:00	8.3	13.8	6.9	88.4	2,710,269.5	1,365.6	1.0	0.5
07/12/2020 14:00	8.3	13.9	7.0	88.3	2,606,471.1	1,313.3	1.1	0.5
07/12/2020 15:00	8.8	13.6	7.1	103.5	3,126,281.7	1,643.7	1.0	0.7
07/12/2020 16:00	9.9	13.0	7.4	134.7	3,195,271.7	2,053.3	1.4	1.0
07/12/2020 17:00	9.7	12.8	7.1	148.7	3,143,424.4	2,111.8	1.5	1.3
07/12/2020 18:00	9.6	12.8	7.0	146.2	3,129,134.7	2,102.2	1.5	1.3
07/12/2020 19:00	9.6	12.8	7.0	144.8	3,146,967.3	2,091.2	1.5	1.3
07/12/2020 20:00	9.4	12.9	6.9	138.1	3,152,291.8	2,048.7	1.4	1.0
07/12/2020 21:00	9.3	13.0	6.9	133.4	3,182,731.2	2,022.0	1.4	1.0
07/12/2020 22:00	9.3	12.9	6.9	136.9	3,171,833.1	2,061.4	1.4	1.0
07/12/2020 23:00	9.1	13.1	6.9	124.9	3,156,523.2	1,936.2	1.3	1.0
Average/Sum#:	8.7	13.5	7.0	105.1	2,808,369.0	1,577.9	1.2	0.7
Minimum:	8.1	12.8	6.7	86.0	2,515,632.6	1,285.9	1.0	0.5
Maximum:	9.9	13.9	7.4	148.7	3,195,271.7	2,111.8	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/13/2020 00:00	8.0	13.6	6.5	102.2	3,039,350.6	1,575.8	1.1	0.6
07/13/2020 01:00	8.1	13.7	6.6	91.0	2,774,531.0	1,438.5	1.0	0.6
07/13/2020 02:00	8.2	13.7	6.7	86.9	2,582,147.5	1,319.9	1.1	0.5
07/13/2020 03:00	8.4	13.7	6.9	86.9	2,521,697.2	1,289.0	1.1	0.5
07/13/2020 04:00	8.4	13.8	7.0	86.9	2,522,088.5	1,289.2	1.1	0.5
07/13/2020 05:00	8.2	13.7	6.7	102.1	3,129,038.3	1,622.3	1.0	0.6
07/13/2020 06:00	8.0	13.7	6.6	95.9	2,867,497.5	1,486.7	1.1	0.6
07/13/2020 07:00	8.4	13.7	6.9	88.9	2,719,285.6	1,390.0	1.0	0.6
07/13/2020 08:00	8.3	13.7	6.8	96.2	2,977,128.6	1,521.8	1.0	0.6
07/13/2020 09:00	8.4	13.8	7.0	87.5	2,555,737.2	1,306.4	1.1	0.5
07/13/2020 10:00	8.3	13.7	6.8	93.2	2,896,723.8	1,480.7	1.0	0.6
07/13/2020 11:00	8.6	13.7	7.0	102.2	3,119,780.2	1,617.5	1.0	0.6
07/13/2020 12:00	9.6	13.0	7.2	126.4	3,223,625.0	2,000.9	1.3	1.0
07/13/2020 13:00	9.5	12.9	7.0	134.9	3,155,523.1	2,050.8	1.4	1.0
07/13/2020 14:00	9.3	12.9	6.9	137.6	3,175,679.8	2,063.9	1.4	1.0
07/13/2020 15:00	9.3	12.9	6.9	136.7	3,141,459.5	2,064.6	1.4	1.0
07/13/2020 16:00	9.3	12.9	6.9	137.8	3,156,371.0	2,074.4	1.4	1.0
07/13/2020 17:00	9.4	12.8	6.8	140.4	3,135,981.8	2,083.9	1.5	1.3
07/13/2020 18:00	9.3	12.9	6.9	139.8	3,135,379.9	2,083.5	1.4	1.0
07/13/2020 19:00	9.3	12.9	6.9	138.8	3,163,826.8	2,079.3	1.4	1.0
07/13/2020 20:00	9.1	12.9	6.7	136.3	3,181,065.1	2,067.4	1.4	1.0
07/13/2020 21:00	9.1	12.9	6.7	135.0	3,199,784.6	2,056.2	1.4	1.0
07/13/2020 22:00	8.9	12.9	6.6	132.2	3,236,406.3	2,056.1	1.3	1.0
07/13/2020 23:00	8.7	13.1	6.6	119.5	3,250,378.9	1,946.3	1.2	1.0
Average/Sum#:	8.8	13.3	6.8	114.0	2,994,187.0	1,748.5	1.2	0.8
Minimum:	8.0	12.8	6.5	86.9	2,521,697.2	1,289.0	1.0	0.5
Maximum:	9.6	13.8	7.2	140.4	3,250,378.9	2,083.9	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/14/2020 00:00	8.3	13.3	6.4	111.5	3,118,951.8	1,776.5	1.1	0.7
07/14/2020 01:00	7.9	13.7	6.5	85.7	2,496,402.8	1,294.3	1.1	0.5
07/14/2020 02:00	7.9	13.7	6.5	85.3	2,644,749.7	1,351.9	1.0	0.5
07/14/2020 03:00	8.3	13.7	6.8	86.0	2,529,131.2	1,292.8	1.1	0.5
07/14/2020 04:00	8.4	13.7	6.9	86.3	2,517,002.0	1,286.6	1.1	0.5
07/14/2020 05:00	8.1	13.7	6.6	101.1	3,135,403.2	1,625.6	1.0	0.7
07/14/2020 06:00	8.2	13.7	6.7	100.7	3,197,702.4	1,657.9	1.0	0.7
07/14/2020 07:00	8.5	13.7	7.0	105.8	3,224,705.1	1,671.9	1.0	0.7
07/14/2020 08:00	8.0	13.7	6.6	97.2	2,983,609.3	1,546.9	1.0	0.6
07/14/2020 09:00	8.5	13.7	7.0	87.2	2,539,108.4	1,297.9	1.1	0.5
07/14/2020 10:00	8.4	13.7	6.9	87.2	2,569,627.0	1,313.5	1.1	0.5
07/14/2020 11:00	8.5	13.7	7.0	89.1	2,660,009.0	1,359.7	1.0	0.5
07/14/2020 12:00	8.3	13.7	6.8	95.6	2,952,556.1	1,530.8	1.0	0.6
07/14/2020 13:00	8.5	13.7	7.0	88.4	2,621,665.2	1,340.1	1.1	0.5
07/14/2020 14:00	9.8	13.0	7.3	124.4	3,156,281.5	1,959.1	1.3	1.0
07/14/2020 15:00	9.6	12.9	7.1	133.7	3,141,059.5	2,041.4	1.4	1.0
07/14/2020 16:00	9.4	12.9	6.9	136.4	3,169,678.9	2,060.0	1.4	1.0
07/14/2020 17:00	9.3	12.9	6.9	135.9	3,138,872.8	2,062.9	1.4	1.0
07/14/2020 18:00	9.3	12.9	6.9	138.4	3,162,457.4	2,078.4	1.4	1.0
07/14/2020 19:00	9.3	12.8	6.8	137.8	3,157,740.5	2,075.3	1.4	1.0
07/14/2020 20:00	9.2	12.9	6.8	136.3	3,182,296.1	2,068.2	1.4	1.0
07/14/2020 21:00	9.2	12.9	6.8	137.8	3,188,604.7	2,072.3	1.4	1.0
07/14/2020 22:00	8.9	13.1	6.7	123.0	3,221,447.1	1,952.5	1.2	1.0
07/14/2020 23:00	8.5	13.3	6.6	113.1	3,081,204.9	1,777.5	1.2	0.9
Average/Sum#:	8.7	13.4	6.8	109.3	2,949,594.4	1,687.3	1.2	0.7
Minimum:	7.9	12.8	6.4	85.3	2,496,402.8	1,286.6	1.0	0.5
Maximum:	9.8	13.7	7.3	138.4	3,224,705.1	2,078.4	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/15/2020 00:00	8.3	13.7	6.8	86.8	2,488,880.6	1,290.4	1.1	0.5
07/15/2020 01:00	8.4	13.7	6.9	86.5	2,522,088.5	1,289.2	1.1	0.5
07/15/2020 02:00	8.4	13.8	7.0	86.6	2,519,349.6	1,287.8	1.1	0.5
07/15/2020 03:00	8.4	13.8	7.0	86.6	2,522,479.7	1,289.4	1.1	0.5
07/15/2020 04:00	8.3	13.8	6.9	86.4	2,523,262.2	1,289.8	1.1	0.5
07/15/2020 05:00	8.4	13.7	6.9	86.9	2,572,561.5	1,315.0	1.1	0.5
07/15/2020 06:00	8.5	13.7	7.0	86.9	2,545,564.3	1,301.2	1.1	0.5
07/15/2020 07:00	8.7	13.8	7.2	87.4	2,519,740.9	1,288.0	1.1	0.5
07/15/2020 08:00	8.6	13.8	7.1	87.2	2,523,066.6	1,289.7	1.1	0.5
07/15/2020 09:00	8.6	13.8	7.1	87.2	2,530,305.0	1,293.4	1.1	0.5
07/15/2020 10:00	8.6	13.7	7.0	87.3	2,531,674.4	1,294.1	1.1	0.5
07/15/2020 11:00	8.6	13.7	7.0	87.4	2,537,934.6	1,297.3	1.1	0.5
07/15/2020 12:00	8.6	13.7	7.0	87.7	2,533,826.4	1,295.2	1.1	0.5
07/15/2020 13:00	8.6	13.7	7.0	88.2	2,540,673.5	1,298.7	1.1	0.5
07/15/2020 14:00	8.6	13.8	7.1	88.6	2,557,302.2	1,307.2	1.1	0.5
07/15/2020 15:00	8.5	13.8	7.1	88.9	2,548,303.1	1,302.6	1.1	0.5
07/15/2020 16:00	8.6	13.7	7.0	88.1	2,559,649.8	1,308.4	1.1	0.5
07/15/2020 17:00	8.7	13.7	7.1	88.5	2,559,454.2	1,308.3	1.1	0.5
07/15/2020 18:00	8.6	13.7	7.0	90.3	2,722,415.7	1,391.6	1.0	0.6
07/15/2020 19:00	8.3	13.7	6.8	91.8	2,854,271.7	1,459.0	1.0	0.6
07/15/2020 20:00	8.5	13.7	7.0	89.9	2,651,401.2	1,355.3	1.1	0.5
07/15/2020 21:00	8.5	13.7	7.0	86.9	2,518,371.4	1,287.3	1.1	0.5
07/15/2020 22:00	8.6	13.7	7.0	86.9	2,511,915.6	1,284.0	1.1	0.5
07/15/2020 23:00	8.5	13.7	7.0	87.6	2,573,735.3	1,315.6	1.1	0.5
Average/Sum#:	8.5	13.7	7.0	87.8	2,561,176.2	1,309.9	1.1	0.5
Minimum:	8.3	13.7	6.8	86.4	2,488,880.6	1,284.0	1.0	0.5
Maximum:	8.7	13.8	7.2	91.8	2,854,271.7	1,459.0	1.1	0.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/16/2020 00:00	8.6	13.8	7.1	87.1	2,512,306.8	1,284.2	1.1	0.5
07/16/2020 01:00	8.6	13.8	7.1	87.0	2,515,437.0	1,285.8	1.1	0.5
07/16/2020 02:00	8.6	13.7	7.0	87.0	2,511,915.6	1,284.0	1.1	0.5
07/16/2020 03:00	8.6	13.7	7.0	87.0	2,508,198.6	1,282.1	1.1	0.5
07/16/2020 04:00	8.6	13.7	7.0	87.1	2,509,372.4	1,282.7	1.1	0.5
07/16/2020 05:00	8.6	13.7	7.0	87.1	2,510,546.2	1,283.3	1.1	0.5
07/16/2020 06:00	8.7	13.8	7.2	88.0	2,514,850.1	1,285.5	1.1	0.5
07/16/2020 07:00	8.7	13.7	7.1	87.4	2,516,806.4	1,286.5	1.1	0.5
07/16/2020 08:00	8.5	13.7	7.0	87.0	2,522,871.0	1,289.6	1.1	0.5
07/16/2020 09:00	8.5	13.8	7.1	86.8	2,529,131.2	1,292.8	1.1	0.5
07/16/2020 10:00	8.4	13.8	7.0	86.8	2,538,912.8	1,297.8	1.1	0.5
07/16/2020 11:00	8.4	13.8	7.0	86.8	2,533,630.7	1,295.1	1.1	0.5
07/16/2020 12:00	8.4	13.8	7.0	86.9	2,532,065.7	1,294.3	1.1	0.5
07/16/2020 13:00	8.4	13.8	7.0	88.1	2,536,760.9	1,296.7	1.1	0.5
07/16/2020 14:00	8.4	13.7	6.9	92.5	2,860,140.6	1,462.0	1.0	0.6
07/16/2020 15:00	8.7	13.7	7.1	96.8	2,898,936.4	1,503.0	1.0	0.6
07/16/2020 16:00	9.9	12.9	7.3	130.2	3,159,013.1	2,030.0	1.3	1.0
07/16/2020 17:00	9.4	12.9	6.9	134.3	3,136,438.3	2,061.3	1.4	1.0
07/16/2020 18:00	9.3	12.9	6.9	133.2	3,156,138.5	2,051.2	1.4	1.0
07/16/2020 19:00	9.2	12.9	6.8	135.5	3,158,653.4	2,075.9	1.4	1.0
07/16/2020 20:00	9.1	12.9	6.7	134.7	3,158,044.8	2,075.5	1.4	1.0
07/16/2020 21:00	8.9	12.9	6.6	133.3	3,220,014.7	2,069.2	1.3	1.0
07/16/2020 22:00	8.7	13.1	6.6	120.6	3,260,733.1	1,952.5	1.2	1.0
07/16/2020 23:00	8.3	13.3	6.4	111.5	3,122,638.7	1,778.6	1.1	0.7
Average/Sum#:	8.7	13.5	7.0	101.8	2,767,648.2	1,545.8	1.2	0.7
Minimum:	8.3	12.9	6.4	86.8	2,508,198.6	1,282.1	1.0	0.5
Maximum:	9.9	13.8	7.3	135.5	3,260,733.1	2,075.9	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/17/2020 00:00	7.9	13.7	6.5	85.8	2,495,824.2	1,294.0	1.1	0.5
07/17/2020 01:00	8.1	13.8	6.7	85.8	2,534,022.0	1,295.3	1.1	0.5
07/17/2020 02:00	8.3	13.8	6.9	86.3	2,524,240.4	1,290.3	1.1	0.5
07/17/2020 03:00	8.2	13.8	6.8	86.2	2,538,912.8	1,297.8	1.1	0.5
07/17/2020 04:00	8.2	13.8	6.8	86.1	2,528,739.9	1,292.6	1.1	0.5
07/17/2020 05:00	8.2	13.8	6.8	86.2	2,543,608.0	1,300.2	1.1	0.5
07/17/2020 06:00	8.2	13.8	6.8	86.4	2,544,586.1	1,300.7	1.1	0.5
07/17/2020 07:00	8.3	13.8	6.9	86.5	2,534,608.9	1,295.6	1.1	0.5
07/17/2020 08:00	8.2	13.8	6.8	86.0	2,539,304.1	1,298.0	1.1	0.5
07/17/2020 09:00	8.1	13.8	6.7	85.9	2,566,496.9	1,311.9	1.1	0.5
07/17/2020 10:00	8.2	13.8	6.8	86.3	2,554,172.1	1,305.6	1.1	0.5
07/17/2020 11:00	8.3	13.7	6.8	86.5	2,560,041.1	1,308.6	1.1	0.5
07/17/2020 12:00	8.4	13.7	6.9	86.7	2,577,843.6	1,317.7	1.1	0.5
07/17/2020 13:00	8.4	13.7	6.9	86.9	2,596,819.9	1,327.4	1.0	0.5
07/17/2020 14:00	8.5	13.7	7.0	87.0	2,543,608.0	1,300.2	1.1	0.5
07/17/2020 15:00	8.5	13.7	7.0	87.0	2,549,281.3	1,303.1	1.1	0.5
07/17/2020 16:00	8.7	13.6	7.0	96.8	2,898,743.5	1,502.9	1.0	0.6
07/17/2020 17:00	10.0	12.9	7.4	130.3	3,142,050.9	2,019.1	1.3	1.0
07/17/2020 18:00	9.5	12.9	7.0	137.2	3,140,546.6	2,064.0	1.4	1.0
07/17/2020 19:00	9.3	12.9	6.9	138.3	3,187,373.7	2,071.5	1.4	1.0
07/17/2020 20:00	9.2	12.9	6.8	139.1	3,195,836.5	2,077.0	1.4	1.0
07/17/2020 21:00	9.1	12.9	6.7	137.7	3,217,213.6	2,067.4	1.4	1.0
07/17/2020 22:00	8.8	13.1	6.7	122.0	3,236,131.3	1,961.4	1.2	1.0
07/17/2020 23:00	8.7	13.3	6.8	119.2	3,203,586.3	1,848.1	1.2	0.9
Average/Sum#:	8.6	13.5	6.9	100.1	2,748,066.3	1,518.8	1.2	0.6
Minimum:	7.9	12.9	6.5	85.8	2,495,824.2	1,290.3	1.0	0.5
Maximum:	10.0	13.8	7.4	139.1	3,236,131.3	2,077.0	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/18/2020 00:00	8.3	13.5	6.6	109.3	3,322,565.9	1,746.9	1.0	0.7
07/18/2020 01:00	8.0	13.6	6.5	100.8	3,068,475.0	1,590.9	1.0	0.6
07/18/2020 02:00	8.2	13.7	6.7	86.5	2,555,345.9	1,306.2	1.1	0.5
07/18/2020 03:00	8.1	13.8	6.7	86.0	2,557,302.2	1,307.2	1.1	0.5
07/18/2020 04:00	8.0	13.8	6.6	85.7	2,579,604.3	1,318.6	1.0	0.5
07/18/2020 05:00	7.9	13.8	6.6	86.9	2,643,967.2	1,351.5	1.0	0.5
07/18/2020 06:00	8.2	13.8	6.8	86.5	2,527,174.9	1,291.8	1.1	0.5
07/18/2020 07:00	8.4	13.8	7.0	86.5	2,527,566.1	1,292.0	1.1	0.5
07/18/2020 08:00	8.3	13.8	6.9	86.4	2,527,957.4	1,292.2	1.1	0.5
07/18/2020 09:00	8.3	13.8	6.9	86.6	2,539,695.3	1,298.2	1.1	0.5
07/18/2020 10:00	8.4	13.8	7.0	87.1	2,542,042.9	1,299.4	1.1	0.5
07/18/2020 11:00	8.4	13.8	7.0	90.8	2,717,916.1	1,389.3	1.0	0.6
07/18/2020 12:00	8.4	13.8	7.0	90.6	2,748,434.7	1,404.9	1.0	0.6
07/18/2020 13:00	8.8	13.7	7.2	100.7	3,055,359.4	1,584.1	1.0	0.6
07/18/2020 14:00	9.6	13.1	7.3	123.1	3,224,994.4	1,978.2	1.2	1.0
07/18/2020 15:00	8.3	13.6	6.7	100.3	2,791,960.2	1,508.7	1.1	0.6
07/18/2020 16:00	8.6	13.7	7.0	100.1	3,072,525.4	1,593.0	1.0	0.6
07/18/2020 17:00	9.6	13.0	7.2	130.0	3,166,833.2	2,011.9	1.3	1.0
07/18/2020 18:00	9.5	12.9	7.0	141.6	3,143,807.1	2,089.1	1.5	1.3
07/18/2020 19:00	9.5	12.9	7.0	146.9	3,174,205.3	2,109.3	1.5	1.3
07/18/2020 20:00	9.4	12.9	6.9	143.6	3,167,630.8	2,081.8	1.5	1.2
07/18/2020 21:00	9.2	13.0	6.9	127.5	3,190,436.6	1,980.3	1.3	1.0
07/18/2020 22:00	9.3	13.1	7.0	127.2	3,205,105.2	1,966.0	1.3	1.0
07/18/2020 23:00	9.0	13.2	6.9	123.6	3,121,104.1	1,846.1	1.3	0.9
Average/Sum#:	8.7	13.5	6.9	105.6	2,882,167.1	1,609.9	1.2	0.7
Minimum:	7.9	12.9	6.5	85.7	2,527,174.9	1,291.8	1.0	0.5
Maximum:	9.6	13.8	7.3	146.9	3,322,565.9	2,109.3	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/19/2020 00:00	8.9	13.4	7.0	111.3	3,254,540.2	1,734.9	1.1	0.7
07/19/2020 01:00	8.4	13.7	6.9	88.9	2,529,963.3	1,311.7	1.1	0.5
07/19/2020 02:00	8.6	13.7	7.0	87.4	2,519,154.0	1,287.7	1.1	0.5
07/19/2020 03:00	8.6	13.7	7.0	87.4	2,529,326.8	1,292.9	1.1	0.5
07/19/2020 04:00	8.5	13.7	7.0	87.4	2,517,784.5	1,287.0	1.1	0.5
07/19/2020 05:00	8.5	13.8	7.1	87.3	2,520,914.7	1,288.6	1.1	0.5
07/19/2020 06:00	8.6	13.8	7.1	87.7	2,517,980.2	1,287.1	1.1	0.5
07/19/2020 07:00	8.6	13.8	7.1	87.8	2,524,631.7	1,290.5	1.1	0.5
07/19/2020 08:00	8.5	13.8	7.1	87.5	2,541,651.7	1,299.2	1.1	0.5
07/19/2020 09:00	8.4	13.7	6.9	87.2	2,530,696.3	1,293.6	1.1	0.5
07/19/2020 10:00	8.5	13.7	7.0	87.5	2,544,781.8	1,300.8	1.1	0.5
07/19/2020 11:00	8.5	13.7	7.0	87.4	2,543,216.7	1,300.0	1.1	0.5
07/19/2020 12:00	8.5	13.7	7.0	87.3	2,543,999.2	1,300.4	1.1	0.5
07/19/2020 13:00	8.5	13.7	7.0	88.4	2,548,890.0	1,302.9	1.1	0.5
07/19/2020 14:00	8.5	13.8	7.1	89.0	2,560,628.0	1,308.9	1.1	0.5
07/19/2020 15:00	8.4	13.8	7.0	89.1	2,557,106.6	1,307.1	1.1	0.5
07/19/2020 16:00	8.9	13.6	7.2	97.8	2,886,206.5	1,496.4	1.1	0.6
07/19/2020 17:00	10.0	12.9	7.4	129.4	3,132,402.7	2,012.9	1.3	1.0
07/19/2020 18:00	9.5	12.8	6.9	138.1	3,131,166.3	2,080.7	1.4	1.0
07/19/2020 19:00	9.2	12.8	6.7	137.1	3,160,479.3	2,077.1	1.4	1.0
07/19/2020 20:00	9.1	12.9	6.7	136.3	3,183,065.4	2,068.7	1.4	1.0
07/19/2020 21:00	9.0	12.9	6.6	133.5	3,196,516.6	2,054.1	1.4	1.0
07/19/2020 22:00	8.9	13.1	6.7	122.0	3,219,302.2	1,951.2	1.2	1.0
07/19/2020 23:00	8.5	13.3	6.6	113.9	3,111,051.3	1,772.0	1.2	0.9
Average/Sum#:	8.7	13.5	7.0	101.5	2,762,727.3	1,529.4	1.2	0.7
Minimum:	8.4	12.8	6.6	87.2	2,517,784.5	1,287.0	1.1	0.5
Maximum:	10.0	13.8	7.4	138.1	3,254,540.2	2,080.7	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/20/2020 00:00	8.1	13.7	6.6	86.5	2,524,631.7	1,290.5	1.1	0.5
07/20/2020 01:00	8.2	13.8	6.8	86.3	2,508,394.2	1,282.2	1.1	0.5
07/20/2020 02:00	8.3	13.8	6.9	86.5	2,505,851.0	1,280.9	1.1	0.5
07/20/2020 03:00	8.3	13.8	6.9	86.5	2,504,285.9	1,280.1	1.1	0.5
07/20/2020 04:00	8.3	13.8	6.9	86.5	2,501,547.1	1,278.7	1.1	0.5
07/20/2020 05:00	8.4	13.8	7.0	87.2	2,531,870.1	1,294.2	1.1	0.5
07/20/2020 06:00	8.0	13.7	6.6	102.8	3,193,652.0	1,655.8	1.0	0.7
07/20/2020 07:00	8.1	13.7	6.6	102.7	3,140,225.1	1,628.1	1.0	0.7
07/20/2020 08:00	8.2	13.7	6.7	105.1	3,223,162.1	1,671.1	1.0	0.7
07/20/2020 09:00	8.1	13.8	6.7	88.6	2,702,461.2	1,381.4	1.0	0.6
07/20/2020 10:00	8.0	13.7	6.6	96.0	2,991,801.0	1,529.3	1.0	0.6
07/20/2020 11:00	8.0	13.7	6.6	96.2	2,969,336.4	1,539.5	1.0	0.6
07/20/2020 12:00	8.6	13.6	7.0	97.3	2,926,710.6	1,517.4	1.0	0.6
07/20/2020 13:00	9.6	13.0	7.2	125.6	3,182,637.8	1,998.7	1.3	1.0
07/20/2020 14:00	9.2	13.0	6.9	123.8	3,185,120.0	1,977.0	1.2	1.0
07/20/2020 15:00	9.3	12.9	6.9	132.5	3,133,981.6	2,036.8	1.4	1.0
07/20/2020 16:00	9.2	12.9	6.8	134.2	3,141,521.1	2,041.7	1.4	1.0
07/20/2020 17:00	9.2	12.9	6.8	133.5	3,145,675.5	2,044.4	1.4	1.0
07/20/2020 18:00	9.2	12.8	6.7	137.0	3,150,436.9	2,070.5	1.4	1.0
07/20/2020 19:00	9.0	12.9	6.6	136.5	3,153,480.0	2,072.5	1.4	1.0
07/20/2020 20:00	9.0	12.9	6.6	135.8	3,178,911.0	2,066.0	1.4	1.0
07/20/2020 21:00	9.0	12.9	6.6	133.4	3,188,735.8	2,049.1	1.4	1.0
07/20/2020 22:00	8.7	13.0	6.5	124.2	3,223,853.2	1,977.5	1.2	1.0
07/20/2020 23:00	8.1	13.3	6.3	111.5	3,050,176.1	1,759.6	1.2	0.9
Average/Sum#:	8.6	13.4	6.7	109.8	2,956,602.4	1,696.8	1.2	0.8
Minimum:	8.0	12.8	6.3	86.3	2,501,547.1	1,278.7	1.0	0.5
Maximum:	9.6	13.8	7.2	137.0	3,223,853.2	2,072.5	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/21/2020 00:00	7.9	13.8	6.6	86.4	2,510,350.5	1,283.2	1.1	0.5
07/21/2020 01:00	8.1	13.8	6.7	86.3	2,508,394.2	1,282.2	1.1	0.5
07/21/2020 02:00	8.2	13.7	6.7	86.7	2,507,416.0	1,281.7	1.1	0.5
07/21/2020 03:00	8.4	13.7	6.9	87.1	2,505,655.4	1,280.8	1.1	0.5
07/21/2020 04:00	8.4	13.7	6.9	87.4	2,505,068.5	1,280.5	1.1	0.5
07/21/2020 05:00	8.5	13.7	7.0	87.8	2,527,957.4	1,292.2	1.1	0.5
07/21/2020 06:00	8.2	13.7	6.7	100.9	3,176,871.7	1,647.1	1.0	0.7
07/21/2020 07:00	8.1	13.7	6.6	97.4	2,937,318.9	1,522.9	1.0	0.6
07/21/2020 08:00	7.9	13.7	6.5	96.1	2,974,389.8	1,520.4	1.0	0.6
07/21/2020 09:00	8.2	13.7	6.7	88.4	2,677,420.3	1,368.6	1.0	0.5
07/21/2020 10:00	7.9	13.7	6.5	94.4	2,903,179.7	1,505.2	1.0	0.6
07/21/2020 11:00	8.3	13.7	6.8	88.3	2,674,681.5	1,367.2	1.0	0.5
07/21/2020 12:00	8.4	13.7	6.9	89.6	2,702,461.2	1,381.4	1.0	0.6
07/21/2020 13:00	9.2	13.2	7.0	116.4	3,064,258.2	1,790.1	1.2	0.9
07/21/2020 14:00	9.6	12.9	7.1	133.4	3,145,060.0	2,044.0	1.4	1.0
07/21/2020 15:00	9.4	12.8	6.8	136.2	3,121,070.3	2,051.2	1.4	1.0
07/21/2020 16:00	9.3	12.8	6.8	137.9	3,112,506.0	2,068.3	1.4	1.0
07/21/2020 17:00	9.2	12.8	6.7	140.2	3,144,860.5	2,089.8	1.4	1.0
07/21/2020 18:00	9.1	12.8	6.6	138.5	3,140,496.4	2,086.9	1.4	1.0
07/21/2020 19:00	9.0	12.9	6.6	135.6	3,156,979.7	2,074.8	1.4	1.0
07/21/2020 20:00	9.0	12.9	6.6	136.5	3,194,297.8	2,076.0	1.4	1.0
07/21/2020 21:00	8.9	12.9	6.6	133.1	3,206,009.2	2,060.2	1.3	1.0
07/21/2020 22:00	8.6	13.1	6.5	119.8	3,247,350.7	1,968.2	1.2	1.0
07/21/2020 23:00	8.1	13.3	6.3	112.5	3,171,170.8	1,829.4	1.1	0.7
Average/Sum#:	8.6	13.4	6.7	109.0	2,908,967.7	1,673.0	1.2	0.7
Minimum:	7.9	12.8	6.3	86.3	2,505,068.5	1,280.5	1.0	0.5
Maximum:	9.6	13.8	7.1	140.2	3,247,350.7	2,089.8	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/22/2020 00:00	7.9	13.7	6.5	92.3	2,687,736.4	1,393.5	1.1	0.6
07/22/2020 01:00	8.2	13.7	6.7	86.6	2,504,481.6	1,280.2	1.1	0.5
07/22/2020 02:00	8.2	13.7	6.7	86.6	2,505,655.4	1,280.8	1.1	0.5
07/22/2020 03:00	8.2	13.7	6.7	86.6	2,499,982.0	1,277.9	1.1	0.5
07/22/2020 04:00	8.4	13.7	6.9	87.5	2,528,544.3	1,292.5	1.1	0.5
07/22/2020 05:00	8.1	13.7	6.6	88.2	2,647,811.0	1,372.8	1.0	0.5
07/22/2020 06:00	8.1	13.7	6.6	98.1	3,193,266.2	1,655.6	1.0	0.7
07/22/2020 07:00	8.2	13.7	6.7	88.6	2,655,705.1	1,357.5	1.0	0.5
07/22/2020 08:00	8.4	13.7	6.9	87.3	2,531,478.8	1,294.0	1.1	0.5
07/22/2020 09:00	8.3	13.7	6.8	87.2	2,535,782.7	1,296.2	1.1	0.5
07/22/2020 10:00	8.3	13.7	6.8	87.4	2,539,304.1	1,298.0	1.1	0.5
07/22/2020 11:00	8.3	13.8	6.9	87.2	2,539,891.0	1,298.3	1.1	0.5
07/22/2020 12:00	8.4	13.8	7.0	87.2	2,529,326.8	1,292.9	1.1	0.5
07/22/2020 13:00	8.4	13.7	6.9	87.4	2,527,174.9	1,291.8	1.1	0.5
07/22/2020 14:00	8.4	13.7	6.9	87.5	2,528,739.9	1,292.6	1.1	0.5
07/22/2020 15:00	8.4	13.8	7.0	87.7	2,545,173.0	1,301.0	1.1	0.5
07/22/2020 16:00	8.7	13.6	7.0	103.1	3,145,625.7	1,630.9	1.0	0.7
07/22/2020 17:00	9.6	13.0	7.2	126.8	3,180,408.5	1,997.3	1.3	1.0
07/22/2020 18:00	9.3	12.9	6.9	135.0	3,179,243.2	2,043.0	1.4	1.0
07/22/2020 19:00	9.1	12.9	6.7	134.2	3,211,064.1	2,040.0	1.4	1.0
07/22/2020 20:00	9.1	12.9	6.7	132.8	3,247,924.3	2,039.7	1.3	1.0
07/22/2020 21:00	8.9	12.9	6.6	132.7	3,244,421.1	2,037.5	1.3	1.0
07/22/2020 22:00	8.7	13.1	6.6	119.9	3,254,386.9	1,948.7	1.2	1.0
07/22/2020 23:00	8.2	13.3	6.4	110.5	3,108,242.2	1,770.4	1.1	0.7
Average/Sum#:	8.5	13.5	6.8	100.4	2,794,640.4	1,532.6	1.1	0.7
Minimum:	7.9	12.9	6.4	86.6	2,499,982.0	1,277.9	1.0	0.5
Maximum:	9.6	13.8	7.2	135.0	3,254,386.9	2,043.0	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/23/2020 00:00	7.9	13.7	6.5	86.5	2,512,502.5	1,284.3	1.1	0.5
07/23/2020 01:00	8.2	13.7	6.7	86.8	2,501,155.8	1,278.5	1.1	0.5
07/23/2020 02:00	8.4	13.7	6.9	87.1	2,498,417.0	1,277.1	1.1	0.5
07/23/2020 03:00	8.3	13.7	6.8	87.0	2,499,395.1	1,277.6	1.1	0.5
07/23/2020 04:00	8.4	13.7	6.9	87.3	2,503,112.1	1,279.5	1.1	0.5
07/23/2020 05:00	8.4	13.7	6.9	87.3	2,511,720.0	1,283.9	1.1	0.5
07/23/2020 06:00	8.5	13.7	7.0	87.1	2,520,327.8	1,288.3	1.1	0.5
07/23/2020 07:00	8.6	13.7	7.0	87.7	2,526,196.7	1,291.3	1.1	0.5
07/23/2020 08:00	8.4	13.8	7.0	87.5	2,534,022.0	1,295.3	1.1	0.5
07/23/2020 09:00	8.4	13.8	7.0	87.5	2,534,022.0	1,295.3	1.1	0.5
07/23/2020 10:00	8.3	13.8	6.9	87.5	2,543,803.6	1,300.3	1.1	0.5
07/23/2020 11:00	8.3	13.8	6.9	87.1	2,533,826.4	1,295.2	1.1	0.5
07/23/2020 12:00	8.4	13.8	7.0	87.3	2,535,782.7	1,296.2	1.1	0.5
07/23/2020 13:00	8.4	13.8	7.0	87.4	2,518,762.7	1,287.5	1.1	0.5
07/23/2020 14:00	8.4	13.8	7.0	87.3	2,526,392.4	1,291.4	1.1	0.5
07/23/2020 15:00	8.4	13.8	7.0	87.3	2,532,848.2	1,294.7	1.1	0.5
07/23/2020 16:00	8.4	13.8	7.0	87.3	2,530,109.4	1,293.3	1.1	0.5
07/23/2020 17:00	8.3	13.7	6.8	91.3	2,749,999.8	1,405.7	1.0	0.6
07/23/2020 18:00	8.3	13.6	6.7	103.2	3,137,139.1	1,626.5	1.0	0.7
07/23/2020 19:00	8.2	13.6	6.6	102.6	3,103,192.8	1,608.9	1.0	0.6
07/23/2020 20:00	8.3	13.7	6.8	92.6	2,753,507.4	1,427.6	1.1	0.6
07/23/2020 21:00	8.4	13.8	7.0	88.2	2,609,340.3	1,333.8	1.1	0.5
07/23/2020 22:00	8.6	13.8	7.1	88.0	2,516,806.4	1,286.5	1.1	0.5
07/23/2020 23:00	8.5	13.7	7.0	87.9	2,590,364.0	1,324.1	1.1	0.5
Average/Sum#:	8.4	13.7	6.9	89.0	2,596,781.1	1,330.1	1.1	0.5
Minimum:	7.9	13.6	6.5	86.5	2,498,417.0	1,277.1	1.0	0.5
Maximum:	8.6	13.8	7.1	103.2	3,137,139.1	1,626.5	1.1	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/24/2020 00:00	8.6	13.7	7.0	87.8	2,505,264.1	1,280.6	1.1	0.5
07/24/2020 01:00	8.6	13.7	7.0	87.8	2,509,568.0	1,282.8	1.1	0.5
07/24/2020 02:00	8.6	13.7	7.0	87.6	2,501,938.3	1,278.9	1.1	0.5
07/24/2020 03:00	8.5	13.7	7.0	87.5	2,500,373.3	1,278.1	1.1	0.5
07/24/2020 04:00	8.5	13.7	7.0	87.5	2,507,220.4	1,281.6	1.1	0.5
07/24/2020 05:00	8.5	13.7	7.0	87.5	2,519,740.9	1,288.0	1.1	0.5
07/24/2020 06:00	8.5	13.7	7.0	87.5	2,583,125.7	1,320.4	1.1	0.5
07/24/2020 07:00	8.6	13.7	7.0	86.1	2,480,810.1	1,268.1	1.1	0.5
07/24/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/24/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/24/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/24/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/24/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/24/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/24/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/24/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/24/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/24/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/24/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/24/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/24/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/24/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/24/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/24/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	8.6	13.7	7.0	87.4	2,513,505.1	1,284.8	1.1	0.5
Minimum:	8.5	13.7	7.0	86.1	2,480,810.1	1,268.1	1.1	0.5
Maximum:	8.6	13.7	7.0	87.8	2,583,125.7	1,320.4	1.1	0.5
%SI	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/25/2020 13:00	39.1	17.3	64.1	0.0	1,828,181.6	427.2	-0.3	0.0
07/25/2020 14:00	38.6	15.5	42.2	202.0	2,099,696.3	797.3	2.9	0.9
07/25/2020 15:00	7.7	13.6	6.2	102.4	2,987,273.9	1,548.8	1.1	0.6
07/25/2020 16:00	8.4	13.6	6.8	98.0	2,964,321.6	1,536.9	1.0	0.6
07/25/2020 17:00	9.4	13.0	7.0	127.5	3,203,019.9	2,011.5	1.3	1.0
07/25/2020 18:00	9.3	12.9	6.9	139.8	3,154,240.8	2,073.0	1.4	1.0
07/25/2020 19:00	9.2	12.9	6.8	140.7	3,160,783.6	2,077.3	1.4	1.0
07/25/2020 20:00	9.1	12.9	6.7	139.0	3,197,067.4	2,077.8	1.4	1.0
07/25/2020 21:00	9.1	13.0	6.8	139.1	3,208,187.9	2,061.6	1.4	1.0
07/25/2020 22:00	9.0	13.1	6.8	130.2	3,237,641.5	2,009.6	1.3	1.0
07/25/2020 23:00	9.0	13.0	6.7	137.2	3,206,363.9	2,013.6	1.4	1.0
Average/Sum#:	14.4	13.7	15.2	123.3	2,931,525.3	1,694.1	1.3	0.8
Minimum:	7.7	12.9	6.2	0.0	1,828,181.6	427.2	-0.3	0.0
Maximum:	39.1	17.3	64.1	202.0	3,237,641.5	2,077.8	2.9	1.0
%SI	54.17	54.17	54.17	54.17	54.17	54.17	54.17	54.17

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/26/2020 00:00	7.7	13.7	6.3	91.7	2,822,383.7	1,442.7	1.0	0.6
07/26/2020 01:00	7.9	13.7	6.5	99.9	3,126,395.9	1,598.1	1.0	0.6
07/26/2020 02:00	7.6	13.7	6.2	96.2	3,009,212.3	1,538.2	1.0	0.6
07/26/2020 03:00	7.8	13.7	6.4	94.6	2,929,785.7	1,497.6	1.0	0.6
07/26/2020 04:00	7.8	13.7	6.4	96.0	2,991,409.8	1,529.1	1.0	0.6
07/26/2020 05:00	7.9	13.8	6.6	91.3	2,755,868.8	1,408.7	1.0	0.6
07/26/2020 06:00	8.4	13.8	7.0	85.8	2,508,002.9	1,282.0	1.1	0.5
07/26/2020 07:00	8.4	13.8	7.0	87.3	2,511,524.3	1,283.8	1.1	0.5
07/26/2020 08:00	8.2	13.8	6.8	86.9	2,515,241.3	1,285.7	1.1	0.5
07/26/2020 09:00	8.3	13.8	6.9	87.0	2,522,284.1	1,289.3	1.1	0.5
07/26/2020 10:00	8.2	13.8	6.8	90.2	2,695,614.1	1,377.9	1.1	0.6
07/26/2020 11:00	8.1	13.7	6.6	96.7	2,999,430.7	1,533.2	1.0	0.6
07/26/2020 12:00	8.2	13.7	6.7	97.5	3,019,972.0	1,543.7	1.0	0.6
07/26/2020 13:00	8.7	13.6	7.0	107.3	3,206,925.6	1,686.1	1.1	0.7
07/26/2020 14:00	9.5	13.0	7.1	126.1	3,192,828.9	2,005.1	1.3	1.0
07/26/2020 15:00	8.2	13.4	6.5	107.9	2,964,895.1	1,623.8	1.2	0.8
07/26/2020 16:00	9.2	13.2	7.0	116.1	3,079,124.7	1,776.3	1.2	0.9
07/26/2020 17:00	9.5	12.8	6.9	141.9	3,122,883.0	2,098.0	1.5	1.3
07/26/2020 18:00	9.3	12.8	6.8	143.0	3,127,646.2	2,101.2	1.5	1.3
07/26/2020 19:00	9.2	12.8	6.7	143.4	3,128,985.9	2,102.1	1.5	1.3
07/26/2020 20:00	9.1	12.9	6.7	138.9	3,160,783.6	2,077.3	1.4	1.0
07/26/2020 21:00	9.1	12.9	6.7	136.7	3,183,834.8	2,069.2	1.4	1.0
07/26/2020 22:00	8.9	13.1	6.7	123.6	3,196,790.8	1,960.9	1.2	1.0
07/26/2020 23:00	8.5	13.3	6.6	115.6	3,037,554.5	1,774.5	1.2	0.9
Average/Sum#:	8.5	13.4	6.7	108.4	2,950,390.8	1,661.9	1.2	0.8
Minimum:	7.6	12.8	6.2	85.8	2,508,002.9	1,282.0	1.0	0.5
Maximum:	9.5	13.8	7.1	143.4	3,206,925.6	2,102.1	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/27/2020 00:00	8.0	13.7	6.6	86.8	2,518,371.4	1,287.3	1.1	0.5
07/27/2020 01:00	8.3	13.7	6.8	86.9	2,510,741.8	1,283.4	1.1	0.5
07/27/2020 02:00	8.3	13.8	6.9	86.8	2,509,959.3	1,283.0	1.1	0.5
07/27/2020 03:00	8.3	13.8	6.9	86.9	2,515,045.7	1,285.6	1.1	0.5
07/27/2020 04:00	8.3	13.8	6.9	87.3	2,529,718.1	1,293.1	1.1	0.5
07/27/2020 05:00	8.0	13.7	6.6	103.0	3,163,370.3	1,640.1	1.0	0.7
07/27/2020 06:00	8.3	13.7	6.8	104.3	3,271,163.6	1,672.1	1.0	0.7
07/27/2020 07:00	8.3	13.7	6.8	106.2	3,234,156.1	1,676.8	1.0	0.7
07/27/2020 08:00	8.0	13.7	6.6	103.8	3,208,561.3	1,640.1	1.0	0.7
07/27/2020 09:00	8.0	13.8	6.6	87.7	2,628,316.7	1,343.5	1.0	0.5
07/27/2020 10:00	8.2	13.7	6.7	98.8	3,069,858.2	1,569.2	1.0	0.6
07/27/2020 11:00	8.4	13.7	6.9	97.8	2,962,007.1	1,535.7	1.0	0.6
07/27/2020 12:00	9.5	13.0	7.1	128.2	3,191,545.8	2,027.6	1.3	1.0
07/27/2020 13:00	9.3	12.8	6.8	139.3	3,138,389.6	2,085.5	1.4	1.0
07/27/2020 14:00	9.3	12.8	6.8	136.6	3,134,916.7	2,060.3	1.4	1.0
07/27/2020 15:00	9.3	12.8	6.8	140.5	3,105,914.0	2,086.6	1.5	1.3
07/27/2020 16:00	9.3	12.8	6.8	143.8	3,079,143.4	2,091.1	1.5	1.3
07/27/2020 17:00	9.3	12.7	6.7	142.6	3,082,088.4	2,093.1	1.5	1.3
07/27/2020 18:00	9.3	12.8	6.8	142.4	3,093,112.9	2,078.0	1.5	1.2
07/27/2020 19:00	9.3	12.8	6.8	141.4	3,117,923.5	2,071.9	1.5	1.2
07/27/2020 20:00	9.3	12.8	6.8	146.7	3,134,046.8	2,105.5	1.5	1.3
07/27/2020 21:00	9.2	12.8	6.7	142.0	3,163,826.8	2,079.3	1.5	1.2
07/27/2020 22:00	9.1	12.9	6.7	142.1	3,165,044.1	2,080.1	1.5	1.2
07/27/2020 23:00	8.8	13.0	6.6	124.6	3,158,316.5	1,937.3	1.3	1.0
Average/Sum#:	8.7	13.3	6.8	116.9	2,986,897.4	1,762.8	1.2	0.9
Minimum:	8.0	12.7	6.6	86.8	2,509,959.3	1,283.0	1.0	0.5
Maximum:	9.5	13.8	7.1	146.7	3,271,163.6	2,105.5	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/28/2020 00:00	7.6	13.7	6.2	98.7	2,967,600.5	1,538.6	1.1	0.6
07/28/2020 01:00	7.7	13.7	6.3	95.5	2,892,764.4	1,499.8	1.0	0.6
07/28/2020 02:00	7.8	13.7	6.4	91.0	2,783,648.5	1,422.9	1.0	0.6
07/28/2020 03:00	7.7	13.7	6.3	95.3	2,930,372.5	1,497.9	1.0	0.6
07/28/2020 04:00	7.7	13.7	6.3	97.7	2,963,935.8	1,536.7	1.0	0.6
07/28/2020 05:00	7.8	13.7	6.4	101.8	3,075,225.7	1,594.4	1.0	0.6
07/28/2020 06:00	8.3	13.7	6.8	106.6	3,255,951.1	1,688.1	1.0	0.7
07/28/2020 07:00	8.4	13.7	6.9	108.1	3,218,918.8	1,668.9	1.1	0.7
07/28/2020 08:00	7.9	13.7	6.5	98.0	2,970,477.1	1,518.4	1.0	0.6
07/28/2020 09:00	8.2	13.8	6.8	89.4	2,569,431.4	1,313.4	1.1	0.5
07/28/2020 10:00	8.1	13.7	6.6	97.5	2,970,281.5	1,518.3	1.0	0.6
07/28/2020 11:00	8.7	13.7	7.1	98.5	2,880,227.4	1,493.3	1.1	0.6
07/28/2020 12:00	9.7	13.0	7.2	129.6	3,193,749.5	2,029.0	1.3	1.0
07/28/2020 13:00	9.5	12.9	7.0	140.3	3,187,066.0	2,071.3	1.4	1.0
07/28/2020 14:00	9.4	12.9	6.9	141.0	3,161,544.4	2,077.8	1.4	1.0
07/28/2020 15:00	9.3	12.8	6.8	145.5	3,130,325.5	2,103.0	1.5	1.3
07/28/2020 16:00	9.3	12.8	6.8	147.5	3,134,642.2	2,105.9	1.5	1.3
07/28/2020 17:00	9.4	12.8	6.8	145.4	3,120,501.4	2,096.4	1.5	1.3
07/28/2020 18:00	9.4	12.8	6.8	146.7	3,123,925.0	2,098.7	1.5	1.3
07/28/2020 19:00	9.3	12.9	6.9	142.7	3,151,197.7	2,071.0	1.5	1.2
07/28/2020 20:00	9.2	12.9	6.8	143.8	3,216,608.6	2,090.5	1.5	1.3
07/28/2020 21:00	9.2	12.9	6.8	147.0	3,225,379.1	2,096.2	1.5	1.3
07/28/2020 22:00	9.1	12.9	6.7	141.7	3,230,129.8	2,075.7	1.4	1.0
07/28/2020 23:00	9.2	13.0	6.9	140.2	3,202,741.3	2,058.1	1.4	1.0
Average/Sum#:	8.7	13.3	6.7	120.4	3,064,860.2	1,802.7	1.2	0.9
Minimum:	7.6	12.8	6.2	89.4	2,569,431.4	1,313.4	1.0	0.5
Maximum:	9.7	13.8	7.2	147.5	3,255,951.1	2,105.9	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/29/2020 00:00	8.8	13.1	6.7	125.0	3,261,735.1	1,953.1	1.2	1.0
07/29/2020 01:00	8.9	13.1	6.7	121.4	3,271,571.8	1,935.1	1.2	1.0
07/29/2020 02:00	8.8	13.1	6.7	119.7	3,273,769.6	1,936.4	1.2	1.0
07/29/2020 03:00	8.8	13.2	6.7	120.7	3,294,733.6	1,948.8	1.2	1.0
07/29/2020 04:00	8.8	13.0	6.6	129.5	3,267,510.3	2,052.0	1.3	1.0
07/29/2020 05:00	8.9	13.0	6.6	135.4	3,292,510.2	2,067.7	1.3	1.0
07/29/2020 06:00	8.8	13.0	6.6	129.2	3,268,784.2	2,052.8	1.3	1.0
07/29/2020 07:00	8.8	13.1	6.7	121.2	3,297,607.7	1,950.5	1.2	1.0
07/29/2020 08:00	8.8	13.1	6.7	120.4	3,246,036.8	1,943.7	1.2	1.0
07/29/2020 09:00	9.0	13.1	6.8	124.4	3,269,918.2	1,958.0	1.2	1.0
07/29/2020 10:00	9.2	13.0	6.9	138.6	3,249,156.1	2,064.2	1.4	1.0
07/29/2020 11:00	9.2	12.9	6.8	137.5	3,213,945.7	2,065.3	1.4	1.0
07/29/2020 12:00	9.2	12.9	6.8	139.8	3,194,451.6	2,076.1	1.4	1.0
07/29/2020 13:00	9.2	12.9	6.8	139.4	3,181,834.5	2,067.9	1.4	1.0
07/29/2020 14:00	9.4	12.8	6.8	143.0	3,157,049.9	2,097.9	1.5	1.3
07/29/2020 15:00	9.3	12.8	6.8	145.4	3,132,856.0	2,104.7	1.5	1.3
07/29/2020 16:00	9.3	12.8	6.8	145.2	3,174,054.8	2,109.2	1.5	1.3
07/29/2020 17:00	9.3	12.8	6.8	144.8	3,167,433.5	2,104.8	1.5	1.3
07/29/2020 18:00	9.1	12.8	6.6	141.5	3,162,467.4	2,101.5	1.5	1.3
07/29/2020 19:00	9.1	12.8	6.6	144.4	3,185,642.3	2,116.9	1.5	1.3
07/29/2020 20:00	9.1	12.9	6.7	143.3	3,210,539.4	2,110.0	1.5	1.3
07/29/2020 21:00	9.0	12.9	6.6	137.1	3,228,418.0	2,074.6	1.4	1.0
07/29/2020 22:00	9.1	12.9	6.7	141.4	3,222,147.9	2,094.1	1.4	1.0
07/29/2020 23:00	8.9	12.9	6.6	137.6	3,234,331.4	2,078.4	1.4	1.0
Average/Sum#:	9.0	13.0	6.7	134.4	3,227,437.8	2,044.3	1.4	1.1
Minimum:	8.8	12.8	6.6	119.7	3,132,856.0	1,935.1	1.2	1.0
Maximum:	9.4	13.2	6.9	145.4	3,297,607.7	2,116.9	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/30/2020 00:00	8.9	13.0	6.6	133.9	3,240,813.6	2,058.9	1.3	1.0
07/30/2020 01:00	8.7	13.1	6.6	120.5	3,255,222.0	1,949.2	1.2	1.0
07/30/2020 02:00	8.7	13.2	6.7	118.5	3,275,798.4	1,937.6	1.2	1.0
07/30/2020 03:00	8.7	13.2	6.7	118.6	3,313,151.1	1,935.5	1.1	0.8
07/30/2020 04:00	8.7	13.2	6.7	119.0	3,333,692.5	1,947.5	1.1	0.8
07/30/2020 05:00	8.9	13.0	6.6	131.2	3,287,573.9	2,064.6	1.3	1.0
07/30/2020 06:00	9.1	13.0	6.8	130.5	3,303,212.7	2,050.3	1.3	1.0
07/30/2020 07:00	8.8	13.2	6.7	118.6	3,292,028.6	1,947.2	1.2	1.0
07/30/2020 08:00	8.7	13.2	6.7	118.3	3,281,546.6	1,941.0	1.2	1.0
07/30/2020 09:00	8.8	13.1	6.7	119.6	3,259,397.0	1,951.7	1.2	1.0
07/30/2020 10:00	9.0	12.9	6.6	133.8	3,239,239.6	2,057.9	1.3	1.0
07/30/2020 11:00	9.0	12.9	6.6	138.0	3,235,576.3	2,079.2	1.4	1.0
07/30/2020 12:00	8.9	12.9	6.6	136.1	3,219,081.0	2,068.6	1.4	1.0
07/30/2020 13:00	8.9	12.9	6.6	135.8	3,187,681.5	2,071.7	1.4	1.0
07/30/2020 14:00	9.0	12.9	6.6	138.1	3,161,544.4	2,077.8	1.4	1.0
07/30/2020 15:00	9.1	12.8	6.6	142.5	3,158,103.3	2,098.6	1.5	1.3
07/30/2020 16:00	9.1	12.8	6.6	143.0	3,133,451.4	2,105.1	1.5	1.3
07/30/2020 17:00	9.1	12.8	6.6	143.1	3,134,939.9	2,106.1	1.5	1.3
07/30/2020 18:00	9.1	12.8	6.6	141.5	3,133,302.5	2,105.0	1.5	1.3
07/30/2020 19:00	8.9	12.9	6.6	130.7	3,158,079.4	2,029.4	1.3	1.0
07/30/2020 20:00	9.1	12.9	6.7	133.2	3,184,689.8	2,046.5	1.4	1.0
07/30/2020 21:00	9.1	13.0	6.8	134.3	3,207,758.6	2,037.9	1.4	1.0
07/30/2020 22:00	9.2	12.9	6.8	139.6	3,232,308.4	2,077.1	1.4	1.0
07/30/2020 23:00	8.9	13.0	6.6	132.6	3,228,019.9	2,027.2	1.3	1.0
Average/Sum#:	8.9	13.0	6.7	131.3	3,227,342.2	2,032.2	1.3	1.0
Minimum:	8.7	12.8	6.6	118.3	3,133,302.5	1,935.5	1.1	0.8
Maximum:	9.2	13.2	6.8	143.1	3,333,692.5	2,106.1	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/31/2020 00:00	8.8	13.1	6.7	121.9	3,264,908.1	1,955.0	1.2	1.0
07/31/2020 01:00	8.8	13.2	6.7	119.9	3,264,978.2	1,931.2	1.2	1.0
07/31/2020 02:00	8.8	13.2	6.7	119.5	3,305,448.1	1,931.0	1.2	1.0
07/31/2020 03:00	8.6	13.2	6.6	117.5	3,303,394.0	1,929.8	1.1	0.8
07/31/2020 04:00	8.8	13.2	6.7	120.1	3,309,898.7	1,933.6	1.2	1.0
07/31/2020 05:00	8.9	13.0	6.6	129.2	3,311,398.6	2,031.2	1.3	1.0
07/31/2020 06:00	9.1	13.0	6.8	132.2	3,282,429.7	2,037.4	1.3	1.0
07/31/2020 07:00	9.0	13.1	6.8	121.6	3,265,075.1	1,955.1	1.2	1.0
07/31/2020 08:00	8.9	13.2	6.8	120.9	3,265,316.4	1,931.4	1.2	1.0
07/31/2020 09:00	9.1	13.1	6.9	128.4	3,241,786.2	1,988.5	1.3	1.0
07/31/2020 10:00	9.1	13.0	6.8	136.5	3,226,017.6	2,049.5	1.4	1.0
07/31/2020 11:00	9.1	12.9	6.7	139.4	3,209,588.4	2,062.5	1.4	1.0
07/31/2020 12:00	9.1	12.9	6.7	141.9	3,175,679.8	2,063.9	1.5	1.2
07/31/2020 13:00	9.1	12.9	6.7	142.4	3,187,373.7	2,071.5	1.5	1.2
07/31/2020 14:00	9.2	12.9	6.8	144.0	3,160,479.3	2,077.1	1.5	1.2
07/31/2020 15:00	9.3	12.8	6.8	147.0	3,174,021.4	2,086.0	1.5	1.3
07/31/2020 16:00	9.2	12.8	6.7	147.5	3,139,593.5	2,086.3	1.5	1.3
07/31/2020 17:00	9.3	12.8	6.8	143.9	3,158,501.3	2,075.8	1.5	1.2
07/31/2020 18:00	9.3	12.8	6.8	148.8	3,129,432.4	2,102.4	1.6	1.3
07/31/2020 19:00	9.2	12.9	6.8	143.3	3,181,988.3	2,068.0	1.5	1.2
07/31/2020 20:00	9.2	12.9	6.8	144.2	3,192,605.2	2,074.9	1.5	1.2
07/31/2020 21:00	9.2	12.9	6.8	140.7	3,203,052.5	2,058.3	1.4	1.0
07/31/2020 22:00	9.2	13.0	6.9	140.2	3,229,637.9	2,051.8	1.4	1.0
07/31/2020 23:00	9.1	13.0	6.8	136.0	3,253,975.3	2,043.5	1.4	1.0
Average/Sum#:	9.1	13.0	6.8	134.5	3,226,524.2	2,024.8	1.4	1.1
Minimum:	8.6	12.8	6.6	117.5	3,129,432.4	1,929.8	1.1	0.8
Maximum:	9.3	13.2	6.9	148.8	3,311,398.6	2,102.4	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/01/2020 00:00	9.1	13.0	6.8	134.9	3,236,459.4	2,032.5	1.3	1.0
08/01/2020 01:00	8.6	13.2	6.6	120.2	3,277,320.0	1,938.5	1.2	1.0
08/01/2020 02:00	8.7	13.2	6.7	120.4	3,255,635.3	1,901.9	1.2	1.0
08/01/2020 03:00	7.6	13.7	6.2	90.6	2,799,886.0	1,431.2	1.0	0.6
08/01/2020 04:00	7.4	13.7	6.1	93.8	2,930,953.9	1,519.6	1.0	0.6
08/01/2020 05:00	7.5	13.7	6.1	95.4	2,961,235.6	1,535.3	1.0	0.6
08/01/2020 06:00	8.0	13.8	6.6	87.7	2,538,912.8	1,297.8	1.1	0.5
08/01/2020 07:00	8.3	13.8	6.9	86.5	2,517,002.0	1,286.6	1.1	0.5
08/01/2020 08:00	8.1	13.8	6.7	86.0	2,522,088.5	1,289.2	1.1	0.5
08/01/2020 09:00	8.1	13.8	6.7	86.2	2,533,826.4	1,295.2	1.1	0.5
08/01/2020 10:00	8.0	13.8	6.6	89.9	2,799,690.3	1,431.1	1.0	0.6
08/01/2020 11:00	8.4	13.7	6.9	96.5	2,903,758.3	1,505.5	1.0	0.6
08/01/2020 12:00	9.6	13.0	7.2	128.1	3,250,207.9	2,017.4	1.3	1.0
08/01/2020 13:00	9.5	12.9	7.0	141.1	3,210,833.3	2,063.3	1.4	1.0
08/01/2020 14:00	9.4	12.9	6.9	142.5	3,184,604.1	2,069.7	1.5	1.2
08/01/2020 15:00	9.3	12.9	6.9	143.1	3,197,375.1	2,078.0	1.5	1.2
08/01/2020 16:00	9.3	12.9	6.9	146.8	3,187,259.2	2,094.7	1.5	1.3
08/01/2020 17:00	9.3	12.9	6.9	147.5	3,198,671.0	2,102.2	1.5	1.3
08/01/2020 18:00	9.3	12.9	6.9	148.8	3,203,844.4	2,105.6	1.5	1.3
08/01/2020 19:00	9.3	12.9	6.9	149.5	3,208,257.0	2,108.5	1.5	1.3
08/01/2020 20:00	9.3	12.9	6.9	150.9	3,211,756.7	2,110.8	1.5	1.3
08/01/2020 21:00	9.2	13.0	6.9	143.1	3,219,547.8	2,068.9	1.4	1.0
08/01/2020 22:00	9.2	13.0	6.9	140.3	3,207,876.6	2,061.4	1.4	1.0
08/01/2020 23:00	8.8	13.1	6.7	122.6	3,209,129.1	1,921.6	1.2	1.0
Average/Sum#:	8.7	13.3	6.7	120.5	3,031,922.1	1,802.8	1.3	0.9
Minimum:	7.4	12.9	6.1	86.0	2,517,002.0	1,286.6	1.0	0.5
Maximum:	9.6	13.8	7.2	150.9	3,277,320.0	2,110.8	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/02/2020 00:00	7.8	13.7	6.4	90.6	2,746,371.0	1,423.9	1.0	0.6
08/02/2020 01:00	8.2	13.8	6.8	85.9	2,509,763.6	1,282.9	1.1	0.5
08/02/2020 02:00	8.3	13.8	6.9	86.1	2,515,632.6	1,285.9	1.1	0.5
08/02/2020 03:00	8.3	13.8	6.9	86.0	2,521,501.6	1,288.9	1.1	0.5
08/02/2020 04:00	7.9	13.7	6.5	93.3	2,920,199.7	1,492.7	1.0	0.6
08/02/2020 05:00	7.9	13.8	6.6	89.1	2,698,157.3	1,379.2	1.0	0.6
08/02/2020 06:00	8.2	13.8	6.8	85.4	2,529,718.1	1,293.1	1.1	0.5
08/02/2020 07:00	8.2	13.8	6.8	86.0	2,526,001.1	1,291.2	1.1	0.5
08/02/2020 08:00	8.1	13.8	6.7	85.7	2,529,131.2	1,292.8	1.1	0.5
08/02/2020 09:00	8.2	13.8	6.8	85.9	2,537,347.8	1,297.0	1.1	0.5
08/02/2020 10:00	8.2	13.8	6.8	86.9	2,546,738.1	1,301.8	1.1	0.5
08/02/2020 11:00	8.2	13.8	6.8	87.6	2,550,650.7	1,303.8	1.1	0.5
08/02/2020 12:00	8.2	13.8	6.8	87.8	2,544,977.4	1,300.9	1.1	0.5
08/02/2020 13:00	8.3	13.8	6.9	88.8	2,569,235.8	1,313.3	1.1	0.5
08/02/2020 14:00	8.3	13.8	6.9	88.1	2,669,790.7	1,364.7	1.0	0.5
08/02/2020 15:00	8.6	13.7	7.0	96.6	2,908,773.1	1,508.1	1.0	0.6
08/02/2020 16:00	9.6	13.0	7.2	123.9	3,142,665.9	1,927.7	1.3	1.0
08/02/2020 17:00	9.4	12.9	6.9	134.3	3,193,093.1	2,051.9	1.4	1.0
08/02/2020 18:00	9.3	12.9	6.9	136.3	3,194,493.6	2,052.8	1.4	1.0
08/02/2020 19:00	9.3	12.9	6.9	140.0	3,167,326.4	2,081.6	1.4	1.0
08/02/2020 20:00	9.1	12.9	6.7	136.7	3,167,524.8	2,058.6	1.4	1.0
08/02/2020 21:00	9.1	12.9	6.7	139.2	3,189,835.6	2,073.1	1.4	1.0
08/02/2020 22:00	9.0	12.9	6.6	136.2	3,200,562.6	2,056.7	1.4	1.0
08/02/2020 23:00	8.7	13.1	6.6	123.0	3,177,064.6	1,925.6	1.2	1.0
Average/Sum#:	8.5	13.5	6.8	103.3	2,802,356.5	1,568.7	1.2	0.7
Minimum:	7.8	12.9	6.4	85.4	2,509,763.6	1,282.9	1.0	0.5
Maximum:	9.6	13.8	7.2	140.0	3,200,562.6	2,081.6	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/03/2020 00:00	7.8	13.7	6.4	92.0	2,760,258.1	1,431.1	1.1	0.6
08/03/2020 01:00	7.9	13.7	6.5	85.5	2,579,017.4	1,318.3	1.0	0.5
08/03/2020 02:00	8.1	13.8	6.7	85.9	2,523,849.1	1,290.1	1.1	0.5
08/03/2020 03:00	8.2	13.8	6.8	86.1	2,524,436.0	1,290.4	1.1	0.5
08/03/2020 04:00	7.8	13.7	6.4	93.5	2,945,631.8	1,505.7	1.0	0.6
08/03/2020 05:00	7.8	13.7	6.4	92.6	2,904,744.8	1,484.8	1.0	0.6
08/03/2020 06:00	7.9	13.7	6.5	95.8	3,038,386.2	1,575.3	1.0	0.6
08/03/2020 07:00	7.9	13.7	6.5	96.3	3,003,147.7	1,535.1	1.0	0.6
08/03/2020 08:00	7.9	13.7	6.5	92.7	2,895,354.4	1,480.0	1.0	0.6
08/03/2020 09:00	8.2	13.7	6.7	87.0	2,686,223.7	1,373.1	1.0	0.5
08/03/2020 10:00	8.0	13.8	6.6	88.2	2,578,288.7	1,299.1	1.1	0.5
08/03/2020 11:00	8.1	13.8	6.7	89.3	2,702,330.8	1,361.6	1.0	0.5
08/03/2020 12:00	8.4	13.7	6.9	96.5	2,929,981.3	1,497.7	1.0	0.6
08/03/2020 13:00	9.7	13.0	7.2	131.0	3,218,625.0	2,021.3	1.3	1.0
08/03/2020 14:00	9.4	12.9	6.9	138.8	3,196,672.2	2,054.2	1.4	1.0
08/03/2020 15:00	9.3	12.9	6.9	139.7	3,193,248.7	2,052.0	1.4	1.0
08/03/2020 16:00	9.3	12.9	6.9	139.6	3,168,294.1	2,059.1	1.4	1.0
08/03/2020 17:00	9.3	12.9	6.9	140.7	3,173,064.0	2,062.2	1.4	1.0
08/03/2020 18:00	9.2	12.9	6.8	139.3	3,165,678.3	2,057.4	1.4	1.0
08/03/2020 19:00	9.2	12.9	6.8	141.4	3,194,451.6	2,076.1	1.4	1.0
08/03/2020 20:00	9.2	12.9	6.8	139.4	3,173,987.2	2,062.8	1.4	1.0
08/03/2020 21:00	9.2	12.9	6.8	140.2	3,179,218.7	2,066.2	1.4	1.0
08/03/2020 22:00	9.1	12.9	6.7	138.1	3,204,297.4	2,059.1	1.4	1.0
08/03/2020 23:00	8.6	13.2	6.6	118.7	3,050,735.2	1,782.2	1.3	0.9
Average/Sum#:	8.6	13.4	6.7	112.0	2,957,913.4	1,699.8	1.2	0.8
Minimum:	7.8	12.9	6.4	85.5	2,523,849.1	1,290.1	1.0	0.5
Maximum:	9.7	13.8	7.2	141.4	3,218,625.0	2,076.1	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/04/2020 00:00	8.0	13.7	6.6	85.8	2,515,241.3	1,285.7	1.1	0.5
08/04/2020 01:00	8.2	13.7	6.7	85.7	2,509,568.0	1,282.8	1.1	0.5
08/04/2020 02:00	8.1	13.7	6.6	85.6	2,527,370.5	1,291.9	1.1	0.5
08/04/2020 03:00	8.1	13.7	6.6	85.6	2,515,632.6	1,285.9	1.1	0.5
08/04/2020 04:00	8.1	13.7	6.6	85.6	2,520,327.8	1,288.3	1.1	0.5
08/04/2020 05:00	7.8	13.7	6.4	87.5	2,743,348.3	1,402.3	1.0	0.6
08/04/2020 06:00	8.1	13.7	6.6	86.0	2,542,238.6	1,299.5	1.1	0.5
08/04/2020 07:00	8.3	13.7	6.8	86.3	2,518,371.4	1,287.3	1.1	0.5
08/04/2020 08:00	8.2	13.8	6.8	85.8	2,521,110.3	1,288.7	1.1	0.5
08/04/2020 09:00	8.2	13.8	6.8	85.8	2,527,174.9	1,291.8	1.1	0.5
08/04/2020 10:00	8.1	13.7	6.6	85.9	2,539,891.0	1,298.3	1.1	0.5
08/04/2020 11:00	8.1	13.8	6.7	87.4	2,542,434.2	1,299.6	1.1	0.5
08/04/2020 12:00	8.2	13.8	6.8	92.5	2,808,885.0	1,435.8	1.0	0.6
08/04/2020 13:00	8.4	13.7	6.9	94.7	2,839,337.5	1,472.1	1.0	0.6
08/04/2020 14:00	8.2	13.7	6.7	87.2	2,581,756.2	1,319.7	1.1	0.5
08/04/2020 15:00	8.1	13.6	6.5	95.5	2,947,927.1	1,528.4	1.0	0.6
08/04/2020 16:00	8.5	13.6	6.9	96.0	2,899,707.9	1,503.4	1.0	0.6
08/04/2020 17:00	9.8	12.9	7.2	131.2	3,152,010.3	2,025.5	1.3	1.0
08/04/2020 18:00	9.5	12.8	6.9	139.1	3,150,436.9	2,070.5	1.4	1.0
08/04/2020 19:00	9.2	12.8	6.7	138.1	3,157,436.2	2,075.1	1.4	1.0
08/04/2020 20:00	9.2	12.9	6.8	137.7	3,172,910.1	2,062.1	1.4	1.0
08/04/2020 21:00	9.1	12.9	6.7	136.4	3,199,006.5	2,055.7	1.4	1.0
08/04/2020 22:00	8.7	13.1	6.6	122.3	3,221,777.1	1,952.7	1.2	1.0
08/04/2020 23:00	8.1	13.3	6.3	110.6	3,114,387.1	1,773.9	1.1	0.7
Average/Sum#:	8.4	13.5	6.7	100.6	2,782,012.0	1,536.5	1.1	0.7
Minimum:	7.8	12.8	6.3	85.6	2,509,568.0	1,282.8	1.0	0.5
Maximum:	9.8	13.8	7.2	139.1	3,221,777.1	2,075.1	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/05/2020 00:00	7.6	13.7	6.2	84.5	2,513,089.4	1,284.6	1.1	0.5
08/05/2020 01:00	7.8	13.7	6.4	84.7	2,510,741.8	1,283.4	1.1	0.5
08/05/2020 02:00	7.9	13.7	6.5	85.1	2,499,395.1	1,277.6	1.1	0.5
08/05/2020 03:00	8.0	13.7	6.6	85.1	2,498,808.2	1,277.3	1.1	0.5
08/05/2020 04:00	7.9	13.7	6.5	85.1	2,504,090.3	1,280.0	1.1	0.5
08/05/2020 05:00	7.9	13.7	6.5	85.7	2,569,235.8	1,313.3	1.1	0.5
08/05/2020 06:00	8.1	13.7	6.6	85.5	2,498,612.6	1,277.2	1.1	0.5
08/05/2020 07:00	8.2	13.7	6.7	85.9	2,499,395.1	1,277.6	1.1	0.5
08/05/2020 08:00	8.1	13.7	6.6	85.7	2,507,220.4	1,281.6	1.1	0.5
08/05/2020 09:00	8.0	13.7	6.6	85.4	2,513,871.9	1,285.0	1.1	0.5
08/05/2020 10:00	8.1	13.8	6.7	85.6	2,521,305.9	1,288.8	1.1	0.5
08/05/2020 11:00	8.0	13.8	6.6	85.5	2,525,805.5	1,291.1	1.1	0.5
08/05/2020 12:00	8.0	13.7	6.6	85.4	2,527,761.8	1,292.1	1.1	0.5
08/05/2020 13:00	8.1	13.7	6.6	85.5	2,529,131.2	1,292.8	1.1	0.5
08/05/2020 14:00	8.1	13.7	6.6	85.6	2,525,805.5	1,291.1	1.1	0.5
08/05/2020 15:00	8.1	13.7	6.6	85.7	2,524,044.8	1,290.2	1.1	0.5
08/05/2020 16:00	8.1	13.7	6.6	85.9	2,541,651.7	1,299.2	1.1	0.5
08/05/2020 17:00	9.1	13.3	7.1	110.5	3,110,194.0	1,748.8	1.1	0.7
08/05/2020 18:00	9.6	12.9	7.1	137.8	3,168,601.8	2,059.3	1.4	1.0
08/05/2020 19:00	8.9	13.0	6.6	129.3	3,174,516.8	1,993.6	1.3	1.0
08/05/2020 20:00	7.2	13.7	5.9	97.3	3,033,950.1	1,573.0	1.0	0.6
08/05/2020 21:00	7.4	13.7	6.1	88.3	2,737,479.3	1,399.3	1.0	0.6
08/05/2020 22:00	7.5	13.7	6.1	87.4	2,696,396.6	1,378.3	1.0	0.6
08/05/2020 23:00	7.7	13.7	6.3	84.4	2,500,960.2	1,278.4	1.1	0.5
Average/Sum#:	8.1	13.6	6.5	91.1	2,634,669.4	1,388.1	1.1	0.6
Minimum:	7.2	12.9	5.9	84.4	2,498,612.6	1,277.2	1.0	0.5
Maximum:	9.6	13.8	7.1	137.8	3,174,516.8	2,059.3	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/06/2020 00:00	7.8	13.7	6.4	84.6	2,499,395.1	1,277.6	1.1	0.5
08/06/2020 01:00	7.8	13.7	6.4	84.6	2,497,830.1	1,276.8	1.1	0.5
08/06/2020 02:00	7.9	13.7	6.5	84.9	2,499,003.9	1,277.4	1.1	0.5
08/06/2020 03:00	7.9	13.7	6.5	84.9	2,507,024.8	1,281.5	1.1	0.5
08/06/2020 04:00	7.9	13.7	6.5	85.1	2,540,282.2	1,298.5	1.1	0.5
08/06/2020 05:00	7.8	13.7	6.4	85.3	2,586,255.8	1,322.0	1.0	0.5
08/06/2020 06:00	8.0	13.7	6.6	85.5	2,517,197.6	1,286.7	1.1	0.5
08/06/2020 07:00	8.1	13.7	6.6	85.6	2,527,957.4	1,292.2	1.1	0.5
08/06/2020 08:00	7.9	13.7	6.5	85.2	2,530,891.9	1,293.7	1.1	0.5
08/06/2020 09:00	7.9	13.8	6.6	85.2	2,532,456.9	1,294.5	1.1	0.5
08/06/2020 10:00	8.0	13.8	6.6	85.8	2,531,870.1	1,294.2	1.1	0.5
08/06/2020 11:00	8.0	13.8	6.6	86.6	2,532,065.7	1,294.3	1.1	0.5
08/06/2020 12:00	8.1	13.8	6.7	86.6	2,532,848.2	1,294.7	1.1	0.5
08/06/2020 13:00	8.1	13.8	6.7	87.2	2,524,436.0	1,290.4	1.1	0.5
08/06/2020 14:00	8.1	13.7	6.6	86.2	2,524,436.0	1,290.4	1.1	0.5
08/06/2020 15:00	8.1	13.7	6.6	87.0	2,527,566.1	1,292.0	1.1	0.5
08/06/2020 16:00	8.1	13.8	6.7	86.9	2,522,088.5	1,289.2	1.1	0.5
08/06/2020 17:00	8.0	13.7	6.6	90.3	2,735,131.8	1,398.1	1.0	0.6
08/06/2020 18:00	8.1	13.7	6.6	89.8	2,736,109.9	1,398.6	1.0	0.6
08/06/2020 19:00	8.1	13.8	6.7	85.8	2,556,715.3	1,306.9	1.1	0.5
08/06/2020 20:00	8.2	13.8	6.8	86.0	2,509,763.6	1,282.9	1.1	0.5
08/06/2020 21:00	8.3	13.8	6.9	86.0	2,502,525.2	1,279.2	1.1	0.5
08/06/2020 22:00	8.2	13.8	6.8	85.8	2,500,373.3	1,278.1	1.1	0.5
08/06/2020 23:00	8.3	13.7	6.8	85.9	2,504,090.3	1,280.0	1.1	0.5
Average/Sum#:	8.0	13.7	6.6	86.1	2,540,763.2	1,298.7	1.1	0.5
Minimum:	7.8	13.7	6.4	84.6	2,497,830.1	1,276.8	1.0	0.5
Maximum:	8.3	13.8	6.9	90.3	2,736,109.9	1,398.6	1.1	0.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/07/2020 00:00	8.3	13.8	6.9	86.0	2,503,894.7	1,279.9	1.1	0.5
08/07/2020 01:00	8.2	13.8	6.8	85.9	2,501,351.5	1,278.6	1.1	0.5
08/07/2020 02:00	8.2	13.8	6.8	85.9	2,501,938.3	1,278.9	1.1	0.5
08/07/2020 03:00	8.2	13.8	6.8	85.8	2,502,916.5	1,279.4	1.1	0.5
08/07/2020 04:00	7.9	13.7	6.5	85.2	2,590,364.0	1,324.1	1.0	0.5
08/07/2020 05:00	7.9	13.7	6.5	85.8	2,571,583.4	1,314.5	1.1	0.5
08/07/2020 06:00	8.2	13.8	6.8	86.3	2,504,481.6	1,280.2	1.1	0.5
08/07/2020 07:00	8.3	13.8	6.9	86.1	2,513,480.6	1,284.8	1.1	0.5
08/07/2020 08:00	8.1	13.8	6.7	85.6	2,526,783.6	1,291.6	1.1	0.5
08/07/2020 09:00	7.9	13.8	6.6	85.3	2,532,261.3	1,294.4	1.1	0.5
08/07/2020 10:00	8.0	13.8	6.6	87.0	2,530,109.4	1,293.3	1.1	0.5
08/07/2020 11:00	8.1	13.8	6.7	88.1	2,566,777.6	1,293.3	1.1	0.5
08/07/2020 12:00	8.1	13.8	6.7	87.5	2,558,442.0	1,289.1	1.1	0.5
08/07/2020 13:00	8.0	13.8	6.6	88.5	2,630,859.9	1,344.8	1.1	0.5
08/07/2020 14:00	8.1	13.8	6.7	88.2	2,691,018.1	1,355.9	1.0	0.5
08/07/2020 15:00	8.2	13.8	6.8	86.8	2,568,166.9	1,294.0	1.1	0.5
08/07/2020 16:00	8.2	13.8	6.8	90.9	2,738,261.9	1,399.7	1.0	0.6
08/07/2020 17:00	8.1	13.8	6.7	92.5	2,861,118.8	1,462.5	1.0	0.6
08/07/2020 18:00	8.6	13.6	7.0	104.9	3,216,025.7	1,667.4	1.0	0.7
08/07/2020 19:00	8.1	13.7	6.6	103.0	3,158,548.4	1,637.6	1.0	0.7
08/07/2020 20:00	8.1	13.7	6.6	94.1	2,853,610.4	1,479.5	1.0	0.6
08/07/2020 21:00	8.1	13.8	6.7	87.3	2,611,492.3	1,334.9	1.0	0.5
08/07/2020 22:00	8.0	13.7	6.6	89.0	2,713,807.9	1,387.2	1.0	0.6
08/07/2020 23:00	7.9	13.7	6.5	91.5	2,819,644.8	1,441.3	1.0	0.6
Average/Sum#:	8.1	13.8	6.7	89.1	2,656,955.8	1,357.8	1.1	0.5
Minimum:	7.9	13.6	6.5	85.2	2,501,351.5	1,278.6	1.0	0.5
Maximum:	8.6	13.8	7.0	104.9	3,216,025.7	1,667.4	1.1	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/08/2020 00:00	8.0	13.8	6.6	87.2	2,633,207.5	1,346.0	1.0	0.5
08/08/2020 01:00	8.1	13.8	6.7	85.7	2,505,068.5	1,280.5	1.1	0.5
08/08/2020 02:00	8.2	13.7	6.7	85.8	2,501,155.8	1,278.5	1.1	0.5
08/08/2020 03:00	8.2	13.7	6.7	85.8	2,507,024.8	1,281.5	1.1	0.5
08/08/2020 04:00	8.2	13.8	6.8	85.7	2,512,893.7	1,284.5	1.1	0.5
08/08/2020 05:00	8.2	13.7	6.7	85.9	2,504,090.3	1,280.0	1.1	0.5
08/08/2020 06:00	8.4	13.7	6.9	86.0	2,506,046.6	1,281.0	1.1	0.5
08/08/2020 07:00	8.4	13.8	7.0	86.4	2,521,892.8	1,289.1	1.1	0.5
08/08/2020 08:00	8.4	13.8	7.0	86.3	2,519,936.5	1,288.1	1.1	0.5
08/08/2020 09:00	8.3	13.8	6.9	86.3	2,525,414.2	1,290.9	1.1	0.5
08/08/2020 10:00	8.2	13.8	6.8	87.1	2,530,696.3	1,293.6	1.1	0.5
08/08/2020 11:00	8.2	13.8	6.8	88.3	2,526,001.1	1,291.2	1.1	0.5
08/08/2020 12:00	8.2	13.8	6.8	87.9	2,524,827.3	1,290.6	1.1	0.5
08/08/2020 13:00	8.3	13.8	6.9	92.4	2,761,542.1	1,411.6	1.0	0.6
08/08/2020 14:00	8.2	13.8	6.8	88.0	2,591,146.6	1,324.5	1.1	0.5
08/08/2020 15:00	8.2	13.7	6.7	88.7	2,680,941.7	1,370.4	1.0	0.5
08/08/2020 16:00	8.4	13.7	6.9	93.9	2,824,340.0	1,443.7	1.0	0.6
08/08/2020 17:00	9.8	12.9	7.2	131.4	3,190,601.4	2,027.0	1.3	1.0
08/08/2020 18:00	9.6	12.8	7.0	141.8	3,149,375.1	2,092.8	1.5	1.3
08/08/2020 19:00	9.4	12.8	6.8	142.9	3,155,695.5	2,097.0	1.5	1.3
08/08/2020 20:00	9.2	12.9	6.8	138.0	3,179,526.5	2,066.4	1.4	1.0
08/08/2020 21:00	9.2	12.9	6.8	136.2	3,198,384.0	2,055.3	1.4	1.0
08/08/2020 22:00	9.0	13.1	6.8	126.3	3,220,429.7	1,975.4	1.3	1.0
08/08/2020 23:00	8.9	13.1	6.7	120.8	3,196,436.9	1,914.0	1.2	1.0
Average/Sum#:	8.6	13.5	6.8	101.0	2,748,611.5	1,523.1	1.2	0.7
Minimum:	8.0	12.8	6.6	85.7	2,501,155.8	1,278.5	1.0	0.5
Maximum:	9.8	13.8	7.2	142.9	3,220,429.7	2,097.0	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/09/2020 00:00	7.6	13.7	6.2	96.2	2,966,636.1	1,538.1	1.0	0.6
08/09/2020 01:00	8.1	13.7	6.6	86.0	2,552,215.8	1,304.6	1.1	0.5
08/09/2020 02:00	8.1	13.8	6.7	85.5	2,513,480.6	1,284.8	1.1	0.5
08/09/2020 03:00	8.0	13.8	6.6	85.4	2,514,850.1	1,285.5	1.1	0.5
08/09/2020 04:00	8.1	13.8	6.7	85.4	2,511,328.7	1,283.7	1.1	0.5
08/09/2020 05:00	8.1	13.8	6.7	85.4	2,513,676.3	1,284.9	1.1	0.5
08/09/2020 06:00	8.2	13.8	6.8	85.3	2,522,088.5	1,289.2	1.1	0.5
08/09/2020 07:00	8.2	13.8	6.8	86.0	2,526,979.3	1,291.7	1.1	0.5
08/09/2020 08:00	8.2	13.8	6.8	85.9	2,528,544.3	1,292.5	1.1	0.5
08/09/2020 09:00	8.2	13.7	6.7	86.2	2,517,980.2	1,287.1	1.1	0.5
08/09/2020 10:00	8.3	13.7	6.8	88.2	2,528,348.7	1,292.4	1.1	0.5
08/09/2020 11:00	8.1	13.8	6.7	89.5	2,531,674.4	1,294.1	1.1	0.5
08/09/2020 12:00	8.3	13.7	6.8	93.4	2,810,058.8	1,436.4	1.0	0.6
08/09/2020 13:00	8.4	13.7	6.9	96.6	2,907,037.2	1,507.2	1.0	0.6
08/09/2020 14:00	8.1	13.8	6.7	88.5	2,702,852.5	1,381.6	1.0	0.6
08/09/2020 15:00	8.6	13.5	6.9	100.8	3,035,557.4	1,596.0	1.0	0.6
08/09/2020 16:00	9.7	12.9	7.2	132.0	3,135,674.1	2,037.9	1.4	1.0
08/09/2020 17:00	9.5	12.8	6.9	140.4	3,128,758.5	2,079.1	1.5	1.2
08/09/2020 18:00	9.3	12.8	6.8	143.6	3,143,957.6	2,089.2	1.5	1.3
08/09/2020 19:00	9.1	12.8	6.6	137.7	3,132,330.0	2,058.6	1.4	1.0
08/09/2020 20:00	9.1	12.9	6.7	136.4	3,141,675.0	2,041.8	1.4	1.0
08/09/2020 21:00	9.1	12.8	6.6	139.6	3,137,959.9	2,062.3	1.4	1.0
08/09/2020 22:00	8.8	13.0	6.6	126.0	3,155,249.3	1,981.5	1.3	1.0
08/09/2020 23:00	8.7	13.1	6.6	119.9	3,153,305.9	1,911.2	1.2	1.0
Average/Sum#:	8.5	13.5	6.7	104.2	2,804,675.8	1,579.6	1.2	0.7
Minimum:	7.6	12.8	6.2	85.3	2,511,328.7	1,283.7	1.0	0.5
Maximum:	9.7	13.8	7.2	143.6	3,155,249.3	2,089.2	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/10/2020 00:00	7.7	13.7	6.3	89.6	2,726,504.7	1,413.6	1.0	0.6
08/10/2020 01:00	7.9	13.8	6.6	85.0	2,512,698.1	1,284.4	1.1	0.5
08/10/2020 02:00	7.9	13.8	6.6	85.4	2,525,805.5	1,291.1	1.1	0.5
08/10/2020 03:00	7.7	13.7	6.3	92.5	2,920,004.1	1,492.6	1.0	0.6
08/10/2020 04:00	7.7	13.7	6.3	94.6	2,975,563.6	1,521.0	1.0	0.6
08/10/2020 05:00	7.6	13.7	6.2	94.1	2,958,934.8	1,512.5	1.0	0.6
08/10/2020 06:00	8.1	13.7	6.6	95.9	3,146,350.3	1,608.3	1.0	0.6
08/10/2020 07:00	8.1	13.8	6.7	86.9	2,670,964.4	1,365.3	1.0	0.5
08/10/2020 08:00	7.9	13.7	6.5	92.7	2,920,199.7	1,492.7	1.0	0.6
08/10/2020 09:00	8.0	13.8	6.6	85.9	2,561,410.5	1,309.3	1.1	0.5
08/10/2020 10:00	8.1	13.7	6.6	94.9	2,980,063.1	1,523.3	1.0	0.6
08/10/2020 11:00	8.2	13.7	6.7	95.0	2,970,085.9	1,518.2	1.0	0.6
08/10/2020 12:00	8.1	13.8	6.7	87.9	2,554,563.4	1,305.8	1.1	0.5
08/10/2020 13:00	8.2	13.8	6.8	88.8	2,593,298.5	1,325.6	1.1	0.5
08/10/2020 14:00	8.2	13.8	6.8	88.3	2,606,405.9	1,332.3	1.1	0.5
08/10/2020 15:00	9.0	13.6	7.3	105.2	3,117,152.3	1,638.9	1.1	0.7
08/10/2020 16:00	9.8	12.9	7.2	132.4	3,136,135.7	2,038.2	1.4	1.0
08/10/2020 17:00	9.5	12.8	6.9	143.2	3,110,826.1	2,089.9	1.5	1.3
08/10/2020 18:00	9.3	12.9	6.9	136.5	3,114,071.0	2,046.6	1.4	1.0
08/10/2020 19:00	9.1	12.9	6.7	132.6	3,174,703.5	2,016.9	1.4	1.0
08/10/2020 20:00	9.0	13.0	6.7	128.5	3,152,666.8	2,002.9	1.3	1.0
08/10/2020 21:00	9.0	13.0	6.7	128.1	3,177,064.6	1,995.2	1.3	1.0
08/10/2020 22:00	8.7	13.1	6.6	122.2	3,217,652.3	1,950.2	1.2	1.0
08/10/2020 23:00	8.4	13.3	6.5	113.4	3,056,416.5	1,763.2	1.2	0.9
Average/Sum#:	8.4	13.5	6.7	104.2	2,911,647.6	1,618.3	1.1	0.7
Minimum:	7.6	12.8	6.2	85.0	2,512,698.1	1,284.4	1.0	0.5
Maximum:	9.8	13.8	7.3	143.2	3,217,652.3	2,089.9	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/11/2020 00:00	7.6	13.7	6.2	84.8	2,508,589.8	1,282.3	1.1	0.5
08/11/2020 01:00	7.8	13.7	6.4	84.9	2,507,416.0	1,281.7	1.1	0.5
08/11/2020 02:00	7.8	13.7	6.4	84.9	2,509,568.0	1,282.8	1.1	0.5
08/11/2020 03:00	7.8	13.7	6.4	84.9	2,507,807.3	1,281.9	1.1	0.5
08/11/2020 04:00	7.8	13.7	6.4	85.1	2,523,262.2	1,289.8	1.1	0.5
08/11/2020 05:00	7.9	13.7	6.5	85.4	2,541,651.7	1,299.2	1.1	0.5
08/11/2020 06:00	7.9	13.7	6.5	89.8	2,608,557.8	1,333.4	1.1	0.5
08/11/2020 07:00	8.2	13.7	6.7	86.2	2,511,524.3	1,283.8	1.1	0.5
08/11/2020 08:00	8.0	13.8	6.6	85.7	2,521,697.2	1,289.0	1.1	0.5
08/11/2020 09:00	8.0	13.8	6.6	85.6	2,526,979.3	1,291.7	1.1	0.5
08/11/2020 10:00	7.9	13.8	6.6	85.5	2,533,826.4	1,295.2	1.1	0.5
08/11/2020 11:00	8.0	13.7	6.6	85.6	2,540,086.6	1,298.4	1.1	0.5
08/11/2020 12:00	8.0	13.7	6.6	85.7	2,535,391.4	1,296.0	1.1	0.5
08/11/2020 13:00	8.1	13.7	6.6	85.8	2,536,956.5	1,296.8	1.1	0.5
08/11/2020 14:00	8.1	13.7	6.6	86.2	2,573,344.0	1,315.4	1.1	0.5
08/11/2020 15:00	8.2	13.7	6.7	87.2	2,604,253.9	1,331.2	1.1	0.5
08/11/2020 16:00	8.2	13.7	6.7	91.2	2,788,930.6	1,425.6	1.0	0.6
08/11/2020 17:00	8.3	13.7	6.8	98.5	3,066,336.8	1,567.4	1.0	0.6
08/11/2020 18:00	8.3	13.7	6.8	96.7	2,972,042.2	1,519.2	1.0	0.6
08/11/2020 19:00	8.1	13.7	6.6	87.1	2,688,962.6	1,374.5	1.0	0.5
08/11/2020 20:00	8.0	13.7	6.6	87.6	2,653,553.2	1,356.4	1.0	0.5
08/11/2020 21:00	8.0	13.8	6.6	85.7	2,555,737.2	1,306.4	1.1	0.5
08/11/2020 22:00	7.9	13.7	6.5	89.4	2,719,872.5	1,390.3	1.0	0.6
08/11/2020 23:00	8.0	13.7	6.6	85.7	2,538,912.8	1,297.8	1.1	0.5
Average/Sum#:	8.0	13.7	6.6	87.3	2,607,302.5	1,332.8	1.1	0.5
Minimum:	7.6	13.7	6.2	84.8	2,507,416.0	1,281.7	1.0	0.5
Maximum:	8.3	13.8	6.8	98.5	3,066,336.8	1,567.4	1.1	0.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/12/2020 00:00	8.1	13.7	6.6	85.8	2,513,676.3	1,284.9	1.1	0.5
08/12/2020 01:00	8.0	13.7	6.6	85.7	2,557,497.9	1,307.3	1.1	0.5
08/12/2020 02:00	8.1	13.7	6.6	85.8	2,509,176.7	1,282.6	1.1	0.5
08/12/2020 03:00	8.1	13.7	6.6	85.9	2,516,415.1	1,286.3	1.1	0.5
08/12/2020 04:00	8.0	13.7	6.6	85.8	2,557,693.5	1,307.4	1.1	0.5
08/12/2020 05:00	8.1	13.7	6.6	85.9	2,539,695.3	1,298.2	1.1	0.5
08/12/2020 06:00	8.2	13.7	6.7	85.7	2,529,326.8	1,292.9	1.1	0.5
08/12/2020 07:00	8.3	13.7	6.8	86.6	2,558,867.3	1,308.0	1.1	0.5
08/12/2020 08:00	8.0	13.7	6.6	86.6	2,698,939.8	1,379.6	1.0	0.6
08/12/2020 09:00	7.9	13.7	6.5	85.6	2,607,579.7	1,332.9	1.0	0.5
08/12/2020 10:00	7.9	13.7	6.5	87.0	2,620,687.0	1,339.6	1.0	0.5
08/12/2020 11:00	7.9	13.7	6.5	89.7	2,704,613.2	1,382.5	1.0	0.6
08/12/2020 12:00	8.5	13.6	6.9	102.9	3,156,812.5	1,636.7	1.0	0.7
08/12/2020 13:00	9.5	13.0	7.1	125.7	3,192,191.9	2,004.7	1.3	1.0
08/12/2020 14:00	9.5	12.9	7.0	135.8	3,159,677.5	2,053.5	1.4	1.0
08/12/2020 15:00	9.5	12.8	6.9	140.2	3,128,457.5	2,078.9	1.5	1.2
08/12/2020 16:00	9.4	12.8	6.8	140.8	3,128,006.1	2,078.6	1.5	1.2
08/12/2020 17:00	9.3	12.8	6.8	140.3	3,154,545.1	2,073.2	1.4	1.0
08/12/2020 18:00	9.3	12.9	6.9	140.1	3,168,448.0	2,059.2	1.4	1.0
08/12/2020 19:00	9.2	12.9	6.8	139.5	3,160,754.6	2,054.2	1.4	1.0
08/12/2020 20:00	9.1	13.0	6.8	132.5	3,187,453.3	2,025.0	1.3	1.0
08/12/2020 21:00	9.0	13.0	6.7	131.3	3,212,096.4	2,017.2	1.3	1.0
08/12/2020 22:00	9.1	13.0	6.8	132.4	3,235,822.4	2,032.1	1.3	1.0
08/12/2020 23:00	8.8	13.1	6.7	122.5	3,206,624.1	1,920.1	1.2	1.0
Average/Sum#:	8.6	13.3	6.7	109.2	2,875,210.8	1,659.8	1.2	0.8
Minimum:	7.9	12.8	6.5	85.6	2,509,176.7	1,282.6	1.0	0.5
Maximum:	9.5	13.7	7.1	140.8	3,235,822.4	2,078.9	1.5	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/13/2020 00:00	7.8	13.7	6.4	104.7	3,225,669.5	1,672.4	1.0	0.7
08/13/2020 01:00	7.8	13.7	6.4	101.2	3,108,014.7	1,611.4	1.0	0.6
08/13/2020 02:00	7.6	13.7	6.2	96.5	3,019,972.0	1,543.7	1.0	0.6
08/13/2020 03:00	7.6	13.7	6.2	98.2	3,085,117.5	1,577.0	1.0	0.6
08/13/2020 04:00	7.6	13.7	6.2	98.4	3,103,311.3	1,586.3	1.0	0.6
08/13/2020 05:00	7.5	13.7	6.1	99.0	3,145,763.4	1,608.0	1.0	0.6
08/13/2020 06:00	8.0	13.7	6.6	104.4	3,317,919.7	1,696.0	1.0	0.7
08/13/2020 07:00	7.9	13.7	6.5	99.9	3,126,395.9	1,598.1	1.0	0.6
08/13/2020 08:00	8.1	13.7	6.6	104.3	3,226,055.2	1,672.6	1.0	0.7
08/13/2020 09:00	7.9	13.7	6.5	99.3	3,076,961.6	1,595.3	1.0	0.6
08/13/2020 10:00	9.3	13.1	7.0	121.0	3,254,115.3	1,972.3	1.2	1.0
08/13/2020 11:00	9.3	12.9	6.9	137.4	3,225,461.3	2,072.7	1.4	1.0
08/13/2020 12:00	9.3	12.9	6.9	138.1	3,214,412.5	2,065.6	1.4	1.0
08/13/2020 13:00	9.2	12.9	6.8	137.3	3,193,715.5	2,052.3	1.4	1.0
08/13/2020 14:00	9.2	12.9	6.8	135.5	3,173,796.6	2,039.5	1.4	1.0
08/13/2020 15:00	9.3	12.9	6.9	140.8	3,151,502.0	2,071.2	1.4	1.0
08/13/2020 16:00	9.2	12.9	6.8	139.3	3,173,987.2	2,062.8	1.4	1.0
08/13/2020 17:00	9.3	12.9	6.9	138.6	3,140,546.6	2,064.0	1.4	1.0
08/13/2020 18:00	9.2	12.9	6.8	137.8	3,173,525.6	2,062.5	1.4	1.0
08/13/2020 19:00	9.1	12.9	6.7	138.8	3,183,527.0	2,069.0	1.4	1.0
08/13/2020 20:00	9.0	13.0	6.7	135.0	3,181,110.6	2,044.2	1.4	1.0
08/13/2020 21:00	8.9	13.0	6.6	129.8	3,233,115.4	2,030.4	1.3	1.0
08/13/2020 22:00	9.0	12.9	6.6	135.8	3,223,593.9	2,071.5	1.4	1.0
08/13/2020 23:00	9.0	12.9	6.6	143.8	3,223,016.4	2,118.2	1.5	1.3
Average/Sum#:	8.6	13.3	6.6	121.5	3,174,191.9	1,873.2	1.2	0.9
Minimum:	7.5	12.9	6.1	96.5	3,019,972.0	1,543.7	1.0	0.6
Maximum:	9.3	13.7	7.0	143.8	3,317,919.7	2,118.2	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/14/2020 00:00	8.9	12.9	6.6	144.8	3,237,319.2	2,127.6	1.5	1.3
08/14/2020 01:00	8.8	12.9	6.5	140.8	3,217,538.7	2,114.6	1.4	1.1
08/14/2020 02:00	8.8	12.9	6.5	139.3	3,259,696.9	2,094.7	1.4	1.0
08/14/2020 03:00	8.8	13.0	6.6	135.8	3,280,637.1	2,084.2	1.3	1.0
08/14/2020 04:00	8.8	12.9	6.5	143.4	3,272,154.9	2,126.6	1.4	1.1
08/14/2020 05:00	8.8	13.0	6.6	136.3	3,272,452.1	2,079.0	1.4	1.0
08/14/2020 06:00	9.0	13.0	6.7	137.0	3,268,465.7	2,052.6	1.4	1.0
08/14/2020 07:00	9.1	13.0	6.8	130.5	3,258,274.6	2,046.2	1.3	1.0
08/14/2020 08:00	9.0	13.0	6.7	135.4	3,257,026.4	2,069.2	1.3	1.0
08/14/2020 09:00	9.2	12.9	6.8	139.6	3,200,760.2	2,080.2	1.4	1.0
08/14/2020 10:00	9.2	12.8	6.7	144.8	3,170,142.2	2,106.6	1.5	1.3
08/14/2020 11:00	9.2	12.9	6.8	142.8	3,173,412.8	2,085.6	1.5	1.3
08/14/2020 12:00	9.2	12.9	6.8	147.4	3,191,367.4	2,097.4	1.5	1.3
08/14/2020 13:00	9.2	12.9	6.8	142.2	3,168,239.4	2,082.2	1.5	1.2
08/14/2020 14:00	9.2	12.9	6.8	139.8	3,142,372.5	2,065.2	1.4	1.0
08/14/2020 15:00	9.2	12.9	6.8	138.9	3,167,063.2	2,058.3	1.4	1.0
08/14/2020 16:00	9.2	12.9	6.8	138.7	3,140,905.6	2,041.3	1.4	1.0
08/14/2020 17:00	9.3	12.9	6.9	140.8	3,165,062.9	2,057.0	1.4	1.0
08/14/2020 18:00	9.3	12.9	6.9	142.2	3,168,294.1	2,059.1	1.5	1.2
08/14/2020 19:00	9.4	12.9	6.9	147.4	3,161,696.6	2,077.9	1.5	1.2
08/14/2020 20:00	9.4	12.9	6.9	148.4	3,148,923.7	2,092.5	1.5	1.3
08/14/2020 21:00	9.3	12.9	6.9	149.3	3,181,629.3	2,091.0	1.5	1.3
08/14/2020 22:00	9.2	12.9	6.8	149.7	3,174,506.3	2,109.5	1.5	1.3
08/14/2020 23:00	9.2	12.8	6.7	148.7	3,183,836.4	2,115.7	1.5	1.3
Average/Sum#:	9.1	12.9	6.7	141.8	3,202,574.1	2,083.9	1.4	1.1
Minimum:	8.8	12.8	6.5	130.5	3,140,905.6	2,041.3	1.3	1.0
Maximum:	9.4	13.0	6.9	149.7	3,280,637.1	2,127.6	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/15/2020 00:00	9.2	12.8	6.7	148.6	3,187,749.1	2,118.3	1.5	1.3
08/15/2020 01:00	9.2	12.8	6.7	150.2	3,192,263.7	2,121.3	1.5	1.3
08/15/2020 02:00	9.1	12.9	6.7	145.9	3,189,998.0	2,096.5	1.5	1.3
08/15/2020 03:00	9.1	12.9	6.7	142.2	3,210,761.6	2,086.7	1.4	1.0
08/15/2020 04:00	9.0	12.9	6.6	139.9	3,224,994.4	2,072.4	1.4	1.0
08/15/2020 05:00	9.0	13.0	6.7	138.7	3,247,582.1	2,063.2	1.4	1.0
08/15/2020 06:00	9.1	13.0	6.8	142.1	3,251,359.8	2,065.6	1.4	1.0
08/15/2020 07:00	9.3	12.9	6.9	137.1	3,209,588.4	2,062.5	1.4	1.0
08/15/2020 08:00	9.1	13.0	6.8	128.1	3,233,471.8	1,983.4	1.3	1.0
08/15/2020 09:00	9.3	12.9	6.9	138.2	3,195,116.1	2,053.2	1.4	1.0
08/15/2020 10:00	9.3	12.9	6.9	138.5	3,166,139.9	2,057.7	1.4	1.0
08/15/2020 11:00	9.4	12.9	6.9	144.1	3,172,347.7	2,084.9	1.5	1.3
08/15/2020 12:00	9.4	12.8	6.8	146.3	3,152,083.9	2,094.6	1.5	1.3
08/15/2020 13:00	9.5	12.8	6.9	145.8	3,109,933.0	2,089.3	1.5	1.3
08/15/2020 14:00	9.5	12.8	6.9	145.4	3,138,239.1	2,085.4	1.5	1.3
08/15/2020 15:00	9.5	12.8	6.9	144.1	3,096,983.0	2,080.6	1.5	1.2
08/15/2020 16:00	9.5	12.8	6.9	144.8	3,095,941.1	2,079.9	1.5	1.2
08/15/2020 17:00	9.4	12.8	6.8	141.3	3,092,070.9	2,077.3	1.5	1.2
08/15/2020 18:00	9.3	12.8	6.8	140.3	3,121,836.1	2,074.5	1.5	1.2
08/15/2020 19:00	9.3	12.8	6.8	142.4	3,125,748.8	2,077.1	1.5	1.2
08/15/2020 20:00	9.3	12.8	6.8	142.7	3,152,083.9	2,094.6	1.5	1.3
08/15/2020 21:00	9.1	12.9	6.7	140.8	3,164,131.1	2,079.5	1.4	1.0
08/15/2020 22:00	8.9	12.9	6.6	135.0	3,174,602.7	2,063.2	1.4	1.0
08/15/2020 23:00	9.0	12.8	6.6	143.1	3,177,365.5	2,111.4	1.5	1.3
Average/Sum#:	9.2	12.9	6.8	141.9	3,170,099.7	2,078.0	1.5	1.2
Minimum:	8.9	12.8	6.6	128.1	3,092,070.9	1,983.4	1.3	1.0
Maximum:	9.5	13.0	6.9	150.2	3,251,359.8	2,121.3	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/16/2020 00:00	8.8	12.8	6.4	142.0	3,187,448.1	2,118.1	1.5	1.3
08/16/2020 01:00	8.8	12.8	6.4	142.3	3,184,287.9	2,116.0	1.5	1.3
08/16/2020 02:00	8.8	12.8	6.4	141.1	3,185,040.3	2,116.5	1.4	1.1
08/16/2020 03:00	8.7	12.9	6.4	138.5	3,227,994.8	2,097.9	1.4	1.0
08/16/2020 04:00	8.7	12.9	6.4	141.7	3,221,038.3	2,116.9	1.4	1.1
08/16/2020 05:00	8.8	12.9	6.5	141.1	3,205,670.3	2,106.8	1.4	1.1
08/16/2020 06:00	9.1	12.9	6.7	139.6	3,186,194.1	2,094.0	1.4	1.0
08/16/2020 07:00	8.9	13.0	6.6	126.4	3,189,962.6	2,003.3	1.3	1.0
08/16/2020 08:00	8.7	13.1	6.6	119.4	3,225,076.9	1,954.7	1.2	1.0
08/16/2020 09:00	8.8	13.0	6.6	125.9	3,203,019.9	2,011.5	1.3	1.0
08/16/2020 10:00	8.9	13.0	6.6	129.1	3,177,536.8	2,018.7	1.3	1.0
08/16/2020 11:00	8.8	12.9	6.5	126.3	3,169,981.3	2,013.9	1.3	1.0
08/16/2020 12:00	8.8	12.9	6.5	131.0	3,172,551.7	2,038.7	1.3	1.0
08/16/2020 13:00	8.8	12.9	6.5	133.8	3,161,216.2	2,054.5	1.4	1.0
08/16/2020 14:00	9.1	12.8	6.6	143.5	3,183,911.7	2,092.5	1.5	1.3
08/16/2020 15:00	9.1	12.8	6.6	144.9	3,152,986.8	2,095.2	1.5	1.3
08/16/2020 16:00	9.1	12.8	6.6	145.4	3,162,918.9	2,101.8	1.5	1.3
08/16/2020 17:00	9.1	12.8	6.6	143.1	3,119,906.0	2,096.0	1.5	1.3
08/16/2020 18:00	9.1	12.8	6.6	141.4	3,110,230.7	2,089.5	1.5	1.3
08/16/2020 19:00	9.2	12.8	6.7	140.6	3,134,176.0	2,082.7	1.5	1.2
08/16/2020 20:00	9.1	12.8	6.6	140.9	3,140,797.4	2,087.1	1.5	1.3
08/16/2020 21:00	9.1	12.8	6.6	138.5	3,158,957.7	2,076.1	1.4	1.0
08/16/2020 22:00	9.0	12.8	6.6	135.7	3,155,305.9	2,073.7	1.4	1.0
08/16/2020 23:00	9.0	12.8	6.6	138.1	3,166,413.5	2,081.0	1.4	1.0
Average/Sum#:	8.9	12.9	6.6	137.1	3,174,276.0	2,072.4	1.4	1.1
Minimum:	8.7	12.8	6.4	119.4	3,110,230.7	1,954.7	1.2	1.0
Maximum:	9.2	13.1	6.7	145.4	3,227,994.8	2,118.1	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/17/2020 00:00	9.0	12.8	6.6	140.3	3,176,760.3	2,087.8	1.4	1.0
08/17/2020 01:00	8.9	12.9	6.6	137.2	3,199,837.0	2,079.6	1.4	1.0
08/17/2020 02:00	8.8	12.9	6.5	135.5	3,192,451.4	2,074.8	1.4	1.0
08/17/2020 03:00	8.9	12.9	6.6	138.6	3,209,223.0	2,085.7	1.4	1.0
08/17/2020 04:00	9.0	12.9	6.6	140.7	3,211,992.6	2,087.5	1.4	1.0
08/17/2020 05:00	8.8	12.9	6.5	136.7	3,200,914.1	2,080.3	1.4	1.0
08/17/2020 06:00	9.1	12.9	6.7	151.0	3,196,084.4	2,100.5	1.5	1.3
08/17/2020 07:00	9.3	12.8	6.8	142.9	3,205,518.2	2,106.7	1.4	1.1
08/17/2020 08:00	9.0	12.9	6.6	138.9	3,183,759.5	2,092.4	1.4	1.0
08/17/2020 09:00	9.1	12.8	6.6	143.2	3,173,151.9	2,108.6	1.5	1.3
08/17/2020 10:00	9.1	12.8	6.6	145.1	3,175,559.7	2,110.2	1.5	1.3
08/17/2020 11:00	9.0	12.8	6.6	139.3	3,168,239.4	2,082.2	1.4	1.0
08/17/2020 12:00	9.0	12.8	6.6	140.0	3,176,760.3	2,087.8	1.4	1.0
08/17/2020 13:00	8.9	12.9	6.6	134.7	3,167,524.8	2,058.6	1.4	1.0
08/17/2020 14:00	8.9	12.9	6.6	133.7	3,175,064.3	2,063.5	1.4	1.0
08/17/2020 15:00	8.9	12.8	6.5	139.3	3,149,224.6	2,092.7	1.4	1.0
08/17/2020 16:00	8.9	12.8	6.5	140.8	3,150,729.5	2,093.7	1.5	1.3
08/17/2020 17:00	8.8	12.9	6.5	137.7	3,142,220.3	2,065.1	1.4	1.0
08/17/2020 18:00	8.8	12.9	6.5	135.0	3,183,444.8	2,045.7	1.4	1.0
08/17/2020 19:00	8.9	12.9	6.6	134.6	3,185,623.5	2,047.1	1.4	1.0
08/17/2020 20:00	8.9	12.9	6.6	137.1	3,217,369.2	2,067.5	1.4	1.0
08/17/2020 21:00	9.0	12.9	6.6	142.9	3,191,976.1	2,097.8	1.5	1.3
08/17/2020 22:00	8.9	12.9	6.6	140.7	3,178,129.7	2,088.7	1.4	1.0
08/17/2020 23:00	8.8	12.9	6.5	139.1	3,214,300.6	2,089.0	1.4	1.0
Average/Sum#:	8.9	12.9	6.6	139.4	3,184,410.8	2,083.1	1.4	1.1
Minimum:	8.8	12.8	6.5	133.7	3,142,220.3	2,045.7	1.4	1.0
Maximum:	9.3	12.9	6.8	151.0	3,217,369.2	2,110.2	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/18/2020 00:00	8.7	12.9	6.4	133.5	3,199,162.1	2,055.8	1.4	1.0
08/18/2020 01:00	8.8	12.9	6.5	138.2	3,199,837.0	2,079.6	1.4	1.0
08/18/2020 02:00	8.9	12.9	6.6	140.5	3,184,824.6	2,093.1	1.4	1.0
08/18/2020 03:00	8.6	12.9	6.3	134.3	3,220,792.8	2,069.7	1.4	1.0
08/18/2020 04:00	8.9	12.9	6.6	140.3	3,208,299.8	2,085.1	1.4	1.0
08/18/2020 05:00	9.0	12.9	6.6	140.1	3,196,913.5	2,077.7	1.4	1.0
08/18/2020 06:00	9.3	12.9	6.9	145.2	3,195,019.2	2,099.8	1.5	1.3
08/18/2020 07:00	9.3	12.9	6.9	138.5	3,199,221.5	2,079.2	1.4	1.0
08/18/2020 08:00	9.1	12.9	6.7	136.9	3,199,473.3	2,056.0	1.4	1.0
08/18/2020 09:00	9.1	12.9	6.7	137.8	3,189,825.1	2,049.8	1.4	1.0
08/18/2020 10:00	9.2	12.9	6.8	141.9	3,174,602.7	2,063.2	1.5	1.2
08/18/2020 11:00	9.3	12.9	6.9	137.5	3,121,210.5	2,028.5	1.4	1.0
08/18/2020 12:00	9.3	12.8	6.8	143.3	3,117,622.5	2,071.7	1.5	1.2
08/18/2020 13:00	9.3	12.8	6.8	145.2	3,093,559.5	2,078.3	1.5	1.2
08/18/2020 14:00	9.3	12.8	6.8	144.9	3,100,704.3	2,083.1	1.5	1.2
08/18/2020 15:00	9.3	12.8	6.8	145.4	3,091,773.2	2,077.1	1.5	1.2
08/18/2020 16:00	9.3	12.8	6.8	143.6	3,092,964.1	2,077.9	1.5	1.2
08/18/2020 17:00	9.2	12.8	6.7	142.6	3,097,429.6	2,080.9	1.5	1.2
08/18/2020 18:00	9.1	12.8	6.6	142.7	3,096,983.0	2,080.6	1.5	1.2
08/18/2020 19:00	9.0	12.8	6.6	140.6	3,102,937.0	2,084.6	1.5	1.3
08/18/2020 20:00	8.9	12.8	6.5	142.7	3,157,501.4	2,098.2	1.5	1.3
08/18/2020 21:00	8.8	12.9	6.5	145.1	3,228,456.5	2,098.2	1.5	1.3
08/18/2020 22:00	8.9	12.9	6.6	144.0	3,209,778.6	2,109.5	1.5	1.3
08/18/2020 23:00	8.8	12.9	6.5	146.8	3,221,038.3	2,116.9	1.5	1.3
Average/Sum#:	9.1	12.9	6.7	141.3	3,162,497.1	2,078.9	1.5	1.1
Minimum:	8.6	12.8	6.3	133.5	3,091,773.2	2,028.5	1.4	1.0
Maximum:	9.3	12.9	6.9	146.8	3,228,456.5	2,116.9	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/19/2020 00:00	8.7	12.9	6.4	138.0	3,209,838.4	2,086.1	1.4	1.0
08/19/2020 01:00	8.6	12.9	6.3	137.2	3,201,837.3	2,080.9	1.4	1.0
08/19/2020 02:00	8.6	12.9	6.3	140.0	3,218,608.9	2,091.8	1.4	1.0
08/19/2020 03:00	8.7	13.0	6.5	138.6	3,220,014.7	2,069.2	1.4	1.0
08/19/2020 04:00	8.8	12.9	6.5	140.0	3,231,841.5	2,076.8	1.4	1.0
08/19/2020 05:00	8.8	13.0	6.6	140.2	3,256,869.0	2,069.1	1.4	1.0
08/19/2020 06:00	9.0	13.0	6.7	139.9	3,252,776.4	2,066.5	1.4	1.0
08/19/2020 07:00	9.1	12.9	6.7	146.2	3,240,919.8	2,106.3	1.5	1.3
08/19/2020 08:00	8.8	13.0	6.6	135.2	3,236,406.3	2,056.1	1.4	1.0
08/19/2020 09:00	9.0	12.9	6.6	145.4	3,228,764.2	2,098.4	1.5	1.3
08/19/2020 10:00	9.0	12.8	6.6	149.9	3,182,933.5	2,115.1	1.5	1.3
08/19/2020 11:00	9.0	12.8	6.6	144.7	3,163,821.8	2,102.4	1.5	1.3
08/19/2020 12:00	8.9	12.8	6.5	140.4	3,159,870.7	2,076.7	1.4	1.0
08/19/2020 13:00	8.9	12.8	6.5	145.3	3,159,758.7	2,099.7	1.5	1.3
08/19/2020 14:00	9.0	12.8	6.6	144.0	3,148,171.2	2,092.0	1.5	1.3
08/19/2020 15:00	9.1	12.8	6.6	144.0	3,100,257.7	2,082.8	1.5	1.2
08/19/2020 16:00	9.0	12.8	6.6	143.9	3,137,637.2	2,085.0	1.5	1.3
08/19/2020 17:00	9.1	12.8	6.6	147.1	3,178,738.3	2,089.1	1.5	1.3
08/19/2020 18:00	9.0	12.9	6.6	150.1	3,210,691.5	2,110.1	1.5	1.3
08/19/2020 19:00	8.9	12.9	6.6	145.6	3,233,688.0	2,101.6	1.5	1.3
08/19/2020 20:00	8.9	12.9	6.6	147.0	3,228,302.6	2,098.1	1.5	1.3
08/19/2020 21:00	8.8	13.0	6.6	140.9	3,264,424.4	2,073.9	1.4	1.0
08/19/2020 22:00	8.8	13.0	6.6	138.9	3,284,230.0	2,062.5	1.4	1.0
08/19/2020 23:00	8.7	13.0	6.5	134.5	3,300,635.0	2,048.7	1.3	1.0
Average/Sum#:	8.9	12.9	6.6	142.4	3,210,459.9	2,085.0	1.4	1.1
Minimum:	8.6	12.8	6.3	134.5	3,100,257.7	2,048.7	1.3	1.0
Maximum:	9.1	13.0	6.7	150.1	3,300,635.0	2,115.1	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/20/2020 00:00	8.7	13.0	6.5	135.2	3,307,079.3	2,052.7	1.3	1.0
08/20/2020 01:00	8.6	13.1	6.5	133.4	3,290,968.5	2,042.7	1.3	1.0
08/20/2020 02:00	8.4	13.1	6.4	128.1	3,313,191.9	2,032.3	1.2	1.0
08/20/2020 03:00	8.6	13.0	6.4	132.7	3,314,985.2	2,033.4	1.3	1.0
08/20/2020 04:00	8.5	13.0	6.3	130.9	3,288,229.6	2,041.0	1.3	1.0
08/20/2020 05:00	8.5	13.0	6.3	132.2	3,292,740.7	2,043.8	1.3	1.0
08/20/2020 06:00	8.6	13.1	6.5	129.6	3,312,539.8	2,031.9	1.3	1.0
08/20/2020 07:00	8.9	13.0	6.6	128.8	3,306,344.8	2,028.1	1.3	1.0
08/20/2020 08:00	8.7	13.0	6.5	132.8	3,277,274.2	2,034.2	1.3	1.0
08/20/2020 09:00	8.7	13.0	6.5	133.2	3,262,733.2	2,049.0	1.3	1.0
08/20/2020 10:00	8.6	13.0	6.4	133.4	3,269,261.9	2,053.1	1.3	1.0
08/20/2020 11:00	8.6	13.0	6.4	132.8	3,264,166.3	2,049.9	1.3	1.0
08/20/2020 12:00	8.7	13.0	6.5	135.0	3,272,128.1	2,054.9	1.3	1.0
08/20/2020 13:00	8.7	13.0	6.5	137.0	3,275,312.8	2,056.9	1.4	1.0
08/20/2020 14:00	8.8	13.0	6.6	139.0	3,271,491.2	2,054.5	1.4	1.0
08/20/2020 15:00	8.9	13.0	6.6	136.9	3,253,019.9	2,042.9	1.4	1.0
08/20/2020 16:00	8.9	13.0	6.6	137.5	3,246,968.9	2,039.1	1.4	1.0
08/20/2020 17:00	9.0	12.9	6.6	139.1	3,192,470.6	2,051.5	1.4	1.0
08/20/2020 18:00	8.9	13.0	6.6	138.0	3,223,971.3	2,048.2	1.4	1.0
08/20/2020 19:00	8.9	13.0	6.6	138.8	3,230,424.9	2,052.3	1.4	1.0
08/20/2020 20:00	8.9	13.0	6.6	138.7	3,235,619.3	2,055.6	1.4	1.0
08/20/2020 21:00	8.9	13.0	6.6	137.5	3,265,440.2	2,050.7	1.4	1.0
08/20/2020 22:00	8.6	13.0	6.4	130.6	3,247,605.8	2,039.5	1.3	1.0
08/20/2020 23:00	8.8	13.0	6.6	142.8	3,206,499.3	2,037.1	1.5	1.2
Average/Sum#:	8.7	13.0	6.5	134.8	3,267,519.5	2,044.8	1.3	1.0
Minimum:	8.4	12.9	6.3	128.1	3,192,470.6	2,028.1	1.2	1.0
Maximum:	9.0	13.1	6.6	142.8	3,314,985.2	2,056.9	1.5	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/21/2020 00:00	8.7	13.0	6.5	148.6	3,232,471.2	2,053.6	1.5	1.2
08/21/2020 01:00	8.5	13.1	6.4	142.6	3,226,109.1	2,026.0	1.4	1.0
08/21/2020 02:00	8.2	13.2	6.3	128.1	3,254,721.0	1,948.9	1.3	1.0
08/21/2020 03:00	8.5	13.1	6.4	143.3	3,233,274.7	2,030.5	1.4	1.0
08/21/2020 04:00	8.4	13.1	6.4	143.9	3,247,128.1	2,039.2	1.4	1.0
08/21/2020 05:00	8.4	13.1	6.4	142.4	3,237,414.8	2,033.1	1.4	1.0
08/21/2020 06:00	8.7	13.0	6.5	145.8	3,213,945.7	2,065.3	1.5	1.2
08/21/2020 07:00	8.7	13.0	6.5	144.3	3,245,850.6	2,062.1	1.4	1.0
08/21/2020 08:00	8.4	13.0	6.3	142.8	3,217,832.5	2,044.3	1.5	1.2
08/21/2020 09:00	8.4	13.0	6.3	142.8	3,219,236.6	2,068.7	1.5	1.2
08/21/2020 10:00	8.5	13.0	6.3	146.3	3,183,527.0	2,069.0	1.5	1.2
08/21/2020 11:00	8.6	13.0	6.4	147.6	3,173,987.2	2,062.8	1.5	1.2
08/21/2020 12:00	8.9	12.9	6.6	143.0	3,226,083.7	2,073.1	1.4	1.0
08/21/2020 13:00	9.0	12.9	6.6	146.5	3,184,520.3	2,092.9	1.5	1.3
08/21/2020 14:00	9.1	12.9	6.7	146.1	3,171,525.3	2,061.2	1.5	1.2
08/21/2020 15:00	9.1	12.9	6.7	143.1	3,167,986.4	2,058.9	1.5	1.2
08/21/2020 16:00	9.3	12.9	6.9	148.3	3,159,109.9	2,076.2	1.5	1.2
08/21/2020 17:00	9.2	12.9	6.8	145.3	3,164,891.9	2,080.0	1.5	1.2
08/21/2020 18:00	9.1	12.9	6.7	142.3	3,174,448.8	2,063.1	1.5	1.2
08/21/2020 19:00	9.0	12.9	6.6	137.2	3,186,090.3	2,047.4	1.4	1.0
08/21/2020 20:00	9.0	12.9	6.6	140.5	3,204,141.8	2,059.0	1.4	1.0
08/21/2020 21:00	8.9	12.9	6.6	137.1	3,214,369.6	2,042.1	1.4	1.0
08/21/2020 22:00	9.0	13.0	6.7	137.4	3,195,116.1	2,053.2	1.4	1.0
08/21/2020 23:00	9.0	12.9	6.6	139.2	3,203,830.6	2,058.8	1.4	1.0
Average/Sum#:	8.8	13.0	6.5	142.7	3,205,733.9	2,052.9	1.4	1.1
Minimum:	8.2	12.9	6.3	128.1	3,159,109.9	1,948.9	1.3	1.0
Maximum:	9.3	13.2	6.9	148.6	3,254,721.0	2,092.9	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/22/2020 00:00	8.8	12.9	6.5	139.5	3,208,499.1	2,061.8	1.4	1.0
08/22/2020 01:00	8.3	13.1	6.3	119.4	3,165,185.2	1,918.4	1.2	1.0
08/22/2020 02:00	7.4	13.6	6.0	102.9	3,215,061.3	1,666.9	1.0	0.7
08/22/2020 03:00	7.0	13.8	5.8	93.3	3,002,365.1	1,534.7	1.0	0.6
08/22/2020 04:00	7.6	13.7	6.2	102.1	3,248,861.5	1,660.7	1.0	0.7
08/22/2020 05:00	7.9	13.7	6.5	105.0	3,244,378.5	1,682.1	1.0	0.7
08/22/2020 06:00	8.0	13.7	6.6	106.2	3,289,748.6	1,681.6	1.0	0.7
08/22/2020 07:00	8.1	13.7	6.6	105.1	3,273,119.9	1,673.1	1.0	0.7
08/22/2020 08:00	8.1	13.7	6.6	104.5	3,214,096.9	1,666.4	1.0	0.7
08/22/2020 09:00	8.0	13.7	6.6	103.5	3,174,557.2	1,645.9	1.0	0.7
08/22/2020 10:00	8.0	13.7	6.6	98.2	3,056,946.5	1,562.6	1.0	0.6
08/22/2020 11:00	9.5	13.0	7.1	131.1	3,237,158.1	2,009.3	1.3	1.0
08/22/2020 12:00	9.6	12.9	7.1	147.2	3,156,827.5	2,074.7	1.5	1.2
08/22/2020 13:00	9.5	12.8	6.9	149.2	3,168,695.9	2,082.5	1.5	1.2
08/22/2020 14:00	9.4	12.9	6.9	143.5	3,154,753.7	2,050.3	1.5	1.2
08/22/2020 15:00	9.5	12.8	6.9	149.4	3,139,292.5	2,086.1	1.6	1.3
08/22/2020 16:00	9.4	12.8	6.8	150.1	3,118,566.3	2,095.1	1.6	1.3
08/22/2020 17:00	9.3	12.8	6.8	145.6	3,155,305.9	2,073.7	1.5	1.2
08/22/2020 18:00	9.4	12.9	6.9	144.2	3,167,832.5	2,058.8	1.5	1.2
08/22/2020 19:00	9.2	12.9	6.8	141.2	3,166,755.4	2,058.1	1.4	1.0
08/22/2020 20:00	9.2	12.9	6.8	139.9	3,154,138.3	2,049.9	1.4	1.0
08/22/2020 21:00	9.3	12.9	6.9	146.7	3,170,673.9	2,083.8	1.5	1.3
08/22/2020 22:00	9.0	12.9	6.6	142.4	3,183,680.9	2,069.1	1.5	1.2
08/22/2020 23:00	9.1	12.9	6.7	144.7	3,180,259.9	2,090.1	1.5	1.3
Average/Sum#:	8.7	13.2	6.6	127.3	3,176,948.4	1,901.5	1.3	1.0
Minimum:	7.0	12.8	5.8	93.3	3,002,365.1	1,534.7	1.0	0.6
Maximum:	9.6	13.8	7.1	150.1	3,289,748.6	2,095.1	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/23/2020 00:00	9.1	12.9	6.7	141.3	3,205,698.0	2,060.0	1.4	1.0
08/23/2020 01:00	8.8	12.9	6.5	134.5	3,197,212.4	2,031.2	1.4	1.0
08/23/2020 02:00	8.8	12.9	6.5	134.5	3,224,128.7	2,048.3	1.4	1.0
08/23/2020 03:00	8.8	13.0	6.6	131.2	3,240,281.0	2,034.9	1.3	1.0
08/23/2020 04:00	8.4	13.1	6.4	121.7	3,233,678.6	1,936.3	1.2	1.0
08/23/2020 05:00	7.4	13.7	6.1	104.8	3,246,693.0	1,683.3	1.0	0.7
08/23/2020 06:00	7.7	13.7	6.3	102.3	3,200,540.4	1,636.0	1.0	0.7
08/23/2020 07:00	7.7	13.7	6.3	100.4	3,093,529.7	1,581.3	1.0	0.6
08/23/2020 08:00	7.9	13.6	6.4	104.1	3,166,649.2	1,641.8	1.0	0.7
08/23/2020 09:00	7.9	13.7	6.5	101.9	3,102,614.2	1,608.6	1.0	0.6
08/23/2020 10:00	8.1	13.7	6.6	98.2	2,991,996.6	1,529.4	1.0	0.6
08/23/2020 11:00	9.4	13.0	7.0	128.6	3,239,091.4	2,010.5	1.3	1.0
08/23/2020 12:00	9.2	12.9	6.8	143.4	3,202,145.0	2,081.1	1.5	1.2
08/23/2020 13:00	9.1	12.9	6.7	143.1	3,160,631.5	2,077.2	1.5	1.2
08/23/2020 14:00	9.0	12.9	6.6	141.6	3,188,912.4	2,072.5	1.4	1.0
08/23/2020 15:00	9.0	12.8	6.6	144.4	3,149,375.1	2,092.8	1.5	1.3
08/23/2020 16:00	9.1	12.8	6.6	146.7	3,114,696.2	2,092.5	1.5	1.3
08/23/2020 17:00	9.2	12.8	6.7	147.6	3,122,287.6	2,097.6	1.5	1.3
08/23/2020 18:00	9.1	12.8	6.6	145.9	3,125,413.5	2,099.7	1.5	1.3
08/23/2020 19:00	9.0	12.8	6.6	147.2	3,128,539.3	2,101.8	1.5	1.3
08/23/2020 20:00	9.0	12.8	6.6	148.2	3,178,118.0	2,111.9	1.5	1.3
08/23/2020 21:00	8.9	12.9	6.6	143.9	3,210,761.6	2,086.7	1.5	1.3
08/23/2020 22:00	8.9	12.9	6.6	140.8	3,193,220.7	2,075.3	1.4	1.0
08/23/2020 23:00	9.0	12.9	6.6	140.8	3,188,758.5	2,072.4	1.4	1.0
Average/Sum#:	8.7	13.1	6.6	130.7	3,171,040.5	1,952.6	1.3	1.0
Minimum:	7.4	12.8	6.1	98.2	2,991,996.6	1,529.4	1.0	0.6
Maximum:	9.4	13.7	7.0	148.2	3,246,693.0	2,111.9	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/24/2020 00:00	9.0	12.9	6.6	141.1	3,196,298.1	2,077.3	1.4	1.0
08/24/2020 01:00	8.9	12.9	6.6	140.0	3,225,616.9	2,072.8	1.4	1.0
08/24/2020 02:00	9.0	12.9	6.6	141.1	3,210,300.0	2,086.4	1.4	1.0
08/24/2020 03:00	8.9	12.9	6.6	145.4	3,205,213.8	2,106.5	1.5	1.3
08/24/2020 04:00	8.8	12.9	6.5	143.2	3,228,456.5	2,098.2	1.4	1.0
08/24/2020 05:00	8.8	12.9	6.5	140.1	3,219,532.1	2,092.4	1.4	1.0
08/24/2020 06:00	8.9	12.9	6.6	143.5	3,205,376.3	2,083.2	1.5	1.2
08/24/2020 07:00	9.0	12.9	6.6	135.4	3,238,452.6	2,057.4	1.4	1.0
08/24/2020 08:00	8.9	12.9	6.6	135.9	3,221,767.6	2,046.8	1.4	1.0
08/24/2020 09:00	9.0	12.9	6.6	138.6	3,209,277.2	2,062.3	1.4	1.0
08/24/2020 10:00	9.0	12.9	6.6	144.6	3,189,998.0	2,096.5	1.5	1.3
08/24/2020 11:00	9.0	12.9	6.6	149.4	3,170,593.7	2,106.9	1.5	1.3
08/24/2020 12:00	9.0	12.9	6.6	148.5	3,213,377.4	2,088.4	1.5	1.3
08/24/2020 13:00	9.0	12.9	6.6	144.0	3,174,782.2	2,086.5	1.5	1.3
08/24/2020 14:00	9.0	12.9	6.6	141.8	3,145,567.8	2,067.3	1.5	1.2
08/24/2020 15:00	9.1	12.8	6.6	144.3	3,119,127.4	2,072.7	1.5	1.2
08/24/2020 16:00	9.3	12.8	6.8	151.2	3,136,282.8	2,084.1	1.6	1.3
08/24/2020 17:00	9.3	12.8	6.8	147.9	3,127,554.6	2,078.3	1.5	1.2
08/24/2020 18:00	9.2	12.8	6.7	145.3	3,132,219.7	2,081.4	1.5	1.2
08/24/2020 19:00	9.1	12.9	6.7	139.1	3,159,831.4	2,053.6	1.4	1.0
08/24/2020 20:00	9.1	12.9	6.7	142.0	3,185,527.3	2,070.3	1.5	1.2
08/24/2020 21:00	9.0	12.9	6.6	141.1	3,186,604.4	2,071.0	1.4	1.0
08/24/2020 22:00	8.9	12.9	6.6	140.9	3,197,836.7	2,078.3	1.4	1.0
08/24/2020 23:00	8.8	12.9	6.5	138.4	3,195,221.0	2,076.6	1.4	1.0
Average/Sum#:	9.0	12.9	6.6	142.6	3,187,284.0	2,079.0	1.5	1.1
Minimum:	8.8	12.8	6.5	135.4	3,119,127.4	2,046.8	1.4	1.0
Maximum:	9.3	12.9	6.8	151.2	3,238,452.6	2,106.9	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/25/2020 00:00	8.7	12.9	6.4	133.3	3,197,294.7	2,054.6	1.4	1.0
08/25/2020 01:00	8.8	12.9	6.5	134.7	3,186,245.9	2,047.5	1.4	1.0
08/25/2020 02:00	8.6	12.9	6.3	131.7	3,207,443.8	2,037.7	1.3	1.0
08/25/2020 03:00	8.5	13.0	6.3	123.2	3,244,557.6	1,990.2	1.2	1.0
08/25/2020 04:00	8.7	13.0	6.5	130.7	3,240,918.0	2,035.3	1.3	1.0
08/25/2020 05:00	8.5	13.0	6.3	128.1	3,217,675.1	2,044.2	1.3	1.0
08/25/2020 06:00	8.7	12.9	6.4	134.6	3,253,975.3	2,043.5	1.3	1.0
08/25/2020 07:00	8.8	13.0	6.6	126.9	3,269,863.2	2,029.6	1.2	1.0
08/25/2020 08:00	8.7	13.0	6.5	128.3	3,227,701.4	2,027.0	1.3	1.0
08/25/2020 09:00	8.7	12.9	6.4	133.4	3,223,184.3	2,047.7	1.3	1.0
08/25/2020 10:00	8.8	12.9	6.5	132.9	3,188,891.4	2,049.2	1.4	1.0
08/25/2020 11:00	8.9	12.9	6.6	135.1	3,180,332.5	2,043.7	1.4	1.0
08/25/2020 12:00	8.9	12.9	6.6	137.3	3,173,641.0	2,039.4	1.4	1.0
08/25/2020 13:00	9.0	12.9	6.6	138.4	3,170,839.9	2,037.6	1.4	1.0
08/25/2020 14:00	9.0	12.9	6.6	137.5	3,139,520.8	2,040.4	1.4	1.0
08/25/2020 15:00	8.9	12.9	6.6	137.5	3,149,983.8	2,047.2	1.4	1.0
08/25/2020 16:00	9.1	12.9	6.7	142.6	3,137,503.4	2,062.0	1.5	1.2
08/25/2020 17:00	9.1	12.8	6.6	143.6	3,128,909.0	2,079.2	1.5	1.2
08/25/2020 18:00	9.1	12.8	6.6	146.4	3,140,947.9	2,087.2	1.5	1.3
08/25/2020 19:00	9.1	12.8	6.6	143.7	3,145,161.5	2,090.0	1.5	1.3
08/25/2020 20:00	8.9	12.9	6.6	140.5	3,149,523.9	2,069.9	1.5	1.2
08/25/2020 21:00	8.9	12.9	6.6	138.0	3,162,601.0	2,055.4	1.4	1.0
08/25/2020 22:00	8.9	12.9	6.6	136.8	3,190,292.0	2,050.1	1.4	1.0
08/25/2020 23:00	8.8	12.9	6.5	136.6	3,161,831.6	2,054.9	1.4	1.0
Average/Sum#:	8.8	12.9	6.5	135.5	3,187,035.0	2,048.5	1.4	1.1
Minimum:	8.5	12.8	6.3	123.2	3,128,909.0	1,990.2	1.2	1.0
Maximum:	9.1	13.0	6.7	146.4	3,269,863.2	2,090.0	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/26/2020 00:00	8.7	12.9	6.4	130.5	3,184,620.0	2,023.2	1.3	1.0
08/26/2020 01:00	8.5	13.1	6.4	119.7	3,222,155.4	1,929.4	1.2	1.0
08/26/2020 02:00	8.4	13.1	6.4	116.5	3,273,093.3	1,936.0	1.1	0.8
08/26/2020 03:00	8.7	13.0	6.5	127.2	3,257,941.2	2,022.2	1.3	1.0
08/26/2020 04:00	8.4	13.0	6.3	126.2	3,236,300.1	2,032.4	1.3	1.0
08/26/2020 05:00	8.4	13.0	6.3	127.9	3,237,414.8	2,033.1	1.3	1.0
08/26/2020 06:00	8.7	13.0	6.5	128.4	3,242,669.6	2,036.4	1.3	1.0
08/26/2020 07:00	8.5	13.1	6.4	117.9	3,241,193.7	1,940.8	1.2	1.0
08/26/2020 08:00	8.5	13.1	6.4	116.6	3,243,030.7	1,941.9	1.2	1.0
08/26/2020 09:00	8.8	13.0	6.6	131.2	3,206,341.9	2,037.0	1.3	1.0
08/26/2020 10:00	8.8	12.9	6.5	134.8	3,203,052.5	2,058.3	1.4	1.0
08/26/2020 11:00	8.9	12.9	6.6	136.0	3,186,401.6	2,047.6	1.4	1.0
08/26/2020 12:00	9.0	12.9	6.6	136.4	3,153,830.5	2,049.7	1.4	1.0
08/26/2020 13:00	9.1	12.9	6.7	139.2	3,151,368.6	2,048.1	1.4	1.0
08/26/2020 14:00	9.1	12.8	6.6	141.6	3,135,829.7	2,060.9	1.5	1.2
08/26/2020 15:00	9.1	12.8	6.6	143.2	3,131,918.7	2,081.2	1.5	1.2
08/26/2020 16:00	9.1	12.9	6.7	136.3	3,123,056.9	2,029.7	1.4	1.0
08/26/2020 17:00	9.1	12.9	6.7	133.5	3,127,267.3	2,009.6	1.4	1.0
08/26/2020 18:00	9.3	12.9	6.9	134.8	3,125,088.7	2,008.2	1.4	1.0
08/26/2020 19:00	8.9	12.9	6.6	129.2	3,147,472.4	1,999.6	1.3	1.0
08/26/2020 20:00	8.7	13.0	6.5	127.0	3,171,650.6	1,991.8	1.3	1.0
08/26/2020 21:00	8.6	13.0	6.4	123.8	3,204,775.3	1,989.2	1.2	1.0
08/26/2020 22:00	8.5	13.1	6.4	119.0	3,231,006.5	1,934.7	1.2	1.0
08/26/2020 23:00	8.4	13.1	6.4	116.2	3,257,201.3	1,926.6	1.1	0.8
Average/Sum#:	8.8	13.0	6.5	128.9	3,195,611.7	2,007.0	1.3	1.0
Minimum:	8.4	12.8	6.3	116.2	3,123,056.9	1,926.6	1.1	0.8
Maximum:	9.3	13.1	6.9	143.2	3,273,093.3	2,081.2	1.5	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/27/2020 00:00	8.3	13.2	6.4	114.6	3,262,442.3	1,929.7	1.1	0.8
08/27/2020 01:00	8.2	13.2	6.3	113.4	3,303,394.0	1,929.8	1.1	0.8
08/27/2020 02:00	8.3	13.2	6.4	115.0	3,293,979.2	1,924.3	1.1	0.8
08/27/2020 03:00	8.0	13.2	6.1	113.8	3,305,448.1	1,931.0	1.1	0.8
08/27/2020 04:00	8.1	13.0	6.0	124.6	3,274,696.5	2,032.6	1.2	1.0
08/27/2020 05:00	7.9	13.0	5.9	124.1	3,282,107.5	2,037.2	1.2	1.0
08/27/2020 06:00	8.3	13.0	6.2	134.0	3,309,657.1	2,054.3	1.3	1.0
08/27/2020 07:00	8.5	13.2	6.5	116.5	3,279,179.7	1,939.6	1.1	0.8
08/27/2020 08:00	8.5	13.1	6.4	122.9	3,254,502.3	1,996.3	1.2	1.0
08/27/2020 09:00	8.4	13.1	6.4	122.5	3,252,872.0	1,995.3	1.2	1.0
08/27/2020 10:00	8.5	13.0	6.3	123.0	3,244,720.7	1,990.3	1.2	1.0
08/27/2020 11:00	8.7	12.9	6.4	138.4	3,215,069.9	2,089.5	1.4	1.0
08/27/2020 12:00	8.7	12.9	6.4	141.8	3,197,758.1	2,101.6	1.4	1.1
08/27/2020 13:00	8.7	12.8	6.3	141.0	3,154,491.6	2,096.2	1.5	1.3
08/27/2020 14:00	8.9	12.8	6.5	144.1	3,155,695.5	2,097.0	1.5	1.3
08/27/2020 15:00	8.8	12.8	6.4	144.1	3,167,734.4	2,105.0	1.5	1.3
08/27/2020 16:00	8.7	13.0	6.5	134.3	3,178,620.7	2,042.6	1.4	1.0
08/27/2020 17:00	8.9	13.0	6.6	135.9	3,177,375.8	2,041.8	1.4	1.0
08/27/2020 18:00	8.6	13.0	6.4	132.7	3,187,646.5	2,048.4	1.4	1.0
08/27/2020 19:00	8.7	12.9	6.4	138.4	3,200,452.5	2,080.0	1.4	1.0
08/27/2020 20:00	8.8	12.9	6.5	142.5	3,222,763.3	2,094.5	1.4	1.0
08/27/2020 21:00	8.9	12.9	6.6	145.8	3,219,516.7	2,115.9	1.5	1.3
08/27/2020 22:00	8.8	12.9	6.5	144.1	3,218,147.3	2,115.0	1.5	1.3
08/27/2020 23:00	8.5	13.0	6.3	126.0	3,235,063.7	2,008.0	1.3	1.0
Average/Sum#:	8.5	13.0	6.4	130.6	3,233,055.6	2,033.2	1.3	1.0
Minimum:	7.9	12.8	5.9	113.4	3,154,491.6	1,924.3	1.1	0.8
Maximum:	8.9	13.2	6.6	145.8	3,309,657.1	2,115.9	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/28/2020 00:00	8.4	13.1	6.4	117.9	3,238,096.9	1,915.3	1.2	1.0
08/28/2020 01:00	7.4	13.7	6.1	96.3	2,920,345.7	1,514.1	1.0	0.6
08/28/2020 02:00	7.3	13.8	6.1	90.4	2,823,361.8	1,443.2	1.0	0.6
08/28/2020 03:00	7.4	13.8	6.1	86.0	2,514,850.1	1,285.5	1.1	0.5
08/28/2020 04:00	7.3	13.7	6.0	91.9	2,870,313.5	1,467.2	1.0	0.6
08/28/2020 05:00	7.5	13.7	6.1	100.0	3,109,962.8	1,589.7	1.0	0.6
08/28/2020 06:00	7.5	13.8	6.2	94.3	2,835,295.4	1,449.3	1.1	0.6
08/28/2020 07:00	7.9	13.8	6.6	88.9	2,683,680.5	1,371.8	1.0	0.5
08/28/2020 08:00	7.9	13.8	6.6	89.1	2,723,393.8	1,392.1	1.0	0.6
08/28/2020 09:00	7.9	13.8	6.6	91.4	2,782,474.7	1,422.3	1.0	0.6
08/28/2020 10:00	7.7	13.8	6.4	92.7	2,849,380.9	1,456.5	1.0	0.6
08/28/2020 11:00	8.1	13.7	6.6	97.2	2,945,631.8	1,505.7	1.0	0.6
08/28/2020 12:00	9.4	12.9	6.9	128.7	3,174,198.3	1,993.4	1.3	1.0
08/28/2020 13:00	9.4	12.8	6.8	143.7	3,143,589.8	2,066.0	1.5	1.2
08/28/2020 14:00	9.3	12.8	6.8	142.4	3,136,286.2	2,061.2	1.5	1.2
08/28/2020 15:00	9.1	12.8	6.6	140.7	3,134,764.6	2,060.2	1.5	1.2
08/28/2020 16:00	9.1	12.8	6.6	140.6	3,138,112.1	2,062.4	1.5	1.2
08/28/2020 17:00	9.2	12.8	6.7	138.5	3,122,135.4	2,051.9	1.4	1.0
08/28/2020 18:00	9.1	12.8	6.6	138.2	3,156,446.3	2,051.4	1.4	1.0
08/28/2020 19:00	8.9	12.9	6.6	131.4	3,187,892.6	2,002.0	1.3	1.0
08/28/2020 20:00	8.9	12.9	6.6	129.8	3,177,223.8	1,995.3	1.3	1.0
08/28/2020 21:00	8.9	12.9	6.6	129.0	3,212,025.2	1,993.7	1.3	1.0
08/28/2020 22:00	8.7	13.0	6.5	123.0	3,201,029.5	1,963.5	1.2	1.0
08/28/2020 23:00	8.8	12.9	6.5	133.4	3,202,249.4	2,034.4	1.4	1.0
Average/Sum#:	8.4	13.3	6.5	114.8	3,011,780.9	1,756.2	1.2	0.8
Minimum:	7.3	12.8	6.0	86.0	2,514,850.1	1,285.5	1.0	0.5
Maximum:	9.4	13.8	6.9	143.7	3,238,096.9	2,066.0	1.5	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/29/2020 00:00	8.8	12.9	6.5	134.2	3,211,378.9	2,040.2	1.4	1.0
08/29/2020 01:00	8.6	12.9	6.3	131.4	3,245,376.6	2,038.1	1.3	1.0
08/29/2020 02:00	8.6	12.9	6.3	128.4	3,253,913.4	2,019.7	1.3	1.0
08/29/2020 03:00	8.3	13.1	6.3	117.8	3,215,475.3	1,925.4	1.2	1.0
08/29/2020 04:00	7.4	13.7	6.1	98.9	3,083,133.6	1,598.5	1.0	0.6
08/29/2020 05:00	7.5	13.7	6.1	97.6	3,044,172.5	1,578.3	1.0	0.6
08/29/2020 06:00	7.7	13.7	6.3	94.0	2,993,253.1	1,551.9	1.0	0.6
08/29/2020 07:00	7.8	13.7	6.4	89.1	2,743,670.7	1,422.5	1.0	0.6
08/29/2020 08:00	7.7	13.7	6.3	85.9	2,692,679.6	1,376.4	1.0	0.6
08/29/2020 09:00	7.8	13.8	6.5	84.8	2,505,851.0	1,280.9	1.1	0.5
08/29/2020 10:00	7.9	13.8	6.6	85.3	2,530,500.6	1,293.5	1.1	0.5
08/29/2020 11:00	8.0	13.8	6.6	85.7	2,597,211.2	1,327.6	1.0	0.5
08/29/2020 12:00	8.1	13.8	6.7	85.6	2,516,415.1	1,286.3	1.1	0.5
08/29/2020 13:00	8.2	13.8	6.8	99.1	3,109,962.8	1,589.7	1.0	0.6
08/29/2020 14:00	8.1	13.7	6.6	99.9	3,079,083.2	1,596.4	1.0	0.6
08/29/2020 15:00	8.1	13.6	6.5	100.5	3,094,127.6	1,604.2	1.0	0.6
08/29/2020 16:00	8.3	13.6	6.7	103.8	3,186,515.5	1,652.1	1.0	0.7
08/29/2020 17:00	9.6	12.9	7.1	130.1	3,183,046.0	2,022.2	1.3	1.0
08/29/2020 18:00	9.2	12.9	6.8	138.1	3,134,764.6	2,060.2	1.4	1.0
08/29/2020 19:00	9.1	12.9	6.7	138.2	3,172,448.5	2,061.8	1.4	1.0
08/29/2020 20:00	9.0	12.8	6.6	145.1	3,169,239.3	2,106.0	1.5	1.3
08/29/2020 21:00	8.8	12.9	6.5	139.3	3,170,673.9	2,083.8	1.4	1.0
08/29/2020 22:00	8.7	13.0	6.5	127.0	3,210,091.9	1,992.5	1.3	1.0
08/29/2020 23:00	8.7	13.0	6.5	125.7	3,241,460.1	1,988.3	1.3	1.0
Average/Sum#:	8.3	13.4	6.5	111.1	3,016,018.5	1,729.0	1.2	0.8
Minimum:	7.4	12.8	6.1	84.8	2,505,851.0	1,280.9	1.0	0.5
Maximum:	9.6	13.8	7.1	145.1	3,253,913.4	2,106.0	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/30/2020 00:00	8.4	13.1	6.4	117.7	3,232,010.6	1,911.7	1.2	1.0
08/30/2020 01:00	8.1	13.5	6.5	108.7	3,307,920.7	1,739.2	1.0	0.7
08/30/2020 02:00	8.2	13.5	6.5	108.3	3,314,767.8	1,742.8	1.0	0.7
08/30/2020 03:00	8.2	13.5	6.5	108.4	3,318,191.4	1,744.6	1.0	0.7
08/30/2020 04:00	8.2	13.5	6.5	108.5	3,318,001.2	1,744.5	1.0	0.7
08/30/2020 05:00	8.3	13.5	6.6	108.8	3,326,560.1	1,749.0	1.0	0.7
08/30/2020 06:00	8.2	13.5	6.5	108.9	3,316,860.0	1,743.9	1.0	0.7
08/30/2020 07:00	8.3	13.5	6.6	108.3	3,306,018.7	1,738.2	1.0	0.7
08/30/2020 08:00	8.3	13.5	6.6	108.8	3,321,424.7	1,746.3	1.0	0.7
08/30/2020 09:00	8.6	13.5	6.9	109.7	3,273,487.1	1,745.0	1.1	0.7
08/30/2020 10:00	8.6	13.5	6.9	109.5	3,256,791.3	1,736.1	1.1	0.7
08/30/2020 11:00	8.7	13.5	6.9	109.1	3,239,532.8	1,726.9	1.1	0.7
08/30/2020 12:00	8.7	13.5	6.9	109.0	3,223,399.9	1,718.3	1.1	0.7
08/30/2020 13:00	8.1	13.6	6.5	102.1	3,084,438.2	1,621.7	1.0	0.6
08/30/2020 14:00	8.3	13.6	6.7	96.7	2,956,799.4	1,533.0	1.0	0.6
08/30/2020 15:00	9.5	12.9	7.0	133.9	3,170,217.4	2,037.2	1.4	1.0
08/30/2020 16:00	9.3	12.8	6.8	146.2	3,166,380.1	2,104.1	1.5	1.3
08/30/2020 17:00	9.0	12.9	6.6	139.2	3,178,449.4	2,065.7	1.4	1.0
08/30/2020 18:00	8.9	12.9	6.6	135.8	3,183,133.6	2,045.5	1.4	1.0
08/30/2020 19:00	8.8	13.0	6.6	130.6	3,205,408.5	2,013.0	1.3	1.0
08/30/2020 20:00	8.8	13.0	6.6	128.3	3,196,332.1	2,007.3	1.3	1.0
08/30/2020 21:00	8.8	13.0	6.6	127.3	3,227,008.3	2,003.0	1.3	1.0
08/30/2020 22:00	8.7	13.0	6.5	126.1	3,219,758.4	1,998.5	1.3	1.0
08/30/2020 23:00	8.6	13.1	6.5	119.4	3,204,954.1	1,919.1	1.2	1.0
Average/Sum#:	8.6	13.3	6.6	117.1	3,231,160.2	1,838.9	1.2	0.8
Minimum:	8.1	12.8	6.4	96.7	2,956,799.4	1,533.0	1.0	0.6
Maximum:	9.5	13.6	7.0	146.2	3,326,560.1	2,104.1	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/31/2020 00:00	7.5	13.6	6.1	99.9	3,103,771.4	1,609.2	1.0	0.6
08/31/2020 01:00	7.9	13.7	6.5	86.2	2,541,847.3	1,299.3	1.1	0.5
08/31/2020 02:00	7.9	13.8	6.6	85.3	2,514,850.1	1,285.5	1.1	0.5
08/31/2020 03:00	7.8	13.8	6.5	85.1	2,536,369.6	1,296.5	1.1	0.5
08/31/2020 04:00	7.8	13.7	6.4	101.0	3,147,747.3	1,632.0	1.0	0.7
08/31/2020 05:00	8.0	13.7	6.6	103.7	3,207,346.2	1,662.9	1.0	0.7
08/31/2020 06:00	8.2	13.6	6.6	104.7	3,250,357.7	1,685.2	1.0	0.7
08/31/2020 07:00	8.0	13.7	6.6	88.1	2,703,243.7	1,381.8	1.0	0.6
08/31/2020 08:00	7.7	13.7	6.3	87.1	2,748,043.5	1,404.7	1.0	0.6
08/31/2020 09:00	7.5	13.9	6.3	84.4	2,600,715.5	1,310.4	1.0	0.5
08/31/2020 10:00	7.4	13.9	6.2	85.9	2,578,487.2	1,299.2	1.1	0.5
08/31/2020 11:00	7.5	13.8	6.2	92.3	2,977,009.5	1,500.0	1.0	0.6
08/31/2020 12:00	7.7	13.8	6.4	93.1	2,884,007.8	1,474.2	1.0	0.6
08/31/2020 13:00	9.1	13.0	6.8	130.8	3,208,274.7	2,014.8	1.3	1.0
08/31/2020 14:00	9.1	12.9	6.7	149.0	3,217,843.0	2,114.8	1.5	1.3
08/31/2020 15:00	9.0	12.9	6.6	146.2	3,169,540.3	2,106.2	1.5	1.3
08/31/2020 16:00	8.8	13.0	6.6	133.9	3,193,119.9	2,028.6	1.4	1.0
08/31/2020 17:00	8.8	13.0	6.6	129.1	3,232,163.8	2,006.2	1.3	1.0
08/31/2020 18:00	8.8	13.0	6.6	129.7	3,227,652.7	2,003.4	1.3	1.0
08/31/2020 19:00	8.8	13.0	6.6	127.4	3,220,241.7	1,998.8	1.3	1.0
08/31/2020 20:00	8.7	13.0	6.5	126.7	3,215,408.5	1,995.8	1.3	1.0
08/31/2020 21:00	8.7	13.0	6.5	125.5	3,250,589.6	1,993.9	1.2	1.0
08/31/2020 22:00	8.6	13.1	6.5	125.9	3,247,166.1	1,991.8	1.3	1.0
08/31/2020 23:00	8.1	13.3	6.3	111.9	3,080,684.8	1,777.2	1.2	0.9
Average/Sum#:	8.2	13.4	6.5	109.7	3,002,353.4	1,703.0	1.2	0.8
Minimum:	7.4	12.9	6.1	84.4	2,514,850.1	1,285.5	1.0	0.5
Maximum:	9.1	13.9	6.8	149.0	3,250,589.6	2,114.8	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/01/2020 00:00	7.4	13.8	6.1	84.4	2,534,022.0	1,295.3	1.1	0.5
09/01/2020 01:00	7.1	13.8	5.9	90.7	2,920,590.9	1,492.9	1.0	0.6
09/01/2020 02:00	7.4	13.8	6.1	87.6	2,755,718.5	1,388.5	1.0	0.6
09/01/2020 03:00	7.4	13.8	6.1	84.6	2,575,113.2	1,297.5	1.0	0.5
09/01/2020 04:00	7.2	13.8	6.0	83.5	2,669,583.7	1,345.1	1.0	0.5
09/01/2020 05:00	8.1	13.7	6.6	102.9	3,209,082.1	1,663.8	1.0	0.7
09/01/2020 06:00	7.5	13.7	6.1	104.1	3,183,815.3	1,650.7	1.0	0.7
09/01/2020 07:00	8.0	13.7	6.6	104.9	3,224,319.4	1,671.7	1.0	0.7
09/01/2020 08:00	7.8	13.7	6.4	99.7	3,072,332.5	1,592.9	1.0	0.6
09/01/2020 09:00	7.9	13.6	6.4	101.8	3,125,759.4	1,620.6	1.0	0.6
09/01/2020 10:00	7.9	13.7	6.5	93.0	2,853,224.6	1,479.3	1.0	0.6
09/01/2020 11:00	7.9	13.9	6.7	86.2	2,598,532.4	1,309.3	1.0	0.5
09/01/2020 12:00	7.8	13.9	6.6	87.0	2,656,087.9	1,338.3	1.0	0.5
09/01/2020 13:00	7.6	13.9	6.4	91.9	2,949,224.1	1,486.0	1.0	0.6
09/01/2020 14:00	7.9	13.7	6.5	102.1	3,173,978.5	1,645.6	1.0	0.7
09/01/2020 15:00	8.0	13.7	6.6	101.4	3,111,679.4	1,613.3	1.0	0.6
09/01/2020 16:00	8.3	13.7	6.8	97.2	2,960,656.9	1,535.0	1.0	0.6
09/01/2020 17:00	9.5	13.0	7.1	129.3	3,186,981.1	2,024.7	1.3	1.0
09/01/2020 18:00	9.3	12.9	6.9	140.4	3,161,414.0	2,100.8	1.4	1.1
09/01/2020 19:00	9.1	12.9	6.7	137.1	3,162,000.9	2,078.1	1.4	1.0
09/01/2020 20:00	8.8	13.0	6.6	124.2	3,215,408.5	1,995.8	1.2	1.0
09/01/2020 21:00	8.6	13.0	6.4	121.8	3,239,177.7	1,986.9	1.2	1.0
09/01/2020 22:00	8.5	13.1	6.4	116.1	3,265,316.4	1,931.4	1.1	0.8
09/01/2020 23:00	8.0	13.3	6.2	108.7	3,150,921.0	1,771.7	1.1	0.7
Average/Sum#:	8.0	13.5	6.4	103.4	2,998,122.5	1,638.1	1.1	0.7
Minimum:	7.1	12.9	5.9	83.5	2,534,022.0	1,295.3	1.0	0.5
Maximum:	9.5	13.9	7.1	140.4	3,265,316.4	2,100.8	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/02/2020 00:00	7.6	13.7	6.2	84.8	2,508,394.2	1,282.2	1.1	0.5
09/02/2020 01:00	7.6	13.7	6.2	84.4	2,499,003.9	1,277.4	1.1	0.5
09/02/2020 02:00	7.6	13.7	6.2	84.8	2,532,456.9	1,294.5	1.1	0.5
09/02/2020 03:00	7.6	13.7	6.2	84.5	2,520,327.8	1,288.3	1.1	0.5
09/02/2020 04:00	7.6	13.7	6.2	85.4	2,567,866.4	1,312.6	1.1	0.5
09/02/2020 05:00	7.7	13.8	6.4	84.8	2,502,134.0	1,279.0	1.1	0.5
09/02/2020 06:00	7.8	13.7	6.4	85.2	2,516,219.5	1,286.2	1.1	0.5
09/02/2020 07:00	16.1	14.9	15.8	132.6	2,117,893.4	943.4	1.9	0.7
09/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	8.7	13.9	7.5	90.8	2,470,537.0	1,245.5	1.2	0.5
Minimum:	7.6	13.7	6.2	84.4	2,117,893.4	943.4	1.1	0.5
Maximum:	16.1	14.9	15.8	132.6	2,567,866.4	1,312.6	1.9	0.7
%SI	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2020 03:00	33.3	17.5	57.8	0.0	1,839,887.9	416.5	-0.3	0.0
09/03/2020 04:00	30.9	14.9	30.4	166.7	2,328,257.6	986.1	2.2	0.8
09/03/2020 05:00	7.3	13.7	6.0	97.1	3,026,620.8	1,569.2	1.0	0.6
09/03/2020 06:00	7.5	13.7	6.1	97.6	3,052,852.0	1,582.8	1.0	0.6
09/03/2020 07:00	7.8	13.7	6.4	101.9	3,164,720.5	1,640.8	1.0	0.7
09/03/2020 08:00	7.6	13.7	6.2	102.6	3,156,041.0	1,636.3	1.0	0.7
09/03/2020 09:00	7.6	13.7	6.2	95.2	2,997,083.1	1,532.0	1.0	0.6
09/03/2020 10:00	7.7	13.7	6.3	97.6	3,075,531.5	1,572.1	1.0	0.6
09/03/2020 11:00	8.0	13.7	6.6	96.2	2,936,354.5	1,522.4	1.0	0.6
09/03/2020 12:00	9.4	13.0	7.0	129.7	3,218,619.5	2,044.8	1.3	1.0
09/03/2020 13:00	9.2	12.9	6.8	140.7	3,184,368.2	2,092.8	1.4	1.0
09/03/2020 14:00	9.1	12.9	6.7	135.9	3,165,986.1	2,057.6	1.4	1.0
09/03/2020 15:00	9.2	12.9	6.8	141.1	3,144,108.1	2,089.3	1.5	1.3
09/03/2020 16:00	9.2	12.8	6.7	141.7	3,144,258.6	2,089.4	1.5	1.3
09/03/2020 17:00	9.1	12.9	6.7	140.8	3,149,977.1	2,093.2	1.5	1.3
09/03/2020 18:00	9.0	12.8	6.6	141.0	3,154,190.7	2,096.0	1.5	1.3
09/03/2020 19:00	8.9	12.9	6.6	135.8	3,161,062.3	2,054.4	1.4	1.0
09/03/2020 20:00	8.9	13.0	6.6	126.9	3,178,020.0	1,995.8	1.3	1.0
09/03/2020 21:00	8.8	13.0	6.6	126.5	3,180,408.5	1,997.3	1.3	1.0
09/03/2020 22:00	8.7	12.9	6.4	128.4	3,193,749.5	2,029.0	1.3	1.0
09/03/2020 23:00	8.8	12.9	6.5	138.1	3,190,150.2	2,096.6	1.4	1.0
Average/Sum#:	10.8	13.5	10.1	118.2	3,030,583.2	1,771.2	1.2	0.9
Minimum:	7.3	12.8	6.0	0.0	1,839,887.9	416.5	-0.3	0.0
Maximum:	33.3	17.5	57.8	166.7	3,218,619.5	2,096.6	2.2	1.3
%SI	12.50	12.50	12.50	12.50	12.50	12.50	12.50	12.50

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/04/2020 00:00	8.4	13.0	6.3	125.1	3,240,219.2	2,011.2	1.2	1.0
09/04/2020 01:00	8.5	13.1	6.4	122.0	3,228,255.0	1,980.2	1.2	1.0
09/04/2020 02:00	8.4	13.1	6.4	120.7	3,229,722.2	1,981.1	1.2	1.0
09/04/2020 03:00	8.4	13.1	6.4	120.4	3,273,089.3	1,983.8	1.2	1.0
09/04/2020 04:00	8.5	12.9	6.3	134.7	3,237,380.8	2,104.0	1.4	1.1
09/04/2020 05:00	8.6	12.9	6.3	142.6	3,237,471.4	2,127.7	1.4	1.1
09/04/2020 06:00	8.6	12.9	6.3	137.9	3,242,458.4	2,107.3	1.4	1.1
09/04/2020 07:00	8.8	12.9	6.5	135.6	3,223,686.5	2,095.1	1.4	1.0
09/04/2020 08:00	8.4	13.0	6.3	124.4	3,249,402.4	2,016.9	1.2	1.0
09/04/2020 09:00	8.7	13.0	6.5	123.5	3,233,145.8	1,983.2	1.2	1.0
09/04/2020 10:00	8.7	12.9	6.4	131.7	3,177,220.2	2,041.7	1.3	1.0
09/04/2020 11:00	8.8	12.9	6.5	133.9	3,178,757.1	2,065.9	1.4	1.0
09/04/2020 12:00	8.9	12.9	6.6	138.1	3,151,654.1	2,071.3	1.4	1.0
09/04/2020 13:00	9.0	12.9	6.6	138.6	3,153,175.7	2,072.3	1.4	1.0
09/04/2020 14:00	9.0	12.9	6.6	139.3	3,160,935.8	2,077.4	1.4	1.0
09/04/2020 15:00	9.0	12.8	6.6	139.3	3,125,598.3	2,077.0	1.5	1.2
09/04/2020 16:00	9.1	12.8	6.6	140.0	3,125,297.3	2,076.8	1.5	1.2
09/04/2020 17:00	9.1	12.8	6.6	139.4	3,130,714.8	2,080.4	1.5	1.2
09/04/2020 18:00	9.0	12.9	6.6	139.3	3,142,603.2	2,088.3	1.4	1.0
09/04/2020 19:00	8.9	12.8	6.5	138.6	3,150,880.0	2,093.8	1.4	1.0
09/04/2020 20:00	8.7	12.8	6.3	137.8	3,156,297.5	2,097.4	1.4	1.0
09/04/2020 21:00	8.6	12.9	6.3	135.1	3,166,870.0	2,081.3	1.4	1.0
09/04/2020 22:00	8.8	12.9	6.5	137.4	3,203,837.6	2,082.2	1.4	1.0
09/04/2020 23:00	8.6	13.0	6.4	127.3	3,218,147.3	2,021.0	1.3	1.0
Average/Sum#:	8.7	12.9	6.5	133.4	3,193,200.8	2,059.1	1.4	1.0
Minimum:	8.4	12.8	6.3	120.4	3,125,297.3	1,980.2	1.2	1.0
Maximum:	9.1	13.1	6.6	142.6	3,273,089.3	2,127.7	1.5	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/05/2020 00:00	8.4	13.0	6.3	122.2	3,217,180.6	1,996.9	1.2	1.0
09/05/2020 01:00	8.6	13.0	6.4	123.9	3,216,214.0	1,996.3	1.2	1.0
09/05/2020 02:00	8.7	13.0	6.5	124.3	3,217,019.5	1,996.8	1.2	1.0
09/05/2020 03:00	8.6	13.0	6.4	123.5	3,218,630.6	1,997.8	1.2	1.0
09/05/2020 04:00	8.5	13.0	6.3	124.1	3,238,930.3	2,010.4	1.2	1.0
09/05/2020 05:00	8.5	13.1	6.4	123.6	3,188,020.0	1,978.8	1.3	1.0
09/05/2020 06:00	7.3	13.7	6.0	102.6	3,162,984.6	1,639.9	1.0	0.7
09/05/2020 07:00	7.7	13.7	6.3	97.7	3,024,884.9	1,568.3	1.0	0.6
09/05/2020 08:00	7.8	13.7	6.4	100.1	3,110,715.0	1,612.8	1.0	0.6
09/05/2020 09:00	7.8	13.7	6.4	99.0	3,071,175.3	1,592.3	1.0	0.6
09/05/2020 10:00	8.1	13.7	6.6	101.1	3,126,530.9	1,621.0	1.0	0.6
09/05/2020 11:00	9.3	13.0	6.9	127.8	3,188,082.9	2,025.4	1.3	1.0
09/05/2020 12:00	9.2	12.9	6.8	140.1	3,140,195.5	2,086.7	1.5	1.3
09/05/2020 13:00	9.1	12.9	6.7	142.2	3,147,870.2	2,091.8	1.5	1.3
09/05/2020 14:00	9.0	12.9	6.6	142.3	3,149,525.6	2,092.9	1.5	1.3
09/05/2020 15:00	9.1	12.8	6.6	140.7	3,102,490.5	2,084.3	1.5	1.3
09/05/2020 16:00	9.1	12.8	6.6	139.6	3,093,857.2	2,078.5	1.5	1.2
09/05/2020 17:00	9.0	12.8	6.6	139.9	3,106,956.0	2,087.3	1.5	1.3
09/05/2020 18:00	9.0	12.8	6.6	140.9	3,145,011.0	2,089.9	1.5	1.3
09/05/2020 19:00	9.1	12.8	6.6	142.3	3,152,836.3	2,095.1	1.5	1.3
09/05/2020 20:00	8.9	12.9	6.6	140.9	3,160,812.1	2,100.4	1.5	1.3
09/05/2020 21:00	8.9	12.8	6.5	141.9	3,174,355.8	2,109.4	1.5	1.3
09/05/2020 22:00	8.8	12.9	6.5	141.3	3,186,846.2	2,117.7	1.4	1.1
09/05/2020 23:00	8.7	12.9	6.4	134.7	3,187,681.5	2,071.7	1.4	1.0
Average/Sum#:	8.6	13.1	6.5	127.4	3,155,366.9	1,964.3	1.3	1.0
Minimum:	7.3	12.8	6.0	97.7	3,024,884.9	1,568.3	1.0	0.6
Maximum:	9.3	13.7	6.9	142.3	3,238,930.3	2,117.7	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/06/2020 00:00	8.8	12.9	6.5	138.3	3,220,609.2	2,093.1	1.4	1.0
09/06/2020 01:00	8.7	13.0	6.5	130.7	3,225,230.5	2,049.0	1.3	1.0
09/06/2020 02:00	8.8	12.9	6.5	138.5	3,228,610.3	2,098.3	1.4	1.0
09/06/2020 03:00	8.7	12.9	6.4	140.3	3,216,321.4	2,113.8	1.4	1.1
09/06/2020 04:00	8.6	13.0	6.4	128.2	3,241,077.2	2,035.4	1.3	1.0
09/06/2020 05:00	8.7	13.0	6.5	126.1	3,255,202.3	2,020.5	1.3	1.0
09/06/2020 06:00	8.6	13.1	6.5	118.0	3,323,643.7	1,965.9	1.1	0.8
09/06/2020 07:00	9.1	13.0	6.8	134.4	3,259,702.2	2,070.9	1.3	1.0
09/06/2020 08:00	8.8	12.9	6.5	137.1	3,211,069.4	2,086.9	1.4	1.0
09/06/2020 09:00	8.9	12.9	6.6	141.4	3,219,532.1	2,092.4	1.4	1.0
09/06/2020 10:00	8.9	12.9	6.6	140.1	3,167,782.9	2,081.9	1.4	1.0
09/06/2020 11:00	9.0	12.9	6.6	140.8	3,161,848.7	2,078.0	1.4	1.0
09/06/2020 12:00	9.1	12.9	6.7	141.2	3,127,554.6	2,078.3	1.5	1.2
09/06/2020 13:00	9.1	12.9	6.7	141.6	3,129,962.4	2,079.9	1.5	1.2
09/06/2020 14:00	9.1	12.9	6.7	142.3	3,133,724.5	2,082.4	1.5	1.2
09/06/2020 15:00	9.1	12.8	6.6	141.5	3,131,015.8	2,080.6	1.5	1.2
09/06/2020 16:00	8.9	12.9	6.6	132.0	3,121,364.4	2,028.6	1.4	1.0
09/06/2020 17:00	9.0	12.9	6.6	137.7	3,114,311.8	2,069.5	1.4	1.0
09/06/2020 18:00	8.9	12.9	6.6	136.7	3,137,807.7	2,062.2	1.4	1.0
09/06/2020 19:00	8.9	12.9	6.6	133.4	3,143,983.0	2,043.3	1.4	1.0
09/06/2020 20:00	8.8	13.0	6.6	132.6	3,181,733.1	2,044.6	1.4	1.0
09/06/2020 21:00	8.9	12.9	6.6	138.9	3,203,068.2	2,081.7	1.4	1.0
09/06/2020 22:00	8.8	12.9	6.5	142.0	3,201,409.9	2,104.0	1.4	1.1
09/06/2020 23:00	8.8	12.9	6.5	140.0	3,163,219.8	2,102.0	1.4	1.1
Average/Sum#:	8.9	12.9	6.6	136.4	3,188,324.4	2,068.5	1.4	1.0
Minimum:	8.6	12.8	6.4	118.0	3,114,311.8	1,965.9	1.1	0.8
Maximum:	9.1	13.1	6.8	142.3	3,323,643.7	2,113.8	1.5	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/07/2020 00:00	8.8	12.9	6.5	140.7	3,163,972.3	2,102.5	1.5	1.3
09/07/2020 01:00	8.7	12.9	6.4	142.2	3,212,669.6	2,111.4	1.4	1.1
09/07/2020 02:00	8.8	12.9	6.5	142.1	3,212,821.8	2,111.5	1.4	1.1
09/07/2020 03:00	8.7	13.0	6.5	134.4	3,204,608.7	2,059.3	1.4	1.0
09/07/2020 04:00	8.6	13.0	6.4	126.4	3,238,124.8	2,009.9	1.3	1.0
09/07/2020 05:00	8.7	13.0	6.5	130.0	3,198,402.1	2,008.6	1.3	1.0
09/07/2020 06:00	7.4	13.7	6.1	108.0	3,101,746.2	1,585.5	1.1	0.6
09/07/2020 07:00	7.4	13.8	6.1	97.4	3,149,080.7	1,586.7	1.0	0.6
09/07/2020 08:00	7.3	13.8	6.1	97.1	3,182,224.7	1,603.4	1.0	0.6
09/07/2020 09:00	7.2	13.8	6.0	94.9	3,105,020.9	1,564.5	1.0	0.6
09/07/2020 10:00	7.4	13.8	6.1	92.0	2,941,914.8	1,503.8	1.0	0.6
09/07/2020 11:00	7.7	13.8	6.4	94.5	2,936,045.9	1,500.8	1.0	0.6
09/07/2020 12:00	9.0	13.1	6.8	117.8	3,224,326.4	1,930.7	1.2	1.0
09/07/2020 13:00	8.5	13.4	6.7	108.5	3,112,377.3	1,727.3	1.1	0.7
09/07/2020 14:00	8.5	13.5	6.8	104.6	3,149,866.3	1,656.1	1.0	0.7
09/07/2020 15:00	8.6	13.5	6.9	107.0	3,181,004.0	1,695.7	1.1	0.7
09/07/2020 16:00	9.0	13.3	7.0	113.8	3,080,853.7	1,754.8	1.2	0.9
09/07/2020 17:00	9.0	13.0	6.7	124.9	3,171,650.6	1,991.8	1.3	1.0
09/07/2020 18:00	8.9	13.0	6.6	124.8	3,161,618.7	1,985.5	1.3	1.0
09/07/2020 19:00	9.0	12.9	6.6	137.3	3,179,372.6	2,066.3	1.4	1.0
09/07/2020 20:00	8.9	12.9	6.6	134.6	3,164,755.1	2,056.8	1.4	1.0
09/07/2020 21:00	8.9	13.0	6.6	127.7	3,157,074.1	2,005.7	1.3	1.0
09/07/2020 22:00	8.8	13.0	6.6	128.4	3,162,268.5	2,009.0	1.3	1.0
09/07/2020 23:00	8.8	13.0	6.6	127.7	3,199,835.2	2,009.5	1.3	1.0
Average/Sum#:	8.4	13.3	6.5	119.0	3,149,651.5	1,859.9	1.2	0.9
Minimum:	7.2	12.9	6.0	92.0	2,936,045.9	1,500.8	1.0	0.6
Maximum:	9.0	13.8	7.0	142.2	3,238,124.8	2,111.5	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/08/2020 00:00	8.7	13.0	6.5	126.7	3,206,841.6	2,013.9	1.3	1.0
09/08/2020 01:00	8.8	13.0	6.6	134.3	3,240,341.4	2,058.6	1.3	1.0
09/08/2020 02:00	8.8	13.0	6.6	134.8	3,220,508.4	2,046.0	1.4	1.0
09/08/2020 03:00	8.9	13.0	6.6	141.8	3,230,610.6	2,099.6	1.4	1.0
09/08/2020 04:00	8.6	13.1	6.5	133.5	3,271,013.5	2,054.2	1.3	1.0
09/08/2020 05:00	8.6	13.1	6.5	131.4	3,259,068.9	2,022.9	1.3	1.0
09/08/2020 06:00	7.5	13.7	6.1	100.5	3,183,911.7	1,627.5	1.0	0.7
09/08/2020 07:00	7.4	13.9	6.2	100.0	3,233,826.2	1,629.4	1.0	0.7
09/08/2020 08:00	7.0	13.9	5.9	91.2	2,988,917.6	1,506.0	1.0	0.6
09/08/2020 09:00	7.9	13.8	6.6	100.6	3,177,847.1	1,624.4	1.0	0.6
09/08/2020 10:00	7.2	13.8	6.0	95.3	3,111,768.8	1,567.9	1.0	0.6
09/08/2020 11:00	7.6	13.7	6.2	103.4	3,286,227.3	1,679.8	1.0	0.7
09/08/2020 12:00	7.9	13.8	6.6	95.8	2,996,691.8	1,531.8	1.0	0.6
09/08/2020 13:00	9.3	13.1	7.0	131.6	3,287,101.8	2,040.3	1.3	1.0
09/08/2020 14:00	9.2	13.0	6.9	147.5	3,256,152.7	2,116.2	1.5	1.3
09/08/2020 15:00	9.1	13.0	6.8	150.1	3,225,603.1	2,119.9	1.5	1.3
09/08/2020 16:00	9.1	12.9	6.7	150.0	3,227,733.3	2,121.3	1.5	1.3
09/08/2020 17:00	9.0	12.9	6.6	149.2	3,237,775.7	2,127.9	1.5	1.3
09/08/2020 18:00	8.9	13.0	6.6	150.0	3,246,905.2	2,133.9	1.5	1.3
09/08/2020 19:00	8.8	13.1	6.7	138.4	3,266,942.9	2,075.5	1.4	1.0
09/08/2020 20:00	8.8	13.0	6.6	136.5	3,281,841.5	2,061.0	1.3	1.0
09/08/2020 21:00	8.8	13.0	6.6	137.3	3,295,535.7	2,069.6	1.4	1.0
09/08/2020 22:00	8.7	13.1	6.6	128.3	3,326,711.3	2,016.3	1.2	1.0
09/08/2020 23:00	8.8	13.1	6.7	132.1	3,291,672.3	2,019.1	1.3	1.0
Average/Sum#:	8.5	13.3	6.5	126.7	3,222,981.3	1,931.8	1.3	1.0
Minimum:	7.0	12.9	5.9	91.2	2,988,917.6	1,506.0	1.0	0.6
Maximum:	9.3	13.9	7.0	150.1	3,326,711.3	2,133.9	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/09/2020 00:00	8.4	13.3	6.5	135.6	3,181,189.3	1,928.1	1.4	1.0
09/09/2020 01:00	7.7	13.7	6.3	104.3	3,253,165.4	1,662.9	1.0	0.7
09/09/2020 02:00	6.7	13.9	5.6	86.2	2,805,104.7	1,392.9	1.0	0.6
09/09/2020 03:00	7.6	13.8	6.3	100.8	3,287,809.3	1,656.6	1.0	0.7
09/09/2020 04:00	6.7	13.9	5.6	90.1	2,974,627.9	1,498.8	1.0	0.6
09/09/2020 05:00	6.8	13.9	5.7	93.9	3,120,501.4	1,572.3	1.0	0.6
09/09/2020 06:00	7.0	13.9	5.9	93.4	3,125,264.6	1,574.7	0.9	0.5
09/09/2020 07:00	7.0	13.9	5.9	94.1	3,078,227.9	1,551.0	1.0	0.6
09/09/2020 08:00	6.8	13.9	5.7	91.0	2,992,291.5	1,507.7	1.0	0.6
09/09/2020 09:00	6.8	13.9	5.7	86.7	2,881,631.4	1,430.9	1.0	0.6
09/09/2020 10:00	6.8	13.9	5.7	85.8	2,855,652.6	1,418.0	0.9	0.4
09/09/2020 11:00	6.8	13.9	5.7	89.3	2,957,361.3	1,490.1	1.0	0.6
09/09/2020 12:00	7.3	13.8	6.1	93.1	3,002,214.9	1,512.7	1.0	0.6
09/09/2020 13:00	9.0	13.1	6.8	131.1	3,348,894.7	2,054.2	1.3	1.0
09/09/2020 14:00	8.8	13.1	6.7	131.5	3,300,312.8	2,024.4	1.3	1.0
09/09/2020 15:00	8.8	13.1	6.7	126.9	3,299,157.8	1,999.6	1.2	1.0
09/09/2020 16:00	8.8	13.1	6.7	125.3	3,285,628.6	1,991.4	1.2	1.0
09/09/2020 17:00	8.6	13.1	6.5	123.2	3,282,823.7	1,989.7	1.2	1.0
09/09/2020 18:00	8.6	13.1	6.5	123.4	3,322,858.2	1,989.7	1.2	1.0
09/09/2020 19:00	8.5	13.2	6.5	124.0	3,327,367.2	1,992.4	1.2	1.0
09/09/2020 20:00	8.5	13.2	6.5	124.0	3,332,043.3	1,995.2	1.2	1.0
09/09/2020 21:00	8.5	13.2	6.5	123.8	3,364,557.4	1,990.1	1.2	1.0
09/09/2020 22:00	8.5	13.2	6.5	122.9	3,365,402.7	1,990.6	1.2	1.0
09/09/2020 23:00	8.1	13.2	6.2	113.9	3,326,661.2	1,919.1	1.1	0.8
Average/Sum#:	7.8	13.5	6.2	108.9	3,169,614.6	1,755.5	1.1	0.8
Minimum:	6.7	13.1	5.6	85.8	2,805,104.7	1,392.9	0.9	0.4
Maximum:	9.0	13.9	6.8	135.6	3,365,402.7	2,054.2	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/10/2020 00:00	7.0	13.8	5.8	92.0	2,957,565.4	1,511.8	1.0	0.6
09/10/2020 01:00	6.8	13.8	5.7	89.0	2,906,701.1	1,485.8	1.0	0.6
09/10/2020 02:00	7.1	13.8	5.9	83.3	2,597,738.5	1,308.9	1.0	0.5
09/10/2020 03:00	6.8	13.8	5.7	94.7	3,105,658.9	1,587.5	1.0	0.6
09/10/2020 04:00	6.8	13.8	5.7	93.9	3,047,360.5	1,557.7	1.0	0.6
09/10/2020 05:00	6.7	13.8	5.6	92.7	3,035,035.7	1,551.4	1.0	0.6
09/10/2020 06:00	7.0	13.8	5.8	95.1	3,130,112.9	1,600.0	1.0	0.6
09/10/2020 07:00	7.2	13.8	6.0	99.5	3,202,888.0	1,637.2	1.0	0.7
09/10/2020 08:00	7.1	13.8	5.9	101.5	3,272,728.6	1,672.9	1.0	0.7
09/10/2020 09:00	7.1	13.8	5.9	98.1	3,210,010.1	1,617.4	1.0	0.6
09/10/2020 10:00	7.2	13.8	6.0	101.4	3,273,706.8	1,673.4	1.0	0.7
09/10/2020 11:00	7.1	13.8	5.9	89.6	2,913,500.0	1,468.0	1.0	0.6
09/10/2020 12:00	7.2	13.8	6.0	88.1	2,865,867.8	1,444.0	1.0	0.6
09/10/2020 13:00	7.3	13.8	6.1	88.7	2,885,516.1	1,453.9	1.0	0.6
09/10/2020 14:00	7.5	13.8	6.2	98.0	3,122,874.5	1,596.3	1.0	0.6
09/10/2020 15:00	7.8	13.7	6.4	96.7	3,061,837.3	1,565.1	1.0	0.6
09/10/2020 16:00	8.9	13.1	6.7	125.0	3,274,052.0	2,032.2	1.2	1.0
09/10/2020 17:00	8.5	13.1	6.4	123.2	3,283,684.0	2,014.2	1.2	1.0
09/10/2020 18:00	8.5	13.1	6.4	121.3	3,287,773.5	1,992.7	1.2	1.0
09/10/2020 19:00	8.3	13.1	6.3	120.2	3,283,483.7	1,990.1	1.2	1.0
09/10/2020 20:00	8.4	13.2	6.4	119.4	3,319,518.1	1,987.7	1.2	1.0
09/10/2020 21:00	8.2	13.2	6.3	118.7	3,355,427.9	1,984.7	1.1	0.8
09/10/2020 22:00	8.3	13.2	6.4	119.3	3,310,332.9	1,982.2	1.2	1.0
09/10/2020 23:00	7.9	13.4	6.2	112.0	3,257,095.9	1,831.4	1.1	0.7
Average/Sum#:	7.5	13.6	6.1	102.6	3,123,352.9	1,689.4	1.1	0.7
Minimum:	6.7	13.1	5.6	83.3	2,597,738.5	1,308.9	1.0	0.5
Maximum:	8.9	13.8	6.7	125.0	3,355,427.9	2,032.2	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/11/2020 00:00	7.6	13.7	6.2	90.9	2,756,846.9	1,409.2	1.0	0.6
09/11/2020 01:00	7.5	13.8	6.2	84.3	2,519,154.0	1,287.7	1.1	0.5
09/11/2020 02:00	7.4	13.8	6.1	83.8	2,516,610.8	1,286.4	1.1	0.5
09/11/2020 03:00	7.4	13.8	6.1	84.1	2,514,850.1	1,285.5	1.1	0.5
09/11/2020 04:00	7.4	13.8	6.1	83.9	2,517,197.6	1,286.7	1.1	0.5
09/11/2020 05:00	7.1	13.8	5.9	89.5	2,893,593.7	1,479.1	1.0	0.6
09/11/2020 06:00	7.6	13.8	6.3	85.0	2,564,792.9	1,292.3	1.0	0.5
09/11/2020 07:00	7.5	13.8	6.2	84.4	2,617,585.2	1,318.9	1.0	0.5
09/11/2020 08:00	7.4	13.8	6.1	85.4	2,663,431.2	1,342.0	1.0	0.5
09/11/2020 09:00	7.2	13.8	6.0	94.9	3,063,793.6	1,566.1	1.0	0.6
09/11/2020 10:00	7.1	13.8	5.9	93.9	3,029,362.4	1,548.5	1.0	0.6
09/11/2020 11:00	7.3	13.8	6.1	93.5	3,002,169.5	1,534.6	1.0	0.6
09/11/2020 12:00	7.6	13.8	6.3	98.0	3,094,312.2	1,581.7	1.0	0.6
09/11/2020 13:00	7.6	13.8	6.3	85.1	2,571,540.8	1,295.7	1.0	0.5
09/11/2020 14:00	7.8	13.8	6.5	85.1	2,578,685.7	1,299.3	1.0	0.5
09/11/2020 15:00	7.9	13.8	6.6	86.1	2,647,950.7	1,334.2	1.0	0.5
09/11/2020 16:00	7.9	13.7	6.5	102.0	3,176,100.2	1,646.7	1.0	0.7
09/11/2020 17:00	7.7	13.7	6.3	101.8	3,154,305.1	1,635.4	1.0	0.7
09/11/2020 18:00	8.6	13.4	6.8	112.1	3,219,048.2	1,786.5	1.1	0.7
09/11/2020 19:00	8.7	13.1	6.6	124.5	3,259,713.4	2,023.3	1.2	1.0
09/11/2020 20:00	8.5	13.1	6.4	121.2	3,290,743.3	1,994.5	1.2	1.0
09/11/2020 21:00	8.4	13.2	6.4	117.6	3,304,877.5	1,954.8	1.1	0.8
09/11/2020 22:00	7.7	13.6	6.2	95.8	2,771,302.2	1,477.3	1.1	0.6
09/11/2020 23:00	29.1	16.9	42.9	201.5	1,146,270.5	368.3	5.4	0.8
Average/Sum#:	8.6	13.8	7.8	99.4	2,786,426.6	1,459.8	1.2	0.6
Minimum:	7.1	13.1	5.9	83.8	1,146,270.5	368.3	1.0	0.5
Maximum:	29.1	16.9	42.9	201.5	3,304,877.5	2,023.3	5.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2020 17:00	38.2	17.3	62.6	59.7	1,815,292.9	450.7	0.8	0.1
09/12/2020 18:00	34.2	17.0	51.7	266.7	1,846,560.7	512.4	4.2	0.8
09/12/2020 19:00	30.8	15.3	32.5	230.2	2,351,352.4	927.2	3.0	1.1
09/12/2020 20:00	7.0	13.8	5.8	91.6	2,892,419.9	1,478.5	1.0	0.6
09/12/2020 21:00	7.1	13.8	5.9	89.7	2,964,506.1	1,493.7	1.0	0.6
09/12/2020 22:00	7.2	13.8	6.0	87.8	2,849,576.5	1,456.6	1.0	0.6
09/12/2020 23:00	7.4	13.8	6.1	83.9	2,649,249.3	1,354.2	1.0	0.5
Average/Sum#:	18.8	15.0	24.4	129.9	2,481,279.7	1,096.2	1.7	0.6
Minimum:	7.0	13.8	5.8	59.7	1,815,292.9	450.7	0.8	0.1
Maximum:	38.2	17.3	62.6	266.7	2,964,506.1	1,493.7	4.2	1.1
%SI	70.83	70.83	70.83	70.83	70.83	70.83	70.83	70.83

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/13/2020 00:00	7.4	13.8	6.1	83.8	2,644,749.7	1,351.9	1.0	0.5
09/13/2020 01:00	7.4	13.8	6.1	86.1	2,648,943.1	1,334.7	1.0	0.5
09/13/2020 02:00	29.4	17.2	46.9	186.7	1,040,428.5	311.5	5.5	0.7
09/13/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2020 17:00	37.1	17.2	59.2	71.0	1,804,901.3	461.3	1.0	0.2
09/13/2020 18:00	34.1	17.0	51.6	264.3	1,854,488.9	514.6	4.2	0.8
09/13/2020 19:00	32.2	14.9	31.7	221.3	2,406,881.4	1,019.4	2.8	1.1
09/13/2020 20:00	7.2	13.7	5.9	91.6	2,884,985.9	1,474.7	1.0	0.6
09/13/2020 21:00	7.4	13.7	6.1	85.2	2,703,830.6	1,382.1	1.0	0.6
09/13/2020 22:00	7.4	13.7	6.1	85.3	2,695,222.8	1,377.7	1.0	0.6
09/13/2020 23:00	7.5	13.7	6.1	84.3	2,626,751.6	1,342.7	1.0	0.5
Average/Sum#:	17.7	14.9	22.6	126.0	2,331,118.4	1,057.1	2.0	0.6
Minimum:	7.2	13.7	5.9	71.0	1,040,428.5	311.5	1.0	0.2
Maximum:	37.1	17.2	59.2	264.3	2,884,985.9	1,474.7	5.5	1.1
%SI	58.33	58.33	58.33	58.33	58.33	58.33	58.33	58.33

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/14/2020 00:00	7.6	13.7	6.2	84.4	2,624,795.3	1,341.7	1.0	0.5
09/14/2020 01:00	7.6	13.7	6.2	86.9	2,594,081.0	1,326.0	1.1	0.5
09/14/2020 02:00	28.6	17.2	45.6	186.7	1,032,078.4	309.0	5.5	0.6
09/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2020 09:00	13.0	18.5	32.0	0.0	1,652,438.8	181.0	-0.6	0.0
09/14/2020 10:00	48.2	16.2	60.5	155.9	1,866,882.7	627.1	2.4	0.6
09/14/2020 11:00	12.5	13.9	10.5	133.7	2,670,578.9	1,326.1	1.6	0.8
09/14/2020 12:00	7.8	13.8	6.5	85.7	2,672,560.7	1,346.6	1.0	0.5
09/14/2020 13:00	7.8	13.8	6.5	98.4	3,128,939.1	1,599.4	1.0	0.6
09/14/2020 14:00	7.6	13.8	6.3	93.9	3,025,038.6	1,524.2	1.0	0.6
09/14/2020 15:00	8.2	13.7	6.7	98.7	3,091,182.1	1,580.1	1.0	0.6
09/14/2020 16:00	8.6	13.4	6.8	112.1	3,174,752.6	1,785.1	1.1	0.7
09/14/2020 17:00	8.8	13.0	6.6	136.0	3,236,919.2	2,103.7	1.4	1.1
09/14/2020 18:00	8.6	12.9	6.3	137.9	3,240,765.9	2,106.2	1.4	1.1
09/14/2020 19:00	8.4	13.0	6.3	133.6	3,245,224.6	2,085.4	1.3	1.0
09/14/2020 20:00	8.4	12.9	6.2	136.0	3,229,533.5	2,098.9	1.4	1.0
09/14/2020 21:00	8.1	13.1	6.1	122.1	3,242,958.0	2,012.9	1.2	1.0
09/14/2020 22:00	8.0	13.2	6.1	115.6	3,292,197.7	1,947.3	1.1	0.8
09/14/2020 23:00	8.0	13.2	6.1	116.2	3,284,251.6	1,942.6	1.1	0.8
Average/Sum#:	12.0	14.1	13.2	113.0	2,794,732.2	1,513.5	1.4	0.7
Minimum:	7.6	12.9	6.1	0.0	1,032,078.4	181.0	-0.6	0.0
Maximum:	48.2	18.5	60.5	186.7	3,292,197.7	2,106.2	5.5	1.1
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/15/2020 00:00	7.2	13.7	5.9	90.0	2,822,579.3	1,442.8	1.0	0.6
09/15/2020 01:00	7.4	13.8	6.1	84.2	2,593,689.8	1,325.8	1.0	0.5
09/15/2020 02:00	7.6	13.8	6.3	84.0	2,548,121.7	1,283.9	1.0	0.5
09/15/2020 03:00	7.6	13.8	6.3	84.0	2,550,304.8	1,285.0	1.0	0.5
09/15/2020 04:00	7.5	13.8	6.2	83.9	2,603,097.1	1,311.6	1.0	0.5
09/15/2020 05:00	6.9	13.8	5.7	93.9	3,062,815.5	1,565.6	1.0	0.6
09/15/2020 06:00	7.1	13.8	5.9	96.0	3,140,677.0	1,605.4	1.0	0.6
09/15/2020 07:00	7.3	13.8	6.1	87.7	2,792,843.2	1,427.6	1.0	0.6
09/15/2020 08:00	7.3	13.8	6.1	86.4	2,772,301.8	1,417.1	1.0	0.6
09/15/2020 09:00	7.7	13.8	6.4	84.8	2,559,434.3	1,289.6	1.0	0.5
09/15/2020 10:00	7.4	13.8	6.1	96.6	3,147,492.9	1,585.9	1.0	0.6
09/15/2020 11:00	7.6	13.8	6.3	98.9	3,198,697.5	1,611.7	1.0	0.6
09/15/2020 12:00	7.8	13.8	6.5	99.2	3,181,827.8	1,603.2	1.0	0.6
09/15/2020 13:00	8.3	13.7	6.8	103.6	3,206,960.5	1,662.7	1.0	0.7
09/15/2020 14:00	9.0	13.0	6.7	130.7	3,254,665.3	2,067.7	1.3	1.0
09/15/2020 15:00	8.7	13.0	6.5	135.5	3,249,115.0	2,087.9	1.4	1.0
09/15/2020 16:00	8.5	13.1	6.4	127.0	3,267,768.8	2,028.3	1.3	1.0
09/15/2020 17:00	8.5	13.1	6.4	125.6	3,256,974.5	2,021.6	1.2	1.0
09/15/2020 18:00	8.4	13.1	6.4	124.9	3,239,091.4	2,010.5	1.2	1.0
09/15/2020 19:00	8.3	13.1	6.3	125.5	3,265,513.3	2,026.9	1.2	1.0
09/15/2020 20:00	8.4	13.0	6.3	135.2	3,237,996.3	2,104.4	1.4	1.1
09/15/2020 21:00	8.2	13.0	6.1	127.8	3,258,911.6	2,046.6	1.3	1.0
09/15/2020 22:00	13.7	14.5	12.6	138.9	2,466,776.4	1,224.9	1.8	0.9
09/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	8.1	13.6	6.5	106.3	2,985,985.0	1,653.8	1.1	0.7
Minimum:	6.9	13.0	5.7	83.9	2,466,776.4	1,224.9	1.0	0.5
Maximum:	13.7	14.5	12.6	138.9	3,267,768.8	2,104.4	1.8	1.1
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT2 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2020 11:00	37.7	17.0	57.0	54.2	1,873,068.2	492.4	0.7	0.1
09/16/2020 12:00	25.5	14.3	22.8	185.4	2,548,814.8	1,209.8	2.3	1.1
09/16/2020 13:00	8.1	13.7	6.6	106.7	3,212,168.1	1,665.4	1.0	0.7
09/16/2020 14:00	8.3	13.7	6.8	106.2	3,211,782.4	1,665.2	1.0	0.7
09/16/2020 15:00	8.9	13.0	6.6	129.9	3,286,940.7	2,040.2	1.3	1.0
09/16/2020 16:00	8.7	12.9	6.4	141.0	3,215,069.9	2,089.5	1.4	1.0
09/16/2020 17:00	8.6	12.9	6.3	140.9	3,227,581.1	2,121.2	1.4	1.1
09/16/2020 18:00	8.5	12.9	6.3	138.0	3,244,304.8	2,108.5	1.4	1.1
09/16/2020 19:00	8.2	13.1	6.2	121.5	3,258,741.0	1,998.9	1.2	1.0
09/16/2020 20:00	8.2	13.1	6.2	123.6	3,246,663.6	2,015.2	1.2	1.0
09/16/2020 21:00	8.2	13.1	6.2	122.0	3,274,717.6	2,008.7	1.2	1.0
09/16/2020 22:00	8.2	13.1	6.2	120.1	3,285,133.6	1,991.1	1.2	1.0
09/16/2020 23:00	8.0	13.2	6.1	115.0	3,267,852.3	1,932.9	1.1	0.8
Average/Sum#:	11.9	13.5	11.5	123.4	3,088,679.9	1,795.3	1.3	0.9
Minimum:	8.0	12.9	6.1	54.2	1,873,068.2	492.4	0.7	0.1
Maximum:	37.7	17.0	57.0	185.4	3,286,940.7	2,121.2	2.3	1.1
%SI	45.83	45.83	45.83	45.83	45.83	45.83	45.83	45.83

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/17/2020 00:00	7.3	13.7	6.0	92.6	2,740,805.1	1,401.0	1.1	0.6
09/17/2020 01:00	7.4	13.8	6.1	87.6	2,558,084.7	1,307.6	1.1	0.5
09/17/2020 02:00	7.6	13.8	6.3	87.9	2,519,740.9	1,288.0	1.1	0.5
09/17/2020 03:00	7.6	13.8	6.3	88.0	2,521,305.9	1,288.8	1.1	0.5
09/17/2020 04:00	7.1	13.7	5.8	92.5	2,853,684.8	1,458.7	1.0	0.6
09/17/2020 05:00	7.0	13.7	5.7	98.7	3,069,271.3	1,568.9	1.0	0.6
09/17/2020 06:00	7.3	13.7	6.0	98.1	3,002,952.0	1,535.0	1.0	0.6
09/17/2020 07:00	7.4	13.7	6.1	103.7	3,112,836.6	1,613.9	1.1	0.6
09/17/2020 08:00	7.3	13.7	6.0	102.2	3,061,145.7	1,587.1	1.1	0.6
09/17/2020 09:00	7.4	13.7	6.1	102.7	3,133,829.9	1,601.9	1.0	0.6
09/17/2020 10:00	7.4	13.8	6.1	90.5	2,770,149.9	1,416.0	1.0	0.6
09/17/2020 11:00	7.6	13.8	6.3	87.9	2,783,844.1	1,423.0	1.0	0.6
09/17/2020 12:00	7.9	13.7	6.5	99.9	3,162,587.8	1,616.6	1.0	0.6
09/17/2020 13:00	9.1	13.0	6.8	130.8	3,255,137.5	2,068.0	1.3	1.0
09/17/2020 14:00	9.0	12.8	6.6	141.6	3,188,652.0	2,118.9	1.4	1.1
09/17/2020 15:00	8.8	12.8	6.4	139.7	3,181,880.1	2,114.4	1.4	1.1
09/17/2020 16:00	8.7	12.8	6.3	139.8	3,174,205.3	2,109.3	1.4	1.1
09/17/2020 17:00	8.6	12.9	6.3	134.2	3,196,759.7	2,077.6	1.4	1.0
09/17/2020 18:00	8.3	13.0	6.2	124.9	3,220,535.8	2,022.5	1.3	1.0
09/17/2020 19:00	8.5	12.9	6.3	132.4	3,235,887.6	2,079.4	1.3	1.0
09/17/2020 20:00	8.3	13.0	6.2	124.5	3,259,874.5	2,023.4	1.2	1.0
09/17/2020 21:00	8.3	13.0	6.2	125.5	3,276,790.9	2,033.9	1.2	1.0
09/17/2020 22:00	8.3	13.0	6.2	129.2	3,260,331.9	2,071.3	1.3	1.0
09/17/2020 23:00	11.1	13.3	8.6	139.2	2,918,853.8	1,769.1	1.5	1.1
Average/Sum#:	8.1	13.4	6.3	112.3	3,019,131.2	1,733.1	1.2	0.8
Minimum:	7.0	12.8	5.7	87.6	2,519,740.9	1,288.0	1.0	0.5
Maximum:	11.1	13.8	8.6	141.6	3,276,790.9	2,118.9	1.5	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/18/2020 00:00	3.1	19.3	11.4	148.5	1,441.5	0.2	3,619.9	0.3
09/18/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2020 10:00	23.2	17.9	45.6	0.0	1,881,246.7	329.7	-0.4	-0.1
09/18/2020 11:00	40.0	15.4	42.9	175.5	2,115,760.7	834.3	2.5	0.8
09/18/2020 12:00	7.4	13.7	6.1	102.6	3,098,370.9	1,606.4	1.1	0.6
09/18/2020 13:00	7.9	13.6	6.4	95.1	2,951,398.9	1,530.2	1.0	0.6
09/18/2020 14:00	8.9	13.0	6.6	122.8	3,265,914.1	2,003.3	1.2	1.0
09/18/2020 15:00	8.6	13.0	6.4	128.0	3,253,338.3	2,043.1	1.3	1.0
09/18/2020 16:00	8.6	13.0	6.4	126.4	3,271,152.1	2,030.4	1.2	1.0
09/18/2020 17:00	8.4	13.0	6.3	122.7	3,281,401.7	2,012.8	1.2	1.0
09/18/2020 18:00	8.4	13.0	6.3	121.9	3,274,554.5	2,008.6	1.2	1.0
09/18/2020 19:00	8.2	13.0	6.1	120.2	3,299,157.8	1,999.6	1.2	1.0
09/18/2020 20:00	8.3	13.1	6.3	120.4	3,293,383.1	1,996.1	1.2	1.0
09/18/2020 21:00	8.2	13.1	6.2	119.5	3,288,433.4	1,993.1	1.2	1.0
09/18/2020 22:00	11.6	14.0	9.9	129.4	2,772,133.4	1,457.5	1.5	0.9
09/18/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	11.5	14.2	12.4	116.6	2,789,120.5	1,560.4	259.7	0.8
Minimum:	3.1	13.0	6.1	0.0	1,441.5	0.2	-0.4	-0.1
Maximum:	40.0	19.3	45.6	175.5	3,299,157.8	2,043.1	3,619.9	1.0
%SI	41.67	41.67	41.67	41.67	41.67	41.67	41.67	41.67

Daily Summary Report

CT2 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/19/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2020 13:00	32.9	17.5	57.1	0.0	1,876,111.4	411.0	-0.2	0.0
09/19/2020 14:00	38.8	15.3	40.9	205.5	2,174,088.0	857.3	2.9	0.9
09/19/2020 15:00	7.2	13.8	6.0	97.0	2,994,539.9	1,530.7	1.0	0.6
09/19/2020 16:00	8.5	13.1	6.4	123.4	3,280,749.6	2,012.4	1.2	1.0
09/19/2020 17:00	8.6	12.9	6.3	144.1	3,245,383.6	2,132.9	1.5	1.3
09/19/2020 18:00	8.5	13.0	6.3	140.1	3,288,952.8	2,113.5	1.4	1.1
09/19/2020 19:00	8.5	13.0	6.3	139.7	3,282,261.3	2,109.2	1.4	1.1
09/19/2020 20:00	8.4	13.0	6.3	139.1	3,270,123.2	2,101.4	1.4	1.1
09/19/2020 21:00	8.5	13.0	6.3	133.2	3,257,026.4	2,069.2	1.3	1.0
09/19/2020 22:00	8.5	13.0	6.3	133.0	3,260,961.5	2,071.7	1.3	1.0
09/19/2020 23:00	8.1	13.2	6.2	117.7	3,304,032.2	1,954.3	1.1	0.8
Average/Sum#:	13.3	13.7	14.0	124.8	3,021,293.6	1,760.3	1.3	0.9
Minimum:	7.2	12.9	6.0	0.0	1,876,111.4	411.0	-0.2	0.0
Maximum:	38.8	17.5	57.1	205.5	3,304,032.2	2,132.9	2.9	1.3
%SI	54.17	54.17	54.17	54.17	54.17	54.17	54.17	54.17

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/20/2020 00:00	8.1	13.2	6.2	115.5	3,323,250.6	1,941.4	1.1	0.8
09/20/2020 01:00	8.2	13.2	6.3	115.9	3,330,953.6	1,945.9	1.1	0.8
09/20/2020 02:00	8.2	13.2	6.3	116.9	3,334,377.2	1,947.9	1.1	0.8
09/20/2020 03:00	8.2	13.2	6.3	116.6	3,329,241.9	1,944.9	1.1	0.8
09/20/2020 04:00	8.0	13.2	6.1	113.8	3,354,916.4	1,935.4	1.1	0.8
09/20/2020 05:00	7.7	13.3	6.0	111.4	3,296,672.5	1,901.8	1.1	0.8
09/20/2020 06:00	20.6	15.8	23.8	88.6	436,970.9	666.9	6.6	1.7
09/20/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2020 14:00	35.0	17.4	59.0	106.6	1,853,430.3	433.1	1.5	0.3
09/20/2020 15:00	28.9	15.1	29.4	223.7	2,299,410.3	940.3	3.0	1.1
09/20/2020 16:00	7.6	13.7	6.2	98.1	3,053,430.6	1,583.1	1.0	0.6
09/20/2020 17:00	8.8	13.1	6.7	126.8	3,250,369.1	2,017.5	1.3	1.0
09/20/2020 18:00	8.8	12.9	6.5	144.8	3,216,943.4	2,137.7	1.5	1.3
09/20/2020 19:00	8.6	12.9	6.3	143.0	3,211,525.9	2,134.1	1.5	1.3
09/20/2020 20:00	8.4	12.9	6.2	137.6	3,237,534.7	2,104.1	1.4	1.1
09/20/2020 21:00	8.3	13.1	6.3	124.8	3,192,369.9	1,981.5	1.3	1.0
09/20/2020 22:00	20.5	15.9	24.2	171.2	1,633,490.7	632.2	3.3	0.8
09/20/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	12.7	13.9	13.2	128.5	2,994,527.8	1,640.5	1.5	0.9
Minimum:	7.6	12.9	6.0	88.6	1,633,490.7	433.1	1.0	0.3
Maximum:	35.0	17.4	59.0	223.7	3,354,916.4	2,137.7	3.3	1.3
%SI	33.33	33.33	33.33	33.33	37.50	33.33	37.50	37.50

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/21/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2020 08:00	30.1	17.6	53.8	0.0	1,846,834.1	391.1	-0.2	0.0
09/21/2020 09:00	35.3	17.0	53.4	223.3	1,864,579.4	517.4	3.5	0.7
09/21/2020 10:00	33.0	15.4	35.4	239.7	2,207,816.4	870.6	3.3	1.1
09/21/2020 11:00	6.8	13.8	5.7	91.5	2,907,874.9	1,486.4	1.0	0.6
09/21/2020 12:00	7.7	13.7	6.3	102.1	3,209,660.7	1,664.1	1.0	0.7
09/21/2020 13:00	7.6	13.7	6.2	97.6	3,081,400.5	1,575.1	1.0	0.6
09/21/2020 14:00	7.7	13.7	6.3	92.7	2,852,902.3	1,458.3	1.0	0.6
09/21/2020 15:00	8.0	13.7	6.6	95.1	2,954,239.7	1,510.1	1.0	0.6
09/21/2020 16:00	8.8	13.1	6.7	118.9	3,229,036.7	1,957.1	1.2	1.0
09/21/2020 17:00	8.7	13.1	6.6	123.3	3,196,719.8	1,984.2	1.2	1.0
09/21/2020 18:00	8.5	13.1	6.4	121.0	3,243,555.9	1,965.9	1.2	1.0
09/21/2020 19:00	8.5	13.0	6.3	134.0	3,292,650.5	2,019.7	1.3	1.0
09/21/2020 20:00	8.5	13.0	6.3	132.5	3,240,971.0	2,059.0	1.3	1.0
09/21/2020 21:00	8.3	13.1	6.3	129.0	3,186,141.0	2,000.9	1.3	1.0
09/21/2020 22:00	20.8	15.9	24.5	171.4	1,623,672.2	628.4	3.3	0.8
09/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	13.9	14.2	15.8	124.8	2,795,870.3	1,472.6	1.5	0.8
Minimum:	6.8	13.0	5.7	0.0	1,623,672.2	391.1	-0.2	0.0
Maximum:	35.3	17.6	53.8	239.7	3,292,650.5	2,059.0	3.5	1.1
%SI	37.50	37.50	37.50	37.50	37.50	37.50	37.50	37.50

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2020 08:00	30.5	17.6	54.5	0.0	1,859,111.7	393.7	-0.2	0.0
09/22/2020 09:00	33.8	17.0	51.1	203.1	1,879,715.2	521.6	3.2	0.6
09/22/2020 10:00	34.8	15.3	36.7	243.3	2,168,508.9	855.1	3.4	1.1
09/22/2020 11:00	6.9	13.7	5.7	93.6	2,936,045.9	1,500.8	1.0	0.6
09/22/2020 12:00	8.1	13.3	6.3	112.7	3,231,841.5	1,817.2	1.1	0.7
09/22/2020 13:00	8.6	13.1	6.5	129.0	3,213,362.6	1,947.6	1.3	1.0
09/22/2020 14:00	7.5	13.7	6.1	96.2	3,013,711.8	1,540.5	1.0	0.6
09/22/2020 15:00	7.5	13.8	6.2	91.3	2,876,783.5	1,449.5	1.0	0.6
09/22/2020 16:00	7.9	13.7	6.5	94.9	2,958,152.3	1,512.1	1.0	0.6
09/22/2020 17:00	8.6	13.1	6.5	116.9	3,290,168.9	1,946.1	1.1	0.8
09/22/2020 18:00	8.3	13.2	6.4	115.7	3,314,520.5	1,936.3	1.1	0.8
09/22/2020 19:00	8.2	13.2	6.3	116.4	3,309,385.2	1,933.3	1.1	0.8
09/22/2020 20:00	8.2	13.2	6.3	114.7	3,313,835.8	1,935.9	1.1	0.8
09/22/2020 21:00	13.9	14.7	13.2	136.2	2,484,135.8	1,179.1	1.7	0.8
09/22/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	13.8	14.2	15.6	118.9	2,846,377.1	1,462.1	1.4	0.7
Minimum:	6.9	13.1	5.7	0.0	1,859,111.7	393.7	-0.2	0.0
Maximum:	34.8	17.6	54.5	243.3	3,314,520.5	1,947.6	3.4	1.1
%SI	41.67	41.67	41.67	41.67	41.67	41.67	41.67	41.67

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/23/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/23/2020 08:00	33.7	17.5	58.5	0.4	1,905,266.9	431.3	-0.2	0.0
09/23/2020 09:00	33.7	17.1	52.3	243.9	1,872,507.7	519.6	3.8	0.8
09/23/2020 10:00	33.7	15.2	34.9	235.8	2,224,825.5	909.8	3.3	1.2
09/23/2020 11:00	7.1	13.8	5.9	86.6	2,729,917.7	1,375.5	1.0	0.6
09/23/2020 12:00	7.3	13.8	6.1	88.8	2,890,477.8	1,456.4	1.0	0.6
09/23/2020 13:00	7.6	13.8	6.3	93.2	3,029,801.8	1,526.6	1.0	0.6
09/23/2020 14:00	7.5	13.9	6.3	91.2	2,896,630.3	1,459.5	1.0	0.6
09/23/2020 15:00	7.9	13.7	6.5	95.5	3,012,733.6	1,540.0	1.0	0.6
09/23/2020 16:00	8.7	13.1	6.6	121.4	3,247,818.2	1,992.2	1.2	1.0
09/23/2020 17:00	8.6	13.1	6.5	122.6	3,242,275.3	1,988.8	1.2	1.0
09/23/2020 18:00	8.4	13.2	6.4	119.5	3,272,089.3	1,959.3	1.2	1.0
09/23/2020 19:00	8.5	13.1	6.4	134.1	3,299,497.6	2,023.9	1.3	1.0
09/23/2020 20:00	8.3	13.2	6.4	119.3	3,280,627.3	1,916.5	1.2	1.0
09/23/2020 21:00	21.4	16.0	25.8	169.6	1,608,810.3	610.9	3.3	0.8
09/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	14.5	14.3	16.8	123.0	2,750,948.5	1,407.9	1.5	0.8
Minimum:	7.1	13.1	5.9	0.4	1,608,810.3	431.3	-0.2	0.0
Maximum:	33.7	17.5	58.5	243.9	3,299,497.6	2,023.9	3.8	1.2
%SI	41.67	41.67	41.67	41.67	41.67	41.67	41.67	41.67

Daily Summary Report

CT2 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2020 13:00	35.9	17.4	60.5	24.9	1,848,722.9	445.5	0.3	0.0
09/24/2020 14:00	32.6	14.7	31.0	205.3	2,343,313.4	1,026.7	2.7	1.0
09/24/2020 15:00	7.4	13.7	6.1	100.9	3,184,972.5	1,651.3	1.0	0.7
09/24/2020 16:00	8.1	13.5	6.5	109.7	3,209,565.6	1,757.8	1.1	0.7
09/24/2020 17:00	8.5	13.1	6.4	130.5	3,239,622.4	2,081.8	1.3	1.0
09/24/2020 18:00	8.4	13.1	6.4	129.7	3,259,859.7	2,071.0	1.3	1.0
09/24/2020 19:00	8.3	13.1	6.3	128.6	3,282,637.6	2,061.5	1.3	1.0
09/24/2020 20:00	14.1	14.6	13.2	140.8	2,450,656.5	1,199.0	1.8	0.8
09/24/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	15.4	14.2	17.1	121.3	2,852,418.8	1,536.8	1.4	0.8
Minimum:	7.4	13.1	6.1	24.9	1,848,722.9	445.5	0.3	0.0
Maximum:	35.9	17.4	60.5	205.3	3,282,637.6	2,081.8	2.7	1.0
%SI	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67

Daily Summary Report

CT2 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2020 08:00	2.8	20.5	41.3	0.0	0.0	34.5	0.0	0.0
09/27/2020 09:00	40.5	17.0	61.3	49.0	1,857,975.8	502.0	0.8	0.2
09/27/2020 10:00	37.1	16.1	45.6	259.6	2,059,672.5	706.9	3.8	1.1
09/27/2020 11:00	6.5	13.9	5.5	93.5	2,827,660.0	1,404.1	1.1	0.6
09/27/2020 12:00	6.9	13.9	5.8	85.6	2,767,042.8	1,374.0	1.0	0.5
09/27/2020 13:00	8.2	13.8	6.8	102.6	3,147,294.5	1,585.8	1.0	0.6
09/27/2020 14:00	8.5	13.8	7.1	104.8	3,133,047.4	1,601.5	1.0	0.6
09/27/2020 15:00	7.9	13.7	6.5	102.8	3,173,151.9	1,622.0	1.0	0.6
09/27/2020 16:00	8.4	13.6	6.8	102.7	3,047,159.5	1,602.1	1.1	0.6
09/27/2020 17:00	9.1	13.1	6.9	136.6	3,303,656.7	2,074.7	1.3	1.0
09/27/2020 18:00	9.1	13.1	6.9	147.1	3,290,353.3	2,114.4	1.5	1.3
09/27/2020 19:00	9.0	13.1	6.8	147.1	3,302,802.6	2,122.4	1.4	1.1
09/27/2020 20:00	8.9	13.1	6.7	145.7	3,300,624.0	2,121.0	1.4	1.1
09/27/2020 21:00	8.9	13.1	6.7	149.1	3,306,537.4	2,124.8	1.5	1.3
09/27/2020 22:00	14.9	14.5	13.7	154.0	2,491,374.2	1,273.5	1.9	0.9
09/27/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	12.4	14.4	15.6	118.7	2,733,890.2	1,484.2	1.3	0.8
Minimum:	2.8	13.1	5.5	0.0	0.0	34.5	0.0	0.0
Maximum:	40.5	20.5	61.3	259.6	3,306,537.4	2,124.8	3.8	1.3
%SI	37.50	37.50	37.50	37.50	37.50	37.50	37.50	37.50

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/28/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2020 10:00	41.8	17.3	68.5	61.2	1,874,036.5	451.6	0.8	0.1
09/28/2020 11:00	31.7	14.9	31.2	223.6	2,311,730.0	979.1	3.0	1.2
09/28/2020 12:00	7.7	13.6	6.2	106.6	3,310,149.5	1,716.2	1.0	0.7
09/28/2020 13:00	8.4	13.6	6.8	110.9	3,151,958.5	1,657.2	1.1	0.7
09/28/2020 14:00	9.1	13.1	6.9	145.4	3,288,822.2	2,089.4	1.4	1.0
09/28/2020 15:00	9.1	13.0	6.8	164.6	3,230,948.4	2,170.6	1.7	1.5
09/28/2020 16:00	9.0	13.0	6.7	159.0	3,226,780.6	2,167.8	1.6	1.3
09/28/2020 17:00	8.9	13.0	6.6	154.9	3,275,358.8	2,152.6	1.5	1.3
09/28/2020 18:00	8.8	13.0	6.6	151.7	3,266,077.2	2,146.5	1.5	1.3
09/28/2020 19:00	8.8	13.1	6.7	144.1	3,261,875.5	2,096.1	1.4	1.0
09/28/2020 20:00	8.8	13.1	6.7	143.8	3,276,814.7	2,105.7	1.4	1.1
09/28/2020 21:00	8.7	13.1	6.6	138.7	3,305,886.0	2,076.1	1.4	1.0
09/28/2020 22:00	14.7	14.5	13.6	146.9	2,518,532.6	1,250.6	1.8	0.9
09/28/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	13.5	13.7	13.8	142.4	3,022,997.7	1,773.8	1.5	1.0
Minimum:	7.7	13.0	6.2	61.2	1,874,036.5	451.6	0.8	0.1
Maximum:	41.8	17.3	68.5	223.6	3,310,149.5	2,170.6	3.0	1.5
%SI	45.83	45.83	45.83	45.83	45.83	45.83	45.83	45.83

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2020 10:00	39.5	17.3	64.7	90.6	1,851,139.5	459.6	1.3	0.2
09/29/2020 11:00	30.2	14.9	29.7	221.6	2,375,715.2	1,006.2	2.9	1.1
09/29/2020 12:00	7.4	13.7	6.1	104.7	3,334,157.1	1,704.3	1.0	0.7
09/29/2020 13:00	8.3	13.5	6.6	110.9	3,217,782.1	1,762.3	1.1	0.7
09/29/2020 14:00	9.0	13.0	6.7	137.8	3,289,451.8	2,089.8	1.4	1.0
09/29/2020 15:00	8.9	13.0	6.6	145.7	3,275,881.0	2,105.1	1.4	1.1
09/29/2020 16:00	8.8	13.0	6.6	146.7	3,272,770.4	2,127.0	1.5	1.3
09/29/2020 17:00	8.7	13.0	6.5	145.3	3,309,494.1	2,126.7	1.4	1.1
09/29/2020 18:00	8.6	13.0	6.4	139.4	3,292,285.1	2,091.6	1.4	1.0
09/29/2020 19:00	8.6	13.0	6.4	141.2	3,298,756.6	2,119.8	1.4	1.1
09/29/2020 20:00	8.5	13.0	6.3	138.3	3,313,220.0	2,104.9	1.4	1.1
09/29/2020 21:00	8.5	13.0	6.3	137.4	3,329,771.3	2,091.1	1.3	1.0
09/29/2020 22:00	8.5	13.1	6.4	132.2	3,332,212.3	2,068.3	1.3	1.0
09/29/2020 23:00	8.4	13.1	6.4	130.4	3,362,099.9	2,062.3	1.3	1.0
Average/Sum#:	12.3	13.5	12.3	137.3	3,132,481.2	1,851.4	1.4	1.0
Minimum:	7.4	13.0	6.1	90.6	1,851,139.5	459.6	1.0	0.2
Maximum:	39.5	17.3	64.7	221.6	3,362,099.9	2,127.0	2.9	1.3
%SI	41.67	41.67	41.67	41.67	41.67	41.67	41.67	41.67

Daily Summary Report

CT2 - NH3 slip



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:53 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/30/2020 00:00	8.1	13.2	6.2	123.6	3,360,330.7	1,987.6	1.2	1.0
09/30/2020 01:00	7.0	13.7	5.7	99.8	3,207,583.2	1,639.6	1.0	0.7
09/30/2020 02:00	7.2	13.7	5.9	102.0	3,278,793.2	1,676.0	1.0	0.7
09/30/2020 03:00	7.3	13.7	6.0	101.8	3,240,645.0	1,656.5	1.0	0.7
09/30/2020 04:00	8.0	13.6	6.5	105.0	3,231,651.3	1,699.1	1.0	0.7
09/30/2020 05:00	8.6	13.2	6.6	122.3	3,381,309.2	2,024.7	1.2	1.0
09/30/2020 06:00	8.5	13.2	6.5	136.7	3,366,947.0	2,016.1	1.3	1.0
09/30/2020 07:00	7.3	13.7	6.0	101.2	3,219,125.5	1,645.5	1.0	0.7
09/30/2020 08:00	7.4	13.7	6.1	102.5	3,282,119.0	1,677.7	1.0	0.7
09/30/2020 09:00	7.7	13.7	6.3	104.0	3,291,705.0	1,682.6	1.0	0.7
09/30/2020 10:00	8.2	13.6	6.6	104.8	3,143,673.1	1,675.8	1.1	0.7
09/30/2020 11:00	8.9	13.1	6.7	132.5	3,306,682.2	2,076.6	1.3	1.0
09/30/2020 12:00	8.8	13.0	6.6	143.4	3,276,155.5	2,129.2	1.4	1.1
09/30/2020 13:00	8.7	13.0	6.5	150.1	3,260,584.4	2,166.7	1.5	1.3
09/30/2020 14:00	8.6	13.0	6.4	144.6	3,235,189.0	2,126.2	1.5	1.3
09/30/2020 15:00	8.6	13.0	6.4	144.0	3,249,339.7	2,135.5	1.4	1.1
09/30/2020 16:00	8.6	13.0	6.4	143.4	3,232,450.2	2,124.4	1.4	1.1
09/30/2020 17:00	8.6	13.1	6.5	137.7	3,263,898.5	2,097.4	1.4	1.0
09/30/2020 18:00	8.7	13.0	6.5	142.3	3,261,230.3	2,119.5	1.4	1.1
09/30/2020 19:00	8.7	13.0	6.5	149.2	3,268,816.0	2,148.3	1.5	1.3
09/30/2020 20:00	8.7	13.0	6.5	144.2	3,277,848.1	2,130.3	1.4	1.1
09/30/2020 21:00	8.6	13.0	6.4	141.4	3,284,906.7	2,110.9	1.4	1.1
09/30/2020 22:00	8.4	13.1	6.4	135.6	3,299,525.7	2,096.2	1.3	1.0
09/30/2020 23:00	8.3	13.2	6.4	122.6	3,271,922.3	1,959.2	1.2	1.0
Average/Sum#:	8.2	13.3	6.4	126.4	3,270,518.0	1,950.1	1.2	1.0
Minimum:	7.0	13.0	5.7	99.8	3,143,673.1	1,639.6	1.0	0.7
Maximum:	8.9	13.7	6.7	150.1	3,381,309.2	2,166.7	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Excess Emission Report



CT1 - NH3 LbPerHr 1-Hour Block Average

From: 07/01/2020 00:00 To: 09/30/2020 23:59
Generated: 10/06/2020 08:53

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA

Tag Name: CT1_NH3slip_LbPerHr_1H

Total Operating Time: 1,885.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 323.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,885.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 - NH3 Ppmvdc 1-Hour Block Average

From: 07/01/2020 00:00 To: 09/30/2020 23:59
Generated: 10/06/2020 08:54

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H

Total Operating Time: 1,885.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 323.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,885.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT2 - NH3 LbPerHr 1-Hour Block Average

From: 07/01/2020 00:00 To: 09/30/2020 23:59
Generated: 10/06/2020 08:55

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA

Tag Name: CT2_NH3slip_LbPerHr_1H

Total Operating Time: 1,865.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 343.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,865.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT2 - NH3 Ppmvdc 1-Hour Block Average

From: 07/01/2020 00:00 To: 09/30/2020 23:59
Generated: 10/06/2020 08:55

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H

Total Operating Time: 1,865.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 343.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,865.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

ATTACHMENT 9
Quarterly/Annual Emissions
(Fuel Use, Hours of Operation, and NH₃ Injection)

FCD: AQ-23, 26
Title V: #6, 14

Emissions Limits per AQ-26

Quarterly and Annual Combustion Emissions from CGS Facility					
Pollutant	1 st Quarter Emissions (tons)	2 nd Quarter Emissions (tons)	3 rd Quarter Emissions (tons)	4 th Quarter Emissions (tons)	Annual Emissions (tons)
NO _x	45.56	43.58	51.30	44.27	184.7
CO	54.29	52.49	107.15	53.95	267.9
VOC's	12.30	11.63	11.84	11.76	47.5
PM10	25.54	25.78	26.02	26.02	103.4
SO ₂	4.07	3.85	3.89	3.89	15.7

Notes

1. Emissions based on CT1 and CT2.
2. VOC Mass Emissions based on Average Source Test Results (lb/MMBtu). CT1 EF = 0.0009 prior to 10/30/2013 and 0.0007 after 10/30/2013. CT2 EF = 0.0007 prior to 11/01/2014 and 0.0003 after 11/01/2014.
3. PM10 based on 2010 lb/MMBtu Source Test Results. CT1 EF = 0.0025; CT2 EF = 0.003

Quarterly Emissions

Cumulative Emissions Report



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 08:56 **Location:** Maxwell, CA

Month	Plantwide	Plantwide	Plantwide	Plantwide	Plantwide
	NOx, Tons 1 Day(s)	CO, Tons 1 Day(s)	VOC, Tons 1 Day(s)	PM10, Tons 1 Day(s)	SO2, Tons 1 Day(s)
July	3.5	1.5	0.5	2.9	0.0
August	4.4	1.4	0.7	3.7	0.0
September	4.0	1.5	0.4	2.4	0.0
Quarter 3	11.9	4.4	1.6	9.0	0.0
YTD	11.9	4.4	1.6	9.0	0.0

Cumulative Emissions Report

CT1



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 08:57 Location: Maxwell, CA

Month	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlowCT, 100scf	GasFlowDB, 100scf	GasFlow, Total, 100scf	Uniton, TF	NH3, Inj, LbPerHr
	1 Day(s)	1 Day(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
July	9,383,089	841,464	10,224,548.4	633	134.3
August	11,641,653	1,555,775	13,197,426.2	744	157.2
September	7,669,212	823,155	8,492,361.7	508	150.1
Quarter 3	28,693,954	3,220,394	31,914,336.3	1,885	147.2
YTD	28,693,954	3,220,394	31,914,336.3	1,885	147.2

Cumulative Emissions Report

CT2



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 08:58 **Location:** Maxwell, CA

Month	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlowCT, 100scf	GasFlowDB, 100scf	GasFlow, Total, 100scf	Uniton, TF	NH3, Inj, LbPerHr
	1 Day(s)	1 Day(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
July	9,223,913	784,545	10,008,457.9	623	68,749.0
August	11,644,997	1,461,636	13,106,628.1	744	88,788.2
September	7,430,136	787,980	8,218,114.3	498	59,402.9
Quarter 3	28,299,046	3,034,161	31,333,200.3	1,865	216,940.1
YTD	28,299,046	3,034,161	31,333,200.3	1,865	216,940.1

Monthly Summary By Day Report

VOC PM10



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:00 Location: Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
07/01/2020	0.0	0.0	0.0	0.0
07/02/2020	0.0	0.0	0.0	0.0
07/03/2020	12.4	44.1	7.0	71.8
07/04/2020	0.0	0.0	0.0	0.0
07/05/2020	9.9	34.5	5.9	60.4
07/06/2020	15.3	54.7	10.3	105.6
07/07/2020	25.9	92.6	11.3	112.2
07/08/2020	25.8	91.6	11.1	111.2
07/09/2020	27.1	96.3	11.7	116.5
07/10/2020	29.5	104.7	12.2	124.2
07/11/2020	28.2	100.7	11.7	119.8
07/12/2020	26.9	95.4	11.3	113.8
07/13/2020	29.8	106.7	12.4	126.2
07/14/2020	28.9	102.5	12.1	121.5
07/15/2020	21.9	78.5	9.6	94.6
07/16/2020	26.3	93.3	11.2	111.5
07/17/2020	25.6	92.2	11.1	109.4
07/18/2020	27.2	97.7	11.7	115.9
07/19/2020	25.8	92.6	11.0	110.2
07/20/2020	29.1	103.0	12.3	121.9
07/21/2020	28.9	101.4	12.0	120.3
07/22/2020	26.1	92.6	11.1	110.3
07/23/2020	22.2	79.4	9.8	96.0
07/24/2020	25.0	87.8	2.9	28.0
07/25/2020	27.5	96.7	5.5	55.1
07/26/2020	28.4	100.9	11.9	119.6
07/27/2020	30.3	107.5	12.6	126.9
07/28/2020	31.0	110.1	12.7	129.9
07/29/2020	35.1	124.7	14.4	147.2
07/30/2020	34.9	123.9	14.4	146.1
07/31/2020	34.9	123.0	14.4	145.9
Monthly Avg/Sum*:	739.9 *	2,629.1 *	305.6 *	3,072.0 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	35.1	124.7	14.4	147.2
Jul 2020 - Jul 2020	739.9	2,629.1	305.6	3,072.0
QTD:	739.9 *	2,629.1 *	305.6 *	3,072.0 *
YTD 2020:	3,346.5 *	11,947.9 *	1,534.3 *	15,475.1 *

Monthly Summary By Day Report

VOC PM10



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:00 Location: Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
08/01/2020	30.8	109.6	12.9	129.9
08/02/2020	26.8	95.0	11.3	113.1
08/03/2020	29.2	102.9	12.0	122.6
08/04/2020	26.0	92.9	11.1	110.9
08/05/2020	23.4	83.3	10.2	99.9
08/06/2020	21.8	77.7	9.6	93.5
08/07/2020	22.8	81.4	9.8	97.7
08/08/2020	25.8	91.9	11.0	109.6
08/09/2020	27.0	95.6	11.5	113.9
08/10/2020	27.3	97.6	11.7	116.7
08/11/2020	22.4	80.0	9.8	96.0
08/12/2020	28.2	100.9	11.9	119.5
08/13/2020	32.1	114.1	13.4	134.8
08/14/2020	35.9	127.8	14.4	150.0
08/15/2020	35.9	128.0	14.4	149.8
08/16/2020	35.5	127.8	14.4	149.2
08/17/2020	36.0	128.4	14.4	150.0
08/18/2020	35.9	128.3	14.4	149.5
08/19/2020	36.0	128.2	14.4	150.0
08/20/2020	34.8	124.2	14.4	147.3
08/21/2020	35.8	125.6	14.4	147.8
08/22/2020	32.9	115.9	13.5	136.9
08/23/2020	33.4	119.1	13.8	140.3
08/24/2020	36.0	127.8	14.4	149.6
08/25/2020	35.6	125.6	14.4	147.4
08/26/2020	34.4	123.0	14.4	144.4
08/27/2020	34.9	124.4	14.4	146.3
08/28/2020	30.1	107.7	12.5	126.6
08/29/2020	29.4	105.3	12.5	124.8
08/30/2020	31.0	112.0	13.0	132.1
08/31/2020	28.9	103.8	12.2	122.5
Monthly Avg/Sum*:	956.0 *	3,405.8 *	396.5 *	4,022.6 *
Daily Min:	21.8	77.7	9.6	93.5
Daily Max:	36.0	128.4	14.4	150.0
Jul 2020 - Aug 2020	1,695.9	6,034.9	702.1	7,094.6
QTD:	1,695.9 *	6,034.9 *	702.1 *	7,094.6 *
YTD 2020:	4,302.5 *	15,353.7 *	1,930.8 *	19,497.7 *

Monthly Summary By Day Report

VOC PM10



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:00 Location: Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
09/01/2020	27.5	99.2	11.7	118.0
09/02/2020	25.1	88.5	2.9	28.2
09/03/2020	30.6	109.1	11.0	111.0
09/04/2020	35.3	126.6	14.4	148.0
09/05/2020	33.4	120.6	13.9	141.6
09/06/2020	35.7	127.0	14.4	148.6
09/07/2020	31.6	113.0	13.4	134.0
09/08/2020	32.9	117.6	13.7	139.1
09/09/2020	29.8	106.2	12.7	126.8
09/10/2020	28.4	101.9	12.2	121.8
09/11/2020	24.2	87.0	10.5	104.3
09/12/2020	0.0	0.0	2.2	22.8
09/13/2020	0.0	0.0	3.0	30.8
09/14/2020	13.3	47.1	8.0	80.5
09/15/2020	26.3	94.5	11.2	112.5
09/16/2020	21.5	76.6	6.9	69.5
09/17/2020	29.3	105.2	12.3	124.7
09/18/2020	19.2	69.1	6.4	63.7
09/19/2020	22.8	81.1	5.6	57.3
09/20/2020	22.0	78.9	7.6	75.0
09/21/2020	10.5	37.3	6.4	64.3
09/22/2020	7.0	25.4	6.1	58.7
09/23/2020	8.9	31.9	5.8	57.2
09/24/2020	12.6	44.0	3.4	34.6
09/25/2020	0.0	0.0	0.0	0.0
09/26/2020	0.0	0.0	0.0	0.0
09/27/2020	10.5	37.8	6.4	64.7
09/28/2020	19.7	70.7	6.6	66.9
09/29/2020	22.3	80.0	7.4	77.6
09/30/2020	33.2	118.0	13.7	140.3
Monthly Avg/Sum*:	613.6 *	2,194.3 *	249.8 *	2,522.5 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	35.7	127.0	14.4	148.6
Jul 2020 - Sep 2020	2,309.5	8,229.2	951.9	9,617.1
QTD:	2,309.5 *	8,229.2 *	951.9 *	9,617.1 *
YTD 2020:	4,916.1 *	17,548.0 *	2,180.6 *	22,020.2 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:00 Location: Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
07/01/2020	0.0	0.00	0.0	0.0	0.00	0.0
07/02/2020	0.0	0.00	0.0	0.0	0.00	0.0
07/03/2020	151.6	157.10	10.7	185.4	192.66	14.4
07/04/2020	0.0	0.00	0.0	0.0	0.00	0.0
07/05/2020	125.2	140.28	8.4	153.5	216.87	12.0
07/06/2020	94.9	127.08	13.3	63.1	136.79	21.0
07/07/2020	53.6	97.50	22.5	23.2	110.40	22.5
07/08/2020	53.2	97.30	22.7	15.2	110.90	22.4
07/09/2020	59.6	114.00	23.4	21.2	119.30	23.5
07/10/2020	56.2	118.80	25.3	21.9	134.60	24.9
07/11/2020	58.2	122.90	24.4	23.7	125.70	24.1
07/12/2020	55.7	113.70	23.3	20.8	114.40	23.0
07/13/2020	68.5	128.10	25.9	26.4	142.50	25.1
07/14/2020	68.8	121.80	24.8	25.9	132.90	24.2
07/15/2020	47.2	93.50	19.3	17.7	65.90	19.3
07/16/2020	66.2	108.80	23.0	23.8	109.60	22.5
07/17/2020	62.0	107.00	22.4	23.5	102.70	22.0
07/18/2020	63.6	139.60	23.6	25.9	119.20	23.4
07/19/2020	62.6	103.30	22.7	24.1	106.50	22.2
07/20/2020	66.8	116.00	24.9	25.8	135.50	24.4
07/21/2020	64.9	114.50	24.6	23.9	129.40	24.1
07/22/2020	61.5	98.40	22.7	22.4	106.40	22.3
07/23/2020	47.3	79.50	19.7	18.8	68.90	19.7
07/24/2020	63.2	93.80	21.1	6.3	18.95	5.8
07/25/2020	62.3	116.30	22.8	91.8	161.50	10.8
07/26/2020	61.9	113.10	24.3	21.8	125.50	24.1
07/27/2020	68.2	119.50	26.0	22.4	143.80	25.5
07/28/2020	67.7	130.50	26.5	22.7	146.00	26.0
07/29/2020	95.8	151.60	30.3	32.0	196.20	29.6
07/30/2020	94.1	148.50	29.9	32.9	195.10	29.2
07/31/2020	98.4	147.80	30.0	35.1	194.20	29.1
Monthly Avg/Sum*:	1,999.2 *	3,320.26 *	638.5 *	1,051.2 *	3,662.37 *	617.1 *
Daily Min:	47.2	79.50	8.4	6.3	18.95	5.8
Daily Max:	151.6	157.10	30.3	185.4	216.87	29.6
Jul 2020 - Jul 2020	1,999.2	3,320.26	638.5	1,051.2	3,662.37	617.1
QTD:	1,999.2 *	3,320.26 *	638.5 *	1,051.2 *	3,662.37 *	617.1 *
YTD 2020:	11,291.7 *	20,788.53 *	2,874.9 *	6,283.5 *	20,862.02 *	3,093.0 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:00 Location: Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
08/01/2020	76.9	130.10	26.6	26.9	149.50	26.1
08/02/2020	62.2	107.80	23.3	20.9	110.70	22.7
08/03/2020	70.7	124.20	25.1	23.0	133.60	24.2
08/04/2020	59.2	103.90	22.7	19.5	106.40	22.3
08/05/2020	48.2	89.30	20.5	14.8	80.30	20.3
08/06/2020	42.7	81.10	19.2	12.6	62.80	19.2
08/07/2020	43.9	94.80	19.9	13.8	74.80	19.9
08/08/2020	62.8	104.50	22.5	21.3	103.30	22.2
08/09/2020	62.5	110.00	23.4	20.3	114.60	22.9
08/10/2020	61.8	119.20	23.5	22.0	123.70	23.4
08/11/2020	44.6	86.10	19.5	13.7	67.40	19.5
08/12/2020	72.1	110.70	24.4	24.2	126.20	23.8
08/13/2020	73.0	138.50	27.8	26.4	159.20	26.7
08/14/2020	92.1	153.20	30.9	28.9	200.00	30.0
08/15/2020	86.6	155.40	31.1	28.5	197.40	29.8
08/16/2020	81.9	153.10	30.6	23.8	199.10	30.1
08/17/2020	82.6	154.20	31.2	21.3	198.10	30.2
08/18/2020	79.8	156.00	31.1	21.9	199.40	29.6
08/19/2020	82.0	155.90	31.1	24.2	200.20	30.1
08/20/2020	99.5	149.30	29.5	33.0	196.20	28.8
08/21/2020	53.2	106.40	30.6	22.5	195.00	28.9
08/22/2020	66.7	148.90	28.1	26.9	166.00	27.2
08/23/2020	67.3	145.00	28.8	24.8	175.90	28.1
08/24/2020	85.2	155.60	31.2	26.4	199.40	29.7
08/25/2020	88.5	159.60	30.5	28.7	196.80	29.0
08/26/2020	90.7	165.50	29.4	31.4	192.40	28.8
08/27/2020	80.8	149.70	30.1	29.7	195.30	29.6
08/28/2020	62.1	129.60	26.0	24.0	141.30	25.2
08/29/2020	61.9	128.20	25.6	25.3	139.10	25.1
08/30/2020	61.0	148.30	27.2	27.8	170.00	25.9
08/31/2020	60.4	128.30	24.8	24.4	134.00	24.7
Monthly Avg/Sum*:	2,162.9 *	4,042.40 *	826.2 *	732.9 *	4,708.10 *	804.0 *
Daily Min:	42.7	81.10	19.2	12.6	62.80	19.2
Daily Max:	99.5	165.50	31.2	33.0	200.20	30.2
Jul 2020 - Aug 2020	4,162.1	7,362.66	1,464.7	1,784.1	8,370.47	1,421.1
QTD:	4,162.1 *	7,362.66 *	1,464.7 *	1,784.1 *	8,370.47 *	1,421.1 *
YTD 2020:	13,454.6 *	24,830.93 *	3,701.1 *	7,016.4 *	25,570.12 *	3,897.0 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:00 Location: Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
09/01/2020	27.6	111.30	23.9	21.4	122.40	23.8
09/02/2020	27.1	97.40	21.2	9.6	21.04	5.8
09/03/2020	30.5	131.00	26.2	81.9	213.81	22.2
09/04/2020	46.0	152.10	30.5	23.8	197.60	29.5
09/05/2020	37.4	144.70	28.9	24.6	180.50	28.7
09/06/2020	37.2	151.90	30.7	26.2	198.50	29.5
09/07/2020	27.6	144.00	27.1	26.3	164.30	26.9
09/08/2020	32.4	141.40	28.4	26.6	172.90	27.7
09/09/2020	32.4	126.10	25.5	22.7	138.70	25.3
09/10/2020	23.3	120.90	24.5	23.3	117.50	24.5
09/11/2020	22.9	95.33	21.0	22.0	91.06	20.9
09/12/2020	0.0	0.00	0.0	68.6	131.34	4.6
09/13/2020	0.0	0.00	0.0	93.8	146.92	6.0
09/14/2020	160.7	187.76	11.4	68.2	178.58	16.3
09/15/2020	23.1	110.03	22.9	23.6	118.72	22.8
09/16/2020	77.9	130.93	18.3	53.9	174.50	14.0
09/17/2020	24.0	125.00	25.5	22.8	135.00	25.0
09/18/2020	93.2	104.44	16.4	61.2	162.34	12.7
09/19/2020	86.5	116.84	19.4	52.2	169.66	11.5
09/20/2020	80.7	122.50	19.0	58.8	155.97	15.3
09/21/2020	116.2	134.40	8.9	75.6	169.14	12.8
09/22/2020	119.4	127.87	6.2	89.0	170.72	11.9
09/23/2020	116.7	141.52	7.6	83.0	179.84	11.3
09/24/2020	127.0	131.97	10.5	76.2	153.82	6.8
09/25/2020	0.0	0.00	0.0	0.0	0.00	0.0
09/26/2020	0.0	0.00	0.0	0.0	0.00	0.0
09/27/2020	120.8	175.96	9.3	106.8	221.70	13.1
09/28/2020	69.3	174.84	16.9	52.8	191.14	13.5
09/29/2020	79.9	176.30	19.2	55.1	192.33	15.7
09/30/2020	39.5	143.60	28.4	27.5	171.60	28.3
Monthly Avg/Sum*:	1,679.3 *	3,520.09 *	527.8 *	1,377.5 *	4,441.63 *	506.4 *
Daily Min:	22.9	95.33	6.2	9.6	21.04	4.6
Daily Max:	160.7	187.76	30.7	106.8	221.70	29.5
Jul 2020 - Sep 2020	5,841.4	10,882.75	1,992.5	3,161.6	12,812.10	1,927.5
QTD:	5,841.4 *	10,882.75 *	1,992.5 *	3,161.6 *	12,812.10 *	1,927.5 *
YTD 2020:	15,133.9 *	28,351.02 *	4,228.9 *	8,393.9 *	30,011.75 *	4,403.4 *

Monthly Summary By Day Report



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:05 Location: Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr 1 Hour(s)	Unit CT1 GasFlowCT, 100scf 1 Hour(s)	Unit CT1 DBOn, Hr 1 Hour(s)	Unit CT1 GasFlowDB, 100scf 1 Hour(s)	Unit CT1 GasFlow, Total, 100scf 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtu 1 Hour(s)
07/01/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
07/02/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
07/03/2020	10.20	154,256.5	6.25	20,613.1	174,869.6	1,721.2	17,644.250
07/04/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
07/05/2020	8.20	120,148.8	4.88	16,186.5	136,335.3	1,394.4	13,756.240
07/06/2020	12.38	194,299.4	7.75	23,049.7	217,349.1	2,088.4	21,930.572
07/07/2020	24.00	342,913.1	7.75	23,430.6	366,343.7	2,964.8	36,964.100
07/08/2020	24.00	338,721.4	7.77	24,533.8	363,255.2	2,984.2	36,652.600
07/09/2020	24.00	350,369.0	8.98	30,356.9	380,725.9	3,191.8	38,415.200
07/10/2020	24.00	368,467.0	10.70	38,830.5	407,297.5	3,411.7	41,885.500
07/11/2020	24.00	361,284.7	8.33	29,188.7	390,473.4	3,140.8	40,336.000
07/12/2020	24.00	342,263.0	8.00	28,302.5	370,565.5	2,961.6	38,279.400
07/13/2020	24.00	371,477.0	12.05	41,566.3	413,043.3	3,345.1	42,667.800
07/14/2020	24.00	365,044.9	10.43	31,888.3	396,933.2	3,191.4	41,003.300
07/15/2020	24.00	304,767.0	0.00	0.0	304,767.0	2,163.5	31,482.600
07/16/2020	24.00	338,412.8	7.77	24,038.8	362,451.6	2,847.5	37,441.300
07/17/2020	24.00	335,453.2	6.77	20,342.2	355,795.4	2,767.5	36,753.700
07/18/2020	24.00	354,073.1	8.02	23,929.2	378,002.3	2,827.5	39,047.500
07/19/2020	24.00	337,952.5	6.73	20,256.6	358,209.1	2,934.0	37,002.800
07/20/2020	24.00	365,935.3	10.76	32,636.7	398,572.0	3,301.5	41,172.700
07/21/2020	24.00	360,312.1	10.26	33,042.8	393,354.9	3,324.1	40,633.700
07/22/2020	24.00	340,823.9	6.73	18,703.5	359,527.4	2,915.4	37,139.100
07/23/2020	24.00	309,568.1	0.00	0.0	309,568.1	2,263.1	31,978.500
07/24/2020	24.00	332,019.4	3.96	8,396.0	340,415.4	2,735.2	35,164.900
07/25/2020	24.00	352,335.5	7.00	22,755.5	375,091.0	2,984.5	38,746.800
07/26/2020	24.00	363,419.1	8.48	27,187.3	390,606.4	3,269.2	40,349.600
07/27/2020	24.00	370,994.1	11.98	45,442.5	416,436.6	3,517.0	43,018.000
07/28/2020	24.00	379,739.7	12.07	45,658.8	425,398.5	3,550.9	43,943.700
07/29/2020	24.00	409,215.9	24.00	73,688.0	482,903.9	4,308.1	49,883.900
07/30/2020	24.00	409,927.1	24.00	69,216.1	479,143.2	4,202.0	49,495.800
07/31/2020	24.00	408,894.8	24.00	68,219.1	477,113.9	4,282.4	49,285.800
Monthly Avg/Sum*:	630.78 *	9,383,088.4 *	265.42 *	841,460.0 *	10,224,548.4 *	84,588.8 *	1,052,075.362 *
Daily Min:	8.20	120,148.8	0.00	0.0	136,335.3	1,394.4	13,756.240
Daily Max:	24.00	409,927.1	24.00	73,688.0	482,903.9	4,308.1	49,883.900
Jul 2020 - Jul 2020	630.78	9,383,088.4	265.42	841,460.0	10,224,548.4	84,588.8	1,052,075.362
QTD:	630.78 *	9,383,088.4 *	265.42 *	841,460.0 *	10,224,548.4 *	84,588.8 *	1,052,075.362 *
YTD 2020:	2,634.48 *	43,188,545.7 *	1,326.77 *	3,620,088.4 *	46,808,634.1 *	365,409.5 *	4,779,731.241 *

Monthly Summary By Day Report



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:05 Location: Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2020	24.00	378,155.6	14.95	46,074.9	424,230.5	3,636.3	43,822.800
08/02/2020	24.00	343,476.5	7.97	24,762.0	368,238.5	2,901.3	38,038.800
08/03/2020	24.00	363,958.4	10.75	35,171.3	399,129.7	3,234.2	41,230.200
08/04/2020	24.00	339,546.1	6.75	20,326.4	359,872.5	2,812.4	37,174.700
08/05/2020	24.00	317,603.9	2.50	6,382.9	323,986.8	2,368.9	33,467.700
08/06/2020	24.00	302,376.0	0.00	0.0	302,376.0	2,120.9	31,235.500
08/07/2020	24.00	316,253.3	0.00	0.0	316,253.3	2,217.2	32,669.100
08/08/2020	24.00	334,655.0	6.98	22,436.1	357,091.1	2,813.3	36,887.600
08/09/2020	24.00	343,785.3	8.05	26,783.6	370,568.9	2,961.8	38,279.800
08/10/2020	24.00	355,947.2	7.73	23,282.7	379,229.9	2,927.9	39,174.500
08/11/2020	24.00	310,390.4	0.00	0.0	310,390.4	2,158.6	32,063.500
08/12/2020	24.00	355,035.9	11.00	35,686.9	390,722.8	3,170.2	40,361.900
08/13/2020	24.00	393,857.6	14.05	48,075.4	441,933.0	3,682.7	45,651.800
08/14/2020	24.00	405,855.8	24.00	88,920.5	494,776.3	4,722.2	51,110.400
08/15/2020	24.00	404,248.2	24.00	91,352.6	495,600.8	4,653.4	51,195.200
08/16/2020	24.00	404,986.6	24.00	88,973.8	493,960.4	4,585.9	51,026.200
08/17/2020	24.00	406,005.8	24.00	91,423.2	497,429.0	4,681.3	51,384.300
08/18/2020	24.00	403,823.5	24.00	92,457.5	496,281.0	4,667.5	51,265.700
08/19/2020	24.00	407,293.2	24.00	89,161.2	496,454.4	4,707.6	51,283.500
08/20/2020	24.00	410,672.0	24.00	70,566.9	481,238.9	4,334.1	49,712.000
08/21/2020	24.00	403,161.0	24.00	83,425.1	486,586.1	4,667.9	50,264.500
08/22/2020	24.00	396,570.1	15.00	52,712.1	449,282.2	4,177.8	46,410.700
08/23/2020	24.00	398,606.3	18.00	63,539.6	462,145.9	4,415.5	47,739.800
08/24/2020	24.00	406,180.1	24.00	89,101.1	495,281.2	5,142.7	51,162.500
08/25/2020	24.00	405,712.0	23.98	81,113.2	486,825.2	5,120.3	50,289.300
08/26/2020	24.00	406,108.8	24.00	69,310.8	475,419.6	4,835.2	49,110.800
08/27/2020	24.00	408,574.7	24.00	73,720.5	482,295.2	4,669.9	49,821.000
08/28/2020	24.00	373,553.9	12.92	44,534.1	418,088.0	3,737.1	43,188.200
08/29/2020	24.00	372,377.2	11.02	34,826.2	407,203.4	3,506.1	42,064.100
08/30/2020	24.00	403,726.4	9.95	29,516.0	433,242.4	3,947.6	44,754.200
08/31/2020	24.00	369,155.7	10.73	32,137.1	401,292.8	3,395.4	41,453.500
Monthly Avg/Sum*:	744.00 *	11,641,652.5 *	456.33 *	1,555,773.7 *	13,197,426.2 *	116,973.2 *	1,363,293.800 *
Daily Min:	24.00	302,376.0	0.00	0.0	302,376.0	2,120.9	31,235.500
Daily Max:	24.00	410,672.0	24.00	92,457.5	497,429.0	5,142.7	51,384.300
Ju1 2020 - Aug 2020	1,374.78	21,024,740.9	721.75	2,397,233.7	23,421,974.6	201,562.0	2,415,369.162
QTD:	1,374.78 *	21,024,740.9 *	721.75 *	2,397,233.7 *	23,421,974.6 *	201,562.0 *	2,415,369.162 *
YTD 2020:	3,378.48 *	54,830,198.2 *	1,783.10 *	5,175,862.1 *	60,006,060.3 *	482,382.7 *	6,143,025.041 *

Monthly Summary By Day Report



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:05 Location: Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2020	24.00	364,838.5	6.77	18,668.8	383,507.3	3,097.0	39,616.300
09/02/2020	24.00	334,011.7	4.88	9,064.0	343,075.7	2,567.3	35,439.600
09/03/2020	24.00	379,569.9	12.03	43,644.2	423,214.1	3,475.2	43,717.700
09/04/2020	24.00	407,420.6	24.00	83,382.0	490,802.6	4,479.1	50,700.200
09/05/2020	24.00	398,669.3	19.00	68,079.6	466,748.9	4,117.3	48,215.200
09/06/2020	24.00	402,448.5	24.00	88,409.5	490,858.0	4,581.3	50,705.700
09/07/2020	24.00	390,358.7	14.99	46,604.5	436,963.2	3,722.4	45,138.200
09/08/2020	24.00	398,620.5	17.00	57,271.2	455,891.7	3,985.0	47,093.700
09/09/2020	24.00	384,574.9	11.95	26,698.4	411,273.3	3,158.7	42,484.500
09/10/2020	24.00	378,290.2	7.75	16,585.0	394,875.2	2,878.5	40,790.300
09/11/2020	23.17	330,317.9	3.76	7,528.3	337,846.2	2,676.1	34,899.835
09/12/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
09/13/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
09/14/2020	10.58	161,165.5	7.53	21,543.8	182,709.3	1,767.3	18,873.778
09/15/2020	22.45	341,129.5	8.31	24,997.3	366,126.9	2,917.3	37,820.850
09/16/2020	17.52	269,669.1	9.04	26,537.7	296,206.8	2,714.9	30,598.264
09/17/2020	24.00	371,104.2	10.83	36,401.7	407,505.9	3,292.3	42,095.600
09/18/2020	16.27	247,073.5	8.53	20,856.1	267,929.7	2,666.0	27,677.176
09/19/2020	19.27	287,079.0	8.03	26,404.7	313,483.7	2,842.0	32,383.136
09/20/2020	17.96	277,599.6	10.92	27,443.8	305,043.4	3,237.2	31,510.882
09/21/2020	8.76	128,163.0	6.00	16,024.5	144,187.5	1,595.3	14,894.554
09/22/2020	6.92	98,601.1	4.25	0.0	98,601.1	1,166.0	10,185.457
09/23/2020	7.66	111,484.7	5.02	11,518.4	123,003.1	1,354.7	12,706.359
09/24/2020	11.85	160,064.6	3.77	10,404.7	170,469.2	1,855.0	17,609.688
09/25/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
09/26/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
09/27/2020	8.78	129,034.3	5.50	17,777.5	146,811.8	1,551.3	15,165.715
09/28/2020	15.87	242,260.3	8.50	30,134.9	272,395.3	2,716.8	28,256.223
09/29/2020	17.40	271,322.9	10.52	36,532.4	307,855.3	2,895.7	31,955.480
09/30/2020	24.00	404,336.3	16.35	50,640.2	454,976.5	3,882.5	47,226.800
Monthly Avg/Sum*:	492.46 *	7,669,208.3 *	269.23 *	823,153.2 *	8,492,361.7 *	75,192.2 *	877,761.197 *
Daily Min:	6.92	98,601.1	3.76	0.0	98,601.1	1,166.0	10,185.457
Daily Max:	24.00	407,420.6	24.00	88,409.5	490,858.0	4,581.3	50,705.700
Jul 2020 - Sep 2020	1,867.24	28,693,949.2	990.98	3,220,386.9	31,914,336.3	276,754.2	3,293,130.359
QTD:	1,867.24 *	28,693,949.2 *	990.98 *	3,220,386.9 *	31,914,336.3 *	276,754.2 *	3,293,130.359 *
YTD 2020:	3,870.94 *	62,499,406.5 *	2,052.33 *	5,999,015.3 *	68,498,422.0 *	557,574.9 *	7,020,786.238 *

Monthly Summary By Day Report



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:06 Location: Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr 1 Hour(s)	Unit CT2 GasFlowCT, 100scf 1 Hour(s)	Unit CT2 DBOn, Hr 1 Hour(s)	Unit CT2 GasFlowDB, 100scf 1 Hour(s)	Unit CT2 GasFlow, Total, 100scf 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtu 1 Hour(s)
07/01/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
07/02/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
07/03/2020	15.22	213,993.2	6.25	19,070.4	233,063.6	1,963.3	23,842.496
07/04/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
07/05/2020	13.30	181,564.2	4.88	14,933.3	196,497.5	1,745.7	20,101.480
07/06/2020	21.35	322,448.3	7.75	21,582.9	344,031.2	2,574.8	35,194.145
07/07/2020	24.00	344,609.4	7.75	21,988.9	366,598.3	2,481.6	37,503.200
07/08/2020	24.00	340,157.3	7.74	22,827.7	362,985.0	2,485.6	37,133.200
07/09/2020	24.00	351,958.9	8.98	28,064.9	380,023.8	2,587.8	38,876.400
07/10/2020	24.00	369,237.8	10.75	35,547.9	404,785.7	2,727.1	41,409.500
07/11/2020	24.00	362,962.9	8.33	26,721.1	389,684.0	2,624.5	39,864.800
07/12/2020	24.00	344,065.1	8.00	26,117.2	370,182.3	2,521.9	37,869.700
07/13/2020	24.00	371,677.3	12.05	38,537.3	410,214.6	2,735.3	41,965.100
07/14/2020	24.00	366,127.8	10.32	29,709.6	395,837.4	2,623.9	40,494.000
07/15/2020	24.00	307,316.5	0.00	0.0	307,316.5	2,106.6	31,438.500
07/16/2020	24.00	339,986.5	7.77	22,668.1	362,654.6	2,442.7	37,099.600
07/17/2020	24.00	337,118.7	6.77	19,189.2	356,307.9	2,402.2	36,450.400
07/18/2020	24.00	355,253.1	7.99	22,436.1	377,689.2	2,534.3	38,637.600
07/19/2020	24.00	339,427.8	6.70	19,381.9	358,809.7	2,436.7	36,706.400
07/20/2020	24.00	366,977.0	10.76	31,097.2	398,074.2	2,636.2	40,723.000
07/21/2020	24.00	361,255.4	10.26	31,240.1	392,495.5	2,616.9	40,152.300
07/22/2020	24.00	342,397.9	6.75	17,165.7	359,563.6	2,408.4	36,783.100
07/23/2020	24.00	312,051.4	0.00	0.0	312,051.4	2,136.8	31,922.800
07/24/2020	7.30	91,796.9	0.00	0.0	91,796.9	699.3	9,390.830
07/25/2020	10.50	158,643.4	7.00	21,424.3	180,067.7	1,355.9	18,421.000
07/26/2020	24.00	364,631.4	8.48	25,246.0	389,877.4	2,601.6	39,884.500
07/27/2020	24.00	371,657.7	11.98	41,891.0	413,548.7	2,806.5	42,306.200
07/28/2020	24.00	380,444.1	12.07	42,470.8	422,914.9	2,889.5	43,264.300
07/29/2020	24.00	408,640.5	24.00	70,964.6	479,605.1	3,225.9	49,063.700
07/30/2020	24.00	409,320.5	24.00	67,430.0	476,750.5	3,151.0	48,771.600
07/31/2020	24.00	408,191.7	24.00	66,839.0	475,030.7	3,227.0	48,595.700
Monthly Avg/Sum*:	619.67 *	9,223,912.7 *	261.33 *	784,545.2 *	10,008,457.9 *	68,749.0 *	1,023,865.551 *
Daily Min:	7.30	91,796.9	0.00	0.0	91,796.9	699.3	9,390.830
Daily Max:	24.00	409,320.5	24.00	70,964.6	479,605.1	3,227.0	49,063.700
Jul 2020 - Jul 2020	619.67	9,223,912.7	261.33	784,545.2	10,008,457.9	68,749.0	1,023,865.551
QTD:	619.67 *	9,223,912.7 *	261.33 *	784,545.2 *	10,008,457.9 *	68,749.0 *	1,023,865.551 *
YTD 2020:	2,962.86 *	46,736,182.3 *	1,367.52 *	3,522,863.5 *	50,259,046.2 *	326,078.9 *	5,158,637.134 *

Monthly Summary By Day Report



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:06 Location: Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2020	24.00	378,382.6	14.95	44,556.4	422,939.0	2,892.4	43,266.500
08/02/2020	24.00	344,648.7	7.82	23,371.7	368,020.4	2,479.4	37,648.200
08/03/2020	24.00	365,099.6	10.75	33,678.7	398,778.3	2,688.3	40,794.900
08/04/2020	24.00	341,038.7	6.75	19,441.0	360,479.7	2,414.3	36,877.000
08/05/2020	24.00	319,257.6	2.50	6,388.3	325,645.9	2,186.9	33,313.600
08/06/2020	24.00	304,691.1	0.00	0.0	304,691.1	2,066.8	31,169.900
08/07/2020	24.00	318,544.0	0.00	0.0	318,544.0	2,137.2	32,586.900
08/08/2020	24.00	335,987.3	6.98	21,329.7	357,317.0	2,424.8	36,553.600
08/09/2020	24.00	345,211.0	8.05	25,380.0	370,591.0	2,499.9	37,911.400
08/10/2020	24.00	357,349.9	7.75	22,299.9	379,649.8	2,499.6	38,838.000
08/11/2020	24.00	312,671.8	0.00	0.0	312,671.8	2,095.2	31,986.200
08/12/2020	24.00	355,387.0	11.00	34,013.9	389,400.9	2,620.1	39,835.600
08/13/2020	24.00	393,841.8	14.05	45,621.5	439,463.3	2,914.9	44,957.000
08/14/2020	24.00	405,415.0	24.00	83,484.1	488,899.1	3,404.0	50,014.200
08/15/2020	24.00	402,508.9	24.00	85,007.6	487,516.5	3,405.6	49,873.100
08/16/2020	24.00	403,447.3	24.00	82,741.1	486,188.4	3,290.3	49,737.100
08/17/2020	24.00	404,105.9	24.00	84,588.4	488,694.3	3,345.0	49,993.500
08/18/2020	24.00	402,145.5	24.00	85,580.2	487,725.7	3,391.6	49,894.500
08/19/2020	24.00	405,926.6	24.00	83,211.7	489,138.3	3,417.0	50,038.900
08/20/2020	24.00	411,048.2	24.00	68,670.2	479,718.4	3,234.0	49,075.300
08/21/2020	24.00	402,928.6	24.00	78,688.9	481,617.5	3,424.5	49,269.400
08/22/2020	24.00	396,183.2	15.00	49,913.8	446,097.0	3,054.9	45,635.700
08/23/2020	24.00	397,920.0	18.00	60,172.7	458,092.7	3,137.1	46,863.100
08/24/2020	24.00	404,527.4	24.00	83,208.4	487,735.8	3,422.8	49,895.200
08/25/2020	24.00	404,362.5	23.98	76,216.8	480,579.3	3,251.8	49,163.500
08/26/2020	24.00	404,867.9	24.00	65,978.7	470,846.6	3,093.1	48,167.600
08/27/2020	24.00	407,928.5	24.00	69,058.7	476,987.2	3,133.5	48,795.900
08/28/2020	24.00	373,553.1	12.95	38,451.6	412,004.7	2,755.5	42,148.100
08/29/2020	24.00	373,191.4	11.02	32,444.5	405,635.9	2,665.5	41,496.500
08/30/2020	24.00	403,430.3	9.95	27,993.0	431,423.3	2,809.3	44,134.600
08/31/2020	24.00	369,393.4	10.65	30,141.8	399,535.2	2,632.9	40,872.400
Monthly Avg/Sum*:	744.00 *	11,644,994.8 *	456.15 *	1,461,633.3 *	13,106,628.1 *	88,788.2 *	1,340,807.400 *
Daily Min:	24.00	304,691.1	0.00	0.0	304,691.1	2,066.8	31,169.900
Daily Max:	24.00	411,048.2	24.00	85,580.2	489,138.3	3,424.5	50,038.900
Jul 2020 - Aug 2020	1,363.67	20,868,907.5	717.48	2,246,178.5	23,115,086.0	157,537.2	2,364,672.951
QTD:	1,363.67 *	20,868,907.5 *	717.48 *	2,246,178.5 *	23,115,086.0 *	157,537.2 *	2,364,672.951 *
YTD 2020:	3,706.86 *	58,381,177.1 *	1,823.67 *	4,984,496.8 *	63,365,674.3 *	414,867.1 *	6,499,444.534 *

Monthly Summary By Day Report



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:06 Location: Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2020	24.00	366,406.2	6.77	17,906.4	384,312.6	2,480.6	39,315.200
09/02/2020	7.43	92,140.0	0.00	0.0	92,140.0	726.5	9,425.862
09/03/2020	20.45	321,046.8	12.03	40,295.8	361,342.6	2,481.5	36,965.325
09/04/2020	24.00	405,639.3	24.00	77,422.5	483,061.8	3,202.7	49,417.300
09/05/2020	24.00	397,701.0	19.02	63,124.9	460,825.9	3,056.7	47,142.400
09/06/2020	24.00	403,531.3	24.00	81,737.9	485,269.2	3,273.8	49,643.200
09/07/2020	24.00	392,277.6	14.99	44,057.2	436,334.8	2,856.8	44,637.100
09/08/2020	24.00	399,465.2	17.00	53,740.6	453,205.8	3,040.3	46,363.000
09/09/2020	24.00	385,294.1	11.95	26,565.2	411,859.3	2,614.3	42,133.100
09/10/2020	24.00	379,967.0	7.75	16,382.2	396,349.2	2,461.4	40,546.500
09/11/2020	23.17	332,041.6	3.76	7,441.7	339,483.3	2,384.4	34,729.011
09/12/2020	6.78	74,037.5	0.00	0.0	74,037.5	909.6	7,574.146
09/13/2020	9.07	100,352.1	0.00	0.0	100,352.1	1,259.6	10,265.925
09/14/2020	16.32	241,618.5	7.53	20,680.0	262,298.5	2,033.8	26,832.980
09/15/2020	22.52	342,178.3	8.30	23,888.8	366,067.2	2,444.3	37,448.748
09/16/2020	12.65	201,060.5	9.05	25,396.3	226,456.8	1,604.5	23,166.660
09/17/2020	24.00	371,628.3	10.83	34,960.6	406,588.9	2,694.1	41,594.300
09/18/2020	12.05	187,175.4	8.53	20,606.2	207,781.7	1,633.0	21,256.016
09/19/2020	10.43	162,127.0	8.03	24,865.9	186,992.9	1,372.8	19,129.330
09/20/2020	14.10	218,868.2	10.87	26,450.2	245,318.4	2,055.3	25,096.253
09/21/2020	13.63	193,383.3	6.00	15,511.0	208,894.3	1,872.1	21,369.772
09/22/2020	12.85	181,324.7	5.92	10,343.6	191,668.3	1,664.0	19,607.637
09/23/2020	12.76	174,866.4	5.00	11,225.8	186,092.2	1,721.9	19,037.196
09/24/2020	7.16	102,610.0	3.57	10,083.7	112,693.7	970.4	11,528.560
09/25/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
09/26/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
09/27/2020	13.55	192,992.5	5.49	17,851.9	210,844.4	1,780.2	21,569.395
09/28/2020	12.20	187,839.6	8.44	30,134.9	217,974.4	1,851.4	22,298.720
09/29/2020	13.78	218,234.3	10.48	34,140.9	252,375.2	1,922.2	25,817.888
09/30/2020	24.00	404,329.0	16.38	53,164.3	457,493.3	3,034.7	46,801.600
Monthly Avg/Sum*:	480.90 *	7,430,135.7 *	265.69 *	787,978.5 *	8,218,114.3 *	59,402.9 *	840,713.124 *
Daily Min:	6.78	74,037.5	0.00	0.0	74,037.5	726.5	7,574.146
Daily Max:	24.00	405,639.3	24.00	81,737.9	485,269.2	3,273.8	49,643.200
Jul 2020 - Sep 2020	1,844.57	28,299,043.2	983.17	3,034,157.0	31,333,200.3	216,940.1	3,205,386.075
QTD:	1,844.57 *	28,299,043.2 *	983.17 *	3,034,157.0 *	31,333,200.3 *	216,940.1 *	3,205,386.075 *
YTD 2020:	4,187.76 *	65,811,312.8 *	2,089.36 *	5,772,475.3 *	71,583,788.6 *	474,270.0 *	7,340,157.658 *

ATTACHMENT 10
Maximum Emissions

FCD: AQ-25
Title V: #6

AQ-25 Emission Limits

Maximum Emissions Both Turbines (lbs)		
Pollutant	1-Hour Emissions	24-Hour Emissions
NO _x	666.60	2,994.60
CO	967.00	7,659.00
VOC	55.40	630.60
PM10	27.00	648.00
SO ₂	14.80	355.20

Monthly Summary By Day Report

AQ-25



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:10 Location: Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Plantwide NOx, Lb 1 Day(s)	Plantwide CO, Lb 1 Day(s)	Plantwide VOC, Lb 1 Day(s)	Plantwide PM10, Lb 1 Day(s)	Plantwide SO2, Lb 1 Day(s)
07/01/2020	0.0	0.0	0.0	0.0	0.0
07/02/2020	0.0	0.0	0.0	0.0	0.0
07/03/2020	349.8	337.0	19.4	115.9	14.4
07/04/2020	0.0	0.0	0.0	0.0	0.0
07/05/2020	357.2	278.7	15.8	94.9	12.0
07/06/2020	263.9	158.0	25.6	160.3	21.0
07/07/2020	207.9	76.8	37.2	204.8	22.5
07/08/2020	208.2	68.4	36.9	202.8	22.4
07/09/2020	233.3	80.8	38.8	212.8	23.5
07/10/2020	253.4	78.1	41.7	228.9	24.9
07/11/2020	248.6	81.9	39.9	220.5	24.1
07/12/2020	228.1	76.5	38.2	209.2	23.0
07/13/2020	270.6	94.9	42.2	232.9	25.1
07/14/2020	254.7	94.7	41.0	224.0	24.2
07/15/2020	159.4	64.9	31.5	173.1	19.3
07/16/2020	218.4	90.0	37.5	204.8	22.5
07/17/2020	209.7	85.5	36.7	201.6	22.0
07/18/2020	258.8	89.5	38.9	213.6	23.4
07/19/2020	209.8	86.7	36.8	202.8	22.2
07/20/2020	251.5	92.6	41.4	224.9	24.4
07/21/2020	243.9	88.8	40.9	221.7	24.1
07/22/2020	204.8	83.9	37.2	202.9	22.3
07/23/2020	148.4	66.1	32.0	175.4	19.7
07/24/2020	112.8	69.5	27.9	115.8	5.8
07/25/2020	277.8	154.1	33.0	151.8	10.8
07/26/2020	238.6	83.7	40.3	220.5	24.1
07/27/2020	263.3	90.6	42.9	234.4	25.5
07/28/2020	276.5	90.4	43.7	240.0	26.0
07/29/2020	347.8	127.8	49.5	271.9	29.6
07/30/2020	343.6	127.0	49.3	270.0	29.2
07/31/2020	342.0	133.5	49.3	268.9	29.1
Monthly Avg/Sum*:	6,982.8 *	3,050.4 *	1,045.5 *	5,701.1 *	- *
Daily Min:	0.0	0.0	0.0	0.0	-
Daily Max:	357.2	337.0	49.5	271.9	-
Jul 2020 - Jul 2020	6,982.8	3,050.4	1,045.5	5,701.1	-
QTD:	6,982.8 *	3,050.4 *	1,045.5 *	5,701.1 *	0.0 *
YTD 2020:	41,651.3 *	17,575.2 *	4,880.8 *	27,423.0 *	46.1 *

Monthly Summary By Day Report

AQ-25



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:10 Location: Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Plantwide NOx, Lb 1 Day(s)	Plantwide CO, Lb 1 Day(s)	Plantwide VOC, Lb 1 Day(s)	Plantwide PM10, Lb 1 Day(s)	Plantwide SO2, Lb 1 Day(s)
08/01/2020	279.6	103.8	43.7	239.5	26.1
08/02/2020	218.5	83.1	38.1	208.1	22.7
08/03/2020	257.8	93.7	41.2	225.5	24.2
08/04/2020	210.3	78.7	37.1	203.8	22.3
08/05/2020	169.6	63.0	33.6	183.2	20.3
08/06/2020	143.9	55.3	31.4	171.2	19.2
08/07/2020	169.6	57.7	32.6	179.1	19.9
08/08/2020	207.8	84.1	36.8	201.5	22.2
08/09/2020	224.6	82.8	38.5	209.5	22.9
08/10/2020	242.9	83.8	39.0	214.3	23.4
08/11/2020	153.5	58.3	32.2	176.0	19.5
08/12/2020	236.9	96.3	40.1	220.4	23.8
08/13/2020	297.7	99.4	45.5	248.9	26.7
08/14/2020	353.2	121.0	50.3	277.8	30.0
08/15/2020	352.8	115.1	50.3	277.8	29.8
08/16/2020	352.2	105.7	49.9	277.0	30.1
08/17/2020	352.3	103.9	50.4	278.4	30.2
08/18/2020	355.4	101.7	50.3	277.8	29.6
08/19/2020	356.1	106.2	50.4	278.2	30.1
08/20/2020	345.5	132.5	49.2	271.5	28.8
08/21/2020	301.4	75.7	50.2	273.4	28.9
08/22/2020	314.9	93.6	46.4	252.8	27.2
08/23/2020	320.9	92.1	47.2	259.4	28.1
08/24/2020	355.0	111.6	50.4	277.4	29.7
08/25/2020	356.4	117.2	50.0	273.0	29.0
08/26/2020	357.9	122.1	48.8	267.4	28.8
08/27/2020	345.0	110.5	49.3	270.7	29.6
08/28/2020	270.9	86.1	42.6	234.3	25.2
08/29/2020	267.3	87.2	41.9	230.1	25.1
08/30/2020	318.3	88.8	44.0	244.1	25.9
08/31/2020	262.3	84.8	41.1	226.3	24.7
Monthly Avg/Sum*:	8,750.5 *	2,895.8 *	1,352.5 *	7,428.4 *	- *
Daily Min:	143.9	55.3	31.4	171.2	-
Daily Max:	357.9	132.5	50.4	278.4	-
Jul 2020 - Aug 2020	15,733.3	5,946.2	2,398.0	13,129.5	-
QTD:	15,733.3 *	5,946.2 *	2,398.0 *	13,129.5 *	0.0 *
YTD 2020:	50,401.8 *	20,471.0 *	6,233.3 *	34,851.4 *	46.1 *

Monthly Summary By Day Report

AQ-25



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:10 Location: Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Plantwide NOx, Lb 1 Day(s)	Plantwide CO, Lb 1 Day(s)	Plantwide VOC, Lb 1 Day(s)	Plantwide PM10, Lb 1 Day(s)	Plantwide SO2, Lb 1 Day(s)
09/01/2020	233.7	49.0	39.2	217.2	23.8
09/02/2020	118.4	36.7	28.0	116.7	5.8
09/03/2020	344.8	112.4	41.6	220.1	22.2
09/04/2020	349.7	69.8	49.7	274.6	29.5
09/05/2020	325.2	62.0	47.3	262.2	28.7
09/06/2020	350.4	63.4	50.1	275.6	29.5
09/07/2020	308.3	53.9	45.0	247.0	26.9
09/08/2020	314.3	59.0	46.6	256.7	27.7
09/09/2020	264.8	55.1	42.5	233.0	25.3
09/10/2020	238.4	46.6	40.6	223.7	24.5
09/11/2020	186.4	44.9	34.7	191.3	20.9
09/12/2020	131.3	68.6	2.2	22.8	4.6
09/13/2020	146.9	93.8	3.0	30.8	6.0
09/14/2020	366.4	228.9	21.3	127.6	16.3
09/15/2020	228.7	46.7	37.5	207.0	22.8
09/16/2020	305.4	131.8	28.4	146.1	14.0
09/17/2020	260.0	46.8	41.6	229.9	25.0
09/18/2020	266.7	154.4	25.6	132.8	12.7
09/19/2020	286.5	138.7	28.4	138.4	11.5
09/20/2020	278.5	139.5	29.6	153.9	15.3
09/21/2020	303.5	191.8	16.9	101.6	12.8
09/22/2020	298.6	208.4	13.1	84.1	11.9
09/23/2020	321.3	199.7	14.7	89.1	11.3
09/24/2020	285.8	203.2	16.0	78.6	6.8
09/25/2020	0.0	0.0	0.0	0.0	0.0
09/26/2020	0.0	0.0	0.0	0.0	0.0
09/27/2020	397.7	227.6	16.9	102.5	13.1
09/28/2020	365.9	122.1	26.3	137.6	13.5
09/29/2020	368.6	135.0	29.7	157.6	15.7
09/30/2020	315.2	67.0	46.9	258.3	28.3
Monthly Avg/Sum*:	7,961.4 *	3,056.8 *	863.4 *	4,716.8 *	- *
Daily Min:	0.0	0.0	0.0	0.0	-
Daily Max:	397.7	228.9	50.1	275.6	-
Jul 2020 - Sep 2020	23,694.7	9,003.0	3,261.4	17,846.3	-
QTD:	23,694.7 *	9,003.0 *	3,261.4 *	17,846.3 *	0.0 *
YTD 2020:	58,363.2 *	23,527.8 *	7,096.7 *	39,568.2 *	46.1 *

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/01/2020 00:00	0.0	0.0	0.0	0.0	0.0
07/01/2020 01:00	0.0	0.0	0.0	0.0	0.0
07/01/2020 02:00	0.0	0.0	0.0	0.0	0.0
07/01/2020 03:00	0.0	0.0	0.0	0.0	0.0
07/01/2020 04:00	0.0	0.0	0.0	0.0	0.0
07/01/2020 05:00	0.0	0.0	0.0	0.0	0.0
07/01/2020 06:00	0.0	0.0	0.0	0.0	0.0
07/01/2020 07:00	0.0	0.0	0.0	0.0	0.0
07/01/2020 08:00	0.0	0.0	0.0	0.0	0.0
07/01/2020 09:00	0.0	0.0	0.0	0.0	0.0
07/01/2020 10:00	0.0	0.0	0.0	0.0	0.0
07/01/2020 11:00	0.0	0.0	0.0	0.0	0.0
07/01/2020 12:00	0.0	0.0	0.0	0.0	0.0
07/01/2020 13:00	0.0	0.0	0.0	0.0	0.0
07/01/2020 14:00	0.0	0.0	0.0	0.0	0.0
07/01/2020 15:00	0.0	0.0	0.0	0.0	0.0
07/01/2020 16:00	0.0	0.0	0.0	0.0	0.0
07/01/2020 17:00	0.0	0.0	0.0	0.0	0.0
07/01/2020 18:00	0.0	0.0	0.0	0.0	0.0
07/01/2020 19:00	0.0	0.0	0.0	0.0	0.0
07/01/2020 20:00	0.0	0.0	0.0	0.0	0.0
07/01/2020 21:00	0.0	0.0	0.0	0.0	0.0
07/01/2020 22:00	0.0	0.0	0.0	0.0	0.0
07/01/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/02/2020 00:00	0.0	0.0	0.0	0.0	0.0
07/02/2020 01:00	0.0	0.0	0.0	0.0	0.0
07/02/2020 02:00	0.0	0.0	0.0	0.0	0.0
07/02/2020 03:00	0.0	0.0	0.0	0.0	0.0
07/02/2020 04:00	0.0	0.0	0.0	0.0	0.0
07/02/2020 05:00	0.0	0.0	0.0	0.0	0.0
07/02/2020 06:00	0.0	0.0	0.0	0.0	0.0
07/02/2020 07:00	0.0	0.0	0.0	0.0	0.0
07/02/2020 08:00	0.0	0.0	0.0	0.0	0.0
07/02/2020 09:00	0.0	0.0	0.0	0.0	0.0
07/02/2020 10:00	0.0	0.0	0.0	0.0	0.0
07/02/2020 11:00	0.0	0.0	0.0	0.0	0.0
07/02/2020 12:00	0.0	0.0	0.0	0.0	0.0
07/02/2020 13:00	0.0	0.0	0.0	0.0	0.0
07/02/2020 14:00	0.0	0.0	0.0	0.0	0.0
07/02/2020 15:00	0.0	0.0	0.0	0.0	0.0
07/02/2020 16:00	0.0	0.0	0.0	0.0	0.0
07/02/2020 17:00	0.0	0.0	0.0	0.0	0.0
07/02/2020 18:00	0.0	0.0	0.0	0.0	0.0
07/02/2020 19:00	0.0	0.0	0.0	0.0	0.0
07/02/2020 20:00	0.0	0.0	0.0	0.0	0.0
07/02/2020 21:00	0.0	0.0	0.0	0.0	0.0
07/02/2020 22:00	0.0	0.0	0.0	0.0	0.0
07/02/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/03/2020 00:00	0.0	0.0	0.0	0.0	0.0
07/03/2020 01:00	0.0	0.0	0.0	0.0	0.0
07/03/2020 02:00	0.0	0.0	0.0	0.0	0.0
07/03/2020 03:00	0.0	0.0	0.0	0.0	0.0
07/03/2020 04:00	0.0	0.0	0.0	0.0	0.0
07/03/2020 05:00	0.0	0.0	0.0	0.0	0.0
07/03/2020 06:00	0.0	0.0	0.0	0.0	0.0
07/03/2020 07:00	0.0	0.0	0.0	0.0	0.0
07/03/2020 08:00	57.2	94.5	0.1	1.0	0.2
07/03/2020 09:00	32.1	29.0	0.2	1.6	0.3
07/03/2020 10:00	24.9	39.8	0.2	2.5	0.5
07/03/2020 11:00	2.8	0.5	0.4	4.2	0.8
07/03/2020 12:00	2.7	0.8	0.4	4.1	0.8
07/03/2020 13:00	66.4	90.4	0.7	5.6	1.2
07/03/2020 14:00	48.3	41.4	1.1	7.0	1.5
07/03/2020 15:00	10.0	0.9	1.7	9.1	2.0
07/03/2020 16:00	9.7	0.9	1.6	8.9	2.0
07/03/2020 17:00	14.1	4.4	2.0	11.1	2.4
07/03/2020 18:00	14.7	3.1	2.1	11.6	2.6
07/03/2020 19:00	14.7	3.0	2.1	11.5	2.6
07/03/2020 20:00	14.9	3.0	2.1	11.7	2.6
07/03/2020 21:00	14.2	3.8	2.0	11.2	2.4
07/03/2020 22:00	14.3	3.8	2.0	11.3	2.4
07/03/2020 23:00	8.8	17.7	0.7	3.5	0.8
Average/Sum#:	349.8 #	337.0 #	19.4 #	115.9 #	25.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	66.4	94.5	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/04/2020 00:00	0.0	0.0	0.0	0.0	0.0
07/04/2020 01:00	0.0	0.0	0.0	0.0	0.0
07/04/2020 02:00	0.0	0.0	0.0	0.0	0.0
07/04/2020 03:00	0.0	0.0	0.0	0.0	0.0
07/04/2020 04:00	0.0	0.0	0.0	0.0	0.0
07/04/2020 05:00	0.0	0.0	0.0	0.0	0.0
07/04/2020 06:00	0.0	0.0	0.0	0.0	0.0
07/04/2020 07:00	0.0	0.0	0.0	0.0	0.0
07/04/2020 08:00	0.0	0.0	0.0	0.0	0.0
07/04/2020 09:00	0.0	0.0	0.0	0.0	0.0
07/04/2020 10:00	0.0	0.0	0.0	0.0	0.0
07/04/2020 11:00	0.0	0.0	0.0	0.0	0.0
07/04/2020 12:00	0.0	0.0	0.0	0.0	0.0
07/04/2020 13:00	0.0	0.0	0.0	0.0	0.0
07/04/2020 14:00	0.0	0.0	0.0	0.0	0.0
07/04/2020 15:00	0.0	0.0	0.0	0.0	0.0
07/04/2020 16:00	0.0	0.0	0.0	0.0	0.0
07/04/2020 17:00	0.0	0.0	0.0	0.0	0.0
07/04/2020 18:00	0.0	0.0	0.0	0.0	0.0
07/04/2020 19:00	0.0	0.0	0.0	0.0	0.0
07/04/2020 20:00	0.0	0.0	0.0	0.0	0.0
07/04/2020 21:00	0.0	0.0	0.0	0.0	0.0
07/04/2020 22:00	0.0	0.0	0.0	0.0	0.0
07/04/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/05/2020 00:00	0.0	0.0	0.0	0.0	0.0
07/05/2020 01:00	0.0	0.0	0.0	0.0	0.0
07/05/2020 02:00	0.0	0.0	0.0	0.0	0.0
07/05/2020 03:00	0.0	0.0	0.0	0.0	0.0
07/05/2020 04:00	0.0	0.0	0.0	0.0	0.0
07/05/2020 05:00	0.0	0.0	0.0	0.0	0.0
07/05/2020 06:00	0.0	0.0	0.0	0.0	0.0
07/05/2020 07:00	0.0	0.0	0.0	0.0	0.0
07/05/2020 08:00	0.0	0.0	0.0	0.0	0.0
07/05/2020 09:00	64.5	71.1	0.1	1.0	0.2
07/05/2020 10:00	36.9	22.9	0.2	1.6	0.3
07/05/2020 11:00	52.0	41.0	0.3	2.6	0.5
07/05/2020 12:00	2.8	0.5	0.4	4.2	0.8
07/05/2020 13:00	2.8	0.5	0.4	4.2	0.8
07/05/2020 14:00	59.7	66.3	0.7	5.6	1.2
07/05/2020 15:00	51.4	41.3	1.1	6.6	1.4
07/05/2020 16:00	7.9	1.2	1.6	8.7	1.9
07/05/2020 17:00	10.8	3.0	1.8	9.9	2.2
07/05/2020 18:00	14.7	3.6	2.1	11.6	2.6
07/05/2020 19:00	14.5	3.6	2.1	11.4	2.4
07/05/2020 20:00	14.7	3.7	2.1	11.6	2.6
07/05/2020 21:00	14.6	3.7	2.1	11.4	2.5
07/05/2020 22:00	9.8	16.3	0.8	4.5	1.0
07/05/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	357.1 #	278.7 #	15.8 #	94.9 #	20.4 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	64.5	71.1	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/06/2020 00:00	0.0	0.0	0.0	0.0	0.0
07/06/2020 01:00	0.0	0.0	0.0	0.0	0.0
07/06/2020 02:00	1.1	9.5	0.0	0.5	0.1
07/06/2020 03:00	28.7	28.4	0.3	3.4	0.7
07/06/2020 04:00	2.8	0.5	0.4	4.1	0.8
07/06/2020 05:00	2.8	0.8	0.4	4.1	0.8
07/06/2020 06:00	2.8	0.8	0.4	4.1	0.8
07/06/2020 07:00	2.8	0.8	0.4	4.1	0.8
07/06/2020 08:00	2.8	0.8	0.4	4.1	0.8
07/06/2020 09:00	2.8	0.8	0.4	4.2	0.8
07/06/2020 10:00	2.8	0.8	0.4	4.2	0.8
07/06/2020 11:00	25.4	12.8	0.6	5.2	1.1
07/06/2020 12:00	48.5	49.3	1.1	6.7	1.4
07/06/2020 13:00	8.4	1.2	1.7	9.3	2.0
07/06/2020 14:00	9.7	2.1	1.6	8.9	2.0
07/06/2020 15:00	9.3	2.8	1.6	8.5	1.8
07/06/2020 16:00	14.3	6.5	2.0	11.3	2.4
07/06/2020 17:00	14.7	5.6	2.1	11.5	2.6
07/06/2020 18:00	14.7	5.2	2.1	11.6	2.6
07/06/2020 19:00	14.6	5.6	2.1	11.5	2.6
07/06/2020 20:00	14.5	6.3	2.0	11.3	2.4
07/06/2020 21:00	14.3	6.3	2.0	11.2	2.4
07/06/2020 22:00	13.6	6.0	1.9	10.7	2.4
07/06/2020 23:00	12.5	5.1	1.7	9.8	2.2
Average/Sum#:	263.9 #	158.0 #	25.6 #	160.3 #	34.3 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	48.5	49.3	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/07/2020 00:00	5.1	2.4	1.3	7.1	1.6
07/07/2020 01:00	6.7	2.3	1.3	7.3	1.6
07/07/2020 02:00	5.2	2.2	1.3	7.1	1.6
07/07/2020 03:00	5.1	2.2	1.3	7.1	1.6
07/07/2020 04:00	5.1	2.1	1.3	6.9	1.6
07/07/2020 05:00	5.2	2.2	1.3	7.1	1.6
07/07/2020 06:00	5.1	2.2	1.3	7.1	1.6
07/07/2020 07:00	5.2	1.9	1.3	7.1	1.6
07/07/2020 08:00	6.6	2.0	1.3	7.3	1.6
07/07/2020 09:00	6.4	1.9	1.3	7.1	1.6
07/07/2020 10:00	6.4	1.7	1.3	7.1	1.6
07/07/2020 11:00	6.4	1.7	1.3	7.1	1.6
07/07/2020 12:00	6.4	1.5	1.3	7.1	1.6
07/07/2020 13:00	8.3	2.9	1.4	7.6	1.6
07/07/2020 14:00	6.7	2.3	1.3	7.5	1.6
07/07/2020 15:00	4.5	0.9	1.5	8.2	1.8
07/07/2020 16:00	14.2	6.6	2.0	11.2	2.4
07/07/2020 17:00	14.7	5.3	2.1	11.6	2.6
07/07/2020 18:00	14.5	5.2	2.1	11.4	2.4
07/07/2020 19:00	14.5	5.3	2.0	11.4	2.4
07/07/2020 20:00	14.5	5.3	2.0	11.4	2.4
07/07/2020 21:00	14.5	5.3	2.0	11.3	2.4
07/07/2020 22:00	13.7	6.3	2.0	10.7	2.4
07/07/2020 23:00	12.9	5.1	1.9	10.0	2.2
Average/Sum#:	203.4 #	75.9 #	37.2 #	204.8 #	45.0 #
Minimum:	5.1	1.5	1.3	6.9	1.6
Maximum:	14.7	6.6	2.1	11.6	2.6
%SI	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/08/2020 00:00	5.2	1.8	1.3	7.1	1.6
07/08/2020 01:00	5.1	1.9	1.3	6.9	1.6
07/08/2020 02:00	5.1	1.7	1.3	6.9	1.6
07/08/2020 03:00	5.1	1.4	1.3	6.9	1.6
07/08/2020 04:00	5.1	1.4	1.3	7.0	1.6
07/08/2020 05:00	5.1	1.4	1.3	7.1	1.6
07/08/2020 06:00	5.1	1.4	1.3	7.0	1.6
07/08/2020 07:00	5.1	1.2	1.3	7.1	1.6
07/08/2020 08:00	5.1	1.4	1.3	7.1	1.6
07/08/2020 09:00	5.1	1.6	1.3	7.1	1.6
07/08/2020 10:00	6.4	1.4	1.3	7.1	1.6
07/08/2020 11:00	6.4	1.7	1.3	7.1	1.6
07/08/2020 12:00	8.1	1.8	1.3	7.4	1.6
07/08/2020 13:00	6.5	2.0	1.3	7.1	1.6
07/08/2020 14:00	8.1	1.8	1.3	7.4	1.6
07/08/2020 15:00	8.7	1.9	1.4	8.0	1.8
07/08/2020 16:00	14.2	6.1	2.0	11.2	2.4
07/08/2020 17:00	14.5	5.1	2.0	11.4	2.4
07/08/2020 18:00	14.6	4.8	2.1	11.4	2.5
07/08/2020 19:00	14.6	5.4	2.1	11.4	2.5
07/08/2020 20:00	14.6	5.1	2.1	11.4	2.5
07/08/2020 21:00	14.1	5.5	2.0	11.0	2.4
07/08/2020 22:00	13.8	5.9	2.0	10.8	2.4
07/08/2020 23:00	12.5	4.7	1.7	9.9	2.2
Average/Sum#:	208.2 #	68.4 #	36.9 #	202.8 #	45.1 #
Minimum:	5.1	1.2	1.3	6.9	1.6
Maximum:	14.6	6.1	2.1	11.4	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/09/2020 00:00	5.1	2.5	1.3	7.1	1.6
07/09/2020 01:00	6.4	2.4	1.3	7.1	1.6
07/09/2020 02:00	6.4	2.2	1.3	6.9	1.6
07/09/2020 03:00	6.6	2.3	1.3	7.3	1.6
07/09/2020 04:00	6.5	2.5	1.3	7.1	1.6
07/09/2020 05:00	6.7	2.3	1.3	7.4	1.6
07/09/2020 06:00	6.4	2.2	1.3	7.1	1.6
07/09/2020 07:00	6.4	1.9	1.3	7.0	1.6
07/09/2020 08:00	6.4	1.6	1.3	7.0	1.6
07/09/2020 09:00	6.4	2.0	1.3	7.1	1.6
07/09/2020 10:00	6.4	2.2	1.3	7.1	1.6
07/09/2020 11:00	6.4	1.7	1.3	7.1	1.6
07/09/2020 12:00	9.1	2.3	1.6	8.4	1.8
07/09/2020 13:00	9.9	2.4	1.6	9.1	2.0
07/09/2020 14:00	9.1	2.6	1.6	8.4	1.8
07/09/2020 15:00	14.2	6.1	2.0	11.2	2.4
07/09/2020 16:00	14.5	5.4	2.0	11.4	2.4
07/09/2020 17:00	14.6	4.8	2.1	11.6	2.6
07/09/2020 18:00	14.8	4.8	2.1	11.6	2.6
07/09/2020 19:00	14.8	4.8	2.1	11.6	2.6
07/09/2020 20:00	14.5	4.8	2.1	11.4	2.4
07/09/2020 21:00	14.5	5.2	2.1	11.4	2.4
07/09/2020 22:00	13.8	5.6	2.0	10.8	2.4
07/09/2020 23:00	13.4	6.2	1.9	10.6	2.3
Average/Sum#:	233.3 #	80.8 #	38.8 #	212.8 #	46.9 #
Minimum:	5.1	1.6	1.3	6.9	1.6
Maximum:	14.8	6.2	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/10/2020 00:00	5.5	1.8	1.4	7.6	1.6
07/10/2020 01:00	5.1	1.5	1.3	7.0	1.6
07/10/2020 02:00	5.1	1.2	1.3	7.0	1.6
07/10/2020 03:00	5.1	1.2	1.3	7.0	1.6
07/10/2020 04:00	5.1	1.2	1.3	7.1	1.6
07/10/2020 05:00	7.7	1.8	1.6	8.5	1.8
07/10/2020 06:00	10.0	2.2	1.7	9.2	2.0
07/10/2020 07:00	10.0	1.9	1.7	9.2	2.0
07/10/2020 08:00	9.4	1.8	1.6	8.6	1.8
07/10/2020 09:00	7.2	1.6	1.4	7.9	1.8
07/10/2020 10:00	7.4	1.7	1.4	8.1	1.8
07/10/2020 11:00	6.8	1.6	1.4	7.5	1.6
07/10/2020 12:00	9.2	2.4	1.6	8.5	1.8
07/10/2020 13:00	14.1	6.3	2.0	11.1	2.4
07/10/2020 14:00	14.6	5.5	2.1	11.5	2.5
07/10/2020 15:00	14.6	5.2	2.1	11.5	2.5
07/10/2020 16:00	14.8	4.9	2.1	11.7	2.6
07/10/2020 17:00	14.9	4.6	2.1	11.8	2.6
07/10/2020 18:00	15.0	4.6	2.1	11.8	2.6
07/10/2020 19:00	15.1	4.6	2.1	11.8	2.6
07/10/2020 20:00	15.1	4.6	2.1	11.8	2.6
07/10/2020 21:00	14.5	5.5	2.1	11.3	2.5
07/10/2020 22:00	14.5	5.6	2.1	11.5	2.5
07/10/2020 23:00	12.6	4.8	1.8	9.9	2.2
Average/Sum#:	253.4 #	78.1 #	41.7 #	228.9 #	50.2 #
Minimum:	5.1	1.2	1.3	7.0	1.6
Maximum:	15.1	6.3	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/11/2020 00:00	6.5	2.9	1.3	7.1	1.6
07/11/2020 01:00	6.7	3.1	1.3	7.4	1.6
07/11/2020 02:00	6.8	2.6	1.3	7.5	1.6
07/11/2020 03:00	6.8	2.6	1.4	7.5	1.6
07/11/2020 04:00	6.7	2.3	1.3	7.3	1.6
07/11/2020 05:00	10.0	3.1	1.7	9.1	2.0
07/11/2020 06:00	9.6	3.3	1.6	8.8	2.0
07/11/2020 07:00	6.8	2.4	1.4	7.5	1.6
07/11/2020 08:00	9.5	2.4	1.6	8.7	1.9
07/11/2020 09:00	6.5	2.2	1.3	7.2	1.6
07/11/2020 10:00	8.8	2.2	1.4	8.1	1.8
07/11/2020 11:00	9.6	2.4	1.6	8.8	2.0
07/11/2020 12:00	9.8	2.4	1.6	8.9	2.0
07/11/2020 13:00	6.8	2.1	1.4	7.5	1.6
07/11/2020 14:00	6.8	1.8	1.4	7.5	1.6
07/11/2020 15:00	14.4	4.8	1.8	9.9	2.2
07/11/2020 16:00	14.8	5.2	2.1	11.6	2.6
07/11/2020 17:00	15.0	4.6	2.1	11.7	2.6
07/11/2020 18:00	15.1	4.3	2.1	11.9	2.6
07/11/2020 19:00	15.1	4.3	2.1	11.9	2.6
07/11/2020 20:00	14.7	4.9	2.1	11.7	2.6
07/11/2020 21:00	14.5	5.2	2.1	11.4	2.5
07/11/2020 22:00	14.6	5.7	2.1	11.5	2.5
07/11/2020 23:00	12.7	5.1	1.8	10.0	2.2
Average/Sum#:	248.6 #	81.9 #	39.9 #	220.5 #	48.5 #
Minimum:	6.5	1.8	1.3	7.1	1.6
Maximum:	15.1	5.7	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/12/2020 00:00	6.5	2.2	1.3	7.1	1.6
07/12/2020 01:00	6.5	2.0	1.3	7.1	1.6
07/12/2020 02:00	6.5	2.7	1.3	7.1	1.6
07/12/2020 03:00	6.5	2.4	1.3	7.1	1.6
07/12/2020 04:00	5.2	2.0	1.3	7.1	1.6
07/12/2020 05:00	6.5	2.2	1.3	7.1	1.6
07/12/2020 06:00	6.5	2.2	1.3	7.1	1.6
07/12/2020 07:00	6.5	1.7	1.3	7.1	1.6
07/12/2020 08:00	6.5	1.8	1.3	7.1	1.6
07/12/2020 09:00	6.5	1.8	1.3	7.2	1.6
07/12/2020 10:00	8.4	1.9	1.4	7.7	1.6
07/12/2020 11:00	6.8	2.4	1.4	7.5	1.6
07/12/2020 12:00	8.6	2.4	1.4	7.9	1.8
07/12/2020 13:00	8.2	2.1	1.4	7.5	1.6
07/12/2020 14:00	6.5	1.8	1.3	7.2	1.6
07/12/2020 15:00	9.8	2.4	1.7	9.0	2.0
07/12/2020 16:00	14.5	5.8	2.1	11.4	2.5
07/12/2020 17:00	14.9	4.5	2.1	11.7	2.6
07/12/2020 18:00	14.9	4.8	2.1	11.7	2.6
07/12/2020 19:00	14.9	4.8	2.1	11.7	2.6
07/12/2020 20:00	14.5	5.2	2.1	11.3	2.5
07/12/2020 21:00	14.3	5.8	2.0	11.3	2.4
07/12/2020 22:00	14.5	5.5	2.1	11.5	2.5
07/12/2020 23:00	13.6	6.1	2.0	10.7	2.4
Average/Sum#:	228.1 #	76.5 #	38.2 #	209.2 #	46.3 #
Minimum:	5.2	1.7	1.3	7.1	1.6
Maximum:	14.9	6.1	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/13/2020 00:00	9.4	3.3	1.6	8.7	1.8
07/13/2020 01:00	8.6	3.0	1.4	7.9	1.8
07/13/2020 02:00	6.6	2.7	1.3	7.3	1.6
07/13/2020 03:00	6.5	2.7	1.3	7.1	1.6
07/13/2020 04:00	6.5	2.4	1.3	7.1	1.6
07/13/2020 05:00	9.8	3.0	1.6	9.0	2.0
07/13/2020 06:00	7.5	3.1	1.4	8.2	1.8
07/13/2020 07:00	7.0	2.8	1.4	7.7	1.6
07/13/2020 08:00	9.2	2.8	1.6	8.4	1.8
07/13/2020 09:00	6.5	2.5	1.3	7.2	1.6
07/13/2020 10:00	8.8	2.2	1.4	8.1	1.8
07/13/2020 11:00	9.8	2.4	1.6	9.0	2.0
07/13/2020 12:00	14.1	6.6	2.0	11.1	2.4
07/13/2020 13:00	14.5	5.5	2.1	11.4	2.5
07/13/2020 14:00	14.7	5.2	2.1	11.5	2.5
07/13/2020 15:00	14.7	4.9	2.1	11.5	2.5
07/13/2020 16:00	14.7	4.8	2.1	11.6	2.5
07/13/2020 17:00	14.8	4.9	2.1	11.7	2.6
07/13/2020 18:00	14.8	4.2	2.1	11.7	2.6
07/13/2020 19:00	14.7	4.6	2.1	11.6	2.5
07/13/2020 20:00	14.7	4.9	2.1	11.5	2.5
07/13/2020 21:00	14.5	5.2	2.1	11.5	2.5
07/13/2020 22:00	14.5	5.2	2.1	11.4	2.5
07/13/2020 23:00	13.7	6.0	2.0	10.7	2.4
Average/Sum#:	270.6 #	94.9 #	42.2 #	232.9 #	51.0 #
Minimum:	6.5	2.2	1.3	7.1	1.6
Maximum:	14.8	6.6	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/14/2020 00:00	12.5	4.8	1.8	9.8	2.2
07/14/2020 01:00	5.2	2.7	1.3	7.1	1.6
07/14/2020 02:00	6.8	2.3	1.3	7.5	1.6
07/14/2020 03:00	6.5	2.7	1.3	7.1	1.6
07/14/2020 04:00	6.5	2.7	1.3	7.1	1.6
07/14/2020 05:00	9.8	3.4	1.6	9.0	2.0
07/14/2020 06:00	10.0	3.4	1.7	9.2	2.0
07/14/2020 07:00	10.0	2.8	1.7	9.2	2.0
07/14/2020 08:00	9.3	2.4	1.6	8.5	1.8
07/14/2020 09:00	6.5	2.4	1.3	7.1	1.6
07/14/2020 10:00	6.5	2.5	1.3	7.2	1.6
07/14/2020 11:00	6.8	2.6	1.4	7.5	1.6
07/14/2020 12:00	9.2	2.6	1.6	8.4	1.8
07/14/2020 13:00	6.7	2.6	1.3	7.4	1.6
07/14/2020 14:00	13.9	6.5	2.0	11.0	2.4
07/14/2020 15:00	14.4	5.8	2.1	11.3	2.4
07/14/2020 16:00	14.5	5.5	2.1	11.4	2.5
07/14/2020 17:00	14.6	5.2	2.1	11.5	2.5
07/14/2020 18:00	14.7	5.2	2.1	11.5	2.5
07/14/2020 19:00	14.7	5.1	2.1	11.5	2.5
07/14/2020 20:00	14.7	5.2	2.1	11.5	2.5
07/14/2020 21:00	14.7	5.2	2.1	11.5	2.5
07/14/2020 22:00	13.7	6.0	2.0	10.9	2.4
07/14/2020 23:00	12.5	5.1	1.8	9.8	2.2
Average/Sum#:	254.7 #	94.7 #	41.0 #	224.0 #	49.0 #
Minimum:	5.2	2.3	1.3	7.1	1.6
Maximum:	14.7	6.5	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/15/2020 00:00	5.2	3.4	1.3	7.1	1.6
07/15/2020 01:00	6.5	2.9	1.3	7.1	1.6
07/15/2020 02:00	6.5	2.7	1.3	7.1	1.6
07/15/2020 03:00	6.5	2.7	1.3	7.1	1.6
07/15/2020 04:00	6.5	2.7	1.3	7.1	1.6
07/15/2020 05:00	6.6	2.9	1.3	7.2	1.6
07/15/2020 06:00	6.5	2.9	1.3	7.2	1.6
07/15/2020 07:00	6.5	2.7	1.3	7.1	1.6
07/15/2020 08:00	6.5	2.7	1.3	7.1	1.6
07/15/2020 09:00	6.5	2.7	1.3	7.1	1.6
07/15/2020 10:00	6.5	2.7	1.3	7.1	1.6
07/15/2020 11:00	6.5	2.4	1.3	7.1	1.6
07/15/2020 12:00	6.5	2.4	1.3	7.1	1.6
07/15/2020 13:00	6.5	2.4	1.3	7.1	1.6
07/15/2020 14:00	6.5	2.5	1.3	7.2	1.6
07/15/2020 15:00	6.5	2.4	1.3	7.2	1.6
07/15/2020 16:00	6.5	2.8	1.3	7.2	1.6
07/15/2020 17:00	6.5	2.5	1.3	7.2	1.6
07/15/2020 18:00	8.4	2.6	1.4	7.7	1.6
07/15/2020 19:00	8.8	2.8	1.4	8.1	1.8
07/15/2020 20:00	6.8	2.6	1.4	7.5	1.6
07/15/2020 21:00	6.5	2.7	1.3	7.1	1.6
07/15/2020 22:00	6.5	3.1	1.3	7.1	1.6
07/15/2020 23:00	6.6	2.7	1.3	7.2	1.6
Average/Sum#:	159.4 #	64.9 #	31.5 #	173.1 #	38.6 #
Minimum:	5.2	2.4	1.3	7.1	1.6
Maximum:	8.8	3.4	1.4	8.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/16/2020 00:00	6.5	2.7	1.3	7.1	1.6
07/16/2020 01:00	6.5	2.9	1.3	7.1	1.6
07/16/2020 02:00	6.5	2.9	1.3	7.1	1.6
07/16/2020 03:00	5.2	3.1	1.3	7.0	1.6
07/16/2020 04:00	5.2	3.4	1.3	7.0	1.6
07/16/2020 05:00	5.2	3.4	1.3	7.0	1.6
07/16/2020 06:00	6.5	2.9	1.3	7.1	1.6
07/16/2020 07:00	6.5	2.9	1.3	7.1	1.6
07/16/2020 08:00	6.5	3.0	1.3	7.1	1.6
07/16/2020 09:00	6.5	2.7	1.3	7.1	1.6
07/16/2020 10:00	6.5	2.4	1.3	7.1	1.6
07/16/2020 11:00	6.5	2.4	1.3	7.1	1.6
07/16/2020 12:00	6.5	2.7	1.3	7.1	1.6
07/16/2020 13:00	6.5	2.4	1.3	7.1	1.6
07/16/2020 14:00	8.8	2.5	1.4	8.1	1.8
07/16/2020 15:00	9.0	3.1	1.6	8.3	1.8
07/16/2020 16:00	14.3	6.4	2.0	11.3	2.4
07/16/2020 17:00	14.5	5.4	2.1	11.5	2.5
07/16/2020 18:00	14.5	5.5	2.1	11.4	2.5
07/16/2020 19:00	14.7	5.2	2.1	11.5	2.5
07/16/2020 20:00	14.7	5.2	2.1	11.5	2.5
07/16/2020 21:00	14.6	5.5	2.1	11.5	2.5
07/16/2020 22:00	13.7	6.3	2.0	10.8	2.4
07/16/2020 23:00	12.5	5.1	1.8	9.8	2.2
Average/Sum#:	218.4 #	90.0 #	37.5 #	204.8 #	45.5 #
Minimum:	5.2	2.4	1.3	7.0	1.6
Maximum:	14.7	6.4	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/17/2020 00:00	5.2	3.2	1.3	7.1	1.6
07/17/2020 01:00	5.2	2.7	1.3	7.1	1.6
07/17/2020 02:00	6.5	2.7	1.3	7.1	1.6
07/17/2020 03:00	6.5	2.7	1.3	7.2	1.6
07/17/2020 04:00	6.5	2.7	1.3	7.1	1.6
07/17/2020 05:00	5.2	2.9	1.3	7.2	1.6
07/17/2020 06:00	5.2	2.7	1.3	7.2	1.6
07/17/2020 07:00	6.5	2.2	1.3	7.1	1.6
07/17/2020 08:00	6.5	2.0	1.3	7.2	1.6
07/17/2020 09:00	6.5	2.2	1.3	7.2	1.6
07/17/2020 10:00	6.5	2.4	1.3	7.2	1.6
07/17/2020 11:00	6.5	2.5	1.3	7.2	1.6
07/17/2020 12:00	6.6	2.5	1.3	7.3	1.6
07/17/2020 13:00	6.7	2.6	1.3	7.3	1.6
07/17/2020 14:00	6.5	2.4	1.3	7.2	1.6
07/17/2020 15:00	6.5	2.4	1.3	7.2	1.6
07/17/2020 16:00	9.0	3.1	1.6	8.3	1.8
07/17/2020 17:00	14.3	6.4	2.0	11.3	2.4
07/17/2020 18:00	14.6	5.8	2.1	11.5	2.5
07/17/2020 19:00	14.7	5.8	2.1	11.5	2.5
07/17/2020 20:00	14.7	5.8	2.1	11.5	2.5
07/17/2020 21:00	14.6	5.9	2.1	11.5	2.5
07/17/2020 22:00	13.8	6.3	2.0	10.9	2.4
07/17/2020 23:00	14.9	5.6	1.9	10.2	2.2
Average/Sum#:	209.7 #	85.5 #	36.7 #	201.6 #	44.4 #
Minimum:	5.2	2.0	1.3	7.1	1.6
Maximum:	14.9	6.4	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/18/2020 00:00	12.3	2.9	1.7	9.6	2.1
07/18/2020 01:00	9.6	3.3	1.6	8.8	2.0
07/18/2020 02:00	5.2	3.4	1.3	7.2	1.6
07/18/2020 03:00	5.2	2.7	1.3	7.2	1.6
07/18/2020 04:00	5.2	2.7	1.3	7.3	1.6
07/18/2020 05:00	6.8	2.6	1.3	7.5	1.6
07/18/2020 06:00	5.2	2.7	1.3	7.1	1.6
07/18/2020 07:00	6.5	2.4	1.3	7.1	1.6
07/18/2020 08:00	6.5	2.4	1.3	7.1	1.6
07/18/2020 09:00	6.5	2.4	1.3	7.2	1.6
07/18/2020 10:00	6.5	2.4	1.3	7.2	1.6
07/18/2020 11:00	7.0	2.4	1.4	7.7	1.6
07/18/2020 12:00	7.0	2.4	1.4	7.7	1.6
07/18/2020 13:00	11.1	3.0	1.6	8.8	2.0
07/18/2020 14:00	19.9	7.2	2.0	10.9	2.4
07/18/2020 15:00	10.6	3.3	1.6	8.3	1.8
07/18/2020 16:00	11.2	2.7	1.6	8.8	2.0
07/18/2020 17:00	20.4	5.8	2.1	11.2	2.4
07/18/2020 18:00	21.3	4.8	2.1	11.7	2.6
07/18/2020 19:00	19.3	4.8	2.1	11.7	2.6
07/18/2020 20:00	14.7	5.1	2.1	11.5	2.5
07/18/2020 21:00	13.9	5.8	2.0	10.9	2.4
07/18/2020 22:00	13.9	6.5	2.0	10.9	2.4
07/18/2020 23:00	13.0	5.8	1.9	10.2	2.2
Average/Sum#:	258.8 #	89.5 #	38.9 #	213.6 #	47.0 #
Minimum:	5.2	2.4	1.3	7.1	1.6
Maximum:	21.3	7.2	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/19/2020 00:00	12.2	4.1	1.7	9.6	2.1
07/19/2020 01:00	5.2	4.0	1.3	7.2	1.6
07/19/2020 02:00	5.2	3.7	1.3	7.1	1.6
07/19/2020 03:00	5.2	3.7	1.3	7.1	1.6
07/19/2020 04:00	5.2	3.2	1.3	7.1	1.6
07/19/2020 05:00	5.2	2.9	1.3	7.1	1.6
07/19/2020 06:00	5.2	2.9	1.3	7.1	1.6
07/19/2020 07:00	6.5	2.7	1.3	7.1	1.6
07/19/2020 08:00	6.5	2.4	1.3	7.2	1.6
07/19/2020 09:00	6.5	2.4	1.3	7.2	1.6
07/19/2020 10:00	6.5	2.4	1.3	7.2	1.6
07/19/2020 11:00	6.5	2.4	1.3	7.2	1.6
07/19/2020 12:00	6.5	2.4	1.3	7.2	1.6
07/19/2020 13:00	6.5	2.4	1.3	7.2	1.6
07/19/2020 14:00	6.5	2.2	1.3	7.2	1.6
07/19/2020 15:00	6.5	2.2	1.3	7.2	1.6
07/19/2020 16:00	9.0	2.5	1.4	8.2	1.8
07/19/2020 17:00	14.2	6.1	2.0	11.1	2.4
07/19/2020 18:00	14.7	4.8	2.1	11.5	2.5
07/19/2020 19:00	14.7	4.9	2.1	11.5	2.5
07/19/2020 20:00	14.6	5.2	2.1	11.5	2.5
07/19/2020 21:00	14.5	5.8	2.1	11.4	2.5
07/19/2020 22:00	13.7	6.3	2.0	10.8	2.4
07/19/2020 23:00	12.5	5.1	1.8	9.8	2.2
Average/Sum#:	209.8 #	86.7 #	36.8 #	202.8 #	44.9 #
Minimum:	5.2	2.2	1.3	7.1	1.6
Maximum:	14.7	6.3	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/20/2020 00:00	5.2	2.9	1.3	7.1	1.6
07/20/2020 01:00	5.2	2.6	1.3	7.0	1.6
07/20/2020 02:00	5.2	2.6	1.3	7.0	1.6
07/20/2020 03:00	5.2	2.6	1.3	7.0	1.6
07/20/2020 04:00	5.2	2.6	1.3	7.0	1.6
07/20/2020 05:00	5.2	2.9	1.3	7.2	1.6
07/20/2020 06:00	10.0	2.8	1.7	9.2	2.0
07/20/2020 07:00	9.8	2.4	1.6	9.0	2.0
07/20/2020 08:00	10.0	2.5	1.7	9.2	2.0
07/20/2020 09:00	7.0	2.4	1.4	7.6	1.6
07/20/2020 10:00	9.2	2.3	1.6	8.4	1.8
07/20/2020 11:00	9.2	2.4	1.6	8.5	1.8
07/20/2020 12:00	9.2	2.8	1.6	8.4	1.8
07/20/2020 13:00	14.1	6.4	2.0	11.1	2.4
07/20/2020 14:00	13.9	6.1	2.0	10.9	2.4
07/20/2020 15:00	14.3	5.5	2.1	11.3	2.4
07/20/2020 16:00	14.4	5.2	2.1	11.3	2.4
07/20/2020 17:00	14.5	5.1	2.1	11.3	2.5
07/20/2020 18:00	14.7	4.8	2.1	11.5	2.5
07/20/2020 19:00	14.7	5.2	2.1	11.5	2.5
07/20/2020 20:00	14.6	5.2	2.1	11.5	2.5
07/20/2020 21:00	14.5	5.8	2.1	11.3	2.5
07/20/2020 22:00	13.9	5.6	2.0	10.9	2.4
07/20/2020 23:00	12.3	3.9	1.7	9.7	2.2
Average/Sum#:	251.5 #	92.6 #	41.4 #	224.9 #	49.3 #
Minimum:	5.2	2.3	1.3	7.0	1.6
Maximum:	14.7	6.4	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/21/2020 00:00	5.2	2.2	1.3	7.0	1.6
07/21/2020 01:00	5.2	2.2	1.3	7.0	1.6
07/21/2020 02:00	5.2	2.4	1.3	7.0	1.6
07/21/2020 03:00	5.2	2.6	1.3	7.0	1.6
07/21/2020 04:00	5.2	2.6	1.3	7.0	1.6
07/21/2020 05:00	5.2	2.9	1.3	7.1	1.6
07/21/2020 06:00	9.9	2.8	1.7	9.0	2.0
07/21/2020 07:00	9.2	2.5	1.6	8.4	1.8
07/21/2020 08:00	7.6	2.6	1.6	8.4	1.8
07/21/2020 09:00	6.8	2.6	1.4	7.5	1.6
07/21/2020 10:00	9.0	2.2	1.6	8.3	1.8
07/21/2020 11:00	6.8	2.4	1.4	7.5	1.6
07/21/2020 12:00	6.9	2.6	1.4	7.6	1.6
07/21/2020 13:00	12.6	5.4	1.8	9.9	2.2
07/21/2020 14:00	14.4	5.7	2.1	11.3	2.4
07/21/2020 15:00	14.5	5.1	2.1	11.4	2.5
07/21/2020 16:00	14.7	5.1	2.1	11.5	2.5
07/21/2020 17:00	14.9	4.8	2.1	11.7	2.6
07/21/2020 18:00	14.8	4.8	2.1	11.7	2.6
07/21/2020 19:00	14.7	4.9	2.1	11.5	2.5
07/21/2020 20:00	14.7	5.2	2.1	11.5	2.5
07/21/2020 21:00	14.5	5.2	2.1	11.4	2.5
07/21/2020 22:00	13.9	6.0	2.0	10.9	2.4
07/21/2020 23:00	12.8	4.0	1.8	10.1	2.2
Average/Sum#:	243.9 #	88.8 #	40.9 #	221.7 #	48.7 #
Minimum:	5.2	2.2	1.3	7.0	1.6
Maximum:	14.9	6.0	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/22/2020 00:00	7.0	2.3	1.4	7.7	1.6
07/22/2020 01:00	5.2	2.2	1.3	7.0	1.6
07/22/2020 02:00	5.2	2.6	1.3	7.0	1.6
07/22/2020 03:00	5.2	2.9	1.3	7.0	1.6
07/22/2020 04:00	5.2	2.9	1.3	7.1	1.6
07/22/2020 05:00	5.5	3.4	1.4	7.5	1.6
07/22/2020 06:00	10.0	2.8	1.7	9.2	2.0
07/22/2020 07:00	5.4	2.9	1.4	7.5	1.6
07/22/2020 08:00	5.2	2.7	1.3	7.1	1.6
07/22/2020 09:00	5.2	2.2	1.3	7.1	1.6
07/22/2020 10:00	5.2	2.4	1.3	7.2	1.6
07/22/2020 11:00	6.5	2.2	1.3	7.2	1.6
07/22/2020 12:00	6.5	2.4	1.3	7.1	1.6
07/22/2020 13:00	6.5	2.4	1.3	7.1	1.6
07/22/2020 14:00	6.5	2.4	1.3	7.1	1.6
07/22/2020 15:00	6.5	2.4	1.3	7.2	1.6
07/22/2020 16:00	9.8	2.7	1.6	9.0	2.0
07/22/2020 17:00	14.1	6.4	2.0	11.1	2.4
07/22/2020 18:00	14.5	5.5	2.1	11.4	2.5
07/22/2020 19:00	14.5	5.5	2.1	11.3	2.5
07/22/2020 20:00	14.5	6.0	2.1	11.3	2.5
07/22/2020 21:00	14.5	5.6	2.1	11.3	2.5
07/22/2020 22:00	13.7	6.0	2.0	10.7	2.4
07/22/2020 23:00	12.4	5.1	1.7	9.7	2.2
Average/Sum#:	204.8 #	83.9 #	37.2 #	202.9 #	45.0 #
Minimum:	5.2	2.2	1.3	7.0	1.6
Maximum:	14.5	6.4	2.1	11.4	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/23/2020 00:00	5.2	2.9	1.3	7.1	1.6
07/23/2020 01:00	5.2	2.9	1.3	7.0	1.6
07/23/2020 02:00	5.2	2.9	1.3	7.0	1.6
07/23/2020 03:00	5.2	2.9	1.3	7.0	1.6
07/23/2020 04:00	5.2	2.9	1.3	7.0	1.6
07/23/2020 05:00	5.2	3.1	1.3	7.1	1.6
07/23/2020 06:00	5.2	3.1	1.3	7.1	1.6
07/23/2020 07:00	5.2	2.9	1.3	7.1	1.6
07/23/2020 08:00	5.2	2.7	1.3	7.1	1.6
07/23/2020 09:00	5.2	2.4	1.3	7.1	1.6
07/23/2020 10:00	5.2	2.4	1.3	7.1	1.6
07/23/2020 11:00	5.2	2.4	1.3	7.1	1.6
07/23/2020 12:00	6.5	2.4	1.3	7.1	1.6
07/23/2020 13:00	6.5	2.4	1.3	7.1	1.6
07/23/2020 14:00	6.5	2.2	1.3	7.1	1.6
07/23/2020 15:00	6.5	2.2	1.3	7.1	1.6
07/23/2020 16:00	6.5	2.2	1.3	7.1	1.6
07/23/2020 17:00	7.0	2.4	1.4	7.7	1.6
07/23/2020 18:00	9.8	3.0	1.6	9.0	2.0
07/23/2020 19:00	9.6	3.0	1.6	8.8	2.0
07/23/2020 20:00	8.6	3.5	1.4	7.9	1.8
07/23/2020 21:00	6.7	2.8	1.3	7.3	1.6
07/23/2020 22:00	5.2	3.2	1.3	7.1	1.6
07/23/2020 23:00	6.6	3.3	1.3	7.3	1.6
Average/Sum#:	148.4 #	66.1 #	32.0 #	175.4 #	39.4 #
Minimum:	5.2	2.2	1.3	7.0	1.6
Maximum:	9.8	3.5	1.6	9.0	2.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/24/2020 00:00	5.2	3.2	1.3	7.0	1.6
07/24/2020 01:00	5.2	2.9	1.3	7.0	1.6
07/24/2020 02:00	5.2	2.9	1.3	7.0	1.6
07/24/2020 03:00	5.2	3.1	1.3	7.0	1.6
07/24/2020 04:00	5.2	3.4	1.3	7.0	1.6
07/24/2020 05:00	5.2	3.7	1.3	7.1	1.6
07/24/2020 06:00	5.2	3.7	1.3	7.3	1.6
07/24/2020 07:00	5.5	2.2	1.2	5.0	1.1
07/24/2020 08:00	2.9	1.9	1.0	3.7	0.9
07/24/2020 09:00	4.1	1.8	1.0	3.4	0.8
07/24/2020 10:00	4.1	1.8	1.0	3.5	0.8
07/24/2020 11:00	4.2	1.6	1.0	3.5	0.8
07/24/2020 12:00	4.2	1.6	1.0	3.5	0.8
07/24/2020 13:00	4.2	1.6	1.0	3.5	0.8
07/24/2020 14:00	4.2	1.6	1.0	3.5	0.8
07/24/2020 15:00	4.2	1.6	1.0	3.5	0.8
07/24/2020 16:00	4.3	1.6	1.0	3.5	0.9
07/24/2020 17:00	5.9	5.8	1.4	4.9	1.2
07/24/2020 18:00	5.9	5.8	1.4	4.9	1.2
07/24/2020 19:00	5.9	5.9	1.4	4.9	1.2
07/24/2020 20:00	5.8	5.8	1.4	4.8	1.2
07/24/2020 21:00	2.8	2.1	1.0	3.5	0.8
07/24/2020 22:00	4.1	1.8	1.0	3.4	0.8
07/24/2020 23:00	4.1	2.1	1.0	3.4	0.8
Average/Sum#:	112.8 #	69.5 #	27.9 #	115.8 #	26.9 #
Minimum:	2.8	1.6	1.0	3.4	0.8
Maximum:	5.9	5.9	1.4	7.3	1.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/25/2020 00:00	4.1	2.1	1.0	3.4	0.8
07/25/2020 01:00	4.1	2.3	1.0	3.4	0.8
07/25/2020 02:00	4.1	2.3	1.0	3.4	0.8
07/25/2020 03:00	4.1	2.3	1.0	3.4	0.8
07/25/2020 04:00	4.1	2.6	1.0	3.4	0.8
07/25/2020 05:00	4.1	2.6	1.0	3.4	0.8
07/25/2020 06:00	4.1	2.6	1.0	3.4	0.8
07/25/2020 07:00	4.2	2.1	1.0	3.5	0.8
07/25/2020 08:00	4.2	1.8	1.0	3.5	0.8
07/25/2020 09:00	4.2	1.8	1.0	3.5	0.8
07/25/2020 10:00	4.2	1.6	1.0	3.5	0.8
07/25/2020 11:00	4.2	1.6	1.0	3.5	0.8
07/25/2020 12:00	4.2	1.6	1.0	3.5	0.8
07/25/2020 13:00	45.4	46.9	1.2	4.6	1.0
07/25/2020 14:00	60.3	37.8	1.2	6.1	1.4
07/25/2020 15:00	7.8	2.4	1.6	8.5	1.8
07/25/2020 16:00	9.2	2.6	1.6	8.5	1.8
07/25/2020 17:00	14.2	6.1	2.0	11.1	2.4
07/25/2020 18:00	14.7	4.9	2.1	11.5	2.5
07/25/2020 19:00	14.7	4.9	2.1	11.5	2.5
07/25/2020 20:00	14.7	4.9	2.1	11.5	2.5
07/25/2020 21:00	14.5	5.2	2.1	11.5	2.5
07/25/2020 22:00	14.1	5.9	2.0	11.1	2.4
07/25/2020 23:00	14.3	5.2	2.0	11.1	2.4
Average/Sum#:	277.8 #	154.1 #	33.0 #	151.8 #	33.6 #
Minimum:	4.1	1.6	1.0	3.4	0.8
Maximum:	60.3	46.9	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/26/2020 00:00	5.8	2.4	1.4	7.9	1.8
07/26/2020 01:00	9.6	2.4	1.6	8.8	2.0
07/26/2020 02:00	7.7	2.6	1.6	8.5	1.8
07/26/2020 03:00	7.5	2.8	1.5	8.3	1.8
07/26/2020 04:00	7.7	2.6	1.6	8.4	1.8
07/26/2020 05:00	5.6	2.6	1.4	7.7	1.6
07/26/2020 06:00	5.2	2.7	1.3	7.0	1.6
07/26/2020 07:00	5.2	2.4	1.3	7.1	1.6
07/26/2020 08:00	5.2	2.2	1.3	7.1	1.6
07/26/2020 09:00	5.2	2.6	1.3	7.1	1.6
07/26/2020 10:00	6.9	2.6	1.4	7.6	1.6
07/26/2020 11:00	9.2	2.6	1.6	8.4	1.8
07/26/2020 12:00	9.2	2.4	1.6	8.5	1.8
07/26/2020 13:00	11.8	2.8	1.7	9.4	2.0
07/26/2020 14:00	14.1	6.1	2.0	11.1	2.4
07/26/2020 15:00	9.8	3.4	1.6	9.0	2.0
07/26/2020 16:00	12.5	4.5	1.8	9.8	2.2
07/26/2020 17:00	14.9	5.1	2.1	11.7	2.6
07/26/2020 18:00	14.9	4.5	2.1	11.7	2.6
07/26/2020 19:00	14.9	4.2	2.1	11.7	2.6
07/26/2020 20:00	14.7	4.8	2.1	11.5	2.5
07/26/2020 21:00	14.7	4.9	2.1	11.5	2.5
07/26/2020 22:00	13.8	5.8	2.0	10.9	2.4
07/26/2020 23:00	12.5	4.7	1.8	9.8	2.2
Average/Sum#:	238.6 #	83.7 #	40.3 #	220.5 #	48.4 #
Minimum:	5.2	2.2	1.3	7.0	1.6
Maximum:	14.9	6.1	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/27/2020 00:00	5.2	3.1	1.3	7.1	1.6
07/27/2020 01:00	5.2	3.1	1.3	7.1	1.6
07/27/2020 02:00	5.2	2.6	1.3	7.0	1.6
07/27/2020 03:00	5.2	2.2	1.3	7.1	1.6
07/27/2020 04:00	5.2	2.9	1.3	7.1	1.6
07/27/2020 05:00	8.2	2.7	1.7	9.0	2.0
07/27/2020 06:00	10.0	2.8	1.7	9.2	2.0
07/27/2020 07:00	10.0	2.2	1.7	9.2	2.0
07/27/2020 08:00	9.8	2.2	1.7	9.0	2.0
07/27/2020 09:00	5.4	2.0	1.3	7.4	1.6
07/27/2020 10:00	9.4	2.4	1.6	8.6	1.8
07/27/2020 11:00	9.2	2.6	1.6	8.5	1.8
07/27/2020 12:00	14.3	6.4	2.1	11.3	2.4
07/27/2020 13:00	14.7	5.1	2.1	11.7	2.6
07/27/2020 14:00	14.5	5.1	2.1	11.5	2.5
07/27/2020 15:00	14.7	5.1	2.1	11.7	2.6
07/27/2020 16:00	14.9	5.1	2.1	11.7	2.6
07/27/2020 17:00	14.9	5.1	2.1	11.7	2.6
07/27/2020 18:00	14.7	4.5	2.1	11.6	2.5
07/27/2020 19:00	14.7	4.8	2.1	11.5	2.5
07/27/2020 20:00	14.9	4.5	2.1	11.7	2.6
07/27/2020 21:00	14.7	4.5	2.1	11.5	2.5
07/27/2020 22:00	14.7	4.5	2.1	11.5	2.5
07/27/2020 23:00	13.6	5.1	2.0	10.7	2.4
Average/Sum#:	263.3 #	90.6 #	42.9 #	234.4 #	51.5 #
Minimum:	5.2	2.0	1.3	7.0	1.6
Maximum:	14.9	6.4	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/28/2020 00:00	9.2	2.3	1.6	8.5	1.8
07/28/2020 01:00	7.5	3.0	1.5	8.3	1.8
07/28/2020 02:00	7.1	2.7	1.4	7.9	1.8
07/28/2020 03:00	7.5	2.5	1.5	8.3	1.8
07/28/2020 04:00	7.7	2.6	1.6	8.5	1.8
07/28/2020 05:00	9.6	2.7	1.6	8.8	2.0
07/28/2020 06:00	10.2	2.8	1.7	9.3	2.0
07/28/2020 07:00	10.0	2.5	1.7	9.2	2.0
07/28/2020 08:00	7.6	2.6	1.6	8.4	1.8
07/28/2020 09:00	5.2	2.5	1.3	7.2	1.6
07/28/2020 10:00	9.2	2.0	1.6	8.4	1.8
07/28/2020 11:00	9.0	2.3	1.5	8.3	1.8
07/28/2020 12:00	14.3	6.1	2.0	11.3	2.4
07/28/2020 13:00	14.6	5.1	2.1	11.5	2.5
07/28/2020 14:00	14.7	5.1	2.1	11.5	2.5
07/28/2020 15:00	14.9	4.8	2.1	11.7	2.6
07/28/2020 16:00	14.9	4.8	2.1	11.7	2.6
07/28/2020 17:00	14.9	4.8	2.1	11.7	2.6
07/28/2020 18:00	14.9	4.5	2.1	11.7	2.6
07/28/2020 19:00	14.7	4.5	2.1	11.5	2.5
07/28/2020 20:00	14.8	4.6	2.1	11.7	2.6
07/28/2020 21:00	14.8	4.9	2.1	11.7	2.6
07/28/2020 22:00	14.7	4.9	2.1	11.5	2.5
07/28/2020 23:00	14.5	5.8	2.1	11.4	2.5
Average/Sum#:	276.5 #	90.4 #	43.7 #	240.0 #	52.5 #
Minimum:	5.2	2.0	1.3	7.2	1.6
Maximum:	14.9	6.1	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/29/2020 00:00	13.7	6.2	2.0	10.8	2.4
07/29/2020 01:00	13.5	6.3	2.0	10.7	2.4
07/29/2020 02:00	13.5	6.3	2.0	10.7	2.4
07/29/2020 03:00	13.7	6.3	2.0	10.7	2.4
07/29/2020 04:00	14.4	6.0	2.0	11.4	2.4
07/29/2020 05:00	16.6	6.0	2.1	11.4	2.5
07/29/2020 06:00	14.4	5.7	2.0	11.4	2.4
07/29/2020 07:00	13.7	6.0	2.0	10.8	2.4
07/29/2020 08:00	13.7	6.0	2.0	10.7	2.4
07/29/2020 09:00	13.7	6.0	2.0	10.8	2.4
07/29/2020 10:00	14.6	5.3	2.1	11.4	2.5
07/29/2020 11:00	14.6	5.2	2.1	11.5	2.5
07/29/2020 12:00	14.7	5.2	2.1	11.5	2.5
07/29/2020 13:00	14.6	5.1	2.1	11.5	2.5
07/29/2020 14:00	14.9	5.1	2.1	11.7	2.6
07/29/2020 15:00	14.9	4.5	2.1	11.7	2.6
07/29/2020 16:00	14.9	4.5	2.1	11.7	2.6
07/29/2020 17:00	14.9	4.5	2.1	11.7	2.6
07/29/2020 18:00	14.9	4.5	2.1	11.7	2.6
07/29/2020 19:00	15.0	4.2	2.1	11.8	2.6
07/29/2020 20:00	14.9	4.2	2.1	11.7	2.6
07/29/2020 21:00	14.6	4.9	2.1	11.5	2.5
07/29/2020 22:00	14.8	4.9	2.1	11.6	2.6
07/29/2020 23:00	14.6	4.9	2.1	11.5	2.5
Average/Sum#:	347.8 #	127.8 #	49.5 #	271.9 #	59.9 #
Minimum:	13.5	4.2	2.0	10.7	2.4
Maximum:	16.6	6.3	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/30/2020 00:00	14.5	5.3	2.1	11.4	2.5
07/30/2020 01:00	13.7	6.0	2.0	10.7	2.4
07/30/2020 02:00	13.6	6.3	2.0	10.7	2.4
07/30/2020 03:00	13.5	6.3	2.0	10.7	2.4
07/30/2020 04:00	13.7	6.4	2.0	10.7	2.4
07/30/2020 05:00	14.5	6.0	2.1	11.4	2.4
07/30/2020 06:00	14.4	6.0	2.0	11.4	2.4
07/30/2020 07:00	13.7	5.7	2.0	10.7	2.4
07/30/2020 08:00	13.6	5.7	2.0	10.7	2.4
07/30/2020 09:00	13.7	5.7	2.0	10.8	2.4
07/30/2020 10:00	14.5	5.3	2.1	11.4	2.5
07/30/2020 11:00	14.7	4.9	2.1	11.5	2.5
07/30/2020 12:00	14.6	4.9	2.1	11.5	2.5
07/30/2020 13:00	14.6	4.9	2.1	11.5	2.5
07/30/2020 14:00	14.7	4.9	2.1	11.5	2.5
07/30/2020 15:00	14.9	4.5	2.1	11.7	2.6
07/30/2020 16:00	14.9	4.5	2.1	11.7	2.6
07/30/2020 17:00	14.9	4.5	2.1	11.7	2.6
07/30/2020 18:00	14.9	4.5	2.1	11.7	2.6
07/30/2020 19:00	14.3	4.8	2.0	11.3	2.4
07/30/2020 20:00	14.4	4.9	2.1	11.3	2.4
07/30/2020 21:00	14.4	5.2	2.0	11.3	2.4
07/30/2020 22:00	14.6	4.9	2.1	11.5	2.5
07/30/2020 23:00	14.3	4.9	2.0	11.2	2.4
Average/Sum#:	343.6 #	127.0 #	49.3 #	270.0 #	59.1 #
Minimum:	13.5	4.5	2.0	10.7	2.4
Maximum:	14.9	6.4	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
07/31/2020 00:00	13.7	5.9	2.0	10.8	2.4
07/31/2020 01:00	13.5	6.3	2.0	10.6	2.4
07/31/2020 02:00	13.5	6.3	2.0	10.6	2.4
07/31/2020 03:00	13.5	6.3	2.0	10.6	2.4
07/31/2020 04:00	13.5	6.3	2.0	10.7	2.4
07/31/2020 05:00	14.2	6.6	2.0	11.2	2.4
07/31/2020 06:00	14.3	6.3	2.0	11.2	2.4
07/31/2020 07:00	13.7	6.0	2.0	10.8	2.4
07/31/2020 08:00	13.5	6.3	2.0	10.6	2.4
07/31/2020 09:00	14.0	5.6	2.0	11.0	2.4
07/31/2020 10:00	14.4	4.9	2.1	11.3	2.4
07/31/2020 11:00	14.6	5.2	2.1	11.5	2.5
07/31/2020 12:00	14.6	5.2	2.1	11.5	2.5
07/31/2020 13:00	14.6	5.1	2.1	11.5	2.5
07/31/2020 14:00	14.7	5.1	2.1	11.5	2.5
07/31/2020 15:00	14.7	5.1	2.1	11.6	2.6
07/31/2020 16:00	14.7	5.1	2.1	11.6	2.6
07/31/2020 17:00	14.7	5.1	2.1	11.5	2.5
07/31/2020 18:00	14.9	4.5	2.1	11.7	2.6
07/31/2020 19:00	14.6	4.8	2.1	11.5	2.5
07/31/2020 20:00	14.7	5.2	2.1	11.5	2.5
07/31/2020 21:00	14.5	4.8	2.1	11.4	2.5
07/31/2020 22:00	14.5	5.6	2.1	11.4	2.5
07/31/2020 23:00	14.4	5.9	2.0	11.3	2.4
Average/Sum#:	342.0 #	133.5 #	49.3 #	268.9 #	59.1 #
Minimum:	13.5	4.5	2.0	10.6	2.4
Maximum:	14.9	6.6	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/01/2020 00:00	14.2	5.6	2.0	11.2	2.4
08/01/2020 01:00	13.6	6.0	2.0	10.7	2.4
08/01/2020 02:00	13.3	6.3	1.9	10.5	2.2
08/01/2020 03:00	7.2	2.6	1.4	7.9	1.8
08/01/2020 04:00	7.6	2.0	1.6	8.4	1.8
08/01/2020 05:00	7.7	2.3	1.6	8.5	1.8
08/01/2020 06:00	5.2	2.2	1.3	7.2	1.6
08/01/2020 07:00	6.5	2.2	1.3	7.1	1.6
08/01/2020 08:00	6.5	2.0	1.3	7.1	1.6
08/01/2020 09:00	6.5	2.0	1.3	7.1	1.6
08/01/2020 10:00	7.2	1.8	1.4	7.9	1.8
08/01/2020 11:00	9.0	2.5	1.6	8.3	1.8
08/01/2020 12:00	14.3	6.5	2.0	11.2	2.4
08/01/2020 13:00	14.6	5.8	2.1	11.5	2.5
08/01/2020 14:00	14.6	5.7	2.1	11.5	2.5
08/01/2020 15:00	14.7	5.5	2.1	11.5	2.5
08/01/2020 16:00	14.8	5.5	2.1	11.7	2.6
08/01/2020 17:00	14.9	5.2	2.1	11.7	2.6
08/01/2020 18:00	14.9	5.2	2.1	11.7	2.6
08/01/2020 19:00	14.9	5.2	2.1	11.7	2.6
08/01/2020 20:00	14.8	5.2	2.1	11.7	2.6
08/01/2020 21:00	14.6	5.5	2.1	11.4	2.5
08/01/2020 22:00	14.5	5.2	2.1	11.4	2.5
08/01/2020 23:00	13.5	5.8	2.0	10.6	2.4
Average/Sum#:	279.6 #	103.8 #	43.7 #	239.5 #	52.7 #
Minimum:	5.2	1.8	1.3	7.1	1.6
Maximum:	14.9	6.5	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/02/2020 00:00	8.6	2.9	1.4	7.9	1.8
08/02/2020 01:00	5.2	2.7	1.3	7.0	1.6
08/02/2020 02:00	5.2	2.4	1.3	7.1	1.6
08/02/2020 03:00	5.2	2.2	1.3	7.1	1.6
08/02/2020 04:00	7.5	2.5	1.4	8.2	1.8
08/02/2020 05:00	7.0	2.3	1.4	7.6	1.6
08/02/2020 06:00	5.2	2.0	1.3	7.1	1.6
08/02/2020 07:00	5.2	2.0	1.3	7.1	1.6
08/02/2020 08:00	6.5	2.0	1.3	7.1	1.6
08/02/2020 09:00	6.5	2.0	1.3	7.1	1.6
08/02/2020 10:00	6.5	2.0	1.3	7.2	1.6
08/02/2020 11:00	6.5	2.2	1.3	7.2	1.6
08/02/2020 12:00	6.5	2.4	1.3	7.2	1.6
08/02/2020 13:00	6.5	2.4	1.3	7.2	1.6
08/02/2020 14:00	6.8	2.3	1.4	7.5	1.6
08/02/2020 15:00	9.1	2.5	1.6	8.3	1.8
08/02/2020 16:00	13.7	6.4	2.0	10.8	2.4
08/02/2020 17:00	14.5	6.1	2.1	11.4	2.5
08/02/2020 18:00	14.5	5.8	2.1	11.4	2.5
08/02/2020 19:00	14.7	5.4	2.1	11.5	2.5
08/02/2020 20:00	14.5	5.5	2.1	11.5	2.5
08/02/2020 21:00	14.6	5.5	2.1	11.5	2.5
08/02/2020 22:00	14.5	5.8	2.1	11.4	2.5
08/02/2020 23:00	13.5	5.8	2.0	10.7	2.4
Average/Sum#:	218.5 #	83.1 #	38.1 #	208.1 #	46.0 #
Minimum:	5.2	2.0	1.3	7.0	1.6
Maximum:	14.7	6.4	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/03/2020 00:00	8.6	3.2	1.4	7.9	1.8
08/03/2020 01:00	6.6	2.9	1.3	7.3	1.6
08/03/2020 02:00	5.2	2.7	1.3	7.1	1.6
08/03/2020 03:00	6.5	2.5	1.3	7.1	1.6
08/03/2020 04:00	7.5	2.6	1.6	8.3	1.8
08/03/2020 05:00	7.5	2.7	1.4	8.2	1.8
08/03/2020 06:00	9.4	3.0	1.6	8.6	1.8
08/03/2020 07:00	10.8	2.6	1.6	8.4	1.8
08/03/2020 08:00	7.5	2.5	1.4	8.1	1.8
08/03/2020 09:00	6.8	2.5	1.4	7.5	1.6
08/03/2020 10:00	6.5	2.0	1.3	7.2	1.6
08/03/2020 11:00	8.2	2.0	1.4	7.5	1.6
08/03/2020 12:00	9.0	2.5	1.5	8.3	1.8
08/03/2020 13:00	14.3	6.5	2.0	11.2	2.4
08/03/2020 14:00	14.5	5.5	2.1	11.4	2.5
08/03/2020 15:00	14.5	5.4	2.1	11.4	2.5
08/03/2020 16:00	14.5	5.4	2.1	11.4	2.5
08/03/2020 17:00	14.5	5.1	2.1	11.5	2.5
08/03/2020 18:00	14.5	5.4	2.1	11.4	2.5
08/03/2020 19:00	14.7	5.4	2.1	11.5	2.5
08/03/2020 20:00	14.6	5.4	2.1	11.5	2.5
08/03/2020 21:00	14.6	5.4	2.1	11.5	2.5
08/03/2020 22:00	14.5	5.5	2.1	11.4	2.5
08/03/2020 23:00	12.5	5.0	1.8	9.8	2.2
Average/Sum#:	257.8 #	93.7 #	41.2 #	225.5 #	49.3 #
Minimum:	5.2	2.0	1.3	7.1	1.6
Maximum:	14.7	6.5	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/04/2020 00:00	5.2	2.7	1.3	7.1	1.6
08/04/2020 01:00	5.2	2.4	1.3	7.0	1.6
08/04/2020 02:00	5.2	2.2	1.3	7.1	1.6
08/04/2020 03:00	5.2	2.4	1.3	7.1	1.6
08/04/2020 04:00	5.2	2.4	1.3	7.1	1.6
08/04/2020 05:00	7.0	2.9	1.4	7.7	1.6
08/04/2020 06:00	6.5	2.7	1.3	7.2	1.6
08/04/2020 07:00	6.5	2.4	1.3	7.1	1.6
08/04/2020 08:00	6.5	2.2	1.3	7.1	1.6
08/04/2020 09:00	6.5	2.2	1.3	7.1	1.6
08/04/2020 10:00	6.5	2.0	1.3	7.2	1.6
08/04/2020 11:00	6.5	2.0	1.3	7.2	1.6
08/04/2020 12:00	7.2	2.4	1.4	7.9	1.8
08/04/2020 13:00	8.8	2.4	1.4	8.1	1.8
08/04/2020 14:00	5.2	2.2	1.3	7.3	1.6
08/04/2020 15:00	9.2	2.6	1.6	8.4	1.8
08/04/2020 16:00	9.0	2.8	1.6	8.3	1.8
08/04/2020 17:00	14.3	6.3	2.0	11.3	2.4
08/04/2020 18:00	14.7	5.4	2.1	11.5	2.5
08/04/2020 19:00	14.7	5.4	2.1	11.5	2.5
08/04/2020 20:00	14.5	5.4	2.1	11.5	2.5
08/04/2020 21:00	14.5	5.5	2.1	11.4	2.5
08/04/2020 22:00	13.7	5.6	2.0	10.8	2.4
08/04/2020 23:00	12.5	4.2	1.7	9.8	2.2
Average/Sum#:	210.3 #	78.7 #	37.1 #	203.8 #	45.0 #
Minimum:	5.2	2.0	1.3	7.0	1.6
Maximum:	14.7	6.3	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/05/2020 00:00	5.2	2.4	1.3	7.1	1.6
08/05/2020 01:00	5.2	2.2	1.3	7.1	1.6
08/05/2020 02:00	5.2	2.2	1.3	7.0	1.6
08/05/2020 03:00	5.2	2.4	1.3	7.0	1.6
08/05/2020 04:00	5.2	2.7	1.3	7.0	1.6
08/05/2020 05:00	6.6	2.7	1.3	7.2	1.6
08/05/2020 06:00	5.2	2.6	1.3	7.0	1.6
08/05/2020 07:00	5.2	2.4	1.3	7.0	1.6
08/05/2020 08:00	5.2	2.2	1.3	7.0	1.6
08/05/2020 09:00	6.5	1.9	1.3	7.1	1.6
08/05/2020 10:00	6.5	1.9	1.3	7.1	1.6
08/05/2020 11:00	6.5	1.9	1.3	7.1	1.6
08/05/2020 12:00	6.5	2.0	1.3	7.1	1.6
08/05/2020 13:00	6.5	2.0	1.3	7.1	1.6
08/05/2020 14:00	6.5	2.2	1.3	7.1	1.6
08/05/2020 15:00	6.5	2.2	1.3	7.1	1.6
08/05/2020 16:00	6.5	2.2	1.3	7.1	1.6
08/05/2020 17:00	12.3	4.8	1.7	9.6	2.1
08/05/2020 18:00	14.5	6.1	2.1	11.4	2.5
08/05/2020 19:00	14.0	5.4	2.0	11.0	2.4
08/05/2020 20:00	9.4	2.1	1.6	8.7	1.8
08/05/2020 21:00	7.0	2.1	1.4	7.7	1.6
08/05/2020 22:00	7.0	2.0	1.4	7.6	1.6
08/05/2020 23:00	5.2	2.4	1.3	7.0	1.6
Average/Sum#:	169.6 #	63.0 #	33.6 #	183.2 #	40.8 #
Minimum:	5.2	1.9	1.3	7.0	1.6
Maximum:	14.5	6.1	2.1	11.4	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/06/2020 00:00	5.2	2.4	1.3	7.0	1.6
08/06/2020 01:00	5.2	2.4	1.3	7.0	1.6
08/06/2020 02:00	5.2	2.4	1.3	7.0	1.6
08/06/2020 03:00	5.2	2.4	1.3	7.0	1.6
08/06/2020 04:00	5.2	2.4	1.3	7.2	1.6
08/06/2020 05:00	5.3	2.7	1.3	7.3	1.6
08/06/2020 06:00	5.2	2.7	1.3	7.1	1.6
08/06/2020 07:00	5.2	2.2	1.3	7.1	1.6
08/06/2020 08:00	5.2	2.2	1.3	7.1	1.6
08/06/2020 09:00	6.5	1.9	1.3	7.1	1.6
08/06/2020 10:00	6.5	1.9	1.3	7.1	1.6
08/06/2020 11:00	6.5	1.9	1.3	7.1	1.6
08/06/2020 12:00	6.5	2.0	1.3	7.1	1.6
08/06/2020 13:00	6.5	2.0	1.3	7.1	1.6
08/06/2020 14:00	6.5	2.2	1.3	7.1	1.6
08/06/2020 15:00	6.5	2.2	1.3	7.1	1.6
08/06/2020 16:00	6.5	2.2	1.3	7.1	1.6
08/06/2020 17:00	7.0	2.4	1.4	7.7	1.6
08/06/2020 18:00	7.0	2.4	1.4	7.7	1.6
08/06/2020 19:00	6.5	2.4	1.3	7.2	1.6
08/06/2020 20:00	6.5	2.4	1.3	7.0	1.6
08/06/2020 21:00	6.4	2.4	1.3	7.0	1.6
08/06/2020 22:00	6.4	2.6	1.3	7.0	1.6
08/06/2020 23:00	5.2	2.6	1.3	7.0	1.6
Average/Sum#:	143.9 #	55.3 #	31.4 #	171.2 #	38.4 #
Minimum:	5.2	1.9	1.3	7.0	1.6
Maximum:	7.0	2.7	1.4	7.7	1.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/07/2020 00:00	6.4	2.4	1.3	7.0	1.6
08/07/2020 01:00	5.2	2.4	1.3	7.0	1.6
08/07/2020 02:00	5.2	2.2	1.3	7.0	1.6
08/07/2020 03:00	5.2	2.2	1.3	7.0	1.6
08/07/2020 04:00	5.3	2.5	1.3	7.3	1.6
08/07/2020 05:00	6.6	3.0	1.3	7.2	1.6
08/07/2020 06:00	6.5	2.4	1.3	7.0	1.6
08/07/2020 07:00	6.5	2.4	1.3	7.1	1.6
08/07/2020 08:00	6.5	2.2	1.3	7.1	1.6
08/07/2020 09:00	6.5	2.0	1.3	7.1	1.6
08/07/2020 10:00	6.5	2.0	1.3	7.1	1.6
08/07/2020 11:00	6.5	2.0	1.3	7.1	1.6
08/07/2020 12:00	6.5	2.2	1.3	7.1	1.6
08/07/2020 13:00	6.7	2.0	1.3	7.4	1.6
08/07/2020 14:00	8.2	2.0	1.4	7.5	1.6
08/07/2020 15:00	6.5	2.2	1.3	7.1	1.6
08/07/2020 16:00	7.0	2.3	1.4	7.7	1.6
08/07/2020 17:00	8.8	2.2	1.4	8.1	1.8
08/07/2020 18:00	11.7	3.1	1.7	9.2	2.0
08/07/2020 19:00	11.5	3.0	1.7	9.0	2.0
08/07/2020 20:00	8.9	3.0	1.4	8.1	1.8
08/07/2020 21:00	6.7	2.7	1.3	7.3	1.6
08/07/2020 22:00	7.0	2.6	1.4	7.7	1.6
08/07/2020 23:00	7.2	2.7	1.4	7.9	1.8
Average/Sum#:	169.6 #	57.7 #	32.6 #	179.1 #	39.8 #
Minimum:	5.2	2.0	1.3	7.0	1.6
Maximum:	11.7	3.1	1.7	9.2	2.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/08/2020 00:00	6.8	2.5	1.3	7.4	1.6
08/08/2020 01:00	5.2	2.6	1.3	7.0	1.6
08/08/2020 02:00	5.2	2.6	1.3	7.0	1.6
08/08/2020 03:00	5.2	2.9	1.3	7.0	1.6
08/08/2020 04:00	5.2	2.6	1.3	7.1	1.6
08/08/2020 05:00	6.5	3.1	1.3	7.0	1.6
08/08/2020 06:00	6.5	3.1	1.3	7.0	1.6
08/08/2020 07:00	6.5	2.6	1.3	7.1	1.6
08/08/2020 08:00	6.5	2.2	1.3	7.1	1.6
08/08/2020 09:00	6.5	2.4	1.3	7.1	1.6
08/08/2020 10:00	6.5	2.6	1.3	7.1	1.6
08/08/2020 11:00	6.5	2.5	1.3	7.1	1.6
08/08/2020 12:00	6.5	2.2	1.3	7.1	1.6
08/08/2020 13:00	7.0	2.4	1.4	7.7	1.6
08/08/2020 14:00	5.3	2.5	1.3	7.3	1.6
08/08/2020 15:00	6.8	2.4	1.4	7.5	1.6
08/08/2020 16:00	8.6	2.7	1.4	7.9	1.8
08/08/2020 17:00	14.3	6.6	2.0	11.3	2.4
08/08/2020 18:00	14.8	5.1	2.1	11.7	2.6
08/08/2020 19:00	14.9	5.1	2.1	11.7	2.6
08/08/2020 20:00	14.6	5.4	2.1	11.5	2.5
08/08/2020 21:00	14.5	5.7	2.1	11.4	2.5
08/08/2020 22:00	13.9	5.9	2.0	10.9	2.4
08/08/2020 23:00	13.5	6.4	2.0	10.5	2.3
Average/Sum#:	207.8 #	84.1 #	36.8 #	201.5 #	44.7 #
Minimum:	5.2	2.2	1.3	7.0	1.6
Maximum:	14.9	6.6	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/09/2020 00:00	10.8	3.6	1.6	8.5	1.8
08/09/2020 01:00	6.5	3.2	1.3	7.2	1.6
08/09/2020 02:00	5.2	2.9	1.3	7.1	1.6
08/09/2020 03:00	5.2	2.7	1.3	7.1	1.6
08/09/2020 04:00	5.2	2.4	1.3	7.1	1.6
08/09/2020 05:00	5.2	2.4	1.3	7.1	1.6
08/09/2020 06:00	5.2	2.4	1.3	7.1	1.6
08/09/2020 07:00	6.5	2.2	1.3	7.1	1.6
08/09/2020 08:00	6.5	2.2	1.3	7.1	1.6
08/09/2020 09:00	6.5	2.2	1.3	7.1	1.6
08/09/2020 10:00	6.5	2.4	1.3	7.1	1.6
08/09/2020 11:00	6.5	2.0	1.3	7.1	1.6
08/09/2020 12:00	8.6	2.4	1.4	7.9	1.8
08/09/2020 13:00	9.0	3.0	1.6	8.3	1.8
08/09/2020 14:00	6.9	2.6	1.4	7.6	1.6
08/09/2020 15:00	9.6	3.5	1.6	8.8	2.0
08/09/2020 16:00	14.4	5.7	2.1	11.3	2.4
08/09/2020 17:00	14.7	5.0	2.1	11.5	2.5
08/09/2020 18:00	14.8	4.4	2.1	11.7	2.6
08/09/2020 19:00	14.5	4.7	2.1	11.5	2.5
08/09/2020 20:00	14.5	5.0	2.1	11.3	2.5
08/09/2020 21:00	14.5	5.1	2.1	11.5	2.5
08/09/2020 22:00	13.9	5.1	2.0	10.9	2.4
08/09/2020 23:00	13.4	5.7	2.0	10.5	2.3
Average/Sum#:	224.6 #	82.8 #	38.5 #	209.5 #	46.3 #
Minimum:	5.2	2.0	1.3	7.1	1.6
Maximum:	14.8	5.7	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/10/2020 00:00	8.4	2.9	1.4	7.7	1.6
08/10/2020 01:00	6.5	2.4	1.3	7.1	1.6
08/10/2020 02:00	5.2	2.4	1.3	7.1	1.6
08/10/2020 03:00	7.5	2.5	1.4	8.2	1.8
08/10/2020 04:00	10.7	2.6	1.6	8.4	1.8
08/10/2020 05:00	9.1	2.9	1.6	8.3	1.8
08/10/2020 06:00	9.6	3.0	1.6	8.8	2.0
08/10/2020 07:00	6.8	2.3	1.4	7.5	1.6
08/10/2020 08:00	10.5	2.3	1.4	8.2	1.8
08/10/2020 09:00	6.5	2.2	1.3	7.2	1.6
08/10/2020 10:00	9.2	2.6	1.6	8.4	1.8
08/10/2020 11:00	9.2	2.6	1.6	8.4	1.8
08/10/2020 12:00	6.5	2.2	1.3	7.2	1.6
08/10/2020 13:00	6.7	2.3	1.3	7.3	1.6
08/10/2020 14:00	6.7	2.0	1.3	7.3	1.6
08/10/2020 15:00	11.5	3.0	1.6	9.0	2.0
08/10/2020 16:00	14.4	5.9	2.1	11.3	2.4
08/10/2020 17:00	14.8	5.0	2.1	11.7	2.6
08/10/2020 18:00	14.5	5.0	2.1	11.3	2.5
08/10/2020 19:00	14.3	5.4	2.0	11.2	2.4
08/10/2020 20:00	14.1	5.4	2.0	11.1	2.4
08/10/2020 21:00	14.1	5.7	2.0	11.1	2.4
08/10/2020 22:00	13.7	6.2	2.0	10.8	2.4
08/10/2020 23:00	12.4	5.0	1.7	9.7	2.2
Average/Sum#:	242.9 #	83.8 #	39.0 #	214.3 #	46.9 #
Minimum:	5.2	2.0	1.3	7.1	1.6
Maximum:	14.8	6.2	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/11/2020 00:00	5.2	2.9	1.3	7.0	1.6
08/11/2020 01:00	5.2	2.4	1.3	7.0	1.6
08/11/2020 02:00	5.2	2.4	1.3	7.0	1.6
08/11/2020 03:00	5.2	2.4	1.3	7.0	1.6
08/11/2020 04:00	5.2	2.4	1.3	7.1	1.6
08/11/2020 05:00	5.2	2.7	1.3	7.2	1.6
08/11/2020 06:00	6.7	2.5	1.3	7.4	1.6
08/11/2020 07:00	5.2	2.4	1.3	7.1	1.6
08/11/2020 08:00	6.5	2.2	1.3	7.1	1.6
08/11/2020 09:00	6.5	2.2	1.3	7.1	1.6
08/11/2020 10:00	6.5	2.2	1.3	7.1	1.6
08/11/2020 11:00	6.5	2.2	1.3	7.2	1.6
08/11/2020 12:00	6.5	2.4	1.3	7.1	1.6
08/11/2020 13:00	6.5	2.4	1.3	7.1	1.6
08/11/2020 14:00	6.6	2.2	1.3	7.2	1.6
08/11/2020 15:00	6.7	2.5	1.3	7.3	1.6
08/11/2020 16:00	7.2	2.4	1.4	7.9	1.8
08/11/2020 17:00	9.4	2.7	1.6	8.6	1.8
08/11/2020 18:00	9.2	2.6	1.6	8.4	1.8
08/11/2020 19:00	6.8	2.6	1.4	7.5	1.6
08/11/2020 20:00	6.8	2.5	1.4	7.5	1.6
08/11/2020 21:00	6.5	2.4	1.3	7.2	1.6
08/11/2020 22:00	7.0	2.3	1.4	7.7	1.6
08/11/2020 23:00	5.2	2.4	1.3	7.2	1.6
Average/Sum#:	153.5 #	58.3 #	32.2 #	176.0 #	39.0 #
Minimum:	5.2	2.2	1.3	7.0	1.6
Maximum:	9.4	2.9	1.6	8.6	1.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/12/2020 00:00	5.2	2.4	1.3	7.1	1.6
08/12/2020 01:00	5.2	2.7	1.3	7.2	1.6
08/12/2020 02:00	5.2	2.7	1.3	7.0	1.6
08/12/2020 03:00	5.2	2.9	1.3	7.1	1.6
08/12/2020 04:00	5.2	3.1	1.3	7.2	1.6
08/12/2020 05:00	5.2	3.1	1.3	7.2	1.6
08/12/2020 06:00	5.2	3.1	1.3	7.1	1.6
08/12/2020 07:00	5.2	2.9	1.3	7.2	1.6
08/12/2020 08:00	7.0	2.3	1.4	7.6	1.6
08/12/2020 09:00	6.7	2.2	1.3	7.3	1.6
08/12/2020 10:00	6.7	2.2	1.3	7.4	1.6
08/12/2020 11:00	7.0	2.0	1.4	7.6	1.6
08/12/2020 12:00	9.8	2.7	1.7	9.0	2.0
08/12/2020 13:00	14.1	6.6	2.0	11.1	2.4
08/12/2020 14:00	14.5	5.7	2.1	11.4	2.5
08/12/2020 15:00	14.7	5.1	2.1	11.5	2.5
08/12/2020 16:00	14.7	5.1	2.1	11.5	2.5
08/12/2020 17:00	14.7	5.1	2.1	11.5	2.5
08/12/2020 18:00	14.5	5.1	2.1	11.5	2.5
08/12/2020 19:00	14.5	5.4	2.1	11.4	2.5
08/12/2020 20:00	14.3	5.7	2.0	11.3	2.4
08/12/2020 21:00	14.3	5.8	2.0	11.2	2.4
08/12/2020 22:00	14.3	6.2	2.0	11.3	2.4
08/12/2020 23:00	13.5	6.2	2.0	10.7	2.4
Average/Sum#:	236.9 #	96.3 #	40.1 #	220.4 #	48.2 #
Minimum:	5.2	2.0	1.3	7.0	1.6
Maximum:	14.7	6.6	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/13/2020 00:00	10.0	2.8	1.7	9.2	2.0
08/13/2020 01:00	11.3	3.0	1.6	8.8	2.0
08/13/2020 02:00	7.8	2.6	1.6	8.5	1.8
08/13/2020 03:00	9.5	2.4	1.6	8.7	1.9
08/13/2020 04:00	8.0	2.4	1.6	8.8	2.0
08/13/2020 05:00	8.0	2.7	1.6	8.8	2.0
08/13/2020 06:00	10.2	2.2	1.7	9.3	2.0
08/13/2020 07:00	9.6	2.1	1.6	8.8	2.0
08/13/2020 08:00	10.0	2.2	1.7	9.2	2.0
08/13/2020 09:00	9.6	2.4	1.6	8.8	2.0
08/13/2020 10:00	13.9	6.9	2.0	10.9	2.4
08/13/2020 11:00	14.7	5.9	2.1	11.5	2.5
08/13/2020 12:00	14.6	5.8	2.1	11.5	2.5
08/13/2020 13:00	14.5	5.5	2.1	11.4	2.5
08/13/2020 14:00	14.5	5.4	2.1	11.3	2.5
08/13/2020 15:00	14.6	4.8	2.1	11.5	2.5
08/13/2020 16:00	14.6	5.1	2.1	11.5	2.5
08/13/2020 17:00	14.7	4.8	2.1	11.5	2.5
08/13/2020 18:00	14.6	4.8	2.1	11.5	2.5
08/13/2020 19:00	14.7	4.8	2.1	11.5	2.5
08/13/2020 20:00	14.4	5.2	2.1	11.3	2.4
08/13/2020 21:00	14.3	5.5	2.0	11.3	2.4
08/13/2020 22:00	14.6	5.2	2.1	11.5	2.5
08/13/2020 23:00	15.0	4.9	2.1	11.8	2.6
Average/Sum#:	297.7 #	99.4 #	45.5 #	248.9 #	54.5 #
Minimum:	7.8	2.1	1.6	8.5	1.8
Maximum:	15.0	6.9	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/14/2020 00:00	15.1	4.9	2.1	11.9	2.6
08/14/2020 01:00	15.0	5.2	2.1	11.7	2.6
08/14/2020 02:00	14.8	5.3	2.1	11.6	2.6
08/14/2020 03:00	14.6	5.6	2.1	11.6	2.6
08/14/2020 04:00	15.0	5.0	2.1	11.8	2.6
08/14/2020 05:00	14.6	5.7	2.1	11.5	2.5
08/14/2020 06:00	14.4	6.3	2.1	11.4	2.4
08/14/2020 07:00	14.4	5.9	2.0	11.3	2.4
08/14/2020 08:00	14.6	5.6	2.1	11.4	2.5
08/14/2020 09:00	14.7	5.2	2.1	11.5	2.5
08/14/2020 10:00	14.9	4.5	2.1	11.7	2.6
08/14/2020 11:00	14.7	4.5	2.1	11.6	2.6
08/14/2020 12:00	14.9	4.8	2.1	11.7	2.6
08/14/2020 13:00	14.7	4.8	2.1	11.5	2.5
08/14/2020 14:00	14.6	4.8	2.1	11.5	2.5
08/14/2020 15:00	14.5	4.8	2.1	11.5	2.5
08/14/2020 16:00	14.4	5.1	2.1	11.3	2.4
08/14/2020 17:00	14.5	4.8	2.1	11.5	2.5
08/14/2020 18:00	14.5	4.8	2.1	11.5	2.5
08/14/2020 19:00	14.7	4.8	2.1	11.5	2.5
08/14/2020 20:00	14.9	4.8	2.1	11.7	2.6
08/14/2020 21:00	14.8	4.8	2.1	11.7	2.6
08/14/2020 22:00	14.9	4.5	2.1	11.7	2.6
08/14/2020 23:00	15.0	4.5	2.1	11.7	2.6
Average/Sum#:	353.2 #	121.0 #	50.3 #	277.8 #	60.9 #
Minimum:	14.4	4.5	2.0	11.3	2.4
Maximum:	15.1	6.3	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/15/2020 00:00	15.1	4.5	2.1	11.9	2.6
08/15/2020 01:00	15.0	4.5	2.1	11.9	2.6
08/15/2020 02:00	14.8	4.8	2.1	11.6	2.6
08/15/2020 03:00	14.7	4.9	2.1	11.6	2.6
08/15/2020 04:00	14.6	5.2	2.1	11.5	2.5
08/15/2020 05:00	16.7	5.3	2.1	11.4	2.5
08/15/2020 06:00	12.5	5.6	2.1	11.5	2.5
08/15/2020 07:00	14.6	5.8	2.1	11.4	2.5
08/15/2020 08:00	13.9	5.9	2.0	11.0	2.4
08/15/2020 09:00	14.5	5.2	2.1	11.4	2.5
08/15/2020 10:00	14.5	5.1	2.1	11.5	2.5
08/15/2020 11:00	14.7	4.8	2.1	11.7	2.6
08/15/2020 12:00	14.9	4.8	2.1	11.7	2.6
08/15/2020 13:00	14.9	4.8	2.1	11.7	2.6
08/15/2020 14:00	14.8	4.5	2.1	11.7	2.6
08/15/2020 15:00	14.7	4.4	2.1	11.6	2.5
08/15/2020 16:00	14.7	4.7	2.1	11.6	2.5
08/15/2020 17:00	14.7	4.7	2.1	11.6	2.5
08/15/2020 18:00	14.7	4.4	2.1	11.5	2.5
08/15/2020 19:00	14.7	4.4	2.1	11.6	2.5
08/15/2020 20:00	14.9	4.2	2.1	11.7	2.6
08/15/2020 21:00	14.7	4.2	2.1	11.5	2.5
08/15/2020 22:00	14.6	4.2	2.1	11.5	2.5
08/15/2020 23:00	14.9	4.2	2.1	11.7	2.6
Average/Sum#:	352.8 #	115.1 #	50.3 #	277.8 #	60.9 #
Minimum:	12.5	4.2	2.0	11.0	2.4
Maximum:	16.7	5.9	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/16/2020 00:00	15.1	3.9	2.1	11.9	2.6
08/16/2020 01:00	15.1	3.9	2.1	11.8	2.6
08/16/2020 02:00	15.1	3.9	2.1	11.8	2.6
08/16/2020 03:00	14.9	4.0	2.1	11.7	2.6
08/16/2020 04:00	15.0	3.9	2.1	11.9	2.6
08/16/2020 05:00	14.9	4.2	2.1	11.7	2.6
08/16/2020 06:00	14.8	4.3	2.1	11.7	2.6
08/16/2020 07:00	14.1	4.9	2.0	11.1	2.4
08/16/2020 08:00	13.7	5.6	2.0	10.9	2.4
08/16/2020 09:00	14.1	5.2	2.0	11.1	2.4
08/16/2020 10:00	14.3	4.9	2.0	11.2	2.4
08/16/2020 11:00	14.3	4.9	2.0	11.1	2.4
08/16/2020 12:00	14.4	4.5	2.1	11.3	2.4
08/16/2020 13:00	14.5	4.2	2.1	11.5	2.5
08/16/2020 14:00	14.8	4.2	2.1	11.7	2.6
08/16/2020 15:00	14.9	4.2	2.1	11.7	2.6
08/16/2020 16:00	14.9	4.2	2.1	11.7	2.6
08/16/2020 17:00	14.9	4.2	2.1	11.7	2.6
08/16/2020 18:00	14.9	4.2	2.1	11.7	2.6
08/16/2020 19:00	14.7	4.4	2.1	11.6	2.5
08/16/2020 20:00	14.7	4.5	2.1	11.7	2.6
08/16/2020 21:00	14.7	4.8	2.1	11.5	2.5
08/16/2020 22:00	14.7	4.5	2.1	11.5	2.5
08/16/2020 23:00	14.7	4.2	2.1	11.5	2.5
Average/Sum#:	352.2 #	105.7 #	49.9 #	277.0 #	60.7 #
Minimum:	13.7	3.9	2.0	10.9	2.4
Maximum:	15.1	5.6	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/17/2020 00:00	14.8	4.2	2.1	11.7	2.6
08/17/2020 01:00	14.7	4.5	2.1	11.5	2.5
08/17/2020 02:00	14.7	4.5	2.1	11.5	2.5
08/17/2020 03:00	14.7	4.6	2.1	11.7	2.6
08/17/2020 04:00	14.8	4.6	2.1	11.7	2.6
08/17/2020 05:00	14.7	4.9	2.1	11.5	2.5
08/17/2020 06:00	12.8	4.6	2.1	11.7	2.6
08/17/2020 07:00	14.9	4.5	2.1	11.7	2.6
08/17/2020 08:00	14.8	4.3	2.1	11.7	2.6
08/17/2020 09:00	14.9	4.2	2.1	11.7	2.6
08/17/2020 10:00	14.9	4.2	2.1	11.7	2.6
08/17/2020 11:00	14.7	4.2	2.1	11.5	2.5
08/17/2020 12:00	14.9	4.2	2.1	11.7	2.6
08/17/2020 13:00	14.5	4.2	2.1	11.5	2.5
08/17/2020 14:00	14.7	4.2	2.1	11.5	2.5
08/17/2020 15:00	14.9	3.9	2.1	11.7	2.6
08/17/2020 16:00	14.9	3.6	2.1	11.7	2.6
08/17/2020 17:00	14.7	4.2	2.1	11.5	2.5
08/17/2020 18:00	14.5	4.5	2.1	11.3	2.5
08/17/2020 19:00	14.5	4.5	2.1	11.3	2.5
08/17/2020 20:00	14.7	4.6	2.1	11.5	2.5
08/17/2020 21:00	14.9	4.2	2.1	11.7	2.6
08/17/2020 22:00	14.9	4.2	2.1	11.7	2.6
08/17/2020 23:00	14.8	4.3	2.1	11.7	2.6
Average/Sum#:	352.3 #	103.9 #	50.4 #	278.4 #	61.4 #
Minimum:	12.8	3.6	2.1	11.3	2.5
Maximum:	14.9	4.9	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/18/2020 00:00	14.5	4.6	2.1	11.4	2.5
08/18/2020 01:00	14.7	4.2	2.1	11.5	2.5
08/18/2020 02:00	14.9	4.2	2.1	11.7	2.6
08/18/2020 03:00	14.7	4.6	2.1	11.5	2.5
08/18/2020 04:00	14.7	4.5	2.1	11.6	2.6
08/18/2020 05:00	16.8	4.6	2.1	11.5	2.5
08/18/2020 06:00	14.9	4.5	2.1	11.7	2.6
08/18/2020 07:00	14.7	4.6	2.1	11.5	2.5
08/18/2020 08:00	14.5	4.9	2.1	11.5	2.5
08/18/2020 09:00	14.5	4.8	2.1	11.3	2.5
08/18/2020 10:00	14.6	4.5	2.1	11.5	2.5
08/18/2020 11:00	14.3	4.5	2.0	11.3	2.4
08/18/2020 12:00	14.7	4.2	2.1	11.5	2.5
08/18/2020 13:00	14.7	4.1	2.1	11.6	2.5
08/18/2020 14:00	14.8	3.9	2.1	11.6	2.5
08/18/2020 15:00	14.7	3.8	2.1	11.6	2.5
08/18/2020 16:00	14.7	4.1	2.1	11.6	2.5
08/18/2020 17:00	14.7	3.8	2.1	11.6	2.5
08/18/2020 18:00	14.8	4.1	2.1	11.6	2.5
08/18/2020 19:00	14.8	3.8	2.1	11.7	2.6
08/18/2020 20:00	14.9	3.6	2.1	11.7	2.6
08/18/2020 21:00	14.9	3.9	2.1	11.7	2.6
08/18/2020 22:00	14.9	3.9	2.1	11.7	2.6
08/18/2020 23:00	15.0	4.0	2.1	11.9	2.6
Average/Sum#:	355.4 #	101.7 #	50.3 #	277.8 #	60.7 #
Minimum:	14.3	3.6	2.0	11.3	2.4
Maximum:	16.8	4.9	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/19/2020 00:00	14.7	3.9	2.1	11.7	2.6
08/19/2020 01:00	14.7	3.9	2.1	11.5	2.5
08/19/2020 02:00	14.8	3.9	2.1	11.6	2.6
08/19/2020 03:00	14.6	4.6	2.1	11.5	2.5
08/19/2020 04:00	14.7	4.9	2.1	11.5	2.5
08/19/2020 05:00	16.8	5.3	2.1	11.5	2.5
08/19/2020 06:00	14.6	5.3	2.1	11.5	2.5
08/19/2020 07:00	14.9	4.6	2.1	11.7	2.6
08/19/2020 08:00	14.5	5.2	2.1	11.4	2.5
08/19/2020 09:00	14.9	4.5	2.1	11.7	2.6
08/19/2020 10:00	15.0	4.2	2.1	11.7	2.6
08/19/2020 11:00	14.9	4.2	2.1	11.7	2.6
08/19/2020 12:00	14.7	4.2	2.1	11.5	2.5
08/19/2020 13:00	14.9	4.2	2.1	11.7	2.6
08/19/2020 14:00	14.9	3.9	2.1	11.7	2.6
08/19/2020 15:00	14.7	3.8	2.1	11.6	2.5
08/19/2020 16:00	14.7	3.9	2.1	11.7	2.6
08/19/2020 17:00	14.9	4.2	2.1	11.7	2.6
08/19/2020 18:00	14.9	3.9	2.1	11.7	2.6
08/19/2020 19:00	14.8	4.3	2.1	11.7	2.6
08/19/2020 20:00	14.8	4.3	2.1	11.7	2.6
08/19/2020 21:00	14.7	5.0	2.1	11.5	2.5
08/19/2020 22:00	14.6	5.0	2.1	11.4	2.5
08/19/2020 23:00	14.4	5.0	2.1	11.3	2.4
Average/Sum#:	356.1 #	106.2 #	50.4 #	278.2 #	61.2 #
Minimum:	14.4	3.8	2.1	11.3	2.4
Maximum:	16.8	5.3	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/20/2020 00:00	14.4	5.3	2.1	11.4	2.4
08/20/2020 01:00	14.4	5.4	2.0	11.3	2.4
08/20/2020 02:00	14.2	5.3	2.0	11.2	2.4
08/20/2020 03:00	14.3	5.7	2.0	11.2	2.4
08/20/2020 04:00	14.4	5.3	2.0	11.2	2.4
08/20/2020 05:00	14.4	5.6	2.0	11.3	2.4
08/20/2020 06:00	14.3	5.7	2.0	11.2	2.4
08/20/2020 07:00	14.2	5.7	2.0	11.2	2.4
08/20/2020 08:00	14.3	5.6	2.0	11.2	2.4
08/20/2020 09:00	14.4	5.3	2.0	11.3	2.4
08/20/2020 10:00	14.4	5.3	2.1	11.4	2.4
08/20/2020 11:00	14.4	5.3	2.1	11.3	2.4
08/20/2020 12:00	14.5	5.3	2.1	11.4	2.5
08/20/2020 13:00	14.5	5.3	2.1	11.4	2.5
08/20/2020 14:00	14.4	5.6	2.1	11.4	2.4
08/20/2020 15:00	14.4	5.9	2.0	11.3	2.4
08/20/2020 16:00	14.4	5.8	2.0	11.3	2.4
08/20/2020 17:00	14.5	6.0	2.1	11.4	2.5
08/20/2020 18:00	14.5	5.4	2.1	11.3	2.5
08/20/2020 19:00	14.5	6.1	2.1	11.4	2.5
08/20/2020 20:00	14.5	5.8	2.1	11.4	2.5
08/20/2020 21:00	14.4	5.8	2.1	11.4	2.4
08/20/2020 22:00	14.4	5.8	2.0	11.3	2.4
08/20/2020 23:00	14.4	4.2	2.1	11.3	2.5
Average/Sum#:	345.5 #	132.5 #	49.2 #	271.5 #	58.3 #
Minimum:	14.2	4.2	2.0	11.2	2.4
Maximum:	14.5	6.1	2.1	11.4	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/21/2020 00:00	14.5	3.3	2.1	11.4	2.5
08/21/2020 01:00	14.3	3.9	2.1	11.3	2.4
08/21/2020 02:00	13.7	3.9	2.0	10.8	2.4
08/21/2020 03:00	14.3	3.9	2.1	11.3	2.4
08/21/2020 04:00	14.5	3.6	2.1	11.3	2.5
08/21/2020 05:00	10.2	2.2	2.1	11.3	2.5
08/21/2020 06:00	8.3	1.9	2.1	11.5	2.5
08/21/2020 07:00	10.3	1.8	2.1	11.5	2.5
08/21/2020 08:00	10.3	1.8	2.1	11.3	2.5
08/21/2020 09:00	10.4	1.8	2.1	11.5	2.5
08/21/2020 10:00	10.4	1.8	2.1	11.5	2.5
08/21/2020 11:00	10.4	1.5	2.1	11.5	2.5
08/21/2020 12:00	14.6	4.3	2.1	11.4	2.5
08/21/2020 13:00	14.7	3.0	2.1	11.5	2.6
08/21/2020 14:00	14.3	3.3	2.0	11.3	2.4
08/21/2020 15:00	14.4	4.2	2.1	11.4	2.4
08/21/2020 16:00	14.7	4.6	2.1	11.5	2.5
08/21/2020 17:00	14.7	4.2	2.1	11.6	2.5
08/21/2020 18:00	14.7	4.5	2.1	11.5	2.5
08/21/2020 19:00	14.5	4.9	2.1	11.3	2.5
08/21/2020 20:00	14.5	4.9	2.1	11.5	2.5
08/21/2020 21:00	14.4	4.9	2.1	11.3	2.4
08/21/2020 22:00	14.5	4.9	2.1	11.4	2.5
08/21/2020 23:00	14.5	4.9	2.1	11.5	2.5
Average/Sum#:	245.8 #	71.2 #	50.2 #	273.4 #	59.5 #
Minimum:	13.7	3.0	2.0	10.8	2.4
Maximum:	14.7	4.9	2.1	11.6	2.6
%SI	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/22/2020 00:00	14.6	4.6	2.1	11.5	2.5
08/22/2020 01:00	13.5	4.6	2.0	10.7	2.4
08/22/2020 02:00	10.0	1.5	1.7	9.2	2.0
08/22/2020 03:00	7.7	1.8	1.6	8.4	1.8
08/22/2020 04:00	10.0	2.4	1.7	9.2	2.0
08/22/2020 05:00	11.8	2.8	1.7	9.2	2.0
08/22/2020 06:00	11.8	2.6	1.7	9.2	2.0
08/22/2020 07:00	10.0	2.2	1.7	9.2	2.0
08/22/2020 08:00	10.0	2.1	1.7	9.2	2.0
08/22/2020 09:00	9.9	2.1	1.7	9.0	2.0
08/22/2020 10:00	9.4	2.7	1.6	8.6	1.8
08/22/2020 11:00	14.1	6.5	2.0	11.1	2.4
08/22/2020 12:00	14.7	5.4	2.1	11.5	2.5
08/22/2020 13:00	14.7	4.8	2.1	11.6	2.5
08/22/2020 14:00	16.6	5.4	2.1	11.4	2.5
08/22/2020 15:00	14.8	4.8	2.1	11.7	2.6
08/22/2020 16:00	14.9	4.7	2.1	11.7	2.6
08/22/2020 17:00	14.7	4.7	2.1	11.5	2.5
08/22/2020 18:00	14.5	4.8	2.1	11.5	2.5
08/22/2020 19:00	16.6	4.8	2.1	11.4	2.5
08/22/2020 20:00	16.5	4.8	2.1	11.3	2.5
08/22/2020 21:00	14.7	4.5	2.1	11.6	2.6
08/22/2020 22:00	14.6	4.5	2.1	11.5	2.5
08/22/2020 23:00	14.8	4.5	2.1	11.6	2.6
Average/Sum#:	314.9 #	93.6 #	46.4 #	252.8 #	55.3 #
Minimum:	7.7	1.5	1.6	8.4	1.8
Maximum:	16.6	6.5	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/23/2020 00:00	14.5	4.8	2.1	11.4	2.5
08/23/2020 01:00	14.3	4.8	2.0	11.2	2.4
08/23/2020 02:00	14.4	4.8	2.1	11.3	2.4
08/23/2020 03:00	14.3	4.8	2.0	11.3	2.4
08/23/2020 04:00	13.5	5.2	2.0	10.7	2.4
08/23/2020 05:00	10.1	2.1	1.7	9.2	2.0
08/23/2020 06:00	11.5	1.8	1.6	9.0	2.0
08/23/2020 07:00	8.0	1.8	1.6	8.7	1.9
08/23/2020 08:00	9.8	1.8	1.7	9.0	2.0
08/23/2020 09:00	9.7	1.5	1.6	8.8	2.0
08/23/2020 10:00	9.2	2.0	1.6	8.4	1.8
08/23/2020 11:00	14.1	5.5	2.0	11.1	2.4
08/23/2020 12:00	14.7	4.5	2.1	11.5	2.5
08/23/2020 13:00	14.7	4.5	2.1	11.5	2.5
08/23/2020 14:00	14.7	4.4	2.1	11.5	2.5
08/23/2020 15:00	14.9	4.1	2.1	11.7	2.6
08/23/2020 16:00	14.9	3.8	2.1	11.7	2.6
08/23/2020 17:00	14.9	3.8	2.1	11.7	2.6
08/23/2020 18:00	14.9	3.8	2.1	11.7	2.6
08/23/2020 19:00	14.9	3.8	2.1	11.7	2.6
08/23/2020 20:00	14.9	4.1	2.1	11.7	2.6
08/23/2020 21:00	14.7	4.5	2.1	11.6	2.6
08/23/2020 22:00	14.7	4.8	2.1	11.5	2.5
08/23/2020 23:00	14.6	5.1	2.1	11.5	2.5
Average/Sum#:	320.9 #	92.1 #	47.2 #	259.4 #	56.9 #
Minimum:	8.0	1.5	1.6	8.4	1.8
Maximum:	14.9	5.5	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/24/2020 00:00	14.7	4.8	2.1	11.5	2.5
08/24/2020 01:00	14.7	4.8	2.1	11.5	2.5
08/24/2020 02:00	14.7	4.8	2.1	11.6	2.6
08/24/2020 03:00	14.9	4.8	2.1	11.7	2.6
08/24/2020 04:00	14.8	4.5	2.1	11.7	2.6
08/24/2020 05:00	16.9	4.8	2.1	11.6	2.6
08/24/2020 06:00	14.7	4.8	2.1	11.5	2.5
08/24/2020 07:00	14.5	5.1	2.1	11.4	2.5
08/24/2020 08:00	14.5	5.1	2.1	11.3	2.5
08/24/2020 09:00	14.5	4.8	2.1	11.5	2.5
08/24/2020 10:00	14.8	4.2	2.1	11.7	2.6
08/24/2020 11:00	14.9	4.4	2.1	11.7	2.6
08/24/2020 12:00	14.8	4.4	2.1	11.6	2.6
08/24/2020 13:00	14.7	4.4	2.1	11.7	2.6
08/24/2020 14:00	14.6	4.4	2.1	11.5	2.5
08/24/2020 15:00	14.7	4.0	2.1	11.5	2.5
08/24/2020 16:00	14.8	4.6	2.1	11.7	2.6
08/24/2020 17:00	14.7	4.3	2.1	11.6	2.5
08/24/2020 18:00	14.8	4.3	2.1	11.6	2.5
08/24/2020 19:00	14.5	4.6	2.1	11.5	2.5
08/24/2020 20:00	14.7	4.7	2.1	11.5	2.5
08/24/2020 21:00	14.7	5.0	2.1	11.5	2.5
08/24/2020 22:00	14.7	5.0	2.1	11.5	2.5
08/24/2020 23:00	14.7	5.0	2.1	11.5	2.5
Average/Sum#:	355.0 #	111.6 #	50.4 #	277.4 #	60.9 #
Minimum:	14.5	4.0	2.1	11.3	2.5
Maximum:	16.9	5.1	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/25/2020 00:00	14.5	5.0	2.1	11.4	2.5
08/25/2020 01:00	14.5	5.0	2.1	11.3	2.5
08/25/2020 02:00	14.4	5.0	2.1	11.3	2.4
08/25/2020 03:00	14.1	5.8	2.0	11.1	2.4
08/25/2020 04:00	16.4	5.8	2.0	11.3	2.4
08/25/2020 05:00	16.5	5.4	2.1	11.3	2.4
08/25/2020 06:00	14.4	5.8	2.1	11.3	2.4
08/25/2020 07:00	14.3	5.5	2.0	11.3	2.4
08/25/2020 08:00	14.3	5.5	2.0	11.3	2.4
08/25/2020 09:00	14.5	5.0	2.1	11.3	2.5
08/25/2020 10:00	16.6	4.7	2.1	11.3	2.5
08/25/2020 11:00	16.6	4.7	2.1	11.3	2.5
08/25/2020 12:00	14.5	4.7	2.1	11.3	2.5
08/25/2020 13:00	14.5	4.7	2.1	11.3	2.5
08/25/2020 14:00	14.5	4.7	2.1	11.3	2.5
08/25/2020 15:00	14.5	4.3	2.1	11.3	2.5
08/25/2020 16:00	14.6	4.3	2.1	11.5	2.5
08/25/2020 17:00	14.8	4.3	2.1	11.6	2.5
08/25/2020 18:00	14.8	4.0	2.1	11.7	2.6
08/25/2020 19:00	14.9	4.0	2.1	11.7	2.6
08/25/2020 20:00	14.7	4.4	2.1	11.5	2.5
08/25/2020 21:00	14.5	4.6	2.1	11.5	2.5
08/25/2020 22:00	14.5	5.0	2.1	11.4	2.5
08/25/2020 23:00	14.5	5.0	2.1	11.4	2.5
Average/Sum#:	356.4 #	117.2 #	50.0 #	273.0 #	59.5 #
Minimum:	14.1	4.0	2.0	11.1	2.4
Maximum:	16.6	5.8	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/26/2020 00:00	14.3	5.0	2.0	11.3	2.4
08/26/2020 01:00	15.5	5.8	2.0	10.7	2.4
08/26/2020 02:00	15.5	5.9	2.0	10.7	2.4
08/26/2020 03:00	14.3	5.8	2.0	11.2	2.4
08/26/2020 04:00	14.3	5.4	2.0	11.3	2.4
08/26/2020 05:00	16.4	5.1	2.0	11.3	2.4
08/26/2020 06:00	14.3	5.5	2.0	11.3	2.4
08/26/2020 07:00	15.6	5.5	2.0	10.7	2.4
08/26/2020 08:00	13.7	5.9	2.0	10.7	2.4
08/26/2020 09:00	16.4	5.1	2.1	11.3	2.4
08/26/2020 10:00	16.6	5.1	2.1	11.4	2.5
08/26/2020 11:00	14.5	4.7	2.1	11.3	2.5
08/26/2020 12:00	14.5	4.7	2.1	11.4	2.5
08/26/2020 13:00	14.5	4.7	2.1	11.4	2.5
08/26/2020 14:00	14.6	4.3	2.1	11.5	2.5
08/26/2020 15:00	14.8	4.0	2.1	11.6	2.5
08/26/2020 16:00	14.3	4.6	2.1	11.3	2.4
08/26/2020 17:00	14.2	4.6	2.0	11.1	2.4
08/26/2020 18:00	14.2	4.6	2.0	11.2	2.4
08/26/2020 19:00	16.2	4.7	2.0	11.1	2.4
08/26/2020 20:00	14.1	5.0	2.0	11.1	2.4
08/26/2020 21:00	14.1	5.1	2.0	11.1	2.4
08/26/2020 22:00	15.5	5.5	2.0	10.7	2.4
08/26/2020 23:00	15.5	5.5	2.0	10.7	2.4
Average/Sum#:	357.9 #	122.1 #	48.8 #	267.4 #	58.2 #
Minimum:	13.7	4.0	2.0	10.7	2.4
Maximum:	16.6	5.9	2.1	11.6	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/27/2020 00:00	13.5	5.5	2.0	10.7	2.4
08/27/2020 01:00	13.5	5.5	2.0	10.7	2.4
08/27/2020 02:00	13.5	5.5	2.0	10.6	2.4
08/27/2020 03:00	13.6	4.3	2.0	10.7	2.4
08/27/2020 04:00	14.3	4.5	2.0	11.3	2.4
08/27/2020 05:00	14.3	4.2	2.0	11.3	2.4
08/27/2020 06:00	14.5	4.2	2.1	11.4	2.5
08/27/2020 07:00	13.7	5.9	2.0	10.7	2.4
08/27/2020 08:00	14.1	5.5	2.0	11.0	2.4
08/27/2020 09:00	14.1	5.2	2.0	11.0	2.4
08/27/2020 10:00	14.0	5.1	2.0	11.0	2.4
08/27/2020 11:00	14.9	4.1	2.1	11.7	2.6
08/27/2020 12:00	14.9	3.7	2.1	11.7	2.6
08/27/2020 13:00	14.9	3.7	2.1	11.7	2.6
08/27/2020 14:00	14.9	3.6	2.1	11.7	2.6
08/27/2020 15:00	14.9	3.6	2.1	11.7	2.6
08/27/2020 16:00	14.5	4.6	2.1	11.3	2.5
08/27/2020 17:00	14.5	4.6	2.1	11.3	2.5
08/27/2020 18:00	14.5	4.3	2.1	11.3	2.5
08/27/2020 19:00	14.7	4.0	2.1	11.5	2.5
08/27/2020 20:00	14.9	4.6	2.1	11.7	2.6
08/27/2020 21:00	15.1	4.3	2.1	11.8	2.6
08/27/2020 22:00	15.1	4.3	2.1	11.8	2.6
08/27/2020 23:00	14.1	5.7	2.0	11.1	2.4
Average/Sum#:	345.0 #	110.5 #	49.3 #	270.7 #	59.7 #
Minimum:	13.5	3.6	2.0	10.6	2.4
Maximum:	15.1	5.9	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/28/2020 00:00	13.5	6.0	2.0	10.5	2.3
08/28/2020 01:00	9.1	2.0	1.6	8.3	1.8
08/28/2020 02:00	7.2	1.3	1.4	7.9	1.8
08/28/2020 03:00	6.5	1.7	1.3	7.1	1.6
08/28/2020 04:00	7.3	1.4	1.4	8.1	1.8
08/28/2020 05:00	9.6	1.8	1.6	8.8	2.0
08/28/2020 06:00	7.3	1.9	1.4	7.9	1.8
08/28/2020 07:00	6.8	2.4	1.4	7.5	1.6
08/28/2020 08:00	7.0	1.8	1.4	7.7	1.6
08/28/2020 09:00	7.1	1.6	1.4	7.9	1.8
08/28/2020 10:00	7.3	1.3	1.4	8.1	1.8
08/28/2020 11:00	9.0	1.7	1.6	8.3	1.8
08/28/2020 12:00	14.2	6.1	2.0	11.1	2.4
08/28/2020 13:00	14.8	4.8	2.1	11.6	2.5
08/28/2020 14:00	14.7	4.8	2.1	11.6	2.5
08/28/2020 15:00	14.7	4.8	2.1	11.6	2.5
08/28/2020 16:00	14.7	4.8	2.1	11.6	2.5
08/28/2020 17:00	14.7	4.5	2.1	11.6	2.5
08/28/2020 18:00	14.7	4.8	2.1	11.6	2.5
08/28/2020 19:00	14.2	4.9	2.0	11.1	2.4
08/28/2020 20:00	14.1	5.5	2.0	11.1	2.4
08/28/2020 21:00	14.1	5.5	2.0	11.1	2.4
08/28/2020 22:00	13.9	5.5	2.0	10.9	2.4
08/28/2020 23:00	14.4	5.2	2.1	11.3	2.5
Average/Sum#:	270.9 #	86.1 #	42.6 #	234.3 #	51.2 #
Minimum:	6.5	1.3	1.3	7.1	1.6
Maximum:	14.8	6.1	2.1	11.6	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/29/2020 00:00	14.5	5.2	2.1	11.4	2.5
08/29/2020 01:00	14.5	5.3	2.1	11.3	2.5
08/29/2020 02:00	14.3	5.4	2.0	11.3	2.4
08/29/2020 03:00	13.5	5.7	2.0	10.7	2.4
08/29/2020 04:00	9.6	2.4	1.6	8.8	2.0
08/29/2020 05:00	9.5	2.7	1.6	8.7	1.9
08/29/2020 06:00	9.4	2.7	1.6	8.6	1.8
08/29/2020 07:00	7.1	2.4	1.4	7.9	1.8
08/29/2020 08:00	6.9	1.8	1.4	7.6	1.6
08/29/2020 09:00	6.4	2.0	1.3	7.0	1.6
08/29/2020 10:00	6.5	1.7	1.3	7.1	1.6
08/29/2020 11:00	6.7	1.5	1.3	7.3	1.6
08/29/2020 12:00	6.5	1.7	1.3	7.1	1.6
08/29/2020 13:00	9.6	2.1	1.6	8.8	2.0
08/29/2020 14:00	9.6	2.4	1.6	8.8	2.0
08/29/2020 15:00	9.6	2.7	1.6	8.8	2.0
08/29/2020 16:00	10.0	2.7	1.7	9.1	2.0
08/29/2020 17:00	14.3	5.7	2.0	11.3	2.4
08/29/2020 18:00	14.5	4.8	2.1	11.5	2.5
08/29/2020 19:00	14.5	4.8	2.1	11.5	2.5
08/29/2020 20:00	14.9	4.8	2.1	11.7	2.6
08/29/2020 21:00	14.7	4.9	2.1	11.7	2.6
08/29/2020 22:00	16.1	5.8	2.0	11.1	2.4
08/29/2020 23:00	14.1	6.0	2.0	11.0	2.4
Average/Sum#:	267.3 #	87.2 #	41.9 #	230.1 #	50.7 #
Minimum:	6.4	1.5	1.3	7.0	1.6
Maximum:	16.1	6.0	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/30/2020 00:00	13.4	5.6	2.0	10.5	2.3
08/30/2020 01:00	12.3	2.6	1.7	9.6	2.1
08/30/2020 02:00	14.0	2.6	1.7	9.6	2.1
08/30/2020 03:00	12.3	2.6	1.7	9.6	2.1
08/30/2020 04:00	14.0	2.6	1.7	9.6	2.1
08/30/2020 05:00	14.0	2.6	1.7	9.6	2.0
08/30/2020 06:00	10.4	2.6	1.7	9.6	2.0
08/30/2020 07:00	12.2	1.9	1.7	9.6	2.1
08/30/2020 08:00	12.3	2.6	1.7	9.6	2.1
08/30/2020 09:00	14.1	2.5	1.7	9.6	2.1
08/30/2020 10:00	13.9	2.5	1.7	9.6	2.1
08/30/2020 11:00	13.9	2.5	1.7	9.6	2.1
08/30/2020 12:00	13.9	2.5	1.7	9.6	2.0
08/30/2020 13:00	9.8	2.4	1.6	9.0	2.0
08/30/2020 14:00	9.2	2.6	1.6	8.5	1.8
08/30/2020 15:00	14.4	5.5	2.1	11.3	2.5
08/30/2020 16:00	14.9	4.5	2.1	11.7	2.6
08/30/2020 17:00	14.7	4.8	2.1	11.5	2.5
08/30/2020 18:00	14.5	4.9	2.1	11.3	2.5
08/30/2020 19:00	14.3	5.5	2.0	11.1	2.4
08/30/2020 20:00	14.1	5.5	2.0	11.1	2.4
08/30/2020 21:00	14.1	5.9	2.0	11.1	2.4
08/30/2020 22:00	14.1	5.6	2.0	11.1	2.4
08/30/2020 23:00	13.5	5.9	2.0	10.7	2.4
Average/Sum#:	318.3 #	88.8 #	44.0 #	244.1 #	53.1 #
Minimum:	9.2	1.9	1.6	8.5	1.8
Maximum:	14.9	5.9	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
08/31/2020 00:00	9.6	2.7	1.6	8.8	2.0
08/31/2020 01:00	6.5	2.9	1.3	7.2	1.6
08/31/2020 02:00	6.5	2.0	1.3	7.1	1.6
08/31/2020 03:00	6.5	2.0	1.3	7.1	1.6
08/31/2020 04:00	9.8	2.4	1.6	9.0	2.0
08/31/2020 05:00	10.0	2.5	1.7	9.2	2.0
08/31/2020 06:00	10.2	2.5	1.7	9.3	2.0
08/31/2020 07:00	7.0	2.9	1.4	7.6	1.6
08/31/2020 08:00	7.0	2.1	1.4	7.7	1.6
08/31/2020 09:00	6.5	1.5	1.3	7.2	1.6
08/31/2020 10:00	6.5	1.2	1.3	7.2	1.6
08/31/2020 11:00	9.0	1.2	1.6	8.3	1.8
08/31/2020 12:00	7.4	1.1	1.4	8.1	1.8
08/31/2020 13:00	14.4	5.5	2.1	11.2	2.5
08/31/2020 14:00	15.1	4.8	2.1	11.8	2.6
08/31/2020 15:00	14.9	4.5	2.1	11.8	2.6
08/31/2020 16:00	14.3	4.9	2.1	11.3	2.4
08/31/2020 17:00	14.1	5.3	2.0	11.1	2.4
08/31/2020 18:00	14.1	5.6	2.0	11.1	2.4
08/31/2020 19:00	14.1	5.6	2.0	11.1	2.4
08/31/2020 20:00	14.1	5.6	2.0	11.1	2.4
08/31/2020 21:00	16.1	5.6	2.0	11.1	2.4
08/31/2020 22:00	16.1	5.6	2.0	11.1	2.4
08/31/2020 23:00	12.5	4.8	1.8	9.8	2.2
Average/Sum#:	262.3 #	84.8 #	41.1 #	226.3 #	49.5 #
Minimum:	6.5	1.1	1.3	7.1	1.6
Maximum:	16.1	5.6	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/01/2020 00:00	6.5	2.2	1.3	7.1	1.6
09/01/2020 01:00	7.5	1.4	1.4	8.2	1.8
09/01/2020 02:00	7.0	1.6	1.4	7.7	1.6
09/01/2020 03:00	5.2	2.0	1.3	7.2	1.6
09/01/2020 04:00	6.7	1.5	1.3	7.4	1.6
09/01/2020 05:00	11.7	1.5	1.7	9.2	2.0
09/01/2020 06:00	10.0	2.1	1.7	9.1	2.0
09/01/2020 07:00	10.0	2.5	1.7	9.2	2.0
09/01/2020 08:00	4.8	0.9	1.6	8.8	2.0
09/01/2020 09:00	8.1	1.5	1.6	9.0	2.0
09/01/2020 10:00	8.9	1.1	1.4	8.1	1.8
09/01/2020 11:00	5.2	0.6	1.3	7.2	1.6
09/01/2020 12:00	6.7	0.3	1.3	7.4	1.6
09/01/2020 13:00	9.0	0.3	1.4	8.2	1.8
09/01/2020 14:00	9.8	0.9	1.7	9.0	2.0
09/01/2020 15:00	9.6	0.9	1.6	8.8	2.0
09/01/2020 16:00	9.2	0.9	1.6	8.5	1.8
09/01/2020 17:00	14.3	4.3	2.0	11.3	2.4
09/01/2020 18:00	14.9	3.3	2.1	11.7	2.6
09/01/2020 19:00	14.7	3.3	2.1	11.5	2.5
09/01/2020 20:00	14.1	4.1	2.0	11.1	2.4
09/01/2020 21:00	13.9	4.4	2.0	11.0	2.4
09/01/2020 22:00	13.5	4.4	2.0	10.7	2.4
09/01/2020 23:00	12.4	3.0	1.7	9.8	2.2
Average/Sum#:	228.9 #	48.1 #	39.2 #	217.2 #	47.7 #
Minimum:	5.2	0.3	1.3	7.1	1.6
Maximum:	14.9	4.4	2.1	11.7	2.6
%SI	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/02/2020 00:00	5.2	1.5	1.3	7.0	1.6
09/02/2020 01:00	5.2	1.2	1.3	7.0	1.6
09/02/2020 02:00	5.2	1.2	1.3	7.2	1.6
09/02/2020 03:00	5.2	1.0	1.3	7.1	1.6
09/02/2020 04:00	5.2	1.0	1.3	7.2	1.6
09/02/2020 05:00	5.2	1.2	1.3	7.0	1.6
09/02/2020 06:00	5.2	1.0	1.3	7.1	1.6
09/02/2020 07:00	7.0	6.6	1.1	4.7	1.0
09/02/2020 08:00	4.1	1.0	1.0	3.4	0.8
09/02/2020 09:00	4.1	0.5	1.0	3.4	0.8
09/02/2020 10:00	4.2	0.0	1.0	3.5	0.8
09/02/2020 11:00	4.2	0.0	1.0	3.5	0.8
09/02/2020 12:00	4.2	0.0	1.0	3.5	0.8
09/02/2020 13:00	4.2	0.0	1.0	3.5	0.8
09/02/2020 14:00	4.2	0.0	1.0	3.5	0.8
09/02/2020 15:00	4.3	0.0	1.0	3.5	0.9
09/02/2020 16:00	5.8	3.8	1.3	4.8	1.2
09/02/2020 17:00	5.9	4.1	1.4	4.9	1.2
09/02/2020 18:00	5.9	3.8	1.4	4.9	1.2
09/02/2020 19:00	5.8	3.8	1.4	4.9	1.2
09/02/2020 20:00	5.7	3.7	1.3	4.8	1.1
09/02/2020 21:00	4.2	0.5	1.0	3.5	0.8
09/02/2020 22:00	4.1	0.3	1.0	3.4	0.8
09/02/2020 23:00	4.1	0.5	1.0	3.4	0.8
Average/Sum#:	118.4 #	36.7 #	28.0 #	116.7 #	27.0 #
Minimum:	4.1	0.0	1.0	3.4	0.8
Maximum:	7.0	6.6	1.4	7.2	1.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/03/2020 00:00	4.1	0.5	1.0	3.4	0.8
09/03/2020 01:00	4.1	0.8	1.0	3.4	0.8
09/03/2020 02:00	4.1	0.8	1.0	3.4	0.8
09/03/2020 03:00	34.5	33.0	1.1	4.6	1.1
09/03/2020 04:00	62.5	32.9	1.3	6.6	1.5
09/03/2020 05:00	7.8	0.9	1.6	8.6	1.8
09/03/2020 06:00	8.0	0.6	1.6	8.7	1.9
09/03/2020 07:00	9.8	0.6	1.7	9.0	2.0
09/03/2020 08:00	8.2	0.6	1.6	9.0	2.0
09/03/2020 09:00	7.7	0.6	1.6	8.4	1.8
09/03/2020 10:00	9.4	0.6	1.6	8.6	1.8
09/03/2020 11:00	9.2	0.6	1.6	8.4	1.8
09/03/2020 12:00	14.5	6.0	2.1	11.3	2.5
09/03/2020 13:00	14.9	3.1	2.1	11.7	2.6
09/03/2020 14:00	14.5	3.7	2.1	11.5	2.5
09/03/2020 15:00	14.9	3.0	2.1	11.7	2.6
09/03/2020 16:00	14.9	2.7	2.1	11.7	2.6
09/03/2020 17:00	14.9	2.7	2.1	11.7	2.6
09/03/2020 18:00	14.9	2.7	2.1	11.7	2.6
09/03/2020 19:00	14.5	3.0	2.1	11.5	2.5
09/03/2020 20:00	14.1	3.7	2.0	11.1	2.4
09/03/2020 21:00	14.1	3.4	2.0	11.1	2.4
09/03/2020 22:00	14.3	3.1	2.0	11.3	2.4
09/03/2020 23:00	14.9	2.8	2.1	11.7	2.6
Average/Sum#:	344.8 #	112.4 #	41.6 #	220.1 #	48.4 #
Minimum:	4.1	0.5	1.0	3.4	0.8
Maximum:	62.5	33.0	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/04/2020 00:00	14.1	3.7	2.0	11.1	2.4
09/04/2020 01:00	13.9	3.8	2.0	10.9	2.4
09/04/2020 02:00	13.9	3.8	2.0	10.9	2.4
09/04/2020 03:00	13.9	4.2	2.0	11.0	2.4
09/04/2020 04:00	14.9	3.1	2.1	11.7	2.6
09/04/2020 05:00	15.1	2.8	2.1	11.9	2.6
09/04/2020 06:00	14.9	2.8	2.1	11.7	2.6
09/04/2020 07:00	14.8	2.8	2.1	11.7	2.6
09/04/2020 08:00	14.2	3.1	2.0	11.2	2.4
09/04/2020 09:00	13.9	3.4	2.0	10.9	2.4
09/04/2020 10:00	14.5	3.1	2.1	11.3	2.5
09/04/2020 11:00	14.7	2.8	2.1	11.5	2.5
09/04/2020 12:00	14.7	2.8	2.1	11.5	2.5
09/04/2020 13:00	14.7	2.4	2.1	11.6	2.5
09/04/2020 14:00	14.7	2.4	2.1	11.6	2.5
09/04/2020 15:00	14.8	2.4	2.1	11.6	2.5
09/04/2020 16:00	14.8	2.4	2.1	11.6	2.5
09/04/2020 17:00	14.8	2.4	2.1	11.6	2.5
09/04/2020 18:00	14.9	2.7	2.1	11.7	2.6
09/04/2020 19:00	14.9	2.4	2.1	11.7	2.6
09/04/2020 20:00	14.9	2.4	2.1	11.7	2.6
09/04/2020 21:00	14.7	2.5	2.1	11.5	2.5
09/04/2020 22:00	14.7	2.5	2.1	11.5	2.5
09/04/2020 23:00	14.3	3.1	2.0	11.2	2.4
Average/Sum#:	349.7 #	69.8 #	49.7 #	274.6 #	60.0 #
Minimum:	13.9	2.4	2.0	10.9	2.4
Maximum:	15.1	4.2	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/05/2020 00:00	14.1	3.4	2.0	11.1	2.4
09/05/2020 01:00	14.1	3.4	2.0	11.1	2.4
09/05/2020 02:00	14.1	3.4	2.0	11.1	2.4
09/05/2020 03:00	14.1	3.4	2.0	11.1	2.4
09/05/2020 04:00	14.1	3.5	2.0	11.1	2.4
09/05/2020 05:00	13.9	3.8	2.0	10.9	2.4
09/05/2020 06:00	9.8	1.2	1.7	9.0	2.0
09/05/2020 07:00	9.4	1.2	1.6	8.6	1.8
09/05/2020 08:00	9.7	1.2	1.6	8.8	2.0
09/05/2020 09:00	9.6	1.8	1.6	8.8	2.0
09/05/2020 10:00	9.8	1.5	1.6	9.0	2.0
09/05/2020 11:00	14.3	4.3	2.0	11.3	2.4
09/05/2020 12:00	14.7	2.7	2.1	11.7	2.6
09/05/2020 13:00	14.9	2.4	2.1	11.7	2.6
09/05/2020 14:00	14.9	2.4	2.1	11.7	2.6
09/05/2020 15:00	14.8	2.4	2.1	11.7	2.6
09/05/2020 16:00	14.7	2.7	2.1	11.6	2.5
09/05/2020 17:00	14.8	2.4	2.1	11.7	2.6
09/05/2020 18:00	14.9	2.4	2.1	11.7	2.6
09/05/2020 19:00	14.9	2.4	2.1	11.7	2.6
09/05/2020 20:00	14.9	2.4	2.1	11.7	2.6
09/05/2020 21:00	14.9	2.4	2.1	11.7	2.6
09/05/2020 22:00	15.1	2.5	2.1	11.9	2.6
09/05/2020 23:00	14.7	2.8	2.1	11.5	2.5
Average/Sum#:	325.2 #	62.0 #	47.3 #	262.2 #	57.6 #
Minimum:	9.4	1.2	1.6	8.6	1.8
Maximum:	15.1	4.3	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/06/2020 00:00	14.9	2.5	2.1	11.7	2.6
09/06/2020 01:00	14.5	2.8	2.1	11.3	2.5
09/06/2020 02:00	14.6	1.8	2.1	11.5	2.5
09/06/2020 03:00	14.8	1.8	2.1	11.6	2.6
09/06/2020 04:00	14.3	3.8	2.0	11.3	2.4
09/06/2020 05:00	14.3	4.5	2.0	11.2	2.4
09/06/2020 06:00	13.9	4.8	2.0	10.9	2.4
09/06/2020 07:00	14.6	4.1	2.1	11.5	2.5
09/06/2020 08:00	14.7	3.4	2.1	11.6	2.6
09/06/2020 09:00	14.8	3.0	2.1	11.7	2.6
09/06/2020 10:00	14.7	2.4	2.1	11.6	2.5
09/06/2020 11:00	14.7	2.4	2.1	11.5	2.5
09/06/2020 12:00	14.7	2.4	2.1	11.6	2.5
09/06/2020 13:00	14.7	2.4	2.1	11.6	2.5
09/06/2020 14:00	14.7	2.4	2.1	11.6	2.5
09/06/2020 15:00	14.7	2.1	2.1	11.6	2.5
09/06/2020 16:00	14.3	2.4	2.1	11.3	2.4
09/06/2020 17:00	14.7	2.1	2.1	11.6	2.5
09/06/2020 18:00	14.6	2.4	2.1	11.5	2.5
09/06/2020 19:00	14.5	2.4	2.1	11.3	2.5
09/06/2020 20:00	14.5	2.4	2.1	11.3	2.5
09/06/2020 21:00	14.7	2.4	2.1	11.6	2.5
09/06/2020 22:00	14.8	1.5	2.1	11.7	2.6
09/06/2020 23:00	14.7	1.2	2.1	11.5	2.6
Average/Sum#:	350.4 #	63.4 #	50.1 #	275.6 #	60.2 #
Minimum:	13.9	1.2	2.0	10.9	2.4
Maximum:	14.9	4.8	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/07/2020 00:00	14.7	1.2	2.1	11.5	2.6
09/07/2020 01:00	14.6	1.2	2.1	11.5	2.5
09/07/2020 02:00	14.7	1.2	2.1	11.5	2.6
09/07/2020 03:00	14.5	3.1	2.1	11.5	2.5
09/07/2020 04:00	14.1	3.8	2.0	11.1	2.4
09/07/2020 05:00	16.2	3.4	2.0	11.1	2.4
09/07/2020 06:00	8.0	0.9	1.6	8.8	2.0
09/07/2020 07:00	11.2	0.6	1.6	8.8	2.0
09/07/2020 08:00	11.2	0.6	1.6	8.8	2.0
09/07/2020 09:00	11.0	0.6	1.6	8.6	1.8
09/07/2020 10:00	7.5	0.9	1.6	8.3	1.8
09/07/2020 11:00	7.5	0.6	1.6	8.3	1.8
09/07/2020 12:00	13.6	5.0	2.0	10.7	2.4
09/07/2020 13:00	12.1	3.0	1.7	9.6	2.0
09/07/2020 14:00	11.6	0.9	1.7	9.2	2.0
09/07/2020 15:00	13.7	0.9	1.7	9.4	2.0
09/07/2020 16:00	12.3	2.4	1.7	9.8	2.2
09/07/2020 17:00	14.1	4.0	2.0	11.1	2.4
09/07/2020 18:00	14.0	3.6	2.0	11.1	2.4
09/07/2020 19:00	14.7	3.0	2.1	11.5	2.5
09/07/2020 20:00	14.5	3.0	2.1	11.5	2.5
09/07/2020 21:00	14.1	3.3	2.0	11.1	2.4
09/07/2020 22:00	14.2	3.3	2.0	11.1	2.4
09/07/2020 23:00	14.2	3.4	2.0	11.1	2.4
Average/Sum#:	308.3 #	53.9 #	45.0 #	247.0 #	54.0 #
Minimum:	7.5	0.6	1.6	8.3	1.8
Maximum:	16.2	5.0	2.1	11.5	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/08/2020 00:00	14.3	3.7	2.0	11.1	2.4
09/08/2020 01:00	14.5	3.2	2.1	11.5	2.5
09/08/2020 02:00	14.5	3.1	2.1	11.3	2.5
09/08/2020 03:00	14.9	3.1	2.1	11.7	2.6
09/08/2020 04:00	14.5	3.2	2.1	11.4	2.5
09/08/2020 05:00	14.3	3.8	2.0	11.2	2.4
09/08/2020 06:00	9.8	0.6	1.6	9.0	2.0
09/08/2020 07:00	9.8	0.6	1.6	9.0	2.0
09/08/2020 08:00	7.5	0.3	1.6	8.3	1.8
09/08/2020 09:00	9.8	0.3	1.6	9.0	2.0
09/08/2020 10:00	9.4	0.3	1.6	8.7	1.8
09/08/2020 11:00	10.1	1.0	1.7	9.2	2.0
09/08/2020 12:00	9.2	0.9	1.6	8.4	1.8
09/08/2020 13:00	14.4	4.8	2.1	11.3	2.5
09/08/2020 14:00	15.0	3.2	2.1	11.7	2.6
09/08/2020 15:00	15.1	3.1	2.1	11.9	2.6
09/08/2020 16:00	15.1	3.1	2.1	11.9	2.6
09/08/2020 17:00	15.1	2.4	2.1	11.9	2.6
09/08/2020 18:00	14.8	1.2	2.1	11.6	2.6
09/08/2020 19:00	14.6	2.5	2.1	11.4	2.5
09/08/2020 20:00	14.5	3.5	2.1	11.4	2.5
09/08/2020 21:00	14.6	3.5	2.1	11.5	2.5
09/08/2020 22:00	14.2	3.8	2.0	11.1	2.4
09/08/2020 23:00	14.3	3.8	2.0	11.2	2.4
Average/Sum#:	314.3 #	59.0 #	46.6 #	256.7 #	56.1 #
Minimum:	7.5	0.3	1.6	8.3	1.8
Maximum:	15.1	4.8	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/09/2020 00:00	13.7	2.8	2.0	10.8	2.4
09/09/2020 01:00	11.7	0.3	1.7	9.2	2.0
09/09/2020 02:00	5.6	0.3	1.4	7.7	1.6
09/09/2020 03:00	10.0	0.3	1.7	9.1	2.0
09/09/2020 04:00	7.5	0.3	1.5	8.3	1.8
09/09/2020 05:00	7.8	0.3	1.6	8.7	1.8
09/09/2020 06:00	7.9	0.3	1.6	8.7	1.9
09/09/2020 07:00	7.8	0.3	1.6	8.6	1.8
09/09/2020 08:00	7.6	0.3	1.6	8.3	1.8
09/09/2020 09:00	7.2	0.3	1.4	7.9	1.8
09/09/2020 10:00	7.1	0.3	1.4	7.9	1.8
09/09/2020 11:00	7.5	0.3	1.4	8.2	1.8
09/09/2020 12:00	9.1	0.6	1.6	8.3	1.8
09/09/2020 13:00	14.5	5.1	2.1	11.4	2.5
09/09/2020 14:00	14.2	4.5	2.0	11.2	2.4
09/09/2020 15:00	14.1	4.5	2.0	11.1	2.4
09/09/2020 16:00	14.0	4.4	2.0	11.0	2.4
09/09/2020 17:00	14.0	4.1	2.0	11.0	2.4
09/09/2020 18:00	14.0	4.5	2.0	11.0	2.4
09/09/2020 19:00	14.0	4.2	2.0	11.0	2.4
09/09/2020 20:00	14.0	4.2	2.0	11.0	2.4
09/09/2020 21:00	14.0	4.5	2.0	11.0	2.4
09/09/2020 22:00	14.0	4.2	2.0	11.0	2.4
09/09/2020 23:00	13.5	4.2	1.9	10.6	2.4
Average/Sum#:	264.8 #	55.1 #	42.5 #	233.0 #	50.8 #
Minimum:	5.6	0.3	1.4	7.7	1.6
Maximum:	14.5	5.1	2.1	11.4	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/10/2020 00:00	7.6	0.6	1.6	8.3	1.8
09/10/2020 01:00	7.5	0.6	1.4	8.2	1.8
09/10/2020 02:00	5.2	0.3	1.3	7.2	1.6
09/10/2020 03:00	8.0	0.6	1.6	8.8	2.0
09/10/2020 04:00	7.8	0.6	1.6	8.6	1.8
09/10/2020 05:00	7.8	0.6	1.6	8.6	1.8
09/10/2020 06:00	8.0	0.6	1.6	8.8	2.0
09/10/2020 07:00	8.2	0.6	1.7	9.0	2.0
09/10/2020 08:00	8.3	0.6	1.7	9.2	2.0
09/10/2020 09:00	9.8	0.9	1.6	9.0	2.0
09/10/2020 10:00	8.3	0.6	1.7	9.2	2.0
09/10/2020 11:00	7.3	0.6	1.4	8.1	1.8
09/10/2020 12:00	7.2	0.6	1.4	7.9	1.8
09/10/2020 13:00	7.3	0.6	1.4	8.1	1.8
09/10/2020 14:00	9.6	0.9	1.6	8.8	2.0
09/10/2020 15:00	9.4	0.9	1.6	8.6	1.8
09/10/2020 16:00	14.3	5.4	2.0	11.2	2.4
09/10/2020 17:00	14.2	4.8	2.0	11.1	2.4
09/10/2020 18:00	14.0	4.4	2.0	11.0	2.4
09/10/2020 19:00	14.0	4.5	2.0	11.0	2.4
09/10/2020 20:00	14.0	4.5	2.0	11.0	2.4
09/10/2020 21:00	13.9	4.5	2.0	11.0	2.4
09/10/2020 22:00	13.9	4.5	2.0	10.9	2.4
09/10/2020 23:00	12.8	3.8	1.8	10.1	2.2
Average/Sum#:	238.4 #	46.6 #	40.6 #	223.7 #	49.0 #
Minimum:	5.2	0.3	1.3	7.2	1.6
Maximum:	14.3	5.4	2.0	11.2	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/11/2020 00:00	5.6	1.9	1.4	7.7	1.6
09/11/2020 01:00	5.2	1.2	1.3	7.1	1.6
09/11/2020 02:00	5.2	1.0	1.3	7.1	1.6
09/11/2020 03:00	5.2	1.0	1.3	7.1	1.6
09/11/2020 04:00	5.2	0.7	1.3	7.1	1.6
09/11/2020 05:00	7.5	0.6	1.4	8.1	1.8
09/11/2020 06:00	5.2	1.0	1.3	7.1	1.6
09/11/2020 07:00	5.2	1.3	1.3	7.3	1.6
09/11/2020 08:00	5.4	1.0	1.3	7.4	1.6
09/11/2020 09:00	7.8	0.6	1.6	8.6	1.8
09/11/2020 10:00	7.8	0.6	1.6	8.5	1.8
09/11/2020 11:00	7.7	0.9	1.6	8.5	1.8
09/11/2020 12:00	9.5	0.9	1.6	8.7	1.9
09/11/2020 13:00	6.5	1.0	1.3	7.1	1.6
09/11/2020 14:00	6.5	0.8	1.3	7.2	1.6
09/11/2020 15:00	6.7	1.1	1.3	7.3	1.6
09/11/2020 16:00	9.8	1.5	1.7	9.0	2.0
09/11/2020 17:00	9.8	1.2	1.6	9.0	2.0
09/11/2020 18:00	10.8	3.5	1.8	9.9	2.2
09/11/2020 19:00	14.3	4.4	2.0	11.2	2.4
09/11/2020 20:00	14.0	4.7	2.0	11.0	2.4
09/11/2020 21:00	13.7	5.1	2.0	10.8	2.4
09/11/2020 22:00	8.9	2.4	1.4	8.1	1.8
09/11/2020 23:00	2.9	6.5	0.0	0.4	0.0
Average/Sum#:	186.4 #	44.9 #	34.7 #	191.3 #	41.9 #
Minimum:	2.9	0.6	0.0	0.4	0.0
Maximum:	14.3	6.5	2.0	11.2	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/12/2020 00:00	0.0	0.0	0.0	0.0	0.0
09/12/2020 01:00	0.0	0.0	0.0	0.0	0.0
09/12/2020 02:00	0.0	0.0	0.0	0.0	0.0
09/12/2020 03:00	0.0	0.0	0.0	0.0	0.0
09/12/2020 04:00	0.0	0.0	0.0	0.0	0.0
09/12/2020 05:00	0.0	0.0	0.0	0.0	0.0
09/12/2020 06:00	0.0	0.0	0.0	0.0	0.0
09/12/2020 07:00	0.0	0.0	0.0	0.0	0.0
09/12/2020 08:00	0.0	0.0	0.0	0.0	0.0
09/12/2020 09:00	0.0	0.0	0.0	0.0	0.0
09/12/2020 10:00	0.0	0.0	0.0	0.0	0.0
09/12/2020 11:00	0.0	0.0	0.0	0.0	0.0
09/12/2020 12:00	0.0	0.0	0.0	0.0	0.0
09/12/2020 13:00	0.0	0.0	0.0	0.0	0.0
09/12/2020 14:00	0.0	0.0	0.0	0.0	0.0
09/12/2020 15:00	0.0	0.0	0.0	0.0	0.0
09/12/2020 16:00	0.0	0.0	0.0	0.0	0.0
09/12/2020 17:00	60.1	21.6	0.1	1.1	0.2
09/12/2020 18:00	21.0	18.7	0.2	1.5	0.3
09/12/2020 19:00	37.1	26.1	0.3	2.8	0.6
09/12/2020 20:00	3.0	0.6	0.4	4.4	0.9
09/12/2020 21:00	4.5	0.6	0.4	4.5	0.9
09/12/2020 22:00	2.9	0.5	0.4	4.4	0.9
09/12/2020 23:00	2.7	0.5	0.4	4.1	0.8
Average/Sum#:	131.3 #	68.6 #	2.2 #	22.8 #	4.6 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	60.1	26.1	0.4	4.5	0.9
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/13/2020 00:00	2.7	0.5	0.4	4.1	0.8
09/13/2020 01:00	2.7	0.5	0.4	4.0	0.8
09/13/2020 02:00	1.3	2.5	0.0	0.2	0.0
09/13/2020 03:00	0.0	0.0	0.0	0.0	0.0
09/13/2020 04:00	0.0	0.0	0.0	0.0	0.0
09/13/2020 05:00	0.0	0.0	0.0	0.0	0.0
09/13/2020 06:00	0.0	0.0	0.0	0.0	0.0
09/13/2020 07:00	0.0	0.0	0.0	0.0	0.0
09/13/2020 08:00	0.0	0.0	0.0	0.0	0.0
09/13/2020 09:00	0.0	0.0	0.0	0.0	0.0
09/13/2020 10:00	0.0	0.0	0.0	0.0	0.0
09/13/2020 11:00	0.0	0.0	0.0	0.0	0.0
09/13/2020 12:00	0.0	0.0	0.0	0.0	0.0
09/13/2020 13:00	0.0	0.0	0.0	0.0	0.0
09/13/2020 14:00	0.0	0.0	0.0	0.0	0.0
09/13/2020 15:00	0.0	0.0	0.0	0.0	0.0
09/13/2020 16:00	0.0	0.0	0.0	0.0	0.0
09/13/2020 17:00	63.5	36.0	0.1	1.3	0.2
09/13/2020 18:00	20.6	20.0	0.2	1.5	0.3
09/13/2020 19:00	44.9	31.1	0.3	3.1	0.6
09/13/2020 20:00	2.9	0.8	0.4	4.4	0.9
09/13/2020 21:00	2.8	0.8	0.4	4.1	0.8
09/13/2020 22:00	2.8	0.8	0.4	4.1	0.8
09/13/2020 23:00	2.7	0.8	0.4	4.0	0.8
Average/Sum#:	146.9 #	93.8 #	3.0 #	30.8 #	6.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	63.5	36.0	0.4	4.4	0.9
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/14/2020 00:00	2.7	0.8	0.4	4.0	0.8
09/14/2020 01:00	2.7	0.8	0.4	4.0	0.8
09/14/2020 02:00	1.1	3.0	0.0	0.2	0.0
09/14/2020 03:00	0.0	0.0	0.0	0.0	0.0
09/14/2020 04:00	0.0	0.0	0.0	0.0	0.0
09/14/2020 05:00	0.0	0.0	0.0	0.0	0.0
09/14/2020 06:00	0.0	0.0	0.0	0.0	0.0
09/14/2020 07:00	0.0	0.0	0.0	0.0	0.0
09/14/2020 08:00	0.0	0.0	0.0	0.0	0.0
09/14/2020 09:00	0.2	1.2	0.0	0.1	0.0
09/14/2020 10:00	75.3	44.1	0.2	1.9	0.4
09/14/2020 11:00	17.2	6.7	0.4	4.0	0.8
09/14/2020 12:00	2.7	0.8	0.4	4.0	0.8
09/14/2020 13:00	58.2	80.5	0.7	5.4	1.2
09/14/2020 14:00	74.1	60.1	1.0	6.3	1.3
09/14/2020 15:00	20.4	6.2	1.6	8.6	1.8
09/14/2020 16:00	10.8	2.7	1.8	9.9	2.2
09/14/2020 17:00	14.9	2.8	2.1	11.7	2.6
09/14/2020 18:00	14.9	2.8	2.1	11.7	2.6
09/14/2020 19:00	14.7	2.8	2.1	11.6	2.6
09/14/2020 20:00	14.9	2.8	2.1	11.7	2.6
09/14/2020 21:00	14.2	3.5	2.0	11.1	2.4
09/14/2020 22:00	13.7	3.5	2.0	10.7	2.4
09/14/2020 23:00	13.7	3.8	2.0	10.7	2.4
Average/Sum#:	366.4 #	228.9 #	21.3 #	127.6 #	27.7 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	75.3	80.5	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/15/2020 00:00	5.8	0.5	1.4	7.9	1.8
09/15/2020 01:00	6.7	0.5	1.3	7.3	1.6
09/15/2020 02:00	5.2	0.5	1.3	7.1	1.6
09/15/2020 03:00	5.2	0.5	1.3	7.1	1.6
09/15/2020 04:00	5.2	0.5	1.3	7.2	1.6
09/15/2020 05:00	7.8	0.6	1.6	8.6	1.8
09/15/2020 06:00	8.0	0.9	1.6	8.8	2.0
09/15/2020 07:00	7.2	0.5	1.4	7.9	1.8
09/15/2020 08:00	7.1	0.5	1.4	7.9	1.8
09/15/2020 09:00	6.5	0.5	1.3	7.1	1.6
09/15/2020 10:00	9.6	0.6	1.6	8.8	2.0
09/15/2020 11:00	9.6	0.6	1.6	8.8	2.0
09/15/2020 12:00	9.6	0.9	1.6	8.8	2.0
09/15/2020 13:00	10.0	0.9	1.7	9.2	2.0
09/15/2020 14:00	14.6	3.8	2.1	11.5	2.5
09/15/2020 15:00	14.8	3.0	2.1	11.6	2.6
09/15/2020 16:00	14.3	3.5	2.0	11.3	2.4
09/15/2020 17:00	14.3	3.5	2.0	11.2	2.4
09/15/2020 18:00	14.1	3.4	2.0	11.1	2.4
09/15/2020 19:00	14.3	3.8	2.0	11.3	2.4
09/15/2020 20:00	14.9	2.8	2.1	11.7	2.6
09/15/2020 21:00	14.4	3.2	2.1	11.3	2.4
09/15/2020 22:00	9.6	11.2	0.7	3.5	0.8
09/15/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	228.8 #	46.7 #	37.5 #	207.0 #	45.7 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	14.9	11.2	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/16/2020 00:00	0.0	0.0	0.0	0.0	0.0
09/16/2020 01:00	0.0	0.0	0.0	0.0	0.0
09/16/2020 02:00	0.0	0.0	0.0	0.0	0.0
09/16/2020 03:00	0.0	0.0	0.0	0.0	0.0
09/16/2020 04:00	0.0	0.0	0.0	0.0	0.0
09/16/2020 05:00	0.0	0.0	0.0	0.0	0.0
09/16/2020 06:00	11.2	17.4	0.2	0.6	0.1
09/16/2020 07:00	33.3	42.2	0.8	2.8	0.7
09/16/2020 08:00	2.8	0.0	1.0	3.5	0.8
09/16/2020 09:00	4.2	0.0	1.0	3.5	0.8
09/16/2020 10:00	4.2	0.0	1.0	3.5	0.8
09/16/2020 11:00	54.4	19.2	1.2	5.0	1.2
09/16/2020 12:00	44.3	23.6	1.4	7.3	1.6
09/16/2020 13:00	10.1	0.6	1.7	9.2	2.0
09/16/2020 14:00	11.8	0.6	1.7	9.2	2.0
09/16/2020 15:00	14.5	3.8	2.1	11.3	2.5
09/16/2020 16:00	14.8	2.7	2.1	11.6	2.6
09/16/2020 17:00	15.0	2.1	2.1	11.9	2.6
09/16/2020 18:00	14.9	2.1	2.1	11.7	2.6
09/16/2020 19:00	14.1	3.5	2.0	11.1	2.4
09/16/2020 20:00	14.2	3.5	2.0	11.1	2.4
09/16/2020 21:00	14.1	3.5	2.0	11.1	2.4
09/16/2020 22:00	14.0	3.5	2.0	11.0	2.4
09/16/2020 23:00	13.5	3.5	2.0	10.7	2.4
Average/Sum#:	305.4 #	131.8 #	28.4 #	146.1 #	32.3 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	54.4	42.2	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/17/2020 00:00	5.6	0.3	1.4	7.7	1.6
09/17/2020 01:00	5.2	0.2	1.3	7.2	1.6
09/17/2020 02:00	5.2	0.2	1.3	7.1	1.6
09/17/2020 03:00	5.2	0.5	1.3	7.1	1.6
09/17/2020 04:00	5.8	0.6	1.4	8.1	1.8
09/17/2020 05:00	7.8	0.6	1.6	8.6	1.8
09/17/2020 06:00	7.7	0.6	1.6	8.5	1.8
09/17/2020 07:00	8.1	1.2	1.6	8.8	2.0
09/17/2020 08:00	8.0	0.9	1.6	8.8	2.0
09/17/2020 09:00	8.0	0.6	1.6	8.8	2.0
09/17/2020 10:00	7.1	0.5	1.4	7.8	1.7
09/17/2020 11:00	7.1	0.5	1.4	7.9	1.8
09/17/2020 12:00	9.7	0.9	1.6	8.9	2.0
09/17/2020 13:00	14.6	3.8	2.1	11.4	2.5
09/17/2020 14:00	14.9	2.4	2.1	11.8	2.6
09/17/2020 15:00	15.0	1.8	2.1	11.7	2.6
09/17/2020 16:00	14.9	1.5	2.1	11.7	2.6
09/17/2020 17:00	14.7	2.1	2.1	11.5	2.5
09/17/2020 18:00	14.3	2.4	2.0	11.2	2.4
09/17/2020 19:00	14.7	2.1	2.1	11.5	2.5
09/17/2020 20:00	14.3	2.9	2.0	11.2	2.4
09/17/2020 21:00	14.3	2.9	2.0	11.3	2.4
09/17/2020 22:00	14.6	2.5	2.1	11.5	2.5
09/17/2020 23:00	23.2	14.8	1.8	9.8	2.2
Average/Sum#:	260.0 #	46.8 #	41.6 #	229.9 #	50.5 #
Minimum:	5.2	0.2	1.3	7.1	1.6
Maximum:	23.2	14.8	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/18/2020 00:00	0.0	0.0	0.0	0.0	0.0
09/18/2020 01:00	0.0	0.0	0.0	0.0	0.0
09/18/2020 02:00	0.0	0.0	0.0	0.0	0.0
09/18/2020 03:00	0.0	0.0	0.0	0.0	0.0
09/18/2020 04:00	0.0	0.0	0.0	0.0	0.0
09/18/2020 05:00	0.0	0.0	0.0	0.0	0.0
09/18/2020 06:00	3.9	13.4	0.1	0.5	0.1
09/18/2020 07:00	20.1	49.2	0.7	2.4	0.6
09/18/2020 08:00	2.8	0.0	1.0	3.5	0.8
09/18/2020 09:00	4.2	0.0	1.0	3.5	0.8
09/18/2020 10:00	11.9	5.9	1.2	4.4	1.0
09/18/2020 11:00	78.8	35.9	1.3	6.2	1.4
09/18/2020 12:00	8.0	0.6	1.6	8.8	2.0
09/18/2020 13:00	9.2	0.6	1.6	8.5	1.8
09/18/2020 14:00	14.1	4.4	2.0	11.1	2.4
09/18/2020 15:00	14.4	3.8	2.0	11.3	2.4
09/18/2020 16:00	14.3	3.4	2.0	11.2	2.4
09/18/2020 17:00	14.2	3.5	2.0	11.1	2.4
09/18/2020 18:00	14.1	3.8	2.0	11.1	2.4
09/18/2020 19:00	14.1	3.8	2.0	11.0	2.4
09/18/2020 20:00	14.0	3.5	2.0	11.0	2.4
09/18/2020 21:00	14.0	3.5	2.0	11.0	2.4
09/18/2020 22:00	14.6	19.1	1.1	6.2	1.4
09/18/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	266.7 #	154.4 #	25.6 #	132.8 #	29.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	78.8	49.2	2.0	11.3	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/19/2020 00:00	0.0	0.0	0.0	0.0	0.0
09/19/2020 01:00	0.0	0.0	0.0	0.0	0.0
09/19/2020 02:00	0.0	0.0	0.0	0.0	0.0
09/19/2020 03:00	0.0	0.0	0.0	0.0	0.0
09/19/2020 04:00	1.2	6.8	0.1	0.2	0.1
09/19/2020 05:00	22.9	61.2	0.7	2.4	0.6
09/19/2020 06:00	2.8	0.0	1.0	3.5	0.8
09/19/2020 07:00	4.2	0.0	1.0	3.5	0.8
09/19/2020 08:00	4.2	0.0	1.0	3.5	0.8
09/19/2020 09:00	4.2	0.0	1.0	3.5	0.8
09/19/2020 10:00	4.2	0.0	1.0	3.5	0.8
09/19/2020 11:00	4.2	0.0	1.0	3.5	0.8
09/19/2020 12:00	4.5	0.0	1.0	3.7	0.9
09/19/2020 13:00	34.8	14.2	1.1	4.5	1.1
09/19/2020 14:00	74.7	28.5	1.3	6.3	1.4
09/19/2020 15:00	7.7	0.3	1.6	8.4	1.8
09/19/2020 16:00	14.2	4.1	2.0	11.1	2.4
09/19/2020 17:00	15.1	2.8	2.1	11.9	2.6
09/19/2020 18:00	15.0	3.2	2.1	11.7	2.6
09/19/2020 19:00	14.9	3.1	2.1	11.7	2.6
09/19/2020 20:00	14.8	3.1	2.1	11.7	2.6
09/19/2020 21:00	14.6	3.5	2.1	11.5	2.5
09/19/2020 22:00	14.6	3.8	2.1	11.5	2.5
09/19/2020 23:00	13.7	4.1	2.0	10.8	2.4
Average/Sum#:	286.5 #	138.7 #	28.4 #	138.4 #	30.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	74.7	61.2	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/20/2020 00:00	13.7	4.5	2.0	10.7	2.4
09/20/2020 01:00	13.7	4.5	2.0	10.7	2.4
09/20/2020 02:00	13.7	4.5	2.0	10.7	2.4
09/20/2020 03:00	13.7	4.5	2.0	10.7	2.4
09/20/2020 04:00	13.5	4.5	2.0	10.7	2.4
09/20/2020 05:00	15.3	3.2	1.9	10.5	2.2
09/20/2020 06:00	1.8	5.3	0.2	0.9	0.2
09/20/2020 07:00	0.0	0.0	0.0	0.0	0.0
09/20/2020 08:00	0.0	0.0	0.0	0.0	0.0
09/20/2020 09:00	0.0	0.0	0.0	0.0	0.0
09/20/2020 10:00	1.6	10.4	0.1	0.5	0.1
09/20/2020 11:00	23.8	31.2	0.7	2.4	0.6
09/20/2020 12:00	4.5	0.0	1.0	3.7	0.9
09/20/2020 13:00	4.6	0.0	1.1	3.9	0.9
09/20/2020 14:00	40.8	11.3	1.2	4.8	1.2
09/20/2020 15:00	30.7	27.5	1.3	6.5	1.5
09/20/2020 16:00	9.5	0.9	1.6	8.7	1.9
09/20/2020 17:00	14.3	4.7	2.1	11.3	2.4
09/20/2020 18:00	15.2	3.3	2.1	11.9	2.6
09/20/2020 19:00	15.1	3.0	2.1	11.9	2.6
09/20/2020 20:00	14.9	3.1	2.1	11.7	2.6
09/20/2020 21:00	13.9	3.6	2.0	10.9	2.4
09/20/2020 22:00	4.2	9.5	0.1	0.8	0.2
09/20/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	276.7 #	134.2 #	29.6 #	153.9 #	34.3 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	40.8	31.2	2.1	11.9	2.6
%SI	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/21/2020 00:00	0.0	0.0	0.0	0.0	0.0
09/21/2020 01:00	0.0	0.0	0.0	0.0	0.0
09/21/2020 02:00	0.0	0.0	0.0	0.0	0.0
09/21/2020 03:00	0.0	0.0	0.0	0.0	0.0
09/21/2020 04:00	0.0	0.0	0.0	0.0	0.0
09/21/2020 05:00	0.0	0.0	0.0	0.0	0.0
09/21/2020 06:00	0.0	0.0	0.0	0.0	0.0
09/21/2020 07:00	0.0	0.0	0.0	0.0	0.0
09/21/2020 08:00	25.0	10.3	0.0	0.5	0.1
09/21/2020 09:00	36.7	21.4	0.2	1.6	0.3
09/21/2020 10:00	38.3	29.6	0.3	2.6	0.5
09/21/2020 11:00	3.0	0.3	0.4	4.5	0.9
09/21/2020 12:00	5.0	0.6	0.5	5.0	1.0
09/21/2020 13:00	47.5	50.4	0.7	5.3	1.0
09/21/2020 14:00	51.5	48.3	1.0	6.4	1.4
09/21/2020 15:00	6.0	0.6	1.6	8.3	1.8
09/21/2020 16:00	13.8	4.1	2.0	10.9	2.4
09/21/2020 17:00	13.9	3.7	2.0	11.0	2.4
09/21/2020 18:00	15.9	4.1	2.0	10.9	2.4
09/21/2020 19:00	14.3	3.5	2.0	11.2	2.4
09/21/2020 20:00	14.5	3.5	2.1	11.5	2.5
09/21/2020 21:00	14.1	3.0	2.0	11.1	2.4
09/21/2020 22:00	4.0	8.4	0.1	0.8	0.2
09/21/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	303.5 #	191.8 #	16.9 #	101.6 #	21.7 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	51.5	50.4	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/22/2020 00:00	0.0	0.0	0.0	0.0	0.0
09/22/2020 01:00	0.0	0.0	0.0	0.0	0.0
09/22/2020 02:00	0.0	0.0	0.0	0.0	0.0
09/22/2020 03:00	0.0	0.0	0.0	0.0	0.0
09/22/2020 04:00	0.0	0.0	0.0	0.0	0.0
09/22/2020 05:00	0.0	0.0	0.0	0.0	0.0
09/22/2020 06:00	0.0	0.0	0.0	0.0	0.0
09/22/2020 07:00	0.0	0.0	0.0	0.0	0.0
09/22/2020 08:00	23.2	10.1	0.0	0.4	0.1
09/22/2020 09:00	40.2	24.7	0.2	1.6	0.3
09/22/2020 10:00	39.3	36.8	0.3	2.6	0.5
09/22/2020 11:00	3.0	0.3	0.5	4.5	0.9
09/22/2020 12:00	7.3	1.6	0.5	5.5	1.1
09/22/2020 13:00	7.8	1.9	0.6	5.8	1.2
09/22/2020 14:00	37.3	54.7	0.6	5.1	1.0
09/22/2020 15:00	71.4	50.0	1.0	6.4	1.4
09/22/2020 16:00	7.5	0.6	1.6	8.3	1.8
09/22/2020 17:00	13.1	3.3	1.8	10.2	2.3
09/22/2020 18:00	13.0	3.0	1.8	10.2	2.3
09/22/2020 19:00	13.0	3.0	1.8	10.2	2.3
09/22/2020 20:00	13.0	3.0	1.8	10.2	2.3
09/22/2020 21:00	9.6	15.4	0.6	3.1	0.6
09/22/2020 22:00	0.0	0.0	0.0	0.0	0.0
09/22/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	298.7 #	208.4 #	13.1 #	84.1 #	18.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	71.4	54.7	1.8	10.2	2.3
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/23/2020 00:00	0.0	0.0	0.0	0.0	0.0
09/23/2020 01:00	0.0	0.0	0.0	0.0	0.0
09/23/2020 02:00	0.0	0.0	0.0	0.0	0.0
09/23/2020 03:00	0.0	0.0	0.0	0.0	0.0
09/23/2020 04:00	0.0	0.0	0.0	0.0	0.0
09/23/2020 05:00	0.0	0.0	0.0	0.0	0.0
09/23/2020 06:00	0.0	0.0	0.0	0.0	0.0
09/23/2020 07:00	0.0	0.0	0.0	0.0	0.0
09/23/2020 08:00	42.1	15.9	0.1	0.7	0.1
09/23/2020 09:00	29.1	21.7	0.2	1.6	0.3
09/23/2020 10:00	44.6	31.5	0.3	2.7	0.5
09/23/2020 11:00	2.8	0.3	0.4	4.1	0.8
09/23/2020 12:00	4.4	0.6	0.4	4.4	0.9
09/23/2020 13:00	37.5	50.5	0.6	5.1	1.0
09/23/2020 14:00	76.0	49.9	1.0	6.4	1.4
09/23/2020 15:00	7.7	0.6	1.6	8.5	1.8
09/23/2020 16:00	14.1	3.8	2.0	11.1	2.4
09/23/2020 17:00	14.1	3.8	2.0	11.0	2.4
09/23/2020 18:00	13.8	4.1	2.0	10.9	2.4
09/23/2020 19:00	16.3	4.1	2.0	11.3	2.4
09/23/2020 20:00	13.5	4.1	2.0	10.6	2.3
09/23/2020 21:00	5.3	8.8	0.1	0.7	0.2
09/23/2020 22:00	0.0	0.0	0.0	0.0	0.0
09/23/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	321.3 #	199.7 #	14.7 #	89.1 #	18.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	76.0	50.5	2.0	11.3	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/24/2020 00:00	0.0	0.0	0.0	0.0	0.0
09/24/2020 01:00	0.0	0.0	0.0	0.0	0.0
09/24/2020 02:00	0.0	0.0	0.0	0.0	0.0
09/24/2020 03:00	0.0	0.0	0.0	0.0	0.0
09/24/2020 04:00	0.0	0.0	0.0	0.0	0.0
09/24/2020 05:00	0.0	0.0	0.0	0.0	0.0
09/24/2020 06:00	0.0	0.0	0.0	0.0	0.0
09/24/2020 07:00	0.0	0.0	0.0	0.0	0.0
09/24/2020 08:00	24.2	29.3	0.1	0.4	0.1
09/24/2020 09:00	37.6	34.0	0.4	1.3	0.3
09/24/2020 10:00	20.9	45.7	0.6	2.2	0.5
09/24/2020 11:00	2.8	0.0	1.0	3.5	0.8
09/24/2020 12:00	4.1	0.0	1.0	3.4	0.8
09/24/2020 13:00	61.7	34.9	1.2	4.8	1.1
09/24/2020 14:00	59.6	30.1	1.3	6.6	1.4
09/24/2020 15:00	10.0	0.6	1.7	9.1	2.0
09/24/2020 16:00	10.8	2.4	1.8	9.9	2.2
09/24/2020 17:00	14.6	3.7	2.1	11.5	2.5
09/24/2020 18:00	14.6	3.8	2.1	11.4	2.5
09/24/2020 19:00	14.5	3.8	2.1	11.4	2.5
09/24/2020 20:00	10.4	14.9	0.6	3.1	0.6
09/24/2020 21:00	0.0	0.0	0.0	0.0	0.0
09/24/2020 22:00	0.0	0.0	0.0	0.0	0.0
09/24/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	285.8 #	203.2 #	16.0 #	78.6 #	17.3 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	61.7	45.7	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/25/2020 00:00	0.0	0.0	0.0	0.0	0.0
09/25/2020 01:00	0.0	0.0	0.0	0.0	0.0
09/25/2020 02:00	0.0	0.0	0.0	0.0	0.0
09/25/2020 03:00	0.0	0.0	0.0	0.0	0.0
09/25/2020 04:00	0.0	0.0	0.0	0.0	0.0
09/25/2020 05:00	0.0	0.0	0.0	0.0	0.0
09/25/2020 06:00	0.0	0.0	0.0	0.0	0.0
09/25/2020 07:00	0.0	0.0	0.0	0.0	0.0
09/25/2020 08:00	0.0	0.0	0.0	0.0	0.0
09/25/2020 09:00	0.0	0.0	0.0	0.0	0.0
09/25/2020 10:00	0.0	0.0	0.0	0.0	0.0
09/25/2020 11:00	0.0	0.0	0.0	0.0	0.0
09/25/2020 12:00	0.0	0.0	0.0	0.0	0.0
09/25/2020 13:00	0.0	0.0	0.0	0.0	0.0
09/25/2020 14:00	0.0	0.0	0.0	0.0	0.0
09/25/2020 15:00	0.0	0.0	0.0	0.0	0.0
09/25/2020 16:00	0.0	0.0	0.0	0.0	0.0
09/25/2020 17:00	0.0	0.0	0.0	0.0	0.0
09/25/2020 18:00	0.0	0.0	0.0	0.0	0.0
09/25/2020 19:00	0.0	0.0	0.0	0.0	0.0
09/25/2020 20:00	0.0	0.0	0.0	0.0	0.0
09/25/2020 21:00	0.0	0.0	0.0	0.0	0.0
09/25/2020 22:00	0.0	0.0	0.0	0.0	0.0
09/25/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/26/2020 00:00	0.0	0.0	0.0	0.0	0.0
09/26/2020 01:00	0.0	0.0	0.0	0.0	0.0
09/26/2020 02:00	0.0	0.0	0.0	0.0	0.0
09/26/2020 03:00	0.0	0.0	0.0	0.0	0.0
09/26/2020 04:00	0.0	0.0	0.0	0.0	0.0
09/26/2020 05:00	0.0	0.0	0.0	0.0	0.0
09/26/2020 06:00	0.0	0.0	0.0	0.0	0.0
09/26/2020 07:00	0.0	0.0	0.0	0.0	0.0
09/26/2020 08:00	0.0	0.0	0.0	0.0	0.0
09/26/2020 09:00	0.0	0.0	0.0	0.0	0.0
09/26/2020 10:00	0.0	0.0	0.0	0.0	0.0
09/26/2020 11:00	0.0	0.0	0.0	0.0	0.0
09/26/2020 12:00	0.0	0.0	0.0	0.0	0.0
09/26/2020 13:00	0.0	0.0	0.0	0.0	0.0
09/26/2020 14:00	0.0	0.0	0.0	0.0	0.0
09/26/2020 15:00	0.0	0.0	0.0	0.0	0.0
09/26/2020 16:00	0.0	0.0	0.0	0.0	0.0
09/26/2020 17:00	0.0	0.0	0.0	0.0	0.0
09/26/2020 18:00	0.0	0.0	0.0	0.0	0.0
09/26/2020 19:00	0.0	0.0	0.0	0.0	0.0
09/26/2020 20:00	0.0	0.0	0.0	0.0	0.0
09/26/2020 21:00	0.0	0.0	0.0	0.0	0.0
09/26/2020 22:00	0.0	0.0	0.0	0.0	0.0
09/26/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/27/2020 00:00	0.0	0.0	0.0	0.0	0.0
09/27/2020 01:00	0.0	0.0	0.0	0.0	0.0
09/27/2020 02:00	0.0	0.0	0.0	0.0	0.0
09/27/2020 03:00	0.0	0.0	0.0	0.0	0.0
09/27/2020 04:00	0.0	0.0	0.0	0.0	0.0
09/27/2020 05:00	0.0	0.0	0.0	0.0	0.0
09/27/2020 06:00	0.0	0.0	0.0	0.0	0.0
09/27/2020 07:00	0.0	0.0	0.0	0.0	0.0
09/27/2020 08:00	0.8	22.1	0.0	0.0	0.0
09/27/2020 09:00	102.4	70.4	0.2	1.5	0.3
09/27/2020 10:00	44.5	20.9	0.2	2.1	0.4
09/27/2020 11:00	2.8	0.3	0.4	4.2	0.8
09/27/2020 12:00	2.7	0.3	0.4	4.1	0.8
09/27/2020 13:00	9.4	24.0	0.5	4.9	1.0
09/27/2020 14:00	123.1	51.7	0.9	6.3	1.4
09/27/2020 15:00	22.6	3.1	1.6	8.9	2.0
09/27/2020 16:00	4.8	1.1	1.6	8.8	2.0
09/27/2020 17:00	14.6	4.3	2.1	11.4	2.5
09/27/2020 18:00	14.9	3.8	2.1	11.6	2.6
09/27/2020 19:00	14.9	3.8	2.1	11.8	2.6
09/27/2020 20:00	14.9	3.8	2.1	11.8	2.6
09/27/2020 21:00	14.9	3.8	2.1	11.8	2.6
09/27/2020 22:00	10.4	14.4	0.6	3.3	0.8
09/27/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	392.9 #	226.7 #	16.9 #	102.5 #	22.4 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	123.1	70.4	2.1	11.8	2.6
%SI	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/28/2020 00:00	0.0	0.0	0.0	0.0	0.0
09/28/2020 01:00	0.0	0.0	0.0	0.0	0.0
09/28/2020 02:00	0.0	0.0	0.0	0.0	0.0
09/28/2020 03:00	0.0	0.0	0.0	0.0	0.0
09/28/2020 04:00	0.0	0.0	0.0	0.0	0.0
09/28/2020 05:00	0.0	0.0	0.0	0.0	0.0
09/28/2020 06:00	28.3	9.4	0.1	0.4	0.1
09/28/2020 07:00	63.7	33.6	0.6	2.2	0.5
09/28/2020 08:00	2.8	0.0	1.0	3.5	0.8
09/28/2020 09:00	4.1	0.0	1.0	3.4	0.8
09/28/2020 10:00	65.6	11.8	1.2	5.1	1.2
09/28/2020 11:00	50.4	23.4	1.3	6.6	1.5
09/28/2020 12:00	10.3	1.0	1.7	9.4	2.0
09/28/2020 13:00	10.1	2.1	1.7	9.2	2.0
09/28/2020 14:00	14.8	4.1	2.1	11.6	2.6
09/28/2020 15:00	15.3	2.5	2.2	12.0	2.6
09/28/2020 16:00	15.3	2.5	2.2	12.0	2.6
09/28/2020 17:00	15.2	2.8	2.1	12.0	2.6
09/28/2020 18:00	15.2	2.8	2.1	11.9	2.6
09/28/2020 19:00	14.8	3.5	2.1	11.6	2.6
09/28/2020 20:00	14.8	3.5	2.1	11.7	2.6
09/28/2020 21:00	14.6	3.8	2.1	11.5	2.5
09/28/2020 22:00	10.7	15.3	0.7	3.5	0.8
09/28/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	366.0 #	122.1 #	26.3 #	137.6 #	30.4 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	65.6	33.6	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/29/2020 00:00	0.0	0.0	0.0	0.0	0.0
09/29/2020 01:00	0.0	0.0	0.0	0.0	0.0
09/29/2020 02:00	0.0	0.0	0.0	0.0	0.0
09/29/2020 03:00	0.0	0.0	0.0	0.0	0.0
09/29/2020 04:00	0.0	0.0	0.0	0.0	0.0
09/29/2020 05:00	0.0	0.0	0.0	0.0	0.0
09/29/2020 06:00	26.4	11.1	0.1	0.4	0.1
09/29/2020 07:00	58.5	43.3	0.6	2.2	0.5
09/29/2020 08:00	2.7	0.0	1.0	3.4	0.8
09/29/2020 09:00	4.1	0.0	1.0	3.4	0.8
09/29/2020 10:00	61.4	13.8	1.2	5.1	1.2
09/29/2020 11:00	45.8	26.1	1.3	6.7	1.5
09/29/2020 12:00	10.3	1.0	1.7	9.4	2.0
09/29/2020 13:00	10.7	3.1	1.8	9.8	2.2
09/29/2020 14:00	14.8	4.4	2.1	11.7	2.6
09/29/2020 15:00	14.9	3.8	2.1	11.7	2.6
09/29/2020 16:00	15.1	3.5	2.1	11.9	2.6
09/29/2020 17:00	15.1	2.9	2.1	11.9	2.6
09/29/2020 18:00	14.9	3.5	2.1	11.7	2.6
09/29/2020 19:00	15.1	3.5	2.1	11.9	2.6
09/29/2020 20:00	14.9	3.5	2.1	11.7	2.6
09/29/2020 21:00	14.8	3.8	2.1	11.7	2.6
09/29/2020 22:00	14.6	3.8	2.1	11.5	2.5
09/29/2020 23:00	14.5	3.9	2.1	11.5	2.5
Average/Sum#:	368.6 #	135.0 #	29.7 #	157.6 #	34.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	61.4	43.3	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
09/30/2020 00:00	14.0	3.9	2.0	11.0	2.4
09/30/2020 01:00	9.9	0.9	1.7	9.0	2.0
09/30/2020 02:00	10.1	0.9	1.7	9.2	2.0
09/30/2020 03:00	10.0	0.9	1.7	9.2	2.0
09/30/2020 04:00	10.3	2.1	1.7	9.4	2.0
09/30/2020 05:00	16.3	4.8	2.0	11.2	2.4
09/30/2020 06:00	12.1	4.4	2.0	11.1	2.4
09/30/2020 07:00	9.9	0.9	1.7	9.1	2.0
09/30/2020 08:00	10.1	1.2	1.7	9.2	2.0
09/30/2020 09:00	10.1	1.0	1.7	9.2	2.0
09/30/2020 10:00	10.1	2.1	1.7	9.2	2.0
09/30/2020 11:00	14.6	4.5	2.1	11.5	2.5
09/30/2020 12:00	14.9	3.8	2.1	11.8	2.6
09/30/2020 13:00	15.2	2.8	2.2	11.9	2.6
09/30/2020 14:00	14.8	2.7	2.1	11.7	2.6
09/30/2020 15:00	15.0	3.1	2.1	11.8	2.6
09/30/2020 16:00	14.9	2.7	2.1	11.8	2.6
09/30/2020 17:00	14.8	3.5	2.1	11.6	2.6
09/30/2020 18:00	14.9	3.5	2.1	11.7	2.6
09/30/2020 19:00	15.1	3.1	2.1	11.8	2.6
09/30/2020 20:00	14.9	3.1	2.1	11.8	2.6
09/30/2020 21:00	14.8	3.5	2.1	11.6	2.6
09/30/2020 22:00	14.7	3.5	2.1	11.6	2.6
09/30/2020 23:00	13.7	4.1	2.0	10.9	2.4
Average/Sum#:	315.2 #	67.0 #	46.9 #	258.3 #	56.7 #
Minimum:	9.9	0.9	1.7	9.0	2.0
Maximum:	16.3	4.8	2.2	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Excess Emission Report

CT1 and CT2 CO Lb/Day



From: 07/01/2020 00:00 To: 09/30/2020 23:59
Generated: 10/06/2020 09:12

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA

Tag Name: ALL_CO_Lb_1D

Total Operating Time: 87.00 Day(s)

No Exclusions Allowed

Non-Operating Time: 5.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	87.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT1 and CT2 CO Lb/Hr



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 10/06/2020 09:12 Location: Maxwell, CA

Tag Name: ALL_CO_Lb_1H

Total Operating Time: 1,948.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 260.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,948.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 and CT2 NOx Lb/Day

From: 07/01/2020 00:00 To: 09/30/2020 23:59
Generated: 10/06/2020 09:13

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA

Tag Name: ALL_NOx_Lb_1D

Total Operating Time: 87.00 Day(s)

No Exclusions Allowed

Non-Operating Time: 5.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	87.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT1 and CT2 NOx Lb/Hr



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 10/06/2020 09:13 Location: Maxwell, CA

Tag Name: ALL_NOx_Lb_1H

Total Operating Time: 1,948.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 260.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,948.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 and CT2 PM10 Lb/Day

From: 07/01/2020 00:00 To: 09/30/2020 23:59
Generated: 10/06/2020 09:15

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA

Tag Name: ALL_PM10_Lb_1D

Total Operating Time: 87.00 Day(s)

No Exclusions Allowed

Non-Operating Time: 5.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	87.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT1 and CT2 PM10 Lb/Hr



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 10/06/2020 09:18 Location: Maxwell, CA

Tag Name: ALL_PM10_Lb_1H
Total Operating Time: 1,948.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 260.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,948.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 and CT2 SO2 Lb/Day

From: 07/01/2020 00:00 To: 09/30/2020 23:59
Generated: 10/06/2020 09:28

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA

Tag Name: ALL_SO2_Lb_1D

Total Operating Time: 87.00 Day(s)

No Exclusions Allowed

Non-Operating Time: 5.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	87.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT1 and CT2 SO2 Lb/Hr



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 10/06/2020 09:29 Location: Maxwell, CA

Tag Name: ALL_SO2_Lb_1H

Total Operating Time: 1,948.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 260.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,948.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT1 and CT2 VOC Lb/Day



From: 07/01/2020 00:00 To: 09/30/2020 23:59
Generated: 10/06/2020 09:29

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA

Tag Name: ALL_VOC_Lb_1D

Total Operating Time: 87.00 Day(s)

No Exclusions Allowed

Non-Operating Time: 5.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	87.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT1 and CT2 VOC Lb/Hr



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 10/06/2020 09:29 Location: Maxwell, CA

Tag Name: ALL_VOC_Lb_1H

Total Operating Time: 1,948.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 260.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,948.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

ATTACHMENT 11
CGA/Linearity

FCD: AQ-19
Title V: #13

Linearity Report

07/08/2020

Page 1

ORIS Code: 56298 Facility Name: COLUSA GENERATION ReasonForTest: QA
 EDR Site ID: CT1 Component ID: All Grace Period: 0
 Component Type: NOXA
 Instrument Name: CT1_NOXDualRg_P_Instrume Test End Date/Time: 07/07/2020 Scale: High
 Performance Spec: 5 % Test No.: 97 Highest Error: 1.6
 Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/07/2020	1225	L	200.0	50.7	49.6		25.4 %
07/07/2020	1231	M	200.0	110.9	111.7		55.5 %
07/07/2020	1237	H	200.0	179.1	180.9		89.6 %
07/07/2020	1246	L	200.0	50.7	50.0		25.4 %
07/07/2020	1252	M	200.0	110.9	111.5		55.5 %
07/07/2020	1258	H	200.0	179.1	180.9		89.6 %
07/07/2020	1306	L	200.0	50.7	50.1		25.4 %
07/07/2020	1312	M	200.0	110.9	111.9		55.5 %
07/07/2020	1318	H	200.0	179.1	180.9		89.6 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	50.700	49.900	No	1.6
M	110.900	111.700	No	0.7
H	179.100	180.900	No	1.0

Cylinder Gas Audit

07/08/2020

Page 1

Facility: COLUSA GENERATION **Instrument Name:** CT1_CODualRg_P_Instrum
Unit/Stack: CT1 **Test Date:** 07/08/2020 **Performance Spec:** 15 Pct
Parameter/Scale: CO / High **Test Result:** Pass **Alternate Spec:** 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/08/2020	08:36	L	2000	505.500	469.400	25.3 %
07/08/2020	08:42	M	2000	1156.000	1166.400	57.8 %
07/08/2020	08:51	L	2000	505.500	468.600	25.3 %
07/08/2020	08:57	M	2000	1156.000	1166.900	57.8 %
07/08/2020	09:05	L	2000	505.500	469.400	25.3 %
07/08/2020	09:11	M	2000	1156.000	1165.000	57.8 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	505.500	469.133	Std	7.2
M	1156.000	1166.100	Std	0.9

Cylinder Gas Audit

07/08/2020

Page 1

Facility: COLUSA GENERATION
 Unit/Stack: CT1
 Parameter/Scale: NOX / Low
 Instrument Name: CT1_NOXDualRg_P_Instru
 Test Date: 07/08/2020
 Performance Spec: 15 Pct
 Test Result: **Pass**
 Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct	Span
07/08/2020	06:30	L	10	2.400	1.800	24.0 %	24.0 %
07/08/2020	06:36	M	10	5.500	5.100	55.0 %	55.0 %
07/08/2020	06:45	L	10	2.400	1.800	24.0 %	24.0 %
07/08/2020	06:51	M	10	5.500	5.200	55.0 %	55.0 %
07/08/2020	06:59	L	10	2.400	1.800	24.0 %	24.0 %
07/08/2020	07:05	M	10	5.500	5.100	55.0 %	55.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.400	1.800	Alt	0.6
M	5.500	5.133	Std	6.7

Cylinder Gas Audit

07/08/2020

Page 1

Facility: COLUSA GENERATION Instrument Name: CT1_CODualRg_P_Instrum
 Unit/Stack: CT1 Test Date: 07/07/2020 Performance Spec: 15 Pct
 Parameter/Scale: CO / Low Test Result: **Pass** Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/07/2020	15:06	L	20	4.700	4.700	23.5 %
07/07/2020	15:12	M	20	10.900	10.800	54.5 %
07/07/2020	15:21	L	20	4.700	4.700	23.5 %
07/07/2020	15:27	M	20	10.900	10.700	54.5 %
07/07/2020	15:35	L	20	4.700	4.700	23.5 %
07/07/2020	15:41	M	20	10.900	10.700	54.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	4.700	4.700	Std	0.0
M	10.900	10.733	Std	1.5

Cylinder Gas Audit

07/08/2020

Page 1

Facility: COLUSA GENERATION **Instrument Name:** CT1_NOXInlet_P_Instrum
Unit/Stack: CT1 **Test Date:** 07/07/2020 **Performance Spec:** 15 Pct
Parameter/Scale: NOX / High **Test Result:** Pass **Alternate Spec:** 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/07/2020	13:41	L	200	50.700	50.400	25.4 %
07/07/2020	13:47	M	200	110.900	111.800	55.5 %
07/07/2020	13:56	L	200	50.700	50.600	25.4 %
07/07/2020	14:02	M	200	110.900	111.800	55.5 %
07/07/2020	14:10	L	200	50.700	50.800	25.4 %
07/07/2020	14:16	M	200	110.900	112.100	55.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.700	50.600	Std	0.2
M	110.900	111.900	Std	0.9

Cylinder Gas Audit

07/08/2020

Page 1

Facility: COLUSA GENERATION
 Unit/Stack: CT1
 Parameter/Scale: O2D / High
 Instrument Name: CT1_O2DInlet_P_Instrum
 Performance Spec: 15 Pct
 Alternate Spec: 0 Pct
 Test Date: 07/07/2020
 Test Result: **Pass**

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/07/2020	06:55	L	25	5.600	5.600	22.4 %
07/07/2020	07:01	M	25	13.100	13.000	52.4 %
07/07/2020	07:10	L	25	5.600	5.600	22.4 %
07/07/2020	07:16	M	25	13.100	13.000	52.4 %
07/07/2020	07:24	L	25	5.600	5.600	22.4 %
07/07/2020	07:30	M	25	13.100	13.000	52.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	5.600	5.600	Std	0.0
M	13.100	13.000	Std	0.8

Linearity Report

07/08/2020

Page 1

ORIS Code: 56298 Facility Name: COLUSA GENERATION ReasonForTest: QA
 EDR Site ID: CT1 Component ID: A12 Grace Period: 0
 Component Type: O2D
 Instrument Name: CT1_O2D_P_Instrument Test End Date/Time: 07/07/2020 Scale: High
 Performance Spec: 5 % Test No.: 96 Highest Error: 1.8
 Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/07/2020	1027	L	25.0	5.6	5.5		22.4 %
07/07/2020	1033	M	25.0	13.1	13.0		52.4 %
07/07/2020	1039	H	25.0	21.1	21.1		84.4 %
07/07/2020	1048	L	25.0	5.6	5.5		22.4 %
07/07/2020	1054	M	25.0	13.1	13.0		52.4 %
07/07/2020	1100	H	25.0	21.1	21.1		84.4 %
07/07/2020	1108	L	25.0	5.6	5.5		22.4 %
07/07/2020	1114	M	25.0	13.1	13.0		52.4 %
07/07/2020	1120	H	25.0	21.1	21.1		84.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.600	5.500	No	1.8
M	13.100	13.000	No	0.8
H	21.100	21.100	No	0.0

*CT1
CV1*

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A42D0	Reference Number:	153-401669884-1
Cylinder Number:	CC210951	Cylinder Volume:	144.4 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72019	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Dec 18, 2019

Expiration Date: Dec 18, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	180.0 PPM	179.1 PPM	G1	+/- 0.6% NIST Traceable	12/10/2019, 12/18/2019
NITRIC OXIDE	180.0 PPM	179.1 PPM	G1	+/- 0.6% NIST Traceable	12/10/2019, 12/18/2019
CARBON MONOXIDE	1150 PPM	1156 PPM	G1	+/- 1.0% NIST Traceable	12/10/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	18060132	KAL004328	249.9 PPM NITRIC OXIDE/NITROGEN	0.4%	Nov 08, 2023
PRM	12376	D562879	10.01 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Aug 17, 2018
GMIS	7301017103	CC506597	4.451 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Dec 18, 2020
NTRM	09010357	KAL004691	970.0 PPM CARBON MONOXIDE/NITROGEN	0.4%	May 14, 2021

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AMP0900119 CO HCO	FTIR	Dec 04, 2019
Nicolet 6700 AMP0900119 NO MNO	FTIR	Nov 26, 2019
Nicolet 6700 AMP0900119 NO2 impurity	FTIR NO2 impurity	Nov 27, 2019

Triad Data Available Upon Request



[Handwritten Signature]

Approved for Release

*CV3
CT1*

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A7635	Reference Number:	153-401557389-1
Cylinder Number:	CC505749	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72019	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Aug 05, 2019

Expiration Date: Aug 05, 2022

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	8.940 PPM	G1	+/- 1.1% NIST Traceable	07/29/2019, 08/05/2019
NITRIC OXIDE	9.000 PPM	8.906 PPM	G1	+/- 1.1% NIST Traceable	07/29/2019, 08/05/2019
CARBON MONOXIDE	11.00 PPM	10.89 PPM	G1	+/- 0.5% NIST Traceable	07/29/2019
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060719	CC437477	10.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Oct 16, 2022
PRM	12376	D562879	10.01 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Aug 17, 2018
GMIS	7302017111	CC511391	4.634 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Aug 15, 2021
NTRM	15010203	KAL003073	24.35 PPM CARBON MONOXIDE/NITROGEN	0.3%	Sep 04, 2021

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 CO LCO	FTIR	Jul 10, 2019
Nicolet 6700 AHR0801550 NO LNO	FTIR	Jul 24, 2019
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Jul 25, 2019

Triad Data Available Upon Request



[Signature]

Approved for Release

UNIT #1
CV4

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0093	Reference Number:	153-401144291-1
Cylinder Number:	CC268605	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72018	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Mar 12, 2018

Expiration Date: Mar 12, 2026

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	110.0 PPM	110.9 PPM	G1	+/- 1.0% NIST Traceable	03/05/2018, 03/12/2018
NITRIC OXIDE	110.0 PPM	110.7 PPM	G1	+/- 1.0% NIST Traceable	03/05/2018, 03/12/2018
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	13010413	KAL004013	97.6 PPM NITRIC OXIDE/NITROGEN	0.8%	May 09, 2019
PRM	12367	APEX1099237	9.82 PPM NITROGEN DIOXIDE/NITROGEN	1.6%	May 29, 2016
GMIS	1114201604	CC507567	4.955 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Nov 14, 2019

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 NO LNO	FTIR	Mar 07, 2018
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Mar 07, 2018

Triad Data Available Upon Request



Caryl Doyle

Approved for Release

Airgas Specialty Gases
 11711 South Alameda Street
 Los Angeles, CA 90059
 (323) 568-2203 Fax: (323) 567-3686
 www.airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: E02NI99E15A0147	Reference Number: 48-124363135-1
Cylinder Number: CC276685	Cylinder Volume: 144.3 CF
Laboratory: ASG - Los Angeles - CA	Cylinder Pressure: 2015 PSIG
PGVP Number: B32013	Valve Outlet: 660
Gas Code: NO	Certification Date: Mar 12, 2013

Expiration Date: Mar 12, 2021

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	50.00 PPM	50.71 PPM	G1	+/- 1.2% NIST Traceable	03/05/2013, 03/12/2013
NITRIC OXIDE	50.00 PPM	50.55 PPM	G1	+/- 1.0% NIST Traceable	03/05/2013, 03/12/2013
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12060833	CC283887	49.95 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Dec 16, 2017
PRM	12312	680179	10.01 PPM NITROGEN DIOXIDE/NITROGEN	+/- 2.0%	Feb 14, 2012
GMIS	124208889129	CC323206	4.835 PPM NITROGEN DIOXIDE/NITROGEN	+/-2.0%	Oct 11, 2013

The SRM or PRM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801551 NO	FTIR	Feb 16, 2013
Nicolet 6700 AHR0801551 NO2	FTIR	Mar 07, 2013

Triad Data Available Upon Request

Notes:



Approved for Release

UNIT 1

CV6

CERTIFICATE OF ANALYSIS
Grade of Product: EPA Protocol

Part Number: E03NI99E15A42C9 Reference Number: 48-400996728-1
 Cylinder Number: CC185484 Cylinder Volume: 144.3 CF
 Laboratory: 124 - Los Angeles (SAP) - CA Cylinder Pressure: 2015 PSIG
 PGVP Number: B32017 Valve Outlet: 660
 Gas Code: CO,NO,NOX,BALN Certification Date: Sep 22, 2017

Expiration Date: Sep 22, 2020

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	5.500 PPM	5.497 PPM	G1	+/- 1.1% NIST Traceable	09/15/2017, 09/22/2017
NITRIC OXIDE	5.500 PPM	5.360 PPM	G1	+/- 1.2% NIST Traceable	09/15/2017, 09/22/2017
CARBON MONOXIDE	500.0 PPM	505.5 PPM	G1	+/- 0.6% NIST Traceable	09/20/2017
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	103107A	KAL004222	5.08 PPM NITRIC OXIDE/NITROGEN	+/- 1.0%	Jun 02, 2018
NTRM	103107A	KAL004222-NOx	5.08 PPM NOx/NITROGEN	+/- 1.0%	Jun 02, 2018
NTRM	12062427	CC366878	487.1 PPM CARBON MONOXIDE/NITROGEN	+/- 0.6%	Jun 22, 2018

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS 6E CO HIGH	NDIR	Sep 14, 2017
Thermo 42-iLS 1115848421 NO	Chemiluminescence	Aug 31, 2017
Thermo 42-iLS 1115848421 NOx	Chemiluminescence	Aug 31, 2017

Triad Data Available Upon Request



[Signature]

Approved for Release

CERTIFICATE OF ANALYSIS
Grade of Product: EPA Protocol

CV 7

Part Number: E03NI99E15A73F4 Reference Number: 153-401144293-1
 Cylinder Number: EB0061551 Cylinder Volume: 144.3 CF
 Laboratory: 124 - Tooele (SAP) - UT Cylinder Pressure: 2015 PSIG
 PGVP Number: B72018 Valve Outlet: 660
 Gas Code: CO,NO,NOX,BALN Certification Date: Mar 13, 2018

Expiration Date: Mar 13, 2021

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	2.500 PPM	2.404 PPM	G1	+/- 1.4% NIST Traceable	03/06/2018, 03/13/2018
NITRIC OXIDE	2.500 PPM	2.397 PPM	G1	+/- 1.4% NIST Traceable	03/06/2018, 03/13/2018
CARBON MONOXIDE	4.750 PPM	4.653 PPM	G1	+/- 0.6% NIST Traceable	03/06/2018
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	08012121A	KAL004278	5.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Jun 02, 2018
NTRM	08012121A	KAL004278-NOX	5.08 PPM NOX/NITROGEN	1.0%	Jun 02, 2018
NTRM	1	CC401502	9.766 PPM CARBON MONOXIDE/NITROGEN	0.3	Sep 07, 2018

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Feb 13, 2018
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Feb 22, 2018
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Feb 22, 2018

Triad Data Available Upon Request



[Signature]
Approved for Release

IN SERVICE: 09 July 19

unit # 1
CV-8

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI87E15A0080	Reference Number:	153-124604208-1
Cylinder Number:	CC25033	Cylinder Volume:	145.5 CF
Laboratory:	124 - Tooele - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72017	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Feb 20, 2017

Expiration Date: Feb 20, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	13.00 %	13.05 %	G1	+/- 0.7% NIST Traceable	02/20/2017
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	98051014	SG9162888BAL	12.05 % OXYGEN/NITROGEN	0.7%	Dec 02, 2017

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 X9A4UGL8 O2	O2 Paramagnetic (Dixon)	Feb 17, 2017

Triad Data Available Upon Request



[Handwritten Signature]

Approved for Release

IN SERVICE 06/11/2018

*CT1
CV9*

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI94E15AC040	Reference Number:	153-401707983-1
Cylinder Number:	SG9173546BAL	Cylinder Volume:	144.8 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72020	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Jan 21, 2020

Expiration Date: Jan 21, 2028

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	5.500 %	5.581 %	G1	+/- 0.7% NIST Traceable	01/21/2020
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	11060717	CC338451	4.861 % OXYGEN/NITROGEN	0.4%	Dec 13, 2022

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Dec 30, 2019

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

NOTES:NO: 0.001 PPM
CO: 0.001 PPM
CO2: 0.001 PPM



[Signature]

Approved for Release

W. S. ... 07/16/2020

*CT1
CV2*

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: E02NI79E15AC046
Cylinder Number: CC163235
Laboratory: 124 - Tooele (SAP) - UT
PGVP Number: B72020

Reference Number: 153-401762410-1
Cylinder Volume: 146.2 CF
Cylinder Pressure: 2015 PSIG
Valve Outlet: 590
Certification Date: Mar 16, 2020

Expiration Date: Mar 16, 2028

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	21.00 %	21.07 %	G1	+/- 0.2% NIST Traceable	03/16/2020
NITROGEN	Balance				

CALIBRATION STANDARDS				
Type	Lot ID	Cylinder No	Concentration	Expiration Date
NTRM	12062019	CC367606	22.883 % OXYGEN/NITROGEN	May 14, 2024

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Feb 26, 2020

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

NOTES:NO: 0.01PPM

CO: 0.01PPM

CO2: 0.01PPM



[Signature]

Approved for Release

Linearity Report

07/08/2020

Page 1

ORIS Code: 56298 Facility Name: COLUSA GENERATION ReasonForTest: QA
 EDR Site ID: CT2 Component ID: A22 Grace Period: 0
 Component Type: O2D
 Instrument Name: CT2_O2D_P_Instrument Test End Date/Time: 07/07/2020 Scale: High
 Performance Spec: 5 % Test No.: 98 Highest Error: 0.0
 Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/07/2020	1029	L	25.0	5.5	5.5		22.0 %
07/07/2020	1035	M	25.0	13.0	13.0		52.0 %
07/07/2020	1041	H	25.0	21.1	21.1		84.4 %
07/07/2020	1050	L	25.0	5.5	5.5		22.0 %
07/07/2020	1056	M	25.0	13.0	13.0		52.0 %
07/07/2020	1102	H	25.0	21.1	21.1		84.4 %
07/07/2020	1110	L	25.0	5.5	5.5		22.0 %
07/07/2020	1116	M	25.0	13.0	13.0		52.0 %
07/07/2020	1122	H	25.0	21.1	21.1		84.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.500	No	0.0
M	13.000	13.000	No	0.0
H	21.100	21.100	No	0.0

Linearity Report

ORIS Code: 56298 Facility Name: COLUSA GENERATION ReasonForTest: QA
 EDR Site ID: CT2 Component ID: A21 Grace Period: 0
 Component Type: NOXA
 Instrument Name: CT2_NOXDualRg_P_Instrume Test End Date/Time: 07/07/2020 Scale: High
 Performance Spec: 5 % Test No.: 97 Highest Error: 0.8
 Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/07/2020	1227	L	200.0	51.2	50.6		25.6 %
07/07/2020	1233	M	200.0	110.4	110.6		55.2 %
07/07/2020	1239	H	200.0	184.7	185.0		92.4 %
07/07/2020	1248	L	200.0	51.2	50.8		25.6 %
07/07/2020	1254	M	200.0	110.4	110.5		55.2 %
07/07/2020	1300	H	200.0	184.7	185.2		92.4 %
07/07/2020	1308	L	200.0	51.2	50.9		25.6 %
07/07/2020	1314	M	200.0	110.4	110.5		55.2 %
07/07/2020	1320	H	200.0	184.7	185.0		92.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.200	50.767	No	0.8
M	110.400	110.533	No	0.1
H	184.700	185.067	No	0.2

Cylinder Gas Audit

07/08/2020

Page 1

Facility: COLUSA GENERATION Instrument Name: CT2_CODualRg_P_Instrum
 Unit/Stack: CT2 Test Date: 07/08/2020 Performance Spec: 15 Pct
 Parameter/Scale: CO / High Test Result: **Pass** Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/08/2020	10:22	L	2000	500.500	488.900	25.0 %
07/08/2020	10:28	M	2000	1145.000	1142.200	57.3 %
07/08/2020	10:37	L	2000	500.500	488.600	25.0 %
07/08/2020	10:43	M	2000	1145.000	1141.100	57.3 %
07/08/2020	10:51	L	2000	500.500	488.600	25.0 %
07/08/2020	10:57	M	2000	1145.000	1141.100	57.3 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	500.500		488.700	Std	2.4
M	1145.000		1141.467	Std	0.3

Cylinder Gas Audit

Facility: COLUSA GENERATION
 Unit/Stack: CT2
 Parameter/Scale: NOX / Low
 Instrument Name: CT2_NOXDualRg_P_Instru
 Performance Spec: 15 Pct
 Alternate Spec: 5 Ppm
 Test Date: 07/08/2020
 Test Result: Pass

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/08/2020	08:38	L	10	2.500	2.500	25.0 %
07/08/2020	08:44	M	10	5.200	5.200	52.0 %
07/08/2020	08:53	L	10	2.500	2.500	25.0 %
07/08/2020	08:59	M	10	5.200	5.200	52.0 %
07/08/2020	09:07	L	10	2.500	2.500	25.0 %
07/08/2020	09:13	M	10	5.200	5.200	52.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.500	2.500	Std	0.0
M	5.200	5.200	Std	0.0

Cylinder Gas Audit

07/08/2020

Page 1

Facility: COLUSA GENERATION
 Unit/Stack: CT2
 Parameter/Scale: CO / Low

Instrument Name: CT2_CODualRg_P_Instrum
 Performance Spec: 15 Pct
 Alternate Spec: 5 Ppm

Test Date: 07/08/2020
 Test Result: Pass

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/08/2020	07:25	L	20	4.600	4.500	23.0 %
07/08/2020	07:31	M	20	10.900	10.700	54.5 %
07/08/2020	07:40	L	20	4.600	4.400	23.0 %
07/08/2020	07:46	M	20	10.900	10.700	54.5 %
07/08/2020	07:54	L	20	4.600	4.500	23.0 %
07/08/2020	08:00	M	20	10.900	10.700	54.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	4.600	4.467	Std	2.9
M	10.900	10.700	Std	1.8

Cylinder Gas Audit

07/08/2020

Page 1

Facility: COLUSA GENERATION	Instrument Name: CT2_NOXInlet_P_Instrum	
Unit/Stack: CT2	Test Date: 07/07/2020	Performance Spec: 15 Pct
Parameter/Scale: NOX / High	Test Result: Pass	Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/07/2020	15:09	L	200	51.200	51.100	25.6 %
07/07/2020	15:15	M	200	110.400	111.000	55.2 %
07/07/2020	15:24	L	200	51.200	51.200	25.6 %
07/07/2020	15:30	M	200	110.400	111.100	55.2 %
07/07/2020	15:38	L	200	51.200	51.200	25.6 %
07/07/2020	15:44	M	200	110.400	111.200	55.2 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	51.200	51.167	Std	0.1
M	110.400	111.100	Std	0.6

Cylinder Gas Audit

Facility: COLUSA GENERATION
 Unit/Stack: CT2
 Parameter/Scale: O2D / High
 Instrument Name: CT2_O2DInlet_P_Instrum
 Test Date: 07/07/2020
 Performance Spec: 15 Pct
 Test Result: **Pass**
 Alternate Spec: 0 Pct

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/07/2020	13:44	L	25	5.500	5.200	22.0 %
07/07/2020	13:50	M	25	13.000	12.900	52.0 %
07/07/2020	13:59	L	25	5.500	5.200	22.0 %
07/07/2020	14:05	M	25	13.000	12.900	52.0 %
07/07/2020	14:13	L	25	5.500	5.200	22.0 %
07/07/2020	14:19	M	25	13.000	12.900	52.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	5.500	5.200	Std	5.5
M	13.000	12.900	Std	0.8

*CT2
CV1*

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A42D0	Reference Number:	153-401557387-1
Cylinder Number:	EB0035810	Cylinder Volume:	144.4 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72019	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Aug 05, 2019

Expiration Date: Aug 05, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	180.0 PPM	184.7 PPM	G1	+/- 0.8% NIST Traceable	07/29/2019, 08/05/2019
NITRIC OXIDE	180.0 PPM	183.9 PPM	G1	+/- 0.7% NIST Traceable	07/29/2019, 08/05/2019
CARBON MONOXIDE	1150 PPM	1145 PPM	G1	+/- 0.7% NIST Traceable	07/29/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	18060132	KAL004328	249.9 PPM NITRIC OXIDE/NITROGEN	0.4%	Nov 08, 2023
PRM	12376	D562879	10.01 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Aug 17, 2018
GMIS	7301017103	CC506597	4.451 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Dec 18, 2020
NTRM	14060151	CC436896	990.9 PPM CARBON MONOXIDE/NITROGEN	0.6%	Nov 18, 2019

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AMP0900119 CO HCO	FTIR	Jul 17, 2019
Nicolet 6700 AMP0900119 NO MNO	FTIR	Jul 10, 2019
Nicolet 6700 AMP0900119 NO2 impurity	FTIR NO2 impurity	Jul 11, 2019

Triad Data Available Upon Request



mlz

Approved for Release

IN SERVICE 30 Jun 20

*CT 2
CV 2*

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI79E15AC046	Reference Number:	153-401762410-1
Cylinder Number:	ALM030600	Cylinder Volume:	146.2 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72020	Valve Outlet:	590
		Certification Date:	Mar 16, 2020

Expiration Date: Mar 16, 2028

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	21.00 %	21.07 %	G1	+/- 0.2% NIST Traceable	03/16/2020
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12062019	CC367606	22.883 % OXYGEN/NITROGEN	0.050%	May 14, 2024

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Feb 26, 2020

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

NOTES:NO: 0.01PPM

CO: 0.01PPM

CO2: 0.01PPM



[Handwritten Signature]

Approved for Release

*CT2
CV3*

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A7635	Reference Number:	153-401617764-1
Cylinder Number:	EB0106672	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72019	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Oct 14, 2019

Expiration Date: Oct 14, 2022

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	9.333 PPM	G1	+/- 1.1% NIST Traceable	10/07/2019, 10/14/2019
NITRIC OXIDE	9.000 PPM	9.228 PPM	G1	+/- 1.1% NIST Traceable	10/07/2019, 10/14/2019
CARBON MONOXIDE	11.00 PPM	10.90 PPM	G1	+/- 0.6% NIST Traceable	10/07/2019
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060708	CC437400	10.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Oct 16, 2022
NTRM	16060708	CC437400-NOX	10.08 PPM NOX/NITROGEN	1.0%	Oct 16, 2022
NTRM	08011130	KAL004049	9.855 PPM CARBON MONOXIDE/NITROGEN	0.5%	Jun 05, 2024

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Sep 23, 2019
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Oct 03, 2019
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Oct 03, 2019

Triad Data Available Upon Request



Cheryl Wright

Approved for Release

CT2 - CV4

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0093	Reference Number:	153-400996726-1
Cylinder Number:	CC205834	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72017	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Sep 19, 2017

Expiration Date: Sep 19, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	110.0 PPM	110.4 PPM	G1	+/- 1.0% NIST Traceable	09/12/2017, 09/19/2017
NITRIC OXIDE	110.0 PPM	110.2 PPM	G1	+/- 1.0% NIST Traceable	09/12/2017, 09/19/2017
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	13010428	KAL004053	97.6 PPM NITRIC OXIDE/NITROGEN	0.8	May 09, 2019
PRM	12367	APEX1099237	10.00 PPM NITROGEN DIOXIDE/NITROGEN	1.6%	May 29, 2016
GMIS	1114201604	CC507567	4.955 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Nov 14, 2019

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 NO LNO	FTIR	Sep 07, 2017
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Sep 07, 2017

Triad Data Available Upon Request



Approved for Release

IN SERVICE 01/02/18



Airgas Specialty Gases
Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT2

CV5

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0147	Reference Number:	153-400996727-1
Cylinder Number:	CC254020	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72017	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Sep 19, 2017

Expiration Date: Sep 19, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	50.00 PPM	51.16 PPM	G1	+/- 1.2% NIST Traceable	09/12/2017, 09/19/2017
NITRIC OXIDE	50.00 PPM	51.12 PPM	G1	+/- 1.2% NIST Traceable	09/12/2017, 09/19/2017
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060632	CC442611	50.42 PPM NITRIC OXIDE/NITROGEN	0.8%	May 27, 2020
PRM	12367	APEX1099237	10.00 PPM NITROGEN DIOXIDE/NITROGEN	1.6%	May 29, 2016
GMS	1114201604	CC507567	4.955 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Nov 14, 2019

The SRM, PRM or RGM noted above is only in reference to the GMS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 NO LNO	FTIR	Sep 07, 2017
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Sep 07, 2017

Triad Data Available Upon Request



Approved for Release

IN SERVICE: 9 April 19

*CT 2
CV 6*

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A42C9	Reference Number:	48-401198488-1
Cylinder Number:	CC437300	Cylinder Volume:	128.9 CF
Laboratory:	124 - Los Angeles (SAP) - CA	Cylinder Pressure:	1800 PSIG
PGVP Number:	B32018	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	May 18, 2018

Expiration Date: May 18, 2021

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	5.500 PPM	5.207 PPM	G1	+/- 1.4% NIST Traceable	05/18/2018
NITRIC OXIDE	5.500 PPM	4.934 PPM	G1	+/- 1.2% NIST Traceable	05/18/2018
CARBON MONOXIDE	500.0 PPM	500.5 PPM	G1	+/- 0.7% NIST Traceable	05/10/2018
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	103107A	KAL004222	5.08 PPM NITRIC OXIDE/NITROGEN	+/- 1.0%	Jun 02, 2018
NTRM	103107A	KAL004222-NOx	5.08 PPM NOx/NITROGEN	+/- 1.0%	Jun 02, 2018
NTRM	12062427	CC366878	487.1 PPM CARBON MONOXIDE/NITROGEN	+/- 0.6%	Jun 22, 2018

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS 6E CO HIGH	NDIR	Apr 23, 2018
Thermo 42-iLS 1115848421 NO	Chemiluminescence	Apr 24, 2018
Thermo 42-iLS 1115848421 NOx	Chemiluminescence	Apr 24, 2018

Triad Data Available Upon Request



[Handwritten Signature]

Approved for Release

CT 2
CV 7

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A73F4	Reference Number:	153-401707981-1
Cylinder Number:	CC472917	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72020	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Jan 28, 2020

Expiration Date: Jan 28, 2023

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	2.500 PPM	2.507 PPM	G1	+/- 1.3% NIST Traceable	01/21/2020, 01/28/2020
NITRIC OXIDE	2.500 PPM	2.502 PPM	G1	+/- 1.4% NIST Traceable	01/21/2020, 01/28/2020
CARBON MONOXIDE	4.750 PPM	4.637 PPM	G1	+/- 0.6% NIST Traceable	01/21/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	08012121A	KAL004278	5.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Jun 05, 2021
NTRM	08012126	KAL004291	5.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Jul 05, 2021
NTRM	08012121A	KAL004278-NOX	5.08 PPM NOx/NITROGEN	1.0%	Jun 05, 2021
NTRM	08012126	KAL004291-NOX	5.08 PPM NOx/NITROGEN	1.0%	Jul 05, 2021
NTRM	08011130	KAL004049	9.855 PPM CARBON MONOXIDE/NITROGEN	0.5%	Jun 05, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Jan 06, 2020
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Jan 16, 2020
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Jan 16, 2020

Triad Data Available Upon Request



Carlye Taylor

Approved for Release

CT2
CV8

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI87E15A0080	Reference Number:	153-124618307-1
Cylinder Number:	CC420243	Cylinder Volume:	145.5 CF
Laboratory:	124 - Tooele - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72017	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	May 09, 2017

Expiration Date: May 09, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	13.00 %	13.04 %	G1	+/- 0.7% NIST Traceable	05/09/2017
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	98051014	SG9162888BAL	12.05 % OXYGEN/NITROGEN	0.7%	Dec 02, 2017

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 X9A4UGL8 O2	O2 Paramagnetic (Dixon)	Apr 12, 2017

Triad Data Available Upon Request



Carry Wright

Approved for Release

CERTIFICATE OF ANALYSIS
Grade of Product: EPA Protocol

CT.2
CV.9

Part Number: E02NI94E15AC040 Reference Number: 153-401707983-1
Cylinder Number: CC54718 Cylinder Volume: 144.8 CF
Laboratory: 124 - Tooele (SAP) - UT Cylinder Pressure: 2015 PSIG
PGVP Number: B72020 Valve Outlet: 590
Gas Code: O2,BALN Certification Date: Jan 21, 2020

Expiration Date: Jan 21, 2028

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	5.500 %	5.507 %	G1	+/- 0.6% NIST Traceable	01/21/2020
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	11060717	CC338451	4.861 % OXYGEN/NITROGEN	0.4%	Dec 13, 2022

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Dec 30, 2019

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

NOTES:NO: 0.001 PPM

CO: 0.001 PPM

CO2: 0.001 PPM



[Handwritten Signature]

Approved for Release

ATTACHMENT 12
Startup/Shutdown Emissions

FCD: AQ-22
Title V: #13, #14

100scf Per Event Report

CT1 - GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 10/06/2020 09:32 Location: Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,867.23 Hours

Non-Operating Time: 340.77 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
07/03/2020 13:18 07/03/2020 14:38 Warm Start - Gas	81	137.4		
07/03/2020 23:24 07/03/2020 23:29 Shut Down - Gas	6	2.3		
07/05/2020 14:24 07/05/2020 15:43 Warm Start - Gas	80	140.0		
07/05/2020 22:30 07/05/2020 22:35 Shut Down - Gas	6	2.1		
07/06/2020 11:37 07/06/2020 12:49 Warm Start - Gas	73	129.2		
09/11/2020 23:04 09/11/2020 23:09 Shut Down - Gas	6	1.6		
09/14/2020 13:25 09/14/2020 15:09 Warm Start - Gas	105	184.6		
09/15/2020 22:25 09/15/2020 22:26 Shut Down - Gas	2	1.4		
09/16/2020 06:29 09/16/2020 07:33 Warm Start - Gas	65	117.5		
09/17/2020 23:57 09/18/2020 00:02 Shut Down - Gas	6	1.7		
09/18/2020 06:33 09/18/2020 07:46 Hot Start - Gas	74	130.4		
09/18/2020 22:40 09/18/2020 22:45 Shut Down - Gas	6	1.7		
09/19/2020 04:44 09/19/2020 05:47 Hot Start - Gas	64	122.7		

100scf Per Event Report

CT1 - GasFlowTotal 100scf



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/06/2020 09:32 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,867.23 Hours

Non-Operating Time: 340.77 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
09/20/2020 06:09 09/20/2020 06:14 Shut Down - Gas	6	1.9		
09/20/2020 10:31 09/20/2020 11:42 Hot Start - Gas	72	121.0		
09/20/2020 22:08 09/20/2020 22:13 Shut Down - Gas	6	2.0		
09/21/2020 13:28 09/21/2020 14:56 Warm Start - Gas	89	156.2		
09/21/2020 22:08 09/21/2020 22:13 Shut Down - Gas	6	2.0		
09/22/2020 14:33 09/22/2020 15:55 Warm Start - Gas	83	148.7		
09/22/2020 21:22 09/22/2020 21:27 Shut Down - Gas	6	2.0		
09/23/2020 13:34 09/23/2020 14:57 Warm Start - Gas	84	150.6		
09/23/2020 21:08 09/23/2020 21:13 Shut Down - Gas	6	1.7		
09/24/2020 08:38 09/24/2020 10:49 Warm Start - Gas	132	208.9		
09/24/2020 20:22 09/24/2020 20:28 Shut Down - Gas	7	2.3		
09/27/2020 08:18 09/27/2020 08:25 Warm Start - Gas	8	2.6		
09/27/2020 13:50 09/27/2020 15:09 Warm Start - Gas	80	136.4		
09/27/2020 22:23 09/27/2020 22:28 Shut Down - Gas	6	2.1		

100scf Per Event Report

CT1 - GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 10/06/2020 09:32 Location: Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,867.23 Hours

Non-Operating Time: 340.77 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
09/28/2020 06:38 09/28/2020 07:49 Warm Start - Gas	72	129.5		
09/28/2020 22:24 09/28/2020 22:29 Shut Down - Gas	6	2.0		
09/29/2020 06:36 09/29/2020 07:52 Warm Start - Gas	77	139.3		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 10/06/2020 09:32 Location: Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,867.23 Hours

Non-Operating Time: 340.77 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 10/06/2020 09:32 Location: Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,867.23 Hours

Non-Operating Time: 340.77 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary

1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/01/2020 00:00	0.0	0	0	0	0	0
07/01/2020 01:00	0.0	0	0	0	0	0
07/01/2020 02:00	0.0	0	0	0	0	0
07/01/2020 03:00	0.0	0	0	0	0	0
07/01/2020 04:00	0.0	0	0	0	0	0
07/01/2020 05:00	0.0	0	0	0	0	0
07/01/2020 06:00	0.0	0	0	0	0	0
07/01/2020 07:00	0.0	0	0	0	0	0
07/01/2020 08:00	0.0	0	0	0	0	0
07/01/2020 09:00	0.0	0	0	0	0	0
07/01/2020 10:00	0.0	0	0	0	0	0
07/01/2020 11:00	0.0	0	0	0	0	0
07/01/2020 12:00	0.0	0	0	0	0	0
07/01/2020 13:00	0.0	0	0	0	0	0
07/01/2020 14:00	0.0	0	0	0	0	0
07/01/2020 15:00	0.0	0	0	0	0	0
07/01/2020 16:00	0.0	0	0	0	0	0
07/01/2020 17:00	0.0	0	0	0	0	0
07/01/2020 18:00	0.0	0	0	0	0	0
07/01/2020 19:00	0.0	0	0	0	0	0
07/01/2020 20:00	0.0	0	0	0	0	0
07/01/2020 21:00	0.0	0	0	0	0	0
07/01/2020 22:00	0.0	0	0	0	0	0
07/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/02/2020 00:00	0.0	0	0	0	0	0
07/02/2020 01:00	0.0	0	0	0	0	0
07/02/2020 02:00	0.0	0	0	0	0	0
07/02/2020 03:00	0.0	0	0	0	0	0
07/02/2020 04:00	0.0	0	0	0	0	0
07/02/2020 05:00	0.0	0	0	0	0	0
07/02/2020 06:00	0.0	0	0	0	0	0
07/02/2020 07:00	0.0	0	0	0	0	0
07/02/2020 08:00	0.0	0	0	0	0	0
07/02/2020 09:00	0.0	0	0	0	0	0
07/02/2020 10:00	0.0	0	0	0	0	0
07/02/2020 11:00	0.0	0	0	0	0	0
07/02/2020 12:00	0.0	0	0	0	0	0
07/02/2020 13:00	0.0	0	0	0	0	0
07/02/2020 14:00	0.0	0	0	0	0	0
07/02/2020 15:00	0.0	0	0	0	0	0
07/02/2020 16:00	0.0	0	0	0	0	0
07/02/2020 17:00	0.0	0	0	0	0	0
07/02/2020 18:00	0.0	0	0	0	0	0
07/02/2020 19:00	0.0	0	0	0	0	0
07/02/2020 20:00	0.0	0	0	0	0	0
07/02/2020 21:00	0.0	0	0	0	0	0
07/02/2020 22:00	0.0	0	0	0	0	0
07/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/03/2020 00:00	0.0	0	0	0	0	0
07/03/2020 01:00	0.0	0	0	0	0	0
07/03/2020 02:00	0.0	0	0	0	0	0
07/03/2020 03:00	0.0	0	0	0	0	0
07/03/2020 04:00	0.0	0	0	0	0	0
07/03/2020 05:00	0.0	0	0	0	0	0
07/03/2020 06:00	0.0	0	0	0	0	0
07/03/2020 07:00	0.0	0	0	0	0	0
07/03/2020 08:00	0.0	0	0	0	0	0
07/03/2020 09:00	0.0	0	0	0	0	0
07/03/2020 10:00	0.0	0	0	0	0	0
07/03/2020 11:00	0.0	0	0	0	0	0
07/03/2020 12:00	0.0	0	0	0	0	0
07/03/2020 13:00	89.5	0	1	0	0	0
07/03/2020 14:00	26.4	0	1	0	0	0
07/03/2020 15:00	0.0	0	0	0	0	1
07/03/2020 16:00	0.0	0	0	0	0	1
07/03/2020 17:00	0.0	0	0	0	0	1
07/03/2020 18:00	0.0	0	0	0	0	1
07/03/2020 19:00	0.0	0	0	0	0	1
07/03/2020 20:00	0.0	0	0	0	0	1
07/03/2020 21:00	0.0	0	0	0	0	1
07/03/2020 22:00	0.0	0	0	0	0	1
07/03/2020 23:00	1.8	0	0	0	1	0
Average/Sum#:	117.7 #	0 #	2 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	89.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/04/2020 00:00	0.0	0	0	0	0	0
07/04/2020 01:00	0.0	0	0	0	0	0
07/04/2020 02:00	0.0	0	0	0	0	0
07/04/2020 03:00	0.0	0	0	0	0	0
07/04/2020 04:00	0.0	0	0	0	0	0
07/04/2020 05:00	0.0	0	0	0	0	0
07/04/2020 06:00	0.0	0	0	0	0	0
07/04/2020 07:00	0.0	0	0	0	0	0
07/04/2020 08:00	0.0	0	0	0	0	0
07/04/2020 09:00	0.0	0	0	0	0	0
07/04/2020 10:00	0.0	0	0	0	0	0
07/04/2020 11:00	0.0	0	0	0	0	0
07/04/2020 12:00	0.0	0	0	0	0	0
07/04/2020 13:00	0.0	0	0	0	0	0
07/04/2020 14:00	0.0	0	0	0	0	0
07/04/2020 15:00	0.0	0	0	0	0	0
07/04/2020 16:00	0.0	0	0	0	0	0
07/04/2020 17:00	0.0	0	0	0	0	0
07/04/2020 18:00	0.0	0	0	0	0	0
07/04/2020 19:00	0.0	0	0	0	0	0
07/04/2020 20:00	0.0	0	0	0	0	0
07/04/2020 21:00	0.0	0	0	0	0	0
07/04/2020 22:00	0.0	0	0	0	0	0
07/04/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/05/2020 00:00	0.0	0	0	0	0	0
07/05/2020 01:00	0.0	0	0	0	0	0
07/05/2020 02:00	0.0	0	0	0	0	0
07/05/2020 03:00	0.0	0	0	0	0	0
07/05/2020 04:00	0.0	0	0	0	0	0
07/05/2020 05:00	0.0	0	0	0	0	0
07/05/2020 06:00	0.0	0	0	0	0	0
07/05/2020 07:00	0.0	0	0	0	0	0
07/05/2020 08:00	0.0	0	0	0	0	0
07/05/2020 09:00	0.0	0	0	0	0	0
07/05/2020 10:00	0.0	0	0	0	0	0
07/05/2020 11:00	0.0	0	0	0	0	0
07/05/2020 12:00	0.0	0	0	0	0	0
07/05/2020 13:00	0.0	0	0	0	0	0
07/05/2020 14:00	65.4	0	1	0	0	0
07/05/2020 15:00	29.8	0	1	0	0	0
07/05/2020 16:00	0.0	0	0	0	0	1
07/05/2020 17:00	0.0	0	0	0	0	1
07/05/2020 18:00	0.0	0	0	0	0	1
07/05/2020 19:00	0.0	0	0	0	0	1
07/05/2020 20:00	0.0	0	0	0	0	1
07/05/2020 21:00	0.0	0	0	0	0	1
07/05/2020 22:00	1.5	0	0	0	1	0
07/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	96.7 #	0 #	2 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	65.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/06/2020 00:00	0.0	0	0	0	0	0
07/06/2020 01:00	0.0	0	0	0	0	0
07/06/2020 02:00	0.0	0	0	0	0	0
07/06/2020 03:00	0.0	0	0	0	0	0
07/06/2020 04:00	0.0	0	0	0	0	0
07/06/2020 05:00	0.0	0	0	0	0	0
07/06/2020 06:00	0.0	0	0	0	0	0
07/06/2020 07:00	0.0	0	0	0	0	0
07/06/2020 08:00	0.0	0	0	0	0	0
07/06/2020 09:00	0.0	0	0	0	0	0
07/06/2020 10:00	0.0	0	0	0	0	0
07/06/2020 11:00	11.6	0	1	0	0	0
07/06/2020 12:00	40.0	0	1	0	0	0
07/06/2020 13:00	0.0	0	0	0	0	1
07/06/2020 14:00	0.0	0	0	0	0	1
07/06/2020 15:00	0.0	0	0	0	0	1
07/06/2020 16:00	0.0	0	0	0	0	1
07/06/2020 17:00	0.0	0	0	0	0	1
07/06/2020 18:00	0.0	0	0	0	0	1
07/06/2020 19:00	0.0	0	0	0	0	1
07/06/2020 20:00	0.0	0	0	0	0	1
07/06/2020 21:00	0.0	0	0	0	0	1
07/06/2020 22:00	0.0	0	0	0	0	1
07/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	51.6 #	0 #	2 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	40.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/07/2020 00:00	0.0	0	0	0	0	1
07/07/2020 01:00	0.0	0	0	0	0	1
07/07/2020 02:00	0.0	0	0	0	0	1
07/07/2020 03:00	0.0	0	0	0	0	1
07/07/2020 04:00	0.0	0	0	0	0	1
07/07/2020 05:00	0.0	0	0	0	0	1
07/07/2020 06:00	0.0	0	0	0	0	1
07/07/2020 07:00	0.0	0	0	0	0	1
07/07/2020 08:00	0.0	0	0	0	0	1
07/07/2020 09:00	0.0	0	0	0	0	1
07/07/2020 10:00	0.0	0	0	0	0	1
07/07/2020 11:00	0.0	0	0	0	0	1
07/07/2020 12:00	0.0	0	0	0	0	1
07/07/2020 13:00	0.0	0	0	0	0	1
07/07/2020 14:00	0.0	0	0	0	0	1
07/07/2020 15:00	0.0	0	0	0	0	1
07/07/2020 16:00	0.0	0	0	0	0	1
07/07/2020 17:00	0.0	0	0	0	0	1
07/07/2020 18:00	0.0	0	0	0	0	1
07/07/2020 19:00	0.0	0	0	0	0	1
07/07/2020 20:00	0.0	0	0	0	0	1
07/07/2020 21:00	0.0	0	0	0	0	1
07/07/2020 22:00	0.0	0	0	0	0	1
07/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/08/2020 00:00	0.0	0	0	0	0	1
07/08/2020 01:00	0.0	0	0	0	0	1
07/08/2020 02:00	0.0	0	0	0	0	1
07/08/2020 03:00	0.0	0	0	0	0	1
07/08/2020 04:00	0.0	0	0	0	0	1
07/08/2020 05:00	0.0	0	0	0	0	1
07/08/2020 06:00	0.0	0	0	0	0	1
07/08/2020 07:00	0.0	0	0	0	0	1
07/08/2020 08:00	0.0	0	0	0	0	1
07/08/2020 09:00	0.0	0	0	0	0	1
07/08/2020 10:00	0.0	0	0	0	0	1
07/08/2020 11:00	0.0	0	0	0	0	1
07/08/2020 12:00	0.0	0	0	0	0	1
07/08/2020 13:00	0.0	0	0	0	0	1
07/08/2020 14:00	0.0	0	0	0	0	1
07/08/2020 15:00	0.0	0	0	0	0	1
07/08/2020 16:00	0.0	0	0	0	0	1
07/08/2020 17:00	0.0	0	0	0	0	1
07/08/2020 18:00	0.0	0	0	0	0	1
07/08/2020 19:00	0.0	0	0	0	0	1
07/08/2020 20:00	0.0	0	0	0	0	1
07/08/2020 21:00	0.0	0	0	0	0	1
07/08/2020 22:00	0.0	0	0	0	0	1
07/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/09/2020 00:00	0.0	0	0	0	0	1
07/09/2020 01:00	0.0	0	0	0	0	1
07/09/2020 02:00	0.0	0	0	0	0	1
07/09/2020 03:00	0.0	0	0	0	0	1
07/09/2020 04:00	0.0	0	0	0	0	1
07/09/2020 05:00	0.0	0	0	0	0	1
07/09/2020 06:00	0.0	0	0	0	0	1
07/09/2020 07:00	0.0	0	0	0	0	1
07/09/2020 08:00	0.0	0	0	0	0	1
07/09/2020 09:00	0.0	0	0	0	0	1
07/09/2020 10:00	0.0	0	0	0	0	1
07/09/2020 11:00	0.0	0	0	0	0	1
07/09/2020 12:00	0.0	0	0	0	0	1
07/09/2020 13:00	0.0	0	0	0	0	1
07/09/2020 14:00	0.0	0	0	0	0	1
07/09/2020 15:00	0.0	0	0	0	0	1
07/09/2020 16:00	0.0	0	0	0	0	1
07/09/2020 17:00	0.0	0	0	0	0	1
07/09/2020 18:00	0.0	0	0	0	0	1
07/09/2020 19:00	0.0	0	0	0	0	1
07/09/2020 20:00	0.0	0	0	0	0	1
07/09/2020 21:00	0.0	0	0	0	0	1
07/09/2020 22:00	0.0	0	0	0	0	1
07/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/10/2020 00:00	0.0	0	0	0	0	1
07/10/2020 01:00	0.0	0	0	0	0	1
07/10/2020 02:00	0.0	0	0	0	0	1
07/10/2020 03:00	0.0	0	0	0	0	1
07/10/2020 04:00	0.0	0	0	0	0	1
07/10/2020 05:00	0.0	0	0	0	0	1
07/10/2020 06:00	0.0	0	0	0	0	1
07/10/2020 07:00	0.0	0	0	0	0	1
07/10/2020 08:00	0.0	0	0	0	0	1
07/10/2020 09:00	0.0	0	0	0	0	1
07/10/2020 10:00	0.0	0	0	0	0	1
07/10/2020 11:00	0.0	0	0	0	0	1
07/10/2020 12:00	0.0	0	0	0	0	1
07/10/2020 13:00	0.0	0	0	0	0	1
07/10/2020 14:00	0.0	0	0	0	0	1
07/10/2020 15:00	0.0	0	0	0	0	1
07/10/2020 16:00	0.0	0	0	0	0	1
07/10/2020 17:00	0.0	0	0	0	0	1
07/10/2020 18:00	0.0	0	0	0	0	1
07/10/2020 19:00	0.0	0	0	0	0	1
07/10/2020 20:00	0.0	0	0	0	0	1
07/10/2020 21:00	0.0	0	0	0	0	1
07/10/2020 22:00	0.0	0	0	0	0	1
07/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/11/2020 00:00	0.0	0	0	0	0	1
07/11/2020 01:00	0.0	0	0	0	0	1
07/11/2020 02:00	0.0	0	0	0	0	1
07/11/2020 03:00	0.0	0	0	0	0	1
07/11/2020 04:00	0.0	0	0	0	0	1
07/11/2020 05:00	0.0	0	0	0	0	1
07/11/2020 06:00	0.0	0	0	0	0	1
07/11/2020 07:00	0.0	0	0	0	0	1
07/11/2020 08:00	0.0	0	0	0	0	1
07/11/2020 09:00	0.0	0	0	0	0	1
07/11/2020 10:00	0.0	0	0	0	0	1
07/11/2020 11:00	0.0	0	0	0	0	1
07/11/2020 12:00	0.0	0	0	0	0	1
07/11/2020 13:00	0.0	0	0	0	0	1
07/11/2020 14:00	0.0	0	0	0	0	1
07/11/2020 15:00	0.0	0	0	0	0	1
07/11/2020 16:00	0.0	0	0	0	0	1
07/11/2020 17:00	0.0	0	0	0	0	1
07/11/2020 18:00	0.0	0	0	0	0	1
07/11/2020 19:00	0.0	0	0	0	0	1
07/11/2020 20:00	0.0	0	0	0	0	1
07/11/2020 21:00	0.0	0	0	0	0	1
07/11/2020 22:00	0.0	0	0	0	0	1
07/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/12/2020 00:00	0.0	0	0	0	0	1
07/12/2020 01:00	0.0	0	0	0	0	1
07/12/2020 02:00	0.0	0	0	0	0	1
07/12/2020 03:00	0.0	0	0	0	0	1
07/12/2020 04:00	0.0	0	0	0	0	1
07/12/2020 05:00	0.0	0	0	0	0	1
07/12/2020 06:00	0.0	0	0	0	0	1
07/12/2020 07:00	0.0	0	0	0	0	1
07/12/2020 08:00	0.0	0	0	0	0	1
07/12/2020 09:00	0.0	0	0	0	0	1
07/12/2020 10:00	0.0	0	0	0	0	1
07/12/2020 11:00	0.0	0	0	0	0	1
07/12/2020 12:00	0.0	0	0	0	0	1
07/12/2020 13:00	0.0	0	0	0	0	1
07/12/2020 14:00	0.0	0	0	0	0	1
07/12/2020 15:00	0.0	0	0	0	0	1
07/12/2020 16:00	0.0	0	0	0	0	1
07/12/2020 17:00	0.0	0	0	0	0	1
07/12/2020 18:00	0.0	0	0	0	0	1
07/12/2020 19:00	0.0	0	0	0	0	1
07/12/2020 20:00	0.0	0	0	0	0	1
07/12/2020 21:00	0.0	0	0	0	0	1
07/12/2020 22:00	0.0	0	0	0	0	1
07/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/13/2020 00:00	0.0	0	0	0	0	1
07/13/2020 01:00	0.0	0	0	0	0	1
07/13/2020 02:00	0.0	0	0	0	0	1
07/13/2020 03:00	0.0	0	0	0	0	1
07/13/2020 04:00	0.0	0	0	0	0	1
07/13/2020 05:00	0.0	0	0	0	0	1
07/13/2020 06:00	0.0	0	0	0	0	1
07/13/2020 07:00	0.0	0	0	0	0	1
07/13/2020 08:00	0.0	0	0	0	0	1
07/13/2020 09:00	0.0	0	0	0	0	1
07/13/2020 10:00	0.0	0	0	0	0	1
07/13/2020 11:00	0.0	0	0	0	0	1
07/13/2020 12:00	0.0	0	0	0	0	1
07/13/2020 13:00	0.0	0	0	0	0	1
07/13/2020 14:00	0.0	0	0	0	0	1
07/13/2020 15:00	0.0	0	0	0	0	1
07/13/2020 16:00	0.0	0	0	0	0	1
07/13/2020 17:00	0.0	0	0	0	0	1
07/13/2020 18:00	0.0	0	0	0	0	1
07/13/2020 19:00	0.0	0	0	0	0	1
07/13/2020 20:00	0.0	0	0	0	0	1
07/13/2020 21:00	0.0	0	0	0	0	1
07/13/2020 22:00	0.0	0	0	0	0	1
07/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/14/2020 00:00	0.0	0	0	0	0	1
07/14/2020 01:00	0.0	0	0	0	0	1
07/14/2020 02:00	0.0	0	0	0	0	1
07/14/2020 03:00	0.0	0	0	0	0	1
07/14/2020 04:00	0.0	0	0	0	0	1
07/14/2020 05:00	0.0	0	0	0	0	1
07/14/2020 06:00	0.0	0	0	0	0	1
07/14/2020 07:00	0.0	0	0	0	0	1
07/14/2020 08:00	0.0	0	0	0	0	1
07/14/2020 09:00	0.0	0	0	0	0	1
07/14/2020 10:00	0.0	0	0	0	0	1
07/14/2020 11:00	0.0	0	0	0	0	1
07/14/2020 12:00	0.0	0	0	0	0	1
07/14/2020 13:00	0.0	0	0	0	0	1
07/14/2020 14:00	0.0	0	0	0	0	1
07/14/2020 15:00	0.0	0	0	0	0	1
07/14/2020 16:00	0.0	0	0	0	0	1
07/14/2020 17:00	0.0	0	0	0	0	1
07/14/2020 18:00	0.0	0	0	0	0	1
07/14/2020 19:00	0.0	0	0	0	0	1
07/14/2020 20:00	0.0	0	0	0	0	1
07/14/2020 21:00	0.0	0	0	0	0	1
07/14/2020 22:00	0.0	0	0	0	0	1
07/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/15/2020 00:00	0.0	0	0	0	0	1
07/15/2020 01:00	0.0	0	0	0	0	1
07/15/2020 02:00	0.0	0	0	0	0	1
07/15/2020 03:00	0.0	0	0	0	0	1
07/15/2020 04:00	0.0	0	0	0	0	1
07/15/2020 05:00	0.0	0	0	0	0	1
07/15/2020 06:00	0.0	0	0	0	0	1
07/15/2020 07:00	0.0	0	0	0	0	1
07/15/2020 08:00	0.0	0	0	0	0	1
07/15/2020 09:00	0.0	0	0	0	0	1
07/15/2020 10:00	0.0	0	0	0	0	1
07/15/2020 11:00	0.0	0	0	0	0	1
07/15/2020 12:00	0.0	0	0	0	0	1
07/15/2020 13:00	0.0	0	0	0	0	1
07/15/2020 14:00	0.0	0	0	0	0	1
07/15/2020 15:00	0.0	0	0	0	0	1
07/15/2020 16:00	0.0	0	0	0	0	1
07/15/2020 17:00	0.0	0	0	0	0	1
07/15/2020 18:00	0.0	0	0	0	0	1
07/15/2020 19:00	0.0	0	0	0	0	1
07/15/2020 20:00	0.0	0	0	0	0	1
07/15/2020 21:00	0.0	0	0	0	0	1
07/15/2020 22:00	0.0	0	0	0	0	1
07/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/16/2020 00:00	0.0	0	0	0	0	1
07/16/2020 01:00	0.0	0	0	0	0	1
07/16/2020 02:00	0.0	0	0	0	0	1
07/16/2020 03:00	0.0	0	0	0	0	1
07/16/2020 04:00	0.0	0	0	0	0	1
07/16/2020 05:00	0.0	0	0	0	0	1
07/16/2020 06:00	0.0	0	0	0	0	1
07/16/2020 07:00	0.0	0	0	0	0	1
07/16/2020 08:00	0.0	0	0	0	0	1
07/16/2020 09:00	0.0	0	0	0	0	1
07/16/2020 10:00	0.0	0	0	0	0	1
07/16/2020 11:00	0.0	0	0	0	0	1
07/16/2020 12:00	0.0	0	0	0	0	1
07/16/2020 13:00	0.0	0	0	0	0	1
07/16/2020 14:00	0.0	0	0	0	0	1
07/16/2020 15:00	0.0	0	0	0	0	1
07/16/2020 16:00	0.0	0	0	0	0	1
07/16/2020 17:00	0.0	0	0	0	0	1
07/16/2020 18:00	0.0	0	0	0	0	1
07/16/2020 19:00	0.0	0	0	0	0	1
07/16/2020 20:00	0.0	0	0	0	0	1
07/16/2020 21:00	0.0	0	0	0	0	1
07/16/2020 22:00	0.0	0	0	0	0	1
07/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/17/2020 00:00	0.0	0	0	0	0	1
07/17/2020 01:00	0.0	0	0	0	0	1
07/17/2020 02:00	0.0	0	0	0	0	1
07/17/2020 03:00	0.0	0	0	0	0	1
07/17/2020 04:00	0.0	0	0	0	0	1
07/17/2020 05:00	0.0	0	0	0	0	1
07/17/2020 06:00	0.0	0	0	0	0	1
07/17/2020 07:00	0.0	0	0	0	0	1
07/17/2020 08:00	0.0	0	0	0	0	1
07/17/2020 09:00	0.0	0	0	0	0	1
07/17/2020 10:00	0.0	0	0	0	0	1
07/17/2020 11:00	0.0	0	0	0	0	1
07/17/2020 12:00	0.0	0	0	0	0	1
07/17/2020 13:00	0.0	0	0	0	0	1
07/17/2020 14:00	0.0	0	0	0	0	1
07/17/2020 15:00	0.0	0	0	0	0	1
07/17/2020 16:00	0.0	0	0	0	0	1
07/17/2020 17:00	0.0	0	0	0	0	1
07/17/2020 18:00	0.0	0	0	0	0	1
07/17/2020 19:00	0.0	0	0	0	0	1
07/17/2020 20:00	0.0	0	0	0	0	1
07/17/2020 21:00	0.0	0	0	0	0	1
07/17/2020 22:00	0.0	0	0	0	0	1
07/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/18/2020 00:00	0.0	0	0	0	0	1
07/18/2020 01:00	0.0	0	0	0	0	1
07/18/2020 02:00	0.0	0	0	0	0	1
07/18/2020 03:00	0.0	0	0	0	0	1
07/18/2020 04:00	0.0	0	0	0	0	1
07/18/2020 05:00	0.0	0	0	0	0	1
07/18/2020 06:00	0.0	0	0	0	0	1
07/18/2020 07:00	0.0	0	0	0	0	1
07/18/2020 08:00	0.0	0	0	0	0	1
07/18/2020 09:00	0.0	0	0	0	0	1
07/18/2020 10:00	0.0	0	0	0	0	1
07/18/2020 11:00	0.0	0	0	0	0	1
07/18/2020 12:00	0.0	0	0	0	0	1
07/18/2020 13:00	0.0	0	0	0	0	1
07/18/2020 14:00	0.0	0	0	0	0	1
07/18/2020 15:00	0.0	0	0	0	0	1
07/18/2020 16:00	0.0	0	0	0	0	1
07/18/2020 17:00	0.0	0	0	0	0	1
07/18/2020 18:00	0.0	0	0	0	0	1
07/18/2020 19:00	0.0	0	0	0	0	1
07/18/2020 20:00	0.0	0	0	0	0	1
07/18/2020 21:00	0.0	0	0	0	0	1
07/18/2020 22:00	0.0	0	0	0	0	1
07/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/19/2020 00:00	0.0	0	0	0	0	1
07/19/2020 01:00	0.0	0	0	0	0	1
07/19/2020 02:00	0.0	0	0	0	0	1
07/19/2020 03:00	0.0	0	0	0	0	1
07/19/2020 04:00	0.0	0	0	0	0	1
07/19/2020 05:00	0.0	0	0	0	0	1
07/19/2020 06:00	0.0	0	0	0	0	1
07/19/2020 07:00	0.0	0	0	0	0	1
07/19/2020 08:00	0.0	0	0	0	0	1
07/19/2020 09:00	0.0	0	0	0	0	1
07/19/2020 10:00	0.0	0	0	0	0	1
07/19/2020 11:00	0.0	0	0	0	0	1
07/19/2020 12:00	0.0	0	0	0	0	1
07/19/2020 13:00	0.0	0	0	0	0	1
07/19/2020 14:00	0.0	0	0	0	0	1
07/19/2020 15:00	0.0	0	0	0	0	1
07/19/2020 16:00	0.0	0	0	0	0	1
07/19/2020 17:00	0.0	0	0	0	0	1
07/19/2020 18:00	0.0	0	0	0	0	1
07/19/2020 19:00	0.0	0	0	0	0	1
07/19/2020 20:00	0.0	0	0	0	0	1
07/19/2020 21:00	0.0	0	0	0	0	1
07/19/2020 22:00	0.0	0	0	0	0	1
07/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/20/2020 00:00	0.0	0	0	0	0	1
07/20/2020 01:00	0.0	0	0	0	0	1
07/20/2020 02:00	0.0	0	0	0	0	1
07/20/2020 03:00	0.0	0	0	0	0	1
07/20/2020 04:00	0.0	0	0	0	0	1
07/20/2020 05:00	0.0	0	0	0	0	1
07/20/2020 06:00	0.0	0	0	0	0	1
07/20/2020 07:00	0.0	0	0	0	0	1
07/20/2020 08:00	0.0	0	0	0	0	1
07/20/2020 09:00	0.0	0	0	0	0	1
07/20/2020 10:00	0.0	0	0	0	0	1
07/20/2020 11:00	0.0	0	0	0	0	1
07/20/2020 12:00	0.0	0	0	0	0	1
07/20/2020 13:00	0.0	0	0	0	0	1
07/20/2020 14:00	0.0	0	0	0	0	1
07/20/2020 15:00	0.0	0	0	0	0	1
07/20/2020 16:00	0.0	0	0	0	0	1
07/20/2020 17:00	0.0	0	0	0	0	1
07/20/2020 18:00	0.0	0	0	0	0	1
07/20/2020 19:00	0.0	0	0	0	0	1
07/20/2020 20:00	0.0	0	0	0	0	1
07/20/2020 21:00	0.0	0	0	0	0	1
07/20/2020 22:00	0.0	0	0	0	0	1
07/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/21/2020 00:00	0.0	0	0	0	0	1
07/21/2020 01:00	0.0	0	0	0	0	1
07/21/2020 02:00	0.0	0	0	0	0	1
07/21/2020 03:00	0.0	0	0	0	0	1
07/21/2020 04:00	0.0	0	0	0	0	1
07/21/2020 05:00	0.0	0	0	0	0	1
07/21/2020 06:00	0.0	0	0	0	0	1
07/21/2020 07:00	0.0	0	0	0	0	1
07/21/2020 08:00	0.0	0	0	0	0	1
07/21/2020 09:00	0.0	0	0	0	0	1
07/21/2020 10:00	0.0	0	0	0	0	1
07/21/2020 11:00	0.0	0	0	0	0	1
07/21/2020 12:00	0.0	0	0	0	0	1
07/21/2020 13:00	0.0	0	0	0	0	1
07/21/2020 14:00	0.0	0	0	0	0	1
07/21/2020 15:00	0.0	0	0	0	0	1
07/21/2020 16:00	0.0	0	0	0	0	1
07/21/2020 17:00	0.0	0	0	0	0	1
07/21/2020 18:00	0.0	0	0	0	0	1
07/21/2020 19:00	0.0	0	0	0	0	1
07/21/2020 20:00	0.0	0	0	0	0	1
07/21/2020 21:00	0.0	0	0	0	0	1
07/21/2020 22:00	0.0	0	0	0	0	1
07/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/22/2020 00:00	0.0	0	0	0	0	1
07/22/2020 01:00	0.0	0	0	0	0	1
07/22/2020 02:00	0.0	0	0	0	0	1
07/22/2020 03:00	0.0	0	0	0	0	1
07/22/2020 04:00	0.0	0	0	0	0	1
07/22/2020 05:00	0.0	0	0	0	0	1
07/22/2020 06:00	0.0	0	0	0	0	1
07/22/2020 07:00	0.0	0	0	0	0	1
07/22/2020 08:00	0.0	0	0	0	0	1
07/22/2020 09:00	0.0	0	0	0	0	1
07/22/2020 10:00	0.0	0	0	0	0	1
07/22/2020 11:00	0.0	0	0	0	0	1
07/22/2020 12:00	0.0	0	0	0	0	1
07/22/2020 13:00	0.0	0	0	0	0	1
07/22/2020 14:00	0.0	0	0	0	0	1
07/22/2020 15:00	0.0	0	0	0	0	1
07/22/2020 16:00	0.0	0	0	0	0	1
07/22/2020 17:00	0.0	0	0	0	0	1
07/22/2020 18:00	0.0	0	0	0	0	1
07/22/2020 19:00	0.0	0	0	0	0	1
07/22/2020 20:00	0.0	0	0	0	0	1
07/22/2020 21:00	0.0	0	0	0	0	1
07/22/2020 22:00	0.0	0	0	0	0	1
07/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/23/2020 00:00	0.0	0	0	0	0	1
07/23/2020 01:00	0.0	0	0	0	0	1
07/23/2020 02:00	0.0	0	0	0	0	1
07/23/2020 03:00	0.0	0	0	0	0	1
07/23/2020 04:00	0.0	0	0	0	0	1
07/23/2020 05:00	0.0	0	0	0	0	1
07/23/2020 06:00	0.0	0	0	0	0	1
07/23/2020 07:00	0.0	0	0	0	0	1
07/23/2020 08:00	0.0	0	0	0	0	1
07/23/2020 09:00	0.0	0	0	0	0	1
07/23/2020 10:00	0.0	0	0	0	0	1
07/23/2020 11:00	0.0	0	0	0	0	1
07/23/2020 12:00	0.0	0	0	0	0	1
07/23/2020 13:00	0.0	0	0	0	0	1
07/23/2020 14:00	0.0	0	0	0	0	1
07/23/2020 15:00	0.0	0	0	0	0	1
07/23/2020 16:00	0.0	0	0	0	0	1
07/23/2020 17:00	0.0	0	0	0	0	1
07/23/2020 18:00	0.0	0	0	0	0	1
07/23/2020 19:00	0.0	0	0	0	0	1
07/23/2020 20:00	0.0	0	0	0	0	1
07/23/2020 21:00	0.0	0	0	0	0	1
07/23/2020 22:00	0.0	0	0	0	0	1
07/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/24/2020 00:00	0.0	0	0	0	0	1
07/24/2020 01:00	0.0	0	0	0	0	1
07/24/2020 02:00	0.0	0	0	0	0	1
07/24/2020 03:00	0.0	0	0	0	0	1
07/24/2020 04:00	0.0	0	0	0	0	1
07/24/2020 05:00	0.0	0	0	0	0	1
07/24/2020 06:00	0.0	0	0	0	0	1
07/24/2020 07:00	0.0	0	0	0	0	1
07/24/2020 08:00	0.0	0	0	0	0	1
07/24/2020 09:00	0.0	0	0	0	0	1
07/24/2020 10:00	0.0	0	0	0	0	1
07/24/2020 11:00	0.0	0	0	0	0	1
07/24/2020 12:00	0.0	0	0	0	0	1
07/24/2020 13:00	0.0	0	0	0	0	1
07/24/2020 14:00	0.0	0	0	0	0	1
07/24/2020 15:00	0.0	0	0	0	0	1
07/24/2020 16:00	0.0	0	0	0	0	1
07/24/2020 17:00	0.0	0	0	0	0	1
07/24/2020 18:00	0.0	0	0	0	0	1
07/24/2020 19:00	0.0	0	0	0	0	1
07/24/2020 20:00	0.0	0	0	0	0	1
07/24/2020 21:00	0.0	0	0	0	0	1
07/24/2020 22:00	0.0	0	0	0	0	1
07/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/25/2020 00:00	0.0	0	0	0	0	1
07/25/2020 01:00	0.0	0	0	0	0	1
07/25/2020 02:00	0.0	0	0	0	0	1
07/25/2020 03:00	0.0	0	0	0	0	1
07/25/2020 04:00	0.0	0	0	0	0	1
07/25/2020 05:00	0.0	0	0	0	0	1
07/25/2020 06:00	0.0	0	0	0	0	1
07/25/2020 07:00	0.0	0	0	0	0	1
07/25/2020 08:00	0.0	0	0	0	0	1
07/25/2020 09:00	0.0	0	0	0	0	1
07/25/2020 10:00	0.0	0	0	0	0	1
07/25/2020 11:00	0.0	0	0	0	0	1
07/25/2020 12:00	0.0	0	0	0	0	1
07/25/2020 13:00	0.0	0	0	0	0	1
07/25/2020 14:00	0.0	0	0	0	0	1
07/25/2020 15:00	0.0	0	0	0	0	1
07/25/2020 16:00	0.0	0	0	0	0	1
07/25/2020 17:00	0.0	0	0	0	0	1
07/25/2020 18:00	0.0	0	0	0	0	1
07/25/2020 19:00	0.0	0	0	0	0	1
07/25/2020 20:00	0.0	0	0	0	0	1
07/25/2020 21:00	0.0	0	0	0	0	1
07/25/2020 22:00	0.0	0	0	0	0	1
07/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/26/2020 00:00	0.0	0	0	0	0	1
07/26/2020 01:00	0.0	0	0	0	0	1
07/26/2020 02:00	0.0	0	0	0	0	1
07/26/2020 03:00	0.0	0	0	0	0	1
07/26/2020 04:00	0.0	0	0	0	0	1
07/26/2020 05:00	0.0	0	0	0	0	1
07/26/2020 06:00	0.0	0	0	0	0	1
07/26/2020 07:00	0.0	0	0	0	0	1
07/26/2020 08:00	0.0	0	0	0	0	1
07/26/2020 09:00	0.0	0	0	0	0	1
07/26/2020 10:00	0.0	0	0	0	0	1
07/26/2020 11:00	0.0	0	0	0	0	1
07/26/2020 12:00	0.0	0	0	0	0	1
07/26/2020 13:00	0.0	0	0	0	0	1
07/26/2020 14:00	0.0	0	0	0	0	1
07/26/2020 15:00	0.0	0	0	0	0	1
07/26/2020 16:00	0.0	0	0	0	0	1
07/26/2020 17:00	0.0	0	0	0	0	1
07/26/2020 18:00	0.0	0	0	0	0	1
07/26/2020 19:00	0.0	0	0	0	0	1
07/26/2020 20:00	0.0	0	0	0	0	1
07/26/2020 21:00	0.0	0	0	0	0	1
07/26/2020 22:00	0.0	0	0	0	0	1
07/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/27/2020 00:00	0.0	0	0	0	0	1
07/27/2020 01:00	0.0	0	0	0	0	1
07/27/2020 02:00	0.0	0	0	0	0	1
07/27/2020 03:00	0.0	0	0	0	0	1
07/27/2020 04:00	0.0	0	0	0	0	1
07/27/2020 05:00	0.0	0	0	0	0	1
07/27/2020 06:00	0.0	0	0	0	0	1
07/27/2020 07:00	0.0	0	0	0	0	1
07/27/2020 08:00	0.0	0	0	0	0	1
07/27/2020 09:00	0.0	0	0	0	0	1
07/27/2020 10:00	0.0	0	0	0	0	1
07/27/2020 11:00	0.0	0	0	0	0	1
07/27/2020 12:00	0.0	0	0	0	0	1
07/27/2020 13:00	0.0	0	0	0	0	1
07/27/2020 14:00	0.0	0	0	0	0	1
07/27/2020 15:00	0.0	0	0	0	0	1
07/27/2020 16:00	0.0	0	0	0	0	1
07/27/2020 17:00	0.0	0	0	0	0	1
07/27/2020 18:00	0.0	0	0	0	0	1
07/27/2020 19:00	0.0	0	0	0	0	1
07/27/2020 20:00	0.0	0	0	0	0	1
07/27/2020 21:00	0.0	0	0	0	0	1
07/27/2020 22:00	0.0	0	0	0	0	1
07/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/28/2020 00:00	0.0	0	0	0	0	1
07/28/2020 01:00	0.0	0	0	0	0	1
07/28/2020 02:00	0.0	0	0	0	0	1
07/28/2020 03:00	0.0	0	0	0	0	1
07/28/2020 04:00	0.0	0	0	0	0	1
07/28/2020 05:00	0.0	0	0	0	0	1
07/28/2020 06:00	0.0	0	0	0	0	1
07/28/2020 07:00	0.0	0	0	0	0	1
07/28/2020 08:00	0.0	0	0	0	0	1
07/28/2020 09:00	0.0	0	0	0	0	1
07/28/2020 10:00	0.0	0	0	0	0	1
07/28/2020 11:00	0.0	0	0	0	0	1
07/28/2020 12:00	0.0	0	0	0	0	1
07/28/2020 13:00	0.0	0	0	0	0	1
07/28/2020 14:00	0.0	0	0	0	0	1
07/28/2020 15:00	0.0	0	0	0	0	1
07/28/2020 16:00	0.0	0	0	0	0	1
07/28/2020 17:00	0.0	0	0	0	0	1
07/28/2020 18:00	0.0	0	0	0	0	1
07/28/2020 19:00	0.0	0	0	0	0	1
07/28/2020 20:00	0.0	0	0	0	0	1
07/28/2020 21:00	0.0	0	0	0	0	1
07/28/2020 22:00	0.0	0	0	0	0	1
07/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/29/2020 00:00	0.0	0	0	0	0	1
07/29/2020 01:00	0.0	0	0	0	0	1
07/29/2020 02:00	0.0	0	0	0	0	1
07/29/2020 03:00	0.0	0	0	0	0	1
07/29/2020 04:00	0.0	0	0	0	0	1
07/29/2020 05:00	0.0	0	0	0	0	1
07/29/2020 06:00	0.0	0	0	0	0	1
07/29/2020 07:00	0.0	0	0	0	0	1
07/29/2020 08:00	0.0	0	0	0	0	1
07/29/2020 09:00	0.0	0	0	0	0	1
07/29/2020 10:00	0.0	0	0	0	0	1
07/29/2020 11:00	0.0	0	0	0	0	1
07/29/2020 12:00	0.0	0	0	0	0	1
07/29/2020 13:00	0.0	0	0	0	0	1
07/29/2020 14:00	0.0	0	0	0	0	1
07/29/2020 15:00	0.0	0	0	0	0	1
07/29/2020 16:00	0.0	0	0	0	0	1
07/29/2020 17:00	0.0	0	0	0	0	1
07/29/2020 18:00	0.0	0	0	0	0	1
07/29/2020 19:00	0.0	0	0	0	0	1
07/29/2020 20:00	0.0	0	0	0	0	1
07/29/2020 21:00	0.0	0	0	0	0	1
07/29/2020 22:00	0.0	0	0	0	0	1
07/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/30/2020 00:00	0.0	0	0	0	0	1
07/30/2020 01:00	0.0	0	0	0	0	1
07/30/2020 02:00	0.0	0	0	0	0	1
07/30/2020 03:00	0.0	0	0	0	0	1
07/30/2020 04:00	0.0	0	0	0	0	1
07/30/2020 05:00	0.0	0	0	0	0	1
07/30/2020 06:00	0.0	0	0	0	0	1
07/30/2020 07:00	0.0	0	0	0	0	1
07/30/2020 08:00	0.0	0	0	0	0	1
07/30/2020 09:00	0.0	0	0	0	0	1
07/30/2020 10:00	0.0	0	0	0	0	1
07/30/2020 11:00	0.0	0	0	0	0	1
07/30/2020 12:00	0.0	0	0	0	0	1
07/30/2020 13:00	0.0	0	0	0	0	1
07/30/2020 14:00	0.0	0	0	0	0	1
07/30/2020 15:00	0.0	0	0	0	0	1
07/30/2020 16:00	0.0	0	0	0	0	1
07/30/2020 17:00	0.0	0	0	0	0	1
07/30/2020 18:00	0.0	0	0	0	0	1
07/30/2020 19:00	0.0	0	0	0	0	1
07/30/2020 20:00	0.0	0	0	0	0	1
07/30/2020 21:00	0.0	0	0	0	0	1
07/30/2020 22:00	0.0	0	0	0	0	1
07/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/31/2020 00:00	0.0	0	0	0	0	1
07/31/2020 01:00	0.0	0	0	0	0	1
07/31/2020 02:00	0.0	0	0	0	0	1
07/31/2020 03:00	0.0	0	0	0	0	1
07/31/2020 04:00	0.0	0	0	0	0	1
07/31/2020 05:00	0.0	0	0	0	0	1
07/31/2020 06:00	0.0	0	0	0	0	1
07/31/2020 07:00	0.0	0	0	0	0	1
07/31/2020 08:00	0.0	0	0	0	0	1
07/31/2020 09:00	0.0	0	0	0	0	1
07/31/2020 10:00	0.0	0	0	0	0	1
07/31/2020 11:00	0.0	0	0	0	0	1
07/31/2020 12:00	0.0	0	0	0	0	1
07/31/2020 13:00	0.0	0	0	0	0	1
07/31/2020 14:00	0.0	0	0	0	0	1
07/31/2020 15:00	0.0	0	0	0	0	1
07/31/2020 16:00	0.0	0	0	0	0	1
07/31/2020 17:00	0.0	0	0	0	0	1
07/31/2020 18:00	0.0	0	0	0	0	1
07/31/2020 19:00	0.0	0	0	0	0	1
07/31/2020 20:00	0.0	0	0	0	0	1
07/31/2020 21:00	0.0	0	0	0	0	1
07/31/2020 22:00	0.0	0	0	0	0	1
07/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/01/2020 00:00	0.0	0	0	0	0	1
08/01/2020 01:00	0.0	0	0	0	0	1
08/01/2020 02:00	0.0	0	0	0	0	1
08/01/2020 03:00	0.0	0	0	0	0	1
08/01/2020 04:00	0.0	0	0	0	0	1
08/01/2020 05:00	0.0	0	0	0	0	1
08/01/2020 06:00	0.0	0	0	0	0	1
08/01/2020 07:00	0.0	0	0	0	0	1
08/01/2020 08:00	0.0	0	0	0	0	1
08/01/2020 09:00	0.0	0	0	0	0	1
08/01/2020 10:00	0.0	0	0	0	0	1
08/01/2020 11:00	0.0	0	0	0	0	1
08/01/2020 12:00	0.0	0	0	0	0	1
08/01/2020 13:00	0.0	0	0	0	0	1
08/01/2020 14:00	0.0	0	0	0	0	1
08/01/2020 15:00	0.0	0	0	0	0	1
08/01/2020 16:00	0.0	0	0	0	0	1
08/01/2020 17:00	0.0	0	0	0	0	1
08/01/2020 18:00	0.0	0	0	0	0	1
08/01/2020 19:00	0.0	0	0	0	0	1
08/01/2020 20:00	0.0	0	0	0	0	1
08/01/2020 21:00	0.0	0	0	0	0	1
08/01/2020 22:00	0.0	0	0	0	0	1
08/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/02/2020 00:00	0.0	0	0	0	0	1
08/02/2020 01:00	0.0	0	0	0	0	1
08/02/2020 02:00	0.0	0	0	0	0	1
08/02/2020 03:00	0.0	0	0	0	0	1
08/02/2020 04:00	0.0	0	0	0	0	1
08/02/2020 05:00	0.0	0	0	0	0	1
08/02/2020 06:00	0.0	0	0	0	0	1
08/02/2020 07:00	0.0	0	0	0	0	1
08/02/2020 08:00	0.0	0	0	0	0	1
08/02/2020 09:00	0.0	0	0	0	0	1
08/02/2020 10:00	0.0	0	0	0	0	1
08/02/2020 11:00	0.0	0	0	0	0	1
08/02/2020 12:00	0.0	0	0	0	0	1
08/02/2020 13:00	0.0	0	0	0	0	1
08/02/2020 14:00	0.0	0	0	0	0	1
08/02/2020 15:00	0.0	0	0	0	0	1
08/02/2020 16:00	0.0	0	0	0	0	1
08/02/2020 17:00	0.0	0	0	0	0	1
08/02/2020 18:00	0.0	0	0	0	0	1
08/02/2020 19:00	0.0	0	0	0	0	1
08/02/2020 20:00	0.0	0	0	0	0	1
08/02/2020 21:00	0.0	0	0	0	0	1
08/02/2020 22:00	0.0	0	0	0	0	1
08/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/03/2020 00:00	0.0	0	0	0	0	1
08/03/2020 01:00	0.0	0	0	0	0	1
08/03/2020 02:00	0.0	0	0	0	0	1
08/03/2020 03:00	0.0	0	0	0	0	1
08/03/2020 04:00	0.0	0	0	0	0	1
08/03/2020 05:00	0.0	0	0	0	0	1
08/03/2020 06:00	0.0	0	0	0	0	1
08/03/2020 07:00	0.0	0	0	0	0	1
08/03/2020 08:00	0.0	0	0	0	0	1
08/03/2020 09:00	0.0	0	0	0	0	1
08/03/2020 10:00	0.0	0	0	0	0	1
08/03/2020 11:00	0.0	0	0	0	0	1
08/03/2020 12:00	0.0	0	0	0	0	1
08/03/2020 13:00	0.0	0	0	0	0	1
08/03/2020 14:00	0.0	0	0	0	0	1
08/03/2020 15:00	0.0	0	0	0	0	1
08/03/2020 16:00	0.0	0	0	0	0	1
08/03/2020 17:00	0.0	0	0	0	0	1
08/03/2020 18:00	0.0	0	0	0	0	1
08/03/2020 19:00	0.0	0	0	0	0	1
08/03/2020 20:00	0.0	0	0	0	0	1
08/03/2020 21:00	0.0	0	0	0	0	1
08/03/2020 22:00	0.0	0	0	0	0	1
08/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/04/2020 00:00	0.0	0	0	0	0	1
08/04/2020 01:00	0.0	0	0	0	0	1
08/04/2020 02:00	0.0	0	0	0	0	1
08/04/2020 03:00	0.0	0	0	0	0	1
08/04/2020 04:00	0.0	0	0	0	0	1
08/04/2020 05:00	0.0	0	0	0	0	1
08/04/2020 06:00	0.0	0	0	0	0	1
08/04/2020 07:00	0.0	0	0	0	0	1
08/04/2020 08:00	0.0	0	0	0	0	1
08/04/2020 09:00	0.0	0	0	0	0	1
08/04/2020 10:00	0.0	0	0	0	0	1
08/04/2020 11:00	0.0	0	0	0	0	1
08/04/2020 12:00	0.0	0	0	0	0	1
08/04/2020 13:00	0.0	0	0	0	0	1
08/04/2020 14:00	0.0	0	0	0	0	1
08/04/2020 15:00	0.0	0	0	0	0	1
08/04/2020 16:00	0.0	0	0	0	0	1
08/04/2020 17:00	0.0	0	0	0	0	1
08/04/2020 18:00	0.0	0	0	0	0	1
08/04/2020 19:00	0.0	0	0	0	0	1
08/04/2020 20:00	0.0	0	0	0	0	1
08/04/2020 21:00	0.0	0	0	0	0	1
08/04/2020 22:00	0.0	0	0	0	0	1
08/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/05/2020 00:00	0.0	0	0	0	0	1
08/05/2020 01:00	0.0	0	0	0	0	1
08/05/2020 02:00	0.0	0	0	0	0	1
08/05/2020 03:00	0.0	0	0	0	0	1
08/05/2020 04:00	0.0	0	0	0	0	1
08/05/2020 05:00	0.0	0	0	0	0	1
08/05/2020 06:00	0.0	0	0	0	0	1
08/05/2020 07:00	0.0	0	0	0	0	1
08/05/2020 08:00	0.0	0	0	0	0	1
08/05/2020 09:00	0.0	0	0	0	0	1
08/05/2020 10:00	0.0	0	0	0	0	1
08/05/2020 11:00	0.0	0	0	0	0	1
08/05/2020 12:00	0.0	0	0	0	0	1
08/05/2020 13:00	0.0	0	0	0	0	1
08/05/2020 14:00	0.0	0	0	0	0	1
08/05/2020 15:00	0.0	0	0	0	0	1
08/05/2020 16:00	0.0	0	0	0	0	1
08/05/2020 17:00	0.0	0	0	0	0	1
08/05/2020 18:00	0.0	0	0	0	0	1
08/05/2020 19:00	0.0	0	0	0	0	1
08/05/2020 20:00	0.0	0	0	0	0	1
08/05/2020 21:00	0.0	0	0	0	0	1
08/05/2020 22:00	0.0	0	0	0	0	1
08/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/06/2020 00:00	0.0	0	0	0	0	1
08/06/2020 01:00	0.0	0	0	0	0	1
08/06/2020 02:00	0.0	0	0	0	0	1
08/06/2020 03:00	0.0	0	0	0	0	1
08/06/2020 04:00	0.0	0	0	0	0	1
08/06/2020 05:00	0.0	0	0	0	0	1
08/06/2020 06:00	0.0	0	0	0	0	1
08/06/2020 07:00	0.0	0	0	0	0	1
08/06/2020 08:00	0.0	0	0	0	0	1
08/06/2020 09:00	0.0	0	0	0	0	1
08/06/2020 10:00	0.0	0	0	0	0	1
08/06/2020 11:00	0.0	0	0	0	0	1
08/06/2020 12:00	0.0	0	0	0	0	1
08/06/2020 13:00	0.0	0	0	0	0	1
08/06/2020 14:00	0.0	0	0	0	0	1
08/06/2020 15:00	0.0	0	0	0	0	1
08/06/2020 16:00	0.0	0	0	0	0	1
08/06/2020 17:00	0.0	0	0	0	0	1
08/06/2020 18:00	0.0	0	0	0	0	1
08/06/2020 19:00	0.0	0	0	0	0	1
08/06/2020 20:00	0.0	0	0	0	0	1
08/06/2020 21:00	0.0	0	0	0	0	1
08/06/2020 22:00	0.0	0	0	0	0	1
08/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/07/2020 00:00	0.0	0	0	0	0	1
08/07/2020 01:00	0.0	0	0	0	0	1
08/07/2020 02:00	0.0	0	0	0	0	1
08/07/2020 03:00	0.0	0	0	0	0	1
08/07/2020 04:00	0.0	0	0	0	0	1
08/07/2020 05:00	0.0	0	0	0	0	1
08/07/2020 06:00	0.0	0	0	0	0	1
08/07/2020 07:00	0.0	0	0	0	0	1
08/07/2020 08:00	0.0	0	0	0	0	1
08/07/2020 09:00	0.0	0	0	0	0	1
08/07/2020 10:00	0.0	0	0	0	0	1
08/07/2020 11:00	0.0	0	0	0	0	1
08/07/2020 12:00	0.0	0	0	0	0	1
08/07/2020 13:00	0.0	0	0	0	0	1
08/07/2020 14:00	0.0	0	0	0	0	1
08/07/2020 15:00	0.0	0	0	0	0	1
08/07/2020 16:00	0.0	0	0	0	0	1
08/07/2020 17:00	0.0	0	0	0	0	1
08/07/2020 18:00	0.0	0	0	0	0	1
08/07/2020 19:00	0.0	0	0	0	0	1
08/07/2020 20:00	0.0	0	0	0	0	1
08/07/2020 21:00	0.0	0	0	0	0	1
08/07/2020 22:00	0.0	0	0	0	0	1
08/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/08/2020 00:00	0.0	0	0	0	0	1
08/08/2020 01:00	0.0	0	0	0	0	1
08/08/2020 02:00	0.0	0	0	0	0	1
08/08/2020 03:00	0.0	0	0	0	0	1
08/08/2020 04:00	0.0	0	0	0	0	1
08/08/2020 05:00	0.0	0	0	0	0	1
08/08/2020 06:00	0.0	0	0	0	0	1
08/08/2020 07:00	0.0	0	0	0	0	1
08/08/2020 08:00	0.0	0	0	0	0	1
08/08/2020 09:00	0.0	0	0	0	0	1
08/08/2020 10:00	0.0	0	0	0	0	1
08/08/2020 11:00	0.0	0	0	0	0	1
08/08/2020 12:00	0.0	0	0	0	0	1
08/08/2020 13:00	0.0	0	0	0	0	1
08/08/2020 14:00	0.0	0	0	0	0	1
08/08/2020 15:00	0.0	0	0	0	0	1
08/08/2020 16:00	0.0	0	0	0	0	1
08/08/2020 17:00	0.0	0	0	0	0	1
08/08/2020 18:00	0.0	0	0	0	0	1
08/08/2020 19:00	0.0	0	0	0	0	1
08/08/2020 20:00	0.0	0	0	0	0	1
08/08/2020 21:00	0.0	0	0	0	0	1
08/08/2020 22:00	0.0	0	0	0	0	1
08/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/09/2020 00:00	0.0	0	0	0	0	1
08/09/2020 01:00	0.0	0	0	0	0	1
08/09/2020 02:00	0.0	0	0	0	0	1
08/09/2020 03:00	0.0	0	0	0	0	1
08/09/2020 04:00	0.0	0	0	0	0	1
08/09/2020 05:00	0.0	0	0	0	0	1
08/09/2020 06:00	0.0	0	0	0	0	1
08/09/2020 07:00	0.0	0	0	0	0	1
08/09/2020 08:00	0.0	0	0	0	0	1
08/09/2020 09:00	0.0	0	0	0	0	1
08/09/2020 10:00	0.0	0	0	0	0	1
08/09/2020 11:00	0.0	0	0	0	0	1
08/09/2020 12:00	0.0	0	0	0	0	1
08/09/2020 13:00	0.0	0	0	0	0	1
08/09/2020 14:00	0.0	0	0	0	0	1
08/09/2020 15:00	0.0	0	0	0	0	1
08/09/2020 16:00	0.0	0	0	0	0	1
08/09/2020 17:00	0.0	0	0	0	0	1
08/09/2020 18:00	0.0	0	0	0	0	1
08/09/2020 19:00	0.0	0	0	0	0	1
08/09/2020 20:00	0.0	0	0	0	0	1
08/09/2020 21:00	0.0	0	0	0	0	1
08/09/2020 22:00	0.0	0	0	0	0	1
08/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/10/2020 00:00	0.0	0	0	0	0	1
08/10/2020 01:00	0.0	0	0	0	0	1
08/10/2020 02:00	0.0	0	0	0	0	1
08/10/2020 03:00	0.0	0	0	0	0	1
08/10/2020 04:00	0.0	0	0	0	0	1
08/10/2020 05:00	0.0	0	0	0	0	1
08/10/2020 06:00	0.0	0	0	0	0	1
08/10/2020 07:00	0.0	0	0	0	0	1
08/10/2020 08:00	0.0	0	0	0	0	1
08/10/2020 09:00	0.0	0	0	0	0	1
08/10/2020 10:00	0.0	0	0	0	0	1
08/10/2020 11:00	0.0	0	0	0	0	1
08/10/2020 12:00	0.0	0	0	0	0	1
08/10/2020 13:00	0.0	0	0	0	0	1
08/10/2020 14:00	0.0	0	0	0	0	1
08/10/2020 15:00	0.0	0	0	0	0	1
08/10/2020 16:00	0.0	0	0	0	0	1
08/10/2020 17:00	0.0	0	0	0	0	1
08/10/2020 18:00	0.0	0	0	0	0	1
08/10/2020 19:00	0.0	0	0	0	0	1
08/10/2020 20:00	0.0	0	0	0	0	1
08/10/2020 21:00	0.0	0	0	0	0	1
08/10/2020 22:00	0.0	0	0	0	0	1
08/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/11/2020 00:00	0.0	0	0	0	0	1
08/11/2020 01:00	0.0	0	0	0	0	1
08/11/2020 02:00	0.0	0	0	0	0	1
08/11/2020 03:00	0.0	0	0	0	0	1
08/11/2020 04:00	0.0	0	0	0	0	1
08/11/2020 05:00	0.0	0	0	0	0	1
08/11/2020 06:00	0.0	0	0	0	0	1
08/11/2020 07:00	0.0	0	0	0	0	1
08/11/2020 08:00	0.0	0	0	0	0	1
08/11/2020 09:00	0.0	0	0	0	0	1
08/11/2020 10:00	0.0	0	0	0	0	1
08/11/2020 11:00	0.0	0	0	0	0	1
08/11/2020 12:00	0.0	0	0	0	0	1
08/11/2020 13:00	0.0	0	0	0	0	1
08/11/2020 14:00	0.0	0	0	0	0	1
08/11/2020 15:00	0.0	0	0	0	0	1
08/11/2020 16:00	0.0	0	0	0	0	1
08/11/2020 17:00	0.0	0	0	0	0	1
08/11/2020 18:00	0.0	0	0	0	0	1
08/11/2020 19:00	0.0	0	0	0	0	1
08/11/2020 20:00	0.0	0	0	0	0	1
08/11/2020 21:00	0.0	0	0	0	0	1
08/11/2020 22:00	0.0	0	0	0	0	1
08/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/12/2020 00:00	0.0	0	0	0	0	1
08/12/2020 01:00	0.0	0	0	0	0	1
08/12/2020 02:00	0.0	0	0	0	0	1
08/12/2020 03:00	0.0	0	0	0	0	1
08/12/2020 04:00	0.0	0	0	0	0	1
08/12/2020 05:00	0.0	0	0	0	0	1
08/12/2020 06:00	0.0	0	0	0	0	1
08/12/2020 07:00	0.0	0	0	0	0	1
08/12/2020 08:00	0.0	0	0	0	0	1
08/12/2020 09:00	0.0	0	0	0	0	1
08/12/2020 10:00	0.0	0	0	0	0	1
08/12/2020 11:00	0.0	0	0	0	0	1
08/12/2020 12:00	0.0	0	0	0	0	1
08/12/2020 13:00	0.0	0	0	0	0	1
08/12/2020 14:00	0.0	0	0	0	0	1
08/12/2020 15:00	0.0	0	0	0	0	1
08/12/2020 16:00	0.0	0	0	0	0	1
08/12/2020 17:00	0.0	0	0	0	0	1
08/12/2020 18:00	0.0	0	0	0	0	1
08/12/2020 19:00	0.0	0	0	0	0	1
08/12/2020 20:00	0.0	0	0	0	0	1
08/12/2020 21:00	0.0	0	0	0	0	1
08/12/2020 22:00	0.0	0	0	0	0	1
08/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/13/2020 00:00	0.0	0	0	0	0	1
08/13/2020 01:00	0.0	0	0	0	0	1
08/13/2020 02:00	0.0	0	0	0	0	1
08/13/2020 03:00	0.0	0	0	0	0	1
08/13/2020 04:00	0.0	0	0	0	0	1
08/13/2020 05:00	0.0	0	0	0	0	1
08/13/2020 06:00	0.0	0	0	0	0	1
08/13/2020 07:00	0.0	0	0	0	0	1
08/13/2020 08:00	0.0	0	0	0	0	1
08/13/2020 09:00	0.0	0	0	0	0	1
08/13/2020 10:00	0.0	0	0	0	0	1
08/13/2020 11:00	0.0	0	0	0	0	1
08/13/2020 12:00	0.0	0	0	0	0	1
08/13/2020 13:00	0.0	0	0	0	0	1
08/13/2020 14:00	0.0	0	0	0	0	1
08/13/2020 15:00	0.0	0	0	0	0	1
08/13/2020 16:00	0.0	0	0	0	0	1
08/13/2020 17:00	0.0	0	0	0	0	1
08/13/2020 18:00	0.0	0	0	0	0	1
08/13/2020 19:00	0.0	0	0	0	0	1
08/13/2020 20:00	0.0	0	0	0	0	1
08/13/2020 21:00	0.0	0	0	0	0	1
08/13/2020 22:00	0.0	0	0	0	0	1
08/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/14/2020 00:00	0.0	0	0	0	0	1
08/14/2020 01:00	0.0	0	0	0	0	1
08/14/2020 02:00	0.0	0	0	0	0	1
08/14/2020 03:00	0.0	0	0	0	0	1
08/14/2020 04:00	0.0	0	0	0	0	1
08/14/2020 05:00	0.0	0	0	0	0	1
08/14/2020 06:00	0.0	0	0	0	0	1
08/14/2020 07:00	0.0	0	0	0	0	1
08/14/2020 08:00	0.0	0	0	0	0	1
08/14/2020 09:00	0.0	0	0	0	0	1
08/14/2020 10:00	0.0	0	0	0	0	1
08/14/2020 11:00	0.0	0	0	0	0	1
08/14/2020 12:00	0.0	0	0	0	0	1
08/14/2020 13:00	0.0	0	0	0	0	1
08/14/2020 14:00	0.0	0	0	0	0	1
08/14/2020 15:00	0.0	0	0	0	0	1
08/14/2020 16:00	0.0	0	0	0	0	1
08/14/2020 17:00	0.0	0	0	0	0	1
08/14/2020 18:00	0.0	0	0	0	0	1
08/14/2020 19:00	0.0	0	0	0	0	1
08/14/2020 20:00	0.0	0	0	0	0	1
08/14/2020 21:00	0.0	0	0	0	0	1
08/14/2020 22:00	0.0	0	0	0	0	1
08/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/15/2020 00:00	0.0	0	0	0	0	1
08/15/2020 01:00	0.0	0	0	0	0	1
08/15/2020 02:00	0.0	0	0	0	0	1
08/15/2020 03:00	0.0	0	0	0	0	1
08/15/2020 04:00	0.0	0	0	0	0	1
08/15/2020 05:00	0.0	0	0	0	0	1
08/15/2020 06:00	0.0	0	0	0	0	1
08/15/2020 07:00	0.0	0	0	0	0	1
08/15/2020 08:00	0.0	0	0	0	0	1
08/15/2020 09:00	0.0	0	0	0	0	1
08/15/2020 10:00	0.0	0	0	0	0	1
08/15/2020 11:00	0.0	0	0	0	0	1
08/15/2020 12:00	0.0	0	0	0	0	1
08/15/2020 13:00	0.0	0	0	0	0	1
08/15/2020 14:00	0.0	0	0	0	0	1
08/15/2020 15:00	0.0	0	0	0	0	1
08/15/2020 16:00	0.0	0	0	0	0	1
08/15/2020 17:00	0.0	0	0	0	0	1
08/15/2020 18:00	0.0	0	0	0	0	1
08/15/2020 19:00	0.0	0	0	0	0	1
08/15/2020 20:00	0.0	0	0	0	0	1
08/15/2020 21:00	0.0	0	0	0	0	1
08/15/2020 22:00	0.0	0	0	0	0	1
08/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/16/2020 00:00	0.0	0	0	0	0	1
08/16/2020 01:00	0.0	0	0	0	0	1
08/16/2020 02:00	0.0	0	0	0	0	1
08/16/2020 03:00	0.0	0	0	0	0	1
08/16/2020 04:00	0.0	0	0	0	0	1
08/16/2020 05:00	0.0	0	0	0	0	1
08/16/2020 06:00	0.0	0	0	0	0	1
08/16/2020 07:00	0.0	0	0	0	0	1
08/16/2020 08:00	0.0	0	0	0	0	1
08/16/2020 09:00	0.0	0	0	0	0	1
08/16/2020 10:00	0.0	0	0	0	0	1
08/16/2020 11:00	0.0	0	0	0	0	1
08/16/2020 12:00	0.0	0	0	0	0	1
08/16/2020 13:00	0.0	0	0	0	0	1
08/16/2020 14:00	0.0	0	0	0	0	1
08/16/2020 15:00	0.0	0	0	0	0	1
08/16/2020 16:00	0.0	0	0	0	0	1
08/16/2020 17:00	0.0	0	0	0	0	1
08/16/2020 18:00	0.0	0	0	0	0	1
08/16/2020 19:00	0.0	0	0	0	0	1
08/16/2020 20:00	0.0	0	0	0	0	1
08/16/2020 21:00	0.0	0	0	0	0	1
08/16/2020 22:00	0.0	0	0	0	0	1
08/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/17/2020 00:00	0.0	0	0	0	0	1
08/17/2020 01:00	0.0	0	0	0	0	1
08/17/2020 02:00	0.0	0	0	0	0	1
08/17/2020 03:00	0.0	0	0	0	0	1
08/17/2020 04:00	0.0	0	0	0	0	1
08/17/2020 05:00	0.0	0	0	0	0	1
08/17/2020 06:00	0.0	0	0	0	0	1
08/17/2020 07:00	0.0	0	0	0	0	1
08/17/2020 08:00	0.0	0	0	0	0	1
08/17/2020 09:00	0.0	0	0	0	0	1
08/17/2020 10:00	0.0	0	0	0	0	1
08/17/2020 11:00	0.0	0	0	0	0	1
08/17/2020 12:00	0.0	0	0	0	0	1
08/17/2020 13:00	0.0	0	0	0	0	1
08/17/2020 14:00	0.0	0	0	0	0	1
08/17/2020 15:00	0.0	0	0	0	0	1
08/17/2020 16:00	0.0	0	0	0	0	1
08/17/2020 17:00	0.0	0	0	0	0	1
08/17/2020 18:00	0.0	0	0	0	0	1
08/17/2020 19:00	0.0	0	0	0	0	1
08/17/2020 20:00	0.0	0	0	0	0	1
08/17/2020 21:00	0.0	0	0	0	0	1
08/17/2020 22:00	0.0	0	0	0	0	1
08/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/18/2020 00:00	0.0	0	0	0	0	1
08/18/2020 01:00	0.0	0	0	0	0	1
08/18/2020 02:00	0.0	0	0	0	0	1
08/18/2020 03:00	0.0	0	0	0	0	1
08/18/2020 04:00	0.0	0	0	0	0	1
08/18/2020 05:00	0.0	0	0	0	0	1
08/18/2020 06:00	0.0	0	0	0	0	1
08/18/2020 07:00	0.0	0	0	0	0	1
08/18/2020 08:00	0.0	0	0	0	0	1
08/18/2020 09:00	0.0	0	0	0	0	1
08/18/2020 10:00	0.0	0	0	0	0	1
08/18/2020 11:00	0.0	0	0	0	0	1
08/18/2020 12:00	0.0	0	0	0	0	1
08/18/2020 13:00	0.0	0	0	0	0	1
08/18/2020 14:00	0.0	0	0	0	0	1
08/18/2020 15:00	0.0	0	0	0	0	1
08/18/2020 16:00	0.0	0	0	0	0	1
08/18/2020 17:00	0.0	0	0	0	0	1
08/18/2020 18:00	0.0	0	0	0	0	1
08/18/2020 19:00	0.0	0	0	0	0	1
08/18/2020 20:00	0.0	0	0	0	0	1
08/18/2020 21:00	0.0	0	0	0	0	1
08/18/2020 22:00	0.0	0	0	0	0	1
08/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/19/2020 00:00	0.0	0	0	0	0	1
08/19/2020 01:00	0.0	0	0	0	0	1
08/19/2020 02:00	0.0	0	0	0	0	1
08/19/2020 03:00	0.0	0	0	0	0	1
08/19/2020 04:00	0.0	0	0	0	0	1
08/19/2020 05:00	0.0	0	0	0	0	1
08/19/2020 06:00	0.0	0	0	0	0	1
08/19/2020 07:00	0.0	0	0	0	0	1
08/19/2020 08:00	0.0	0	0	0	0	1
08/19/2020 09:00	0.0	0	0	0	0	1
08/19/2020 10:00	0.0	0	0	0	0	1
08/19/2020 11:00	0.0	0	0	0	0	1
08/19/2020 12:00	0.0	0	0	0	0	1
08/19/2020 13:00	0.0	0	0	0	0	1
08/19/2020 14:00	0.0	0	0	0	0	1
08/19/2020 15:00	0.0	0	0	0	0	1
08/19/2020 16:00	0.0	0	0	0	0	1
08/19/2020 17:00	0.0	0	0	0	0	1
08/19/2020 18:00	0.0	0	0	0	0	1
08/19/2020 19:00	0.0	0	0	0	0	1
08/19/2020 20:00	0.0	0	0	0	0	1
08/19/2020 21:00	0.0	0	0	0	0	1
08/19/2020 22:00	0.0	0	0	0	0	1
08/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/20/2020 00:00	0.0	0	0	0	0	1
08/20/2020 01:00	0.0	0	0	0	0	1
08/20/2020 02:00	0.0	0	0	0	0	1
08/20/2020 03:00	0.0	0	0	0	0	1
08/20/2020 04:00	0.0	0	0	0	0	1
08/20/2020 05:00	0.0	0	0	0	0	1
08/20/2020 06:00	0.0	0	0	0	0	1
08/20/2020 07:00	0.0	0	0	0	0	1
08/20/2020 08:00	0.0	0	0	0	0	1
08/20/2020 09:00	0.0	0	0	0	0	1
08/20/2020 10:00	0.0	0	0	0	0	1
08/20/2020 11:00	0.0	0	0	0	0	1
08/20/2020 12:00	0.0	0	0	0	0	1
08/20/2020 13:00	0.0	0	0	0	0	1
08/20/2020 14:00	0.0	0	0	0	0	1
08/20/2020 15:00	0.0	0	0	0	0	1
08/20/2020 16:00	0.0	0	0	0	0	1
08/20/2020 17:00	0.0	0	0	0	0	1
08/20/2020 18:00	0.0	0	0	0	0	1
08/20/2020 19:00	0.0	0	0	0	0	1
08/20/2020 20:00	0.0	0	0	0	0	1
08/20/2020 21:00	0.0	0	0	0	0	1
08/20/2020 22:00	0.0	0	0	0	0	1
08/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/21/2020 00:00	0.0	0	0	0	0	1
08/21/2020 01:00	0.0	0	0	0	0	1
08/21/2020 02:00	0.0	0	0	0	0	1
08/21/2020 03:00	0.0	0	0	0	0	1
08/21/2020 04:00	0.0	0	0	0	0	1
08/21/2020 05:00	0.0	0	0	0	0	1
08/21/2020 06:00	0.0	0	0	0	0	1
08/21/2020 07:00	0.0	0	0	0	0	1
08/21/2020 08:00	0.0	0	0	0	0	1
08/21/2020 09:00	0.0	0	0	0	0	1
08/21/2020 10:00	0.0	0	0	0	0	1
08/21/2020 11:00	0.0	0	0	0	0	1
08/21/2020 12:00	0.0	0	0	0	0	1
08/21/2020 13:00	0.0	0	0	0	0	1
08/21/2020 14:00	0.0	0	0	0	0	1
08/21/2020 15:00	0.0	0	0	0	0	1
08/21/2020 16:00	0.0	0	0	0	0	1
08/21/2020 17:00	0.0	0	0	0	0	1
08/21/2020 18:00	0.0	0	0	0	0	1
08/21/2020 19:00	0.0	0	0	0	0	1
08/21/2020 20:00	0.0	0	0	0	0	1
08/21/2020 21:00	0.0	0	0	0	0	1
08/21/2020 22:00	0.0	0	0	0	0	1
08/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/22/2020 00:00	0.0	0	0	0	0	1
08/22/2020 01:00	0.0	0	0	0	0	1
08/22/2020 02:00	0.0	0	0	0	0	1
08/22/2020 03:00	0.0	0	0	0	0	1
08/22/2020 04:00	0.0	0	0	0	0	1
08/22/2020 05:00	0.0	0	0	0	0	1
08/22/2020 06:00	0.0	0	0	0	0	1
08/22/2020 07:00	0.0	0	0	0	0	1
08/22/2020 08:00	0.0	0	0	0	0	1
08/22/2020 09:00	0.0	0	0	0	0	1
08/22/2020 10:00	0.0	0	0	0	0	1
08/22/2020 11:00	0.0	0	0	0	0	1
08/22/2020 12:00	0.0	0	0	0	0	1
08/22/2020 13:00	0.0	0	0	0	0	1
08/22/2020 14:00	0.0	0	0	0	0	1
08/22/2020 15:00	0.0	0	0	0	0	1
08/22/2020 16:00	0.0	0	0	0	0	1
08/22/2020 17:00	0.0	0	0	0	0	1
08/22/2020 18:00	0.0	0	0	0	0	1
08/22/2020 19:00	0.0	0	0	0	0	1
08/22/2020 20:00	0.0	0	0	0	0	1
08/22/2020 21:00	0.0	0	0	0	0	1
08/22/2020 22:00	0.0	0	0	0	0	1
08/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/23/2020 00:00	0.0	0	0	0	0	1
08/23/2020 01:00	0.0	0	0	0	0	1
08/23/2020 02:00	0.0	0	0	0	0	1
08/23/2020 03:00	0.0	0	0	0	0	1
08/23/2020 04:00	0.0	0	0	0	0	1
08/23/2020 05:00	0.0	0	0	0	0	1
08/23/2020 06:00	0.0	0	0	0	0	1
08/23/2020 07:00	0.0	0	0	0	0	1
08/23/2020 08:00	0.0	0	0	0	0	1
08/23/2020 09:00	0.0	0	0	0	0	1
08/23/2020 10:00	0.0	0	0	0	0	1
08/23/2020 11:00	0.0	0	0	0	0	1
08/23/2020 12:00	0.0	0	0	0	0	1
08/23/2020 13:00	0.0	0	0	0	0	1
08/23/2020 14:00	0.0	0	0	0	0	1
08/23/2020 15:00	0.0	0	0	0	0	1
08/23/2020 16:00	0.0	0	0	0	0	1
08/23/2020 17:00	0.0	0	0	0	0	1
08/23/2020 18:00	0.0	0	0	0	0	1
08/23/2020 19:00	0.0	0	0	0	0	1
08/23/2020 20:00	0.0	0	0	0	0	1
08/23/2020 21:00	0.0	0	0	0	0	1
08/23/2020 22:00	0.0	0	0	0	0	1
08/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/24/2020 00:00	0.0	0	0	0	0	1
08/24/2020 01:00	0.0	0	0	0	0	1
08/24/2020 02:00	0.0	0	0	0	0	1
08/24/2020 03:00	0.0	0	0	0	0	1
08/24/2020 04:00	0.0	0	0	0	0	1
08/24/2020 05:00	0.0	0	0	0	0	1
08/24/2020 06:00	0.0	0	0	0	0	1
08/24/2020 07:00	0.0	0	0	0	0	1
08/24/2020 08:00	0.0	0	0	0	0	1
08/24/2020 09:00	0.0	0	0	0	0	1
08/24/2020 10:00	0.0	0	0	0	0	1
08/24/2020 11:00	0.0	0	0	0	0	1
08/24/2020 12:00	0.0	0	0	0	0	1
08/24/2020 13:00	0.0	0	0	0	0	1
08/24/2020 14:00	0.0	0	0	0	0	1
08/24/2020 15:00	0.0	0	0	0	0	1
08/24/2020 16:00	0.0	0	0	0	0	1
08/24/2020 17:00	0.0	0	0	0	0	1
08/24/2020 18:00	0.0	0	0	0	0	1
08/24/2020 19:00	0.0	0	0	0	0	1
08/24/2020 20:00	0.0	0	0	0	0	1
08/24/2020 21:00	0.0	0	0	0	0	1
08/24/2020 22:00	0.0	0	0	0	0	1
08/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/25/2020 00:00	0.0	0	0	0	0	1
08/25/2020 01:00	0.0	0	0	0	0	1
08/25/2020 02:00	0.0	0	0	0	0	1
08/25/2020 03:00	0.0	0	0	0	0	1
08/25/2020 04:00	0.0	0	0	0	0	1
08/25/2020 05:00	0.0	0	0	0	0	1
08/25/2020 06:00	0.0	0	0	0	0	1
08/25/2020 07:00	0.0	0	0	0	0	1
08/25/2020 08:00	0.0	0	0	0	0	1
08/25/2020 09:00	0.0	0	0	0	0	1
08/25/2020 10:00	0.0	0	0	0	0	1
08/25/2020 11:00	0.0	0	0	0	0	1
08/25/2020 12:00	0.0	0	0	0	0	1
08/25/2020 13:00	0.0	0	0	0	0	1
08/25/2020 14:00	0.0	0	0	0	0	1
08/25/2020 15:00	0.0	0	0	0	0	1
08/25/2020 16:00	0.0	0	0	0	0	1
08/25/2020 17:00	0.0	0	0	0	0	1
08/25/2020 18:00	0.0	0	0	0	0	1
08/25/2020 19:00	0.0	0	0	0	0	1
08/25/2020 20:00	0.0	0	0	0	0	1
08/25/2020 21:00	0.0	0	0	0	0	1
08/25/2020 22:00	0.0	0	0	0	0	1
08/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/26/2020 00:00	0.0	0	0	0	0	1
08/26/2020 01:00	0.0	0	0	0	0	1
08/26/2020 02:00	0.0	0	0	0	0	1
08/26/2020 03:00	0.0	0	0	0	0	1
08/26/2020 04:00	0.0	0	0	0	0	1
08/26/2020 05:00	0.0	0	0	0	0	1
08/26/2020 06:00	0.0	0	0	0	0	1
08/26/2020 07:00	0.0	0	0	0	0	1
08/26/2020 08:00	0.0	0	0	0	0	1
08/26/2020 09:00	0.0	0	0	0	0	1
08/26/2020 10:00	0.0	0	0	0	0	1
08/26/2020 11:00	0.0	0	0	0	0	1
08/26/2020 12:00	0.0	0	0	0	0	1
08/26/2020 13:00	0.0	0	0	0	0	1
08/26/2020 14:00	0.0	0	0	0	0	1
08/26/2020 15:00	0.0	0	0	0	0	1
08/26/2020 16:00	0.0	0	0	0	0	1
08/26/2020 17:00	0.0	0	0	0	0	1
08/26/2020 18:00	0.0	0	0	0	0	1
08/26/2020 19:00	0.0	0	0	0	0	1
08/26/2020 20:00	0.0	0	0	0	0	1
08/26/2020 21:00	0.0	0	0	0	0	1
08/26/2020 22:00	0.0	0	0	0	0	1
08/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/27/2020 00:00	0.0	0	0	0	0	1
08/27/2020 01:00	0.0	0	0	0	0	1
08/27/2020 02:00	0.0	0	0	0	0	1
08/27/2020 03:00	0.0	0	0	0	0	1
08/27/2020 04:00	0.0	0	0	0	0	1
08/27/2020 05:00	0.0	0	0	0	0	1
08/27/2020 06:00	0.0	0	0	0	0	1
08/27/2020 07:00	0.0	0	0	0	0	1
08/27/2020 08:00	0.0	0	0	0	0	1
08/27/2020 09:00	0.0	0	0	0	0	1
08/27/2020 10:00	0.0	0	0	0	0	1
08/27/2020 11:00	0.0	0	0	0	0	1
08/27/2020 12:00	0.0	0	0	0	0	1
08/27/2020 13:00	0.0	0	0	0	0	1
08/27/2020 14:00	0.0	0	0	0	0	1
08/27/2020 15:00	0.0	0	0	0	0	1
08/27/2020 16:00	0.0	0	0	0	0	1
08/27/2020 17:00	0.0	0	0	0	0	1
08/27/2020 18:00	0.0	0	0	0	0	1
08/27/2020 19:00	0.0	0	0	0	0	1
08/27/2020 20:00	0.0	0	0	0	0	1
08/27/2020 21:00	0.0	0	0	0	0	1
08/27/2020 22:00	0.0	0	0	0	0	1
08/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/28/2020 00:00	0.0	0	0	0	0	1
08/28/2020 01:00	0.0	0	0	0	0	1
08/28/2020 02:00	0.0	0	0	0	0	1
08/28/2020 03:00	0.0	0	0	0	0	1
08/28/2020 04:00	0.0	0	0	0	0	1
08/28/2020 05:00	0.0	0	0	0	0	1
08/28/2020 06:00	0.0	0	0	0	0	1
08/28/2020 07:00	0.0	0	0	0	0	1
08/28/2020 08:00	0.0	0	0	0	0	1
08/28/2020 09:00	0.0	0	0	0	0	1
08/28/2020 10:00	0.0	0	0	0	0	1
08/28/2020 11:00	0.0	0	0	0	0	1
08/28/2020 12:00	0.0	0	0	0	0	1
08/28/2020 13:00	0.0	0	0	0	0	1
08/28/2020 14:00	0.0	0	0	0	0	1
08/28/2020 15:00	0.0	0	0	0	0	1
08/28/2020 16:00	0.0	0	0	0	0	1
08/28/2020 17:00	0.0	0	0	0	0	1
08/28/2020 18:00	0.0	0	0	0	0	1
08/28/2020 19:00	0.0	0	0	0	0	1
08/28/2020 20:00	0.0	0	0	0	0	1
08/28/2020 21:00	0.0	0	0	0	0	1
08/28/2020 22:00	0.0	0	0	0	0	1
08/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/29/2020 00:00	0.0	0	0	0	0	1
08/29/2020 01:00	0.0	0	0	0	0	1
08/29/2020 02:00	0.0	0	0	0	0	1
08/29/2020 03:00	0.0	0	0	0	0	1
08/29/2020 04:00	0.0	0	0	0	0	1
08/29/2020 05:00	0.0	0	0	0	0	1
08/29/2020 06:00	0.0	0	0	0	0	1
08/29/2020 07:00	0.0	0	0	0	0	1
08/29/2020 08:00	0.0	0	0	0	0	1
08/29/2020 09:00	0.0	0	0	0	0	1
08/29/2020 10:00	0.0	0	0	0	0	1
08/29/2020 11:00	0.0	0	0	0	0	1
08/29/2020 12:00	0.0	0	0	0	0	1
08/29/2020 13:00	0.0	0	0	0	0	1
08/29/2020 14:00	0.0	0	0	0	0	1
08/29/2020 15:00	0.0	0	0	0	0	1
08/29/2020 16:00	0.0	0	0	0	0	1
08/29/2020 17:00	0.0	0	0	0	0	1
08/29/2020 18:00	0.0	0	0	0	0	1
08/29/2020 19:00	0.0	0	0	0	0	1
08/29/2020 20:00	0.0	0	0	0	0	1
08/29/2020 21:00	0.0	0	0	0	0	1
08/29/2020 22:00	0.0	0	0	0	0	1
08/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/30/2020 00:00	0.0	0	0	0	0	1
08/30/2020 01:00	0.0	0	0	0	0	1
08/30/2020 02:00	0.0	0	0	0	0	1
08/30/2020 03:00	0.0	0	0	0	0	1
08/30/2020 04:00	0.0	0	0	0	0	1
08/30/2020 05:00	0.0	0	0	0	0	1
08/30/2020 06:00	0.0	0	0	0	0	1
08/30/2020 07:00	0.0	0	0	0	0	1
08/30/2020 08:00	0.0	0	0	0	0	1
08/30/2020 09:00	0.0	0	0	0	0	1
08/30/2020 10:00	0.0	0	0	0	0	1
08/30/2020 11:00	0.0	0	0	0	0	1
08/30/2020 12:00	0.0	0	0	0	0	1
08/30/2020 13:00	0.0	0	0	0	0	1
08/30/2020 14:00	0.0	0	0	0	0	1
08/30/2020 15:00	0.0	0	0	0	0	1
08/30/2020 16:00	0.0	0	0	0	0	1
08/30/2020 17:00	0.0	0	0	0	0	1
08/30/2020 18:00	0.0	0	0	0	0	1
08/30/2020 19:00	0.0	0	0	0	0	1
08/30/2020 20:00	0.0	0	0	0	0	1
08/30/2020 21:00	0.0	0	0	0	0	1
08/30/2020 22:00	0.0	0	0	0	0	1
08/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/31/2020 00:00	0.0	0	0	0	0	1
08/31/2020 01:00	0.0	0	0	0	0	1
08/31/2020 02:00	0.0	0	0	0	0	1
08/31/2020 03:00	0.0	0	0	0	0	1
08/31/2020 04:00	0.0	0	0	0	0	1
08/31/2020 05:00	0.0	0	0	0	0	1
08/31/2020 06:00	0.0	0	0	0	0	1
08/31/2020 07:00	0.0	0	0	0	0	1
08/31/2020 08:00	0.0	0	0	0	0	1
08/31/2020 09:00	0.0	0	0	0	0	1
08/31/2020 10:00	0.0	0	0	0	0	1
08/31/2020 11:00	0.0	0	0	0	0	1
08/31/2020 12:00	0.0	0	0	0	0	1
08/31/2020 13:00	0.0	0	0	0	0	1
08/31/2020 14:00	0.0	0	0	0	0	1
08/31/2020 15:00	0.0	0	0	0	0	1
08/31/2020 16:00	0.0	0	0	0	0	1
08/31/2020 17:00	0.0	0	0	0	0	1
08/31/2020 18:00	0.0	0	0	0	0	1
08/31/2020 19:00	0.0	0	0	0	0	1
08/31/2020 20:00	0.0	0	0	0	0	1
08/31/2020 21:00	0.0	0	0	0	0	1
08/31/2020 22:00	0.0	0	0	0	0	1
08/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/01/2020 00:00	0.0	0	0	0	0	1
09/01/2020 01:00	0.0	0	0	0	0	1
09/01/2020 02:00	0.0	0	0	0	0	1
09/01/2020 03:00	0.0	0	0	0	0	1
09/01/2020 04:00	0.0	0	0	0	0	1
09/01/2020 05:00	0.0	0	0	0	0	1
09/01/2020 06:00	0.0	0	0	0	0	1
09/01/2020 07:00	0.0	0	0	0	0	1
09/01/2020 08:00	0.0	0	0	0	0	1
09/01/2020 09:00	0.0	0	0	0	0	1
09/01/2020 10:00	0.0	0	0	0	0	1
09/01/2020 11:00	0.0	0	0	0	0	1
09/01/2020 12:00	0.0	0	0	0	0	1
09/01/2020 13:00	0.0	0	0	0	0	1
09/01/2020 14:00	0.0	0	0	0	0	1
09/01/2020 15:00	0.0	0	0	0	0	1
09/01/2020 16:00	0.0	0	0	0	0	1
09/01/2020 17:00	0.0	0	0	0	0	1
09/01/2020 18:00	0.0	0	0	0	0	1
09/01/2020 19:00	0.0	0	0	0	0	1
09/01/2020 20:00	0.0	0	0	0	0	1
09/01/2020 21:00	0.0	0	0	0	0	1
09/01/2020 22:00	0.0	0	0	0	0	1
09/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/02/2020 00:00	0.0	0	0	0	0	1
09/02/2020 01:00	0.0	0	0	0	0	1
09/02/2020 02:00	0.0	0	0	0	0	1
09/02/2020 03:00	0.0	0	0	0	0	1
09/02/2020 04:00	0.0	0	0	0	0	1
09/02/2020 05:00	0.0	0	0	0	0	1
09/02/2020 06:00	0.0	0	0	0	0	1
09/02/2020 07:00	0.0	0	0	0	0	1
09/02/2020 08:00	0.0	0	0	0	0	1
09/02/2020 09:00	0.0	0	0	0	0	1
09/02/2020 10:00	0.0	0	0	0	0	1
09/02/2020 11:00	0.0	0	0	0	0	1
09/02/2020 12:00	0.0	0	0	0	0	1
09/02/2020 13:00	0.0	0	0	0	0	1
09/02/2020 14:00	0.0	0	0	0	0	1
09/02/2020 15:00	0.0	0	0	0	0	1
09/02/2020 16:00	0.0	0	0	0	0	1
09/02/2020 17:00	0.0	0	0	0	0	1
09/02/2020 18:00	0.0	0	0	0	0	1
09/02/2020 19:00	0.0	0	0	0	0	1
09/02/2020 20:00	0.0	0	0	0	0	1
09/02/2020 21:00	0.0	0	0	0	0	1
09/02/2020 22:00	0.0	0	0	0	0	1
09/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/03/2020 00:00	0.0	0	0	0	0	1
09/03/2020 01:00	0.0	0	0	0	0	1
09/03/2020 02:00	0.0	0	0	0	0	1
09/03/2020 03:00	0.0	0	0	0	0	1
09/03/2020 04:00	0.0	0	0	0	0	1
09/03/2020 05:00	0.0	0	0	0	0	1
09/03/2020 06:00	0.0	0	0	0	0	1
09/03/2020 07:00	0.0	0	0	0	0	1
09/03/2020 08:00	0.0	0	0	0	0	1
09/03/2020 09:00	0.0	0	0	0	0	1
09/03/2020 10:00	0.0	0	0	0	0	1
09/03/2020 11:00	0.0	0	0	0	0	1
09/03/2020 12:00	0.0	0	0	0	0	1
09/03/2020 13:00	0.0	0	0	0	0	1
09/03/2020 14:00	0.0	0	0	0	0	1
09/03/2020 15:00	0.0	0	0	0	0	1
09/03/2020 16:00	0.0	0	0	0	0	1
09/03/2020 17:00	0.0	0	0	0	0	1
09/03/2020 18:00	0.0	0	0	0	0	1
09/03/2020 19:00	0.0	0	0	0	0	1
09/03/2020 20:00	0.0	0	0	0	0	1
09/03/2020 21:00	0.0	0	0	0	0	1
09/03/2020 22:00	0.0	0	0	0	0	1
09/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/04/2020 00:00	0.0	0	0	0	0	1
09/04/2020 01:00	0.0	0	0	0	0	1
09/04/2020 02:00	0.0	0	0	0	0	1
09/04/2020 03:00	0.0	0	0	0	0	1
09/04/2020 04:00	0.0	0	0	0	0	1
09/04/2020 05:00	0.0	0	0	0	0	1
09/04/2020 06:00	0.0	0	0	0	0	1
09/04/2020 07:00	0.0	0	0	0	0	1
09/04/2020 08:00	0.0	0	0	0	0	1
09/04/2020 09:00	0.0	0	0	0	0	1
09/04/2020 10:00	0.0	0	0	0	0	1
09/04/2020 11:00	0.0	0	0	0	0	1
09/04/2020 12:00	0.0	0	0	0	0	1
09/04/2020 13:00	0.0	0	0	0	0	1
09/04/2020 14:00	0.0	0	0	0	0	1
09/04/2020 15:00	0.0	0	0	0	0	1
09/04/2020 16:00	0.0	0	0	0	0	1
09/04/2020 17:00	0.0	0	0	0	0	1
09/04/2020 18:00	0.0	0	0	0	0	1
09/04/2020 19:00	0.0	0	0	0	0	1
09/04/2020 20:00	0.0	0	0	0	0	1
09/04/2020 21:00	0.0	0	0	0	0	1
09/04/2020 22:00	0.0	0	0	0	0	1
09/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/05/2020 00:00	0.0	0	0	0	0	1
09/05/2020 01:00	0.0	0	0	0	0	1
09/05/2020 02:00	0.0	0	0	0	0	1
09/05/2020 03:00	0.0	0	0	0	0	1
09/05/2020 04:00	0.0	0	0	0	0	1
09/05/2020 05:00	0.0	0	0	0	0	1
09/05/2020 06:00	0.0	0	0	0	0	1
09/05/2020 07:00	0.0	0	0	0	0	1
09/05/2020 08:00	0.0	0	0	0	0	1
09/05/2020 09:00	0.0	0	0	0	0	1
09/05/2020 10:00	0.0	0	0	0	0	1
09/05/2020 11:00	0.0	0	0	0	0	1
09/05/2020 12:00	0.0	0	0	0	0	1
09/05/2020 13:00	0.0	0	0	0	0	1
09/05/2020 14:00	0.0	0	0	0	0	1
09/05/2020 15:00	0.0	0	0	0	0	1
09/05/2020 16:00	0.0	0	0	0	0	1
09/05/2020 17:00	0.0	0	0	0	0	1
09/05/2020 18:00	0.0	0	0	0	0	1
09/05/2020 19:00	0.0	0	0	0	0	1
09/05/2020 20:00	0.0	0	0	0	0	1
09/05/2020 21:00	0.0	0	0	0	0	1
09/05/2020 22:00	0.0	0	0	0	0	1
09/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/06/2020 00:00	0.0	0	0	0	0	1
09/06/2020 01:00	0.0	0	0	0	0	1
09/06/2020 02:00	0.0	0	0	0	0	1
09/06/2020 03:00	0.0	0	0	0	0	1
09/06/2020 04:00	0.0	0	0	0	0	1
09/06/2020 05:00	0.0	0	0	0	0	1
09/06/2020 06:00	0.0	0	0	0	0	1
09/06/2020 07:00	0.0	0	0	0	0	1
09/06/2020 08:00	0.0	0	0	0	0	1
09/06/2020 09:00	0.0	0	0	0	0	1
09/06/2020 10:00	0.0	0	0	0	0	1
09/06/2020 11:00	0.0	0	0	0	0	1
09/06/2020 12:00	0.0	0	0	0	0	1
09/06/2020 13:00	0.0	0	0	0	0	1
09/06/2020 14:00	0.0	0	0	0	0	1
09/06/2020 15:00	0.0	0	0	0	0	1
09/06/2020 16:00	0.0	0	0	0	0	1
09/06/2020 17:00	0.0	0	0	0	0	1
09/06/2020 18:00	0.0	0	0	0	0	1
09/06/2020 19:00	0.0	0	0	0	0	1
09/06/2020 20:00	0.0	0	0	0	0	1
09/06/2020 21:00	0.0	0	0	0	0	1
09/06/2020 22:00	0.0	0	0	0	0	1
09/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/07/2020 00:00	0.0	0	0	0	0	1
09/07/2020 01:00	0.0	0	0	0	0	1
09/07/2020 02:00	0.0	0	0	0	0	1
09/07/2020 03:00	0.0	0	0	0	0	1
09/07/2020 04:00	0.0	0	0	0	0	1
09/07/2020 05:00	0.0	0	0	0	0	1
09/07/2020 06:00	0.0	0	0	0	0	1
09/07/2020 07:00	0.0	0	0	0	0	1
09/07/2020 08:00	0.0	0	0	0	0	1
09/07/2020 09:00	0.0	0	0	0	0	1
09/07/2020 10:00	0.0	0	0	0	0	1
09/07/2020 11:00	0.0	0	0	0	0	1
09/07/2020 12:00	0.0	0	0	0	0	1
09/07/2020 13:00	0.0	0	0	0	0	1
09/07/2020 14:00	0.0	0	0	0	0	1
09/07/2020 15:00	0.0	0	0	0	0	1
09/07/2020 16:00	0.0	0	0	0	0	1
09/07/2020 17:00	0.0	0	0	0	0	1
09/07/2020 18:00	0.0	0	0	0	0	1
09/07/2020 19:00	0.0	0	0	0	0	1
09/07/2020 20:00	0.0	0	0	0	0	1
09/07/2020 21:00	0.0	0	0	0	0	1
09/07/2020 22:00	0.0	0	0	0	0	1
09/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/08/2020 00:00	0.0	0	0	0	0	1
09/08/2020 01:00	0.0	0	0	0	0	1
09/08/2020 02:00	0.0	0	0	0	0	1
09/08/2020 03:00	0.0	0	0	0	0	1
09/08/2020 04:00	0.0	0	0	0	0	1
09/08/2020 05:00	0.0	0	0	0	0	1
09/08/2020 06:00	0.0	0	0	0	0	1
09/08/2020 07:00	0.0	0	0	0	0	1
09/08/2020 08:00	0.0	0	0	0	0	1
09/08/2020 09:00	0.0	0	0	0	0	1
09/08/2020 10:00	0.0	0	0	0	0	1
09/08/2020 11:00	0.0	0	0	0	0	1
09/08/2020 12:00	0.0	0	0	0	0	1
09/08/2020 13:00	0.0	0	0	0	0	1
09/08/2020 14:00	0.0	0	0	0	0	1
09/08/2020 15:00	0.0	0	0	0	0	1
09/08/2020 16:00	0.0	0	0	0	0	1
09/08/2020 17:00	0.0	0	0	0	0	1
09/08/2020 18:00	0.0	0	0	0	0	1
09/08/2020 19:00	0.0	0	0	0	0	1
09/08/2020 20:00	0.0	0	0	0	0	1
09/08/2020 21:00	0.0	0	0	0	0	1
09/08/2020 22:00	0.0	0	0	0	0	1
09/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/09/2020 00:00	0.0	0	0	0	0	1
09/09/2020 01:00	0.0	0	0	0	0	1
09/09/2020 02:00	0.0	0	0	0	0	1
09/09/2020 03:00	0.0	0	0	0	0	1
09/09/2020 04:00	0.0	0	0	0	0	1
09/09/2020 05:00	0.0	0	0	0	0	1
09/09/2020 06:00	0.0	0	0	0	0	1
09/09/2020 07:00	0.0	0	0	0	0	1
09/09/2020 08:00	0.0	0	0	0	0	1
09/09/2020 09:00	0.0	0	0	0	0	1
09/09/2020 10:00	0.0	0	0	0	0	1
09/09/2020 11:00	0.0	0	0	0	0	1
09/09/2020 12:00	0.0	0	0	0	0	1
09/09/2020 13:00	0.0	0	0	0	0	1
09/09/2020 14:00	0.0	0	0	0	0	1
09/09/2020 15:00	0.0	0	0	0	0	1
09/09/2020 16:00	0.0	0	0	0	0	1
09/09/2020 17:00	0.0	0	0	0	0	1
09/09/2020 18:00	0.0	0	0	0	0	1
09/09/2020 19:00	0.0	0	0	0	0	1
09/09/2020 20:00	0.0	0	0	0	0	1
09/09/2020 21:00	0.0	0	0	0	0	1
09/09/2020 22:00	0.0	0	0	0	0	1
09/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/10/2020 00:00	0.0	0	0	0	0	1
09/10/2020 01:00	0.0	0	0	0	0	1
09/10/2020 02:00	0.0	0	0	0	0	1
09/10/2020 03:00	0.0	0	0	0	0	1
09/10/2020 04:00	0.0	0	0	0	0	1
09/10/2020 05:00	0.0	0	0	0	0	1
09/10/2020 06:00	0.0	0	0	0	0	1
09/10/2020 07:00	0.0	0	0	0	0	1
09/10/2020 08:00	0.0	0	0	0	0	1
09/10/2020 09:00	0.0	0	0	0	0	1
09/10/2020 10:00	0.0	0	0	0	0	1
09/10/2020 11:00	0.0	0	0	0	0	1
09/10/2020 12:00	0.0	0	0	0	0	1
09/10/2020 13:00	0.0	0	0	0	0	1
09/10/2020 14:00	0.0	0	0	0	0	1
09/10/2020 15:00	0.0	0	0	0	0	1
09/10/2020 16:00	0.0	0	0	0	0	1
09/10/2020 17:00	0.0	0	0	0	0	1
09/10/2020 18:00	0.0	0	0	0	0	1
09/10/2020 19:00	0.0	0	0	0	0	1
09/10/2020 20:00	0.0	0	0	0	0	1
09/10/2020 21:00	0.0	0	0	0	0	1
09/10/2020 22:00	0.0	0	0	0	0	1
09/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/11/2020 00:00	0.0	0	0	0	0	1
09/11/2020 01:00	0.0	0	0	0	0	1
09/11/2020 02:00	0.0	0	0	0	0	1
09/11/2020 03:00	0.0	0	0	0	0	1
09/11/2020 04:00	0.0	0	0	0	0	1
09/11/2020 05:00	0.0	0	0	0	0	1
09/11/2020 06:00	0.0	0	0	0	0	1
09/11/2020 07:00	0.0	0	0	0	0	1
09/11/2020 08:00	0.0	0	0	0	0	1
09/11/2020 09:00	0.0	0	0	0	0	1
09/11/2020 10:00	0.0	0	0	0	0	1
09/11/2020 11:00	0.0	0	0	0	0	1
09/11/2020 12:00	0.0	0	0	0	0	1
09/11/2020 13:00	0.0	0	0	0	0	1
09/11/2020 14:00	0.0	0	0	0	0	1
09/11/2020 15:00	0.0	0	0	0	0	1
09/11/2020 16:00	0.0	0	0	0	0	1
09/11/2020 17:00	0.0	0	0	0	0	1
09/11/2020 18:00	0.0	0	0	0	0	1
09/11/2020 19:00	0.0	0	0	0	0	1
09/11/2020 20:00	0.0	0	0	0	0	1
09/11/2020 21:00	0.0	0	0	0	0	1
09/11/2020 22:00	0.0	0	0	0	0	1
09/11/2020 23:00	2.2	0	0	0	1	0
Average/Sum#:	2.2 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/12/2020 00:00	0.0	0	0	0	0	0
09/12/2020 01:00	0.0	0	0	0	0	0
09/12/2020 02:00	0.0	0	0	0	0	0
09/12/2020 03:00	0.0	0	0	0	0	0
09/12/2020 04:00	0.0	0	0	0	0	0
09/12/2020 05:00	0.0	0	0	0	0	0
09/12/2020 06:00	0.0	0	0	0	0	0
09/12/2020 07:00	0.0	0	0	0	0	0
09/12/2020 08:00	0.0	0	0	0	0	0
09/12/2020 09:00	0.0	0	0	0	0	0
09/12/2020 10:00	0.0	0	0	0	0	0
09/12/2020 11:00	0.0	0	0	0	0	0
09/12/2020 12:00	0.0	0	0	0	0	0
09/12/2020 13:00	0.0	0	0	0	0	0
09/12/2020 14:00	0.0	0	0	0	0	0
09/12/2020 15:00	0.0	0	0	0	0	0
09/12/2020 16:00	0.0	0	0	0	0	0
09/12/2020 17:00	0.0	0	0	0	0	0
09/12/2020 18:00	0.0	0	0	0	0	0
09/12/2020 19:00	0.0	0	0	0	0	0
09/12/2020 20:00	0.0	0	0	0	0	0
09/12/2020 21:00	0.0	0	0	0	0	0
09/12/2020 22:00	0.0	0	0	0	0	0
09/12/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/13/2020 00:00	0.0	0	0	0	0	0
09/13/2020 01:00	0.0	0	0	0	0	0
09/13/2020 02:00	0.0	0	0	0	0	0
09/13/2020 03:00	0.0	0	0	0	0	0
09/13/2020 04:00	0.0	0	0	0	0	0
09/13/2020 05:00	0.0	0	0	0	0	0
09/13/2020 06:00	0.0	0	0	0	0	0
09/13/2020 07:00	0.0	0	0	0	0	0
09/13/2020 08:00	0.0	0	0	0	0	0
09/13/2020 09:00	0.0	0	0	0	0	0
09/13/2020 10:00	0.0	0	0	0	0	0
09/13/2020 11:00	0.0	0	0	0	0	0
09/13/2020 12:00	0.0	0	0	0	0	0
09/13/2020 13:00	0.0	0	0	0	0	0
09/13/2020 14:00	0.0	0	0	0	0	0
09/13/2020 15:00	0.0	0	0	0	0	0
09/13/2020 16:00	0.0	0	0	0	0	0
09/13/2020 17:00	0.0	0	0	0	0	0
09/13/2020 18:00	0.0	0	0	0	0	0
09/13/2020 19:00	0.0	0	0	0	0	0
09/13/2020 20:00	0.0	0	0	0	0	0
09/13/2020 21:00	0.0	0	0	0	0	0
09/13/2020 22:00	0.0	0	0	0	0	0
09/13/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/14/2020 00:00	0.0	0	0	0	0	0
09/14/2020 01:00	0.0	0	0	0	0	0
09/14/2020 02:00	0.0	0	0	0	0	0
09/14/2020 03:00	0.0	0	0	0	0	0
09/14/2020 04:00	0.0	0	0	0	0	0
09/14/2020 05:00	0.0	0	0	0	0	0
09/14/2020 06:00	0.0	0	0	0	0	0
09/14/2020 07:00	0.0	0	0	0	0	0
09/14/2020 08:00	0.0	0	0	0	0	0
09/14/2020 09:00	0.0	0	0	0	0	0
09/14/2020 10:00	0.0	0	0	0	0	0
09/14/2020 11:00	0.0	0	0	0	0	0
09/14/2020 12:00	0.0	0	0	0	0	0
09/14/2020 13:00	79.6	0	1	0	0	0
09/14/2020 14:00	59.5	0	1	0	0	0
09/14/2020 15:00	1.0	0	1	0	0	0
09/14/2020 16:00	0.0	0	0	0	0	1
09/14/2020 17:00	0.0	0	0	0	0	1
09/14/2020 18:00	0.0	0	0	0	0	1
09/14/2020 19:00	0.0	0	0	0	0	1
09/14/2020 20:00	0.0	0	0	0	0	1
09/14/2020 21:00	0.0	0	0	0	0	1
09/14/2020 22:00	0.0	0	0	0	0	1
09/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	140.1 #	0 #	3 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	79.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/15/2020 00:00	0.0	0	0	0	0	1
09/15/2020 01:00	0.0	0	0	0	0	1
09/15/2020 02:00	0.0	0	0	0	0	1
09/15/2020 03:00	0.0	0	0	0	0	1
09/15/2020 04:00	0.0	0	0	0	0	1
09/15/2020 05:00	0.0	0	0	0	0	1
09/15/2020 06:00	0.0	0	0	0	0	1
09/15/2020 07:00	0.0	0	0	0	0	1
09/15/2020 08:00	0.0	0	0	0	0	1
09/15/2020 09:00	0.0	0	0	0	0	1
09/15/2020 10:00	0.0	0	0	0	0	1
09/15/2020 11:00	0.0	0	0	0	0	1
09/15/2020 12:00	0.0	0	0	0	0	1
09/15/2020 13:00	0.0	0	0	0	0	1
09/15/2020 14:00	0.0	0	0	0	0	1
09/15/2020 15:00	0.0	0	0	0	0	1
09/15/2020 16:00	0.0	0	0	0	0	1
09/15/2020 17:00	0.0	0	0	0	0	1
09/15/2020 18:00	0.0	0	0	0	0	1
09/15/2020 19:00	0.0	0	0	0	0	1
09/15/2020 20:00	0.0	0	0	0	0	1
09/15/2020 21:00	0.0	0	0	0	0	1
09/15/2020 22:00	0.4	0	0	0	1	0
09/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.4 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/16/2020 00:00	0.0	0	0	0	0	0
09/16/2020 01:00	0.0	0	0	0	0	0
09/16/2020 02:00	0.0	0	0	0	0	0
09/16/2020 03:00	0.0	0	0	0	0	0
09/16/2020 04:00	0.0	0	0	0	0	0
09/16/2020 05:00	0.0	0	0	0	0	0
09/16/2020 06:00	17.4	0	1	0	0	0
09/16/2020 07:00	24.1	0	1	0	0	0
09/16/2020 08:00	0.0	0	0	0	0	1
09/16/2020 09:00	0.0	0	0	0	0	1
09/16/2020 10:00	0.0	0	0	0	0	1
09/16/2020 11:00	0.0	0	0	0	0	1
09/16/2020 12:00	0.0	0	0	0	0	1
09/16/2020 13:00	0.0	0	0	0	0	1
09/16/2020 14:00	0.0	0	0	0	0	1
09/16/2020 15:00	0.0	0	0	0	0	1
09/16/2020 16:00	0.0	0	0	0	0	1
09/16/2020 17:00	0.0	0	0	0	0	1
09/16/2020 18:00	0.0	0	0	0	0	1
09/16/2020 19:00	0.0	0	0	0	0	1
09/16/2020 20:00	0.0	0	0	0	0	1
09/16/2020 21:00	0.0	0	0	0	0	1
09/16/2020 22:00	0.0	0	0	0	0	1
09/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	41.5 #	0 #	2 #	0 #	0 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	24.1	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/17/2020 00:00	0.0	0	0	0	0	1
09/17/2020 01:00	0.0	0	0	0	0	1
09/17/2020 02:00	0.0	0	0	0	0	1
09/17/2020 03:00	0.0	0	0	0	0	1
09/17/2020 04:00	0.0	0	0	0	0	1
09/17/2020 05:00	0.0	0	0	0	0	1
09/17/2020 06:00	0.0	0	0	0	0	1
09/17/2020 07:00	0.0	0	0	0	0	1
09/17/2020 08:00	0.0	0	0	0	0	1
09/17/2020 09:00	0.0	0	0	0	0	1
09/17/2020 10:00	0.0	0	0	0	0	1
09/17/2020 11:00	0.0	0	0	0	0	1
09/17/2020 12:00	0.0	0	0	0	0	1
09/17/2020 13:00	0.0	0	0	0	0	1
09/17/2020 14:00	0.0	0	0	0	0	1
09/17/2020 15:00	0.0	0	0	0	0	1
09/17/2020 16:00	0.0	0	0	0	0	1
09/17/2020 17:00	0.0	0	0	0	0	1
09/17/2020 18:00	0.0	0	0	0	0	1
09/17/2020 19:00	0.0	0	0	0	0	1
09/17/2020 20:00	0.0	0	0	0	0	1
09/17/2020 21:00	0.0	0	0	0	0	1
09/17/2020 22:00	0.0	0	0	0	0	1
09/17/2020 23:00	0.4	0	0	0	1	0
Average/Sum#:	0.4 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/18/2020 00:00	0.0	0	0	0	1	0
09/18/2020 01:00	0.0	0	0	0	0	0
09/18/2020 02:00	0.0	0	0	0	0	0
09/18/2020 03:00	0.0	0	0	0	0	0
09/18/2020 04:00	0.0	0	0	0	0	0
09/18/2020 05:00	0.0	0	0	0	0	0
09/18/2020 06:00	13.4	0	0	1	0	0
09/18/2020 07:00	38.4	0	0	1	0	0
09/18/2020 08:00	0.0	0	0	0	0	1
09/18/2020 09:00	0.0	0	0	0	0	1
09/18/2020 10:00	0.0	0	0	0	0	1
09/18/2020 11:00	0.0	0	0	0	0	1
09/18/2020 12:00	0.0	0	0	0	0	1
09/18/2020 13:00	0.0	0	0	0	0	1
09/18/2020 14:00	0.0	0	0	0	0	1
09/18/2020 15:00	0.0	0	0	0	0	1
09/18/2020 16:00	0.0	0	0	0	0	1
09/18/2020 17:00	0.0	0	0	0	0	1
09/18/2020 18:00	0.0	0	0	0	0	1
09/18/2020 19:00	0.0	0	0	0	0	1
09/18/2020 20:00	0.0	0	0	0	0	1
09/18/2020 21:00	0.0	0	0	0	0	1
09/18/2020 22:00	1.5	0	0	0	1	0
09/18/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	53.3 #	0 #	0 #	2 #	2 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	38.4	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/19/2020 00:00	0.0	0	0	0	0	0
09/19/2020 01:00	0.0	0	0	0	0	0
09/19/2020 02:00	0.0	0	0	0	0	0
09/19/2020 03:00	0.0	0	0	0	0	0
09/19/2020 04:00	6.8	0	0	1	0	0
09/19/2020 05:00	49.0	0	0	1	0	0
09/19/2020 06:00	0.0	0	0	0	0	1
09/19/2020 07:00	0.0	0	0	0	0	1
09/19/2020 08:00	0.0	0	0	0	0	1
09/19/2020 09:00	0.0	0	0	0	0	1
09/19/2020 10:00	0.0	0	0	0	0	1
09/19/2020 11:00	0.0	0	0	0	0	1
09/19/2020 12:00	0.0	0	0	0	0	1
09/19/2020 13:00	0.0	0	0	0	0	1
09/19/2020 14:00	0.0	0	0	0	0	1
09/19/2020 15:00	0.0	0	0	0	0	1
09/19/2020 16:00	0.0	0	0	0	0	1
09/19/2020 17:00	0.0	0	0	0	0	1
09/19/2020 18:00	0.0	0	0	0	0	1
09/19/2020 19:00	0.0	0	0	0	0	1
09/19/2020 20:00	0.0	0	0	0	0	1
09/19/2020 21:00	0.0	0	0	0	0	1
09/19/2020 22:00	0.0	0	0	0	0	1
09/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	55.8 #	0 #	0 #	2 #	0 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	49.0	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/20/2020 00:00	0.0	0	0	0	0	1
09/20/2020 01:00	0.0	0	0	0	0	1
09/20/2020 02:00	0.0	0	0	0	0	1
09/20/2020 03:00	0.0	0	0	0	0	1
09/20/2020 04:00	0.0	0	0	0	0	1
09/20/2020 05:00	0.0	0	0	0	0	1
09/20/2020 06:00	2.1	0	0	0	1	0
09/20/2020 07:00	0.0	0	0	0	0	0
09/20/2020 08:00	0.0	0	0	0	0	0
09/20/2020 09:00	0.0	0	0	0	0	0
09/20/2020 10:00	10.4	0	0	1	0	0
09/20/2020 11:00	22.5	0	0	1	0	0
09/20/2020 12:00	0.0	0	0	0	0	1
09/20/2020 13:00	0.0	0	0	0	0	1
09/20/2020 14:00	0.0	0	0	0	0	1
09/20/2020 15:00	0.0	0	0	0	0	1
09/20/2020 16:00	0.0	0	0	0	0	1
09/20/2020 17:00	0.0	0	0	0	0	1
09/20/2020 18:00	0.0	0	0	0	0	1
09/20/2020 19:00	0.0	0	0	0	0	1
09/20/2020 20:00	0.0	0	0	0	0	1
09/20/2020 21:00	0.0	0	0	0	0	1
09/20/2020 22:00	2.4	0	0	0	1	0
09/20/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	37.4 #	0 #	0 #	2 #	2 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	22.5	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/21/2020 00:00	0.0	0	0	0	0	0
09/21/2020 01:00	0.0	0	0	0	0	0
09/21/2020 02:00	0.0	0	0	0	0	0
09/21/2020 03:00	0.0	0	0	0	0	0
09/21/2020 04:00	0.0	0	0	0	0	0
09/21/2020 05:00	0.0	0	0	0	0	0
09/21/2020 06:00	0.0	0	0	0	0	0
09/21/2020 07:00	0.0	0	0	0	0	0
09/21/2020 08:00	0.0	0	0	0	0	0
09/21/2020 09:00	0.0	0	0	0	0	0
09/21/2020 10:00	0.0	0	0	0	0	0
09/21/2020 11:00	0.0	0	0	0	0	0
09/21/2020 12:00	0.0	0	0	0	0	0
09/21/2020 13:00	49.8	0	1	0	0	0
09/21/2020 14:00	45.3	0	1	0	0	0
09/21/2020 15:00	0.0	0	0	0	0	1
09/21/2020 16:00	0.0	0	0	0	0	1
09/21/2020 17:00	0.0	0	0	0	0	1
09/21/2020 18:00	0.0	0	0	0	0	1
09/21/2020 19:00	0.0	0	0	0	0	1
09/21/2020 20:00	0.0	0	0	0	0	1
09/21/2020 21:00	0.0	0	0	0	0	1
09/21/2020 22:00	2.1	0	0	0	1	0
09/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	97.2 #	0 #	2 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	49.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/22/2020 00:00	0.0	0	0	0	0	0
09/22/2020 01:00	0.0	0	0	0	0	0
09/22/2020 02:00	0.0	0	0	0	0	0
09/22/2020 03:00	0.0	0	0	0	0	0
09/22/2020 04:00	0.0	0	0	0	0	0
09/22/2020 05:00	0.0	0	0	0	0	0
09/22/2020 06:00	0.0	0	0	0	0	0
09/22/2020 07:00	0.0	0	0	0	0	0
09/22/2020 08:00	0.0	0	0	0	0	0
09/22/2020 09:00	0.0	0	0	0	0	0
09/22/2020 10:00	0.0	0	0	0	0	0
09/22/2020 11:00	0.0	0	0	0	0	0
09/22/2020 12:00	0.0	0	0	0	0	0
09/22/2020 13:00	0.0	0	0	0	0	0
09/22/2020 14:00	54.1	0	1	0	0	0
09/22/2020 15:00	45.9	0	1	0	0	0
09/22/2020 16:00	0.0	0	0	0	0	1
09/22/2020 17:00	0.0	0	0	0	0	1
09/22/2020 18:00	0.0	0	0	0	0	1
09/22/2020 19:00	0.0	0	0	0	0	1
09/22/2020 20:00	0.0	0	0	0	0	1
09/22/2020 21:00	1.9	0	0	0	1	0
09/22/2020 22:00	0.0	0	0	0	0	0
09/22/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	101.9 #	0 #	2 #	0 #	1 #	5 #
Minimum:	0.0	0	0	0	0	0
Maximum:	54.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/23/2020 00:00	0.0	0	0	0	0	0
09/23/2020 01:00	0.0	0	0	0	0	0
09/23/2020 02:00	0.0	0	0	0	0	0
09/23/2020 03:00	0.0	0	0	0	0	0
09/23/2020 04:00	0.0	0	0	0	0	0
09/23/2020 05:00	0.0	0	0	0	0	0
09/23/2020 06:00	0.0	0	0	0	0	0
09/23/2020 07:00	0.0	0	0	0	0	0
09/23/2020 08:00	0.0	0	0	0	0	0
09/23/2020 09:00	0.0	0	0	0	0	0
09/23/2020 10:00	0.0	0	0	0	0	0
09/23/2020 11:00	0.0	0	0	0	0	0
09/23/2020 12:00	0.0	0	0	0	0	0
09/23/2020 13:00	49.9	0	1	0	0	0
09/23/2020 14:00	47.8	0	1	0	0	0
09/23/2020 15:00	0.0	0	0	0	0	1
09/23/2020 16:00	0.0	0	0	0	0	1
09/23/2020 17:00	0.0	0	0	0	0	1
09/23/2020 18:00	0.0	0	0	0	0	1
09/23/2020 19:00	0.0	0	0	0	0	1
09/23/2020 20:00	0.0	0	0	0	0	1
09/23/2020 21:00	2.2	0	0	0	1	0
09/23/2020 22:00	0.0	0	0	0	0	0
09/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	99.9 #	0 #	2 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	49.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/24/2020 00:00	0.0	0	0	0	0	0
09/24/2020 01:00	0.0	0	0	0	0	0
09/24/2020 02:00	0.0	0	0	0	0	0
09/24/2020 03:00	0.0	0	0	0	0	0
09/24/2020 04:00	0.0	0	0	0	0	0
09/24/2020 05:00	0.0	0	0	0	0	0
09/24/2020 06:00	0.0	0	0	0	0	0
09/24/2020 07:00	0.0	0	0	0	0	0
09/24/2020 08:00	29.3	0	1	0	0	0
09/24/2020 09:00	34.0	0	1	0	0	0
09/24/2020 10:00	37.9	0	1	0	0	0
09/24/2020 11:00	0.0	0	0	0	0	1
09/24/2020 12:00	0.0	0	0	0	0	1
09/24/2020 13:00	0.0	0	0	0	0	1
09/24/2020 14:00	0.0	0	0	0	0	1
09/24/2020 15:00	0.0	0	0	0	0	1
09/24/2020 16:00	0.0	0	0	0	0	1
09/24/2020 17:00	0.0	0	0	0	0	1
09/24/2020 18:00	0.0	0	0	0	0	1
09/24/2020 19:00	0.0	0	0	0	0	1
09/24/2020 20:00	2.2	0	0	0	1	0
09/24/2020 21:00	0.0	0	0	0	0	0
09/24/2020 22:00	0.0	0	0	0	0	0
09/24/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	103.4 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	37.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/25/2020 00:00	0.0	0	0	0	0	0
09/25/2020 01:00	0.0	0	0	0	0	0
09/25/2020 02:00	0.0	0	0	0	0	0
09/25/2020 03:00	0.0	0	0	0	0	0
09/25/2020 04:00	0.0	0	0	0	0	0
09/25/2020 05:00	0.0	0	0	0	0	0
09/25/2020 06:00	0.0	0	0	0	0	0
09/25/2020 07:00	0.0	0	0	0	0	0
09/25/2020 08:00	0.0	0	0	0	0	0
09/25/2020 09:00	0.0	0	0	0	0	0
09/25/2020 10:00	0.0	0	0	0	0	0
09/25/2020 11:00	0.0	0	0	0	0	0
09/25/2020 12:00	0.0	0	0	0	0	0
09/25/2020 13:00	0.0	0	0	0	0	0
09/25/2020 14:00	0.0	0	0	0	0	0
09/25/2020 15:00	0.0	0	0	0	0	0
09/25/2020 16:00	0.0	0	0	0	0	0
09/25/2020 17:00	0.0	0	0	0	0	0
09/25/2020 18:00	0.0	0	0	0	0	0
09/25/2020 19:00	0.0	0	0	0	0	0
09/25/2020 20:00	0.0	0	0	0	0	0
09/25/2020 21:00	0.0	0	0	0	0	0
09/25/2020 22:00	0.0	0	0	0	0	0
09/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/26/2020 00:00	0.0	0	0	0	0	0
09/26/2020 01:00	0.0	0	0	0	0	0
09/26/2020 02:00	0.0	0	0	0	0	0
09/26/2020 03:00	0.0	0	0	0	0	0
09/26/2020 04:00	0.0	0	0	0	0	0
09/26/2020 05:00	0.0	0	0	0	0	0
09/26/2020 06:00	0.0	0	0	0	0	0
09/26/2020 07:00	0.0	0	0	0	0	0
09/26/2020 08:00	0.0	0	0	0	0	0
09/26/2020 09:00	0.0	0	0	0	0	0
09/26/2020 10:00	0.0	0	0	0	0	0
09/26/2020 11:00	0.0	0	0	0	0	0
09/26/2020 12:00	0.0	0	0	0	0	0
09/26/2020 13:00	0.0	0	0	0	0	0
09/26/2020 14:00	0.0	0	0	0	0	0
09/26/2020 15:00	0.0	0	0	0	0	0
09/26/2020 16:00	0.0	0	0	0	0	0
09/26/2020 17:00	0.0	0	0	0	0	0
09/26/2020 18:00	0.0	0	0	0	0	0
09/26/2020 19:00	0.0	0	0	0	0	0
09/26/2020 20:00	0.0	0	0	0	0	0
09/26/2020 21:00	0.0	0	0	0	0	0
09/26/2020 22:00	0.0	0	0	0	0	0
09/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/27/2020 00:00	0.0	0	0	0	0	0
09/27/2020 01:00	0.0	0	0	0	0	0
09/27/2020 02:00	0.0	0	0	0	0	0
09/27/2020 03:00	0.0	0	0	0	0	0
09/27/2020 04:00	0.0	0	0	0	0	0
09/27/2020 05:00	0.0	0	0	0	0	0
09/27/2020 06:00	0.0	0	0	0	0	0
09/27/2020 07:00	0.0	0	0	0	0	0
09/27/2020 08:00	22.1	0	1	0	0	0
09/27/2020 09:00	0.0	0	0	0	0	0
09/27/2020 10:00	0.0	0	0	0	0	0
09/27/2020 11:00	0.0	0	0	0	0	0
09/27/2020 12:00	0.0	0	0	0	0	0
09/27/2020 13:00	23.7	0	1	0	0	0
09/27/2020 14:00	51.4	0	1	0	0	0
09/27/2020 15:00	0.4	0	1	0	0	0
09/27/2020 16:00	0.0	0	0	0	0	1
09/27/2020 17:00	0.0	0	0	0	0	1
09/27/2020 18:00	0.0	0	0	0	0	1
09/27/2020 19:00	0.0	0	0	0	0	1
09/27/2020 20:00	0.0	0	0	0	0	1
09/27/2020 21:00	0.0	0	0	0	0	1
09/27/2020 22:00	1.8	0	0	0	1	0
09/27/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	99.4 #	0 #	4 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	51.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/28/2020 00:00	0.0	0	0	0	0	0
09/28/2020 01:00	0.0	0	0	0	0	0
09/28/2020 02:00	0.0	0	0	0	0	0
09/28/2020 03:00	0.0	0	0	0	0	0
09/28/2020 04:00	0.0	0	0	0	0	0
09/28/2020 05:00	0.0	0	0	0	0	0
09/28/2020 06:00	9.4	0	1	0	0	0
09/28/2020 07:00	27.9	0	1	0	0	0
09/28/2020 08:00	0.0	0	0	0	0	1
09/28/2020 09:00	0.0	0	0	0	0	1
09/28/2020 10:00	0.0	0	0	0	0	1
09/28/2020 11:00	0.0	0	0	0	0	1
09/28/2020 12:00	0.0	0	0	0	0	1
09/28/2020 13:00	0.0	0	0	0	0	1
09/28/2020 14:00	0.0	0	0	0	0	1
09/28/2020 15:00	0.0	0	0	0	0	1
09/28/2020 16:00	0.0	0	0	0	0	1
09/28/2020 17:00	0.0	0	0	0	0	1
09/28/2020 18:00	0.0	0	0	0	0	1
09/28/2020 19:00	0.0	0	0	0	0	1
09/28/2020 20:00	0.0	0	0	0	0	1
09/28/2020 21:00	0.0	0	0	0	0	1
09/28/2020 22:00	1.8	0	0	0	1	0
09/28/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	39.1 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	27.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/29/2020 00:00	0.0	0	0	0	0	0
09/29/2020 01:00	0.0	0	0	0	0	0
09/29/2020 02:00	0.0	0	0	0	0	0
09/29/2020 03:00	0.0	0	0	0	0	0
09/29/2020 04:00	0.0	0	0	0	0	0
09/29/2020 05:00	0.0	0	0	0	0	0
09/29/2020 06:00	11.1	0	1	0	0	0
09/29/2020 07:00	38.1	0	1	0	0	0
09/29/2020 08:00	0.0	0	0	0	0	1
09/29/2020 09:00	0.0	0	0	0	0	1
09/29/2020 10:00	0.0	0	0	0	0	1
09/29/2020 11:00	0.0	0	0	0	0	1
09/29/2020 12:00	0.0	0	0	0	0	1
09/29/2020 13:00	0.0	0	0	0	0	1
09/29/2020 14:00	0.0	0	0	0	0	1
09/29/2020 15:00	0.0	0	0	0	0	1
09/29/2020 16:00	0.0	0	0	0	0	1
09/29/2020 17:00	0.0	0	0	0	0	1
09/29/2020 18:00	0.0	0	0	0	0	1
09/29/2020 19:00	0.0	0	0	0	0	1
09/29/2020 20:00	0.0	0	0	0	0	1
09/29/2020 21:00	0.0	0	0	0	0	1
09/29/2020 22:00	0.0	0	0	0	0	1
09/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	49.2 #	0 #	2 #	0 #	0 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	38.1	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:33 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/30/2020 00:00	0.0	0	0	0	0	1
09/30/2020 01:00	0.0	0	0	0	0	1
09/30/2020 02:00	0.0	0	0	0	0	1
09/30/2020 03:00	0.0	0	0	0	0	1
09/30/2020 04:00	0.0	0	0	0	0	1
09/30/2020 05:00	0.0	0	0	0	0	1
09/30/2020 06:00	0.0	0	0	0	0	1
09/30/2020 07:00	0.0	0	0	0	0	1
09/30/2020 08:00	0.0	0	0	0	0	1
09/30/2020 09:00	0.0	0	0	0	0	1
09/30/2020 10:00	0.0	0	0	0	0	1
09/30/2020 11:00	0.0	0	0	0	0	1
09/30/2020 12:00	0.0	0	0	0	0	1
09/30/2020 13:00	0.0	0	0	0	0	1
09/30/2020 14:00	0.0	0	0	0	0	1
09/30/2020 15:00	0.0	0	0	0	0	1
09/30/2020 16:00	0.0	0	0	0	0	1
09/30/2020 17:00	0.0	0	0	0	0	1
09/30/2020 18:00	0.0	0	0	0	0	1
09/30/2020 19:00	0.0	0	0	0	0	1
09/30/2020 20:00	0.0	0	0	0	0	1
09/30/2020 21:00	0.0	0	0	0	0	1
09/30/2020 22:00	0.0	0	0	0	0	1
09/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/01/2020 00:00	0.0	0	0	0	0	0
07/01/2020 01:00	0.0	0	0	0	0	0
07/01/2020 02:00	0.0	0	0	0	0	0
07/01/2020 03:00	0.0	0	0	0	0	0
07/01/2020 04:00	0.0	0	0	0	0	0
07/01/2020 05:00	0.0	0	0	0	0	0
07/01/2020 06:00	0.0	0	0	0	0	0
07/01/2020 07:00	0.0	0	0	0	0	0
07/01/2020 08:00	0.0	0	0	0	0	0
07/01/2020 09:00	0.0	0	0	0	0	0
07/01/2020 10:00	0.0	0	0	0	0	0
07/01/2020 11:00	0.0	0	0	0	0	0
07/01/2020 12:00	0.0	0	0	0	0	0
07/01/2020 13:00	0.0	0	0	0	0	0
07/01/2020 14:00	0.0	0	0	0	0	0
07/01/2020 15:00	0.0	0	0	0	0	0
07/01/2020 16:00	0.0	0	0	0	0	0
07/01/2020 17:00	0.0	0	0	0	0	0
07/01/2020 18:00	0.0	0	0	0	0	0
07/01/2020 19:00	0.0	0	0	0	0	0
07/01/2020 20:00	0.0	0	0	0	0	0
07/01/2020 21:00	0.0	0	0	0	0	0
07/01/2020 22:00	0.0	0	0	0	0	0
07/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/02/2020 00:00	0.0	0	0	0	0	0
07/02/2020 01:00	0.0	0	0	0	0	0
07/02/2020 02:00	0.0	0	0	0	0	0
07/02/2020 03:00	0.0	0	0	0	0	0
07/02/2020 04:00	0.0	0	0	0	0	0
07/02/2020 05:00	0.0	0	0	0	0	0
07/02/2020 06:00	0.0	0	0	0	0	0
07/02/2020 07:00	0.0	0	0	0	0	0
07/02/2020 08:00	0.0	0	0	0	0	0
07/02/2020 09:00	0.0	0	0	0	0	0
07/02/2020 10:00	0.0	0	0	0	0	0
07/02/2020 11:00	0.0	0	0	0	0	0
07/02/2020 12:00	0.0	0	0	0	0	0
07/02/2020 13:00	0.0	0	0	0	0	0
07/02/2020 14:00	0.0	0	0	0	0	0
07/02/2020 15:00	0.0	0	0	0	0	0
07/02/2020 16:00	0.0	0	0	0	0	0
07/02/2020 17:00	0.0	0	0	0	0	0
07/02/2020 18:00	0.0	0	0	0	0	0
07/02/2020 19:00	0.0	0	0	0	0	0
07/02/2020 20:00	0.0	0	0	0	0	0
07/02/2020 21:00	0.0	0	0	0	0	0
07/02/2020 22:00	0.0	0	0	0	0	0
07/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/03/2020 00:00	0.0	0	0	0	0	0
07/03/2020 01:00	0.0	0	0	0	0	0
07/03/2020 02:00	0.0	0	0	0	0	0
07/03/2020 03:00	0.0	0	0	0	0	0
07/03/2020 04:00	0.0	0	0	0	0	0
07/03/2020 05:00	0.0	0	0	0	0	0
07/03/2020 06:00	0.0	0	0	0	0	0
07/03/2020 07:00	0.0	0	0	0	0	0
07/03/2020 08:00	0.0	0	0	0	0	0
07/03/2020 09:00	0.0	0	0	0	0	0
07/03/2020 10:00	0.0	0	0	0	0	0
07/03/2020 11:00	0.0	0	0	0	0	0
07/03/2020 12:00	0.0	0	0	0	0	0
07/03/2020 13:00	3,052.4	0	1	0	0	0
07/03/2020 14:00	5,189.9	0	1	0	0	0
07/03/2020 15:00	0.0	0	0	0	0	1
07/03/2020 16:00	0.0	0	0	0	0	1
07/03/2020 17:00	0.0	0	0	0	0	1
07/03/2020 18:00	0.0	0	0	0	0	1
07/03/2020 19:00	0.0	0	0	0	0	1
07/03/2020 20:00	0.0	0	0	0	0	1
07/03/2020 21:00	0.0	0	0	0	0	1
07/03/2020 22:00	0.0	0	0	0	0	1
07/03/2020 23:00	135.9	0	0	0	1	0
Average/Sum#:	8,378.2 #	0 #	2 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,189.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/04/2020 00:00	0.0	0	0	0	0	0
07/04/2020 01:00	0.0	0	0	0	0	0
07/04/2020 02:00	0.0	0	0	0	0	0
07/04/2020 03:00	0.0	0	0	0	0	0
07/04/2020 04:00	0.0	0	0	0	0	0
07/04/2020 05:00	0.0	0	0	0	0	0
07/04/2020 06:00	0.0	0	0	0	0	0
07/04/2020 07:00	0.0	0	0	0	0	0
07/04/2020 08:00	0.0	0	0	0	0	0
07/04/2020 09:00	0.0	0	0	0	0	0
07/04/2020 10:00	0.0	0	0	0	0	0
07/04/2020 11:00	0.0	0	0	0	0	0
07/04/2020 12:00	0.0	0	0	0	0	0
07/04/2020 13:00	0.0	0	0	0	0	0
07/04/2020 14:00	0.0	0	0	0	0	0
07/04/2020 15:00	0.0	0	0	0	0	0
07/04/2020 16:00	0.0	0	0	0	0	0
07/04/2020 17:00	0.0	0	0	0	0	0
07/04/2020 18:00	0.0	0	0	0	0	0
07/04/2020 19:00	0.0	0	0	0	0	0
07/04/2020 20:00	0.0	0	0	0	0	0
07/04/2020 21:00	0.0	0	0	0	0	0
07/04/2020 22:00	0.0	0	0	0	0	0
07/04/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/05/2020 00:00	0.0	0	0	0	0	0
07/05/2020 01:00	0.0	0	0	0	0	0
07/05/2020 02:00	0.0	0	0	0	0	0
07/05/2020 03:00	0.0	0	0	0	0	0
07/05/2020 04:00	0.0	0	0	0	0	0
07/05/2020 05:00	0.0	0	0	0	0	0
07/05/2020 06:00	0.0	0	0	0	0	0
07/05/2020 07:00	0.0	0	0	0	0	0
07/05/2020 08:00	0.0	0	0	0	0	0
07/05/2020 09:00	0.0	0	0	0	0	0
07/05/2020 10:00	0.0	0	0	0	0	0
07/05/2020 11:00	0.0	0	0	0	0	0
07/05/2020 12:00	0.0	0	0	0	0	0
07/05/2020 13:00	0.0	0	0	0	0	0
07/05/2020 14:00	2,515.9	0	1	0	0	0
07/05/2020 15:00	5,881.7	0	1	0	0	0
07/05/2020 16:00	0.0	0	0	0	0	1
07/05/2020 17:00	0.0	0	0	0	0	1
07/05/2020 18:00	0.0	0	0	0	0	1
07/05/2020 19:00	0.0	0	0	0	0	1
07/05/2020 20:00	0.0	0	0	0	0	1
07/05/2020 21:00	0.0	0	0	0	0	1
07/05/2020 22:00	127.7	0	0	0	1	0
07/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	8,525.3 #	0 #	2 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,881.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/06/2020 00:00	0.0	0	0	0	0	0
07/06/2020 01:00	0.0	0	0	0	0	0
07/06/2020 02:00	0.0	0	0	0	0	0
07/06/2020 03:00	0.0	0	0	0	0	0
07/06/2020 04:00	0.0	0	0	0	0	0
07/06/2020 05:00	0.0	0	0	0	0	0
07/06/2020 06:00	0.0	0	0	0	0	0
07/06/2020 07:00	0.0	0	0	0	0	0
07/06/2020 08:00	0.0	0	0	0	0	0
07/06/2020 09:00	0.0	0	0	0	0	0
07/06/2020 10:00	0.0	0	0	0	0	0
07/06/2020 11:00	1,441.5	0	1	0	0	0
07/06/2020 12:00	6,307.9	0	1	0	0	0
07/06/2020 13:00	0.0	0	0	0	0	1
07/06/2020 14:00	0.0	0	0	0	0	1
07/06/2020 15:00	0.0	0	0	0	0	1
07/06/2020 16:00	0.0	0	0	0	0	1
07/06/2020 17:00	0.0	0	0	0	0	1
07/06/2020 18:00	0.0	0	0	0	0	1
07/06/2020 19:00	0.0	0	0	0	0	1
07/06/2020 20:00	0.0	0	0	0	0	1
07/06/2020 21:00	0.0	0	0	0	0	1
07/06/2020 22:00	0.0	0	0	0	0	1
07/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,749.4 #	0 #	2 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,307.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/07/2020 00:00	0.0	0	0	0	0	1
07/07/2020 01:00	0.0	0	0	0	0	1
07/07/2020 02:00	0.0	0	0	0	0	1
07/07/2020 03:00	0.0	0	0	0	0	1
07/07/2020 04:00	0.0	0	0	0	0	1
07/07/2020 05:00	0.0	0	0	0	0	1
07/07/2020 06:00	0.0	0	0	0	0	1
07/07/2020 07:00	0.0	0	0	0	0	1
07/07/2020 08:00	0.0	0	0	0	0	1
07/07/2020 09:00	0.0	0	0	0	0	1
07/07/2020 10:00	0.0	0	0	0	0	1
07/07/2020 11:00	0.0	0	0	0	0	1
07/07/2020 12:00	0.0	0	0	0	0	1
07/07/2020 13:00	0.0	0	0	0	0	1
07/07/2020 14:00	0.0	0	0	0	0	1
07/07/2020 15:00	0.0	0	0	0	0	1
07/07/2020 16:00	0.0	0	0	0	0	1
07/07/2020 17:00	0.0	0	0	0	0	1
07/07/2020 18:00	0.0	0	0	0	0	1
07/07/2020 19:00	0.0	0	0	0	0	1
07/07/2020 20:00	0.0	0	0	0	0	1
07/07/2020 21:00	0.0	0	0	0	0	1
07/07/2020 22:00	0.0	0	0	0	0	1
07/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/08/2020 00:00	0.0	0	0	0	0	1
07/08/2020 01:00	0.0	0	0	0	0	1
07/08/2020 02:00	0.0	0	0	0	0	1
07/08/2020 03:00	0.0	0	0	0	0	1
07/08/2020 04:00	0.0	0	0	0	0	1
07/08/2020 05:00	0.0	0	0	0	0	1
07/08/2020 06:00	0.0	0	0	0	0	1
07/08/2020 07:00	0.0	0	0	0	0	1
07/08/2020 08:00	0.0	0	0	0	0	1
07/08/2020 09:00	0.0	0	0	0	0	1
07/08/2020 10:00	0.0	0	0	0	0	1
07/08/2020 11:00	0.0	0	0	0	0	1
07/08/2020 12:00	0.0	0	0	0	0	1
07/08/2020 13:00	0.0	0	0	0	0	1
07/08/2020 14:00	0.0	0	0	0	0	1
07/08/2020 15:00	0.0	0	0	0	0	1
07/08/2020 16:00	0.0	0	0	0	0	1
07/08/2020 17:00	0.0	0	0	0	0	1
07/08/2020 18:00	0.0	0	0	0	0	1
07/08/2020 19:00	0.0	0	0	0	0	1
07/08/2020 20:00	0.0	0	0	0	0	1
07/08/2020 21:00	0.0	0	0	0	0	1
07/08/2020 22:00	0.0	0	0	0	0	1
07/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/09/2020 00:00	0.0	0	0	0	0	1
07/09/2020 01:00	0.0	0	0	0	0	1
07/09/2020 02:00	0.0	0	0	0	0	1
07/09/2020 03:00	0.0	0	0	0	0	1
07/09/2020 04:00	0.0	0	0	0	0	1
07/09/2020 05:00	0.0	0	0	0	0	1
07/09/2020 06:00	0.0	0	0	0	0	1
07/09/2020 07:00	0.0	0	0	0	0	1
07/09/2020 08:00	0.0	0	0	0	0	1
07/09/2020 09:00	0.0	0	0	0	0	1
07/09/2020 10:00	0.0	0	0	0	0	1
07/09/2020 11:00	0.0	0	0	0	0	1
07/09/2020 12:00	0.0	0	0	0	0	1
07/09/2020 13:00	0.0	0	0	0	0	1
07/09/2020 14:00	0.0	0	0	0	0	1
07/09/2020 15:00	0.0	0	0	0	0	1
07/09/2020 16:00	0.0	0	0	0	0	1
07/09/2020 17:00	0.0	0	0	0	0	1
07/09/2020 18:00	0.0	0	0	0	0	1
07/09/2020 19:00	0.0	0	0	0	0	1
07/09/2020 20:00	0.0	0	0	0	0	1
07/09/2020 21:00	0.0	0	0	0	0	1
07/09/2020 22:00	0.0	0	0	0	0	1
07/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/10/2020 00:00	0.0	0	0	0	0	1
07/10/2020 01:00	0.0	0	0	0	0	1
07/10/2020 02:00	0.0	0	0	0	0	1
07/10/2020 03:00	0.0	0	0	0	0	1
07/10/2020 04:00	0.0	0	0	0	0	1
07/10/2020 05:00	0.0	0	0	0	0	1
07/10/2020 06:00	0.0	0	0	0	0	1
07/10/2020 07:00	0.0	0	0	0	0	1
07/10/2020 08:00	0.0	0	0	0	0	1
07/10/2020 09:00	0.0	0	0	0	0	1
07/10/2020 10:00	0.0	0	0	0	0	1
07/10/2020 11:00	0.0	0	0	0	0	1
07/10/2020 12:00	0.0	0	0	0	0	1
07/10/2020 13:00	0.0	0	0	0	0	1
07/10/2020 14:00	0.0	0	0	0	0	1
07/10/2020 15:00	0.0	0	0	0	0	1
07/10/2020 16:00	0.0	0	0	0	0	1
07/10/2020 17:00	0.0	0	0	0	0	1
07/10/2020 18:00	0.0	0	0	0	0	1
07/10/2020 19:00	0.0	0	0	0	0	1
07/10/2020 20:00	0.0	0	0	0	0	1
07/10/2020 21:00	0.0	0	0	0	0	1
07/10/2020 22:00	0.0	0	0	0	0	1
07/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/11/2020 00:00	0.0	0	0	0	0	1
07/11/2020 01:00	0.0	0	0	0	0	1
07/11/2020 02:00	0.0	0	0	0	0	1
07/11/2020 03:00	0.0	0	0	0	0	1
07/11/2020 04:00	0.0	0	0	0	0	1
07/11/2020 05:00	0.0	0	0	0	0	1
07/11/2020 06:00	0.0	0	0	0	0	1
07/11/2020 07:00	0.0	0	0	0	0	1
07/11/2020 08:00	0.0	0	0	0	0	1
07/11/2020 09:00	0.0	0	0	0	0	1
07/11/2020 10:00	0.0	0	0	0	0	1
07/11/2020 11:00	0.0	0	0	0	0	1
07/11/2020 12:00	0.0	0	0	0	0	1
07/11/2020 13:00	0.0	0	0	0	0	1
07/11/2020 14:00	0.0	0	0	0	0	1
07/11/2020 15:00	0.0	0	0	0	0	1
07/11/2020 16:00	0.0	0	0	0	0	1
07/11/2020 17:00	0.0	0	0	0	0	1
07/11/2020 18:00	0.0	0	0	0	0	1
07/11/2020 19:00	0.0	0	0	0	0	1
07/11/2020 20:00	0.0	0	0	0	0	1
07/11/2020 21:00	0.0	0	0	0	0	1
07/11/2020 22:00	0.0	0	0	0	0	1
07/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/12/2020 00:00	0.0	0	0	0	0	1
07/12/2020 01:00	0.0	0	0	0	0	1
07/12/2020 02:00	0.0	0	0	0	0	1
07/12/2020 03:00	0.0	0	0	0	0	1
07/12/2020 04:00	0.0	0	0	0	0	1
07/12/2020 05:00	0.0	0	0	0	0	1
07/12/2020 06:00	0.0	0	0	0	0	1
07/12/2020 07:00	0.0	0	0	0	0	1
07/12/2020 08:00	0.0	0	0	0	0	1
07/12/2020 09:00	0.0	0	0	0	0	1
07/12/2020 10:00	0.0	0	0	0	0	1
07/12/2020 11:00	0.0	0	0	0	0	1
07/12/2020 12:00	0.0	0	0	0	0	1
07/12/2020 13:00	0.0	0	0	0	0	1
07/12/2020 14:00	0.0	0	0	0	0	1
07/12/2020 15:00	0.0	0	0	0	0	1
07/12/2020 16:00	0.0	0	0	0	0	1
07/12/2020 17:00	0.0	0	0	0	0	1
07/12/2020 18:00	0.0	0	0	0	0	1
07/12/2020 19:00	0.0	0	0	0	0	1
07/12/2020 20:00	0.0	0	0	0	0	1
07/12/2020 21:00	0.0	0	0	0	0	1
07/12/2020 22:00	0.0	0	0	0	0	1
07/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/13/2020 00:00	0.0	0	0	0	0	1
07/13/2020 01:00	0.0	0	0	0	0	1
07/13/2020 02:00	0.0	0	0	0	0	1
07/13/2020 03:00	0.0	0	0	0	0	1
07/13/2020 04:00	0.0	0	0	0	0	1
07/13/2020 05:00	0.0	0	0	0	0	1
07/13/2020 06:00	0.0	0	0	0	0	1
07/13/2020 07:00	0.0	0	0	0	0	1
07/13/2020 08:00	0.0	0	0	0	0	1
07/13/2020 09:00	0.0	0	0	0	0	1
07/13/2020 10:00	0.0	0	0	0	0	1
07/13/2020 11:00	0.0	0	0	0	0	1
07/13/2020 12:00	0.0	0	0	0	0	1
07/13/2020 13:00	0.0	0	0	0	0	1
07/13/2020 14:00	0.0	0	0	0	0	1
07/13/2020 15:00	0.0	0	0	0	0	1
07/13/2020 16:00	0.0	0	0	0	0	1
07/13/2020 17:00	0.0	0	0	0	0	1
07/13/2020 18:00	0.0	0	0	0	0	1
07/13/2020 19:00	0.0	0	0	0	0	1
07/13/2020 20:00	0.0	0	0	0	0	1
07/13/2020 21:00	0.0	0	0	0	0	1
07/13/2020 22:00	0.0	0	0	0	0	1
07/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/14/2020 00:00	0.0	0	0	0	0	1
07/14/2020 01:00	0.0	0	0	0	0	1
07/14/2020 02:00	0.0	0	0	0	0	1
07/14/2020 03:00	0.0	0	0	0	0	1
07/14/2020 04:00	0.0	0	0	0	0	1
07/14/2020 05:00	0.0	0	0	0	0	1
07/14/2020 06:00	0.0	0	0	0	0	1
07/14/2020 07:00	0.0	0	0	0	0	1
07/14/2020 08:00	0.0	0	0	0	0	1
07/14/2020 09:00	0.0	0	0	0	0	1
07/14/2020 10:00	0.0	0	0	0	0	1
07/14/2020 11:00	0.0	0	0	0	0	1
07/14/2020 12:00	0.0	0	0	0	0	1
07/14/2020 13:00	0.0	0	0	0	0	1
07/14/2020 14:00	0.0	0	0	0	0	1
07/14/2020 15:00	0.0	0	0	0	0	1
07/14/2020 16:00	0.0	0	0	0	0	1
07/14/2020 17:00	0.0	0	0	0	0	1
07/14/2020 18:00	0.0	0	0	0	0	1
07/14/2020 19:00	0.0	0	0	0	0	1
07/14/2020 20:00	0.0	0	0	0	0	1
07/14/2020 21:00	0.0	0	0	0	0	1
07/14/2020 22:00	0.0	0	0	0	0	1
07/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/15/2020 00:00	0.0	0	0	0	0	1
07/15/2020 01:00	0.0	0	0	0	0	1
07/15/2020 02:00	0.0	0	0	0	0	1
07/15/2020 03:00	0.0	0	0	0	0	1
07/15/2020 04:00	0.0	0	0	0	0	1
07/15/2020 05:00	0.0	0	0	0	0	1
07/15/2020 06:00	0.0	0	0	0	0	1
07/15/2020 07:00	0.0	0	0	0	0	1
07/15/2020 08:00	0.0	0	0	0	0	1
07/15/2020 09:00	0.0	0	0	0	0	1
07/15/2020 10:00	0.0	0	0	0	0	1
07/15/2020 11:00	0.0	0	0	0	0	1
07/15/2020 12:00	0.0	0	0	0	0	1
07/15/2020 13:00	0.0	0	0	0	0	1
07/15/2020 14:00	0.0	0	0	0	0	1
07/15/2020 15:00	0.0	0	0	0	0	1
07/15/2020 16:00	0.0	0	0	0	0	1
07/15/2020 17:00	0.0	0	0	0	0	1
07/15/2020 18:00	0.0	0	0	0	0	1
07/15/2020 19:00	0.0	0	0	0	0	1
07/15/2020 20:00	0.0	0	0	0	0	1
07/15/2020 21:00	0.0	0	0	0	0	1
07/15/2020 22:00	0.0	0	0	0	0	1
07/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/16/2020 00:00	0.0	0	0	0	0	1
07/16/2020 01:00	0.0	0	0	0	0	1
07/16/2020 02:00	0.0	0	0	0	0	1
07/16/2020 03:00	0.0	0	0	0	0	1
07/16/2020 04:00	0.0	0	0	0	0	1
07/16/2020 05:00	0.0	0	0	0	0	1
07/16/2020 06:00	0.0	0	0	0	0	1
07/16/2020 07:00	0.0	0	0	0	0	1
07/16/2020 08:00	0.0	0	0	0	0	1
07/16/2020 09:00	0.0	0	0	0	0	1
07/16/2020 10:00	0.0	0	0	0	0	1
07/16/2020 11:00	0.0	0	0	0	0	1
07/16/2020 12:00	0.0	0	0	0	0	1
07/16/2020 13:00	0.0	0	0	0	0	1
07/16/2020 14:00	0.0	0	0	0	0	1
07/16/2020 15:00	0.0	0	0	0	0	1
07/16/2020 16:00	0.0	0	0	0	0	1
07/16/2020 17:00	0.0	0	0	0	0	1
07/16/2020 18:00	0.0	0	0	0	0	1
07/16/2020 19:00	0.0	0	0	0	0	1
07/16/2020 20:00	0.0	0	0	0	0	1
07/16/2020 21:00	0.0	0	0	0	0	1
07/16/2020 22:00	0.0	0	0	0	0	1
07/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/17/2020 00:00	0.0	0	0	0	0	1
07/17/2020 01:00	0.0	0	0	0	0	1
07/17/2020 02:00	0.0	0	0	0	0	1
07/17/2020 03:00	0.0	0	0	0	0	1
07/17/2020 04:00	0.0	0	0	0	0	1
07/17/2020 05:00	0.0	0	0	0	0	1
07/17/2020 06:00	0.0	0	0	0	0	1
07/17/2020 07:00	0.0	0	0	0	0	1
07/17/2020 08:00	0.0	0	0	0	0	1
07/17/2020 09:00	0.0	0	0	0	0	1
07/17/2020 10:00	0.0	0	0	0	0	1
07/17/2020 11:00	0.0	0	0	0	0	1
07/17/2020 12:00	0.0	0	0	0	0	1
07/17/2020 13:00	0.0	0	0	0	0	1
07/17/2020 14:00	0.0	0	0	0	0	1
07/17/2020 15:00	0.0	0	0	0	0	1
07/17/2020 16:00	0.0	0	0	0	0	1
07/17/2020 17:00	0.0	0	0	0	0	1
07/17/2020 18:00	0.0	0	0	0	0	1
07/17/2020 19:00	0.0	0	0	0	0	1
07/17/2020 20:00	0.0	0	0	0	0	1
07/17/2020 21:00	0.0	0	0	0	0	1
07/17/2020 22:00	0.0	0	0	0	0	1
07/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/18/2020 00:00	0.0	0	0	0	0	1
07/18/2020 01:00	0.0	0	0	0	0	1
07/18/2020 02:00	0.0	0	0	0	0	1
07/18/2020 03:00	0.0	0	0	0	0	1
07/18/2020 04:00	0.0	0	0	0	0	1
07/18/2020 05:00	0.0	0	0	0	0	1
07/18/2020 06:00	0.0	0	0	0	0	1
07/18/2020 07:00	0.0	0	0	0	0	1
07/18/2020 08:00	0.0	0	0	0	0	1
07/18/2020 09:00	0.0	0	0	0	0	1
07/18/2020 10:00	0.0	0	0	0	0	1
07/18/2020 11:00	0.0	0	0	0	0	1
07/18/2020 12:00	0.0	0	0	0	0	1
07/18/2020 13:00	0.0	0	0	0	0	1
07/18/2020 14:00	0.0	0	0	0	0	1
07/18/2020 15:00	0.0	0	0	0	0	1
07/18/2020 16:00	0.0	0	0	0	0	1
07/18/2020 17:00	0.0	0	0	0	0	1
07/18/2020 18:00	0.0	0	0	0	0	1
07/18/2020 19:00	0.0	0	0	0	0	1
07/18/2020 20:00	0.0	0	0	0	0	1
07/18/2020 21:00	0.0	0	0	0	0	1
07/18/2020 22:00	0.0	0	0	0	0	1
07/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/19/2020 00:00	0.0	0	0	0	0	1
07/19/2020 01:00	0.0	0	0	0	0	1
07/19/2020 02:00	0.0	0	0	0	0	1
07/19/2020 03:00	0.0	0	0	0	0	1
07/19/2020 04:00	0.0	0	0	0	0	1
07/19/2020 05:00	0.0	0	0	0	0	1
07/19/2020 06:00	0.0	0	0	0	0	1
07/19/2020 07:00	0.0	0	0	0	0	1
07/19/2020 08:00	0.0	0	0	0	0	1
07/19/2020 09:00	0.0	0	0	0	0	1
07/19/2020 10:00	0.0	0	0	0	0	1
07/19/2020 11:00	0.0	0	0	0	0	1
07/19/2020 12:00	0.0	0	0	0	0	1
07/19/2020 13:00	0.0	0	0	0	0	1
07/19/2020 14:00	0.0	0	0	0	0	1
07/19/2020 15:00	0.0	0	0	0	0	1
07/19/2020 16:00	0.0	0	0	0	0	1
07/19/2020 17:00	0.0	0	0	0	0	1
07/19/2020 18:00	0.0	0	0	0	0	1
07/19/2020 19:00	0.0	0	0	0	0	1
07/19/2020 20:00	0.0	0	0	0	0	1
07/19/2020 21:00	0.0	0	0	0	0	1
07/19/2020 22:00	0.0	0	0	0	0	1
07/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/20/2020 00:00	0.0	0	0	0	0	1
07/20/2020 01:00	0.0	0	0	0	0	1
07/20/2020 02:00	0.0	0	0	0	0	1
07/20/2020 03:00	0.0	0	0	0	0	1
07/20/2020 04:00	0.0	0	0	0	0	1
07/20/2020 05:00	0.0	0	0	0	0	1
07/20/2020 06:00	0.0	0	0	0	0	1
07/20/2020 07:00	0.0	0	0	0	0	1
07/20/2020 08:00	0.0	0	0	0	0	1
07/20/2020 09:00	0.0	0	0	0	0	1
07/20/2020 10:00	0.0	0	0	0	0	1
07/20/2020 11:00	0.0	0	0	0	0	1
07/20/2020 12:00	0.0	0	0	0	0	1
07/20/2020 13:00	0.0	0	0	0	0	1
07/20/2020 14:00	0.0	0	0	0	0	1
07/20/2020 15:00	0.0	0	0	0	0	1
07/20/2020 16:00	0.0	0	0	0	0	1
07/20/2020 17:00	0.0	0	0	0	0	1
07/20/2020 18:00	0.0	0	0	0	0	1
07/20/2020 19:00	0.0	0	0	0	0	1
07/20/2020 20:00	0.0	0	0	0	0	1
07/20/2020 21:00	0.0	0	0	0	0	1
07/20/2020 22:00	0.0	0	0	0	0	1
07/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/21/2020 00:00	0.0	0	0	0	0	1
07/21/2020 01:00	0.0	0	0	0	0	1
07/21/2020 02:00	0.0	0	0	0	0	1
07/21/2020 03:00	0.0	0	0	0	0	1
07/21/2020 04:00	0.0	0	0	0	0	1
07/21/2020 05:00	0.0	0	0	0	0	1
07/21/2020 06:00	0.0	0	0	0	0	1
07/21/2020 07:00	0.0	0	0	0	0	1
07/21/2020 08:00	0.0	0	0	0	0	1
07/21/2020 09:00	0.0	0	0	0	0	1
07/21/2020 10:00	0.0	0	0	0	0	1
07/21/2020 11:00	0.0	0	0	0	0	1
07/21/2020 12:00	0.0	0	0	0	0	1
07/21/2020 13:00	0.0	0	0	0	0	1
07/21/2020 14:00	0.0	0	0	0	0	1
07/21/2020 15:00	0.0	0	0	0	0	1
07/21/2020 16:00	0.0	0	0	0	0	1
07/21/2020 17:00	0.0	0	0	0	0	1
07/21/2020 18:00	0.0	0	0	0	0	1
07/21/2020 19:00	0.0	0	0	0	0	1
07/21/2020 20:00	0.0	0	0	0	0	1
07/21/2020 21:00	0.0	0	0	0	0	1
07/21/2020 22:00	0.0	0	0	0	0	1
07/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/22/2020 00:00	0.0	0	0	0	0	1
07/22/2020 01:00	0.0	0	0	0	0	1
07/22/2020 02:00	0.0	0	0	0	0	1
07/22/2020 03:00	0.0	0	0	0	0	1
07/22/2020 04:00	0.0	0	0	0	0	1
07/22/2020 05:00	0.0	0	0	0	0	1
07/22/2020 06:00	0.0	0	0	0	0	1
07/22/2020 07:00	0.0	0	0	0	0	1
07/22/2020 08:00	0.0	0	0	0	0	1
07/22/2020 09:00	0.0	0	0	0	0	1
07/22/2020 10:00	0.0	0	0	0	0	1
07/22/2020 11:00	0.0	0	0	0	0	1
07/22/2020 12:00	0.0	0	0	0	0	1
07/22/2020 13:00	0.0	0	0	0	0	1
07/22/2020 14:00	0.0	0	0	0	0	1
07/22/2020 15:00	0.0	0	0	0	0	1
07/22/2020 16:00	0.0	0	0	0	0	1
07/22/2020 17:00	0.0	0	0	0	0	1
07/22/2020 18:00	0.0	0	0	0	0	1
07/22/2020 19:00	0.0	0	0	0	0	1
07/22/2020 20:00	0.0	0	0	0	0	1
07/22/2020 21:00	0.0	0	0	0	0	1
07/22/2020 22:00	0.0	0	0	0	0	1
07/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/23/2020 00:00	0.0	0	0	0	0	1
07/23/2020 01:00	0.0	0	0	0	0	1
07/23/2020 02:00	0.0	0	0	0	0	1
07/23/2020 03:00	0.0	0	0	0	0	1
07/23/2020 04:00	0.0	0	0	0	0	1
07/23/2020 05:00	0.0	0	0	0	0	1
07/23/2020 06:00	0.0	0	0	0	0	1
07/23/2020 07:00	0.0	0	0	0	0	1
07/23/2020 08:00	0.0	0	0	0	0	1
07/23/2020 09:00	0.0	0	0	0	0	1
07/23/2020 10:00	0.0	0	0	0	0	1
07/23/2020 11:00	0.0	0	0	0	0	1
07/23/2020 12:00	0.0	0	0	0	0	1
07/23/2020 13:00	0.0	0	0	0	0	1
07/23/2020 14:00	0.0	0	0	0	0	1
07/23/2020 15:00	0.0	0	0	0	0	1
07/23/2020 16:00	0.0	0	0	0	0	1
07/23/2020 17:00	0.0	0	0	0	0	1
07/23/2020 18:00	0.0	0	0	0	0	1
07/23/2020 19:00	0.0	0	0	0	0	1
07/23/2020 20:00	0.0	0	0	0	0	1
07/23/2020 21:00	0.0	0	0	0	0	1
07/23/2020 22:00	0.0	0	0	0	0	1
07/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/24/2020 00:00	0.0	0	0	0	0	1
07/24/2020 01:00	0.0	0	0	0	0	1
07/24/2020 02:00	0.0	0	0	0	0	1
07/24/2020 03:00	0.0	0	0	0	0	1
07/24/2020 04:00	0.0	0	0	0	0	1
07/24/2020 05:00	0.0	0	0	0	0	1
07/24/2020 06:00	0.0	0	0	0	0	1
07/24/2020 07:00	0.0	0	0	0	0	1
07/24/2020 08:00	0.0	0	0	0	0	1
07/24/2020 09:00	0.0	0	0	0	0	1
07/24/2020 10:00	0.0	0	0	0	0	1
07/24/2020 11:00	0.0	0	0	0	0	1
07/24/2020 12:00	0.0	0	0	0	0	1
07/24/2020 13:00	0.0	0	0	0	0	1
07/24/2020 14:00	0.0	0	0	0	0	1
07/24/2020 15:00	0.0	0	0	0	0	1
07/24/2020 16:00	0.0	0	0	0	0	1
07/24/2020 17:00	0.0	0	0	0	0	1
07/24/2020 18:00	0.0	0	0	0	0	1
07/24/2020 19:00	0.0	0	0	0	0	1
07/24/2020 20:00	0.0	0	0	0	0	1
07/24/2020 21:00	0.0	0	0	0	0	1
07/24/2020 22:00	0.0	0	0	0	0	1
07/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/25/2020 00:00	0.0	0	0	0	0	1
07/25/2020 01:00	0.0	0	0	0	0	1
07/25/2020 02:00	0.0	0	0	0	0	1
07/25/2020 03:00	0.0	0	0	0	0	1
07/25/2020 04:00	0.0	0	0	0	0	1
07/25/2020 05:00	0.0	0	0	0	0	1
07/25/2020 06:00	0.0	0	0	0	0	1
07/25/2020 07:00	0.0	0	0	0	0	1
07/25/2020 08:00	0.0	0	0	0	0	1
07/25/2020 09:00	0.0	0	0	0	0	1
07/25/2020 10:00	0.0	0	0	0	0	1
07/25/2020 11:00	0.0	0	0	0	0	1
07/25/2020 12:00	0.0	0	0	0	0	1
07/25/2020 13:00	0.0	0	0	0	0	1
07/25/2020 14:00	0.0	0	0	0	0	1
07/25/2020 15:00	0.0	0	0	0	0	1
07/25/2020 16:00	0.0	0	0	0	0	1
07/25/2020 17:00	0.0	0	0	0	0	1
07/25/2020 18:00	0.0	0	0	0	0	1
07/25/2020 19:00	0.0	0	0	0	0	1
07/25/2020 20:00	0.0	0	0	0	0	1
07/25/2020 21:00	0.0	0	0	0	0	1
07/25/2020 22:00	0.0	0	0	0	0	1
07/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/26/2020 00:00	0.0	0	0	0	0	1
07/26/2020 01:00	0.0	0	0	0	0	1
07/26/2020 02:00	0.0	0	0	0	0	1
07/26/2020 03:00	0.0	0	0	0	0	1
07/26/2020 04:00	0.0	0	0	0	0	1
07/26/2020 05:00	0.0	0	0	0	0	1
07/26/2020 06:00	0.0	0	0	0	0	1
07/26/2020 07:00	0.0	0	0	0	0	1
07/26/2020 08:00	0.0	0	0	0	0	1
07/26/2020 09:00	0.0	0	0	0	0	1
07/26/2020 10:00	0.0	0	0	0	0	1
07/26/2020 11:00	0.0	0	0	0	0	1
07/26/2020 12:00	0.0	0	0	0	0	1
07/26/2020 13:00	0.0	0	0	0	0	1
07/26/2020 14:00	0.0	0	0	0	0	1
07/26/2020 15:00	0.0	0	0	0	0	1
07/26/2020 16:00	0.0	0	0	0	0	1
07/26/2020 17:00	0.0	0	0	0	0	1
07/26/2020 18:00	0.0	0	0	0	0	1
07/26/2020 19:00	0.0	0	0	0	0	1
07/26/2020 20:00	0.0	0	0	0	0	1
07/26/2020 21:00	0.0	0	0	0	0	1
07/26/2020 22:00	0.0	0	0	0	0	1
07/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/27/2020 00:00	0.0	0	0	0	0	1
07/27/2020 01:00	0.0	0	0	0	0	1
07/27/2020 02:00	0.0	0	0	0	0	1
07/27/2020 03:00	0.0	0	0	0	0	1
07/27/2020 04:00	0.0	0	0	0	0	1
07/27/2020 05:00	0.0	0	0	0	0	1
07/27/2020 06:00	0.0	0	0	0	0	1
07/27/2020 07:00	0.0	0	0	0	0	1
07/27/2020 08:00	0.0	0	0	0	0	1
07/27/2020 09:00	0.0	0	0	0	0	1
07/27/2020 10:00	0.0	0	0	0	0	1
07/27/2020 11:00	0.0	0	0	0	0	1
07/27/2020 12:00	0.0	0	0	0	0	1
07/27/2020 13:00	0.0	0	0	0	0	1
07/27/2020 14:00	0.0	0	0	0	0	1
07/27/2020 15:00	0.0	0	0	0	0	1
07/27/2020 16:00	0.0	0	0	0	0	1
07/27/2020 17:00	0.0	0	0	0	0	1
07/27/2020 18:00	0.0	0	0	0	0	1
07/27/2020 19:00	0.0	0	0	0	0	1
07/27/2020 20:00	0.0	0	0	0	0	1
07/27/2020 21:00	0.0	0	0	0	0	1
07/27/2020 22:00	0.0	0	0	0	0	1
07/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/28/2020 00:00	0.0	0	0	0	0	1
07/28/2020 01:00	0.0	0	0	0	0	1
07/28/2020 02:00	0.0	0	0	0	0	1
07/28/2020 03:00	0.0	0	0	0	0	1
07/28/2020 04:00	0.0	0	0	0	0	1
07/28/2020 05:00	0.0	0	0	0	0	1
07/28/2020 06:00	0.0	0	0	0	0	1
07/28/2020 07:00	0.0	0	0	0	0	1
07/28/2020 08:00	0.0	0	0	0	0	1
07/28/2020 09:00	0.0	0	0	0	0	1
07/28/2020 10:00	0.0	0	0	0	0	1
07/28/2020 11:00	0.0	0	0	0	0	1
07/28/2020 12:00	0.0	0	0	0	0	1
07/28/2020 13:00	0.0	0	0	0	0	1
07/28/2020 14:00	0.0	0	0	0	0	1
07/28/2020 15:00	0.0	0	0	0	0	1
07/28/2020 16:00	0.0	0	0	0	0	1
07/28/2020 17:00	0.0	0	0	0	0	1
07/28/2020 18:00	0.0	0	0	0	0	1
07/28/2020 19:00	0.0	0	0	0	0	1
07/28/2020 20:00	0.0	0	0	0	0	1
07/28/2020 21:00	0.0	0	0	0	0	1
07/28/2020 22:00	0.0	0	0	0	0	1
07/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/29/2020 00:00	0.0	0	0	0	0	1
07/29/2020 01:00	0.0	0	0	0	0	1
07/29/2020 02:00	0.0	0	0	0	0	1
07/29/2020 03:00	0.0	0	0	0	0	1
07/29/2020 04:00	0.0	0	0	0	0	1
07/29/2020 05:00	0.0	0	0	0	0	1
07/29/2020 06:00	0.0	0	0	0	0	1
07/29/2020 07:00	0.0	0	0	0	0	1
07/29/2020 08:00	0.0	0	0	0	0	1
07/29/2020 09:00	0.0	0	0	0	0	1
07/29/2020 10:00	0.0	0	0	0	0	1
07/29/2020 11:00	0.0	0	0	0	0	1
07/29/2020 12:00	0.0	0	0	0	0	1
07/29/2020 13:00	0.0	0	0	0	0	1
07/29/2020 14:00	0.0	0	0	0	0	1
07/29/2020 15:00	0.0	0	0	0	0	1
07/29/2020 16:00	0.0	0	0	0	0	1
07/29/2020 17:00	0.0	0	0	0	0	1
07/29/2020 18:00	0.0	0	0	0	0	1
07/29/2020 19:00	0.0	0	0	0	0	1
07/29/2020 20:00	0.0	0	0	0	0	1
07/29/2020 21:00	0.0	0	0	0	0	1
07/29/2020 22:00	0.0	0	0	0	0	1
07/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/30/2020 00:00	0.0	0	0	0	0	1
07/30/2020 01:00	0.0	0	0	0	0	1
07/30/2020 02:00	0.0	0	0	0	0	1
07/30/2020 03:00	0.0	0	0	0	0	1
07/30/2020 04:00	0.0	0	0	0	0	1
07/30/2020 05:00	0.0	0	0	0	0	1
07/30/2020 06:00	0.0	0	0	0	0	1
07/30/2020 07:00	0.0	0	0	0	0	1
07/30/2020 08:00	0.0	0	0	0	0	1
07/30/2020 09:00	0.0	0	0	0	0	1
07/30/2020 10:00	0.0	0	0	0	0	1
07/30/2020 11:00	0.0	0	0	0	0	1
07/30/2020 12:00	0.0	0	0	0	0	1
07/30/2020 13:00	0.0	0	0	0	0	1
07/30/2020 14:00	0.0	0	0	0	0	1
07/30/2020 15:00	0.0	0	0	0	0	1
07/30/2020 16:00	0.0	0	0	0	0	1
07/30/2020 17:00	0.0	0	0	0	0	1
07/30/2020 18:00	0.0	0	0	0	0	1
07/30/2020 19:00	0.0	0	0	0	0	1
07/30/2020 20:00	0.0	0	0	0	0	1
07/30/2020 21:00	0.0	0	0	0	0	1
07/30/2020 22:00	0.0	0	0	0	0	1
07/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/31/2020 00:00	0.0	0	0	0	0	1
07/31/2020 01:00	0.0	0	0	0	0	1
07/31/2020 02:00	0.0	0	0	0	0	1
07/31/2020 03:00	0.0	0	0	0	0	1
07/31/2020 04:00	0.0	0	0	0	0	1
07/31/2020 05:00	0.0	0	0	0	0	1
07/31/2020 06:00	0.0	0	0	0	0	1
07/31/2020 07:00	0.0	0	0	0	0	1
07/31/2020 08:00	0.0	0	0	0	0	1
07/31/2020 09:00	0.0	0	0	0	0	1
07/31/2020 10:00	0.0	0	0	0	0	1
07/31/2020 11:00	0.0	0	0	0	0	1
07/31/2020 12:00	0.0	0	0	0	0	1
07/31/2020 13:00	0.0	0	0	0	0	1
07/31/2020 14:00	0.0	0	0	0	0	1
07/31/2020 15:00	0.0	0	0	0	0	1
07/31/2020 16:00	0.0	0	0	0	0	1
07/31/2020 17:00	0.0	0	0	0	0	1
07/31/2020 18:00	0.0	0	0	0	0	1
07/31/2020 19:00	0.0	0	0	0	0	1
07/31/2020 20:00	0.0	0	0	0	0	1
07/31/2020 21:00	0.0	0	0	0	0	1
07/31/2020 22:00	0.0	0	0	0	0	1
07/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/01/2020 00:00	0.0	0	0	0	0	1
08/01/2020 01:00	0.0	0	0	0	0	1
08/01/2020 02:00	0.0	0	0	0	0	1
08/01/2020 03:00	0.0	0	0	0	0	1
08/01/2020 04:00	0.0	0	0	0	0	1
08/01/2020 05:00	0.0	0	0	0	0	1
08/01/2020 06:00	0.0	0	0	0	0	1
08/01/2020 07:00	0.0	0	0	0	0	1
08/01/2020 08:00	0.0	0	0	0	0	1
08/01/2020 09:00	0.0	0	0	0	0	1
08/01/2020 10:00	0.0	0	0	0	0	1
08/01/2020 11:00	0.0	0	0	0	0	1
08/01/2020 12:00	0.0	0	0	0	0	1
08/01/2020 13:00	0.0	0	0	0	0	1
08/01/2020 14:00	0.0	0	0	0	0	1
08/01/2020 15:00	0.0	0	0	0	0	1
08/01/2020 16:00	0.0	0	0	0	0	1
08/01/2020 17:00	0.0	0	0	0	0	1
08/01/2020 18:00	0.0	0	0	0	0	1
08/01/2020 19:00	0.0	0	0	0	0	1
08/01/2020 20:00	0.0	0	0	0	0	1
08/01/2020 21:00	0.0	0	0	0	0	1
08/01/2020 22:00	0.0	0	0	0	0	1
08/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/02/2020 00:00	0.0	0	0	0	0	1
08/02/2020 01:00	0.0	0	0	0	0	1
08/02/2020 02:00	0.0	0	0	0	0	1
08/02/2020 03:00	0.0	0	0	0	0	1
08/02/2020 04:00	0.0	0	0	0	0	1
08/02/2020 05:00	0.0	0	0	0	0	1
08/02/2020 06:00	0.0	0	0	0	0	1
08/02/2020 07:00	0.0	0	0	0	0	1
08/02/2020 08:00	0.0	0	0	0	0	1
08/02/2020 09:00	0.0	0	0	0	0	1
08/02/2020 10:00	0.0	0	0	0	0	1
08/02/2020 11:00	0.0	0	0	0	0	1
08/02/2020 12:00	0.0	0	0	0	0	1
08/02/2020 13:00	0.0	0	0	0	0	1
08/02/2020 14:00	0.0	0	0	0	0	1
08/02/2020 15:00	0.0	0	0	0	0	1
08/02/2020 16:00	0.0	0	0	0	0	1
08/02/2020 17:00	0.0	0	0	0	0	1
08/02/2020 18:00	0.0	0	0	0	0	1
08/02/2020 19:00	0.0	0	0	0	0	1
08/02/2020 20:00	0.0	0	0	0	0	1
08/02/2020 21:00	0.0	0	0	0	0	1
08/02/2020 22:00	0.0	0	0	0	0	1
08/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/03/2020 00:00	0.0	0	0	0	0	1
08/03/2020 01:00	0.0	0	0	0	0	1
08/03/2020 02:00	0.0	0	0	0	0	1
08/03/2020 03:00	0.0	0	0	0	0	1
08/03/2020 04:00	0.0	0	0	0	0	1
08/03/2020 05:00	0.0	0	0	0	0	1
08/03/2020 06:00	0.0	0	0	0	0	1
08/03/2020 07:00	0.0	0	0	0	0	1
08/03/2020 08:00	0.0	0	0	0	0	1
08/03/2020 09:00	0.0	0	0	0	0	1
08/03/2020 10:00	0.0	0	0	0	0	1
08/03/2020 11:00	0.0	0	0	0	0	1
08/03/2020 12:00	0.0	0	0	0	0	1
08/03/2020 13:00	0.0	0	0	0	0	1
08/03/2020 14:00	0.0	0	0	0	0	1
08/03/2020 15:00	0.0	0	0	0	0	1
08/03/2020 16:00	0.0	0	0	0	0	1
08/03/2020 17:00	0.0	0	0	0	0	1
08/03/2020 18:00	0.0	0	0	0	0	1
08/03/2020 19:00	0.0	0	0	0	0	1
08/03/2020 20:00	0.0	0	0	0	0	1
08/03/2020 21:00	0.0	0	0	0	0	1
08/03/2020 22:00	0.0	0	0	0	0	1
08/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/04/2020 00:00	0.0	0	0	0	0	1
08/04/2020 01:00	0.0	0	0	0	0	1
08/04/2020 02:00	0.0	0	0	0	0	1
08/04/2020 03:00	0.0	0	0	0	0	1
08/04/2020 04:00	0.0	0	0	0	0	1
08/04/2020 05:00	0.0	0	0	0	0	1
08/04/2020 06:00	0.0	0	0	0	0	1
08/04/2020 07:00	0.0	0	0	0	0	1
08/04/2020 08:00	0.0	0	0	0	0	1
08/04/2020 09:00	0.0	0	0	0	0	1
08/04/2020 10:00	0.0	0	0	0	0	1
08/04/2020 11:00	0.0	0	0	0	0	1
08/04/2020 12:00	0.0	0	0	0	0	1
08/04/2020 13:00	0.0	0	0	0	0	1
08/04/2020 14:00	0.0	0	0	0	0	1
08/04/2020 15:00	0.0	0	0	0	0	1
08/04/2020 16:00	0.0	0	0	0	0	1
08/04/2020 17:00	0.0	0	0	0	0	1
08/04/2020 18:00	0.0	0	0	0	0	1
08/04/2020 19:00	0.0	0	0	0	0	1
08/04/2020 20:00	0.0	0	0	0	0	1
08/04/2020 21:00	0.0	0	0	0	0	1
08/04/2020 22:00	0.0	0	0	0	0	1
08/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/05/2020 00:00	0.0	0	0	0	0	1
08/05/2020 01:00	0.0	0	0	0	0	1
08/05/2020 02:00	0.0	0	0	0	0	1
08/05/2020 03:00	0.0	0	0	0	0	1
08/05/2020 04:00	0.0	0	0	0	0	1
08/05/2020 05:00	0.0	0	0	0	0	1
08/05/2020 06:00	0.0	0	0	0	0	1
08/05/2020 07:00	0.0	0	0	0	0	1
08/05/2020 08:00	0.0	0	0	0	0	1
08/05/2020 09:00	0.0	0	0	0	0	1
08/05/2020 10:00	0.0	0	0	0	0	1
08/05/2020 11:00	0.0	0	0	0	0	1
08/05/2020 12:00	0.0	0	0	0	0	1
08/05/2020 13:00	0.0	0	0	0	0	1
08/05/2020 14:00	0.0	0	0	0	0	1
08/05/2020 15:00	0.0	0	0	0	0	1
08/05/2020 16:00	0.0	0	0	0	0	1
08/05/2020 17:00	0.0	0	0	0	0	1
08/05/2020 18:00	0.0	0	0	0	0	1
08/05/2020 19:00	0.0	0	0	0	0	1
08/05/2020 20:00	0.0	0	0	0	0	1
08/05/2020 21:00	0.0	0	0	0	0	1
08/05/2020 22:00	0.0	0	0	0	0	1
08/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/06/2020 00:00	0.0	0	0	0	0	1
08/06/2020 01:00	0.0	0	0	0	0	1
08/06/2020 02:00	0.0	0	0	0	0	1
08/06/2020 03:00	0.0	0	0	0	0	1
08/06/2020 04:00	0.0	0	0	0	0	1
08/06/2020 05:00	0.0	0	0	0	0	1
08/06/2020 06:00	0.0	0	0	0	0	1
08/06/2020 07:00	0.0	0	0	0	0	1
08/06/2020 08:00	0.0	0	0	0	0	1
08/06/2020 09:00	0.0	0	0	0	0	1
08/06/2020 10:00	0.0	0	0	0	0	1
08/06/2020 11:00	0.0	0	0	0	0	1
08/06/2020 12:00	0.0	0	0	0	0	1
08/06/2020 13:00	0.0	0	0	0	0	1
08/06/2020 14:00	0.0	0	0	0	0	1
08/06/2020 15:00	0.0	0	0	0	0	1
08/06/2020 16:00	0.0	0	0	0	0	1
08/06/2020 17:00	0.0	0	0	0	0	1
08/06/2020 18:00	0.0	0	0	0	0	1
08/06/2020 19:00	0.0	0	0	0	0	1
08/06/2020 20:00	0.0	0	0	0	0	1
08/06/2020 21:00	0.0	0	0	0	0	1
08/06/2020 22:00	0.0	0	0	0	0	1
08/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/07/2020 00:00	0.0	0	0	0	0	1
08/07/2020 01:00	0.0	0	0	0	0	1
08/07/2020 02:00	0.0	0	0	0	0	1
08/07/2020 03:00	0.0	0	0	0	0	1
08/07/2020 04:00	0.0	0	0	0	0	1
08/07/2020 05:00	0.0	0	0	0	0	1
08/07/2020 06:00	0.0	0	0	0	0	1
08/07/2020 07:00	0.0	0	0	0	0	1
08/07/2020 08:00	0.0	0	0	0	0	1
08/07/2020 09:00	0.0	0	0	0	0	1
08/07/2020 10:00	0.0	0	0	0	0	1
08/07/2020 11:00	0.0	0	0	0	0	1
08/07/2020 12:00	0.0	0	0	0	0	1
08/07/2020 13:00	0.0	0	0	0	0	1
08/07/2020 14:00	0.0	0	0	0	0	1
08/07/2020 15:00	0.0	0	0	0	0	1
08/07/2020 16:00	0.0	0	0	0	0	1
08/07/2020 17:00	0.0	0	0	0	0	1
08/07/2020 18:00	0.0	0	0	0	0	1
08/07/2020 19:00	0.0	0	0	0	0	1
08/07/2020 20:00	0.0	0	0	0	0	1
08/07/2020 21:00	0.0	0	0	0	0	1
08/07/2020 22:00	0.0	0	0	0	0	1
08/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/08/2020 00:00	0.0	0	0	0	0	1
08/08/2020 01:00	0.0	0	0	0	0	1
08/08/2020 02:00	0.0	0	0	0	0	1
08/08/2020 03:00	0.0	0	0	0	0	1
08/08/2020 04:00	0.0	0	0	0	0	1
08/08/2020 05:00	0.0	0	0	0	0	1
08/08/2020 06:00	0.0	0	0	0	0	1
08/08/2020 07:00	0.0	0	0	0	0	1
08/08/2020 08:00	0.0	0	0	0	0	1
08/08/2020 09:00	0.0	0	0	0	0	1
08/08/2020 10:00	0.0	0	0	0	0	1
08/08/2020 11:00	0.0	0	0	0	0	1
08/08/2020 12:00	0.0	0	0	0	0	1
08/08/2020 13:00	0.0	0	0	0	0	1
08/08/2020 14:00	0.0	0	0	0	0	1
08/08/2020 15:00	0.0	0	0	0	0	1
08/08/2020 16:00	0.0	0	0	0	0	1
08/08/2020 17:00	0.0	0	0	0	0	1
08/08/2020 18:00	0.0	0	0	0	0	1
08/08/2020 19:00	0.0	0	0	0	0	1
08/08/2020 20:00	0.0	0	0	0	0	1
08/08/2020 21:00	0.0	0	0	0	0	1
08/08/2020 22:00	0.0	0	0	0	0	1
08/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/09/2020 00:00	0.0	0	0	0	0	1
08/09/2020 01:00	0.0	0	0	0	0	1
08/09/2020 02:00	0.0	0	0	0	0	1
08/09/2020 03:00	0.0	0	0	0	0	1
08/09/2020 04:00	0.0	0	0	0	0	1
08/09/2020 05:00	0.0	0	0	0	0	1
08/09/2020 06:00	0.0	0	0	0	0	1
08/09/2020 07:00	0.0	0	0	0	0	1
08/09/2020 08:00	0.0	0	0	0	0	1
08/09/2020 09:00	0.0	0	0	0	0	1
08/09/2020 10:00	0.0	0	0	0	0	1
08/09/2020 11:00	0.0	0	0	0	0	1
08/09/2020 12:00	0.0	0	0	0	0	1
08/09/2020 13:00	0.0	0	0	0	0	1
08/09/2020 14:00	0.0	0	0	0	0	1
08/09/2020 15:00	0.0	0	0	0	0	1
08/09/2020 16:00	0.0	0	0	0	0	1
08/09/2020 17:00	0.0	0	0	0	0	1
08/09/2020 18:00	0.0	0	0	0	0	1
08/09/2020 19:00	0.0	0	0	0	0	1
08/09/2020 20:00	0.0	0	0	0	0	1
08/09/2020 21:00	0.0	0	0	0	0	1
08/09/2020 22:00	0.0	0	0	0	0	1
08/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/10/2020 00:00	0.0	0	0	0	0	1
08/10/2020 01:00	0.0	0	0	0	0	1
08/10/2020 02:00	0.0	0	0	0	0	1
08/10/2020 03:00	0.0	0	0	0	0	1
08/10/2020 04:00	0.0	0	0	0	0	1
08/10/2020 05:00	0.0	0	0	0	0	1
08/10/2020 06:00	0.0	0	0	0	0	1
08/10/2020 07:00	0.0	0	0	0	0	1
08/10/2020 08:00	0.0	0	0	0	0	1
08/10/2020 09:00	0.0	0	0	0	0	1
08/10/2020 10:00	0.0	0	0	0	0	1
08/10/2020 11:00	0.0	0	0	0	0	1
08/10/2020 12:00	0.0	0	0	0	0	1
08/10/2020 13:00	0.0	0	0	0	0	1
08/10/2020 14:00	0.0	0	0	0	0	1
08/10/2020 15:00	0.0	0	0	0	0	1
08/10/2020 16:00	0.0	0	0	0	0	1
08/10/2020 17:00	0.0	0	0	0	0	1
08/10/2020 18:00	0.0	0	0	0	0	1
08/10/2020 19:00	0.0	0	0	0	0	1
08/10/2020 20:00	0.0	0	0	0	0	1
08/10/2020 21:00	0.0	0	0	0	0	1
08/10/2020 22:00	0.0	0	0	0	0	1
08/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/11/2020 00:00	0.0	0	0	0	0	1
08/11/2020 01:00	0.0	0	0	0	0	1
08/11/2020 02:00	0.0	0	0	0	0	1
08/11/2020 03:00	0.0	0	0	0	0	1
08/11/2020 04:00	0.0	0	0	0	0	1
08/11/2020 05:00	0.0	0	0	0	0	1
08/11/2020 06:00	0.0	0	0	0	0	1
08/11/2020 07:00	0.0	0	0	0	0	1
08/11/2020 08:00	0.0	0	0	0	0	1
08/11/2020 09:00	0.0	0	0	0	0	1
08/11/2020 10:00	0.0	0	0	0	0	1
08/11/2020 11:00	0.0	0	0	0	0	1
08/11/2020 12:00	0.0	0	0	0	0	1
08/11/2020 13:00	0.0	0	0	0	0	1
08/11/2020 14:00	0.0	0	0	0	0	1
08/11/2020 15:00	0.0	0	0	0	0	1
08/11/2020 16:00	0.0	0	0	0	0	1
08/11/2020 17:00	0.0	0	0	0	0	1
08/11/2020 18:00	0.0	0	0	0	0	1
08/11/2020 19:00	0.0	0	0	0	0	1
08/11/2020 20:00	0.0	0	0	0	0	1
08/11/2020 21:00	0.0	0	0	0	0	1
08/11/2020 22:00	0.0	0	0	0	0	1
08/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/12/2020 00:00	0.0	0	0	0	0	1
08/12/2020 01:00	0.0	0	0	0	0	1
08/12/2020 02:00	0.0	0	0	0	0	1
08/12/2020 03:00	0.0	0	0	0	0	1
08/12/2020 04:00	0.0	0	0	0	0	1
08/12/2020 05:00	0.0	0	0	0	0	1
08/12/2020 06:00	0.0	0	0	0	0	1
08/12/2020 07:00	0.0	0	0	0	0	1
08/12/2020 08:00	0.0	0	0	0	0	1
08/12/2020 09:00	0.0	0	0	0	0	1
08/12/2020 10:00	0.0	0	0	0	0	1
08/12/2020 11:00	0.0	0	0	0	0	1
08/12/2020 12:00	0.0	0	0	0	0	1
08/12/2020 13:00	0.0	0	0	0	0	1
08/12/2020 14:00	0.0	0	0	0	0	1
08/12/2020 15:00	0.0	0	0	0	0	1
08/12/2020 16:00	0.0	0	0	0	0	1
08/12/2020 17:00	0.0	0	0	0	0	1
08/12/2020 18:00	0.0	0	0	0	0	1
08/12/2020 19:00	0.0	0	0	0	0	1
08/12/2020 20:00	0.0	0	0	0	0	1
08/12/2020 21:00	0.0	0	0	0	0	1
08/12/2020 22:00	0.0	0	0	0	0	1
08/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/13/2020 00:00	0.0	0	0	0	0	1
08/13/2020 01:00	0.0	0	0	0	0	1
08/13/2020 02:00	0.0	0	0	0	0	1
08/13/2020 03:00	0.0	0	0	0	0	1
08/13/2020 04:00	0.0	0	0	0	0	1
08/13/2020 05:00	0.0	0	0	0	0	1
08/13/2020 06:00	0.0	0	0	0	0	1
08/13/2020 07:00	0.0	0	0	0	0	1
08/13/2020 08:00	0.0	0	0	0	0	1
08/13/2020 09:00	0.0	0	0	0	0	1
08/13/2020 10:00	0.0	0	0	0	0	1
08/13/2020 11:00	0.0	0	0	0	0	1
08/13/2020 12:00	0.0	0	0	0	0	1
08/13/2020 13:00	0.0	0	0	0	0	1
08/13/2020 14:00	0.0	0	0	0	0	1
08/13/2020 15:00	0.0	0	0	0	0	1
08/13/2020 16:00	0.0	0	0	0	0	1
08/13/2020 17:00	0.0	0	0	0	0	1
08/13/2020 18:00	0.0	0	0	0	0	1
08/13/2020 19:00	0.0	0	0	0	0	1
08/13/2020 20:00	0.0	0	0	0	0	1
08/13/2020 21:00	0.0	0	0	0	0	1
08/13/2020 22:00	0.0	0	0	0	0	1
08/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/14/2020 00:00	0.0	0	0	0	0	1
08/14/2020 01:00	0.0	0	0	0	0	1
08/14/2020 02:00	0.0	0	0	0	0	1
08/14/2020 03:00	0.0	0	0	0	0	1
08/14/2020 04:00	0.0	0	0	0	0	1
08/14/2020 05:00	0.0	0	0	0	0	1
08/14/2020 06:00	0.0	0	0	0	0	1
08/14/2020 07:00	0.0	0	0	0	0	1
08/14/2020 08:00	0.0	0	0	0	0	1
08/14/2020 09:00	0.0	0	0	0	0	1
08/14/2020 10:00	0.0	0	0	0	0	1
08/14/2020 11:00	0.0	0	0	0	0	1
08/14/2020 12:00	0.0	0	0	0	0	1
08/14/2020 13:00	0.0	0	0	0	0	1
08/14/2020 14:00	0.0	0	0	0	0	1
08/14/2020 15:00	0.0	0	0	0	0	1
08/14/2020 16:00	0.0	0	0	0	0	1
08/14/2020 17:00	0.0	0	0	0	0	1
08/14/2020 18:00	0.0	0	0	0	0	1
08/14/2020 19:00	0.0	0	0	0	0	1
08/14/2020 20:00	0.0	0	0	0	0	1
08/14/2020 21:00	0.0	0	0	0	0	1
08/14/2020 22:00	0.0	0	0	0	0	1
08/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/15/2020 00:00	0.0	0	0	0	0	1
08/15/2020 01:00	0.0	0	0	0	0	1
08/15/2020 02:00	0.0	0	0	0	0	1
08/15/2020 03:00	0.0	0	0	0	0	1
08/15/2020 04:00	0.0	0	0	0	0	1
08/15/2020 05:00	0.0	0	0	0	0	1
08/15/2020 06:00	0.0	0	0	0	0	1
08/15/2020 07:00	0.0	0	0	0	0	1
08/15/2020 08:00	0.0	0	0	0	0	1
08/15/2020 09:00	0.0	0	0	0	0	1
08/15/2020 10:00	0.0	0	0	0	0	1
08/15/2020 11:00	0.0	0	0	0	0	1
08/15/2020 12:00	0.0	0	0	0	0	1
08/15/2020 13:00	0.0	0	0	0	0	1
08/15/2020 14:00	0.0	0	0	0	0	1
08/15/2020 15:00	0.0	0	0	0	0	1
08/15/2020 16:00	0.0	0	0	0	0	1
08/15/2020 17:00	0.0	0	0	0	0	1
08/15/2020 18:00	0.0	0	0	0	0	1
08/15/2020 19:00	0.0	0	0	0	0	1
08/15/2020 20:00	0.0	0	0	0	0	1
08/15/2020 21:00	0.0	0	0	0	0	1
08/15/2020 22:00	0.0	0	0	0	0	1
08/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/16/2020 00:00	0.0	0	0	0	0	1
08/16/2020 01:00	0.0	0	0	0	0	1
08/16/2020 02:00	0.0	0	0	0	0	1
08/16/2020 03:00	0.0	0	0	0	0	1
08/16/2020 04:00	0.0	0	0	0	0	1
08/16/2020 05:00	0.0	0	0	0	0	1
08/16/2020 06:00	0.0	0	0	0	0	1
08/16/2020 07:00	0.0	0	0	0	0	1
08/16/2020 08:00	0.0	0	0	0	0	1
08/16/2020 09:00	0.0	0	0	0	0	1
08/16/2020 10:00	0.0	0	0	0	0	1
08/16/2020 11:00	0.0	0	0	0	0	1
08/16/2020 12:00	0.0	0	0	0	0	1
08/16/2020 13:00	0.0	0	0	0	0	1
08/16/2020 14:00	0.0	0	0	0	0	1
08/16/2020 15:00	0.0	0	0	0	0	1
08/16/2020 16:00	0.0	0	0	0	0	1
08/16/2020 17:00	0.0	0	0	0	0	1
08/16/2020 18:00	0.0	0	0	0	0	1
08/16/2020 19:00	0.0	0	0	0	0	1
08/16/2020 20:00	0.0	0	0	0	0	1
08/16/2020 21:00	0.0	0	0	0	0	1
08/16/2020 22:00	0.0	0	0	0	0	1
08/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/17/2020 00:00	0.0	0	0	0	0	1
08/17/2020 01:00	0.0	0	0	0	0	1
08/17/2020 02:00	0.0	0	0	0	0	1
08/17/2020 03:00	0.0	0	0	0	0	1
08/17/2020 04:00	0.0	0	0	0	0	1
08/17/2020 05:00	0.0	0	0	0	0	1
08/17/2020 06:00	0.0	0	0	0	0	1
08/17/2020 07:00	0.0	0	0	0	0	1
08/17/2020 08:00	0.0	0	0	0	0	1
08/17/2020 09:00	0.0	0	0	0	0	1
08/17/2020 10:00	0.0	0	0	0	0	1
08/17/2020 11:00	0.0	0	0	0	0	1
08/17/2020 12:00	0.0	0	0	0	0	1
08/17/2020 13:00	0.0	0	0	0	0	1
08/17/2020 14:00	0.0	0	0	0	0	1
08/17/2020 15:00	0.0	0	0	0	0	1
08/17/2020 16:00	0.0	0	0	0	0	1
08/17/2020 17:00	0.0	0	0	0	0	1
08/17/2020 18:00	0.0	0	0	0	0	1
08/17/2020 19:00	0.0	0	0	0	0	1
08/17/2020 20:00	0.0	0	0	0	0	1
08/17/2020 21:00	0.0	0	0	0	0	1
08/17/2020 22:00	0.0	0	0	0	0	1
08/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/18/2020 00:00	0.0	0	0	0	0	1
08/18/2020 01:00	0.0	0	0	0	0	1
08/18/2020 02:00	0.0	0	0	0	0	1
08/18/2020 03:00	0.0	0	0	0	0	1
08/18/2020 04:00	0.0	0	0	0	0	1
08/18/2020 05:00	0.0	0	0	0	0	1
08/18/2020 06:00	0.0	0	0	0	0	1
08/18/2020 07:00	0.0	0	0	0	0	1
08/18/2020 08:00	0.0	0	0	0	0	1
08/18/2020 09:00	0.0	0	0	0	0	1
08/18/2020 10:00	0.0	0	0	0	0	1
08/18/2020 11:00	0.0	0	0	0	0	1
08/18/2020 12:00	0.0	0	0	0	0	1
08/18/2020 13:00	0.0	0	0	0	0	1
08/18/2020 14:00	0.0	0	0	0	0	1
08/18/2020 15:00	0.0	0	0	0	0	1
08/18/2020 16:00	0.0	0	0	0	0	1
08/18/2020 17:00	0.0	0	0	0	0	1
08/18/2020 18:00	0.0	0	0	0	0	1
08/18/2020 19:00	0.0	0	0	0	0	1
08/18/2020 20:00	0.0	0	0	0	0	1
08/18/2020 21:00	0.0	0	0	0	0	1
08/18/2020 22:00	0.0	0	0	0	0	1
08/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/19/2020 00:00	0.0	0	0	0	0	1
08/19/2020 01:00	0.0	0	0	0	0	1
08/19/2020 02:00	0.0	0	0	0	0	1
08/19/2020 03:00	0.0	0	0	0	0	1
08/19/2020 04:00	0.0	0	0	0	0	1
08/19/2020 05:00	0.0	0	0	0	0	1
08/19/2020 06:00	0.0	0	0	0	0	1
08/19/2020 07:00	0.0	0	0	0	0	1
08/19/2020 08:00	0.0	0	0	0	0	1
08/19/2020 09:00	0.0	0	0	0	0	1
08/19/2020 10:00	0.0	0	0	0	0	1
08/19/2020 11:00	0.0	0	0	0	0	1
08/19/2020 12:00	0.0	0	0	0	0	1
08/19/2020 13:00	0.0	0	0	0	0	1
08/19/2020 14:00	0.0	0	0	0	0	1
08/19/2020 15:00	0.0	0	0	0	0	1
08/19/2020 16:00	0.0	0	0	0	0	1
08/19/2020 17:00	0.0	0	0	0	0	1
08/19/2020 18:00	0.0	0	0	0	0	1
08/19/2020 19:00	0.0	0	0	0	0	1
08/19/2020 20:00	0.0	0	0	0	0	1
08/19/2020 21:00	0.0	0	0	0	0	1
08/19/2020 22:00	0.0	0	0	0	0	1
08/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/20/2020 00:00	0.0	0	0	0	0	1
08/20/2020 01:00	0.0	0	0	0	0	1
08/20/2020 02:00	0.0	0	0	0	0	1
08/20/2020 03:00	0.0	0	0	0	0	1
08/20/2020 04:00	0.0	0	0	0	0	1
08/20/2020 05:00	0.0	0	0	0	0	1
08/20/2020 06:00	0.0	0	0	0	0	1
08/20/2020 07:00	0.0	0	0	0	0	1
08/20/2020 08:00	0.0	0	0	0	0	1
08/20/2020 09:00	0.0	0	0	0	0	1
08/20/2020 10:00	0.0	0	0	0	0	1
08/20/2020 11:00	0.0	0	0	0	0	1
08/20/2020 12:00	0.0	0	0	0	0	1
08/20/2020 13:00	0.0	0	0	0	0	1
08/20/2020 14:00	0.0	0	0	0	0	1
08/20/2020 15:00	0.0	0	0	0	0	1
08/20/2020 16:00	0.0	0	0	0	0	1
08/20/2020 17:00	0.0	0	0	0	0	1
08/20/2020 18:00	0.0	0	0	0	0	1
08/20/2020 19:00	0.0	0	0	0	0	1
08/20/2020 20:00	0.0	0	0	0	0	1
08/20/2020 21:00	0.0	0	0	0	0	1
08/20/2020 22:00	0.0	0	0	0	0	1
08/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/21/2020 00:00	0.0	0	0	0	0	1
08/21/2020 01:00	0.0	0	0	0	0	1
08/21/2020 02:00	0.0	0	0	0	0	1
08/21/2020 03:00	0.0	0	0	0	0	1
08/21/2020 04:00	0.0	0	0	0	0	1
08/21/2020 05:00	0.0	0	0	0	0	1
08/21/2020 06:00	0.0	0	0	0	0	1
08/21/2020 07:00	0.0	0	0	0	0	1
08/21/2020 08:00	0.0	0	0	0	0	1
08/21/2020 09:00	0.0	0	0	0	0	1
08/21/2020 10:00	0.0	0	0	0	0	1
08/21/2020 11:00	0.0	0	0	0	0	1
08/21/2020 12:00	0.0	0	0	0	0	1
08/21/2020 13:00	0.0	0	0	0	0	1
08/21/2020 14:00	0.0	0	0	0	0	1
08/21/2020 15:00	0.0	0	0	0	0	1
08/21/2020 16:00	0.0	0	0	0	0	1
08/21/2020 17:00	0.0	0	0	0	0	1
08/21/2020 18:00	0.0	0	0	0	0	1
08/21/2020 19:00	0.0	0	0	0	0	1
08/21/2020 20:00	0.0	0	0	0	0	1
08/21/2020 21:00	0.0	0	0	0	0	1
08/21/2020 22:00	0.0	0	0	0	0	1
08/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/22/2020 00:00	0.0	0	0	0	0	1
08/22/2020 01:00	0.0	0	0	0	0	1
08/22/2020 02:00	0.0	0	0	0	0	1
08/22/2020 03:00	0.0	0	0	0	0	1
08/22/2020 04:00	0.0	0	0	0	0	1
08/22/2020 05:00	0.0	0	0	0	0	1
08/22/2020 06:00	0.0	0	0	0	0	1
08/22/2020 07:00	0.0	0	0	0	0	1
08/22/2020 08:00	0.0	0	0	0	0	1
08/22/2020 09:00	0.0	0	0	0	0	1
08/22/2020 10:00	0.0	0	0	0	0	1
08/22/2020 11:00	0.0	0	0	0	0	1
08/22/2020 12:00	0.0	0	0	0	0	1
08/22/2020 13:00	0.0	0	0	0	0	1
08/22/2020 14:00	0.0	0	0	0	0	1
08/22/2020 15:00	0.0	0	0	0	0	1
08/22/2020 16:00	0.0	0	0	0	0	1
08/22/2020 17:00	0.0	0	0	0	0	1
08/22/2020 18:00	0.0	0	0	0	0	1
08/22/2020 19:00	0.0	0	0	0	0	1
08/22/2020 20:00	0.0	0	0	0	0	1
08/22/2020 21:00	0.0	0	0	0	0	1
08/22/2020 22:00	0.0	0	0	0	0	1
08/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/23/2020 00:00	0.0	0	0	0	0	1
08/23/2020 01:00	0.0	0	0	0	0	1
08/23/2020 02:00	0.0	0	0	0	0	1
08/23/2020 03:00	0.0	0	0	0	0	1
08/23/2020 04:00	0.0	0	0	0	0	1
08/23/2020 05:00	0.0	0	0	0	0	1
08/23/2020 06:00	0.0	0	0	0	0	1
08/23/2020 07:00	0.0	0	0	0	0	1
08/23/2020 08:00	0.0	0	0	0	0	1
08/23/2020 09:00	0.0	0	0	0	0	1
08/23/2020 10:00	0.0	0	0	0	0	1
08/23/2020 11:00	0.0	0	0	0	0	1
08/23/2020 12:00	0.0	0	0	0	0	1
08/23/2020 13:00	0.0	0	0	0	0	1
08/23/2020 14:00	0.0	0	0	0	0	1
08/23/2020 15:00	0.0	0	0	0	0	1
08/23/2020 16:00	0.0	0	0	0	0	1
08/23/2020 17:00	0.0	0	0	0	0	1
08/23/2020 18:00	0.0	0	0	0	0	1
08/23/2020 19:00	0.0	0	0	0	0	1
08/23/2020 20:00	0.0	0	0	0	0	1
08/23/2020 21:00	0.0	0	0	0	0	1
08/23/2020 22:00	0.0	0	0	0	0	1
08/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/24/2020 00:00	0.0	0	0	0	0	1
08/24/2020 01:00	0.0	0	0	0	0	1
08/24/2020 02:00	0.0	0	0	0	0	1
08/24/2020 03:00	0.0	0	0	0	0	1
08/24/2020 04:00	0.0	0	0	0	0	1
08/24/2020 05:00	0.0	0	0	0	0	1
08/24/2020 06:00	0.0	0	0	0	0	1
08/24/2020 07:00	0.0	0	0	0	0	1
08/24/2020 08:00	0.0	0	0	0	0	1
08/24/2020 09:00	0.0	0	0	0	0	1
08/24/2020 10:00	0.0	0	0	0	0	1
08/24/2020 11:00	0.0	0	0	0	0	1
08/24/2020 12:00	0.0	0	0	0	0	1
08/24/2020 13:00	0.0	0	0	0	0	1
08/24/2020 14:00	0.0	0	0	0	0	1
08/24/2020 15:00	0.0	0	0	0	0	1
08/24/2020 16:00	0.0	0	0	0	0	1
08/24/2020 17:00	0.0	0	0	0	0	1
08/24/2020 18:00	0.0	0	0	0	0	1
08/24/2020 19:00	0.0	0	0	0	0	1
08/24/2020 20:00	0.0	0	0	0	0	1
08/24/2020 21:00	0.0	0	0	0	0	1
08/24/2020 22:00	0.0	0	0	0	0	1
08/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/25/2020 00:00	0.0	0	0	0	0	1
08/25/2020 01:00	0.0	0	0	0	0	1
08/25/2020 02:00	0.0	0	0	0	0	1
08/25/2020 03:00	0.0	0	0	0	0	1
08/25/2020 04:00	0.0	0	0	0	0	1
08/25/2020 05:00	0.0	0	0	0	0	1
08/25/2020 06:00	0.0	0	0	0	0	1
08/25/2020 07:00	0.0	0	0	0	0	1
08/25/2020 08:00	0.0	0	0	0	0	1
08/25/2020 09:00	0.0	0	0	0	0	1
08/25/2020 10:00	0.0	0	0	0	0	1
08/25/2020 11:00	0.0	0	0	0	0	1
08/25/2020 12:00	0.0	0	0	0	0	1
08/25/2020 13:00	0.0	0	0	0	0	1
08/25/2020 14:00	0.0	0	0	0	0	1
08/25/2020 15:00	0.0	0	0	0	0	1
08/25/2020 16:00	0.0	0	0	0	0	1
08/25/2020 17:00	0.0	0	0	0	0	1
08/25/2020 18:00	0.0	0	0	0	0	1
08/25/2020 19:00	0.0	0	0	0	0	1
08/25/2020 20:00	0.0	0	0	0	0	1
08/25/2020 21:00	0.0	0	0	0	0	1
08/25/2020 22:00	0.0	0	0	0	0	1
08/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/26/2020 00:00	0.0	0	0	0	0	1
08/26/2020 01:00	0.0	0	0	0	0	1
08/26/2020 02:00	0.0	0	0	0	0	1
08/26/2020 03:00	0.0	0	0	0	0	1
08/26/2020 04:00	0.0	0	0	0	0	1
08/26/2020 05:00	0.0	0	0	0	0	1
08/26/2020 06:00	0.0	0	0	0	0	1
08/26/2020 07:00	0.0	0	0	0	0	1
08/26/2020 08:00	0.0	0	0	0	0	1
08/26/2020 09:00	0.0	0	0	0	0	1
08/26/2020 10:00	0.0	0	0	0	0	1
08/26/2020 11:00	0.0	0	0	0	0	1
08/26/2020 12:00	0.0	0	0	0	0	1
08/26/2020 13:00	0.0	0	0	0	0	1
08/26/2020 14:00	0.0	0	0	0	0	1
08/26/2020 15:00	0.0	0	0	0	0	1
08/26/2020 16:00	0.0	0	0	0	0	1
08/26/2020 17:00	0.0	0	0	0	0	1
08/26/2020 18:00	0.0	0	0	0	0	1
08/26/2020 19:00	0.0	0	0	0	0	1
08/26/2020 20:00	0.0	0	0	0	0	1
08/26/2020 21:00	0.0	0	0	0	0	1
08/26/2020 22:00	0.0	0	0	0	0	1
08/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/27/2020 00:00	0.0	0	0	0	0	1
08/27/2020 01:00	0.0	0	0	0	0	1
08/27/2020 02:00	0.0	0	0	0	0	1
08/27/2020 03:00	0.0	0	0	0	0	1
08/27/2020 04:00	0.0	0	0	0	0	1
08/27/2020 05:00	0.0	0	0	0	0	1
08/27/2020 06:00	0.0	0	0	0	0	1
08/27/2020 07:00	0.0	0	0	0	0	1
08/27/2020 08:00	0.0	0	0	0	0	1
08/27/2020 09:00	0.0	0	0	0	0	1
08/27/2020 10:00	0.0	0	0	0	0	1
08/27/2020 11:00	0.0	0	0	0	0	1
08/27/2020 12:00	0.0	0	0	0	0	1
08/27/2020 13:00	0.0	0	0	0	0	1
08/27/2020 14:00	0.0	0	0	0	0	1
08/27/2020 15:00	0.0	0	0	0	0	1
08/27/2020 16:00	0.0	0	0	0	0	1
08/27/2020 17:00	0.0	0	0	0	0	1
08/27/2020 18:00	0.0	0	0	0	0	1
08/27/2020 19:00	0.0	0	0	0	0	1
08/27/2020 20:00	0.0	0	0	0	0	1
08/27/2020 21:00	0.0	0	0	0	0	1
08/27/2020 22:00	0.0	0	0	0	0	1
08/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/28/2020 00:00	0.0	0	0	0	0	1
08/28/2020 01:00	0.0	0	0	0	0	1
08/28/2020 02:00	0.0	0	0	0	0	1
08/28/2020 03:00	0.0	0	0	0	0	1
08/28/2020 04:00	0.0	0	0	0	0	1
08/28/2020 05:00	0.0	0	0	0	0	1
08/28/2020 06:00	0.0	0	0	0	0	1
08/28/2020 07:00	0.0	0	0	0	0	1
08/28/2020 08:00	0.0	0	0	0	0	1
08/28/2020 09:00	0.0	0	0	0	0	1
08/28/2020 10:00	0.0	0	0	0	0	1
08/28/2020 11:00	0.0	0	0	0	0	1
08/28/2020 12:00	0.0	0	0	0	0	1
08/28/2020 13:00	0.0	0	0	0	0	1
08/28/2020 14:00	0.0	0	0	0	0	1
08/28/2020 15:00	0.0	0	0	0	0	1
08/28/2020 16:00	0.0	0	0	0	0	1
08/28/2020 17:00	0.0	0	0	0	0	1
08/28/2020 18:00	0.0	0	0	0	0	1
08/28/2020 19:00	0.0	0	0	0	0	1
08/28/2020 20:00	0.0	0	0	0	0	1
08/28/2020 21:00	0.0	0	0	0	0	1
08/28/2020 22:00	0.0	0	0	0	0	1
08/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/29/2020 00:00	0.0	0	0	0	0	1
08/29/2020 01:00	0.0	0	0	0	0	1
08/29/2020 02:00	0.0	0	0	0	0	1
08/29/2020 03:00	0.0	0	0	0	0	1
08/29/2020 04:00	0.0	0	0	0	0	1
08/29/2020 05:00	0.0	0	0	0	0	1
08/29/2020 06:00	0.0	0	0	0	0	1
08/29/2020 07:00	0.0	0	0	0	0	1
08/29/2020 08:00	0.0	0	0	0	0	1
08/29/2020 09:00	0.0	0	0	0	0	1
08/29/2020 10:00	0.0	0	0	0	0	1
08/29/2020 11:00	0.0	0	0	0	0	1
08/29/2020 12:00	0.0	0	0	0	0	1
08/29/2020 13:00	0.0	0	0	0	0	1
08/29/2020 14:00	0.0	0	0	0	0	1
08/29/2020 15:00	0.0	0	0	0	0	1
08/29/2020 16:00	0.0	0	0	0	0	1
08/29/2020 17:00	0.0	0	0	0	0	1
08/29/2020 18:00	0.0	0	0	0	0	1
08/29/2020 19:00	0.0	0	0	0	0	1
08/29/2020 20:00	0.0	0	0	0	0	1
08/29/2020 21:00	0.0	0	0	0	0	1
08/29/2020 22:00	0.0	0	0	0	0	1
08/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/30/2020 00:00	0.0	0	0	0	0	1
08/30/2020 01:00	0.0	0	0	0	0	1
08/30/2020 02:00	0.0	0	0	0	0	1
08/30/2020 03:00	0.0	0	0	0	0	1
08/30/2020 04:00	0.0	0	0	0	0	1
08/30/2020 05:00	0.0	0	0	0	0	1
08/30/2020 06:00	0.0	0	0	0	0	1
08/30/2020 07:00	0.0	0	0	0	0	1
08/30/2020 08:00	0.0	0	0	0	0	1
08/30/2020 09:00	0.0	0	0	0	0	1
08/30/2020 10:00	0.0	0	0	0	0	1
08/30/2020 11:00	0.0	0	0	0	0	1
08/30/2020 12:00	0.0	0	0	0	0	1
08/30/2020 13:00	0.0	0	0	0	0	1
08/30/2020 14:00	0.0	0	0	0	0	1
08/30/2020 15:00	0.0	0	0	0	0	1
08/30/2020 16:00	0.0	0	0	0	0	1
08/30/2020 17:00	0.0	0	0	0	0	1
08/30/2020 18:00	0.0	0	0	0	0	1
08/30/2020 19:00	0.0	0	0	0	0	1
08/30/2020 20:00	0.0	0	0	0	0	1
08/30/2020 21:00	0.0	0	0	0	0	1
08/30/2020 22:00	0.0	0	0	0	0	1
08/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/31/2020 00:00	0.0	0	0	0	0	1
08/31/2020 01:00	0.0	0	0	0	0	1
08/31/2020 02:00	0.0	0	0	0	0	1
08/31/2020 03:00	0.0	0	0	0	0	1
08/31/2020 04:00	0.0	0	0	0	0	1
08/31/2020 05:00	0.0	0	0	0	0	1
08/31/2020 06:00	0.0	0	0	0	0	1
08/31/2020 07:00	0.0	0	0	0	0	1
08/31/2020 08:00	0.0	0	0	0	0	1
08/31/2020 09:00	0.0	0	0	0	0	1
08/31/2020 10:00	0.0	0	0	0	0	1
08/31/2020 11:00	0.0	0	0	0	0	1
08/31/2020 12:00	0.0	0	0	0	0	1
08/31/2020 13:00	0.0	0	0	0	0	1
08/31/2020 14:00	0.0	0	0	0	0	1
08/31/2020 15:00	0.0	0	0	0	0	1
08/31/2020 16:00	0.0	0	0	0	0	1
08/31/2020 17:00	0.0	0	0	0	0	1
08/31/2020 18:00	0.0	0	0	0	0	1
08/31/2020 19:00	0.0	0	0	0	0	1
08/31/2020 20:00	0.0	0	0	0	0	1
08/31/2020 21:00	0.0	0	0	0	0	1
08/31/2020 22:00	0.0	0	0	0	0	1
08/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/01/2020 00:00	0.0	0	0	0	0	1
09/01/2020 01:00	0.0	0	0	0	0	1
09/01/2020 02:00	0.0	0	0	0	0	1
09/01/2020 03:00	0.0	0	0	0	0	1
09/01/2020 04:00	0.0	0	0	0	0	1
09/01/2020 05:00	0.0	0	0	0	0	1
09/01/2020 06:00	0.0	0	0	0	0	1
09/01/2020 07:00	0.0	0	0	0	0	1
09/01/2020 08:00	0.0	0	0	0	0	1
09/01/2020 09:00	0.0	0	0	0	0	1
09/01/2020 10:00	0.0	0	0	0	0	1
09/01/2020 11:00	0.0	0	0	0	0	1
09/01/2020 12:00	0.0	0	0	0	0	1
09/01/2020 13:00	0.0	0	0	0	0	1
09/01/2020 14:00	0.0	0	0	0	0	1
09/01/2020 15:00	0.0	0	0	0	0	1
09/01/2020 16:00	0.0	0	0	0	0	1
09/01/2020 17:00	0.0	0	0	0	0	1
09/01/2020 18:00	0.0	0	0	0	0	1
09/01/2020 19:00	0.0	0	0	0	0	1
09/01/2020 20:00	0.0	0	0	0	0	1
09/01/2020 21:00	0.0	0	0	0	0	1
09/01/2020 22:00	0.0	0	0	0	0	1
09/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/02/2020 00:00	0.0	0	0	0	0	1
09/02/2020 01:00	0.0	0	0	0	0	1
09/02/2020 02:00	0.0	0	0	0	0	1
09/02/2020 03:00	0.0	0	0	0	0	1
09/02/2020 04:00	0.0	0	0	0	0	1
09/02/2020 05:00	0.0	0	0	0	0	1
09/02/2020 06:00	0.0	0	0	0	0	1
09/02/2020 07:00	0.0	0	0	0	0	1
09/02/2020 08:00	0.0	0	0	0	0	1
09/02/2020 09:00	0.0	0	0	0	0	1
09/02/2020 10:00	0.0	0	0	0	0	1
09/02/2020 11:00	0.0	0	0	0	0	1
09/02/2020 12:00	0.0	0	0	0	0	1
09/02/2020 13:00	0.0	0	0	0	0	1
09/02/2020 14:00	0.0	0	0	0	0	1
09/02/2020 15:00	0.0	0	0	0	0	1
09/02/2020 16:00	0.0	0	0	0	0	1
09/02/2020 17:00	0.0	0	0	0	0	1
09/02/2020 18:00	0.0	0	0	0	0	1
09/02/2020 19:00	0.0	0	0	0	0	1
09/02/2020 20:00	0.0	0	0	0	0	1
09/02/2020 21:00	0.0	0	0	0	0	1
09/02/2020 22:00	0.0	0	0	0	0	1
09/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/03/2020 00:00	0.0	0	0	0	0	1
09/03/2020 01:00	0.0	0	0	0	0	1
09/03/2020 02:00	0.0	0	0	0	0	1
09/03/2020 03:00	0.0	0	0	0	0	1
09/03/2020 04:00	0.0	0	0	0	0	1
09/03/2020 05:00	0.0	0	0	0	0	1
09/03/2020 06:00	0.0	0	0	0	0	1
09/03/2020 07:00	0.0	0	0	0	0	1
09/03/2020 08:00	0.0	0	0	0	0	1
09/03/2020 09:00	0.0	0	0	0	0	1
09/03/2020 10:00	0.0	0	0	0	0	1
09/03/2020 11:00	0.0	0	0	0	0	1
09/03/2020 12:00	0.0	0	0	0	0	1
09/03/2020 13:00	0.0	0	0	0	0	1
09/03/2020 14:00	0.0	0	0	0	0	1
09/03/2020 15:00	0.0	0	0	0	0	1
09/03/2020 16:00	0.0	0	0	0	0	1
09/03/2020 17:00	0.0	0	0	0	0	1
09/03/2020 18:00	0.0	0	0	0	0	1
09/03/2020 19:00	0.0	0	0	0	0	1
09/03/2020 20:00	0.0	0	0	0	0	1
09/03/2020 21:00	0.0	0	0	0	0	1
09/03/2020 22:00	0.0	0	0	0	0	1
09/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/04/2020 00:00	0.0	0	0	0	0	1
09/04/2020 01:00	0.0	0	0	0	0	1
09/04/2020 02:00	0.0	0	0	0	0	1
09/04/2020 03:00	0.0	0	0	0	0	1
09/04/2020 04:00	0.0	0	0	0	0	1
09/04/2020 05:00	0.0	0	0	0	0	1
09/04/2020 06:00	0.0	0	0	0	0	1
09/04/2020 07:00	0.0	0	0	0	0	1
09/04/2020 08:00	0.0	0	0	0	0	1
09/04/2020 09:00	0.0	0	0	0	0	1
09/04/2020 10:00	0.0	0	0	0	0	1
09/04/2020 11:00	0.0	0	0	0	0	1
09/04/2020 12:00	0.0	0	0	0	0	1
09/04/2020 13:00	0.0	0	0	0	0	1
09/04/2020 14:00	0.0	0	0	0	0	1
09/04/2020 15:00	0.0	0	0	0	0	1
09/04/2020 16:00	0.0	0	0	0	0	1
09/04/2020 17:00	0.0	0	0	0	0	1
09/04/2020 18:00	0.0	0	0	0	0	1
09/04/2020 19:00	0.0	0	0	0	0	1
09/04/2020 20:00	0.0	0	0	0	0	1
09/04/2020 21:00	0.0	0	0	0	0	1
09/04/2020 22:00	0.0	0	0	0	0	1
09/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/05/2020 00:00	0.0	0	0	0	0	1
09/05/2020 01:00	0.0	0	0	0	0	1
09/05/2020 02:00	0.0	0	0	0	0	1
09/05/2020 03:00	0.0	0	0	0	0	1
09/05/2020 04:00	0.0	0	0	0	0	1
09/05/2020 05:00	0.0	0	0	0	0	1
09/05/2020 06:00	0.0	0	0	0	0	1
09/05/2020 07:00	0.0	0	0	0	0	1
09/05/2020 08:00	0.0	0	0	0	0	1
09/05/2020 09:00	0.0	0	0	0	0	1
09/05/2020 10:00	0.0	0	0	0	0	1
09/05/2020 11:00	0.0	0	0	0	0	1
09/05/2020 12:00	0.0	0	0	0	0	1
09/05/2020 13:00	0.0	0	0	0	0	1
09/05/2020 14:00	0.0	0	0	0	0	1
09/05/2020 15:00	0.0	0	0	0	0	1
09/05/2020 16:00	0.0	0	0	0	0	1
09/05/2020 17:00	0.0	0	0	0	0	1
09/05/2020 18:00	0.0	0	0	0	0	1
09/05/2020 19:00	0.0	0	0	0	0	1
09/05/2020 20:00	0.0	0	0	0	0	1
09/05/2020 21:00	0.0	0	0	0	0	1
09/05/2020 22:00	0.0	0	0	0	0	1
09/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/06/2020 00:00	0.0	0	0	0	0	1
09/06/2020 01:00	0.0	0	0	0	0	1
09/06/2020 02:00	0.0	0	0	0	0	1
09/06/2020 03:00	0.0	0	0	0	0	1
09/06/2020 04:00	0.0	0	0	0	0	1
09/06/2020 05:00	0.0	0	0	0	0	1
09/06/2020 06:00	0.0	0	0	0	0	1
09/06/2020 07:00	0.0	0	0	0	0	1
09/06/2020 08:00	0.0	0	0	0	0	1
09/06/2020 09:00	0.0	0	0	0	0	1
09/06/2020 10:00	0.0	0	0	0	0	1
09/06/2020 11:00	0.0	0	0	0	0	1
09/06/2020 12:00	0.0	0	0	0	0	1
09/06/2020 13:00	0.0	0	0	0	0	1
09/06/2020 14:00	0.0	0	0	0	0	1
09/06/2020 15:00	0.0	0	0	0	0	1
09/06/2020 16:00	0.0	0	0	0	0	1
09/06/2020 17:00	0.0	0	0	0	0	1
09/06/2020 18:00	0.0	0	0	0	0	1
09/06/2020 19:00	0.0	0	0	0	0	1
09/06/2020 20:00	0.0	0	0	0	0	1
09/06/2020 21:00	0.0	0	0	0	0	1
09/06/2020 22:00	0.0	0	0	0	0	1
09/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/07/2020 00:00	0.0	0	0	0	0	1
09/07/2020 01:00	0.0	0	0	0	0	1
09/07/2020 02:00	0.0	0	0	0	0	1
09/07/2020 03:00	0.0	0	0	0	0	1
09/07/2020 04:00	0.0	0	0	0	0	1
09/07/2020 05:00	0.0	0	0	0	0	1
09/07/2020 06:00	0.0	0	0	0	0	1
09/07/2020 07:00	0.0	0	0	0	0	1
09/07/2020 08:00	0.0	0	0	0	0	1
09/07/2020 09:00	0.0	0	0	0	0	1
09/07/2020 10:00	0.0	0	0	0	0	1
09/07/2020 11:00	0.0	0	0	0	0	1
09/07/2020 12:00	0.0	0	0	0	0	1
09/07/2020 13:00	0.0	0	0	0	0	1
09/07/2020 14:00	0.0	0	0	0	0	1
09/07/2020 15:00	0.0	0	0	0	0	1
09/07/2020 16:00	0.0	0	0	0	0	1
09/07/2020 17:00	0.0	0	0	0	0	1
09/07/2020 18:00	0.0	0	0	0	0	1
09/07/2020 19:00	0.0	0	0	0	0	1
09/07/2020 20:00	0.0	0	0	0	0	1
09/07/2020 21:00	0.0	0	0	0	0	1
09/07/2020 22:00	0.0	0	0	0	0	1
09/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/08/2020 00:00	0.0	0	0	0	0	1
09/08/2020 01:00	0.0	0	0	0	0	1
09/08/2020 02:00	0.0	0	0	0	0	1
09/08/2020 03:00	0.0	0	0	0	0	1
09/08/2020 04:00	0.0	0	0	0	0	1
09/08/2020 05:00	0.0	0	0	0	0	1
09/08/2020 06:00	0.0	0	0	0	0	1
09/08/2020 07:00	0.0	0	0	0	0	1
09/08/2020 08:00	0.0	0	0	0	0	1
09/08/2020 09:00	0.0	0	0	0	0	1
09/08/2020 10:00	0.0	0	0	0	0	1
09/08/2020 11:00	0.0	0	0	0	0	1
09/08/2020 12:00	0.0	0	0	0	0	1
09/08/2020 13:00	0.0	0	0	0	0	1
09/08/2020 14:00	0.0	0	0	0	0	1
09/08/2020 15:00	0.0	0	0	0	0	1
09/08/2020 16:00	0.0	0	0	0	0	1
09/08/2020 17:00	0.0	0	0	0	0	1
09/08/2020 18:00	0.0	0	0	0	0	1
09/08/2020 19:00	0.0	0	0	0	0	1
09/08/2020 20:00	0.0	0	0	0	0	1
09/08/2020 21:00	0.0	0	0	0	0	1
09/08/2020 22:00	0.0	0	0	0	0	1
09/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/09/2020 00:00	0.0	0	0	0	0	1
09/09/2020 01:00	0.0	0	0	0	0	1
09/09/2020 02:00	0.0	0	0	0	0	1
09/09/2020 03:00	0.0	0	0	0	0	1
09/09/2020 04:00	0.0	0	0	0	0	1
09/09/2020 05:00	0.0	0	0	0	0	1
09/09/2020 06:00	0.0	0	0	0	0	1
09/09/2020 07:00	0.0	0	0	0	0	1
09/09/2020 08:00	0.0	0	0	0	0	1
09/09/2020 09:00	0.0	0	0	0	0	1
09/09/2020 10:00	0.0	0	0	0	0	1
09/09/2020 11:00	0.0	0	0	0	0	1
09/09/2020 12:00	0.0	0	0	0	0	1
09/09/2020 13:00	0.0	0	0	0	0	1
09/09/2020 14:00	0.0	0	0	0	0	1
09/09/2020 15:00	0.0	0	0	0	0	1
09/09/2020 16:00	0.0	0	0	0	0	1
09/09/2020 17:00	0.0	0	0	0	0	1
09/09/2020 18:00	0.0	0	0	0	0	1
09/09/2020 19:00	0.0	0	0	0	0	1
09/09/2020 20:00	0.0	0	0	0	0	1
09/09/2020 21:00	0.0	0	0	0	0	1
09/09/2020 22:00	0.0	0	0	0	0	1
09/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/10/2020 00:00	0.0	0	0	0	0	1
09/10/2020 01:00	0.0	0	0	0	0	1
09/10/2020 02:00	0.0	0	0	0	0	1
09/10/2020 03:00	0.0	0	0	0	0	1
09/10/2020 04:00	0.0	0	0	0	0	1
09/10/2020 05:00	0.0	0	0	0	0	1
09/10/2020 06:00	0.0	0	0	0	0	1
09/10/2020 07:00	0.0	0	0	0	0	1
09/10/2020 08:00	0.0	0	0	0	0	1
09/10/2020 09:00	0.0	0	0	0	0	1
09/10/2020 10:00	0.0	0	0	0	0	1
09/10/2020 11:00	0.0	0	0	0	0	1
09/10/2020 12:00	0.0	0	0	0	0	1
09/10/2020 13:00	0.0	0	0	0	0	1
09/10/2020 14:00	0.0	0	0	0	0	1
09/10/2020 15:00	0.0	0	0	0	0	1
09/10/2020 16:00	0.0	0	0	0	0	1
09/10/2020 17:00	0.0	0	0	0	0	1
09/10/2020 18:00	0.0	0	0	0	0	1
09/10/2020 19:00	0.0	0	0	0	0	1
09/10/2020 20:00	0.0	0	0	0	0	1
09/10/2020 21:00	0.0	0	0	0	0	1
09/10/2020 22:00	0.0	0	0	0	0	1
09/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/11/2020 00:00	0.0	0	0	0	0	1
09/11/2020 01:00	0.0	0	0	0	0	1
09/11/2020 02:00	0.0	0	0	0	0	1
09/11/2020 03:00	0.0	0	0	0	0	1
09/11/2020 04:00	0.0	0	0	0	0	1
09/11/2020 05:00	0.0	0	0	0	0	1
09/11/2020 06:00	0.0	0	0	0	0	1
09/11/2020 07:00	0.0	0	0	0	0	1
09/11/2020 08:00	0.0	0	0	0	0	1
09/11/2020 09:00	0.0	0	0	0	0	1
09/11/2020 10:00	0.0	0	0	0	0	1
09/11/2020 11:00	0.0	0	0	0	0	1
09/11/2020 12:00	0.0	0	0	0	0	1
09/11/2020 13:00	0.0	0	0	0	0	1
09/11/2020 14:00	0.0	0	0	0	0	1
09/11/2020 15:00	0.0	0	0	0	0	1
09/11/2020 16:00	0.0	0	0	0	0	1
09/11/2020 17:00	0.0	0	0	0	0	1
09/11/2020 18:00	0.0	0	0	0	0	1
09/11/2020 19:00	0.0	0	0	0	0	1
09/11/2020 20:00	0.0	0	0	0	0	1
09/11/2020 21:00	0.0	0	0	0	0	1
09/11/2020 22:00	0.0	0	0	0	0	1
09/11/2020 23:00	95.1	0	0	0	1	0
Average/Sum#:	95.1 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	95.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/12/2020 00:00	0.0	0	0	0	0	0
09/12/2020 01:00	0.0	0	0	0	0	0
09/12/2020 02:00	0.0	0	0	0	0	0
09/12/2020 03:00	0.0	0	0	0	0	0
09/12/2020 04:00	0.0	0	0	0	0	0
09/12/2020 05:00	0.0	0	0	0	0	0
09/12/2020 06:00	0.0	0	0	0	0	0
09/12/2020 07:00	0.0	0	0	0	0	0
09/12/2020 08:00	0.0	0	0	0	0	0
09/12/2020 09:00	0.0	0	0	0	0	0
09/12/2020 10:00	0.0	0	0	0	0	0
09/12/2020 11:00	0.0	0	0	0	0	0
09/12/2020 12:00	0.0	0	0	0	0	0
09/12/2020 13:00	0.0	0	0	0	0	0
09/12/2020 14:00	0.0	0	0	0	0	0
09/12/2020 15:00	0.0	0	0	0	0	0
09/12/2020 16:00	0.0	0	0	0	0	0
09/12/2020 17:00	0.0	0	0	0	0	0
09/12/2020 18:00	0.0	0	0	0	0	0
09/12/2020 19:00	0.0	0	0	0	0	0
09/12/2020 20:00	0.0	0	0	0	0	0
09/12/2020 21:00	0.0	0	0	0	0	0
09/12/2020 22:00	0.0	0	0	0	0	0
09/12/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/13/2020 00:00	0.0	0	0	0	0	0
09/13/2020 01:00	0.0	0	0	0	0	0
09/13/2020 02:00	0.0	0	0	0	0	0
09/13/2020 03:00	0.0	0	0	0	0	0
09/13/2020 04:00	0.0	0	0	0	0	0
09/13/2020 05:00	0.0	0	0	0	0	0
09/13/2020 06:00	0.0	0	0	0	0	0
09/13/2020 07:00	0.0	0	0	0	0	0
09/13/2020 08:00	0.0	0	0	0	0	0
09/13/2020 09:00	0.0	0	0	0	0	0
09/13/2020 10:00	0.0	0	0	0	0	0
09/13/2020 11:00	0.0	0	0	0	0	0
09/13/2020 12:00	0.0	0	0	0	0	0
09/13/2020 13:00	0.0	0	0	0	0	0
09/13/2020 14:00	0.0	0	0	0	0	0
09/13/2020 15:00	0.0	0	0	0	0	0
09/13/2020 16:00	0.0	0	0	0	0	0
09/13/2020 17:00	0.0	0	0	0	0	0
09/13/2020 18:00	0.0	0	0	0	0	0
09/13/2020 19:00	0.0	0	0	0	0	0
09/13/2020 20:00	0.0	0	0	0	0	0
09/13/2020 21:00	0.0	0	0	0	0	0
09/13/2020 22:00	0.0	0	0	0	0	0
09/13/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/14/2020 00:00	0.0	0	0	0	0	0
09/14/2020 01:00	0.0	0	0	0	0	0
09/14/2020 02:00	0.0	0	0	0	0	0
09/14/2020 03:00	0.0	0	0	0	0	0
09/14/2020 04:00	0.0	0	0	0	0	0
09/14/2020 05:00	0.0	0	0	0	0	0
09/14/2020 06:00	0.0	0	0	0	0	0
09/14/2020 07:00	0.0	0	0	0	0	0
09/14/2020 08:00	0.0	0	0	0	0	0
09/14/2020 09:00	0.0	0	0	0	0	0
09/14/2020 10:00	0.0	0	0	0	0	0
09/14/2020 11:00	0.0	0	0	0	0	0
09/14/2020 12:00	0.0	0	0	0	0	0
09/14/2020 13:00	2,451.0	0	1	0	0	0
09/14/2020 14:00	6,662.2	0	1	0	0	0
09/14/2020 15:00	1,965.3	0	1	0	0	0
09/14/2020 16:00	0.0	0	0	0	0	1
09/14/2020 17:00	0.0	0	0	0	0	1
09/14/2020 18:00	0.0	0	0	0	0	1
09/14/2020 19:00	0.0	0	0	0	0	1
09/14/2020 20:00	0.0	0	0	0	0	1
09/14/2020 21:00	0.0	0	0	0	0	1
09/14/2020 22:00	0.0	0	0	0	0	1
09/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	11,078.5 #	0 #	3 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,662.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/15/2020 00:00	0.0	0	0	0	0	1
09/15/2020 01:00	0.0	0	0	0	0	1
09/15/2020 02:00	0.0	0	0	0	0	1
09/15/2020 03:00	0.0	0	0	0	0	1
09/15/2020 04:00	0.0	0	0	0	0	1
09/15/2020 05:00	0.0	0	0	0	0	1
09/15/2020 06:00	0.0	0	0	0	0	1
09/15/2020 07:00	0.0	0	0	0	0	1
09/15/2020 08:00	0.0	0	0	0	0	1
09/15/2020 09:00	0.0	0	0	0	0	1
09/15/2020 10:00	0.0	0	0	0	0	1
09/15/2020 11:00	0.0	0	0	0	0	1
09/15/2020 12:00	0.0	0	0	0	0	1
09/15/2020 13:00	0.0	0	0	0	0	1
09/15/2020 14:00	0.0	0	0	0	0	1
09/15/2020 15:00	0.0	0	0	0	0	1
09/15/2020 16:00	0.0	0	0	0	0	1
09/15/2020 17:00	0.0	0	0	0	0	1
09/15/2020 18:00	0.0	0	0	0	0	1
09/15/2020 19:00	0.0	0	0	0	0	1
09/15/2020 20:00	0.0	0	0	0	0	1
09/15/2020 21:00	0.0	0	0	0	0	1
09/15/2020 22:00	83.9	0	0	0	1	0
09/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	83.9 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	83.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/16/2020 00:00	0.0	0	0	0	0	0
09/16/2020 01:00	0.0	0	0	0	0	0
09/16/2020 02:00	0.0	0	0	0	0	0
09/16/2020 03:00	0.0	0	0	0	0	0
09/16/2020 04:00	0.0	0	0	0	0	0
09/16/2020 05:00	0.0	0	0	0	0	0
09/16/2020 06:00	2,254.5	0	1	0	0	0
09/16/2020 07:00	4,796.2	0	1	0	0	0
09/16/2020 08:00	0.0	0	0	0	0	1
09/16/2020 09:00	0.0	0	0	0	0	1
09/16/2020 10:00	0.0	0	0	0	0	1
09/16/2020 11:00	0.0	0	0	0	0	1
09/16/2020 12:00	0.0	0	0	0	0	1
09/16/2020 13:00	0.0	0	0	0	0	1
09/16/2020 14:00	0.0	0	0	0	0	1
09/16/2020 15:00	0.0	0	0	0	0	1
09/16/2020 16:00	0.0	0	0	0	0	1
09/16/2020 17:00	0.0	0	0	0	0	1
09/16/2020 18:00	0.0	0	0	0	0	1
09/16/2020 19:00	0.0	0	0	0	0	1
09/16/2020 20:00	0.0	0	0	0	0	1
09/16/2020 21:00	0.0	0	0	0	0	1
09/16/2020 22:00	0.0	0	0	0	0	1
09/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,050.7 #	0 #	2 #	0 #	0 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,796.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/17/2020 00:00	0.0	0	0	0	0	1
09/17/2020 01:00	0.0	0	0	0	0	1
09/17/2020 02:00	0.0	0	0	0	0	1
09/17/2020 03:00	0.0	0	0	0	0	1
09/17/2020 04:00	0.0	0	0	0	0	1
09/17/2020 05:00	0.0	0	0	0	0	1
09/17/2020 06:00	0.0	0	0	0	0	1
09/17/2020 07:00	0.0	0	0	0	0	1
09/17/2020 08:00	0.0	0	0	0	0	1
09/17/2020 09:00	0.0	0	0	0	0	1
09/17/2020 10:00	0.0	0	0	0	0	1
09/17/2020 11:00	0.0	0	0	0	0	1
09/17/2020 12:00	0.0	0	0	0	0	1
09/17/2020 13:00	0.0	0	0	0	0	1
09/17/2020 14:00	0.0	0	0	0	0	1
09/17/2020 15:00	0.0	0	0	0	0	1
09/17/2020 16:00	0.0	0	0	0	0	1
09/17/2020 17:00	0.0	0	0	0	0	1
09/17/2020 18:00	0.0	0	0	0	0	1
09/17/2020 19:00	0.0	0	0	0	0	1
09/17/2020 20:00	0.0	0	0	0	0	1
09/17/2020 21:00	0.0	0	0	0	0	1
09/17/2020 22:00	0.0	0	0	0	0	1
09/17/2020 23:00	99.8	0	0	0	1	0
Average/Sum#:	99.8 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	99.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/18/2020 00:00	0.0	0	0	0	1	0
09/18/2020 01:00	0.0	0	0	0	0	0
09/18/2020 02:00	0.0	0	0	0	0	0
09/18/2020 03:00	0.0	0	0	0	0	0
09/18/2020 04:00	0.0	0	0	0	0	0
09/18/2020 05:00	0.0	0	0	0	0	0
09/18/2020 06:00	1,803.0	0	0	1	0	0
09/18/2020 07:00	6,018.9	0	0	1	0	0
09/18/2020 08:00	0.0	0	0	0	0	1
09/18/2020 09:00	0.0	0	0	0	0	1
09/18/2020 10:00	0.0	0	0	0	0	1
09/18/2020 11:00	0.0	0	0	0	0	1
09/18/2020 12:00	0.0	0	0	0	0	1
09/18/2020 13:00	0.0	0	0	0	0	1
09/18/2020 14:00	0.0	0	0	0	0	1
09/18/2020 15:00	0.0	0	0	0	0	1
09/18/2020 16:00	0.0	0	0	0	0	1
09/18/2020 17:00	0.0	0	0	0	0	1
09/18/2020 18:00	0.0	0	0	0	0	1
09/18/2020 19:00	0.0	0	0	0	0	1
09/18/2020 20:00	0.0	0	0	0	0	1
09/18/2020 21:00	0.0	0	0	0	0	1
09/18/2020 22:00	103.7	0	0	0	1	0
09/18/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	7,925.6 #	0 #	0 #	2 #	2 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,018.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/19/2020 00:00	0.0	0	0	0	0	0
09/19/2020 01:00	0.0	0	0	0	0	0
09/19/2020 02:00	0.0	0	0	0	0	0
09/19/2020 03:00	0.0	0	0	0	0	0
09/19/2020 04:00	921.0	0	0	1	0	0
09/19/2020 05:00	6,441.6	0	0	1	0	0
09/19/2020 06:00	0.0	0	0	0	0	1
09/19/2020 07:00	0.0	0	0	0	0	1
09/19/2020 08:00	0.0	0	0	0	0	1
09/19/2020 09:00	0.0	0	0	0	0	1
09/19/2020 10:00	0.0	0	0	0	0	1
09/19/2020 11:00	0.0	0	0	0	0	1
09/19/2020 12:00	0.0	0	0	0	0	1
09/19/2020 13:00	0.0	0	0	0	0	1
09/19/2020 14:00	0.0	0	0	0	0	1
09/19/2020 15:00	0.0	0	0	0	0	1
09/19/2020 16:00	0.0	0	0	0	0	1
09/19/2020 17:00	0.0	0	0	0	0	1
09/19/2020 18:00	0.0	0	0	0	0	1
09/19/2020 19:00	0.0	0	0	0	0	1
09/19/2020 20:00	0.0	0	0	0	0	1
09/19/2020 21:00	0.0	0	0	0	0	1
09/19/2020 22:00	0.0	0	0	0	0	1
09/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,362.6 #	0 #	0 #	2 #	0 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,441.6	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/20/2020 00:00	0.0	0	0	0	0	1
09/20/2020 01:00	0.0	0	0	0	0	1
09/20/2020 02:00	0.0	0	0	0	0	1
09/20/2020 03:00	0.0	0	0	0	0	1
09/20/2020 04:00	0.0	0	0	0	0	1
09/20/2020 05:00	0.0	0	0	0	0	1
09/20/2020 06:00	115.9	0	0	0	1	0
09/20/2020 07:00	0.0	0	0	0	0	0
09/20/2020 08:00	0.0	0	0	0	0	0
09/20/2020 09:00	0.0	0	0	0	0	0
09/20/2020 10:00	1,909.3	0	0	1	0	0
09/20/2020 11:00	5,348.0	0	0	1	0	0
09/20/2020 12:00	0.0	0	0	0	0	1
09/20/2020 13:00	0.0	0	0	0	0	1
09/20/2020 14:00	0.0	0	0	0	0	1
09/20/2020 15:00	0.0	0	0	0	0	1
09/20/2020 16:00	0.0	0	0	0	0	1
09/20/2020 17:00	0.0	0	0	0	0	1
09/20/2020 18:00	0.0	0	0	0	0	1
09/20/2020 19:00	0.0	0	0	0	0	1
09/20/2020 20:00	0.0	0	0	0	0	1
09/20/2020 21:00	0.0	0	0	0	0	1
09/20/2020 22:00	122.1	0	0	0	1	0
09/20/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	7,495.3 #	0 #	0 #	2 #	2 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,348.0	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/21/2020 00:00	0.0	0	0	0	0	0
09/21/2020 01:00	0.0	0	0	0	0	0
09/21/2020 02:00	0.0	0	0	0	0	0
09/21/2020 03:00	0.0	0	0	0	0	0
09/21/2020 04:00	0.0	0	0	0	0	0
09/21/2020 05:00	0.0	0	0	0	0	0
09/21/2020 06:00	0.0	0	0	0	0	0
09/21/2020 07:00	0.0	0	0	0	0	0
09/21/2020 08:00	0.0	0	0	0	0	0
09/21/2020 09:00	0.0	0	0	0	0	0
09/21/2020 10:00	0.0	0	0	0	0	0
09/21/2020 11:00	0.0	0	0	0	0	0
09/21/2020 12:00	0.0	0	0	0	0	0
09/21/2020 13:00	2,182.1	0	1	0	0	0
09/21/2020 14:00	7,190.6	0	1	0	0	0
09/21/2020 15:00	0.0	0	0	0	0	1
09/21/2020 16:00	0.0	0	0	0	0	1
09/21/2020 17:00	0.0	0	0	0	0	1
09/21/2020 18:00	0.0	0	0	0	0	1
09/21/2020 19:00	0.0	0	0	0	0	1
09/21/2020 20:00	0.0	0	0	0	0	1
09/21/2020 21:00	0.0	0	0	0	0	1
09/21/2020 22:00	120.0	0	0	0	1	0
09/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	9,492.7 #	0 #	2 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,190.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/22/2020 00:00	0.0	0	0	0	0	0
09/22/2020 01:00	0.0	0	0	0	0	0
09/22/2020 02:00	0.0	0	0	0	0	0
09/22/2020 03:00	0.0	0	0	0	0	0
09/22/2020 04:00	0.0	0	0	0	0	0
09/22/2020 05:00	0.0	0	0	0	0	0
09/22/2020 06:00	0.0	0	0	0	0	0
09/22/2020 07:00	0.0	0	0	0	0	0
09/22/2020 08:00	0.0	0	0	0	0	0
09/22/2020 09:00	0.0	0	0	0	0	0
09/22/2020 10:00	0.0	0	0	0	0	0
09/22/2020 11:00	0.0	0	0	0	0	0
09/22/2020 12:00	0.0	0	0	0	0	0
09/22/2020 13:00	0.0	0	0	0	0	0
09/22/2020 14:00	1,797.1	0	1	0	0	0
09/22/2020 15:00	7,124.1	0	1	0	0	0
09/22/2020 16:00	0.0	0	0	0	0	1
09/22/2020 17:00	0.0	0	0	0	0	1
09/22/2020 18:00	0.0	0	0	0	0	1
09/22/2020 19:00	0.0	0	0	0	0	1
09/22/2020 20:00	0.0	0	0	0	0	1
09/22/2020 21:00	119.2	0	0	0	1	0
09/22/2020 22:00	0.0	0	0	0	0	0
09/22/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	9,040.4 #	0 #	2 #	0 #	1 #	5 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,124.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/23/2020 00:00	0.0	0	0	0	0	0
09/23/2020 01:00	0.0	0	0	0	0	0
09/23/2020 02:00	0.0	0	0	0	0	0
09/23/2020 03:00	0.0	0	0	0	0	0
09/23/2020 04:00	0.0	0	0	0	0	0
09/23/2020 05:00	0.0	0	0	0	0	0
09/23/2020 06:00	0.0	0	0	0	0	0
09/23/2020 07:00	0.0	0	0	0	0	0
09/23/2020 08:00	0.0	0	0	0	0	0
09/23/2020 09:00	0.0	0	0	0	0	0
09/23/2020 10:00	0.0	0	0	0	0	0
09/23/2020 11:00	0.0	0	0	0	0	0
09/23/2020 12:00	0.0	0	0	0	0	0
09/23/2020 13:00	1,774.9	0	1	0	0	0
09/23/2020 14:00	7,263.5	0	1	0	0	0
09/23/2020 15:00	0.0	0	0	0	0	1
09/23/2020 16:00	0.0	0	0	0	0	1
09/23/2020 17:00	0.0	0	0	0	0	1
09/23/2020 18:00	0.0	0	0	0	0	1
09/23/2020 19:00	0.0	0	0	0	0	1
09/23/2020 20:00	0.0	0	0	0	0	1
09/23/2020 21:00	102.0	0	0	0	1	0
09/23/2020 22:00	0.0	0	0	0	0	0
09/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	9,140.4 #	0 #	2 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,263.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/24/2020 00:00	0.0	0	0	0	0	0
09/24/2020 01:00	0.0	0	0	0	0	0
09/24/2020 02:00	0.0	0	0	0	0	0
09/24/2020 03:00	0.0	0	0	0	0	0
09/24/2020 04:00	0.0	0	0	0	0	0
09/24/2020 05:00	0.0	0	0	0	0	0
09/24/2020 06:00	0.0	0	0	0	0	0
09/24/2020 07:00	0.0	0	0	0	0	0
09/24/2020 08:00	1,408.3	0	1	0	0	0
09/24/2020 09:00	4,987.8	0	1	0	0	0
09/24/2020 10:00	6,138.9	0	1	0	0	0
09/24/2020 11:00	0.0	0	0	0	0	1
09/24/2020 12:00	0.0	0	0	0	0	1
09/24/2020 13:00	0.0	0	0	0	0	1
09/24/2020 14:00	0.0	0	0	0	0	1
09/24/2020 15:00	0.0	0	0	0	0	1
09/24/2020 16:00	0.0	0	0	0	0	1
09/24/2020 17:00	0.0	0	0	0	0	1
09/24/2020 18:00	0.0	0	0	0	0	1
09/24/2020 19:00	0.0	0	0	0	0	1
09/24/2020 20:00	137.3	0	0	0	1	0
09/24/2020 21:00	0.0	0	0	0	0	0
09/24/2020 22:00	0.0	0	0	0	0	0
09/24/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	12,672.3 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,138.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/25/2020 00:00	0.0	0	0	0	0	0
09/25/2020 01:00	0.0	0	0	0	0	0
09/25/2020 02:00	0.0	0	0	0	0	0
09/25/2020 03:00	0.0	0	0	0	0	0
09/25/2020 04:00	0.0	0	0	0	0	0
09/25/2020 05:00	0.0	0	0	0	0	0
09/25/2020 06:00	0.0	0	0	0	0	0
09/25/2020 07:00	0.0	0	0	0	0	0
09/25/2020 08:00	0.0	0	0	0	0	0
09/25/2020 09:00	0.0	0	0	0	0	0
09/25/2020 10:00	0.0	0	0	0	0	0
09/25/2020 11:00	0.0	0	0	0	0	0
09/25/2020 12:00	0.0	0	0	0	0	0
09/25/2020 13:00	0.0	0	0	0	0	0
09/25/2020 14:00	0.0	0	0	0	0	0
09/25/2020 15:00	0.0	0	0	0	0	0
09/25/2020 16:00	0.0	0	0	0	0	0
09/25/2020 17:00	0.0	0	0	0	0	0
09/25/2020 18:00	0.0	0	0	0	0	0
09/25/2020 19:00	0.0	0	0	0	0	0
09/25/2020 20:00	0.0	0	0	0	0	0
09/25/2020 21:00	0.0	0	0	0	0	0
09/25/2020 22:00	0.0	0	0	0	0	0
09/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/26/2020 00:00	0.0	0	0	0	0	0
09/26/2020 01:00	0.0	0	0	0	0	0
09/26/2020 02:00	0.0	0	0	0	0	0
09/26/2020 03:00	0.0	0	0	0	0	0
09/26/2020 04:00	0.0	0	0	0	0	0
09/26/2020 05:00	0.0	0	0	0	0	0
09/26/2020 06:00	0.0	0	0	0	0	0
09/26/2020 07:00	0.0	0	0	0	0	0
09/26/2020 08:00	0.0	0	0	0	0	0
09/26/2020 09:00	0.0	0	0	0	0	0
09/26/2020 10:00	0.0	0	0	0	0	0
09/26/2020 11:00	0.0	0	0	0	0	0
09/26/2020 12:00	0.0	0	0	0	0	0
09/26/2020 13:00	0.0	0	0	0	0	0
09/26/2020 14:00	0.0	0	0	0	0	0
09/26/2020 15:00	0.0	0	0	0	0	0
09/26/2020 16:00	0.0	0	0	0	0	0
09/26/2020 17:00	0.0	0	0	0	0	0
09/26/2020 18:00	0.0	0	0	0	0	0
09/26/2020 19:00	0.0	0	0	0	0	0
09/26/2020 20:00	0.0	0	0	0	0	0
09/26/2020 21:00	0.0	0	0	0	0	0
09/26/2020 22:00	0.0	0	0	0	0	0
09/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/27/2020 00:00	0.0	0	0	0	0	0
09/27/2020 01:00	0.0	0	0	0	0	0
09/27/2020 02:00	0.0	0	0	0	0	0
09/27/2020 03:00	0.0	0	0	0	0	0
09/27/2020 04:00	0.0	0	0	0	0	0
09/27/2020 05:00	0.0	0	0	0	0	0
09/27/2020 06:00	0.0	0	0	0	0	0
09/27/2020 07:00	0.0	0	0	0	0	0
09/27/2020 08:00	157.3	0	1	0	0	0
09/27/2020 09:00	0.0	0	0	0	0	0
09/27/2020 10:00	0.0	0	0	0	0	0
09/27/2020 11:00	0.0	0	0	0	0	0
09/27/2020 12:00	0.0	0	0	0	0	0
09/27/2020 13:00	348.5	0	1	0	0	0
09/27/2020 14:00	5,821.4	0	1	0	0	0
09/27/2020 15:00	2,012.6	0	1	0	0	0
09/27/2020 16:00	0.0	0	0	0	0	1
09/27/2020 17:00	0.0	0	0	0	0	1
09/27/2020 18:00	0.0	0	0	0	0	1
09/27/2020 19:00	0.0	0	0	0	0	1
09/27/2020 20:00	0.0	0	0	0	0	1
09/27/2020 21:00	0.0	0	0	0	0	1
09/27/2020 22:00	125.9	0	0	0	1	0
09/27/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	8,465.7 #	0 #	4 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,821.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/28/2020 00:00	0.0	0	0	0	0	0
09/28/2020 01:00	0.0	0	0	0	0	0
09/28/2020 02:00	0.0	0	0	0	0	0
09/28/2020 03:00	0.0	0	0	0	0	0
09/28/2020 04:00	0.0	0	0	0	0	0
09/28/2020 05:00	0.0	0	0	0	0	0
09/28/2020 06:00	1,430.0	0	1	0	0	0
09/28/2020 07:00	6,338.4	0	1	0	0	0
09/28/2020 08:00	0.0	0	0	0	0	1
09/28/2020 09:00	0.0	0	0	0	0	1
09/28/2020 10:00	0.0	0	0	0	0	1
09/28/2020 11:00	0.0	0	0	0	0	1
09/28/2020 12:00	0.0	0	0	0	0	1
09/28/2020 13:00	0.0	0	0	0	0	1
09/28/2020 14:00	0.0	0	0	0	0	1
09/28/2020 15:00	0.0	0	0	0	0	1
09/28/2020 16:00	0.0	0	0	0	0	1
09/28/2020 17:00	0.0	0	0	0	0	1
09/28/2020 18:00	0.0	0	0	0	0	1
09/28/2020 19:00	0.0	0	0	0	0	1
09/28/2020 20:00	0.0	0	0	0	0	1
09/28/2020 21:00	0.0	0	0	0	0	1
09/28/2020 22:00	120.5	0	0	0	1	0
09/28/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	7,888.9 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,338.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/29/2020 00:00	0.0	0	0	0	0	0
09/29/2020 01:00	0.0	0	0	0	0	0
09/29/2020 02:00	0.0	0	0	0	0	0
09/29/2020 03:00	0.0	0	0	0	0	0
09/29/2020 04:00	0.0	0	0	0	0	0
09/29/2020 05:00	0.0	0	0	0	0	0
09/29/2020 06:00	1,588.4	0	1	0	0	0
09/29/2020 07:00	6,771.9	0	1	0	0	0
09/29/2020 08:00	0.0	0	0	0	0	1
09/29/2020 09:00	0.0	0	0	0	0	1
09/29/2020 10:00	0.0	0	0	0	0	1
09/29/2020 11:00	0.0	0	0	0	0	1
09/29/2020 12:00	0.0	0	0	0	0	1
09/29/2020 13:00	0.0	0	0	0	0	1
09/29/2020 14:00	0.0	0	0	0	0	1
09/29/2020 15:00	0.0	0	0	0	0	1
09/29/2020 16:00	0.0	0	0	0	0	1
09/29/2020 17:00	0.0	0	0	0	0	1
09/29/2020 18:00	0.0	0	0	0	0	1
09/29/2020 19:00	0.0	0	0	0	0	1
09/29/2020 20:00	0.0	0	0	0	0	1
09/29/2020 21:00	0.0	0	0	0	0	1
09/29/2020 22:00	0.0	0	0	0	0	1
09/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,360.3 #	0 #	2 #	0 #	0 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,771.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/30/2020 00:00	0.0	0	0	0	0	1
09/30/2020 01:00	0.0	0	0	0	0	1
09/30/2020 02:00	0.0	0	0	0	0	1
09/30/2020 03:00	0.0	0	0	0	0	1
09/30/2020 04:00	0.0	0	0	0	0	1
09/30/2020 05:00	0.0	0	0	0	0	1
09/30/2020 06:00	0.0	0	0	0	0	1
09/30/2020 07:00	0.0	0	0	0	0	1
09/30/2020 08:00	0.0	0	0	0	0	1
09/30/2020 09:00	0.0	0	0	0	0	1
09/30/2020 10:00	0.0	0	0	0	0	1
09/30/2020 11:00	0.0	0	0	0	0	1
09/30/2020 12:00	0.0	0	0	0	0	1
09/30/2020 13:00	0.0	0	0	0	0	1
09/30/2020 14:00	0.0	0	0	0	0	1
09/30/2020 15:00	0.0	0	0	0	0	1
09/30/2020 16:00	0.0	0	0	0	0	1
09/30/2020 17:00	0.0	0	0	0	0	1
09/30/2020 18:00	0.0	0	0	0	0	1
09/30/2020 19:00	0.0	0	0	0	0	1
09/30/2020 20:00	0.0	0	0	0	0	1
09/30/2020 21:00	0.0	0	0	0	0	1
09/30/2020 22:00	0.0	0	0	0	0	1
09/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/01/2020 00:00	0.0	0	0	0	0	0
07/01/2020 01:00	0.0	0	0	0	0	0
07/01/2020 02:00	0.0	0	0	0	0	0
07/01/2020 03:00	0.0	0	0	0	0	0
07/01/2020 04:00	0.0	0	0	0	0	0
07/01/2020 05:00	0.0	0	0	0	0	0
07/01/2020 06:00	0.0	0	0	0	0	0
07/01/2020 07:00	0.0	0	0	0	0	0
07/01/2020 08:00	0.0	0	0	0	0	0
07/01/2020 09:00	0.0	0	0	0	0	0
07/01/2020 10:00	0.0	0	0	0	0	0
07/01/2020 11:00	0.0	0	0	0	0	0
07/01/2020 12:00	0.0	0	0	0	0	0
07/01/2020 13:00	0.0	0	0	0	0	0
07/01/2020 14:00	0.0	0	0	0	0	0
07/01/2020 15:00	0.0	0	0	0	0	0
07/01/2020 16:00	0.0	0	0	0	0	0
07/01/2020 17:00	0.0	0	0	0	0	0
07/01/2020 18:00	0.0	0	0	0	0	0
07/01/2020 19:00	0.0	0	0	0	0	0
07/01/2020 20:00	0.0	0	0	0	0	0
07/01/2020 21:00	0.0	0	0	0	0	0
07/01/2020 22:00	0.0	0	0	0	0	0
07/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/02/2020 00:00	0.0	0	0	0	0	0
07/02/2020 01:00	0.0	0	0	0	0	0
07/02/2020 02:00	0.0	0	0	0	0	0
07/02/2020 03:00	0.0	0	0	0	0	0
07/02/2020 04:00	0.0	0	0	0	0	0
07/02/2020 05:00	0.0	0	0	0	0	0
07/02/2020 06:00	0.0	0	0	0	0	0
07/02/2020 07:00	0.0	0	0	0	0	0
07/02/2020 08:00	0.0	0	0	0	0	0
07/02/2020 09:00	0.0	0	0	0	0	0
07/02/2020 10:00	0.0	0	0	0	0	0
07/02/2020 11:00	0.0	0	0	0	0	0
07/02/2020 12:00	0.0	0	0	0	0	0
07/02/2020 13:00	0.0	0	0	0	0	0
07/02/2020 14:00	0.0	0	0	0	0	0
07/02/2020 15:00	0.0	0	0	0	0	0
07/02/2020 16:00	0.0	0	0	0	0	0
07/02/2020 17:00	0.0	0	0	0	0	0
07/02/2020 18:00	0.0	0	0	0	0	0
07/02/2020 19:00	0.0	0	0	0	0	0
07/02/2020 20:00	0.0	0	0	0	0	0
07/02/2020 21:00	0.0	0	0	0	0	0
07/02/2020 22:00	0.0	0	0	0	0	0
07/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/03/2020 00:00	0.0	0	0	0	0	0
07/03/2020 01:00	0.0	0	0	0	0	0
07/03/2020 02:00	0.0	0	0	0	0	0
07/03/2020 03:00	0.0	0	0	0	0	0
07/03/2020 04:00	0.0	0	0	0	0	0
07/03/2020 05:00	0.0	0	0	0	0	0
07/03/2020 06:00	0.0	0	0	0	0	0
07/03/2020 07:00	0.0	0	0	0	0	0
07/03/2020 08:00	0.0	0	0	0	0	0
07/03/2020 09:00	0.0	0	0	0	0	0
07/03/2020 10:00	0.0	0	0	0	0	0
07/03/2020 11:00	0.0	0	0	0	0	0
07/03/2020 12:00	0.0	0	0	0	0	0
07/03/2020 13:00	61.6	0	1	0	0	0
07/03/2020 14:00	29.5	0	1	0	0	0
07/03/2020 15:00	0.0	0	0	0	0	1
07/03/2020 16:00	0.0	0	0	0	0	1
07/03/2020 17:00	0.0	0	0	0	0	1
07/03/2020 18:00	0.0	0	0	0	0	1
07/03/2020 19:00	0.0	0	0	0	0	1
07/03/2020 20:00	0.0	0	0	0	0	1
07/03/2020 21:00	0.0	0	0	0	0	1
07/03/2020 22:00	0.0	0	0	0	0	1
07/03/2020 23:00	0.6	0	0	0	1	0
Average/Sum#:	91.7 #	0 #	2 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	61.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/04/2020 00:00	0.0	0	0	0	0	0
07/04/2020 01:00	0.0	0	0	0	0	0
07/04/2020 02:00	0.0	0	0	0	0	0
07/04/2020 03:00	0.0	0	0	0	0	0
07/04/2020 04:00	0.0	0	0	0	0	0
07/04/2020 05:00	0.0	0	0	0	0	0
07/04/2020 06:00	0.0	0	0	0	0	0
07/04/2020 07:00	0.0	0	0	0	0	0
07/04/2020 08:00	0.0	0	0	0	0	0
07/04/2020 09:00	0.0	0	0	0	0	0
07/04/2020 10:00	0.0	0	0	0	0	0
07/04/2020 11:00	0.0	0	0	0	0	0
07/04/2020 12:00	0.0	0	0	0	0	0
07/04/2020 13:00	0.0	0	0	0	0	0
07/04/2020 14:00	0.0	0	0	0	0	0
07/04/2020 15:00	0.0	0	0	0	0	0
07/04/2020 16:00	0.0	0	0	0	0	0
07/04/2020 17:00	0.0	0	0	0	0	0
07/04/2020 18:00	0.0	0	0	0	0	0
07/04/2020 19:00	0.0	0	0	0	0	0
07/04/2020 20:00	0.0	0	0	0	0	0
07/04/2020 21:00	0.0	0	0	0	0	0
07/04/2020 22:00	0.0	0	0	0	0	0
07/04/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/05/2020 00:00	0.0	0	0	0	0	0
07/05/2020 01:00	0.0	0	0	0	0	0
07/05/2020 02:00	0.0	0	0	0	0	0
07/05/2020 03:00	0.0	0	0	0	0	0
07/05/2020 04:00	0.0	0	0	0	0	0
07/05/2020 05:00	0.0	0	0	0	0	0
07/05/2020 06:00	0.0	0	0	0	0	0
07/05/2020 07:00	0.0	0	0	0	0	0
07/05/2020 08:00	0.0	0	0	0	0	0
07/05/2020 09:00	0.0	0	0	0	0	0
07/05/2020 10:00	0.0	0	0	0	0	0
07/05/2020 11:00	0.0	0	0	0	0	0
07/05/2020 12:00	0.0	0	0	0	0	0
07/05/2020 13:00	0.0	0	0	0	0	0
07/05/2020 14:00	54.8	0	1	0	0	0
07/05/2020 15:00	35.5	0	1	0	0	0
07/05/2020 16:00	0.0	0	0	0	0	1
07/05/2020 17:00	0.0	0	0	0	0	1
07/05/2020 18:00	0.0	0	0	0	0	1
07/05/2020 19:00	0.0	0	0	0	0	1
07/05/2020 20:00	0.0	0	0	0	0	1
07/05/2020 21:00	0.0	0	0	0	0	1
07/05/2020 22:00	0.5	0	0	0	1	0
07/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	90.8 #	0 #	2 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	54.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/06/2020 00:00	0.0	0	0	0	0	0
07/06/2020 01:00	0.0	0	0	0	0	0
07/06/2020 02:00	0.0	0	0	0	0	0
07/06/2020 03:00	0.0	0	0	0	0	0
07/06/2020 04:00	0.0	0	0	0	0	0
07/06/2020 05:00	0.0	0	0	0	0	0
07/06/2020 06:00	0.0	0	0	0	0	0
07/06/2020 07:00	0.0	0	0	0	0	0
07/06/2020 08:00	0.0	0	0	0	0	0
07/06/2020 09:00	0.0	0	0	0	0	0
07/06/2020 10:00	0.0	0	0	0	0	0
07/06/2020 11:00	20.5	0	1	0	0	0
07/06/2020 12:00	37.8	0	1	0	0	0
07/06/2020 13:00	0.0	0	0	0	0	1
07/06/2020 14:00	0.0	0	0	0	0	1
07/06/2020 15:00	0.0	0	0	0	0	1
07/06/2020 16:00	0.0	0	0	0	0	1
07/06/2020 17:00	0.0	0	0	0	0	1
07/06/2020 18:00	0.0	0	0	0	0	1
07/06/2020 19:00	0.0	0	0	0	0	1
07/06/2020 20:00	0.0	0	0	0	0	1
07/06/2020 21:00	0.0	0	0	0	0	1
07/06/2020 22:00	0.0	0	0	0	0	1
07/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	58.3 #	0 #	2 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	37.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/07/2020 00:00	0.0	0	0	0	0	1
07/07/2020 01:00	0.0	0	0	0	0	1
07/07/2020 02:00	0.0	0	0	0	0	1
07/07/2020 03:00	0.0	0	0	0	0	1
07/07/2020 04:00	0.0	0	0	0	0	1
07/07/2020 05:00	0.0	0	0	0	0	1
07/07/2020 06:00	0.0	0	0	0	0	1
07/07/2020 07:00	0.0	0	0	0	0	1
07/07/2020 08:00	0.0	0	0	0	0	1
07/07/2020 09:00	0.0	0	0	0	0	1
07/07/2020 10:00	0.0	0	0	0	0	1
07/07/2020 11:00	0.0	0	0	0	0	1
07/07/2020 12:00	0.0	0	0	0	0	1
07/07/2020 13:00	0.0	0	0	0	0	1
07/07/2020 14:00	0.0	0	0	0	0	1
07/07/2020 15:00	0.0	0	0	0	0	1
07/07/2020 16:00	0.0	0	0	0	0	1
07/07/2020 17:00	0.0	0	0	0	0	1
07/07/2020 18:00	0.0	0	0	0	0	1
07/07/2020 19:00	0.0	0	0	0	0	1
07/07/2020 20:00	0.0	0	0	0	0	1
07/07/2020 21:00	0.0	0	0	0	0	1
07/07/2020 22:00	0.0	0	0	0	0	1
07/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/08/2020 00:00	0.0	0	0	0	0	1
07/08/2020 01:00	0.0	0	0	0	0	1
07/08/2020 02:00	0.0	0	0	0	0	1
07/08/2020 03:00	0.0	0	0	0	0	1
07/08/2020 04:00	0.0	0	0	0	0	1
07/08/2020 05:00	0.0	0	0	0	0	1
07/08/2020 06:00	0.0	0	0	0	0	1
07/08/2020 07:00	0.0	0	0	0	0	1
07/08/2020 08:00	0.0	0	0	0	0	1
07/08/2020 09:00	0.0	0	0	0	0	1
07/08/2020 10:00	0.0	0	0	0	0	1
07/08/2020 11:00	0.0	0	0	0	0	1
07/08/2020 12:00	0.0	0	0	0	0	1
07/08/2020 13:00	0.0	0	0	0	0	1
07/08/2020 14:00	0.0	0	0	0	0	1
07/08/2020 15:00	0.0	0	0	0	0	1
07/08/2020 16:00	0.0	0	0	0	0	1
07/08/2020 17:00	0.0	0	0	0	0	1
07/08/2020 18:00	0.0	0	0	0	0	1
07/08/2020 19:00	0.0	0	0	0	0	1
07/08/2020 20:00	0.0	0	0	0	0	1
07/08/2020 21:00	0.0	0	0	0	0	1
07/08/2020 22:00	0.0	0	0	0	0	1
07/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/09/2020 00:00	0.0	0	0	0	0	1
07/09/2020 01:00	0.0	0	0	0	0	1
07/09/2020 02:00	0.0	0	0	0	0	1
07/09/2020 03:00	0.0	0	0	0	0	1
07/09/2020 04:00	0.0	0	0	0	0	1
07/09/2020 05:00	0.0	0	0	0	0	1
07/09/2020 06:00	0.0	0	0	0	0	1
07/09/2020 07:00	0.0	0	0	0	0	1
07/09/2020 08:00	0.0	0	0	0	0	1
07/09/2020 09:00	0.0	0	0	0	0	1
07/09/2020 10:00	0.0	0	0	0	0	1
07/09/2020 11:00	0.0	0	0	0	0	1
07/09/2020 12:00	0.0	0	0	0	0	1
07/09/2020 13:00	0.0	0	0	0	0	1
07/09/2020 14:00	0.0	0	0	0	0	1
07/09/2020 15:00	0.0	0	0	0	0	1
07/09/2020 16:00	0.0	0	0	0	0	1
07/09/2020 17:00	0.0	0	0	0	0	1
07/09/2020 18:00	0.0	0	0	0	0	1
07/09/2020 19:00	0.0	0	0	0	0	1
07/09/2020 20:00	0.0	0	0	0	0	1
07/09/2020 21:00	0.0	0	0	0	0	1
07/09/2020 22:00	0.0	0	0	0	0	1
07/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/10/2020 00:00	0.0	0	0	0	0	1
07/10/2020 01:00	0.0	0	0	0	0	1
07/10/2020 02:00	0.0	0	0	0	0	1
07/10/2020 03:00	0.0	0	0	0	0	1
07/10/2020 04:00	0.0	0	0	0	0	1
07/10/2020 05:00	0.0	0	0	0	0	1
07/10/2020 06:00	0.0	0	0	0	0	1
07/10/2020 07:00	0.0	0	0	0	0	1
07/10/2020 08:00	0.0	0	0	0	0	1
07/10/2020 09:00	0.0	0	0	0	0	1
07/10/2020 10:00	0.0	0	0	0	0	1
07/10/2020 11:00	0.0	0	0	0	0	1
07/10/2020 12:00	0.0	0	0	0	0	1
07/10/2020 13:00	0.0	0	0	0	0	1
07/10/2020 14:00	0.0	0	0	0	0	1
07/10/2020 15:00	0.0	0	0	0	0	1
07/10/2020 16:00	0.0	0	0	0	0	1
07/10/2020 17:00	0.0	0	0	0	0	1
07/10/2020 18:00	0.0	0	0	0	0	1
07/10/2020 19:00	0.0	0	0	0	0	1
07/10/2020 20:00	0.0	0	0	0	0	1
07/10/2020 21:00	0.0	0	0	0	0	1
07/10/2020 22:00	0.0	0	0	0	0	1
07/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/11/2020 00:00	0.0	0	0	0	0	1
07/11/2020 01:00	0.0	0	0	0	0	1
07/11/2020 02:00	0.0	0	0	0	0	1
07/11/2020 03:00	0.0	0	0	0	0	1
07/11/2020 04:00	0.0	0	0	0	0	1
07/11/2020 05:00	0.0	0	0	0	0	1
07/11/2020 06:00	0.0	0	0	0	0	1
07/11/2020 07:00	0.0	0	0	0	0	1
07/11/2020 08:00	0.0	0	0	0	0	1
07/11/2020 09:00	0.0	0	0	0	0	1
07/11/2020 10:00	0.0	0	0	0	0	1
07/11/2020 11:00	0.0	0	0	0	0	1
07/11/2020 12:00	0.0	0	0	0	0	1
07/11/2020 13:00	0.0	0	0	0	0	1
07/11/2020 14:00	0.0	0	0	0	0	1
07/11/2020 15:00	0.0	0	0	0	0	1
07/11/2020 16:00	0.0	0	0	0	0	1
07/11/2020 17:00	0.0	0	0	0	0	1
07/11/2020 18:00	0.0	0	0	0	0	1
07/11/2020 19:00	0.0	0	0	0	0	1
07/11/2020 20:00	0.0	0	0	0	0	1
07/11/2020 21:00	0.0	0	0	0	0	1
07/11/2020 22:00	0.0	0	0	0	0	1
07/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/12/2020 00:00	0.0	0	0	0	0	1
07/12/2020 01:00	0.0	0	0	0	0	1
07/12/2020 02:00	0.0	0	0	0	0	1
07/12/2020 03:00	0.0	0	0	0	0	1
07/12/2020 04:00	0.0	0	0	0	0	1
07/12/2020 05:00	0.0	0	0	0	0	1
07/12/2020 06:00	0.0	0	0	0	0	1
07/12/2020 07:00	0.0	0	0	0	0	1
07/12/2020 08:00	0.0	0	0	0	0	1
07/12/2020 09:00	0.0	0	0	0	0	1
07/12/2020 10:00	0.0	0	0	0	0	1
07/12/2020 11:00	0.0	0	0	0	0	1
07/12/2020 12:00	0.0	0	0	0	0	1
07/12/2020 13:00	0.0	0	0	0	0	1
07/12/2020 14:00	0.0	0	0	0	0	1
07/12/2020 15:00	0.0	0	0	0	0	1
07/12/2020 16:00	0.0	0	0	0	0	1
07/12/2020 17:00	0.0	0	0	0	0	1
07/12/2020 18:00	0.0	0	0	0	0	1
07/12/2020 19:00	0.0	0	0	0	0	1
07/12/2020 20:00	0.0	0	0	0	0	1
07/12/2020 21:00	0.0	0	0	0	0	1
07/12/2020 22:00	0.0	0	0	0	0	1
07/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/13/2020 00:00	0.0	0	0	0	0	1
07/13/2020 01:00	0.0	0	0	0	0	1
07/13/2020 02:00	0.0	0	0	0	0	1
07/13/2020 03:00	0.0	0	0	0	0	1
07/13/2020 04:00	0.0	0	0	0	0	1
07/13/2020 05:00	0.0	0	0	0	0	1
07/13/2020 06:00	0.0	0	0	0	0	1
07/13/2020 07:00	0.0	0	0	0	0	1
07/13/2020 08:00	0.0	0	0	0	0	1
07/13/2020 09:00	0.0	0	0	0	0	1
07/13/2020 10:00	0.0	0	0	0	0	1
07/13/2020 11:00	0.0	0	0	0	0	1
07/13/2020 12:00	0.0	0	0	0	0	1
07/13/2020 13:00	0.0	0	0	0	0	1
07/13/2020 14:00	0.0	0	0	0	0	1
07/13/2020 15:00	0.0	0	0	0	0	1
07/13/2020 16:00	0.0	0	0	0	0	1
07/13/2020 17:00	0.0	0	0	0	0	1
07/13/2020 18:00	0.0	0	0	0	0	1
07/13/2020 19:00	0.0	0	0	0	0	1
07/13/2020 20:00	0.0	0	0	0	0	1
07/13/2020 21:00	0.0	0	0	0	0	1
07/13/2020 22:00	0.0	0	0	0	0	1
07/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/14/2020 00:00	0.0	0	0	0	0	1
07/14/2020 01:00	0.0	0	0	0	0	1
07/14/2020 02:00	0.0	0	0	0	0	1
07/14/2020 03:00	0.0	0	0	0	0	1
07/14/2020 04:00	0.0	0	0	0	0	1
07/14/2020 05:00	0.0	0	0	0	0	1
07/14/2020 06:00	0.0	0	0	0	0	1
07/14/2020 07:00	0.0	0	0	0	0	1
07/14/2020 08:00	0.0	0	0	0	0	1
07/14/2020 09:00	0.0	0	0	0	0	1
07/14/2020 10:00	0.0	0	0	0	0	1
07/14/2020 11:00	0.0	0	0	0	0	1
07/14/2020 12:00	0.0	0	0	0	0	1
07/14/2020 13:00	0.0	0	0	0	0	1
07/14/2020 14:00	0.0	0	0	0	0	1
07/14/2020 15:00	0.0	0	0	0	0	1
07/14/2020 16:00	0.0	0	0	0	0	1
07/14/2020 17:00	0.0	0	0	0	0	1
07/14/2020 18:00	0.0	0	0	0	0	1
07/14/2020 19:00	0.0	0	0	0	0	1
07/14/2020 20:00	0.0	0	0	0	0	1
07/14/2020 21:00	0.0	0	0	0	0	1
07/14/2020 22:00	0.0	0	0	0	0	1
07/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/15/2020 00:00	0.0	0	0	0	0	1
07/15/2020 01:00	0.0	0	0	0	0	1
07/15/2020 02:00	0.0	0	0	0	0	1
07/15/2020 03:00	0.0	0	0	0	0	1
07/15/2020 04:00	0.0	0	0	0	0	1
07/15/2020 05:00	0.0	0	0	0	0	1
07/15/2020 06:00	0.0	0	0	0	0	1
07/15/2020 07:00	0.0	0	0	0	0	1
07/15/2020 08:00	0.0	0	0	0	0	1
07/15/2020 09:00	0.0	0	0	0	0	1
07/15/2020 10:00	0.0	0	0	0	0	1
07/15/2020 11:00	0.0	0	0	0	0	1
07/15/2020 12:00	0.0	0	0	0	0	1
07/15/2020 13:00	0.0	0	0	0	0	1
07/15/2020 14:00	0.0	0	0	0	0	1
07/15/2020 15:00	0.0	0	0	0	0	1
07/15/2020 16:00	0.0	0	0	0	0	1
07/15/2020 17:00	0.0	0	0	0	0	1
07/15/2020 18:00	0.0	0	0	0	0	1
07/15/2020 19:00	0.0	0	0	0	0	1
07/15/2020 20:00	0.0	0	0	0	0	1
07/15/2020 21:00	0.0	0	0	0	0	1
07/15/2020 22:00	0.0	0	0	0	0	1
07/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/16/2020 00:00	0.0	0	0	0	0	1
07/16/2020 01:00	0.0	0	0	0	0	1
07/16/2020 02:00	0.0	0	0	0	0	1
07/16/2020 03:00	0.0	0	0	0	0	1
07/16/2020 04:00	0.0	0	0	0	0	1
07/16/2020 05:00	0.0	0	0	0	0	1
07/16/2020 06:00	0.0	0	0	0	0	1
07/16/2020 07:00	0.0	0	0	0	0	1
07/16/2020 08:00	0.0	0	0	0	0	1
07/16/2020 09:00	0.0	0	0	0	0	1
07/16/2020 10:00	0.0	0	0	0	0	1
07/16/2020 11:00	0.0	0	0	0	0	1
07/16/2020 12:00	0.0	0	0	0	0	1
07/16/2020 13:00	0.0	0	0	0	0	1
07/16/2020 14:00	0.0	0	0	0	0	1
07/16/2020 15:00	0.0	0	0	0	0	1
07/16/2020 16:00	0.0	0	0	0	0	1
07/16/2020 17:00	0.0	0	0	0	0	1
07/16/2020 18:00	0.0	0	0	0	0	1
07/16/2020 19:00	0.0	0	0	0	0	1
07/16/2020 20:00	0.0	0	0	0	0	1
07/16/2020 21:00	0.0	0	0	0	0	1
07/16/2020 22:00	0.0	0	0	0	0	1
07/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/17/2020 00:00	0.0	0	0	0	0	1
07/17/2020 01:00	0.0	0	0	0	0	1
07/17/2020 02:00	0.0	0	0	0	0	1
07/17/2020 03:00	0.0	0	0	0	0	1
07/17/2020 04:00	0.0	0	0	0	0	1
07/17/2020 05:00	0.0	0	0	0	0	1
07/17/2020 06:00	0.0	0	0	0	0	1
07/17/2020 07:00	0.0	0	0	0	0	1
07/17/2020 08:00	0.0	0	0	0	0	1
07/17/2020 09:00	0.0	0	0	0	0	1
07/17/2020 10:00	0.0	0	0	0	0	1
07/17/2020 11:00	0.0	0	0	0	0	1
07/17/2020 12:00	0.0	0	0	0	0	1
07/17/2020 13:00	0.0	0	0	0	0	1
07/17/2020 14:00	0.0	0	0	0	0	1
07/17/2020 15:00	0.0	0	0	0	0	1
07/17/2020 16:00	0.0	0	0	0	0	1
07/17/2020 17:00	0.0	0	0	0	0	1
07/17/2020 18:00	0.0	0	0	0	0	1
07/17/2020 19:00	0.0	0	0	0	0	1
07/17/2020 20:00	0.0	0	0	0	0	1
07/17/2020 21:00	0.0	0	0	0	0	1
07/17/2020 22:00	0.0	0	0	0	0	1
07/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/18/2020 00:00	0.0	0	0	0	0	1
07/18/2020 01:00	0.0	0	0	0	0	1
07/18/2020 02:00	0.0	0	0	0	0	1
07/18/2020 03:00	0.0	0	0	0	0	1
07/18/2020 04:00	0.0	0	0	0	0	1
07/18/2020 05:00	0.0	0	0	0	0	1
07/18/2020 06:00	0.0	0	0	0	0	1
07/18/2020 07:00	0.0	0	0	0	0	1
07/18/2020 08:00	0.0	0	0	0	0	1
07/18/2020 09:00	0.0	0	0	0	0	1
07/18/2020 10:00	0.0	0	0	0	0	1
07/18/2020 11:00	0.0	0	0	0	0	1
07/18/2020 12:00	0.0	0	0	0	0	1
07/18/2020 13:00	0.0	0	0	0	0	1
07/18/2020 14:00	0.0	0	0	0	0	1
07/18/2020 15:00	0.0	0	0	0	0	1
07/18/2020 16:00	0.0	0	0	0	0	1
07/18/2020 17:00	0.0	0	0	0	0	1
07/18/2020 18:00	0.0	0	0	0	0	1
07/18/2020 19:00	0.0	0	0	0	0	1
07/18/2020 20:00	0.0	0	0	0	0	1
07/18/2020 21:00	0.0	0	0	0	0	1
07/18/2020 22:00	0.0	0	0	0	0	1
07/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/19/2020 00:00	0.0	0	0	0	0	1
07/19/2020 01:00	0.0	0	0	0	0	1
07/19/2020 02:00	0.0	0	0	0	0	1
07/19/2020 03:00	0.0	0	0	0	0	1
07/19/2020 04:00	0.0	0	0	0	0	1
07/19/2020 05:00	0.0	0	0	0	0	1
07/19/2020 06:00	0.0	0	0	0	0	1
07/19/2020 07:00	0.0	0	0	0	0	1
07/19/2020 08:00	0.0	0	0	0	0	1
07/19/2020 09:00	0.0	0	0	0	0	1
07/19/2020 10:00	0.0	0	0	0	0	1
07/19/2020 11:00	0.0	0	0	0	0	1
07/19/2020 12:00	0.0	0	0	0	0	1
07/19/2020 13:00	0.0	0	0	0	0	1
07/19/2020 14:00	0.0	0	0	0	0	1
07/19/2020 15:00	0.0	0	0	0	0	1
07/19/2020 16:00	0.0	0	0	0	0	1
07/19/2020 17:00	0.0	0	0	0	0	1
07/19/2020 18:00	0.0	0	0	0	0	1
07/19/2020 19:00	0.0	0	0	0	0	1
07/19/2020 20:00	0.0	0	0	0	0	1
07/19/2020 21:00	0.0	0	0	0	0	1
07/19/2020 22:00	0.0	0	0	0	0	1
07/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/20/2020 00:00	0.0	0	0	0	0	1
07/20/2020 01:00	0.0	0	0	0	0	1
07/20/2020 02:00	0.0	0	0	0	0	1
07/20/2020 03:00	0.0	0	0	0	0	1
07/20/2020 04:00	0.0	0	0	0	0	1
07/20/2020 05:00	0.0	0	0	0	0	1
07/20/2020 06:00	0.0	0	0	0	0	1
07/20/2020 07:00	0.0	0	0	0	0	1
07/20/2020 08:00	0.0	0	0	0	0	1
07/20/2020 09:00	0.0	0	0	0	0	1
07/20/2020 10:00	0.0	0	0	0	0	1
07/20/2020 11:00	0.0	0	0	0	0	1
07/20/2020 12:00	0.0	0	0	0	0	1
07/20/2020 13:00	0.0	0	0	0	0	1
07/20/2020 14:00	0.0	0	0	0	0	1
07/20/2020 15:00	0.0	0	0	0	0	1
07/20/2020 16:00	0.0	0	0	0	0	1
07/20/2020 17:00	0.0	0	0	0	0	1
07/20/2020 18:00	0.0	0	0	0	0	1
07/20/2020 19:00	0.0	0	0	0	0	1
07/20/2020 20:00	0.0	0	0	0	0	1
07/20/2020 21:00	0.0	0	0	0	0	1
07/20/2020 22:00	0.0	0	0	0	0	1
07/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/21/2020 00:00	0.0	0	0	0	0	1
07/21/2020 01:00	0.0	0	0	0	0	1
07/21/2020 02:00	0.0	0	0	0	0	1
07/21/2020 03:00	0.0	0	0	0	0	1
07/21/2020 04:00	0.0	0	0	0	0	1
07/21/2020 05:00	0.0	0	0	0	0	1
07/21/2020 06:00	0.0	0	0	0	0	1
07/21/2020 07:00	0.0	0	0	0	0	1
07/21/2020 08:00	0.0	0	0	0	0	1
07/21/2020 09:00	0.0	0	0	0	0	1
07/21/2020 10:00	0.0	0	0	0	0	1
07/21/2020 11:00	0.0	0	0	0	0	1
07/21/2020 12:00	0.0	0	0	0	0	1
07/21/2020 13:00	0.0	0	0	0	0	1
07/21/2020 14:00	0.0	0	0	0	0	1
07/21/2020 15:00	0.0	0	0	0	0	1
07/21/2020 16:00	0.0	0	0	0	0	1
07/21/2020 17:00	0.0	0	0	0	0	1
07/21/2020 18:00	0.0	0	0	0	0	1
07/21/2020 19:00	0.0	0	0	0	0	1
07/21/2020 20:00	0.0	0	0	0	0	1
07/21/2020 21:00	0.0	0	0	0	0	1
07/21/2020 22:00	0.0	0	0	0	0	1
07/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/22/2020 00:00	0.0	0	0	0	0	1
07/22/2020 01:00	0.0	0	0	0	0	1
07/22/2020 02:00	0.0	0	0	0	0	1
07/22/2020 03:00	0.0	0	0	0	0	1
07/22/2020 04:00	0.0	0	0	0	0	1
07/22/2020 05:00	0.0	0	0	0	0	1
07/22/2020 06:00	0.0	0	0	0	0	1
07/22/2020 07:00	0.0	0	0	0	0	1
07/22/2020 08:00	0.0	0	0	0	0	1
07/22/2020 09:00	0.0	0	0	0	0	1
07/22/2020 10:00	0.0	0	0	0	0	1
07/22/2020 11:00	0.0	0	0	0	0	1
07/22/2020 12:00	0.0	0	0	0	0	1
07/22/2020 13:00	0.0	0	0	0	0	1
07/22/2020 14:00	0.0	0	0	0	0	1
07/22/2020 15:00	0.0	0	0	0	0	1
07/22/2020 16:00	0.0	0	0	0	0	1
07/22/2020 17:00	0.0	0	0	0	0	1
07/22/2020 18:00	0.0	0	0	0	0	1
07/22/2020 19:00	0.0	0	0	0	0	1
07/22/2020 20:00	0.0	0	0	0	0	1
07/22/2020 21:00	0.0	0	0	0	0	1
07/22/2020 22:00	0.0	0	0	0	0	1
07/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/23/2020 00:00	0.0	0	0	0	0	1
07/23/2020 01:00	0.0	0	0	0	0	1
07/23/2020 02:00	0.0	0	0	0	0	1
07/23/2020 03:00	0.0	0	0	0	0	1
07/23/2020 04:00	0.0	0	0	0	0	1
07/23/2020 05:00	0.0	0	0	0	0	1
07/23/2020 06:00	0.0	0	0	0	0	1
07/23/2020 07:00	0.0	0	0	0	0	1
07/23/2020 08:00	0.0	0	0	0	0	1
07/23/2020 09:00	0.0	0	0	0	0	1
07/23/2020 10:00	0.0	0	0	0	0	1
07/23/2020 11:00	0.0	0	0	0	0	1
07/23/2020 12:00	0.0	0	0	0	0	1
07/23/2020 13:00	0.0	0	0	0	0	1
07/23/2020 14:00	0.0	0	0	0	0	1
07/23/2020 15:00	0.0	0	0	0	0	1
07/23/2020 16:00	0.0	0	0	0	0	1
07/23/2020 17:00	0.0	0	0	0	0	1
07/23/2020 18:00	0.0	0	0	0	0	1
07/23/2020 19:00	0.0	0	0	0	0	1
07/23/2020 20:00	0.0	0	0	0	0	1
07/23/2020 21:00	0.0	0	0	0	0	1
07/23/2020 22:00	0.0	0	0	0	0	1
07/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/24/2020 00:00	0.0	0	0	0	0	1
07/24/2020 01:00	0.0	0	0	0	0	1
07/24/2020 02:00	0.0	0	0	0	0	1
07/24/2020 03:00	0.0	0	0	0	0	1
07/24/2020 04:00	0.0	0	0	0	0	1
07/24/2020 05:00	0.0	0	0	0	0	1
07/24/2020 06:00	0.0	0	0	0	0	1
07/24/2020 07:00	0.0	0	0	0	0	1
07/24/2020 08:00	0.0	0	0	0	0	1
07/24/2020 09:00	0.0	0	0	0	0	1
07/24/2020 10:00	0.0	0	0	0	0	1
07/24/2020 11:00	0.0	0	0	0	0	1
07/24/2020 12:00	0.0	0	0	0	0	1
07/24/2020 13:00	0.0	0	0	0	0	1
07/24/2020 14:00	0.0	0	0	0	0	1
07/24/2020 15:00	0.0	0	0	0	0	1
07/24/2020 16:00	0.0	0	0	0	0	1
07/24/2020 17:00	0.0	0	0	0	0	1
07/24/2020 18:00	0.0	0	0	0	0	1
07/24/2020 19:00	0.0	0	0	0	0	1
07/24/2020 20:00	0.0	0	0	0	0	1
07/24/2020 21:00	0.0	0	0	0	0	1
07/24/2020 22:00	0.0	0	0	0	0	1
07/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/25/2020 00:00	0.0	0	0	0	0	1
07/25/2020 01:00	0.0	0	0	0	0	1
07/25/2020 02:00	0.0	0	0	0	0	1
07/25/2020 03:00	0.0	0	0	0	0	1
07/25/2020 04:00	0.0	0	0	0	0	1
07/25/2020 05:00	0.0	0	0	0	0	1
07/25/2020 06:00	0.0	0	0	0	0	1
07/25/2020 07:00	0.0	0	0	0	0	1
07/25/2020 08:00	0.0	0	0	0	0	1
07/25/2020 09:00	0.0	0	0	0	0	1
07/25/2020 10:00	0.0	0	0	0	0	1
07/25/2020 11:00	0.0	0	0	0	0	1
07/25/2020 12:00	0.0	0	0	0	0	1
07/25/2020 13:00	0.0	0	0	0	0	1
07/25/2020 14:00	0.0	0	0	0	0	1
07/25/2020 15:00	0.0	0	0	0	0	1
07/25/2020 16:00	0.0	0	0	0	0	1
07/25/2020 17:00	0.0	0	0	0	0	1
07/25/2020 18:00	0.0	0	0	0	0	1
07/25/2020 19:00	0.0	0	0	0	0	1
07/25/2020 20:00	0.0	0	0	0	0	1
07/25/2020 21:00	0.0	0	0	0	0	1
07/25/2020 22:00	0.0	0	0	0	0	1
07/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/26/2020 00:00	0.0	0	0	0	0	1
07/26/2020 01:00	0.0	0	0	0	0	1
07/26/2020 02:00	0.0	0	0	0	0	1
07/26/2020 03:00	0.0	0	0	0	0	1
07/26/2020 04:00	0.0	0	0	0	0	1
07/26/2020 05:00	0.0	0	0	0	0	1
07/26/2020 06:00	0.0	0	0	0	0	1
07/26/2020 07:00	0.0	0	0	0	0	1
07/26/2020 08:00	0.0	0	0	0	0	1
07/26/2020 09:00	0.0	0	0	0	0	1
07/26/2020 10:00	0.0	0	0	0	0	1
07/26/2020 11:00	0.0	0	0	0	0	1
07/26/2020 12:00	0.0	0	0	0	0	1
07/26/2020 13:00	0.0	0	0	0	0	1
07/26/2020 14:00	0.0	0	0	0	0	1
07/26/2020 15:00	0.0	0	0	0	0	1
07/26/2020 16:00	0.0	0	0	0	0	1
07/26/2020 17:00	0.0	0	0	0	0	1
07/26/2020 18:00	0.0	0	0	0	0	1
07/26/2020 19:00	0.0	0	0	0	0	1
07/26/2020 20:00	0.0	0	0	0	0	1
07/26/2020 21:00	0.0	0	0	0	0	1
07/26/2020 22:00	0.0	0	0	0	0	1
07/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/27/2020 00:00	0.0	0	0	0	0	1
07/27/2020 01:00	0.0	0	0	0	0	1
07/27/2020 02:00	0.0	0	0	0	0	1
07/27/2020 03:00	0.0	0	0	0	0	1
07/27/2020 04:00	0.0	0	0	0	0	1
07/27/2020 05:00	0.0	0	0	0	0	1
07/27/2020 06:00	0.0	0	0	0	0	1
07/27/2020 07:00	0.0	0	0	0	0	1
07/27/2020 08:00	0.0	0	0	0	0	1
07/27/2020 09:00	0.0	0	0	0	0	1
07/27/2020 10:00	0.0	0	0	0	0	1
07/27/2020 11:00	0.0	0	0	0	0	1
07/27/2020 12:00	0.0	0	0	0	0	1
07/27/2020 13:00	0.0	0	0	0	0	1
07/27/2020 14:00	0.0	0	0	0	0	1
07/27/2020 15:00	0.0	0	0	0	0	1
07/27/2020 16:00	0.0	0	0	0	0	1
07/27/2020 17:00	0.0	0	0	0	0	1
07/27/2020 18:00	0.0	0	0	0	0	1
07/27/2020 19:00	0.0	0	0	0	0	1
07/27/2020 20:00	0.0	0	0	0	0	1
07/27/2020 21:00	0.0	0	0	0	0	1
07/27/2020 22:00	0.0	0	0	0	0	1
07/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/28/2020 00:00	0.0	0	0	0	0	1
07/28/2020 01:00	0.0	0	0	0	0	1
07/28/2020 02:00	0.0	0	0	0	0	1
07/28/2020 03:00	0.0	0	0	0	0	1
07/28/2020 04:00	0.0	0	0	0	0	1
07/28/2020 05:00	0.0	0	0	0	0	1
07/28/2020 06:00	0.0	0	0	0	0	1
07/28/2020 07:00	0.0	0	0	0	0	1
07/28/2020 08:00	0.0	0	0	0	0	1
07/28/2020 09:00	0.0	0	0	0	0	1
07/28/2020 10:00	0.0	0	0	0	0	1
07/28/2020 11:00	0.0	0	0	0	0	1
07/28/2020 12:00	0.0	0	0	0	0	1
07/28/2020 13:00	0.0	0	0	0	0	1
07/28/2020 14:00	0.0	0	0	0	0	1
07/28/2020 15:00	0.0	0	0	0	0	1
07/28/2020 16:00	0.0	0	0	0	0	1
07/28/2020 17:00	0.0	0	0	0	0	1
07/28/2020 18:00	0.0	0	0	0	0	1
07/28/2020 19:00	0.0	0	0	0	0	1
07/28/2020 20:00	0.0	0	0	0	0	1
07/28/2020 21:00	0.0	0	0	0	0	1
07/28/2020 22:00	0.0	0	0	0	0	1
07/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/29/2020 00:00	0.0	0	0	0	0	1
07/29/2020 01:00	0.0	0	0	0	0	1
07/29/2020 02:00	0.0	0	0	0	0	1
07/29/2020 03:00	0.0	0	0	0	0	1
07/29/2020 04:00	0.0	0	0	0	0	1
07/29/2020 05:00	0.0	0	0	0	0	1
07/29/2020 06:00	0.0	0	0	0	0	1
07/29/2020 07:00	0.0	0	0	0	0	1
07/29/2020 08:00	0.0	0	0	0	0	1
07/29/2020 09:00	0.0	0	0	0	0	1
07/29/2020 10:00	0.0	0	0	0	0	1
07/29/2020 11:00	0.0	0	0	0	0	1
07/29/2020 12:00	0.0	0	0	0	0	1
07/29/2020 13:00	0.0	0	0	0	0	1
07/29/2020 14:00	0.0	0	0	0	0	1
07/29/2020 15:00	0.0	0	0	0	0	1
07/29/2020 16:00	0.0	0	0	0	0	1
07/29/2020 17:00	0.0	0	0	0	0	1
07/29/2020 18:00	0.0	0	0	0	0	1
07/29/2020 19:00	0.0	0	0	0	0	1
07/29/2020 20:00	0.0	0	0	0	0	1
07/29/2020 21:00	0.0	0	0	0	0	1
07/29/2020 22:00	0.0	0	0	0	0	1
07/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/30/2020 00:00	0.0	0	0	0	0	1
07/30/2020 01:00	0.0	0	0	0	0	1
07/30/2020 02:00	0.0	0	0	0	0	1
07/30/2020 03:00	0.0	0	0	0	0	1
07/30/2020 04:00	0.0	0	0	0	0	1
07/30/2020 05:00	0.0	0	0	0	0	1
07/30/2020 06:00	0.0	0	0	0	0	1
07/30/2020 07:00	0.0	0	0	0	0	1
07/30/2020 08:00	0.0	0	0	0	0	1
07/30/2020 09:00	0.0	0	0	0	0	1
07/30/2020 10:00	0.0	0	0	0	0	1
07/30/2020 11:00	0.0	0	0	0	0	1
07/30/2020 12:00	0.0	0	0	0	0	1
07/30/2020 13:00	0.0	0	0	0	0	1
07/30/2020 14:00	0.0	0	0	0	0	1
07/30/2020 15:00	0.0	0	0	0	0	1
07/30/2020 16:00	0.0	0	0	0	0	1
07/30/2020 17:00	0.0	0	0	0	0	1
07/30/2020 18:00	0.0	0	0	0	0	1
07/30/2020 19:00	0.0	0	0	0	0	1
07/30/2020 20:00	0.0	0	0	0	0	1
07/30/2020 21:00	0.0	0	0	0	0	1
07/30/2020 22:00	0.0	0	0	0	0	1
07/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/31/2020 00:00	0.0	0	0	0	0	1
07/31/2020 01:00	0.0	0	0	0	0	1
07/31/2020 02:00	0.0	0	0	0	0	1
07/31/2020 03:00	0.0	0	0	0	0	1
07/31/2020 04:00	0.0	0	0	0	0	1
07/31/2020 05:00	0.0	0	0	0	0	1
07/31/2020 06:00	0.0	0	0	0	0	1
07/31/2020 07:00	0.0	0	0	0	0	1
07/31/2020 08:00	0.0	0	0	0	0	1
07/31/2020 09:00	0.0	0	0	0	0	1
07/31/2020 10:00	0.0	0	0	0	0	1
07/31/2020 11:00	0.0	0	0	0	0	1
07/31/2020 12:00	0.0	0	0	0	0	1
07/31/2020 13:00	0.0	0	0	0	0	1
07/31/2020 14:00	0.0	0	0	0	0	1
07/31/2020 15:00	0.0	0	0	0	0	1
07/31/2020 16:00	0.0	0	0	0	0	1
07/31/2020 17:00	0.0	0	0	0	0	1
07/31/2020 18:00	0.0	0	0	0	0	1
07/31/2020 19:00	0.0	0	0	0	0	1
07/31/2020 20:00	0.0	0	0	0	0	1
07/31/2020 21:00	0.0	0	0	0	0	1
07/31/2020 22:00	0.0	0	0	0	0	1
07/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/01/2020 00:00	0.0	0	0	0	0	1
08/01/2020 01:00	0.0	0	0	0	0	1
08/01/2020 02:00	0.0	0	0	0	0	1
08/01/2020 03:00	0.0	0	0	0	0	1
08/01/2020 04:00	0.0	0	0	0	0	1
08/01/2020 05:00	0.0	0	0	0	0	1
08/01/2020 06:00	0.0	0	0	0	0	1
08/01/2020 07:00	0.0	0	0	0	0	1
08/01/2020 08:00	0.0	0	0	0	0	1
08/01/2020 09:00	0.0	0	0	0	0	1
08/01/2020 10:00	0.0	0	0	0	0	1
08/01/2020 11:00	0.0	0	0	0	0	1
08/01/2020 12:00	0.0	0	0	0	0	1
08/01/2020 13:00	0.0	0	0	0	0	1
08/01/2020 14:00	0.0	0	0	0	0	1
08/01/2020 15:00	0.0	0	0	0	0	1
08/01/2020 16:00	0.0	0	0	0	0	1
08/01/2020 17:00	0.0	0	0	0	0	1
08/01/2020 18:00	0.0	0	0	0	0	1
08/01/2020 19:00	0.0	0	0	0	0	1
08/01/2020 20:00	0.0	0	0	0	0	1
08/01/2020 21:00	0.0	0	0	0	0	1
08/01/2020 22:00	0.0	0	0	0	0	1
08/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/02/2020 00:00	0.0	0	0	0	0	1
08/02/2020 01:00	0.0	0	0	0	0	1
08/02/2020 02:00	0.0	0	0	0	0	1
08/02/2020 03:00	0.0	0	0	0	0	1
08/02/2020 04:00	0.0	0	0	0	0	1
08/02/2020 05:00	0.0	0	0	0	0	1
08/02/2020 06:00	0.0	0	0	0	0	1
08/02/2020 07:00	0.0	0	0	0	0	1
08/02/2020 08:00	0.0	0	0	0	0	1
08/02/2020 09:00	0.0	0	0	0	0	1
08/02/2020 10:00	0.0	0	0	0	0	1
08/02/2020 11:00	0.0	0	0	0	0	1
08/02/2020 12:00	0.0	0	0	0	0	1
08/02/2020 13:00	0.0	0	0	0	0	1
08/02/2020 14:00	0.0	0	0	0	0	1
08/02/2020 15:00	0.0	0	0	0	0	1
08/02/2020 16:00	0.0	0	0	0	0	1
08/02/2020 17:00	0.0	0	0	0	0	1
08/02/2020 18:00	0.0	0	0	0	0	1
08/02/2020 19:00	0.0	0	0	0	0	1
08/02/2020 20:00	0.0	0	0	0	0	1
08/02/2020 21:00	0.0	0	0	0	0	1
08/02/2020 22:00	0.0	0	0	0	0	1
08/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/03/2020 00:00	0.0	0	0	0	0	1
08/03/2020 01:00	0.0	0	0	0	0	1
08/03/2020 02:00	0.0	0	0	0	0	1
08/03/2020 03:00	0.0	0	0	0	0	1
08/03/2020 04:00	0.0	0	0	0	0	1
08/03/2020 05:00	0.0	0	0	0	0	1
08/03/2020 06:00	0.0	0	0	0	0	1
08/03/2020 07:00	0.0	0	0	0	0	1
08/03/2020 08:00	0.0	0	0	0	0	1
08/03/2020 09:00	0.0	0	0	0	0	1
08/03/2020 10:00	0.0	0	0	0	0	1
08/03/2020 11:00	0.0	0	0	0	0	1
08/03/2020 12:00	0.0	0	0	0	0	1
08/03/2020 13:00	0.0	0	0	0	0	1
08/03/2020 14:00	0.0	0	0	0	0	1
08/03/2020 15:00	0.0	0	0	0	0	1
08/03/2020 16:00	0.0	0	0	0	0	1
08/03/2020 17:00	0.0	0	0	0	0	1
08/03/2020 18:00	0.0	0	0	0	0	1
08/03/2020 19:00	0.0	0	0	0	0	1
08/03/2020 20:00	0.0	0	0	0	0	1
08/03/2020 21:00	0.0	0	0	0	0	1
08/03/2020 22:00	0.0	0	0	0	0	1
08/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/04/2020 00:00	0.0	0	0	0	0	1
08/04/2020 01:00	0.0	0	0	0	0	1
08/04/2020 02:00	0.0	0	0	0	0	1
08/04/2020 03:00	0.0	0	0	0	0	1
08/04/2020 04:00	0.0	0	0	0	0	1
08/04/2020 05:00	0.0	0	0	0	0	1
08/04/2020 06:00	0.0	0	0	0	0	1
08/04/2020 07:00	0.0	0	0	0	0	1
08/04/2020 08:00	0.0	0	0	0	0	1
08/04/2020 09:00	0.0	0	0	0	0	1
08/04/2020 10:00	0.0	0	0	0	0	1
08/04/2020 11:00	0.0	0	0	0	0	1
08/04/2020 12:00	0.0	0	0	0	0	1
08/04/2020 13:00	0.0	0	0	0	0	1
08/04/2020 14:00	0.0	0	0	0	0	1
08/04/2020 15:00	0.0	0	0	0	0	1
08/04/2020 16:00	0.0	0	0	0	0	1
08/04/2020 17:00	0.0	0	0	0	0	1
08/04/2020 18:00	0.0	0	0	0	0	1
08/04/2020 19:00	0.0	0	0	0	0	1
08/04/2020 20:00	0.0	0	0	0	0	1
08/04/2020 21:00	0.0	0	0	0	0	1
08/04/2020 22:00	0.0	0	0	0	0	1
08/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/05/2020 00:00	0.0	0	0	0	0	1
08/05/2020 01:00	0.0	0	0	0	0	1
08/05/2020 02:00	0.0	0	0	0	0	1
08/05/2020 03:00	0.0	0	0	0	0	1
08/05/2020 04:00	0.0	0	0	0	0	1
08/05/2020 05:00	0.0	0	0	0	0	1
08/05/2020 06:00	0.0	0	0	0	0	1
08/05/2020 07:00	0.0	0	0	0	0	1
08/05/2020 08:00	0.0	0	0	0	0	1
08/05/2020 09:00	0.0	0	0	0	0	1
08/05/2020 10:00	0.0	0	0	0	0	1
08/05/2020 11:00	0.0	0	0	0	0	1
08/05/2020 12:00	0.0	0	0	0	0	1
08/05/2020 13:00	0.0	0	0	0	0	1
08/05/2020 14:00	0.0	0	0	0	0	1
08/05/2020 15:00	0.0	0	0	0	0	1
08/05/2020 16:00	0.0	0	0	0	0	1
08/05/2020 17:00	0.0	0	0	0	0	1
08/05/2020 18:00	0.0	0	0	0	0	1
08/05/2020 19:00	0.0	0	0	0	0	1
08/05/2020 20:00	0.0	0	0	0	0	1
08/05/2020 21:00	0.0	0	0	0	0	1
08/05/2020 22:00	0.0	0	0	0	0	1
08/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/06/2020 00:00	0.0	0	0	0	0	1
08/06/2020 01:00	0.0	0	0	0	0	1
08/06/2020 02:00	0.0	0	0	0	0	1
08/06/2020 03:00	0.0	0	0	0	0	1
08/06/2020 04:00	0.0	0	0	0	0	1
08/06/2020 05:00	0.0	0	0	0	0	1
08/06/2020 06:00	0.0	0	0	0	0	1
08/06/2020 07:00	0.0	0	0	0	0	1
08/06/2020 08:00	0.0	0	0	0	0	1
08/06/2020 09:00	0.0	0	0	0	0	1
08/06/2020 10:00	0.0	0	0	0	0	1
08/06/2020 11:00	0.0	0	0	0	0	1
08/06/2020 12:00	0.0	0	0	0	0	1
08/06/2020 13:00	0.0	0	0	0	0	1
08/06/2020 14:00	0.0	0	0	0	0	1
08/06/2020 15:00	0.0	0	0	0	0	1
08/06/2020 16:00	0.0	0	0	0	0	1
08/06/2020 17:00	0.0	0	0	0	0	1
08/06/2020 18:00	0.0	0	0	0	0	1
08/06/2020 19:00	0.0	0	0	0	0	1
08/06/2020 20:00	0.0	0	0	0	0	1
08/06/2020 21:00	0.0	0	0	0	0	1
08/06/2020 22:00	0.0	0	0	0	0	1
08/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/07/2020 00:00	0.0	0	0	0	0	1
08/07/2020 01:00	0.0	0	0	0	0	1
08/07/2020 02:00	0.0	0	0	0	0	1
08/07/2020 03:00	0.0	0	0	0	0	1
08/07/2020 04:00	0.0	0	0	0	0	1
08/07/2020 05:00	0.0	0	0	0	0	1
08/07/2020 06:00	0.0	0	0	0	0	1
08/07/2020 07:00	0.0	0	0	0	0	1
08/07/2020 08:00	0.0	0	0	0	0	1
08/07/2020 09:00	0.0	0	0	0	0	1
08/07/2020 10:00	0.0	0	0	0	0	1
08/07/2020 11:00	0.0	0	0	0	0	1
08/07/2020 12:00	0.0	0	0	0	0	1
08/07/2020 13:00	0.0	0	0	0	0	1
08/07/2020 14:00	0.0	0	0	0	0	1
08/07/2020 15:00	0.0	0	0	0	0	1
08/07/2020 16:00	0.0	0	0	0	0	1
08/07/2020 17:00	0.0	0	0	0	0	1
08/07/2020 18:00	0.0	0	0	0	0	1
08/07/2020 19:00	0.0	0	0	0	0	1
08/07/2020 20:00	0.0	0	0	0	0	1
08/07/2020 21:00	0.0	0	0	0	0	1
08/07/2020 22:00	0.0	0	0	0	0	1
08/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/08/2020 00:00	0.0	0	0	0	0	1
08/08/2020 01:00	0.0	0	0	0	0	1
08/08/2020 02:00	0.0	0	0	0	0	1
08/08/2020 03:00	0.0	0	0	0	0	1
08/08/2020 04:00	0.0	0	0	0	0	1
08/08/2020 05:00	0.0	0	0	0	0	1
08/08/2020 06:00	0.0	0	0	0	0	1
08/08/2020 07:00	0.0	0	0	0	0	1
08/08/2020 08:00	0.0	0	0	0	0	1
08/08/2020 09:00	0.0	0	0	0	0	1
08/08/2020 10:00	0.0	0	0	0	0	1
08/08/2020 11:00	0.0	0	0	0	0	1
08/08/2020 12:00	0.0	0	0	0	0	1
08/08/2020 13:00	0.0	0	0	0	0	1
08/08/2020 14:00	0.0	0	0	0	0	1
08/08/2020 15:00	0.0	0	0	0	0	1
08/08/2020 16:00	0.0	0	0	0	0	1
08/08/2020 17:00	0.0	0	0	0	0	1
08/08/2020 18:00	0.0	0	0	0	0	1
08/08/2020 19:00	0.0	0	0	0	0	1
08/08/2020 20:00	0.0	0	0	0	0	1
08/08/2020 21:00	0.0	0	0	0	0	1
08/08/2020 22:00	0.0	0	0	0	0	1
08/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/09/2020 00:00	0.0	0	0	0	0	1
08/09/2020 01:00	0.0	0	0	0	0	1
08/09/2020 02:00	0.0	0	0	0	0	1
08/09/2020 03:00	0.0	0	0	0	0	1
08/09/2020 04:00	0.0	0	0	0	0	1
08/09/2020 05:00	0.0	0	0	0	0	1
08/09/2020 06:00	0.0	0	0	0	0	1
08/09/2020 07:00	0.0	0	0	0	0	1
08/09/2020 08:00	0.0	0	0	0	0	1
08/09/2020 09:00	0.0	0	0	0	0	1
08/09/2020 10:00	0.0	0	0	0	0	1
08/09/2020 11:00	0.0	0	0	0	0	1
08/09/2020 12:00	0.0	0	0	0	0	1
08/09/2020 13:00	0.0	0	0	0	0	1
08/09/2020 14:00	0.0	0	0	0	0	1
08/09/2020 15:00	0.0	0	0	0	0	1
08/09/2020 16:00	0.0	0	0	0	0	1
08/09/2020 17:00	0.0	0	0	0	0	1
08/09/2020 18:00	0.0	0	0	0	0	1
08/09/2020 19:00	0.0	0	0	0	0	1
08/09/2020 20:00	0.0	0	0	0	0	1
08/09/2020 21:00	0.0	0	0	0	0	1
08/09/2020 22:00	0.0	0	0	0	0	1
08/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/10/2020 00:00	0.0	0	0	0	0	1
08/10/2020 01:00	0.0	0	0	0	0	1
08/10/2020 02:00	0.0	0	0	0	0	1
08/10/2020 03:00	0.0	0	0	0	0	1
08/10/2020 04:00	0.0	0	0	0	0	1
08/10/2020 05:00	0.0	0	0	0	0	1
08/10/2020 06:00	0.0	0	0	0	0	1
08/10/2020 07:00	0.0	0	0	0	0	1
08/10/2020 08:00	0.0	0	0	0	0	1
08/10/2020 09:00	0.0	0	0	0	0	1
08/10/2020 10:00	0.0	0	0	0	0	1
08/10/2020 11:00	0.0	0	0	0	0	1
08/10/2020 12:00	0.0	0	0	0	0	1
08/10/2020 13:00	0.0	0	0	0	0	1
08/10/2020 14:00	0.0	0	0	0	0	1
08/10/2020 15:00	0.0	0	0	0	0	1
08/10/2020 16:00	0.0	0	0	0	0	1
08/10/2020 17:00	0.0	0	0	0	0	1
08/10/2020 18:00	0.0	0	0	0	0	1
08/10/2020 19:00	0.0	0	0	0	0	1
08/10/2020 20:00	0.0	0	0	0	0	1
08/10/2020 21:00	0.0	0	0	0	0	1
08/10/2020 22:00	0.0	0	0	0	0	1
08/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/11/2020 00:00	0.0	0	0	0	0	1
08/11/2020 01:00	0.0	0	0	0	0	1
08/11/2020 02:00	0.0	0	0	0	0	1
08/11/2020 03:00	0.0	0	0	0	0	1
08/11/2020 04:00	0.0	0	0	0	0	1
08/11/2020 05:00	0.0	0	0	0	0	1
08/11/2020 06:00	0.0	0	0	0	0	1
08/11/2020 07:00	0.0	0	0	0	0	1
08/11/2020 08:00	0.0	0	0	0	0	1
08/11/2020 09:00	0.0	0	0	0	0	1
08/11/2020 10:00	0.0	0	0	0	0	1
08/11/2020 11:00	0.0	0	0	0	0	1
08/11/2020 12:00	0.0	0	0	0	0	1
08/11/2020 13:00	0.0	0	0	0	0	1
08/11/2020 14:00	0.0	0	0	0	0	1
08/11/2020 15:00	0.0	0	0	0	0	1
08/11/2020 16:00	0.0	0	0	0	0	1
08/11/2020 17:00	0.0	0	0	0	0	1
08/11/2020 18:00	0.0	0	0	0	0	1
08/11/2020 19:00	0.0	0	0	0	0	1
08/11/2020 20:00	0.0	0	0	0	0	1
08/11/2020 21:00	0.0	0	0	0	0	1
08/11/2020 22:00	0.0	0	0	0	0	1
08/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/12/2020 00:00	0.0	0	0	0	0	1
08/12/2020 01:00	0.0	0	0	0	0	1
08/12/2020 02:00	0.0	0	0	0	0	1
08/12/2020 03:00	0.0	0	0	0	0	1
08/12/2020 04:00	0.0	0	0	0	0	1
08/12/2020 05:00	0.0	0	0	0	0	1
08/12/2020 06:00	0.0	0	0	0	0	1
08/12/2020 07:00	0.0	0	0	0	0	1
08/12/2020 08:00	0.0	0	0	0	0	1
08/12/2020 09:00	0.0	0	0	0	0	1
08/12/2020 10:00	0.0	0	0	0	0	1
08/12/2020 11:00	0.0	0	0	0	0	1
08/12/2020 12:00	0.0	0	0	0	0	1
08/12/2020 13:00	0.0	0	0	0	0	1
08/12/2020 14:00	0.0	0	0	0	0	1
08/12/2020 15:00	0.0	0	0	0	0	1
08/12/2020 16:00	0.0	0	0	0	0	1
08/12/2020 17:00	0.0	0	0	0	0	1
08/12/2020 18:00	0.0	0	0	0	0	1
08/12/2020 19:00	0.0	0	0	0	0	1
08/12/2020 20:00	0.0	0	0	0	0	1
08/12/2020 21:00	0.0	0	0	0	0	1
08/12/2020 22:00	0.0	0	0	0	0	1
08/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/13/2020 00:00	0.0	0	0	0	0	1
08/13/2020 01:00	0.0	0	0	0	0	1
08/13/2020 02:00	0.0	0	0	0	0	1
08/13/2020 03:00	0.0	0	0	0	0	1
08/13/2020 04:00	0.0	0	0	0	0	1
08/13/2020 05:00	0.0	0	0	0	0	1
08/13/2020 06:00	0.0	0	0	0	0	1
08/13/2020 07:00	0.0	0	0	0	0	1
08/13/2020 08:00	0.0	0	0	0	0	1
08/13/2020 09:00	0.0	0	0	0	0	1
08/13/2020 10:00	0.0	0	0	0	0	1
08/13/2020 11:00	0.0	0	0	0	0	1
08/13/2020 12:00	0.0	0	0	0	0	1
08/13/2020 13:00	0.0	0	0	0	0	1
08/13/2020 14:00	0.0	0	0	0	0	1
08/13/2020 15:00	0.0	0	0	0	0	1
08/13/2020 16:00	0.0	0	0	0	0	1
08/13/2020 17:00	0.0	0	0	0	0	1
08/13/2020 18:00	0.0	0	0	0	0	1
08/13/2020 19:00	0.0	0	0	0	0	1
08/13/2020 20:00	0.0	0	0	0	0	1
08/13/2020 21:00	0.0	0	0	0	0	1
08/13/2020 22:00	0.0	0	0	0	0	1
08/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/14/2020 00:00	0.0	0	0	0	0	1
08/14/2020 01:00	0.0	0	0	0	0	1
08/14/2020 02:00	0.0	0	0	0	0	1
08/14/2020 03:00	0.0	0	0	0	0	1
08/14/2020 04:00	0.0	0	0	0	0	1
08/14/2020 05:00	0.0	0	0	0	0	1
08/14/2020 06:00	0.0	0	0	0	0	1
08/14/2020 07:00	0.0	0	0	0	0	1
08/14/2020 08:00	0.0	0	0	0	0	1
08/14/2020 09:00	0.0	0	0	0	0	1
08/14/2020 10:00	0.0	0	0	0	0	1
08/14/2020 11:00	0.0	0	0	0	0	1
08/14/2020 12:00	0.0	0	0	0	0	1
08/14/2020 13:00	0.0	0	0	0	0	1
08/14/2020 14:00	0.0	0	0	0	0	1
08/14/2020 15:00	0.0	0	0	0	0	1
08/14/2020 16:00	0.0	0	0	0	0	1
08/14/2020 17:00	0.0	0	0	0	0	1
08/14/2020 18:00	0.0	0	0	0	0	1
08/14/2020 19:00	0.0	0	0	0	0	1
08/14/2020 20:00	0.0	0	0	0	0	1
08/14/2020 21:00	0.0	0	0	0	0	1
08/14/2020 22:00	0.0	0	0	0	0	1
08/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/15/2020 00:00	0.0	0	0	0	0	1
08/15/2020 01:00	0.0	0	0	0	0	1
08/15/2020 02:00	0.0	0	0	0	0	1
08/15/2020 03:00	0.0	0	0	0	0	1
08/15/2020 04:00	0.0	0	0	0	0	1
08/15/2020 05:00	0.0	0	0	0	0	1
08/15/2020 06:00	0.0	0	0	0	0	1
08/15/2020 07:00	0.0	0	0	0	0	1
08/15/2020 08:00	0.0	0	0	0	0	1
08/15/2020 09:00	0.0	0	0	0	0	1
08/15/2020 10:00	0.0	0	0	0	0	1
08/15/2020 11:00	0.0	0	0	0	0	1
08/15/2020 12:00	0.0	0	0	0	0	1
08/15/2020 13:00	0.0	0	0	0	0	1
08/15/2020 14:00	0.0	0	0	0	0	1
08/15/2020 15:00	0.0	0	0	0	0	1
08/15/2020 16:00	0.0	0	0	0	0	1
08/15/2020 17:00	0.0	0	0	0	0	1
08/15/2020 18:00	0.0	0	0	0	0	1
08/15/2020 19:00	0.0	0	0	0	0	1
08/15/2020 20:00	0.0	0	0	0	0	1
08/15/2020 21:00	0.0	0	0	0	0	1
08/15/2020 22:00	0.0	0	0	0	0	1
08/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/16/2020 00:00	0.0	0	0	0	0	1
08/16/2020 01:00	0.0	0	0	0	0	1
08/16/2020 02:00	0.0	0	0	0	0	1
08/16/2020 03:00	0.0	0	0	0	0	1
08/16/2020 04:00	0.0	0	0	0	0	1
08/16/2020 05:00	0.0	0	0	0	0	1
08/16/2020 06:00	0.0	0	0	0	0	1
08/16/2020 07:00	0.0	0	0	0	0	1
08/16/2020 08:00	0.0	0	0	0	0	1
08/16/2020 09:00	0.0	0	0	0	0	1
08/16/2020 10:00	0.0	0	0	0	0	1
08/16/2020 11:00	0.0	0	0	0	0	1
08/16/2020 12:00	0.0	0	0	0	0	1
08/16/2020 13:00	0.0	0	0	0	0	1
08/16/2020 14:00	0.0	0	0	0	0	1
08/16/2020 15:00	0.0	0	0	0	0	1
08/16/2020 16:00	0.0	0	0	0	0	1
08/16/2020 17:00	0.0	0	0	0	0	1
08/16/2020 18:00	0.0	0	0	0	0	1
08/16/2020 19:00	0.0	0	0	0	0	1
08/16/2020 20:00	0.0	0	0	0	0	1
08/16/2020 21:00	0.0	0	0	0	0	1
08/16/2020 22:00	0.0	0	0	0	0	1
08/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/17/2020 00:00	0.0	0	0	0	0	1
08/17/2020 01:00	0.0	0	0	0	0	1
08/17/2020 02:00	0.0	0	0	0	0	1
08/17/2020 03:00	0.0	0	0	0	0	1
08/17/2020 04:00	0.0	0	0	0	0	1
08/17/2020 05:00	0.0	0	0	0	0	1
08/17/2020 06:00	0.0	0	0	0	0	1
08/17/2020 07:00	0.0	0	0	0	0	1
08/17/2020 08:00	0.0	0	0	0	0	1
08/17/2020 09:00	0.0	0	0	0	0	1
08/17/2020 10:00	0.0	0	0	0	0	1
08/17/2020 11:00	0.0	0	0	0	0	1
08/17/2020 12:00	0.0	0	0	0	0	1
08/17/2020 13:00	0.0	0	0	0	0	1
08/17/2020 14:00	0.0	0	0	0	0	1
08/17/2020 15:00	0.0	0	0	0	0	1
08/17/2020 16:00	0.0	0	0	0	0	1
08/17/2020 17:00	0.0	0	0	0	0	1
08/17/2020 18:00	0.0	0	0	0	0	1
08/17/2020 19:00	0.0	0	0	0	0	1
08/17/2020 20:00	0.0	0	0	0	0	1
08/17/2020 21:00	0.0	0	0	0	0	1
08/17/2020 22:00	0.0	0	0	0	0	1
08/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/18/2020 00:00	0.0	0	0	0	0	1
08/18/2020 01:00	0.0	0	0	0	0	1
08/18/2020 02:00	0.0	0	0	0	0	1
08/18/2020 03:00	0.0	0	0	0	0	1
08/18/2020 04:00	0.0	0	0	0	0	1
08/18/2020 05:00	0.0	0	0	0	0	1
08/18/2020 06:00	0.0	0	0	0	0	1
08/18/2020 07:00	0.0	0	0	0	0	1
08/18/2020 08:00	0.0	0	0	0	0	1
08/18/2020 09:00	0.0	0	0	0	0	1
08/18/2020 10:00	0.0	0	0	0	0	1
08/18/2020 11:00	0.0	0	0	0	0	1
08/18/2020 12:00	0.0	0	0	0	0	1
08/18/2020 13:00	0.0	0	0	0	0	1
08/18/2020 14:00	0.0	0	0	0	0	1
08/18/2020 15:00	0.0	0	0	0	0	1
08/18/2020 16:00	0.0	0	0	0	0	1
08/18/2020 17:00	0.0	0	0	0	0	1
08/18/2020 18:00	0.0	0	0	0	0	1
08/18/2020 19:00	0.0	0	0	0	0	1
08/18/2020 20:00	0.0	0	0	0	0	1
08/18/2020 21:00	0.0	0	0	0	0	1
08/18/2020 22:00	0.0	0	0	0	0	1
08/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/19/2020 00:00	0.0	0	0	0	0	1
08/19/2020 01:00	0.0	0	0	0	0	1
08/19/2020 02:00	0.0	0	0	0	0	1
08/19/2020 03:00	0.0	0	0	0	0	1
08/19/2020 04:00	0.0	0	0	0	0	1
08/19/2020 05:00	0.0	0	0	0	0	1
08/19/2020 06:00	0.0	0	0	0	0	1
08/19/2020 07:00	0.0	0	0	0	0	1
08/19/2020 08:00	0.0	0	0	0	0	1
08/19/2020 09:00	0.0	0	0	0	0	1
08/19/2020 10:00	0.0	0	0	0	0	1
08/19/2020 11:00	0.0	0	0	0	0	1
08/19/2020 12:00	0.0	0	0	0	0	1
08/19/2020 13:00	0.0	0	0	0	0	1
08/19/2020 14:00	0.0	0	0	0	0	1
08/19/2020 15:00	0.0	0	0	0	0	1
08/19/2020 16:00	0.0	0	0	0	0	1
08/19/2020 17:00	0.0	0	0	0	0	1
08/19/2020 18:00	0.0	0	0	0	0	1
08/19/2020 19:00	0.0	0	0	0	0	1
08/19/2020 20:00	0.0	0	0	0	0	1
08/19/2020 21:00	0.0	0	0	0	0	1
08/19/2020 22:00	0.0	0	0	0	0	1
08/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/20/2020 00:00	0.0	0	0	0	0	1
08/20/2020 01:00	0.0	0	0	0	0	1
08/20/2020 02:00	0.0	0	0	0	0	1
08/20/2020 03:00	0.0	0	0	0	0	1
08/20/2020 04:00	0.0	0	0	0	0	1
08/20/2020 05:00	0.0	0	0	0	0	1
08/20/2020 06:00	0.0	0	0	0	0	1
08/20/2020 07:00	0.0	0	0	0	0	1
08/20/2020 08:00	0.0	0	0	0	0	1
08/20/2020 09:00	0.0	0	0	0	0	1
08/20/2020 10:00	0.0	0	0	0	0	1
08/20/2020 11:00	0.0	0	0	0	0	1
08/20/2020 12:00	0.0	0	0	0	0	1
08/20/2020 13:00	0.0	0	0	0	0	1
08/20/2020 14:00	0.0	0	0	0	0	1
08/20/2020 15:00	0.0	0	0	0	0	1
08/20/2020 16:00	0.0	0	0	0	0	1
08/20/2020 17:00	0.0	0	0	0	0	1
08/20/2020 18:00	0.0	0	0	0	0	1
08/20/2020 19:00	0.0	0	0	0	0	1
08/20/2020 20:00	0.0	0	0	0	0	1
08/20/2020 21:00	0.0	0	0	0	0	1
08/20/2020 22:00	0.0	0	0	0	0	1
08/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/21/2020 00:00	0.0	0	0	0	0	1
08/21/2020 01:00	0.0	0	0	0	0	1
08/21/2020 02:00	0.0	0	0	0	0	1
08/21/2020 03:00	0.0	0	0	0	0	1
08/21/2020 04:00	0.0	0	0	0	0	1
08/21/2020 05:00	0.0	0	0	0	0	1
08/21/2020 06:00	0.0	0	0	0	0	1
08/21/2020 07:00	0.0	0	0	0	0	1
08/21/2020 08:00	0.0	0	0	0	0	1
08/21/2020 09:00	0.0	0	0	0	0	1
08/21/2020 10:00	0.0	0	0	0	0	1
08/21/2020 11:00	0.0	0	0	0	0	1
08/21/2020 12:00	0.0	0	0	0	0	1
08/21/2020 13:00	0.0	0	0	0	0	1
08/21/2020 14:00	0.0	0	0	0	0	1
08/21/2020 15:00	0.0	0	0	0	0	1
08/21/2020 16:00	0.0	0	0	0	0	1
08/21/2020 17:00	0.0	0	0	0	0	1
08/21/2020 18:00	0.0	0	0	0	0	1
08/21/2020 19:00	0.0	0	0	0	0	1
08/21/2020 20:00	0.0	0	0	0	0	1
08/21/2020 21:00	0.0	0	0	0	0	1
08/21/2020 22:00	0.0	0	0	0	0	1
08/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/22/2020 00:00	0.0	0	0	0	0	1
08/22/2020 01:00	0.0	0	0	0	0	1
08/22/2020 02:00	0.0	0	0	0	0	1
08/22/2020 03:00	0.0	0	0	0	0	1
08/22/2020 04:00	0.0	0	0	0	0	1
08/22/2020 05:00	0.0	0	0	0	0	1
08/22/2020 06:00	0.0	0	0	0	0	1
08/22/2020 07:00	0.0	0	0	0	0	1
08/22/2020 08:00	0.0	0	0	0	0	1
08/22/2020 09:00	0.0	0	0	0	0	1
08/22/2020 10:00	0.0	0	0	0	0	1
08/22/2020 11:00	0.0	0	0	0	0	1
08/22/2020 12:00	0.0	0	0	0	0	1
08/22/2020 13:00	0.0	0	0	0	0	1
08/22/2020 14:00	0.0	0	0	0	0	1
08/22/2020 15:00	0.0	0	0	0	0	1
08/22/2020 16:00	0.0	0	0	0	0	1
08/22/2020 17:00	0.0	0	0	0	0	1
08/22/2020 18:00	0.0	0	0	0	0	1
08/22/2020 19:00	0.0	0	0	0	0	1
08/22/2020 20:00	0.0	0	0	0	0	1
08/22/2020 21:00	0.0	0	0	0	0	1
08/22/2020 22:00	0.0	0	0	0	0	1
08/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/23/2020 00:00	0.0	0	0	0	0	1
08/23/2020 01:00	0.0	0	0	0	0	1
08/23/2020 02:00	0.0	0	0	0	0	1
08/23/2020 03:00	0.0	0	0	0	0	1
08/23/2020 04:00	0.0	0	0	0	0	1
08/23/2020 05:00	0.0	0	0	0	0	1
08/23/2020 06:00	0.0	0	0	0	0	1
08/23/2020 07:00	0.0	0	0	0	0	1
08/23/2020 08:00	0.0	0	0	0	0	1
08/23/2020 09:00	0.0	0	0	0	0	1
08/23/2020 10:00	0.0	0	0	0	0	1
08/23/2020 11:00	0.0	0	0	0	0	1
08/23/2020 12:00	0.0	0	0	0	0	1
08/23/2020 13:00	0.0	0	0	0	0	1
08/23/2020 14:00	0.0	0	0	0	0	1
08/23/2020 15:00	0.0	0	0	0	0	1
08/23/2020 16:00	0.0	0	0	0	0	1
08/23/2020 17:00	0.0	0	0	0	0	1
08/23/2020 18:00	0.0	0	0	0	0	1
08/23/2020 19:00	0.0	0	0	0	0	1
08/23/2020 20:00	0.0	0	0	0	0	1
08/23/2020 21:00	0.0	0	0	0	0	1
08/23/2020 22:00	0.0	0	0	0	0	1
08/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/24/2020 00:00	0.0	0	0	0	0	1
08/24/2020 01:00	0.0	0	0	0	0	1
08/24/2020 02:00	0.0	0	0	0	0	1
08/24/2020 03:00	0.0	0	0	0	0	1
08/24/2020 04:00	0.0	0	0	0	0	1
08/24/2020 05:00	0.0	0	0	0	0	1
08/24/2020 06:00	0.0	0	0	0	0	1
08/24/2020 07:00	0.0	0	0	0	0	1
08/24/2020 08:00	0.0	0	0	0	0	1
08/24/2020 09:00	0.0	0	0	0	0	1
08/24/2020 10:00	0.0	0	0	0	0	1
08/24/2020 11:00	0.0	0	0	0	0	1
08/24/2020 12:00	0.0	0	0	0	0	1
08/24/2020 13:00	0.0	0	0	0	0	1
08/24/2020 14:00	0.0	0	0	0	0	1
08/24/2020 15:00	0.0	0	0	0	0	1
08/24/2020 16:00	0.0	0	0	0	0	1
08/24/2020 17:00	0.0	0	0	0	0	1
08/24/2020 18:00	0.0	0	0	0	0	1
08/24/2020 19:00	0.0	0	0	0	0	1
08/24/2020 20:00	0.0	0	0	0	0	1
08/24/2020 21:00	0.0	0	0	0	0	1
08/24/2020 22:00	0.0	0	0	0	0	1
08/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/25/2020 00:00	0.0	0	0	0	0	1
08/25/2020 01:00	0.0	0	0	0	0	1
08/25/2020 02:00	0.0	0	0	0	0	1
08/25/2020 03:00	0.0	0	0	0	0	1
08/25/2020 04:00	0.0	0	0	0	0	1
08/25/2020 05:00	0.0	0	0	0	0	1
08/25/2020 06:00	0.0	0	0	0	0	1
08/25/2020 07:00	0.0	0	0	0	0	1
08/25/2020 08:00	0.0	0	0	0	0	1
08/25/2020 09:00	0.0	0	0	0	0	1
08/25/2020 10:00	0.0	0	0	0	0	1
08/25/2020 11:00	0.0	0	0	0	0	1
08/25/2020 12:00	0.0	0	0	0	0	1
08/25/2020 13:00	0.0	0	0	0	0	1
08/25/2020 14:00	0.0	0	0	0	0	1
08/25/2020 15:00	0.0	0	0	0	0	1
08/25/2020 16:00	0.0	0	0	0	0	1
08/25/2020 17:00	0.0	0	0	0	0	1
08/25/2020 18:00	0.0	0	0	0	0	1
08/25/2020 19:00	0.0	0	0	0	0	1
08/25/2020 20:00	0.0	0	0	0	0	1
08/25/2020 21:00	0.0	0	0	0	0	1
08/25/2020 22:00	0.0	0	0	0	0	1
08/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/26/2020 00:00	0.0	0	0	0	0	1
08/26/2020 01:00	0.0	0	0	0	0	1
08/26/2020 02:00	0.0	0	0	0	0	1
08/26/2020 03:00	0.0	0	0	0	0	1
08/26/2020 04:00	0.0	0	0	0	0	1
08/26/2020 05:00	0.0	0	0	0	0	1
08/26/2020 06:00	0.0	0	0	0	0	1
08/26/2020 07:00	0.0	0	0	0	0	1
08/26/2020 08:00	0.0	0	0	0	0	1
08/26/2020 09:00	0.0	0	0	0	0	1
08/26/2020 10:00	0.0	0	0	0	0	1
08/26/2020 11:00	0.0	0	0	0	0	1
08/26/2020 12:00	0.0	0	0	0	0	1
08/26/2020 13:00	0.0	0	0	0	0	1
08/26/2020 14:00	0.0	0	0	0	0	1
08/26/2020 15:00	0.0	0	0	0	0	1
08/26/2020 16:00	0.0	0	0	0	0	1
08/26/2020 17:00	0.0	0	0	0	0	1
08/26/2020 18:00	0.0	0	0	0	0	1
08/26/2020 19:00	0.0	0	0	0	0	1
08/26/2020 20:00	0.0	0	0	0	0	1
08/26/2020 21:00	0.0	0	0	0	0	1
08/26/2020 22:00	0.0	0	0	0	0	1
08/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/27/2020 00:00	0.0	0	0	0	0	1
08/27/2020 01:00	0.0	0	0	0	0	1
08/27/2020 02:00	0.0	0	0	0	0	1
08/27/2020 03:00	0.0	0	0	0	0	1
08/27/2020 04:00	0.0	0	0	0	0	1
08/27/2020 05:00	0.0	0	0	0	0	1
08/27/2020 06:00	0.0	0	0	0	0	1
08/27/2020 07:00	0.0	0	0	0	0	1
08/27/2020 08:00	0.0	0	0	0	0	1
08/27/2020 09:00	0.0	0	0	0	0	1
08/27/2020 10:00	0.0	0	0	0	0	1
08/27/2020 11:00	0.0	0	0	0	0	1
08/27/2020 12:00	0.0	0	0	0	0	1
08/27/2020 13:00	0.0	0	0	0	0	1
08/27/2020 14:00	0.0	0	0	0	0	1
08/27/2020 15:00	0.0	0	0	0	0	1
08/27/2020 16:00	0.0	0	0	0	0	1
08/27/2020 17:00	0.0	0	0	0	0	1
08/27/2020 18:00	0.0	0	0	0	0	1
08/27/2020 19:00	0.0	0	0	0	0	1
08/27/2020 20:00	0.0	0	0	0	0	1
08/27/2020 21:00	0.0	0	0	0	0	1
08/27/2020 22:00	0.0	0	0	0	0	1
08/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/28/2020 00:00	0.0	0	0	0	0	1
08/28/2020 01:00	0.0	0	0	0	0	1
08/28/2020 02:00	0.0	0	0	0	0	1
08/28/2020 03:00	0.0	0	0	0	0	1
08/28/2020 04:00	0.0	0	0	0	0	1
08/28/2020 05:00	0.0	0	0	0	0	1
08/28/2020 06:00	0.0	0	0	0	0	1
08/28/2020 07:00	0.0	0	0	0	0	1
08/28/2020 08:00	0.0	0	0	0	0	1
08/28/2020 09:00	0.0	0	0	0	0	1
08/28/2020 10:00	0.0	0	0	0	0	1
08/28/2020 11:00	0.0	0	0	0	0	1
08/28/2020 12:00	0.0	0	0	0	0	1
08/28/2020 13:00	0.0	0	0	0	0	1
08/28/2020 14:00	0.0	0	0	0	0	1
08/28/2020 15:00	0.0	0	0	0	0	1
08/28/2020 16:00	0.0	0	0	0	0	1
08/28/2020 17:00	0.0	0	0	0	0	1
08/28/2020 18:00	0.0	0	0	0	0	1
08/28/2020 19:00	0.0	0	0	0	0	1
08/28/2020 20:00	0.0	0	0	0	0	1
08/28/2020 21:00	0.0	0	0	0	0	1
08/28/2020 22:00	0.0	0	0	0	0	1
08/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/29/2020 00:00	0.0	0	0	0	0	1
08/29/2020 01:00	0.0	0	0	0	0	1
08/29/2020 02:00	0.0	0	0	0	0	1
08/29/2020 03:00	0.0	0	0	0	0	1
08/29/2020 04:00	0.0	0	0	0	0	1
08/29/2020 05:00	0.0	0	0	0	0	1
08/29/2020 06:00	0.0	0	0	0	0	1
08/29/2020 07:00	0.0	0	0	0	0	1
08/29/2020 08:00	0.0	0	0	0	0	1
08/29/2020 09:00	0.0	0	0	0	0	1
08/29/2020 10:00	0.0	0	0	0	0	1
08/29/2020 11:00	0.0	0	0	0	0	1
08/29/2020 12:00	0.0	0	0	0	0	1
08/29/2020 13:00	0.0	0	0	0	0	1
08/29/2020 14:00	0.0	0	0	0	0	1
08/29/2020 15:00	0.0	0	0	0	0	1
08/29/2020 16:00	0.0	0	0	0	0	1
08/29/2020 17:00	0.0	0	0	0	0	1
08/29/2020 18:00	0.0	0	0	0	0	1
08/29/2020 19:00	0.0	0	0	0	0	1
08/29/2020 20:00	0.0	0	0	0	0	1
08/29/2020 21:00	0.0	0	0	0	0	1
08/29/2020 22:00	0.0	0	0	0	0	1
08/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/30/2020 00:00	0.0	0	0	0	0	1
08/30/2020 01:00	0.0	0	0	0	0	1
08/30/2020 02:00	0.0	0	0	0	0	1
08/30/2020 03:00	0.0	0	0	0	0	1
08/30/2020 04:00	0.0	0	0	0	0	1
08/30/2020 05:00	0.0	0	0	0	0	1
08/30/2020 06:00	0.0	0	0	0	0	1
08/30/2020 07:00	0.0	0	0	0	0	1
08/30/2020 08:00	0.0	0	0	0	0	1
08/30/2020 09:00	0.0	0	0	0	0	1
08/30/2020 10:00	0.0	0	0	0	0	1
08/30/2020 11:00	0.0	0	0	0	0	1
08/30/2020 12:00	0.0	0	0	0	0	1
08/30/2020 13:00	0.0	0	0	0	0	1
08/30/2020 14:00	0.0	0	0	0	0	1
08/30/2020 15:00	0.0	0	0	0	0	1
08/30/2020 16:00	0.0	0	0	0	0	1
08/30/2020 17:00	0.0	0	0	0	0	1
08/30/2020 18:00	0.0	0	0	0	0	1
08/30/2020 19:00	0.0	0	0	0	0	1
08/30/2020 20:00	0.0	0	0	0	0	1
08/30/2020 21:00	0.0	0	0	0	0	1
08/30/2020 22:00	0.0	0	0	0	0	1
08/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/31/2020 00:00	0.0	0	0	0	0	1
08/31/2020 01:00	0.0	0	0	0	0	1
08/31/2020 02:00	0.0	0	0	0	0	1
08/31/2020 03:00	0.0	0	0	0	0	1
08/31/2020 04:00	0.0	0	0	0	0	1
08/31/2020 05:00	0.0	0	0	0	0	1
08/31/2020 06:00	0.0	0	0	0	0	1
08/31/2020 07:00	0.0	0	0	0	0	1
08/31/2020 08:00	0.0	0	0	0	0	1
08/31/2020 09:00	0.0	0	0	0	0	1
08/31/2020 10:00	0.0	0	0	0	0	1
08/31/2020 11:00	0.0	0	0	0	0	1
08/31/2020 12:00	0.0	0	0	0	0	1
08/31/2020 13:00	0.0	0	0	0	0	1
08/31/2020 14:00	0.0	0	0	0	0	1
08/31/2020 15:00	0.0	0	0	0	0	1
08/31/2020 16:00	0.0	0	0	0	0	1
08/31/2020 17:00	0.0	0	0	0	0	1
08/31/2020 18:00	0.0	0	0	0	0	1
08/31/2020 19:00	0.0	0	0	0	0	1
08/31/2020 20:00	0.0	0	0	0	0	1
08/31/2020 21:00	0.0	0	0	0	0	1
08/31/2020 22:00	0.0	0	0	0	0	1
08/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/01/2020 00:00	0.0	0	0	0	0	1
09/01/2020 01:00	0.0	0	0	0	0	1
09/01/2020 02:00	0.0	0	0	0	0	1
09/01/2020 03:00	0.0	0	0	0	0	1
09/01/2020 04:00	0.0	0	0	0	0	1
09/01/2020 05:00	0.0	0	0	0	0	1
09/01/2020 06:00	0.0	0	0	0	0	1
09/01/2020 07:00	0.0	0	0	0	0	1
09/01/2020 08:00	0.0	0	0	0	0	1
09/01/2020 09:00	0.0	0	0	0	0	1
09/01/2020 10:00	0.0	0	0	0	0	1
09/01/2020 11:00	0.0	0	0	0	0	1
09/01/2020 12:00	0.0	0	0	0	0	1
09/01/2020 13:00	0.0	0	0	0	0	1
09/01/2020 14:00	0.0	0	0	0	0	1
09/01/2020 15:00	0.0	0	0	0	0	1
09/01/2020 16:00	0.0	0	0	0	0	1
09/01/2020 17:00	0.0	0	0	0	0	1
09/01/2020 18:00	0.0	0	0	0	0	1
09/01/2020 19:00	0.0	0	0	0	0	1
09/01/2020 20:00	0.0	0	0	0	0	1
09/01/2020 21:00	0.0	0	0	0	0	1
09/01/2020 22:00	0.0	0	0	0	0	1
09/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/02/2020 00:00	0.0	0	0	0	0	1
09/02/2020 01:00	0.0	0	0	0	0	1
09/02/2020 02:00	0.0	0	0	0	0	1
09/02/2020 03:00	0.0	0	0	0	0	1
09/02/2020 04:00	0.0	0	0	0	0	1
09/02/2020 05:00	0.0	0	0	0	0	1
09/02/2020 06:00	0.0	0	0	0	0	1
09/02/2020 07:00	0.0	0	0	0	0	1
09/02/2020 08:00	0.0	0	0	0	0	1
09/02/2020 09:00	0.0	0	0	0	0	1
09/02/2020 10:00	0.0	0	0	0	0	1
09/02/2020 11:00	0.0	0	0	0	0	1
09/02/2020 12:00	0.0	0	0	0	0	1
09/02/2020 13:00	0.0	0	0	0	0	1
09/02/2020 14:00	0.0	0	0	0	0	1
09/02/2020 15:00	0.0	0	0	0	0	1
09/02/2020 16:00	0.0	0	0	0	0	1
09/02/2020 17:00	0.0	0	0	0	0	1
09/02/2020 18:00	0.0	0	0	0	0	1
09/02/2020 19:00	0.0	0	0	0	0	1
09/02/2020 20:00	0.0	0	0	0	0	1
09/02/2020 21:00	0.0	0	0	0	0	1
09/02/2020 22:00	0.0	0	0	0	0	1
09/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/03/2020 00:00	0.0	0	0	0	0	1
09/03/2020 01:00	0.0	0	0	0	0	1
09/03/2020 02:00	0.0	0	0	0	0	1
09/03/2020 03:00	0.0	0	0	0	0	1
09/03/2020 04:00	0.0	0	0	0	0	1
09/03/2020 05:00	0.0	0	0	0	0	1
09/03/2020 06:00	0.0	0	0	0	0	1
09/03/2020 07:00	0.0	0	0	0	0	1
09/03/2020 08:00	0.0	0	0	0	0	1
09/03/2020 09:00	0.0	0	0	0	0	1
09/03/2020 10:00	0.0	0	0	0	0	1
09/03/2020 11:00	0.0	0	0	0	0	1
09/03/2020 12:00	0.0	0	0	0	0	1
09/03/2020 13:00	0.0	0	0	0	0	1
09/03/2020 14:00	0.0	0	0	0	0	1
09/03/2020 15:00	0.0	0	0	0	0	1
09/03/2020 16:00	0.0	0	0	0	0	1
09/03/2020 17:00	0.0	0	0	0	0	1
09/03/2020 18:00	0.0	0	0	0	0	1
09/03/2020 19:00	0.0	0	0	0	0	1
09/03/2020 20:00	0.0	0	0	0	0	1
09/03/2020 21:00	0.0	0	0	0	0	1
09/03/2020 22:00	0.0	0	0	0	0	1
09/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/04/2020 00:00	0.0	0	0	0	0	1
09/04/2020 01:00	0.0	0	0	0	0	1
09/04/2020 02:00	0.0	0	0	0	0	1
09/04/2020 03:00	0.0	0	0	0	0	1
09/04/2020 04:00	0.0	0	0	0	0	1
09/04/2020 05:00	0.0	0	0	0	0	1
09/04/2020 06:00	0.0	0	0	0	0	1
09/04/2020 07:00	0.0	0	0	0	0	1
09/04/2020 08:00	0.0	0	0	0	0	1
09/04/2020 09:00	0.0	0	0	0	0	1
09/04/2020 10:00	0.0	0	0	0	0	1
09/04/2020 11:00	0.0	0	0	0	0	1
09/04/2020 12:00	0.0	0	0	0	0	1
09/04/2020 13:00	0.0	0	0	0	0	1
09/04/2020 14:00	0.0	0	0	0	0	1
09/04/2020 15:00	0.0	0	0	0	0	1
09/04/2020 16:00	0.0	0	0	0	0	1
09/04/2020 17:00	0.0	0	0	0	0	1
09/04/2020 18:00	0.0	0	0	0	0	1
09/04/2020 19:00	0.0	0	0	0	0	1
09/04/2020 20:00	0.0	0	0	0	0	1
09/04/2020 21:00	0.0	0	0	0	0	1
09/04/2020 22:00	0.0	0	0	0	0	1
09/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/05/2020 00:00	0.0	0	0	0	0	1
09/05/2020 01:00	0.0	0	0	0	0	1
09/05/2020 02:00	0.0	0	0	0	0	1
09/05/2020 03:00	0.0	0	0	0	0	1
09/05/2020 04:00	0.0	0	0	0	0	1
09/05/2020 05:00	0.0	0	0	0	0	1
09/05/2020 06:00	0.0	0	0	0	0	1
09/05/2020 07:00	0.0	0	0	0	0	1
09/05/2020 08:00	0.0	0	0	0	0	1
09/05/2020 09:00	0.0	0	0	0	0	1
09/05/2020 10:00	0.0	0	0	0	0	1
09/05/2020 11:00	0.0	0	0	0	0	1
09/05/2020 12:00	0.0	0	0	0	0	1
09/05/2020 13:00	0.0	0	0	0	0	1
09/05/2020 14:00	0.0	0	0	0	0	1
09/05/2020 15:00	0.0	0	0	0	0	1
09/05/2020 16:00	0.0	0	0	0	0	1
09/05/2020 17:00	0.0	0	0	0	0	1
09/05/2020 18:00	0.0	0	0	0	0	1
09/05/2020 19:00	0.0	0	0	0	0	1
09/05/2020 20:00	0.0	0	0	0	0	1
09/05/2020 21:00	0.0	0	0	0	0	1
09/05/2020 22:00	0.0	0	0	0	0	1
09/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/06/2020 00:00	0.0	0	0	0	0	1
09/06/2020 01:00	0.0	0	0	0	0	1
09/06/2020 02:00	0.0	0	0	0	0	1
09/06/2020 03:00	0.0	0	0	0	0	1
09/06/2020 04:00	0.0	0	0	0	0	1
09/06/2020 05:00	0.0	0	0	0	0	1
09/06/2020 06:00	0.0	0	0	0	0	1
09/06/2020 07:00	0.0	0	0	0	0	1
09/06/2020 08:00	0.0	0	0	0	0	1
09/06/2020 09:00	0.0	0	0	0	0	1
09/06/2020 10:00	0.0	0	0	0	0	1
09/06/2020 11:00	0.0	0	0	0	0	1
09/06/2020 12:00	0.0	0	0	0	0	1
09/06/2020 13:00	0.0	0	0	0	0	1
09/06/2020 14:00	0.0	0	0	0	0	1
09/06/2020 15:00	0.0	0	0	0	0	1
09/06/2020 16:00	0.0	0	0	0	0	1
09/06/2020 17:00	0.0	0	0	0	0	1
09/06/2020 18:00	0.0	0	0	0	0	1
09/06/2020 19:00	0.0	0	0	0	0	1
09/06/2020 20:00	0.0	0	0	0	0	1
09/06/2020 21:00	0.0	0	0	0	0	1
09/06/2020 22:00	0.0	0	0	0	0	1
09/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/07/2020 00:00	0.0	0	0	0	0	1
09/07/2020 01:00	0.0	0	0	0	0	1
09/07/2020 02:00	0.0	0	0	0	0	1
09/07/2020 03:00	0.0	0	0	0	0	1
09/07/2020 04:00	0.0	0	0	0	0	1
09/07/2020 05:00	0.0	0	0	0	0	1
09/07/2020 06:00	0.0	0	0	0	0	1
09/07/2020 07:00	0.0	0	0	0	0	1
09/07/2020 08:00	0.0	0	0	0	0	1
09/07/2020 09:00	0.0	0	0	0	0	1
09/07/2020 10:00	0.0	0	0	0	0	1
09/07/2020 11:00	0.0	0	0	0	0	1
09/07/2020 12:00	0.0	0	0	0	0	1
09/07/2020 13:00	0.0	0	0	0	0	1
09/07/2020 14:00	0.0	0	0	0	0	1
09/07/2020 15:00	0.0	0	0	0	0	1
09/07/2020 16:00	0.0	0	0	0	0	1
09/07/2020 17:00	0.0	0	0	0	0	1
09/07/2020 18:00	0.0	0	0	0	0	1
09/07/2020 19:00	0.0	0	0	0	0	1
09/07/2020 20:00	0.0	0	0	0	0	1
09/07/2020 21:00	0.0	0	0	0	0	1
09/07/2020 22:00	0.0	0	0	0	0	1
09/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/08/2020 00:00	0.0	0	0	0	0	1
09/08/2020 01:00	0.0	0	0	0	0	1
09/08/2020 02:00	0.0	0	0	0	0	1
09/08/2020 03:00	0.0	0	0	0	0	1
09/08/2020 04:00	0.0	0	0	0	0	1
09/08/2020 05:00	0.0	0	0	0	0	1
09/08/2020 06:00	0.0	0	0	0	0	1
09/08/2020 07:00	0.0	0	0	0	0	1
09/08/2020 08:00	0.0	0	0	0	0	1
09/08/2020 09:00	0.0	0	0	0	0	1
09/08/2020 10:00	0.0	0	0	0	0	1
09/08/2020 11:00	0.0	0	0	0	0	1
09/08/2020 12:00	0.0	0	0	0	0	1
09/08/2020 13:00	0.0	0	0	0	0	1
09/08/2020 14:00	0.0	0	0	0	0	1
09/08/2020 15:00	0.0	0	0	0	0	1
09/08/2020 16:00	0.0	0	0	0	0	1
09/08/2020 17:00	0.0	0	0	0	0	1
09/08/2020 18:00	0.0	0	0	0	0	1
09/08/2020 19:00	0.0	0	0	0	0	1
09/08/2020 20:00	0.0	0	0	0	0	1
09/08/2020 21:00	0.0	0	0	0	0	1
09/08/2020 22:00	0.0	0	0	0	0	1
09/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/09/2020 00:00	0.0	0	0	0	0	1
09/09/2020 01:00	0.0	0	0	0	0	1
09/09/2020 02:00	0.0	0	0	0	0	1
09/09/2020 03:00	0.0	0	0	0	0	1
09/09/2020 04:00	0.0	0	0	0	0	1
09/09/2020 05:00	0.0	0	0	0	0	1
09/09/2020 06:00	0.0	0	0	0	0	1
09/09/2020 07:00	0.0	0	0	0	0	1
09/09/2020 08:00	0.0	0	0	0	0	1
09/09/2020 09:00	0.0	0	0	0	0	1
09/09/2020 10:00	0.0	0	0	0	0	1
09/09/2020 11:00	0.0	0	0	0	0	1
09/09/2020 12:00	0.0	0	0	0	0	1
09/09/2020 13:00	0.0	0	0	0	0	1
09/09/2020 14:00	0.0	0	0	0	0	1
09/09/2020 15:00	0.0	0	0	0	0	1
09/09/2020 16:00	0.0	0	0	0	0	1
09/09/2020 17:00	0.0	0	0	0	0	1
09/09/2020 18:00	0.0	0	0	0	0	1
09/09/2020 19:00	0.0	0	0	0	0	1
09/09/2020 20:00	0.0	0	0	0	0	1
09/09/2020 21:00	0.0	0	0	0	0	1
09/09/2020 22:00	0.0	0	0	0	0	1
09/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/10/2020 00:00	0.0	0	0	0	0	1
09/10/2020 01:00	0.0	0	0	0	0	1
09/10/2020 02:00	0.0	0	0	0	0	1
09/10/2020 03:00	0.0	0	0	0	0	1
09/10/2020 04:00	0.0	0	0	0	0	1
09/10/2020 05:00	0.0	0	0	0	0	1
09/10/2020 06:00	0.0	0	0	0	0	1
09/10/2020 07:00	0.0	0	0	0	0	1
09/10/2020 08:00	0.0	0	0	0	0	1
09/10/2020 09:00	0.0	0	0	0	0	1
09/10/2020 10:00	0.0	0	0	0	0	1
09/10/2020 11:00	0.0	0	0	0	0	1
09/10/2020 12:00	0.0	0	0	0	0	1
09/10/2020 13:00	0.0	0	0	0	0	1
09/10/2020 14:00	0.0	0	0	0	0	1
09/10/2020 15:00	0.0	0	0	0	0	1
09/10/2020 16:00	0.0	0	0	0	0	1
09/10/2020 17:00	0.0	0	0	0	0	1
09/10/2020 18:00	0.0	0	0	0	0	1
09/10/2020 19:00	0.0	0	0	0	0	1
09/10/2020 20:00	0.0	0	0	0	0	1
09/10/2020 21:00	0.0	0	0	0	0	1
09/10/2020 22:00	0.0	0	0	0	0	1
09/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/11/2020 00:00	0.0	0	0	0	0	1
09/11/2020 01:00	0.0	0	0	0	0	1
09/11/2020 02:00	0.0	0	0	0	0	1
09/11/2020 03:00	0.0	0	0	0	0	1
09/11/2020 04:00	0.0	0	0	0	0	1
09/11/2020 05:00	0.0	0	0	0	0	1
09/11/2020 06:00	0.0	0	0	0	0	1
09/11/2020 07:00	0.0	0	0	0	0	1
09/11/2020 08:00	0.0	0	0	0	0	1
09/11/2020 09:00	0.0	0	0	0	0	1
09/11/2020 10:00	0.0	0	0	0	0	1
09/11/2020 11:00	0.0	0	0	0	0	1
09/11/2020 12:00	0.0	0	0	0	0	1
09/11/2020 13:00	0.0	0	0	0	0	1
09/11/2020 14:00	0.0	0	0	0	0	1
09/11/2020 15:00	0.0	0	0	0	0	1
09/11/2020 16:00	0.0	0	0	0	0	1
09/11/2020 17:00	0.0	0	0	0	0	1
09/11/2020 18:00	0.0	0	0	0	0	1
09/11/2020 19:00	0.0	0	0	0	0	1
09/11/2020 20:00	0.0	0	0	0	0	1
09/11/2020 21:00	0.0	0	0	0	0	1
09/11/2020 22:00	0.0	0	0	0	0	1
09/11/2020 23:00	0.8	0	0	0	1	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/12/2020 00:00	0.0	0	0	0	0	0
09/12/2020 01:00	0.0	0	0	0	0	0
09/12/2020 02:00	0.0	0	0	0	0	0
09/12/2020 03:00	0.0	0	0	0	0	0
09/12/2020 04:00	0.0	0	0	0	0	0
09/12/2020 05:00	0.0	0	0	0	0	0
09/12/2020 06:00	0.0	0	0	0	0	0
09/12/2020 07:00	0.0	0	0	0	0	0
09/12/2020 08:00	0.0	0	0	0	0	0
09/12/2020 09:00	0.0	0	0	0	0	0
09/12/2020 10:00	0.0	0	0	0	0	0
09/12/2020 11:00	0.0	0	0	0	0	0
09/12/2020 12:00	0.0	0	0	0	0	0
09/12/2020 13:00	0.0	0	0	0	0	0
09/12/2020 14:00	0.0	0	0	0	0	0
09/12/2020 15:00	0.0	0	0	0	0	0
09/12/2020 16:00	0.0	0	0	0	0	0
09/12/2020 17:00	0.0	0	0	0	0	0
09/12/2020 18:00	0.0	0	0	0	0	0
09/12/2020 19:00	0.0	0	0	0	0	0
09/12/2020 20:00	0.0	0	0	0	0	0
09/12/2020 21:00	0.0	0	0	0	0	0
09/12/2020 22:00	0.0	0	0	0	0	0
09/12/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/13/2020 00:00	0.0	0	0	0	0	0
09/13/2020 01:00	0.0	0	0	0	0	0
09/13/2020 02:00	0.0	0	0	0	0	0
09/13/2020 03:00	0.0	0	0	0	0	0
09/13/2020 04:00	0.0	0	0	0	0	0
09/13/2020 05:00	0.0	0	0	0	0	0
09/13/2020 06:00	0.0	0	0	0	0	0
09/13/2020 07:00	0.0	0	0	0	0	0
09/13/2020 08:00	0.0	0	0	0	0	0
09/13/2020 09:00	0.0	0	0	0	0	0
09/13/2020 10:00	0.0	0	0	0	0	0
09/13/2020 11:00	0.0	0	0	0	0	0
09/13/2020 12:00	0.0	0	0	0	0	0
09/13/2020 13:00	0.0	0	0	0	0	0
09/13/2020 14:00	0.0	0	0	0	0	0
09/13/2020 15:00	0.0	0	0	0	0	0
09/13/2020 16:00	0.0	0	0	0	0	0
09/13/2020 17:00	0.0	0	0	0	0	0
09/13/2020 18:00	0.0	0	0	0	0	0
09/13/2020 19:00	0.0	0	0	0	0	0
09/13/2020 20:00	0.0	0	0	0	0	0
09/13/2020 21:00	0.0	0	0	0	0	0
09/13/2020 22:00	0.0	0	0	0	0	0
09/13/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/14/2020 00:00	0.0	0	0	0	0	0
09/14/2020 01:00	0.0	0	0	0	0	0
09/14/2020 02:00	0.0	0	0	0	0	0
09/14/2020 03:00	0.0	0	0	0	0	0
09/14/2020 04:00	0.0	0	0	0	0	0
09/14/2020 05:00	0.0	0	0	0	0	0
09/14/2020 06:00	0.0	0	0	0	0	0
09/14/2020 07:00	0.0	0	0	0	0	0
09/14/2020 08:00	0.0	0	0	0	0	0
09/14/2020 09:00	0.0	0	0	0	0	0
09/14/2020 10:00	0.0	0	0	0	0	0
09/14/2020 11:00	0.0	0	0	0	0	0
09/14/2020 12:00	0.0	0	0	0	0	0
09/14/2020 13:00	53.4	0	1	0	0	0
09/14/2020 14:00	69.5	0	1	0	0	0
09/14/2020 15:00	2.7	0	1	0	0	0
09/14/2020 16:00	0.0	0	0	0	0	1
09/14/2020 17:00	0.0	0	0	0	0	1
09/14/2020 18:00	0.0	0	0	0	0	1
09/14/2020 19:00	0.0	0	0	0	0	1
09/14/2020 20:00	0.0	0	0	0	0	1
09/14/2020 21:00	0.0	0	0	0	0	1
09/14/2020 22:00	0.0	0	0	0	0	1
09/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	125.6 #	0 #	3 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	69.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/15/2020 00:00	0.0	0	0	0	0	1
09/15/2020 01:00	0.0	0	0	0	0	1
09/15/2020 02:00	0.0	0	0	0	0	1
09/15/2020 03:00	0.0	0	0	0	0	1
09/15/2020 04:00	0.0	0	0	0	0	1
09/15/2020 05:00	0.0	0	0	0	0	1
09/15/2020 06:00	0.0	0	0	0	0	1
09/15/2020 07:00	0.0	0	0	0	0	1
09/15/2020 08:00	0.0	0	0	0	0	1
09/15/2020 09:00	0.0	0	0	0	0	1
09/15/2020 10:00	0.0	0	0	0	0	1
09/15/2020 11:00	0.0	0	0	0	0	1
09/15/2020 12:00	0.0	0	0	0	0	1
09/15/2020 13:00	0.0	0	0	0	0	1
09/15/2020 14:00	0.0	0	0	0	0	1
09/15/2020 15:00	0.0	0	0	0	0	1
09/15/2020 16:00	0.0	0	0	0	0	1
09/15/2020 17:00	0.0	0	0	0	0	1
09/15/2020 18:00	0.0	0	0	0	0	1
09/15/2020 19:00	0.0	0	0	0	0	1
09/15/2020 20:00	0.0	0	0	0	0	1
09/15/2020 21:00	0.0	0	0	0	0	1
09/15/2020 22:00	0.3	0	0	0	1	0
09/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.3 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/16/2020 00:00	0.0	0	0	0	0	0
09/16/2020 01:00	0.0	0	0	0	0	0
09/16/2020 02:00	0.0	0	0	0	0	0
09/16/2020 03:00	0.0	0	0	0	0	0
09/16/2020 04:00	0.0	0	0	0	0	0
09/16/2020 05:00	0.0	0	0	0	0	0
09/16/2020 06:00	11.2	0	1	0	0	0
09/16/2020 07:00	19.0	0	1	0	0	0
09/16/2020 08:00	0.0	0	0	0	0	1
09/16/2020 09:00	0.0	0	0	0	0	1
09/16/2020 10:00	0.0	0	0	0	0	1
09/16/2020 11:00	0.0	0	0	0	0	1
09/16/2020 12:00	0.0	0	0	0	0	1
09/16/2020 13:00	0.0	0	0	0	0	1
09/16/2020 14:00	0.0	0	0	0	0	1
09/16/2020 15:00	0.0	0	0	0	0	1
09/16/2020 16:00	0.0	0	0	0	0	1
09/16/2020 17:00	0.0	0	0	0	0	1
09/16/2020 18:00	0.0	0	0	0	0	1
09/16/2020 19:00	0.0	0	0	0	0	1
09/16/2020 20:00	0.0	0	0	0	0	1
09/16/2020 21:00	0.0	0	0	0	0	1
09/16/2020 22:00	0.0	0	0	0	0	1
09/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	30.2 #	0 #	2 #	0 #	0 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	19.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOX_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/17/2020 00:00	0.0	0	0	0	0	1
09/17/2020 01:00	0.0	0	0	0	0	1
09/17/2020 02:00	0.0	0	0	0	0	1
09/17/2020 03:00	0.0	0	0	0	0	1
09/17/2020 04:00	0.0	0	0	0	0	1
09/17/2020 05:00	0.0	0	0	0	0	1
09/17/2020 06:00	0.0	0	0	0	0	1
09/17/2020 07:00	0.0	0	0	0	0	1
09/17/2020 08:00	0.0	0	0	0	0	1
09/17/2020 09:00	0.0	0	0	0	0	1
09/17/2020 10:00	0.0	0	0	0	0	1
09/17/2020 11:00	0.0	0	0	0	0	1
09/17/2020 12:00	0.0	0	0	0	0	1
09/17/2020 13:00	0.0	0	0	0	0	1
09/17/2020 14:00	0.0	0	0	0	0	1
09/17/2020 15:00	0.0	0	0	0	0	1
09/17/2020 16:00	0.0	0	0	0	0	1
09/17/2020 17:00	0.0	0	0	0	0	1
09/17/2020 18:00	0.0	0	0	0	0	1
09/17/2020 19:00	0.0	0	0	0	0	1
09/17/2020 20:00	0.0	0	0	0	0	1
09/17/2020 21:00	0.0	0	0	0	0	1
09/17/2020 22:00	0.0	0	0	0	0	1
09/17/2020 23:00	0.5	0	0	0	1	0
Average/Sum#:	0.5 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/18/2020 00:00	0.0	0	0	0	1	0
09/18/2020 01:00	0.0	0	0	0	0	0
09/18/2020 02:00	0.0	0	0	0	0	0
09/18/2020 03:00	0.0	0	0	0	0	0
09/18/2020 04:00	0.0	0	0	0	0	0
09/18/2020 05:00	0.0	0	0	0	0	0
09/18/2020 06:00	3.9	0	0	1	0	0
09/18/2020 07:00	15.7	0	0	1	0	0
09/18/2020 08:00	0.0	0	0	0	0	1
09/18/2020 09:00	0.0	0	0	0	0	1
09/18/2020 10:00	0.0	0	0	0	0	1
09/18/2020 11:00	0.0	0	0	0	0	1
09/18/2020 12:00	0.0	0	0	0	0	1
09/18/2020 13:00	0.0	0	0	0	0	1
09/18/2020 14:00	0.0	0	0	0	0	1
09/18/2020 15:00	0.0	0	0	0	0	1
09/18/2020 16:00	0.0	0	0	0	0	1
09/18/2020 17:00	0.0	0	0	0	0	1
09/18/2020 18:00	0.0	0	0	0	0	1
09/18/2020 19:00	0.0	0	0	0	0	1
09/18/2020 20:00	0.0	0	0	0	0	1
09/18/2020 21:00	0.0	0	0	0	0	1
09/18/2020 22:00	0.7	0	0	0	1	0
09/18/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	20.3 #	0 #	0 #	2 #	2 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	15.7	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/19/2020 00:00	0.0	0	0	0	0	0
09/19/2020 01:00	0.0	0	0	0	0	0
09/19/2020 02:00	0.0	0	0	0	0	0
09/19/2020 03:00	0.0	0	0	0	0	0
09/19/2020 04:00	1.2	0	0	1	0	0
09/19/2020 05:00	18.3	0	0	1	0	0
09/19/2020 06:00	0.0	0	0	0	0	1
09/19/2020 07:00	0.0	0	0	0	0	1
09/19/2020 08:00	0.0	0	0	0	0	1
09/19/2020 09:00	0.0	0	0	0	0	1
09/19/2020 10:00	0.0	0	0	0	0	1
09/19/2020 11:00	0.0	0	0	0	0	1
09/19/2020 12:00	0.0	0	0	0	0	1
09/19/2020 13:00	0.0	0	0	0	0	1
09/19/2020 14:00	0.0	0	0	0	0	1
09/19/2020 15:00	0.0	0	0	0	0	1
09/19/2020 16:00	0.0	0	0	0	0	1
09/19/2020 17:00	0.0	0	0	0	0	1
09/19/2020 18:00	0.0	0	0	0	0	1
09/19/2020 19:00	0.0	0	0	0	0	1
09/19/2020 20:00	0.0	0	0	0	0	1
09/19/2020 21:00	0.0	0	0	0	0	1
09/19/2020 22:00	0.0	0	0	0	0	1
09/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	19.5 #	0 #	0 #	2 #	0 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	18.3	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/20/2020 00:00	0.0	0	0	0	0	1
09/20/2020 01:00	0.0	0	0	0	0	1
09/20/2020 02:00	0.0	0	0	0	0	1
09/20/2020 03:00	0.0	0	0	0	0	1
09/20/2020 04:00	0.0	0	0	0	0	1
09/20/2020 05:00	0.0	0	0	0	0	1
09/20/2020 06:00	0.7	0	0	0	1	0
09/20/2020 07:00	0.0	0	0	0	0	0
09/20/2020 08:00	0.0	0	0	0	0	0
09/20/2020 09:00	0.0	0	0	0	0	0
09/20/2020 10:00	1.6	0	0	1	0	0
09/20/2020 11:00	17.1	0	0	1	0	0
09/20/2020 12:00	0.0	0	0	0	0	1
09/20/2020 13:00	0.0	0	0	0	0	1
09/20/2020 14:00	0.0	0	0	0	0	1
09/20/2020 15:00	0.0	0	0	0	0	1
09/20/2020 16:00	0.0	0	0	0	0	1
09/20/2020 17:00	0.0	0	0	0	0	1
09/20/2020 18:00	0.0	0	0	0	0	1
09/20/2020 19:00	0.0	0	0	0	0	1
09/20/2020 20:00	0.0	0	0	0	0	1
09/20/2020 21:00	0.0	0	0	0	0	1
09/20/2020 22:00	0.7	0	0	0	1	0
09/20/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	20.1 #	0 #	0 #	2 #	2 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	17.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/21/2020 00:00	0.0	0	0	0	0	0
09/21/2020 01:00	0.0	0	0	0	0	0
09/21/2020 02:00	0.0	0	0	0	0	0
09/21/2020 03:00	0.0	0	0	0	0	0
09/21/2020 04:00	0.0	0	0	0	0	0
09/21/2020 05:00	0.0	0	0	0	0	0
09/21/2020 06:00	0.0	0	0	0	0	0
09/21/2020 07:00	0.0	0	0	0	0	0
09/21/2020 08:00	0.0	0	0	0	0	0
09/21/2020 09:00	0.0	0	0	0	0	0
09/21/2020 10:00	0.0	0	0	0	0	0
09/21/2020 11:00	0.0	0	0	0	0	0
09/21/2020 12:00	0.0	0	0	0	0	0
09/21/2020 13:00	42.8	0	1	0	0	0
09/21/2020 14:00	46.2	0	1	0	0	0
09/21/2020 15:00	0.0	0	0	0	0	1
09/21/2020 16:00	0.0	0	0	0	0	1
09/21/2020 17:00	0.0	0	0	0	0	1
09/21/2020 18:00	0.0	0	0	0	0	1
09/21/2020 19:00	0.0	0	0	0	0	1
09/21/2020 20:00	0.0	0	0	0	0	1
09/21/2020 21:00	0.0	0	0	0	0	1
09/21/2020 22:00	0.6	0	0	0	1	0
09/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	89.6 #	0 #	2 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	46.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/22/2020 00:00	0.0	0	0	0	0	0
09/22/2020 01:00	0.0	0	0	0	0	0
09/22/2020 02:00	0.0	0	0	0	0	0
09/22/2020 03:00	0.0	0	0	0	0	0
09/22/2020 04:00	0.0	0	0	0	0	0
09/22/2020 05:00	0.0	0	0	0	0	0
09/22/2020 06:00	0.0	0	0	0	0	0
09/22/2020 07:00	0.0	0	0	0	0	0
09/22/2020 08:00	0.0	0	0	0	0	0
09/22/2020 09:00	0.0	0	0	0	0	0
09/22/2020 10:00	0.0	0	0	0	0	0
09/22/2020 11:00	0.0	0	0	0	0	0
09/22/2020 12:00	0.0	0	0	0	0	0
09/22/2020 13:00	0.0	0	0	0	0	0
09/22/2020 14:00	32.7	0	1	0	0	0
09/22/2020 15:00	62.4	0	1	0	0	0
09/22/2020 16:00	0.0	0	0	0	0	1
09/22/2020 17:00	0.0	0	0	0	0	1
09/22/2020 18:00	0.0	0	0	0	0	1
09/22/2020 19:00	0.0	0	0	0	0	1
09/22/2020 20:00	0.0	0	0	0	0	1
09/22/2020 21:00	0.8	0	0	0	1	0
09/22/2020 22:00	0.0	0	0	0	0	0
09/22/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	95.9 #	0 #	2 #	0 #	1 #	5 #
Minimum:	0.0	0	0	0	0	0
Maximum:	62.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/23/2020 00:00	0.0	0	0	0	0	0
09/23/2020 01:00	0.0	0	0	0	0	0
09/23/2020 02:00	0.0	0	0	0	0	0
09/23/2020 03:00	0.0	0	0	0	0	0
09/23/2020 04:00	0.0	0	0	0	0	0
09/23/2020 05:00	0.0	0	0	0	0	0
09/23/2020 06:00	0.0	0	0	0	0	0
09/23/2020 07:00	0.0	0	0	0	0	0
09/23/2020 08:00	0.0	0	0	0	0	0
09/23/2020 09:00	0.0	0	0	0	0	0
09/23/2020 10:00	0.0	0	0	0	0	0
09/23/2020 11:00	0.0	0	0	0	0	0
09/23/2020 12:00	0.0	0	0	0	0	0
09/23/2020 13:00	32.9	0	1	0	0	0
09/23/2020 14:00	69.5	0	1	0	0	0
09/23/2020 15:00	0.0	0	0	0	0	1
09/23/2020 16:00	0.0	0	0	0	0	1
09/23/2020 17:00	0.0	0	0	0	0	1
09/23/2020 18:00	0.0	0	0	0	0	1
09/23/2020 19:00	0.0	0	0	0	0	1
09/23/2020 20:00	0.0	0	0	0	0	1
09/23/2020 21:00	0.7	0	0	0	1	0
09/23/2020 22:00	0.0	0	0	0	0	0
09/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	103.1 #	0 #	2 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	69.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/24/2020 00:00	0.0	0	0	0	0	0
09/24/2020 01:00	0.0	0	0	0	0	0
09/24/2020 02:00	0.0	0	0	0	0	0
09/24/2020 03:00	0.0	0	0	0	0	0
09/24/2020 04:00	0.0	0	0	0	0	0
09/24/2020 05:00	0.0	0	0	0	0	0
09/24/2020 06:00	0.0	0	0	0	0	0
09/24/2020 07:00	0.0	0	0	0	0	0
09/24/2020 08:00	24.2	0	1	0	0	0
09/24/2020 09:00	37.6	0	1	0	0	0
09/24/2020 10:00	17.3	0	1	0	0	0
09/24/2020 11:00	0.0	0	0	0	0	1
09/24/2020 12:00	0.0	0	0	0	0	1
09/24/2020 13:00	0.0	0	0	0	0	1
09/24/2020 14:00	0.0	0	0	0	0	1
09/24/2020 15:00	0.0	0	0	0	0	1
09/24/2020 16:00	0.0	0	0	0	0	1
09/24/2020 17:00	0.0	0	0	0	0	1
09/24/2020 18:00	0.0	0	0	0	0	1
09/24/2020 19:00	0.0	0	0	0	0	1
09/24/2020 20:00	1.0	0	0	0	1	0
09/24/2020 21:00	0.0	0	0	0	0	0
09/24/2020 22:00	0.0	0	0	0	0	0
09/24/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	80.1 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	37.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/25/2020 00:00	0.0	0	0	0	0	0
09/25/2020 01:00	0.0	0	0	0	0	0
09/25/2020 02:00	0.0	0	0	0	0	0
09/25/2020 03:00	0.0	0	0	0	0	0
09/25/2020 04:00	0.0	0	0	0	0	0
09/25/2020 05:00	0.0	0	0	0	0	0
09/25/2020 06:00	0.0	0	0	0	0	0
09/25/2020 07:00	0.0	0	0	0	0	0
09/25/2020 08:00	0.0	0	0	0	0	0
09/25/2020 09:00	0.0	0	0	0	0	0
09/25/2020 10:00	0.0	0	0	0	0	0
09/25/2020 11:00	0.0	0	0	0	0	0
09/25/2020 12:00	0.0	0	0	0	0	0
09/25/2020 13:00	0.0	0	0	0	0	0
09/25/2020 14:00	0.0	0	0	0	0	0
09/25/2020 15:00	0.0	0	0	0	0	0
09/25/2020 16:00	0.0	0	0	0	0	0
09/25/2020 17:00	0.0	0	0	0	0	0
09/25/2020 18:00	0.0	0	0	0	0	0
09/25/2020 19:00	0.0	0	0	0	0	0
09/25/2020 20:00	0.0	0	0	0	0	0
09/25/2020 21:00	0.0	0	0	0	0	0
09/25/2020 22:00	0.0	0	0	0	0	0
09/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/26/2020 00:00	0.0	0	0	0	0	0
09/26/2020 01:00	0.0	0	0	0	0	0
09/26/2020 02:00	0.0	0	0	0	0	0
09/26/2020 03:00	0.0	0	0	0	0	0
09/26/2020 04:00	0.0	0	0	0	0	0
09/26/2020 05:00	0.0	0	0	0	0	0
09/26/2020 06:00	0.0	0	0	0	0	0
09/26/2020 07:00	0.0	0	0	0	0	0
09/26/2020 08:00	0.0	0	0	0	0	0
09/26/2020 09:00	0.0	0	0	0	0	0
09/26/2020 10:00	0.0	0	0	0	0	0
09/26/2020 11:00	0.0	0	0	0	0	0
09/26/2020 12:00	0.0	0	0	0	0	0
09/26/2020 13:00	0.0	0	0	0	0	0
09/26/2020 14:00	0.0	0	0	0	0	0
09/26/2020 15:00	0.0	0	0	0	0	0
09/26/2020 16:00	0.0	0	0	0	0	0
09/26/2020 17:00	0.0	0	0	0	0	0
09/26/2020 18:00	0.0	0	0	0	0	0
09/26/2020 19:00	0.0	0	0	0	0	0
09/26/2020 20:00	0.0	0	0	0	0	0
09/26/2020 21:00	0.0	0	0	0	0	0
09/26/2020 22:00	0.0	0	0	0	0	0
09/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/27/2020 00:00	0.0	0	0	0	0	0
09/27/2020 01:00	0.0	0	0	0	0	0
09/27/2020 02:00	0.0	0	0	0	0	0
09/27/2020 03:00	0.0	0	0	0	0	0
09/27/2020 04:00	0.0	0	0	0	0	0
09/27/2020 05:00	0.0	0	0	0	0	0
09/27/2020 06:00	0.0	0	0	0	0	0
09/27/2020 07:00	0.0	0	0	0	0	0
09/27/2020 08:00	0.8	0	1	0	0	0
09/27/2020 09:00	0.0	0	0	0	0	0
09/27/2020 10:00	0.0	0	0	0	0	0
09/27/2020 11:00	0.0	0	0	0	0	0
09/27/2020 12:00	0.0	0	0	0	0	0
09/27/2020 13:00	4.6	0	1	0	0	0
09/27/2020 14:00	116.7	0	1	0	0	0
09/27/2020 15:00	3.0	0	1	0	0	0
09/27/2020 16:00	0.0	0	0	0	0	1
09/27/2020 17:00	0.0	0	0	0	0	1
09/27/2020 18:00	0.0	0	0	0	0	1
09/27/2020 19:00	0.0	0	0	0	0	1
09/27/2020 20:00	0.0	0	0	0	0	1
09/27/2020 21:00	0.0	0	0	0	0	1
09/27/2020 22:00	0.9	0	0	0	1	0
09/27/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	126.0 #	0 #	4 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	116.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/28/2020 00:00	0.0	0	0	0	0	0
09/28/2020 01:00	0.0	0	0	0	0	0
09/28/2020 02:00	0.0	0	0	0	0	0
09/28/2020 03:00	0.0	0	0	0	0	0
09/28/2020 04:00	0.0	0	0	0	0	0
09/28/2020 05:00	0.0	0	0	0	0	0
09/28/2020 06:00	28.3	0	1	0	0	0
09/28/2020 07:00	52.9	0	1	0	0	0
09/28/2020 08:00	0.0	0	0	0	0	1
09/28/2020 09:00	0.0	0	0	0	0	1
09/28/2020 10:00	0.0	0	0	0	0	1
09/28/2020 11:00	0.0	0	0	0	0	1
09/28/2020 12:00	0.0	0	0	0	0	1
09/28/2020 13:00	0.0	0	0	0	0	1
09/28/2020 14:00	0.0	0	0	0	0	1
09/28/2020 15:00	0.0	0	0	0	0	1
09/28/2020 16:00	0.0	0	0	0	0	1
09/28/2020 17:00	0.0	0	0	0	0	1
09/28/2020 18:00	0.0	0	0	0	0	1
09/28/2020 19:00	0.0	0	0	0	0	1
09/28/2020 20:00	0.0	0	0	0	0	1
09/28/2020 21:00	0.0	0	0	0	0	1
09/28/2020 22:00	0.9	0	0	0	1	0
09/28/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	82.1 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	52.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/29/2020 00:00	0.0	0	0	0	0	0
09/29/2020 01:00	0.0	0	0	0	0	0
09/29/2020 02:00	0.0	0	0	0	0	0
09/29/2020 03:00	0.0	0	0	0	0	0
09/29/2020 04:00	0.0	0	0	0	0	0
09/29/2020 05:00	0.0	0	0	0	0	0
09/29/2020 06:00	26.4	0	1	0	0	0
09/29/2020 07:00	51.5	0	1	0	0	0
09/29/2020 08:00	0.0	0	0	0	0	1
09/29/2020 09:00	0.0	0	0	0	0	1
09/29/2020 10:00	0.0	0	0	0	0	1
09/29/2020 11:00	0.0	0	0	0	0	1
09/29/2020 12:00	0.0	0	0	0	0	1
09/29/2020 13:00	0.0	0	0	0	0	1
09/29/2020 14:00	0.0	0	0	0	0	1
09/29/2020 15:00	0.0	0	0	0	0	1
09/29/2020 16:00	0.0	0	0	0	0	1
09/29/2020 17:00	0.0	0	0	0	0	1
09/29/2020 18:00	0.0	0	0	0	0	1
09/29/2020 19:00	0.0	0	0	0	0	1
09/29/2020 20:00	0.0	0	0	0	0	1
09/29/2020 21:00	0.0	0	0	0	0	1
09/29/2020 22:00	0.0	0	0	0	0	1
09/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	77.9 #	0 #	2 #	0 #	0 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	51.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:34 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/30/2020 00:00	0.0	0	0	0	0	1
09/30/2020 01:00	0.0	0	0	0	0	1
09/30/2020 02:00	0.0	0	0	0	0	1
09/30/2020 03:00	0.0	0	0	0	0	1
09/30/2020 04:00	0.0	0	0	0	0	1
09/30/2020 05:00	0.0	0	0	0	0	1
09/30/2020 06:00	0.0	0	0	0	0	1
09/30/2020 07:00	0.0	0	0	0	0	1
09/30/2020 08:00	0.0	0	0	0	0	1
09/30/2020 09:00	0.0	0	0	0	0	1
09/30/2020 10:00	0.0	0	0	0	0	1
09/30/2020 11:00	0.0	0	0	0	0	1
09/30/2020 12:00	0.0	0	0	0	0	1
09/30/2020 13:00	0.0	0	0	0	0	1
09/30/2020 14:00	0.0	0	0	0	0	1
09/30/2020 15:00	0.0	0	0	0	0	1
09/30/2020 16:00	0.0	0	0	0	0	1
09/30/2020 17:00	0.0	0	0	0	0	1
09/30/2020 18:00	0.0	0	0	0	0	1
09/30/2020 19:00	0.0	0	0	0	0	1
09/30/2020 20:00	0.0	0	0	0	0	1
09/30/2020 21:00	0.0	0	0	0	0	1
09/30/2020 22:00	0.0	0	0	0	0	1
09/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Pound Per Event Report

CT1 - CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 10/06/2020 09:35 Location: Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,867.23 Hours
 Non-Operating Time: 340.77 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
07/03/2020 13:18 07/03/2020 14:38 Warm Start - Gas	81	111.7	790.5		
07/03/2020 23:24 07/03/2020 23:29 Shut Down - Gas	6	1.5	483.5		
07/05/2020 14:24 07/05/2020 15:43 Warm Start - Gas	80	92.7	790.5		
07/05/2020 22:30 07/05/2020 22:35 Shut Down - Gas	6	1.4	483.5		
07/06/2020 11:37 07/06/2020 12:49 Warm Start - Gas	73	51.0	790.5		
09/11/2020 23:04 09/11/2020 23:09 Shut Down - Gas	6	1.0	483.5		
09/14/2020 13:25 09/14/2020 15:09 Warm Start - Gas	105	135.3	790.5		
09/15/2020 22:25 09/15/2020 22:26 Shut Down - Gas	2	0.9	483.5		
09/16/2020 06:29 09/16/2020 07:33 Warm Start - Gas	65	50.7	790.5		
09/17/2020 23:57 09/18/2020 00:02 Shut Down - Gas	6	1.2	483.5		
09/18/2020 06:33 09/18/2020 07:46 Hot Start - Gas	74	53.3	679.6		
09/18/2020 22:40 09/18/2020 22:45 Shut Down - Gas	6	1.3	483.5		
09/19/2020 04:44 09/19/2020 05:47 Hot Start - Gas	64	58.4	679.6		

Pound Per Event Report

CT1 - CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 10/06/2020 09:35 Location: Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,867.23 Hours
 Non-Operating Time: 340.77 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
09/20/2020 06:09 09/20/2020 06:14 Shut Down - Gas	6	1.3	483.5		
09/20/2020 10:31 09/20/2020 11:42 Hot Start - Gas	72	35.9	679.6		
09/20/2020 22:08 09/20/2020 22:13 Shut Down - Gas	6	1.4	483.5		
09/21/2020 13:28 09/21/2020 14:56 Warm Start - Gas	89	85.3	790.5		
09/21/2020 22:08 09/21/2020 22:13 Shut Down - Gas	6	1.0	483.5		
09/22/2020 14:33 09/22/2020 15:55 Warm Start - Gas	83	89.0	790.5		
09/22/2020 21:22 09/22/2020 21:27 Shut Down - Gas	6	1.3	483.5		
09/23/2020 13:34 09/23/2020 14:57 Warm Start - Gas	84	88.1	790.5		
09/23/2020 21:08 09/23/2020 21:13 Shut Down - Gas	6	1.0	483.5		
09/24/2020 08:38 09/24/2020 10:49 Warm Start - Gas	132	99.0	790.5		
09/24/2020 20:22 09/24/2020 20:28 Shut Down - Gas	7	1.5	483.5		
09/27/2020 08:18 09/27/2020 08:25 Warm Start - Gas	8	16.3	790.5		
09/27/2020 13:50 09/27/2020 15:09 Warm Start - Gas	80	72.9	790.5		
09/27/2020 22:23 09/27/2020 22:28 Shut Down - Gas	6	1.3	483.5		

Pound Per Event Report

CT1 - CO Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/06/2020 09:35 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,867.23 Hours
 Non-Operating Time: 340.77 Hours **Report Time:** 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
09/28/2020 06:38 09/28/2020 07:49 Warm Start - Gas	72	37.2	790.5		
09/28/2020 22:24 09/28/2020 22:29 Shut Down - Gas	6	1.3	483.5		
09/29/2020 06:36 09/29/2020 07:52 Warm Start - Gas	77	47.4	790.5		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT1 - CO Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/06/2020 09:35 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,867.23 Hours

Non-Operating Time: 340.77 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT1 - CO Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/06/2020 09:35 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,867.23 Hours
 Non-Operating Time: 340.77 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary

1. Duration of excess emission in event reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in event reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Pound Per Event Report

CT1 - NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 10/06/2020 09:36 Location: Maxwell, CA

Tag Name: CT1_NOX_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,867.23 Hours
 Non-Operating Time: 340.77 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
07/03/2020 13:18 07/03/2020 14:38 Warm Start - Gas	81	98.45	456.20		
07/03/2020 23:24 07/03/2020 23:29 Shut Down - Gas	6	0.30	115.00		
07/05/2020 14:24 07/05/2020 15:43 Warm Start - Gas	80	96.85	456.20		
07/05/2020 22:30 07/05/2020 22:35 Shut Down - Gas	6	0.24	115.00		
07/06/2020 11:37 07/06/2020 12:49 Warm Start - Gas	73	59.15	456.20		
09/11/2020 23:04 09/11/2020 23:09 Shut Down - Gas	6	0.20	115.00		
09/14/2020 13:25 09/14/2020 15:09 Warm Start - Gas	105	132.35	456.20		
09/15/2020 22:25 09/15/2020 22:26 Shut Down - Gas	2	0.22	115.00		
09/16/2020 06:29 09/16/2020 07:33 Warm Start - Gas	65	38.54	456.20		
09/17/2020 23:57 09/18/2020 00:02 Shut Down - Gas	6	0.33	115.00		
09/18/2020 06:33 09/18/2020 07:46 Hot Start - Gas	74	20.64	259.90		
09/18/2020 22:40 09/18/2020 22:45 Shut Down - Gas	6	0.25	115.00		
09/19/2020 04:44 09/19/2020 05:47 Hot Start - Gas	64	20.94	259.90		

Pound Per Event Report

CT1 - NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 10/06/2020 09:36 Location: Maxwell, CA

Tag Name: CT1_NOX_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,867.23 Hours
 Non-Operating Time: 340.77 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
09/20/2020 06:09 09/20/2020 06:14 Shut Down - Gas	6	0.30	115.00		
09/20/2020 10:31 09/20/2020 11:42 Hot Start - Gas	72	22.61	259.90		
09/20/2020 22:08 09/20/2020 22:13 Shut Down - Gas	6	0.25	115.00		
09/21/2020 13:28 09/21/2020 14:56 Warm Start - Gas	89	88.55	456.20		
09/21/2020 22:08 09/21/2020 22:13 Shut Down - Gas	6	0.24	115.00		
09/22/2020 14:33 09/22/2020 15:55 Warm Start - Gas	83	93.27	456.20		
09/22/2020 21:22 09/22/2020 21:27 Shut Down - Gas	6	0.28	115.00		
09/23/2020 13:34 09/23/2020 14:57 Warm Start - Gas	84	98.91	456.20		
09/23/2020 21:08 09/23/2020 21:13 Shut Down - Gas	6	0.22	115.00		
09/24/2020 08:38 09/24/2020 10:49 Warm Start - Gas	132	81.96	456.20		
09/24/2020 20:22 09/24/2020 20:28 Shut Down - Gas	7	0.39	115.00		
09/27/2020 08:18 09/27/2020 08:25 Warm Start - Gas	8	0.84	456.20		
09/27/2020 13:50 09/27/2020 15:09 Warm Start - Gas	80	132.75	456.20		
09/27/2020 22:23 09/27/2020 22:28 Shut Down - Gas	6	0.40	115.00		

Pound Per Event Report

CT1 - NOx Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/06/2020 09:36 **Location:** Maxwell, CA

Tag Name: CT1_NOX_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,867.23 Hours
 Non-Operating Time: 340.77 Hours **Report Time:** 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
09/28/2020 06:38 09/28/2020 07:49 Warm Start - Gas	72	83.54	456.20		
09/28/2020 22:24 09/28/2020 22:29 Shut Down - Gas	6	0.36	115.00		
09/29/2020 06:36 09/29/2020 07:52 Warm Start - Gas	77	77.72	456.20		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT1 - NOx Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/06/2020 09:36 **Location:** Maxwell, CA

Tag Name: CT1_NOX_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,867.23 Hours

Non-Operating Time: 340.77 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT1 - NOx Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/06/2020 09:36 **Location:** Maxwell, CA

Tag Name: CT1_NOX_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,867.23 Hours

Non-Operating Time: 340.77 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary

1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

100scf Per Event Report

CT2 - GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 10/06/2020 09:37 Location: Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,844.57 Hours

Non-Operating Time: 363.43 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
07/03/2020 08:18 07/03/2020 10:50 Warm Start - Gas	153	237.4		
07/03/2020 23:25 07/03/2020 23:30 Shut Down - Gas	6	1.3		
07/05/2020 09:18 07/05/2020 11:51 Warm Start - Gas	154	248.0		
07/05/2020 22:30 07/05/2020 22:35 Shut Down - Gas	6	2.4		
07/06/2020 02:39 07/06/2020 03:30 Hot Start - Gas	52	103.0		
07/25/2020 13:30 07/25/2020 14:54 Warm Start - Gas	85	145.1		
09/02/2020 07:20 09/02/2020 07:25 Shut Down - Gas	6	2.2		
09/03/2020 03:33 09/03/2020 04:41 Warm Start - Gas	69	123.5		
09/11/2020 23:04 09/11/2020 23:09 Shut Down - Gas	6	1.9		
09/12/2020 17:13 09/12/2020 19:46 Warm Start - Gas	154	238.0		
09/13/2020 02:03 09/13/2020 02:09 Shut Down - Gas	7	2.5		
09/13/2020 17:06 09/13/2020 19:43 Warm Start - Gas	158	249.8		
09/14/2020 02:03 09/14/2020 02:09 Shut Down - Gas	7	2.4		

100scf Per Event Report

CT2 - GasFlowTotal 100scf



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/06/2020 09:37 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,844.57 Hours

Non-Operating Time: 363.43 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
09/14/2020 09:51 09/14/2020 11:12 Hot Start - Gas	82	147.5		
09/15/2020 22:25 09/15/2020 22:30 Shut Down - Gas	6	2.3		
09/16/2020 11:21 09/16/2020 12:28 Warm Start - Gas	68	122.8		
09/17/2020 23:57 09/18/2020 00:02 Shut Down - Gas	6	2.0		
09/18/2020 10:46 09/18/2020 11:53 Warm Start - Gas	68	126.0		
09/18/2020 22:40 09/18/2020 22:45 Shut Down - Gas	6	1.9		
09/19/2020 13:34 09/19/2020 14:51 Warm Start - Gas	78	139.4		
09/20/2020 06:09 09/20/2020 06:14 Shut Down - Gas	6	2.2		
09/20/2020 14:23 09/20/2020 15:44 Warm Start - Gas	82	139.9		
09/20/2020 22:08 09/20/2020 22:13 Shut Down - Gas	6	2.3		
09/21/2020 08:36 09/21/2020 10:49 Warm Start - Gas	134	214.3		
09/21/2020 22:08 09/21/2020 22:13 Shut Down - Gas	6	2.3		
09/22/2020 08:38 09/22/2020 10:51 Warm Start - Gas	134	217.5		
09/22/2020 21:22 09/22/2020 21:28 Shut Down - Gas	7	2.5		

100scf Per Event Report

CT2 - GasFlowTotal 100scf



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/06/2020 09:37 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,844.57 Hours

Non-Operating Time: 363.43 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
09/23/2020 08:28 09/23/2020 10:47 Warm Start - Gas	140	225.3		
09/23/2020 21:08 09/23/2020 21:13 Shut Down - Gas	6	1.9		
09/24/2020 13:19 09/24/2020 14:39 Warm Start - Gas	81	141.0		
09/24/2020 20:23 09/24/2020 20:28 Shut Down - Gas	6	1.3		
09/27/2020 08:56 09/27/2020 10:59 Warm Start - Gas	124	197.3		
09/27/2020 22:23 09/27/2020 22:28 Shut Down - Gas	6	2.3		
09/28/2020 10:18 09/28/2020 11:43 Warm Start - Gas	86	148.7		
09/28/2020 22:24 09/28/2020 22:29 Shut Down - Gas	6	2.3		
09/29/2020 10:13 09/29/2020 11:43 Warm Start - Gas	91	157.9		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/06/2020 09:37 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,844.57 Hours

Non-Operating Time: 363.43 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 10/06/2020 09:37 Location: Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,844.57 Hours

Non-Operating Time: 363.43 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary

1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/01/2020 00:00	0.0	0	0	0	0	0
07/01/2020 01:00	0.0	0	0	0	0	0
07/01/2020 02:00	0.0	0	0	0	0	0
07/01/2020 03:00	0.0	0	0	0	0	0
07/01/2020 04:00	0.0	0	0	0	0	0
07/01/2020 05:00	0.0	0	0	0	0	0
07/01/2020 06:00	0.0	0	0	0	0	0
07/01/2020 07:00	0.0	0	0	0	0	0
07/01/2020 08:00	0.0	0	0	0	0	0
07/01/2020 09:00	0.0	0	0	0	0	0
07/01/2020 10:00	0.0	0	0	0	0	0
07/01/2020 11:00	0.0	0	0	0	0	0
07/01/2020 12:00	0.0	0	0	0	0	0
07/01/2020 13:00	0.0	0	0	0	0	0
07/01/2020 14:00	0.0	0	0	0	0	0
07/01/2020 15:00	0.0	0	0	0	0	0
07/01/2020 16:00	0.0	0	0	0	0	0
07/01/2020 17:00	0.0	0	0	0	0	0
07/01/2020 18:00	0.0	0	0	0	0	0
07/01/2020 19:00	0.0	0	0	0	0	0
07/01/2020 20:00	0.0	0	0	0	0	0
07/01/2020 21:00	0.0	0	0	0	0	0
07/01/2020 22:00	0.0	0	0	0	0	0
07/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/02/2020 00:00	0.0	0	0	0	0	0
07/02/2020 01:00	0.0	0	0	0	0	0
07/02/2020 02:00	0.0	0	0	0	0	0
07/02/2020 03:00	0.0	0	0	0	0	0
07/02/2020 04:00	0.0	0	0	0	0	0
07/02/2020 05:00	0.0	0	0	0	0	0
07/02/2020 06:00	0.0	0	0	0	0	0
07/02/2020 07:00	0.0	0	0	0	0	0
07/02/2020 08:00	0.0	0	0	0	0	0
07/02/2020 09:00	0.0	0	0	0	0	0
07/02/2020 10:00	0.0	0	0	0	0	0
07/02/2020 11:00	0.0	0	0	0	0	0
07/02/2020 12:00	0.0	0	0	0	0	0
07/02/2020 13:00	0.0	0	0	0	0	0
07/02/2020 14:00	0.0	0	0	0	0	0
07/02/2020 15:00	0.0	0	0	0	0	0
07/02/2020 16:00	0.0	0	0	0	0	0
07/02/2020 17:00	0.0	0	0	0	0	0
07/02/2020 18:00	0.0	0	0	0	0	0
07/02/2020 19:00	0.0	0	0	0	0	0
07/02/2020 20:00	0.0	0	0	0	0	0
07/02/2020 21:00	0.0	0	0	0	0	0
07/02/2020 22:00	0.0	0	0	0	0	0
07/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/03/2020 00:00	0.0	0	0	0	0	0
07/03/2020 01:00	0.0	0	0	0	0	0
07/03/2020 02:00	0.0	0	0	0	0	0
07/03/2020 03:00	0.0	0	0	0	0	0
07/03/2020 04:00	0.0	0	0	0	0	0
07/03/2020 05:00	0.0	0	0	0	0	0
07/03/2020 06:00	0.0	0	0	0	0	0
07/03/2020 07:00	0.0	0	0	0	0	0
07/03/2020 08:00	94.5	0	1	0	0	0
07/03/2020 09:00	29.0	0	1	0	0	0
07/03/2020 10:00	33.8	0	1	0	0	0
07/03/2020 11:00	0.0	0	0	0	0	1
07/03/2020 12:00	0.0	0	0	0	0	1
07/03/2020 13:00	0.0	0	0	0	0	1
07/03/2020 14:00	0.0	0	0	0	0	1
07/03/2020 15:00	0.0	0	0	0	0	1
07/03/2020 16:00	0.0	0	0	0	0	1
07/03/2020 17:00	0.0	0	0	0	0	1
07/03/2020 18:00	0.0	0	0	0	0	1
07/03/2020 19:00	0.0	0	0	0	0	1
07/03/2020 20:00	0.0	0	0	0	0	1
07/03/2020 21:00	0.0	0	0	0	0	1
07/03/2020 22:00	0.0	0	0	0	0	1
07/03/2020 23:00	1.6	0	0	0	1	0
Average/Sum#:	158.9 #	0 #	3 #	0 #	1 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	94.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/04/2020 00:00	0.0	0	0	0	0	0
07/04/2020 01:00	0.0	0	0	0	0	0
07/04/2020 02:00	0.0	0	0	0	0	0
07/04/2020 03:00	0.0	0	0	0	0	0
07/04/2020 04:00	0.0	0	0	0	0	0
07/04/2020 05:00	0.0	0	0	0	0	0
07/04/2020 06:00	0.0	0	0	0	0	0
07/04/2020 07:00	0.0	0	0	0	0	0
07/04/2020 08:00	0.0	0	0	0	0	0
07/04/2020 09:00	0.0	0	0	0	0	0
07/04/2020 10:00	0.0	0	0	0	0	0
07/04/2020 11:00	0.0	0	0	0	0	0
07/04/2020 12:00	0.0	0	0	0	0	0
07/04/2020 13:00	0.0	0	0	0	0	0
07/04/2020 14:00	0.0	0	0	0	0	0
07/04/2020 15:00	0.0	0	0	0	0	0
07/04/2020 16:00	0.0	0	0	0	0	0
07/04/2020 17:00	0.0	0	0	0	0	0
07/04/2020 18:00	0.0	0	0	0	0	0
07/04/2020 19:00	0.0	0	0	0	0	0
07/04/2020 20:00	0.0	0	0	0	0	0
07/04/2020 21:00	0.0	0	0	0	0	0
07/04/2020 22:00	0.0	0	0	0	0	0
07/04/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/05/2020 00:00	0.0	0	0	0	0	0
07/05/2020 01:00	0.0	0	0	0	0	0
07/05/2020 02:00	0.0	0	0	0	0	0
07/05/2020 03:00	0.0	0	0	0	0	0
07/05/2020 04:00	0.0	0	0	0	0	0
07/05/2020 05:00	0.0	0	0	0	0	0
07/05/2020 06:00	0.0	0	0	0	0	0
07/05/2020 07:00	0.0	0	0	0	0	0
07/05/2020 08:00	0.0	0	0	0	0	0
07/05/2020 09:00	71.1	0	1	0	0	0
07/05/2020 10:00	22.9	0	1	0	0	0
07/05/2020 11:00	35.7	0	1	0	0	0
07/05/2020 12:00	0.0	0	0	0	0	1
07/05/2020 13:00	0.0	0	0	0	0	1
07/05/2020 14:00	0.0	0	0	0	0	1
07/05/2020 15:00	0.0	0	0	0	0	1
07/05/2020 16:00	0.0	0	0	0	0	1
07/05/2020 17:00	0.0	0	0	0	0	1
07/05/2020 18:00	0.0	0	0	0	0	1
07/05/2020 19:00	0.0	0	0	0	0	1
07/05/2020 20:00	0.0	0	0	0	0	1
07/05/2020 21:00	0.0	0	0	0	0	1
07/05/2020 22:00	1.2	0	0	0	1	0
07/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	130.9 #	0 #	3 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	71.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/06/2020 00:00	0.0	0	0	0	0	0
07/06/2020 01:00	0.0	0	0	0	0	0
07/06/2020 02:00	9.5	0	0	1	0	0
07/06/2020 03:00	14.8	0	0	1	0	0
07/06/2020 04:00	0.0	0	0	0	0	1
07/06/2020 05:00	0.0	0	0	0	0	1
07/06/2020 06:00	0.0	0	0	0	0	1
07/06/2020 07:00	0.0	0	0	0	0	1
07/06/2020 08:00	0.0	0	0	0	0	1
07/06/2020 09:00	0.0	0	0	0	0	1
07/06/2020 10:00	0.0	0	0	0	0	1
07/06/2020 11:00	0.0	0	0	0	0	1
07/06/2020 12:00	0.0	0	0	0	0	1
07/06/2020 13:00	0.0	0	0	0	0	1
07/06/2020 14:00	0.0	0	0	0	0	1
07/06/2020 15:00	0.0	0	0	0	0	1
07/06/2020 16:00	0.0	0	0	0	0	1
07/06/2020 17:00	0.0	0	0	0	0	1
07/06/2020 18:00	0.0	0	0	0	0	1
07/06/2020 19:00	0.0	0	0	0	0	1
07/06/2020 20:00	0.0	0	0	0	0	1
07/06/2020 21:00	0.0	0	0	0	0	1
07/06/2020 22:00	0.0	0	0	0	0	1
07/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	24.3 #	0 #	0 #	2 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	14.8	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/07/2020 00:00	0.0	0	0	0	0	1
07/07/2020 01:00	0.0	0	0	0	0	1
07/07/2020 02:00	0.0	0	0	0	0	1
07/07/2020 03:00	0.0	0	0	0	0	1
07/07/2020 04:00	0.0	0	0	0	0	1
07/07/2020 05:00	0.0	0	0	0	0	1
07/07/2020 06:00	0.0	0	0	0	0	1
07/07/2020 07:00	0.0	0	0	0	0	1
07/07/2020 08:00	0.0	0	0	0	0	1
07/07/2020 09:00	0.0	0	0	0	0	1
07/07/2020 10:00	0.0	0	0	0	0	1
07/07/2020 11:00	0.0	0	0	0	0	1
07/07/2020 12:00	0.0	0	0	0	0	1
07/07/2020 13:00	0.0	0	0	0	0	1
07/07/2020 14:00	0.0	0	0	0	0	1
07/07/2020 15:00	0.0	0	0	0	0	1
07/07/2020 16:00	0.0	0	0	0	0	1
07/07/2020 17:00	0.0	0	0	0	0	1
07/07/2020 18:00	0.0	0	0	0	0	1
07/07/2020 19:00	0.0	0	0	0	0	1
07/07/2020 20:00	0.0	0	0	0	0	1
07/07/2020 21:00	0.0	0	0	0	0	1
07/07/2020 22:00	0.0	0	0	0	0	1
07/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/08/2020 00:00	0.0	0	0	0	0	1
07/08/2020 01:00	0.0	0	0	0	0	1
07/08/2020 02:00	0.0	0	0	0	0	1
07/08/2020 03:00	0.0	0	0	0	0	1
07/08/2020 04:00	0.0	0	0	0	0	1
07/08/2020 05:00	0.0	0	0	0	0	1
07/08/2020 06:00	0.0	0	0	0	0	1
07/08/2020 07:00	0.0	0	0	0	0	1
07/08/2020 08:00	0.0	0	0	0	0	1
07/08/2020 09:00	0.0	0	0	0	0	1
07/08/2020 10:00	0.0	0	0	0	0	1
07/08/2020 11:00	0.0	0	0	0	0	1
07/08/2020 12:00	0.0	0	0	0	0	1
07/08/2020 13:00	0.0	0	0	0	0	1
07/08/2020 14:00	0.0	0	0	0	0	1
07/08/2020 15:00	0.0	0	0	0	0	1
07/08/2020 16:00	0.0	0	0	0	0	1
07/08/2020 17:00	0.0	0	0	0	0	1
07/08/2020 18:00	0.0	0	0	0	0	1
07/08/2020 19:00	0.0	0	0	0	0	1
07/08/2020 20:00	0.0	0	0	0	0	1
07/08/2020 21:00	0.0	0	0	0	0	1
07/08/2020 22:00	0.0	0	0	0	0	1
07/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/09/2020 00:00	0.0	0	0	0	0	1
07/09/2020 01:00	0.0	0	0	0	0	1
07/09/2020 02:00	0.0	0	0	0	0	1
07/09/2020 03:00	0.0	0	0	0	0	1
07/09/2020 04:00	0.0	0	0	0	0	1
07/09/2020 05:00	0.0	0	0	0	0	1
07/09/2020 06:00	0.0	0	0	0	0	1
07/09/2020 07:00	0.0	0	0	0	0	1
07/09/2020 08:00	0.0	0	0	0	0	1
07/09/2020 09:00	0.0	0	0	0	0	1
07/09/2020 10:00	0.0	0	0	0	0	1
07/09/2020 11:00	0.0	0	0	0	0	1
07/09/2020 12:00	0.0	0	0	0	0	1
07/09/2020 13:00	0.0	0	0	0	0	1
07/09/2020 14:00	0.0	0	0	0	0	1
07/09/2020 15:00	0.0	0	0	0	0	1
07/09/2020 16:00	0.0	0	0	0	0	1
07/09/2020 17:00	0.0	0	0	0	0	1
07/09/2020 18:00	0.0	0	0	0	0	1
07/09/2020 19:00	0.0	0	0	0	0	1
07/09/2020 20:00	0.0	0	0	0	0	1
07/09/2020 21:00	0.0	0	0	0	0	1
07/09/2020 22:00	0.0	0	0	0	0	1
07/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/10/2020 00:00	0.0	0	0	0	0	1
07/10/2020 01:00	0.0	0	0	0	0	1
07/10/2020 02:00	0.0	0	0	0	0	1
07/10/2020 03:00	0.0	0	0	0	0	1
07/10/2020 04:00	0.0	0	0	0	0	1
07/10/2020 05:00	0.0	0	0	0	0	1
07/10/2020 06:00	0.0	0	0	0	0	1
07/10/2020 07:00	0.0	0	0	0	0	1
07/10/2020 08:00	0.0	0	0	0	0	1
07/10/2020 09:00	0.0	0	0	0	0	1
07/10/2020 10:00	0.0	0	0	0	0	1
07/10/2020 11:00	0.0	0	0	0	0	1
07/10/2020 12:00	0.0	0	0	0	0	1
07/10/2020 13:00	0.0	0	0	0	0	1
07/10/2020 14:00	0.0	0	0	0	0	1
07/10/2020 15:00	0.0	0	0	0	0	1
07/10/2020 16:00	0.0	0	0	0	0	1
07/10/2020 17:00	0.0	0	0	0	0	1
07/10/2020 18:00	0.0	0	0	0	0	1
07/10/2020 19:00	0.0	0	0	0	0	1
07/10/2020 20:00	0.0	0	0	0	0	1
07/10/2020 21:00	0.0	0	0	0	0	1
07/10/2020 22:00	0.0	0	0	0	0	1
07/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/11/2020 00:00	0.0	0	0	0	0	1
07/11/2020 01:00	0.0	0	0	0	0	1
07/11/2020 02:00	0.0	0	0	0	0	1
07/11/2020 03:00	0.0	0	0	0	0	1
07/11/2020 04:00	0.0	0	0	0	0	1
07/11/2020 05:00	0.0	0	0	0	0	1
07/11/2020 06:00	0.0	0	0	0	0	1
07/11/2020 07:00	0.0	0	0	0	0	1
07/11/2020 08:00	0.0	0	0	0	0	1
07/11/2020 09:00	0.0	0	0	0	0	1
07/11/2020 10:00	0.0	0	0	0	0	1
07/11/2020 11:00	0.0	0	0	0	0	1
07/11/2020 12:00	0.0	0	0	0	0	1
07/11/2020 13:00	0.0	0	0	0	0	1
07/11/2020 14:00	0.0	0	0	0	0	1
07/11/2020 15:00	0.0	0	0	0	0	1
07/11/2020 16:00	0.0	0	0	0	0	1
07/11/2020 17:00	0.0	0	0	0	0	1
07/11/2020 18:00	0.0	0	0	0	0	1
07/11/2020 19:00	0.0	0	0	0	0	1
07/11/2020 20:00	0.0	0	0	0	0	1
07/11/2020 21:00	0.0	0	0	0	0	1
07/11/2020 22:00	0.0	0	0	0	0	1
07/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/12/2020 00:00	0.0	0	0	0	0	1
07/12/2020 01:00	0.0	0	0	0	0	1
07/12/2020 02:00	0.0	0	0	0	0	1
07/12/2020 03:00	0.0	0	0	0	0	1
07/12/2020 04:00	0.0	0	0	0	0	1
07/12/2020 05:00	0.0	0	0	0	0	1
07/12/2020 06:00	0.0	0	0	0	0	1
07/12/2020 07:00	0.0	0	0	0	0	1
07/12/2020 08:00	0.0	0	0	0	0	1
07/12/2020 09:00	0.0	0	0	0	0	1
07/12/2020 10:00	0.0	0	0	0	0	1
07/12/2020 11:00	0.0	0	0	0	0	1
07/12/2020 12:00	0.0	0	0	0	0	1
07/12/2020 13:00	0.0	0	0	0	0	1
07/12/2020 14:00	0.0	0	0	0	0	1
07/12/2020 15:00	0.0	0	0	0	0	1
07/12/2020 16:00	0.0	0	0	0	0	1
07/12/2020 17:00	0.0	0	0	0	0	1
07/12/2020 18:00	0.0	0	0	0	0	1
07/12/2020 19:00	0.0	0	0	0	0	1
07/12/2020 20:00	0.0	0	0	0	0	1
07/12/2020 21:00	0.0	0	0	0	0	1
07/12/2020 22:00	0.0	0	0	0	0	1
07/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/13/2020 00:00	0.0	0	0	0	0	1
07/13/2020 01:00	0.0	0	0	0	0	1
07/13/2020 02:00	0.0	0	0	0	0	1
07/13/2020 03:00	0.0	0	0	0	0	1
07/13/2020 04:00	0.0	0	0	0	0	1
07/13/2020 05:00	0.0	0	0	0	0	1
07/13/2020 06:00	0.0	0	0	0	0	1
07/13/2020 07:00	0.0	0	0	0	0	1
07/13/2020 08:00	0.0	0	0	0	0	1
07/13/2020 09:00	0.0	0	0	0	0	1
07/13/2020 10:00	0.0	0	0	0	0	1
07/13/2020 11:00	0.0	0	0	0	0	1
07/13/2020 12:00	0.0	0	0	0	0	1
07/13/2020 13:00	0.0	0	0	0	0	1
07/13/2020 14:00	0.0	0	0	0	0	1
07/13/2020 15:00	0.0	0	0	0	0	1
07/13/2020 16:00	0.0	0	0	0	0	1
07/13/2020 17:00	0.0	0	0	0	0	1
07/13/2020 18:00	0.0	0	0	0	0	1
07/13/2020 19:00	0.0	0	0	0	0	1
07/13/2020 20:00	0.0	0	0	0	0	1
07/13/2020 21:00	0.0	0	0	0	0	1
07/13/2020 22:00	0.0	0	0	0	0	1
07/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/14/2020 00:00	0.0	0	0	0	0	1
07/14/2020 01:00	0.0	0	0	0	0	1
07/14/2020 02:00	0.0	0	0	0	0	1
07/14/2020 03:00	0.0	0	0	0	0	1
07/14/2020 04:00	0.0	0	0	0	0	1
07/14/2020 05:00	0.0	0	0	0	0	1
07/14/2020 06:00	0.0	0	0	0	0	1
07/14/2020 07:00	0.0	0	0	0	0	1
07/14/2020 08:00	0.0	0	0	0	0	1
07/14/2020 09:00	0.0	0	0	0	0	1
07/14/2020 10:00	0.0	0	0	0	0	1
07/14/2020 11:00	0.0	0	0	0	0	1
07/14/2020 12:00	0.0	0	0	0	0	1
07/14/2020 13:00	0.0	0	0	0	0	1
07/14/2020 14:00	0.0	0	0	0	0	1
07/14/2020 15:00	0.0	0	0	0	0	1
07/14/2020 16:00	0.0	0	0	0	0	1
07/14/2020 17:00	0.0	0	0	0	0	1
07/14/2020 18:00	0.0	0	0	0	0	1
07/14/2020 19:00	0.0	0	0	0	0	1
07/14/2020 20:00	0.0	0	0	0	0	1
07/14/2020 21:00	0.0	0	0	0	0	1
07/14/2020 22:00	0.0	0	0	0	0	1
07/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/15/2020 00:00	0.0	0	0	0	0	1
07/15/2020 01:00	0.0	0	0	0	0	1
07/15/2020 02:00	0.0	0	0	0	0	1
07/15/2020 03:00	0.0	0	0	0	0	1
07/15/2020 04:00	0.0	0	0	0	0	1
07/15/2020 05:00	0.0	0	0	0	0	1
07/15/2020 06:00	0.0	0	0	0	0	1
07/15/2020 07:00	0.0	0	0	0	0	1
07/15/2020 08:00	0.0	0	0	0	0	1
07/15/2020 09:00	0.0	0	0	0	0	1
07/15/2020 10:00	0.0	0	0	0	0	1
07/15/2020 11:00	0.0	0	0	0	0	1
07/15/2020 12:00	0.0	0	0	0	0	1
07/15/2020 13:00	0.0	0	0	0	0	1
07/15/2020 14:00	0.0	0	0	0	0	1
07/15/2020 15:00	0.0	0	0	0	0	1
07/15/2020 16:00	0.0	0	0	0	0	1
07/15/2020 17:00	0.0	0	0	0	0	1
07/15/2020 18:00	0.0	0	0	0	0	1
07/15/2020 19:00	0.0	0	0	0	0	1
07/15/2020 20:00	0.0	0	0	0	0	1
07/15/2020 21:00	0.0	0	0	0	0	1
07/15/2020 22:00	0.0	0	0	0	0	1
07/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/16/2020 00:00	0.0	0	0	0	0	1
07/16/2020 01:00	0.0	0	0	0	0	1
07/16/2020 02:00	0.0	0	0	0	0	1
07/16/2020 03:00	0.0	0	0	0	0	1
07/16/2020 04:00	0.0	0	0	0	0	1
07/16/2020 05:00	0.0	0	0	0	0	1
07/16/2020 06:00	0.0	0	0	0	0	1
07/16/2020 07:00	0.0	0	0	0	0	1
07/16/2020 08:00	0.0	0	0	0	0	1
07/16/2020 09:00	0.0	0	0	0	0	1
07/16/2020 10:00	0.0	0	0	0	0	1
07/16/2020 11:00	0.0	0	0	0	0	1
07/16/2020 12:00	0.0	0	0	0	0	1
07/16/2020 13:00	0.0	0	0	0	0	1
07/16/2020 14:00	0.0	0	0	0	0	1
07/16/2020 15:00	0.0	0	0	0	0	1
07/16/2020 16:00	0.0	0	0	0	0	1
07/16/2020 17:00	0.0	0	0	0	0	1
07/16/2020 18:00	0.0	0	0	0	0	1
07/16/2020 19:00	0.0	0	0	0	0	1
07/16/2020 20:00	0.0	0	0	0	0	1
07/16/2020 21:00	0.0	0	0	0	0	1
07/16/2020 22:00	0.0	0	0	0	0	1
07/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/17/2020 00:00	0.0	0	0	0	0	1
07/17/2020 01:00	0.0	0	0	0	0	1
07/17/2020 02:00	0.0	0	0	0	0	1
07/17/2020 03:00	0.0	0	0	0	0	1
07/17/2020 04:00	0.0	0	0	0	0	1
07/17/2020 05:00	0.0	0	0	0	0	1
07/17/2020 06:00	0.0	0	0	0	0	1
07/17/2020 07:00	0.0	0	0	0	0	1
07/17/2020 08:00	0.0	0	0	0	0	1
07/17/2020 09:00	0.0	0	0	0	0	1
07/17/2020 10:00	0.0	0	0	0	0	1
07/17/2020 11:00	0.0	0	0	0	0	1
07/17/2020 12:00	0.0	0	0	0	0	1
07/17/2020 13:00	0.0	0	0	0	0	1
07/17/2020 14:00	0.0	0	0	0	0	1
07/17/2020 15:00	0.0	0	0	0	0	1
07/17/2020 16:00	0.0	0	0	0	0	1
07/17/2020 17:00	0.0	0	0	0	0	1
07/17/2020 18:00	0.0	0	0	0	0	1
07/17/2020 19:00	0.0	0	0	0	0	1
07/17/2020 20:00	0.0	0	0	0	0	1
07/17/2020 21:00	0.0	0	0	0	0	1
07/17/2020 22:00	0.0	0	0	0	0	1
07/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/18/2020 00:00	0.0	0	0	0	0	1
07/18/2020 01:00	0.0	0	0	0	0	1
07/18/2020 02:00	0.0	0	0	0	0	1
07/18/2020 03:00	0.0	0	0	0	0	1
07/18/2020 04:00	0.0	0	0	0	0	1
07/18/2020 05:00	0.0	0	0	0	0	1
07/18/2020 06:00	0.0	0	0	0	0	1
07/18/2020 07:00	0.0	0	0	0	0	1
07/18/2020 08:00	0.0	0	0	0	0	1
07/18/2020 09:00	0.0	0	0	0	0	1
07/18/2020 10:00	0.0	0	0	0	0	1
07/18/2020 11:00	0.0	0	0	0	0	1
07/18/2020 12:00	0.0	0	0	0	0	1
07/18/2020 13:00	0.0	0	0	0	0	1
07/18/2020 14:00	0.0	0	0	0	0	1
07/18/2020 15:00	0.0	0	0	0	0	1
07/18/2020 16:00	0.0	0	0	0	0	1
07/18/2020 17:00	0.0	0	0	0	0	1
07/18/2020 18:00	0.0	0	0	0	0	1
07/18/2020 19:00	0.0	0	0	0	0	1
07/18/2020 20:00	0.0	0	0	0	0	1
07/18/2020 21:00	0.0	0	0	0	0	1
07/18/2020 22:00	0.0	0	0	0	0	1
07/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/19/2020 00:00	0.0	0	0	0	0	1
07/19/2020 01:00	0.0	0	0	0	0	1
07/19/2020 02:00	0.0	0	0	0	0	1
07/19/2020 03:00	0.0	0	0	0	0	1
07/19/2020 04:00	0.0	0	0	0	0	1
07/19/2020 05:00	0.0	0	0	0	0	1
07/19/2020 06:00	0.0	0	0	0	0	1
07/19/2020 07:00	0.0	0	0	0	0	1
07/19/2020 08:00	0.0	0	0	0	0	1
07/19/2020 09:00	0.0	0	0	0	0	1
07/19/2020 10:00	0.0	0	0	0	0	1
07/19/2020 11:00	0.0	0	0	0	0	1
07/19/2020 12:00	0.0	0	0	0	0	1
07/19/2020 13:00	0.0	0	0	0	0	1
07/19/2020 14:00	0.0	0	0	0	0	1
07/19/2020 15:00	0.0	0	0	0	0	1
07/19/2020 16:00	0.0	0	0	0	0	1
07/19/2020 17:00	0.0	0	0	0	0	1
07/19/2020 18:00	0.0	0	0	0	0	1
07/19/2020 19:00	0.0	0	0	0	0	1
07/19/2020 20:00	0.0	0	0	0	0	1
07/19/2020 21:00	0.0	0	0	0	0	1
07/19/2020 22:00	0.0	0	0	0	0	1
07/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/20/2020 00:00	0.0	0	0	0	0	1
07/20/2020 01:00	0.0	0	0	0	0	1
07/20/2020 02:00	0.0	0	0	0	0	1
07/20/2020 03:00	0.0	0	0	0	0	1
07/20/2020 04:00	0.0	0	0	0	0	1
07/20/2020 05:00	0.0	0	0	0	0	1
07/20/2020 06:00	0.0	0	0	0	0	1
07/20/2020 07:00	0.0	0	0	0	0	1
07/20/2020 08:00	0.0	0	0	0	0	1
07/20/2020 09:00	0.0	0	0	0	0	1
07/20/2020 10:00	0.0	0	0	0	0	1
07/20/2020 11:00	0.0	0	0	0	0	1
07/20/2020 12:00	0.0	0	0	0	0	1
07/20/2020 13:00	0.0	0	0	0	0	1
07/20/2020 14:00	0.0	0	0	0	0	1
07/20/2020 15:00	0.0	0	0	0	0	1
07/20/2020 16:00	0.0	0	0	0	0	1
07/20/2020 17:00	0.0	0	0	0	0	1
07/20/2020 18:00	0.0	0	0	0	0	1
07/20/2020 19:00	0.0	0	0	0	0	1
07/20/2020 20:00	0.0	0	0	0	0	1
07/20/2020 21:00	0.0	0	0	0	0	1
07/20/2020 22:00	0.0	0	0	0	0	1
07/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/21/2020 00:00	0.0	0	0	0	0	1
07/21/2020 01:00	0.0	0	0	0	0	1
07/21/2020 02:00	0.0	0	0	0	0	1
07/21/2020 03:00	0.0	0	0	0	0	1
07/21/2020 04:00	0.0	0	0	0	0	1
07/21/2020 05:00	0.0	0	0	0	0	1
07/21/2020 06:00	0.0	0	0	0	0	1
07/21/2020 07:00	0.0	0	0	0	0	1
07/21/2020 08:00	0.0	0	0	0	0	1
07/21/2020 09:00	0.0	0	0	0	0	1
07/21/2020 10:00	0.0	0	0	0	0	1
07/21/2020 11:00	0.0	0	0	0	0	1
07/21/2020 12:00	0.0	0	0	0	0	1
07/21/2020 13:00	0.0	0	0	0	0	1
07/21/2020 14:00	0.0	0	0	0	0	1
07/21/2020 15:00	0.0	0	0	0	0	1
07/21/2020 16:00	0.0	0	0	0	0	1
07/21/2020 17:00	0.0	0	0	0	0	1
07/21/2020 18:00	0.0	0	0	0	0	1
07/21/2020 19:00	0.0	0	0	0	0	1
07/21/2020 20:00	0.0	0	0	0	0	1
07/21/2020 21:00	0.0	0	0	0	0	1
07/21/2020 22:00	0.0	0	0	0	0	1
07/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/22/2020 00:00	0.0	0	0	0	0	1
07/22/2020 01:00	0.0	0	0	0	0	1
07/22/2020 02:00	0.0	0	0	0	0	1
07/22/2020 03:00	0.0	0	0	0	0	1
07/22/2020 04:00	0.0	0	0	0	0	1
07/22/2020 05:00	0.0	0	0	0	0	1
07/22/2020 06:00	0.0	0	0	0	0	1
07/22/2020 07:00	0.0	0	0	0	0	1
07/22/2020 08:00	0.0	0	0	0	0	1
07/22/2020 09:00	0.0	0	0	0	0	1
07/22/2020 10:00	0.0	0	0	0	0	1
07/22/2020 11:00	0.0	0	0	0	0	1
07/22/2020 12:00	0.0	0	0	0	0	1
07/22/2020 13:00	0.0	0	0	0	0	1
07/22/2020 14:00	0.0	0	0	0	0	1
07/22/2020 15:00	0.0	0	0	0	0	1
07/22/2020 16:00	0.0	0	0	0	0	1
07/22/2020 17:00	0.0	0	0	0	0	1
07/22/2020 18:00	0.0	0	0	0	0	1
07/22/2020 19:00	0.0	0	0	0	0	1
07/22/2020 20:00	0.0	0	0	0	0	1
07/22/2020 21:00	0.0	0	0	0	0	1
07/22/2020 22:00	0.0	0	0	0	0	1
07/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/23/2020 00:00	0.0	0	0	0	0	1
07/23/2020 01:00	0.0	0	0	0	0	1
07/23/2020 02:00	0.0	0	0	0	0	1
07/23/2020 03:00	0.0	0	0	0	0	1
07/23/2020 04:00	0.0	0	0	0	0	1
07/23/2020 05:00	0.0	0	0	0	0	1
07/23/2020 06:00	0.0	0	0	0	0	1
07/23/2020 07:00	0.0	0	0	0	0	1
07/23/2020 08:00	0.0	0	0	0	0	1
07/23/2020 09:00	0.0	0	0	0	0	1
07/23/2020 10:00	0.0	0	0	0	0	1
07/23/2020 11:00	0.0	0	0	0	0	1
07/23/2020 12:00	0.0	0	0	0	0	1
07/23/2020 13:00	0.0	0	0	0	0	1
07/23/2020 14:00	0.0	0	0	0	0	1
07/23/2020 15:00	0.0	0	0	0	0	1
07/23/2020 16:00	0.0	0	0	0	0	1
07/23/2020 17:00	0.0	0	0	0	0	1
07/23/2020 18:00	0.0	0	0	0	0	1
07/23/2020 19:00	0.0	0	0	0	0	1
07/23/2020 20:00	0.0	0	0	0	0	1
07/23/2020 21:00	0.0	0	0	0	0	1
07/23/2020 22:00	0.0	0	0	0	0	1
07/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/24/2020 00:00	0.0	0	0	0	0	1
07/24/2020 01:00	0.0	0	0	0	0	1
07/24/2020 02:00	0.0	0	0	0	0	1
07/24/2020 03:00	0.0	0	0	0	0	1
07/24/2020 04:00	0.0	0	0	0	0	1
07/24/2020 05:00	0.0	0	0	0	0	1
07/24/2020 06:00	0.0	0	0	0	0	1
07/24/2020 07:00	0.0	0	0	0	0	1
07/24/2020 08:00	0.0	0	0	0	0	0
07/24/2020 09:00	0.0	0	0	0	0	0
07/24/2020 10:00	0.0	0	0	0	0	0
07/24/2020 11:00	0.0	0	0	0	0	0
07/24/2020 12:00	0.0	0	0	0	0	0
07/24/2020 13:00	0.0	0	0	0	0	0
07/24/2020 14:00	0.0	0	0	0	0	0
07/24/2020 15:00	0.0	0	0	0	0	0
07/24/2020 16:00	0.0	0	0	0	0	0
07/24/2020 17:00	0.0	0	0	0	0	0
07/24/2020 18:00	0.0	0	0	0	0	0
07/24/2020 19:00	0.0	0	0	0	0	0
07/24/2020 20:00	0.0	0	0	0	0	0
07/24/2020 21:00	0.0	0	0	0	0	0
07/24/2020 22:00	0.0	0	0	0	0	0
07/24/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/25/2020 00:00	0.0	0	0	0	0	0
07/25/2020 01:00	0.0	0	0	0	0	0
07/25/2020 02:00	0.0	0	0	0	0	0
07/25/2020 03:00	0.0	0	0	0	0	0
07/25/2020 04:00	0.0	0	0	0	0	0
07/25/2020 05:00	0.0	0	0	0	0	0
07/25/2020 06:00	0.0	0	0	0	0	0
07/25/2020 07:00	0.0	0	0	0	0	0
07/25/2020 08:00	0.0	0	0	0	0	0
07/25/2020 09:00	0.0	0	0	0	0	0
07/25/2020 10:00	0.0	0	0	0	0	0
07/25/2020 11:00	0.0	0	0	0	0	0
07/25/2020 12:00	0.0	0	0	0	0	0
07/25/2020 13:00	45.1	0	1	0	0	0
07/25/2020 14:00	32.9	0	1	0	0	0
07/25/2020 15:00	0.0	0	0	0	0	1
07/25/2020 16:00	0.0	0	0	0	0	1
07/25/2020 17:00	0.0	0	0	0	0	1
07/25/2020 18:00	0.0	0	0	0	0	1
07/25/2020 19:00	0.0	0	0	0	0	1
07/25/2020 20:00	0.0	0	0	0	0	1
07/25/2020 21:00	0.0	0	0	0	0	1
07/25/2020 22:00	0.0	0	0	0	0	1
07/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	78.0 #	0 #	2 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	45.1	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/26/2020 00:00	0.0	0	0	0	0	1
07/26/2020 01:00	0.0	0	0	0	0	1
07/26/2020 02:00	0.0	0	0	0	0	1
07/26/2020 03:00	0.0	0	0	0	0	1
07/26/2020 04:00	0.0	0	0	0	0	1
07/26/2020 05:00	0.0	0	0	0	0	1
07/26/2020 06:00	0.0	0	0	0	0	1
07/26/2020 07:00	0.0	0	0	0	0	1
07/26/2020 08:00	0.0	0	0	0	0	1
07/26/2020 09:00	0.0	0	0	0	0	1
07/26/2020 10:00	0.0	0	0	0	0	1
07/26/2020 11:00	0.0	0	0	0	0	1
07/26/2020 12:00	0.0	0	0	0	0	1
07/26/2020 13:00	0.0	0	0	0	0	1
07/26/2020 14:00	0.0	0	0	0	0	1
07/26/2020 15:00	0.0	0	0	0	0	1
07/26/2020 16:00	0.0	0	0	0	0	1
07/26/2020 17:00	0.0	0	0	0	0	1
07/26/2020 18:00	0.0	0	0	0	0	1
07/26/2020 19:00	0.0	0	0	0	0	1
07/26/2020 20:00	0.0	0	0	0	0	1
07/26/2020 21:00	0.0	0	0	0	0	1
07/26/2020 22:00	0.0	0	0	0	0	1
07/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/27/2020 00:00	0.0	0	0	0	0	1
07/27/2020 01:00	0.0	0	0	0	0	1
07/27/2020 02:00	0.0	0	0	0	0	1
07/27/2020 03:00	0.0	0	0	0	0	1
07/27/2020 04:00	0.0	0	0	0	0	1
07/27/2020 05:00	0.0	0	0	0	0	1
07/27/2020 06:00	0.0	0	0	0	0	1
07/27/2020 07:00	0.0	0	0	0	0	1
07/27/2020 08:00	0.0	0	0	0	0	1
07/27/2020 09:00	0.0	0	0	0	0	1
07/27/2020 10:00	0.0	0	0	0	0	1
07/27/2020 11:00	0.0	0	0	0	0	1
07/27/2020 12:00	0.0	0	0	0	0	1
07/27/2020 13:00	0.0	0	0	0	0	1
07/27/2020 14:00	0.0	0	0	0	0	1
07/27/2020 15:00	0.0	0	0	0	0	1
07/27/2020 16:00	0.0	0	0	0	0	1
07/27/2020 17:00	0.0	0	0	0	0	1
07/27/2020 18:00	0.0	0	0	0	0	1
07/27/2020 19:00	0.0	0	0	0	0	1
07/27/2020 20:00	0.0	0	0	0	0	1
07/27/2020 21:00	0.0	0	0	0	0	1
07/27/2020 22:00	0.0	0	0	0	0	1
07/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/28/2020 00:00	0.0	0	0	0	0	1
07/28/2020 01:00	0.0	0	0	0	0	1
07/28/2020 02:00	0.0	0	0	0	0	1
07/28/2020 03:00	0.0	0	0	0	0	1
07/28/2020 04:00	0.0	0	0	0	0	1
07/28/2020 05:00	0.0	0	0	0	0	1
07/28/2020 06:00	0.0	0	0	0	0	1
07/28/2020 07:00	0.0	0	0	0	0	1
07/28/2020 08:00	0.0	0	0	0	0	1
07/28/2020 09:00	0.0	0	0	0	0	1
07/28/2020 10:00	0.0	0	0	0	0	1
07/28/2020 11:00	0.0	0	0	0	0	1
07/28/2020 12:00	0.0	0	0	0	0	1
07/28/2020 13:00	0.0	0	0	0	0	1
07/28/2020 14:00	0.0	0	0	0	0	1
07/28/2020 15:00	0.0	0	0	0	0	1
07/28/2020 16:00	0.0	0	0	0	0	1
07/28/2020 17:00	0.0	0	0	0	0	1
07/28/2020 18:00	0.0	0	0	0	0	1
07/28/2020 19:00	0.0	0	0	0	0	1
07/28/2020 20:00	0.0	0	0	0	0	1
07/28/2020 21:00	0.0	0	0	0	0	1
07/28/2020 22:00	0.0	0	0	0	0	1
07/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/29/2020 00:00	0.0	0	0	0	0	1
07/29/2020 01:00	0.0	0	0	0	0	1
07/29/2020 02:00	0.0	0	0	0	0	1
07/29/2020 03:00	0.0	0	0	0	0	1
07/29/2020 04:00	0.0	0	0	0	0	1
07/29/2020 05:00	0.0	0	0	0	0	1
07/29/2020 06:00	0.0	0	0	0	0	1
07/29/2020 07:00	0.0	0	0	0	0	1
07/29/2020 08:00	0.0	0	0	0	0	1
07/29/2020 09:00	0.0	0	0	0	0	1
07/29/2020 10:00	0.0	0	0	0	0	1
07/29/2020 11:00	0.0	0	0	0	0	1
07/29/2020 12:00	0.0	0	0	0	0	1
07/29/2020 13:00	0.0	0	0	0	0	1
07/29/2020 14:00	0.0	0	0	0	0	1
07/29/2020 15:00	0.0	0	0	0	0	1
07/29/2020 16:00	0.0	0	0	0	0	1
07/29/2020 17:00	0.0	0	0	0	0	1
07/29/2020 18:00	0.0	0	0	0	0	1
07/29/2020 19:00	0.0	0	0	0	0	1
07/29/2020 20:00	0.0	0	0	0	0	1
07/29/2020 21:00	0.0	0	0	0	0	1
07/29/2020 22:00	0.0	0	0	0	0	1
07/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/30/2020 00:00	0.0	0	0	0	0	1
07/30/2020 01:00	0.0	0	0	0	0	1
07/30/2020 02:00	0.0	0	0	0	0	1
07/30/2020 03:00	0.0	0	0	0	0	1
07/30/2020 04:00	0.0	0	0	0	0	1
07/30/2020 05:00	0.0	0	0	0	0	1
07/30/2020 06:00	0.0	0	0	0	0	1
07/30/2020 07:00	0.0	0	0	0	0	1
07/30/2020 08:00	0.0	0	0	0	0	1
07/30/2020 09:00	0.0	0	0	0	0	1
07/30/2020 10:00	0.0	0	0	0	0	1
07/30/2020 11:00	0.0	0	0	0	0	1
07/30/2020 12:00	0.0	0	0	0	0	1
07/30/2020 13:00	0.0	0	0	0	0	1
07/30/2020 14:00	0.0	0	0	0	0	1
07/30/2020 15:00	0.0	0	0	0	0	1
07/30/2020 16:00	0.0	0	0	0	0	1
07/30/2020 17:00	0.0	0	0	0	0	1
07/30/2020 18:00	0.0	0	0	0	0	1
07/30/2020 19:00	0.0	0	0	0	0	1
07/30/2020 20:00	0.0	0	0	0	0	1
07/30/2020 21:00	0.0	0	0	0	0	1
07/30/2020 22:00	0.0	0	0	0	0	1
07/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/31/2020 00:00	0.0	0	0	0	0	1
07/31/2020 01:00	0.0	0	0	0	0	1
07/31/2020 02:00	0.0	0	0	0	0	1
07/31/2020 03:00	0.0	0	0	0	0	1
07/31/2020 04:00	0.0	0	0	0	0	1
07/31/2020 05:00	0.0	0	0	0	0	1
07/31/2020 06:00	0.0	0	0	0	0	1
07/31/2020 07:00	0.0	0	0	0	0	1
07/31/2020 08:00	0.0	0	0	0	0	1
07/31/2020 09:00	0.0	0	0	0	0	1
07/31/2020 10:00	0.0	0	0	0	0	1
07/31/2020 11:00	0.0	0	0	0	0	1
07/31/2020 12:00	0.0	0	0	0	0	1
07/31/2020 13:00	0.0	0	0	0	0	1
07/31/2020 14:00	0.0	0	0	0	0	1
07/31/2020 15:00	0.0	0	0	0	0	1
07/31/2020 16:00	0.0	0	0	0	0	1
07/31/2020 17:00	0.0	0	0	0	0	1
07/31/2020 18:00	0.0	0	0	0	0	1
07/31/2020 19:00	0.0	0	0	0	0	1
07/31/2020 20:00	0.0	0	0	0	0	1
07/31/2020 21:00	0.0	0	0	0	0	1
07/31/2020 22:00	0.0	0	0	0	0	1
07/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/01/2020 00:00	0.0	0	0	0	0	1
08/01/2020 01:00	0.0	0	0	0	0	1
08/01/2020 02:00	0.0	0	0	0	0	1
08/01/2020 03:00	0.0	0	0	0	0	1
08/01/2020 04:00	0.0	0	0	0	0	1
08/01/2020 05:00	0.0	0	0	0	0	1
08/01/2020 06:00	0.0	0	0	0	0	1
08/01/2020 07:00	0.0	0	0	0	0	1
08/01/2020 08:00	0.0	0	0	0	0	1
08/01/2020 09:00	0.0	0	0	0	0	1
08/01/2020 10:00	0.0	0	0	0	0	1
08/01/2020 11:00	0.0	0	0	0	0	1
08/01/2020 12:00	0.0	0	0	0	0	1
08/01/2020 13:00	0.0	0	0	0	0	1
08/01/2020 14:00	0.0	0	0	0	0	1
08/01/2020 15:00	0.0	0	0	0	0	1
08/01/2020 16:00	0.0	0	0	0	0	1
08/01/2020 17:00	0.0	0	0	0	0	1
08/01/2020 18:00	0.0	0	0	0	0	1
08/01/2020 19:00	0.0	0	0	0	0	1
08/01/2020 20:00	0.0	0	0	0	0	1
08/01/2020 21:00	0.0	0	0	0	0	1
08/01/2020 22:00	0.0	0	0	0	0	1
08/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/02/2020 00:00	0.0	0	0	0	0	1
08/02/2020 01:00	0.0	0	0	0	0	1
08/02/2020 02:00	0.0	0	0	0	0	1
08/02/2020 03:00	0.0	0	0	0	0	1
08/02/2020 04:00	0.0	0	0	0	0	1
08/02/2020 05:00	0.0	0	0	0	0	1
08/02/2020 06:00	0.0	0	0	0	0	1
08/02/2020 07:00	0.0	0	0	0	0	1
08/02/2020 08:00	0.0	0	0	0	0	1
08/02/2020 09:00	0.0	0	0	0	0	1
08/02/2020 10:00	0.0	0	0	0	0	1
08/02/2020 11:00	0.0	0	0	0	0	1
08/02/2020 12:00	0.0	0	0	0	0	1
08/02/2020 13:00	0.0	0	0	0	0	1
08/02/2020 14:00	0.0	0	0	0	0	1
08/02/2020 15:00	0.0	0	0	0	0	1
08/02/2020 16:00	0.0	0	0	0	0	1
08/02/2020 17:00	0.0	0	0	0	0	1
08/02/2020 18:00	0.0	0	0	0	0	1
08/02/2020 19:00	0.0	0	0	0	0	1
08/02/2020 20:00	0.0	0	0	0	0	1
08/02/2020 21:00	0.0	0	0	0	0	1
08/02/2020 22:00	0.0	0	0	0	0	1
08/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/03/2020 00:00	0.0	0	0	0	0	1
08/03/2020 01:00	0.0	0	0	0	0	1
08/03/2020 02:00	0.0	0	0	0	0	1
08/03/2020 03:00	0.0	0	0	0	0	1
08/03/2020 04:00	0.0	0	0	0	0	1
08/03/2020 05:00	0.0	0	0	0	0	1
08/03/2020 06:00	0.0	0	0	0	0	1
08/03/2020 07:00	0.0	0	0	0	0	1
08/03/2020 08:00	0.0	0	0	0	0	1
08/03/2020 09:00	0.0	0	0	0	0	1
08/03/2020 10:00	0.0	0	0	0	0	1
08/03/2020 11:00	0.0	0	0	0	0	1
08/03/2020 12:00	0.0	0	0	0	0	1
08/03/2020 13:00	0.0	0	0	0	0	1
08/03/2020 14:00	0.0	0	0	0	0	1
08/03/2020 15:00	0.0	0	0	0	0	1
08/03/2020 16:00	0.0	0	0	0	0	1
08/03/2020 17:00	0.0	0	0	0	0	1
08/03/2020 18:00	0.0	0	0	0	0	1
08/03/2020 19:00	0.0	0	0	0	0	1
08/03/2020 20:00	0.0	0	0	0	0	1
08/03/2020 21:00	0.0	0	0	0	0	1
08/03/2020 22:00	0.0	0	0	0	0	1
08/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/04/2020 00:00	0.0	0	0	0	0	1
08/04/2020 01:00	0.0	0	0	0	0	1
08/04/2020 02:00	0.0	0	0	0	0	1
08/04/2020 03:00	0.0	0	0	0	0	1
08/04/2020 04:00	0.0	0	0	0	0	1
08/04/2020 05:00	0.0	0	0	0	0	1
08/04/2020 06:00	0.0	0	0	0	0	1
08/04/2020 07:00	0.0	0	0	0	0	1
08/04/2020 08:00	0.0	0	0	0	0	1
08/04/2020 09:00	0.0	0	0	0	0	1
08/04/2020 10:00	0.0	0	0	0	0	1
08/04/2020 11:00	0.0	0	0	0	0	1
08/04/2020 12:00	0.0	0	0	0	0	1
08/04/2020 13:00	0.0	0	0	0	0	1
08/04/2020 14:00	0.0	0	0	0	0	1
08/04/2020 15:00	0.0	0	0	0	0	1
08/04/2020 16:00	0.0	0	0	0	0	1
08/04/2020 17:00	0.0	0	0	0	0	1
08/04/2020 18:00	0.0	0	0	0	0	1
08/04/2020 19:00	0.0	0	0	0	0	1
08/04/2020 20:00	0.0	0	0	0	0	1
08/04/2020 21:00	0.0	0	0	0	0	1
08/04/2020 22:00	0.0	0	0	0	0	1
08/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/05/2020 00:00	0.0	0	0	0	0	1
08/05/2020 01:00	0.0	0	0	0	0	1
08/05/2020 02:00	0.0	0	0	0	0	1
08/05/2020 03:00	0.0	0	0	0	0	1
08/05/2020 04:00	0.0	0	0	0	0	1
08/05/2020 05:00	0.0	0	0	0	0	1
08/05/2020 06:00	0.0	0	0	0	0	1
08/05/2020 07:00	0.0	0	0	0	0	1
08/05/2020 08:00	0.0	0	0	0	0	1
08/05/2020 09:00	0.0	0	0	0	0	1
08/05/2020 10:00	0.0	0	0	0	0	1
08/05/2020 11:00	0.0	0	0	0	0	1
08/05/2020 12:00	0.0	0	0	0	0	1
08/05/2020 13:00	0.0	0	0	0	0	1
08/05/2020 14:00	0.0	0	0	0	0	1
08/05/2020 15:00	0.0	0	0	0	0	1
08/05/2020 16:00	0.0	0	0	0	0	1
08/05/2020 17:00	0.0	0	0	0	0	1
08/05/2020 18:00	0.0	0	0	0	0	1
08/05/2020 19:00	0.0	0	0	0	0	1
08/05/2020 20:00	0.0	0	0	0	0	1
08/05/2020 21:00	0.0	0	0	0	0	1
08/05/2020 22:00	0.0	0	0	0	0	1
08/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/06/2020 00:00	0.0	0	0	0	0	1
08/06/2020 01:00	0.0	0	0	0	0	1
08/06/2020 02:00	0.0	0	0	0	0	1
08/06/2020 03:00	0.0	0	0	0	0	1
08/06/2020 04:00	0.0	0	0	0	0	1
08/06/2020 05:00	0.0	0	0	0	0	1
08/06/2020 06:00	0.0	0	0	0	0	1
08/06/2020 07:00	0.0	0	0	0	0	1
08/06/2020 08:00	0.0	0	0	0	0	1
08/06/2020 09:00	0.0	0	0	0	0	1
08/06/2020 10:00	0.0	0	0	0	0	1
08/06/2020 11:00	0.0	0	0	0	0	1
08/06/2020 12:00	0.0	0	0	0	0	1
08/06/2020 13:00	0.0	0	0	0	0	1
08/06/2020 14:00	0.0	0	0	0	0	1
08/06/2020 15:00	0.0	0	0	0	0	1
08/06/2020 16:00	0.0	0	0	0	0	1
08/06/2020 17:00	0.0	0	0	0	0	1
08/06/2020 18:00	0.0	0	0	0	0	1
08/06/2020 19:00	0.0	0	0	0	0	1
08/06/2020 20:00	0.0	0	0	0	0	1
08/06/2020 21:00	0.0	0	0	0	0	1
08/06/2020 22:00	0.0	0	0	0	0	1
08/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/07/2020 00:00	0.0	0	0	0	0	1
08/07/2020 01:00	0.0	0	0	0	0	1
08/07/2020 02:00	0.0	0	0	0	0	1
08/07/2020 03:00	0.0	0	0	0	0	1
08/07/2020 04:00	0.0	0	0	0	0	1
08/07/2020 05:00	0.0	0	0	0	0	1
08/07/2020 06:00	0.0	0	0	0	0	1
08/07/2020 07:00	0.0	0	0	0	0	1
08/07/2020 08:00	0.0	0	0	0	0	1
08/07/2020 09:00	0.0	0	0	0	0	1
08/07/2020 10:00	0.0	0	0	0	0	1
08/07/2020 11:00	0.0	0	0	0	0	1
08/07/2020 12:00	0.0	0	0	0	0	1
08/07/2020 13:00	0.0	0	0	0	0	1
08/07/2020 14:00	0.0	0	0	0	0	1
08/07/2020 15:00	0.0	0	0	0	0	1
08/07/2020 16:00	0.0	0	0	0	0	1
08/07/2020 17:00	0.0	0	0	0	0	1
08/07/2020 18:00	0.0	0	0	0	0	1
08/07/2020 19:00	0.0	0	0	0	0	1
08/07/2020 20:00	0.0	0	0	0	0	1
08/07/2020 21:00	0.0	0	0	0	0	1
08/07/2020 22:00	0.0	0	0	0	0	1
08/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/08/2020 00:00	0.0	0	0	0	0	1
08/08/2020 01:00	0.0	0	0	0	0	1
08/08/2020 02:00	0.0	0	0	0	0	1
08/08/2020 03:00	0.0	0	0	0	0	1
08/08/2020 04:00	0.0	0	0	0	0	1
08/08/2020 05:00	0.0	0	0	0	0	1
08/08/2020 06:00	0.0	0	0	0	0	1
08/08/2020 07:00	0.0	0	0	0	0	1
08/08/2020 08:00	0.0	0	0	0	0	1
08/08/2020 09:00	0.0	0	0	0	0	1
08/08/2020 10:00	0.0	0	0	0	0	1
08/08/2020 11:00	0.0	0	0	0	0	1
08/08/2020 12:00	0.0	0	0	0	0	1
08/08/2020 13:00	0.0	0	0	0	0	1
08/08/2020 14:00	0.0	0	0	0	0	1
08/08/2020 15:00	0.0	0	0	0	0	1
08/08/2020 16:00	0.0	0	0	0	0	1
08/08/2020 17:00	0.0	0	0	0	0	1
08/08/2020 18:00	0.0	0	0	0	0	1
08/08/2020 19:00	0.0	0	0	0	0	1
08/08/2020 20:00	0.0	0	0	0	0	1
08/08/2020 21:00	0.0	0	0	0	0	1
08/08/2020 22:00	0.0	0	0	0	0	1
08/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/09/2020 00:00	0.0	0	0	0	0	1
08/09/2020 01:00	0.0	0	0	0	0	1
08/09/2020 02:00	0.0	0	0	0	0	1
08/09/2020 03:00	0.0	0	0	0	0	1
08/09/2020 04:00	0.0	0	0	0	0	1
08/09/2020 05:00	0.0	0	0	0	0	1
08/09/2020 06:00	0.0	0	0	0	0	1
08/09/2020 07:00	0.0	0	0	0	0	1
08/09/2020 08:00	0.0	0	0	0	0	1
08/09/2020 09:00	0.0	0	0	0	0	1
08/09/2020 10:00	0.0	0	0	0	0	1
08/09/2020 11:00	0.0	0	0	0	0	1
08/09/2020 12:00	0.0	0	0	0	0	1
08/09/2020 13:00	0.0	0	0	0	0	1
08/09/2020 14:00	0.0	0	0	0	0	1
08/09/2020 15:00	0.0	0	0	0	0	1
08/09/2020 16:00	0.0	0	0	0	0	1
08/09/2020 17:00	0.0	0	0	0	0	1
08/09/2020 18:00	0.0	0	0	0	0	1
08/09/2020 19:00	0.0	0	0	0	0	1
08/09/2020 20:00	0.0	0	0	0	0	1
08/09/2020 21:00	0.0	0	0	0	0	1
08/09/2020 22:00	0.0	0	0	0	0	1
08/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/10/2020 00:00	0.0	0	0	0	0	1
08/10/2020 01:00	0.0	0	0	0	0	1
08/10/2020 02:00	0.0	0	0	0	0	1
08/10/2020 03:00	0.0	0	0	0	0	1
08/10/2020 04:00	0.0	0	0	0	0	1
08/10/2020 05:00	0.0	0	0	0	0	1
08/10/2020 06:00	0.0	0	0	0	0	1
08/10/2020 07:00	0.0	0	0	0	0	1
08/10/2020 08:00	0.0	0	0	0	0	1
08/10/2020 09:00	0.0	0	0	0	0	1
08/10/2020 10:00	0.0	0	0	0	0	1
08/10/2020 11:00	0.0	0	0	0	0	1
08/10/2020 12:00	0.0	0	0	0	0	1
08/10/2020 13:00	0.0	0	0	0	0	1
08/10/2020 14:00	0.0	0	0	0	0	1
08/10/2020 15:00	0.0	0	0	0	0	1
08/10/2020 16:00	0.0	0	0	0	0	1
08/10/2020 17:00	0.0	0	0	0	0	1
08/10/2020 18:00	0.0	0	0	0	0	1
08/10/2020 19:00	0.0	0	0	0	0	1
08/10/2020 20:00	0.0	0	0	0	0	1
08/10/2020 21:00	0.0	0	0	0	0	1
08/10/2020 22:00	0.0	0	0	0	0	1
08/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/11/2020 00:00	0.0	0	0	0	0	1
08/11/2020 01:00	0.0	0	0	0	0	1
08/11/2020 02:00	0.0	0	0	0	0	1
08/11/2020 03:00	0.0	0	0	0	0	1
08/11/2020 04:00	0.0	0	0	0	0	1
08/11/2020 05:00	0.0	0	0	0	0	1
08/11/2020 06:00	0.0	0	0	0	0	1
08/11/2020 07:00	0.0	0	0	0	0	1
08/11/2020 08:00	0.0	0	0	0	0	1
08/11/2020 09:00	0.0	0	0	0	0	1
08/11/2020 10:00	0.0	0	0	0	0	1
08/11/2020 11:00	0.0	0	0	0	0	1
08/11/2020 12:00	0.0	0	0	0	0	1
08/11/2020 13:00	0.0	0	0	0	0	1
08/11/2020 14:00	0.0	0	0	0	0	1
08/11/2020 15:00	0.0	0	0	0	0	1
08/11/2020 16:00	0.0	0	0	0	0	1
08/11/2020 17:00	0.0	0	0	0	0	1
08/11/2020 18:00	0.0	0	0	0	0	1
08/11/2020 19:00	0.0	0	0	0	0	1
08/11/2020 20:00	0.0	0	0	0	0	1
08/11/2020 21:00	0.0	0	0	0	0	1
08/11/2020 22:00	0.0	0	0	0	0	1
08/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/12/2020 00:00	0.0	0	0	0	0	1
08/12/2020 01:00	0.0	0	0	0	0	1
08/12/2020 02:00	0.0	0	0	0	0	1
08/12/2020 03:00	0.0	0	0	0	0	1
08/12/2020 04:00	0.0	0	0	0	0	1
08/12/2020 05:00	0.0	0	0	0	0	1
08/12/2020 06:00	0.0	0	0	0	0	1
08/12/2020 07:00	0.0	0	0	0	0	1
08/12/2020 08:00	0.0	0	0	0	0	1
08/12/2020 09:00	0.0	0	0	0	0	1
08/12/2020 10:00	0.0	0	0	0	0	1
08/12/2020 11:00	0.0	0	0	0	0	1
08/12/2020 12:00	0.0	0	0	0	0	1
08/12/2020 13:00	0.0	0	0	0	0	1
08/12/2020 14:00	0.0	0	0	0	0	1
08/12/2020 15:00	0.0	0	0	0	0	1
08/12/2020 16:00	0.0	0	0	0	0	1
08/12/2020 17:00	0.0	0	0	0	0	1
08/12/2020 18:00	0.0	0	0	0	0	1
08/12/2020 19:00	0.0	0	0	0	0	1
08/12/2020 20:00	0.0	0	0	0	0	1
08/12/2020 21:00	0.0	0	0	0	0	1
08/12/2020 22:00	0.0	0	0	0	0	1
08/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/13/2020 00:00	0.0	0	0	0	0	1
08/13/2020 01:00	0.0	0	0	0	0	1
08/13/2020 02:00	0.0	0	0	0	0	1
08/13/2020 03:00	0.0	0	0	0	0	1
08/13/2020 04:00	0.0	0	0	0	0	1
08/13/2020 05:00	0.0	0	0	0	0	1
08/13/2020 06:00	0.0	0	0	0	0	1
08/13/2020 07:00	0.0	0	0	0	0	1
08/13/2020 08:00	0.0	0	0	0	0	1
08/13/2020 09:00	0.0	0	0	0	0	1
08/13/2020 10:00	0.0	0	0	0	0	1
08/13/2020 11:00	0.0	0	0	0	0	1
08/13/2020 12:00	0.0	0	0	0	0	1
08/13/2020 13:00	0.0	0	0	0	0	1
08/13/2020 14:00	0.0	0	0	0	0	1
08/13/2020 15:00	0.0	0	0	0	0	1
08/13/2020 16:00	0.0	0	0	0	0	1
08/13/2020 17:00	0.0	0	0	0	0	1
08/13/2020 18:00	0.0	0	0	0	0	1
08/13/2020 19:00	0.0	0	0	0	0	1
08/13/2020 20:00	0.0	0	0	0	0	1
08/13/2020 21:00	0.0	0	0	0	0	1
08/13/2020 22:00	0.0	0	0	0	0	1
08/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/14/2020 00:00	0.0	0	0	0	0	1
08/14/2020 01:00	0.0	0	0	0	0	1
08/14/2020 02:00	0.0	0	0	0	0	1
08/14/2020 03:00	0.0	0	0	0	0	1
08/14/2020 04:00	0.0	0	0	0	0	1
08/14/2020 05:00	0.0	0	0	0	0	1
08/14/2020 06:00	0.0	0	0	0	0	1
08/14/2020 07:00	0.0	0	0	0	0	1
08/14/2020 08:00	0.0	0	0	0	0	1
08/14/2020 09:00	0.0	0	0	0	0	1
08/14/2020 10:00	0.0	0	0	0	0	1
08/14/2020 11:00	0.0	0	0	0	0	1
08/14/2020 12:00	0.0	0	0	0	0	1
08/14/2020 13:00	0.0	0	0	0	0	1
08/14/2020 14:00	0.0	0	0	0	0	1
08/14/2020 15:00	0.0	0	0	0	0	1
08/14/2020 16:00	0.0	0	0	0	0	1
08/14/2020 17:00	0.0	0	0	0	0	1
08/14/2020 18:00	0.0	0	0	0	0	1
08/14/2020 19:00	0.0	0	0	0	0	1
08/14/2020 20:00	0.0	0	0	0	0	1
08/14/2020 21:00	0.0	0	0	0	0	1
08/14/2020 22:00	0.0	0	0	0	0	1
08/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/15/2020 00:00	0.0	0	0	0	0	1
08/15/2020 01:00	0.0	0	0	0	0	1
08/15/2020 02:00	0.0	0	0	0	0	1
08/15/2020 03:00	0.0	0	0	0	0	1
08/15/2020 04:00	0.0	0	0	0	0	1
08/15/2020 05:00	0.0	0	0	0	0	1
08/15/2020 06:00	0.0	0	0	0	0	1
08/15/2020 07:00	0.0	0	0	0	0	1
08/15/2020 08:00	0.0	0	0	0	0	1
08/15/2020 09:00	0.0	0	0	0	0	1
08/15/2020 10:00	0.0	0	0	0	0	1
08/15/2020 11:00	0.0	0	0	0	0	1
08/15/2020 12:00	0.0	0	0	0	0	1
08/15/2020 13:00	0.0	0	0	0	0	1
08/15/2020 14:00	0.0	0	0	0	0	1
08/15/2020 15:00	0.0	0	0	0	0	1
08/15/2020 16:00	0.0	0	0	0	0	1
08/15/2020 17:00	0.0	0	0	0	0	1
08/15/2020 18:00	0.0	0	0	0	0	1
08/15/2020 19:00	0.0	0	0	0	0	1
08/15/2020 20:00	0.0	0	0	0	0	1
08/15/2020 21:00	0.0	0	0	0	0	1
08/15/2020 22:00	0.0	0	0	0	0	1
08/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/16/2020 00:00	0.0	0	0	0	0	1
08/16/2020 01:00	0.0	0	0	0	0	1
08/16/2020 02:00	0.0	0	0	0	0	1
08/16/2020 03:00	0.0	0	0	0	0	1
08/16/2020 04:00	0.0	0	0	0	0	1
08/16/2020 05:00	0.0	0	0	0	0	1
08/16/2020 06:00	0.0	0	0	0	0	1
08/16/2020 07:00	0.0	0	0	0	0	1
08/16/2020 08:00	0.0	0	0	0	0	1
08/16/2020 09:00	0.0	0	0	0	0	1
08/16/2020 10:00	0.0	0	0	0	0	1
08/16/2020 11:00	0.0	0	0	0	0	1
08/16/2020 12:00	0.0	0	0	0	0	1
08/16/2020 13:00	0.0	0	0	0	0	1
08/16/2020 14:00	0.0	0	0	0	0	1
08/16/2020 15:00	0.0	0	0	0	0	1
08/16/2020 16:00	0.0	0	0	0	0	1
08/16/2020 17:00	0.0	0	0	0	0	1
08/16/2020 18:00	0.0	0	0	0	0	1
08/16/2020 19:00	0.0	0	0	0	0	1
08/16/2020 20:00	0.0	0	0	0	0	1
08/16/2020 21:00	0.0	0	0	0	0	1
08/16/2020 22:00	0.0	0	0	0	0	1
08/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/17/2020 00:00	0.0	0	0	0	0	1
08/17/2020 01:00	0.0	0	0	0	0	1
08/17/2020 02:00	0.0	0	0	0	0	1
08/17/2020 03:00	0.0	0	0	0	0	1
08/17/2020 04:00	0.0	0	0	0	0	1
08/17/2020 05:00	0.0	0	0	0	0	1
08/17/2020 06:00	0.0	0	0	0	0	1
08/17/2020 07:00	0.0	0	0	0	0	1
08/17/2020 08:00	0.0	0	0	0	0	1
08/17/2020 09:00	0.0	0	0	0	0	1
08/17/2020 10:00	0.0	0	0	0	0	1
08/17/2020 11:00	0.0	0	0	0	0	1
08/17/2020 12:00	0.0	0	0	0	0	1
08/17/2020 13:00	0.0	0	0	0	0	1
08/17/2020 14:00	0.0	0	0	0	0	1
08/17/2020 15:00	0.0	0	0	0	0	1
08/17/2020 16:00	0.0	0	0	0	0	1
08/17/2020 17:00	0.0	0	0	0	0	1
08/17/2020 18:00	0.0	0	0	0	0	1
08/17/2020 19:00	0.0	0	0	0	0	1
08/17/2020 20:00	0.0	0	0	0	0	1
08/17/2020 21:00	0.0	0	0	0	0	1
08/17/2020 22:00	0.0	0	0	0	0	1
08/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/18/2020 00:00	0.0	0	0	0	0	1
08/18/2020 01:00	0.0	0	0	0	0	1
08/18/2020 02:00	0.0	0	0	0	0	1
08/18/2020 03:00	0.0	0	0	0	0	1
08/18/2020 04:00	0.0	0	0	0	0	1
08/18/2020 05:00	0.0	0	0	0	0	1
08/18/2020 06:00	0.0	0	0	0	0	1
08/18/2020 07:00	0.0	0	0	0	0	1
08/18/2020 08:00	0.0	0	0	0	0	1
08/18/2020 09:00	0.0	0	0	0	0	1
08/18/2020 10:00	0.0	0	0	0	0	1
08/18/2020 11:00	0.0	0	0	0	0	1
08/18/2020 12:00	0.0	0	0	0	0	1
08/18/2020 13:00	0.0	0	0	0	0	1
08/18/2020 14:00	0.0	0	0	0	0	1
08/18/2020 15:00	0.0	0	0	0	0	1
08/18/2020 16:00	0.0	0	0	0	0	1
08/18/2020 17:00	0.0	0	0	0	0	1
08/18/2020 18:00	0.0	0	0	0	0	1
08/18/2020 19:00	0.0	0	0	0	0	1
08/18/2020 20:00	0.0	0	0	0	0	1
08/18/2020 21:00	0.0	0	0	0	0	1
08/18/2020 22:00	0.0	0	0	0	0	1
08/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/19/2020 00:00	0.0	0	0	0	0	1
08/19/2020 01:00	0.0	0	0	0	0	1
08/19/2020 02:00	0.0	0	0	0	0	1
08/19/2020 03:00	0.0	0	0	0	0	1
08/19/2020 04:00	0.0	0	0	0	0	1
08/19/2020 05:00	0.0	0	0	0	0	1
08/19/2020 06:00	0.0	0	0	0	0	1
08/19/2020 07:00	0.0	0	0	0	0	1
08/19/2020 08:00	0.0	0	0	0	0	1
08/19/2020 09:00	0.0	0	0	0	0	1
08/19/2020 10:00	0.0	0	0	0	0	1
08/19/2020 11:00	0.0	0	0	0	0	1
08/19/2020 12:00	0.0	0	0	0	0	1
08/19/2020 13:00	0.0	0	0	0	0	1
08/19/2020 14:00	0.0	0	0	0	0	1
08/19/2020 15:00	0.0	0	0	0	0	1
08/19/2020 16:00	0.0	0	0	0	0	1
08/19/2020 17:00	0.0	0	0	0	0	1
08/19/2020 18:00	0.0	0	0	0	0	1
08/19/2020 19:00	0.0	0	0	0	0	1
08/19/2020 20:00	0.0	0	0	0	0	1
08/19/2020 21:00	0.0	0	0	0	0	1
08/19/2020 22:00	0.0	0	0	0	0	1
08/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/20/2020 00:00	0.0	0	0	0	0	1
08/20/2020 01:00	0.0	0	0	0	0	1
08/20/2020 02:00	0.0	0	0	0	0	1
08/20/2020 03:00	0.0	0	0	0	0	1
08/20/2020 04:00	0.0	0	0	0	0	1
08/20/2020 05:00	0.0	0	0	0	0	1
08/20/2020 06:00	0.0	0	0	0	0	1
08/20/2020 07:00	0.0	0	0	0	0	1
08/20/2020 08:00	0.0	0	0	0	0	1
08/20/2020 09:00	0.0	0	0	0	0	1
08/20/2020 10:00	0.0	0	0	0	0	1
08/20/2020 11:00	0.0	0	0	0	0	1
08/20/2020 12:00	0.0	0	0	0	0	1
08/20/2020 13:00	0.0	0	0	0	0	1
08/20/2020 14:00	0.0	0	0	0	0	1
08/20/2020 15:00	0.0	0	0	0	0	1
08/20/2020 16:00	0.0	0	0	0	0	1
08/20/2020 17:00	0.0	0	0	0	0	1
08/20/2020 18:00	0.0	0	0	0	0	1
08/20/2020 19:00	0.0	0	0	0	0	1
08/20/2020 20:00	0.0	0	0	0	0	1
08/20/2020 21:00	0.0	0	0	0	0	1
08/20/2020 22:00	0.0	0	0	0	0	1
08/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/21/2020 00:00	0.0	0	0	0	0	1
08/21/2020 01:00	0.0	0	0	0	0	1
08/21/2020 02:00	0.0	0	0	0	0	1
08/21/2020 03:00	0.0	0	0	0	0	1
08/21/2020 04:00	0.0	0	0	0	0	1
08/21/2020 05:00	0.0	0	0	0	0	1
08/21/2020 06:00	0.0	0	0	0	0	1
08/21/2020 07:00	0.0	0	0	0	0	1
08/21/2020 08:00	0.0	0	0	0	0	1
08/21/2020 09:00	0.0	0	0	0	0	1
08/21/2020 10:00	0.0	0	0	0	0	1
08/21/2020 11:00	0.0	0	0	0	0	1
08/21/2020 12:00	0.0	0	0	0	0	1
08/21/2020 13:00	0.0	0	0	0	0	1
08/21/2020 14:00	0.0	0	0	0	0	1
08/21/2020 15:00	0.0	0	0	0	0	1
08/21/2020 16:00	0.0	0	0	0	0	1
08/21/2020 17:00	0.0	0	0	0	0	1
08/21/2020 18:00	0.0	0	0	0	0	1
08/21/2020 19:00	0.0	0	0	0	0	1
08/21/2020 20:00	0.0	0	0	0	0	1
08/21/2020 21:00	0.0	0	0	0	0	1
08/21/2020 22:00	0.0	0	0	0	0	1
08/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/22/2020 00:00	0.0	0	0	0	0	1
08/22/2020 01:00	0.0	0	0	0	0	1
08/22/2020 02:00	0.0	0	0	0	0	1
08/22/2020 03:00	0.0	0	0	0	0	1
08/22/2020 04:00	0.0	0	0	0	0	1
08/22/2020 05:00	0.0	0	0	0	0	1
08/22/2020 06:00	0.0	0	0	0	0	1
08/22/2020 07:00	0.0	0	0	0	0	1
08/22/2020 08:00	0.0	0	0	0	0	1
08/22/2020 09:00	0.0	0	0	0	0	1
08/22/2020 10:00	0.0	0	0	0	0	1
08/22/2020 11:00	0.0	0	0	0	0	1
08/22/2020 12:00	0.0	0	0	0	0	1
08/22/2020 13:00	0.0	0	0	0	0	1
08/22/2020 14:00	0.0	0	0	0	0	1
08/22/2020 15:00	0.0	0	0	0	0	1
08/22/2020 16:00	0.0	0	0	0	0	1
08/22/2020 17:00	0.0	0	0	0	0	1
08/22/2020 18:00	0.0	0	0	0	0	1
08/22/2020 19:00	0.0	0	0	0	0	1
08/22/2020 20:00	0.0	0	0	0	0	1
08/22/2020 21:00	0.0	0	0	0	0	1
08/22/2020 22:00	0.0	0	0	0	0	1
08/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/23/2020 00:00	0.0	0	0	0	0	1
08/23/2020 01:00	0.0	0	0	0	0	1
08/23/2020 02:00	0.0	0	0	0	0	1
08/23/2020 03:00	0.0	0	0	0	0	1
08/23/2020 04:00	0.0	0	0	0	0	1
08/23/2020 05:00	0.0	0	0	0	0	1
08/23/2020 06:00	0.0	0	0	0	0	1
08/23/2020 07:00	0.0	0	0	0	0	1
08/23/2020 08:00	0.0	0	0	0	0	1
08/23/2020 09:00	0.0	0	0	0	0	1
08/23/2020 10:00	0.0	0	0	0	0	1
08/23/2020 11:00	0.0	0	0	0	0	1
08/23/2020 12:00	0.0	0	0	0	0	1
08/23/2020 13:00	0.0	0	0	0	0	1
08/23/2020 14:00	0.0	0	0	0	0	1
08/23/2020 15:00	0.0	0	0	0	0	1
08/23/2020 16:00	0.0	0	0	0	0	1
08/23/2020 17:00	0.0	0	0	0	0	1
08/23/2020 18:00	0.0	0	0	0	0	1
08/23/2020 19:00	0.0	0	0	0	0	1
08/23/2020 20:00	0.0	0	0	0	0	1
08/23/2020 21:00	0.0	0	0	0	0	1
08/23/2020 22:00	0.0	0	0	0	0	1
08/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/24/2020 00:00	0.0	0	0	0	0	1
08/24/2020 01:00	0.0	0	0	0	0	1
08/24/2020 02:00	0.0	0	0	0	0	1
08/24/2020 03:00	0.0	0	0	0	0	1
08/24/2020 04:00	0.0	0	0	0	0	1
08/24/2020 05:00	0.0	0	0	0	0	1
08/24/2020 06:00	0.0	0	0	0	0	1
08/24/2020 07:00	0.0	0	0	0	0	1
08/24/2020 08:00	0.0	0	0	0	0	1
08/24/2020 09:00	0.0	0	0	0	0	1
08/24/2020 10:00	0.0	0	0	0	0	1
08/24/2020 11:00	0.0	0	0	0	0	1
08/24/2020 12:00	0.0	0	0	0	0	1
08/24/2020 13:00	0.0	0	0	0	0	1
08/24/2020 14:00	0.0	0	0	0	0	1
08/24/2020 15:00	0.0	0	0	0	0	1
08/24/2020 16:00	0.0	0	0	0	0	1
08/24/2020 17:00	0.0	0	0	0	0	1
08/24/2020 18:00	0.0	0	0	0	0	1
08/24/2020 19:00	0.0	0	0	0	0	1
08/24/2020 20:00	0.0	0	0	0	0	1
08/24/2020 21:00	0.0	0	0	0	0	1
08/24/2020 22:00	0.0	0	0	0	0	1
08/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/25/2020 00:00	0.0	0	0	0	0	1
08/25/2020 01:00	0.0	0	0	0	0	1
08/25/2020 02:00	0.0	0	0	0	0	1
08/25/2020 03:00	0.0	0	0	0	0	1
08/25/2020 04:00	0.0	0	0	0	0	1
08/25/2020 05:00	0.0	0	0	0	0	1
08/25/2020 06:00	0.0	0	0	0	0	1
08/25/2020 07:00	0.0	0	0	0	0	1
08/25/2020 08:00	0.0	0	0	0	0	1
08/25/2020 09:00	0.0	0	0	0	0	1
08/25/2020 10:00	0.0	0	0	0	0	1
08/25/2020 11:00	0.0	0	0	0	0	1
08/25/2020 12:00	0.0	0	0	0	0	1
08/25/2020 13:00	0.0	0	0	0	0	1
08/25/2020 14:00	0.0	0	0	0	0	1
08/25/2020 15:00	0.0	0	0	0	0	1
08/25/2020 16:00	0.0	0	0	0	0	1
08/25/2020 17:00	0.0	0	0	0	0	1
08/25/2020 18:00	0.0	0	0	0	0	1
08/25/2020 19:00	0.0	0	0	0	0	1
08/25/2020 20:00	0.0	0	0	0	0	1
08/25/2020 21:00	0.0	0	0	0	0	1
08/25/2020 22:00	0.0	0	0	0	0	1
08/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/26/2020 00:00	0.0	0	0	0	0	1
08/26/2020 01:00	0.0	0	0	0	0	1
08/26/2020 02:00	0.0	0	0	0	0	1
08/26/2020 03:00	0.0	0	0	0	0	1
08/26/2020 04:00	0.0	0	0	0	0	1
08/26/2020 05:00	0.0	0	0	0	0	1
08/26/2020 06:00	0.0	0	0	0	0	1
08/26/2020 07:00	0.0	0	0	0	0	1
08/26/2020 08:00	0.0	0	0	0	0	1
08/26/2020 09:00	0.0	0	0	0	0	1
08/26/2020 10:00	0.0	0	0	0	0	1
08/26/2020 11:00	0.0	0	0	0	0	1
08/26/2020 12:00	0.0	0	0	0	0	1
08/26/2020 13:00	0.0	0	0	0	0	1
08/26/2020 14:00	0.0	0	0	0	0	1
08/26/2020 15:00	0.0	0	0	0	0	1
08/26/2020 16:00	0.0	0	0	0	0	1
08/26/2020 17:00	0.0	0	0	0	0	1
08/26/2020 18:00	0.0	0	0	0	0	1
08/26/2020 19:00	0.0	0	0	0	0	1
08/26/2020 20:00	0.0	0	0	0	0	1
08/26/2020 21:00	0.0	0	0	0	0	1
08/26/2020 22:00	0.0	0	0	0	0	1
08/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/27/2020 00:00	0.0	0	0	0	0	1
08/27/2020 01:00	0.0	0	0	0	0	1
08/27/2020 02:00	0.0	0	0	0	0	1
08/27/2020 03:00	0.0	0	0	0	0	1
08/27/2020 04:00	0.0	0	0	0	0	1
08/27/2020 05:00	0.0	0	0	0	0	1
08/27/2020 06:00	0.0	0	0	0	0	1
08/27/2020 07:00	0.0	0	0	0	0	1
08/27/2020 08:00	0.0	0	0	0	0	1
08/27/2020 09:00	0.0	0	0	0	0	1
08/27/2020 10:00	0.0	0	0	0	0	1
08/27/2020 11:00	0.0	0	0	0	0	1
08/27/2020 12:00	0.0	0	0	0	0	1
08/27/2020 13:00	0.0	0	0	0	0	1
08/27/2020 14:00	0.0	0	0	0	0	1
08/27/2020 15:00	0.0	0	0	0	0	1
08/27/2020 16:00	0.0	0	0	0	0	1
08/27/2020 17:00	0.0	0	0	0	0	1
08/27/2020 18:00	0.0	0	0	0	0	1
08/27/2020 19:00	0.0	0	0	0	0	1
08/27/2020 20:00	0.0	0	0	0	0	1
08/27/2020 21:00	0.0	0	0	0	0	1
08/27/2020 22:00	0.0	0	0	0	0	1
08/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/28/2020 00:00	0.0	0	0	0	0	1
08/28/2020 01:00	0.0	0	0	0	0	1
08/28/2020 02:00	0.0	0	0	0	0	1
08/28/2020 03:00	0.0	0	0	0	0	1
08/28/2020 04:00	0.0	0	0	0	0	1
08/28/2020 05:00	0.0	0	0	0	0	1
08/28/2020 06:00	0.0	0	0	0	0	1
08/28/2020 07:00	0.0	0	0	0	0	1
08/28/2020 08:00	0.0	0	0	0	0	1
08/28/2020 09:00	0.0	0	0	0	0	1
08/28/2020 10:00	0.0	0	0	0	0	1
08/28/2020 11:00	0.0	0	0	0	0	1
08/28/2020 12:00	0.0	0	0	0	0	1
08/28/2020 13:00	0.0	0	0	0	0	1
08/28/2020 14:00	0.0	0	0	0	0	1
08/28/2020 15:00	0.0	0	0	0	0	1
08/28/2020 16:00	0.0	0	0	0	0	1
08/28/2020 17:00	0.0	0	0	0	0	1
08/28/2020 18:00	0.0	0	0	0	0	1
08/28/2020 19:00	0.0	0	0	0	0	1
08/28/2020 20:00	0.0	0	0	0	0	1
08/28/2020 21:00	0.0	0	0	0	0	1
08/28/2020 22:00	0.0	0	0	0	0	1
08/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/29/2020 00:00	0.0	0	0	0	0	1
08/29/2020 01:00	0.0	0	0	0	0	1
08/29/2020 02:00	0.0	0	0	0	0	1
08/29/2020 03:00	0.0	0	0	0	0	1
08/29/2020 04:00	0.0	0	0	0	0	1
08/29/2020 05:00	0.0	0	0	0	0	1
08/29/2020 06:00	0.0	0	0	0	0	1
08/29/2020 07:00	0.0	0	0	0	0	1
08/29/2020 08:00	0.0	0	0	0	0	1
08/29/2020 09:00	0.0	0	0	0	0	1
08/29/2020 10:00	0.0	0	0	0	0	1
08/29/2020 11:00	0.0	0	0	0	0	1
08/29/2020 12:00	0.0	0	0	0	0	1
08/29/2020 13:00	0.0	0	0	0	0	1
08/29/2020 14:00	0.0	0	0	0	0	1
08/29/2020 15:00	0.0	0	0	0	0	1
08/29/2020 16:00	0.0	0	0	0	0	1
08/29/2020 17:00	0.0	0	0	0	0	1
08/29/2020 18:00	0.0	0	0	0	0	1
08/29/2020 19:00	0.0	0	0	0	0	1
08/29/2020 20:00	0.0	0	0	0	0	1
08/29/2020 21:00	0.0	0	0	0	0	1
08/29/2020 22:00	0.0	0	0	0	0	1
08/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/30/2020 00:00	0.0	0	0	0	0	1
08/30/2020 01:00	0.0	0	0	0	0	1
08/30/2020 02:00	0.0	0	0	0	0	1
08/30/2020 03:00	0.0	0	0	0	0	1
08/30/2020 04:00	0.0	0	0	0	0	1
08/30/2020 05:00	0.0	0	0	0	0	1
08/30/2020 06:00	0.0	0	0	0	0	1
08/30/2020 07:00	0.0	0	0	0	0	1
08/30/2020 08:00	0.0	0	0	0	0	1
08/30/2020 09:00	0.0	0	0	0	0	1
08/30/2020 10:00	0.0	0	0	0	0	1
08/30/2020 11:00	0.0	0	0	0	0	1
08/30/2020 12:00	0.0	0	0	0	0	1
08/30/2020 13:00	0.0	0	0	0	0	1
08/30/2020 14:00	0.0	0	0	0	0	1
08/30/2020 15:00	0.0	0	0	0	0	1
08/30/2020 16:00	0.0	0	0	0	0	1
08/30/2020 17:00	0.0	0	0	0	0	1
08/30/2020 18:00	0.0	0	0	0	0	1
08/30/2020 19:00	0.0	0	0	0	0	1
08/30/2020 20:00	0.0	0	0	0	0	1
08/30/2020 21:00	0.0	0	0	0	0	1
08/30/2020 22:00	0.0	0	0	0	0	1
08/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/31/2020 00:00	0.0	0	0	0	0	1
08/31/2020 01:00	0.0	0	0	0	0	1
08/31/2020 02:00	0.0	0	0	0	0	1
08/31/2020 03:00	0.0	0	0	0	0	1
08/31/2020 04:00	0.0	0	0	0	0	1
08/31/2020 05:00	0.0	0	0	0	0	1
08/31/2020 06:00	0.0	0	0	0	0	1
08/31/2020 07:00	0.0	0	0	0	0	1
08/31/2020 08:00	0.0	0	0	0	0	1
08/31/2020 09:00	0.0	0	0	0	0	1
08/31/2020 10:00	0.0	0	0	0	0	1
08/31/2020 11:00	0.0	0	0	0	0	1
08/31/2020 12:00	0.0	0	0	0	0	1
08/31/2020 13:00	0.0	0	0	0	0	1
08/31/2020 14:00	0.0	0	0	0	0	1
08/31/2020 15:00	0.0	0	0	0	0	1
08/31/2020 16:00	0.0	0	0	0	0	1
08/31/2020 17:00	0.0	0	0	0	0	1
08/31/2020 18:00	0.0	0	0	0	0	1
08/31/2020 19:00	0.0	0	0	0	0	1
08/31/2020 20:00	0.0	0	0	0	0	1
08/31/2020 21:00	0.0	0	0	0	0	1
08/31/2020 22:00	0.0	0	0	0	0	1
08/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/01/2020 00:00	0.0	0	0	0	0	1
09/01/2020 01:00	0.0	0	0	0	0	1
09/01/2020 02:00	0.0	0	0	0	0	1
09/01/2020 03:00	0.0	0	0	0	0	1
09/01/2020 04:00	0.0	0	0	0	0	1
09/01/2020 05:00	0.0	0	0	0	0	1
09/01/2020 06:00	0.0	0	0	0	0	1
09/01/2020 07:00	0.0	0	0	0	0	1
09/01/2020 08:00	0.0	0	0	0	0	1
09/01/2020 09:00	0.0	0	0	0	0	1
09/01/2020 10:00	0.0	0	0	0	0	1
09/01/2020 11:00	0.0	0	0	0	0	1
09/01/2020 12:00	0.0	0	0	0	0	1
09/01/2020 13:00	0.0	0	0	0	0	1
09/01/2020 14:00	0.0	0	0	0	0	1
09/01/2020 15:00	0.0	0	0	0	0	1
09/01/2020 16:00	0.0	0	0	0	0	1
09/01/2020 17:00	0.0	0	0	0	0	1
09/01/2020 18:00	0.0	0	0	0	0	1
09/01/2020 19:00	0.0	0	0	0	0	1
09/01/2020 20:00	0.0	0	0	0	0	1
09/01/2020 21:00	0.0	0	0	0	0	1
09/01/2020 22:00	0.0	0	0	0	0	1
09/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/02/2020 00:00	0.0	0	0	0	0	1
09/02/2020 01:00	0.0	0	0	0	0	1
09/02/2020 02:00	0.0	0	0	0	0	1
09/02/2020 03:00	0.0	0	0	0	0	1
09/02/2020 04:00	0.0	0	0	0	0	1
09/02/2020 05:00	0.0	0	0	0	0	1
09/02/2020 06:00	0.0	0	0	0	0	1
09/02/2020 07:00	1.4	0	0	0	1	0
09/02/2020 08:00	0.0	0	0	0	0	0
09/02/2020 09:00	0.0	0	0	0	0	0
09/02/2020 10:00	0.0	0	0	0	0	0
09/02/2020 11:00	0.0	0	0	0	0	0
09/02/2020 12:00	0.0	0	0	0	0	0
09/02/2020 13:00	0.0	0	0	0	0	0
09/02/2020 14:00	0.0	0	0	0	0	0
09/02/2020 15:00	0.0	0	0	0	0	0
09/02/2020 16:00	0.0	0	0	0	0	0
09/02/2020 17:00	0.0	0	0	0	0	0
09/02/2020 18:00	0.0	0	0	0	0	0
09/02/2020 19:00	0.0	0	0	0	0	0
09/02/2020 20:00	0.0	0	0	0	0	0
09/02/2020 21:00	0.0	0	0	0	0	0
09/02/2020 22:00	0.0	0	0	0	0	0
09/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.4 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/03/2020 00:00	0.0	0	0	0	0	0
09/03/2020 01:00	0.0	0	0	0	0	0
09/03/2020 02:00	0.0	0	0	0	0	0
09/03/2020 03:00	32.7	0	1	0	0	0
09/03/2020 04:00	22.6	0	1	0	0	0
09/03/2020 05:00	0.0	0	0	0	0	1
09/03/2020 06:00	0.0	0	0	0	0	1
09/03/2020 07:00	0.0	0	0	0	0	1
09/03/2020 08:00	0.0	0	0	0	0	1
09/03/2020 09:00	0.0	0	0	0	0	1
09/03/2020 10:00	0.0	0	0	0	0	1
09/03/2020 11:00	0.0	0	0	0	0	1
09/03/2020 12:00	0.0	0	0	0	0	1
09/03/2020 13:00	0.0	0	0	0	0	1
09/03/2020 14:00	0.0	0	0	0	0	1
09/03/2020 15:00	0.0	0	0	0	0	1
09/03/2020 16:00	0.0	0	0	0	0	1
09/03/2020 17:00	0.0	0	0	0	0	1
09/03/2020 18:00	0.0	0	0	0	0	1
09/03/2020 19:00	0.0	0	0	0	0	1
09/03/2020 20:00	0.0	0	0	0	0	1
09/03/2020 21:00	0.0	0	0	0	0	1
09/03/2020 22:00	0.0	0	0	0	0	1
09/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	55.3 #	0 #	2 #	0 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	32.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/04/2020 00:00	0.0	0	0	0	0	1
09/04/2020 01:00	0.0	0	0	0	0	1
09/04/2020 02:00	0.0	0	0	0	0	1
09/04/2020 03:00	0.0	0	0	0	0	1
09/04/2020 04:00	0.0	0	0	0	0	1
09/04/2020 05:00	0.0	0	0	0	0	1
09/04/2020 06:00	0.0	0	0	0	0	1
09/04/2020 07:00	0.0	0	0	0	0	1
09/04/2020 08:00	0.0	0	0	0	0	1
09/04/2020 09:00	0.0	0	0	0	0	1
09/04/2020 10:00	0.0	0	0	0	0	1
09/04/2020 11:00	0.0	0	0	0	0	1
09/04/2020 12:00	0.0	0	0	0	0	1
09/04/2020 13:00	0.0	0	0	0	0	1
09/04/2020 14:00	0.0	0	0	0	0	1
09/04/2020 15:00	0.0	0	0	0	0	1
09/04/2020 16:00	0.0	0	0	0	0	1
09/04/2020 17:00	0.0	0	0	0	0	1
09/04/2020 18:00	0.0	0	0	0	0	1
09/04/2020 19:00	0.0	0	0	0	0	1
09/04/2020 20:00	0.0	0	0	0	0	1
09/04/2020 21:00	0.0	0	0	0	0	1
09/04/2020 22:00	0.0	0	0	0	0	1
09/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/05/2020 00:00	0.0	0	0	0	0	1
09/05/2020 01:00	0.0	0	0	0	0	1
09/05/2020 02:00	0.0	0	0	0	0	1
09/05/2020 03:00	0.0	0	0	0	0	1
09/05/2020 04:00	0.0	0	0	0	0	1
09/05/2020 05:00	0.0	0	0	0	0	1
09/05/2020 06:00	0.0	0	0	0	0	1
09/05/2020 07:00	0.0	0	0	0	0	1
09/05/2020 08:00	0.0	0	0	0	0	1
09/05/2020 09:00	0.0	0	0	0	0	1
09/05/2020 10:00	0.0	0	0	0	0	1
09/05/2020 11:00	0.0	0	0	0	0	1
09/05/2020 12:00	0.0	0	0	0	0	1
09/05/2020 13:00	0.0	0	0	0	0	1
09/05/2020 14:00	0.0	0	0	0	0	1
09/05/2020 15:00	0.0	0	0	0	0	1
09/05/2020 16:00	0.0	0	0	0	0	1
09/05/2020 17:00	0.0	0	0	0	0	1
09/05/2020 18:00	0.0	0	0	0	0	1
09/05/2020 19:00	0.0	0	0	0	0	1
09/05/2020 20:00	0.0	0	0	0	0	1
09/05/2020 21:00	0.0	0	0	0	0	1
09/05/2020 22:00	0.0	0	0	0	0	1
09/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/06/2020 00:00	0.0	0	0	0	0	1
09/06/2020 01:00	0.0	0	0	0	0	1
09/06/2020 02:00	0.0	0	0	0	0	1
09/06/2020 03:00	0.0	0	0	0	0	1
09/06/2020 04:00	0.0	0	0	0	0	1
09/06/2020 05:00	0.0	0	0	0	0	1
09/06/2020 06:00	0.0	0	0	0	0	1
09/06/2020 07:00	0.0	0	0	0	0	1
09/06/2020 08:00	0.0	0	0	0	0	1
09/06/2020 09:00	0.0	0	0	0	0	1
09/06/2020 10:00	0.0	0	0	0	0	1
09/06/2020 11:00	0.0	0	0	0	0	1
09/06/2020 12:00	0.0	0	0	0	0	1
09/06/2020 13:00	0.0	0	0	0	0	1
09/06/2020 14:00	0.0	0	0	0	0	1
09/06/2020 15:00	0.0	0	0	0	0	1
09/06/2020 16:00	0.0	0	0	0	0	1
09/06/2020 17:00	0.0	0	0	0	0	1
09/06/2020 18:00	0.0	0	0	0	0	1
09/06/2020 19:00	0.0	0	0	0	0	1
09/06/2020 20:00	0.0	0	0	0	0	1
09/06/2020 21:00	0.0	0	0	0	0	1
09/06/2020 22:00	0.0	0	0	0	0	1
09/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/07/2020 00:00	0.0	0	0	0	0	1
09/07/2020 01:00	0.0	0	0	0	0	1
09/07/2020 02:00	0.0	0	0	0	0	1
09/07/2020 03:00	0.0	0	0	0	0	1
09/07/2020 04:00	0.0	0	0	0	0	1
09/07/2020 05:00	0.0	0	0	0	0	1
09/07/2020 06:00	0.0	0	0	0	0	1
09/07/2020 07:00	0.0	0	0	0	0	1
09/07/2020 08:00	0.0	0	0	0	0	1
09/07/2020 09:00	0.0	0	0	0	0	1
09/07/2020 10:00	0.0	0	0	0	0	1
09/07/2020 11:00	0.0	0	0	0	0	1
09/07/2020 12:00	0.0	0	0	0	0	1
09/07/2020 13:00	0.0	0	0	0	0	1
09/07/2020 14:00	0.0	0	0	0	0	1
09/07/2020 15:00	0.0	0	0	0	0	1
09/07/2020 16:00	0.0	0	0	0	0	1
09/07/2020 17:00	0.0	0	0	0	0	1
09/07/2020 18:00	0.0	0	0	0	0	1
09/07/2020 19:00	0.0	0	0	0	0	1
09/07/2020 20:00	0.0	0	0	0	0	1
09/07/2020 21:00	0.0	0	0	0	0	1
09/07/2020 22:00	0.0	0	0	0	0	1
09/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/08/2020 00:00	0.0	0	0	0	0	1
09/08/2020 01:00	0.0	0	0	0	0	1
09/08/2020 02:00	0.0	0	0	0	0	1
09/08/2020 03:00	0.0	0	0	0	0	1
09/08/2020 04:00	0.0	0	0	0	0	1
09/08/2020 05:00	0.0	0	0	0	0	1
09/08/2020 06:00	0.0	0	0	0	0	1
09/08/2020 07:00	0.0	0	0	0	0	1
09/08/2020 08:00	0.0	0	0	0	0	1
09/08/2020 09:00	0.0	0	0	0	0	1
09/08/2020 10:00	0.0	0	0	0	0	1
09/08/2020 11:00	0.0	0	0	0	0	1
09/08/2020 12:00	0.0	0	0	0	0	1
09/08/2020 13:00	0.0	0	0	0	0	1
09/08/2020 14:00	0.0	0	0	0	0	1
09/08/2020 15:00	0.0	0	0	0	0	1
09/08/2020 16:00	0.0	0	0	0	0	1
09/08/2020 17:00	0.0	0	0	0	0	1
09/08/2020 18:00	0.0	0	0	0	0	1
09/08/2020 19:00	0.0	0	0	0	0	1
09/08/2020 20:00	0.0	0	0	0	0	1
09/08/2020 21:00	0.0	0	0	0	0	1
09/08/2020 22:00	0.0	0	0	0	0	1
09/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/09/2020 00:00	0.0	0	0	0	0	1
09/09/2020 01:00	0.0	0	0	0	0	1
09/09/2020 02:00	0.0	0	0	0	0	1
09/09/2020 03:00	0.0	0	0	0	0	1
09/09/2020 04:00	0.0	0	0	0	0	1
09/09/2020 05:00	0.0	0	0	0	0	1
09/09/2020 06:00	0.0	0	0	0	0	1
09/09/2020 07:00	0.0	0	0	0	0	1
09/09/2020 08:00	0.0	0	0	0	0	1
09/09/2020 09:00	0.0	0	0	0	0	1
09/09/2020 10:00	0.0	0	0	0	0	1
09/09/2020 11:00	0.0	0	0	0	0	1
09/09/2020 12:00	0.0	0	0	0	0	1
09/09/2020 13:00	0.0	0	0	0	0	1
09/09/2020 14:00	0.0	0	0	0	0	1
09/09/2020 15:00	0.0	0	0	0	0	1
09/09/2020 16:00	0.0	0	0	0	0	1
09/09/2020 17:00	0.0	0	0	0	0	1
09/09/2020 18:00	0.0	0	0	0	0	1
09/09/2020 19:00	0.0	0	0	0	0	1
09/09/2020 20:00	0.0	0	0	0	0	1
09/09/2020 21:00	0.0	0	0	0	0	1
09/09/2020 22:00	0.0	0	0	0	0	1
09/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/10/2020 00:00	0.0	0	0	0	0	1
09/10/2020 01:00	0.0	0	0	0	0	1
09/10/2020 02:00	0.0	0	0	0	0	1
09/10/2020 03:00	0.0	0	0	0	0	1
09/10/2020 04:00	0.0	0	0	0	0	1
09/10/2020 05:00	0.0	0	0	0	0	1
09/10/2020 06:00	0.0	0	0	0	0	1
09/10/2020 07:00	0.0	0	0	0	0	1
09/10/2020 08:00	0.0	0	0	0	0	1
09/10/2020 09:00	0.0	0	0	0	0	1
09/10/2020 10:00	0.0	0	0	0	0	1
09/10/2020 11:00	0.0	0	0	0	0	1
09/10/2020 12:00	0.0	0	0	0	0	1
09/10/2020 13:00	0.0	0	0	0	0	1
09/10/2020 14:00	0.0	0	0	0	0	1
09/10/2020 15:00	0.0	0	0	0	0	1
09/10/2020 16:00	0.0	0	0	0	0	1
09/10/2020 17:00	0.0	0	0	0	0	1
09/10/2020 18:00	0.0	0	0	0	0	1
09/10/2020 19:00	0.0	0	0	0	0	1
09/10/2020 20:00	0.0	0	0	0	0	1
09/10/2020 21:00	0.0	0	0	0	0	1
09/10/2020 22:00	0.0	0	0	0	0	1
09/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/11/2020 00:00	0.0	0	0	0	0	1
09/11/2020 01:00	0.0	0	0	0	0	1
09/11/2020 02:00	0.0	0	0	0	0	1
09/11/2020 03:00	0.0	0	0	0	0	1
09/11/2020 04:00	0.0	0	0	0	0	1
09/11/2020 05:00	0.0	0	0	0	0	1
09/11/2020 06:00	0.0	0	0	0	0	1
09/11/2020 07:00	0.0	0	0	0	0	1
09/11/2020 08:00	0.0	0	0	0	0	1
09/11/2020 09:00	0.0	0	0	0	0	1
09/11/2020 10:00	0.0	0	0	0	0	1
09/11/2020 11:00	0.0	0	0	0	0	1
09/11/2020 12:00	0.0	0	0	0	0	1
09/11/2020 13:00	0.0	0	0	0	0	1
09/11/2020 14:00	0.0	0	0	0	0	1
09/11/2020 15:00	0.0	0	0	0	0	1
09/11/2020 16:00	0.0	0	0	0	0	1
09/11/2020 17:00	0.0	0	0	0	0	1
09/11/2020 18:00	0.0	0	0	0	0	1
09/11/2020 19:00	0.0	0	0	0	0	1
09/11/2020 20:00	0.0	0	0	0	0	1
09/11/2020 21:00	0.0	0	0	0	0	1
09/11/2020 22:00	0.0	0	0	0	0	1
09/11/2020 23:00	1.6	0	0	0	1	0
Average/Sum#:	1.6 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:37 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/12/2020 00:00	0.0	0	0	0	0	0
09/12/2020 01:00	0.0	0	0	0	0	0
09/12/2020 02:00	0.0	0	0	0	0	0
09/12/2020 03:00	0.0	0	0	0	0	0
09/12/2020 04:00	0.0	0	0	0	0	0
09/12/2020 05:00	0.0	0	0	0	0	0
09/12/2020 06:00	0.0	0	0	0	0	0
09/12/2020 07:00	0.0	0	0	0	0	0
09/12/2020 08:00	0.0	0	0	0	0	0
09/12/2020 09:00	0.0	0	0	0	0	0
09/12/2020 10:00	0.0	0	0	0	0	0
09/12/2020 11:00	0.0	0	0	0	0	0
09/12/2020 12:00	0.0	0	0	0	0	0
09/12/2020 13:00	0.0	0	0	0	0	0
09/12/2020 14:00	0.0	0	0	0	0	0
09/12/2020 15:00	0.0	0	0	0	0	0
09/12/2020 16:00	0.0	0	0	0	0	0
09/12/2020 17:00	21.6	0	1	0	0	0
09/12/2020 18:00	18.7	0	1	0	0	0
09/12/2020 19:00	20.4	0	1	0	0	0
09/12/2020 20:00	0.0	0	0	0	0	1
09/12/2020 21:00	0.0	0	0	0	0	1
09/12/2020 22:00	0.0	0	0	0	0	1
09/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	60.7 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	21.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/13/2020 00:00	0.0	0	0	0	0	1
09/13/2020 01:00	0.0	0	0	0	0	1
09/13/2020 02:00	1.7	0	0	0	1	0
09/13/2020 03:00	0.0	0	0	0	0	0
09/13/2020 04:00	0.0	0	0	0	0	0
09/13/2020 05:00	0.0	0	0	0	0	0
09/13/2020 06:00	0.0	0	0	0	0	0
09/13/2020 07:00	0.0	0	0	0	0	0
09/13/2020 08:00	0.0	0	0	0	0	0
09/13/2020 09:00	0.0	0	0	0	0	0
09/13/2020 10:00	0.0	0	0	0	0	0
09/13/2020 11:00	0.0	0	0	0	0	0
09/13/2020 12:00	0.0	0	0	0	0	0
09/13/2020 13:00	0.0	0	0	0	0	0
09/13/2020 14:00	0.0	0	0	0	0	0
09/13/2020 15:00	0.0	0	0	0	0	0
09/13/2020 16:00	0.0	0	0	0	0	0
09/13/2020 17:00	36.0	0	1	0	0	0
09/13/2020 18:00	20.0	0	1	0	0	0
09/13/2020 19:00	22.7	0	1	0	0	0
09/13/2020 20:00	0.0	0	0	0	0	1
09/13/2020 21:00	0.0	0	0	0	0	1
09/13/2020 22:00	0.0	0	0	0	0	1
09/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	80.4 #	0 #	3 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	36.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/14/2020 00:00	0.0	0	0	0	0	1
09/14/2020 01:00	0.0	0	0	0	0	1
09/14/2020 02:00	2.1	0	0	0	1	0
09/14/2020 03:00	0.0	0	0	0	0	0
09/14/2020 04:00	0.0	0	0	0	0	0
09/14/2020 05:00	0.0	0	0	0	0	0
09/14/2020 06:00	0.0	0	0	0	0	0
09/14/2020 07:00	0.0	0	0	0	0	0
09/14/2020 08:00	0.0	0	0	0	0	0
09/14/2020 09:00	1.2	0	0	1	0	0
09/14/2020 10:00	44.1	0	0	1	0	0
09/14/2020 11:00	1.5	0	0	1	0	0
09/14/2020 12:00	0.0	0	0	0	0	1
09/14/2020 13:00	0.0	0	0	0	0	1
09/14/2020 14:00	0.0	0	0	0	0	1
09/14/2020 15:00	0.0	0	0	0	0	1
09/14/2020 16:00	0.0	0	0	0	0	1
09/14/2020 17:00	0.0	0	0	0	0	1
09/14/2020 18:00	0.0	0	0	0	0	1
09/14/2020 19:00	0.0	0	0	0	0	1
09/14/2020 20:00	0.0	0	0	0	0	1
09/14/2020 21:00	0.0	0	0	0	0	1
09/14/2020 22:00	0.0	0	0	0	0	1
09/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	48.9 #	0 #	0 #	3 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	44.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/15/2020 00:00	0.0	0	0	0	0	1
09/15/2020 01:00	0.0	0	0	0	0	1
09/15/2020 02:00	0.0	0	0	0	0	1
09/15/2020 03:00	0.0	0	0	0	0	1
09/15/2020 04:00	0.0	0	0	0	0	1
09/15/2020 05:00	0.0	0	0	0	0	1
09/15/2020 06:00	0.0	0	0	0	0	1
09/15/2020 07:00	0.0	0	0	0	0	1
09/15/2020 08:00	0.0	0	0	0	0	1
09/15/2020 09:00	0.0	0	0	0	0	1
09/15/2020 10:00	0.0	0	0	0	0	1
09/15/2020 11:00	0.0	0	0	0	0	1
09/15/2020 12:00	0.0	0	0	0	0	1
09/15/2020 13:00	0.0	0	0	0	0	1
09/15/2020 14:00	0.0	0	0	0	0	1
09/15/2020 15:00	0.0	0	0	0	0	1
09/15/2020 16:00	0.0	0	0	0	0	1
09/15/2020 17:00	0.0	0	0	0	0	1
09/15/2020 18:00	0.0	0	0	0	0	1
09/15/2020 19:00	0.0	0	0	0	0	1
09/15/2020 20:00	0.0	0	0	0	0	1
09/15/2020 21:00	0.0	0	0	0	0	1
09/15/2020 22:00	1.1	0	0	0	1	0
09/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.1 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/16/2020 00:00	0.0	0	0	0	0	0
09/16/2020 01:00	0.0	0	0	0	0	0
09/16/2020 02:00	0.0	0	0	0	0	0
09/16/2020 03:00	0.0	0	0	0	0	0
09/16/2020 04:00	0.0	0	0	0	0	0
09/16/2020 05:00	0.0	0	0	0	0	0
09/16/2020 06:00	0.0	0	0	0	0	0
09/16/2020 07:00	0.0	0	0	0	0	0
09/16/2020 08:00	0.0	0	0	0	0	0
09/16/2020 09:00	0.0	0	0	0	0	0
09/16/2020 10:00	0.0	0	0	0	0	0
09/16/2020 11:00	19.2	0	1	0	0	0
09/16/2020 12:00	11.3	0	1	0	0	0
09/16/2020 13:00	0.0	0	0	0	0	1
09/16/2020 14:00	0.0	0	0	0	0	1
09/16/2020 15:00	0.0	0	0	0	0	1
09/16/2020 16:00	0.0	0	0	0	0	1
09/16/2020 17:00	0.0	0	0	0	0	1
09/16/2020 18:00	0.0	0	0	0	0	1
09/16/2020 19:00	0.0	0	0	0	0	1
09/16/2020 20:00	0.0	0	0	0	0	1
09/16/2020 21:00	0.0	0	0	0	0	1
09/16/2020 22:00	0.0	0	0	0	0	1
09/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	30.5 #	0 #	2 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	19.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/17/2020 00:00	0.0	0	0	0	0	1
09/17/2020 01:00	0.0	0	0	0	0	1
09/17/2020 02:00	0.0	0	0	0	0	1
09/17/2020 03:00	0.0	0	0	0	0	1
09/17/2020 04:00	0.0	0	0	0	0	1
09/17/2020 05:00	0.0	0	0	0	0	1
09/17/2020 06:00	0.0	0	0	0	0	1
09/17/2020 07:00	0.0	0	0	0	0	1
09/17/2020 08:00	0.0	0	0	0	0	1
09/17/2020 09:00	0.0	0	0	0	0	1
09/17/2020 10:00	0.0	0	0	0	0	1
09/17/2020 11:00	0.0	0	0	0	0	1
09/17/2020 12:00	0.0	0	0	0	0	1
09/17/2020 13:00	0.0	0	0	0	0	1
09/17/2020 14:00	0.0	0	0	0	0	1
09/17/2020 15:00	0.0	0	0	0	0	1
09/17/2020 16:00	0.0	0	0	0	0	1
09/17/2020 17:00	0.0	0	0	0	0	1
09/17/2020 18:00	0.0	0	0	0	0	1
09/17/2020 19:00	0.0	0	0	0	0	1
09/17/2020 20:00	0.0	0	0	0	0	1
09/17/2020 21:00	0.0	0	0	0	0	1
09/17/2020 22:00	0.0	0	0	0	0	1
09/17/2020 23:00	0.3	0	0	0	1	0
Average/Sum#:	0.3 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/18/2020 00:00	0.0	0	0	0	1	0
09/18/2020 01:00	0.0	0	0	0	0	0
09/18/2020 02:00	0.0	0	0	0	0	0
09/18/2020 03:00	0.0	0	0	0	0	0
09/18/2020 04:00	0.0	0	0	0	0	0
09/18/2020 05:00	0.0	0	0	0	0	0
09/18/2020 06:00	0.0	0	0	0	0	0
09/18/2020 07:00	0.0	0	0	0	0	0
09/18/2020 08:00	0.0	0	0	0	0	0
09/18/2020 09:00	0.0	0	0	0	0	0
09/18/2020 10:00	5.9	0	1	0	0	0
09/18/2020 11:00	32.3	0	1	0	0	0
09/18/2020 12:00	0.0	0	0	0	0	1
09/18/2020 13:00	0.0	0	0	0	0	1
09/18/2020 14:00	0.0	0	0	0	0	1
09/18/2020 15:00	0.0	0	0	0	0	1
09/18/2020 16:00	0.0	0	0	0	0	1
09/18/2020 17:00	0.0	0	0	0	0	1
09/18/2020 18:00	0.0	0	0	0	0	1
09/18/2020 19:00	0.0	0	0	0	0	1
09/18/2020 20:00	0.0	0	0	0	0	1
09/18/2020 21:00	0.0	0	0	0	0	1
09/18/2020 22:00	1.0	0	0	0	1	0
09/18/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	39.2 #	0 #	2 #	0 #	2 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	32.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:37 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/19/2020 00:00	0.0	0	0	0	0	0
09/19/2020 01:00	0.0	0	0	0	0	0
09/19/2020 02:00	0.0	0	0	0	0	0
09/19/2020 03:00	0.0	0	0	0	0	0
09/19/2020 04:00	0.0	0	0	0	0	0
09/19/2020 05:00	0.0	0	0	0	0	0
09/19/2020 06:00	0.0	0	0	0	0	0
09/19/2020 07:00	0.0	0	0	0	0	0
09/19/2020 08:00	0.0	0	0	0	0	0
09/19/2020 09:00	0.0	0	0	0	0	0
09/19/2020 10:00	0.0	0	0	0	0	0
09/19/2020 11:00	0.0	0	0	0	0	0
09/19/2020 12:00	0.0	0	0	0	0	0
09/19/2020 13:00	14.2	0	1	0	0	0
09/19/2020 14:00	24.8	0	1	0	0	0
09/19/2020 15:00	0.0	0	0	0	0	1
09/19/2020 16:00	0.0	0	0	0	0	1
09/19/2020 17:00	0.0	0	0	0	0	1
09/19/2020 18:00	0.0	0	0	0	0	1
09/19/2020 19:00	0.0	0	0	0	0	1
09/19/2020 20:00	0.0	0	0	0	0	1
09/19/2020 21:00	0.0	0	0	0	0	1
09/19/2020 22:00	0.0	0	0	0	0	1
09/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	39.0 #	0 #	2 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	24.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/20/2020 00:00	0.0	0	0	0	0	1
09/20/2020 01:00	0.0	0	0	0	0	1
09/20/2020 02:00	0.0	0	0	0	0	1
09/20/2020 03:00	0.0	0	0	0	0	1
09/20/2020 04:00	0.0	0	0	0	0	1
09/20/2020 05:00	0.0	0	0	0	0	1
09/20/2020 06:00	0.0	0	0	0	1	0
09/20/2020 07:00	0.0	0	0	0	0	0
09/20/2020 08:00	0.0	0	0	0	0	0
09/20/2020 09:00	0.0	0	0	0	0	0
09/20/2020 10:00	0.0	0	0	0	0	0
09/20/2020 11:00	0.0	0	0	0	0	0
09/20/2020 12:00	0.0	0	0	0	0	0
09/20/2020 13:00	0.0	0	0	0	0	0
09/20/2020 14:00	11.3	0	1	0	0	0
09/20/2020 15:00	20.6	0	1	0	0	0
09/20/2020 16:00	0.0	0	0	0	0	1
09/20/2020 17:00	0.0	0	0	0	0	1
09/20/2020 18:00	0.0	0	0	0	0	1
09/20/2020 19:00	0.0	0	0	0	0	1
09/20/2020 20:00	0.0	0	0	0	0	1
09/20/2020 21:00	0.0	0	0	0	0	1
09/20/2020 22:00	1.7	0	0	0	1	0
09/20/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	33.6 #	0 #	2 #	0 #	2 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	20.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/21/2020 00:00	0.0	0	0	0	0	0
09/21/2020 01:00	0.0	0	0	0	0	0
09/21/2020 02:00	0.0	0	0	0	0	0
09/21/2020 03:00	0.0	0	0	0	0	0
09/21/2020 04:00	0.0	0	0	0	0	0
09/21/2020 05:00	0.0	0	0	0	0	0
09/21/2020 06:00	0.0	0	0	0	0	0
09/21/2020 07:00	0.0	0	0	0	0	0
09/21/2020 08:00	10.3	0	1	0	0	0
09/21/2020 09:00	21.4	0	1	0	0	0
09/21/2020 10:00	24.6	0	1	0	0	0
09/21/2020 11:00	0.0	0	0	0	0	1
09/21/2020 12:00	0.0	0	0	0	0	1
09/21/2020 13:00	0.0	0	0	0	0	1
09/21/2020 14:00	0.0	0	0	0	0	1
09/21/2020 15:00	0.0	0	0	0	0	1
09/21/2020 16:00	0.0	0	0	0	0	1
09/21/2020 17:00	0.0	0	0	0	0	1
09/21/2020 18:00	0.0	0	0	0	0	1
09/21/2020 19:00	0.0	0	0	0	0	1
09/21/2020 20:00	0.0	0	0	0	0	1
09/21/2020 21:00	0.0	0	0	0	0	1
09/21/2020 22:00	1.6	0	0	0	1	0
09/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	57.9 #	0 #	3 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	24.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/22/2020 00:00	0.0	0	0	0	0	0
09/22/2020 01:00	0.0	0	0	0	0	0
09/22/2020 02:00	0.0	0	0	0	0	0
09/22/2020 03:00	0.0	0	0	0	0	0
09/22/2020 04:00	0.0	0	0	0	0	0
09/22/2020 05:00	0.0	0	0	0	0	0
09/22/2020 06:00	0.0	0	0	0	0	0
09/22/2020 07:00	0.0	0	0	0	0	0
09/22/2020 08:00	10.1	0	1	0	0	0
09/22/2020 09:00	24.7	0	1	0	0	0
09/22/2020 10:00	32.0	0	1	0	0	0
09/22/2020 11:00	0.0	0	0	0	0	1
09/22/2020 12:00	0.0	0	0	0	0	1
09/22/2020 13:00	0.0	0	0	0	0	1
09/22/2020 14:00	0.0	0	0	0	0	1
09/22/2020 15:00	0.0	0	0	0	0	1
09/22/2020 16:00	0.0	0	0	0	0	1
09/22/2020 17:00	0.0	0	0	0	0	1
09/22/2020 18:00	0.0	0	0	0	0	1
09/22/2020 19:00	0.0	0	0	0	0	1
09/22/2020 20:00	0.0	0	0	0	0	1
09/22/2020 21:00	1.6	0	0	0	1	0
09/22/2020 22:00	0.0	0	0	0	0	0
09/22/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	68.4 #	0 #	3 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	32.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/23/2020 00:00	0.0	0	0	0	0	0
09/23/2020 01:00	0.0	0	0	0	0	0
09/23/2020 02:00	0.0	0	0	0	0	0
09/23/2020 03:00	0.0	0	0	0	0	0
09/23/2020 04:00	0.0	0	0	0	0	0
09/23/2020 05:00	0.0	0	0	0	0	0
09/23/2020 06:00	0.0	0	0	0	0	0
09/23/2020 07:00	0.0	0	0	0	0	0
09/23/2020 08:00	15.9	0	1	0	0	0
09/23/2020 09:00	21.7	0	1	0	0	0
09/23/2020 10:00	25.2	0	1	0	0	0
09/23/2020 11:00	0.0	0	0	0	0	1
09/23/2020 12:00	0.0	0	0	0	0	1
09/23/2020 13:00	0.0	0	0	0	0	1
09/23/2020 14:00	0.0	0	0	0	0	1
09/23/2020 15:00	0.0	0	0	0	0	1
09/23/2020 16:00	0.0	0	0	0	0	1
09/23/2020 17:00	0.0	0	0	0	0	1
09/23/2020 18:00	0.0	0	0	0	0	1
09/23/2020 19:00	0.0	0	0	0	0	1
09/23/2020 20:00	0.0	0	0	0	0	1
09/23/2020 21:00	1.7	0	0	0	1	0
09/23/2020 22:00	0.0	0	0	0	0	0
09/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	64.5 #	0 #	3 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	25.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/24/2020 00:00	0.0	0	0	0	0	0
09/24/2020 01:00	0.0	0	0	0	0	0
09/24/2020 02:00	0.0	0	0	0	0	0
09/24/2020 03:00	0.0	0	0	0	0	0
09/24/2020 04:00	0.0	0	0	0	0	0
09/24/2020 05:00	0.0	0	0	0	0	0
09/24/2020 06:00	0.0	0	0	0	0	0
09/24/2020 07:00	0.0	0	0	0	0	0
09/24/2020 08:00	0.0	0	0	0	0	0
09/24/2020 09:00	0.0	0	0	0	0	0
09/24/2020 10:00	0.0	0	0	0	0	0
09/24/2020 11:00	0.0	0	0	0	0	0
09/24/2020 12:00	0.0	0	0	0	0	0
09/24/2020 13:00	34.9	0	1	0	0	0
09/24/2020 14:00	20.2	0	1	0	0	0
09/24/2020 15:00	0.0	0	0	0	0	1
09/24/2020 16:00	0.0	0	0	0	0	1
09/24/2020 17:00	0.0	0	0	0	0	1
09/24/2020 18:00	0.0	0	0	0	0	1
09/24/2020 19:00	0.0	0	0	0	0	1
09/24/2020 20:00	1.2	0	0	0	1	0
09/24/2020 21:00	0.0	0	0	0	0	0
09/24/2020 22:00	0.0	0	0	0	0	0
09/24/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	56.3 #	0 #	2 #	0 #	1 #	5 #
Minimum:	0.0	0	0	0	0	0
Maximum:	34.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/25/2020 00:00	0.0	0	0	0	0	0
09/25/2020 01:00	0.0	0	0	0	0	0
09/25/2020 02:00	0.0	0	0	0	0	0
09/25/2020 03:00	0.0	0	0	0	0	0
09/25/2020 04:00	0.0	0	0	0	0	0
09/25/2020 05:00	0.0	0	0	0	0	0
09/25/2020 06:00	0.0	0	0	0	0	0
09/25/2020 07:00	0.0	0	0	0	0	0
09/25/2020 08:00	0.0	0	0	0	0	0
09/25/2020 09:00	0.0	0	0	0	0	0
09/25/2020 10:00	0.0	0	0	0	0	0
09/25/2020 11:00	0.0	0	0	0	0	0
09/25/2020 12:00	0.0	0	0	0	0	0
09/25/2020 13:00	0.0	0	0	0	0	0
09/25/2020 14:00	0.0	0	0	0	0	0
09/25/2020 15:00	0.0	0	0	0	0	0
09/25/2020 16:00	0.0	0	0	0	0	0
09/25/2020 17:00	0.0	0	0	0	0	0
09/25/2020 18:00	0.0	0	0	0	0	0
09/25/2020 19:00	0.0	0	0	0	0	0
09/25/2020 20:00	0.0	0	0	0	0	0
09/25/2020 21:00	0.0	0	0	0	0	0
09/25/2020 22:00	0.0	0	0	0	0	0
09/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:37 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/26/2020 00:00	0.0	0	0	0	0	0
09/26/2020 01:00	0.0	0	0	0	0	0
09/26/2020 02:00	0.0	0	0	0	0	0
09/26/2020 03:00	0.0	0	0	0	0	0
09/26/2020 04:00	0.0	0	0	0	0	0
09/26/2020 05:00	0.0	0	0	0	0	0
09/26/2020 06:00	0.0	0	0	0	0	0
09/26/2020 07:00	0.0	0	0	0	0	0
09/26/2020 08:00	0.0	0	0	0	0	0
09/26/2020 09:00	0.0	0	0	0	0	0
09/26/2020 10:00	0.0	0	0	0	0	0
09/26/2020 11:00	0.0	0	0	0	0	0
09/26/2020 12:00	0.0	0	0	0	0	0
09/26/2020 13:00	0.0	0	0	0	0	0
09/26/2020 14:00	0.0	0	0	0	0	0
09/26/2020 15:00	0.0	0	0	0	0	0
09/26/2020 16:00	0.0	0	0	0	0	0
09/26/2020 17:00	0.0	0	0	0	0	0
09/26/2020 18:00	0.0	0	0	0	0	0
09/26/2020 19:00	0.0	0	0	0	0	0
09/26/2020 20:00	0.0	0	0	0	0	0
09/26/2020 21:00	0.0	0	0	0	0	0
09/26/2020 22:00	0.0	0	0	0	0	0
09/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/27/2020 00:00	0.0	0	0	0	0	0
09/27/2020 01:00	0.0	0	0	0	0	0
09/27/2020 02:00	0.0	0	0	0	0	0
09/27/2020 03:00	0.0	0	0	0	0	0
09/27/2020 04:00	0.0	0	0	0	0	0
09/27/2020 05:00	0.0	0	0	0	0	0
09/27/2020 06:00	0.0	0	0	0	0	0
09/27/2020 07:00	0.0	0	0	0	0	0
09/27/2020 08:00	0.0	0	1	0	0	0
09/27/2020 09:00	70.4	0	1	0	0	0
09/27/2020 10:00	20.9	0	1	0	0	0
09/27/2020 11:00	0.0	0	0	0	0	1
09/27/2020 12:00	0.0	0	0	0	0	1
09/27/2020 13:00	0.0	0	0	0	0	1
09/27/2020 14:00	0.0	0	0	0	0	1
09/27/2020 15:00	0.0	0	0	0	0	1
09/27/2020 16:00	0.0	0	0	0	0	1
09/27/2020 17:00	0.0	0	0	0	0	1
09/27/2020 18:00	0.0	0	0	0	0	1
09/27/2020 19:00	0.0	0	0	0	0	1
09/27/2020 20:00	0.0	0	0	0	0	1
09/27/2020 21:00	0.0	0	0	0	0	1
09/27/2020 22:00	1.3	0	0	0	1	0
09/27/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	92.6 #	0 #	3 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	70.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/28/2020 00:00	0.0	0	0	0	0	0
09/28/2020 01:00	0.0	0	0	0	0	0
09/28/2020 02:00	0.0	0	0	0	0	0
09/28/2020 03:00	0.0	0	0	0	0	0
09/28/2020 04:00	0.0	0	0	0	0	0
09/28/2020 05:00	0.0	0	0	0	0	0
09/28/2020 06:00	0.0	0	0	0	0	0
09/28/2020 07:00	0.0	0	0	0	0	0
09/28/2020 08:00	0.0	0	0	0	0	0
09/28/2020 09:00	0.0	0	0	0	0	0
09/28/2020 10:00	11.8	0	1	0	0	0
09/28/2020 11:00	17.1	0	1	0	0	0
09/28/2020 12:00	0.0	0	0	0	0	1
09/28/2020 13:00	0.0	0	0	0	0	1
09/28/2020 14:00	0.0	0	0	0	0	1
09/28/2020 15:00	0.0	0	0	0	0	1
09/28/2020 16:00	0.0	0	0	0	0	1
09/28/2020 17:00	0.0	0	0	0	0	1
09/28/2020 18:00	0.0	0	0	0	0	1
09/28/2020 19:00	0.0	0	0	0	0	1
09/28/2020 20:00	0.0	0	0	0	0	1
09/28/2020 21:00	0.0	0	0	0	0	1
09/28/2020 22:00	1.3	0	0	0	1	0
09/28/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	30.2 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	17.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/29/2020 00:00	0.0	0	0	0	0	0
09/29/2020 01:00	0.0	0	0	0	0	0
09/29/2020 02:00	0.0	0	0	0	0	0
09/29/2020 03:00	0.0	0	0	0	0	0
09/29/2020 04:00	0.0	0	0	0	0	0
09/29/2020 05:00	0.0	0	0	0	0	0
09/29/2020 06:00	0.0	0	0	0	0	0
09/29/2020 07:00	0.0	0	0	0	0	0
09/29/2020 08:00	0.0	0	0	0	0	0
09/29/2020 09:00	0.0	0	0	0	0	0
09/29/2020 10:00	13.8	0	1	0	0	0
09/29/2020 11:00	19.1	0	1	0	0	0
09/29/2020 12:00	0.0	0	0	0	0	1
09/29/2020 13:00	0.0	0	0	0	0	1
09/29/2020 14:00	0.0	0	0	0	0	1
09/29/2020 15:00	0.0	0	0	0	0	1
09/29/2020 16:00	0.0	0	0	0	0	1
09/29/2020 17:00	0.0	0	0	0	0	1
09/29/2020 18:00	0.0	0	0	0	0	1
09/29/2020 19:00	0.0	0	0	0	0	1
09/29/2020 20:00	0.0	0	0	0	0	1
09/29/2020 21:00	0.0	0	0	0	0	1
09/29/2020 22:00	0.0	0	0	0	0	1
09/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	32.9 #	0 #	2 #	0 #	0 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	19.1	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:37 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/30/2020 00:00	0.0	0	0	0	0	1
09/30/2020 01:00	0.0	0	0	0	0	1
09/30/2020 02:00	0.0	0	0	0	0	1
09/30/2020 03:00	0.0	0	0	0	0	1
09/30/2020 04:00	0.0	0	0	0	0	1
09/30/2020 05:00	0.0	0	0	0	0	1
09/30/2020 06:00	0.0	0	0	0	0	1
09/30/2020 07:00	0.0	0	0	0	0	1
09/30/2020 08:00	0.0	0	0	0	0	1
09/30/2020 09:00	0.0	0	0	0	0	1
09/30/2020 10:00	0.0	0	0	0	0	1
09/30/2020 11:00	0.0	0	0	0	0	1
09/30/2020 12:00	0.0	0	0	0	0	1
09/30/2020 13:00	0.0	0	0	0	0	1
09/30/2020 14:00	0.0	0	0	0	0	1
09/30/2020 15:00	0.0	0	0	0	0	1
09/30/2020 16:00	0.0	0	0	0	0	1
09/30/2020 17:00	0.0	0	0	0	0	1
09/30/2020 18:00	0.0	0	0	0	0	1
09/30/2020 19:00	0.0	0	0	0	0	1
09/30/2020 20:00	0.0	0	0	0	0	1
09/30/2020 21:00	0.0	0	0	0	0	1
09/30/2020 22:00	0.0	0	0	0	0	1
09/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/01/2020 00:00	0.0	0	0	0	0	0
07/01/2020 01:00	0.0	0	0	0	0	0
07/01/2020 02:00	0.0	0	0	0	0	0
07/01/2020 03:00	0.0	0	0	0	0	0
07/01/2020 04:00	0.0	0	0	0	0	0
07/01/2020 05:00	0.0	0	0	0	0	0
07/01/2020 06:00	0.0	0	0	0	0	0
07/01/2020 07:00	0.0	0	0	0	0	0
07/01/2020 08:00	0.0	0	0	0	0	0
07/01/2020 09:00	0.0	0	0	0	0	0
07/01/2020 10:00	0.0	0	0	0	0	0
07/01/2020 11:00	0.0	0	0	0	0	0
07/01/2020 12:00	0.0	0	0	0	0	0
07/01/2020 13:00	0.0	0	0	0	0	0
07/01/2020 14:00	0.0	0	0	0	0	0
07/01/2020 15:00	0.0	0	0	0	0	0
07/01/2020 16:00	0.0	0	0	0	0	0
07/01/2020 17:00	0.0	0	0	0	0	0
07/01/2020 18:00	0.0	0	0	0	0	0
07/01/2020 19:00	0.0	0	0	0	0	0
07/01/2020 20:00	0.0	0	0	0	0	0
07/01/2020 21:00	0.0	0	0	0	0	0
07/01/2020 22:00	0.0	0	0	0	0	0
07/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/02/2020 00:00	0.0	0	0	0	0	0
07/02/2020 01:00	0.0	0	0	0	0	0
07/02/2020 02:00	0.0	0	0	0	0	0
07/02/2020 03:00	0.0	0	0	0	0	0
07/02/2020 04:00	0.0	0	0	0	0	0
07/02/2020 05:00	0.0	0	0	0	0	0
07/02/2020 06:00	0.0	0	0	0	0	0
07/02/2020 07:00	0.0	0	0	0	0	0
07/02/2020 08:00	0.0	0	0	0	0	0
07/02/2020 09:00	0.0	0	0	0	0	0
07/02/2020 10:00	0.0	0	0	0	0	0
07/02/2020 11:00	0.0	0	0	0	0	0
07/02/2020 12:00	0.0	0	0	0	0	0
07/02/2020 13:00	0.0	0	0	0	0	0
07/02/2020 14:00	0.0	0	0	0	0	0
07/02/2020 15:00	0.0	0	0	0	0	0
07/02/2020 16:00	0.0	0	0	0	0	0
07/02/2020 17:00	0.0	0	0	0	0	0
07/02/2020 18:00	0.0	0	0	0	0	0
07/02/2020 19:00	0.0	0	0	0	0	0
07/02/2020 20:00	0.0	0	0	0	0	0
07/02/2020 21:00	0.0	0	0	0	0	0
07/02/2020 22:00	0.0	0	0	0	0	0
07/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/03/2020 00:00	0.0	0	0	0	0	0
07/03/2020 01:00	0.0	0	0	0	0	0
07/03/2020 02:00	0.0	0	0	0	0	0
07/03/2020 03:00	0.0	0	0	0	0	0
07/03/2020 04:00	0.0	0	0	0	0	0
07/03/2020 05:00	0.0	0	0	0	0	0
07/03/2020 06:00	0.0	0	0	0	0	0
07/03/2020 07:00	0.0	0	0	0	0	0
07/03/2020 08:00	3,089.8	0	1	0	0	0
07/03/2020 09:00	5,061.3	0	1	0	0	0
07/03/2020 10:00	6,090.0	0	1	0	0	0
07/03/2020 11:00	0.0	0	0	0	0	1
07/03/2020 12:00	0.0	0	0	0	0	1
07/03/2020 13:00	0.0	0	0	0	0	1
07/03/2020 14:00	0.0	0	0	0	0	1
07/03/2020 15:00	0.0	0	0	0	0	1
07/03/2020 16:00	0.0	0	0	0	0	1
07/03/2020 17:00	0.0	0	0	0	0	1
07/03/2020 18:00	0.0	0	0	0	0	1
07/03/2020 19:00	0.0	0	0	0	0	1
07/03/2020 20:00	0.0	0	0	0	0	1
07/03/2020 21:00	0.0	0	0	0	0	1
07/03/2020 22:00	0.0	0	0	0	0	1
07/03/2020 23:00	77.6	0	0	0	1	0
Average/Sum#:	14,318.7 #	0 #	3 #	0 #	1 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,090.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/04/2020 00:00	0.0	0	0	0	0	0
07/04/2020 01:00	0.0	0	0	0	0	0
07/04/2020 02:00	0.0	0	0	0	0	0
07/04/2020 03:00	0.0	0	0	0	0	0
07/04/2020 04:00	0.0	0	0	0	0	0
07/04/2020 05:00	0.0	0	0	0	0	0
07/04/2020 06:00	0.0	0	0	0	0	0
07/04/2020 07:00	0.0	0	0	0	0	0
07/04/2020 08:00	0.0	0	0	0	0	0
07/04/2020 09:00	0.0	0	0	0	0	0
07/04/2020 10:00	0.0	0	0	0	0	0
07/04/2020 11:00	0.0	0	0	0	0	0
07/04/2020 12:00	0.0	0	0	0	0	0
07/04/2020 13:00	0.0	0	0	0	0	0
07/04/2020 14:00	0.0	0	0	0	0	0
07/04/2020 15:00	0.0	0	0	0	0	0
07/04/2020 16:00	0.0	0	0	0	0	0
07/04/2020 17:00	0.0	0	0	0	0	0
07/04/2020 18:00	0.0	0	0	0	0	0
07/04/2020 19:00	0.0	0	0	0	0	0
07/04/2020 20:00	0.0	0	0	0	0	0
07/04/2020 21:00	0.0	0	0	0	0	0
07/04/2020 22:00	0.0	0	0	0	0	0
07/04/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/05/2020 00:00	0.0	0	0	0	0	0
07/05/2020 01:00	0.0	0	0	0	0	0
07/05/2020 02:00	0.0	0	0	0	0	0
07/05/2020 03:00	0.0	0	0	0	0	0
07/05/2020 04:00	0.0	0	0	0	0	0
07/05/2020 05:00	0.0	0	0	0	0	0
07/05/2020 06:00	0.0	0	0	0	0	0
07/05/2020 07:00	0.0	0	0	0	0	0
07/05/2020 08:00	0.0	0	0	0	0	0
07/05/2020 09:00	3,118.7	0	1	0	0	0
07/05/2020 10:00	5,085.1	0	1	0	0	0
07/05/2020 11:00	6,675.4	0	1	0	0	0
07/05/2020 12:00	0.0	0	0	0	0	1
07/05/2020 13:00	0.0	0	0	0	0	1
07/05/2020 14:00	0.0	0	0	0	0	1
07/05/2020 15:00	0.0	0	0	0	0	1
07/05/2020 16:00	0.0	0	0	0	0	1
07/05/2020 17:00	0.0	0	0	0	0	1
07/05/2020 18:00	0.0	0	0	0	0	1
07/05/2020 19:00	0.0	0	0	0	0	1
07/05/2020 20:00	0.0	0	0	0	0	1
07/05/2020 21:00	0.0	0	0	0	0	1
07/05/2020 22:00	142.3	0	0	0	1	0
07/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	15,021.5 #	0 #	3 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,675.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/06/2020 00:00	0.0	0	0	0	0	0
07/06/2020 01:00	0.0	0	0	0	0	0
07/06/2020 02:00	1,534.9	0	0	1	0	0
07/06/2020 03:00	4,647.4	0	0	1	0	0
07/06/2020 04:00	0.0	0	0	0	0	1
07/06/2020 05:00	0.0	0	0	0	0	1
07/06/2020 06:00	0.0	0	0	0	0	1
07/06/2020 07:00	0.0	0	0	0	0	1
07/06/2020 08:00	0.0	0	0	0	0	1
07/06/2020 09:00	0.0	0	0	0	0	1
07/06/2020 10:00	0.0	0	0	0	0	1
07/06/2020 11:00	0.0	0	0	0	0	1
07/06/2020 12:00	0.0	0	0	0	0	1
07/06/2020 13:00	0.0	0	0	0	0	1
07/06/2020 14:00	0.0	0	0	0	0	1
07/06/2020 15:00	0.0	0	0	0	0	1
07/06/2020 16:00	0.0	0	0	0	0	1
07/06/2020 17:00	0.0	0	0	0	0	1
07/06/2020 18:00	0.0	0	0	0	0	1
07/06/2020 19:00	0.0	0	0	0	0	1
07/06/2020 20:00	0.0	0	0	0	0	1
07/06/2020 21:00	0.0	0	0	0	0	1
07/06/2020 22:00	0.0	0	0	0	0	1
07/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,182.3 #	0 #	0 #	2 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,647.4	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/07/2020 00:00	0.0	0	0	0	0	1
07/07/2020 01:00	0.0	0	0	0	0	1
07/07/2020 02:00	0.0	0	0	0	0	1
07/07/2020 03:00	0.0	0	0	0	0	1
07/07/2020 04:00	0.0	0	0	0	0	1
07/07/2020 05:00	0.0	0	0	0	0	1
07/07/2020 06:00	0.0	0	0	0	0	1
07/07/2020 07:00	0.0	0	0	0	0	1
07/07/2020 08:00	0.0	0	0	0	0	1
07/07/2020 09:00	0.0	0	0	0	0	1
07/07/2020 10:00	0.0	0	0	0	0	1
07/07/2020 11:00	0.0	0	0	0	0	1
07/07/2020 12:00	0.0	0	0	0	0	1
07/07/2020 13:00	0.0	0	0	0	0	1
07/07/2020 14:00	0.0	0	0	0	0	1
07/07/2020 15:00	0.0	0	0	0	0	1
07/07/2020 16:00	0.0	0	0	0	0	1
07/07/2020 17:00	0.0	0	0	0	0	1
07/07/2020 18:00	0.0	0	0	0	0	1
07/07/2020 19:00	0.0	0	0	0	0	1
07/07/2020 20:00	0.0	0	0	0	0	1
07/07/2020 21:00	0.0	0	0	0	0	1
07/07/2020 22:00	0.0	0	0	0	0	1
07/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/08/2020 00:00	0.0	0	0	0	0	1
07/08/2020 01:00	0.0	0	0	0	0	1
07/08/2020 02:00	0.0	0	0	0	0	1
07/08/2020 03:00	0.0	0	0	0	0	1
07/08/2020 04:00	0.0	0	0	0	0	1
07/08/2020 05:00	0.0	0	0	0	0	1
07/08/2020 06:00	0.0	0	0	0	0	1
07/08/2020 07:00	0.0	0	0	0	0	1
07/08/2020 08:00	0.0	0	0	0	0	1
07/08/2020 09:00	0.0	0	0	0	0	1
07/08/2020 10:00	0.0	0	0	0	0	1
07/08/2020 11:00	0.0	0	0	0	0	1
07/08/2020 12:00	0.0	0	0	0	0	1
07/08/2020 13:00	0.0	0	0	0	0	1
07/08/2020 14:00	0.0	0	0	0	0	1
07/08/2020 15:00	0.0	0	0	0	0	1
07/08/2020 16:00	0.0	0	0	0	0	1
07/08/2020 17:00	0.0	0	0	0	0	1
07/08/2020 18:00	0.0	0	0	0	0	1
07/08/2020 19:00	0.0	0	0	0	0	1
07/08/2020 20:00	0.0	0	0	0	0	1
07/08/2020 21:00	0.0	0	0	0	0	1
07/08/2020 22:00	0.0	0	0	0	0	1
07/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/09/2020 00:00	0.0	0	0	0	0	1
07/09/2020 01:00	0.0	0	0	0	0	1
07/09/2020 02:00	0.0	0	0	0	0	1
07/09/2020 03:00	0.0	0	0	0	0	1
07/09/2020 04:00	0.0	0	0	0	0	1
07/09/2020 05:00	0.0	0	0	0	0	1
07/09/2020 06:00	0.0	0	0	0	0	1
07/09/2020 07:00	0.0	0	0	0	0	1
07/09/2020 08:00	0.0	0	0	0	0	1
07/09/2020 09:00	0.0	0	0	0	0	1
07/09/2020 10:00	0.0	0	0	0	0	1
07/09/2020 11:00	0.0	0	0	0	0	1
07/09/2020 12:00	0.0	0	0	0	0	1
07/09/2020 13:00	0.0	0	0	0	0	1
07/09/2020 14:00	0.0	0	0	0	0	1
07/09/2020 15:00	0.0	0	0	0	0	1
07/09/2020 16:00	0.0	0	0	0	0	1
07/09/2020 17:00	0.0	0	0	0	0	1
07/09/2020 18:00	0.0	0	0	0	0	1
07/09/2020 19:00	0.0	0	0	0	0	1
07/09/2020 20:00	0.0	0	0	0	0	1
07/09/2020 21:00	0.0	0	0	0	0	1
07/09/2020 22:00	0.0	0	0	0	0	1
07/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/10/2020 00:00	0.0	0	0	0	0	1
07/10/2020 01:00	0.0	0	0	0	0	1
07/10/2020 02:00	0.0	0	0	0	0	1
07/10/2020 03:00	0.0	0	0	0	0	1
07/10/2020 04:00	0.0	0	0	0	0	1
07/10/2020 05:00	0.0	0	0	0	0	1
07/10/2020 06:00	0.0	0	0	0	0	1
07/10/2020 07:00	0.0	0	0	0	0	1
07/10/2020 08:00	0.0	0	0	0	0	1
07/10/2020 09:00	0.0	0	0	0	0	1
07/10/2020 10:00	0.0	0	0	0	0	1
07/10/2020 11:00	0.0	0	0	0	0	1
07/10/2020 12:00	0.0	0	0	0	0	1
07/10/2020 13:00	0.0	0	0	0	0	1
07/10/2020 14:00	0.0	0	0	0	0	1
07/10/2020 15:00	0.0	0	0	0	0	1
07/10/2020 16:00	0.0	0	0	0	0	1
07/10/2020 17:00	0.0	0	0	0	0	1
07/10/2020 18:00	0.0	0	0	0	0	1
07/10/2020 19:00	0.0	0	0	0	0	1
07/10/2020 20:00	0.0	0	0	0	0	1
07/10/2020 21:00	0.0	0	0	0	0	1
07/10/2020 22:00	0.0	0	0	0	0	1
07/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/11/2020 00:00	0.0	0	0	0	0	1
07/11/2020 01:00	0.0	0	0	0	0	1
07/11/2020 02:00	0.0	0	0	0	0	1
07/11/2020 03:00	0.0	0	0	0	0	1
07/11/2020 04:00	0.0	0	0	0	0	1
07/11/2020 05:00	0.0	0	0	0	0	1
07/11/2020 06:00	0.0	0	0	0	0	1
07/11/2020 07:00	0.0	0	0	0	0	1
07/11/2020 08:00	0.0	0	0	0	0	1
07/11/2020 09:00	0.0	0	0	0	0	1
07/11/2020 10:00	0.0	0	0	0	0	1
07/11/2020 11:00	0.0	0	0	0	0	1
07/11/2020 12:00	0.0	0	0	0	0	1
07/11/2020 13:00	0.0	0	0	0	0	1
07/11/2020 14:00	0.0	0	0	0	0	1
07/11/2020 15:00	0.0	0	0	0	0	1
07/11/2020 16:00	0.0	0	0	0	0	1
07/11/2020 17:00	0.0	0	0	0	0	1
07/11/2020 18:00	0.0	0	0	0	0	1
07/11/2020 19:00	0.0	0	0	0	0	1
07/11/2020 20:00	0.0	0	0	0	0	1
07/11/2020 21:00	0.0	0	0	0	0	1
07/11/2020 22:00	0.0	0	0	0	0	1
07/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/12/2020 00:00	0.0	0	0	0	0	1
07/12/2020 01:00	0.0	0	0	0	0	1
07/12/2020 02:00	0.0	0	0	0	0	1
07/12/2020 03:00	0.0	0	0	0	0	1
07/12/2020 04:00	0.0	0	0	0	0	1
07/12/2020 05:00	0.0	0	0	0	0	1
07/12/2020 06:00	0.0	0	0	0	0	1
07/12/2020 07:00	0.0	0	0	0	0	1
07/12/2020 08:00	0.0	0	0	0	0	1
07/12/2020 09:00	0.0	0	0	0	0	1
07/12/2020 10:00	0.0	0	0	0	0	1
07/12/2020 11:00	0.0	0	0	0	0	1
07/12/2020 12:00	0.0	0	0	0	0	1
07/12/2020 13:00	0.0	0	0	0	0	1
07/12/2020 14:00	0.0	0	0	0	0	1
07/12/2020 15:00	0.0	0	0	0	0	1
07/12/2020 16:00	0.0	0	0	0	0	1
07/12/2020 17:00	0.0	0	0	0	0	1
07/12/2020 18:00	0.0	0	0	0	0	1
07/12/2020 19:00	0.0	0	0	0	0	1
07/12/2020 20:00	0.0	0	0	0	0	1
07/12/2020 21:00	0.0	0	0	0	0	1
07/12/2020 22:00	0.0	0	0	0	0	1
07/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/13/2020 00:00	0.0	0	0	0	0	1
07/13/2020 01:00	0.0	0	0	0	0	1
07/13/2020 02:00	0.0	0	0	0	0	1
07/13/2020 03:00	0.0	0	0	0	0	1
07/13/2020 04:00	0.0	0	0	0	0	1
07/13/2020 05:00	0.0	0	0	0	0	1
07/13/2020 06:00	0.0	0	0	0	0	1
07/13/2020 07:00	0.0	0	0	0	0	1
07/13/2020 08:00	0.0	0	0	0	0	1
07/13/2020 09:00	0.0	0	0	0	0	1
07/13/2020 10:00	0.0	0	0	0	0	1
07/13/2020 11:00	0.0	0	0	0	0	1
07/13/2020 12:00	0.0	0	0	0	0	1
07/13/2020 13:00	0.0	0	0	0	0	1
07/13/2020 14:00	0.0	0	0	0	0	1
07/13/2020 15:00	0.0	0	0	0	0	1
07/13/2020 16:00	0.0	0	0	0	0	1
07/13/2020 17:00	0.0	0	0	0	0	1
07/13/2020 18:00	0.0	0	0	0	0	1
07/13/2020 19:00	0.0	0	0	0	0	1
07/13/2020 20:00	0.0	0	0	0	0	1
07/13/2020 21:00	0.0	0	0	0	0	1
07/13/2020 22:00	0.0	0	0	0	0	1
07/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/14/2020 00:00	0.0	0	0	0	0	1
07/14/2020 01:00	0.0	0	0	0	0	1
07/14/2020 02:00	0.0	0	0	0	0	1
07/14/2020 03:00	0.0	0	0	0	0	1
07/14/2020 04:00	0.0	0	0	0	0	1
07/14/2020 05:00	0.0	0	0	0	0	1
07/14/2020 06:00	0.0	0	0	0	0	1
07/14/2020 07:00	0.0	0	0	0	0	1
07/14/2020 08:00	0.0	0	0	0	0	1
07/14/2020 09:00	0.0	0	0	0	0	1
07/14/2020 10:00	0.0	0	0	0	0	1
07/14/2020 11:00	0.0	0	0	0	0	1
07/14/2020 12:00	0.0	0	0	0	0	1
07/14/2020 13:00	0.0	0	0	0	0	1
07/14/2020 14:00	0.0	0	0	0	0	1
07/14/2020 15:00	0.0	0	0	0	0	1
07/14/2020 16:00	0.0	0	0	0	0	1
07/14/2020 17:00	0.0	0	0	0	0	1
07/14/2020 18:00	0.0	0	0	0	0	1
07/14/2020 19:00	0.0	0	0	0	0	1
07/14/2020 20:00	0.0	0	0	0	0	1
07/14/2020 21:00	0.0	0	0	0	0	1
07/14/2020 22:00	0.0	0	0	0	0	1
07/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/15/2020 00:00	0.0	0	0	0	0	1
07/15/2020 01:00	0.0	0	0	0	0	1
07/15/2020 02:00	0.0	0	0	0	0	1
07/15/2020 03:00	0.0	0	0	0	0	1
07/15/2020 04:00	0.0	0	0	0	0	1
07/15/2020 05:00	0.0	0	0	0	0	1
07/15/2020 06:00	0.0	0	0	0	0	1
07/15/2020 07:00	0.0	0	0	0	0	1
07/15/2020 08:00	0.0	0	0	0	0	1
07/15/2020 09:00	0.0	0	0	0	0	1
07/15/2020 10:00	0.0	0	0	0	0	1
07/15/2020 11:00	0.0	0	0	0	0	1
07/15/2020 12:00	0.0	0	0	0	0	1
07/15/2020 13:00	0.0	0	0	0	0	1
07/15/2020 14:00	0.0	0	0	0	0	1
07/15/2020 15:00	0.0	0	0	0	0	1
07/15/2020 16:00	0.0	0	0	0	0	1
07/15/2020 17:00	0.0	0	0	0	0	1
07/15/2020 18:00	0.0	0	0	0	0	1
07/15/2020 19:00	0.0	0	0	0	0	1
07/15/2020 20:00	0.0	0	0	0	0	1
07/15/2020 21:00	0.0	0	0	0	0	1
07/15/2020 22:00	0.0	0	0	0	0	1
07/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/16/2020 00:00	0.0	0	0	0	0	1
07/16/2020 01:00	0.0	0	0	0	0	1
07/16/2020 02:00	0.0	0	0	0	0	1
07/16/2020 03:00	0.0	0	0	0	0	1
07/16/2020 04:00	0.0	0	0	0	0	1
07/16/2020 05:00	0.0	0	0	0	0	1
07/16/2020 06:00	0.0	0	0	0	0	1
07/16/2020 07:00	0.0	0	0	0	0	1
07/16/2020 08:00	0.0	0	0	0	0	1
07/16/2020 09:00	0.0	0	0	0	0	1
07/16/2020 10:00	0.0	0	0	0	0	1
07/16/2020 11:00	0.0	0	0	0	0	1
07/16/2020 12:00	0.0	0	0	0	0	1
07/16/2020 13:00	0.0	0	0	0	0	1
07/16/2020 14:00	0.0	0	0	0	0	1
07/16/2020 15:00	0.0	0	0	0	0	1
07/16/2020 16:00	0.0	0	0	0	0	1
07/16/2020 17:00	0.0	0	0	0	0	1
07/16/2020 18:00	0.0	0	0	0	0	1
07/16/2020 19:00	0.0	0	0	0	0	1
07/16/2020 20:00	0.0	0	0	0	0	1
07/16/2020 21:00	0.0	0	0	0	0	1
07/16/2020 22:00	0.0	0	0	0	0	1
07/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/17/2020 00:00	0.0	0	0	0	0	1
07/17/2020 01:00	0.0	0	0	0	0	1
07/17/2020 02:00	0.0	0	0	0	0	1
07/17/2020 03:00	0.0	0	0	0	0	1
07/17/2020 04:00	0.0	0	0	0	0	1
07/17/2020 05:00	0.0	0	0	0	0	1
07/17/2020 06:00	0.0	0	0	0	0	1
07/17/2020 07:00	0.0	0	0	0	0	1
07/17/2020 08:00	0.0	0	0	0	0	1
07/17/2020 09:00	0.0	0	0	0	0	1
07/17/2020 10:00	0.0	0	0	0	0	1
07/17/2020 11:00	0.0	0	0	0	0	1
07/17/2020 12:00	0.0	0	0	0	0	1
07/17/2020 13:00	0.0	0	0	0	0	1
07/17/2020 14:00	0.0	0	0	0	0	1
07/17/2020 15:00	0.0	0	0	0	0	1
07/17/2020 16:00	0.0	0	0	0	0	1
07/17/2020 17:00	0.0	0	0	0	0	1
07/17/2020 18:00	0.0	0	0	0	0	1
07/17/2020 19:00	0.0	0	0	0	0	1
07/17/2020 20:00	0.0	0	0	0	0	1
07/17/2020 21:00	0.0	0	0	0	0	1
07/17/2020 22:00	0.0	0	0	0	0	1
07/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/18/2020 00:00	0.0	0	0	0	0	1
07/18/2020 01:00	0.0	0	0	0	0	1
07/18/2020 02:00	0.0	0	0	0	0	1
07/18/2020 03:00	0.0	0	0	0	0	1
07/18/2020 04:00	0.0	0	0	0	0	1
07/18/2020 05:00	0.0	0	0	0	0	1
07/18/2020 06:00	0.0	0	0	0	0	1
07/18/2020 07:00	0.0	0	0	0	0	1
07/18/2020 08:00	0.0	0	0	0	0	1
07/18/2020 09:00	0.0	0	0	0	0	1
07/18/2020 10:00	0.0	0	0	0	0	1
07/18/2020 11:00	0.0	0	0	0	0	1
07/18/2020 12:00	0.0	0	0	0	0	1
07/18/2020 13:00	0.0	0	0	0	0	1
07/18/2020 14:00	0.0	0	0	0	0	1
07/18/2020 15:00	0.0	0	0	0	0	1
07/18/2020 16:00	0.0	0	0	0	0	1
07/18/2020 17:00	0.0	0	0	0	0	1
07/18/2020 18:00	0.0	0	0	0	0	1
07/18/2020 19:00	0.0	0	0	0	0	1
07/18/2020 20:00	0.0	0	0	0	0	1
07/18/2020 21:00	0.0	0	0	0	0	1
07/18/2020 22:00	0.0	0	0	0	0	1
07/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/19/2020 00:00	0.0	0	0	0	0	1
07/19/2020 01:00	0.0	0	0	0	0	1
07/19/2020 02:00	0.0	0	0	0	0	1
07/19/2020 03:00	0.0	0	0	0	0	1
07/19/2020 04:00	0.0	0	0	0	0	1
07/19/2020 05:00	0.0	0	0	0	0	1
07/19/2020 06:00	0.0	0	0	0	0	1
07/19/2020 07:00	0.0	0	0	0	0	1
07/19/2020 08:00	0.0	0	0	0	0	1
07/19/2020 09:00	0.0	0	0	0	0	1
07/19/2020 10:00	0.0	0	0	0	0	1
07/19/2020 11:00	0.0	0	0	0	0	1
07/19/2020 12:00	0.0	0	0	0	0	1
07/19/2020 13:00	0.0	0	0	0	0	1
07/19/2020 14:00	0.0	0	0	0	0	1
07/19/2020 15:00	0.0	0	0	0	0	1
07/19/2020 16:00	0.0	0	0	0	0	1
07/19/2020 17:00	0.0	0	0	0	0	1
07/19/2020 18:00	0.0	0	0	0	0	1
07/19/2020 19:00	0.0	0	0	0	0	1
07/19/2020 20:00	0.0	0	0	0	0	1
07/19/2020 21:00	0.0	0	0	0	0	1
07/19/2020 22:00	0.0	0	0	0	0	1
07/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/20/2020 00:00	0.0	0	0	0	0	1
07/20/2020 01:00	0.0	0	0	0	0	1
07/20/2020 02:00	0.0	0	0	0	0	1
07/20/2020 03:00	0.0	0	0	0	0	1
07/20/2020 04:00	0.0	0	0	0	0	1
07/20/2020 05:00	0.0	0	0	0	0	1
07/20/2020 06:00	0.0	0	0	0	0	1
07/20/2020 07:00	0.0	0	0	0	0	1
07/20/2020 08:00	0.0	0	0	0	0	1
07/20/2020 09:00	0.0	0	0	0	0	1
07/20/2020 10:00	0.0	0	0	0	0	1
07/20/2020 11:00	0.0	0	0	0	0	1
07/20/2020 12:00	0.0	0	0	0	0	1
07/20/2020 13:00	0.0	0	0	0	0	1
07/20/2020 14:00	0.0	0	0	0	0	1
07/20/2020 15:00	0.0	0	0	0	0	1
07/20/2020 16:00	0.0	0	0	0	0	1
07/20/2020 17:00	0.0	0	0	0	0	1
07/20/2020 18:00	0.0	0	0	0	0	1
07/20/2020 19:00	0.0	0	0	0	0	1
07/20/2020 20:00	0.0	0	0	0	0	1
07/20/2020 21:00	0.0	0	0	0	0	1
07/20/2020 22:00	0.0	0	0	0	0	1
07/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/21/2020 00:00	0.0	0	0	0	0	1
07/21/2020 01:00	0.0	0	0	0	0	1
07/21/2020 02:00	0.0	0	0	0	0	1
07/21/2020 03:00	0.0	0	0	0	0	1
07/21/2020 04:00	0.0	0	0	0	0	1
07/21/2020 05:00	0.0	0	0	0	0	1
07/21/2020 06:00	0.0	0	0	0	0	1
07/21/2020 07:00	0.0	0	0	0	0	1
07/21/2020 08:00	0.0	0	0	0	0	1
07/21/2020 09:00	0.0	0	0	0	0	1
07/21/2020 10:00	0.0	0	0	0	0	1
07/21/2020 11:00	0.0	0	0	0	0	1
07/21/2020 12:00	0.0	0	0	0	0	1
07/21/2020 13:00	0.0	0	0	0	0	1
07/21/2020 14:00	0.0	0	0	0	0	1
07/21/2020 15:00	0.0	0	0	0	0	1
07/21/2020 16:00	0.0	0	0	0	0	1
07/21/2020 17:00	0.0	0	0	0	0	1
07/21/2020 18:00	0.0	0	0	0	0	1
07/21/2020 19:00	0.0	0	0	0	0	1
07/21/2020 20:00	0.0	0	0	0	0	1
07/21/2020 21:00	0.0	0	0	0	0	1
07/21/2020 22:00	0.0	0	0	0	0	1
07/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/22/2020 00:00	0.0	0	0	0	0	1
07/22/2020 01:00	0.0	0	0	0	0	1
07/22/2020 02:00	0.0	0	0	0	0	1
07/22/2020 03:00	0.0	0	0	0	0	1
07/22/2020 04:00	0.0	0	0	0	0	1
07/22/2020 05:00	0.0	0	0	0	0	1
07/22/2020 06:00	0.0	0	0	0	0	1
07/22/2020 07:00	0.0	0	0	0	0	1
07/22/2020 08:00	0.0	0	0	0	0	1
07/22/2020 09:00	0.0	0	0	0	0	1
07/22/2020 10:00	0.0	0	0	0	0	1
07/22/2020 11:00	0.0	0	0	0	0	1
07/22/2020 12:00	0.0	0	0	0	0	1
07/22/2020 13:00	0.0	0	0	0	0	1
07/22/2020 14:00	0.0	0	0	0	0	1
07/22/2020 15:00	0.0	0	0	0	0	1
07/22/2020 16:00	0.0	0	0	0	0	1
07/22/2020 17:00	0.0	0	0	0	0	1
07/22/2020 18:00	0.0	0	0	0	0	1
07/22/2020 19:00	0.0	0	0	0	0	1
07/22/2020 20:00	0.0	0	0	0	0	1
07/22/2020 21:00	0.0	0	0	0	0	1
07/22/2020 22:00	0.0	0	0	0	0	1
07/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/23/2020 00:00	0.0	0	0	0	0	1
07/23/2020 01:00	0.0	0	0	0	0	1
07/23/2020 02:00	0.0	0	0	0	0	1
07/23/2020 03:00	0.0	0	0	0	0	1
07/23/2020 04:00	0.0	0	0	0	0	1
07/23/2020 05:00	0.0	0	0	0	0	1
07/23/2020 06:00	0.0	0	0	0	0	1
07/23/2020 07:00	0.0	0	0	0	0	1
07/23/2020 08:00	0.0	0	0	0	0	1
07/23/2020 09:00	0.0	0	0	0	0	1
07/23/2020 10:00	0.0	0	0	0	0	1
07/23/2020 11:00	0.0	0	0	0	0	1
07/23/2020 12:00	0.0	0	0	0	0	1
07/23/2020 13:00	0.0	0	0	0	0	1
07/23/2020 14:00	0.0	0	0	0	0	1
07/23/2020 15:00	0.0	0	0	0	0	1
07/23/2020 16:00	0.0	0	0	0	0	1
07/23/2020 17:00	0.0	0	0	0	0	1
07/23/2020 18:00	0.0	0	0	0	0	1
07/23/2020 19:00	0.0	0	0	0	0	1
07/23/2020 20:00	0.0	0	0	0	0	1
07/23/2020 21:00	0.0	0	0	0	0	1
07/23/2020 22:00	0.0	0	0	0	0	1
07/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/24/2020 00:00	0.0	0	0	0	0	1
07/24/2020 01:00	0.0	0	0	0	0	1
07/24/2020 02:00	0.0	0	0	0	0	1
07/24/2020 03:00	0.0	0	0	0	0	1
07/24/2020 04:00	0.0	0	0	0	0	1
07/24/2020 05:00	0.0	0	0	0	0	1
07/24/2020 06:00	0.0	0	0	0	0	1
07/24/2020 07:00	0.0	0	0	0	0	1
07/24/2020 08:00	0.0	0	0	0	0	0
07/24/2020 09:00	0.0	0	0	0	0	0
07/24/2020 10:00	0.0	0	0	0	0	0
07/24/2020 11:00	0.0	0	0	0	0	0
07/24/2020 12:00	0.0	0	0	0	0	0
07/24/2020 13:00	0.0	0	0	0	0	0
07/24/2020 14:00	0.0	0	0	0	0	0
07/24/2020 15:00	0.0	0	0	0	0	0
07/24/2020 16:00	0.0	0	0	0	0	0
07/24/2020 17:00	0.0	0	0	0	0	0
07/24/2020 18:00	0.0	0	0	0	0	0
07/24/2020 19:00	0.0	0	0	0	0	0
07/24/2020 20:00	0.0	0	0	0	0	0
07/24/2020 21:00	0.0	0	0	0	0	0
07/24/2020 22:00	0.0	0	0	0	0	0
07/24/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/25/2020 00:00	0.0	0	0	0	0	0
07/25/2020 01:00	0.0	0	0	0	0	0
07/25/2020 02:00	0.0	0	0	0	0	0
07/25/2020 03:00	0.0	0	0	0	0	0
07/25/2020 04:00	0.0	0	0	0	0	0
07/25/2020 05:00	0.0	0	0	0	0	0
07/25/2020 06:00	0.0	0	0	0	0	0
07/25/2020 07:00	0.0	0	0	0	0	0
07/25/2020 08:00	0.0	0	0	0	0	0
07/25/2020 09:00	0.0	0	0	0	0	0
07/25/2020 10:00	0.0	0	0	0	0	0
07/25/2020 11:00	0.0	0	0	0	0	0
07/25/2020 12:00	0.0	0	0	0	0	0
07/25/2020 13:00	2,087.6	0	1	0	0	0
07/25/2020 14:00	6,616.4	0	1	0	0	0
07/25/2020 15:00	0.0	0	0	0	0	1
07/25/2020 16:00	0.0	0	0	0	0	1
07/25/2020 17:00	0.0	0	0	0	0	1
07/25/2020 18:00	0.0	0	0	0	0	1
07/25/2020 19:00	0.0	0	0	0	0	1
07/25/2020 20:00	0.0	0	0	0	0	1
07/25/2020 21:00	0.0	0	0	0	0	1
07/25/2020 22:00	0.0	0	0	0	0	1
07/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,704.0 #	0 #	2 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,616.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/26/2020 00:00	0.0	0	0	0	0	1
07/26/2020 01:00	0.0	0	0	0	0	1
07/26/2020 02:00	0.0	0	0	0	0	1
07/26/2020 03:00	0.0	0	0	0	0	1
07/26/2020 04:00	0.0	0	0	0	0	1
07/26/2020 05:00	0.0	0	0	0	0	1
07/26/2020 06:00	0.0	0	0	0	0	1
07/26/2020 07:00	0.0	0	0	0	0	1
07/26/2020 08:00	0.0	0	0	0	0	1
07/26/2020 09:00	0.0	0	0	0	0	1
07/26/2020 10:00	0.0	0	0	0	0	1
07/26/2020 11:00	0.0	0	0	0	0	1
07/26/2020 12:00	0.0	0	0	0	0	1
07/26/2020 13:00	0.0	0	0	0	0	1
07/26/2020 14:00	0.0	0	0	0	0	1
07/26/2020 15:00	0.0	0	0	0	0	1
07/26/2020 16:00	0.0	0	0	0	0	1
07/26/2020 17:00	0.0	0	0	0	0	1
07/26/2020 18:00	0.0	0	0	0	0	1
07/26/2020 19:00	0.0	0	0	0	0	1
07/26/2020 20:00	0.0	0	0	0	0	1
07/26/2020 21:00	0.0	0	0	0	0	1
07/26/2020 22:00	0.0	0	0	0	0	1
07/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/27/2020 00:00	0.0	0	0	0	0	1
07/27/2020 01:00	0.0	0	0	0	0	1
07/27/2020 02:00	0.0	0	0	0	0	1
07/27/2020 03:00	0.0	0	0	0	0	1
07/27/2020 04:00	0.0	0	0	0	0	1
07/27/2020 05:00	0.0	0	0	0	0	1
07/27/2020 06:00	0.0	0	0	0	0	1
07/27/2020 07:00	0.0	0	0	0	0	1
07/27/2020 08:00	0.0	0	0	0	0	1
07/27/2020 09:00	0.0	0	0	0	0	1
07/27/2020 10:00	0.0	0	0	0	0	1
07/27/2020 11:00	0.0	0	0	0	0	1
07/27/2020 12:00	0.0	0	0	0	0	1
07/27/2020 13:00	0.0	0	0	0	0	1
07/27/2020 14:00	0.0	0	0	0	0	1
07/27/2020 15:00	0.0	0	0	0	0	1
07/27/2020 16:00	0.0	0	0	0	0	1
07/27/2020 17:00	0.0	0	0	0	0	1
07/27/2020 18:00	0.0	0	0	0	0	1
07/27/2020 19:00	0.0	0	0	0	0	1
07/27/2020 20:00	0.0	0	0	0	0	1
07/27/2020 21:00	0.0	0	0	0	0	1
07/27/2020 22:00	0.0	0	0	0	0	1
07/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/28/2020 00:00	0.0	0	0	0	0	1
07/28/2020 01:00	0.0	0	0	0	0	1
07/28/2020 02:00	0.0	0	0	0	0	1
07/28/2020 03:00	0.0	0	0	0	0	1
07/28/2020 04:00	0.0	0	0	0	0	1
07/28/2020 05:00	0.0	0	0	0	0	1
07/28/2020 06:00	0.0	0	0	0	0	1
07/28/2020 07:00	0.0	0	0	0	0	1
07/28/2020 08:00	0.0	0	0	0	0	1
07/28/2020 09:00	0.0	0	0	0	0	1
07/28/2020 10:00	0.0	0	0	0	0	1
07/28/2020 11:00	0.0	0	0	0	0	1
07/28/2020 12:00	0.0	0	0	0	0	1
07/28/2020 13:00	0.0	0	0	0	0	1
07/28/2020 14:00	0.0	0	0	0	0	1
07/28/2020 15:00	0.0	0	0	0	0	1
07/28/2020 16:00	0.0	0	0	0	0	1
07/28/2020 17:00	0.0	0	0	0	0	1
07/28/2020 18:00	0.0	0	0	0	0	1
07/28/2020 19:00	0.0	0	0	0	0	1
07/28/2020 20:00	0.0	0	0	0	0	1
07/28/2020 21:00	0.0	0	0	0	0	1
07/28/2020 22:00	0.0	0	0	0	0	1
07/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/29/2020 00:00	0.0	0	0	0	0	1
07/29/2020 01:00	0.0	0	0	0	0	1
07/29/2020 02:00	0.0	0	0	0	0	1
07/29/2020 03:00	0.0	0	0	0	0	1
07/29/2020 04:00	0.0	0	0	0	0	1
07/29/2020 05:00	0.0	0	0	0	0	1
07/29/2020 06:00	0.0	0	0	0	0	1
07/29/2020 07:00	0.0	0	0	0	0	1
07/29/2020 08:00	0.0	0	0	0	0	1
07/29/2020 09:00	0.0	0	0	0	0	1
07/29/2020 10:00	0.0	0	0	0	0	1
07/29/2020 11:00	0.0	0	0	0	0	1
07/29/2020 12:00	0.0	0	0	0	0	1
07/29/2020 13:00	0.0	0	0	0	0	1
07/29/2020 14:00	0.0	0	0	0	0	1
07/29/2020 15:00	0.0	0	0	0	0	1
07/29/2020 16:00	0.0	0	0	0	0	1
07/29/2020 17:00	0.0	0	0	0	0	1
07/29/2020 18:00	0.0	0	0	0	0	1
07/29/2020 19:00	0.0	0	0	0	0	1
07/29/2020 20:00	0.0	0	0	0	0	1
07/29/2020 21:00	0.0	0	0	0	0	1
07/29/2020 22:00	0.0	0	0	0	0	1
07/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/30/2020 00:00	0.0	0	0	0	0	1
07/30/2020 01:00	0.0	0	0	0	0	1
07/30/2020 02:00	0.0	0	0	0	0	1
07/30/2020 03:00	0.0	0	0	0	0	1
07/30/2020 04:00	0.0	0	0	0	0	1
07/30/2020 05:00	0.0	0	0	0	0	1
07/30/2020 06:00	0.0	0	0	0	0	1
07/30/2020 07:00	0.0	0	0	0	0	1
07/30/2020 08:00	0.0	0	0	0	0	1
07/30/2020 09:00	0.0	0	0	0	0	1
07/30/2020 10:00	0.0	0	0	0	0	1
07/30/2020 11:00	0.0	0	0	0	0	1
07/30/2020 12:00	0.0	0	0	0	0	1
07/30/2020 13:00	0.0	0	0	0	0	1
07/30/2020 14:00	0.0	0	0	0	0	1
07/30/2020 15:00	0.0	0	0	0	0	1
07/30/2020 16:00	0.0	0	0	0	0	1
07/30/2020 17:00	0.0	0	0	0	0	1
07/30/2020 18:00	0.0	0	0	0	0	1
07/30/2020 19:00	0.0	0	0	0	0	1
07/30/2020 20:00	0.0	0	0	0	0	1
07/30/2020 21:00	0.0	0	0	0	0	1
07/30/2020 22:00	0.0	0	0	0	0	1
07/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/31/2020 00:00	0.0	0	0	0	0	1
07/31/2020 01:00	0.0	0	0	0	0	1
07/31/2020 02:00	0.0	0	0	0	0	1
07/31/2020 03:00	0.0	0	0	0	0	1
07/31/2020 04:00	0.0	0	0	0	0	1
07/31/2020 05:00	0.0	0	0	0	0	1
07/31/2020 06:00	0.0	0	0	0	0	1
07/31/2020 07:00	0.0	0	0	0	0	1
07/31/2020 08:00	0.0	0	0	0	0	1
07/31/2020 09:00	0.0	0	0	0	0	1
07/31/2020 10:00	0.0	0	0	0	0	1
07/31/2020 11:00	0.0	0	0	0	0	1
07/31/2020 12:00	0.0	0	0	0	0	1
07/31/2020 13:00	0.0	0	0	0	0	1
07/31/2020 14:00	0.0	0	0	0	0	1
07/31/2020 15:00	0.0	0	0	0	0	1
07/31/2020 16:00	0.0	0	0	0	0	1
07/31/2020 17:00	0.0	0	0	0	0	1
07/31/2020 18:00	0.0	0	0	0	0	1
07/31/2020 19:00	0.0	0	0	0	0	1
07/31/2020 20:00	0.0	0	0	0	0	1
07/31/2020 21:00	0.0	0	0	0	0	1
07/31/2020 22:00	0.0	0	0	0	0	1
07/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/01/2020 00:00	0.0	0	0	0	0	1
08/01/2020 01:00	0.0	0	0	0	0	1
08/01/2020 02:00	0.0	0	0	0	0	1
08/01/2020 03:00	0.0	0	0	0	0	1
08/01/2020 04:00	0.0	0	0	0	0	1
08/01/2020 05:00	0.0	0	0	0	0	1
08/01/2020 06:00	0.0	0	0	0	0	1
08/01/2020 07:00	0.0	0	0	0	0	1
08/01/2020 08:00	0.0	0	0	0	0	1
08/01/2020 09:00	0.0	0	0	0	0	1
08/01/2020 10:00	0.0	0	0	0	0	1
08/01/2020 11:00	0.0	0	0	0	0	1
08/01/2020 12:00	0.0	0	0	0	0	1
08/01/2020 13:00	0.0	0	0	0	0	1
08/01/2020 14:00	0.0	0	0	0	0	1
08/01/2020 15:00	0.0	0	0	0	0	1
08/01/2020 16:00	0.0	0	0	0	0	1
08/01/2020 17:00	0.0	0	0	0	0	1
08/01/2020 18:00	0.0	0	0	0	0	1
08/01/2020 19:00	0.0	0	0	0	0	1
08/01/2020 20:00	0.0	0	0	0	0	1
08/01/2020 21:00	0.0	0	0	0	0	1
08/01/2020 22:00	0.0	0	0	0	0	1
08/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/02/2020 00:00	0.0	0	0	0	0	1
08/02/2020 01:00	0.0	0	0	0	0	1
08/02/2020 02:00	0.0	0	0	0	0	1
08/02/2020 03:00	0.0	0	0	0	0	1
08/02/2020 04:00	0.0	0	0	0	0	1
08/02/2020 05:00	0.0	0	0	0	0	1
08/02/2020 06:00	0.0	0	0	0	0	1
08/02/2020 07:00	0.0	0	0	0	0	1
08/02/2020 08:00	0.0	0	0	0	0	1
08/02/2020 09:00	0.0	0	0	0	0	1
08/02/2020 10:00	0.0	0	0	0	0	1
08/02/2020 11:00	0.0	0	0	0	0	1
08/02/2020 12:00	0.0	0	0	0	0	1
08/02/2020 13:00	0.0	0	0	0	0	1
08/02/2020 14:00	0.0	0	0	0	0	1
08/02/2020 15:00	0.0	0	0	0	0	1
08/02/2020 16:00	0.0	0	0	0	0	1
08/02/2020 17:00	0.0	0	0	0	0	1
08/02/2020 18:00	0.0	0	0	0	0	1
08/02/2020 19:00	0.0	0	0	0	0	1
08/02/2020 20:00	0.0	0	0	0	0	1
08/02/2020 21:00	0.0	0	0	0	0	1
08/02/2020 22:00	0.0	0	0	0	0	1
08/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/03/2020 00:00	0.0	0	0	0	0	1
08/03/2020 01:00	0.0	0	0	0	0	1
08/03/2020 02:00	0.0	0	0	0	0	1
08/03/2020 03:00	0.0	0	0	0	0	1
08/03/2020 04:00	0.0	0	0	0	0	1
08/03/2020 05:00	0.0	0	0	0	0	1
08/03/2020 06:00	0.0	0	0	0	0	1
08/03/2020 07:00	0.0	0	0	0	0	1
08/03/2020 08:00	0.0	0	0	0	0	1
08/03/2020 09:00	0.0	0	0	0	0	1
08/03/2020 10:00	0.0	0	0	0	0	1
08/03/2020 11:00	0.0	0	0	0	0	1
08/03/2020 12:00	0.0	0	0	0	0	1
08/03/2020 13:00	0.0	0	0	0	0	1
08/03/2020 14:00	0.0	0	0	0	0	1
08/03/2020 15:00	0.0	0	0	0	0	1
08/03/2020 16:00	0.0	0	0	0	0	1
08/03/2020 17:00	0.0	0	0	0	0	1
08/03/2020 18:00	0.0	0	0	0	0	1
08/03/2020 19:00	0.0	0	0	0	0	1
08/03/2020 20:00	0.0	0	0	0	0	1
08/03/2020 21:00	0.0	0	0	0	0	1
08/03/2020 22:00	0.0	0	0	0	0	1
08/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/04/2020 00:00	0.0	0	0	0	0	1
08/04/2020 01:00	0.0	0	0	0	0	1
08/04/2020 02:00	0.0	0	0	0	0	1
08/04/2020 03:00	0.0	0	0	0	0	1
08/04/2020 04:00	0.0	0	0	0	0	1
08/04/2020 05:00	0.0	0	0	0	0	1
08/04/2020 06:00	0.0	0	0	0	0	1
08/04/2020 07:00	0.0	0	0	0	0	1
08/04/2020 08:00	0.0	0	0	0	0	1
08/04/2020 09:00	0.0	0	0	0	0	1
08/04/2020 10:00	0.0	0	0	0	0	1
08/04/2020 11:00	0.0	0	0	0	0	1
08/04/2020 12:00	0.0	0	0	0	0	1
08/04/2020 13:00	0.0	0	0	0	0	1
08/04/2020 14:00	0.0	0	0	0	0	1
08/04/2020 15:00	0.0	0	0	0	0	1
08/04/2020 16:00	0.0	0	0	0	0	1
08/04/2020 17:00	0.0	0	0	0	0	1
08/04/2020 18:00	0.0	0	0	0	0	1
08/04/2020 19:00	0.0	0	0	0	0	1
08/04/2020 20:00	0.0	0	0	0	0	1
08/04/2020 21:00	0.0	0	0	0	0	1
08/04/2020 22:00	0.0	0	0	0	0	1
08/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/05/2020 00:00	0.0	0	0	0	0	1
08/05/2020 01:00	0.0	0	0	0	0	1
08/05/2020 02:00	0.0	0	0	0	0	1
08/05/2020 03:00	0.0	0	0	0	0	1
08/05/2020 04:00	0.0	0	0	0	0	1
08/05/2020 05:00	0.0	0	0	0	0	1
08/05/2020 06:00	0.0	0	0	0	0	1
08/05/2020 07:00	0.0	0	0	0	0	1
08/05/2020 08:00	0.0	0	0	0	0	1
08/05/2020 09:00	0.0	0	0	0	0	1
08/05/2020 10:00	0.0	0	0	0	0	1
08/05/2020 11:00	0.0	0	0	0	0	1
08/05/2020 12:00	0.0	0	0	0	0	1
08/05/2020 13:00	0.0	0	0	0	0	1
08/05/2020 14:00	0.0	0	0	0	0	1
08/05/2020 15:00	0.0	0	0	0	0	1
08/05/2020 16:00	0.0	0	0	0	0	1
08/05/2020 17:00	0.0	0	0	0	0	1
08/05/2020 18:00	0.0	0	0	0	0	1
08/05/2020 19:00	0.0	0	0	0	0	1
08/05/2020 20:00	0.0	0	0	0	0	1
08/05/2020 21:00	0.0	0	0	0	0	1
08/05/2020 22:00	0.0	0	0	0	0	1
08/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/06/2020 00:00	0.0	0	0	0	0	1
08/06/2020 01:00	0.0	0	0	0	0	1
08/06/2020 02:00	0.0	0	0	0	0	1
08/06/2020 03:00	0.0	0	0	0	0	1
08/06/2020 04:00	0.0	0	0	0	0	1
08/06/2020 05:00	0.0	0	0	0	0	1
08/06/2020 06:00	0.0	0	0	0	0	1
08/06/2020 07:00	0.0	0	0	0	0	1
08/06/2020 08:00	0.0	0	0	0	0	1
08/06/2020 09:00	0.0	0	0	0	0	1
08/06/2020 10:00	0.0	0	0	0	0	1
08/06/2020 11:00	0.0	0	0	0	0	1
08/06/2020 12:00	0.0	0	0	0	0	1
08/06/2020 13:00	0.0	0	0	0	0	1
08/06/2020 14:00	0.0	0	0	0	0	1
08/06/2020 15:00	0.0	0	0	0	0	1
08/06/2020 16:00	0.0	0	0	0	0	1
08/06/2020 17:00	0.0	0	0	0	0	1
08/06/2020 18:00	0.0	0	0	0	0	1
08/06/2020 19:00	0.0	0	0	0	0	1
08/06/2020 20:00	0.0	0	0	0	0	1
08/06/2020 21:00	0.0	0	0	0	0	1
08/06/2020 22:00	0.0	0	0	0	0	1
08/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/07/2020 00:00	0.0	0	0	0	0	1
08/07/2020 01:00	0.0	0	0	0	0	1
08/07/2020 02:00	0.0	0	0	0	0	1
08/07/2020 03:00	0.0	0	0	0	0	1
08/07/2020 04:00	0.0	0	0	0	0	1
08/07/2020 05:00	0.0	0	0	0	0	1
08/07/2020 06:00	0.0	0	0	0	0	1
08/07/2020 07:00	0.0	0	0	0	0	1
08/07/2020 08:00	0.0	0	0	0	0	1
08/07/2020 09:00	0.0	0	0	0	0	1
08/07/2020 10:00	0.0	0	0	0	0	1
08/07/2020 11:00	0.0	0	0	0	0	1
08/07/2020 12:00	0.0	0	0	0	0	1
08/07/2020 13:00	0.0	0	0	0	0	1
08/07/2020 14:00	0.0	0	0	0	0	1
08/07/2020 15:00	0.0	0	0	0	0	1
08/07/2020 16:00	0.0	0	0	0	0	1
08/07/2020 17:00	0.0	0	0	0	0	1
08/07/2020 18:00	0.0	0	0	0	0	1
08/07/2020 19:00	0.0	0	0	0	0	1
08/07/2020 20:00	0.0	0	0	0	0	1
08/07/2020 21:00	0.0	0	0	0	0	1
08/07/2020 22:00	0.0	0	0	0	0	1
08/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/08/2020 00:00	0.0	0	0	0	0	1
08/08/2020 01:00	0.0	0	0	0	0	1
08/08/2020 02:00	0.0	0	0	0	0	1
08/08/2020 03:00	0.0	0	0	0	0	1
08/08/2020 04:00	0.0	0	0	0	0	1
08/08/2020 05:00	0.0	0	0	0	0	1
08/08/2020 06:00	0.0	0	0	0	0	1
08/08/2020 07:00	0.0	0	0	0	0	1
08/08/2020 08:00	0.0	0	0	0	0	1
08/08/2020 09:00	0.0	0	0	0	0	1
08/08/2020 10:00	0.0	0	0	0	0	1
08/08/2020 11:00	0.0	0	0	0	0	1
08/08/2020 12:00	0.0	0	0	0	0	1
08/08/2020 13:00	0.0	0	0	0	0	1
08/08/2020 14:00	0.0	0	0	0	0	1
08/08/2020 15:00	0.0	0	0	0	0	1
08/08/2020 16:00	0.0	0	0	0	0	1
08/08/2020 17:00	0.0	0	0	0	0	1
08/08/2020 18:00	0.0	0	0	0	0	1
08/08/2020 19:00	0.0	0	0	0	0	1
08/08/2020 20:00	0.0	0	0	0	0	1
08/08/2020 21:00	0.0	0	0	0	0	1
08/08/2020 22:00	0.0	0	0	0	0	1
08/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/09/2020 00:00	0.0	0	0	0	0	1
08/09/2020 01:00	0.0	0	0	0	0	1
08/09/2020 02:00	0.0	0	0	0	0	1
08/09/2020 03:00	0.0	0	0	0	0	1
08/09/2020 04:00	0.0	0	0	0	0	1
08/09/2020 05:00	0.0	0	0	0	0	1
08/09/2020 06:00	0.0	0	0	0	0	1
08/09/2020 07:00	0.0	0	0	0	0	1
08/09/2020 08:00	0.0	0	0	0	0	1
08/09/2020 09:00	0.0	0	0	0	0	1
08/09/2020 10:00	0.0	0	0	0	0	1
08/09/2020 11:00	0.0	0	0	0	0	1
08/09/2020 12:00	0.0	0	0	0	0	1
08/09/2020 13:00	0.0	0	0	0	0	1
08/09/2020 14:00	0.0	0	0	0	0	1
08/09/2020 15:00	0.0	0	0	0	0	1
08/09/2020 16:00	0.0	0	0	0	0	1
08/09/2020 17:00	0.0	0	0	0	0	1
08/09/2020 18:00	0.0	0	0	0	0	1
08/09/2020 19:00	0.0	0	0	0	0	1
08/09/2020 20:00	0.0	0	0	0	0	1
08/09/2020 21:00	0.0	0	0	0	0	1
08/09/2020 22:00	0.0	0	0	0	0	1
08/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/10/2020 00:00	0.0	0	0	0	0	1
08/10/2020 01:00	0.0	0	0	0	0	1
08/10/2020 02:00	0.0	0	0	0	0	1
08/10/2020 03:00	0.0	0	0	0	0	1
08/10/2020 04:00	0.0	0	0	0	0	1
08/10/2020 05:00	0.0	0	0	0	0	1
08/10/2020 06:00	0.0	0	0	0	0	1
08/10/2020 07:00	0.0	0	0	0	0	1
08/10/2020 08:00	0.0	0	0	0	0	1
08/10/2020 09:00	0.0	0	0	0	0	1
08/10/2020 10:00	0.0	0	0	0	0	1
08/10/2020 11:00	0.0	0	0	0	0	1
08/10/2020 12:00	0.0	0	0	0	0	1
08/10/2020 13:00	0.0	0	0	0	0	1
08/10/2020 14:00	0.0	0	0	0	0	1
08/10/2020 15:00	0.0	0	0	0	0	1
08/10/2020 16:00	0.0	0	0	0	0	1
08/10/2020 17:00	0.0	0	0	0	0	1
08/10/2020 18:00	0.0	0	0	0	0	1
08/10/2020 19:00	0.0	0	0	0	0	1
08/10/2020 20:00	0.0	0	0	0	0	1
08/10/2020 21:00	0.0	0	0	0	0	1
08/10/2020 22:00	0.0	0	0	0	0	1
08/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/11/2020 00:00	0.0	0	0	0	0	1
08/11/2020 01:00	0.0	0	0	0	0	1
08/11/2020 02:00	0.0	0	0	0	0	1
08/11/2020 03:00	0.0	0	0	0	0	1
08/11/2020 04:00	0.0	0	0	0	0	1
08/11/2020 05:00	0.0	0	0	0	0	1
08/11/2020 06:00	0.0	0	0	0	0	1
08/11/2020 07:00	0.0	0	0	0	0	1
08/11/2020 08:00	0.0	0	0	0	0	1
08/11/2020 09:00	0.0	0	0	0	0	1
08/11/2020 10:00	0.0	0	0	0	0	1
08/11/2020 11:00	0.0	0	0	0	0	1
08/11/2020 12:00	0.0	0	0	0	0	1
08/11/2020 13:00	0.0	0	0	0	0	1
08/11/2020 14:00	0.0	0	0	0	0	1
08/11/2020 15:00	0.0	0	0	0	0	1
08/11/2020 16:00	0.0	0	0	0	0	1
08/11/2020 17:00	0.0	0	0	0	0	1
08/11/2020 18:00	0.0	0	0	0	0	1
08/11/2020 19:00	0.0	0	0	0	0	1
08/11/2020 20:00	0.0	0	0	0	0	1
08/11/2020 21:00	0.0	0	0	0	0	1
08/11/2020 22:00	0.0	0	0	0	0	1
08/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/12/2020 00:00	0.0	0	0	0	0	1
08/12/2020 01:00	0.0	0	0	0	0	1
08/12/2020 02:00	0.0	0	0	0	0	1
08/12/2020 03:00	0.0	0	0	0	0	1
08/12/2020 04:00	0.0	0	0	0	0	1
08/12/2020 05:00	0.0	0	0	0	0	1
08/12/2020 06:00	0.0	0	0	0	0	1
08/12/2020 07:00	0.0	0	0	0	0	1
08/12/2020 08:00	0.0	0	0	0	0	1
08/12/2020 09:00	0.0	0	0	0	0	1
08/12/2020 10:00	0.0	0	0	0	0	1
08/12/2020 11:00	0.0	0	0	0	0	1
08/12/2020 12:00	0.0	0	0	0	0	1
08/12/2020 13:00	0.0	0	0	0	0	1
08/12/2020 14:00	0.0	0	0	0	0	1
08/12/2020 15:00	0.0	0	0	0	0	1
08/12/2020 16:00	0.0	0	0	0	0	1
08/12/2020 17:00	0.0	0	0	0	0	1
08/12/2020 18:00	0.0	0	0	0	0	1
08/12/2020 19:00	0.0	0	0	0	0	1
08/12/2020 20:00	0.0	0	0	0	0	1
08/12/2020 21:00	0.0	0	0	0	0	1
08/12/2020 22:00	0.0	0	0	0	0	1
08/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/13/2020 00:00	0.0	0	0	0	0	1
08/13/2020 01:00	0.0	0	0	0	0	1
08/13/2020 02:00	0.0	0	0	0	0	1
08/13/2020 03:00	0.0	0	0	0	0	1
08/13/2020 04:00	0.0	0	0	0	0	1
08/13/2020 05:00	0.0	0	0	0	0	1
08/13/2020 06:00	0.0	0	0	0	0	1
08/13/2020 07:00	0.0	0	0	0	0	1
08/13/2020 08:00	0.0	0	0	0	0	1
08/13/2020 09:00	0.0	0	0	0	0	1
08/13/2020 10:00	0.0	0	0	0	0	1
08/13/2020 11:00	0.0	0	0	0	0	1
08/13/2020 12:00	0.0	0	0	0	0	1
08/13/2020 13:00	0.0	0	0	0	0	1
08/13/2020 14:00	0.0	0	0	0	0	1
08/13/2020 15:00	0.0	0	0	0	0	1
08/13/2020 16:00	0.0	0	0	0	0	1
08/13/2020 17:00	0.0	0	0	0	0	1
08/13/2020 18:00	0.0	0	0	0	0	1
08/13/2020 19:00	0.0	0	0	0	0	1
08/13/2020 20:00	0.0	0	0	0	0	1
08/13/2020 21:00	0.0	0	0	0	0	1
08/13/2020 22:00	0.0	0	0	0	0	1
08/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/14/2020 00:00	0.0	0	0	0	0	1
08/14/2020 01:00	0.0	0	0	0	0	1
08/14/2020 02:00	0.0	0	0	0	0	1
08/14/2020 03:00	0.0	0	0	0	0	1
08/14/2020 04:00	0.0	0	0	0	0	1
08/14/2020 05:00	0.0	0	0	0	0	1
08/14/2020 06:00	0.0	0	0	0	0	1
08/14/2020 07:00	0.0	0	0	0	0	1
08/14/2020 08:00	0.0	0	0	0	0	1
08/14/2020 09:00	0.0	0	0	0	0	1
08/14/2020 10:00	0.0	0	0	0	0	1
08/14/2020 11:00	0.0	0	0	0	0	1
08/14/2020 12:00	0.0	0	0	0	0	1
08/14/2020 13:00	0.0	0	0	0	0	1
08/14/2020 14:00	0.0	0	0	0	0	1
08/14/2020 15:00	0.0	0	0	0	0	1
08/14/2020 16:00	0.0	0	0	0	0	1
08/14/2020 17:00	0.0	0	0	0	0	1
08/14/2020 18:00	0.0	0	0	0	0	1
08/14/2020 19:00	0.0	0	0	0	0	1
08/14/2020 20:00	0.0	0	0	0	0	1
08/14/2020 21:00	0.0	0	0	0	0	1
08/14/2020 22:00	0.0	0	0	0	0	1
08/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/15/2020 00:00	0.0	0	0	0	0	1
08/15/2020 01:00	0.0	0	0	0	0	1
08/15/2020 02:00	0.0	0	0	0	0	1
08/15/2020 03:00	0.0	0	0	0	0	1
08/15/2020 04:00	0.0	0	0	0	0	1
08/15/2020 05:00	0.0	0	0	0	0	1
08/15/2020 06:00	0.0	0	0	0	0	1
08/15/2020 07:00	0.0	0	0	0	0	1
08/15/2020 08:00	0.0	0	0	0	0	1
08/15/2020 09:00	0.0	0	0	0	0	1
08/15/2020 10:00	0.0	0	0	0	0	1
08/15/2020 11:00	0.0	0	0	0	0	1
08/15/2020 12:00	0.0	0	0	0	0	1
08/15/2020 13:00	0.0	0	0	0	0	1
08/15/2020 14:00	0.0	0	0	0	0	1
08/15/2020 15:00	0.0	0	0	0	0	1
08/15/2020 16:00	0.0	0	0	0	0	1
08/15/2020 17:00	0.0	0	0	0	0	1
08/15/2020 18:00	0.0	0	0	0	0	1
08/15/2020 19:00	0.0	0	0	0	0	1
08/15/2020 20:00	0.0	0	0	0	0	1
08/15/2020 21:00	0.0	0	0	0	0	1
08/15/2020 22:00	0.0	0	0	0	0	1
08/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/16/2020 00:00	0.0	0	0	0	0	1
08/16/2020 01:00	0.0	0	0	0	0	1
08/16/2020 02:00	0.0	0	0	0	0	1
08/16/2020 03:00	0.0	0	0	0	0	1
08/16/2020 04:00	0.0	0	0	0	0	1
08/16/2020 05:00	0.0	0	0	0	0	1
08/16/2020 06:00	0.0	0	0	0	0	1
08/16/2020 07:00	0.0	0	0	0	0	1
08/16/2020 08:00	0.0	0	0	0	0	1
08/16/2020 09:00	0.0	0	0	0	0	1
08/16/2020 10:00	0.0	0	0	0	0	1
08/16/2020 11:00	0.0	0	0	0	0	1
08/16/2020 12:00	0.0	0	0	0	0	1
08/16/2020 13:00	0.0	0	0	0	0	1
08/16/2020 14:00	0.0	0	0	0	0	1
08/16/2020 15:00	0.0	0	0	0	0	1
08/16/2020 16:00	0.0	0	0	0	0	1
08/16/2020 17:00	0.0	0	0	0	0	1
08/16/2020 18:00	0.0	0	0	0	0	1
08/16/2020 19:00	0.0	0	0	0	0	1
08/16/2020 20:00	0.0	0	0	0	0	1
08/16/2020 21:00	0.0	0	0	0	0	1
08/16/2020 22:00	0.0	0	0	0	0	1
08/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/17/2020 00:00	0.0	0	0	0	0	1
08/17/2020 01:00	0.0	0	0	0	0	1
08/17/2020 02:00	0.0	0	0	0	0	1
08/17/2020 03:00	0.0	0	0	0	0	1
08/17/2020 04:00	0.0	0	0	0	0	1
08/17/2020 05:00	0.0	0	0	0	0	1
08/17/2020 06:00	0.0	0	0	0	0	1
08/17/2020 07:00	0.0	0	0	0	0	1
08/17/2020 08:00	0.0	0	0	0	0	1
08/17/2020 09:00	0.0	0	0	0	0	1
08/17/2020 10:00	0.0	0	0	0	0	1
08/17/2020 11:00	0.0	0	0	0	0	1
08/17/2020 12:00	0.0	0	0	0	0	1
08/17/2020 13:00	0.0	0	0	0	0	1
08/17/2020 14:00	0.0	0	0	0	0	1
08/17/2020 15:00	0.0	0	0	0	0	1
08/17/2020 16:00	0.0	0	0	0	0	1
08/17/2020 17:00	0.0	0	0	0	0	1
08/17/2020 18:00	0.0	0	0	0	0	1
08/17/2020 19:00	0.0	0	0	0	0	1
08/17/2020 20:00	0.0	0	0	0	0	1
08/17/2020 21:00	0.0	0	0	0	0	1
08/17/2020 22:00	0.0	0	0	0	0	1
08/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/18/2020 00:00	0.0	0	0	0	0	1
08/18/2020 01:00	0.0	0	0	0	0	1
08/18/2020 02:00	0.0	0	0	0	0	1
08/18/2020 03:00	0.0	0	0	0	0	1
08/18/2020 04:00	0.0	0	0	0	0	1
08/18/2020 05:00	0.0	0	0	0	0	1
08/18/2020 06:00	0.0	0	0	0	0	1
08/18/2020 07:00	0.0	0	0	0	0	1
08/18/2020 08:00	0.0	0	0	0	0	1
08/18/2020 09:00	0.0	0	0	0	0	1
08/18/2020 10:00	0.0	0	0	0	0	1
08/18/2020 11:00	0.0	0	0	0	0	1
08/18/2020 12:00	0.0	0	0	0	0	1
08/18/2020 13:00	0.0	0	0	0	0	1
08/18/2020 14:00	0.0	0	0	0	0	1
08/18/2020 15:00	0.0	0	0	0	0	1
08/18/2020 16:00	0.0	0	0	0	0	1
08/18/2020 17:00	0.0	0	0	0	0	1
08/18/2020 18:00	0.0	0	0	0	0	1
08/18/2020 19:00	0.0	0	0	0	0	1
08/18/2020 20:00	0.0	0	0	0	0	1
08/18/2020 21:00	0.0	0	0	0	0	1
08/18/2020 22:00	0.0	0	0	0	0	1
08/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/19/2020 00:00	0.0	0	0	0	0	1
08/19/2020 01:00	0.0	0	0	0	0	1
08/19/2020 02:00	0.0	0	0	0	0	1
08/19/2020 03:00	0.0	0	0	0	0	1
08/19/2020 04:00	0.0	0	0	0	0	1
08/19/2020 05:00	0.0	0	0	0	0	1
08/19/2020 06:00	0.0	0	0	0	0	1
08/19/2020 07:00	0.0	0	0	0	0	1
08/19/2020 08:00	0.0	0	0	0	0	1
08/19/2020 09:00	0.0	0	0	0	0	1
08/19/2020 10:00	0.0	0	0	0	0	1
08/19/2020 11:00	0.0	0	0	0	0	1
08/19/2020 12:00	0.0	0	0	0	0	1
08/19/2020 13:00	0.0	0	0	0	0	1
08/19/2020 14:00	0.0	0	0	0	0	1
08/19/2020 15:00	0.0	0	0	0	0	1
08/19/2020 16:00	0.0	0	0	0	0	1
08/19/2020 17:00	0.0	0	0	0	0	1
08/19/2020 18:00	0.0	0	0	0	0	1
08/19/2020 19:00	0.0	0	0	0	0	1
08/19/2020 20:00	0.0	0	0	0	0	1
08/19/2020 21:00	0.0	0	0	0	0	1
08/19/2020 22:00	0.0	0	0	0	0	1
08/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/20/2020 00:00	0.0	0	0	0	0	1
08/20/2020 01:00	0.0	0	0	0	0	1
08/20/2020 02:00	0.0	0	0	0	0	1
08/20/2020 03:00	0.0	0	0	0	0	1
08/20/2020 04:00	0.0	0	0	0	0	1
08/20/2020 05:00	0.0	0	0	0	0	1
08/20/2020 06:00	0.0	0	0	0	0	1
08/20/2020 07:00	0.0	0	0	0	0	1
08/20/2020 08:00	0.0	0	0	0	0	1
08/20/2020 09:00	0.0	0	0	0	0	1
08/20/2020 10:00	0.0	0	0	0	0	1
08/20/2020 11:00	0.0	0	0	0	0	1
08/20/2020 12:00	0.0	0	0	0	0	1
08/20/2020 13:00	0.0	0	0	0	0	1
08/20/2020 14:00	0.0	0	0	0	0	1
08/20/2020 15:00	0.0	0	0	0	0	1
08/20/2020 16:00	0.0	0	0	0	0	1
08/20/2020 17:00	0.0	0	0	0	0	1
08/20/2020 18:00	0.0	0	0	0	0	1
08/20/2020 19:00	0.0	0	0	0	0	1
08/20/2020 20:00	0.0	0	0	0	0	1
08/20/2020 21:00	0.0	0	0	0	0	1
08/20/2020 22:00	0.0	0	0	0	0	1
08/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/21/2020 00:00	0.0	0	0	0	0	1
08/21/2020 01:00	0.0	0	0	0	0	1
08/21/2020 02:00	0.0	0	0	0	0	1
08/21/2020 03:00	0.0	0	0	0	0	1
08/21/2020 04:00	0.0	0	0	0	0	1
08/21/2020 05:00	0.0	0	0	0	0	1
08/21/2020 06:00	0.0	0	0	0	0	1
08/21/2020 07:00	0.0	0	0	0	0	1
08/21/2020 08:00	0.0	0	0	0	0	1
08/21/2020 09:00	0.0	0	0	0	0	1
08/21/2020 10:00	0.0	0	0	0	0	1
08/21/2020 11:00	0.0	0	0	0	0	1
08/21/2020 12:00	0.0	0	0	0	0	1
08/21/2020 13:00	0.0	0	0	0	0	1
08/21/2020 14:00	0.0	0	0	0	0	1
08/21/2020 15:00	0.0	0	0	0	0	1
08/21/2020 16:00	0.0	0	0	0	0	1
08/21/2020 17:00	0.0	0	0	0	0	1
08/21/2020 18:00	0.0	0	0	0	0	1
08/21/2020 19:00	0.0	0	0	0	0	1
08/21/2020 20:00	0.0	0	0	0	0	1
08/21/2020 21:00	0.0	0	0	0	0	1
08/21/2020 22:00	0.0	0	0	0	0	1
08/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/22/2020 00:00	0.0	0	0	0	0	1
08/22/2020 01:00	0.0	0	0	0	0	1
08/22/2020 02:00	0.0	0	0	0	0	1
08/22/2020 03:00	0.0	0	0	0	0	1
08/22/2020 04:00	0.0	0	0	0	0	1
08/22/2020 05:00	0.0	0	0	0	0	1
08/22/2020 06:00	0.0	0	0	0	0	1
08/22/2020 07:00	0.0	0	0	0	0	1
08/22/2020 08:00	0.0	0	0	0	0	1
08/22/2020 09:00	0.0	0	0	0	0	1
08/22/2020 10:00	0.0	0	0	0	0	1
08/22/2020 11:00	0.0	0	0	0	0	1
08/22/2020 12:00	0.0	0	0	0	0	1
08/22/2020 13:00	0.0	0	0	0	0	1
08/22/2020 14:00	0.0	0	0	0	0	1
08/22/2020 15:00	0.0	0	0	0	0	1
08/22/2020 16:00	0.0	0	0	0	0	1
08/22/2020 17:00	0.0	0	0	0	0	1
08/22/2020 18:00	0.0	0	0	0	0	1
08/22/2020 19:00	0.0	0	0	0	0	1
08/22/2020 20:00	0.0	0	0	0	0	1
08/22/2020 21:00	0.0	0	0	0	0	1
08/22/2020 22:00	0.0	0	0	0	0	1
08/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/23/2020 00:00	0.0	0	0	0	0	1
08/23/2020 01:00	0.0	0	0	0	0	1
08/23/2020 02:00	0.0	0	0	0	0	1
08/23/2020 03:00	0.0	0	0	0	0	1
08/23/2020 04:00	0.0	0	0	0	0	1
08/23/2020 05:00	0.0	0	0	0	0	1
08/23/2020 06:00	0.0	0	0	0	0	1
08/23/2020 07:00	0.0	0	0	0	0	1
08/23/2020 08:00	0.0	0	0	0	0	1
08/23/2020 09:00	0.0	0	0	0	0	1
08/23/2020 10:00	0.0	0	0	0	0	1
08/23/2020 11:00	0.0	0	0	0	0	1
08/23/2020 12:00	0.0	0	0	0	0	1
08/23/2020 13:00	0.0	0	0	0	0	1
08/23/2020 14:00	0.0	0	0	0	0	1
08/23/2020 15:00	0.0	0	0	0	0	1
08/23/2020 16:00	0.0	0	0	0	0	1
08/23/2020 17:00	0.0	0	0	0	0	1
08/23/2020 18:00	0.0	0	0	0	0	1
08/23/2020 19:00	0.0	0	0	0	0	1
08/23/2020 20:00	0.0	0	0	0	0	1
08/23/2020 21:00	0.0	0	0	0	0	1
08/23/2020 22:00	0.0	0	0	0	0	1
08/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/24/2020 00:00	0.0	0	0	0	0	1
08/24/2020 01:00	0.0	0	0	0	0	1
08/24/2020 02:00	0.0	0	0	0	0	1
08/24/2020 03:00	0.0	0	0	0	0	1
08/24/2020 04:00	0.0	0	0	0	0	1
08/24/2020 05:00	0.0	0	0	0	0	1
08/24/2020 06:00	0.0	0	0	0	0	1
08/24/2020 07:00	0.0	0	0	0	0	1
08/24/2020 08:00	0.0	0	0	0	0	1
08/24/2020 09:00	0.0	0	0	0	0	1
08/24/2020 10:00	0.0	0	0	0	0	1
08/24/2020 11:00	0.0	0	0	0	0	1
08/24/2020 12:00	0.0	0	0	0	0	1
08/24/2020 13:00	0.0	0	0	0	0	1
08/24/2020 14:00	0.0	0	0	0	0	1
08/24/2020 15:00	0.0	0	0	0	0	1
08/24/2020 16:00	0.0	0	0	0	0	1
08/24/2020 17:00	0.0	0	0	0	0	1
08/24/2020 18:00	0.0	0	0	0	0	1
08/24/2020 19:00	0.0	0	0	0	0	1
08/24/2020 20:00	0.0	0	0	0	0	1
08/24/2020 21:00	0.0	0	0	0	0	1
08/24/2020 22:00	0.0	0	0	0	0	1
08/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/25/2020 00:00	0.0	0	0	0	0	1
08/25/2020 01:00	0.0	0	0	0	0	1
08/25/2020 02:00	0.0	0	0	0	0	1
08/25/2020 03:00	0.0	0	0	0	0	1
08/25/2020 04:00	0.0	0	0	0	0	1
08/25/2020 05:00	0.0	0	0	0	0	1
08/25/2020 06:00	0.0	0	0	0	0	1
08/25/2020 07:00	0.0	0	0	0	0	1
08/25/2020 08:00	0.0	0	0	0	0	1
08/25/2020 09:00	0.0	0	0	0	0	1
08/25/2020 10:00	0.0	0	0	0	0	1
08/25/2020 11:00	0.0	0	0	0	0	1
08/25/2020 12:00	0.0	0	0	0	0	1
08/25/2020 13:00	0.0	0	0	0	0	1
08/25/2020 14:00	0.0	0	0	0	0	1
08/25/2020 15:00	0.0	0	0	0	0	1
08/25/2020 16:00	0.0	0	0	0	0	1
08/25/2020 17:00	0.0	0	0	0	0	1
08/25/2020 18:00	0.0	0	0	0	0	1
08/25/2020 19:00	0.0	0	0	0	0	1
08/25/2020 20:00	0.0	0	0	0	0	1
08/25/2020 21:00	0.0	0	0	0	0	1
08/25/2020 22:00	0.0	0	0	0	0	1
08/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/26/2020 00:00	0.0	0	0	0	0	1
08/26/2020 01:00	0.0	0	0	0	0	1
08/26/2020 02:00	0.0	0	0	0	0	1
08/26/2020 03:00	0.0	0	0	0	0	1
08/26/2020 04:00	0.0	0	0	0	0	1
08/26/2020 05:00	0.0	0	0	0	0	1
08/26/2020 06:00	0.0	0	0	0	0	1
08/26/2020 07:00	0.0	0	0	0	0	1
08/26/2020 08:00	0.0	0	0	0	0	1
08/26/2020 09:00	0.0	0	0	0	0	1
08/26/2020 10:00	0.0	0	0	0	0	1
08/26/2020 11:00	0.0	0	0	0	0	1
08/26/2020 12:00	0.0	0	0	0	0	1
08/26/2020 13:00	0.0	0	0	0	0	1
08/26/2020 14:00	0.0	0	0	0	0	1
08/26/2020 15:00	0.0	0	0	0	0	1
08/26/2020 16:00	0.0	0	0	0	0	1
08/26/2020 17:00	0.0	0	0	0	0	1
08/26/2020 18:00	0.0	0	0	0	0	1
08/26/2020 19:00	0.0	0	0	0	0	1
08/26/2020 20:00	0.0	0	0	0	0	1
08/26/2020 21:00	0.0	0	0	0	0	1
08/26/2020 22:00	0.0	0	0	0	0	1
08/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/27/2020 00:00	0.0	0	0	0	0	1
08/27/2020 01:00	0.0	0	0	0	0	1
08/27/2020 02:00	0.0	0	0	0	0	1
08/27/2020 03:00	0.0	0	0	0	0	1
08/27/2020 04:00	0.0	0	0	0	0	1
08/27/2020 05:00	0.0	0	0	0	0	1
08/27/2020 06:00	0.0	0	0	0	0	1
08/27/2020 07:00	0.0	0	0	0	0	1
08/27/2020 08:00	0.0	0	0	0	0	1
08/27/2020 09:00	0.0	0	0	0	0	1
08/27/2020 10:00	0.0	0	0	0	0	1
08/27/2020 11:00	0.0	0	0	0	0	1
08/27/2020 12:00	0.0	0	0	0	0	1
08/27/2020 13:00	0.0	0	0	0	0	1
08/27/2020 14:00	0.0	0	0	0	0	1
08/27/2020 15:00	0.0	0	0	0	0	1
08/27/2020 16:00	0.0	0	0	0	0	1
08/27/2020 17:00	0.0	0	0	0	0	1
08/27/2020 18:00	0.0	0	0	0	0	1
08/27/2020 19:00	0.0	0	0	0	0	1
08/27/2020 20:00	0.0	0	0	0	0	1
08/27/2020 21:00	0.0	0	0	0	0	1
08/27/2020 22:00	0.0	0	0	0	0	1
08/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/28/2020 00:00	0.0	0	0	0	0	1
08/28/2020 01:00	0.0	0	0	0	0	1
08/28/2020 02:00	0.0	0	0	0	0	1
08/28/2020 03:00	0.0	0	0	0	0	1
08/28/2020 04:00	0.0	0	0	0	0	1
08/28/2020 05:00	0.0	0	0	0	0	1
08/28/2020 06:00	0.0	0	0	0	0	1
08/28/2020 07:00	0.0	0	0	0	0	1
08/28/2020 08:00	0.0	0	0	0	0	1
08/28/2020 09:00	0.0	0	0	0	0	1
08/28/2020 10:00	0.0	0	0	0	0	1
08/28/2020 11:00	0.0	0	0	0	0	1
08/28/2020 12:00	0.0	0	0	0	0	1
08/28/2020 13:00	0.0	0	0	0	0	1
08/28/2020 14:00	0.0	0	0	0	0	1
08/28/2020 15:00	0.0	0	0	0	0	1
08/28/2020 16:00	0.0	0	0	0	0	1
08/28/2020 17:00	0.0	0	0	0	0	1
08/28/2020 18:00	0.0	0	0	0	0	1
08/28/2020 19:00	0.0	0	0	0	0	1
08/28/2020 20:00	0.0	0	0	0	0	1
08/28/2020 21:00	0.0	0	0	0	0	1
08/28/2020 22:00	0.0	0	0	0	0	1
08/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/29/2020 00:00	0.0	0	0	0	0	1
08/29/2020 01:00	0.0	0	0	0	0	1
08/29/2020 02:00	0.0	0	0	0	0	1
08/29/2020 03:00	0.0	0	0	0	0	1
08/29/2020 04:00	0.0	0	0	0	0	1
08/29/2020 05:00	0.0	0	0	0	0	1
08/29/2020 06:00	0.0	0	0	0	0	1
08/29/2020 07:00	0.0	0	0	0	0	1
08/29/2020 08:00	0.0	0	0	0	0	1
08/29/2020 09:00	0.0	0	0	0	0	1
08/29/2020 10:00	0.0	0	0	0	0	1
08/29/2020 11:00	0.0	0	0	0	0	1
08/29/2020 12:00	0.0	0	0	0	0	1
08/29/2020 13:00	0.0	0	0	0	0	1
08/29/2020 14:00	0.0	0	0	0	0	1
08/29/2020 15:00	0.0	0	0	0	0	1
08/29/2020 16:00	0.0	0	0	0	0	1
08/29/2020 17:00	0.0	0	0	0	0	1
08/29/2020 18:00	0.0	0	0	0	0	1
08/29/2020 19:00	0.0	0	0	0	0	1
08/29/2020 20:00	0.0	0	0	0	0	1
08/29/2020 21:00	0.0	0	0	0	0	1
08/29/2020 22:00	0.0	0	0	0	0	1
08/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/30/2020 00:00	0.0	0	0	0	0	1
08/30/2020 01:00	0.0	0	0	0	0	1
08/30/2020 02:00	0.0	0	0	0	0	1
08/30/2020 03:00	0.0	0	0	0	0	1
08/30/2020 04:00	0.0	0	0	0	0	1
08/30/2020 05:00	0.0	0	0	0	0	1
08/30/2020 06:00	0.0	0	0	0	0	1
08/30/2020 07:00	0.0	0	0	0	0	1
08/30/2020 08:00	0.0	0	0	0	0	1
08/30/2020 09:00	0.0	0	0	0	0	1
08/30/2020 10:00	0.0	0	0	0	0	1
08/30/2020 11:00	0.0	0	0	0	0	1
08/30/2020 12:00	0.0	0	0	0	0	1
08/30/2020 13:00	0.0	0	0	0	0	1
08/30/2020 14:00	0.0	0	0	0	0	1
08/30/2020 15:00	0.0	0	0	0	0	1
08/30/2020 16:00	0.0	0	0	0	0	1
08/30/2020 17:00	0.0	0	0	0	0	1
08/30/2020 18:00	0.0	0	0	0	0	1
08/30/2020 19:00	0.0	0	0	0	0	1
08/30/2020 20:00	0.0	0	0	0	0	1
08/30/2020 21:00	0.0	0	0	0	0	1
08/30/2020 22:00	0.0	0	0	0	0	1
08/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/31/2020 00:00	0.0	0	0	0	0	1
08/31/2020 01:00	0.0	0	0	0	0	1
08/31/2020 02:00	0.0	0	0	0	0	1
08/31/2020 03:00	0.0	0	0	0	0	1
08/31/2020 04:00	0.0	0	0	0	0	1
08/31/2020 05:00	0.0	0	0	0	0	1
08/31/2020 06:00	0.0	0	0	0	0	1
08/31/2020 07:00	0.0	0	0	0	0	1
08/31/2020 08:00	0.0	0	0	0	0	1
08/31/2020 09:00	0.0	0	0	0	0	1
08/31/2020 10:00	0.0	0	0	0	0	1
08/31/2020 11:00	0.0	0	0	0	0	1
08/31/2020 12:00	0.0	0	0	0	0	1
08/31/2020 13:00	0.0	0	0	0	0	1
08/31/2020 14:00	0.0	0	0	0	0	1
08/31/2020 15:00	0.0	0	0	0	0	1
08/31/2020 16:00	0.0	0	0	0	0	1
08/31/2020 17:00	0.0	0	0	0	0	1
08/31/2020 18:00	0.0	0	0	0	0	1
08/31/2020 19:00	0.0	0	0	0	0	1
08/31/2020 20:00	0.0	0	0	0	0	1
08/31/2020 21:00	0.0	0	0	0	0	1
08/31/2020 22:00	0.0	0	0	0	0	1
08/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/01/2020 00:00	0.0	0	0	0	0	1
09/01/2020 01:00	0.0	0	0	0	0	1
09/01/2020 02:00	0.0	0	0	0	0	1
09/01/2020 03:00	0.0	0	0	0	0	1
09/01/2020 04:00	0.0	0	0	0	0	1
09/01/2020 05:00	0.0	0	0	0	0	1
09/01/2020 06:00	0.0	0	0	0	0	1
09/01/2020 07:00	0.0	0	0	0	0	1
09/01/2020 08:00	0.0	0	0	0	0	1
09/01/2020 09:00	0.0	0	0	0	0	1
09/01/2020 10:00	0.0	0	0	0	0	1
09/01/2020 11:00	0.0	0	0	0	0	1
09/01/2020 12:00	0.0	0	0	0	0	1
09/01/2020 13:00	0.0	0	0	0	0	1
09/01/2020 14:00	0.0	0	0	0	0	1
09/01/2020 15:00	0.0	0	0	0	0	1
09/01/2020 16:00	0.0	0	0	0	0	1
09/01/2020 17:00	0.0	0	0	0	0	1
09/01/2020 18:00	0.0	0	0	0	0	1
09/01/2020 19:00	0.0	0	0	0	0	1
09/01/2020 20:00	0.0	0	0	0	0	1
09/01/2020 21:00	0.0	0	0	0	0	1
09/01/2020 22:00	0.0	0	0	0	0	1
09/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/02/2020 00:00	0.0	0	0	0	0	1
09/02/2020 01:00	0.0	0	0	0	0	1
09/02/2020 02:00	0.0	0	0	0	0	1
09/02/2020 03:00	0.0	0	0	0	0	1
09/02/2020 04:00	0.0	0	0	0	0	1
09/02/2020 05:00	0.0	0	0	0	0	1
09/02/2020 06:00	0.0	0	0	0	0	1
09/02/2020 07:00	131.9	0	0	0	1	0
09/02/2020 08:00	0.0	0	0	0	0	0
09/02/2020 09:00	0.0	0	0	0	0	0
09/02/2020 10:00	0.0	0	0	0	0	0
09/02/2020 11:00	0.0	0	0	0	0	0
09/02/2020 12:00	0.0	0	0	0	0	0
09/02/2020 13:00	0.0	0	0	0	0	0
09/02/2020 14:00	0.0	0	0	0	0	0
09/02/2020 15:00	0.0	0	0	0	0	0
09/02/2020 16:00	0.0	0	0	0	0	0
09/02/2020 17:00	0.0	0	0	0	0	0
09/02/2020 18:00	0.0	0	0	0	0	0
09/02/2020 19:00	0.0	0	0	0	0	0
09/02/2020 20:00	0.0	0	0	0	0	0
09/02/2020 21:00	0.0	0	0	0	0	0
09/02/2020 22:00	0.0	0	0	0	0	0
09/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	131.9 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	131.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/03/2020 00:00	0.0	0	0	0	0	0
09/03/2020 01:00	0.0	0	0	0	0	0
09/03/2020 02:00	0.0	0	0	0	0	0
09/03/2020 03:00	1,831.6	0	1	0	0	0
09/03/2020 04:00	5,579.8	0	1	0	0	0
09/03/2020 05:00	0.0	0	0	0	0	1
09/03/2020 06:00	0.0	0	0	0	0	1
09/03/2020 07:00	0.0	0	0	0	0	1
09/03/2020 08:00	0.0	0	0	0	0	1
09/03/2020 09:00	0.0	0	0	0	0	1
09/03/2020 10:00	0.0	0	0	0	0	1
09/03/2020 11:00	0.0	0	0	0	0	1
09/03/2020 12:00	0.0	0	0	0	0	1
09/03/2020 13:00	0.0	0	0	0	0	1
09/03/2020 14:00	0.0	0	0	0	0	1
09/03/2020 15:00	0.0	0	0	0	0	1
09/03/2020 16:00	0.0	0	0	0	0	1
09/03/2020 17:00	0.0	0	0	0	0	1
09/03/2020 18:00	0.0	0	0	0	0	1
09/03/2020 19:00	0.0	0	0	0	0	1
09/03/2020 20:00	0.0	0	0	0	0	1
09/03/2020 21:00	0.0	0	0	0	0	1
09/03/2020 22:00	0.0	0	0	0	0	1
09/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,411.4 #	0 #	2 #	0 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,579.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/04/2020 00:00	0.0	0	0	0	0	1
09/04/2020 01:00	0.0	0	0	0	0	1
09/04/2020 02:00	0.0	0	0	0	0	1
09/04/2020 03:00	0.0	0	0	0	0	1
09/04/2020 04:00	0.0	0	0	0	0	1
09/04/2020 05:00	0.0	0	0	0	0	1
09/04/2020 06:00	0.0	0	0	0	0	1
09/04/2020 07:00	0.0	0	0	0	0	1
09/04/2020 08:00	0.0	0	0	0	0	1
09/04/2020 09:00	0.0	0	0	0	0	1
09/04/2020 10:00	0.0	0	0	0	0	1
09/04/2020 11:00	0.0	0	0	0	0	1
09/04/2020 12:00	0.0	0	0	0	0	1
09/04/2020 13:00	0.0	0	0	0	0	1
09/04/2020 14:00	0.0	0	0	0	0	1
09/04/2020 15:00	0.0	0	0	0	0	1
09/04/2020 16:00	0.0	0	0	0	0	1
09/04/2020 17:00	0.0	0	0	0	0	1
09/04/2020 18:00	0.0	0	0	0	0	1
09/04/2020 19:00	0.0	0	0	0	0	1
09/04/2020 20:00	0.0	0	0	0	0	1
09/04/2020 21:00	0.0	0	0	0	0	1
09/04/2020 22:00	0.0	0	0	0	0	1
09/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/05/2020 00:00	0.0	0	0	0	0	1
09/05/2020 01:00	0.0	0	0	0	0	1
09/05/2020 02:00	0.0	0	0	0	0	1
09/05/2020 03:00	0.0	0	0	0	0	1
09/05/2020 04:00	0.0	0	0	0	0	1
09/05/2020 05:00	0.0	0	0	0	0	1
09/05/2020 06:00	0.0	0	0	0	0	1
09/05/2020 07:00	0.0	0	0	0	0	1
09/05/2020 08:00	0.0	0	0	0	0	1
09/05/2020 09:00	0.0	0	0	0	0	1
09/05/2020 10:00	0.0	0	0	0	0	1
09/05/2020 11:00	0.0	0	0	0	0	1
09/05/2020 12:00	0.0	0	0	0	0	1
09/05/2020 13:00	0.0	0	0	0	0	1
09/05/2020 14:00	0.0	0	0	0	0	1
09/05/2020 15:00	0.0	0	0	0	0	1
09/05/2020 16:00	0.0	0	0	0	0	1
09/05/2020 17:00	0.0	0	0	0	0	1
09/05/2020 18:00	0.0	0	0	0	0	1
09/05/2020 19:00	0.0	0	0	0	0	1
09/05/2020 20:00	0.0	0	0	0	0	1
09/05/2020 21:00	0.0	0	0	0	0	1
09/05/2020 22:00	0.0	0	0	0	0	1
09/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/06/2020 00:00	0.0	0	0	0	0	1
09/06/2020 01:00	0.0	0	0	0	0	1
09/06/2020 02:00	0.0	0	0	0	0	1
09/06/2020 03:00	0.0	0	0	0	0	1
09/06/2020 04:00	0.0	0	0	0	0	1
09/06/2020 05:00	0.0	0	0	0	0	1
09/06/2020 06:00	0.0	0	0	0	0	1
09/06/2020 07:00	0.0	0	0	0	0	1
09/06/2020 08:00	0.0	0	0	0	0	1
09/06/2020 09:00	0.0	0	0	0	0	1
09/06/2020 10:00	0.0	0	0	0	0	1
09/06/2020 11:00	0.0	0	0	0	0	1
09/06/2020 12:00	0.0	0	0	0	0	1
09/06/2020 13:00	0.0	0	0	0	0	1
09/06/2020 14:00	0.0	0	0	0	0	1
09/06/2020 15:00	0.0	0	0	0	0	1
09/06/2020 16:00	0.0	0	0	0	0	1
09/06/2020 17:00	0.0	0	0	0	0	1
09/06/2020 18:00	0.0	0	0	0	0	1
09/06/2020 19:00	0.0	0	0	0	0	1
09/06/2020 20:00	0.0	0	0	0	0	1
09/06/2020 21:00	0.0	0	0	0	0	1
09/06/2020 22:00	0.0	0	0	0	0	1
09/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/07/2020 00:00	0.0	0	0	0	0	1
09/07/2020 01:00	0.0	0	0	0	0	1
09/07/2020 02:00	0.0	0	0	0	0	1
09/07/2020 03:00	0.0	0	0	0	0	1
09/07/2020 04:00	0.0	0	0	0	0	1
09/07/2020 05:00	0.0	0	0	0	0	1
09/07/2020 06:00	0.0	0	0	0	0	1
09/07/2020 07:00	0.0	0	0	0	0	1
09/07/2020 08:00	0.0	0	0	0	0	1
09/07/2020 09:00	0.0	0	0	0	0	1
09/07/2020 10:00	0.0	0	0	0	0	1
09/07/2020 11:00	0.0	0	0	0	0	1
09/07/2020 12:00	0.0	0	0	0	0	1
09/07/2020 13:00	0.0	0	0	0	0	1
09/07/2020 14:00	0.0	0	0	0	0	1
09/07/2020 15:00	0.0	0	0	0	0	1
09/07/2020 16:00	0.0	0	0	0	0	1
09/07/2020 17:00	0.0	0	0	0	0	1
09/07/2020 18:00	0.0	0	0	0	0	1
09/07/2020 19:00	0.0	0	0	0	0	1
09/07/2020 20:00	0.0	0	0	0	0	1
09/07/2020 21:00	0.0	0	0	0	0	1
09/07/2020 22:00	0.0	0	0	0	0	1
09/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/08/2020 00:00	0.0	0	0	0	0	1
09/08/2020 01:00	0.0	0	0	0	0	1
09/08/2020 02:00	0.0	0	0	0	0	1
09/08/2020 03:00	0.0	0	0	0	0	1
09/08/2020 04:00	0.0	0	0	0	0	1
09/08/2020 05:00	0.0	0	0	0	0	1
09/08/2020 06:00	0.0	0	0	0	0	1
09/08/2020 07:00	0.0	0	0	0	0	1
09/08/2020 08:00	0.0	0	0	0	0	1
09/08/2020 09:00	0.0	0	0	0	0	1
09/08/2020 10:00	0.0	0	0	0	0	1
09/08/2020 11:00	0.0	0	0	0	0	1
09/08/2020 12:00	0.0	0	0	0	0	1
09/08/2020 13:00	0.0	0	0	0	0	1
09/08/2020 14:00	0.0	0	0	0	0	1
09/08/2020 15:00	0.0	0	0	0	0	1
09/08/2020 16:00	0.0	0	0	0	0	1
09/08/2020 17:00	0.0	0	0	0	0	1
09/08/2020 18:00	0.0	0	0	0	0	1
09/08/2020 19:00	0.0	0	0	0	0	1
09/08/2020 20:00	0.0	0	0	0	0	1
09/08/2020 21:00	0.0	0	0	0	0	1
09/08/2020 22:00	0.0	0	0	0	0	1
09/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/09/2020 00:00	0.0	0	0	0	0	1
09/09/2020 01:00	0.0	0	0	0	0	1
09/09/2020 02:00	0.0	0	0	0	0	1
09/09/2020 03:00	0.0	0	0	0	0	1
09/09/2020 04:00	0.0	0	0	0	0	1
09/09/2020 05:00	0.0	0	0	0	0	1
09/09/2020 06:00	0.0	0	0	0	0	1
09/09/2020 07:00	0.0	0	0	0	0	1
09/09/2020 08:00	0.0	0	0	0	0	1
09/09/2020 09:00	0.0	0	0	0	0	1
09/09/2020 10:00	0.0	0	0	0	0	1
09/09/2020 11:00	0.0	0	0	0	0	1
09/09/2020 12:00	0.0	0	0	0	0	1
09/09/2020 13:00	0.0	0	0	0	0	1
09/09/2020 14:00	0.0	0	0	0	0	1
09/09/2020 15:00	0.0	0	0	0	0	1
09/09/2020 16:00	0.0	0	0	0	0	1
09/09/2020 17:00	0.0	0	0	0	0	1
09/09/2020 18:00	0.0	0	0	0	0	1
09/09/2020 19:00	0.0	0	0	0	0	1
09/09/2020 20:00	0.0	0	0	0	0	1
09/09/2020 21:00	0.0	0	0	0	0	1
09/09/2020 22:00	0.0	0	0	0	0	1
09/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/10/2020 00:00	0.0	0	0	0	0	1
09/10/2020 01:00	0.0	0	0	0	0	1
09/10/2020 02:00	0.0	0	0	0	0	1
09/10/2020 03:00	0.0	0	0	0	0	1
09/10/2020 04:00	0.0	0	0	0	0	1
09/10/2020 05:00	0.0	0	0	0	0	1
09/10/2020 06:00	0.0	0	0	0	0	1
09/10/2020 07:00	0.0	0	0	0	0	1
09/10/2020 08:00	0.0	0	0	0	0	1
09/10/2020 09:00	0.0	0	0	0	0	1
09/10/2020 10:00	0.0	0	0	0	0	1
09/10/2020 11:00	0.0	0	0	0	0	1
09/10/2020 12:00	0.0	0	0	0	0	1
09/10/2020 13:00	0.0	0	0	0	0	1
09/10/2020 14:00	0.0	0	0	0	0	1
09/10/2020 15:00	0.0	0	0	0	0	1
09/10/2020 16:00	0.0	0	0	0	0	1
09/10/2020 17:00	0.0	0	0	0	0	1
09/10/2020 18:00	0.0	0	0	0	0	1
09/10/2020 19:00	0.0	0	0	0	0	1
09/10/2020 20:00	0.0	0	0	0	0	1
09/10/2020 21:00	0.0	0	0	0	0	1
09/10/2020 22:00	0.0	0	0	0	0	1
09/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/11/2020 00:00	0.0	0	0	0	0	1
09/11/2020 01:00	0.0	0	0	0	0	1
09/11/2020 02:00	0.0	0	0	0	0	1
09/11/2020 03:00	0.0	0	0	0	0	1
09/11/2020 04:00	0.0	0	0	0	0	1
09/11/2020 05:00	0.0	0	0	0	0	1
09/11/2020 06:00	0.0	0	0	0	0	1
09/11/2020 07:00	0.0	0	0	0	0	1
09/11/2020 08:00	0.0	0	0	0	0	1
09/11/2020 09:00	0.0	0	0	0	0	1
09/11/2020 10:00	0.0	0	0	0	0	1
09/11/2020 11:00	0.0	0	0	0	0	1
09/11/2020 12:00	0.0	0	0	0	0	1
09/11/2020 13:00	0.0	0	0	0	0	1
09/11/2020 14:00	0.0	0	0	0	0	1
09/11/2020 15:00	0.0	0	0	0	0	1
09/11/2020 16:00	0.0	0	0	0	0	1
09/11/2020 17:00	0.0	0	0	0	0	1
09/11/2020 18:00	0.0	0	0	0	0	1
09/11/2020 19:00	0.0	0	0	0	0	1
09/11/2020 20:00	0.0	0	0	0	0	1
09/11/2020 21:00	0.0	0	0	0	0	1
09/11/2020 22:00	0.0	0	0	0	0	1
09/11/2020 23:00	113.9	0	0	0	1	0
Average/Sum#:	113.9 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	113.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/12/2020 00:00	0.0	0	0	0	0	0
09/12/2020 01:00	0.0	0	0	0	0	0
09/12/2020 02:00	0.0	0	0	0	0	0
09/12/2020 03:00	0.0	0	0	0	0	0
09/12/2020 04:00	0.0	0	0	0	0	0
09/12/2020 05:00	0.0	0	0	0	0	0
09/12/2020 06:00	0.0	0	0	0	0	0
09/12/2020 07:00	0.0	0	0	0	0	0
09/12/2020 08:00	0.0	0	0	0	0	0
09/12/2020 09:00	0.0	0	0	0	0	0
09/12/2020 10:00	0.0	0	0	0	0	0
09/12/2020 11:00	0.0	0	0	0	0	0
09/12/2020 12:00	0.0	0	0	0	0	0
09/12/2020 13:00	0.0	0	0	0	0	0
09/12/2020 14:00	0.0	0	0	0	0	0
09/12/2020 15:00	0.0	0	0	0	0	0
09/12/2020 16:00	0.0	0	0	0	0	0
09/12/2020 17:00	3,450.4	0	1	0	0	0
09/12/2020 18:00	5,008.6	0	1	0	0	0
09/12/2020 19:00	5,823.4	0	1	0	0	0
09/12/2020 20:00	0.0	0	0	0	0	1
09/12/2020 21:00	0.0	0	0	0	0	1
09/12/2020 22:00	0.0	0	0	0	0	1
09/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	14,282.4 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,823.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/13/2020 00:00	0.0	0	0	0	0	1
09/13/2020 01:00	0.0	0	0	0	0	1
09/13/2020 02:00	147.9	0	0	0	1	0
09/13/2020 03:00	0.0	0	0	0	0	0
09/13/2020 04:00	0.0	0	0	0	0	0
09/13/2020 05:00	0.0	0	0	0	0	0
09/13/2020 06:00	0.0	0	0	0	0	0
09/13/2020 07:00	0.0	0	0	0	0	0
09/13/2020 08:00	0.0	0	0	0	0	0
09/13/2020 09:00	0.0	0	0	0	0	0
09/13/2020 10:00	0.0	0	0	0	0	0
09/13/2020 11:00	0.0	0	0	0	0	0
09/13/2020 12:00	0.0	0	0	0	0	0
09/13/2020 13:00	0.0	0	0	0	0	0
09/13/2020 14:00	0.0	0	0	0	0	0
09/13/2020 15:00	0.0	0	0	0	0	0
09/13/2020 16:00	0.0	0	0	0	0	0
09/13/2020 17:00	4,058.5	0	1	0	0	0
09/13/2020 18:00	5,030.1	0	1	0	0	0
09/13/2020 19:00	5,896.8	0	1	0	0	0
09/13/2020 20:00	0.0	0	0	0	0	1
09/13/2020 21:00	0.0	0	0	0	0	1
09/13/2020 22:00	0.0	0	0	0	0	1
09/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	15,133.3 #	0 #	3 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,896.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/14/2020 00:00	0.0	0	0	0	0	1
09/14/2020 01:00	0.0	0	0	0	0	1
09/14/2020 02:00	143.1	0	0	0	1	0
09/14/2020 03:00	0.0	0	0	0	0	0
09/14/2020 04:00	0.0	0	0	0	0	0
09/14/2020 05:00	0.0	0	0	0	0	0
09/14/2020 06:00	0.0	0	0	0	0	0
09/14/2020 07:00	0.0	0	0	0	0	0
09/14/2020 08:00	0.0	0	0	0	0	0
09/14/2020 09:00	265.4	0	0	1	0	0
09/14/2020 10:00	6,130.5	0	0	1	0	0
09/14/2020 11:00	2,451.2	0	0	1	0	0
09/14/2020 12:00	0.0	0	0	0	0	1
09/14/2020 13:00	0.0	0	0	0	0	1
09/14/2020 14:00	0.0	0	0	0	0	1
09/14/2020 15:00	0.0	0	0	0	0	1
09/14/2020 16:00	0.0	0	0	0	0	1
09/14/2020 17:00	0.0	0	0	0	0	1
09/14/2020 18:00	0.0	0	0	0	0	1
09/14/2020 19:00	0.0	0	0	0	0	1
09/14/2020 20:00	0.0	0	0	0	0	1
09/14/2020 21:00	0.0	0	0	0	0	1
09/14/2020 22:00	0.0	0	0	0	0	1
09/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,990.2 #	0 #	0 #	3 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,130.5	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/15/2020 00:00	0.0	0	0	0	0	1
09/15/2020 01:00	0.0	0	0	0	0	1
09/15/2020 02:00	0.0	0	0	0	0	1
09/15/2020 03:00	0.0	0	0	0	0	1
09/15/2020 04:00	0.0	0	0	0	0	1
09/15/2020 05:00	0.0	0	0	0	0	1
09/15/2020 06:00	0.0	0	0	0	0	1
09/15/2020 07:00	0.0	0	0	0	0	1
09/15/2020 08:00	0.0	0	0	0	0	1
09/15/2020 09:00	0.0	0	0	0	0	1
09/15/2020 10:00	0.0	0	0	0	0	1
09/15/2020 11:00	0.0	0	0	0	0	1
09/15/2020 12:00	0.0	0	0	0	0	1
09/15/2020 13:00	0.0	0	0	0	0	1
09/15/2020 14:00	0.0	0	0	0	0	1
09/15/2020 15:00	0.0	0	0	0	0	1
09/15/2020 16:00	0.0	0	0	0	0	1
09/15/2020 17:00	0.0	0	0	0	0	1
09/15/2020 18:00	0.0	0	0	0	0	1
09/15/2020 19:00	0.0	0	0	0	0	1
09/15/2020 20:00	0.0	0	0	0	0	1
09/15/2020 21:00	0.0	0	0	0	0	1
09/15/2020 22:00	136.6	0	0	0	1	0
09/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	136.6 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	136.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/16/2020 00:00	0.0	0	0	0	0	0
09/16/2020 01:00	0.0	0	0	0	0	0
09/16/2020 02:00	0.0	0	0	0	0	0
09/16/2020 03:00	0.0	0	0	0	0	0
09/16/2020 04:00	0.0	0	0	0	0	0
09/16/2020 05:00	0.0	0	0	0	0	0
09/16/2020 06:00	0.0	0	0	0	0	0
09/16/2020 07:00	0.0	0	0	0	0	0
09/16/2020 08:00	0.0	0	0	0	0	0
09/16/2020 09:00	0.0	0	0	0	0	0
09/16/2020 10:00	0.0	0	0	0	0	0
09/16/2020 11:00	3,129.1	0	1	0	0	0
09/16/2020 12:00	4,241.3	0	1	0	0	0
09/16/2020 13:00	0.0	0	0	0	0	1
09/16/2020 14:00	0.0	0	0	0	0	1
09/16/2020 15:00	0.0	0	0	0	0	1
09/16/2020 16:00	0.0	0	0	0	0	1
09/16/2020 17:00	0.0	0	0	0	0	1
09/16/2020 18:00	0.0	0	0	0	0	1
09/16/2020 19:00	0.0	0	0	0	0	1
09/16/2020 20:00	0.0	0	0	0	0	1
09/16/2020 21:00	0.0	0	0	0	0	1
09/16/2020 22:00	0.0	0	0	0	0	1
09/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,370.4 #	0 #	2 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,241.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/17/2020 00:00	0.0	0	0	0	0	1
09/17/2020 01:00	0.0	0	0	0	0	1
09/17/2020 02:00	0.0	0	0	0	0	1
09/17/2020 03:00	0.0	0	0	0	0	1
09/17/2020 04:00	0.0	0	0	0	0	1
09/17/2020 05:00	0.0	0	0	0	0	1
09/17/2020 06:00	0.0	0	0	0	0	1
09/17/2020 07:00	0.0	0	0	0	0	1
09/17/2020 08:00	0.0	0	0	0	0	1
09/17/2020 09:00	0.0	0	0	0	0	1
09/17/2020 10:00	0.0	0	0	0	0	1
09/17/2020 11:00	0.0	0	0	0	0	1
09/17/2020 12:00	0.0	0	0	0	0	1
09/17/2020 13:00	0.0	0	0	0	0	1
09/17/2020 14:00	0.0	0	0	0	0	1
09/17/2020 15:00	0.0	0	0	0	0	1
09/17/2020 16:00	0.0	0	0	0	0	1
09/17/2020 17:00	0.0	0	0	0	0	1
09/17/2020 18:00	0.0	0	0	0	0	1
09/17/2020 19:00	0.0	0	0	0	0	1
09/17/2020 20:00	0.0	0	0	0	0	1
09/17/2020 21:00	0.0	0	0	0	0	1
09/17/2020 22:00	0.0	0	0	0	0	1
09/17/2020 23:00	120.7	0	0	0	1	0
Average/Sum#:	120.7 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	120.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/18/2020 00:00	0.0	0	0	0	1	0
09/18/2020 01:00	0.0	0	0	0	0	0
09/18/2020 02:00	0.0	0	0	0	0	0
09/18/2020 03:00	0.0	0	0	0	0	0
09/18/2020 04:00	0.0	0	0	0	0	0
09/18/2020 05:00	0.0	0	0	0	0	0
09/18/2020 06:00	0.0	0	0	0	0	0
09/18/2020 07:00	0.0	0	0	0	0	0
09/18/2020 08:00	0.0	0	0	0	0	0
09/18/2020 09:00	0.0	0	0	0	0	0
09/18/2020 10:00	752.2	0	1	0	0	0
09/18/2020 11:00	6,810.1	0	1	0	0	0
09/18/2020 12:00	0.0	0	0	0	0	1
09/18/2020 13:00	0.0	0	0	0	0	1
09/18/2020 14:00	0.0	0	0	0	0	1
09/18/2020 15:00	0.0	0	0	0	0	1
09/18/2020 16:00	0.0	0	0	0	0	1
09/18/2020 17:00	0.0	0	0	0	0	1
09/18/2020 18:00	0.0	0	0	0	0	1
09/18/2020 19:00	0.0	0	0	0	0	1
09/18/2020 20:00	0.0	0	0	0	0	1
09/18/2020 21:00	0.0	0	0	0	0	1
09/18/2020 22:00	115.1	0	0	0	1	0
09/18/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	7,677.4 #	0 #	2 #	0 #	2 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,810.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/19/2020 00:00	0.0	0	0	0	0	0
09/19/2020 01:00	0.0	0	0	0	0	0
09/19/2020 02:00	0.0	0	0	0	0	0
09/19/2020 03:00	0.0	0	0	0	0	0
09/19/2020 04:00	0.0	0	0	0	0	0
09/19/2020 05:00	0.0	0	0	0	0	0
09/19/2020 06:00	0.0	0	0	0	0	0
09/19/2020 07:00	0.0	0	0	0	0	0
09/19/2020 08:00	0.0	0	0	0	0	0
09/19/2020 09:00	0.0	0	0	0	0	0
09/19/2020 10:00	0.0	0	0	0	0	0
09/19/2020 11:00	0.0	0	0	0	0	0
09/19/2020 12:00	0.0	0	0	0	0	0
09/19/2020 13:00	1,741.3	0	1	0	0	0
09/19/2020 14:00	6,619.9	0	1	0	0	0
09/19/2020 15:00	0.0	0	0	0	0	1
09/19/2020 16:00	0.0	0	0	0	0	1
09/19/2020 17:00	0.0	0	0	0	0	1
09/19/2020 18:00	0.0	0	0	0	0	1
09/19/2020 19:00	0.0	0	0	0	0	1
09/19/2020 20:00	0.0	0	0	0	0	1
09/19/2020 21:00	0.0	0	0	0	0	1
09/19/2020 22:00	0.0	0	0	0	0	1
09/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,361.2 #	0 #	2 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,619.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/20/2020 00:00	0.0	0	0	0	0	1
09/20/2020 01:00	0.0	0	0	0	0	1
09/20/2020 02:00	0.0	0	0	0	0	1
09/20/2020 03:00	0.0	0	0	0	0	1
09/20/2020 04:00	0.0	0	0	0	0	1
09/20/2020 05:00	0.0	0	0	0	0	1
09/20/2020 06:00	130.2	0	0	0	1	0
09/20/2020 07:00	0.0	0	0	0	0	0
09/20/2020 08:00	0.0	0	0	0	0	0
09/20/2020 09:00	0.0	0	0	0	0	0
09/20/2020 10:00	0.0	0	0	0	0	0
09/20/2020 11:00	0.0	0	0	0	0	0
09/20/2020 12:00	0.0	0	0	0	0	0
09/20/2020 13:00	0.0	0	0	0	0	0
09/20/2020 14:00	2,610.7	0	1	0	0	0
09/20/2020 15:00	5,785.1	0	1	0	0	0
09/20/2020 16:00	0.0	0	0	0	0	1
09/20/2020 17:00	0.0	0	0	0	0	1
09/20/2020 18:00	0.0	0	0	0	0	1
09/20/2020 19:00	0.0	0	0	0	0	1
09/20/2020 20:00	0.0	0	0	0	0	1
09/20/2020 21:00	0.0	0	0	0	0	1
09/20/2020 22:00	138.1	0	0	0	1	0
09/20/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	8,664.1 #	0 #	2 #	0 #	2 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,785.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/21/2020 00:00	0.0	0	0	0	0	0
09/21/2020 01:00	0.0	0	0	0	0	0
09/21/2020 02:00	0.0	0	0	0	0	0
09/21/2020 03:00	0.0	0	0	0	0	0
09/21/2020 04:00	0.0	0	0	0	0	0
09/21/2020 05:00	0.0	0	0	0	0	0
09/21/2020 06:00	0.0	0	0	0	0	0
09/21/2020 07:00	0.0	0	0	0	0	0
09/21/2020 08:00	1,529.5	0	1	0	0	0
09/21/2020 09:00	5,057.3	0	1	0	0	0
09/21/2020 10:00	6,269.4	0	1	0	0	0
09/21/2020 11:00	0.0	0	0	0	0	1
09/21/2020 12:00	0.0	0	0	0	0	1
09/21/2020 13:00	0.0	0	0	0	0	1
09/21/2020 14:00	0.0	0	0	0	0	1
09/21/2020 15:00	0.0	0	0	0	0	1
09/21/2020 16:00	0.0	0	0	0	0	1
09/21/2020 17:00	0.0	0	0	0	0	1
09/21/2020 18:00	0.0	0	0	0	0	1
09/21/2020 19:00	0.0	0	0	0	0	1
09/21/2020 20:00	0.0	0	0	0	0	1
09/21/2020 21:00	0.0	0	0	0	0	1
09/21/2020 22:00	136.5	0	0	0	1	0
09/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	12,992.7 #	0 #	3 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,269.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/22/2020 00:00	0.0	0	0	0	0	0
09/22/2020 01:00	0.0	0	0	0	0	0
09/22/2020 02:00	0.0	0	0	0	0	0
09/22/2020 03:00	0.0	0	0	0	0	0
09/22/2020 04:00	0.0	0	0	0	0	0
09/22/2020 05:00	0.0	0	0	0	0	0
09/22/2020 06:00	0.0	0	0	0	0	0
09/22/2020 07:00	0.0	0	0	0	0	0
09/22/2020 08:00	1,410.8	0	1	0	0	0
09/22/2020 09:00	5,098.7	0	1	0	0	0
09/22/2020 10:00	6,541.1	0	1	0	0	0
09/22/2020 11:00	0.0	0	0	0	0	1
09/22/2020 12:00	0.0	0	0	0	0	1
09/22/2020 13:00	0.0	0	0	0	0	1
09/22/2020 14:00	0.0	0	0	0	0	1
09/22/2020 15:00	0.0	0	0	0	0	1
09/22/2020 16:00	0.0	0	0	0	0	1
09/22/2020 17:00	0.0	0	0	0	0	1
09/22/2020 18:00	0.0	0	0	0	0	1
09/22/2020 19:00	0.0	0	0	0	0	1
09/22/2020 20:00	0.0	0	0	0	0	1
09/22/2020 21:00	151.8	0	0	0	1	0
09/22/2020 22:00	0.0	0	0	0	0	0
09/22/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	13,202.4 #	0 #	3 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,541.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/23/2020 00:00	0.0	0	0	0	0	0
09/23/2020 01:00	0.0	0	0	0	0	0
09/23/2020 02:00	0.0	0	0	0	0	0
09/23/2020 03:00	0.0	0	0	0	0	0
09/23/2020 04:00	0.0	0	0	0	0	0
09/23/2020 05:00	0.0	0	0	0	0	0
09/23/2020 06:00	0.0	0	0	0	0	0
09/23/2020 07:00	0.0	0	0	0	0	0
09/23/2020 08:00	2,249.0	0	1	0	0	0
09/23/2020 09:00	5,078.7	0	1	0	0	0
09/23/2020 10:00	6,192.8	0	1	0	0	0
09/23/2020 11:00	0.0	0	0	0	0	1
09/23/2020 12:00	0.0	0	0	0	0	1
09/23/2020 13:00	0.0	0	0	0	0	1
09/23/2020 14:00	0.0	0	0	0	0	1
09/23/2020 15:00	0.0	0	0	0	0	1
09/23/2020 16:00	0.0	0	0	0	0	1
09/23/2020 17:00	0.0	0	0	0	0	1
09/23/2020 18:00	0.0	0	0	0	0	1
09/23/2020 19:00	0.0	0	0	0	0	1
09/23/2020 20:00	0.0	0	0	0	0	1
09/23/2020 21:00	116.5	0	0	0	1	0
09/23/2020 22:00	0.0	0	0	0	0	0
09/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	13,637.0 #	0 #	3 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,192.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/24/2020 00:00	0.0	0	0	0	0	0
09/24/2020 01:00	0.0	0	0	0	0	0
09/24/2020 02:00	0.0	0	0	0	0	0
09/24/2020 03:00	0.0	0	0	0	0	0
09/24/2020 04:00	0.0	0	0	0	0	0
09/24/2020 05:00	0.0	0	0	0	0	0
09/24/2020 06:00	0.0	0	0	0	0	0
09/24/2020 07:00	0.0	0	0	0	0	0
09/24/2020 08:00	0.0	0	0	0	0	0
09/24/2020 09:00	0.0	0	0	0	0	0
09/24/2020 10:00	0.0	0	0	0	0	0
09/24/2020 11:00	0.0	0	0	0	0	0
09/24/2020 12:00	0.0	0	0	0	0	0
09/24/2020 13:00	2,975.8	0	1	0	0	0
09/24/2020 14:00	5,483.5	0	1	0	0	0
09/24/2020 15:00	0.0	0	0	0	0	1
09/24/2020 16:00	0.0	0	0	0	0	1
09/24/2020 17:00	0.0	0	0	0	0	1
09/24/2020 18:00	0.0	0	0	0	0	1
09/24/2020 19:00	0.0	0	0	0	0	1
09/24/2020 20:00	80.3	0	0	0	1	0
09/24/2020 21:00	0.0	0	0	0	0	0
09/24/2020 22:00	0.0	0	0	0	0	0
09/24/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	8,539.6 #	0 #	2 #	0 #	1 #	5 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,483.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/25/2020 00:00	0.0	0	0	0	0	0
09/25/2020 01:00	0.0	0	0	0	0	0
09/25/2020 02:00	0.0	0	0	0	0	0
09/25/2020 03:00	0.0	0	0	0	0	0
09/25/2020 04:00	0.0	0	0	0	0	0
09/25/2020 05:00	0.0	0	0	0	0	0
09/25/2020 06:00	0.0	0	0	0	0	0
09/25/2020 07:00	0.0	0	0	0	0	0
09/25/2020 08:00	0.0	0	0	0	0	0
09/25/2020 09:00	0.0	0	0	0	0	0
09/25/2020 10:00	0.0	0	0	0	0	0
09/25/2020 11:00	0.0	0	0	0	0	0
09/25/2020 12:00	0.0	0	0	0	0	0
09/25/2020 13:00	0.0	0	0	0	0	0
09/25/2020 14:00	0.0	0	0	0	0	0
09/25/2020 15:00	0.0	0	0	0	0	0
09/25/2020 16:00	0.0	0	0	0	0	0
09/25/2020 17:00	0.0	0	0	0	0	0
09/25/2020 18:00	0.0	0	0	0	0	0
09/25/2020 19:00	0.0	0	0	0	0	0
09/25/2020 20:00	0.0	0	0	0	0	0
09/25/2020 21:00	0.0	0	0	0	0	0
09/25/2020 22:00	0.0	0	0	0	0	0
09/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/26/2020 00:00	0.0	0	0	0	0	0
09/26/2020 01:00	0.0	0	0	0	0	0
09/26/2020 02:00	0.0	0	0	0	0	0
09/26/2020 03:00	0.0	0	0	0	0	0
09/26/2020 04:00	0.0	0	0	0	0	0
09/26/2020 05:00	0.0	0	0	0	0	0
09/26/2020 06:00	0.0	0	0	0	0	0
09/26/2020 07:00	0.0	0	0	0	0	0
09/26/2020 08:00	0.0	0	0	0	0	0
09/26/2020 09:00	0.0	0	0	0	0	0
09/26/2020 10:00	0.0	0	0	0	0	0
09/26/2020 11:00	0.0	0	0	0	0	0
09/26/2020 12:00	0.0	0	0	0	0	0
09/26/2020 13:00	0.0	0	0	0	0	0
09/26/2020 14:00	0.0	0	0	0	0	0
09/26/2020 15:00	0.0	0	0	0	0	0
09/26/2020 16:00	0.0	0	0	0	0	0
09/26/2020 17:00	0.0	0	0	0	0	0
09/26/2020 18:00	0.0	0	0	0	0	0
09/26/2020 19:00	0.0	0	0	0	0	0
09/26/2020 20:00	0.0	0	0	0	0	0
09/26/2020 21:00	0.0	0	0	0	0	0
09/26/2020 22:00	0.0	0	0	0	0	0
09/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/27/2020 00:00	0.0	0	0	0	0	0
09/27/2020 01:00	0.0	0	0	0	0	0
09/27/2020 02:00	0.0	0	0	0	0	0
09/27/2020 03:00	0.0	0	0	0	0	0
09/27/2020 04:00	0.0	0	0	0	0	0
09/27/2020 05:00	0.0	0	0	0	0	0
09/27/2020 06:00	0.0	0	0	0	0	0
09/27/2020 07:00	0.0	0	0	0	0	0
09/27/2020 08:00	22.5	0	1	0	0	0
09/27/2020 09:00	4,907.3	0	1	0	0	0
09/27/2020 10:00	6,910.3	0	1	0	0	0
09/27/2020 11:00	0.0	0	0	0	0	1
09/27/2020 12:00	0.0	0	0	0	0	1
09/27/2020 13:00	0.0	0	0	0	0	1
09/27/2020 14:00	0.0	0	0	0	0	1
09/27/2020 15:00	0.0	0	0	0	0	1
09/27/2020 16:00	0.0	0	0	0	0	1
09/27/2020 17:00	0.0	0	0	0	0	1
09/27/2020 18:00	0.0	0	0	0	0	1
09/27/2020 19:00	0.0	0	0	0	0	1
09/27/2020 20:00	0.0	0	0	0	0	1
09/27/2020 21:00	0.0	0	0	0	0	1
09/27/2020 22:00	137.1	0	0	0	1	0
09/27/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	11,977.2 #	0 #	3 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,910.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/28/2020 00:00	0.0	0	0	0	0	0
09/28/2020 01:00	0.0	0	0	0	0	0
09/28/2020 02:00	0.0	0	0	0	0	0
09/28/2020 03:00	0.0	0	0	0	0	0
09/28/2020 04:00	0.0	0	0	0	0	0
09/28/2020 05:00	0.0	0	0	0	0	0
09/28/2020 06:00	0.0	0	0	0	0	0
09/28/2020 07:00	0.0	0	0	0	0	0
09/28/2020 08:00	0.0	0	0	0	0	0
09/28/2020 09:00	0.0	0	0	0	0	0
09/28/2020 10:00	3,090.0	0	1	0	0	0
09/28/2020 11:00	5,830.6	0	1	0	0	0
09/28/2020 12:00	0.0	0	0	0	0	1
09/28/2020 13:00	0.0	0	0	0	0	1
09/28/2020 14:00	0.0	0	0	0	0	1
09/28/2020 15:00	0.0	0	0	0	0	1
09/28/2020 16:00	0.0	0	0	0	0	1
09/28/2020 17:00	0.0	0	0	0	0	1
09/28/2020 18:00	0.0	0	0	0	0	1
09/28/2020 19:00	0.0	0	0	0	0	1
09/28/2020 20:00	0.0	0	0	0	0	1
09/28/2020 21:00	0.0	0	0	0	0	1
09/28/2020 22:00	138.2	0	0	0	1	0
09/28/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	9,058.8 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,830.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/29/2020 00:00	0.0	0	0	0	0	0
09/29/2020 01:00	0.0	0	0	0	0	0
09/29/2020 02:00	0.0	0	0	0	0	0
09/29/2020 03:00	0.0	0	0	0	0	0
09/29/2020 04:00	0.0	0	0	0	0	0
09/29/2020 05:00	0.0	0	0	0	0	0
09/29/2020 06:00	0.0	0	0	0	0	0
09/29/2020 07:00	0.0	0	0	0	0	0
09/29/2020 08:00	0.0	0	0	0	0	0
09/29/2020 09:00	0.0	0	0	0	0	0
09/29/2020 10:00	3,519.0	0	1	0	0	0
09/29/2020 11:00	5,952.2	0	1	0	0	0
09/29/2020 12:00	0.0	0	0	0	0	1
09/29/2020 13:00	0.0	0	0	0	0	1
09/29/2020 14:00	0.0	0	0	0	0	1
09/29/2020 15:00	0.0	0	0	0	0	1
09/29/2020 16:00	0.0	0	0	0	0	1
09/29/2020 17:00	0.0	0	0	0	0	1
09/29/2020 18:00	0.0	0	0	0	0	1
09/29/2020 19:00	0.0	0	0	0	0	1
09/29/2020 20:00	0.0	0	0	0	0	1
09/29/2020 21:00	0.0	0	0	0	0	1
09/29/2020 22:00	0.0	0	0	0	0	1
09/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,471.2 #	0 #	2 #	0 #	0 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,952.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/30/2020 00:00	0.0	0	0	0	0	1
09/30/2020 01:00	0.0	0	0	0	0	1
09/30/2020 02:00	0.0	0	0	0	0	1
09/30/2020 03:00	0.0	0	0	0	0	1
09/30/2020 04:00	0.0	0	0	0	0	1
09/30/2020 05:00	0.0	0	0	0	0	1
09/30/2020 06:00	0.0	0	0	0	0	1
09/30/2020 07:00	0.0	0	0	0	0	1
09/30/2020 08:00	0.0	0	0	0	0	1
09/30/2020 09:00	0.0	0	0	0	0	1
09/30/2020 10:00	0.0	0	0	0	0	1
09/30/2020 11:00	0.0	0	0	0	0	1
09/30/2020 12:00	0.0	0	0	0	0	1
09/30/2020 13:00	0.0	0	0	0	0	1
09/30/2020 14:00	0.0	0	0	0	0	1
09/30/2020 15:00	0.0	0	0	0	0	1
09/30/2020 16:00	0.0	0	0	0	0	1
09/30/2020 17:00	0.0	0	0	0	0	1
09/30/2020 18:00	0.0	0	0	0	0	1
09/30/2020 19:00	0.0	0	0	0	0	1
09/30/2020 20:00	0.0	0	0	0	0	1
09/30/2020 21:00	0.0	0	0	0	0	1
09/30/2020 22:00	0.0	0	0	0	0	1
09/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/01/2020 00:00	0.0	0	0	0	0	0
07/01/2020 01:00	0.0	0	0	0	0	0
07/01/2020 02:00	0.0	0	0	0	0	0
07/01/2020 03:00	0.0	0	0	0	0	0
07/01/2020 04:00	0.0	0	0	0	0	0
07/01/2020 05:00	0.0	0	0	0	0	0
07/01/2020 06:00	0.0	0	0	0	0	0
07/01/2020 07:00	0.0	0	0	0	0	0
07/01/2020 08:00	0.0	0	0	0	0	0
07/01/2020 09:00	0.0	0	0	0	0	0
07/01/2020 10:00	0.0	0	0	0	0	0
07/01/2020 11:00	0.0	0	0	0	0	0
07/01/2020 12:00	0.0	0	0	0	0	0
07/01/2020 13:00	0.0	0	0	0	0	0
07/01/2020 14:00	0.0	0	0	0	0	0
07/01/2020 15:00	0.0	0	0	0	0	0
07/01/2020 16:00	0.0	0	0	0	0	0
07/01/2020 17:00	0.0	0	0	0	0	0
07/01/2020 18:00	0.0	0	0	0	0	0
07/01/2020 19:00	0.0	0	0	0	0	0
07/01/2020 20:00	0.0	0	0	0	0	0
07/01/2020 21:00	0.0	0	0	0	0	0
07/01/2020 22:00	0.0	0	0	0	0	0
07/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/02/2020 00:00	0.0	0	0	0	0	0
07/02/2020 01:00	0.0	0	0	0	0	0
07/02/2020 02:00	0.0	0	0	0	0	0
07/02/2020 03:00	0.0	0	0	0	0	0
07/02/2020 04:00	0.0	0	0	0	0	0
07/02/2020 05:00	0.0	0	0	0	0	0
07/02/2020 06:00	0.0	0	0	0	0	0
07/02/2020 07:00	0.0	0	0	0	0	0
07/02/2020 08:00	0.0	0	0	0	0	0
07/02/2020 09:00	0.0	0	0	0	0	0
07/02/2020 10:00	0.0	0	0	0	0	0
07/02/2020 11:00	0.0	0	0	0	0	0
07/02/2020 12:00	0.0	0	0	0	0	0
07/02/2020 13:00	0.0	0	0	0	0	0
07/02/2020 14:00	0.0	0	0	0	0	0
07/02/2020 15:00	0.0	0	0	0	0	0
07/02/2020 16:00	0.0	0	0	0	0	0
07/02/2020 17:00	0.0	0	0	0	0	0
07/02/2020 18:00	0.0	0	0	0	0	0
07/02/2020 19:00	0.0	0	0	0	0	0
07/02/2020 20:00	0.0	0	0	0	0	0
07/02/2020 21:00	0.0	0	0	0	0	0
07/02/2020 22:00	0.0	0	0	0	0	0
07/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/03/2020 00:00	0.0	0	0	0	0	0
07/03/2020 01:00	0.0	0	0	0	0	0
07/03/2020 02:00	0.0	0	0	0	0	0
07/03/2020 03:00	0.0	0	0	0	0	0
07/03/2020 04:00	0.0	0	0	0	0	0
07/03/2020 05:00	0.0	0	0	0	0	0
07/03/2020 06:00	0.0	0	0	0	0	0
07/03/2020 07:00	0.0	0	0	0	0	0
07/03/2020 08:00	57.2	0	1	0	0	0
07/03/2020 09:00	32.1	0	1	0	0	0
07/03/2020 10:00	21.2	0	1	0	0	0
07/03/2020 11:00	0.0	0	0	0	0	1
07/03/2020 12:00	0.0	0	0	0	0	1
07/03/2020 13:00	0.0	0	0	0	0	1
07/03/2020 14:00	0.0	0	0	0	0	1
07/03/2020 15:00	0.0	0	0	0	0	1
07/03/2020 16:00	0.0	0	0	0	0	1
07/03/2020 17:00	0.0	0	0	0	0	1
07/03/2020 18:00	0.0	0	0	0	0	1
07/03/2020 19:00	0.0	0	0	0	0	1
07/03/2020 20:00	0.0	0	0	0	0	1
07/03/2020 21:00	0.0	0	0	0	0	1
07/03/2020 22:00	0.0	0	0	0	0	1
07/03/2020 23:00	1.1	0	0	0	1	0
Average/Sum#:	111.6 #	0 #	3 #	0 #	1 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	57.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/04/2020 00:00	0.0	0	0	0	0	0
07/04/2020 01:00	0.0	0	0	0	0	0
07/04/2020 02:00	0.0	0	0	0	0	0
07/04/2020 03:00	0.0	0	0	0	0	0
07/04/2020 04:00	0.0	0	0	0	0	0
07/04/2020 05:00	0.0	0	0	0	0	0
07/04/2020 06:00	0.0	0	0	0	0	0
07/04/2020 07:00	0.0	0	0	0	0	0
07/04/2020 08:00	0.0	0	0	0	0	0
07/04/2020 09:00	0.0	0	0	0	0	0
07/04/2020 10:00	0.0	0	0	0	0	0
07/04/2020 11:00	0.0	0	0	0	0	0
07/04/2020 12:00	0.0	0	0	0	0	0
07/04/2020 13:00	0.0	0	0	0	0	0
07/04/2020 14:00	0.0	0	0	0	0	0
07/04/2020 15:00	0.0	0	0	0	0	0
07/04/2020 16:00	0.0	0	0	0	0	0
07/04/2020 17:00	0.0	0	0	0	0	0
07/04/2020 18:00	0.0	0	0	0	0	0
07/04/2020 19:00	0.0	0	0	0	0	0
07/04/2020 20:00	0.0	0	0	0	0	0
07/04/2020 21:00	0.0	0	0	0	0	0
07/04/2020 22:00	0.0	0	0	0	0	0
07/04/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/05/2020 00:00	0.0	0	0	0	0	0
07/05/2020 01:00	0.0	0	0	0	0	0
07/05/2020 02:00	0.0	0	0	0	0	0
07/05/2020 03:00	0.0	0	0	0	0	0
07/05/2020 04:00	0.0	0	0	0	0	0
07/05/2020 05:00	0.0	0	0	0	0	0
07/05/2020 06:00	0.0	0	0	0	0	0
07/05/2020 07:00	0.0	0	0	0	0	0
07/05/2020 08:00	0.0	0	0	0	0	0
07/05/2020 09:00	64.5	0	1	0	0	0
07/05/2020 10:00	36.9	0	1	0	0	0
07/05/2020 11:00	45.2	0	1	0	0	0
07/05/2020 12:00	0.0	0	0	0	0	1
07/05/2020 13:00	0.0	0	0	0	0	1
07/05/2020 14:00	0.0	0	0	0	0	1
07/05/2020 15:00	0.0	0	0	0	0	1
07/05/2020 16:00	0.0	0	0	0	0	1
07/05/2020 17:00	0.0	0	0	0	0	1
07/05/2020 18:00	0.0	0	0	0	0	1
07/05/2020 19:00	0.0	0	0	0	0	1
07/05/2020 20:00	0.0	0	0	0	0	1
07/05/2020 21:00	0.0	0	0	0	0	1
07/05/2020 22:00	1.1	0	0	0	1	0
07/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	147.7 #	0 #	3 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	64.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOX_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/06/2020 00:00	0.0	0	0	0	0	0
07/06/2020 01:00	0.0	0	0	0	0	0
07/06/2020 02:00	1.1	0	0	1	0	0
07/06/2020 03:00	14.9	0	0	1	0	0
07/06/2020 04:00	0.0	0	0	0	0	1
07/06/2020 05:00	0.0	0	0	0	0	1
07/06/2020 06:00	0.0	0	0	0	0	1
07/06/2020 07:00	0.0	0	0	0	0	1
07/06/2020 08:00	0.0	0	0	0	0	1
07/06/2020 09:00	0.0	0	0	0	0	1
07/06/2020 10:00	0.0	0	0	0	0	1
07/06/2020 11:00	0.0	0	0	0	0	1
07/06/2020 12:00	0.0	0	0	0	0	1
07/06/2020 13:00	0.0	0	0	0	0	1
07/06/2020 14:00	0.0	0	0	0	0	1
07/06/2020 15:00	0.0	0	0	0	0	1
07/06/2020 16:00	0.0	0	0	0	0	1
07/06/2020 17:00	0.0	0	0	0	0	1
07/06/2020 18:00	0.0	0	0	0	0	1
07/06/2020 19:00	0.0	0	0	0	0	1
07/06/2020 20:00	0.0	0	0	0	0	1
07/06/2020 21:00	0.0	0	0	0	0	1
07/06/2020 22:00	0.0	0	0	0	0	1
07/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	16.0 #	0 #	0 #	2 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	14.9	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOX_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/07/2020 00:00	0.0	0	0	0	0	1
07/07/2020 01:00	0.0	0	0	0	0	1
07/07/2020 02:00	0.0	0	0	0	0	1
07/07/2020 03:00	0.0	0	0	0	0	1
07/07/2020 04:00	0.0	0	0	0	0	1
07/07/2020 05:00	0.0	0	0	0	0	1
07/07/2020 06:00	0.0	0	0	0	0	1
07/07/2020 07:00	0.0	0	0	0	0	1
07/07/2020 08:00	0.0	0	0	0	0	1
07/07/2020 09:00	0.0	0	0	0	0	1
07/07/2020 10:00	0.0	0	0	0	0	1
07/07/2020 11:00	0.0	0	0	0	0	1
07/07/2020 12:00	0.0	0	0	0	0	1
07/07/2020 13:00	0.0	0	0	0	0	1
07/07/2020 14:00	0.0	0	0	0	0	1
07/07/2020 15:00	0.0	0	0	0	0	1
07/07/2020 16:00	0.0	0	0	0	0	1
07/07/2020 17:00	0.0	0	0	0	0	1
07/07/2020 18:00	0.0	0	0	0	0	1
07/07/2020 19:00	0.0	0	0	0	0	1
07/07/2020 20:00	0.0	0	0	0	0	1
07/07/2020 21:00	0.0	0	0	0	0	1
07/07/2020 22:00	0.0	0	0	0	0	1
07/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/08/2020 00:00	0.0	0	0	0	0	1
07/08/2020 01:00	0.0	0	0	0	0	1
07/08/2020 02:00	0.0	0	0	0	0	1
07/08/2020 03:00	0.0	0	0	0	0	1
07/08/2020 04:00	0.0	0	0	0	0	1
07/08/2020 05:00	0.0	0	0	0	0	1
07/08/2020 06:00	0.0	0	0	0	0	1
07/08/2020 07:00	0.0	0	0	0	0	1
07/08/2020 08:00	0.0	0	0	0	0	1
07/08/2020 09:00	0.0	0	0	0	0	1
07/08/2020 10:00	0.0	0	0	0	0	1
07/08/2020 11:00	0.0	0	0	0	0	1
07/08/2020 12:00	0.0	0	0	0	0	1
07/08/2020 13:00	0.0	0	0	0	0	1
07/08/2020 14:00	0.0	0	0	0	0	1
07/08/2020 15:00	0.0	0	0	0	0	1
07/08/2020 16:00	0.0	0	0	0	0	1
07/08/2020 17:00	0.0	0	0	0	0	1
07/08/2020 18:00	0.0	0	0	0	0	1
07/08/2020 19:00	0.0	0	0	0	0	1
07/08/2020 20:00	0.0	0	0	0	0	1
07/08/2020 21:00	0.0	0	0	0	0	1
07/08/2020 22:00	0.0	0	0	0	0	1
07/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/09/2020 00:00	0.0	0	0	0	0	1
07/09/2020 01:00	0.0	0	0	0	0	1
07/09/2020 02:00	0.0	0	0	0	0	1
07/09/2020 03:00	0.0	0	0	0	0	1
07/09/2020 04:00	0.0	0	0	0	0	1
07/09/2020 05:00	0.0	0	0	0	0	1
07/09/2020 06:00	0.0	0	0	0	0	1
07/09/2020 07:00	0.0	0	0	0	0	1
07/09/2020 08:00	0.0	0	0	0	0	1
07/09/2020 09:00	0.0	0	0	0	0	1
07/09/2020 10:00	0.0	0	0	0	0	1
07/09/2020 11:00	0.0	0	0	0	0	1
07/09/2020 12:00	0.0	0	0	0	0	1
07/09/2020 13:00	0.0	0	0	0	0	1
07/09/2020 14:00	0.0	0	0	0	0	1
07/09/2020 15:00	0.0	0	0	0	0	1
07/09/2020 16:00	0.0	0	0	0	0	1
07/09/2020 17:00	0.0	0	0	0	0	1
07/09/2020 18:00	0.0	0	0	0	0	1
07/09/2020 19:00	0.0	0	0	0	0	1
07/09/2020 20:00	0.0	0	0	0	0	1
07/09/2020 21:00	0.0	0	0	0	0	1
07/09/2020 22:00	0.0	0	0	0	0	1
07/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/10/2020 00:00	0.0	0	0	0	0	1
07/10/2020 01:00	0.0	0	0	0	0	1
07/10/2020 02:00	0.0	0	0	0	0	1
07/10/2020 03:00	0.0	0	0	0	0	1
07/10/2020 04:00	0.0	0	0	0	0	1
07/10/2020 05:00	0.0	0	0	0	0	1
07/10/2020 06:00	0.0	0	0	0	0	1
07/10/2020 07:00	0.0	0	0	0	0	1
07/10/2020 08:00	0.0	0	0	0	0	1
07/10/2020 09:00	0.0	0	0	0	0	1
07/10/2020 10:00	0.0	0	0	0	0	1
07/10/2020 11:00	0.0	0	0	0	0	1
07/10/2020 12:00	0.0	0	0	0	0	1
07/10/2020 13:00	0.0	0	0	0	0	1
07/10/2020 14:00	0.0	0	0	0	0	1
07/10/2020 15:00	0.0	0	0	0	0	1
07/10/2020 16:00	0.0	0	0	0	0	1
07/10/2020 17:00	0.0	0	0	0	0	1
07/10/2020 18:00	0.0	0	0	0	0	1
07/10/2020 19:00	0.0	0	0	0	0	1
07/10/2020 20:00	0.0	0	0	0	0	1
07/10/2020 21:00	0.0	0	0	0	0	1
07/10/2020 22:00	0.0	0	0	0	0	1
07/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/11/2020 00:00	0.0	0	0	0	0	1
07/11/2020 01:00	0.0	0	0	0	0	1
07/11/2020 02:00	0.0	0	0	0	0	1
07/11/2020 03:00	0.0	0	0	0	0	1
07/11/2020 04:00	0.0	0	0	0	0	1
07/11/2020 05:00	0.0	0	0	0	0	1
07/11/2020 06:00	0.0	0	0	0	0	1
07/11/2020 07:00	0.0	0	0	0	0	1
07/11/2020 08:00	0.0	0	0	0	0	1
07/11/2020 09:00	0.0	0	0	0	0	1
07/11/2020 10:00	0.0	0	0	0	0	1
07/11/2020 11:00	0.0	0	0	0	0	1
07/11/2020 12:00	0.0	0	0	0	0	1
07/11/2020 13:00	0.0	0	0	0	0	1
07/11/2020 14:00	0.0	0	0	0	0	1
07/11/2020 15:00	0.0	0	0	0	0	1
07/11/2020 16:00	0.0	0	0	0	0	1
07/11/2020 17:00	0.0	0	0	0	0	1
07/11/2020 18:00	0.0	0	0	0	0	1
07/11/2020 19:00	0.0	0	0	0	0	1
07/11/2020 20:00	0.0	0	0	0	0	1
07/11/2020 21:00	0.0	0	0	0	0	1
07/11/2020 22:00	0.0	0	0	0	0	1
07/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/12/2020 00:00	0.0	0	0	0	0	1
07/12/2020 01:00	0.0	0	0	0	0	1
07/12/2020 02:00	0.0	0	0	0	0	1
07/12/2020 03:00	0.0	0	0	0	0	1
07/12/2020 04:00	0.0	0	0	0	0	1
07/12/2020 05:00	0.0	0	0	0	0	1
07/12/2020 06:00	0.0	0	0	0	0	1
07/12/2020 07:00	0.0	0	0	0	0	1
07/12/2020 08:00	0.0	0	0	0	0	1
07/12/2020 09:00	0.0	0	0	0	0	1
07/12/2020 10:00	0.0	0	0	0	0	1
07/12/2020 11:00	0.0	0	0	0	0	1
07/12/2020 12:00	0.0	0	0	0	0	1
07/12/2020 13:00	0.0	0	0	0	0	1
07/12/2020 14:00	0.0	0	0	0	0	1
07/12/2020 15:00	0.0	0	0	0	0	1
07/12/2020 16:00	0.0	0	0	0	0	1
07/12/2020 17:00	0.0	0	0	0	0	1
07/12/2020 18:00	0.0	0	0	0	0	1
07/12/2020 19:00	0.0	0	0	0	0	1
07/12/2020 20:00	0.0	0	0	0	0	1
07/12/2020 21:00	0.0	0	0	0	0	1
07/12/2020 22:00	0.0	0	0	0	0	1
07/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/13/2020 00:00	0.0	0	0	0	0	1
07/13/2020 01:00	0.0	0	0	0	0	1
07/13/2020 02:00	0.0	0	0	0	0	1
07/13/2020 03:00	0.0	0	0	0	0	1
07/13/2020 04:00	0.0	0	0	0	0	1
07/13/2020 05:00	0.0	0	0	0	0	1
07/13/2020 06:00	0.0	0	0	0	0	1
07/13/2020 07:00	0.0	0	0	0	0	1
07/13/2020 08:00	0.0	0	0	0	0	1
07/13/2020 09:00	0.0	0	0	0	0	1
07/13/2020 10:00	0.0	0	0	0	0	1
07/13/2020 11:00	0.0	0	0	0	0	1
07/13/2020 12:00	0.0	0	0	0	0	1
07/13/2020 13:00	0.0	0	0	0	0	1
07/13/2020 14:00	0.0	0	0	0	0	1
07/13/2020 15:00	0.0	0	0	0	0	1
07/13/2020 16:00	0.0	0	0	0	0	1
07/13/2020 17:00	0.0	0	0	0	0	1
07/13/2020 18:00	0.0	0	0	0	0	1
07/13/2020 19:00	0.0	0	0	0	0	1
07/13/2020 20:00	0.0	0	0	0	0	1
07/13/2020 21:00	0.0	0	0	0	0	1
07/13/2020 22:00	0.0	0	0	0	0	1
07/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/14/2020 00:00	0.0	0	0	0	0	1
07/14/2020 01:00	0.0	0	0	0	0	1
07/14/2020 02:00	0.0	0	0	0	0	1
07/14/2020 03:00	0.0	0	0	0	0	1
07/14/2020 04:00	0.0	0	0	0	0	1
07/14/2020 05:00	0.0	0	0	0	0	1
07/14/2020 06:00	0.0	0	0	0	0	1
07/14/2020 07:00	0.0	0	0	0	0	1
07/14/2020 08:00	0.0	0	0	0	0	1
07/14/2020 09:00	0.0	0	0	0	0	1
07/14/2020 10:00	0.0	0	0	0	0	1
07/14/2020 11:00	0.0	0	0	0	0	1
07/14/2020 12:00	0.0	0	0	0	0	1
07/14/2020 13:00	0.0	0	0	0	0	1
07/14/2020 14:00	0.0	0	0	0	0	1
07/14/2020 15:00	0.0	0	0	0	0	1
07/14/2020 16:00	0.0	0	0	0	0	1
07/14/2020 17:00	0.0	0	0	0	0	1
07/14/2020 18:00	0.0	0	0	0	0	1
07/14/2020 19:00	0.0	0	0	0	0	1
07/14/2020 20:00	0.0	0	0	0	0	1
07/14/2020 21:00	0.0	0	0	0	0	1
07/14/2020 22:00	0.0	0	0	0	0	1
07/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/15/2020 00:00	0.0	0	0	0	0	1
07/15/2020 01:00	0.0	0	0	0	0	1
07/15/2020 02:00	0.0	0	0	0	0	1
07/15/2020 03:00	0.0	0	0	0	0	1
07/15/2020 04:00	0.0	0	0	0	0	1
07/15/2020 05:00	0.0	0	0	0	0	1
07/15/2020 06:00	0.0	0	0	0	0	1
07/15/2020 07:00	0.0	0	0	0	0	1
07/15/2020 08:00	0.0	0	0	0	0	1
07/15/2020 09:00	0.0	0	0	0	0	1
07/15/2020 10:00	0.0	0	0	0	0	1
07/15/2020 11:00	0.0	0	0	0	0	1
07/15/2020 12:00	0.0	0	0	0	0	1
07/15/2020 13:00	0.0	0	0	0	0	1
07/15/2020 14:00	0.0	0	0	0	0	1
07/15/2020 15:00	0.0	0	0	0	0	1
07/15/2020 16:00	0.0	0	0	0	0	1
07/15/2020 17:00	0.0	0	0	0	0	1
07/15/2020 18:00	0.0	0	0	0	0	1
07/15/2020 19:00	0.0	0	0	0	0	1
07/15/2020 20:00	0.0	0	0	0	0	1
07/15/2020 21:00	0.0	0	0	0	0	1
07/15/2020 22:00	0.0	0	0	0	0	1
07/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/16/2020 00:00	0.0	0	0	0	0	1
07/16/2020 01:00	0.0	0	0	0	0	1
07/16/2020 02:00	0.0	0	0	0	0	1
07/16/2020 03:00	0.0	0	0	0	0	1
07/16/2020 04:00	0.0	0	0	0	0	1
07/16/2020 05:00	0.0	0	0	0	0	1
07/16/2020 06:00	0.0	0	0	0	0	1
07/16/2020 07:00	0.0	0	0	0	0	1
07/16/2020 08:00	0.0	0	0	0	0	1
07/16/2020 09:00	0.0	0	0	0	0	1
07/16/2020 10:00	0.0	0	0	0	0	1
07/16/2020 11:00	0.0	0	0	0	0	1
07/16/2020 12:00	0.0	0	0	0	0	1
07/16/2020 13:00	0.0	0	0	0	0	1
07/16/2020 14:00	0.0	0	0	0	0	1
07/16/2020 15:00	0.0	0	0	0	0	1
07/16/2020 16:00	0.0	0	0	0	0	1
07/16/2020 17:00	0.0	0	0	0	0	1
07/16/2020 18:00	0.0	0	0	0	0	1
07/16/2020 19:00	0.0	0	0	0	0	1
07/16/2020 20:00	0.0	0	0	0	0	1
07/16/2020 21:00	0.0	0	0	0	0	1
07/16/2020 22:00	0.0	0	0	0	0	1
07/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/17/2020 00:00	0.0	0	0	0	0	1
07/17/2020 01:00	0.0	0	0	0	0	1
07/17/2020 02:00	0.0	0	0	0	0	1
07/17/2020 03:00	0.0	0	0	0	0	1
07/17/2020 04:00	0.0	0	0	0	0	1
07/17/2020 05:00	0.0	0	0	0	0	1
07/17/2020 06:00	0.0	0	0	0	0	1
07/17/2020 07:00	0.0	0	0	0	0	1
07/17/2020 08:00	0.0	0	0	0	0	1
07/17/2020 09:00	0.0	0	0	0	0	1
07/17/2020 10:00	0.0	0	0	0	0	1
07/17/2020 11:00	0.0	0	0	0	0	1
07/17/2020 12:00	0.0	0	0	0	0	1
07/17/2020 13:00	0.0	0	0	0	0	1
07/17/2020 14:00	0.0	0	0	0	0	1
07/17/2020 15:00	0.0	0	0	0	0	1
07/17/2020 16:00	0.0	0	0	0	0	1
07/17/2020 17:00	0.0	0	0	0	0	1
07/17/2020 18:00	0.0	0	0	0	0	1
07/17/2020 19:00	0.0	0	0	0	0	1
07/17/2020 20:00	0.0	0	0	0	0	1
07/17/2020 21:00	0.0	0	0	0	0	1
07/17/2020 22:00	0.0	0	0	0	0	1
07/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/18/2020 00:00	0.0	0	0	0	0	1
07/18/2020 01:00	0.0	0	0	0	0	1
07/18/2020 02:00	0.0	0	0	0	0	1
07/18/2020 03:00	0.0	0	0	0	0	1
07/18/2020 04:00	0.0	0	0	0	0	1
07/18/2020 05:00	0.0	0	0	0	0	1
07/18/2020 06:00	0.0	0	0	0	0	1
07/18/2020 07:00	0.0	0	0	0	0	1
07/18/2020 08:00	0.0	0	0	0	0	1
07/18/2020 09:00	0.0	0	0	0	0	1
07/18/2020 10:00	0.0	0	0	0	0	1
07/18/2020 11:00	0.0	0	0	0	0	1
07/18/2020 12:00	0.0	0	0	0	0	1
07/18/2020 13:00	0.0	0	0	0	0	1
07/18/2020 14:00	0.0	0	0	0	0	1
07/18/2020 15:00	0.0	0	0	0	0	1
07/18/2020 16:00	0.0	0	0	0	0	1
07/18/2020 17:00	0.0	0	0	0	0	1
07/18/2020 18:00	0.0	0	0	0	0	1
07/18/2020 19:00	0.0	0	0	0	0	1
07/18/2020 20:00	0.0	0	0	0	0	1
07/18/2020 21:00	0.0	0	0	0	0	1
07/18/2020 22:00	0.0	0	0	0	0	1
07/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/19/2020 00:00	0.0	0	0	0	0	1
07/19/2020 01:00	0.0	0	0	0	0	1
07/19/2020 02:00	0.0	0	0	0	0	1
07/19/2020 03:00	0.0	0	0	0	0	1
07/19/2020 04:00	0.0	0	0	0	0	1
07/19/2020 05:00	0.0	0	0	0	0	1
07/19/2020 06:00	0.0	0	0	0	0	1
07/19/2020 07:00	0.0	0	0	0	0	1
07/19/2020 08:00	0.0	0	0	0	0	1
07/19/2020 09:00	0.0	0	0	0	0	1
07/19/2020 10:00	0.0	0	0	0	0	1
07/19/2020 11:00	0.0	0	0	0	0	1
07/19/2020 12:00	0.0	0	0	0	0	1
07/19/2020 13:00	0.0	0	0	0	0	1
07/19/2020 14:00	0.0	0	0	0	0	1
07/19/2020 15:00	0.0	0	0	0	0	1
07/19/2020 16:00	0.0	0	0	0	0	1
07/19/2020 17:00	0.0	0	0	0	0	1
07/19/2020 18:00	0.0	0	0	0	0	1
07/19/2020 19:00	0.0	0	0	0	0	1
07/19/2020 20:00	0.0	0	0	0	0	1
07/19/2020 21:00	0.0	0	0	0	0	1
07/19/2020 22:00	0.0	0	0	0	0	1
07/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/20/2020 00:00	0.0	0	0	0	0	1
07/20/2020 01:00	0.0	0	0	0	0	1
07/20/2020 02:00	0.0	0	0	0	0	1
07/20/2020 03:00	0.0	0	0	0	0	1
07/20/2020 04:00	0.0	0	0	0	0	1
07/20/2020 05:00	0.0	0	0	0	0	1
07/20/2020 06:00	0.0	0	0	0	0	1
07/20/2020 07:00	0.0	0	0	0	0	1
07/20/2020 08:00	0.0	0	0	0	0	1
07/20/2020 09:00	0.0	0	0	0	0	1
07/20/2020 10:00	0.0	0	0	0	0	1
07/20/2020 11:00	0.0	0	0	0	0	1
07/20/2020 12:00	0.0	0	0	0	0	1
07/20/2020 13:00	0.0	0	0	0	0	1
07/20/2020 14:00	0.0	0	0	0	0	1
07/20/2020 15:00	0.0	0	0	0	0	1
07/20/2020 16:00	0.0	0	0	0	0	1
07/20/2020 17:00	0.0	0	0	0	0	1
07/20/2020 18:00	0.0	0	0	0	0	1
07/20/2020 19:00	0.0	0	0	0	0	1
07/20/2020 20:00	0.0	0	0	0	0	1
07/20/2020 21:00	0.0	0	0	0	0	1
07/20/2020 22:00	0.0	0	0	0	0	1
07/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/21/2020 00:00	0.0	0	0	0	0	1
07/21/2020 01:00	0.0	0	0	0	0	1
07/21/2020 02:00	0.0	0	0	0	0	1
07/21/2020 03:00	0.0	0	0	0	0	1
07/21/2020 04:00	0.0	0	0	0	0	1
07/21/2020 05:00	0.0	0	0	0	0	1
07/21/2020 06:00	0.0	0	0	0	0	1
07/21/2020 07:00	0.0	0	0	0	0	1
07/21/2020 08:00	0.0	0	0	0	0	1
07/21/2020 09:00	0.0	0	0	0	0	1
07/21/2020 10:00	0.0	0	0	0	0	1
07/21/2020 11:00	0.0	0	0	0	0	1
07/21/2020 12:00	0.0	0	0	0	0	1
07/21/2020 13:00	0.0	0	0	0	0	1
07/21/2020 14:00	0.0	0	0	0	0	1
07/21/2020 15:00	0.0	0	0	0	0	1
07/21/2020 16:00	0.0	0	0	0	0	1
07/21/2020 17:00	0.0	0	0	0	0	1
07/21/2020 18:00	0.0	0	0	0	0	1
07/21/2020 19:00	0.0	0	0	0	0	1
07/21/2020 20:00	0.0	0	0	0	0	1
07/21/2020 21:00	0.0	0	0	0	0	1
07/21/2020 22:00	0.0	0	0	0	0	1
07/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/22/2020 00:00	0.0	0	0	0	0	1
07/22/2020 01:00	0.0	0	0	0	0	1
07/22/2020 02:00	0.0	0	0	0	0	1
07/22/2020 03:00	0.0	0	0	0	0	1
07/22/2020 04:00	0.0	0	0	0	0	1
07/22/2020 05:00	0.0	0	0	0	0	1
07/22/2020 06:00	0.0	0	0	0	0	1
07/22/2020 07:00	0.0	0	0	0	0	1
07/22/2020 08:00	0.0	0	0	0	0	1
07/22/2020 09:00	0.0	0	0	0	0	1
07/22/2020 10:00	0.0	0	0	0	0	1
07/22/2020 11:00	0.0	0	0	0	0	1
07/22/2020 12:00	0.0	0	0	0	0	1
07/22/2020 13:00	0.0	0	0	0	0	1
07/22/2020 14:00	0.0	0	0	0	0	1
07/22/2020 15:00	0.0	0	0	0	0	1
07/22/2020 16:00	0.0	0	0	0	0	1
07/22/2020 17:00	0.0	0	0	0	0	1
07/22/2020 18:00	0.0	0	0	0	0	1
07/22/2020 19:00	0.0	0	0	0	0	1
07/22/2020 20:00	0.0	0	0	0	0	1
07/22/2020 21:00	0.0	0	0	0	0	1
07/22/2020 22:00	0.0	0	0	0	0	1
07/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/23/2020 00:00	0.0	0	0	0	0	1
07/23/2020 01:00	0.0	0	0	0	0	1
07/23/2020 02:00	0.0	0	0	0	0	1
07/23/2020 03:00	0.0	0	0	0	0	1
07/23/2020 04:00	0.0	0	0	0	0	1
07/23/2020 05:00	0.0	0	0	0	0	1
07/23/2020 06:00	0.0	0	0	0	0	1
07/23/2020 07:00	0.0	0	0	0	0	1
07/23/2020 08:00	0.0	0	0	0	0	1
07/23/2020 09:00	0.0	0	0	0	0	1
07/23/2020 10:00	0.0	0	0	0	0	1
07/23/2020 11:00	0.0	0	0	0	0	1
07/23/2020 12:00	0.0	0	0	0	0	1
07/23/2020 13:00	0.0	0	0	0	0	1
07/23/2020 14:00	0.0	0	0	0	0	1
07/23/2020 15:00	0.0	0	0	0	0	1
07/23/2020 16:00	0.0	0	0	0	0	1
07/23/2020 17:00	0.0	0	0	0	0	1
07/23/2020 18:00	0.0	0	0	0	0	1
07/23/2020 19:00	0.0	0	0	0	0	1
07/23/2020 20:00	0.0	0	0	0	0	1
07/23/2020 21:00	0.0	0	0	0	0	1
07/23/2020 22:00	0.0	0	0	0	0	1
07/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/24/2020 00:00	0.0	0	0	0	0	1
07/24/2020 01:00	0.0	0	0	0	0	1
07/24/2020 02:00	0.0	0	0	0	0	1
07/24/2020 03:00	0.0	0	0	0	0	1
07/24/2020 04:00	0.0	0	0	0	0	1
07/24/2020 05:00	0.0	0	0	0	0	1
07/24/2020 06:00	0.0	0	0	0	0	1
07/24/2020 07:00	0.0	0	0	0	0	1
07/24/2020 08:00	0.0	0	0	0	0	0
07/24/2020 09:00	0.0	0	0	0	0	0
07/24/2020 10:00	0.0	0	0	0	0	0
07/24/2020 11:00	0.0	0	0	0	0	0
07/24/2020 12:00	0.0	0	0	0	0	0
07/24/2020 13:00	0.0	0	0	0	0	0
07/24/2020 14:00	0.0	0	0	0	0	0
07/24/2020 15:00	0.0	0	0	0	0	0
07/24/2020 16:00	0.0	0	0	0	0	0
07/24/2020 17:00	0.0	0	0	0	0	0
07/24/2020 18:00	0.0	0	0	0	0	0
07/24/2020 19:00	0.0	0	0	0	0	0
07/24/2020 20:00	0.0	0	0	0	0	0
07/24/2020 21:00	0.0	0	0	0	0	0
07/24/2020 22:00	0.0	0	0	0	0	0
07/24/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/25/2020 00:00	0.0	0	0	0	0	0
07/25/2020 01:00	0.0	0	0	0	0	0
07/25/2020 02:00	0.0	0	0	0	0	0
07/25/2020 03:00	0.0	0	0	0	0	0
07/25/2020 04:00	0.0	0	0	0	0	0
07/25/2020 05:00	0.0	0	0	0	0	0
07/25/2020 06:00	0.0	0	0	0	0	0
07/25/2020 07:00	0.0	0	0	0	0	0
07/25/2020 08:00	0.0	0	0	0	0	0
07/25/2020 09:00	0.0	0	0	0	0	0
07/25/2020 10:00	0.0	0	0	0	0	0
07/25/2020 11:00	0.0	0	0	0	0	0
07/25/2020 12:00	0.0	0	0	0	0	0
07/25/2020 13:00	40.8	0	1	0	0	0
07/25/2020 14:00	51.3	0	1	0	0	0
07/25/2020 15:00	0.0	0	0	0	0	1
07/25/2020 16:00	0.0	0	0	0	0	1
07/25/2020 17:00	0.0	0	0	0	0	1
07/25/2020 18:00	0.0	0	0	0	0	1
07/25/2020 19:00	0.0	0	0	0	0	1
07/25/2020 20:00	0.0	0	0	0	0	1
07/25/2020 21:00	0.0	0	0	0	0	1
07/25/2020 22:00	0.0	0	0	0	0	1
07/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	92.1 #	0 #	2 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	51.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/26/2020 00:00	0.0	0	0	0	0	1
07/26/2020 01:00	0.0	0	0	0	0	1
07/26/2020 02:00	0.0	0	0	0	0	1
07/26/2020 03:00	0.0	0	0	0	0	1
07/26/2020 04:00	0.0	0	0	0	0	1
07/26/2020 05:00	0.0	0	0	0	0	1
07/26/2020 06:00	0.0	0	0	0	0	1
07/26/2020 07:00	0.0	0	0	0	0	1
07/26/2020 08:00	0.0	0	0	0	0	1
07/26/2020 09:00	0.0	0	0	0	0	1
07/26/2020 10:00	0.0	0	0	0	0	1
07/26/2020 11:00	0.0	0	0	0	0	1
07/26/2020 12:00	0.0	0	0	0	0	1
07/26/2020 13:00	0.0	0	0	0	0	1
07/26/2020 14:00	0.0	0	0	0	0	1
07/26/2020 15:00	0.0	0	0	0	0	1
07/26/2020 16:00	0.0	0	0	0	0	1
07/26/2020 17:00	0.0	0	0	0	0	1
07/26/2020 18:00	0.0	0	0	0	0	1
07/26/2020 19:00	0.0	0	0	0	0	1
07/26/2020 20:00	0.0	0	0	0	0	1
07/26/2020 21:00	0.0	0	0	0	0	1
07/26/2020 22:00	0.0	0	0	0	0	1
07/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/27/2020 00:00	0.0	0	0	0	0	1
07/27/2020 01:00	0.0	0	0	0	0	1
07/27/2020 02:00	0.0	0	0	0	0	1
07/27/2020 03:00	0.0	0	0	0	0	1
07/27/2020 04:00	0.0	0	0	0	0	1
07/27/2020 05:00	0.0	0	0	0	0	1
07/27/2020 06:00	0.0	0	0	0	0	1
07/27/2020 07:00	0.0	0	0	0	0	1
07/27/2020 08:00	0.0	0	0	0	0	1
07/27/2020 09:00	0.0	0	0	0	0	1
07/27/2020 10:00	0.0	0	0	0	0	1
07/27/2020 11:00	0.0	0	0	0	0	1
07/27/2020 12:00	0.0	0	0	0	0	1
07/27/2020 13:00	0.0	0	0	0	0	1
07/27/2020 14:00	0.0	0	0	0	0	1
07/27/2020 15:00	0.0	0	0	0	0	1
07/27/2020 16:00	0.0	0	0	0	0	1
07/27/2020 17:00	0.0	0	0	0	0	1
07/27/2020 18:00	0.0	0	0	0	0	1
07/27/2020 19:00	0.0	0	0	0	0	1
07/27/2020 20:00	0.0	0	0	0	0	1
07/27/2020 21:00	0.0	0	0	0	0	1
07/27/2020 22:00	0.0	0	0	0	0	1
07/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/28/2020 00:00	0.0	0	0	0	0	1
07/28/2020 01:00	0.0	0	0	0	0	1
07/28/2020 02:00	0.0	0	0	0	0	1
07/28/2020 03:00	0.0	0	0	0	0	1
07/28/2020 04:00	0.0	0	0	0	0	1
07/28/2020 05:00	0.0	0	0	0	0	1
07/28/2020 06:00	0.0	0	0	0	0	1
07/28/2020 07:00	0.0	0	0	0	0	1
07/28/2020 08:00	0.0	0	0	0	0	1
07/28/2020 09:00	0.0	0	0	0	0	1
07/28/2020 10:00	0.0	0	0	0	0	1
07/28/2020 11:00	0.0	0	0	0	0	1
07/28/2020 12:00	0.0	0	0	0	0	1
07/28/2020 13:00	0.0	0	0	0	0	1
07/28/2020 14:00	0.0	0	0	0	0	1
07/28/2020 15:00	0.0	0	0	0	0	1
07/28/2020 16:00	0.0	0	0	0	0	1
07/28/2020 17:00	0.0	0	0	0	0	1
07/28/2020 18:00	0.0	0	0	0	0	1
07/28/2020 19:00	0.0	0	0	0	0	1
07/28/2020 20:00	0.0	0	0	0	0	1
07/28/2020 21:00	0.0	0	0	0	0	1
07/28/2020 22:00	0.0	0	0	0	0	1
07/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/29/2020 00:00	0.0	0	0	0	0	1
07/29/2020 01:00	0.0	0	0	0	0	1
07/29/2020 02:00	0.0	0	0	0	0	1
07/29/2020 03:00	0.0	0	0	0	0	1
07/29/2020 04:00	0.0	0	0	0	0	1
07/29/2020 05:00	0.0	0	0	0	0	1
07/29/2020 06:00	0.0	0	0	0	0	1
07/29/2020 07:00	0.0	0	0	0	0	1
07/29/2020 08:00	0.0	0	0	0	0	1
07/29/2020 09:00	0.0	0	0	0	0	1
07/29/2020 10:00	0.0	0	0	0	0	1
07/29/2020 11:00	0.0	0	0	0	0	1
07/29/2020 12:00	0.0	0	0	0	0	1
07/29/2020 13:00	0.0	0	0	0	0	1
07/29/2020 14:00	0.0	0	0	0	0	1
07/29/2020 15:00	0.0	0	0	0	0	1
07/29/2020 16:00	0.0	0	0	0	0	1
07/29/2020 17:00	0.0	0	0	0	0	1
07/29/2020 18:00	0.0	0	0	0	0	1
07/29/2020 19:00	0.0	0	0	0	0	1
07/29/2020 20:00	0.0	0	0	0	0	1
07/29/2020 21:00	0.0	0	0	0	0	1
07/29/2020 22:00	0.0	0	0	0	0	1
07/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/30/2020 00:00	0.0	0	0	0	0	1
07/30/2020 01:00	0.0	0	0	0	0	1
07/30/2020 02:00	0.0	0	0	0	0	1
07/30/2020 03:00	0.0	0	0	0	0	1
07/30/2020 04:00	0.0	0	0	0	0	1
07/30/2020 05:00	0.0	0	0	0	0	1
07/30/2020 06:00	0.0	0	0	0	0	1
07/30/2020 07:00	0.0	0	0	0	0	1
07/30/2020 08:00	0.0	0	0	0	0	1
07/30/2020 09:00	0.0	0	0	0	0	1
07/30/2020 10:00	0.0	0	0	0	0	1
07/30/2020 11:00	0.0	0	0	0	0	1
07/30/2020 12:00	0.0	0	0	0	0	1
07/30/2020 13:00	0.0	0	0	0	0	1
07/30/2020 14:00	0.0	0	0	0	0	1
07/30/2020 15:00	0.0	0	0	0	0	1
07/30/2020 16:00	0.0	0	0	0	0	1
07/30/2020 17:00	0.0	0	0	0	0	1
07/30/2020 18:00	0.0	0	0	0	0	1
07/30/2020 19:00	0.0	0	0	0	0	1
07/30/2020 20:00	0.0	0	0	0	0	1
07/30/2020 21:00	0.0	0	0	0	0	1
07/30/2020 22:00	0.0	0	0	0	0	1
07/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/31/2020 00:00	0.0	0	0	0	0	1
07/31/2020 01:00	0.0	0	0	0	0	1
07/31/2020 02:00	0.0	0	0	0	0	1
07/31/2020 03:00	0.0	0	0	0	0	1
07/31/2020 04:00	0.0	0	0	0	0	1
07/31/2020 05:00	0.0	0	0	0	0	1
07/31/2020 06:00	0.0	0	0	0	0	1
07/31/2020 07:00	0.0	0	0	0	0	1
07/31/2020 08:00	0.0	0	0	0	0	1
07/31/2020 09:00	0.0	0	0	0	0	1
07/31/2020 10:00	0.0	0	0	0	0	1
07/31/2020 11:00	0.0	0	0	0	0	1
07/31/2020 12:00	0.0	0	0	0	0	1
07/31/2020 13:00	0.0	0	0	0	0	1
07/31/2020 14:00	0.0	0	0	0	0	1
07/31/2020 15:00	0.0	0	0	0	0	1
07/31/2020 16:00	0.0	0	0	0	0	1
07/31/2020 17:00	0.0	0	0	0	0	1
07/31/2020 18:00	0.0	0	0	0	0	1
07/31/2020 19:00	0.0	0	0	0	0	1
07/31/2020 20:00	0.0	0	0	0	0	1
07/31/2020 21:00	0.0	0	0	0	0	1
07/31/2020 22:00	0.0	0	0	0	0	1
07/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/01/2020 00:00	0.0	0	0	0	0	1
08/01/2020 01:00	0.0	0	0	0	0	1
08/01/2020 02:00	0.0	0	0	0	0	1
08/01/2020 03:00	0.0	0	0	0	0	1
08/01/2020 04:00	0.0	0	0	0	0	1
08/01/2020 05:00	0.0	0	0	0	0	1
08/01/2020 06:00	0.0	0	0	0	0	1
08/01/2020 07:00	0.0	0	0	0	0	1
08/01/2020 08:00	0.0	0	0	0	0	1
08/01/2020 09:00	0.0	0	0	0	0	1
08/01/2020 10:00	0.0	0	0	0	0	1
08/01/2020 11:00	0.0	0	0	0	0	1
08/01/2020 12:00	0.0	0	0	0	0	1
08/01/2020 13:00	0.0	0	0	0	0	1
08/01/2020 14:00	0.0	0	0	0	0	1
08/01/2020 15:00	0.0	0	0	0	0	1
08/01/2020 16:00	0.0	0	0	0	0	1
08/01/2020 17:00	0.0	0	0	0	0	1
08/01/2020 18:00	0.0	0	0	0	0	1
08/01/2020 19:00	0.0	0	0	0	0	1
08/01/2020 20:00	0.0	0	0	0	0	1
08/01/2020 21:00	0.0	0	0	0	0	1
08/01/2020 22:00	0.0	0	0	0	0	1
08/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/02/2020 00:00	0.0	0	0	0	0	1
08/02/2020 01:00	0.0	0	0	0	0	1
08/02/2020 02:00	0.0	0	0	0	0	1
08/02/2020 03:00	0.0	0	0	0	0	1
08/02/2020 04:00	0.0	0	0	0	0	1
08/02/2020 05:00	0.0	0	0	0	0	1
08/02/2020 06:00	0.0	0	0	0	0	1
08/02/2020 07:00	0.0	0	0	0	0	1
08/02/2020 08:00	0.0	0	0	0	0	1
08/02/2020 09:00	0.0	0	0	0	0	1
08/02/2020 10:00	0.0	0	0	0	0	1
08/02/2020 11:00	0.0	0	0	0	0	1
08/02/2020 12:00	0.0	0	0	0	0	1
08/02/2020 13:00	0.0	0	0	0	0	1
08/02/2020 14:00	0.0	0	0	0	0	1
08/02/2020 15:00	0.0	0	0	0	0	1
08/02/2020 16:00	0.0	0	0	0	0	1
08/02/2020 17:00	0.0	0	0	0	0	1
08/02/2020 18:00	0.0	0	0	0	0	1
08/02/2020 19:00	0.0	0	0	0	0	1
08/02/2020 20:00	0.0	0	0	0	0	1
08/02/2020 21:00	0.0	0	0	0	0	1
08/02/2020 22:00	0.0	0	0	0	0	1
08/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/03/2020 00:00	0.0	0	0	0	0	1
08/03/2020 01:00	0.0	0	0	0	0	1
08/03/2020 02:00	0.0	0	0	0	0	1
08/03/2020 03:00	0.0	0	0	0	0	1
08/03/2020 04:00	0.0	0	0	0	0	1
08/03/2020 05:00	0.0	0	0	0	0	1
08/03/2020 06:00	0.0	0	0	0	0	1
08/03/2020 07:00	0.0	0	0	0	0	1
08/03/2020 08:00	0.0	0	0	0	0	1
08/03/2020 09:00	0.0	0	0	0	0	1
08/03/2020 10:00	0.0	0	0	0	0	1
08/03/2020 11:00	0.0	0	0	0	0	1
08/03/2020 12:00	0.0	0	0	0	0	1
08/03/2020 13:00	0.0	0	0	0	0	1
08/03/2020 14:00	0.0	0	0	0	0	1
08/03/2020 15:00	0.0	0	0	0	0	1
08/03/2020 16:00	0.0	0	0	0	0	1
08/03/2020 17:00	0.0	0	0	0	0	1
08/03/2020 18:00	0.0	0	0	0	0	1
08/03/2020 19:00	0.0	0	0	0	0	1
08/03/2020 20:00	0.0	0	0	0	0	1
08/03/2020 21:00	0.0	0	0	0	0	1
08/03/2020 22:00	0.0	0	0	0	0	1
08/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/04/2020 00:00	0.0	0	0	0	0	1
08/04/2020 01:00	0.0	0	0	0	0	1
08/04/2020 02:00	0.0	0	0	0	0	1
08/04/2020 03:00	0.0	0	0	0	0	1
08/04/2020 04:00	0.0	0	0	0	0	1
08/04/2020 05:00	0.0	0	0	0	0	1
08/04/2020 06:00	0.0	0	0	0	0	1
08/04/2020 07:00	0.0	0	0	0	0	1
08/04/2020 08:00	0.0	0	0	0	0	1
08/04/2020 09:00	0.0	0	0	0	0	1
08/04/2020 10:00	0.0	0	0	0	0	1
08/04/2020 11:00	0.0	0	0	0	0	1
08/04/2020 12:00	0.0	0	0	0	0	1
08/04/2020 13:00	0.0	0	0	0	0	1
08/04/2020 14:00	0.0	0	0	0	0	1
08/04/2020 15:00	0.0	0	0	0	0	1
08/04/2020 16:00	0.0	0	0	0	0	1
08/04/2020 17:00	0.0	0	0	0	0	1
08/04/2020 18:00	0.0	0	0	0	0	1
08/04/2020 19:00	0.0	0	0	0	0	1
08/04/2020 20:00	0.0	0	0	0	0	1
08/04/2020 21:00	0.0	0	0	0	0	1
08/04/2020 22:00	0.0	0	0	0	0	1
08/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/05/2020 00:00	0.0	0	0	0	0	1
08/05/2020 01:00	0.0	0	0	0	0	1
08/05/2020 02:00	0.0	0	0	0	0	1
08/05/2020 03:00	0.0	0	0	0	0	1
08/05/2020 04:00	0.0	0	0	0	0	1
08/05/2020 05:00	0.0	0	0	0	0	1
08/05/2020 06:00	0.0	0	0	0	0	1
08/05/2020 07:00	0.0	0	0	0	0	1
08/05/2020 08:00	0.0	0	0	0	0	1
08/05/2020 09:00	0.0	0	0	0	0	1
08/05/2020 10:00	0.0	0	0	0	0	1
08/05/2020 11:00	0.0	0	0	0	0	1
08/05/2020 12:00	0.0	0	0	0	0	1
08/05/2020 13:00	0.0	0	0	0	0	1
08/05/2020 14:00	0.0	0	0	0	0	1
08/05/2020 15:00	0.0	0	0	0	0	1
08/05/2020 16:00	0.0	0	0	0	0	1
08/05/2020 17:00	0.0	0	0	0	0	1
08/05/2020 18:00	0.0	0	0	0	0	1
08/05/2020 19:00	0.0	0	0	0	0	1
08/05/2020 20:00	0.0	0	0	0	0	1
08/05/2020 21:00	0.0	0	0	0	0	1
08/05/2020 22:00	0.0	0	0	0	0	1
08/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/06/2020 00:00	0.0	0	0	0	0	1
08/06/2020 01:00	0.0	0	0	0	0	1
08/06/2020 02:00	0.0	0	0	0	0	1
08/06/2020 03:00	0.0	0	0	0	0	1
08/06/2020 04:00	0.0	0	0	0	0	1
08/06/2020 05:00	0.0	0	0	0	0	1
08/06/2020 06:00	0.0	0	0	0	0	1
08/06/2020 07:00	0.0	0	0	0	0	1
08/06/2020 08:00	0.0	0	0	0	0	1
08/06/2020 09:00	0.0	0	0	0	0	1
08/06/2020 10:00	0.0	0	0	0	0	1
08/06/2020 11:00	0.0	0	0	0	0	1
08/06/2020 12:00	0.0	0	0	0	0	1
08/06/2020 13:00	0.0	0	0	0	0	1
08/06/2020 14:00	0.0	0	0	0	0	1
08/06/2020 15:00	0.0	0	0	0	0	1
08/06/2020 16:00	0.0	0	0	0	0	1
08/06/2020 17:00	0.0	0	0	0	0	1
08/06/2020 18:00	0.0	0	0	0	0	1
08/06/2020 19:00	0.0	0	0	0	0	1
08/06/2020 20:00	0.0	0	0	0	0	1
08/06/2020 21:00	0.0	0	0	0	0	1
08/06/2020 22:00	0.0	0	0	0	0	1
08/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/07/2020 00:00	0.0	0	0	0	0	1
08/07/2020 01:00	0.0	0	0	0	0	1
08/07/2020 02:00	0.0	0	0	0	0	1
08/07/2020 03:00	0.0	0	0	0	0	1
08/07/2020 04:00	0.0	0	0	0	0	1
08/07/2020 05:00	0.0	0	0	0	0	1
08/07/2020 06:00	0.0	0	0	0	0	1
08/07/2020 07:00	0.0	0	0	0	0	1
08/07/2020 08:00	0.0	0	0	0	0	1
08/07/2020 09:00	0.0	0	0	0	0	1
08/07/2020 10:00	0.0	0	0	0	0	1
08/07/2020 11:00	0.0	0	0	0	0	1
08/07/2020 12:00	0.0	0	0	0	0	1
08/07/2020 13:00	0.0	0	0	0	0	1
08/07/2020 14:00	0.0	0	0	0	0	1
08/07/2020 15:00	0.0	0	0	0	0	1
08/07/2020 16:00	0.0	0	0	0	0	1
08/07/2020 17:00	0.0	0	0	0	0	1
08/07/2020 18:00	0.0	0	0	0	0	1
08/07/2020 19:00	0.0	0	0	0	0	1
08/07/2020 20:00	0.0	0	0	0	0	1
08/07/2020 21:00	0.0	0	0	0	0	1
08/07/2020 22:00	0.0	0	0	0	0	1
08/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/08/2020 00:00	0.0	0	0	0	0	1
08/08/2020 01:00	0.0	0	0	0	0	1
08/08/2020 02:00	0.0	0	0	0	0	1
08/08/2020 03:00	0.0	0	0	0	0	1
08/08/2020 04:00	0.0	0	0	0	0	1
08/08/2020 05:00	0.0	0	0	0	0	1
08/08/2020 06:00	0.0	0	0	0	0	1
08/08/2020 07:00	0.0	0	0	0	0	1
08/08/2020 08:00	0.0	0	0	0	0	1
08/08/2020 09:00	0.0	0	0	0	0	1
08/08/2020 10:00	0.0	0	0	0	0	1
08/08/2020 11:00	0.0	0	0	0	0	1
08/08/2020 12:00	0.0	0	0	0	0	1
08/08/2020 13:00	0.0	0	0	0	0	1
08/08/2020 14:00	0.0	0	0	0	0	1
08/08/2020 15:00	0.0	0	0	0	0	1
08/08/2020 16:00	0.0	0	0	0	0	1
08/08/2020 17:00	0.0	0	0	0	0	1
08/08/2020 18:00	0.0	0	0	0	0	1
08/08/2020 19:00	0.0	0	0	0	0	1
08/08/2020 20:00	0.0	0	0	0	0	1
08/08/2020 21:00	0.0	0	0	0	0	1
08/08/2020 22:00	0.0	0	0	0	0	1
08/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/09/2020 00:00	0.0	0	0	0	0	1
08/09/2020 01:00	0.0	0	0	0	0	1
08/09/2020 02:00	0.0	0	0	0	0	1
08/09/2020 03:00	0.0	0	0	0	0	1
08/09/2020 04:00	0.0	0	0	0	0	1
08/09/2020 05:00	0.0	0	0	0	0	1
08/09/2020 06:00	0.0	0	0	0	0	1
08/09/2020 07:00	0.0	0	0	0	0	1
08/09/2020 08:00	0.0	0	0	0	0	1
08/09/2020 09:00	0.0	0	0	0	0	1
08/09/2020 10:00	0.0	0	0	0	0	1
08/09/2020 11:00	0.0	0	0	0	0	1
08/09/2020 12:00	0.0	0	0	0	0	1
08/09/2020 13:00	0.0	0	0	0	0	1
08/09/2020 14:00	0.0	0	0	0	0	1
08/09/2020 15:00	0.0	0	0	0	0	1
08/09/2020 16:00	0.0	0	0	0	0	1
08/09/2020 17:00	0.0	0	0	0	0	1
08/09/2020 18:00	0.0	0	0	0	0	1
08/09/2020 19:00	0.0	0	0	0	0	1
08/09/2020 20:00	0.0	0	0	0	0	1
08/09/2020 21:00	0.0	0	0	0	0	1
08/09/2020 22:00	0.0	0	0	0	0	1
08/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/10/2020 00:00	0.0	0	0	0	0	1
08/10/2020 01:00	0.0	0	0	0	0	1
08/10/2020 02:00	0.0	0	0	0	0	1
08/10/2020 03:00	0.0	0	0	0	0	1
08/10/2020 04:00	0.0	0	0	0	0	1
08/10/2020 05:00	0.0	0	0	0	0	1
08/10/2020 06:00	0.0	0	0	0	0	1
08/10/2020 07:00	0.0	0	0	0	0	1
08/10/2020 08:00	0.0	0	0	0	0	1
08/10/2020 09:00	0.0	0	0	0	0	1
08/10/2020 10:00	0.0	0	0	0	0	1
08/10/2020 11:00	0.0	0	0	0	0	1
08/10/2020 12:00	0.0	0	0	0	0	1
08/10/2020 13:00	0.0	0	0	0	0	1
08/10/2020 14:00	0.0	0	0	0	0	1
08/10/2020 15:00	0.0	0	0	0	0	1
08/10/2020 16:00	0.0	0	0	0	0	1
08/10/2020 17:00	0.0	0	0	0	0	1
08/10/2020 18:00	0.0	0	0	0	0	1
08/10/2020 19:00	0.0	0	0	0	0	1
08/10/2020 20:00	0.0	0	0	0	0	1
08/10/2020 21:00	0.0	0	0	0	0	1
08/10/2020 22:00	0.0	0	0	0	0	1
08/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/11/2020 00:00	0.0	0	0	0	0	1
08/11/2020 01:00	0.0	0	0	0	0	1
08/11/2020 02:00	0.0	0	0	0	0	1
08/11/2020 03:00	0.0	0	0	0	0	1
08/11/2020 04:00	0.0	0	0	0	0	1
08/11/2020 05:00	0.0	0	0	0	0	1
08/11/2020 06:00	0.0	0	0	0	0	1
08/11/2020 07:00	0.0	0	0	0	0	1
08/11/2020 08:00	0.0	0	0	0	0	1
08/11/2020 09:00	0.0	0	0	0	0	1
08/11/2020 10:00	0.0	0	0	0	0	1
08/11/2020 11:00	0.0	0	0	0	0	1
08/11/2020 12:00	0.0	0	0	0	0	1
08/11/2020 13:00	0.0	0	0	0	0	1
08/11/2020 14:00	0.0	0	0	0	0	1
08/11/2020 15:00	0.0	0	0	0	0	1
08/11/2020 16:00	0.0	0	0	0	0	1
08/11/2020 17:00	0.0	0	0	0	0	1
08/11/2020 18:00	0.0	0	0	0	0	1
08/11/2020 19:00	0.0	0	0	0	0	1
08/11/2020 20:00	0.0	0	0	0	0	1
08/11/2020 21:00	0.0	0	0	0	0	1
08/11/2020 22:00	0.0	0	0	0	0	1
08/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/12/2020 00:00	0.0	0	0	0	0	1
08/12/2020 01:00	0.0	0	0	0	0	1
08/12/2020 02:00	0.0	0	0	0	0	1
08/12/2020 03:00	0.0	0	0	0	0	1
08/12/2020 04:00	0.0	0	0	0	0	1
08/12/2020 05:00	0.0	0	0	0	0	1
08/12/2020 06:00	0.0	0	0	0	0	1
08/12/2020 07:00	0.0	0	0	0	0	1
08/12/2020 08:00	0.0	0	0	0	0	1
08/12/2020 09:00	0.0	0	0	0	0	1
08/12/2020 10:00	0.0	0	0	0	0	1
08/12/2020 11:00	0.0	0	0	0	0	1
08/12/2020 12:00	0.0	0	0	0	0	1
08/12/2020 13:00	0.0	0	0	0	0	1
08/12/2020 14:00	0.0	0	0	0	0	1
08/12/2020 15:00	0.0	0	0	0	0	1
08/12/2020 16:00	0.0	0	0	0	0	1
08/12/2020 17:00	0.0	0	0	0	0	1
08/12/2020 18:00	0.0	0	0	0	0	1
08/12/2020 19:00	0.0	0	0	0	0	1
08/12/2020 20:00	0.0	0	0	0	0	1
08/12/2020 21:00	0.0	0	0	0	0	1
08/12/2020 22:00	0.0	0	0	0	0	1
08/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/13/2020 00:00	0.0	0	0	0	0	1
08/13/2020 01:00	0.0	0	0	0	0	1
08/13/2020 02:00	0.0	0	0	0	0	1
08/13/2020 03:00	0.0	0	0	0	0	1
08/13/2020 04:00	0.0	0	0	0	0	1
08/13/2020 05:00	0.0	0	0	0	0	1
08/13/2020 06:00	0.0	0	0	0	0	1
08/13/2020 07:00	0.0	0	0	0	0	1
08/13/2020 08:00	0.0	0	0	0	0	1
08/13/2020 09:00	0.0	0	0	0	0	1
08/13/2020 10:00	0.0	0	0	0	0	1
08/13/2020 11:00	0.0	0	0	0	0	1
08/13/2020 12:00	0.0	0	0	0	0	1
08/13/2020 13:00	0.0	0	0	0	0	1
08/13/2020 14:00	0.0	0	0	0	0	1
08/13/2020 15:00	0.0	0	0	0	0	1
08/13/2020 16:00	0.0	0	0	0	0	1
08/13/2020 17:00	0.0	0	0	0	0	1
08/13/2020 18:00	0.0	0	0	0	0	1
08/13/2020 19:00	0.0	0	0	0	0	1
08/13/2020 20:00	0.0	0	0	0	0	1
08/13/2020 21:00	0.0	0	0	0	0	1
08/13/2020 22:00	0.0	0	0	0	0	1
08/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/14/2020 00:00	0.0	0	0	0	0	1
08/14/2020 01:00	0.0	0	0	0	0	1
08/14/2020 02:00	0.0	0	0	0	0	1
08/14/2020 03:00	0.0	0	0	0	0	1
08/14/2020 04:00	0.0	0	0	0	0	1
08/14/2020 05:00	0.0	0	0	0	0	1
08/14/2020 06:00	0.0	0	0	0	0	1
08/14/2020 07:00	0.0	0	0	0	0	1
08/14/2020 08:00	0.0	0	0	0	0	1
08/14/2020 09:00	0.0	0	0	0	0	1
08/14/2020 10:00	0.0	0	0	0	0	1
08/14/2020 11:00	0.0	0	0	0	0	1
08/14/2020 12:00	0.0	0	0	0	0	1
08/14/2020 13:00	0.0	0	0	0	0	1
08/14/2020 14:00	0.0	0	0	0	0	1
08/14/2020 15:00	0.0	0	0	0	0	1
08/14/2020 16:00	0.0	0	0	0	0	1
08/14/2020 17:00	0.0	0	0	0	0	1
08/14/2020 18:00	0.0	0	0	0	0	1
08/14/2020 19:00	0.0	0	0	0	0	1
08/14/2020 20:00	0.0	0	0	0	0	1
08/14/2020 21:00	0.0	0	0	0	0	1
08/14/2020 22:00	0.0	0	0	0	0	1
08/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/15/2020 00:00	0.0	0	0	0	0	1
08/15/2020 01:00	0.0	0	0	0	0	1
08/15/2020 02:00	0.0	0	0	0	0	1
08/15/2020 03:00	0.0	0	0	0	0	1
08/15/2020 04:00	0.0	0	0	0	0	1
08/15/2020 05:00	0.0	0	0	0	0	1
08/15/2020 06:00	0.0	0	0	0	0	1
08/15/2020 07:00	0.0	0	0	0	0	1
08/15/2020 08:00	0.0	0	0	0	0	1
08/15/2020 09:00	0.0	0	0	0	0	1
08/15/2020 10:00	0.0	0	0	0	0	1
08/15/2020 11:00	0.0	0	0	0	0	1
08/15/2020 12:00	0.0	0	0	0	0	1
08/15/2020 13:00	0.0	0	0	0	0	1
08/15/2020 14:00	0.0	0	0	0	0	1
08/15/2020 15:00	0.0	0	0	0	0	1
08/15/2020 16:00	0.0	0	0	0	0	1
08/15/2020 17:00	0.0	0	0	0	0	1
08/15/2020 18:00	0.0	0	0	0	0	1
08/15/2020 19:00	0.0	0	0	0	0	1
08/15/2020 20:00	0.0	0	0	0	0	1
08/15/2020 21:00	0.0	0	0	0	0	1
08/15/2020 22:00	0.0	0	0	0	0	1
08/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/16/2020 00:00	0.0	0	0	0	0	1
08/16/2020 01:00	0.0	0	0	0	0	1
08/16/2020 02:00	0.0	0	0	0	0	1
08/16/2020 03:00	0.0	0	0	0	0	1
08/16/2020 04:00	0.0	0	0	0	0	1
08/16/2020 05:00	0.0	0	0	0	0	1
08/16/2020 06:00	0.0	0	0	0	0	1
08/16/2020 07:00	0.0	0	0	0	0	1
08/16/2020 08:00	0.0	0	0	0	0	1
08/16/2020 09:00	0.0	0	0	0	0	1
08/16/2020 10:00	0.0	0	0	0	0	1
08/16/2020 11:00	0.0	0	0	0	0	1
08/16/2020 12:00	0.0	0	0	0	0	1
08/16/2020 13:00	0.0	0	0	0	0	1
08/16/2020 14:00	0.0	0	0	0	0	1
08/16/2020 15:00	0.0	0	0	0	0	1
08/16/2020 16:00	0.0	0	0	0	0	1
08/16/2020 17:00	0.0	0	0	0	0	1
08/16/2020 18:00	0.0	0	0	0	0	1
08/16/2020 19:00	0.0	0	0	0	0	1
08/16/2020 20:00	0.0	0	0	0	0	1
08/16/2020 21:00	0.0	0	0	0	0	1
08/16/2020 22:00	0.0	0	0	0	0	1
08/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/17/2020 00:00	0.0	0	0	0	0	1
08/17/2020 01:00	0.0	0	0	0	0	1
08/17/2020 02:00	0.0	0	0	0	0	1
08/17/2020 03:00	0.0	0	0	0	0	1
08/17/2020 04:00	0.0	0	0	0	0	1
08/17/2020 05:00	0.0	0	0	0	0	1
08/17/2020 06:00	0.0	0	0	0	0	1
08/17/2020 07:00	0.0	0	0	0	0	1
08/17/2020 08:00	0.0	0	0	0	0	1
08/17/2020 09:00	0.0	0	0	0	0	1
08/17/2020 10:00	0.0	0	0	0	0	1
08/17/2020 11:00	0.0	0	0	0	0	1
08/17/2020 12:00	0.0	0	0	0	0	1
08/17/2020 13:00	0.0	0	0	0	0	1
08/17/2020 14:00	0.0	0	0	0	0	1
08/17/2020 15:00	0.0	0	0	0	0	1
08/17/2020 16:00	0.0	0	0	0	0	1
08/17/2020 17:00	0.0	0	0	0	0	1
08/17/2020 18:00	0.0	0	0	0	0	1
08/17/2020 19:00	0.0	0	0	0	0	1
08/17/2020 20:00	0.0	0	0	0	0	1
08/17/2020 21:00	0.0	0	0	0	0	1
08/17/2020 22:00	0.0	0	0	0	0	1
08/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/18/2020 00:00	0.0	0	0	0	0	1
08/18/2020 01:00	0.0	0	0	0	0	1
08/18/2020 02:00	0.0	0	0	0	0	1
08/18/2020 03:00	0.0	0	0	0	0	1
08/18/2020 04:00	0.0	0	0	0	0	1
08/18/2020 05:00	0.0	0	0	0	0	1
08/18/2020 06:00	0.0	0	0	0	0	1
08/18/2020 07:00	0.0	0	0	0	0	1
08/18/2020 08:00	0.0	0	0	0	0	1
08/18/2020 09:00	0.0	0	0	0	0	1
08/18/2020 10:00	0.0	0	0	0	0	1
08/18/2020 11:00	0.0	0	0	0	0	1
08/18/2020 12:00	0.0	0	0	0	0	1
08/18/2020 13:00	0.0	0	0	0	0	1
08/18/2020 14:00	0.0	0	0	0	0	1
08/18/2020 15:00	0.0	0	0	0	0	1
08/18/2020 16:00	0.0	0	0	0	0	1
08/18/2020 17:00	0.0	0	0	0	0	1
08/18/2020 18:00	0.0	0	0	0	0	1
08/18/2020 19:00	0.0	0	0	0	0	1
08/18/2020 20:00	0.0	0	0	0	0	1
08/18/2020 21:00	0.0	0	0	0	0	1
08/18/2020 22:00	0.0	0	0	0	0	1
08/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/19/2020 00:00	0.0	0	0	0	0	1
08/19/2020 01:00	0.0	0	0	0	0	1
08/19/2020 02:00	0.0	0	0	0	0	1
08/19/2020 03:00	0.0	0	0	0	0	1
08/19/2020 04:00	0.0	0	0	0	0	1
08/19/2020 05:00	0.0	0	0	0	0	1
08/19/2020 06:00	0.0	0	0	0	0	1
08/19/2020 07:00	0.0	0	0	0	0	1
08/19/2020 08:00	0.0	0	0	0	0	1
08/19/2020 09:00	0.0	0	0	0	0	1
08/19/2020 10:00	0.0	0	0	0	0	1
08/19/2020 11:00	0.0	0	0	0	0	1
08/19/2020 12:00	0.0	0	0	0	0	1
08/19/2020 13:00	0.0	0	0	0	0	1
08/19/2020 14:00	0.0	0	0	0	0	1
08/19/2020 15:00	0.0	0	0	0	0	1
08/19/2020 16:00	0.0	0	0	0	0	1
08/19/2020 17:00	0.0	0	0	0	0	1
08/19/2020 18:00	0.0	0	0	0	0	1
08/19/2020 19:00	0.0	0	0	0	0	1
08/19/2020 20:00	0.0	0	0	0	0	1
08/19/2020 21:00	0.0	0	0	0	0	1
08/19/2020 22:00	0.0	0	0	0	0	1
08/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/20/2020 00:00	0.0	0	0	0	0	1
08/20/2020 01:00	0.0	0	0	0	0	1
08/20/2020 02:00	0.0	0	0	0	0	1
08/20/2020 03:00	0.0	0	0	0	0	1
08/20/2020 04:00	0.0	0	0	0	0	1
08/20/2020 05:00	0.0	0	0	0	0	1
08/20/2020 06:00	0.0	0	0	0	0	1
08/20/2020 07:00	0.0	0	0	0	0	1
08/20/2020 08:00	0.0	0	0	0	0	1
08/20/2020 09:00	0.0	0	0	0	0	1
08/20/2020 10:00	0.0	0	0	0	0	1
08/20/2020 11:00	0.0	0	0	0	0	1
08/20/2020 12:00	0.0	0	0	0	0	1
08/20/2020 13:00	0.0	0	0	0	0	1
08/20/2020 14:00	0.0	0	0	0	0	1
08/20/2020 15:00	0.0	0	0	0	0	1
08/20/2020 16:00	0.0	0	0	0	0	1
08/20/2020 17:00	0.0	0	0	0	0	1
08/20/2020 18:00	0.0	0	0	0	0	1
08/20/2020 19:00	0.0	0	0	0	0	1
08/20/2020 20:00	0.0	0	0	0	0	1
08/20/2020 21:00	0.0	0	0	0	0	1
08/20/2020 22:00	0.0	0	0	0	0	1
08/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/21/2020 00:00	0.0	0	0	0	0	1
08/21/2020 01:00	0.0	0	0	0	0	1
08/21/2020 02:00	0.0	0	0	0	0	1
08/21/2020 03:00	0.0	0	0	0	0	1
08/21/2020 04:00	0.0	0	0	0	0	1
08/21/2020 05:00	0.0	0	0	0	0	1
08/21/2020 06:00	0.0	0	0	0	0	1
08/21/2020 07:00	0.0	0	0	0	0	1
08/21/2020 08:00	0.0	0	0	0	0	1
08/21/2020 09:00	0.0	0	0	0	0	1
08/21/2020 10:00	0.0	0	0	0	0	1
08/21/2020 11:00	0.0	0	0	0	0	1
08/21/2020 12:00	0.0	0	0	0	0	1
08/21/2020 13:00	0.0	0	0	0	0	1
08/21/2020 14:00	0.0	0	0	0	0	1
08/21/2020 15:00	0.0	0	0	0	0	1
08/21/2020 16:00	0.0	0	0	0	0	1
08/21/2020 17:00	0.0	0	0	0	0	1
08/21/2020 18:00	0.0	0	0	0	0	1
08/21/2020 19:00	0.0	0	0	0	0	1
08/21/2020 20:00	0.0	0	0	0	0	1
08/21/2020 21:00	0.0	0	0	0	0	1
08/21/2020 22:00	0.0	0	0	0	0	1
08/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/22/2020 00:00	0.0	0	0	0	0	1
08/22/2020 01:00	0.0	0	0	0	0	1
08/22/2020 02:00	0.0	0	0	0	0	1
08/22/2020 03:00	0.0	0	0	0	0	1
08/22/2020 04:00	0.0	0	0	0	0	1
08/22/2020 05:00	0.0	0	0	0	0	1
08/22/2020 06:00	0.0	0	0	0	0	1
08/22/2020 07:00	0.0	0	0	0	0	1
08/22/2020 08:00	0.0	0	0	0	0	1
08/22/2020 09:00	0.0	0	0	0	0	1
08/22/2020 10:00	0.0	0	0	0	0	1
08/22/2020 11:00	0.0	0	0	0	0	1
08/22/2020 12:00	0.0	0	0	0	0	1
08/22/2020 13:00	0.0	0	0	0	0	1
08/22/2020 14:00	0.0	0	0	0	0	1
08/22/2020 15:00	0.0	0	0	0	0	1
08/22/2020 16:00	0.0	0	0	0	0	1
08/22/2020 17:00	0.0	0	0	0	0	1
08/22/2020 18:00	0.0	0	0	0	0	1
08/22/2020 19:00	0.0	0	0	0	0	1
08/22/2020 20:00	0.0	0	0	0	0	1
08/22/2020 21:00	0.0	0	0	0	0	1
08/22/2020 22:00	0.0	0	0	0	0	1
08/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/23/2020 00:00	0.0	0	0	0	0	1
08/23/2020 01:00	0.0	0	0	0	0	1
08/23/2020 02:00	0.0	0	0	0	0	1
08/23/2020 03:00	0.0	0	0	0	0	1
08/23/2020 04:00	0.0	0	0	0	0	1
08/23/2020 05:00	0.0	0	0	0	0	1
08/23/2020 06:00	0.0	0	0	0	0	1
08/23/2020 07:00	0.0	0	0	0	0	1
08/23/2020 08:00	0.0	0	0	0	0	1
08/23/2020 09:00	0.0	0	0	0	0	1
08/23/2020 10:00	0.0	0	0	0	0	1
08/23/2020 11:00	0.0	0	0	0	0	1
08/23/2020 12:00	0.0	0	0	0	0	1
08/23/2020 13:00	0.0	0	0	0	0	1
08/23/2020 14:00	0.0	0	0	0	0	1
08/23/2020 15:00	0.0	0	0	0	0	1
08/23/2020 16:00	0.0	0	0	0	0	1
08/23/2020 17:00	0.0	0	0	0	0	1
08/23/2020 18:00	0.0	0	0	0	0	1
08/23/2020 19:00	0.0	0	0	0	0	1
08/23/2020 20:00	0.0	0	0	0	0	1
08/23/2020 21:00	0.0	0	0	0	0	1
08/23/2020 22:00	0.0	0	0	0	0	1
08/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/24/2020 00:00	0.0	0	0	0	0	1
08/24/2020 01:00	0.0	0	0	0	0	1
08/24/2020 02:00	0.0	0	0	0	0	1
08/24/2020 03:00	0.0	0	0	0	0	1
08/24/2020 04:00	0.0	0	0	0	0	1
08/24/2020 05:00	0.0	0	0	0	0	1
08/24/2020 06:00	0.0	0	0	0	0	1
08/24/2020 07:00	0.0	0	0	0	0	1
08/24/2020 08:00	0.0	0	0	0	0	1
08/24/2020 09:00	0.0	0	0	0	0	1
08/24/2020 10:00	0.0	0	0	0	0	1
08/24/2020 11:00	0.0	0	0	0	0	1
08/24/2020 12:00	0.0	0	0	0	0	1
08/24/2020 13:00	0.0	0	0	0	0	1
08/24/2020 14:00	0.0	0	0	0	0	1
08/24/2020 15:00	0.0	0	0	0	0	1
08/24/2020 16:00	0.0	0	0	0	0	1
08/24/2020 17:00	0.0	0	0	0	0	1
08/24/2020 18:00	0.0	0	0	0	0	1
08/24/2020 19:00	0.0	0	0	0	0	1
08/24/2020 20:00	0.0	0	0	0	0	1
08/24/2020 21:00	0.0	0	0	0	0	1
08/24/2020 22:00	0.0	0	0	0	0	1
08/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/25/2020 00:00	0.0	0	0	0	0	1
08/25/2020 01:00	0.0	0	0	0	0	1
08/25/2020 02:00	0.0	0	0	0	0	1
08/25/2020 03:00	0.0	0	0	0	0	1
08/25/2020 04:00	0.0	0	0	0	0	1
08/25/2020 05:00	0.0	0	0	0	0	1
08/25/2020 06:00	0.0	0	0	0	0	1
08/25/2020 07:00	0.0	0	0	0	0	1
08/25/2020 08:00	0.0	0	0	0	0	1
08/25/2020 09:00	0.0	0	0	0	0	1
08/25/2020 10:00	0.0	0	0	0	0	1
08/25/2020 11:00	0.0	0	0	0	0	1
08/25/2020 12:00	0.0	0	0	0	0	1
08/25/2020 13:00	0.0	0	0	0	0	1
08/25/2020 14:00	0.0	0	0	0	0	1
08/25/2020 15:00	0.0	0	0	0	0	1
08/25/2020 16:00	0.0	0	0	0	0	1
08/25/2020 17:00	0.0	0	0	0	0	1
08/25/2020 18:00	0.0	0	0	0	0	1
08/25/2020 19:00	0.0	0	0	0	0	1
08/25/2020 20:00	0.0	0	0	0	0	1
08/25/2020 21:00	0.0	0	0	0	0	1
08/25/2020 22:00	0.0	0	0	0	0	1
08/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/26/2020 00:00	0.0	0	0	0	0	1
08/26/2020 01:00	0.0	0	0	0	0	1
08/26/2020 02:00	0.0	0	0	0	0	1
08/26/2020 03:00	0.0	0	0	0	0	1
08/26/2020 04:00	0.0	0	0	0	0	1
08/26/2020 05:00	0.0	0	0	0	0	1
08/26/2020 06:00	0.0	0	0	0	0	1
08/26/2020 07:00	0.0	0	0	0	0	1
08/26/2020 08:00	0.0	0	0	0	0	1
08/26/2020 09:00	0.0	0	0	0	0	1
08/26/2020 10:00	0.0	0	0	0	0	1
08/26/2020 11:00	0.0	0	0	0	0	1
08/26/2020 12:00	0.0	0	0	0	0	1
08/26/2020 13:00	0.0	0	0	0	0	1
08/26/2020 14:00	0.0	0	0	0	0	1
08/26/2020 15:00	0.0	0	0	0	0	1
08/26/2020 16:00	0.0	0	0	0	0	1
08/26/2020 17:00	0.0	0	0	0	0	1
08/26/2020 18:00	0.0	0	0	0	0	1
08/26/2020 19:00	0.0	0	0	0	0	1
08/26/2020 20:00	0.0	0	0	0	0	1
08/26/2020 21:00	0.0	0	0	0	0	1
08/26/2020 22:00	0.0	0	0	0	0	1
08/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/27/2020 00:00	0.0	0	0	0	0	1
08/27/2020 01:00	0.0	0	0	0	0	1
08/27/2020 02:00	0.0	0	0	0	0	1
08/27/2020 03:00	0.0	0	0	0	0	1
08/27/2020 04:00	0.0	0	0	0	0	1
08/27/2020 05:00	0.0	0	0	0	0	1
08/27/2020 06:00	0.0	0	0	0	0	1
08/27/2020 07:00	0.0	0	0	0	0	1
08/27/2020 08:00	0.0	0	0	0	0	1
08/27/2020 09:00	0.0	0	0	0	0	1
08/27/2020 10:00	0.0	0	0	0	0	1
08/27/2020 11:00	0.0	0	0	0	0	1
08/27/2020 12:00	0.0	0	0	0	0	1
08/27/2020 13:00	0.0	0	0	0	0	1
08/27/2020 14:00	0.0	0	0	0	0	1
08/27/2020 15:00	0.0	0	0	0	0	1
08/27/2020 16:00	0.0	0	0	0	0	1
08/27/2020 17:00	0.0	0	0	0	0	1
08/27/2020 18:00	0.0	0	0	0	0	1
08/27/2020 19:00	0.0	0	0	0	0	1
08/27/2020 20:00	0.0	0	0	0	0	1
08/27/2020 21:00	0.0	0	0	0	0	1
08/27/2020 22:00	0.0	0	0	0	0	1
08/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/28/2020 00:00	0.0	0	0	0	0	1
08/28/2020 01:00	0.0	0	0	0	0	1
08/28/2020 02:00	0.0	0	0	0	0	1
08/28/2020 03:00	0.0	0	0	0	0	1
08/28/2020 04:00	0.0	0	0	0	0	1
08/28/2020 05:00	0.0	0	0	0	0	1
08/28/2020 06:00	0.0	0	0	0	0	1
08/28/2020 07:00	0.0	0	0	0	0	1
08/28/2020 08:00	0.0	0	0	0	0	1
08/28/2020 09:00	0.0	0	0	0	0	1
08/28/2020 10:00	0.0	0	0	0	0	1
08/28/2020 11:00	0.0	0	0	0	0	1
08/28/2020 12:00	0.0	0	0	0	0	1
08/28/2020 13:00	0.0	0	0	0	0	1
08/28/2020 14:00	0.0	0	0	0	0	1
08/28/2020 15:00	0.0	0	0	0	0	1
08/28/2020 16:00	0.0	0	0	0	0	1
08/28/2020 17:00	0.0	0	0	0	0	1
08/28/2020 18:00	0.0	0	0	0	0	1
08/28/2020 19:00	0.0	0	0	0	0	1
08/28/2020 20:00	0.0	0	0	0	0	1
08/28/2020 21:00	0.0	0	0	0	0	1
08/28/2020 22:00	0.0	0	0	0	0	1
08/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/29/2020 00:00	0.0	0	0	0	0	1
08/29/2020 01:00	0.0	0	0	0	0	1
08/29/2020 02:00	0.0	0	0	0	0	1
08/29/2020 03:00	0.0	0	0	0	0	1
08/29/2020 04:00	0.0	0	0	0	0	1
08/29/2020 05:00	0.0	0	0	0	0	1
08/29/2020 06:00	0.0	0	0	0	0	1
08/29/2020 07:00	0.0	0	0	0	0	1
08/29/2020 08:00	0.0	0	0	0	0	1
08/29/2020 09:00	0.0	0	0	0	0	1
08/29/2020 10:00	0.0	0	0	0	0	1
08/29/2020 11:00	0.0	0	0	0	0	1
08/29/2020 12:00	0.0	0	0	0	0	1
08/29/2020 13:00	0.0	0	0	0	0	1
08/29/2020 14:00	0.0	0	0	0	0	1
08/29/2020 15:00	0.0	0	0	0	0	1
08/29/2020 16:00	0.0	0	0	0	0	1
08/29/2020 17:00	0.0	0	0	0	0	1
08/29/2020 18:00	0.0	0	0	0	0	1
08/29/2020 19:00	0.0	0	0	0	0	1
08/29/2020 20:00	0.0	0	0	0	0	1
08/29/2020 21:00	0.0	0	0	0	0	1
08/29/2020 22:00	0.0	0	0	0	0	1
08/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/30/2020 00:00	0.0	0	0	0	0	1
08/30/2020 01:00	0.0	0	0	0	0	1
08/30/2020 02:00	0.0	0	0	0	0	1
08/30/2020 03:00	0.0	0	0	0	0	1
08/30/2020 04:00	0.0	0	0	0	0	1
08/30/2020 05:00	0.0	0	0	0	0	1
08/30/2020 06:00	0.0	0	0	0	0	1
08/30/2020 07:00	0.0	0	0	0	0	1
08/30/2020 08:00	0.0	0	0	0	0	1
08/30/2020 09:00	0.0	0	0	0	0	1
08/30/2020 10:00	0.0	0	0	0	0	1
08/30/2020 11:00	0.0	0	0	0	0	1
08/30/2020 12:00	0.0	0	0	0	0	1
08/30/2020 13:00	0.0	0	0	0	0	1
08/30/2020 14:00	0.0	0	0	0	0	1
08/30/2020 15:00	0.0	0	0	0	0	1
08/30/2020 16:00	0.0	0	0	0	0	1
08/30/2020 17:00	0.0	0	0	0	0	1
08/30/2020 18:00	0.0	0	0	0	0	1
08/30/2020 19:00	0.0	0	0	0	0	1
08/30/2020 20:00	0.0	0	0	0	0	1
08/30/2020 21:00	0.0	0	0	0	0	1
08/30/2020 22:00	0.0	0	0	0	0	1
08/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/31/2020 00:00	0.0	0	0	0	0	1
08/31/2020 01:00	0.0	0	0	0	0	1
08/31/2020 02:00	0.0	0	0	0	0	1
08/31/2020 03:00	0.0	0	0	0	0	1
08/31/2020 04:00	0.0	0	0	0	0	1
08/31/2020 05:00	0.0	0	0	0	0	1
08/31/2020 06:00	0.0	0	0	0	0	1
08/31/2020 07:00	0.0	0	0	0	0	1
08/31/2020 08:00	0.0	0	0	0	0	1
08/31/2020 09:00	0.0	0	0	0	0	1
08/31/2020 10:00	0.0	0	0	0	0	1
08/31/2020 11:00	0.0	0	0	0	0	1
08/31/2020 12:00	0.0	0	0	0	0	1
08/31/2020 13:00	0.0	0	0	0	0	1
08/31/2020 14:00	0.0	0	0	0	0	1
08/31/2020 15:00	0.0	0	0	0	0	1
08/31/2020 16:00	0.0	0	0	0	0	1
08/31/2020 17:00	0.0	0	0	0	0	1
08/31/2020 18:00	0.0	0	0	0	0	1
08/31/2020 19:00	0.0	0	0	0	0	1
08/31/2020 20:00	0.0	0	0	0	0	1
08/31/2020 21:00	0.0	0	0	0	0	1
08/31/2020 22:00	0.0	0	0	0	0	1
08/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/01/2020 00:00	0.0	0	0	0	0	1
09/01/2020 01:00	0.0	0	0	0	0	1
09/01/2020 02:00	0.0	0	0	0	0	1
09/01/2020 03:00	0.0	0	0	0	0	1
09/01/2020 04:00	0.0	0	0	0	0	1
09/01/2020 05:00	0.0	0	0	0	0	1
09/01/2020 06:00	0.0	0	0	0	0	1
09/01/2020 07:00	0.0	0	0	0	0	1
09/01/2020 08:00	0.0	0	0	0	0	1
09/01/2020 09:00	0.0	0	0	0	0	1
09/01/2020 10:00	0.0	0	0	0	0	1
09/01/2020 11:00	0.0	0	0	0	0	1
09/01/2020 12:00	0.0	0	0	0	0	1
09/01/2020 13:00	0.0	0	0	0	0	1
09/01/2020 14:00	0.0	0	0	0	0	1
09/01/2020 15:00	0.0	0	0	0	0	1
09/01/2020 16:00	0.0	0	0	0	0	1
09/01/2020 17:00	0.0	0	0	0	0	1
09/01/2020 18:00	0.0	0	0	0	0	1
09/01/2020 19:00	0.0	0	0	0	0	1
09/01/2020 20:00	0.0	0	0	0	0	1
09/01/2020 21:00	0.0	0	0	0	0	1
09/01/2020 22:00	0.0	0	0	0	0	1
09/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/02/2020 00:00	0.0	0	0	0	0	1
09/02/2020 01:00	0.0	0	0	0	0	1
09/02/2020 02:00	0.0	0	0	0	0	1
09/02/2020 03:00	0.0	0	0	0	0	1
09/02/2020 04:00	0.0	0	0	0	0	1
09/02/2020 05:00	0.0	0	0	0	0	1
09/02/2020 06:00	0.0	0	0	0	0	1
09/02/2020 07:00	0.7	0	0	0	1	0
09/02/2020 08:00	0.0	0	0	0	0	0
09/02/2020 09:00	0.0	0	0	0	0	0
09/02/2020 10:00	0.0	0	0	0	0	0
09/02/2020 11:00	0.0	0	0	0	0	0
09/02/2020 12:00	0.0	0	0	0	0	0
09/02/2020 13:00	0.0	0	0	0	0	0
09/02/2020 14:00	0.0	0	0	0	0	0
09/02/2020 15:00	0.0	0	0	0	0	0
09/02/2020 16:00	0.0	0	0	0	0	0
09/02/2020 17:00	0.0	0	0	0	0	0
09/02/2020 18:00	0.0	0	0	0	0	0
09/02/2020 19:00	0.0	0	0	0	0	0
09/02/2020 20:00	0.0	0	0	0	0	0
09/02/2020 21:00	0.0	0	0	0	0	0
09/02/2020 22:00	0.0	0	0	0	0	0
09/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.7 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOX_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/03/2020 00:00	0.0	0	0	0	0	0
09/03/2020 01:00	0.0	0	0	0	0	0
09/03/2020 02:00	0.0	0	0	0	0	0
09/03/2020 03:00	29.6	0	1	0	0	0
09/03/2020 04:00	40.7	0	1	0	0	0
09/03/2020 05:00	0.0	0	0	0	0	1
09/03/2020 06:00	0.0	0	0	0	0	1
09/03/2020 07:00	0.0	0	0	0	0	1
09/03/2020 08:00	0.0	0	0	0	0	1
09/03/2020 09:00	0.0	0	0	0	0	1
09/03/2020 10:00	0.0	0	0	0	0	1
09/03/2020 11:00	0.0	0	0	0	0	1
09/03/2020 12:00	0.0	0	0	0	0	1
09/03/2020 13:00	0.0	0	0	0	0	1
09/03/2020 14:00	0.0	0	0	0	0	1
09/03/2020 15:00	0.0	0	0	0	0	1
09/03/2020 16:00	0.0	0	0	0	0	1
09/03/2020 17:00	0.0	0	0	0	0	1
09/03/2020 18:00	0.0	0	0	0	0	1
09/03/2020 19:00	0.0	0	0	0	0	1
09/03/2020 20:00	0.0	0	0	0	0	1
09/03/2020 21:00	0.0	0	0	0	0	1
09/03/2020 22:00	0.0	0	0	0	0	1
09/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	70.3 #	0 #	2 #	0 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	40.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/04/2020 00:00	0.0	0	0	0	0	1
09/04/2020 01:00	0.0	0	0	0	0	1
09/04/2020 02:00	0.0	0	0	0	0	1
09/04/2020 03:00	0.0	0	0	0	0	1
09/04/2020 04:00	0.0	0	0	0	0	1
09/04/2020 05:00	0.0	0	0	0	0	1
09/04/2020 06:00	0.0	0	0	0	0	1
09/04/2020 07:00	0.0	0	0	0	0	1
09/04/2020 08:00	0.0	0	0	0	0	1
09/04/2020 09:00	0.0	0	0	0	0	1
09/04/2020 10:00	0.0	0	0	0	0	1
09/04/2020 11:00	0.0	0	0	0	0	1
09/04/2020 12:00	0.0	0	0	0	0	1
09/04/2020 13:00	0.0	0	0	0	0	1
09/04/2020 14:00	0.0	0	0	0	0	1
09/04/2020 15:00	0.0	0	0	0	0	1
09/04/2020 16:00	0.0	0	0	0	0	1
09/04/2020 17:00	0.0	0	0	0	0	1
09/04/2020 18:00	0.0	0	0	0	0	1
09/04/2020 19:00	0.0	0	0	0	0	1
09/04/2020 20:00	0.0	0	0	0	0	1
09/04/2020 21:00	0.0	0	0	0	0	1
09/04/2020 22:00	0.0	0	0	0	0	1
09/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/05/2020 00:00	0.0	0	0	0	0	1
09/05/2020 01:00	0.0	0	0	0	0	1
09/05/2020 02:00	0.0	0	0	0	0	1
09/05/2020 03:00	0.0	0	0	0	0	1
09/05/2020 04:00	0.0	0	0	0	0	1
09/05/2020 05:00	0.0	0	0	0	0	1
09/05/2020 06:00	0.0	0	0	0	0	1
09/05/2020 07:00	0.0	0	0	0	0	1
09/05/2020 08:00	0.0	0	0	0	0	1
09/05/2020 09:00	0.0	0	0	0	0	1
09/05/2020 10:00	0.0	0	0	0	0	1
09/05/2020 11:00	0.0	0	0	0	0	1
09/05/2020 12:00	0.0	0	0	0	0	1
09/05/2020 13:00	0.0	0	0	0	0	1
09/05/2020 14:00	0.0	0	0	0	0	1
09/05/2020 15:00	0.0	0	0	0	0	1
09/05/2020 16:00	0.0	0	0	0	0	1
09/05/2020 17:00	0.0	0	0	0	0	1
09/05/2020 18:00	0.0	0	0	0	0	1
09/05/2020 19:00	0.0	0	0	0	0	1
09/05/2020 20:00	0.0	0	0	0	0	1
09/05/2020 21:00	0.0	0	0	0	0	1
09/05/2020 22:00	0.0	0	0	0	0	1
09/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/06/2020 00:00	0.0	0	0	0	0	1
09/06/2020 01:00	0.0	0	0	0	0	1
09/06/2020 02:00	0.0	0	0	0	0	1
09/06/2020 03:00	0.0	0	0	0	0	1
09/06/2020 04:00	0.0	0	0	0	0	1
09/06/2020 05:00	0.0	0	0	0	0	1
09/06/2020 06:00	0.0	0	0	0	0	1
09/06/2020 07:00	0.0	0	0	0	0	1
09/06/2020 08:00	0.0	0	0	0	0	1
09/06/2020 09:00	0.0	0	0	0	0	1
09/06/2020 10:00	0.0	0	0	0	0	1
09/06/2020 11:00	0.0	0	0	0	0	1
09/06/2020 12:00	0.0	0	0	0	0	1
09/06/2020 13:00	0.0	0	0	0	0	1
09/06/2020 14:00	0.0	0	0	0	0	1
09/06/2020 15:00	0.0	0	0	0	0	1
09/06/2020 16:00	0.0	0	0	0	0	1
09/06/2020 17:00	0.0	0	0	0	0	1
09/06/2020 18:00	0.0	0	0	0	0	1
09/06/2020 19:00	0.0	0	0	0	0	1
09/06/2020 20:00	0.0	0	0	0	0	1
09/06/2020 21:00	0.0	0	0	0	0	1
09/06/2020 22:00	0.0	0	0	0	0	1
09/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/07/2020 00:00	0.0	0	0	0	0	1
09/07/2020 01:00	0.0	0	0	0	0	1
09/07/2020 02:00	0.0	0	0	0	0	1
09/07/2020 03:00	0.0	0	0	0	0	1
09/07/2020 04:00	0.0	0	0	0	0	1
09/07/2020 05:00	0.0	0	0	0	0	1
09/07/2020 06:00	0.0	0	0	0	0	1
09/07/2020 07:00	0.0	0	0	0	0	1
09/07/2020 08:00	0.0	0	0	0	0	1
09/07/2020 09:00	0.0	0	0	0	0	1
09/07/2020 10:00	0.0	0	0	0	0	1
09/07/2020 11:00	0.0	0	0	0	0	1
09/07/2020 12:00	0.0	0	0	0	0	1
09/07/2020 13:00	0.0	0	0	0	0	1
09/07/2020 14:00	0.0	0	0	0	0	1
09/07/2020 15:00	0.0	0	0	0	0	1
09/07/2020 16:00	0.0	0	0	0	0	1
09/07/2020 17:00	0.0	0	0	0	0	1
09/07/2020 18:00	0.0	0	0	0	0	1
09/07/2020 19:00	0.0	0	0	0	0	1
09/07/2020 20:00	0.0	0	0	0	0	1
09/07/2020 21:00	0.0	0	0	0	0	1
09/07/2020 22:00	0.0	0	0	0	0	1
09/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/08/2020 00:00	0.0	0	0	0	0	1
09/08/2020 01:00	0.0	0	0	0	0	1
09/08/2020 02:00	0.0	0	0	0	0	1
09/08/2020 03:00	0.0	0	0	0	0	1
09/08/2020 04:00	0.0	0	0	0	0	1
09/08/2020 05:00	0.0	0	0	0	0	1
09/08/2020 06:00	0.0	0	0	0	0	1
09/08/2020 07:00	0.0	0	0	0	0	1
09/08/2020 08:00	0.0	0	0	0	0	1
09/08/2020 09:00	0.0	0	0	0	0	1
09/08/2020 10:00	0.0	0	0	0	0	1
09/08/2020 11:00	0.0	0	0	0	0	1
09/08/2020 12:00	0.0	0	0	0	0	1
09/08/2020 13:00	0.0	0	0	0	0	1
09/08/2020 14:00	0.0	0	0	0	0	1
09/08/2020 15:00	0.0	0	0	0	0	1
09/08/2020 16:00	0.0	0	0	0	0	1
09/08/2020 17:00	0.0	0	0	0	0	1
09/08/2020 18:00	0.0	0	0	0	0	1
09/08/2020 19:00	0.0	0	0	0	0	1
09/08/2020 20:00	0.0	0	0	0	0	1
09/08/2020 21:00	0.0	0	0	0	0	1
09/08/2020 22:00	0.0	0	0	0	0	1
09/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/09/2020 00:00	0.0	0	0	0	0	1
09/09/2020 01:00	0.0	0	0	0	0	1
09/09/2020 02:00	0.0	0	0	0	0	1
09/09/2020 03:00	0.0	0	0	0	0	1
09/09/2020 04:00	0.0	0	0	0	0	1
09/09/2020 05:00	0.0	0	0	0	0	1
09/09/2020 06:00	0.0	0	0	0	0	1
09/09/2020 07:00	0.0	0	0	0	0	1
09/09/2020 08:00	0.0	0	0	0	0	1
09/09/2020 09:00	0.0	0	0	0	0	1
09/09/2020 10:00	0.0	0	0	0	0	1
09/09/2020 11:00	0.0	0	0	0	0	1
09/09/2020 12:00	0.0	0	0	0	0	1
09/09/2020 13:00	0.0	0	0	0	0	1
09/09/2020 14:00	0.0	0	0	0	0	1
09/09/2020 15:00	0.0	0	0	0	0	1
09/09/2020 16:00	0.0	0	0	0	0	1
09/09/2020 17:00	0.0	0	0	0	0	1
09/09/2020 18:00	0.0	0	0	0	0	1
09/09/2020 19:00	0.0	0	0	0	0	1
09/09/2020 20:00	0.0	0	0	0	0	1
09/09/2020 21:00	0.0	0	0	0	0	1
09/09/2020 22:00	0.0	0	0	0	0	1
09/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/10/2020 00:00	0.0	0	0	0	0	1
09/10/2020 01:00	0.0	0	0	0	0	1
09/10/2020 02:00	0.0	0	0	0	0	1
09/10/2020 03:00	0.0	0	0	0	0	1
09/10/2020 04:00	0.0	0	0	0	0	1
09/10/2020 05:00	0.0	0	0	0	0	1
09/10/2020 06:00	0.0	0	0	0	0	1
09/10/2020 07:00	0.0	0	0	0	0	1
09/10/2020 08:00	0.0	0	0	0	0	1
09/10/2020 09:00	0.0	0	0	0	0	1
09/10/2020 10:00	0.0	0	0	0	0	1
09/10/2020 11:00	0.0	0	0	0	0	1
09/10/2020 12:00	0.0	0	0	0	0	1
09/10/2020 13:00	0.0	0	0	0	0	1
09/10/2020 14:00	0.0	0	0	0	0	1
09/10/2020 15:00	0.0	0	0	0	0	1
09/10/2020 16:00	0.0	0	0	0	0	1
09/10/2020 17:00	0.0	0	0	0	0	1
09/10/2020 18:00	0.0	0	0	0	0	1
09/10/2020 19:00	0.0	0	0	0	0	1
09/10/2020 20:00	0.0	0	0	0	0	1
09/10/2020 21:00	0.0	0	0	0	0	1
09/10/2020 22:00	0.0	0	0	0	0	1
09/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/11/2020 00:00	0.0	0	0	0	0	1
09/11/2020 01:00	0.0	0	0	0	0	1
09/11/2020 02:00	0.0	0	0	0	0	1
09/11/2020 03:00	0.0	0	0	0	0	1
09/11/2020 04:00	0.0	0	0	0	0	1
09/11/2020 05:00	0.0	0	0	0	0	1
09/11/2020 06:00	0.0	0	0	0	0	1
09/11/2020 07:00	0.0	0	0	0	0	1
09/11/2020 08:00	0.0	0	0	0	0	1
09/11/2020 09:00	0.0	0	0	0	0	1
09/11/2020 10:00	0.0	0	0	0	0	1
09/11/2020 11:00	0.0	0	0	0	0	1
09/11/2020 12:00	0.0	0	0	0	0	1
09/11/2020 13:00	0.0	0	0	0	0	1
09/11/2020 14:00	0.0	0	0	0	0	1
09/11/2020 15:00	0.0	0	0	0	0	1
09/11/2020 16:00	0.0	0	0	0	0	1
09/11/2020 17:00	0.0	0	0	0	0	1
09/11/2020 18:00	0.0	0	0	0	0	1
09/11/2020 19:00	0.0	0	0	0	0	1
09/11/2020 20:00	0.0	0	0	0	0	1
09/11/2020 21:00	0.0	0	0	0	0	1
09/11/2020 22:00	0.0	0	0	0	0	1
09/11/2020 23:00	0.9	0	0	0	1	0
Average/Sum#:	0.9 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/12/2020 00:00	0.0	0	0	0	0	0
09/12/2020 01:00	0.0	0	0	0	0	0
09/12/2020 02:00	0.0	0	0	0	0	0
09/12/2020 03:00	0.0	0	0	0	0	0
09/12/2020 04:00	0.0	0	0	0	0	0
09/12/2020 05:00	0.0	0	0	0	0	0
09/12/2020 06:00	0.0	0	0	0	0	0
09/12/2020 07:00	0.0	0	0	0	0	0
09/12/2020 08:00	0.0	0	0	0	0	0
09/12/2020 09:00	0.0	0	0	0	0	0
09/12/2020 10:00	0.0	0	0	0	0	0
09/12/2020 11:00	0.0	0	0	0	0	0
09/12/2020 12:00	0.0	0	0	0	0	0
09/12/2020 13:00	0.0	0	0	0	0	0
09/12/2020 14:00	0.0	0	0	0	0	0
09/12/2020 15:00	0.0	0	0	0	0	0
09/12/2020 16:00	0.0	0	0	0	0	0
09/12/2020 17:00	60.1	0	1	0	0	0
09/12/2020 18:00	21.0	0	1	0	0	0
09/12/2020 19:00	28.9	0	1	0	0	0
09/12/2020 20:00	0.0	0	0	0	0	1
09/12/2020 21:00	0.0	0	0	0	0	1
09/12/2020 22:00	0.0	0	0	0	0	1
09/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	110.0 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	60.1	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/13/2020 00:00	0.0	0	0	0	0	1
09/13/2020 01:00	0.0	0	0	0	0	1
09/13/2020 02:00	0.9	0	0	0	1	0
09/13/2020 03:00	0.0	0	0	0	0	0
09/13/2020 04:00	0.0	0	0	0	0	0
09/13/2020 05:00	0.0	0	0	0	0	0
09/13/2020 06:00	0.0	0	0	0	0	0
09/13/2020 07:00	0.0	0	0	0	0	0
09/13/2020 08:00	0.0	0	0	0	0	0
09/13/2020 09:00	0.0	0	0	0	0	0
09/13/2020 10:00	0.0	0	0	0	0	0
09/13/2020 11:00	0.0	0	0	0	0	0
09/13/2020 12:00	0.0	0	0	0	0	0
09/13/2020 13:00	0.0	0	0	0	0	0
09/13/2020 14:00	0.0	0	0	0	0	0
09/13/2020 15:00	0.0	0	0	0	0	0
09/13/2020 16:00	0.0	0	0	0	0	0
09/13/2020 17:00	63.5	0	1	0	0	0
09/13/2020 18:00	20.6	0	1	0	0	0
09/13/2020 19:00	32.8	0	1	0	0	0
09/13/2020 20:00	0.0	0	0	0	0	1
09/13/2020 21:00	0.0	0	0	0	0	1
09/13/2020 22:00	0.0	0	0	0	0	1
09/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	117.8 #	0 #	3 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	63.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/14/2020 00:00	0.0	0	0	0	0	1
09/14/2020 01:00	0.0	0	0	0	0	1
09/14/2020 02:00	0.8	0	0	0	1	0
09/14/2020 03:00	0.0	0	0	0	0	0
09/14/2020 04:00	0.0	0	0	0	0	0
09/14/2020 05:00	0.0	0	0	0	0	0
09/14/2020 06:00	0.0	0	0	0	0	0
09/14/2020 07:00	0.0	0	0	0	0	0
09/14/2020 08:00	0.0	0	0	0	0	0
09/14/2020 09:00	0.2	0	0	1	0	0
09/14/2020 10:00	75.3	0	0	1	0	0
09/14/2020 11:00	3.8	0	0	1	0	0
09/14/2020 12:00	0.0	0	0	0	0	1
09/14/2020 13:00	0.0	0	0	0	0	1
09/14/2020 14:00	0.0	0	0	0	0	1
09/14/2020 15:00	0.0	0	0	0	0	1
09/14/2020 16:00	0.0	0	0	0	0	1
09/14/2020 17:00	0.0	0	0	0	0	1
09/14/2020 18:00	0.0	0	0	0	0	1
09/14/2020 19:00	0.0	0	0	0	0	1
09/14/2020 20:00	0.0	0	0	0	0	1
09/14/2020 21:00	0.0	0	0	0	0	1
09/14/2020 22:00	0.0	0	0	0	0	1
09/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	80.1 #	0 #	0 #	3 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	75.3	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/15/2020 00:00	0.0	0	0	0	0	1
09/15/2020 01:00	0.0	0	0	0	0	1
09/15/2020 02:00	0.0	0	0	0	0	1
09/15/2020 03:00	0.0	0	0	0	0	1
09/15/2020 04:00	0.0	0	0	0	0	1
09/15/2020 05:00	0.0	0	0	0	0	1
09/15/2020 06:00	0.0	0	0	0	0	1
09/15/2020 07:00	0.0	0	0	0	0	1
09/15/2020 08:00	0.0	0	0	0	0	1
09/15/2020 09:00	0.0	0	0	0	0	1
09/15/2020 10:00	0.0	0	0	0	0	1
09/15/2020 11:00	0.0	0	0	0	0	1
09/15/2020 12:00	0.0	0	0	0	0	1
09/15/2020 13:00	0.0	0	0	0	0	1
09/15/2020 14:00	0.0	0	0	0	0	1
09/15/2020 15:00	0.0	0	0	0	0	1
09/15/2020 16:00	0.0	0	0	0	0	1
09/15/2020 17:00	0.0	0	0	0	0	1
09/15/2020 18:00	0.0	0	0	0	0	1
09/15/2020 19:00	0.0	0	0	0	0	1
09/15/2020 20:00	0.0	0	0	0	0	1
09/15/2020 21:00	0.0	0	0	0	0	1
09/15/2020 22:00	1.1	0	0	0	1	0
09/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.1 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/16/2020 00:00	0.0	0	0	0	0	0
09/16/2020 01:00	0.0	0	0	0	0	0
09/16/2020 02:00	0.0	0	0	0	0	0
09/16/2020 03:00	0.0	0	0	0	0	0
09/16/2020 04:00	0.0	0	0	0	0	0
09/16/2020 05:00	0.0	0	0	0	0	0
09/16/2020 06:00	0.0	0	0	0	0	0
09/16/2020 07:00	0.0	0	0	0	0	0
09/16/2020 08:00	0.0	0	0	0	0	0
09/16/2020 09:00	0.0	0	0	0	0	0
09/16/2020 10:00	0.0	0	0	0	0	0
09/16/2020 11:00	49.6	0	1	0	0	0
09/16/2020 12:00	19.2	0	1	0	0	0
09/16/2020 13:00	0.0	0	0	0	0	1
09/16/2020 14:00	0.0	0	0	0	0	1
09/16/2020 15:00	0.0	0	0	0	0	1
09/16/2020 16:00	0.0	0	0	0	0	1
09/16/2020 17:00	0.0	0	0	0	0	1
09/16/2020 18:00	0.0	0	0	0	0	1
09/16/2020 19:00	0.0	0	0	0	0	1
09/16/2020 20:00	0.0	0	0	0	0	1
09/16/2020 21:00	0.0	0	0	0	0	1
09/16/2020 22:00	0.0	0	0	0	0	1
09/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	68.8 #	0 #	2 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	49.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/17/2020 00:00	0.0	0	0	0	0	1
09/17/2020 01:00	0.0	0	0	0	0	1
09/17/2020 02:00	0.0	0	0	0	0	1
09/17/2020 03:00	0.0	0	0	0	0	1
09/17/2020 04:00	0.0	0	0	0	0	1
09/17/2020 05:00	0.0	0	0	0	0	1
09/17/2020 06:00	0.0	0	0	0	0	1
09/17/2020 07:00	0.0	0	0	0	0	1
09/17/2020 08:00	0.0	0	0	0	0	1
09/17/2020 09:00	0.0	0	0	0	0	1
09/17/2020 10:00	0.0	0	0	0	0	1
09/17/2020 11:00	0.0	0	0	0	0	1
09/17/2020 12:00	0.0	0	0	0	0	1
09/17/2020 13:00	0.0	0	0	0	0	1
09/17/2020 14:00	0.0	0	0	0	0	1
09/17/2020 15:00	0.0	0	0	0	0	1
09/17/2020 16:00	0.0	0	0	0	0	1
09/17/2020 17:00	0.0	0	0	0	0	1
09/17/2020 18:00	0.0	0	0	0	0	1
09/17/2020 19:00	0.0	0	0	0	0	1
09/17/2020 20:00	0.0	0	0	0	0	1
09/17/2020 21:00	0.0	0	0	0	0	1
09/17/2020 22:00	0.0	0	0	0	0	1
09/17/2020 23:00	0.6	0	0	0	1	0
Average/Sum#:	0.6 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/18/2020 00:00	0.0	0	0	0	1	0
09/18/2020 01:00	0.0	0	0	0	0	0
09/18/2020 02:00	0.0	0	0	0	0	0
09/18/2020 03:00	0.0	0	0	0	0	0
09/18/2020 04:00	0.0	0	0	0	0	0
09/18/2020 05:00	0.0	0	0	0	0	0
09/18/2020 06:00	0.0	0	0	0	0	0
09/18/2020 07:00	0.0	0	0	0	0	0
09/18/2020 08:00	0.0	0	0	0	0	0
09/18/2020 09:00	0.0	0	0	0	0	0
09/18/2020 10:00	6.8	0	1	0	0	0
09/18/2020 11:00	66.9	0	1	0	0	0
09/18/2020 12:00	0.0	0	0	0	0	1
09/18/2020 13:00	0.0	0	0	0	0	1
09/18/2020 14:00	0.0	0	0	0	0	1
09/18/2020 15:00	0.0	0	0	0	0	1
09/18/2020 16:00	0.0	0	0	0	0	1
09/18/2020 17:00	0.0	0	0	0	0	1
09/18/2020 18:00	0.0	0	0	0	0	1
09/18/2020 19:00	0.0	0	0	0	0	1
09/18/2020 20:00	0.0	0	0	0	0	1
09/18/2020 21:00	0.0	0	0	0	0	1
09/18/2020 22:00	1.2	0	0	0	1	0
09/18/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	74.9 #	0 #	2 #	0 #	2 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	66.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/19/2020 00:00	0.0	0	0	0	0	0
09/19/2020 01:00	0.0	0	0	0	0	0
09/19/2020 02:00	0.0	0	0	0	0	0
09/19/2020 03:00	0.0	0	0	0	0	0
09/19/2020 04:00	0.0	0	0	0	0	0
09/19/2020 05:00	0.0	0	0	0	0	0
09/19/2020 06:00	0.0	0	0	0	0	0
09/19/2020 07:00	0.0	0	0	0	0	0
09/19/2020 08:00	0.0	0	0	0	0	0
09/19/2020 09:00	0.0	0	0	0	0	0
09/19/2020 10:00	0.0	0	0	0	0	0
09/19/2020 11:00	0.0	0	0	0	0	0
09/19/2020 12:00	0.0	0	0	0	0	0
09/19/2020 13:00	30.1	0	1	0	0	0
09/19/2020 14:00	61.2	0	1	0	0	0
09/19/2020 15:00	0.0	0	0	0	0	1
09/19/2020 16:00	0.0	0	0	0	0	1
09/19/2020 17:00	0.0	0	0	0	0	1
09/19/2020 18:00	0.0	0	0	0	0	1
09/19/2020 19:00	0.0	0	0	0	0	1
09/19/2020 20:00	0.0	0	0	0	0	1
09/19/2020 21:00	0.0	0	0	0	0	1
09/19/2020 22:00	0.0	0	0	0	0	1
09/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	91.3 #	0 #	2 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	61.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/20/2020 00:00	0.0	0	0	0	0	1
09/20/2020 01:00	0.0	0	0	0	0	1
09/20/2020 02:00	0.0	0	0	0	0	1
09/20/2020 03:00	0.0	0	0	0	0	1
09/20/2020 04:00	0.0	0	0	0	0	1
09/20/2020 05:00	0.0	0	0	0	0	1
09/20/2020 06:00	0.0	0	0	0	1	0
09/20/2020 07:00	0.0	0	0	0	0	0
09/20/2020 08:00	0.0	0	0	0	0	0
09/20/2020 09:00	0.0	0	0	0	0	0
09/20/2020 10:00	0.0	0	0	0	0	0
09/20/2020 11:00	0.0	0	0	0	0	0
09/20/2020 12:00	0.0	0	0	0	0	0
09/20/2020 13:00	0.0	0	0	0	0	0
09/20/2020 14:00	34.3	0	1	0	0	0
09/20/2020 15:00	19.7	0	1	0	0	0
09/20/2020 16:00	0.0	0	0	0	0	1
09/20/2020 17:00	0.0	0	0	0	0	1
09/20/2020 18:00	0.0	0	0	0	0	1
09/20/2020 19:00	0.0	0	0	0	0	1
09/20/2020 20:00	0.0	0	0	0	0	1
09/20/2020 21:00	0.0	0	0	0	0	1
09/20/2020 22:00	1.1	0	0	0	1	0
09/20/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	55.1 #	0 #	2 #	0 #	2 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	34.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/21/2020 00:00	0.0	0	0	0	0	0
09/21/2020 01:00	0.0	0	0	0	0	0
09/21/2020 02:00	0.0	0	0	0	0	0
09/21/2020 03:00	0.0	0	0	0	0	0
09/21/2020 04:00	0.0	0	0	0	0	0
09/21/2020 05:00	0.0	0	0	0	0	0
09/21/2020 06:00	0.0	0	0	0	0	0
09/21/2020 07:00	0.0	0	0	0	0	0
09/21/2020 08:00	25.0	0	1	0	0	0
09/21/2020 09:00	36.7	0	1	0	0	0
09/21/2020 10:00	31.8	0	1	0	0	0
09/21/2020 11:00	0.0	0	0	0	0	1
09/21/2020 12:00	0.0	0	0	0	0	1
09/21/2020 13:00	0.0	0	0	0	0	1
09/21/2020 14:00	0.0	0	0	0	0	1
09/21/2020 15:00	0.0	0	0	0	0	1
09/21/2020 16:00	0.0	0	0	0	0	1
09/21/2020 17:00	0.0	0	0	0	0	1
09/21/2020 18:00	0.0	0	0	0	0	1
09/21/2020 19:00	0.0	0	0	0	0	1
09/21/2020 20:00	0.0	0	0	0	0	1
09/21/2020 21:00	0.0	0	0	0	0	1
09/21/2020 22:00	1.1	0	0	0	1	0
09/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	94.6 #	0 #	3 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	36.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/22/2020 00:00	0.0	0	0	0	0	0
09/22/2020 01:00	0.0	0	0	0	0	0
09/22/2020 02:00	0.0	0	0	0	0	0
09/22/2020 03:00	0.0	0	0	0	0	0
09/22/2020 04:00	0.0	0	0	0	0	0
09/22/2020 05:00	0.0	0	0	0	0	0
09/22/2020 06:00	0.0	0	0	0	0	0
09/22/2020 07:00	0.0	0	0	0	0	0
09/22/2020 08:00	23.2	0	1	0	0	0
09/22/2020 09:00	40.2	0	1	0	0	0
09/22/2020 10:00	34.2	0	1	0	0	0
09/22/2020 11:00	0.0	0	0	0	0	1
09/22/2020 12:00	0.0	0	0	0	0	1
09/22/2020 13:00	0.0	0	0	0	0	1
09/22/2020 14:00	0.0	0	0	0	0	1
09/22/2020 15:00	0.0	0	0	0	0	1
09/22/2020 16:00	0.0	0	0	0	0	1
09/22/2020 17:00	0.0	0	0	0	0	1
09/22/2020 18:00	0.0	0	0	0	0	1
09/22/2020 19:00	0.0	0	0	0	0	1
09/22/2020 20:00	0.0	0	0	0	0	1
09/22/2020 21:00	1.4	0	0	0	1	0
09/22/2020 22:00	0.0	0	0	0	0	0
09/22/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	99.0 #	0 #	3 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	40.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/23/2020 00:00	0.0	0	0	0	0	0
09/23/2020 01:00	0.0	0	0	0	0	0
09/23/2020 02:00	0.0	0	0	0	0	0
09/23/2020 03:00	0.0	0	0	0	0	0
09/23/2020 04:00	0.0	0	0	0	0	0
09/23/2020 05:00	0.0	0	0	0	0	0
09/23/2020 06:00	0.0	0	0	0	0	0
09/23/2020 07:00	0.0	0	0	0	0	0
09/23/2020 08:00	42.1	0	1	0	0	0
09/23/2020 09:00	29.1	0	1	0	0	0
09/23/2020 10:00	35.7	0	1	0	0	0
09/23/2020 11:00	0.0	0	0	0	0	1
09/23/2020 12:00	0.0	0	0	0	0	1
09/23/2020 13:00	0.0	0	0	0	0	1
09/23/2020 14:00	0.0	0	0	0	0	1
09/23/2020 15:00	0.0	0	0	0	0	1
09/23/2020 16:00	0.0	0	0	0	0	1
09/23/2020 17:00	0.0	0	0	0	0	1
09/23/2020 18:00	0.0	0	0	0	0	1
09/23/2020 19:00	0.0	0	0	0	0	1
09/23/2020 20:00	0.0	0	0	0	0	1
09/23/2020 21:00	1.6	0	0	0	1	0
09/23/2020 22:00	0.0	0	0	0	0	0
09/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	108.5 #	0 #	3 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	42.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/24/2020 00:00	0.0	0	0	0	0	0
09/24/2020 01:00	0.0	0	0	0	0	0
09/24/2020 02:00	0.0	0	0	0	0	0
09/24/2020 03:00	0.0	0	0	0	0	0
09/24/2020 04:00	0.0	0	0	0	0	0
09/24/2020 05:00	0.0	0	0	0	0	0
09/24/2020 06:00	0.0	0	0	0	0	0
09/24/2020 07:00	0.0	0	0	0	0	0
09/24/2020 08:00	0.0	0	0	0	0	0
09/24/2020 09:00	0.0	0	0	0	0	0
09/24/2020 10:00	0.0	0	0	0	0	0
09/24/2020 11:00	0.0	0	0	0	0	0
09/24/2020 12:00	0.0	0	0	0	0	0
09/24/2020 13:00	57.0	0	1	0	0	0
09/24/2020 14:00	37.1	0	1	0	0	0
09/24/2020 15:00	0.0	0	0	0	0	1
09/24/2020 16:00	0.0	0	0	0	0	1
09/24/2020 17:00	0.0	0	0	0	0	1
09/24/2020 18:00	0.0	0	0	0	0	1
09/24/2020 19:00	0.0	0	0	0	0	1
09/24/2020 20:00	1.3	0	0	0	1	0
09/24/2020 21:00	0.0	0	0	0	0	0
09/24/2020 22:00	0.0	0	0	0	0	0
09/24/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	95.4 #	0 #	2 #	0 #	1 #	5 #
Minimum:	0.0	0	0	0	0	0
Maximum:	57.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/25/2020 00:00	0.0	0	0	0	0	0
09/25/2020 01:00	0.0	0	0	0	0	0
09/25/2020 02:00	0.0	0	0	0	0	0
09/25/2020 03:00	0.0	0	0	0	0	0
09/25/2020 04:00	0.0	0	0	0	0	0
09/25/2020 05:00	0.0	0	0	0	0	0
09/25/2020 06:00	0.0	0	0	0	0	0
09/25/2020 07:00	0.0	0	0	0	0	0
09/25/2020 08:00	0.0	0	0	0	0	0
09/25/2020 09:00	0.0	0	0	0	0	0
09/25/2020 10:00	0.0	0	0	0	0	0
09/25/2020 11:00	0.0	0	0	0	0	0
09/25/2020 12:00	0.0	0	0	0	0	0
09/25/2020 13:00	0.0	0	0	0	0	0
09/25/2020 14:00	0.0	0	0	0	0	0
09/25/2020 15:00	0.0	0	0	0	0	0
09/25/2020 16:00	0.0	0	0	0	0	0
09/25/2020 17:00	0.0	0	0	0	0	0
09/25/2020 18:00	0.0	0	0	0	0	0
09/25/2020 19:00	0.0	0	0	0	0	0
09/25/2020 20:00	0.0	0	0	0	0	0
09/25/2020 21:00	0.0	0	0	0	0	0
09/25/2020 22:00	0.0	0	0	0	0	0
09/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/26/2020 00:00	0.0	0	0	0	0	0
09/26/2020 01:00	0.0	0	0	0	0	0
09/26/2020 02:00	0.0	0	0	0	0	0
09/26/2020 03:00	0.0	0	0	0	0	0
09/26/2020 04:00	0.0	0	0	0	0	0
09/26/2020 05:00	0.0	0	0	0	0	0
09/26/2020 06:00	0.0	0	0	0	0	0
09/26/2020 07:00	0.0	0	0	0	0	0
09/26/2020 08:00	0.0	0	0	0	0	0
09/26/2020 09:00	0.0	0	0	0	0	0
09/26/2020 10:00	0.0	0	0	0	0	0
09/26/2020 11:00	0.0	0	0	0	0	0
09/26/2020 12:00	0.0	0	0	0	0	0
09/26/2020 13:00	0.0	0	0	0	0	0
09/26/2020 14:00	0.0	0	0	0	0	0
09/26/2020 15:00	0.0	0	0	0	0	0
09/26/2020 16:00	0.0	0	0	0	0	0
09/26/2020 17:00	0.0	0	0	0	0	0
09/26/2020 18:00	0.0	0	0	0	0	0
09/26/2020 19:00	0.0	0	0	0	0	0
09/26/2020 20:00	0.0	0	0	0	0	0
09/26/2020 21:00	0.0	0	0	0	0	0
09/26/2020 22:00	0.0	0	0	0	0	0
09/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/27/2020 00:00	0.0	0	0	0	0	0
09/27/2020 01:00	0.0	0	0	0	0	0
09/27/2020 02:00	0.0	0	0	0	0	0
09/27/2020 03:00	0.0	0	0	0	0	0
09/27/2020 04:00	0.0	0	0	0	0	0
09/27/2020 05:00	0.0	0	0	0	0	0
09/27/2020 06:00	0.0	0	0	0	0	0
09/27/2020 07:00	0.0	0	0	0	0	0
09/27/2020 08:00	0.0	0	1	0	0	0
09/27/2020 09:00	102.4	0	1	0	0	0
09/27/2020 10:00	44.5	0	1	0	0	0
09/27/2020 11:00	0.0	0	0	0	0	1
09/27/2020 12:00	0.0	0	0	0	0	1
09/27/2020 13:00	0.0	0	0	0	0	1
09/27/2020 14:00	0.0	0	0	0	0	1
09/27/2020 15:00	0.0	0	0	0	0	1
09/27/2020 16:00	0.0	0	0	0	0	1
09/27/2020 17:00	0.0	0	0	0	0	1
09/27/2020 18:00	0.0	0	0	0	0	1
09/27/2020 19:00	0.0	0	0	0	0	1
09/27/2020 20:00	0.0	0	0	0	0	1
09/27/2020 21:00	0.0	0	0	0	0	1
09/27/2020 22:00	1.3	0	0	0	1	0
09/27/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	148.2 #	0 #	3 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	102.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/28/2020 00:00	0.0	0	0	0	0	0
09/28/2020 01:00	0.0	0	0	0	0	0
09/28/2020 02:00	0.0	0	0	0	0	0
09/28/2020 03:00	0.0	0	0	0	0	0
09/28/2020 04:00	0.0	0	0	0	0	0
09/28/2020 05:00	0.0	0	0	0	0	0
09/28/2020 06:00	0.0	0	0	0	0	0
09/28/2020 07:00	0.0	0	0	0	0	0
09/28/2020 08:00	0.0	0	0	0	0	0
09/28/2020 09:00	0.0	0	0	0	0	0
09/28/2020 10:00	60.7	0	1	0	0	0
09/28/2020 11:00	33.6	0	1	0	0	0
09/28/2020 12:00	0.0	0	0	0	0	1
09/28/2020 13:00	0.0	0	0	0	0	1
09/28/2020 14:00	0.0	0	0	0	0	1
09/28/2020 15:00	0.0	0	0	0	0	1
09/28/2020 16:00	0.0	0	0	0	0	1
09/28/2020 17:00	0.0	0	0	0	0	1
09/28/2020 18:00	0.0	0	0	0	0	1
09/28/2020 19:00	0.0	0	0	0	0	1
09/28/2020 20:00	0.0	0	0	0	0	1
09/28/2020 21:00	0.0	0	0	0	0	1
09/28/2020 22:00	1.3	0	0	0	1	0
09/28/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	95.6 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	60.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/29/2020 00:00	0.0	0	0	0	0	0
09/29/2020 01:00	0.0	0	0	0	0	0
09/29/2020 02:00	0.0	0	0	0	0	0
09/29/2020 03:00	0.0	0	0	0	0	0
09/29/2020 04:00	0.0	0	0	0	0	0
09/29/2020 05:00	0.0	0	0	0	0	0
09/29/2020 06:00	0.0	0	0	0	0	0
09/29/2020 07:00	0.0	0	0	0	0	0
09/29/2020 08:00	0.0	0	0	0	0	0
09/29/2020 09:00	0.0	0	0	0	0	0
09/29/2020 10:00	56.6	0	1	0	0	0
09/29/2020 11:00	30.1	0	1	0	0	0
09/29/2020 12:00	0.0	0	0	0	0	1
09/29/2020 13:00	0.0	0	0	0	0	1
09/29/2020 14:00	0.0	0	0	0	0	1
09/29/2020 15:00	0.0	0	0	0	0	1
09/29/2020 16:00	0.0	0	0	0	0	1
09/29/2020 17:00	0.0	0	0	0	0	1
09/29/2020 18:00	0.0	0	0	0	0	1
09/29/2020 19:00	0.0	0	0	0	0	1
09/29/2020 20:00	0.0	0	0	0	0	1
09/29/2020 21:00	0.0	0	0	0	0	1
09/29/2020 22:00	0.0	0	0	0	0	1
09/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	86.7 #	0 #	2 #	0 #	0 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	56.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
 Generated: 10/06/2020 09:38 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/30/2020 00:00	0.0	0	0	0	0	1
09/30/2020 01:00	0.0	0	0	0	0	1
09/30/2020 02:00	0.0	0	0	0	0	1
09/30/2020 03:00	0.0	0	0	0	0	1
09/30/2020 04:00	0.0	0	0	0	0	1
09/30/2020 05:00	0.0	0	0	0	0	1
09/30/2020 06:00	0.0	0	0	0	0	1
09/30/2020 07:00	0.0	0	0	0	0	1
09/30/2020 08:00	0.0	0	0	0	0	1
09/30/2020 09:00	0.0	0	0	0	0	1
09/30/2020 10:00	0.0	0	0	0	0	1
09/30/2020 11:00	0.0	0	0	0	0	1
09/30/2020 12:00	0.0	0	0	0	0	1
09/30/2020 13:00	0.0	0	0	0	0	1
09/30/2020 14:00	0.0	0	0	0	0	1
09/30/2020 15:00	0.0	0	0	0	0	1
09/30/2020 16:00	0.0	0	0	0	0	1
09/30/2020 17:00	0.0	0	0	0	0	1
09/30/2020 18:00	0.0	0	0	0	0	1
09/30/2020 19:00	0.0	0	0	0	0	1
09/30/2020 20:00	0.0	0	0	0	0	1
09/30/2020 21:00	0.0	0	0	0	0	1
09/30/2020 22:00	0.0	0	0	0	0	1
09/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Pound Per Event Report

CT2 - CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 10/06/2020 09:39 Location: Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,867.23 Hours
 Non-Operating Time: 340.77 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
07/03/2020 08:18 07/03/2020 10:50 Warm Start - Gas	153	155.7	790.5		
07/03/2020 23:25 07/03/2020 23:30 Shut Down - Gas	6	0.8	483.5		
07/05/2020 09:18 07/05/2020 11:51 Warm Start - Gas	154	129.8	790.5		
07/05/2020 22:30 07/05/2020 22:35 Shut Down - Gas	6	1.0	483.5		
07/06/2020 02:39 07/06/2020 03:30 Hot Start - Gas	52	31.5	679.6		
07/25/2020 13:30 07/25/2020 14:54 Warm Start - Gas	85	69.3	790.5		
09/02/2020 07:20 09/02/2020 07:25 Shut Down - Gas	6	1.1	483.5		
09/03/2020 03:33 09/03/2020 04:41 Warm Start - Gas	69	53.5	790.5		
09/11/2020 23:04 09/11/2020 23:09 Shut Down - Gas	6	0.9	483.5		
09/12/2020 17:13 09/12/2020 19:46 Warm Start - Gas	154	58.7	790.5		
09/13/2020 02:03 09/13/2020 02:09 Shut Down - Gas	7	0.9	483.5		
09/13/2020 17:06 09/13/2020 19:43 Warm Start - Gas	158	74.4	790.5		
09/14/2020 02:03 09/14/2020 02:09 Shut Down - Gas	7	1.1	483.5		

Pound Per Event Report

CT2 - CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 10/06/2020 09:39 Location: Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,867.23 Hours
 Non-Operating Time: 340.77 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
09/14/2020 09:51 09/14/2020 11:12 Hot Start - Gas	82	49.3	679.6		
09/15/2020 22:25 09/15/2020 22:30 Shut Down - Gas	6	0.9	483.5		
09/16/2020 11:21 09/16/2020 12:28 Warm Start - Gas	68	36.2	790.5		
09/17/2020 23:57 09/18/2020 00:02 Shut Down - Gas	6	1.0	483.5		
09/18/2020 10:46 09/18/2020 11:53 Warm Start - Gas	68	37.9	790.5		
09/18/2020 22:40 09/18/2020 22:45 Shut Down - Gas	6	0.9	483.5		
09/19/2020 13:34 09/19/2020 14:51 Warm Start - Gas	78	38.6	790.5		
09/20/2020 06:09 09/20/2020 06:14 Shut Down - Gas	6	0.0 SI	483.5		
09/20/2020 14:23 09/20/2020 15:44 Warm Start - Gas	82	33.0	790.5		
09/20/2020 22:08 09/20/2020 22:13 Shut Down - Gas	6	1.0	483.5		
09/21/2020 08:36 09/21/2020 10:49 Warm Start - Gas	134	56.3	790.5		
09/21/2020 22:08 09/21/2020 22:13 Shut Down - Gas	6	1.0	483.5		
09/22/2020 08:38 09/22/2020 10:51 Warm Start - Gas	134	67.4	790.5		
09/22/2020 21:22 09/22/2020 21:28 Shut Down - Gas	7	1.1	483.5		

Pound Per Event Report

CT2 - CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 10/06/2020 09:39 Location: Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,867.23 Hours
 Non-Operating Time: 340.77 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
09/23/2020 08:28 09/23/2020 10:47 Warm Start - Gas	140	63.4	790.5		
09/23/2020 21:08 09/23/2020 21:13 Shut Down - Gas	6	1.0	483.5		
09/24/2020 13:19 09/24/2020 14:39 Warm Start - Gas	81	55.0	790.5		
09/24/2020 20:23 09/24/2020 20:28 Shut Down - Gas	6	0.4	483.5		
09/27/2020 08:56 09/27/2020 10:59 Warm Start - Gas	124	89.9	790.5		
09/27/2020 22:23 09/27/2020 22:28 Shut Down - Gas	6	1.0	483.5		
09/28/2020 10:18 09/28/2020 11:43 Warm Start - Gas	86	31.1	790.5		
09/28/2020 22:24 09/28/2020 22:29 Shut Down - Gas	6	1.0	483.5		
09/29/2020 10:13 09/29/2020 11:43 Warm Start - Gas	91	33.8	790.5		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT2 - CO Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 10/06/2020 09:39 Location: Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,867.23 Hours
 Non-Operating Time: 340.77 Hours Report Time: 2,208.00 Hours

Event Invalid Information

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
09/20/2020 06:09 09/20/2020 06:14	6		

Total CMS Downtime	6 Minute(s)
Total Downtime as a percentage of operating time	0.01 %
Total Availability as a percentage of operating time	99.99 %

Pound Per Event Report

CT2 - CO Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/06/2020 09:39 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,867.23 Hours
 Non-Operating Time: 340.77 Hours **Report Time:** 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary

1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	6
2. Total CMS Downtime in Minute(s)	6
3. Total Downtime as a percentage of operating time	0.01
4. Total Availability as a percentage of operating time	99.99

Pound Per Event Report

CT2 - NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 10/06/2020 09:39 Location: Maxwell, CA

Tag Name: CT2_NOX_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,844.57 Hours
 Non-Operating Time: 363.43 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
07/03/2020 08:18 07/03/2020 10:50 Warm Start - Gas	153	113.74	456.20		
07/03/2020 23:25 07/03/2020 23:30 Shut Down - Gas	6	0.27	115.00		
07/05/2020 09:18 07/05/2020 11:51 Warm Start - Gas	154	149.38	456.20		
07/05/2020 22:30 07/05/2020 22:35 Shut Down - Gas	6	0.53	115.00		
07/06/2020 02:39 07/06/2020 03:30 Hot Start - Gas	52	24.94	259.90		
07/25/2020 13:30 07/25/2020 14:54 Warm Start - Gas	85	91.88	456.20		
09/02/2020 07:20 09/02/2020 07:25 Shut Down - Gas	6	0.34	115.00		
09/03/2020 03:33 09/03/2020 04:41 Warm Start - Gas	69	79.67	456.20		
09/11/2020 23:04 09/11/2020 23:09 Shut Down - Gas	6	0.30	115.00		
09/12/2020 17:13 09/12/2020 19:46 Warm Start - Gas	154	114.13	456.20		
09/13/2020 02:03 09/13/2020 02:09 Shut Down - Gas	7	0.46	115.00		
09/13/2020 17:06 09/13/2020 19:43 Warm Start - Gas	158	122.32	456.20		
09/14/2020 02:03 09/14/2020 02:09 Shut Down - Gas	7	0.37	115.00		

Pound Per Event Report

CT2 - NOx Lbs



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 10/06/2020 09:40 Location: Maxwell, CA

Tag Name: CT2_NOX_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,844.57 Hours
 Non-Operating Time: 363.43 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
09/14/2020 09:51 09/14/2020 11:12 Hot Start - Gas	82	88.72	259.90		
09/15/2020 22:25 09/15/2020 22:30 Shut Down - Gas	6	0.51	115.00		
09/16/2020 11:21 09/16/2020 12:28 Warm Start - Gas	68	80.79	456.20		
09/17/2020 23:57 09/18/2020 00:02 Shut Down - Gas	6	0.60	115.00		
09/18/2020 10:46 09/18/2020 11:53 Warm Start - Gas	68	75.11	456.20		
09/18/2020 22:40 09/18/2020 22:45 Shut Down - Gas	6	0.45	115.00		
09/19/2020 13:34 09/19/2020 14:51 Warm Start - Gas	78	93.27	456.20		
09/20/2020 06:09 09/20/2020 06:14 Shut Down - Gas	6	0.00 SI	115.00		
09/20/2020 14:23 09/20/2020 15:44 Warm Start - Gas	82	58.00	456.20		
09/20/2020 22:08 09/20/2020 22:13 Shut Down - Gas	6	0.49	115.00		
09/21/2020 08:36 09/21/2020 10:49 Warm Start - Gas	134	97.58	456.20		
09/21/2020 22:08 09/21/2020 22:13 Shut Down - Gas	6	0.51	115.00		
09/22/2020 08:38 09/22/2020 10:51 Warm Start - Gas	134	98.88	456.20		
09/22/2020 21:22 09/22/2020 21:28 Shut Down - Gas	7	0.57	115.00		

Pound Per Event Report

CT2 - NOx Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/06/2020 09:40 **Location:** Maxwell, CA

Tag Name: CT2_NOX_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,844.57 Hours
 Non-Operating Time: 363.43 Hours **Report Time:** 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
09/23/2020 08:28 09/23/2020 10:47 Warm Start - Gas	140	110.44	456.20		
09/23/2020 21:08 09/23/2020 21:13 Shut Down - Gas	6	0.42	115.00		
09/24/2020 13:19 09/24/2020 14:39 Warm Start - Gas	81	103.21	456.20		
09/24/2020 20:23 09/24/2020 20:28 Shut Down - Gas	6	0.29	115.00		
09/27/2020 08:56 09/27/2020 10:59 Warm Start - Gas	124	147.56	456.20		
09/27/2020 22:23 09/27/2020 22:28 Shut Down - Gas	6	0.70	115.00		
09/28/2020 10:18 09/28/2020 11:43 Warm Start - Gas	86	100.54	456.20		
09/28/2020 22:24 09/28/2020 22:29 Shut Down - Gas	6	0.70	115.00		
09/29/2020 10:13 09/29/2020 11:43 Warm Start - Gas	91	93.01	456.20		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT2 - NOx Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/06/2020 09:40 **Location:** Maxwell, CA

Tag Name: CT2_NOX_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,844.57 Hours
Non-Operating Time: 363.43 Hours **Report Time:** 2,208.00 Hours

Event Invalid Information

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
09/20/2020 06:09 09/20/2020 06:14	6		

Total CMS Downtime	6 Minute(s)
Total Downtime as a percentage of operating time	0.01 %
Total Availability as a percentage of operating time	99.99 %

Pound Per Event Report

CT2 - NOx Lbs



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/06/2020 09:40 **Location:** Maxwell, CA

Tag Name: CT2_NOX_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,844.57 Hours
 Non-Operating Time: 363.43 Hours **Report Time:** 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary

1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	6
2. Total CMS Downtime in Minute(s)	6
3. Total Downtime as a percentage of operating time	0.01
4. Total Availability as a percentage of operating time	99.99

CT1 Process Event Report

CT1 Cold and Hot Startup Events



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:40 **Location:** Maxwell, CA

Unit Offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
07/01/2020 00:00	07/03/2020 12:00	61
07/04/2020 00:00	07/05/2020 13:00	38
07/05/2020 23:00	07/06/2020 10:00	12
09/12/2020 00:00	09/14/2020 12:00	61
09/15/2020 23:00	09/16/2020 05:00	7
09/18/2020 01:00	09/18/2020 05:00	5
09/18/2020 23:00	09/19/2020 03:00	5
09/20/2020 07:00	09/20/2020 09:00	3
09/20/2020 23:00	09/21/2020 12:00	14
09/21/2020 23:00	09/22/2020 13:00	15
09/22/2020 22:00	09/23/2020 12:00	15
09/23/2020 22:00	09/24/2020 07:00	10
09/24/2020 21:00	09/27/2020 07:00	59
09/27/2020 09:00	09/27/2020 12:00	4
09/27/2020 23:00	09/28/2020 05:00	7
09/28/2020 23:00	09/29/2020 05:00	7

CT1 Process Event Report

CT1 Cold and Hot Startup Events



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:40 **Location:** Maxwell, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	323.00 Hour(s)
Offline Percentage:	14.63 %
Total Online:	1,885.00 Hour(s)
Online Percentage:	85.37 %

CT1 Process Event Report

CT1 Cold and Hot Startup Events



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:40 **Location:** Maxwell, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	07/03/2020 13:00	07/03/2020 14:00	Warm Startup	2
2	07/05/2020 14:00	07/05/2020 15:00	Warm Startup	2
3	07/06/2020 11:00	07/06/2020 12:00	Warm Startup	2
4	09/14/2020 13:00	09/14/2020 15:00	Warm Startup	3
5	09/16/2020 06:00	09/16/2020 07:00	Warm Startup	2
6	09/18/2020 06:00	09/18/2020 07:00	Hot Startup	2
7	09/19/2020 04:00	09/19/2020 05:00	Hot Startup	2
8	09/20/2020 10:00	09/20/2020 11:00	Hot Startup	2
9	09/21/2020 13:00	09/21/2020 14:00	Warm Startup	2
10	09/22/2020 14:00	09/22/2020 15:00	Warm Startup	2
11	09/23/2020 13:00	09/23/2020 14:00	Warm Startup	2
12	09/24/2020 08:00	09/24/2020 10:00	Warm Startup	3
13	09/27/2020 08:00	09/27/2020 08:00	Warm Startup	1
14	09/27/2020 13:00	09/27/2020 15:00	Warm Startup	3
15	09/28/2020 06:00	09/28/2020 07:00	Warm Startup	2
16	09/29/2020 06:00	09/29/2020 07:00	Warm Startup	2

CT1 Process Event Report

CT1 Cold and Hot Startup Events



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:40 **Location:** Maxwell, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	0		0.00
Hot Startup/Startup Shutdown Event Text 02 Add	3	6	0.32
Warm Startup	13	28	1.49
Total Process Events:	16	34	1.8

Total Report Time: 2,208 Hour(s)
Total Operating Time: 1,885 Hour(s)
Total Startup Time: 34 Hour(s)
Total Shutdown Time: 0 Hour(s)
Total Startup/Shutdown Time: 34 Hour(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time: 1.80 %

CT2 Process Event Report

CT2 Cold and Hot Startup Events



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 10/06/2020 09:40 Location: Maxwell, CA

Unit Offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
07/01/2020 00:00	07/03/2020 07:00	56
07/04/2020 00:00	07/05/2020 08:00	33
07/05/2020 23:00	07/06/2020 01:00	3
07/24/2020 08:00	07/25/2020 12:00	29
09/02/2020 08:00	09/03/2020 02:00	19
09/12/2020 00:00	09/12/2020 16:00	17
09/13/2020 03:00	09/13/2020 16:00	14
09/14/2020 03:00	09/14/2020 08:00	6
09/15/2020 23:00	09/16/2020 10:00	12
09/18/2020 01:00	09/18/2020 09:00	9
09/18/2020 23:00	09/19/2020 12:00	14
09/20/2020 07:00	09/20/2020 13:00	7
09/20/2020 23:00	09/21/2020 07:00	9
09/21/2020 23:00	09/22/2020 07:00	9
09/22/2020 22:00	09/23/2020 07:00	10
09/23/2020 22:00	09/24/2020 12:00	15
09/24/2020 21:00	09/27/2020 07:00	59
09/27/2020 23:00	09/28/2020 09:00	11
09/28/2020 23:00	09/29/2020 09:00	11

CT2 Process Event Report

CT2 Cold and Hot Startup Events



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:40 **Location:** Maxwell, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	343.00 Hour(s)
Offline Percentage:	15.53 %
Total Online:	1,865.00 Hour(s)
Online Percentage:	84.47 %

CT2 Process Event Report

CT2 Cold and Hot Startup Events



From: 07/01/2020 00:00 To: 09/30/2020 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 10/06/2020 09:40 Location: Maxwell, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	07/03/2020 08:00	07/03/2020 10:00	Warm startup	3
2	07/05/2020 09:00	07/05/2020 11:00	Warm startup	3
3	07/06/2020 02:00	07/06/2020 03:00	Hot Startup	2
4	07/25/2020 13:00	07/25/2020 14:00	Warm startup	2
5	09/03/2020 03:00	09/03/2020 04:00	Warm startup	2
6	09/12/2020 17:00	09/12/2020 19:00	Warm startup	3
7	09/13/2020 17:00	09/13/2020 19:00	Warm startup	3
8	09/14/2020 09:00	09/14/2020 11:00	Hot Startup	3
9	09/16/2020 11:00	09/16/2020 12:00	Warm startup	2
10	09/18/2020 10:00	09/18/2020 11:00	Warm startup	2
11	09/19/2020 13:00	09/19/2020 14:00	Warm startup	2
12	09/20/2020 14:00	09/20/2020 15:00	Warm startup	2
13	09/21/2020 08:00	09/21/2020 10:00	Warm startup	3
14	09/22/2020 08:00	09/22/2020 10:00	Warm startup	3
15	09/23/2020 08:00	09/23/2020 10:00	Warm startup	3
16	09/24/2020 13:00	09/24/2020 14:00	Warm startup	2
17	09/27/2020 08:00	09/27/2020 10:00	Warm startup	3
18	09/28/2020 10:00	09/28/2020 11:00	Warm startup	2
19	09/29/2020 10:00	09/29/2020 11:00	Warm startup	2

CT2 Process Event Report

CT2 Cold and Hot Startup Events



From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/06/2020 09:40 **Location:** Maxwell, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	0		0.00
Hot Startup	2	5	0.27
Warm startup	17	42	2.25
Total Process Events:	19	47	2.52

Total Report Time: 2,208 Hour(s)
Total Operating Time: 1,865 Hour(s)
Total Startup Time: 47 Hour(s)
Total Shutdown Time: 0 Hour(s)
Total Startup/Shutdown Time: 47 Hour(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time: 2.52 %

ATTACHMENT 13
Water Bath Heater Operations
FCD: AQ-17
Title V: #6

The Natural Gas Fired Water Bath Heater did not operate in the 3rd Quarter of 2020.

ATTACHMENT 14
Certification Report

FCD: AQ-22
Title V: #13

CERTIFICATION REPORT (FORM 3.17-K1)

DISTRICT: Colusa County Air Pollution Control District	► DISTRICT USE ONLY ◀ DISTRICT ID:
COMPANY NAME: Pacific Gas and Electric	FACILITY NAME: Colusa Generating Station

I. FACILITY INFORMATION

1. Company Name: Pacific Gas and Electric
2. Facility Name (if different than Company Name): Colusa Generating Station
3. Mailing Address: 4780 Dirks Rd , Maxwell CA 95955
4. Street Address or Source Location: Same
5. Facility Permit Number: 21006-0259

II. GENERAL INFORMATION

1. Reporting period (specify dates): July 1 - September 30, 2020
2. Due date for submittal of report: October 30, 2020
3. Type of submittal: Monitoring Report (complete Section III below)
 Compliance Schedule Progress Report (complete Section IV of Form 3.17-K2)
 Compliance Certification (complete Section V of Form 3.17-K2)

III. MONITORING REPORT INFORMATION

1. Were deviations from monitoring requirements encountered during the reporting period? No Yes (If Yes, complete Form 3.17-L)