

DOCKETED

Docket Number:	20-SPPE-01
Project Title:	Great Oaks South Backup Generating Facility Small Power Plant Exemption
TN #:	235818
Document Title:	Agenda for Continued Public Scoping Meeting
Description:	For the Great Oaks South Backup Generating Facility
Filer:	Lisa Worrall
Organization:	California Energy Commission
Submitter Role:	Commission Staff
Submission Date:	12/1/2020 10:21:39 AM
Docketed Date:	12/1/2020

Agenda

Great Oaks South Backup Generating Facility Continued Public Scoping Meeting

Held Remotely via Zoom – 11:00 a.m. to 3:00 p.m. December 11, 2020

Remote participation

Participants may join by clicking on the links below. The meeting may also be accessed at: <https://zoom.us/join> by entering the unique Meeting ID and password for each session listed below. To participate by telephone, see instructions below.

Panel Session: Great Oaks South Public Meeting

<https://energy.zoom.us/j/97756743271?pwd=UDFuZlp6Zjl2VTdzeXIWRWNwcmRqdz09>.

Meeting ID: 977 5674 3271.

Password: 636115.

*To Participate by Telephone Only: Dial 1-877-853-5257 (toll free) or 1-669-219-2599. When prompted, enter the unique Meeting ID for the session. To comment, dial *9 to "raise your hand" and *6 to mute/unmute your phone line.*

Zoom: If you experience difficulties, you may contact Zoom at 1-888-799-9666 ext. 2, or the Public Advisor's Office via email or phone.

You may also see TN 235814, Notice of Continued Public Scoping Meeting, for instructions on how to join the meeting via Zoom.

Agenda

Great Oaks South Backup Generating Facility Continued Public Scoping Meeting

Held Remotely via Zoom – 11:00 a.m. to 3:00 p.m. December 11, 2020

1. Introductions (approximately 5 minutes)
2. Discussion of remaining technical areas with potential significant impacts before mitigation. Public questions and comments follow each technical discussion topic.
 - a. Air Quality (including public health)
 - i. Use of NOx offsets when Determining Significance of Impacts
 - b. Greenhouse Gas Emissions
 - i. Routine maintenance and testing: whether BAAQMD's current threshold of significance or a new threshold should apply, any options available if mitigation is determined to be necessary.
 - ii. Electricity use: whether participation in City of San Jose's 100 percent clean energy program is required to avoid potential significant GHG impact.
 - iii. Emergency Operations: Based on the emergency operation scenarios provided in Air Quality section of the EIR, estimate the annual GHG emissions and describe mitigation measures.
 - c. Alternatives
 - i. Project objectives/reliability needs - Applicant
 - ii. In addition to the no project alternative, the EIR will consider fuel cell technology, battery storage, biodiesel fuel, renewable diesel fuel, Tier 4 emissions controls, natural gas engines, and an alternative site location. Discuss and receive comments on the scope of the alternative analysis.
3. Additional Questions and Comments (as time allows)
4. Adjourn meeting (by 3:00 p.m.)