

**DOCKETED**

<b>Docket Number:</b>	20-RENEW-01
<b>Project Title:</b>	School Energy Efficiency Stimulus Program
<b>TN #:</b>	236628
<b>Document Title:</b>	Theresa Pistochni Comments - Filtration Methods
<b>Description:</b>	N/A
<b>Filer:</b>	System
<b>Organization:</b>	Theresa Pistochni
<b>Submitter Role:</b>	Public
<b>Submission Date:</b>	2/4/2021 11:49:14 AM
<b>Docketed Date:</b>	2/4/2021

*Comment Received From: Theresa Pistochini*  
*Submitted On: 2/4/2021*  
*Docket Number: 20-RENEW-01*

## **Filtration Methods**

Dear California Energy Commission,

In the public meeting on this program, a comment was made as to whether portable air-cleaning devices would be considered under this program. I wanted to provide my opinion that central filtration with MERV13 or better is generally a more cost-effective, energy-efficient, quieter, and robust method to achieve filtration goals. I recommend that CEC still with the original intent of the legislation, which was to improve mechanical filtration in central air handling systems.