DOCKETED	
Docket Number:	20-RENEW-01
Project Title:	School Energy Efficiency Stimulus Program
TN #:	236690
Document Title:	Nicholas Maderas Comments - SVREVR Classroom Assessment, Monitoring and Verification
Description:	N/A
Filer:	System
Organization:	Nicholas Maderas
Submitter Role:	Public
Submission Date:	2/5/2021 11:50:54 PM
Docketed Date:	2/8/2021

Comment Received From: Nicholas Maderas

Submitted On: 2/5/2021

Docket Number: 20-RENEW-01

SVREVR Classroom Assessment, Monitoring and Verification

- 1. Sound level maximum of 45 dBA
- 2. co2 level display visible with audible alerting
- 3. Outside air minimum 0.38 CFM PSF
- 4. Merv-13 Air Filtration to achieve CADR ACH 5 per Alameda County guidelines
- 5. Max occupancy posted at entry door (calculated at 15 cfm of filtered outside air per person)
- 6. Exhaust system capable of maintaining neutral pressure