

DOCKETED

Docket Number:	21-BSTD-01
Project Title:	2022 Energy Code Update Rulemaking
TN #:	238300
Document Title:	QTS Data Centers - Alan French Comments - Agree with the Proposed Changes, As Is
Description:	N/A
Filer:	System
Organization:	QTS Data Centers - Alan French
Submitter Role:	Public
Submission Date:	6/19/2021 8:46:48 AM
Docketed Date:	6/19/2021

Comment Received From: QTS Data Centers - Alan French
Submitted On: 6/19/2021
Docket Number: 21-BSTD-01

Agree with the Proposed Changes, As Is

QTS agrees with the proposed changes that are under public review as is. We especially like that it raises economizer requirements from 40F to 50F. QTS would also like to stress the value of using a refrigerant based economizer over a water economizer, as using no water and will assist the emergency drought situation in California. - thanks much, Alan French, VP Engineering, QTS Data Centers